

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	248599
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2022
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	1/30/2023 10:11:46 AM
Docketed Date:	1/30/2023



Roseville Electric Utility
2090 Hilltop Circle
Roseville, California 95747-9704
Reliable Energy. Dependable Service.

City of Roseville

Roseville Energy Park

(03-AFC-1)

California Energy Commission

Quarterly Operational Report

Fourth Quarter 2022

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly SOx AQ-SC6

AQ34 – Startups and Shutdowns

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12-month summary

AQ47 – All nuisance violations

N/A for this report period

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOx, PM-10, SOx, and VOC

AQ59 – Emission limit exceedances – NOx, CO, VOC, PM-10, SO₂

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PM₁₀, SOx

AQ63 – Total facility emission exceedances – NOx, CO, VOC, PM-10, SO₂

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

N/A for this report period

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – $\text{PM-10} = \text{cooling water recirculation rate} \times \text{total dissolved solids concentration in the blow down water} \times \text{design drift rate}$

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

N/A for this report period

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period

ATTACHMENT 1

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

ATTACHMENT 2

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6



California Gas Transmission

Pipe Ranger

[Go](#)[Log in](#)[About CGT](#)[Products](#)[Tools & Services](#)[Operating Data](#)[Reference/Library](#)[Current Pipeline Status](#)[Forecasts](#)[Historical Archives](#)[Gas Quality/Heating Values](#)

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2022				
Third Quarter	4.2	0.25	0.8	0.05
Second Quarter	5.0	0.30	0.9	0.06
First Quarter	4.8	0.28	1.1	0.07

AQ20 ROSEVILLE ENERGY PARK

4Q22

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	OCT	NOV	DEC
1	1042.31	1044.59	1051.85
2	1046.06	1045.83	1052.09
3	1045.49	1040.49	1052.62
4	1041.56	1045.84	1050.56
5	1040.05	1051.42	1050.99
6	1042.10	1053.41	1051.99
7	1041.01	1054.43	1052.13
8	1041.76	1052.52	1051.91
9	1042.26	1045.69	1052.98
10	1042.58	1046.56	1050.27
11	1040.18	1049.81	1050.52
12	1037.77	1050.56	1050.23
13	1039.50	1,054.05	1049.65
14	1038.28	1052.89	1049.72
15	1035.89	1051.16	1049.02
16	1038.02	1051.62	1049.02
17	1034.62	1050.75	1047.71
18	1041.34	1050.56	1049.45
19	1041.67	1050.47	1049.70
20	1040.63	1050.39	1048.18
21	1041.06	1050.96	1049.84
22	1042.74	1049.59	1050.78
23	1039.29	1048.74	1049.30
24	1039.24	1048.37	1049.63
25	1039.94	1048.27	1053.67
26	1040.38	1048.42	1060.68
27	1042.19	1049.39	1062.17
28	1035.85	1049.24	1060.96
29	1036.23	1051.21	1060.57
30	1039.16	1053.81	1059.88
31	1045.12	N/A	1052.25

odeline/operations/gas_quality/p01_2_weeks.shtml

ATTACHMENT 3

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/19/2022 09:00	10/19/2022 15:00	7
12/06/2022 02:00	12/06/2022 14:00	13
12/28/2022 01:00	12/31/2022 23:00	95

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	115.00 Hour(s)
Offline Percentage:	5.21 %
Total Online:	2,093.00 Hour(s)
Online Percentage:	94.79 %

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/19/2022 08:29	10/19/2022 08:36	Shutdown	8
2	10/19/2022 16:09	10/19/2022 16:51	cold Startup	43
3	12/06/2022 00:54	12/06/2022 01:01	Shutdown	8
4	12/06/2022 15:09	12/06/2022 16:23	cold Startup	75
5	12/27/2022 23:54	12/28/2022 00:00	Shutdown	7

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	118	0.09
Warm Startup	0		0.00
Shutdown	3	23	0.02
Total Process Events:	5	141	0.11

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,090.37 Hour(s)
Total Startup Time:	118 Minute(s)
Total Shutdown Time:	23 Minute(s)
Total Startup/Shutdown Time:	141 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.11 %

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/09/2022 00:00	10/18/2022 13:00	230
11/08/2022 01:00	11/09/2022 19:00	43
11/29/2022 08:00	11/29/2022 10:00	3
12/03/2022 19:00	12/05/2022 16:00	46
12/12/2022 16:00	12/17/2022 02:00	107
12/31/2022 11:00	12/31/2022 13:00	3

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	432.00 Hour(s)
Offline Percentage:	19.57 %
Total Online:	1,776.00 Hour(s)
Online Percentage:	80.43 %

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/08/2022 22:53	10/08/2022 23:00	Shutdown	8
2	10/18/2022 14:54	10/18/2022 15:43	cold Startup	50
3	11/07/2022 23:53	11/08/2022 00:01	Shutdown	9
4	11/09/2022 20:31	11/09/2022 21:31	cold Startup	61
5	11/29/2022 07:20	11/29/2022 07:20	Shutdown	1
6	11/29/2022 11:50	11/29/2022 12:33	cold Startup	44
7	12/03/2022 17:55	12/03/2022 18:02	Shutdown	8
8	12/05/2022 17:06	12/05/2022 18:32	cold Startup	87
9	12/12/2022 14:53	12/12/2022 15:00	Shutdown	8
10	12/17/2022 03:05	12/17/2022 03:57	cold Startup	53
11	12/31/2022 09:55	12/31/2022 10:06	Shutdown	12
12	12/31/2022 14:25	12/31/2022 15:21	cold Startup	57

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	6	352	0.33
Warm Startup	0		0.00
Shutdown	6	46	0.04
Total Process Events:	12	398	0.38

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,767.73 Hour(s)
Total Startup Time:	352 Minute(s)
Total Shutdown Time:	46 Minute(s)
Total Startup/Shutdown Time:	398 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.38 %

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2022	23.99	94.97	10.63	21.25	35.40
10/02/2022	38.90	110.10	11.54	23.10	38.51
10/03/2022	48.06	113.38	13.02	26.00	43.38
10/04/2022	85.68	137.90	15.11	30.20	50.34
10/05/2022	68.63	141.28	15.16	30.31	50.56
10/06/2022	52.28	125.69	13.62	27.26	45.42
10/07/2022	71.36	141.34	15.29	30.58	51.00
10/08/2022	73.95	123.81	13.30	26.62	44.33
10/09/2022	35.57	64.88	6.96	13.96	23.26
10/10/2022	27.67	59.52	6.55	13.14	21.90
10/11/2022	17.92	47.24	5.17	10.36	17.25
10/12/2022	15.66	46.66	5.01	10.22	16.98
10/13/2022	16.66	47.21	5.17	10.48	17.41
10/14/2022	26.11	54.89	5.95	11.99	19.93
10/15/2022	15.42	45.23	4.92	9.95	16.56
10/16/2022	27.92	53.05	5.80	11.75	19.52
10/17/2022	32.37	63.74	6.95	13.90	23.19
10/18/2022	50.34	102.68	10.26	20.59	34.26
10/19/2022	75.01	97.70	10.21	20.36	33.92
10/20/2022	29.13	103.49	11.33	22.70	37.88
10/21/2022	32.32	102.93	11.32	22.61	37.71
10/22/2022	34.84	134.28	14.55	29.09	48.52
10/23/2022	40.33	124.08	13.31	26.65	44.41
10/24/2022	46.76	124.44	13.56	27.05	45.09
10/25/2022	37.75	117.15	12.77	25.54	42.60
10/26/2022	32.94	101.99	11.27	22.50	37.52
10/27/2022	48.24	115.96	12.65	25.26	42.06
10/28/2022	50.59	134.17	14.50	29.00	48.37
10/29/2022	37.35	106.67	11.50	23.03	38.37
10/30/2022	35.20	105.48	11.44	22.91	38.15
10/31/2022	38.22	104.11	11.54	23.12	38.52
Monthly Avg/Sum*:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
Daily Min:	15.42	45.23	4.92	9.95	16.56
Daily Max:	85.68	141.34	15.29	30.58	51.00
Oct 2022 - Oct 2022	1,267.17	3,046.02	330.36	661.48	1,102.32
QTD:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
YTD 2022:	11,980.84 *	22,223.38 *	2,278.01 *	4,557.33 *	7,596.69 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2022	57.32	144.53	15.65	31.30	52.21
11/02/2022	49.02	125.51	13.60	27.18	45.35
11/03/2022	46.77	129.29	13.99	28.00	46.67
11/04/2022	36.74	107.04	11.51	23.00	38.38
11/05/2022	30.29	94.08	10.08	20.19	33.62
11/06/2022	44.82	122.08	12.51	25.03	41.71
11/07/2022	44.12	113.74	12.13	24.26	40.41
11/08/2022	36.05	59.15	6.32	12.68	21.10
11/09/2022	54.79	69.43	6.44	12.98	21.63
11/10/2022	40.54	113.02	12.35	24.68	41.12
11/11/2022	47.96	124.31	13.53	27.04	45.02
11/12/2022	56.08	145.56	15.78	31.54	52.56
11/13/2022	47.82	135.29	14.62	29.21	48.70
11/14/2022	46.53	140.29	15.22	30.37	50.66
11/15/2022	43.33	137.03	14.91	29.79	49.69
11/16/2022	51.07	132.38	14.47	28.97	48.27
11/17/2022	53.64	137.91	14.98	29.86	49.78
11/18/2022	48.88	156.10	16.93	33.86	56.43
11/19/2022	44.93	131.37	14.24	28.54	47.54
11/20/2022	61.24	145.00	15.75	31.49	52.52
11/21/2022	57.81	130.39	14.27	28.52	47.52
11/22/2022	57.43	130.21	14.11	28.17	46.92
11/23/2022	52.86	118.68	12.97	25.94	43.25
11/24/2022	65.70	134.77	14.70	29.37	48.96
11/25/2022	63.23	124.07	13.44	26.84	44.75
11/26/2022	61.11	131.31	14.16	28.31	47.24
11/27/2022	56.41	122.51	13.40	26.77	44.62
11/28/2022	63.30	126.35	13.69	27.33	45.56
11/29/2022	86.13	134.44	14.09	28.13	46.91
11/30/2022	43.45	121.76	13.26	26.60	44.32
Monthly Avg/Sum*:	1,549.37 *	3,737.60 *	403.10 *	805.95 *	1,343.42 *
Daily Min:	30.29	59.15	6.32	12.68	21.10
Daily Max:	86.13	156.10	16.93	33.86	56.43
Oct 2022 - Nov 2022	2,816.54	6,783.62	733.46	1,467.43	2,445.74
QTD:	2,816.54 *	6,783.62 *	733.46 *	1,467.43 *	2,445.74 *
YTD 2022:	13,530.21 *	25,960.98 *	2,681.11 *	5,363.28 *	8,940.11 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2022	49.73	141.71	15.37	30.74	51.19
12/02/2022	48.73	154.05	16.60	33.22	55.38
12/03/2022	57.60	133.32	13.90	27.82	46.34
12/04/2022	26.90	65.43	7.03	14.04	23.40
12/05/2022	46.29	90.20	7.88	15.75	26.25
12/06/2022	74.57	90.63	8.75	17.46	29.10
12/07/2022	54.58	134.25	14.54	29.13	48.53
12/08/2022	47.82	150.29	16.33	32.68	54.45
12/09/2022	44.57	126.83	13.77	27.58	46.00
12/10/2022	43.22	125.54	13.72	27.39	45.70
12/11/2022	36.11	105.16	11.50	23.02	38.32
12/12/2022	49.17	85.18	10.04	20.07	33.42
12/13/2022	32.01	61.34	6.71	13.43	22.38
12/14/2022	20.94	59.61	6.44	12.85	21.41
12/15/2022	18.28	64.78	6.96	13.83	23.04
12/16/2022	9.74	39.11	4.25	8.60	14.25
12/17/2022	74.10	121.27	12.22	24.43	40.71
12/18/2022	51.25	130.58	14.25	28.53	47.60
12/19/2022	46.53	159.43	17.31	34.70	57.76
12/20/2022	52.81	126.80	13.75	27.47	45.84
12/21/2022	71.80	146.39	15.88	31.75	52.92
12/22/2022	63.04	142.01	15.40	30.71	51.24
12/23/2022	66.86	141.94	15.41	30.80	51.36
12/24/2022	56.07	125.48	13.57	27.05	45.10
12/25/2022	27.43	84.27	9.30	18.56	30.95
12/26/2022	44.99	110.59	12.10	24.18	40.31
12/27/2022	21.27	77.21	8.44	16.80	28.06
12/28/2022	17.92	40.81	4.57	8.93	14.95
12/29/2022	9.78	40.71	4.54	8.88	14.87
12/30/2022	8.88	40.65	4.40	8.92	14.79
12/31/2022	72.44	42.70	3.74	7.53	12.53
Monthly Avg/Sum*:	1,345.43 *	3,158.27 *	338.67 *	676.85 *	1,128.15 *
Daily Min:	8.88	39.11	3.74	7.53	12.53
Daily Max:	74.57	159.43	17.31	34.70	57.76
Oct 2022 - Dec 2022	4,161.97	9,941.89	1,072.13	2,144.28	3,573.89
QTD:	4,161.97 *	9,941.89 *	1,072.13 *	2,144.28 *	3,573.89 *
YTD 2022:	14,875.64 *	29,119.25 *	3,019.78 *	6,040.13 *	10,068.26 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	0.0	0.0	0.0	0.0
10/02/2022	0.0	0.0	0.0	0.0
10/03/2022	0.0	0.0	0.0	0.0
10/04/2022	0.0	0.0	0.0	0.0
10/05/2022	0.0	0.0	0.0	0.0
10/06/2022	0.0	0.0	0.0	0.0
10/07/2022	0.0	0.0	0.0	0.0
10/08/2022	0.0	0.0	10.5	1.1
10/09/2022	0.0	0.0	0.0	0.0
10/10/2022	0.0	0.0	0.0	0.0
10/11/2022	0.0	0.0	0.0	0.0
10/12/2022	0.0	0.0	0.0	0.0
10/13/2022	0.0	0.0	0.0	0.0
10/14/2022	0.0	0.0	0.0	0.0
10/15/2022	0.0	0.0	0.0	0.0
10/16/2022	0.0	0.0	0.0	0.0
10/17/2022	0.0	0.0	0.0	0.0
10/18/2022	0.0	0.0	18.9	11.3
10/19/2022	44.8	5.9	0.0	0.0
10/20/2022	0.0	0.0	0.0	0.0
10/21/2022	0.0	0.0	0.0	0.0
10/22/2022	0.0	0.0	0.0	0.0
10/23/2022	0.0	0.0	0.0	0.0
10/24/2022	0.0	0.0	0.0	0.0
10/25/2022	0.0	0.0	0.0	0.0
10/26/2022	0.0	0.0	0.0	0.0
10/27/2022	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0
10/30/2022	0.0	0.0	0.0	0.0
10/31/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	44.8 *	5.9 *	29.4 *	12.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	44.8	5.9	18.9	11.3
Oct 2022 - Oct 2022	44.8	5.9	29.4	12.4
QTD:	44.8 *	5.9 *	29.4 *	12.4 *
YTD 2022:	1,997.1 *	326.1 *	2,270.4 *	512.4 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	0.0	0.0	0.0	0.0
11/02/2022	0.0	0.0	0.0	0.0
11/03/2022	0.0	0.0	0.0	0.0
11/04/2022	0.0	0.0	0.0	0.0
11/05/2022	0.0	0.0	0.0	0.0
11/06/2022	0.0	0.0	0.0	0.0
11/07/2022	0.0	0.0	2.9	0.6
11/08/2022	0.0	0.0	8.7	0.3
11/09/2022	0.0	0.0	27.7	12.3
11/10/2022	0.0	0.0	0.0	0.0
11/11/2022	0.0	0.0	0.0	0.0
11/12/2022	0.0	0.0	0.0	0.0
11/13/2022	0.0	0.0	0.0	0.0
11/14/2022	0.0	0.0	0.0	0.0
11/15/2022	0.0	0.0	0.0	0.0
11/16/2022	0.0	0.0	0.0	0.0
11/17/2022	0.0	0.0	0.0	0.0
11/18/2022	0.0	0.0	0.0	0.0
11/19/2022	0.0	0.0	0.0	0.0
11/20/2022	0.0	0.0	0.0	0.0
11/21/2022	0.0	0.0	0.0	0.0
11/22/2022	0.0	0.0	0.0	0.0
11/23/2022	0.0	0.0	0.0	0.0
11/24/2022	0.0	0.0	0.0	0.0
11/25/2022	0.0	0.0	0.0	0.0
11/26/2022	0.0	0.0	0.0	0.0
11/27/2022	0.0	0.0	0.0	0.0
11/28/2022	0.0	0.0	0.0	0.0
11/29/2022	0.0	0.0	44.2	8.9
11/30/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	83.5 *	22.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	44.2	12.3
Oct 2022 - Nov 2022	44.8	5.9	112.9	34.5
QTD:	44.8 *	5.9 *	112.9 *	34.5 *
YTD 2022:	1,997.1 *	326.1 *	2,353.9 *	534.5 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	0.0	0.0	0.0	0.0
12/02/2022	0.0	0.0	0.0	0.0
12/03/2022	0.0	0.0	11.6	2.9
12/04/2022	0.0	0.0	0.0	0.0
12/05/2022	0.0	0.0	24.2	21.6
12/06/2022	48.2	12.8	0.0	0.0
12/07/2022	0.0	0.0	0.0	0.0
12/08/2022	0.0	0.0	0.0	0.0
12/09/2022	0.0	0.0	0.0	0.0
12/10/2022	0.0	0.0	0.0	0.0
12/11/2022	0.0	0.0	0.0	0.0
12/12/2022	0.0	0.0	11.9	0.7
12/13/2022	0.0	0.0	0.0	0.0
12/14/2022	0.0	0.0	0.0	0.0
12/15/2022	0.0	0.0	0.0	0.0
12/16/2022	0.0	0.0	0.0	0.0
12/17/2022	0.0	0.0	28.1	9.8
12/18/2022	0.0	0.0	0.0	0.0
12/19/2022	0.0	0.0	0.0	0.0
12/20/2022	0.0	0.0	0.0	0.0
12/21/2022	0.0	0.0	0.0	0.0
12/22/2022	0.0	0.0	0.0	0.0
12/23/2022	0.0	0.0	0.0	0.0
12/24/2022	0.0	0.0	0.0	0.0
12/25/2022	0.0	0.0	0.0	0.0
12/26/2022	0.0	0.0	0.0	0.0
12/27/2022	3.0	0.5	0.0	0.0
12/28/2022	6.4	0.1	0.0	0.0
12/29/2022	0.0	0.0	0.0	0.0
12/30/2022	0.0	0.0	0.0	0.0
12/31/2022	0.0	0.0	62.2	11.1
Monthly Avg/Sum*:	57.6 *	13.4 *	138.0 *	46.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	48.2	12.8	62.2	21.6
Oct 2022 - Dec 2022	102.4	19.3	250.9	80.6
QTD:	102.4 *	19.3 *	250.9 *	80.6 *
YTD 2022:	2,054.7 *	339.5 *	2,491.9 *	580.6 *

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 8:24	264395.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:25	264626.9			0.6			1.5			0.35			1.54			0		
10/19/22 8:26	264087.8			0.6			1.5			0.35			1.54			0		
10/19/22 8:27	264395.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:28	264087.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:29	264318.8			0.5			1.5			0.29			1.54			1		
10/19/22 8:30	252381.3			0.5			1.5			0.28			1.47			1		
10/19/22 8:31	229507.6			0.5			2.09			0.26			1.87			1		
10/19/22 8:32	207096			0.4			6.82			0.2			5.49			1		
10/19/22 8:33	182681.9			1.9			10.02			0.82			7.12			1		
10/19/22 8:34	161810.6			109			12.06			41.71			7.59			1		
10/19/22 8:35	144559			718.4			13.67			245.55			7.69			1		
10/19/22 8:36	67466			1675.1			14.75			266.98			3.87			1		
10/19/22 8:37	19716.1			0			17.7			113.4			1.36			0		
10/19/22 8:38	20255.2			0			2.95			60.77			0.23			0		
10/19/22 8:39	20486.2			0			2.95			5.71			0.23			0		
10/19/22 8:40	20948.3			0			2.95			3.79			0.24			0		
10/19/22 8:41	20871.3			0			2.95			3.63			0.24			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 16:04	36736.6			0			0			0			0			0		
10/19/22 16:05	36813.6			0			0			0			0			0		
10/19/22 16:06	36890.7			0			0			0			0			0		
10/19/22 16:07	36736.6			0			0			0			0			0		
10/19/22 16:08	36813.6			0			0			0			0			0		
10/19/22 16:09	39509.2			-5.9			0			-0.55			0			1		
10/19/22 16:10	43206			0			0			0			0			1		
10/19/22 16:11	50907.6			30.5			4.92			3.67			0.97			1		
10/19/22 16:12	59764.4			699.3			4.16			98.78			0.97			1		
10/19/22 16:13	69545.4			430.7			6.79			70.77			1.83			1		
10/19/22 16:14	85872.8			200.3			8.85			40.67			2.96			1		
10/19/22 16:15	125073.9			128.1			11.8			37.87			5.74			1		
10/19/22 16:16	141632.4			85.1			16.01			28.51			8.83			1		
10/19/22 16:17	149796.1			339.9			23.24			120.36			13.55			1		
10/19/22 16:18	164891.2			1803			22.04			702.65			14.13			1		
10/19/22 16:19	185608.5			1153.4			24.72			506.03			17.85			1		
10/19/22 16:20	209329.4			230.8			26.97			114.23			21.97			1		
10/19/22 16:21	230046.7			20.4			29.38			11.09			26.29			1		
10/19/22 16:22	253228.5			1.9			31.28			1.13			30.81			1		
10/19/22 16:23	277642.6			1.3			23.4			0.85			25.28			1		
10/19/22 16:24	297743.8			1.2			11.16			0.83			12.93			1		
10/19/22 16:25	306677.6			1.2			7.84			0.89			9.35			1		
10/19/22 16:26	308834.1			1.3			7.04			0.96			8.46			1		
10/19/22 16:27	309681.2			1.2			6.16			0.9			7.43			1		
10/19/22 16:28	309835.3			1.1			5.9			0.77			7.11			1		
10/19/22 16:29	309373.2			1			5.64			0.7			6.79			1		
10/19/22 16:30	307986.9			1			5.47			0.69			6.55			1		
10/19/22 16:31	306061.5			0.9			5.28			0.64			6.29			1		
10/19/22 16:32	303365.9			0.8			5.02			0.57			5.92			1		
10/19/22 16:33	302903.8			0.8			4.76			0.57			5.6			1		
10/19/22 16:34	301902.6			0.7			4.58			0.5			5.38			1		
10/19/22 16:35	302056.7			0.7			4.56			0.51			5.36			1		
10/19/22 16:36	295818.3			0.7			4.56			0.5			5.25			1		
10/19/22 16:37	278412.8			0.7			4.56			0.47			4.94			1		
10/19/22 16:38	273560.7			0.6			5.17			0.41			5.51			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 16:39	270942.2			0.6			6.08			0.35			6.41			1		
10/19/22 16:40	267861.6			0.5			4.96			0.3			5.17			1		
10/19/22 16:41	267784.5			0.5			3.75			0.3			3.9			1		
10/19/22 16:42	266937.4			0.5			3.28			0.3			3.4			1		
10/19/22 16:43	267707.5			0.5			3.14			0.3			3.27			1		
10/19/22 16:44	267014.4			0.4			2.85			0.24			2.97			1		
10/19/22 16:45	266706.3			0.4			2.66			0.24			2.76			1		
10/19/22 16:46	266706.3			0.4			2.38			0.24			2.47			1		
10/19/22 16:47	266244.2			0.4			2.28			0.24			2.37			1		
10/19/22 16:48	266783.3			0.4			2.09			0.24			2.17			1		
10/19/22 16:49	266244.2			0.4			1.9			0.24			1.97			1		
10/19/22 16:50	266167.2			0.4			1.81			0.24			1.87			1		
10/19/22 16:51	266167.2			0.4			1.71			0.24			1.77			1		
10/19/22 16:52	266398.3			0.4			1.62			0.24			1.68			0		
10/19/22 16:53	266244.2			0.4			1.52			0.24			1.58			0		
10/19/22 16:54	265859.1			0.4			1.43			0.24			1.48			0		
10/19/22 16:55	265859.1			0.4			1.43			0.24			1.48			0		
10/19/22 16:56	265628.1			0.4			1.33			0.24			1.38			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 0:49	271481.3			0.6			1.43			0.4			1.5			0		
12/06/22 0:50	266167.2			0.6			1.54			0.4			1.59			0		
12/06/22 0:51	268708.7			0.6			2.25			0.35			2.34			0		
12/06/22 0:52	271173.3			0.5			2.15			0.3			2.26			0		
12/06/22 0:53	271789.4			0.5			1.66			0.29			1.74			0		
12/06/22 0:54	267245.4			0.5			1.38			0.29			1.43			1		
12/06/22 0:55	245526.9			0.5			1.29			0.27			1.23			1		
12/06/22 0:56	224655.6			0.5			3.29			0.26			2.86			1		
12/06/22 0:57	199625.4			0.3			8.74			0.15			6.75			1		
12/06/22 0:58	176058.5			3.5			11.45			1.44			7.8			1		
12/06/22 0:59	157266.6			316.5			15.82			116.95			9.62			1		
12/06/22 1:00	138166.7			1189.8			19.06			386.46			10.19			1		
12/06/22 1:01	31345.5			1781.6			21.58			131.21			2.62			1		
12/06/22 1:02	0			0			24.09			0			0			0		
12/06/22 1:03	0			0			5.9			0			0			0		
12/06/22 1:04	0			0			2.95			0			0			0		
12/06/22 1:05	0			0			2.95			0			0			0		
12/06/22 1:06	0			0			2.95			0			0			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 15:04	0			0			0			0			0			0		
12/06/22 15:05	0			0			0			0			0			0		
12/06/22 15:06	0			0			0			0			0			0		
12/06/22 15:07	0			0			0			0			0			0		
12/06/22 15:08	0			0			0			0			0			0		
12/06/22 15:09	0			0			0			0			0			1		
12/06/22 15:10	15634.2			0			0			0			0			1		
12/06/22 15:11	29959.2			62			11.8			4.37			1.37			1		
12/06/22 15:12	41896.7			1038.4			12.71			102.27			2.06			1		
12/06/22 15:13	54989.4			895.8			16.06			115.7			3.41			1		
12/06/22 15:14	69160.3			550.8			22.13			89.51			5.92			1		
12/06/22 15:15	103278.4			386.2			25.75			93.71			10.28			1		
12/06/22 15:16	140169.1			268			36.63			88.29			19.86			1		
12/06/22 15:17	146561.4			155.8			52.9			53.66			29.99			1		
12/06/22 15:18	162503.7			1418.7			46.31			541.77			29.1			1		
12/06/22 15:19	180525.4			1702.5			47.86			722.55			33.43			1		
12/06/22 15:20	203861.3			728.4			48.97			349.07			38.62			1		
12/06/22 15:21	227428.2			110.9			49.56			59.29			43.6			1		
12/06/22 15:22	246220.1			7.3			45.93			4.22			43.74			1		
12/06/22 15:23	272405.5			1.9			42.78			1.21			45.07			1		
12/06/22 15:24	278258.7			1.6			24.37			1.08			26.24			1		
12/06/22 15:25	279413.9			1.5			13.77			1			14.88			1		
12/06/22 15:26	293353.8			1.6			13.14			1.11			14.91			1		
12/06/22 15:27	309373.2			1.5			11.54			1.09			13.8			1		
12/06/22 15:28	311452.6			1.4			8.42			1.02			10.14			1		
12/06/22 15:29	309373.2			1.4			7.55			1.01			9.03			1		
12/06/22 15:30	307755.8			1.2			6.85			0.88			8.16			1		
12/06/22 15:31	307832.8			1.1			6.42			0.82			7.64			1		
12/06/22 15:32	307139.7			1			6.33			0.75			7.53			1		
12/06/22 15:33	306292.5			1.1			6.25			0.76			7.41			1		
12/06/22 15:34	306523.6			1			6.08			0.7			7.2			1		
12/06/22 15:35	305907.4			1			5.9			0.7			6.98			1		
12/06/22 15:36	305599.4			0.9			5.81			0.63			6.87			1		
12/06/22 15:37	305214.3			0.9			5.81			0.63			6.86			1		
12/06/22 15:38	304521.2			0.8			5.72			0.57			6.74			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 15:39	305368.3			0.8			5.72			0.57			6.76			1		
12/06/22 15:40	305214.3			0.8			5.72			0.58			6.76			1		
12/06/22 15:41	306138.5			0.8			5.72			0.58			6.77			1		
12/06/22 15:42	306061.5			0.8			5.72			0.58			6.77			1		
12/06/22 15:43	304598.2			0.7			5.81			0.51			6.85			1		
12/06/22 15:44	303674			0.7			5.9			0.51			6.93			1		
12/06/22 15:45	302903.8			0.7			5.9			0.51			6.91			1		
12/06/22 15:46	299823.2			0.7			5.9			0.5			6.84			1		
12/06/22 15:47	281185.3			0.7			5.99			0.47			6.51			1		
12/06/22 15:48	272790.6			0.6			6.44			0.41			6.8			1		
12/06/22 15:49	270788.2			0.6			8.2			0.41			8.59			1		
12/06/22 15:50	268323.7			0.6			8.3			0.35			8.61			1		
12/06/22 15:51	268554.7			0.5			7.74			0.29			8.04			1		
12/06/22 15:52	269016.8			0.5			7.56			0.29			7.87			1		
12/06/22 15:53	268246.6			0.5			7.38			0.29			7.65			1		
12/06/22 15:54	267861.6			0.5			7.19			0.29			7.45			1		
12/06/22 15:55	267784.5			0.5			7.1			0.29			7.35			1		
12/06/22 15:56	268323.7			0.5			7.01			0.29			7.27			1		
12/06/22 15:57	268246.6			0.5			6.91			0.29			7.18			1		
12/06/22 15:58	268015.6			0.5			6.91			0.29			7.17			1		
12/06/22 15:59	270788.2			0.5			6.82			0.29			7.14			1		
12/06/22 16:00	273175.7			0.5			6.93			0.3			7.32			1		
12/06/22 16:01	273560.7			0.5			6.73			0.3			7.12			1		
12/06/22 16:02	271789.4			0.5			6.55			0.29			6.88			1		
12/06/22 16:03	270403.1			0.5			6.45			0.29			6.75			1		
12/06/22 16:04	270711.2			0.5			6.27			0.29			6.56			1		
12/06/22 16:05	270711.2			0.5			6.08			0.29			6.37			1		
12/06/22 16:06	271327.3			0.5			5.81			0.29			6.1			1		
12/06/22 16:07	272174.4			0.5			5.72			0.29			6.02			1		
12/06/22 16:08	283033.7			0.5			5.62			0.31			6.16			1		
12/06/22 16:09	303751			0.6			5.25			0.39			6.17			1		
12/06/22 16:10	323467.1			0.5			3.99			0.41			5			1		
12/06/22 16:11	329551.3			0.6			3.79			0.48			4.83			1		
12/06/22 16:12	325084.4			0.7			3.79			0.54			4.76			1		
12/06/22 16:13	329551.3			0.7			4.23			0.55			5.39			1		
12/06/22 16:14	346186.8			0.7			4.14			0.57			5.54			1		
12/06/22 16:15	363361.3			0.7			2.68			0.61			3.77			1		
12/06/22 16:16	374451.7			0.6			2.18			0.56			3.16			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 16:17	376916.2			0.6			2.09			0.56			3.04			1		
12/06/22 16:18	387082.3			0.6			2.06			0.57			3.08			1		
12/06/22 16:19	399250.8			0.6			2.09			0.6			3.22			1		
12/06/22 16:20	409879			0.6			1.94			0.62			3.07			1		
12/06/22 16:21	413190.7			0.6			1.82			0.62			2.9			1		
12/06/22 16:22	412959.7			0.6			1.91			0.62			3.04			1		
12/06/22 16:23	423895.9			0.6			1.91			0.63			3.13			1		
12/06/22 16:24	437142.7			0.6			1.91			0.65			3.22			0		
12/06/22 16:25	438297.9			0.6			1.84			0.66			3.13			0		
12/06/22 16:26	441532.6			0.6			1.84			0.67			3.15			0		
12/06/22 16:27	446153.5			0.6			1.94			0.68			3.34			0		
12/06/22 16:28	447539.8			0.6			2.03			0.68			3.51			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/27/22 23:49	267707.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:50	266937.4			0.6			1.48			0.35			1.52			0		
12/27/22 23:51	267245.4			0.6			1.48			0.41			1.52			0		
12/27/22 23:52	267476.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:53	267399.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:54	257464.4			0.6			1.48			0.33			1.47			1		
12/27/22 23:55	236362			0.6			1.69			0.31			1.54			1		
12/27/22 23:56	214412.5			0.5			5.7			0.25			4.73			1		
12/27/22 23:57	189151.2			0.9			9.4			0.39			6.87			1		
12/27/22 23:58	167894.8			8.8			11.08			3.47			7.19			1		
12/27/22 23:59	150258.2			497			12.62			175.55			7.34			1		
12/28/22 0:00	107822.4			1483.7			13.66			375.96			5.7			1		
12/28/22 0:01	0			0			14.36			0			0			0		
12/28/22 0:02	0			0			8.85			0			0			0		
12/28/22 0:03	0			0			2.95			0			0			0		
12/28/22 0:04	0			0			2.95			0			0			0		
12/28/22 0:05	0			0			2.95			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 22:48	285036.1			0.5			1.24			0.32			1.37			0		
10/08/22 22:49	290273.2			0.5			1.24			0.33			1.4			0		
10/08/22 22:50	291428.4			0.5			1.24			0.33			1.4			0		
10/08/22 22:51	290889.3			0.6			1.22			0.39			1.38			0		
10/08/22 22:52	290504.3			0.6			1.24			0.39			1.4			0		
10/08/22 22:53	287115.5			0.5			1.33			0.32			1.49			1		
10/08/22 22:54	271866.4			0.5			1.43			0.31			1.51			1		
10/08/22 22:55	246990.2			0.5			2.51			0.28			2.42			1		
10/08/22 22:56	223577.4			0.4			7.45			0.22			6.48			1		
10/08/22 22:57	197237.9			2.2			16.11			1.01			12.36			1		
10/08/22 22:58	174595.2			112.6			20.27			46.48			13.77			1		
10/08/22 22:59	153415.8			662			24.63			240.05			14.7			1		
10/08/22 23:00	100736.9			1436.6			29.33			342.15			11.5			1		
10/08/22 23:01	0			0			32.8			0			0			0		
10/08/22 23:02	0			0			11.8			0			0			0		
10/08/22 23:03	0			0			0.1			0			0			0		
10/08/22 23:04	0			0			0			0			0			0		
10/08/22 23:05	0			0			0			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 14:49	0			0			0			0			0			0		
10/18/22 14:50	0			0			0			0			0			0		
10/18/22 14:51	0			0			0			0			0			0		
10/18/22 14:52	0			0			0			0			0			0		
10/18/22 14:53	0			0			0			0			0			0		
10/18/22 14:54	1925.4			0			0			0			0			1		
10/18/22 14:55	15172.1			0			0			0			0			1		
10/18/22 14:56	30190.3			26.6			2.95			1.9			0.35			1		
10/18/22 14:57	43745.1			1083.6			10.82			112.07			1.84			1		
10/18/22 14:58	56144.6			872.9			14.09			115.87			3.08			1		
10/18/22 14:59	67234.9			518.1			17.7			82.34			4.63			1		
10/18/22 15:00	98426.4			356.3			21.29			82.87			8.15			1		
10/18/22 15:01	144636			219.2			22.66			74.94			12.74			1		
10/18/22 15:02	158498.9			141.2			46.44			52.92			28.64			1		
10/18/22 15:03	200010.5			770.1			43.9			364.09			34.16			1		
10/18/22 15:04	230354.8			377.9			56.27			205.72			50.41			1		
10/18/22 15:05	255847.1			25.6			57.07			15.51			56.81			1		
10/18/22 15:06	282032.5			1.7			55.94			1.12			61.38			1		
10/18/22 15:07	308294.9			1.3			37.62			0.92			45.13			1		
10/18/22 15:08	328319.1			1.3			20.96			1.03			26.77			1		
10/18/22 15:09	332786			1.5			16.66			1.16			21.57			1		
10/18/22 15:10	332092.9			1.6			15.18			1.23			19.62			1		
10/18/22 15:11	331784.8			1.6			13.71			1.22			17.7			1		
10/18/22 15:12	345570.7			1.5			13.12			1.22			17.64			1		
10/18/22 15:13	358355.3			1.4			11.62			1.19			16.2			1		
10/18/22 15:14	358663.4			1.4			8.59			1.18			11.98			1		
10/18/22 15:15	358201.3			1.4			8.07			1.18			11.25			1		
10/18/22 15:16	358047.3			1.4			7.31			1.19			10.18			1		
10/18/22 15:17	358432.3			1.3			6.96			1.12			9.7			1		
10/18/22 15:18	356892			1.2			6.43			1.04			8.93			1		
10/18/22 15:19	357739.2			1.1			6.16			0.97			8.58			1		
10/18/22 15:20	348882.3			1.1			5.99			0.87			8.13			1		
10/18/22 15:21	330629.6			1.1			6.34			0.83			8.15			1		
10/18/22 15:22	328319.1			1			7.13			0.75			9.11			1		
10/18/22 15:23	325546.5			1			7.51			0.76			9.51			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 15:24	324545.3			0.9			7.62			0.7			9.63			1		
10/18/22 15:25	325469.5			0.9			7.62			0.7			9.65			1		
10/18/22 15:26	323621.1			0.8			7.72			0.62			9.71			1		
10/18/22 15:27	324160.2			0.8			7.72			0.63			9.73			1		
10/18/22 15:28	323852.2			0.8			7.81			0.63			9.84			1		
10/18/22 15:29	323621.1			0.8			7.81			0.62			9.83			1		
10/18/22 15:30	322542.9			0.8			7.99			0.62			10.02			1		
10/18/22 15:31	323621.1			0.8			8.08			0.62			10.17			1		
10/18/22 15:32	322542.9			0.7			8.17			0.55			10.25			1		
10/18/22 15:33	314071.1			0.7			8.17			0.54			9.98			1		
10/18/22 15:34	311606.6			0.7			8.2			0.54			9.95			1		
10/18/22 15:35	305907.4			0.6			8.11			0.47			9.65			1		
10/18/22 15:36	299592.1			0.6			8.3			0.46			9.67			1		
10/18/22 15:37	294432.1			0.7			8.99			0.46			10.3			1		
10/18/22 15:38	288193.8			0.6			5.9			0.38			6.61			1		
10/18/22 15:39	284651			0.6			3.09			0.38			3.42			1		
10/18/22 15:40	282725.6			0.6			2.28			0.38			2.51			1		
10/18/22 15:41	283110.7			0.5			1.71			0.32			1.89			1		
10/18/22 15:42	284651			0.5			1.43			0.32			1.58			1		
10/18/22 15:43	284343			0.5			1.24			0.32			1.37			1		
10/18/22 15:44	288270.8			0.5			1.05			0.32			1.17			0		
10/18/22 15:45	287269.6			0.5			0.86			0.32			0.96			0		
10/18/22 15:46	288116.8			0.5			0.66			0.32			0.73			0		
10/18/22 15:47	288732.9			0.5			0.66			0.32			0.74			0		
10/18/22 15:48	289888.1			0.5			0.56			0.32			0.63			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 23:48	303057.8			0.9			1.25			0.63			1.45			0		
11/07/22 23:49	285421.2			0.9			1.36			0.6			1.49			0		
11/07/22 23:50	282340.6			0.8			2.12			0.55			2.29			0		
11/07/22 23:51	281185.3			0.8			2.38			0.5			2.56			0		
11/07/22 23:52	287500.6			0.7			2.19			0.45			2.41			0		
11/07/22 23:53	290273.2			0.7			1.78			0.44			1.98			1		
11/07/22 23:54	280261.1			0.6			1.38			0.42			1.49			1		
11/07/22 23:55	257926.5			0.7			1.31			0.39			1.3			1		
11/07/22 23:56	234744.7			0.7			4.1			0.38			3.69			1		
11/07/22 23:57	208636.3			1			8.74			0.48			6.99			1		
11/07/22 23:58	184761.3			7.7			11.56			3.32			8.18			1		
11/07/22 23:59	163273.9			449.9			16.19			171.11			10.13			1		
11/08/22 0:00	143942.9			1153			21.12			386.62			11.65			1		
11/08/22 0:01	34272.1			1707.4			26.64			136.45			3.5			1		
11/08/22 0:02	0			0			28.91			0			0			0		
11/08/22 0:03	0			0			2.95			0			0			0		
11/08/22 0:04	0			0			2.95			0			0			0		
11/08/22 0:05	0			0			5.9			0			0			0		
11/08/22 0:06	0			0			5.9			0			0			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 20:26	0			0			0			0			0			0		
11/09/22 20:27	0			0			0			0			0			0		
11/09/22 20:28	0			0			0			0			0			0		
11/09/22 20:29	0			0			0			0			0			0		
11/09/22 20:30	0			0			0			0			0			0		
11/09/22 20:31	4698			11.8			0			0.13			0			1		
11/09/22 20:32	22257.6			11.8			0			0.61			0			1		
11/09/22 20:33	38431			42.3			9.83			3.79			1.45			1		
11/09/22 20:34	50599.5			1241.4			10.23			146.16			1.98			1		
11/09/22 20:35	61843.8			887			13.44			127.66			3.18			1		
11/09/22 20:36	78479.3			596.5			16.23			109.09			4.88			1		
11/09/22 20:37	120530			467.7			18.24			131.29			8.42			1		
11/09/22 20:38	154186			343.1			21.24			123.21			12.55			1		
11/09/22 20:39	181218.6			281.9			38.06			119			26.45			1		
11/09/22 20:40	204631.4			1013.1			45.81			482.79			35.93			1		
11/09/22 20:41	226889			427.9			51.55			226.14			44.84			1		
11/09/22 20:42	251303.1			114.2			56.95			66.82			54.86			1		
11/09/22 20:43	276487.3			12.7			56.92			8.2			60.33			1		
11/09/22 20:44	302287.7			4.3			55.42			3.04			64.21			1		
11/09/22 20:45	310605.4			3.6			27.5			2.62			32.75			1		
11/09/22 20:46	311067.5			3.5			19.67			2.53			23.45			1		
11/09/22 20:47	312761.9			3.7			18.84			2.69			22.59			1		
11/09/22 20:48	318769.1			4.3			18.14			3.2			22.17			1		
11/09/22 20:49	341950.9			5.4			17.44			4.28			22.85			1		
11/09/22 20:50	349960.6			10.8			13.1			8.77			17.57			1		
11/09/22 20:51	344492.4			14.3			11.8			11.46			15.58			1		
11/09/22 20:52	357585.2			14			10.86			11.68			14.89			1		
11/09/22 20:53	359356.5			9.4			10.69			7.87			14.72			1		
11/09/22 20:54	347419.1			6.9			10			5.6			13.32			1		
11/09/22 20:55	343260.2			6.3			8.81			5.06			11.59			1		
11/09/22 20:56	341411.8			5.6			8.07			4.42			10.56			1		
11/09/22 20:57	341950.9			4.6			7.9			3.66			10.35			1		
11/09/22 20:58	343337.2			3.8			7.64			3.05			10.05			1		
11/09/22 20:59	342027.9			3.1			7.29			2.49			9.56			1		
11/09/22 21:00	343183.2			2.7			7.03			2.15			9.25			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 21:01	345031.6			2.3			6.85			1.81			9.07			1		
11/09/22 21:02	342413			2			6.77			1.59			8.88			1		
11/09/22 21:03	350499.7			1.9			6.87			1.58			9.23			1		
11/09/22 21:04	370292.8			1.8			6.78			1.59			9.62			1		
11/09/22 21:05	389238.7			1.7			6.07			1.57			9.06			1		
11/09/22 21:06	395477			1.7			4.05			1.54			6.14			1		
11/09/22 21:07	399250.8			1.7			4.38			1.58			6.7			1		
11/09/22 21:08	397941.5			1.6			4.76			1.47			7.25			1		
11/09/22 21:09	402870.6			1.4			4.76			1.32			7.34			1		
11/09/22 21:10	400560.1			1.2			4.84			1.15			7.44			1		
11/09/22 21:11	401946.3			1.1			4.93			1.07			7.6			1		
11/09/22 21:12	402023.4			1.1			4.93			1.07			7.6			1		
11/09/22 21:13	404410.9			1.1			5.02			1			7.78			1		
11/09/22 21:14	404641.9			1.1			4.84			1			7.51			1		
11/09/22 21:15	399096.8			1.1			3.08			0.98			4.71			1		
11/09/22 21:16	389084.7			1.1			2.2			0.96			3.28			1		
11/09/22 21:17	383616.6			1			2.78			0.93			4.08			1		
11/09/22 21:18	369214.6			1			2.95			0.9			4.17			1		
11/09/22 21:19	348420.3			1			2.95			0.84			3.94			1		
11/09/22 21:20	326008.6			1			3.56			0.79			4.45			1		
11/09/22 21:21	319385.3			1.1			2.47			0.79			3.02			1		
11/09/22 21:22	313532			1			2.15			0.72			2.58			1		
11/09/22 21:23	310374.4			0.9			2			0.66			2.38			1		
11/09/22 21:24	308371.9			0.9			2.09			0.65			2.47			1		
11/09/22 21:25	309219.1			0.9			2.09			0.65			2.47			1		
11/09/22 21:26	310297.3			0.8			2.09			0.59			2.48			1		
11/09/22 21:27	307986.9			0.8			2			0.59			2.36			1		
11/09/22 21:28	306138.5			0.8			1.91			0.58			2.24			1		
11/09/22 21:29	306446.6			0.8			1.82			0.58			2.13			1		
11/09/22 21:30	306908.7			0.8			1.82			0.58			2.14			1		
11/09/22 21:31	305214.3			0.8			1.82			0.58			2.12			1		
11/09/22 21:32	305830.4			0.8			1.72			0.58			2.02			0		
11/09/22 21:33	306446.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:34	306831.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:35	306831.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:36	306908.7			0.8			1.54			0.58			1.82			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 7:15	500526.8			0.6			1.44			0.96			3.68			0		
11/29/22 7:16	500295.8			0.6			1.63			0.94			4.12			0		
11/29/22 7:17	499833.7			0.5			1.7			0.83			4.25			0		
11/29/22 7:18	503068.3			0.5			1.65			0.85			4.2			0		
11/29/22 7:19	494519.6			0.5			1.51			0.85			3.86			0		
11/29/22 7:20	420584.2			0.5			1.56			0.74			3.51			1		
11/29/22 7:21	0			0			2.07			0			0			0		
11/29/22 7:22	0			0			7.38			0			0			0		
11/29/22 7:23	0			0			0			0			0			0		
11/29/22 7:24	0			0			0			0			0			0		
11/29/22 7:25	0			0			0			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 11:45	0			0			0			0			0			0		
11/29/22 11:46	0			0			0			0			0			0		
11/29/22 11:47	0			0			0			0			0			0		
11/29/22 11:48	0			0			0			0			0			0		
11/29/22 11:49	8471.8			0			0			0.23			0			0		
11/29/22 11:50	15326.2			11.8			0			0.42			0			1		
11/29/22 11:51	30190.3			25.6			0			1.8			0			1		
11/29/22 11:52	44053.1			1005.3			1.36			103.06			0.23			1		
11/29/22 11:53	55836.6			871.5			4.51			113.34			0.97			1		
11/29/22 11:54	68005.1			532.8			7.08			84.44			1.85			1		
11/29/22 11:55	97502.2			406.3			9.83			92.21			3.67			1		
11/29/22 11:56	145406.2			279.1			16.16			94.52			9.01			1		
11/29/22 11:57	153569.8			182.5			18.31			65.28			10.78			1		
11/29/22 11:58	160963.4			1046.3			29.68			392.31			18.32			1		
11/29/22 11:59	180217.4			1814.7			34.68			761.65			23.96			1		
11/29/22 12:00	199086.3			1319.1			37.04			611.54			28.26			1		
11/29/22 12:01	225502.8			485.8			39.43			255.12			34.08			1		
11/29/22 12:02	249531.8			76.1			43.35			44.2			41.46			1		
11/29/22 12:03	272251.5			7.1			46.04			4.48			48.05			1		
11/29/22 12:04	287577.6			2.1			40.16			1.39			44.27			1		
11/29/22 12:05	291890.5			1.8			20.41			1.25			22.83			1		
11/29/22 12:06	291197.4			1.7			17.61			1.14			19.65			1		
11/29/22 12:07	308063.9			1.5			17.23			1.08			20.35			1		
11/29/22 12:08	333248.1			1.4			15.16			1.06			19.36			1		
11/29/22 12:09	346648.9			1.4			11.02			1.12			14.64			1		
11/29/22 12:10	347650.1			1.5			9.89			1.19			13.18			1		
11/29/22 12:11	349421.5			1.5			9.8			1.2			13.13			1		
11/29/22 12:12	351115.8			1.5			9.72			1.21			13.08			1		
11/29/22 12:13	346879.9			1.5			9.63			1.19			12.8			1		
11/29/22 12:14	346648.9			1.4			9.54			1.12			12.68			1		
11/29/22 12:15	346725.9			1.4			9.46			1.12			12.57			1		
11/29/22 12:16	345647.7			1.3			9.37			1.05			12.41			1		
11/29/22 12:17	345108.6			1.3			9.46			1.05			12.51			1		
11/29/22 12:18	344338.4			1.2			8.85			0.97			11.68			1		
11/29/22 12:19	330937.6			1.2			5.55			0.95			7.04			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 12:20	323621.1			1.2			3.17			0.93			3.93			1		
11/29/22 12:21	311298.6			1.2			3.58			0.84			4.27			1		
11/29/22 12:22	301440.5			1.1			4.9			0.76			5.66			1		
11/29/22 12:23	297589.7			1.1			6.63			0.75			7.56			1		
11/29/22 12:24	297204.6			0.9			5.16			0.64			5.88			1		
11/29/22 12:25	296588.5			0.9			3.13			0.64			3.56			1		
11/29/22 12:26	297897.8			0.9			2.21			0.64			2.53			1		
11/29/22 12:27	296665.5			0.9			2.21			0.64			2.52			1		
11/29/22 12:28	305830.4			0.8			2.4			0.59			2.81			1		
11/29/22 12:29	327317.9			0.8			2.67			0.63			3.35			1		
11/29/22 12:30	350499.7			0.9			2.18			0.74			2.93			1		
11/29/22 12:31	363053.3			1			1.85			0.82			2.57			1		
11/29/22 12:32	362899.3			1.1			1.41			0.89			1.96			1		
11/29/22 12:33	369214.6			1.1			0.97			0.91			1.37			1		
11/29/22 12:34	383539.5			1.1			0.88			0.94			1.29			0		
11/29/22 12:35	404102.8			1.1			0.63			1.01			0.97			0		
11/29/22 12:36	413190.7			1.1			0.54			1.05			0.86			0		
11/29/22 12:37	413806.8			1			0.45			0.96			0.72			0		
11/29/22 12:38	421970.5			1			0.45			0.97			0.72			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 17:50	319077.2			0.9			5.81			0.7			7.11			0		
12/03/22 17:51	298128.8			1			6.16			0.67			7.04			0		
12/03/22 17:52	291351.4			0.8			8.26			0.55			9.22			0		
12/03/22 17:53	291967.6			0.6			10.33			0.44			11.56			0		
12/03/22 17:54	290427.2			0.6			10.86			0.38			12.09			0		
12/03/22 17:55	282186.5			0.5			11.24			0.31			12.16			1		
12/03/22 17:56	259697.9			0.5			13.99			0.29			13.92			1		
12/03/22 17:57	239442.7			0.5			29.6			0.28			27.16			1		
12/03/22 17:58	212102			1.3			38.9			0.65			31.62			1		
12/03/22 17:59	188073			10.4			42.65			4.58			30.75			1		
12/03/22 18:00	167509.7			463.5			45.14			180.84			28.99			1		
12/03/22 18:01	148409.8			1175.2			44.41			406.17			25.26			1		
12/03/22 18:02	25338.3			1711.4			45.05			101.13			4.38			1		
12/03/22 18:03	0			0			38.08			0			0			0		
12/03/22 18:04	0			0			11.8			0			0			0		
12/03/22 18:05	0			0			8.85			0			0			0		
12/03/22 18:06	0			0			5.9			0			0			0		
12/03/22 18:07	0			0			5.9			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 17:01	0			0			0			0			0			0		
12/05/22 17:02	0			0			0			0			0			0		
12/05/22 17:03	0			0			0			0			0			0		
12/05/22 17:04	0			0			0			0			0			0		
12/05/22 17:05	0			0			0			0			0			0		
12/05/22 17:06	14093.9			0			0			0			0			1		
12/05/22 17:07	29651.1			23.6			5.9			1.63			0.67			1		
12/05/22 17:08	43591			1198.8			13.41			121.83			2.24			1		
12/05/22 17:09	56298.7			1046			13.88			137.21			3			1		
12/05/22 17:10	67851.1			663.5			17.7			104.85			4.6			1		
12/05/22 17:11	94960.7			472.8			20.92			104.57			7.61			1		
12/05/22 17:12	143172.7			381.2			23.6			127.14			12.95			1		
12/05/22 17:13	158344.8			248.2			43.41			91.51			26.34			1		
12/05/22 17:14	202012.9			746.6			50.24			351.3			38.9			1		
12/05/22 17:15	229892.7			623.4			61.12			333.81			53.86			1		
12/05/22 17:16	255770			52.9			57.28			31.48			56.15			1		
12/05/22 17:17	280415.2			3.8			57.22			2.47			61.51			1		
12/05/22 17:18	299361.1			1.3			44.5			0.91			51.07			1		
12/05/22 17:19	301825.6			1.3			20.1			0.91			23.25			1		
12/05/22 17:20	313763.1			1.3			17.7			0.98			21.29			1		
12/05/22 17:21	333017.1			1.4			17.08			1.09			21.81			1		
12/05/22 17:22	337484			1.4			13.01			1.09			16.83			1		
12/05/22 17:23	336636.8			1.5			11.29			1.14			14.57			1		
12/05/22 17:24	335173.5			1.5			11.19			1.15			14.38			1		
12/05/22 17:25	332477.9			1.5			10.76			1.14			13.71			1		
12/05/22 17:26	333094.1			1.4			10.24			1.08			13.07			1		
12/05/22 17:27	331399.7			1.2			9.89			0.94			12.56			1		
12/05/22 17:28	331168.7			1.1			9.77			0.88			12.41			1		
12/05/22 17:29	329705.4			1.1			9.6			0.88			12.13			1		
12/05/22 17:30	328088			1.1			9.42			0.81			11.85			1		
12/05/22 17:31	328165.1			1			8.01			0.74			10.08			1		
12/05/22 17:32	327240.9			1			8.63			0.74			10.83			1		
12/05/22 17:33	328396.1			0.9			8.63			0.67			10.86			1		
12/05/22 17:34	327240.9			0.9			8.76			0.68			10.99			1		
12/05/22 17:35	325777.6			0.9			8.76			0.68			10.94			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 17:36	325777.6			0.9			8.67			0.68			10.83			1		
12/05/22 17:37	327548.9			0.9			8.67			0.68			10.89			1		
12/05/22 17:38	327086.8			0.9			8.58			0.68			10.76			1		
12/05/22 17:39	325315.5			0.9			8.58			0.68			10.7			1		
12/05/22 17:40	325623.5			0.9			8.49			0.68			10.6			1		
12/05/22 17:41	325700.5			0.8			8.49			0.61			10.6			1		
12/05/22 17:42	326239.7			0.8			8.49			0.61			10.62			1		
12/05/22 17:43	337330			0.8			8.49			0.63			10.98			1		
12/05/22 17:44	332786			0.8			8.58			0.62			10.95			1		
12/05/22 17:45	313686.1			0.8			8.54			0.58			10.27			1		
12/05/22 17:46	310066.3			0.8			8.58			0.58			10.2			1		
12/05/22 17:47	302980.8			0.7			10.62			0.51			12.33			1		
12/05/22 17:48	297204.6			0.7			11.71			0.5			13.34			1		
12/05/22 17:49	289734.1			0.6			12.81			0.44			14.23			1		
12/05/22 17:50	288039.8			0.6			14.01			0.43			15.47			1		
12/05/22 17:51	288963.9			0.6			14.66			0.43			16.24			1		
12/05/22 17:52	288501.8			0.6			15.08			0.38			16.67			1		
12/05/22 17:53	298205.8			0.6			15.27			0.39			17.45			1		
12/05/22 17:54	303519.9			0.6			14.2			0.39			16.52			1		
12/05/22 17:55	304906.2			0.6			12.54			0.39			14.65			1		
12/05/22 17:56	301748.6			0.6			12.07			0.45			13.96			1		
12/05/22 17:57	301594.6			0.6			12.26			0.45			14.17			1		
12/05/22 17:58	301902.6			0.6			12.54			0.45			14.51			1		
12/05/22 17:59	299823.2			0.6			12.72			0.45			14.62			1		
12/05/22 18:00	300593.3			0.6			12.81			0.45			14.77			1		
12/05/22 18:01	301132.4			0.6			12.72			0.45			14.68			1		
12/05/22 18:02	300208.3			0.6			12.81			0.45			14.75			1		
12/05/22 18:03	299900.2			0.6			12.81			0.39			14.73			1		
12/05/22 18:04	300901.4			0.6			12.81			0.39			14.78			1		
12/05/22 18:05	298822			0.6			12.81			0.45			14.68			1		
12/05/22 18:06	299207.1			0.6			12.81			0.45			14.7			1		
12/05/22 18:07	299592.1			0.6			12.81			0.45			14.71			1		
12/05/22 18:08	301517.5			0.6			12.81			0.45			14.81			1		
12/05/22 18:09	300747.4			0.6			12.81			0.39			14.77			1		
12/05/22 18:10	298359.9			0.6			12.81			0.38			14.65			1		
12/05/22 18:11	300054.2			0.6			12.91			0.39			14.84			1		
12/05/22 18:12	299515.1			0.6			12.81			0.45			14.71			1		
12/05/22 18:13	300670.3			0.6			12.91			0.45			14.87			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 18:14	301055.4			0.6			12.91			0.45			14.89			1		
12/05/22 18:15	300978.4			0.6			12.91			0.45			14.89			1		
12/05/22 18:16	299900.2			0.6			12.91			0.45			14.83			1		
12/05/22 18:17	300131.3			0.6			12.91			0.45			14.85			1		
12/05/22 18:18	301363.5			0.6			13			0.45			15.02			1		
12/05/22 18:19	300901.4			0.6			13			0.45			14.99			1		
12/05/22 18:20	300208.3			0.6			13			0.45			14.96			1		
12/05/22 18:21	301902.6			0.6			12.91			0.45			14.93			1		
12/05/22 18:22	302980.8			0.6			12.91			0.46			14.99			1		
12/05/22 18:23	302287.7			0.6			12.81			0.45			14.85			1		
12/05/22 18:24	302133.7			0.6			12.63			0.45			14.63			1		
12/05/22 18:25	301979.6			0.6			12.44			0.45			14.39			1		
12/05/22 18:26	300208.3			0.6			12.63			0.45			14.54			1		
12/05/22 18:27	299592.1			0.6			10.69			0.45			12.28			1		
12/05/22 18:28	298436.9			0.6			4.89			0.45			5.59			1		
12/05/22 18:29	290504.3			0.6			2.58			0.44			2.87			1		
12/05/22 18:30	299438.1			0.6			1.75			0.45			2.01			1		
12/05/22 18:31	326855.8			0.6			1.57			0.42			1.96			1		
12/05/22 18:32	345031.6			0.6			0.91			0.51			1.2			1		
12/05/22 18:33	365286.8			0.7			0.7			0.6			0.99			0		
12/05/22 18:34	384771.8			0.7			0.62			0.63			0.91			0		
12/05/22 18:35	404410.9			0.8			0.54			0.76			0.83			0		
12/05/22 18:36	426899.5			0.8			0.45			0.81			0.74			0		
12/05/22 18:37	455241.4			0.7			0.45			0.77			0.79			0		

CT2 SUSD EVENT 9

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 14:48	287654.7			0.5			1.5			0.32			1.67			0		
12/12/22 14:49	287115.5			0.5			1.5			0.32			1.66			0		
12/12/22 14:50	288347.8			0.5			1.5			0.32			1.67			0		
12/12/22 14:51	286730.5			0.5			1.5			0.32			1.66			0		
12/12/22 14:52	287885.7			0.5			1.5			0.32			1.67			0		
12/12/22 14:53	290966.3			0.5			1.5			0.32			1.69			1		
12/12/22 14:54	277026.4			0.5			1.5			0.3			1.61			1		
12/12/22 14:55	254152.7			0.5			2.09			0.28			2.06			1		
12/12/22 14:56	229122.5			0.4			6.83			0.22			6.06			1		
12/12/22 14:57	202012.9			2.5			10.67			1.19			8.33			1		
12/12/22 14:58	179909.3			119.4			12.55			50.48			8.74			1		
12/12/22 14:59	159346			705			15.69			264.01			9.67			1		
12/12/22 15:00	115215.9			1455.2			18.52			394.14			8.26			1		
12/12/22 15:01	0			0			18.96			0			0			0		
12/12/22 15:02	0			0			11.8			0			0			0		
12/12/22 15:03	0			0			2.95			0			0			0		
12/12/22 15:04	0			0			2.95			0			0			0		
12/12/22 15:05	0			0			2.95			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 3:00	0			0			0			0			0			0		
12/17/22 3:01	0			0			0			0			0			0		
12/17/22 3:02	0			0			0			0			0			0		
12/17/22 3:03	0			0			0			0			0			0		
12/17/22 3:04	1232.3			0			0			0.09			0			0		
12/17/22 3:05	13246.7			29.5			0			0.92			0			1		
12/17/22 3:06	26416.5			53.1			0			3.29			0			1		
12/17/22 3:07	41280.6			70.8			7.38			6.86			1.18			1		
12/17/22 3:08	52447.9			1142			8.85			140.86			1.8			1		
12/17/22 3:09	64770.4			796.2			13.35			121.19			3.34			1		
12/17/22 3:10	82715.2			582.9			17.41			113.39			5.57			1		
12/17/22 3:11	129309.8			464.5			19.58			141.2			9.79			1		
12/17/22 3:12	160578.3			349.5			22.42			131.91			13.93			1		
12/17/22 3:13	193233.1			353.4			39.78			160.52			29.73			1		
12/17/22 3:14	213719.3			1026.8			43.27			515.75			35.77			1		
12/17/22 3:15	238133.4			469.8			49.73			262.88			45.8			1		
12/17/22 3:16	259851.9			88			51.97			53.74			52.23			1		
12/17/22 3:17	282956.7			6.4			54.01			4.23			59.11			1		
12/17/22 3:18	297050.6			1.7			52.48			1.16			60.3			1		
12/17/22 3:19	300208.3			1.4			29.5			1.01			34.26			1		
12/17/22 3:20	312992.9			2.2		X	21.89		X	1.6		X	26.5		X	1		
12/17/22 3:21	338254.2			1.4		X	19.81		X	1.09		X	25.92		X	1		
12/17/22 3:22	343491.3			1.1		X	15.9		X	0.9		X	21.13		X	1		
12/17/22 3:23	341950.9			1.3		X	11.97		X	1.08		X	15.83		X	1		
12/17/22 3:24	341488.8			1.6		X	10.26		X	1.3		X	13.56		X	1		
12/17/22 3:25	338716.3			1.6		X	8.98		X	1.29		X	11.77		X	1		
12/17/22 3:26	339178.3			1.5		X	7.87		X	1.23		X	10.32		X	1		
12/17/22 3:27	337407			1.5		X	7.01		X	1.15		X	9.15		X	1		
12/17/22 3:28	343645.3			1.4			6.68			1.12			8.88			1		
12/17/22 3:29	350499.7			1.3			6.07			1.07			8.23			1		
12/17/22 3:30	352348.1			1.2			5.81			0.99			7.93			1		
12/17/22 3:31	349883.6			1.2			5.73			0.98			7.75			1		
12/17/22 3:32	346802.9			1.2			5.56			0.98			7.46			1		
12/17/22 3:33	346417.8			1.2			5.39			0.97			7.22			1		
12/17/22 3:34	346957			1.2			5.38			0.99			7.22			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 3:35	347111			1.2			5.29			0.99			7.11			1		
12/17/22 3:36	347111			1.2			5.29			0.99			7.11			1		
12/17/22 3:37	348112.2			1.3			5.29			1.06			7.13			1		
12/17/22 3:38	348497.3			1.4			5.38			1.14			7.25			1		
12/17/22 3:39	345262.6			1.4			5.47			1.13			7.3			1		
12/17/22 3:40	323775.2			1.4			5.47			1.06			6.85			1		
12/17/22 3:41	311760.7			1.4			6.16			1.03			7.43			1		
12/17/22 3:42	310682.4			1.3			8.05			0.98			9.67			1		
12/17/22 3:43	302672.8			1.3			8.58			0.89			10.05			1		
12/17/22 3:44	299284.1			1.2			8.9			0.83			10.3			1		
12/17/22 3:45	299207.1			1.1			11.15			0.78			12.91			1		
12/17/22 3:46	300054.2			1			11.61			0.73			13.48			1		
12/17/22 3:47	300978.4			1			12.17			0.73			14.17			1		
12/17/22 3:48	301363.5			0.9			12.17			0.65			14.18			1		
12/17/22 3:49	301825.6			0.9			11.89			0.65			13.88			1		
12/17/22 3:50	300978.4			0.9			10.79			0.65			12.56			1		
12/17/22 3:51	301979.6			0.9			5.44			0.65			6.35			1		
12/17/22 3:52	300208.3			0.9			3.32			0.65			3.85			1		
12/17/22 3:53	299900.2			0.9			2.3			0.65			2.67			1		
12/17/22 3:54	296896.6			0.9			2.03			0.64			2.33			1		
12/17/22 3:55	297358.7			0.9			1.78			0.65			2.05			1		
12/17/22 3:56	298128.8			0.9			1.5			0.66			1.73			1		
12/17/22 3:57	297204.6			0.9			1.31			0.65			1.51			1		
12/17/22 3:58	299515.1			0.9			1.12			0.66			1.3			0		
12/17/22 3:59	301209.5			0.9			1.01			0.65			1.18			0		
12/17/22 4:00	300054.2			0.9			0.92			0.65			1.07			0		
12/17/22 4:01	302133.7			1			0.83			0.72			0.97			0		
12/17/22 4:02	302518.8			1			0.74			0.72			0.86			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 9:50	379149.6			0.7			0.98			0.64			1.44			0		
12/31/22 9:51	380458.9			0.8			0.98			0.72			1.45			0		
12/31/22 9:52	377532.3			0.7			0.98			0.63			1.44			0		
12/31/22 9:53	372911.3			0.7			0.98			0.63			1.42			0		
12/31/22 9:54	373065.4			0.8			1.06			0.69			1.52			0		
12/31/22 9:55	372603.3			0.8			1.06			0.69			1.52			1		
12/31/22 9:56	363900.5			0.8			1.07			0.69			1.51			1		
12/31/22 9:57	341334.8			0.8			1.06			0.64			1.4			1		
12/31/22 9:58	317844.9			0.8			1.41			0.59			1.73			1		
12/31/22 9:59	296665.5			0.8			1.7			0.56			1.95			1		
12/31/22 10:00	270557.1			0.7			2.21			0.47			2.32			1		
12/31/22 10:01	247529.3			0.7			4.09			0.39			3.92			1		
12/31/22 10:02	223423.3			0.5			8.53			0.28			7.38			1		
12/31/22 10:03	196929.8			3			21.17			1.39			16.13			1		
12/31/22 10:04	175057.3			160.7			23.73			66.12			16.07			1		
12/31/22 10:05	155341.2			830.9			26.7			303.34			16.04			1		
12/31/22 10:06	101199			1668.7			28.83			397.06			11.29			1		
12/31/22 10:07	0			0			28.08			0			0			0		
12/31/22 10:08	0			0			23.6			0			0			0		
12/31/22 10:09	0			0			0.2			0			0			0		
12/31/22 10:10	0			0			0.1			0			0			0		
12/31/22 10:11	0			0			0.1			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 14:20	0			0			0			0			0			0		
12/31/22 14:21	0			0			0			0			0			0		
12/31/22 14:22	0			0			0			0			0			0		
12/31/22 14:23	0			0			0			0			0			0		
12/31/22 14:24	0			0			0			0			0			0		
12/31/22 14:25	6238.3			-0.1			0			0			0			1		
12/31/22 14:26	23643.9			-0.1			0			0			0			1		
12/31/22 14:27	38354			55.1			13.77			4.97			2.04			1		
12/31/22 14:28	49906.4			1314.9			8.65			154.23			1.67			1		
12/31/22 14:29	61843.8			955.8			13.19			138.86			3.15			1		
12/31/22 14:30	77786.1			627			16.15			114.66			4.86			1		
12/31/22 14:31	122840.5			477.6			20.79			137.92			9.88			1		
12/31/22 14:32	149719			321.7			23.6			113.19			13.67			1		
12/31/22 14:33	154340			397.1			42.09			144.08			25.13			1		
12/31/22 14:34	171360.5			1949.5			42.06			785.05			27.88			1		
12/31/22 14:35	192539.9			1770.5			46.16			801.37			34.38			1		
12/31/22 14:36	216723			831.6			44.02			423.68			36.91			1		
12/31/22 14:37	241522.1			179.4			45.32			101.85			42.34			1		
12/31/22 14:38	264087.8			14.2			46			8.82			46.99			1		
12/31/22 14:39	289195			2			44.09			1.39			49.33			1		
12/31/22 14:40	316920.7			1.5			20.89			1.15			25.61			1		
12/31/22 14:41	329782.4			1.4			13.77			1.11			17.56			1		
12/31/22 14:42	330860.6			1.4			10.18			1.06			13.02			1		
12/31/22 14:43	330090.5			1.5			8.85			1.14			11.3			1		
12/31/22 14:44	338100.1			1.4			8.24			1.1			10.78			1		
12/31/22 14:45	354042.4			1.3			7.98			1.08			10.93			1		
12/31/22 14:46	355351.7			1.2			7.9			1.01			10.85			1		
12/31/22 14:47	357277.1			1.2			7.35			1.01			10.16			1		
12/31/22 14:48	357431.1			1.1			7.46			0.95			10.32			1		
12/31/22 14:49	355890.8			1			7.29			0.87			10.03			1		
12/31/22 14:50	354581.5			1			7.29			0.87			10			1		
12/31/22 14:51	343953.3			1			7.2			0.77			9.58			1		
12/31/22 14:52	357739.2			1			7.29			0.8			10.08			1		
12/31/22 14:53	360819.8			0.9			7.22			0.75			10.08			1		
12/31/22 14:54	361513			0.9			7.13			0.75			9.97			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 14:55	360280.7			0.9			7.13			0.75			9.94			1		
12/31/22 14:56	351963			0.9			6.52			0.73			8.87			1		
12/31/22 14:57	364593.6			0.9			3.79			0.75			5.34			1		
12/31/22 14:58	366673			0.8			2.55			0.68			3.62			1		
12/31/22 14:59	368521.4			0.8			2.29			0.69			3.26			1		
12/31/22 15:00	365440.8			0.8			2.38			0.68			3.36			1		
12/31/22 15:01	366442			0.8			2.55			0.68			3.62			1		
12/31/22 15:02	368290.4			0.8			2.91			0.69			4.14			1		
12/31/22 15:03	367135.1			0.8			2.99			0.68			4.25			1		
12/31/22 15:04	369368.6			0.8			3.08			0.69			4.4			1		
12/31/22 15:05	366596			0.8			3.17			0.68			4.5			1		
12/31/22 15:06	368983.5			0.8			3.26			0.69			4.65			1		
12/31/22 15:07	366519			0.8			3.26			0.68			4.62			1		
12/31/22 15:08	366056.9			0.8			3.35			0.68			4.74			1		
12/31/22 15:09	366442			0.8			3.17			0.68			4.49			1		
12/31/22 15:10	366442			0.8			2.91			0.68			4.12			1		
12/31/22 15:11	365055.7			0.8			2.64			0.68			3.73			1		
12/31/22 15:12	365132.7			0.7			2.55			0.6			3.61			1		
12/31/22 15:13	366210.9			0.8			2.55			0.68			3.62			1		
12/31/22 15:14	366750.1			0.8			2.47			0.68			3.5			1		
12/31/22 15:15	365055.7			0.8			2.29			0.68			3.23			1		
12/31/22 15:16	364131.5			0.8			2.11			0.68			2.98			1		
12/31/22 15:17	364362.6			0.8			2.03			0.68			2.85			1		
12/31/22 15:18	371987.2			0.8			1.76			0.69			2.53			1		
12/31/22 15:19	379765.8			0.8			1.5			0.71			2.2			1		
12/31/22 15:20	380921			0.8			1.16			0.72			1.71			1		
12/31/22 15:21	382153.3			0.7			0.98			0.64			1.45			1		
12/31/22 15:22	381152			0.7			0.89			0.64			1.32			0		
12/31/22 15:23	379842.8			0.7			0.8			0.64			1.18			0		
12/31/22 15:24	381537.1			0.8			0.72			0.72			1.06			0		
12/31/22 15:25	381152			0.8			0.63			0.72			0.92			0		
12/31/22 15:26	368444.4			0.8			0.62			0.69			0.88			0		

ATTACHMENT 4

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2022	0.6338	6.9447	1.5229	13.9715	0.3310	2.9119	0.1656	1.4563	0.5515	4.8538
Nov 2022	0.7748	7.3343	1.8689	14.5482	0.4031	3.0270	0.2017	1.5140	0.6720	5.0462
Dec 2022	0.6728	7.4389	1.5792	14.5596	0.3385	3.0207	0.1697	1.5116	0.5644	5.0359
Sum/Avg	7.4389		14.5596		3.0207		1.5116		5.0359	
Limit Value										

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
10/01/22 0:00	11.29			45.63			12.7			49.34								
10/02/22 0:00	13.89			53.19			25.01			56.91								
10/03/22 0:00	16.76			55.19			31.3			58.19								
10/04/22 0:00	24.42			67.48			61.26			70.42								
10/05/22 0:00	21.66			70.69			46.97			70.59								
10/06/22 0:00	17.07			61.99			35.21			63.7								
10/07/22 0:00	23.41			71.04			47.95			70.3								
10/08/22 0:00	20.31			62.05			53.64			61.76								
10/09/22 0:00	35.57			64.88			0			0								
10/10/22 0:00	27.67			59.52			0			0								
10/11/22 0:00	17.92			47.24			0			0								
10/12/22 0:00	15.66			46.66			0			0								
10/13/22 0:00	16.66			47.21			0			0								
10/14/22 0:00	26.11			54.89			0			0								
10/15/22 0:00	15.42			45.23			0			0								
10/16/22 0:00	27.92			53.05			0			0								
10/17/22 0:00	32.37			63.74			0			0								
10/18/22 0:00	25.7			66.87			24.64			35.81								
10/19/22 0:00	55.83			42.31			19.18			55.39								
10/20/22 0:00	13.88			50.28			15.25			53.21								
10/21/22 0:00	15.13			50.18			17.19			52.75								
10/22/22 0:00	16.16			64.96			18.68			69.32								
10/23/22 0:00	18.1			59.53			22.23			64.55								
10/24/22 0:00	20.7			60.09			26.06			64.35								
10/25/22 0:00	16.35			56.48			21.4			60.67								
10/26/22 0:00	14.22			49.28			18.72			52.71								
10/27/22 0:00	21.73			56.28			26.51			59.68								
10/28/22 0:00	21.44			64.87			29.15			69.3								
10/29/22 0:00	16.11			50.55			21.24			56.12								
10/30/22 0:00	15.1			49.5			20.1			55.98								
10/31/22 0:00	16.18			50.91			22.04			53.2								
11/01/22 0:00	26.47			70.08			30.85			74.45								
11/02/22 0:00	21.56			60.86			27.46			64.65								
11/03/22 0:00	19.62			62.58			27.15			66.71								
11/04/22 0:00	15.69			50.79			21.05			56.25								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
11/05/22 0:00	13.16			44.02			17.13			50.06								
11/06/22 0:00	19.72			56.35			25.1			65.73								
11/07/22 0:00	17.63			53.66			26.49			60.08								
11/08/22 0:00	27.14			58.9			8.91			0.25								
11/09/22 0:00	25.67			53.16			29.12			16.27								
11/10/22 0:00	18.39			55.07			22.15			57.95								
11/11/22 0:00	21.86			59.89			26.1			64.42								
11/12/22 0:00	25.72			70.28			30.36			75.28								
11/13/22 0:00	20.73			65.28			27.09			70.01								
11/14/22 0:00	20.04			67.86			26.49			72.43								
11/15/22 0:00	18.58			66.48			24.75			70.55								
11/16/22 0:00	22.64			64.22			28.43			68.16								
11/17/22 0:00	23.48			66.61			30.16			71.3								
11/18/22 0:00	20.75			76.06			28.13			80.04								
11/19/22 0:00	18.8			63.69			26.13			67.68								
11/20/22 0:00	26.29			70.33			34.95			74.67								
11/21/22 0:00	25.58			63.27			32.23			67.12								
11/22/22 0:00	24.88			62.83			32.55			67.38								
11/23/22 0:00	23.01			57.46			29.85			61.22								
11/24/22 0:00	29.72			65.08			35.98			69.69								
11/25/22 0:00	28.61			59.88			34.62			64.19								
11/26/22 0:00	26.86			63.3			34.25			68.01								
11/27/22 0:00	24.94			59.29			31.47			63.22								
11/28/22 0:00	28.47			61.04			34.83			65.31								
11/29/22 0:00	17.43			65.32			68.7			69.12								
11/30/22 0:00	18.23			58.95			25.22			62.81								
12/01/22 0:00	23.58			68.73			26.15			72.98								
12/02/22 0:00	23.04			74.38			25.69			79.67								
12/03/22 0:00	22.65			69.27			34.95			64.05								
12/04/22 0:00	26.9			65.43			0			0								
12/05/22 0:00	16.97			53.64			29.32			36.56								
12/06/22 0:00	57.84			37.67			16.73			52.96								
12/07/22 0:00	26.74			64.86			27.84			69.39								
12/08/22 0:00	22.86			72.76			24.96			77.53								
12/09/22 0:00	20.99			61.37			23.58			65.46								
12/10/22 0:00	20.76			60.77			22.46			64.77								
12/11/22 0:00	17.61			50.73			18.5			54.43								
12/12/22 0:00	22.8			49.73			26.37			35.45								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
12/13/22 0:00	32.01			61.34			0			0								
12/14/22 0:00	20.94			59.61			0			0								
12/15/22 0:00	18.28			64.78			0			0								
12/16/22 0:00	9.74			39.11			0			0								
12/17/22 0:00	21.22			56.91			52.88			64.36								
12/18/22 0:00	24.62			63.12			26.63			67.46								
12/19/22 0:00	22.12			76.79			24.41			82.64								
12/20/22 0:00	25.06			61.4			27.75			65.4								
12/21/22 0:00	34.76			71			37.04			75.39								
12/22/22 0:00	30.53			68.8			32.51			73.21								
12/23/22 0:00	32.98			69.22			33.88			72.72								
12/24/22 0:00	26.53			60.58			29.54			64.9								
12/25/22 0:00	13.01			40.88			14.42			43.39								
12/26/22 0:00	21.46			53.57			23.53			57.02								
12/27/22 0:00	12.04			37.04			9.23			40.17								
12/28/22 0:00	7.52			0.11			10.4			40.7								
12/29/22 0:00	0			0			9.78			40.71								
12/30/22 0:00	0			0			8.88			40.65								
12/31/22 0:00	0			0			72.44			42.7								

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/22 0:00	0.7			1.5			14.5		1	0.7			1.5			14.4		1
10/01/22 1:00	0.7			1.5			14.4		1	0.7			1.5			14.3		1
10/01/22 2:00	0.7			1.3			14.4		1	0.7			1.2			14.4		1
10/01/22 3:00	0.7			1.3			14.5		1	0.7			1.3			14.4		1
10/01/22 4:00	0.7			1.4			14.5		1	0.7			1.4			14.4		1
10/01/22 5:00	0.6			1.5			14.5		1	0.7			1.5			14.4		1
10/01/22 6:00	0.6			1.5			14.6		1	0.6			1.5			14.5		1
10/01/22 7:00	0.5			1.5			14.8		1	0.5			1.5			14.7		1
10/01/22 8:00	0.5			1.5			14.8		1	0.5			1.5			14.7		1
10/01/22 9:00	0.4			1.5			14.9		1	0.5			1.5			14.8		1
10/01/22 10:00	0.4			1.5			14.9		1	0.5			1.5			14.8		1
10/01/22 11:00	0.4			1.5			14.9		1	0.4			1.5			14.8		1
10/01/22 12:00	0.4			1.5			14.9		1	0.5			1.5			14.8		1
10/01/22 13:00	0.4			1.5			14.9		1	0.5			1.5			14.8		1
10/01/22 14:00	0.4			1.5			14.9		1	0.4			1.5			14.8		1
10/01/22 15:00	0.4			1.5			14.9		1	0.5			1.5			14.8		1
10/01/22 16:00	0.6			1.4			14.7		1	0.6			1.3			14.6		1
10/01/22 17:00	0.6			1.5			14.6		1	0.6			1.5			14.5		1
10/01/22 18:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/01/22 19:00	0.6			1.5			14.4		1	0.7			1.5			14.3		1
10/01/22 20:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/01/22 21:00	0.6			1.5			14.4		1	0.7			1.5			14.3		1
10/01/22 22:00	0.6			1.5			14.5		1	0.6			1.4			14.4		1
10/01/22 23:00	0.6			1.5			14.4		1	0.7			1.4			14.3		1
10/02/22 0:00	0.7			1.5			14.4		1	0.7			1.4			14.3		1
10/02/22 1:00	0.6			1.4			14.5		1	0.6			1.2			14.4		1
10/02/22 2:00	0.6			1.3			14.5		1	0.6			1.4			14.4		1
10/02/22 3:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/02/22 4:00	0.6			1.6			14.5		1	0.6			1.6			14.4		1
10/02/22 5:00	0.6			1.6			14.5		1	0.6			1.6			14.4		1
10/02/22 6:00	0.6			1.6			14.5		1	0.6			1.6			14.4		1
10/02/22 7:00	0.4			1.6			14.8		1	0.4			1.6			14.7		1
10/02/22 8:00	0.4			1.6			14.8		1	0.4			1.6			14.7		1
10/02/22 9:00	0.4			1.6			14.8		1	0.4			1.6			14.7		1
10/02/22 10:00	0.4			1.6			14.8		1	0.4			1.6			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/22 11:00	0.4			1.6			14.9		1	0.4			1.6			14.8		1
10/02/22 12:00	0.4			1.6			14.8		1	0.4			1.6			14.8		1
10/02/22 13:00	0.6			1.5			14.6		1	0.6			1.4			14.5		1
10/02/22 14:00	0.6			1.6			14.5		1	0.6			1.6			14.4		1
10/02/22 15:00	0.6			1.5			14.6		1	0.6			1.5			14.5		1
10/02/22 16:00	0.9			1.6			14.4		1	1.1			1.6			14.3		1
10/02/22 17:00	0.7			1.6			13.7		1	3.5			1.6			13.6		1
10/02/22 18:00	0.8			1.6			13.7		1	3.1			1.6			13.7		1
10/02/22 19:00	0.9			1.6			13.8		1	2.8			1.6			13.7		1
10/02/22 20:00	1.1			1.6			13.9		1	2.4			1.6			13.8		1
10/02/22 21:00	0.7			1.6			14.4		1	0.8			1.5			14.3		1
10/02/22 22:00	0.6			1.6			14.5		1	0.6			1.5			14.4		1
10/02/22 23:00	0.6			1.6			14.5		1	0.6			1.5			14.4		1
10/03/22 0:00	0.6			1.6			14.5		1	0.7			1.6			14.4		1
10/03/22 1:00	0.6			1.6			14.5		1	0.7			1.6			14.4		1
10/03/22 2:00	0.6			1.7			14.5		1	0.7			1.6			14.4		1
10/03/22 3:00	0.7			1.3			14.5		1	0.6			1.3			14.4		1
10/03/22 4:00	0.6			1.6			14.5		1	0.6			1.6			14.4		1
10/03/22 5:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/03/22 6:00	0.6			1.4			14.5		1	0.7			1.4			14.4		1
10/03/22 7:00	0.6			1.3			14.5		1	0.6			1.1			14.4		1
10/03/22 8:00	0.6			1.3			14.5		1	0.6			1.3			14.4		1
10/03/22 9:00	0.5			1.4			14.7		1	0.5			1.4			14.6		1
10/03/22 10:00	0.5			1.4			14.6		1	0.6			1.2			14.6		1
10/03/22 11:00	0.6			1.4			14.6		1	0.6			1.3			14.5		1
10/03/22 12:00	0.6			1.4			14.6		1	0.6			1.4			14.5		1
10/03/22 13:00	0.6			1.4			14.6		1	0.6			1.4			14.5		1
10/03/22 14:00	0.6			1.4			14.6		1	0.6			1.4			14.5		1
10/03/22 15:00	0.6			1.4			14.6		1	0.6			1.4			14.5		1
10/03/22 16:00	0.7			1.4			14.5		1	0.7			1.4			14.4		1
10/03/22 17:00	0.8			1.4			13.7		1	3.4			1.4			13.7		1
10/03/22 18:00	0.8			1.4			13.7		1	3.4			1.4			13.6		1
10/03/22 19:00	0.9			1.4			13.8		1	3.1			1.4			13.7		1
10/03/22 20:00	1			1.4			13.8		1	2.7			1.4			13.8		1
10/03/22 21:00	1			1.4			14.2		1	1.5			1.4			14.1		1
10/03/22 22:00	0.6			1.4			14.5		1	0.6			1.4			14.4		1
10/03/22 23:00	1.3			1.4			14		1	2.3			1.4			13.9		1
10/04/22 0:00	1.2			1.4			14		1	2.3			1.4			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/22 1:00	1.1			1.4			13.9		1	2.4			1.4			13.8		1
10/04/22 2:00	1.2			1.3			14		1	2.1			1.3			13.9		1
10/04/22 3:00	1.3			1.5			14		1	2.1			1.5			13.9		1
10/04/22 4:00	1.3			1.6			14.1		1	2			1.6			14		1
10/04/22 5:00	1.1			1.5			13.9		1	2.2			1.5			13.8		1
10/04/22 6:00	1.4			1.5			14.1		1	2.2			1.5			14		1
10/04/22 7:00	1.2			1.5			14.3		1	1.4			1.5			14.2		1
10/04/22 8:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/04/22 9:00	1.1			1.1			14.2		1	1.8			1.5			14.1		1
10/04/22 10:00	0.9			1.6			13.8		1	3			1.5			13.7		1
10/04/22 11:00	0.8			1.5			14.4		1	1			1.5			14.4		1
10/04/22 12:00	0.7			1.5			13.6		1	3.7			1.5			13.6		1
10/04/22 13:00	1			1.4			13.9		1	2.6			1.5			13.9		1
10/04/22 14:00	1			1.5			13.9		1	2.3			1.5			13.9		1
10/04/22 15:00	0.8			1.5			13.7		1	3.2			1.5			13.7		1
10/04/22 16:00	0.6			1.5			13.4		1	2.5			1.5			13.9		1
10/04/22 17:00	0.4			1.5			13.1		1	1.9			1.5			14		1
10/04/22 18:00	0.4			1.5			13.2		1	1.9			1.5			14		1
10/04/22 19:00	0.5			1.5			13.3		1	1.9			1.5			14		1
10/04/22 20:00	0.6			1.5			13.4		1	2			1.5			14		1
10/04/22 21:00	0.6			1.5			13.4		1	1.9			1.5			13.9		1
10/04/22 22:00	0.8			1.5			13.7		1	1.9			1.5			13.9		1
10/04/22 23:00	0.6			1.5			13.5		1	1.9			1.5			13.9		1
10/05/22 0:00	0.7			1.5			13.5		1	1.9			1.5			13.9		1
10/05/22 1:00	0.8			1.5			13.6		1	1.9			1.5			13.9		1
10/05/22 2:00	0.8			1.5			13.6		1	1.9			1.5			13.9		1
10/05/22 3:00	0.9			1.5			13.7		1	1.9			1.5			13.9		1
10/05/22 4:00	0.9			1.5			13.7		1	1.9			1.5			13.9		1
10/05/22 5:00	1			1.5			13.7		1	1.9			1.5			13.9		1
10/05/22 6:00	1.2			1.5			13.9		1	1.9			1.5			13.9		1
10/05/22 7:00	1.7			1.5			14.3		1	1.7			1.5			14		1
10/05/22 8:00	1.1			1.5			14.4		1	1.2			1.5			14.2		1
10/05/22 9:00	0.8			1.5			14.3		1	1.2			1.5			14.3		1
10/05/22 10:00	1			1.5			13.9		1	1.6			1.5			14		1
10/05/22 11:00	1			1.5			13.9		1	1.5			1.5			14		1
10/05/22 12:00	0.8			1.5			13.7		1	1.5			1.5			14		1
10/05/22 13:00	0.5			1.5			13.2		1	1.5			1.5			14		1
10/05/22 14:00	0.4			1.5			13.1		1	1.6			1.5			14		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/22 15:00	0.6			1.5			13.4		1	1.6			1.5			14		1
10/05/22 16:00	0.5			1.5			13.3		1	1.6			1.5			14		1
10/05/22 17:00	0.3			1.5			13.1		1	1.6			1.5			14		1
10/05/22 18:00	0.4			1.5			13.2		1	1.6			1.5			14		1
10/05/22 19:00	0.6			1.5			13.3		1	1.8			1.5			14		1
10/05/22 20:00	0.5			1.5			13.3		1	1.8			1.5			14		1
10/05/22 21:00	0.6			1.5			13.4		1	1.7			1.5			13.9		1
10/05/22 22:00	0.8			1.5			13.6		1	1.7			1.5			14		1
10/05/22 23:00	0.7			1.5			14.5		1	0.8			1.5			14.5		1
10/06/22 0:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/06/22 1:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/06/22 2:00	0.6			1.6			14.5		1	0.6			1.5			14.4		1
10/06/22 3:00	0.6			1.5			14.5		1	0.7			1.5			14.4		1
10/06/22 4:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/06/22 5:00	0.9			1.5			14.4		1	1.1			1.5			14.4		1
10/06/22 6:00	1.4			1.5			14		1	2.1			1.5			13.9		1
10/06/22 7:00	1.3			1.5			14.3		1	1.5			1.4			14.2		1
10/06/22 8:00	0.7			1.4			14.6		1	0.7			1.3			14.5		1
10/06/22 9:00	0.5			1.5			14.7		1	0.6			1.5			14.6		1
10/06/22 10:00	0.5			1.5			14.8		1	0.6			1.5			14.7		1
10/06/22 11:00	0.6			1.5			14.6		1	0.6			1.4			14.5		1
10/06/22 12:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1
10/06/22 13:00	0.7			1.5			14.5		1	0.9			1.5			14.4		1
10/06/22 14:00	0.6			1.5			13.5		1	2.2			1.5			13.9		1
10/06/22 15:00	0.6			1.5			13.4		1	1.8			1.5			14		1
10/06/22 16:00	0.4			1.5			13.2		1	1.8			1.5			14		1
10/06/22 17:00	0.4			1.5			13.1		1	1.8			1.5			14		1
10/06/22 18:00	0.4			1.5			13.2		1	1.9			1.5			14		1
10/06/22 19:00	0.5			1.5			13.3		1	2			1.5			14		1
10/06/22 20:00	0.6			1.5			13.3		1	2			1.5			14		1
10/06/22 21:00	0.6			1.5			13.5		1	2			1.5			14		1
10/06/22 22:00	0.9			1.5			13.7		1	2			1.5			13.9		1
10/06/22 23:00	0.9			1.5			13.7		1	1.9			1.5			13.9		1
10/07/22 0:00	1			1.5			13.8		1	2			1.5			13.9		1
10/07/22 1:00	1.2			1.5			13.8		1	2			1.5			13.9		1
10/07/22 2:00	1.2			1.5			14.2		1	1.9			1.5			14		1
10/07/22 3:00	1.1			1.5			14.2		1	1.6			1.5			14.1		1
10/07/22 4:00	1.2			1.5			13.9		1	1.9			1.5			14.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/22 5:00	1.2			1.5			13.8		1	1.8			1.5			14.1		1
10/07/22 6:00	1.5			1.5			14		1	1.9			1.5			14.1		1
10/07/22 7:00	1.5			1.5			14.2		1	1.8			1.5			14.2		1
10/07/22 8:00	1.3			1.5			14.2		1	1.6			1.5			14.2		1
10/07/22 9:00	1			1.5			14.1		1	1.6			1.5			14.2		1
10/07/22 10:00	0.6			1.5			13.5		1	1.5			1.5			14.2		1
10/07/22 11:00	0.4			1.5			13.2		1	1.4			1.5			14.1		1
10/07/22 12:00	0.4			1.5			13.2		1	1.5			1.5			14.1		1
10/07/22 13:00	0.6			1.5			13.5		1	1.5			1.5			14.1		1
10/07/22 14:00	0.8			1.5			13.7		1	1.5			1.5			14		1
10/07/22 15:00	0.6			1.5			13.4		1	1.5			1.5			14		1
10/07/22 16:00	0.5			1.5			13.3		1	1.5			1.5			14		1
10/07/22 17:00	0.4			1.5			13.1		1	1.6			1.5			14		1
10/07/22 18:00	0.4			1.5			13.2		1	1.7			1.5			14		1
10/07/22 19:00	0.5			1.5			13.2		1	1.7			1.5			14		1
10/07/22 20:00	0.5			1.5			13.3		1	1.8			1.5			14		1
10/07/22 21:00	0.6			1.5			13.5		1	1.7			1.5			14		1
10/07/22 22:00	0.8			1.5			13.7		1	1.7			1.5			14		1
10/07/22 23:00	0.8			1.5			13.6		1	1.7			1.5			14		1
10/08/22 0:00	0.8			1.5			13.7		1	1.7			1.5			14		1
10/08/22 1:00	1.1			1.5			13.9		1	1.7			1.5			14		1
10/08/22 2:00	1.1			1.5			13.9		1	1.7			1.5			14		1
10/08/22 3:00	1.2			1.5			13.9		1	1.8			1.5			13.9		1
10/08/22 4:00	1.2			1.5			13.9		1	1.8			1.5			13.9		1
10/08/22 5:00	1.2			1.5			13.9		1	1.8			1.5			13.9		1
10/08/22 6:00	1.2			1.5			14.3		1	1.5			1.5			14.1		1
10/08/22 7:00	0.7			1.4			14.5		1	0.8			1.3			14.4		1
10/08/22 8:00	0.6			1.5			14.6		1	0.8			1.3			14.5		1
10/08/22 9:00	0.6			1.4			14.6		1	0.7			1.3			14.5		1
10/08/22 10:00	0.5			1.5			14.8		1	0.6			1.5			14.7		1
10/08/22 11:00	0.6			1.4			14.6		1	0.6			1.4			14.5		1
10/08/22 12:00	0.6			1.5			14.5		1	0.7			1.6			14.4		1
10/08/22 13:00	1.2			1.5			14.4		1	1.3			1.5			14.3		1
10/08/22 14:00	0.9			1.5			14.3		1	1.3			1.5			14.2		1
10/08/22 15:00	0.6			1.5			13.5		1	2.1			1.5			14		1
10/08/22 16:00	0.4			1.5			13.2		1	2			1.5			14		1
10/08/22 17:00	0.3			1.5			13.2		1	2.1			1.5			13.9		1
10/08/22 18:00	0.5			1.5			13.3		1	2.2			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 19:00	0.5			1.5			13.3		1	2.2			1.5			13.9		1
10/08/22 20:00	0.6			1.5			13.4		1	2.2			1.5			13.9		1
10/08/22 21:00	0.8			1.5			13.7		1	2.2			1.5			14		1
10/08/22 22:00	0.8			1.4			14.3		1	1.8			1.4			14.3		1
10/08/22 23:00	1.4			1.5			14.4		1	0			0			17.4		1
10/09/22 0:00	1.6			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 1:00	1.6			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 2:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 3:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 4:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 5:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 6:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 7:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 8:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 9:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 10:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 11:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 12:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 13:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
10/09/22 14:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
10/09/22 15:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
10/09/22 16:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
10/09/22 17:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
10/09/22 18:00	1.2			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 19:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 20:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 21:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 22:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/09/22 23:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 0:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 1:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 2:00	1.3			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 3:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 4:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 5:00	1.2			1.5			14		1	0	X		0	X		0	X	1
10/10/22 6:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
10/10/22 7:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1
10/10/22 8:00	1.5			1.5			14.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/22 9:00	1.3			1.5			14.2		1	0	X		0	X		0	X	1
10/10/22 10:00	0.9			1.5			14.5		1	0	X		0	X		0	X	1
10/10/22 11:00	0.5			1.5			14.7		1	0	X		0	X		0	X	1
10/10/22 12:00	0.5			1.5			14.8		1	0	X		0	X		0	X	1
10/10/22 13:00	0.5			0.6			14.7		1	0	X		0	X		0	X	1
10/10/22 14:00	0.5			1.5			14.7		1	0	X		0	X		0	X	1
10/10/22 15:00	0.8			1.4			14.4		1	0	X		0	X		0	X	1
10/10/22 16:00	0.6			1.5			13		1	0	X		0	X		0	X	1
10/10/22 17:00	0.6			1.5			13.2		1	0	X		0	X		0	X	1
10/10/22 18:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/10/22 19:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/10/22 20:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/10/22 21:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/10/22 22:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/10/22 23:00	1			1.5			14.2		1	0	X		0	X		0	X	1
10/11/22 0:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
10/11/22 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 2:00	0.6			1.6			14.5		1	0	X		0	X		0	X	1
10/11/22 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/11/22 9:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/11/22 10:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/11/22 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/11/22 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/11/22 13:00	0.5			1.5			14.7		1	0	X		0	X		0	X	1
10/11/22 14:00	0.5			1.5			14.7		1	0	X		0	X		0	X	1
10/11/22 15:00	0.9			1.5			14.3		1	0	X		0	X		0	X	1
10/11/22 16:00	1.2			1.5			14		1	0	X		0	X		0	X	1
10/11/22 17:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/11/22 18:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/11/22 19:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/11/22 20:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/11/22 21:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/11/22 22:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/22 23:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 0:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 1:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 2:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 3:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 4:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 5:00	1.3			1.5			14		1	0	X		0	X		0	X	1
10/12/22 6:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/12/22 7:00	0.9			1.5			14.2		1	0	X		0	X		0	X	1
10/12/22 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/12/22 9:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/12/22 10:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 15:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 16:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 17:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 18:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 19:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/12/22 20:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/12/22 21:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/12/22 22:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/12/22 23:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 0:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 1:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 2:00	0.5			1.4			14.5		1	0	X		0	X		0	X	1
10/13/22 3:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 4:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 5:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 6:00	0.6			1.4			14.3		1	0	X		0	X		0	X	1
10/13/22 7:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 8:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 9:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 10:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/13/22 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/13/22 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/22 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/13/22 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/13/22 15:00	0.9			1.5			14.3		1	0	X		0	X		0	X	1
10/13/22 16:00	1.1			1.5			13.8		1	0	X		0	X		0	X	1
10/13/22 17:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 18:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 19:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 20:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 21:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 22:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/13/22 23:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/14/22 0:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/14/22 1:00	1.3			1.5			14		1	0	X		0	X		0	X	1
10/14/22 2:00	1.3			1.5			14		1	0	X		0	X		0	X	1
10/14/22 3:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 4:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 5:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 6:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 7:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
10/14/22 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/14/22 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/14/22 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/14/22 11:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/14/22 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/14/22 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/14/22 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/14/22 15:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/14/22 16:00	1			1.5			14.3		1	0	X		0	X		0	X	1
10/14/22 17:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 18:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/14/22 19:00	1.5			1.5			14		1	0	X		0	X		0	X	1
10/14/22 20:00	1.4			1.5			14		1	0	X		0	X		0	X	1
10/14/22 21:00	1.5			1.5			14		1	0	X		0	X		0	X	1
10/14/22 22:00	1.5			1.5			14		1	0	X		0	X		0	X	1
10/14/22 23:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/15/22 0:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/15/22 1:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/15/22 2:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/22 3:00	1			1.5			14.2		1	0	X		0	X		0	X	1
10/15/22 4:00	1.8			1.5			14		1	0	X		0	X		0	X	1
10/15/22 5:00	1.7			1.5			14		1	0	X		0	X		0	X	1
10/15/22 6:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/15/22 7:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
10/15/22 8:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 10:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 11:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/15/22 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/15/22 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/15/22 15:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/15/22 16:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
10/15/22 17:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 18:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 19:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 20:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 21:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 22:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/15/22 23:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 0:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 1:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 2:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 3:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 4:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 5:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 6:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 7:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 8:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
10/16/22 9:00	0.5			1.4			14.4		1	0	X		0	X		0	X	1
10/16/22 10:00	1			1.5			14.3		1	0	X		0	X		0	X	1
10/16/22 11:00	1.8			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 12:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 13:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 14:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 15:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 16:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/22 17:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 18:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 19:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 20:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 21:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 22:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/16/22 23:00	1.7			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 0:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 1:00	1.3			1.5			14.2		1	0	X		0	X		0	X	1
10/17/22 2:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
10/17/22 3:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
10/17/22 4:00	1.2			1.5			14.2		1	0	X		0	X		0	X	1
10/17/22 5:00	1.8			1.5			14		1	0	X		0	X		0	X	1
10/17/22 6:00	1.7			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 7:00	1.5			1.3			14.1		1	0	X		0	X		0	X	1
10/17/22 8:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 9:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 10:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 11:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 12:00	1			1.5			14		1	0	X		0	X		0	X	1
10/17/22 13:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 14:00	0.9			1.5			14		1	0	X		0	X		0	X	1
10/17/22 15:00	0.9			1.5			14		1	0	X		0	X		0	X	1
10/17/22 16:00	0.9			1.5			14		1	0	X		0	X		0	X	1
10/17/22 17:00	1			1.5			14		1	0	X		0	X		0	X	1
10/17/22 18:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 19:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 20:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 21:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/17/22 22:00	1.3			1.5			14		1	0	X		0	X		0	X	1
10/17/22 23:00	1.3			1.5			13.8		1	0	X		0	X		0	X	1
10/18/22 0:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 1:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 2:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 3:00	1.5			1.5			14		1	0	X		0	X		0	X	1
10/18/22 4:00	1.3			1.5			13.8		1	0	X		0	X		0	X	1
10/18/22 5:00	1.1			1.5			13.6		1	0	X		0	X		0	X	1
10/18/22 6:00	0.7			1.5			13.2		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 7:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
10/18/22 8:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 9:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 10:00	1			1.5			13.9		1	0	X		0	X		0	X	1
10/18/22 11:00	1			1.5			13.9		1	0	X		0	X		0	X	1
10/18/22 12:00	1.1			1.5			13.9		1	0	X		0	X		0	X	1
10/18/22 13:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
10/18/22 14:00	0.7			1.4			14.4		1	0			0			20		1
10/18/22 15:00	0.8			1.5			14.4		1	0.5			0.5			14.7		1
10/18/22 16:00	0.7			1.4			13.9		1	0.9			0.8			14.2		1
10/18/22 17:00	0.3			1.5			12.7		1	0.3			1.6			12.8		1
10/18/22 18:00	0.4			1.5			12.9		1	0.4			1.5			13		1
10/18/22 19:00	0.2			1.5			12.2		1	0.3			1.5			12.3		1
10/18/22 20:00	0.4			1.5			12.9		1	0.5			1.5			12.9		1
10/18/22 21:00	0.5			1.5			13.1		1	0.6			1.5			13.1		1
10/18/22 22:00	1.1			1.5			13.5		1	1.1			1.5			13.6		1
10/18/22 23:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
10/19/22 0:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/19/22 1:00	0.7			1.5			14.2		1	0.7			1.5			14.3		1
10/19/22 2:00	0.7			1.6			14.2		1	0.8			1.6			14.2		1
10/19/22 3:00	0.9			1.5			14.3		1	0.9			1.5			14.3		1
10/19/22 4:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
10/19/22 5:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
10/19/22 6:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
10/19/22 7:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
10/19/22 8:00	0.6			1.5			14.8		1	0.7			1.3			14.5		1
10/19/22 9:00	0	X		0	X		0	X	1	0.6			1.5			14.4		1
10/19/22 10:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
10/19/22 11:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
10/19/22 12:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
10/19/22 13:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
10/19/22 14:00	0	X		0	X		0	X	1	0.8			1.4			14.4		1
10/19/22 15:00	0	X		0	X		0	X	1	1			1.5			14		1
10/19/22 16:00	0.4			1.4			15.5		1	0.7			1.4			14.4		1
10/19/22 17:00	0.6			1.4			14.4		1	0.6			1.2			14.4		1
10/19/22 18:00	1.6			1.5			14.1		1	1.9			1.6			14.2		1
10/19/22 19:00	1.1			1.5			14		1	1.1			1.5			14		1
10/19/22 20:00	1.2			1.5			13.8		1	1			1.5			13.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 21:00	1.2			1.5			13.9		1	1.1			1.5			13.9		1
10/19/22 22:00	0.7			1.5			14.4		1	0.7			1.4			14.4		1
10/19/22 23:00	0.7			1.5			14.3		1	0.8			1.4			14.2		1
10/20/22 0:00	0.7			1.5			14.2		1	0.7			1.5			14.2		1
10/20/22 1:00	0.7			1.4			14.3		1	0.7			1.4			14.3		1
10/20/22 2:00	0.6			1.5			14.5		1	0.6			1.4			14.5		1
10/20/22 3:00	0.8			1.5			14.2		1	0.8			1.5			14.2		1
10/20/22 4:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
10/20/22 5:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/20/22 6:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/20/22 7:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/20/22 8:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/20/22 9:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/20/22 10:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/20/22 11:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/20/22 12:00	0.4			1.5			14.7		1	0.5			1.4			14.7		1
10/20/22 13:00	0.5			1.4			14.6		1	0.6			1.4			14.6		1
10/20/22 14:00	0.5			1.4			14.5		1	0.6			1.4			14.5		1
10/20/22 15:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/20/22 16:00	0.3			1.5			12.7		1	0.3			1.5			12.7		1
10/20/22 17:00	0.5			1.5			13.2		1	0.5			1.5			13.2		1
10/20/22 18:00	0.8			1.5			13.6		1	0.8			1.5			13.6		1
10/20/22 19:00	1.3			1.5			14		1	1.2			1.5			14		1
10/20/22 20:00	1.2			1.5			14		1	1.1			1.5			14		1
10/20/22 21:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/20/22 22:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
10/20/22 23:00	0.7			1.5			14.3		1	0.7			1.4			14.3		1
10/21/22 0:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/21/22 1:00	0.7			1.4			14.3		1	0.7			1.3			14.3		1
10/21/22 2:00	0.6			1.5			14.5		1	0.6			1.4			14.4		1
10/21/22 3:00	0.7			1.5			14.3		1	0.7			1.4			14.3		1
10/21/22 4:00	0.7			1.4			14.2		1	0.8			1.2			14.2		1
10/21/22 5:00	0.7			1.5			14.3		1	0.8			1.4			14.3		1
10/21/22 6:00	1.1			1.5			14.1		1	1.4			1.5			14.1		1
10/21/22 7:00	1.4			1.5			14.1		1	1.4			1.5			14.1		1
10/21/22 8:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/21/22 9:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/21/22 10:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/22 11:00	0.6			1.5			14.6		1	0.6			1.4			14.6		1
10/21/22 12:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/21/22 13:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/21/22 14:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/21/22 15:00	0.8			1.4			14.2		1	0.9			1.3			14.2		1
10/21/22 16:00	0.8			1.5			13.5		1	0.9			1.5			13.5		1
10/21/22 17:00	1			1.5			13.7		1	1			1.5			13.7		1
10/21/22 18:00	1.1			1.5			14		1	1			1.5			14		1
10/21/22 19:00	0.7			1.5			14.2		1	0.8			1.5			14.2		1
10/21/22 20:00	0.7			1.5			14.2		1	0.7			1.4			14.2		1
10/21/22 21:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/21/22 22:00	0.6			1.5			14.4		1	0.6			1.5			14.3		1
10/21/22 23:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 0:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 1:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 2:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 3:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 4:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 5:00	0.8			1.5			14.2		1	1			1.5			14.2		1
10/22/22 6:00	0.3			1.5			12		1	0.3			1.5			12.1		1
10/22/22 7:00	0.2			1.5			11.8		1	0.2			1.5			11.9		1
10/22/22 8:00	0.3			1.5			12.6		1	0.3			1.5			12.6		1
10/22/22 9:00	0.3			1.5			12.7		1	0.4			1.5			12.7		1
10/22/22 10:00	0.4			1.5			13		1	0.5			1.5			13		1
10/22/22 11:00	1			1.5			13.7		1	1			1.5			13.7		1
10/22/22 12:00	1.1			1.5			14.1		1	1.1			1.5			14.1		1
10/22/22 13:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
10/22/22 14:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 15:00	0.5			1.4			14.4		1	0.6			1.3			14.4		1
10/22/22 16:00	0.5			1.5			14.4		1	0.6			1.4			14.4		1
10/22/22 17:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 18:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 19:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 20:00	0.9			1.5			14.2		1	1.2			1.5			14.2		1
10/22/22 21:00	1.1			1.5			13.8		1	1.1			1.5			13.8		1
10/22/22 22:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
10/22/22 23:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/23/22 0:00	1			1.5			13.9		1	1.3			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/22 1:00	0.9			1.5			14.1		1	1			1.5			14.1		1
10/23/22 2:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/23/22 3:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
10/23/22 4:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/23/22 5:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/23/22 6:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/23/22 7:00	1			1.5			14.1		1	1.3			1.5			14.1		1
10/23/22 8:00	1.1			1.5			13.9		1	1.2			1.5			13.9		1
10/23/22 9:00	0.8			1.5			14.2		1	0.9			1.5			14.2		1
10/23/22 10:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/23/22 11:00	1			1.5			13.9		1	1			1.5			13.8		1
10/23/22 12:00	0.7			1.5			14.2		1	0.8			1.5			14.3		1
10/23/22 13:00	0.6			1.5			14.5		1	0.7			1.4			14.5		1
10/23/22 14:00	0.6			1.5			14.4		1	0.7			1.9			14.4		1
10/23/22 15:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/23/22 16:00	0.5			1.5			14.5		1	0.6			1.5			14.5		1
10/23/22 17:00	0.6			1.5			14.5		1	0.7			1.5			14.4		1
10/23/22 18:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/23/22 19:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/23/22 20:00	1			1.5			13.9		1	1.2			1.5			13.9		1
10/23/22 21:00	0.9			1.5			13.9		1	1.1			1.5			13.9		1
10/23/22 22:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/23/22 23:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/24/22 0:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/24/22 1:00	0.6			1.5			14.3		1	0.8			1.5			14.3		1
10/24/22 2:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
10/24/22 3:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/24/22 4:00	0.6			1.5			14.3		1	0.8			1.5			14.3		1
10/24/22 5:00	0.9			1.5			14.2		1	1.2			1.5			14.2		1
10/24/22 6:00	0.6			1.5			13.1		1	0.8			1.5			13.1		1
10/24/22 7:00	1			1.5			13.5		1	1.1			1.5			13.5		1
10/24/22 8:00	1.2			1.5			14.1		1	1.3			1.5			14.1		1
10/24/22 9:00	1			1.5			14		1	1.2			1.5			14		1
10/24/22 10:00	1			1.5			14.1		1	1.1			1.5			14.1		1
10/24/22 11:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/24/22 12:00	0.4			1.5			14.6		1	0.6			1.8			14.6		1
10/24/22 13:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/24/22 14:00	0.7			1.4			14.4		1	1			1.4			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/22 15:00	1.5			1.5			14.1		1	1.7			1.5			14.2		1
10/24/22 16:00	0.7			1.5			13.4		1	0.9			1.5			13.5		1
10/24/22 17:00	1			1.5			13.7		1	1.1			1.5			13.7		1
10/24/22 18:00	1.4			1.5			14.1		1	1.7			1.5			14.1		1
10/24/22 19:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
10/24/22 20:00	1.1			1.5			13.9		1	1.1			1.5			13.9		1
10/24/22 21:00	0.7			1.5			14.2		1	0.8			1.4			14.2		1
10/24/22 22:00	0.6			1.4			14.4		1	0.7			1.4			14.4		1
10/24/22 23:00	0.6			1.5			14.3		1	0.7			1.4			14.3		1
10/25/22 0:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/25/22 1:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/25/22 2:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/25/22 3:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/25/22 4:00	0.7			1.5			14.2		1	0.8			1.4			14.2		1
10/25/22 5:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/25/22 6:00	1.3			1.5			13.7		1	1.5			1.5			13.7		1
10/25/22 7:00	1			1.5			13.9		1	1.2			1.5			13.8		1
10/25/22 8:00	0.8			1.5			14.2		1	1			1.4			14.1		1
10/25/22 9:00	0.7			1.5			14.3		1	0.8			1.4			14.2		1
10/25/22 10:00	0.5			1.5			14.7		1	0.6			1.5			14.6		1
10/25/22 11:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
10/25/22 12:00	0.6			1.5			14.5		1	1			1.4			14.5		1
10/25/22 13:00	0.9			1.5			13.8		1	1.1			1.5			13.7		1
10/25/22 14:00	0.6			1.5			13.3		1	0.8			1.5			13.3		1
10/25/22 15:00	0.6			1.5			13.3		1	0.7			1.5			13.3		1
10/25/22 16:00	0.4			1.5			13		1	0.6			1.5			13		1
10/25/22 17:00	0.5			1.5			13.2		1	0.6			1.5			13.1		1
10/25/22 18:00	0.8			1.5			13.5		1	1			1.5			13.5		1
10/25/22 19:00	0.9			1.5			13.6		1	1			1.5			13.6		1
10/25/22 20:00	0.9			1.5			13.5		1	1			1.5			13.4		1
10/25/22 21:00	1.1			1.5			13.9		1	1.2			1.5			13.9		1
10/25/22 22:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/25/22 23:00	0.7			1.5			14.3		1	0.9			1.4			14.2		1
10/26/22 0:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/26/22 1:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/26/22 2:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/26/22 3:00	0.7			1.6			14.3		1	0.8			1.6			14.3		1
10/26/22 4:00	0.7			1.5			14.2		1	0.9			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/22 5:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/26/22 6:00	0.6			1.5			14.3		1	0.8			1.5			14.3		1
10/26/22 7:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/26/22 8:00	0.9			1.5			14.1		1	1.2			1.5			14.1		1
10/26/22 9:00	1			1.5			13.8		1	1.2			1.5			13.9		1
10/26/22 10:00	1			1.5			13.7		1	1.1			1.5			13.7		1
10/26/22 11:00	0.8			1.4			14.4		1	0.9			1.4			14.4		1
10/26/22 12:00	0.4			1.5			14.6		1	0.6			1.5			14.6		1
10/26/22 13:00	0.4			1.5			14.6		1	0.6			1.5			14.7		1
10/26/22 14:00	0.6			1.4			14.5		1	0.7			1.5			14.5		1
10/26/22 15:00	0.5			1.3			14.6		1	0.7			1.3			14.6		1
10/26/22 16:00	0.8			1.4			14.3		1	1			1.3			14.3		1
10/26/22 17:00	0.8			1.5			13.8		1	1			1.5			13.8		1
10/26/22 18:00	1.1			1.5			14.2		1	1.1			1.5			14.2		1
10/26/22 19:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
10/26/22 20:00	0.6			1.4			14.4		1	0.8			1.4			14.4		1
10/26/22 21:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
10/26/22 22:00	0.5			1.5			14.5		1	0.6			1.5			14.5		1
10/26/22 23:00	0.5			1.4			14.5		1	0.6			1.4			14.5		1
10/27/22 0:00	0.4			1.5			14.6		1	0.6			1.5			14.6		1
10/27/22 1:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/27/22 2:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
10/27/22 3:00	0.9			1.5			14.4		1	1			1.4			14.4		1
10/27/22 4:00	0.8			1.5			14.4		1	0.9			1.4			14.4		1
10/27/22 5:00	0.8			1.5			14.3		1	0.9			1.4			14.3		1
10/27/22 6:00	0.7			1.6			14.3		1	0.9			1.5			14.3		1
10/27/22 7:00	0.8			1.4			14.2		1	0.9			1.4			14.2		1
10/27/22 8:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/27/22 9:00	1.2			1.5			14.1		1	1.4			1.5			14.1		1
10/27/22 10:00	0.9			1.5			14.2		1	1.1			1.5			14.2		1
10/27/22 11:00	1			1.5			14.1		1	1.2			1.6			14.1		1
10/27/22 12:00	0.9			1.5			14		1	1			1.5			14		1
10/27/22 13:00	0.9			1.5			14.1		1	1			1.5			14.1		1
10/27/22 14:00	0.5			1.5			14.5		1	0.7			1.5			14.5		1
10/27/22 15:00	0.5			1.5			14.6		1	0.7			1.4			14.6		1
10/27/22 16:00	1			1.6			13.5		1	1.2			1.5			13.5		1
10/27/22 17:00	1			1.5			13.7		1	1.1			1.5			13.7		1
10/27/22 18:00	1.3			1.5			14		1	1.3			1.5			14		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/22 19:00	1.4			1.5			13.9		1	1.5			1.5			13.9		1
10/27/22 20:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
10/27/22 21:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
10/27/22 22:00	1.6			1.5			14.1		1	1.9			1.5			14.1		1
10/27/22 23:00	0.7			1.5			14.2		1	0.9			1.5			14.2		1
10/28/22 0:00	0.7			1.5			14.2		1	0.9			1.5			14.2		1
10/28/22 1:00	0.7			1.5			14.2		1	1			1.5			14.1		1
10/28/22 2:00	0.7			1.6			14.2		1	0.9			1.5			14.2		1
10/28/22 3:00	1.3			1.6			14.2		1	1.9			1.5			14.2		1
10/28/22 4:00	1.1			1.5			13.7		1	1.3			1.5			13.7		1
10/28/22 5:00	1			1.5			13.5		1	1			1.5			13.6		1
10/28/22 6:00	1			1.5			13.6		1	1.1			1.5			13.6		1
10/28/22 7:00	1.3			1.5			14.1		1	1.9			1.5			14.1		1
10/28/22 8:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
10/28/22 9:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/28/22 10:00	1.2			1.5			14.1		1	1.4			1.5			14.1		1
10/28/22 11:00	0.8			1.5			14.3		1	1			1.3			14.3		1
10/28/22 12:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/28/22 13:00	0.7			1.4			14.4		1	0.8			1.7			14.4		1
10/28/22 14:00	0.9			1.5			14.4		1	1.2			1.4			14.4		1
10/28/22 15:00	1.1			1.5			13.7		1	1.3			1.5			13.7		1
10/28/22 16:00	1.1			1.5			13.7		1	1.4			1.5			13.8		1
10/28/22 17:00	0.5			1.5			13.1		1	0.7			1.5			13.1		1
10/28/22 18:00	0.5			1.5			13.1		1	0.7			1.5			13.1		1
10/28/22 19:00	0.6			1.5			13.1		1	0.7			1.5			13.1		1
10/28/22 20:00	0.4			1.5			13		1	0.7			1.5			13		1
10/28/22 21:00	0.5			1.5			13		1	0.7			1.5			13		1
10/28/22 22:00	1.1			1.5			13.6		1	1.2			1.5			13.7		1
10/28/22 23:00	0.8			1.5			14.3		1	1			1.5			14.3		1
10/29/22 0:00	0.9			1.5			14.2		1	1			1.4			14.1		1
10/29/22 1:00	0.9			1.5			14.2		1	1			1.5			14.1		1
10/29/22 2:00	0.8			1.4			14.2		1	1			1.3			14.2		1
10/29/22 3:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/29/22 4:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
10/29/22 5:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
10/29/22 6:00	0.8			1.5			14.2		1	1.1			1.5			14.2		1
10/29/22 7:00	0.8			1.5			14.3		1	1			1.4			14.3		1
10/29/22 8:00	0.8			1.5			14.3		1	1			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/22 9:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/29/22 10:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/29/22 11:00	0.7			1.5			14.4		1	0.8			1.7			14.4		1
10/29/22 12:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
10/29/22 13:00	0.6			1.4			14.5		1	0.8			1.2			14.5		1
10/29/22 14:00	0.6			1.4			14.5		1	0.8			1.4			14.5		1
10/29/22 15:00	0.6			1.4			14.6		1	0.7			1.7			14.6		1
10/29/22 16:00	0.6			1.5			14.5		1	0.8			1.9			14.5		1
10/29/22 17:00	0.7			1.5			14.3		1	0.9			1.9			14.4		1
10/29/22 18:00	0.7			1.5			14.5		1	0.8			1.8			14.5		1
10/29/22 19:00	0.7			1.5			14.5		1	0.9			1.4			14.5		1
10/29/22 20:00	1			1.6			14.3		1	1.3			1.5			14.3		1
10/29/22 21:00	1.4			1.5			14.1		1	1.5			1.5			14.1		1
10/29/22 22:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
10/29/22 23:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/30/22 0:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 1:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 2:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 3:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 4:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 5:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/30/22 6:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 7:00	0.8			1.4			14.5		1	0.9			1.5			14.4		1
10/30/22 8:00	0.5			1.2			14.6		1	0.7			1.6			14.5		1
10/30/22 9:00	0.5			1.2			14.6		1	0.7			1.6			14.6		1
10/30/22 10:00	0.5			1.2			14.6		1	0.7			1.6			14.6		1
10/30/22 11:00	0.4			1.2			14.7		1	0.7			1.6			14.6		1
10/30/22 12:00	0.5			1.4			14.7		1	0.7			1.6			14.6		1
10/30/22 13:00	0.5			1.5			14.7		1	0.7			1.6			14.6		1
10/30/22 14:00	0.5			1.5			14.7		1	0.7			1.6			14.6		1
10/30/22 15:00	0.5			1.4			14.6		1	0.7			1.5			14.6		1
10/30/22 16:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/30/22 17:00	0.9			1.5			14.3		1	1.3			1.5			14.3		1
10/30/22 18:00	1.7			1.5			14.1		1	1.7			1.5			14.1		1
10/30/22 19:00	0.8			1.5			14.3		1	1			1.5			14.3		1
10/30/22 20:00	0.8			1.5			14.3		1	1			1.5			14.3		1
10/30/22 21:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/30/22 22:00	0.8			1.5			14.2		1	0.9			1.5			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/22 23:00	0.7			1.5			14.2		1	0.9			1.5			14.3		1
10/31/22 0:00	0.7			1.5			14.2		1	0.9			1.5			14.2		1
10/31/22 1:00	0.7			1.5			14.2		1	0.9			1.5			14.2		1
10/31/22 2:00	0.7			1.5			14.2		1	0.9			1.5			14.3		1
10/31/22 3:00	0.8			1.5			14.2		1	1			1.5			14.2		1
10/31/22 4:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/31/22 5:00	1			1.5			14		1	1.4			1.5			13.9		1
10/31/22 6:00	1.1			1.5			13.6		1	1.2			1.5			13.6		1
10/31/22 7:00	1			1.5			14.3		1	1.3			1.5			14.2		1
10/31/22 8:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
10/31/22 9:00	0.7			1.5			14.4		1	0.9			1.3			14.3		1
10/31/22 10:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/31/22 11:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/31/22 12:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/31/22 13:00	0.6			1.5			14.4		1	0.8			1.3			14.3		1
10/31/22 14:00	0.9			1.5			14.1		1	1.3			1.4			14.1		1
10/31/22 15:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
10/31/22 16:00	0.8			1.4			14.2		1	0.9			1.4			14.2		1
10/31/22 17:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/31/22 18:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/31/22 19:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
10/31/22 20:00	0.8			1.5			14.2		1	1			1.3			14.2		1
10/31/22 21:00	0.8			1.4			14.2		1	1			1.4			14.2		1
10/31/22 22:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
10/31/22 23:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/01/22 0:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/01/22 1:00	1			1.5			14.2		1	1.3			1.5			14.2		1
11/01/22 2:00	1			1.5			13.5		1	1.1			1.4			13.5		1
11/01/22 3:00	0.7			1.5			13.1		1	0.8			1.5			13.2		1
11/01/22 4:00	0.5			1.5			12.9		1	0.6			1.5			13		1
11/01/22 5:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1
11/01/22 6:00	0.5			1.5			12.7		1	0.6			1.5			12.7		1
11/01/22 7:00	0.8			1.5			13.1		1	0.8			1.5			13.2		1
11/01/22 8:00	1			1.5			13.5		1	1			1.5			13.5		1
11/01/22 9:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/01/22 10:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/01/22 11:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/01/22 12:00	0.7			1.5			13.2		1	0.9			1.5			13.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/22 13:00	0.7			1.5			13.3		1	0.9			1.5			13.3		1
11/01/22 14:00	1.4			1.5			13.9		1	1.4			1.5			14		1
11/01/22 15:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
11/01/22 16:00	0.8			1.5			13.3		1	0.9			1.5			13.4		1
11/01/22 17:00	0.9			1.5			13.5		1	1			1.5			13.6		1
11/01/22 18:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
11/01/22 19:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
11/01/22 20:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
11/01/22 21:00	1.4			1.5			13.9		1	1.4			1.5			13.9		1
11/01/22 22:00	1.6			1.5			14		1	1.8			1.5			14		1
11/01/22 23:00	0.8			1.5			14.2		1	1			1.5			14.2		1
11/02/22 0:00	0.5			1.5			14.4		1	0.7			1.5			14.4		1
11/02/22 1:00	0.7			1.5			14.2		1	0.9			1.4			14.2		1
11/02/22 2:00	0.7			1.7			14.3		1	0.8			1.6			14.3		1
11/02/22 3:00	0.8			1.6			14.2		1	0.9			1.6			14.2		1
11/02/22 4:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/02/22 5:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/02/22 6:00	1.4			1.5			13.8		1	1.6			1.5			13.8		1
11/02/22 7:00	1			1.5			14.3		1	1.1			1.5			14.3		1
11/02/22 8:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/02/22 9:00	0.6			1.5			14.4		1	0.8			1.4			14.4		1
11/02/22 10:00	0.6			1.5			14.3		1	0.9			1.4			14.3		1
11/02/22 11:00	1.1			1.5			14.1		1	1.5			1.5			14.1		1
11/02/22 12:00	1.2			1.5			14		1	1.4			1.5			14.1		1
11/02/22 13:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/02/22 14:00	1.3			1.5			14.1		1	1.6			1.5			14.1		1
11/02/22 15:00	1.1			1.5			14		1	1.3			1.5			14		1
11/02/22 16:00	0.8			1.5			13.5		1	1			1.5			13.5		1
11/02/22 17:00	0.5			1.5			13.1		1	0.7			1.5			13.1		1
11/02/22 18:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
11/02/22 19:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
11/02/22 20:00	0.6			1.5			13.2		1	0.8			1.5			13.2		1
11/02/22 21:00	0.9			1.5			13.4		1	1			1.5			13.4		1
11/02/22 22:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/02/22 23:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/03/22 0:00	0.6			1.5			14.3		1	0.8			1.5			14.3		1
11/03/22 1:00	0.6			1.5			14.3		1	0.9			1.5			14.3		1
11/03/22 2:00	0.6			1.5			14.3		1	0.9			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/22 3:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/03/22 4:00	1			1.5			14.3		1	1.5			1.5			14.3		1
11/03/22 5:00	0.5			1.5			12.7		1	0.7			1.5			12.8		1
11/03/22 6:00	0.3			1.5			12.3		1	0.4			1.5			12.4		1
11/03/22 7:00	1.1			1.5			14.1		1	1.2			1.5			14.1		1
11/03/22 8:00	0.7			1.5			14.2		1	0.9			1.5			14.2		1
11/03/22 9:00	1.6			1.5			14.1		1	2.4			1.5			14.1		1
11/03/22 10:00	1.2			1.7			13.9		1	1.4			1.6			13.9		1
11/03/22 11:00	0.7			1.4			14.3		1	1			1.4			14.2		1
11/03/22 12:00	0.5			1.5			14.5		1	0.7			1.5			14.5		1
11/03/22 13:00	0.5			1.5			14.5		1	0.7			1.4			14.5		1
11/03/22 14:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
11/03/22 15:00	0.5			1.5			14.6		1	0.7			1.4			14.6		1
11/03/22 16:00	0.6			1.5			14.4		1	0.8			1.4			14.4		1
11/03/22 17:00	0.9			1.5			13.6		1	1.1			1.5			13.6		1
11/03/22 18:00	1			1.5			13.7		1	1.1			1.5			13.7		1
11/03/22 19:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/03/22 20:00	0.5			1.5			13.1		1	0.7			1.5			13.1		1
11/03/22 21:00	0.4			1.5			12.9		1	0.6			1.5			12.9		1
11/03/22 22:00	0.9			1.5			13.5		1	1.2			1.5			13.5		1
11/03/22 23:00	1.3			1.5			14.1		1	1.8			1.5			14.1		1
11/04/22 0:00	0.8			1.5			14.2		1	1.1			1.5			14.3		1
11/04/22 1:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/04/22 2:00	0.8			1.6			14.2		1	1			1.6			14.2		1
11/04/22 3:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/04/22 4:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/04/22 5:00	1			1.5			13.4		1	1.2			1.5			13.5		1
11/04/22 6:00	0.8			1.5			13.4		1	1			1.5			13.4		1
11/04/22 7:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
11/04/22 8:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/04/22 9:00	0.6			1.5			14.4		1	0.8			1.3			14.4		1
11/04/22 10:00	0.5			1.5			14.5		1	0.7			1.5			14.5		1
11/04/22 11:00	0.5			1.5			14.6		1	0.7			1.5			14.7		1
11/04/22 12:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/04/22 13:00	0.5			1.5			14.6		1	0.7			1.6			14.6		1
11/04/22 14:00	0.5			1.5			14.6		1	0.7			1.7			14.7		1
11/04/22 15:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
11/04/22 16:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/22 17:00	0.7			1.5			14.4		1	0.9			1.7			14.4		1
11/04/22 18:00	1.1			1.5			13.8		1	1.3			1.6			13.8		1
11/04/22 19:00	1.2			1.5			13.8		1	1.2			1.7			13.8		1
11/04/22 20:00	1.3			1.5			13.9		1	1.4			1.7			13.9		1
11/04/22 21:00	0.7			1.5			14.4		1	0.8			2			14.4		1
11/04/22 22:00	0.5			1.5			14.6		1	0.7			1.7			14.6		1
11/04/22 23:00	0.7			1.4			14.3		1	0.9			0.7			14.3		1
11/05/22 0:00	0.6			1.5			14.5		1	0.7			1.6			14.5		1
11/05/22 1:00	0.6			1.5			14.5		1	0.7			1.7			14.5		1
11/05/22 2:00	0.6			1.5			14.5		1	0.7			1.7			14.5		1
11/05/22 3:00	0.6			1.5			14.5		1	0.7			1.7			14.5		1
11/05/22 4:00	0.6			1.5			14.5		1	0.7			1.7			14.5		1
11/05/22 5:00	0.6			1.4			14.4		1	0.8			1.4			14.4		1
11/05/22 6:00	0.6			1.4			14.5		1	0.7			1.6			14.5		1
11/05/22 7:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
11/05/22 8:00	0.5			1.5			14.6		1	0.7			1.6			14.6		1
11/05/22 9:00	0.6			1.5			14.5		1	0.7			1.6			14.5		1
11/05/22 10:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/05/22 11:00	0.7			1.4			14.4		1	0.8			1.5			14.4		1
11/05/22 12:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
11/05/22 13:00	0.7			1.5			14.3		1	0.8			1.4			14.3		1
11/05/22 14:00	0.7			1.5			14.3		1	0.9			1.6			14.3		1
11/05/22 15:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/05/22 16:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
11/05/22 17:00	1			1.5			14.2		1	1.2			1.6			14.2		1
11/05/22 18:00	1.4			1.5			14		1	1.5			1.6			14		1
11/05/22 19:00	1.3			1.5			14.1		1	1.5			1.6			14.1		1
11/05/22 20:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
11/05/22 21:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/05/22 22:00	0.6			1.5			14.5		1	0.6			1.6			14.5		1
11/05/22 23:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
11/06/22 0:00	0.7			1.5			14.2		1	0.9			1.6			14.3		1
11/06/22 1:00	0.8			1.5			14.1		1	1			1.6			14.1		1
11/06/22 2:00	0.7			1.9			14.3		1	0.9			1.6			14.3		1
11/06/22 3:00	0.7			1.5			14.3		1	0.8			1.6			14.3		1
11/06/22 4:00	0.7			1.5			14.3		1	0.9			1.6			14.3		1
11/06/22 5:00	0.6			1.5			14.4		1	0.8			1.6			14.4		1
11/06/22 6:00	0.6			1.5			14.4		1	0.8			1.6			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/22 7:00	0.7			1.5			14.4		1	0.8			1.6			14.4		1
11/06/22 8:00	1.3			1.5			13.8		1	1.5			1.6			13.8		1
11/06/22 9:00	1.2			1.5			14		1	1.3			1.6			14		1
11/06/22 10:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
11/06/22 11:00	0.6			1.5			14.4		1	0.7			1.7			14.5		1
11/06/22 12:00	0.6			1.5			14.5		1	0.7			1.7			14.5		1
11/06/22 13:00	0.6			1.5			14.5		1	0.7			1.6			14.5		1
11/06/22 14:00	0.6			1.5			14.5		1	0.8			1.5			14.4		1
11/06/22 15:00	1.1			1.5			13.9		1	1.4			1.7			13.9		1
11/06/22 16:00	0.8			1.5			13.3		1	0.9			1.7			13.3		1
11/06/22 17:00	1.1			1.5			13.7		1	1.1			1.7			13.7		1
11/06/22 18:00	1.2			1.5			13.9		1	1.4			1.7			14		1
11/06/22 19:00	1.3			1.5			14		1	1.5			1.7			14		1
11/06/22 20:00	1.2			1.5			14		1	1.4			1.7			14		1
11/06/22 21:00	1.2			1.5			13.9		1	1.4			1.7			14		1
11/06/22 22:00	0.9			1.5			14.2		1	1			1.7			14.3		1
11/06/22 23:00	0.5			1.5			14.4		1	0.7			1.7			14.4		1
11/07/22 0:00	0.7			1.4			14.2		1	0.9			1.4			14.2		1
11/07/22 1:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/07/22 2:00	0.7			1.7			14.2		1	0.9			1.8			14.2		1
11/07/22 3:00	0.8			1.5			14.2		1	0.9			1.7			14.2		1
11/07/22 4:00	0.7			1.4			14.2		1	0.9			1.5			14.3		1
11/07/22 5:00	0.7			1.5			14.3		1	0.9			1.6			14.3		1
11/07/22 6:00	0.7			1.5			14.3		1	0.8			1.7			14.3		1
11/07/22 7:00	0.8			1.5			14.2		1	0.9			1.7			14.2		1
11/07/22 8:00	0.6			1.5			14.4		1	0.7			1.6			14.4		1
11/07/22 9:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/07/22 10:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/07/22 11:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/07/22 12:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/07/22 13:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/07/22 14:00	0.7			1.4			14.3		1	0.9			1.1			14.3		1
11/07/22 15:00	0.8			1.5			13.9		1	1			1.5			13.9		1
11/07/22 16:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/07/22 17:00	1			1.5			13.5		1	1			1.5			13.5		1
11/07/22 18:00	1.1			1.5			13.6		1	1.1			1.5			13.6		1
11/07/22 19:00	1			1.5			13.5		1	1			1.5			13.6		1
11/07/22 20:00	0.9			1.5			13.5		1	1			1.5			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 21:00	0.9			1.5			13.4		1	1			1.5			13.5		1
11/07/22 22:00	1.2			1.5			13.8		1	1.2			1.5			13.9		1
11/07/22 23:00	0.9			1.5			14.2		1	1.1			1.5			14.3		1
11/08/22 0:00	0.6			1.5			14.4		1	0			0			17.4		1
11/08/22 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
11/08/22 2:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
11/08/22 3:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
11/08/22 4:00	1			1.5			14.3		1	0	X		0	X		0	X	1
11/08/22 5:00	1.5			1.5			14		1	0	X		0	X		0	X	1
11/08/22 6:00	0.9			1.5			13.5		1	0	X		0	X		0	X	1
11/08/22 7:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
11/08/22 8:00	1.2			1.5			13.8		1	0	X		0	X		0	X	1
11/08/22 9:00	0.8			1.5			13.2		1	0	X		0	X		0	X	1
11/08/22 10:00	1.1			1.5			13.7		1	0	X		0	X		0	X	1
11/08/22 11:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
11/08/22 12:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
11/08/22 13:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
11/08/22 14:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
11/08/22 15:00	0.9			1.5			14.2		1	0	X		0	X		0	X	1
11/08/22 16:00	1.3			1.5			14		1	0	X		0	X		0	X	1
11/08/22 17:00	1.1			1.5			13.9		1	0	X		0	X		0	X	1
11/08/22 18:00	1.3			1.5			14		1	0	X		0	X		0	X	1
11/08/22 19:00	1.5			1.5			14		1	0	X		0	X		0	X	1
11/08/22 20:00	1.4			1.5			14		1	0	X		0	X		0	X	1
11/08/22 21:00	1.4			1.5			14		1	0	X		0	X		0	X	1
11/08/22 22:00	2			1.5			14		1	0	X		0	X		0	X	1
11/08/22 23:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 0:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 1:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 2:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 3:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 4:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 5:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 6:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 7:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 8:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 9:00	1.1			1.5			14.2		1	0	X		0	X		0	X	1
11/09/22 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
11/09/22 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
11/09/22 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
11/09/22 14:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
11/09/22 15:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
11/09/22 16:00	1.1			1.5			14.4		1	0	X		0	X		0	X	1
11/09/22 17:00	1.6			1.5			14.4		1	0	X		0	X		0	X	1
11/09/22 18:00	1.4			1.5			14.2		1	0	X		0	X		0	X	1
11/09/22 19:00	1.7			1.5			14.1		1	0	X		0	X		0	X	1
11/09/22 20:00	1.4			1.5			14.1		1	0			0			16.1		1
11/09/22 21:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
11/09/22 22:00	0.5			1.6			14.5		1	0.7			1.5			14.5		1
11/09/22 23:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/10/22 0:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
11/10/22 1:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
11/10/22 2:00	0.5			1.5			14.4		1	0.7			1.5			14.5		1
11/10/22 3:00	0.8			1.5			14.2		1	0.9			1.3			14.3		1
11/10/22 4:00	0.8			1.5			14.2		1	1			1.6			14.2		1
11/10/22 5:00	1			1.5			14.2		1	1.2			1.5			14.2		1
11/10/22 6:00	0.6			1.5			13		1	0.7			1.5			13		1
11/10/22 7:00	1.4			1.5			14		1	1.5			1.5			14		1
11/10/22 8:00	0.7			1.6			14.4		1	0.8			1.4			14.4		1
11/10/22 9:00	0.8			1.4			14.2		1	0.9			1.2			14.2		1
11/10/22 10:00	0.4			1.6			14.7		1	0.7			1.4			14.6		1
11/10/22 11:00	0.4			1.5			14.6		1	0.6			1.5			14.7		1
11/10/22 12:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/10/22 13:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/10/22 14:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
11/10/22 15:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
11/10/22 16:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
11/10/22 17:00	0.7			1.5			13.3		1	0.8			1.5			13.3		1
11/10/22 18:00	1			1.5			13.6		1	1.1			1.5			13.7		1
11/10/22 19:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/10/22 20:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/10/22 21:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
11/10/22 22:00	1			1.5			13.5		1	1			1.5			13.5		1
11/10/22 23:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
11/11/22 0:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/22 1:00	0.9			1.5			13.4		1	1			1.5			13.5		1
11/11/22 2:00	1.3			1.5			14		1	1.2			1.7			14		1
11/11/22 3:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
11/11/22 4:00	0.9			1.5			14.2		1	1.1			1.5			14.2		1
11/11/22 5:00	0.9			1.5			13.3		1	0.9			1.5			13.3		1
11/11/22 6:00	0.7			1.5			13.2		1	0.8			1.5			13.2		1
11/11/22 7:00	1.3			1.5			14		1	1.4			1.5			14.1		1
11/11/22 8:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/11/22 9:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 10:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 11:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 12:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 13:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 14:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/11/22 15:00	0.8			1.5			14		1	1			1.4			14		1
11/11/22 16:00	0.9			1.5			13.4		1	1			1.5			13.5		1
11/11/22 17:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/11/22 18:00	1.2			1.5			13.7		1	1.1			1.5			13.7		1
11/11/22 19:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
11/11/22 20:00	1.2			1.5			13.7		1	1.2			1.5			13.7		1
11/11/22 21:00	0.8			1.5			13.2		1	0.9			1.5			13.3		1
11/11/22 22:00	0.9			1.5			13.3		1	1			1.5			13.4		1
11/11/22 23:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/12/22 0:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
11/12/22 1:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
11/12/22 2:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
11/12/22 3:00	0.6			1.5			13		1	0.7			1.5			13		1
11/12/22 4:00	0.6			1.5			13.1		1	0.8			1.5			13.1		1
11/12/22 5:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1
11/12/22 6:00	0.6			1.5			13.1		1	0.8			1.5			13.1		1
11/12/22 7:00	1.4			1.5			14		1	1.4			1.5			14		1
11/12/22 8:00	0.6			1.5			13		1	0.8			1.5			13.1		1
11/12/22 9:00	1			1.5			13.6		1	1.1			1.5			13.6		1
11/12/22 10:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/12/22 11:00	1			1.5			14.1		1	1.1			1.5			14.1		1
11/12/22 12:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
11/12/22 13:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
11/12/22 14:00	0.9			1.5			13.9		1	1.1			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/22 15:00	1.1			1.5			13.7		1	1.1			1.5			13.8		1
11/12/22 16:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/12/22 17:00	1			1.5			13.5		1	1.1			1.5			13.6		1
11/12/22 18:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
11/12/22 19:00	1.1			1.5			13.4		1	1.1			1.5			13.5		1
11/12/22 20:00	1.3			1.5			13.7		1	1.2			1.5			13.7		1
11/12/22 21:00	1			1.5			13.6		1	1.1			1.5			13.6		1
11/12/22 22:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/12/22 23:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/13/22 0:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/13/22 1:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/13/22 2:00	0.7			1.6			14.3		1	0.9			1.5			14.3		1
11/13/22 3:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
11/13/22 4:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/13/22 5:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/13/22 6:00	0.9			1.5			14.2		1	1.1			1.5			14.2		1
11/13/22 7:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/13/22 8:00	1			1.5			14.2		1	1.3			1.5			14.2		1
11/13/22 9:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/13/22 10:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
11/13/22 11:00	0.6			1.5			14.4		1	0.9			1.5			14.4		1
11/13/22 12:00	0.6			1.5			14.4		1	0.9			1.5			14.4		1
11/13/22 13:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
11/13/22 14:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/13/22 15:00	0.7			1.5			14.4		1	0.9			1.4			14.3		1
11/13/22 16:00	0.7			1.5			13.3		1	0.9			1.5			13.3		1
11/13/22 17:00	0.6			1.5			13.2		1	0.8			1.5			13.2		1
11/13/22 18:00	0.6			1.5			13.2		1	0.8			1.5			13.3		1
11/13/22 19:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/13/22 20:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/13/22 21:00	0.7			1.5			13.2		1	0.9			1.5			13.3		1
11/13/22 22:00	0.8			1.5			13.3		1	1			1.5			13.3		1
11/13/22 23:00	0.9			1.5			13.4		1	1			1.5			13.4		1
11/14/22 0:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/14/22 1:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/14/22 2:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/14/22 3:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/14/22 4:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/22 5:00	1			1.5			13.4		1	1.1			1.5			13.4		1
11/14/22 6:00	0.3			1.5			12.2		1	0.4			1.5			12.3		1
11/14/22 7:00	0.6			1.5			12.9		1	0.7			1.5			12.9		1
11/14/22 8:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/14/22 9:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/14/22 10:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/14/22 11:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/14/22 12:00	0.7			1.5			14.2		1	1			1.4			14.2		1
11/14/22 13:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/14/22 14:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
11/14/22 15:00	0.8			1.5			13.9		1	1			1.5			13.9		1
11/14/22 16:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1
11/14/22 17:00	0.4			1.5			13		1	0.6			1.5			13		1
11/14/22 18:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1
11/14/22 19:00	0.8			1.5			13.3		1	1			1.3			13.3		1
11/14/22 20:00	0.6			1.5			13		1	0.8			1.5			13.1		1
11/14/22 21:00	0.7			1.5			13.1		1	0.9			1.5			13.2		1
11/14/22 22:00	0.7			1.5			13.2		1	0.9			1.5			13.2		1
11/14/22 23:00	1			1.5			13.5		1	1.1			1.5			13.6		1
11/15/22 0:00	0.7			1.5			13		1	0.9			1.5			13.1		1
11/15/22 1:00	0.6			1.5			13		1	0.8			1.5			13.1		1
11/15/22 2:00	0.5			1.4			12.9		1	0.7			1.3			13		1
11/15/22 3:00	0.7			1.5			13.1		1	0.8			1.5			13.1		1
11/15/22 4:00	0.6			1.5			13		1	0.7			1.5			13		1
11/15/22 5:00	0.6			1.5			13		1	0.8			1.5			13		1
11/15/22 6:00	0.5			1.5			12.8		1	0.7			1.5			12.9		1
11/15/22 7:00	0.6			1.5			13		1	0.8			1.5			13		1
11/15/22 8:00	1.1			1.5			13.6		1	1.1			1.5			13.6		1
11/15/22 9:00	1			1.5			14.2		1	1.1			1.5			14.2		1
11/15/22 10:00	0.7			1.5			14.3		1	1			1.4			14.2		1
11/15/22 11:00	0.7			1.5			14.4		1	0.9			1.4			14.4		1
11/15/22 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/15/22 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/15/22 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/15/22 15:00	0.7			1.5			14.4		1	0.9			1.4			14.3		1
11/15/22 16:00	0.6			1.5			13.3		1	0.8			1.5			13.3		1
11/15/22 17:00	0.5			1.5			13.1		1	0.7			1.5			13.1		1
11/15/22 18:00	0.4			1.5			13		1	0.7			1.5			13.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/22 19:00	0.6			1.5			13.3		1	0.9			1.5			13.3		1
11/15/22 20:00	0.8			1.5			13.4		1	1			1.5			13.5		1
11/15/22 21:00	0.7			1.5			13.3		1	0.9			1.5			13.4		1
11/15/22 22:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/15/22 23:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/16/22 0:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/16/22 1:00	1.1			1.5			13.6		1	1.2			1.5			13.7		1
11/16/22 2:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/16/22 3:00	1.2			1.5			13.7		1	1.2			1.5			13.7		1
11/16/22 4:00	0.9			1.5			13.4		1	1			1.5			13.4		1
11/16/22 5:00	0.8			1.5			13.3		1	1			1.5			13.3		1
11/16/22 6:00	0.6			1.5			13		1	0.8			1.5			13		1
11/16/22 7:00	0.8			1.5			13.2		1	1			1.5			13.3		1
11/16/22 8:00	1.3			1.5			14.1		1	1.7			1.5			14.1		1
11/16/22 9:00	0.8			1.5			14.3		1	1			1.5			14.2		1
11/16/22 10:00	0.7			1.4			14.3		1	0.9			1.4			14.3		1
11/16/22 11:00	0.6			1.4			14.5		1	0.8			1.4			14.5		1
11/16/22 12:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/16/22 13:00	0.8			1.5			14.3		1	1			1.5			14.2		1
11/16/22 14:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
11/16/22 15:00	0.6			1.5			14.4		1	0.9			1.4			14.4		1
11/16/22 16:00	1			1.5			14.3		1	1.3			1.5			14.4		1
11/16/22 17:00	1.3			1.5			14.1		1	1			1.5			13.5		1
11/16/22 18:00	0.5			1.5			13		1	0.6			1.5			12.9		1
11/16/22 19:00	0.5			1.5			12.9		1	0.7			1.5			13		1
11/16/22 20:00	1.4			1.5			14		1	1.3			1.5			14		1
11/16/22 21:00	0.6			1.5			13		1	0.8			1.5			13		1
11/16/22 22:00	0.7			1.5			13.2		1	0.9			1.5			13.2		1
11/16/22 23:00	0.9			1.5			13.4		1	1			1.5			13.4		1
11/17/22 0:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/17/22 1:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/17/22 2:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/17/22 3:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/17/22 4:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/17/22 5:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/17/22 6:00	1			1.5			14.2		1	1.4			1.5			14.2		1
11/17/22 7:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/17/22 8:00	0.8			1.5			14.4		1	1.1			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/22 9:00	0.8			1.4			14.3		1	1			1.3			14.3		1
11/17/22 10:00	1.2			1.5			13.7		1	1.3			1.5			13.7		1
11/17/22 11:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
11/17/22 12:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
11/17/22 13:00	1			1.5			13.6		1	1.1			1.5			13.7		1
11/17/22 14:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/17/22 15:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
11/17/22 16:00	0.6			1.5			13.2		1	0.8			1.5			13.3		1
11/17/22 17:00	0.5			1.5			13		1	0.7			1.5			13		1
11/17/22 18:00	0.5			1.5			13		1	0.7			1.5			13.1		1
11/17/22 19:00	0.6			1.5			13		1	0.8			1.5			13.1		1
11/17/22 20:00	0.9			1.5			13.2		1	1			1.5			13.2		1
11/17/22 21:00	1.1			1.5			13.4		1	1.2			1.5			13.5		1
11/17/22 22:00	1.3			1.5			13.6		1	1.3			1.5			13.6		1
11/17/22 23:00	1.3			1.5			13.7		1	1.4			1.5			13.7		1
11/18/22 0:00	0.9			1.5			13.2		1	1.1			1.5			13.3		1
11/18/22 1:00	1			1.5			13.5		1	1.2			1.5			13.5		1
11/18/22 2:00	1.1			1.6			13.4		1	1.2			1.1			13.5		1
11/18/22 3:00	0.8			1.5			13.1		1	1			1.5			13.1		1
11/18/22 4:00	0.7			1.5			13		1	0.9			1.5			13		1
11/18/22 5:00	0.6			1.5			12.8		1	0.8			1.5			12.8		1
11/18/22 6:00	0.3			1.5			11.9		1	0.5			1.5			12		1
11/18/22 7:00	0.6			1.5			12.8		1	0.8			1.5			12.9		1
11/18/22 8:00	0.7			1.5			13.1		1	0.9			1.5			13.2		1
11/18/22 9:00	0.9			1.5			13.4		1	1			1.5			13.4		1
11/18/22 10:00	1			1.5			13.5		1	1.1			1.5			13.6		1
11/18/22 11:00	1			1.5			13.6		1	1.1			1.5			13.7		1
11/18/22 12:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/18/22 13:00	1			1.5			13.7		1	1.1			1.5			13.7		1
11/18/22 14:00	1			1.5			13.7		1	1.1			1.5			13.7		1
11/18/22 15:00	0.8			1.5			13.4		1	0.9			1.5			13.5		1
11/18/22 16:00	0.4			1.5			12.8		1	0.6			1.5			12.9		1
11/18/22 17:00	0.3			1.5			12.6		1	0.5			1.5			12.7		1
11/18/22 18:00	0.4			1.5			12.7		1	0.5			1.5			12.8		1
11/18/22 19:00	0.4			1.5			12.9		1	0.7			1.5			13		1
11/18/22 20:00	0.4			1.5			12.8		1	0.6			1.5			12.8		1
11/18/22 21:00	0.4			1.5			12.8		1	0.6			1.5			12.9		1
11/18/22 22:00	0.5			1.5			13		1	0.7			1.5			13		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/22 23:00	0.6			1.5			13.2		1	0.9			1.5			13.2		1
11/19/22 0:00	1			1.5			13.6		1	1.1			1.5			13.6		1
11/19/22 1:00	1.1			1.5			13.6		1	1.2			1.5			13.6		1
11/19/22 2:00	1.1			1.5			13.6		1	1.2			1.5			13.7		1
11/19/22 3:00	1.2			1.5			13.9		1	1.4			1.5			13.9		1
11/19/22 4:00	1			1.5			13.4		1	1.1			1.5			13.5		1
11/19/22 5:00	0.7			1.5			13.2		1	0.9			1.5			13.3		1
11/19/22 6:00	0.6			1.5			13		1	0.8			1.5			13.1		1
11/19/22 7:00	0.8			1.5			13.1		1	0.9			1.5			13.1		1
11/19/22 8:00	0.9			1.5			14.2		1	1			1.5			14.2		1
11/19/22 9:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/19/22 10:00	0.6			1.5			14.5		1	0.8			1.4			14.5		1
11/19/22 11:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/19/22 12:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/19/22 13:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/19/22 14:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
11/19/22 15:00	0.6			1.5			14.5		1	0.9			1.4			14.5		1
11/19/22 16:00	0.7			1.5			13.3		1	0.9			1.5			13.3		1
11/19/22 17:00	0.8			1.5			13.5		1	1			1.5			13.5		1
11/19/22 18:00	0.9			1.5			13.5		1	1.2			1.5			13.5		1
11/19/22 19:00	0.6			1.5			13.1		1	0.8			1.5			13.1		1
11/19/22 20:00	0.5			1.5			12.9		1	0.7			1.5			12.9		1
11/19/22 21:00	0.5			1.5			12.9		1	0.7			1.5			13		1
11/19/22 22:00	0.5			1.5			12.9		1	0.7			1.5			13		1
11/19/22 23:00	0.6			1.5			12.9		1	0.8			1.5			12.9		1
11/20/22 0:00	0.6			1.5			12.9		1	0.7			1.5			13		1
11/20/22 1:00	0.6			1.5			12.9		1	0.8			1.5			12.9		1
11/20/22 2:00	0.7			1.5			12.9		1	0.9			1.5			12.9		1
11/20/22 3:00	0.7			1.5			12.9		1	0.8			1.5			12.9		1
11/20/22 4:00	0.6			1.5			12.9		1	0.8			1.5			12.9		1
11/20/22 5:00	0.7			1.5			13		1	0.9			1.5			13		1
11/20/22 6:00	0.8			1.5			13.2		1	1			1.5			13.2		1
11/20/22 7:00	1.1			1.5			13.6		1	1.3			1.5			13.6		1
11/20/22 8:00	1.1			1.5			14.2		1	1.3			1.5			14.2		1
11/20/22 9:00	0.8			1.5			14.3		1	1.2			1.5			14.3		1
11/20/22 10:00	1.3			1.5			14.1		1	2			1.5			14.2		1
11/20/22 11:00	1.2			1.5			14.1		1	1.8			1.5			14.2		1
11/20/22 12:00	0.8			1.5			14.3		1	1.2			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/22 13:00	1			1.5			13.8		1	1.2			1.5			13.8		1
11/20/22 14:00	0.8			1.5			14.2		1	1.1			1.5			14.2		1
11/20/22 15:00	0.8			1.5			14.2		1	1.1			1.5			14.2		1
11/20/22 16:00	0.7			1.5			13.4		1	0.9			1.5			13.4		1
11/20/22 17:00	0.8			1.5			13.4		1	1			1.5			13.4		1
11/20/22 18:00	1			1.5			13.5		1	1.2			1.5			13.6		1
11/20/22 19:00	1.1			1.5			13.6		1	1.2			1.5			13.6		1
11/20/22 20:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/20/22 21:00	1.3			1.5			13.8		1	1.5			1.5			13.8		1
11/20/22 22:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/20/22 23:00	1.4			1.5			13.9		1	1.5			1.5			13.9		1
11/21/22 0:00	1.3			1.5			13.7		1	1.4			1.5			13.7		1
11/21/22 1:00	1.5			1.5			13.8		1	1.5			1.5			13.8		1
11/21/22 2:00	1.5			1.5			13.8		1	1.6			1.4			13.8		1
11/21/22 3:00	1.4			1.5			13.6		1	1.5			1.5			13.6		1
11/21/22 4:00	1			1.5			13.2		1	1.2			1.5			13.3		1
11/21/22 5:00	1.2			1.5			13.3		1	1.4			1.5			13.3		1
11/21/22 6:00	0.6			1.5			13		1	0.9			1.5			13		1
11/21/22 7:00	1.3			1.5			13.7		1	1.6			1.5			13.8		1
11/21/22 8:00	1			1.5			14.3		1	1.2			1.5			14.4		1
11/21/22 9:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/21/22 10:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/21/22 11:00	0.6			1.5			14.5		1	0.8			1.4			14.5		1
11/21/22 12:00	0.6			1.4			14.5		1	0.8			1.3			14.5		1
11/21/22 13:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
11/21/22 14:00	0.8			1.5			14.4		1	1.1			1.4			14.4		1
11/21/22 15:00	0.7			1.5			13.3		1	0.9			1.5			13.4		1
11/21/22 16:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
11/21/22 17:00	0.8			1.5			13.4		1	1			1.5			13.4		1
11/21/22 18:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/21/22 19:00	1			1.5			13.5		1	1.1			1.5			13.5		1
11/21/22 20:00	1			1.5			13.4		1	1.2			1.5			13.5		1
11/21/22 21:00	1			1.5			13.3		1	1.1			1.5			13.4		1
11/21/22 22:00	1			1.5			13.4		1	1.2			1.5			13.5		1
11/21/22 23:00	1.3			1.5			13.7		1	1.4			1.5			13.8		1
11/22/22 0:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
11/22/22 1:00	0.8			1.5			14.3		1	1			1.5			14.4		1
11/22/22 2:00	0.9			1.6			14.3		1	1.2			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/22 3:00	1			1.5			14.2		1	1.2			1.5			14.3		1
11/22/22 4:00	0.9			1.5			14.2		1	1.1			1.5			14.3		1
11/22/22 5:00	0.8			1.5			14.3		1	1			1.5			14.3		1
11/22/22 6:00	0.7			1.5			14.3		1	1			1.5			14.3		1
11/22/22 7:00	0.8			1.5			14.3		1	1.1			1.5			14.3		1
11/22/22 8:00	1.2			1.5			14.3		1	1.6			1.4			14.3		1
11/22/22 9:00	1.1			1.5			13.6		1	1.3			1.5			13.6		1
11/22/22 10:00	0.9			1.5			14.3		1	1.2			1.5			14.3		1
11/22/22 11:00	1.1			1.5			13.9		1	1.3			1.5			13.9		1
11/22/22 12:00	0.8			1.5			13.4		1	1			1.5			13.5		1
11/22/22 13:00	0.7			1.5			13.3		1	0.9			1.5			13.4		1
11/22/22 14:00	0.8			1.5			13.5		1	1			1.5			13.5		1
11/22/22 15:00	1			1.5			13.6		1	1.1			1.5			13.7		1
11/22/22 16:00	1			1.5			13.7		1	1.2			1.5			13.7		1
11/22/22 17:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
11/22/22 18:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
11/22/22 19:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
11/22/22 20:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
11/22/22 21:00	1.3			1.5			14.1		1	1.5			1.5			14.1		1
11/22/22 22:00	1.1			1.5			14.3		1	1.3			1.5			14.3		1
11/22/22 23:00	0.7			1.5			14.4		1	1.1			1.4			14.4		1
11/23/22 0:00	1			1.5			14.2		1	1.2			1.4			14.2		1
11/23/22 1:00	0.9			1.5			14.1		1	1.2			1.5			14.1		1
11/23/22 2:00	0.9			1.7			14.2		1	1.1			1.5			14.2		1
11/23/22 3:00	0.9			1.5			14.2		1	1.1			1.5			14.2		1
11/23/22 4:00	0.9			1.5			14.2		1	1.1			1.5			14.2		1
11/23/22 5:00	0.8			1.5			14.3		1	1.2			1.5			14.2		1
11/23/22 6:00	0.8			1.5			14.2		1	1.1			1.5			14.2		1
11/23/22 7:00	0.9			1.5			14.1		1	1.2			1.6			14.1		1
11/23/22 8:00	0.7			1.5			14.4		1	1			1.4			14.4		1
11/23/22 9:00	0.7			1.4			14.3		1	1			1.3			14.3		1
11/23/22 10:00	0.7			1.4			14.3		1	1			1.3			14.3		1
11/23/22 11:00	1.1			1.5			14.1		1	1.4			1.4			14.2		1
11/23/22 12:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/23/22 13:00	1			1.5			14		1	1.2			1.5			14		1
11/23/22 14:00	0.6			1.5			14.5		1	0.8			1.4			14.6		1
11/23/22 15:00	0.7			1.5			14.5		1	1			1.4			14.5		1
11/23/22 16:00	0.8			1.5			13.4		1	1			1.5			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/22 17:00	0.9			1.5			13.5		1	1.1			1.5			13.5		1
11/23/22 18:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
11/23/22 19:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/23/22 20:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
11/23/22 21:00	1.1			1.5			13.5		1	1.3			1.5			13.6		1
11/23/22 22:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/23/22 23:00	1.4			1.5			13.7		1	1.4			1.5			13.8		1
11/24/22 0:00	1.3			1.5			13.6		1	1.3			1.5			13.7		1
11/24/22 1:00	1.4			1.5			13.7		1	1.4			1.5			13.7		1
11/24/22 2:00	1			1.3			14.2		1	1.2			1.3			14.2		1
11/24/22 3:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
11/24/22 4:00	0.8			1.5			14.3		1	1.1			1.5			14.3		1
11/24/22 5:00	1			1.5			14.3		1	1.4			1.5			14.3		1
11/24/22 6:00	1			1.5			14.2		1	1.5			1.5			14.2		1
11/24/22 7:00	1.2			1.5			13.5		1	1.3			1.5			13.5		1
11/24/22 8:00	1.2			1.5			13.7		1	1.3			1.5			13.7		1
11/24/22 9:00	1			1.5			13.6		1	1.2			1.5			13.6		1
11/24/22 10:00	0.9			1.5			13.5		1	1.1			1.5			13.6		1
11/24/22 11:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
11/24/22 12:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
11/24/22 13:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
11/24/22 14:00	0.8			1.5			14.5		1	1			1.5			14.5		1
11/24/22 15:00	0.8			1.5			14.2		1	1			1.4			14.3		1
11/24/22 16:00	0.8			1.5			13.4		1	1			1.5			13.4		1
11/24/22 17:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/24/22 18:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
11/24/22 19:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/24/22 20:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/24/22 21:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/24/22 22:00	1.4			1.5			13.9		1	1.4			1.5			13.9		1
11/24/22 23:00	1.5			1.5			14		1	1.5			1.5			14		1
11/25/22 0:00	1.4			1.5			14		1	1.5			1.5			14		1
11/25/22 1:00	1.5			1.5			14.1		1	1.6			1.5			14		1
11/25/22 2:00	1.5			1.5			14.1		1	1.7			1.5			14.1		1
11/25/22 3:00	1.4			1.5			13.9		1	1.6			1.5			13.9		1
11/25/22 4:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/25/22 5:00	1.4			1.5			13.8		1	1.5			1.5			13.8		1
11/25/22 6:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/22 7:00	1.4			1.5			13.8		1	1.5			1.5			13.8		1
11/25/22 8:00	1.6			1.5			14.1		1	1.7			1.5			14.1		1
11/25/22 9:00	0.8			1.5			14.4		1	1.1			1.5			14.4		1
11/25/22 10:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
11/25/22 11:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/25/22 12:00	0.6			1.5			14.6		1	0.8			1.5			14.7		1
11/25/22 13:00	0.6			1.5			14.6		1	0.8			1.5			14.7		1
11/25/22 14:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/25/22 15:00	0.7			1.5			14.5		1	1			1.4			14.5		1
11/25/22 16:00	1			1.5			13.6		1	1.2			1.5			13.6		1
11/25/22 17:00	1			1.5			13.6		1	1.1			1.5			13.7		1
11/25/22 18:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
11/25/22 19:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
11/25/22 20:00	1.4			1.5			13.9		1	1.4			1.5			13.9		1
11/25/22 21:00	1.4			1.5			13.9		1	1.5			1.5			13.9		1
11/25/22 22:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/25/22 23:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/26/22 0:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/26/22 1:00	1.4			1.5			13.6		1	1.5			1.5			13.6		1
11/26/22 2:00	1.3			1.5			13.6		1	1.5			1.6			13.6		1
11/26/22 3:00	1.2			1.5			13.6		1	1.5			1.5			13.6		1
11/26/22 4:00	1.2			1.5			13.6		1	1.5			1.5			13.6		1
11/26/22 5:00	0.8			1.5			13.2		1	1			1.5			13.2		1
11/26/22 6:00	0.6			1.5			13		1	0.8			1.5			13		1
11/26/22 7:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/26/22 8:00	1.3			1.5			14.2		1	1.9			1.5			14.2		1
11/26/22 9:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/26/22 10:00	0.9			1.5			14.3		1	1.2			1.4			14.3		1
11/26/22 11:00	0.6			1.5			14.6		1	0.8			1.6			14.6		1
11/26/22 12:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
11/26/22 13:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/26/22 14:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/26/22 15:00	0.7			1.5			14.5		1	0.9			1.4			14.5		1
11/26/22 16:00	0.9			1.5			13.6		1	1.1			1.5			13.7		1
11/26/22 17:00	1.1			1.5			13.6		1	1.2			1.5			13.7		1
11/26/22 18:00	1.2			1.5			13.8		1	1.3			1.5			13.8		1
11/26/22 19:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/26/22 20:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/22 21:00	1.1			1.5			13.6		1	1.2			1.5			13.6		1
11/26/22 22:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
11/26/22 23:00	1.3			1.5			13.9		1	1.5			1.5			13.9		1
11/27/22 0:00	1			1.5			13.5		1	1.3			1.5			13.5		1
11/27/22 1:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/27/22 2:00	1.5			1.5			13.9		1	1.5			1.4			13.9		1
11/27/22 3:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/27/22 4:00	1.1			1.5			13.5		1	1.3			1.5			13.5		1
11/27/22 5:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/27/22 6:00	1.2			1.5			13.6		1	1.3			1.5			13.6		1
11/27/22 7:00	1.2			1.5			14		1	1.4			1.5			14.1		1
11/27/22 8:00	0.7			1.5			14.5		1	1			1.5			14.5		1
11/27/22 9:00	0.6			1.5			14.6		1	0.9			1.5			14.5		1
11/27/22 10:00	0.6			1.5			14.5		1	0.9			1.5			14.5		1
11/27/22 11:00	0.6			1.5			14.5		1	0.9			1.5			14.5		1
11/27/22 12:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/27/22 13:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/27/22 14:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/27/22 15:00	0.9			1.4			14.2		1	1.1			1.3			14.2		1
11/27/22 16:00	1			1.5			13.6		1	1.1			1.5			13.6		1
11/27/22 17:00	0.8			1.5			13.4		1	1.1			1.5			13.4		1
11/27/22 18:00	1			1.5			13.5		1	1.2			1.5			13.5		1
11/27/22 19:00	1.1			1.5			13.5		1	1.3			1.5			13.6		1
11/27/22 20:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/27/22 21:00	0.9			1.5			13.3		1	1.1			1.5			13.3		1
11/27/22 22:00	1.2			1.5			13.8		1	1.3			1.5			13.8		1
11/27/22 23:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
11/28/22 0:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/28/22 1:00	1.4			1.5			13.8		1	1.5			1.5			13.8		1
11/28/22 2:00	1.7			1.5			14		1	1.8			1.6			14		1
11/28/22 3:00	1.5			1.5			13.9		1	1.6			1.5			13.9		1
11/28/22 4:00	1.5			1.5			14		1	1.7			1.5			14		1
11/28/22 5:00	1.4			1.5			13.8		1	1.6			1.5			13.8		1
11/28/22 6:00	1			1.5			13.3		1	1.2			1.5			13.3		1
11/28/22 7:00	0.9			1.5			13.2		1	1			1.5			13.2		1
11/28/22 8:00	1.4			1.5			13.9		1	1.5			1.5			13.9		1
11/28/22 9:00	1			1.5			14.2		1	1.3			1.5			14.2		1
11/28/22 10:00	0.6			1.5			14.5		1	1			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/22 11:00	0.7			1.5			14.5		1	0.9			1.5			14.5		1
11/28/22 12:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/28/22 13:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/28/22 14:00	0.6			1.5			14.6		1	0.8			1.5			14.6		1
11/28/22 15:00	0.7			1.5			14.2		1	1			1.4			14.2		1
11/28/22 16:00	1.1			1.5			13.6		1	1.2			1.5			13.6		1
11/28/22 17:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/28/22 18:00	1.4			1.5			13.9		1	1.4			1.5			13.9		1
11/28/22 19:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
11/28/22 20:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
11/28/22 21:00	0.9			1.5			13.3		1	1.1			1.5			13.3		1
11/28/22 22:00	1.3			1.5			13.8		1	1.4			1.5			13.8		1
11/28/22 23:00	1.6			1.5			14		1	1.6			1.5			14		1
11/29/22 0:00	0.9			1.5			14.3		1	1.3			1.5			14.3		1
11/29/22 1:00	0.9			1.5			14.3		1	1.3			1.5			14.3		1
11/29/22 2:00	0.8			1.5			14.3		1	1.2			1.5			14.3		1
11/29/22 3:00	0.9			1.5			14.3		1	1.2			1.5			14.3		1
11/29/22 4:00	0.8			1.5			14.3		1	1.1			1.5			14.3		1
11/29/22 5:00	0.8			1.5			14.3		1	1.1			1.5			14.3		1
11/29/22 6:00	1			1.5			14.2		1	1.5			1.5			14.2		1
11/29/22 7:00	0.4			1.5			12.3		1	0.8			1.5			12.7		1
11/29/22 8:00	0.7			1.5			13.7		1	0	X		0	X		0	X	1
11/29/22 9:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
11/29/22 10:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
11/29/22 11:00	0.8			1.5			14.4		1	0			0			19		1
11/29/22 12:00	0.8			1.4			14.3		1	1			0.7			14.5		1
11/29/22 13:00	0.7			1.5			14.4		1	1			1.5			14.4		1
11/29/22 14:00	0.5			1.3			12.8		1	0.5			1.5			12.4		1
11/29/22 15:00	0.3			1.3			12.8		1	0.6			1.5			12.9		1
11/29/22 16:00	0.3			1.3			12.7		1	0.6			1.5			12.8		1
11/29/22 17:00	0.5			1.3			12.8		1	0.7			1.5			12.9		1
11/29/22 18:00	0.4			1.3			12.8		1	0.7			1.5			12.9		1
11/29/22 19:00	0.4			1.3			12.8		1	0.7			1.5			12.9		1
11/29/22 20:00	0.4			1.3			12.8		1	0.7			1.5			12.8		1
11/29/22 21:00	0.4			1.3			12.8		1	0.7			1.5			12.9		1
11/29/22 22:00	0.5			1.3			12.9		1	0.8			1.5			13		1
11/29/22 23:00	0.8			1.4			13.3		1	1			1.5			13.3		1
11/30/22 0:00	0.7			1.5			14.3		1	1.1			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/22 1:00	0.6			1.5			14.3		1	1.1			1.5			14.3		1
11/30/22 2:00	0.7			1.5			14.3		1	1.1			1.5			14.3		1
11/30/22 3:00	0.7			1.5			14.3		1	1.1			1.5			14.3		1
11/30/22 4:00	0.7			1.5			14.3		1	1.1			1.5			14.3		1
11/30/22 5:00	1			1.5			14.2		1	1.7			1.5			14.2		1
11/30/22 6:00	0.5			1.5			12.8		1	0.8			1.5			12.9		1
11/30/22 7:00	1.2			1.5			13.7		1	1.4			1.5			13.7		1
11/30/22 8:00	0.9			1.5			14.2		1	1.2			1.5			14.3		1
11/30/22 9:00	0.7			1.4			14.3		1	1.1			1.4			14.3		1
11/30/22 10:00	0.6			1.5			14.5		1	0.9			1.4			14.5		1
11/30/22 11:00	0.5			1.5			14.6		1	0.6			1.3			14.6		1
11/30/22 12:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/30/22 13:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/30/22 14:00	0.7			1.4			14.3		1	0.8			1.3			14.3		1
11/30/22 15:00	0.8			1.5			14.2		1	0.9			1.4			14.2		1
11/30/22 16:00	0.7			1.5			13.4		1	0.8			1.5			13.4		1
11/30/22 17:00	0.7			1.5			13.4		1	0.9			1.5			13.4		1
11/30/22 18:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
11/30/22 19:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
11/30/22 20:00	0.9			1.5			13.5		1	1			1.5			13.5		1
11/30/22 21:00	1			1.5			13.5		1	1			1.5			13.6		1
11/30/22 22:00	1.1			1.5			13.9		1	1.1			1.5			14		1
11/30/22 23:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
12/01/22 0:00	0.7			1.5			14.2		1	0.8			1.4			14.3		1
12/01/22 1:00	0.7			1.5			14.2		1	0.8			1.5			14.3		1
12/01/22 2:00	0.7			1.6			14.3		1	0.8			1.5			14.3		1
12/01/22 3:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
12/01/22 4:00	1			1.5			14.3		1	1.2			1.5			14.3		1
12/01/22 5:00	0.9			1.5			13.4		1	1.2			1.5			13.6		1
12/01/22 6:00	0.7			1.5			13.3		1	0.9			1.5			13.3		1
12/01/22 7:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/01/22 8:00	0.5			1.5			13		1	0.7			1.5			13.1		1
12/01/22 9:00	0.3			1.5			12.5		1	0.4			1.5			12.6		1
12/01/22 10:00	0.5			1.5			12.9		1	0.6			1.5			13		1
12/01/22 11:00	0.5			1.5			13		1	0.6			1.5			13.1		1
12/01/22 12:00	0.7			1.5			13.1		1	0.7			1.5			13.1		1
12/01/22 13:00	0.5			1.5			12.8		1	0.5			1.5			12.9		1
12/01/22 14:00	0.5			1.5			12.8		1	0.5			1.5			12.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/22 15:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
12/01/22 16:00	1.1			1.5			13.7		1	1.1			1.5			13.8		1
12/01/22 17:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/01/22 18:00	1.2			1.5			13.8		1	1.1			1.5			13.9		1
12/01/22 19:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/01/22 20:00	1.3			1.5			13.9		1	1.1			1.5			13.9		1
12/01/22 21:00	1.3			1.5			13.9		1	1.1			1.5			13.9		1
12/01/22 22:00	1.4			1.5			13.9		1	1.2			1.5			13.9		1
12/01/22 23:00	1.4			1.5			14		1	1.3			1.5			14		1
12/02/22 0:00	1.3			1.5			14		1	1.3			1.5			14		1
12/02/22 1:00	1.3			1.5			14		1	1.4			1.5			14		1
12/02/22 2:00	1.3			1.5			14		1	1.3			1.5			14		1
12/02/22 3:00	1.2			1.5			13.9		1	1.2			1.5			13.9		1
12/02/22 4:00	1.2			1.5			13.9		1	1.1			1.5			13.9		1
12/02/22 5:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/02/22 6:00	1.1			1.5			13.5		1	1			1.5			13.5		1
12/02/22 7:00	0.4			1.5			12.8		1	0.5			1.5			12.9		1
12/02/22 8:00	0.9			1.5			13.5		1	1			1.5			13.5		1
12/02/22 9:00	1			1.5			13.5		1	1			1.5			13.5		1
12/02/22 10:00	0.9			1.5			13.4		1	0.9			1.5			13.4		1
12/02/22 11:00	0.9			1.5			13.5		1	1			1.5			13.5		1
12/02/22 12:00	0.9			1.5			13.5		1	0.9			1.5			13.5		1
12/02/22 13:00	0.4			1.5			13		1	0.5			1.5			13		1
12/02/22 14:00	0.4			1.5			12.7		1	0.4			1.5			12.8		1
12/02/22 15:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
12/02/22 16:00	0.5			1.5			12.9		1	0.5			1.5			13		1
12/02/22 17:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
12/02/22 18:00	0.4			1.5			12.9		1	0.5			1.5			13		1
12/02/22 19:00	0.5			1.5			12.9		1	0.5			1.5			12.9		1
12/02/22 20:00	0.4			1.5			12.6		1	0.4			1.5			12.7		1
12/02/22 21:00	0.5			1.5			12.9		1	0.6			1.5			13		1
12/02/22 22:00	0.5			1.5			13		1	0.7			1.5			13.1		1
12/02/22 23:00	1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 0:00	1.1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 1:00	1.1			1.5			13.6		1	1.1			1.5			13.6		1
12/03/22 2:00	1.1			1.4			13.6		1	1.1			1.2			13.6		1
12/03/22 3:00	1.1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 4:00	0.9			1.5			13.4		1	0.9			1.5			13.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 5:00	0.8			1.5			13.2		1	0.9			1.5			13.3		1
12/03/22 6:00	0.8			1.5			13.2		1	0.9			1.5			13.2		1
12/03/22 7:00	0.4			1.5			12.6		1	0.4			1.5			12.6		1
12/03/22 8:00	0.5			1.5			12.9		1	0.6			1.5			12.9		1
12/03/22 9:00	0.5			1.5			12.9		1	0.6			1.5			12.9		1
12/03/22 10:00	0.7			1.5			13.2		1	0.8			1.5			13.2		1
12/03/22 11:00	1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 12:00	1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 13:00	1			1.5			13.5		1	1			1.5			13.5		1
12/03/22 14:00	0.9			1.5			13.4		1	0.9			1.5			13.4		1
12/03/22 15:00	0.6			1.5			13.1		1	0.7			1.5			13.2		1
12/03/22 16:00	0.7			1.5			13.2		1	0.8			1.5			13.3		1
12/03/22 17:00	0.9			1.5			13.6		1	1			2.6			13.7		1
12/03/22 18:00	0.5			1.5			14.5		1	0			0			17.1		1
12/03/22 19:00	0.7			1.4			14.2		1	0	X		0	X		0	X	1
12/03/22 20:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/03/22 21:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/03/22 22:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/03/22 23:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 0:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/04/22 1:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/04/22 2:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 3:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 4:00	1.2			1.5			13.8		1	0	X		0	X		0	X	1
12/04/22 5:00	1.1			1.5			13.7		1	0	X		0	X		0	X	1
12/04/22 6:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 7:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 8:00	1.1			1.5			13.7		1	0	X		0	X		0	X	1
12/04/22 9:00	1.3			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 10:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 11:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 12:00	1.3			1.5			14		1	0	X		0	X		0	X	1
12/04/22 13:00	1.1			1.5			13.9		1	0	X		0	X		0	X	1
12/04/22 14:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 15:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/04/22 16:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/04/22 17:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 18:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/22 19:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 20:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 21:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 22:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/04/22 23:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 0:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 1:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 2:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 3:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 4:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 5:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 6:00	0.8			1.5			14.2		1	0	X		0	X		0	X	1
12/05/22 7:00	1.2			1.5			14		1	0	X		0	X		0	X	1
12/05/22 8:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 9:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/05/22 10:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
12/05/22 11:00	0.5			1.4			14.5		1	0	X		0	X		0	X	1
12/05/22 12:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
12/05/22 13:00	0.5			1.4			14.5		1	0	X		0	X		0	X	1
12/05/22 14:00	0.6			1.3			14.4		1	0	X		0	X		0	X	1
12/05/22 15:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1
12/05/22 16:00	0.7			1.3			14.4		1	0	X		0	X		0	X	1
12/05/22 17:00	0.7			1.4			14.3		1	0			0			15.2		1
12/05/22 18:00	0.7			1.4			14.2		1	1			1			14.2		1
12/05/22 19:00	0.9			1.5			13.4		1	0.8			1.2			13.3		1
12/05/22 20:00	0.9			1.5			13.4		1	0.8			1.5			13.4		1
12/05/22 21:00	1.1			1.5			13.7		1	1			1.5			13.7		1
12/05/22 22:00	1.2			1.5			14		1	1.2			1.5			14		1
12/05/22 23:00	0.7			1.4			14.3		1	0.8			1.4			14.3		1
12/06/22 0:00	0.9			1.5			14.3		1	0.8			1.4			14.3		1
12/06/22 1:00	0			0			17.2		1	0.7			1.3			14.3		1
12/06/22 2:00	0	X		0	X		0	X	1	0.6			1.7			14.4		1
12/06/22 3:00	0	X		0	X		0	X	1	0.6			1.1			14.5		1
12/06/22 4:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 5:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 6:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 7:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 8:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 9:00	0	X		0	X		0	X	1	0.6			1.3			14.4		1
12/06/22 10:00	0	X		0	X		0	X	1	0.7			1.5			14.3		1
12/06/22 11:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 12:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 13:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/06/22 14:00	0	X		0	X		0	X	1	0.6			1.4			14.5		1
12/06/22 15:00	0			0			15.5		1	0.7			1.5			14.4		1
12/06/22 16:00	1.1			1.6			14.1		1	1			1.4			14.2		1
12/06/22 17:00	0.8			1.5			13.4		1	0.8			1.5			13.3		1
12/06/22 18:00	1			1.5			13.5		1	0.9			1.5			13.5		1
12/06/22 19:00	0.9			1.5			13.5		1	0.9			1.5			13.4		1
12/06/22 20:00	0.9			1.5			13.5		1	0.9			1.5			13.5		1
12/06/22 21:00	1			1.5			13.6		1	0.9			1.5			13.5		1
12/06/22 22:00	1.3			1.5			13.9		1	1.1			1.5			13.9		1
12/06/22 23:00	1.4			1.5			14		1	1.2			1.5			14		1
12/07/22 0:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
12/07/22 1:00	0.8			1.5			14.2		1	0.8			1.5			14.2		1
12/07/22 2:00	0.8			1.5			14.2		1	0.8			1.5			14.3		1
12/07/22 3:00	0.8			1.5			14.2		1	0.8			1.5			14.3		1
12/07/22 4:00	1.2			1.5			14.1		1	1.4			1.5			14.2		1
12/07/22 5:00	1			1.5			13.5		1	0.9			1.5			13.4		1
12/07/22 6:00	0.9			1.5			13.4		1	0.9			1.5			13.4		1
12/07/22 7:00	1.3			1.5			14		1	1.2			1.5			13.9		1
12/07/22 8:00	1.4			1.5			14		1	1.4			1.5			14.1		1
12/07/22 9:00	1.2			1.5			13.8		1	1.1			1.5			13.9		1
12/07/22 10:00	1.1			1.5			13.9		1	1			1.5			13.9		1
12/07/22 11:00	1			1.5			13.9		1	1			1.5			14		1
12/07/22 12:00	0.9			1.5			14.1		1	0.9			1.5			14.1		1
12/07/22 13:00	0.5			1.5			14.5		1	0.6			1.5			14.5		1
12/07/22 14:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
12/07/22 15:00	1.1			1.5			13.8		1	1			1.5			13.9		1
12/07/22 16:00	1.1			1.5			13.9		1	1			1.5			13.9		1
12/07/22 17:00	1.1			1.5			13.9		1	1			1.5			13.9		1
12/07/22 18:00	1.1			1.5			13.9		1	1.1			1.5			13.9		1
12/07/22 19:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/07/22 20:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/07/22 21:00	0.8			1.5			13.4		1	0.9			1.5			13.4		1
12/07/22 22:00	1.3			1.5			13.9		1	1.2			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/22 23:00	1.5			1.5			14		1	1.2			1.5			14		1
12/08/22 0:00	1.2			1.5			13.7		1	1.1			1.5			13.7		1
12/08/22 1:00	1.3			1.5			13.9		1	1.1			1.5			13.9		1
12/08/22 2:00	1.3			1.5			13.9		1	1.1			1.5			13.9		1
12/08/22 3:00	1.2			1.5			13.9		1	1.1			1.5			13.9		1
12/08/22 4:00	1.1			1.5			13.7		1	1			1.5			13.7		1
12/08/22 5:00	1			1.5			13.5		1	1			1.5			13.5		1
12/08/22 6:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
12/08/22 7:00	0.9			1.5			13.5		1	1			1.5			13.5		1
12/08/22 8:00	1.2			1.5			13.9		1	1.2			1.5			13.9		1
12/08/22 9:00	0.9			1.5			14.1		1	1			1.5			14.1		1
12/08/22 10:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
12/08/22 11:00	0.9			1.5			13.7		1	1.1			1.5			13.7		1
12/08/22 12:00	0.7			1.5			13.3		1	0.7			1.5			13.4		1
12/08/22 13:00	0.7			1.5			13.3		1	0.8			1.5			13.3		1
12/08/22 14:00	0.5			1.5			13.1		1	0.6			1.5			13.2		1
12/08/22 15:00	0.6			1.5			13.3		1	0.7			1.5			13.3		1
12/08/22 16:00	0.5			1.5			13.1		1	0.6			1.5			13.1		1
12/08/22 17:00	0.4			1.5			12.9		1	0.5			1.5			12.9		1
12/08/22 18:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
12/08/22 19:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
12/08/22 20:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
12/08/22 21:00	0.4			1.5			12.9		1	0.5			1.5			13		1
12/08/22 22:00	0.5			1.5			13.1		1	0.6			1.5			13.1		1
12/08/22 23:00	1			1.5			13.5		1	0.9			1.5			13.6		1
12/09/22 0:00	0.9			1.5			14.2		1	1			1.5			14.2		1
12/09/22 1:00	0.7			1.5			14.2		1	0.8			1.5			14.2		1
12/09/22 2:00	0.7			1.5			14.3		1	0.7			1.6			14.3		1
12/09/22 3:00	0.7			1.5			14.3		1	0.7			1.5			14.3		1
12/09/22 4:00	1.2			1.5			14.2		1	1.4			1.5			14.2		1
12/09/22 5:00	1.4			1.5			14.1		1	1.7			1.5			14.1		1
12/09/22 6:00	1			1.5			14.3		1	1.2			1.5			14.3		1
12/09/22 7:00	1			1.5			13.5		1	1			1.5			13.6		1
12/09/22 8:00	1			1.5			14.2		1	0.9			1.5			14.2		1
12/09/22 9:00	0.8			1.5			14.2		1	0.8			1.4			14.2		1
12/09/22 10:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/09/22 11:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/09/22 12:00	0.6			1.5			14.5		1	0.6			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/22 13:00	0.7			1.5			14.4		1	0.7			1.4			14.4		1
12/09/22 14:00	0.7			1.5			14.4		1	0.7			1.5			14.3		1
12/09/22 15:00	0.9			1.4			14.2		1	0.9			1.4			14.2		1
12/09/22 16:00	0.9			1.5			13.4		1	0.9			1.5			13.5		1
12/09/22 17:00	0.9			1.5			13.5		1	0.9			1.5			13.5		1
12/09/22 18:00	0.9			1.5			13.4		1	0.9			1.5			13.4		1
12/09/22 19:00	0.7			1.5			13.2		1	0.7			1.5			13.2		1
12/09/22 20:00	0.6			1.5			13.1		1	0.7			1.5			13.1		1
12/09/22 21:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/09/22 22:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/09/22 23:00	1			1.5			13.6		1	1			1.5			13.6		1
12/10/22 0:00	0.8			1.5			14.4		1	0.8			1.5			14.3		1
12/10/22 1:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
12/10/22 2:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
12/10/22 3:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
12/10/22 4:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
12/10/22 5:00	0.7			1.5			14.4		1	0.7			1.5			14.3		1
12/10/22 6:00	0.6			1.5			14.3		1	0.7			1.5			14.3		1
12/10/22 7:00	0.6			1.5			14.3		1	0.6			1.4			14.3		1
12/10/22 8:00	0.6			1.4			14.3		1	0.7			1.3			14.3		1
12/10/22 9:00	0.6			1.4			14.3		1	0.6			1.4			14.3		1
12/10/22 10:00	0.5			1.5			14.4		1	0.5			1.5			14.4		1
12/10/22 11:00	0.6			1.5			14.3		1	0.6			1.4			14.3		1
12/10/22 12:00	0.6			1.5			14.3		1	0.7			1.4			14.3		1
12/10/22 13:00	0.9			1.5			14.2		1	1.2			1.5			14.2		1
12/10/22 14:00	1.1			1.5			13.7		1	1.1			1.5			13.6		1
12/10/22 15:00	1			1.5			13.5		1	1			1.5			13.5		1
12/10/22 16:00	0.9			1.5			13.5		1	1			1.5			13.5		1
12/10/22 17:00	1.1			1.5			13.6		1	1.1			1.5			13.6		1
12/10/22 18:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/10/22 19:00	0.7			1.5			13.2		1	0.8			1.5			13.2		1
12/10/22 20:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/10/22 21:00	1			1.5			13.6		1	1			1.5			13.6		1
12/10/22 22:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/10/22 23:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/11/22 0:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/11/22 1:00	0.8			1.5			14.2		1	0.8			1.5			14.2		1
12/11/22 2:00	0.6			1.6			14.3		1	0.7			1.4			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/22 3:00	0.8			1.4			14.2		1	0.8			1.4			14.2		1
12/11/22 4:00	0.7			1.5			14.2		1	0.8			1.5			14.2		1
12/11/22 5:00	0.7			1.5			14.2		1	0.7			1.5			14.2		1
12/11/22 6:00	0.7			1.5			14.2		1	0.8			1.5			14.2		1
12/11/22 7:00	0.6			1.5			14.3		1	0.6			1.5			14.3		1
12/11/22 8:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/11/22 9:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/11/22 10:00	0.5			1.5			14.5		1	0.5			1.5			14.5		1
12/11/22 11:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/11/22 12:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/11/22 13:00	0.5			1.5			14.5		1	0.5			1.5			14.5		1
12/11/22 14:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/11/22 15:00	0.8			1.5			14.3		1	0.8			1.4			14.3		1
12/11/22 16:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/11/22 17:00	1.2			1.5			13.7		1	1.1			1.5			13.7		1
12/11/22 18:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/11/22 19:00	1.3			1.5			13.8		1	1.1			1.5			13.8		1
12/11/22 20:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/11/22 21:00	1.2			1.5			13.8		1	1.1			1.5			13.8		1
12/11/22 22:00	0.9			1.5			14.2		1	0.9			1.5			14.2		1
12/11/22 23:00	0.5			1.5			14.4		1	0.6			1.5			14.4		1
12/12/22 0:00	0.5			1.5			14.4		1	0.6			1.5			14.4		1
12/12/22 1:00	0.6			1.4			14.3		1	0.6			1.3			14.3		1
12/12/22 2:00	0.7			1.8			14.2		1	0.8			1.5			14.2		1
12/12/22 3:00	0.6			1.7			14.3		1	0.7			1.5			14.3		1
12/12/22 4:00	0.9			1.6			14.1		1	1.1			1.4			14.1		1
12/12/22 5:00	0.9			0.7			13.5		1	1			1.5			13.5		1
12/12/22 6:00	0.8			0.7			13.3		1	0.9			1.5			13.4		1
12/12/22 7:00	0.9			0.8			13.5		1	1			1.5			13.6		1
12/12/22 8:00	0	X		0	X		0	X	0	1.1			1.5			13.9		1
12/12/22 9:00	1.3			1.4			13.9		1	1.2			1.5			13.9		1
12/12/22 10:00	1.1			1.5			14.1		1	1.1			1.5			14.1		1
12/12/22 11:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/12/22 12:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/12/22 13:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/12/22 14:00	0.5			1.5			14.6		1	0.5			1.5			14.7		1
12/12/22 15:00	1.2			1.4			14.2		1	0			0			17.3		1
12/12/22 16:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 17:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
12/12/22 18:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
12/12/22 19:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
12/12/22 20:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
12/12/22 21:00	1.5			1.5			14		1	0	X		0	X		0	X	1
12/12/22 22:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/12/22 23:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 0:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 1:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 2:00	1.3			1.5			14		1	0	X		0	X		0	X	1
12/13/22 3:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 4:00	1.5			1.5			14		1	0	X		0	X		0	X	1
12/13/22 5:00	1.5			1.5			14		1	0	X		0	X		0	X	1
12/13/22 6:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 7:00	1.3			1.5			13.7		1	0	X		0	X		0	X	1
12/13/22 8:00	1.5			1.5			14		1	0	X		0	X		0	X	1
12/13/22 9:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 10:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 11:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/13/22 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/13/22 13:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
12/13/22 14:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
12/13/22 15:00	0.9			1.5			14.3		1	0	X		0	X		0	X	1
12/13/22 16:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 17:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 18:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 19:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
12/13/22 20:00	1.4			1.5			14		1	0	X		0	X		0	X	1
12/13/22 21:00	1.2			1.5			13.7		1	0	X		0	X		0	X	1
12/13/22 22:00	1.4			1.5			13.8		1	0	X		0	X		0	X	1
12/13/22 23:00	1.5			1.5			14		1	0	X		0	X		0	X	1
12/14/22 0:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 1:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 2:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 3:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 4:00	0.9			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 5:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 6:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/22 7:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 8:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 9:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 10:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 11:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 12:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
12/14/22 13:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
12/14/22 14:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
12/14/22 15:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
12/14/22 16:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
12/14/22 17:00	1.7			1.5			14.1		1	0	X		0	X		0	X	1
12/14/22 18:00	1.6			1.5			14.1		1	0	X		0	X		0	X	1
12/14/22 19:00	1.5			1.5			14.1		1	0	X		0	X		0	X	1
12/14/22 20:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
12/14/22 21:00	0.9			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 22:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/14/22 23:00	1			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 0:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 1:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 2:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 3:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 4:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 5:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 6:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 7:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 8:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 9:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 10:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 11:00	0.6			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 12:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 13:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 14:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 15:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 16:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 17:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 18:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/15/22 19:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 20:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/22 21:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 22:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/15/22 23:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
12/16/22 0:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
12/16/22 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 2:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 16:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 17:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 19:00	0.8			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
12/16/22 22:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/16/22 23:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/17/22 0:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/17/22 1:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
12/17/22 2:00	0.8			1.3			14.3		1	0	X		0	X		0	X	1
12/17/22 3:00	0.9			1.5			14.3		1	0.9			1.1			15.5		1
12/17/22 4:00	0.7			1.5			14.5		1	0.8			1.3			14.6		1
12/17/22 5:00	0.9			1.5			14.2		1	1.1			1.2			14.1		1
12/17/22 6:00	1.5			1.5			14		1	1.5			1.6			14		1
12/17/22 7:00	1.5			1.5			13.9		1	1.4			1.5			13.9		1
12/17/22 8:00	1			1.5			14.2		1	1.1			1.5			14.3		1
12/17/22 9:00	0.9			1.5			14.2		1	0.9			1.4			14.2		1
12/17/22 10:00	0.7			1.5			14.3		1	0.7			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 11:00	0.5			1.5			14.5		1	0.5			1.5			14.6		1
12/17/22 12:00	0.5			1.5			14.6		1	0.5			1.5			14.6		1
12/17/22 13:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/17/22 14:00	0.7			1.4			14.5		1	0.7			1.4			14.5		1
12/17/22 15:00	0.9			1.5			13.5		1	0.9			1.6			13.6		1
12/17/22 16:00	0.7			1.5			13.3		1	0.8			1.5			13.4		1
12/17/22 17:00	0.9			1.5			13.5		1	0.9			1.5			13.5		1
12/17/22 18:00	1.1			1.5			13.7		1	1			1.5			13.7		1
12/17/22 19:00	0.9			1.5			13.3		1	0.9			1.5			13.3		1
12/17/22 20:00	0.7			1.5			13.1		1	0.7			1.5			13.1		1
12/17/22 21:00	0.8			1.5			13.2		1	0.8			1.5			13.2		1
12/17/22 22:00	0.9			1.5			13.3		1	0.9			1.5			13.3		1
12/17/22 23:00	1.4			1.5			13.7		1	1.3			1.5			13.8		1
12/18/22 0:00	1			1.5			14.2		1	1			1.5			14.3		1
12/18/22 1:00	0.9			1.5			14.2		1	0.8			1.5			14.3		1
12/18/22 2:00	0.9			1.4			14.2		1	0.8			1.5			14.2		1
12/18/22 3:00	0.9			1.5			14.2		1	0.8			1.5			14.2		1
12/18/22 4:00	0.8			1.5			14.2		1	0.8			1.5			14.3		1
12/18/22 5:00	0.8			1.5			14.2		1	0.8			1.5			14.3		1
12/18/22 6:00	1.1			1.5			14.1		1	1.2			1.5			14.1		1
12/18/22 7:00	0.6			1.5			12.9		1	0.6			1.5			13		1
12/18/22 8:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
12/18/22 9:00	0.8			1.5			13.2		1	0.8			1.5			13.3		1
12/18/22 10:00	1			1.5			13.7		1	1			1.5			13.7		1
12/18/22 11:00	0.8			1.5			14.2		1	0.8			1.5			14.3		1
12/18/22 12:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
12/18/22 13:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/18/22 14:00	0.7			1.4			14.3		1	0.7			1.4			14.3		1
12/18/22 15:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
12/18/22 16:00	1.7			1.5			14.1		1	1.9			1.6			14.2		1
12/18/22 17:00	1.5			1.5			13.7		1	1.7			1.5			14		1
12/18/22 18:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
12/18/22 19:00	0.9			1.5			13.4		1	1			1.5			13.4		1
12/18/22 20:00	1			1.5			13.5		1	1			1.5			13.5		1
12/18/22 21:00	1.1			1.5			13.6		1	1.1			1.5			13.6		1
12/18/22 22:00	1.1			1.5			13.7		1	1.1			1.5			13.7		1
12/18/22 23:00	1.3			1.5			13.9		1	1.2			1.5			13.9		1
12/19/22 0:00	1			1.5			13.5		1	1			1.5			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/22 1:00	1			1.5			13.5		1	1.1			1.5			13.6		1
12/19/22 2:00	1			1.5			13.5		1	1			1.5			13.5		1
12/19/22 3:00	1			1.5			13.5		1	1			1.5			13.5		1
12/19/22 4:00	0.8			1.5			13.3		1	0.9			1.5			13.3		1
12/19/22 5:00	0.5			1.5			12.9		1	0.6			1.5			13		1
12/19/22 6:00	0.5			1.5			12.9		1	0.6			1.5			13		1
12/19/22 7:00	0.6			1.5			13		1	0.7			1.5			13.1		1
12/19/22 8:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/19/22 9:00	0.5			1.5			12.8		1	0.5			1.5			12.8		1
12/19/22 10:00	0.5			1.5			12.9		1	0.5			1.5			12.9		1
12/19/22 11:00	0.6			1.5			13		1	0.7			1.5			13.1		1
12/19/22 12:00	0.9			1.5			13.3		1	0.9			1.5			13.4		1
12/19/22 13:00	0.8			1.5			13.3		1	0.8			1.5			13.3		1
12/19/22 14:00	0.6			1.5			13.1		1	0.7			1.5			13.2		1
12/19/22 15:00	0.8			1.5			13.3		1	0.6			1.5			13.1		1
12/19/22 16:00	0.5			1.5			13		1	0.6			1.5			13.2		1
12/19/22 17:00	0.5			1.5			13		1	0.6			1.5			13.1		1
12/19/22 18:00	0.6			1.5			13		1	0.7			1.5			13.1		1
12/19/22 19:00	0.6			1.5			13		1	0.7			1.5			13.1		1
12/19/22 20:00	0.6			1.5			13		1	0.6			1.5			13.1		1
12/19/22 21:00	0.5			1.5			13		1	0.6			1.5			13.1		1
12/19/22 22:00	0.7			1.5			13		1	0.6			1.5			13.2		1
12/19/22 23:00	1			1.5			13.4		1	1			1.5			13.6		1
12/20/22 0:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/20/22 1:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 2:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 3:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 4:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 5:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 6:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/20/22 7:00	0.8			1.5			13.1		1	1			1.5			13.2		1
12/20/22 8:00	0.9			1.5			13.3		1	0.9			1.5			13.5		1
12/20/22 9:00	1.5			1.5			14		1	1.4			1.5			14.2		1
12/20/22 10:00	1.2			1.5			14.1		1	1.2			1.5			14.3		1
12/20/22 11:00	0.5			1.5			14.6		1	0.6			1.4			14.7		1
12/20/22 12:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
12/20/22 13:00	0.5			1.5			14.6		1	0.6			1.5			14.8		1
12/20/22 14:00	0.5			1.5			14.6		1	0.5			1.5			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/22 15:00	0.8			1.4			14.3		1	0.9			1.4			14.4		1
12/20/22 16:00	1.4			1.5			14		1	1.2			1.5			14.1		1
12/20/22 17:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/20/22 18:00	1.3			1.5			14		1	1.4			1.5			14.1		1
12/20/22 19:00	1.3			1.5			14		1	1.3			1.5			14.1		1
12/20/22 20:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/20/22 21:00	1.4			1.5			14		1	1.5			1.5			14.1		1
12/20/22 22:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/20/22 23:00	1.4			1.5			14		1	1.4			1.5			14.1		1
12/21/22 0:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/21/22 1:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/21/22 2:00	1.6			1.5			14		1	1.6			1.5			14.1		1
12/21/22 3:00	1.7			1.5			14		1	1.8			1.5			14.2		1
12/21/22 4:00	1.6			1.5			14.1		1	1.6			1.5			14.2		1
12/21/22 5:00	1.5			1.5			14		1	1.5			1.5			14.2		1
12/21/22 6:00	1.4			1.5			14		1	1.4			1.5			14.1		1
12/21/22 7:00	1.1			1.5			13.4		1	1.1			1.5			13.5		1
12/21/22 8:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
12/21/22 9:00	0.8			1.5			13.2		1	0.9			1.5			13.4		1
12/21/22 10:00	0.9			1.5			13.3		1	1			1.5			13.5		1
12/21/22 11:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/21/22 12:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/21/22 13:00	1			1.5			13.5		1	1			1.5			13.6		1
12/21/22 14:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/21/22 15:00	1.4			1.5			13.9		1	1.4			1.5			14		1
12/21/22 16:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/21/22 17:00	1.2			1.5			13.7		1	1.1			1.5			13.8		1
12/21/22 18:00	1.2			1.5			13.7		1	1.2			1.5			13.9		1
12/21/22 19:00	1.2			1.5			13.7		1	1.2			1.5			13.8		1
12/21/22 20:00	0.9			1.5			13.3		1	0.9			1.5			13.4		1
12/21/22 21:00	0.8			1.5			13.3		1	0.9			1.5			13.4		1
12/21/22 22:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
12/21/22 23:00	1.4			1.5			13.9		1	1.4			1.5			14.1		1
12/22/22 0:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/22/22 1:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/22/22 2:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
12/22/22 3:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
12/22/22 4:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/22 5:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/22/22 6:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/22/22 7:00	1.4			1.5			13.9		1	1.5			1.5			14		1
12/22/22 8:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/22/22 9:00	0.9			1.5			13.3		1	0.9			1.5			13.4		1
12/22/22 10:00	0.5			1.5			13		1	0.6			1.5			13.1		1
12/22/22 11:00	0.6			1.5			13		1	0.6			1.5			13.1		1
12/22/22 12:00	1.2			1.5			13.7		1	1.2			1.5			13.8		1
12/22/22 13:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/22/22 14:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/22/22 15:00	1.3			1.5			13.9		1	1.2			1.5			14		1
12/22/22 16:00	1.1			1.5			13.5		1	1			1.5			13.7		1
12/22/22 17:00	1.3			1.5			13.8		1	1.2			1.5			13.9		1
12/22/22 18:00	1.3			1.5			13.9		1	1.2			1.5			14		1
12/22/22 19:00	1.4			1.5			13.9		1	1.4			1.5			14		1
12/22/22 20:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/22/22 21:00	1.4			1.5			13.9		1	1.3			1.5			14		1
12/22/22 22:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/22/22 23:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/23/22 0:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/23/22 1:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/23/22 2:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/23/22 3:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/23/22 4:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/23/22 5:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/23/22 6:00	1.6			1.5			14		1	1.5			1.5			14.1		1
12/23/22 7:00	1			1.5			13.4		1	1			1.5			13.5		1
12/23/22 8:00	1.2			1.5			13.6		1	1.2			1.5			13.8		1
12/23/22 9:00	1.2			1.5			13.6		1	1.1			1.5			13.7		1
12/23/22 10:00	1.2			1.5			13.7		1	1.1			1.5			13.8		1
12/23/22 11:00	1.2			1.5			13.7		1	1.1			1.5			13.8		1
12/23/22 12:00	1.3			1.5			14		1	1.3			1.5			14.1		1
12/23/22 13:00	0.8			1.5			14.3		1	0.8			1.3			14.4		1
12/23/22 14:00	0.8			1.4			14.4		1	0.9			1.3			14.5		1
12/23/22 15:00	1.2			1.5			13.7		1	1.1			1.5			13.8		1
12/23/22 16:00	0.7			1.5			13.1		1	0.7			1.5			13.2		1
12/23/22 17:00	0.7			1.5			13.2		1	0.8			1.5			13.3		1
12/23/22 18:00	0.8			1.5			13.2		1	0.8			1.5			13.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/22 19:00	1			1.5			13.5		1	1			1.5			13.6		1
12/23/22 20:00	1.1			1.5			13.5		1	1.1			1.5			13.6		1
12/23/22 21:00	1			1.5			13.5		1	1			1.5			13.6		1
12/23/22 22:00	1.3			1.5			13.6		1	1.2			1.5			13.7		1
12/23/22 23:00	1.4			1.5			13.7		1	1.3			1.5			13.8		1
12/24/22 0:00	1			1.5			14.3		1	1			1.5			14.4		1
12/24/22 1:00	0.9			1.5			14.3		1	1			1.5			14.4		1
12/24/22 2:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/24/22 3:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/24/22 4:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/24/22 5:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/24/22 6:00	0.9			1.5			14.3		1	0.9			1.5			14.4		1
12/24/22 7:00	0.8			1.6			14.3		1	0.8			1.5			14.4		1
12/24/22 8:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/22 9:00	1.2			1.4			14.2		1	1.4			1.4			14.3		1
12/24/22 10:00	1.2			1.5			13.7		1	1.2			1.5			13.8		1
12/24/22 11:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/24/22 12:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/24/22 13:00	1.4			1.5			13.9		1	1.2			1.5			14		1
12/24/22 14:00	1.3			1.5			14		1	1.4			1.5			14.1		1
12/24/22 15:00	1.2			1.5			14		1	1.3			1.5			14.1		1
12/24/22 16:00	1.2			1.5			13.9		1	1.3			1.5			14		1
12/24/22 17:00	1.3			1.5			14		1	1.4			1.5			14.1		1
12/24/22 18:00	1.4			1.5			14		1	1.5			1.5			14.1		1
12/24/22 19:00	1.3			1.5			14		1	1.5			1.5			14		1
12/24/22 20:00	1.2			1.5			14.1		1	1.3			1.5			14.2		1
12/24/22 21:00	0.7			1.5			14.5		1	0.7			1.5			14.5		1
12/24/22 22:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/24/22 23:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 0:00	0.8			1.5			14.3		1	0.8			1.4			14.4		1
12/25/22 1:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
12/25/22 2:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 3:00	0.8			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 4:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 5:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 6:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 7:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
12/25/22 8:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/22 9:00	0.8			1.5			14.3		1	0.8			1.3			14.4		1
12/25/22 10:00	0.6			1.5			14.4		1	0.7			1.4			14.5		1
12/25/22 11:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
12/25/22 12:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/25/22 13:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/22 15:00	0.6			1.5			14.6		1	0.6			1.5			14.7		1
12/25/22 16:00	0.9			1.5			14.3		1	1			1.4			14.4		1
12/25/22 17:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/25/22 18:00	0.8			1.5			14.4		1	0.9			1.5			14.5		1
12/25/22 19:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 20:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 21:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/25/22 22:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
12/25/22 23:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
12/26/22 0:00	0.8			1.5			14.3		1	0.8			1.4			14.4		1
12/26/22 1:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/26/22 2:00	0.7			1.4			14.4		1	0.7			1.4			14.5		1
12/26/22 3:00	0.8			1.5			14.4		1	0.7			1.4			14.4		1
12/26/22 4:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
12/26/22 5:00	0.8			1.5			14.2		1	0.9			1.4			14.3		1
12/26/22 6:00	0.8			1.5			14.3		1	0.9			1.4			14.3		1
12/26/22 7:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
12/26/22 8:00	0.7			1.5			14.6		1	0.7			1.5			14.8		1
12/26/22 9:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
12/26/22 10:00	0.9			1.5			14.3		1	0.9			1.2			14.3		1
12/26/22 11:00	1.2			1.5			14.1		1	1.4			1.6			14.2		1
12/26/22 12:00	1.6			1.5			14		1	1.7			1.5			14.1		1
12/26/22 13:00	1.3			1.5			13.8		1	1.4			1.5			13.9		1
12/26/22 14:00	1			1.5			13.5		1	1.1			1.5			13.6		1
12/26/22 15:00	0.9			1.5			13.4		1	1			1.5			13.5		1
12/26/22 16:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/26/22 17:00	1			1.5			13.5		1	1.1			1.5			13.6		1
12/26/22 18:00	1			1.5			13.5		1	1.1			1.5			13.6		1
12/26/22 19:00	1.2			1.5			13.8		1	1.2			1.5			13.9		1
12/26/22 20:00	1.2			1.5			13.8		1	1.1			1.5			13.9		1
12/26/22 21:00	1.2			1.5			13.9		1	1.1			1.5			14		1
12/26/22 22:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/22 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 0:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 2:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 3:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 4:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 5:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 6:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 7:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 8:00	0.6			1.5			14.4		1	0.6			1.5			14.5		1
12/27/22 9:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 10:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 11:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 12:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 13:00	0.6			1.5			14.4		1	0.6			1.5			14.5		1
12/27/22 14:00	0.6			1.5			14.4		1	0.6			1.5			14.5		1
12/27/22 15:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 16:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 17:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 18:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 19:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 20:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/27/22 21:00	0.6			1.5			14.5		1	0.6			1.5			14.7		1
12/27/22 22:00	0.6			1.5			14.5		1	0.6			1.5			14.7		1
12/27/22 23:00	0.6			1.5			14.6		1	0.6			1.5			14.7		1
12/28/22 0:00	0			0			17.1		1	0.7			1.3			14.5		1
12/28/22 1:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 2:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/28/22 3:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
12/28/22 4:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 5:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/28/22 6:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/28/22 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
12/28/22 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
12/28/22 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
12/28/22 10:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 11:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 12:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/22 13:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 14:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 15:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 16:00	0	X		0	X		0	X	1	0.6			1.4			14.5		1
12/28/22 17:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 18:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/28/22 19:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/28/22 20:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
12/28/22 21:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/28/22 22:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
12/28/22 23:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 0:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 1:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 2:00	0	X		0	X		0	X	1	0.6			1.4			14.5		1
12/29/22 3:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 4:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 5:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 6:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 7:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 8:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 9:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 10:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/29/22 11:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 12:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 13:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 14:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 15:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 16:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 17:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 18:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 19:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 20:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 21:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 22:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/29/22 23:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 0:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 1:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 2:00	0	X		0	X		0	X	1	0.6			1.4			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/22 3:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 4:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 5:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 6:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 7:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 8:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 9:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 10:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 11:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 12:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/30/22 13:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/30/22 14:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/30/22 15:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/30/22 16:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/30/22 17:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 18:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 19:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 20:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 21:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/30/22 22:00	0	X		0	X		0	X	1	0.5			1.4			14.6		1
12/30/22 23:00	0	X		0	X		0	X	1	0.5			1.5			14.5		1
12/31/22 0:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
12/31/22 1:00	0	X		0	X		0	X	1	0.5			1.5			14.5		1
12/31/22 2:00	0	X		0	X		0	X	1	0.6			1.6			14.5		1
12/31/22 3:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/31/22 4:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/31/22 5:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/31/22 6:00	0	X		0	X		0	X	1	0.7			1.1			14.4		1
12/31/22 7:00	0	X		0	X		0	X	1	0.7			1.5			14.3		1
12/31/22 8:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
12/31/22 9:00	0	X		0	X		0	X	1	0.6			1.3			14.5		1
12/31/22 10:00	0	X		0	X		0	X	1	0			0			15.8		1
12/31/22 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/22 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/22 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/22 14:00	0	X		0	X		0	X	1	0			0			16		1
12/31/22 15:00	0	X		0	X		0	X	1	0.6			1.2			14.4		1
12/31/22 16:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 17:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 18:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 19:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 20:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 21:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 22:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
12/31/22 23:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1

ATTACHMENT 5

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2022	0.6338	6.9447	1.5229	13.9715	0.3310	2.9119	0.1656	1.4563	0.5515	4.8538
Nov 2022	0.7748	7.3343	1.8689	14.5482	0.4031	3.0270	0.2017	1.5140	0.6720	5.0462
Dec 2022	0.6728	7.4389	1.5792	14.5596	0.3385	3.0207	0.1697	1.5116	0.5644	5.0359
Sum/Avg	7.4389		14.5596		3.0207		1.5116		5.0359	
Limit Value										

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/22 0:00	5.4			5.9														
10/02/22 0:00	5.9			6														
10/03/22 0:00	6.6			6.8														
10/04/22 0:00	7.2			7.2														
10/05/22 0:00	7.2			7.2														
10/06/22 0:00	6.7			6.7														
10/07/22 0:00	7.2			7.2														
10/08/22 0:00	6.5			6.2														
10/09/22 0:00	7.2			0														
10/10/22 0:00	6.7			0														
10/11/22 0:00	5.6			0														
10/12/22 0:00	5.6			0														
10/13/22 0:00	5.6			0														
10/14/22 0:00	6.3			0														
10/15/22 0:00	5.5			0														
10/16/22 0:00	6.2			0														
10/17/22 0:00	7.2			0														
10/18/22 0:00	7.3			3.1														
10/19/22 0:00	4.2			6.2														
10/20/22 0:00	5.7			6														
10/21/22 0:00	5.8			5.8														
10/22/22 0:00	7.4			7.5														
10/23/22 0:00	6.6			6.8														
10/24/22 0:00	6.7			6.9														
10/25/22 0:00	6.1			6.6														
10/26/22 0:00	5.7			5.8														
10/27/22 0:00	6.2			6.5														
10/28/22 0:00	6.9			7.7														
10/29/22 0:00	5.4			5.8														
10/30/22 0:00	6.2			6.3														
10/31/22 0:00	5.8			6														
11/01/22 0:00	7.2			7.9														
11/02/22 0:00	6.4			7														
11/03/22 0:00	7			7.2														
11/04/22 0:00	5.8			6.2														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/05/22 0:00	5.2			5.3														
11/06/22 0:00	6.2			6.3														
11/07/22 0:00	5.8			6.1														
11/08/22 0:00	6.4			0														
11/09/22 0:00	6.2			0.7														
11/10/22 0:00	6			6.4														
11/11/22 0:00	6.5			7.1														
11/12/22 0:00	7.2			8														
11/13/22 0:00	7			7.8														
11/14/22 0:00	7.1			8.1														
11/15/22 0:00	7.3			8														
11/16/22 0:00	6.8			7.7														
11/17/22 0:00	7.1			7.6														
11/18/22 0:00	8.2			9														
11/19/22 0:00	6.9			7.5														
11/20/22 0:00	7.7			7.9														
11/21/22 0:00	6.7			7.1														
11/22/22 0:00	6.8			7														
11/23/22 0:00	6.1			6.5														
11/24/22 0:00	7			7.1														
11/25/22 0:00	6.5			6.5														
11/26/22 0:00	6.7			6.9														
11/27/22 0:00	6.4			6.6														
11/28/22 0:00	6.5			6.9														
11/29/22 0:00	8.1			6.7														
11/30/22 0:00	6.4			6.6														
12/01/22 0:00	7.3			8														
12/02/22 0:00	8.3			8.8														
12/03/22 0:00	7.3			6.4														
12/04/22 0:00	7.2			0														
12/05/22 0:00	6.2			1.9														
12/06/22 0:00	2.7			5.8														
12/07/22 0:00	7			7.4														
12/08/22 0:00	7.7			8.6														
12/09/22 0:00	6.6			7.5														
12/10/22 0:00	6.7			6.8														
12/11/22 0:00	5.5			6														
12/12/22 0:00	6.4			3.9														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/13/22 0:00	6.7			0														
12/14/22 0:00	6.7			0														
12/15/22 0:00	7.2			0														
12/16/22 0:00	4.9			0														
12/17/22 0:00	6			6.1														
12/18/22 0:00	6.9			7.5														
12/19/22 0:00	8.6			9.6														
12/20/22 0:00	6.8			6.9														
12/21/22 0:00	7.2			7.9														
12/22/22 0:00	7.4			7.5														
12/23/22 0:00	7			7.7														
12/24/22 0:00	6.7			6.7														
12/25/22 0:00	4.9			4.9														
12/26/22 0:00	5.9			6														
12/27/22 0:00	4.8			4.8														
12/28/22 0:00	0			4.8														
12/29/22 0:00	0			4.8														
12/30/22 0:00	0			4.8														
12/31/22 0:00	0			3.9														

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/01/22 0:00	0.2517			0.27144			0.52											
10/01/22 1:00	0.23988			0.25854			0.5											
10/01/22 2:00	0.24594			0.26514			0.51											
10/01/22 3:00	0.25392			0.27378			0.53											
10/01/22 4:00	0.24618			0.26544			0.51											
10/01/22 5:00	0.26064			0.2808			0.54											
10/01/22 6:00	0.21648			0.2328			0.45											
10/01/22 7:00	0.16488			0.17724			0.34											
10/01/22 8:00	0.16482			0.17694			0.34											
10/01/22 9:00	0.165			0.17664			0.34											
10/01/22 10:00	0.1653			0.17652			0.34											
10/01/22 11:00	0.16518			0.17598			0.34											
10/01/22 12:00	0.16542			0.1758			0.34											
10/01/22 13:00	0.16782			0.17838			0.35											
10/01/22 14:00	0.16572			0.17598			0.34											
10/01/22 15:00	0.16794			0.17814			0.35											
10/01/22 16:00	0.2283			0.24348			0.47											
10/01/22 17:00	0.26724			0.288			0.56											
10/01/22 18:00	0.2541			0.27342			0.53											
10/01/22 19:00	0.24066			0.25932			0.5											
10/01/22 20:00	0.2586			0.27882			0.54											
10/01/22 21:00	0.24138			0.26004			0.5											
10/01/22 22:00	0.19536			0.20994			0.41											
10/01/22 23:00	0.23022			0.2481			0.48											
10/02/22 0:00	0.21672			0.23382			0.45											
10/02/22 1:00	0.2121			0.2286			0.44											
10/02/22 2:00	0.25176			0.27192			0.52											
10/02/22 3:00	0.25338			0.27366			0.53											
10/02/22 4:00	0.26544			0.28662			0.55											
10/02/22 5:00	0.2637			0.28458			0.55											
10/02/22 6:00	0.22704			0.24474			0.47											
10/02/22 7:00	0.16572			0.17796			0.34											
10/02/22 8:00	0.16482			0.17712			0.34											
10/02/22 9:00	0.16488			0.17682			0.34											
10/02/22 10:00	0.16494			0.17658			0.34											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/02/22 11:00	0.16494			0.17652			0.34											
10/02/22 12:00	0.16872			0.18024			0.35											
10/02/22 13:00	0.2028			0.21726			0.42											
10/02/22 14:00	0.25176			0.27084			0.52											
10/02/22 15:00	0.21246			0.22632			0.44											
10/02/22 16:00	0.26238			0.27924			0.54											
10/02/22 17:00	0.3141			0.33012			0.64											
10/02/22 18:00	0.3114			0.32934			0.64											
10/02/22 19:00	0.31044			0.32802			0.64											
10/02/22 20:00	0.3033			0.32256			0.63											
10/02/22 21:00	0.24072			0.25932			0.5											
10/02/22 22:00	0.21756			0.23418			0.45											
10/02/22 23:00	0.26802			0.28968			0.56											
10/03/22 0:00	0.25722			0.27738			0.53											
10/03/22 1:00	0.25338			0.2733			0.53											
10/03/22 2:00	0.25608			0.2763			0.53											
10/03/22 3:00	0.25866			0.27936			0.54											
10/03/22 4:00	0.26604			0.28746			0.55											
10/03/22 5:00	0.2697			0.2907			0.56											
10/03/22 6:00	0.24756			0.26688			0.51											
10/03/22 7:00	0.1926			0.20724			0.4											
10/03/22 8:00	0.24954			0.26934			0.52											
10/03/22 9:00	0.17634			0.18894			0.37											
10/03/22 10:00	0.19734			0.21168			0.41											
10/03/22 11:00	0.22668			0.24432			0.47											
10/03/22 12:00	0.2658			0.28734			0.55											
10/03/22 13:00	0.26742			0.28836			0.56											
10/03/22 14:00	0.26748			0.28776			0.56											
10/03/22 15:00	0.26976			0.29064			0.56											
10/03/22 16:00	0.26142			0.27972			0.54											
10/03/22 17:00	0.3153			0.33144			0.65											
10/03/22 18:00	0.31644			0.33372			0.65											
10/03/22 19:00	0.3144			0.33288			0.65											
10/03/22 20:00	0.31188			0.33018			0.64											
10/03/22 21:00	0.26838			0.2883			0.56											
10/03/22 22:00	0.2655			0.28632			0.55											
10/03/22 23:00	0.30504			0.32586			0.63											
10/04/22 0:00	0.30672			0.32844			0.64											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/04/22 1:00	0.31086			0.33156			0.64											
10/04/22 2:00	0.30642			0.32718			0.63											
10/04/22 3:00	0.30702			0.32844			0.64											
10/04/22 4:00	0.30126			0.32232			0.62											
10/04/22 5:00	0.31032			0.3303			0.64											
10/04/22 6:00	0.30138			0.32124			0.62											
10/04/22 7:00	0.28434			0.30552			0.59											
10/04/22 8:00	0.26982			0.28998			0.56											
10/04/22 9:00	0.28284			0.30246			0.59											
10/04/22 10:00	0.31098			0.32898			0.64											
10/04/22 11:00	0.2769			0.2961			0.57											
10/04/22 12:00	0.32502			0.32832			0.65											
10/04/22 13:00	0.30498			0.32094			0.63											
10/04/22 14:00	0.30354			0.31932			0.62											
10/04/22 15:00	0.3132			0.32658			0.64											
10/04/22 16:00	0.32916			0.31746			0.65											
10/04/22 17:00	0.34128			0.31344			0.65											
10/04/22 18:00	0.33768			0.31428			0.65											
10/04/22 19:00	0.3327			0.31632			0.65											
10/04/22 20:00	0.33186			0.31764			0.65											
10/04/22 21:00	0.32994			0.31902			0.65											
10/04/22 22:00	0.31632			0.32052			0.64											
10/04/22 23:00	0.32844			0.32094			0.65											
10/05/22 0:00	0.32646			0.3219			0.65											
10/05/22 1:00	0.32172			0.32346			0.65											
10/05/22 2:00	0.32268			0.32376			0.65											
10/05/22 3:00	0.32016			0.324			0.64											
10/05/22 4:00	0.32082			0.3261			0.65											
10/05/22 5:00	0.31986			0.3267			0.65											
10/05/22 6:00	0.30348			0.32556			0.63											
10/05/22 7:00	0.29154			0.3189			0.61											
10/05/22 8:00	0.2748			0.29496			0.57											
10/05/22 9:00	0.26328			0.28074			0.54											
10/05/22 10:00	0.30642			0.31524			0.62											
10/05/22 11:00	0.30636			0.31434			0.62											
10/05/22 12:00	0.31698			0.31308			0.63											
10/05/22 13:00	0.33708			0.312			0.65											
10/05/22 14:00	0.34134			0.31284			0.65											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/05/22 15:00	0.32988			0.31176			0.64											
10/05/22 16:00	0.3318			0.31248			0.64											
10/05/22 17:00	0.34386			0.3126			0.66											
10/05/22 18:00	0.34038			0.3141			0.65											
10/05/22 19:00	0.33564			0.31614			0.65											
10/05/22 20:00	0.33432			0.31782			0.65											
10/05/22 21:00	0.33336			0.31794			0.65											
10/05/22 22:00	0.3195			0.31704			0.64											
10/05/22 23:00	0.2724			0.29328			0.57											
10/06/22 0:00	0.27192			0.29316			0.57											
10/06/22 1:00	0.27228			0.29388			0.57											
10/06/22 2:00	0.2721			0.29388			0.57											
10/06/22 3:00	0.27144			0.29364			0.57											
10/06/22 4:00	0.2721			0.2937			0.57											
10/06/22 5:00	0.27594			0.29718			0.57											
10/06/22 6:00	0.30282			0.3243			0.63											
10/06/22 7:00	0.25962			0.27798			0.54											
10/06/22 8:00	0.18444			0.19764			0.38											
10/06/22 9:00	0.17514			0.18726			0.36											
10/06/22 10:00	0.17604			0.18786			0.36											
10/06/22 11:00	0.20346			0.2175			0.42											
10/06/22 12:00	0.23316			0.24984			0.48											
10/06/22 13:00	0.26562			0.28404			0.55											
10/06/22 14:00	0.32532			0.31776			0.64											
10/06/22 15:00	0.32838			0.31236			0.64											
10/06/22 16:00	0.33906			0.31248			0.65											
10/06/22 17:00	0.34398			0.31326			0.66											
10/06/22 18:00	0.33996			0.315			0.65											
10/06/22 19:00	0.33636			0.31668			0.65											
10/06/22 20:00	0.3342			0.31824			0.65											
10/06/22 21:00	0.32982			0.3198			0.65											
10/06/22 22:00	0.32124			0.3234			0.64											
10/06/22 23:00	0.32214			0.32436			0.65											
10/07/22 0:00	0.3168			0.32412			0.64											
10/07/22 1:00	0.31452			0.32478			0.64											
10/07/22 2:00	0.2952			0.32466			0.62											
10/07/22 3:00	0.28866			0.31854			0.61											
10/07/22 4:00	0.31398			0.3159			0.63											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/07/22 5:00	0.32034			0.32046			0.64											
10/07/22 6:00	0.30624			0.3198			0.63											
10/07/22 7:00	0.2988			0.3147			0.61											
10/07/22 8:00	0.29568			0.3123			0.61											
10/07/22 9:00	0.30228			0.3096			0.61											
10/07/22 10:00	0.33288			0.31122			0.64											
10/07/22 11:00	0.34134			0.31122			0.65											
10/07/22 12:00	0.34236			0.31188			0.65											
10/07/22 13:00	0.32844			0.31188			0.64											
10/07/22 14:00	0.31326			0.31206			0.63											
10/07/22 15:00	0.32724			0.3108			0.64											
10/07/22 16:00	0.33672			0.31182			0.65											
10/07/22 17:00	0.34476			0.3132			0.66											
10/07/22 18:00	0.33792			0.31548			0.65											
10/07/22 19:00	0.33756			0.31584			0.65											
10/07/22 20:00	0.33402			0.31806			0.65											
10/07/22 21:00	0.32958			0.32016			0.65											
10/07/22 22:00	0.3207			0.32094			0.64											
10/07/22 23:00	0.32298			0.3231			0.65											
10/08/22 0:00	0.32304			0.32298			0.65											
10/08/22 1:00	0.31314			0.3249			0.64											
10/08/22 2:00	0.31266			0.32604			0.64											
10/08/22 3:00	0.3138			0.32688			0.64											
10/08/22 4:00	0.3156			0.32688			0.64											
10/08/22 5:00	0.31338			0.32808			0.64											
10/08/22 6:00	0.26796			0.29214			0.56											
10/08/22 7:00	0.19944			0.2145			0.41											
10/08/22 8:00	0.1917			0.20544			0.4											
10/08/22 9:00	0.1953			0.20946			0.4											
10/08/22 10:00	0.1761			0.18762			0.36											
10/08/22 11:00	0.20448			0.2187			0.42											
10/08/22 12:00	0.23046			0.2457			0.48											
10/08/22 13:00	0.27534			0.29166			0.57											
10/08/22 14:00	0.26538			0.28164			0.55											
10/08/22 15:00	0.32592			0.31428			0.64											
10/08/22 16:00	0.3393			0.31452			0.65											
10/08/22 17:00	0.34032			0.31596			0.66											
10/08/22 18:00	0.33462			0.31866			0.65											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/08/22 19:00	0.3348			0.32112			0.66											
10/08/22 20:00	0.33282			0.32022			0.65											
10/08/22 21:00	0.31344			0.31824			0.63											
10/08/22 22:00	0.23334			0.23664			0.47											
10/08/22 23:00	0.28428			0.06384			0.29											
10/09/22 0:00	0.29052			0	X		0.29											
10/09/22 1:00	0.291			0	X		0.29											
10/09/22 2:00	0.29148			0	X		0.29											
10/09/22 3:00	0.29196			0	X		0.29											
10/09/22 4:00	0.29286			0	X		0.29											
10/09/22 5:00	0.29292			0	X		0.29											
10/09/22 6:00	0.29352			0	X		0.29											
10/09/22 7:00	0.29364			0	X		0.29											
10/09/22 8:00	0.2925			0	X		0.29											
10/09/22 9:00	0.2913			0	X		0.29											
10/09/22 10:00	0.29016			0	X		0.29											
10/09/22 11:00	0.28854			0	X		0.29											
10/09/22 12:00	0.28884			0	X		0.29											
10/09/22 13:00	0.29022			0	X		0.29											
10/09/22 14:00	0.2901			0	X		0.29											
10/09/22 15:00	0.29106			0	X		0.29											
10/09/22 16:00	0.29106			0	X		0.29											
10/09/22 17:00	0.29082			0	X		0.29											
10/09/22 18:00	0.28926			0	X		0.29											
10/09/22 19:00	0.28758			0	X		0.29											
10/09/22 20:00	0.28734			0	X		0.29											
10/09/22 21:00	0.28806			0	X		0.29											
10/09/22 22:00	0.2889			0	X		0.29											
10/09/22 23:00	0.28962			0	X		0.29											
10/10/22 0:00	0.29076			0	X		0.29											
10/10/22 1:00	0.29124			0	X		0.29											
10/10/22 2:00	0.2913			0	X		0.29											
10/10/22 3:00	0.2919			0	X		0.29											
10/10/22 4:00	0.29292			0	X		0.29											
10/10/22 5:00	0.30702			0	X		0.31											
10/10/22 6:00	0.31188			0	X		0.31											
10/10/22 7:00	0.2934			0	X		0.29											
10/10/22 8:00	0.29166			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/10/22 9:00	0.29268			0	X		0.29											
10/10/22 10:00	0.28104			0	X		0.28											
10/10/22 11:00	0.1797			0	X		0.18											
10/10/22 12:00	0.17382			0	X		0.17											
10/10/22 13:00	0.174			0	X		0.17											
10/10/22 14:00	0.17394			0	X		0.17											
10/10/22 15:00	0.23712			0	X		0.24											
10/10/22 16:00	0.34044			0	X		0.34											
10/10/22 17:00	0.32928			0	X		0.33											
10/10/22 18:00	0.28962			0	X		0.29											
10/10/22 19:00	0.28866			0	X		0.29											
10/10/22 20:00	0.28752			0	X		0.29											
10/10/22 21:00	0.28782			0	X		0.29											
10/10/22 22:00	0.28896			0	X		0.29											
10/10/22 23:00	0.28242			0	X		0.28											
10/11/22 0:00	0.18006			0	X		0.18											
10/11/22 1:00	0.17412			0	X		0.17											
10/11/22 2:00	0.17442			0	X		0.17											
10/11/22 3:00	0.17502			0	X		0.18											
10/11/22 4:00	0.17508			0	X		0.18											
10/11/22 5:00	0.1749			0	X		0.17											
10/11/22 6:00	0.17496			0	X		0.17											
10/11/22 7:00	0.17502			0	X		0.18											
10/11/22 8:00	0.17448			0	X		0.17											
10/11/22 9:00	0.1749			0	X		0.17											
10/11/22 10:00	0.17568			0	X		0.18											
10/11/22 11:00	0.1752			0	X		0.18											
10/11/22 12:00	0.1743			0	X		0.17											
10/11/22 13:00	0.17292			0	X		0.17											
10/11/22 14:00	0.1725			0	X		0.17											
10/11/22 15:00	0.23718			0	X		0.24											
10/11/22 16:00	0.29022			0	X		0.29											
10/11/22 17:00	0.2889			0	X		0.29											
10/11/22 18:00	0.2871			0	X		0.29											
10/11/22 19:00	0.28812			0	X		0.29											
10/11/22 20:00	0.28992			0	X		0.29											
10/11/22 21:00	0.29052			0	X		0.29											
10/11/22 22:00	0.2913			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/11/22 23:00	0.29196			0	X		0.29											
10/12/22 0:00	0.29202			0	X		0.29											
10/12/22 1:00	0.29244			0	X		0.29											
10/12/22 2:00	0.29268			0	X		0.29											
10/12/22 3:00	0.29358			0	X		0.29											
10/12/22 4:00	0.29394			0	X		0.29											
10/12/22 5:00	0.29448			0	X		0.29											
10/12/22 6:00	0.29436			0	X		0.29											
10/12/22 7:00	0.2571			0	X		0.26											
10/12/22 8:00	0.1746			0	X		0.17											
10/12/22 9:00	0.17478			0	X		0.17											
10/12/22 10:00	0.17424			0	X		0.17											
10/12/22 11:00	0.17394			0	X		0.17											
10/12/22 12:00	0.17328			0	X		0.17											
10/12/22 13:00	0.17364			0	X		0.17											
10/12/22 14:00	0.17328			0	X		0.17											
10/12/22 15:00	0.17382			0	X		0.17											
10/12/22 16:00	0.1743			0	X		0.17											
10/12/22 17:00	0.1743			0	X		0.17											
10/12/22 18:00	0.17364			0	X		0.17											
10/12/22 19:00	0.17322			0	X		0.17											
10/12/22 20:00	0.17304			0	X		0.17											
10/12/22 21:00	0.17322			0	X		0.17											
10/12/22 22:00	0.1743			0	X		0.17											
10/12/22 23:00	0.17376			0	X		0.17											
10/13/22 0:00	0.17358			0	X		0.17											
10/13/22 1:00	0.17352			0	X		0.17											
10/13/22 2:00	0.17316			0	X		0.17											
10/13/22 3:00	0.1731			0	X		0.17											
10/13/22 4:00	0.17316			0	X		0.17											
10/13/22 5:00	0.17376			0	X		0.17											
10/13/22 6:00	0.22326			0	X		0.22											
10/13/22 7:00	0.17352			0	X		0.17											
10/13/22 8:00	0.17352			0	X		0.17											
10/13/22 9:00	0.17418			0	X		0.17											
10/13/22 10:00	0.17478			0	X		0.17											
10/13/22 11:00	0.17322			0	X		0.17											
10/13/22 12:00	0.17286			0	X		0.17											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/22 13:00	0.17262			0	X		0.17											
10/13/22 14:00	0.17268			0	X		0.17											
10/13/22 15:00	0.23676			0	X		0.24											
10/13/22 16:00	0.29994			0	X		0.3											
10/13/22 17:00	0.28794			0	X		0.29											
10/13/22 18:00	0.2883			0	X		0.29											
10/13/22 19:00	0.28956			0	X		0.29											
10/13/22 20:00	0.28944			0	X		0.29											
10/13/22 21:00	0.28956			0	X		0.29											
10/13/22 22:00	0.28992			0	X		0.29											
10/13/22 23:00	0.29022			0	X		0.29											
10/14/22 0:00	0.29112			0	X		0.29											
10/14/22 1:00	0.29178			0	X		0.29											
10/14/22 2:00	0.29208			0	X		0.29											
10/14/22 3:00	0.29274			0	X		0.29											
10/14/22 4:00	0.29304			0	X		0.29											
10/14/22 5:00	0.29406			0	X		0.29											
10/14/22 6:00	0.29472			0	X		0.29											
10/14/22 7:00	0.273			0	X		0.27											
10/14/22 8:00	0.17394			0	X		0.17											
10/14/22 9:00	0.17448			0	X		0.17											
10/14/22 10:00	0.17508			0	X		0.18											
10/14/22 11:00	0.17508			0	X		0.18											
10/14/22 12:00	0.17376			0	X		0.17											
10/14/22 13:00	0.17364			0	X		0.17											
10/14/22 14:00	0.17364			0	X		0.17											
10/14/22 15:00	0.17382			0	X		0.17											
10/14/22 16:00	0.23796			0	X		0.24											
10/14/22 17:00	0.29028			0	X		0.29											
10/14/22 18:00	0.28866			0	X		0.29											
10/14/22 19:00	0.2904			0	X		0.29											
10/14/22 20:00	0.29148			0	X		0.29											
10/14/22 21:00	0.28998			0	X		0.29											
10/14/22 22:00	0.28902			0	X		0.29											
10/14/22 23:00	0.28908			0	X		0.29											
10/15/22 0:00	0.29016			0	X		0.29											
10/15/22 1:00	0.2865			0	X		0.29											
10/15/22 2:00	0.2763			0	X		0.28											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/15/22 3:00	0.27			0	X		0.27											
10/15/22 4:00	0.29214			0	X		0.29											
10/15/22 5:00	0.29262			0	X		0.29											
10/15/22 6:00	0.28578			0	X		0.29											
10/15/22 7:00	0.19824			0	X		0.2											
10/15/22 8:00	0.17382			0	X		0.17											
10/15/22 9:00	0.17388			0	X		0.17											
10/15/22 10:00	0.17418			0	X		0.17											
10/15/22 11:00	0.17388			0	X		0.17											
10/15/22 12:00	0.1725			0	X		0.17											
10/15/22 13:00	0.1725			0	X		0.17											
10/15/22 14:00	0.1725			0	X		0.17											
10/15/22 15:00	0.17244			0	X		0.17											
10/15/22 16:00	0.17244			0	X		0.17											
10/15/22 17:00	0.17244			0	X		0.17											
10/15/22 18:00	0.17388			0	X		0.17											
10/15/22 19:00	0.1728			0	X		0.17											
10/15/22 20:00	0.1725			0	X		0.17											
10/15/22 21:00	0.17358			0	X		0.17											
10/15/22 22:00	0.17406			0	X		0.17											
10/15/22 23:00	0.17418			0	X		0.17											
10/16/22 0:00	0.1743			0	X		0.17											
10/16/22 1:00	0.17478			0	X		0.17											
10/16/22 2:00	0.17436			0	X		0.17											
10/16/22 3:00	0.17442			0	X		0.17											
10/16/22 4:00	0.1749			0	X		0.17											
10/16/22 5:00	0.17514			0	X		0.18											
10/16/22 6:00	0.1776			0	X		0.18											
10/16/22 7:00	0.1737			0	X		0.17											
10/16/22 8:00	0.17454			0	X		0.17											
10/16/22 9:00	0.1992			0	X		0.2											
10/16/22 10:00	0.28338			0	X		0.28											
10/16/22 11:00	0.2925			0	X		0.29											
10/16/22 12:00	0.2919			0	X		0.29											
10/16/22 13:00	0.29142			0	X		0.29											
10/16/22 14:00	0.29094			0	X		0.29											
10/16/22 15:00	0.29106			0	X		0.29											
10/16/22 16:00	0.29166			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/16/22 17:00	0.2925			0	X		0.29											
10/16/22 18:00	0.29358			0	X		0.29											
10/16/22 19:00	0.29418			0	X		0.29											
10/16/22 20:00	0.29442			0	X		0.29											
10/16/22 21:00	0.2946			0	X		0.29											
10/16/22 22:00	0.2949			0	X		0.29											
10/16/22 23:00	0.29496			0	X		0.29											
10/17/22 0:00	0.29514			0	X		0.3											
10/17/22 1:00	0.2865			0	X		0.29											
10/17/22 2:00	0.27474			0	X		0.27											
10/17/22 3:00	0.27324			0	X		0.27											
10/17/22 4:00	0.28068			0	X		0.28											
10/17/22 5:00	0.29898			0	X		0.3											
10/17/22 6:00	0.29886			0	X		0.3											
10/17/22 7:00	0.2922			0	X		0.29											
10/17/22 8:00	0.26928			0	X		0.27											
10/17/22 9:00	0.29172			0	X		0.29											
10/17/22 10:00	0.28884			0	X		0.29											
10/17/22 11:00	0.29046			0	X		0.29											
10/17/22 12:00	0.29208			0	X		0.29											
10/17/22 13:00	0.28986			0	X		0.29											
10/17/22 14:00	0.29154			0	X		0.29											
10/17/22 15:00	0.29286			0	X		0.29											
10/17/22 16:00	0.2922			0	X		0.29											
10/17/22 17:00	0.29094			0	X		0.29											
10/17/22 18:00	0.28938			0	X		0.29											
10/17/22 19:00	0.28818			0	X		0.29											
10/17/22 20:00	0.28974			0	X		0.29											
10/17/22 21:00	0.28968			0	X		0.29											
10/17/22 22:00	0.29922			0	X		0.3											
10/17/22 23:00	0.30726			0	X		0.31											
10/18/22 0:00	0.2934			0	X		0.29											
10/18/22 1:00	0.29346			0	X		0.29											
10/18/22 2:00	0.2943			0	X		0.29											
10/18/22 3:00	0.29826			0	X		0.3											
10/18/22 4:00	0.3102			0	X		0.31											
10/18/22 5:00	0.32154			0	X		0.32											
10/18/22 6:00	0.34212			0	X		0.34											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 7:00	0.30108			0	X		0.3								
10/18/22 8:00	0.294			0	X		0.29								
10/18/22 9:00	0.29268			0	X		0.29								
10/18/22 10:00	0.29682			0	X		0.3								
10/18/22 11:00	0.29814			0	X		0.3								
10/18/22 12:00	0.29556			0	X		0.3								
10/18/22 13:00	0.28434			0	X		0.28								
10/18/22 14:00	0.20514			0.02262			0.21								
10/18/22 15:00	0.1983			0.1929			0.39								
10/18/22 16:00	0.28152			0.29748			0.58								
10/18/22 17:00	0.35892			0.37404			0.73								
10/18/22 18:00	0.34932			0.36504			0.71								
10/18/22 19:00	0.3825			0.39984			0.78								
10/18/22 20:00	0.35358			0.37194			0.73								
10/18/22 21:00	0.34266			0.36084			0.7								
10/18/22 22:00	0.3204			0.3393			0.66								
10/18/22 23:00	0.27318			0.294			0.57								
10/19/22 0:00	0.27306			0.2949			0.57								
10/19/22 1:00	0.2631			0.28404			0.55								
10/19/22 2:00	0.25086			0.27102			0.52								
10/19/22 3:00	0.26166			0.28278			0.54								
10/19/22 4:00	0.27156			0.29358			0.57								
10/19/22 5:00	0.27264			0.29484			0.57								
10/19/22 6:00	0.234			0.25266			0.49								
10/19/22 7:00	0.16758			0.18084			0.35								
10/19/22 8:00	0.15726			0.22824			0.33								
10/19/22 9:00	0	X		0.20736			0.21								
10/19/22 10:00	0	X		0.18636			0.19								
10/19/22 11:00	0	X		0.18552			0.19								
10/19/22 12:00	0	X		0.1857			0.19								
10/19/22 13:00	0	X		0.18606			0.19								
10/19/22 14:00	0	X		0.2526			0.25								
10/19/22 15:00	0	X		0.31146			0.31								
10/19/22 16:00	0.15156			0.22596			0.35								
10/19/22 17:00	0.22164			0.2358			0.46								
10/19/22 18:00	0.28896			0.29952			0.59								
10/19/22 19:00	0.29886			0.31506			0.61								
10/19/22 20:00	0.30864			0.32544			0.63								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/19/22 21:00	0.294			0.31188			0.61											
10/19/22 22:00	0.20628			0.2217			0.43											
10/19/22 23:00	0.2436			0.26244			0.51											
10/20/22 0:00	0.2451			0.26418			0.51											
10/20/22 1:00	0.20466			0.22032			0.42											
10/20/22 2:00	0.17862			0.19188			0.37											
10/20/22 3:00	0.22164			0.2388			0.46											
10/20/22 4:00	0.26112			0.28266			0.54											
10/20/22 5:00	0.27672			0.3			0.58											
10/20/22 6:00	0.24636			0.26634			0.51											
10/20/22 7:00	0.1755			0.18846			0.36											
10/20/22 8:00	0.17046			0.18276			0.35											
10/20/22 9:00	0.17124			0.18312			0.35											
10/20/22 10:00	0.1725			0.1842			0.36											
10/20/22 11:00	0.16962			0.18078			0.35											
10/20/22 12:00	0.17016			0.1812			0.35											
10/20/22 13:00	0.17532			0.18666			0.36											
10/20/22 14:00	0.18042			0.19194			0.37											
10/20/22 15:00	0.24324			0.25854			0.5											
10/20/22 16:00	0.35676			0.37218			0.73											
10/20/22 17:00	0.3339			0.34974			0.68											
10/20/22 18:00	0.31452			0.33174			0.65											
10/20/22 19:00	0.29718			0.31434			0.61											
10/20/22 20:00	0.28962			0.30786			0.6											
10/20/22 21:00	0.1917			0.20568			0.4											
10/20/22 22:00	0.18474			0.1983			0.38											
10/20/22 23:00	0.26064			0.28128			0.54											
10/21/22 0:00	0.21546			0.23172			0.45											
10/21/22 1:00	0.20526			0.22062			0.43											
10/21/22 2:00	0.17856			0.192			0.37											
10/21/22 3:00	0.1881			0.2022			0.39											
10/21/22 4:00	0.20574			0.22188			0.43											
10/21/22 5:00	0.26376			0.28416			0.55											
10/21/22 6:00	0.28434			0.30642			0.59											
10/21/22 7:00	0.2838			0.3036			0.59											
10/21/22 8:00	0.17388			0.18648			0.36											
10/21/22 9:00	0.16752			0.17922			0.35											
10/21/22 10:00	0.16734			0.17862			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/21/22 11:00	0.17436			0.18588			0.36											
10/21/22 12:00	0.16728			0.17832			0.35											
10/21/22 13:00	0.17022			0.18114			0.35											
10/21/22 14:00	0.17154			0.18258			0.35											
10/21/22 15:00	0.25314			0.26892			0.52											
10/21/22 16:00	0.31548			0.333			0.65											
10/21/22 17:00	0.31122			0.32982			0.64											
10/21/22 18:00	0.28794			0.30732			0.6											
10/21/22 19:00	0.22704			0.24444			0.47											
10/21/22 20:00	0.21828			0.23502			0.45											
10/21/22 21:00	0.27012			0.29154			0.56											
10/21/22 22:00	0.27918			0.30186			0.58											
10/21/22 23:00	0.27918			0.3018			0.58											
10/22/22 0:00	0.27864			0.30114			0.58											
10/22/22 1:00	0.27942			0.30084			0.58											
10/22/22 2:00	0.2793			0.30126			0.58											
10/22/22 3:00	0.27954			0.30138			0.58											
10/22/22 4:00	0.27882			0.3009			0.58											
10/22/22 5:00	0.28152			0.30342			0.58											
10/22/22 6:00	0.38868			0.40842			0.8											
10/22/22 7:00	0.3996			0.41976			0.82											
10/22/22 8:00	0.36222			0.3807			0.74											
10/22/22 9:00	0.35802			0.37638			0.73											
10/22/22 10:00	0.34434			0.36402			0.71											
10/22/22 11:00	0.31056			0.3303			0.64											
10/22/22 12:00	0.28584			0.30582			0.59											
10/22/22 13:00	0.26748			0.28806			0.56											
10/22/22 14:00	0.26094			0.28128			0.54											
10/22/22 15:00	0.2061			0.22128			0.43											
10/22/22 16:00	0.22692			0.24468			0.47											
10/22/22 17:00	0.25746			0.27762			0.54											
10/22/22 18:00	0.26016			0.28098			0.54											
10/22/22 19:00	0.2763			0.2985			0.57											
10/22/22 20:00	0.28152			0.3039			0.59											
10/22/22 21:00	0.3117			0.33084			0.64											
10/22/22 22:00	0.27834			0.30054			0.58											
10/22/22 23:00	0.27804			0.30024			0.58											
10/23/22 0:00	0.30138			0.32268			0.62											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/23/22 1:00	0.28686			0.30786			0.59											
10/23/22 2:00	0.27882			0.30198			0.58											
10/23/22 3:00	0.2784			0.30126			0.58											
10/23/22 4:00	0.27828			0.30084			0.58											
10/23/22 5:00	0.27828			0.30096			0.58											
10/23/22 6:00	0.27798			0.3003			0.58											
10/23/22 7:00	0.28446			0.30654			0.59											
10/23/22 8:00	0.30366			0.32628			0.63											
10/23/22 9:00	0.25836			0.27834			0.54											
10/23/22 10:00	0.23832			0.2565			0.49											
10/23/22 11:00	0.30768			0.3246			0.63											
10/23/22 12:00	0.26298			0.28194			0.54											
10/23/22 13:00	0.21078			0.22692			0.44											
10/23/22 14:00	0.2151			0.23166			0.45											
10/23/22 15:00	0.1821			0.19566			0.38											
10/23/22 16:00	0.22596			0.24252			0.47											
10/23/22 17:00	0.27138			0.29376			0.57											
10/23/22 18:00	0.2757			0.29814			0.57											
10/23/22 19:00	0.27786			0.30096			0.58											
10/23/22 20:00	0.29988			0.32292			0.62											
10/23/22 21:00	0.29922			0.3192			0.62											
10/23/22 22:00	0.24246			0.26196			0.5											
10/23/22 23:00	0.27948			0.30144			0.58											
10/24/22 0:00	0.27402			0.29658			0.57											
10/24/22 1:00	0.26718			0.28812			0.56											
10/24/22 2:00	0.2784			0.30102			0.58											
10/24/22 3:00	0.2787			0.3003			0.58											
10/24/22 4:00	0.27648			0.2991			0.58											
10/24/22 5:00	0.27888			0.30024			0.58											
10/24/22 6:00	0.35688			0.3783			0.74											
10/24/22 7:00	0.32886			0.34824			0.68											
10/24/22 8:00	0.29748			0.31962			0.62											
10/24/22 9:00	0.30126			0.32148			0.62											
10/24/22 10:00	0.29526			0.31614			0.61											
10/24/22 11:00	0.25836			0.279			0.54											
10/24/22 12:00	0.17148			0.18342			0.35											
10/24/22 13:00	0.168			0.17952			0.35											
10/24/22 14:00	0.24342			0.2616			0.51											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/24/22 15:00	0.29544			0.31158			0.61											
10/24/22 16:00	0.33222			0.35142			0.68											
10/24/22 17:00	0.31788			0.33399			0.66											
10/24/22 18:00	0.29304			0.3168			0.61											
10/24/22 19:00	0.30492			0.32826			0.63											
10/24/22 20:00	0.2967			0.31992			0.62											
10/24/22 21:00	0.22656			0.24414			0.47											
10/24/22 22:00	0.18666			0.20076			0.39											
10/24/22 23:00	0.19974			0.21528			0.42											
10/25/22 0:00	0.17658			0.18972			0.37											
10/25/22 1:00	0.17712			0.19026			0.37											
10/25/22 2:00	0.17664			0.19026			0.37											
10/25/22 3:00	0.18042			0.19416			0.37											
10/25/22 4:00	0.25158			0.2718			0.52											
10/25/22 5:00	0.27126			0.29268			0.56											
10/25/22 6:00	0.31932			0.34524			0.66											
10/25/22 7:00	0.30054			0.32568			0.63											
10/25/22 8:00	0.2277			0.2463			0.47											
10/25/22 9:00	0.21666			0.23448			0.45											
10/25/22 10:00	0.17088			0.18384			0.35											
10/25/22 11:00	0.17622			0.18876			0.36											
10/25/22 12:00	0.21786			0.23634			0.45											
10/25/22 13:00	0.30654			0.33618			0.64											
10/25/22 14:00	0.32808			0.35742			0.69											
10/25/22 15:00	0.32754			0.35436			0.68											
10/25/22 16:00	0.3435			0.37332			0.72											
10/25/22 17:00	0.33648			0.3651			0.7											
10/25/22 18:00	0.31914			0.34746			0.67											
10/25/22 19:00	0.31794			0.34494			0.66											
10/25/22 20:00	0.32436			0.35124			0.68											
10/25/22 21:00	0.2928			0.3168			0.61											
10/25/22 22:00	0.1818			0.19632			0.38											
10/25/22 23:00	0.19602			0.21162			0.41											
10/26/22 0:00	0.17694			0.1905			0.37											
10/26/22 1:00	0.17718			0.19074			0.37											
10/26/22 2:00	0.1779			0.19188			0.37											
10/26/22 3:00	0.2292			0.24804			0.48											
10/26/22 4:00	0.25206			0.2727			0.52											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/26/22 5:00	0.26436			0.28596			0.55											
10/26/22 6:00	0.27762			0.30084			0.58											
10/26/22 7:00	0.25308			0.27348			0.53											
10/26/22 8:00	0.2859			0.3072			0.59											
10/26/22 9:00	0.30714			0.3273			0.63											
10/26/22 10:00	0.31296			0.33258			0.65											
10/26/22 11:00	0.20916			0.22272			0.43											
10/26/22 12:00	0.16944			0.18174			0.35											
10/26/22 13:00	0.16872			0.18096			0.35											
10/26/22 14:00	0.19734			0.21216			0.41											
10/26/22 15:00	0.19386			0.20832			0.4											
10/26/22 16:00	0.24828			0.2655			0.51											
10/26/22 17:00	0.30984			0.32802			0.64											
10/26/22 18:00	0.28632			0.3048			0.59											
10/26/22 19:00	0.1866			0.2004			0.39											
10/26/22 20:00	0.20592			0.22194			0.43											
10/26/22 21:00	0.18588			0.19986			0.39											
10/26/22 22:00	0.17592			0.18918			0.37											
10/26/22 23:00	0.17694			0.19074			0.37											
10/27/22 0:00	0.16938			0.18264			0.35											
10/27/22 1:00	0.17238			0.18606			0.36											
10/27/22 2:00	0.17472			0.18864			0.36											
10/27/22 3:00	0.1818			0.19644			0.38											
10/27/22 4:00	0.20952			0.22644			0.44											
10/27/22 5:00	0.2394			0.25908			0.5											
10/27/22 6:00	0.23322			0.25242			0.49											
10/27/22 7:00	0.24906			0.26946			0.52											
10/27/22 8:00	0.26916			0.2904			0.56											
10/27/22 9:00	0.2925			0.31374			0.61											
10/27/22 10:00	0.2544			0.27228			0.53											
10/27/22 11:00	0.29538			0.31224			0.61											
10/27/22 12:00	0.30048			0.31788			0.62											
10/27/22 13:00	0.25932			0.27714			0.54											
10/27/22 14:00	0.17982			0.19266			0.37											
10/27/22 15:00	0.19944			0.2139			0.41											
10/27/22 16:00	0.32622			0.34488			0.67											
10/27/22 17:00	0.3156			0.33696			0.65											
10/27/22 18:00	0.30066			0.31908			0.62											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/27/22 19:00	0.30612			0.32658			0.63											
10/27/22 20:00	0.3132			0.33408			0.65											
10/27/22 21:00	0.31272			0.33444			0.65											
10/27/22 22:00	0.29052			0.3045			0.6											
10/27/22 23:00	0.2544			0.27522			0.53											
10/28/22 0:00	0.25038			0.27066			0.52											
10/28/22 1:00	0.23934			0.25896			0.5											
10/28/22 2:00	0.24966			0.27012			0.52											
10/28/22 3:00	0.27162			0.29298			0.56											
10/28/22 4:00	0.32052			0.34278			0.66											
10/28/22 5:00	0.33168			0.35352			0.69											
10/28/22 6:00	0.3261			0.34836			0.67											
10/28/22 7:00	0.29166			0.30486			0.6											
10/28/22 8:00	0.25056			0.27096			0.52											
10/28/22 9:00	0.267			0.28824			0.56											
10/28/22 10:00	0.29748			0.31602			0.61											
10/28/22 11:00	0.23838			0.25512			0.49											
10/28/22 12:00	0.23514			0.25302			0.49											
10/28/22 13:00	0.22506			0.24162			0.47											
10/28/22 14:00	0.24138			0.25836			0.5											
10/28/22 15:00	0.31926			0.33816			0.66											
10/28/22 16:00	0.31236			0.33006			0.64											
10/28/22 17:00	0.3471			0.36636			0.71											
10/28/22 18:00	0.35028			0.3714			0.72											
10/28/22 19:00	0.3495			0.37146			0.72											
10/28/22 20:00	0.35412			0.3756			0.73											
10/28/22 21:00	0.35526			0.37644			0.73											
10/28/22 22:00	0.3207			0.3417			0.66											
10/28/22 23:00	0.27648			0.297			0.57											
10/29/22 0:00	0.22974			0.24834			0.48											
10/29/22 1:00	0.2346			0.25386			0.49											
10/29/22 2:00	0.23244			0.25152			0.48											
10/29/22 3:00	0.17856			0.19272			0.37											
10/29/22 4:00	0.22416			0.24216			0.47											
10/29/22 5:00	0.26838			0.29016			0.56											
10/29/22 6:00	0.2298			0.2484			0.48											
10/29/22 7:00	0.2289			0.24786			0.48											
10/29/22 8:00	0.2652			0.28644			0.55											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/29/22 9:00	0.2418			0.26082			0.5											
10/29/22 10:00	0.24882			0.2682			0.52											
10/29/22 11:00	0.22116			0.23808			0.46											
10/29/22 12:00	0.17904			0.1917			0.37											
10/29/22 13:00	0.1881			0.20166			0.39											
10/29/22 14:00	0.1917			0.20562			0.4											
10/29/22 15:00	0.1962			0.21072			0.41											
10/29/22 16:00	0.22368			0.24048			0.46											
10/29/22 17:00	0.23064			0.24882			0.48											
10/29/22 18:00	0.2238			0.24084			0.46											
10/29/22 19:00	0.18894			0.20502			0.39											
10/29/22 20:00	0.2826			0.30462			0.59											
10/29/22 21:00	0.2979			0.31698			0.61											
10/29/22 22:00	0.2559			0.276			0.53											
10/29/22 23:00	0.27606			0.29796			0.57											
10/30/22 0:00	0.26706			0.28884			0.56											
10/30/22 1:00	0.2505			0.27078			0.52											
10/30/22 2:00	0.2583			0.27894			0.54											
10/30/22 3:00	0.25788			0.27876			0.54											
10/30/22 4:00	0.26274			0.2841			0.55											
10/30/22 5:00	0.28386			0.30672			0.59											
10/30/22 6:00	0.27738			0.29976			0.58											
10/30/22 7:00	0.1791			0.1962			0.38											
10/30/22 8:00	0.17004			0.18684			0.36											
10/30/22 9:00	0.1686			0.18558			0.35											
10/30/22 10:00	0.16854			0.18504			0.35											
10/30/22 11:00	0.16788			0.18474			0.35											
10/30/22 12:00	0.1677			0.18444			0.35											
10/30/22 13:00	0.16764			0.1842			0.35											
10/30/22 14:00	0.16758			0.18396			0.35											
10/30/22 15:00	0.18402			0.20016			0.38											
10/30/22 16:00	0.26196			0.28164			0.54											
10/30/22 17:00	0.27162			0.29214			0.56											
10/30/22 18:00	0.29208			0.31248			0.6											
10/30/22 19:00	0.25866			0.27924			0.54											
10/30/22 20:00	0.25302			0.2727			0.53											
10/30/22 21:00	0.2547			0.27474			0.53											
10/30/22 22:00	0.24654			0.26616			0.51											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/22 23:00	0.25602			0.27636			0.53								
10/31/22 0:00	0.25572			0.27576			0.53								
10/31/22 1:00	0.25194			0.2724			0.52								
10/31/22 2:00	0.25806			0.27888			0.54								
10/31/22 3:00	0.25458			0.27456			0.53								
10/31/22 4:00	0.26982			0.29226			0.56								
10/31/22 5:00	0.28944			0.31332			0.6								
10/31/22 6:00	0.31518			0.34074			0.66								
10/31/22 7:00	0.24246			0.26196			0.5								
10/31/22 8:00	0.22026			0.23772			0.46								
10/31/22 9:00	0.20934			0.22584			0.44								
10/31/22 10:00	0.18798			0.20214			0.39								
10/31/22 11:00	0.17598			0.18834			0.36								
10/31/22 12:00	0.17598			0.18816			0.36								
10/31/22 13:00	0.20238			0.21768			0.42								
10/31/22 14:00	0.26532			0.2862			0.55								
10/31/22 15:00	0.30414			0.32352			0.63								
10/31/22 16:00	0.22788			0.24474			0.47								
10/31/22 17:00	0.17502			0.18762			0.36								
10/31/22 18:00	0.17394			0.18672			0.36								
10/31/22 19:00	0.19428			0.20916			0.4								
10/31/22 20:00	0.20352			0.21942			0.42								
10/31/22 21:00	0.23358			0.25236			0.49								
10/31/22 22:00	0.20508			0.22098			0.43								
10/31/22 23:00	0.27054			0.29322			0.56								
11/01/22 0:00	0.27168			0.29292			0.56								
11/01/22 1:00	0.27768			0.3			0.58								
11/01/22 2:00	0.3228			0.3453			0.67								
11/01/22 3:00	0.33786			0.35892			0.7								
11/01/22 4:00	0.34962			0.37056			0.72								
11/01/22 5:00	0.34032			0.36234			0.7								
11/01/22 6:00	0.36498			0.38448			0.75								
11/01/22 7:00	0.33708			0.35658			0.69								
11/01/22 8:00	0.324			0.34272			0.67								
11/01/22 9:00	0.30474			0.32196			0.63								
11/01/22 10:00	0.30714			0.32442			0.63								
11/01/22 11:00	0.32328			0.3429			0.67								
11/01/22 12:00	0.33468			0.35598			0.69								

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/22 13:00	0.33192			0.35256			0.68											
11/01/22 14:00	0.2973			0.31722			0.61											
11/01/22 15:00	0.30282			0.32166			0.62											
11/01/22 16:00	0.33162			0.34908			0.68											
11/01/22 17:00	0.32448			0.34146			0.67											
11/01/22 18:00	0.32028			0.33948			0.66											
11/01/22 19:00	0.32184			0.33936			0.66											
11/01/22 20:00	0.3174			0.33762			0.66											
11/01/22 21:00	0.3045			0.32634			0.63											
11/01/22 22:00	0.29892			0.31932			0.62											
11/01/22 23:00	0.24006			0.25944			0.5											
11/02/22 0:00	0.17784			0.19188			0.37											
11/02/22 1:00	0.22734			0.24624			0.47											
11/02/22 2:00	0.20334			0.22014			0.42											
11/02/22 3:00	0.24504			0.26538			0.51											
11/02/22 4:00	0.26652			0.28854			0.56											
11/02/22 5:00	0.27912			0.30168			0.58											
11/02/22 6:00	0.31212			0.33546			0.65											
11/02/22 7:00	0.23436			0.252			0.49											
11/02/22 8:00	0.18156			0.19578			0.38											
11/02/22 9:00	0.18486			0.1992			0.38											
11/02/22 10:00	0.24822			0.2676			0.52											
11/02/22 11:00	0.29784			0.31896			0.62											
11/02/22 12:00	0.29736			0.31638			0.61											
11/02/22 13:00	0.26202			0.28158			0.54											
11/02/22 14:00	0.29034			0.31188			0.6											
11/02/22 15:00	0.29868			0.3183			0.62											
11/02/22 16:00	0.3216			0.34152			0.66											
11/02/22 17:00	0.34158			0.36366			0.71											
11/02/22 18:00	0.31374			0.3366			0.65											
11/02/22 19:00	0.31314			0.33648			0.65											
11/02/22 20:00	0.34044			0.36192			0.7											
11/02/22 21:00	0.32952			0.35274			0.68											
11/02/22 22:00	0.31686			0.33654			0.65											
11/02/22 23:00	0.2793			0.30222			0.58											
11/03/22 0:00	0.28134			0.30294			0.58											
11/03/22 1:00	0.27546			0.27542			0.57											
11/03/22 2:00	0.27426			0.2964			0.57											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/03/22 3:00	0.28026			0.30318			0.58											
11/03/22 4:00	0.28272			0.30414			0.59											
11/03/22 5:00	0.36912			0.39066			0.76											
11/03/22 6:00	0.38484			0.40806			0.79											
11/03/22 7:00	0.2886			0.30924			0.6											
11/03/22 8:00	0.26574			0.28734			0.55											
11/03/22 9:00	0.29616			0.31116			0.61											
11/03/22 10:00	0.30696			0.32898			0.64											
11/03/22 11:00	0.23466			0.25314			0.49											
11/03/22 12:00	0.17658			0.19032			0.37											
11/03/22 13:00	0.17454			0.18798			0.36											
11/03/22 14:00	0.16944			0.18246			0.35											
11/03/22 15:00	0.17322			0.18684			0.36											
11/03/22 16:00	0.25236			0.2721			0.52											
11/03/22 17:00	0.31944			0.34062			0.66											
11/03/22 18:00	0.31548			0.33696			0.65											
11/03/22 19:00	0.31638			0.33762			0.65											
11/03/22 20:00	0.34824			0.37068			0.72											
11/03/22 21:00	0.35652			0.37884			0.74											
11/03/22 22:00	0.3237			0.34704			0.67											
11/03/22 23:00	0.29328			0.32136			0.61											
11/04/22 0:00	0.26982			0.2922			0.56											
11/04/22 1:00	0.26724			0.28866			0.56											
11/04/22 2:00	0.24702			0.2673			0.51											
11/04/22 3:00	0.25656			0.27804			0.53											
11/04/22 4:00	0.27276			0.29478			0.57											
11/04/22 5:00	0.3312			0.3516			0.68											
11/04/22 6:00	0.33276			0.35592			0.69											
11/04/22 7:00	0.23268			0.25092			0.48											
11/04/22 8:00	0.17862			0.19278			0.37											
11/04/22 9:00	0.18204			0.19596			0.38											
11/04/22 10:00	0.1731			0.186			0.36											
11/04/22 11:00	0.16716			0.17964			0.35											
11/04/22 12:00	0.17226			0.18486			0.36											
11/04/22 13:00	0.1683			0.18066			0.35											
11/04/22 14:00	0.1677			0.18			0.35											
11/04/22 15:00	0.20226			0.21804			0.42											
11/04/22 16:00	0.21084			0.22692			0.44											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/04/22 17:00	0.25962			0.28002			0.54											
11/04/22 18:00	0.30732			0.32826			0.64											
11/04/22 19:00	0.30756			0.32862			0.64											
11/04/22 20:00	0.29568			0.31668			0.61											
11/04/22 21:00	0.18036			0.19446			0.37											
11/04/22 22:00	0.1674			0.18072			0.35											
11/04/22 23:00	0.19356			0.20904			0.4											
11/05/22 0:00	0.17334			0.1869			0.36											
11/05/22 1:00	0.17346			0.18684			0.36											
11/05/22 2:00	0.17322			0.18648			0.36											
11/05/22 3:00	0.17256			0.18576			0.36											
11/05/22 4:00	0.1734			0.18648			0.36											
11/05/22 5:00	0.19038			0.2055			0.4											
11/05/22 6:00	0.17292			0.18624			0.36											
11/05/22 7:00	0.21162			0.22818			0.44											
11/05/22 8:00	0.1692			0.18216			0.35											
11/05/22 9:00	0.17166			0.18426			0.36											
11/05/22 10:00	0.1794			0.19272			0.37											
11/05/22 11:00	0.18774			0.20178			0.39											
11/05/22 12:00	0.23052			0.24828			0.48											
11/05/22 13:00	0.20442			0.2202			0.42											
11/05/22 14:00	0.25482			0.27462			0.53											
11/05/22 15:00	0.17292			0.1857			0.36											
11/05/22 16:00	0.20916			0.22554			0.43											
11/05/22 17:00	0.25782			0.27774			0.54											
11/05/22 18:00	0.29124			0.312			0.6											
11/05/22 19:00	0.28638			0.30666			0.59											
11/05/22 20:00	0.1992			0.2142			0.41											
11/05/22 21:00	0.1794			0.19278			0.37											
11/05/22 22:00	0.17316			0.18606			0.36											
11/05/22 23:00	0.24924			0.26904			0.52											
11/06/22 0:00	0.24486			0.26436			0.51											
11/06/22 1:00	0.21372			0.23064			0.44											
11/06/22 2:00	0.22062			0.2382			0.46											
11/06/22 3:00	0.258			0.27906			0.54											
11/06/22 4:00	0.25686			0.2772			0.53											
11/06/22 5:00	0.27324			0.29448			0.57											
11/06/22 6:00	0.27684			0.2979			0.57											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/06/22 7:00	0.27612			0.29772			0.57											
11/06/22 8:00	0.30192			0.32394			0.63											
11/06/22 9:00	0.28482			0.306			0.59											
11/06/22 10:00	0.18696			0.20328			0.39											
11/06/22 11:00	0.1767			0.1896			0.37											
11/06/22 12:00	0.17076			0.18336			0.35											
11/06/22 13:00	0.17598			0.18906			0.37											
11/06/22 14:00	0.20934			0.22566			0.44											
11/06/22 15:00	0.29106			0.3114			0.6											
11/06/22 16:00	0.32814			0.3489			0.68											
11/06/22 17:00	0.30726			0.3282			0.64											
11/06/22 18:00	0.29538			0.31692			0.61											
11/06/22 19:00	0.29232			0.31092			0.6											
11/06/22 20:00	0.294			0.31506			0.61											
11/06/22 21:00	0.29616			0.31698			0.61											
11/06/22 22:00	0.22824			0.2454			0.47											
11/06/22 23:00	0.17544			0.18888			0.36											
11/07/22 0:00	0.19692			0.21258			0.41											
11/07/22 1:00	0.2196			0.2376			0.46											
11/07/22 2:00	0.23442			0.25344			0.49											
11/07/22 3:00	0.22044			0.23784			0.46											
11/07/22 4:00	0.2082			0.22512			0.43											
11/07/22 5:00	0.25464			0.27552			0.53											
11/07/22 6:00	0.27438			0.29652			0.57											
11/07/22 7:00	0.24396			0.26382			0.51											
11/07/22 8:00	0.17442			0.18804			0.36											
11/07/22 9:00	0.174			0.18744			0.36											
11/07/22 10:00	0.17262			0.18582			0.36											
11/07/22 11:00	0.1713			0.1839			0.36											
11/07/22 12:00	0.17262			0.18534			0.36											
11/07/22 13:00	0.17328			0.18582			0.36											
11/07/22 14:00	0.22314			0.2406			0.46											
11/07/22 15:00	0.28092			0.30204			0.58											
11/07/22 16:00	0.318			0.3414			0.66											
11/07/22 17:00	0.31674			0.34134			0.66											
11/07/22 18:00	0.31386			0.33534			0.65											
11/07/22 19:00	0.31812			0.33924			0.66											
11/07/22 20:00	0.31872			0.34146			0.66											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/07/22 21:00	0.32088			0.34308			0.66											
11/07/22 22:00	0.30228			0.32586			0.63											
11/07/22 23:00	0.23658			0.25074			0.49											
11/08/22 0:00	0.18372			0.05562			0.19											
11/08/22 1:00	0.16938			0	X		0.17											
11/08/22 2:00	0.16998			0	X		0.17											
11/08/22 3:00	0.16998			0	X		0.17											
11/08/22 4:00	0.23436			0	X		0.23											
11/08/22 5:00	0.29088			0	X		0.29											
11/08/22 6:00	0.31794			0	X		0.32											
11/08/22 7:00	0.29598			0	X		0.3											
11/08/22 8:00	0.30276			0	X		0.3											
11/08/22 9:00	0.33042			0	X		0.33											
11/08/22 10:00	0.30732			0	X		0.31											
11/08/22 11:00	0.29622			0	X		0.3											
11/08/22 12:00	0.29652			0	X		0.3											
11/08/22 13:00	0.19776			0	X		0.2											
11/08/22 14:00	0.17166			0	X		0.17											
11/08/22 15:00	0.23838			0	X		0.24											
11/08/22 16:00	0.29394			0	X		0.29											
11/08/22 17:00	0.2982			0	X		0.3											
11/08/22 18:00	0.29496			0	X		0.29											
11/08/22 19:00	0.294			0	X		0.29											
11/08/22 20:00	0.29358			0	X		0.29											
11/08/22 21:00	0.29358			0	X		0.29											
11/08/22 22:00	0.29262			0	X		0.29											
11/08/22 23:00	0.29256			0	X		0.29											
11/09/22 0:00	0.29286			0	X		0.29											
11/09/22 1:00	0.29328			0	X		0.29											
11/09/22 2:00	0.29352			0	X		0.29											
11/09/22 3:00	0.29364			0	X		0.29											
11/09/22 4:00	0.29388			0	X		0.29											
11/09/22 5:00	0.29412			0	X		0.29											
11/09/22 6:00	0.29472			0	X		0.29											
11/09/22 7:00	0.2946			0	X		0.29											
11/09/22 8:00	0.29406			0	X		0.29											
11/09/22 9:00	0.26238			0	X		0.26											
11/09/22 10:00	0.17142			0	X		0.17											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 11:00	0.17256			0	X		0.17								
11/09/22 12:00	0.17214			0	X		0.17								
11/09/22 13:00	0.17214			0	X		0.17								
11/09/22 14:00	0.17172			0	X		0.17								
11/09/22 15:00	0.171			0	X		0.17								
11/09/22 16:00	0.23466			0	X		0.23								
11/09/22 17:00	0.27852			0	X		0.28								
11/09/22 18:00	0.28686			0	X		0.29								
11/09/22 19:00	0.29484			0	X		0.29								
11/09/22 20:00	0.2688			0.15156			0.34								
11/09/22 21:00	0.19044			0.20712			0.4								
11/09/22 22:00	0.17184			0.1872			0.36								
11/09/22 23:00	0.1749			0.1887			0.36								
11/10/22 0:00	0.17832			0.19278			0.37								
11/10/22 1:00	0.17424			0.1884			0.36								
11/10/22 2:00	0.17424			0.18882			0.36								
11/10/22 3:00	0.19986			0.21642			0.42								
11/10/22 4:00	0.24096			0.26118			0.5								
11/10/22 5:00	0.26448			0.28656			0.55								
11/10/22 6:00	0.3561			0.37746			0.73								
11/10/22 7:00	0.30366			0.32466			0.63								
11/10/22 8:00	0.20046			0.21756			0.42								
11/10/22 9:00	0.21798			0.2229			0.44								
11/10/22 10:00	0.16662			0.19284			0.36								
11/10/22 11:00	0.16734			0.18066			0.35								
11/10/22 12:00	0.16728			0.18066			0.35								
11/10/22 13:00	0.1671			0.18042			0.35								
11/10/22 14:00	0.1671			0.1803			0.35								
11/10/22 15:00	0.22194			0.2382			0.46								
11/10/22 16:00	0.33348			0.35538			0.69								
11/10/22 17:00	0.33312			0.35304			0.69								
11/10/22 18:00	0.31758			0.33924			0.66								
11/10/22 19:00	0.31182			0.33384			0.65								
11/10/22 20:00	0.31686			0.3393			0.66								
11/10/22 21:00	0.33426			0.3567			0.69								
11/10/22 22:00	0.32466			0.34734			0.67								
11/10/22 23:00	0.30942			0.3336			0.64								
11/11/22 0:00	0.33684			0.36018			0.7								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/11/22 1:00	0.32826			0.35136			0.68											
11/11/22 2:00	0.29544			0.31842			0.61											
11/11/22 3:00	0.2646			0.28632			0.55											
11/11/22 4:00	0.28188			0.30504			0.59											
11/11/22 5:00	0.33834			0.3606			0.7											
11/11/22 6:00	0.34146			0.36414			0.71											
11/11/22 7:00	0.2913			0.31158			0.6											
11/11/22 8:00	0.17454			0.18858			0.36											
11/11/22 9:00	0.17388			0.18744			0.36											
11/11/22 10:00	0.1761			0.18978			0.37											
11/11/22 11:00	0.17376			0.18708			0.36											
11/11/22 12:00	0.17334			0.18636			0.36											
11/11/22 13:00	0.17358			0.18648			0.36											
11/11/22 14:00	0.17754			0.19068			0.37											
11/11/22 15:00	0.2676			0.28794			0.56											
11/11/22 16:00	0.32478			0.3459			0.67											
11/11/22 17:00	0.31302			0.33336			0.65											
11/11/22 18:00	0.31272			0.33438			0.65											
11/11/22 19:00	0.31194			0.33414			0.65											
11/11/22 20:00	0.31494			0.33732			0.65											
11/11/22 21:00	0.33564			0.35742			0.69											
11/11/22 22:00	0.33078			0.35196			0.68											
11/11/22 23:00	0.31608			0.33864			0.65											
11/12/22 0:00	0.33348			0.35766			0.69											
11/12/22 1:00	0.33342			0.35748			0.69											
11/12/22 2:00	0.33546			0.35832			0.69											
11/12/22 3:00	0.34674			0.369			0.72											
11/12/22 4:00	0.34344			0.36606			0.71											
11/12/22 5:00	0.34128			0.36366			0.7											
11/12/22 6:00	0.34152			0.36348			0.71											
11/12/22 7:00	0.30108			0.32352			0.62											
11/12/22 8:00	0.34692			0.36906			0.72											
11/12/22 9:00	0.32076			0.34236			0.66											
11/12/22 10:00	0.30732			0.32886			0.64											
11/12/22 11:00	0.28368			0.30528			0.59											
11/12/22 12:00	0.27648			0.29844			0.57											
11/12/22 13:00	0.27318			0.29418			0.57											
11/12/22 14:00	0.2934			0.3159			0.61											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/12/22 15:00	0.30732			0.3279			0.64											
11/12/22 16:00	0.32016			0.34116			0.66											
11/12/22 17:00	0.31842			0.33858			0.66											
11/12/22 18:00	0.31062			0.33222			0.64											
11/12/22 19:00	0.32352			0.34518			0.67											
11/12/22 20:00	0.3129			0.33468			0.65											
11/12/22 21:00	0.31668			0.33906			0.66											
11/12/22 22:00	0.32196			0.34458			0.67											
11/12/22 23:00	0.30948			0.33162			0.64											
11/13/22 0:00	0.27558			0.29784			0.57											
11/13/22 1:00	0.26892			0.29112			0.56											
11/13/22 2:00	0.26664			0.28806			0.55											
11/13/22 3:00	0.27906			0.3018			0.58											
11/13/22 4:00	0.27792			0.30186			0.58											
11/13/22 5:00	0.27798			0.30126			0.58											
11/13/22 6:00	0.28302			0.30624			0.59											
11/13/22 7:00	0.31518			0.33768			0.65											
11/13/22 8:00	0.28266			0.30564			0.59											
11/13/22 9:00	0.32448			0.34656			0.67											
11/13/22 10:00	0.27726			0.3009			0.58											
11/13/22 11:00	0.27282			0.29436			0.57											
11/13/22 12:00	0.26712			0.2889			0.56											
11/13/22 13:00	0.26064			0.2817			0.54											
11/13/22 14:00	0.24078			0.26034			0.5											
11/13/22 15:00	0.2346			0.25344			0.49											
11/13/22 16:00	0.33042			0.35262			0.68											
11/13/22 17:00	0.33702			0.35814			0.7											
11/13/22 18:00	0.33456			0.35556			0.69											
11/13/22 19:00	0.3219			0.3435			0.67											
11/13/22 20:00	0.31368			0.3363			0.65											
11/13/22 21:00	0.3372			0.36024			0.7											
11/13/22 22:00	0.33168			0.35544			0.69											
11/13/22 23:00	0.32724			0.35208			0.68											
11/14/22 0:00	0.30168			0.32562			0.63											
11/14/22 1:00	0.27738			0.29988			0.58											
11/14/22 2:00	0.2769			0.29976			0.58											
11/14/22 3:00	0.2625			0.28416			0.55											
11/14/22 4:00	0.27036			0.29268			0.56											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/14/22 5:00	0.33186			0.35424			0.69											
11/14/22 6:00	0.39198			0.41442			0.81											
11/14/22 7:00	0.35778			0.38004			0.74											
11/14/22 8:00	0.3189			0.34128			0.66											
11/14/22 9:00	0.30102			0.32382			0.62											
11/14/22 10:00	0.26922			0.2913			0.56											
11/14/22 11:00	0.24552			0.26472			0.51											
11/14/22 12:00	0.22386			0.24168			0.47											
11/14/22 13:00	0.24546			0.26526			0.51											
11/14/22 14:00	0.26214			0.28314			0.55											
11/14/22 15:00	0.28176			0.30312			0.58											
11/14/22 16:00	0.34056			0.36054			0.7											
11/14/22 17:00	0.3489			0.36942			0.72											
11/14/22 18:00	0.34176			0.36036			0.7											
11/14/22 19:00	0.33432			0.35532			0.69											
11/14/22 20:00	0.34668			0.3696			0.72											
11/14/22 21:00	0.34218			0.36498			0.71											
11/14/22 22:00	0.34194			0.36402			0.71											
11/14/22 23:00	0.32532			0.34728			0.67											
11/15/22 0:00	0.35004			0.37158			0.72											
11/15/22 1:00	0.35166			0.37356			0.73											
11/15/22 2:00	0.354			0.3765			0.73											
11/15/22 3:00	0.34896			0.37188			0.72											
11/15/22 4:00	0.35382			0.37614			0.73											
11/15/22 5:00	0.35448			0.37614			0.73											
11/15/22 6:00	0.36102			0.3846			0.75											
11/15/22 7:00	0.35328			0.37554			0.73											
11/15/22 8:00	0.32304			0.34572			0.67											
11/15/22 9:00	0.26484			0.28662			0.55											
11/15/22 10:00	0.22212			0.24024			0.46											
11/15/22 11:00	0.19722			0.21276			0.41											
11/15/22 12:00	0.17184			0.18486			0.36											
11/15/22 13:00	0.17076			0.18354			0.35											
11/15/22 14:00	0.17202			0.18492			0.36											
11/15/22 15:00	0.22518			0.24252			0.47											
11/15/22 16:00	0.33138			0.35118			0.68											
11/15/22 17:00	0.3408			0.36144			0.7											
11/15/22 18:00	0.34638			0.36684			0.71											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/15/22 19:00	0.33594			0.35658			0.69											
11/15/22 20:00	0.32892			0.35028			0.68											
11/15/22 21:00	0.33306			0.35382			0.69											
11/15/22 22:00	0.30996			0.3321			0.64											
11/15/22 23:00	0.31296			0.3348			0.65											
11/16/22 0:00	0.31908			0.3411			0.66											
11/16/22 1:00	0.3201			0.34224			0.66											
11/16/22 2:00	0.3186			0.33984			0.66											
11/16/22 3:00	0.31872			0.34206			0.66											
11/16/22 4:00	0.3354			0.35844			0.69											
11/16/22 5:00	0.3408			0.36348			0.7											
11/16/22 6:00	0.35604			0.37848			0.73											
11/16/22 7:00	0.34134			0.36432			0.71											
11/16/22 8:00	0.26862			0.28854			0.56											
11/16/22 9:00	0.24252			0.2622			0.5											
11/16/22 10:00	0.19044			0.20514			0.4											
11/16/22 11:00	0.17736			0.19092			0.37											
11/16/22 12:00	0.23226			0.25068			0.48											
11/16/22 13:00	0.21726			0.23424			0.45											
11/16/22 14:00	0.17028			0.18258			0.35											
11/16/22 15:00	0.24036			0.25818			0.5											
11/16/22 16:00	0.2799			0.29832			0.58											
11/16/22 17:00	0.28914			0.34554			0.63											
11/16/22 18:00	0.3507			0.37686			0.73											
11/16/22 19:00	0.34986			0.369			0.72											
11/16/22 20:00	0.30168			0.32196			0.62											
11/16/22 21:00	0.35268			0.37212			0.72											
11/16/22 22:00	0.34302			0.3645			0.71											
11/16/22 23:00	0.32838			0.34998			0.68											
11/17/22 0:00	0.2766			0.29922			0.58											
11/17/22 1:00	0.27744			0.30018			0.58											
11/17/22 2:00	0.27318			0.29586			0.57											
11/17/22 3:00	0.27372			0.29616			0.57											
11/17/22 4:00	0.27666			0.29928			0.58											
11/17/22 5:00	0.27684			0.29964			0.58											
11/17/22 6:00	0.28242			0.30462			0.59											
11/17/22 7:00	0.31332			0.33534			0.65											
11/17/22 8:00	0.20112			0.2172			0.42											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/17/22 9:00	0.26688			0.28854			0.56											
11/17/22 10:00	0.3168			0.33888			0.66											
11/17/22 11:00	0.27534			0.29694			0.57											
11/17/22 12:00	0.27858			0.30042			0.58											
11/17/22 13:00	0.31422			0.33408			0.65											
11/17/22 14:00	0.30564			0.32502			0.63											
11/17/22 15:00	0.32502			0.34458			0.67											
11/17/22 16:00	0.33444			0.35424			0.69											
11/17/22 17:00	0.34518			0.36576			0.71											
11/17/22 18:00	0.34578			0.366			0.71											
11/17/22 19:00	0.34758			0.36768			0.72											
11/17/22 20:00	0.3384			0.36096			0.7											
11/17/22 21:00	0.32658			0.34908			0.68											
11/17/22 22:00	0.32178			0.34446			0.67											
11/17/22 23:00	0.31782			0.34074			0.66											
11/18/22 0:00	0.33768			0.3606			0.7											
11/18/22 1:00	0.32748			0.35022			0.68											
11/18/22 2:00	0.33084			0.35274			0.68											
11/18/22 3:00	0.345			0.36702			0.71											
11/18/22 4:00	0.3495			0.37212			0.72											
11/18/22 5:00	0.36168			0.38418			0.75											
11/18/22 6:00	0.40116			0.42324			0.82											
11/18/22 7:00	0.3576			0.38052			0.74											
11/18/22 8:00	0.3432			0.36528			0.71											
11/18/22 9:00	0.33084			0.35352			0.68											
11/18/22 10:00	0.32106			0.34326			0.66											
11/18/22 11:00	0.31482			0.3363			0.65											
11/18/22 12:00	0.30774			0.32814			0.64											
11/18/22 13:00	0.30966			0.32952			0.64											
11/18/22 14:00	0.31074			0.32976			0.64											
11/18/22 15:00	0.32274			0.34182			0.66											
11/18/22 16:00	0.35232			0.37098			0.72											
11/18/22 17:00	0.36246			0.38232			0.74											
11/18/22 18:00	0.36036			0.3819			0.74											
11/18/22 19:00	0.3516			0.3735			0.73											
11/18/22 20:00	0.3582			0.37914			0.74											
11/18/22 21:00	0.35814			0.3804			0.74											
11/18/22 22:00	0.35238			0.37326			0.73											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/18/22 23:00	0.34242			0.36438			0.71											
11/19/22 0:00	0.32406			0.34596			0.67											
11/19/22 1:00	0.32304			0.34506			0.67											
11/19/22 2:00	0.3207			0.34194			0.66											
11/19/22 3:00	0.31404			0.33534			0.65											
11/19/22 4:00	0.33246			0.35502			0.69											
11/19/22 5:00	0.3447			0.36696			0.71											
11/19/22 6:00	0.3549			0.37608			0.73											
11/19/22 7:00	0.34956			0.3714			0.72											
11/19/22 8:00	0.23436			0.25272			0.49											
11/19/22 9:00	0.17256			0.18648			0.36											
11/19/22 10:00	0.17508			0.18906			0.36											
11/19/22 11:00	0.17532			0.18888			0.36											
11/19/22 12:00	0.17526			0.18876			0.36											
11/19/22 13:00	0.17508			0.18846			0.36											
11/19/22 14:00	0.17046			0.18318			0.35											
11/19/22 15:00	0.20736			0.2232			0.43											
11/19/22 16:00	0.33384			0.35478			0.69											
11/19/22 17:00	0.3261			0.34602			0.67											
11/19/22 18:00	0.32598			0.34614			0.67											
11/19/22 19:00	0.34566			0.36792			0.71											
11/19/22 20:00	0.35478			0.37716			0.73											
11/19/22 21:00	0.35358			0.37704			0.73											
11/19/22 22:00	0.35508			0.37806			0.73											
11/19/22 23:00	0.35784			0.3813			0.74											
11/20/22 0:00	0.35748			0.381			0.74											
11/20/22 1:00	0.35952			0.3819			0.74											
11/20/22 2:00	0.35976			0.38232			0.74											
11/20/22 3:00	0.3594			0.38142			0.74											
11/20/22 4:00	0.35934			0.3819			0.74											
11/20/22 5:00	0.3537			0.37686			0.73											
11/20/22 6:00	0.34554			0.36774			0.71											
11/20/22 7:00	0.32352			0.34704			0.67											
11/20/22 8:00	0.2802			0.30162			0.58											
11/20/22 9:00	0.28914			0.31194			0.6											
11/20/22 10:00	0.2928			0.30756			0.6											
11/20/22 11:00	0.29076			0.30468			0.6											
11/20/22 12:00	0.27054			0.29088			0.56											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/20/22 13:00	0.30972			0.32874			0.64											
11/20/22 14:00	0.2664			0.2865			0.55											
11/20/22 15:00	0.24978			0.26844			0.52											
11/20/22 16:00	0.32964			0.34974			0.68											
11/20/22 17:00	0.32814			0.34812			0.68											
11/20/22 18:00	0.32214			0.3426			0.66											
11/20/22 19:00	0.3216			0.34416			0.67											
11/20/22 20:00	0.32046			0.34368			0.66											
11/20/22 21:00	0.31314			0.33612			0.65											
11/20/22 22:00	0.31146			0.33462			0.65											
11/20/22 23:00	0.30678			0.32934			0.64											
11/21/22 0:00	0.32136			0.34398			0.67											
11/21/22 1:00	0.3126			0.33498			0.65											
11/21/22 2:00	0.31164			0.33378			0.65											
11/21/22 3:00	0.32118			0.3444			0.67											
11/21/22 4:00	0.3423			0.36528			0.71											
11/21/22 5:00	0.34134			0.36516			0.71											
11/21/22 6:00	0.3546			0.38016			0.73											
11/21/22 7:00	0.31404			0.33672			0.65											
11/21/22 8:00	0.20376			0.21828			0.42											
11/21/22 9:00	0.1734			0.1869			0.36											
11/21/22 10:00	0.17424			0.1878			0.36											
11/21/22 11:00	0.17562			0.18906			0.36											
11/21/22 12:00	0.17988			0.19356			0.37											
11/21/22 13:00	0.17418			0.18696			0.36											
11/21/22 14:00	0.25722			0.27678			0.53											
11/21/22 15:00	0.32304			0.34266			0.67											
11/21/22 16:00	0.32796			0.348			0.68											
11/21/22 17:00	0.327			0.3489			0.68											
11/21/22 18:00	0.32328			0.3456			0.67											
11/21/22 19:00	0.32406			0.3462			0.67											
11/21/22 20:00	0.32682			0.34914			0.68											
11/21/22 21:00	0.33402			0.35604			0.69											
11/21/22 22:00	0.32874			0.35202			0.68											
11/21/22 23:00	0.31314			0.33582			0.65											
11/22/22 0:00	0.2829			0.30606			0.59											
11/22/22 1:00	0.27906			0.30204			0.58											
11/22/22 2:00	0.27714			0.29958			0.58											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/22/22 3:00	0.26208			0.28386			0.55											
11/22/22 4:00	0.26784			0.28998			0.56											
11/22/22 5:00	0.27366			0.29646			0.57											
11/22/22 6:00	0.28554			0.30882			0.59											
11/22/22 7:00	0.21048			0.22788			0.44											
11/22/22 8:00	0.2478			0.26298			0.51											
11/22/22 9:00	0.3228			0.3453			0.67											
11/22/22 10:00	0.28188			0.30462			0.59											
11/22/22 11:00	0.30612			0.32742			0.63											
11/22/22 12:00	0.32754			0.34878			0.68											
11/22/22 13:00	0.33066			0.351			0.68											
11/22/22 14:00	0.32316			0.34326			0.67											
11/22/22 15:00	0.31398			0.33426			0.65											
11/22/22 16:00	0.31398			0.33522			0.65											
11/22/22 17:00	0.3048			0.32496			0.63											
11/22/22 18:00	0.30294			0.32382			0.63											
11/22/22 19:00	0.30204			0.32508			0.63											
11/22/22 20:00	0.3078			0.33036			0.64											
11/22/22 21:00	0.27222			0.29382			0.57											
11/22/22 22:00	0.20928			0.22638			0.44											
11/22/22 23:00	0.1803			0.19488			0.38											
11/23/22 0:00	0.23898			0.25878			0.5											
11/23/22 1:00	0.21732			0.2352			0.45											
11/23/22 2:00	0.23304			0.2526			0.49											
11/23/22 3:00	0.24108			0.26118			0.5											
11/23/22 4:00	0.24792			0.26892			0.52											
11/23/22 5:00	0.264			0.2856			0.55											
11/23/22 6:00	0.26538			0.28722			0.55											
11/23/22 7:00	0.21342			0.23118			0.44											
11/23/22 8:00	0.18312			0.19806			0.38											
11/23/22 9:00	0.19776			0.2136			0.41											
11/23/22 10:00	0.20724			0.2241			0.43											
11/23/22 11:00	0.27084			0.29106			0.56											
11/23/22 12:00	0.30696			0.32802			0.63											
11/23/22 13:00	0.2682			0.2874			0.56											
11/23/22 14:00	0.1731			0.18594			0.36											
11/23/22 15:00	0.20682			0.22218			0.43											
11/23/22 16:00	0.3219			0.34224			0.66											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/23/22 17:00	0.31992			0.3417			0.66											
11/23/22 18:00	0.30468			0.32742			0.63											
11/23/22 19:00	0.30246			0.32424			0.63											
11/23/22 20:00	0.3102			0.3318			0.64											
11/23/22 21:00	0.3228			0.34464			0.67											
11/23/22 22:00	0.32226			0.34392			0.67											
11/23/22 23:00	0.31362			0.33504			0.65											
11/24/22 0:00	0.32004			0.34188			0.66											
11/24/22 1:00	0.31404			0.33582			0.65											
11/24/22 2:00	0.26094			0.28242			0.54											
11/24/22 3:00	0.26532			0.2871			0.55											
11/24/22 4:00	0.26556			0.28704			0.55											
11/24/22 5:00	0.27852			0.30012			0.58											
11/24/22 6:00	0.28584			0.30948			0.6											
11/24/22 7:00	0.32424			0.35412			0.68											
11/24/22 8:00	0.31788			0.3405			0.66											
11/24/22 9:00	0.32166			0.34398			0.67											
11/24/22 10:00	0.3234			0.34494			0.67											
11/24/22 11:00	0.30882			0.32982			0.64											
11/24/22 12:00	0.30924			0.32934			0.64											
11/24/22 13:00	0.309			0.32832			0.64											
11/24/22 14:00	0.20154			0.21606			0.42											
11/24/22 15:00	0.22506			0.24096			0.47											
11/24/22 16:00	0.32442			0.34428			0.67											
11/24/22 17:00	0.3108			0.3309			0.64											
11/24/22 18:00	0.30522			0.32616			0.63											
11/24/22 19:00	0.3039			0.3255			0.63											
11/24/22 20:00	0.30354			0.32484			0.63											
11/24/22 21:00	0.3027			0.3252			0.63											
11/24/22 22:00	0.30618			0.32802			0.63											
11/24/22 23:00	0.29988			0.32226			0.62											
11/25/22 0:00	0.29928			0.32232			0.62											
11/25/22 1:00	0.29814			0.3213			0.62											
11/25/22 2:00	0.2982			0.31992			0.62											
11/25/22 3:00	0.30426			0.32604			0.63											
11/25/22 4:00	0.31368			0.33648			0.65											
11/25/22 5:00	0.31566			0.33864			0.65											
11/25/22 6:00	0.32202			0.34494			0.67											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/25/22 7:00	0.31134			0.33396			0.65											
11/25/22 8:00	0.29874			0.31782			0.62											
11/25/22 9:00	0.20112			0.21642			0.42											
11/25/22 10:00	0.17088			0.1839			0.35											
11/25/22 11:00	0.16734			0.18024			0.35											
11/25/22 12:00	0.1671			0.1797			0.35											
11/25/22 13:00	0.16776			0.17994			0.35											
11/25/22 14:00	0.1707			0.18306			0.35											
11/25/22 15:00	0.20838			0.22392			0.43											
11/25/22 16:00	0.31398			0.33396			0.65											
11/25/22 17:00	0.3144			0.33504			0.65											
11/25/22 18:00	0.30462			0.32628			0.63											
11/25/22 19:00	0.30216			0.32346			0.63											
11/25/22 20:00	0.30138			0.32418			0.63											
11/25/22 21:00	0.30234			0.32484			0.63											
11/25/22 22:00	0.31434			0.33618			0.65											
11/25/22 23:00	0.30954			0.33192			0.64											
11/26/22 0:00	0.32274			0.34512			0.67											
11/26/22 1:00	0.321			0.34368			0.66											
11/26/22 2:00	0.32166			0.345			0.67											
11/26/22 3:00	0.32286			0.34446			0.67											
11/26/22 4:00	0.32298			0.3441			0.67											
11/26/22 5:00	0.34368			0.36642			0.71											
11/26/22 6:00	0.35268			0.37476			0.73											
11/26/22 7:00	0.32286			0.34458			0.67											
11/26/22 8:00	0.2823			0.3033			0.59											
11/26/22 9:00	0.31458			0.33708			0.65											
11/26/22 10:00	0.2358			0.25452			0.49											
11/26/22 11:00	0.1713			0.18396			0.36											
11/26/22 12:00	0.1725			0.18528			0.36											
11/26/22 13:00	0.16662			0.17922			0.35											
11/26/22 14:00	0.1692			0.18192			0.35											
11/26/22 15:00	0.22206			0.23862			0.46											
11/26/22 16:00	0.30792			0.32622			0.63											
11/26/22 17:00	0.31248			0.33222			0.64											
11/26/22 18:00	0.30582			0.327			0.63											
11/26/22 19:00	0.30336			0.32586			0.63											
11/26/22 20:00	0.31482			0.33702			0.65											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/26/22 21:00	0.31824			0.34086			0.66											
11/26/22 22:00	0.3036			0.32712			0.63											
11/26/22 23:00	0.30576			0.32856			0.63											
11/27/22 0:00	0.32592			0.34878			0.67											
11/27/22 1:00	0.31614			0.33936			0.66											
11/27/22 2:00	0.3054			0.32766			0.63											
11/27/22 3:00	0.32142			0.34488			0.67											
11/27/22 4:00	0.3234			0.34524			0.67											
11/27/22 5:00	0.31026			0.33444			0.64											
11/27/22 6:00	0.32082			0.34302			0.66											
11/27/22 7:00	0.26994			0.28962			0.56											
11/27/22 8:00	0.1719			0.18558			0.36											
11/27/22 9:00	0.17022			0.18348			0.35											
11/27/22 10:00	0.17382			0.18708			0.36											
11/27/22 11:00	0.1707			0.18354			0.35											
11/27/22 12:00	0.16686			0.17934			0.35											
11/27/22 13:00	0.16698			0.17922			0.35											
11/27/22 14:00	0.16686			0.1791			0.35											
11/27/22 15:00	0.2475			0.26424			0.51											
11/27/22 16:00	0.31572			0.33594			0.65											
11/27/22 17:00	0.32442			0.34566			0.67											
11/27/22 18:00	0.32262			0.34446			0.67											
11/27/22 19:00	0.31914			0.3408			0.66											
11/27/22 20:00	0.31236			0.33444			0.65											
11/27/22 21:00	0.33144			0.3543			0.69											
11/27/22 22:00	0.30624			0.3303			0.64											
11/27/22 23:00	0.30204			0.32466			0.63											
11/28/22 0:00	0.31278			0.33576			0.65											
11/28/22 1:00	0.30648			0.32868			0.64											
11/28/22 2:00	0.2994			0.32178			0.62											
11/28/22 3:00	0.30162			0.32454			0.63											
11/28/22 4:00	0.29904			0.32226			0.62											
11/28/22 5:00	0.30798			0.33102			0.64											
11/28/22 6:00	0.3357			0.35832			0.69											
11/28/22 7:00	0.33936			0.36162			0.7											
11/28/22 8:00	0.3015			0.32448			0.63											
11/28/22 9:00	0.2322			0.25092			0.48											
11/28/22 10:00	0.17448			0.18786			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/28/22 11:00	0.1704			0.18336			0.35											
11/28/22 12:00	0.16644			0.17922			0.35											
11/28/22 13:00	0.16704			0.17952			0.35											
11/28/22 14:00	0.16812			0.18048			0.35											
11/28/22 15:00	0.2256			0.24216			0.47											
11/28/22 16:00	0.31458			0.33414			0.65											
11/28/22 17:00	0.3123			0.33348			0.65											
11/28/22 18:00	0.30336			0.32538			0.63											
11/28/22 19:00	0.30348			0.3255			0.63											
11/28/22 20:00	0.31314			0.33534			0.65											
11/28/22 21:00	0.33204			0.35364			0.69											
11/28/22 22:00	0.30864			0.33018			0.64											
11/28/22 23:00	0.29892			0.3216			0.62											
11/29/22 0:00	0.27936			0.30192			0.58											
11/29/22 1:00	0.28326			0.30684			0.59											
11/29/22 2:00	0.28326			0.30648			0.59											
11/29/22 3:00	0.27			0.29208			0.56											
11/29/22 4:00	0.27312			0.2958			0.57											
11/29/22 5:00	0.28626			0.31002			0.6											
11/29/22 6:00	0.28944			0.31188			0.6											
11/29/22 7:00	0.38658			0.39084			0.52											
11/29/22 8:00	0.29406			0		X	0.29											
11/29/22 9:00	0.27594			0		X	0.28											
11/29/22 10:00	0.27606			0		X	0.28											
11/29/22 11:00	0.27732			0.0594			0.29											
11/29/22 12:00	0.2301			0.23772			0.47											
11/29/22 13:00	0.27492			0.29724			0.57											
11/29/22 14:00	0.35586			0.37428			0.73											
11/29/22 15:00	0.35448			0.37464			0.73											
11/29/22 16:00	0.3603			0.3801			0.74											
11/29/22 17:00	0.35598			0.37692			0.73											
11/29/22 18:00	0.35526			0.3774			0.73											
11/29/22 19:00	0.35712			0.37926			0.74											
11/29/22 20:00	0.35994			0.38076			0.74											
11/29/22 21:00	0.35754			0.37944			0.74											
11/29/22 22:00	0.35184			0.37428			0.73											
11/29/22 23:00	0.3333			0.35436			0.69											
11/30/22 0:00	0.28356			0.3081			0.59											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/30/22 1:00	0.28476			0.3087			0.59											
11/30/22 2:00	0.28518			0.30954			0.59											
11/30/22 3:00	0.28476			0.3084			0.59											
11/30/22 4:00	0.28446			0.30822			0.59											
11/30/22 5:00	0.28716			0.31032			0.6											
11/30/22 6:00	0.36066			0.38178			0.74											
11/30/22 7:00	0.31194			0.33288			0.64											
11/30/22 8:00	0.23124			0.2496			0.48											
11/30/22 9:00	0.2106			0.22764			0.44											
11/30/22 10:00	0.17436			0.18792			0.36											
11/30/22 11:00	0.16878			0.18186			0.35											
11/30/22 12:00	0.16818			0.1812			0.35											
11/30/22 13:00	0.16908			0.18204			0.35											
11/30/22 14:00	0.23586			0.25506			0.49											
11/30/22 15:00	0.24552			0.26478			0.51											
11/30/22 16:00	0.32502			0.3465			0.67											
11/30/22 17:00	0.32598			0.34764			0.67											
11/30/22 18:00	0.32424			0.34716			0.67											
11/30/22 19:00	0.32484			0.34788			0.67											
11/30/22 20:00	0.3216			0.34434			0.67											
11/30/22 21:00	0.31812			0.34098			0.66											
11/30/22 22:00	0.29268			0.31548			0.61											
11/30/22 23:00	0.18498			0.19938			0.38											
12/01/22 0:00	0.24318			0.26286			0.51											
12/01/22 1:00	0.24198			0.26184			0.5											
12/01/22 2:00	0.25044			0.27048			0.52											
12/01/22 3:00	0.2526			0.2736			0.53											
12/01/22 4:00	0.2697			0.29148			0.56											
12/01/22 5:00	0.32376			0.33384			0.66											
12/01/22 6:00	0.32778			0.35028			0.68											
12/01/22 7:00	0.3066			0.3288			0.64											
12/01/22 8:00	0.34344			0.36546			0.71											
12/01/22 9:00	0.36798			0.38982			0.76											
12/01/22 10:00	0.34794			0.36972			0.72											
12/01/22 11:00	0.34236			0.3642			0.71											
12/01/22 12:00	0.33864			0.36048			0.7											
12/01/22 13:00	0.3513			0.3729			0.72											
12/01/22 14:00	0.35208			0.37248			0.72											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/01/22 15:00	0.32346			0.3447			0.67											
12/01/22 16:00	0.30834			0.32982			0.64											
12/01/22 17:00	0.31266			0.33468			0.65											
12/01/22 18:00	0.30318			0.3255			0.63											
12/01/22 19:00	0.30942			0.3318			0.64											
12/01/22 20:00	0.30258			0.32568			0.63											
12/01/22 21:00	0.30066			0.32406			0.62											
12/01/22 22:00	0.3024			0.32628			0.63											
12/01/22 23:00	0.29862			0.32262			0.62											
12/02/22 0:00	0.29784			0.32196			0.62											
12/02/22 1:00	0.29706			0.321			0.62											
12/02/22 2:00	0.29928			0.32322			0.62											
12/02/22 3:00	0.30828			0.3333			0.64											
12/02/22 4:00	0.30564			0.33012			0.64											
12/02/22 5:00	0.31188			0.33588			0.65											
12/02/22 6:00	0.32808			0.3522			0.68											
12/02/22 7:00	0.36108			0.38376			0.74											
12/02/22 8:00	0.3273			0.35016			0.68											
12/02/22 9:00	0.327			0.35016			0.68											
12/02/22 10:00	0.33024			0.35298			0.68											
12/02/22 11:00	0.32682			0.34872			0.68											
12/02/22 12:00	0.3285			0.3507			0.68											
12/02/22 13:00	0.35028			0.3723			0.72											
12/02/22 14:00	0.36078			0.38208			0.74											
12/02/22 15:00	0.35802			0.37968			0.74											
12/02/22 16:00	0.35052			0.37194			0.72											
12/02/22 17:00	0.35658			0.37836			0.73											
12/02/22 18:00	0.35358			0.37548			0.73											
12/02/22 19:00	0.3567			0.37788			0.73											
12/02/22 20:00	0.36876			0.39084			0.76											
12/02/22 21:00	0.35376			0.37578			0.73											
12/02/22 22:00	0.35058			0.37314			0.72											
12/02/22 23:00	0.32598			0.34788			0.67											
12/03/22 0:00	0.32754			0.34956			0.68											
12/03/22 1:00	0.32328			0.3456			0.67											
12/03/22 2:00	0.32034			0.34272			0.66											
12/03/22 3:00	0.3252			0.34758			0.67											
12/03/22 4:00	0.33222			0.3546			0.69											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 5:00	0.33768			0.36066			0.7											
12/03/22 6:00	0.34098			0.36348			0.7											
12/03/22 7:00	0.3705			0.39228			0.76											
12/03/22 8:00	0.35538			0.37746			0.73											
12/03/22 9:00	0.35448			0.37662			0.73											
12/03/22 10:00	0.34098			0.36318			0.7											
12/03/22 11:00	0.32376			0.34608			0.67											
12/03/22 12:00	0.3228			0.34506			0.67											
12/03/22 13:00	0.32292			0.34512			0.67											
12/03/22 14:00	0.32862			0.35148			0.68											
12/03/22 15:00	0.34284			0.3651			0.71											
12/03/22 16:00	0.3369			0.3591			0.7											
12/03/22 17:00	0.28482			0.30126			0.59											
12/03/22 18:00	0.16902			0.07104			0.17											
12/03/22 19:00	0.24618			0	X		0.25											
12/03/22 20:00	0.27258			0	X		0.27											
12/03/22 21:00	0.27426			0	X		0.27											
12/03/22 22:00	0.27672			0	X		0.28											
12/03/22 23:00	0.27996			0	X		0.28											
12/04/22 0:00	0.29622			0	X		0.3											
12/04/22 1:00	0.29832			0	X		0.3											
12/04/22 2:00	0.3015			0	X		0.3											
12/04/22 3:00	0.30216			0	X		0.3											
12/04/22 4:00	0.30504			0	X		0.31											
12/04/22 5:00	0.31104			0	X		0.31											
12/04/22 6:00	0.30156			0	X		0.3											
12/04/22 7:00	0.303			0	X		0.3											
12/04/22 8:00	0.3117			0	X		0.31											
12/04/22 9:00	0.29946			0	X		0.3											
12/04/22 10:00	0.2997			0	X		0.3											
12/04/22 11:00	0.29976			0	X		0.3											
12/04/22 12:00	0.29718			0	X		0.3											
12/04/22 13:00	0.29838			0	X		0.3											
12/04/22 14:00	0.2781			0	X		0.28											
12/04/22 15:00	0.27954			0	X		0.28											
12/04/22 16:00	0.27966			0	X		0.28											
12/04/22 17:00	0.27972			0	X		0.28											
12/04/22 18:00	0.27978			0	X		0.28											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/22 19:00	0.27978			0	X		0.28											
12/04/22 20:00	0.28014			0	X		0.28											
12/04/22 21:00	0.28014			0	X		0.28											
12/04/22 22:00	0.28008			0	X		0.28											
12/04/22 23:00	0.28002			0	X		0.28											
12/05/22 0:00	0.27984			0	X		0.28											
12/05/22 1:00	0.27984			0	X		0.28											
12/05/22 2:00	0.27978			0	X		0.28											
12/05/22 3:00	0.27984			0	X		0.28											
12/05/22 4:00	0.27972			0	X		0.28											
12/05/22 5:00	0.27954			0	X		0.28											
12/05/22 6:00	0.28344			0	X		0.28											
12/05/22 7:00	0.294			0	X		0.29											
12/05/22 8:00	0.2808			0	X		0.28											
12/05/22 9:00	0.28056			0	X		0.28											
12/05/22 10:00	0.21804			0	X		0.22											
12/05/22 11:00	0.16734			0	X		0.17											
12/05/22 12:00	0.16692			0	X		0.17											
12/05/22 13:00	0.16656			0	X		0.17											
12/05/22 14:00	0.17856			0	X		0.18											
12/05/22 15:00	0.18126			0	X		0.18											
12/05/22 16:00	0.19926			0	X		0.2											
12/05/22 17:00	0.21024			0.17226			0.37											
12/05/22 18:00	0.22158			0.23868			0.46											
12/05/22 19:00	0.32412			0.35316			0.68											
12/05/22 20:00	0.32238			0.34944			0.67											
12/05/22 21:00	0.30882			0.33192			0.64											
12/05/22 22:00	0.27006			0.29004			0.56											
12/05/22 23:00	0.19416			0.21006			0.4											
12/06/22 0:00	0.22398			0.24876			0.47											
12/06/22 1:00	0.0534			0.20736			0.21											
12/06/22 2:00	0	X		0.1911			0.19											
12/06/22 3:00	0	X		0.1872			0.19											
12/06/22 4:00	0	X		0.1875			0.19											
12/06/22 5:00	0	X		0.18744			0.19											
12/06/22 6:00	0	X		0.18768			0.19											
12/06/22 7:00	0	X		0.18756			0.19											
12/06/22 8:00	0	X		0.1875			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/06/22 9:00	0	X		0.20016			0.2											
12/06/22 10:00	0	X		0.21264			0.21											
12/06/22 11:00	0	X		0.1875			0.19											
12/06/22 12:00	0	X		0.1881			0.19											
12/06/22 13:00	0	X		0.1866			0.19											
12/06/22 14:00	0	X		0.19692			0.2											
12/06/22 15:00	0.15288			0.23544			0.37											
12/06/22 16:00	0.2592			0.27804			0.54											
12/06/22 17:00	0.32874			0.35646			0.69											
12/06/22 18:00	0.32652			0.34842			0.67											
12/06/22 19:00	0.32712			0.35088			0.68											
12/06/22 20:00	0.32604			0.34806			0.67											
12/06/22 21:00	0.32304			0.34872			0.67											
12/06/22 22:00	0.30828			0.33114			0.64											
12/06/22 23:00	0.30132			0.32466			0.63											
12/07/22 0:00	0.26886			0.29052			0.56											
12/07/22 1:00	0.25836			0.27906			0.54											
12/07/22 2:00	0.26694			0.2889			0.56											
12/07/22 3:00	0.26604			0.2877			0.55											
12/07/22 4:00	0.28542			0.30288			0.59											
12/07/22 5:00	0.33018			0.3591			0.69											
12/07/22 6:00	0.3333			0.35904			0.69											
12/07/22 7:00	0.30408			0.32808			0.63											
12/07/22 8:00	0.30078			0.3237			0.62											
12/07/22 9:00	0.31182			0.33438			0.65											
12/07/22 10:00	0.30828			0.33048			0.64											
12/07/22 11:00	0.3054			0.3273			0.63											
12/07/22 12:00	0.2748			0.29556			0.57											
12/07/22 13:00	0.1749			0.18756			0.36											
12/07/22 14:00	0.19716			0.21186			0.41											
12/07/22 15:00	0.31008			0.33108			0.64											
12/07/22 16:00	0.3057			0.32748			0.63											
12/07/22 17:00	0.30468			0.32772			0.63											
12/07/22 18:00	0.30408			0.3279			0.63											
12/07/22 19:00	0.31722			0.34104			0.66											
12/07/22 20:00	0.33876			0.36186			0.7											
12/07/22 21:00	0.33504			0.3579			0.69											
12/07/22 22:00	0.30978			0.33354			0.64											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/07/22 23:00	0.30276			0.32556			0.63											
12/08/22 0:00	0.31866			0.34134			0.66											
12/08/22 1:00	0.31038			0.33354			0.64											
12/08/22 2:00	0.30804			0.3312			0.64											
12/08/22 3:00	0.30882			0.333			0.64											
12/08/22 4:00	0.31872			0.34242			0.66											
12/08/22 5:00	0.33078			0.35376			0.68											
12/08/22 6:00	0.34158			0.36474			0.71											
12/08/22 7:00	0.32922			0.35196			0.68											
12/08/22 8:00	0.30882			0.33222			0.64											
12/08/22 9:00	0.29058			0.31326			0.6											
12/08/22 10:00	0.26466			0.28572			0.55											
12/08/22 11:00	0.3183			0.33852			0.66											
12/08/22 12:00	0.33534			0.3576			0.69											
12/08/22 13:00	0.33486			0.35694			0.69											
12/08/22 14:00	0.34404			0.36618			0.71											
12/08/22 15:00	0.33846			0.36012			0.7											
12/08/22 16:00	0.34458			0.36696			0.71											
12/08/22 17:00	0.35484			0.37716			0.73											
12/08/22 18:00	0.35802			0.38034			0.74											
12/08/22 19:00	0.35766			0.3801			0.74											
12/08/22 20:00	0.3567			0.3798			0.74											
12/08/22 21:00	0.35394			0.37662			0.73											
12/08/22 22:00	0.34614			0.369			0.72											
12/08/22 23:00	0.32256			0.3456			0.67											
12/09/22 0:00	0.25746			0.27684			0.53											
12/09/22 1:00	0.24144			0.26088			0.5											
12/09/22 2:00	0.25584			0.2763			0.53											
12/09/22 3:00	0.25944			0.2805			0.54											
12/09/22 4:00	0.28128			0.29736			0.58											
12/09/22 5:00	0.2949			0.3			0.59											
12/09/22 6:00	0.28722			0.3066			0.59											
12/09/22 7:00	0.32382			0.34704			0.67											
12/09/22 8:00	0.25554			0.27576			0.53											
12/09/22 9:00	0.2373			0.2559			0.49											
12/09/22 10:00	0.17544			0.18816			0.36											
12/09/22 11:00	0.17754			0.19068			0.37											
12/09/22 12:00	0.18024			0.19386			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/09/22 13:00	0.27966			0.30222			0.58											
12/09/22 14:00	0.2808			0.30318			0.58											
12/09/22 15:00	0.2322			0.25026			0.48											
12/09/22 16:00	0.32808			0.34998			0.68											
12/09/22 17:00	0.32562			0.34794			0.67											
12/09/22 18:00	0.32802			0.35034			0.68											
12/09/22 19:00	0.33888			0.3609			0.7											
12/09/22 20:00	0.34182			0.3642			0.71											
12/09/22 21:00	0.33522			0.35826			0.69											
12/09/22 22:00	0.33258			0.35604			0.69											
12/09/22 23:00	0.3183			0.34146			0.66											
12/10/22 0:00	0.28302			0.3063			0.59											
12/10/22 1:00	0.28206			0.30486			0.59											
12/10/22 2:00	0.2823			0.30492			0.59											
12/10/22 3:00	0.2823			0.30474			0.59											
12/10/22 4:00	0.28236			0.30462			0.59											
12/10/22 5:00	0.28236			0.30492			0.59											
12/10/22 6:00	0.28212			0.30528			0.59											
12/10/22 7:00	0.1884			0.20322			0.39											
12/10/22 8:00	0.2037			0.21966			0.42											
12/10/22 9:00	0.18582			0.20046			0.39											
12/10/22 10:00	0.17286			0.18642			0.36											
12/10/22 11:00	0.20172			0.2178			0.42											
12/10/22 12:00	0.25746			0.27936			0.54											
12/10/22 13:00	0.25728			0.27762			0.53											
12/10/22 14:00	0.31164			0.3342			0.65											
12/10/22 15:00	0.31626			0.33822			0.65											
12/10/22 16:00	0.31848			0.3408			0.66											
12/10/22 17:00	0.31092			0.3333			0.64											
12/10/22 18:00	0.31074			0.33306			0.64											
12/10/22 19:00	0.33018			0.3522			0.68											
12/10/22 20:00	0.3267			0.34902			0.68											
12/10/22 21:00	0.31338			0.3357			0.65											
12/10/22 22:00	0.30846			0.33084			0.64											
12/10/22 23:00	0.31122			0.33384			0.65											
12/11/22 0:00	0.29976			0.32262			0.62											
12/11/22 1:00	0.2172			0.23484			0.45											
12/11/22 2:00	0.1872			0.2022			0.39											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/22 3:00	0.2031			0.21954			0.42											
12/11/22 4:00	0.23988			0.25932			0.5											
12/11/22 5:00	0.24882			0.26922			0.52											
12/11/22 6:00	0.24552			0.26514			0.51											
12/11/22 7:00	0.18336			0.198			0.38											
12/11/22 8:00	0.1695			0.18288			0.35											
12/11/22 9:00	0.16842			0.18162			0.35											
12/11/22 10:00	0.17196			0.18534			0.36											
12/11/22 11:00	0.16824			0.1812			0.35											
12/11/22 12:00	0.1683			0.18126			0.35											
12/11/22 13:00	0.1716			0.18468			0.36											
12/11/22 14:00	0.17586			0.18906			0.36											
12/11/22 15:00	0.24552			0.2646			0.51											
12/11/22 16:00	0.30954			0.33294			0.64											
12/11/22 17:00	0.31188			0.3342			0.65											
12/11/22 18:00	0.30714			0.33024			0.64											
12/11/22 19:00	0.30852			0.3309			0.64											
12/11/22 20:00	0.31632			0.33858			0.65											
12/11/22 21:00	0.30714			0.32964			0.64											
12/11/22 22:00	0.23982			0.25878			0.5											
12/11/22 23:00	0.1752			0.18918			0.36											
12/12/22 0:00	0.17814			0.19248			0.37											
12/12/22 1:00	0.18186			0.19644			0.38											
12/12/22 2:00	0.1974			0.21324			0.41											
12/12/22 3:00	0.18102			0.1953			0.38											
12/12/22 4:00	0.2502			0.26868			0.52											
12/12/22 5:00	0.32772			0.35052			0.68											
12/12/22 6:00	0.3354			0.3579			0.69											
12/12/22 7:00	0.3225			0.34494			0.67											
12/12/22 8:00	0.30918			0.33114			0.64											
12/12/22 9:00	0.3081			0.33018			0.64											
12/12/22 10:00	0.27138			0.2931			0.56											
12/12/22 11:00	0.17424			0.18792			0.36											
12/12/22 12:00	0.17448			0.18816			0.36											
12/12/22 13:00	0.17052			0.18414			0.35											
12/12/22 14:00	0.1698			0.17736			0.35											
12/12/22 15:00	0.28584			0.0726			0.29											
12/12/22 16:00	0.294			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/12/22 17:00	0.2955			0	X		0.3											
12/12/22 18:00	0.29616			0	X		0.3											
12/12/22 19:00	0.297			0	X		0.3											
12/12/22 20:00	0.2979			0	X		0.3											
12/12/22 21:00	0.29838			0	X		0.3											
12/12/22 22:00	0.2997			0	X		0.3											
12/12/22 23:00	0.29988			0	X		0.3											
12/13/22 0:00	0.30036			0	X		0.3											
12/13/22 1:00	0.30012			0	X		0.3											
12/13/22 2:00	0.3012			0	X		0.3											
12/13/22 3:00	0.30228			0	X		0.3											
12/13/22 4:00	0.29994			0	X		0.3											
12/13/22 5:00	0.29964			0	X		0.3											
12/13/22 6:00	0.30246			0	X		0.3											
12/13/22 7:00	0.3207			0	X		0.32											
12/13/22 8:00	0.3009			0	X		0.3											
12/13/22 9:00	0.29994			0	X		0.3											
12/13/22 10:00	0.29988			0	X		0.3											
12/13/22 11:00	0.2058			0	X		0.21											
12/13/22 12:00	0.17448			0	X		0.17											
12/13/22 13:00	0.17424			0	X		0.17											
12/13/22 14:00	0.1746			0	X		0.17											
12/13/22 15:00	0.24144			0	X		0.24											
12/13/22 16:00	0.2979			0	X		0.3											
12/13/22 17:00	0.29748			0	X		0.3											
12/13/22 18:00	0.29802			0	X		0.3											
12/13/22 19:00	0.29826			0	X		0.3											
12/13/22 20:00	0.2994			0	X		0.3											
12/13/22 21:00	0.32016			0	X		0.32											
12/13/22 22:00	0.31038			0	X		0.31											
12/13/22 23:00	0.3009			0	X		0.3											
12/14/22 0:00	0.28692			0	X		0.29											
12/14/22 1:00	0.28686			0	X		0.29											
12/14/22 2:00	0.2871			0	X		0.29											
12/14/22 3:00	0.28644			0	X		0.29											
12/14/22 4:00	0.28902			0	X		0.29											
12/14/22 5:00	0.2907			0	X		0.29											
12/14/22 6:00	0.29322			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/14/22 7:00	0.2883			0	X		0.29											
12/14/22 8:00	0.28944			0	X		0.29											
12/14/22 9:00	0.28926			0	X		0.29											
12/14/22 10:00	0.2892			0	X		0.29											
12/14/22 11:00	0.28044			0	X		0.28											
12/14/22 12:00	0.18108			0	X		0.18											
12/14/22 13:00	0.17496			0	X		0.17											
12/14/22 14:00	0.17496			0	X		0.17											
12/14/22 15:00	0.17478			0	X		0.17											
12/14/22 16:00	0.21228			0	X		0.21											
12/14/22 17:00	0.29652			0	X		0.3											
12/14/22 18:00	0.29838			0	X		0.3											
12/14/22 19:00	0.29916			0	X		0.3											
12/14/22 20:00	0.29598			0	X		0.3											
12/14/22 21:00	0.28842			0	X		0.29											
12/14/22 22:00	0.2874			0	X		0.29											
12/14/22 23:00	0.28866			0	X		0.29											
12/15/22 0:00	0.28902			0	X		0.29											
12/15/22 1:00	0.28986			0	X		0.29											
12/15/22 2:00	0.28914			0	X		0.29											
12/15/22 3:00	0.28812			0	X		0.29											
12/15/22 4:00	0.28962			0	X		0.29											
12/15/22 5:00	0.28926			0	X		0.29											
12/15/22 6:00	0.2901			0	X		0.29											
12/15/22 7:00	0.29094			0	X		0.29											
12/15/22 8:00	0.28962			0	X		0.29											
12/15/22 9:00	0.28974			0	X		0.29											
12/15/22 10:00	0.28968			0	X		0.29											
12/15/22 11:00	0.28848			0	X		0.29											
12/15/22 12:00	0.28776			0	X		0.29											
12/15/22 13:00	0.28608			0	X		0.29											
12/15/22 14:00	0.28572			0	X		0.29											
12/15/22 15:00	0.28578			0	X		0.29											
12/15/22 16:00	0.2856			0	X		0.29											
12/15/22 17:00	0.28632			0	X		0.29											
12/15/22 18:00	0.28548			0	X		0.29											
12/15/22 19:00	0.28596			0	X		0.29											
12/15/22 20:00	0.28614			0	X		0.29											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/15/22 21:00	0.28662			0	X		0.29											
12/15/22 22:00	0.28842			0	X		0.29											
12/15/22 23:00	0.2895			0	X		0.29											
12/16/22 0:00	0.27384			0	X		0.27											
12/16/22 1:00	0.17502			0	X		0.18											
12/16/22 2:00	0.1749			0	X		0.17											
12/16/22 3:00	0.17496			0	X		0.17											
12/16/22 4:00	0.17454			0	X		0.17											
12/16/22 5:00	0.17472			0	X		0.17											
12/16/22 6:00	0.17472			0	X		0.17											
12/16/22 7:00	0.17406			0	X		0.17											
12/16/22 8:00	0.1749			0	X		0.17											
12/16/22 9:00	0.17454			0	X		0.17											
12/16/22 10:00	0.17454			0	X		0.17											
12/16/22 11:00	0.17466			0	X		0.17											
12/16/22 12:00	0.1746			0	X		0.17											
12/16/22 13:00	0.17508			0	X		0.18											
12/16/22 14:00	0.1752			0	X		0.18											
12/16/22 15:00	0.17538			0	X		0.18											
12/16/22 16:00	0.17544			0	X		0.18											
12/16/22 17:00	0.17526			0	X		0.18											
12/16/22 18:00	0.17484			0	X		0.17											
12/16/22 19:00	0.17418			0	X		0.17											
12/16/22 20:00	0.17466			0	X		0.17											
12/16/22 21:00	0.1746			0	X		0.17											
12/16/22 22:00	0.1746			0	X		0.17											
12/16/22 23:00	0.17508			0	X		0.18											
12/17/22 0:00	0.17508			0	X		0.18											
12/17/22 1:00	0.1752			0	X		0.18											
12/17/22 2:00	0.23874			0	X		0.24											
12/17/22 3:00	0.21402			0.1749			0.37											
12/17/22 4:00	0.1728			0.18738			0.36											
12/17/22 5:00	0.2322			0.25146			0.48											
12/17/22 6:00	0.30774			0.33072			0.64											
12/17/22 7:00	0.31116			0.3336			0.64											
12/17/22 8:00	0.27492			0.2979			0.57											
12/17/22 9:00	0.24372			0.26418			0.51											
12/17/22 10:00	0.18708			0.20172			0.39											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 11:00	0.17172			0.18498			0.36											
12/17/22 12:00	0.16878			0.18216			0.35											
12/17/22 13:00	0.17424			0.18768			0.36											
12/17/22 14:00	0.19944			0.21456			0.41											
12/17/22 15:00	0.32526			0.3468			0.67											
12/17/22 16:00	0.33528			0.35652			0.69											
12/17/22 17:00	0.32766			0.34872			0.68											
12/17/22 18:00	0.31632			0.33882			0.66											
12/17/22 19:00	0.33732			0.35964			0.7											
12/17/22 20:00	0.34968			0.37182			0.72											
12/17/22 21:00	0.34374			0.36576			0.71											
12/17/22 22:00	0.3372			0.35916			0.7											
12/17/22 23:00	0.31584			0.33792			0.65											
12/18/22 0:00	0.26886			0.29076			0.56											
12/18/22 1:00	0.26778			0.28974			0.56											
12/18/22 2:00	0.25662			0.2778			0.53											
12/18/22 3:00	0.25134			0.27216			0.52											
12/18/22 4:00	0.26508			0.2868			0.55											
12/18/22 5:00	0.27474			0.29712			0.57											
12/18/22 6:00	0.28548			0.30534			0.59											
12/18/22 7:00	0.3597			0.38178			0.74											
12/18/22 8:00	0.34116			0.36288			0.7											
12/18/22 9:00	0.34608			0.36804			0.71											
12/18/22 10:00	0.3105			0.3312			0.64											
12/18/22 11:00	0.26256			0.28362			0.55											
12/18/22 12:00	0.21978			0.23724			0.46											
12/18/22 13:00	0.17412			0.1878			0.36											
12/18/22 14:00	0.21228			0.22878			0.44											
12/18/22 15:00	0.21252			0.22974			0.44											
12/18/22 16:00	0.29652			0.31452			0.61											
12/18/22 17:00	0.31662			0.32256			0.64											
12/18/22 18:00	0.34002			0.3627			0.7											
12/18/22 19:00	0.33516			0.35766			0.69											
12/18/22 20:00	0.33168			0.35406			0.69											
12/18/22 21:00	0.32748			0.35034			0.68											
12/18/22 22:00	0.3225			0.34494			0.67											
12/18/22 23:00	0.31122			0.33408			0.65											
12/19/22 0:00	0.33048			0.35304			0.68											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/19/22 1:00	0.3306			0.3528			0.68											
12/19/22 2:00	0.33084			0.3534			0.68											
12/19/22 3:00	0.33072			0.3531			0.68											
12/19/22 4:00	0.3435			0.366			0.71											
12/19/22 5:00	0.35994			0.38208			0.74											
12/19/22 6:00	0.36156			0.38442			0.75											
12/19/22 7:00	0.3555			0.37818			0.73											
12/19/22 8:00	0.34506			0.3675			0.71											
12/19/22 9:00	0.37026			0.39342			0.76											
12/19/22 10:00	0.3648			0.38826			0.75											
12/19/22 11:00	0.35532			0.37794			0.73											
12/19/22 12:00	0.34026			0.36282			0.7											
12/19/22 13:00	0.34458			0.3666			0.71											
12/19/22 14:00	0.35058			0.37302			0.72											
12/19/22 15:00	0.34236			0.36462			0.71											
12/19/22 16:00	0.35676			0.37902			0.74											
12/19/22 17:00	0.35868			0.38118			0.74											
12/19/22 18:00	0.35802			0.38016			0.74											
12/19/22 19:00	0.3576			0.38064			0.74											
12/19/22 20:00	0.35766			0.38046			0.74											
12/19/22 21:00	0.35778			0.3807			0.74											
12/19/22 22:00	0.35778			0.37938			0.74											
12/19/22 23:00	0.33378			0.35604			0.69											
12/20/22 0:00	0.28668			0.3099			0.6											
12/20/22 1:00	0.28752			0.3108			0.6											
12/20/22 2:00	0.28752			0.31104			0.6											
12/20/22 3:00	0.28728			0.31134			0.6											
12/20/22 4:00	0.28698			0.31074			0.6											
12/20/22 5:00	0.28818			0.31158			0.6											
12/20/22 6:00	0.28782			0.31152			0.6											
12/20/22 7:00	0.35556			0.37878			0.73											
12/20/22 8:00	0.33936			0.36228			0.7											
12/20/22 9:00	0.30444			0.3255			0.63											
12/20/22 10:00	0.26832			0.2868			0.56											
12/20/22 11:00	0.1743			0.18762			0.36											
12/20/22 12:00	0.16992			0.1833			0.35											
12/20/22 13:00	0.16992			0.18354			0.35											
12/20/22 14:00	0.16944			0.18294			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/20/22 15:00	0.22956			0.24702			0.48											
12/20/22 16:00	0.30564			0.3273			0.63											
12/20/22 17:00	0.30372			0.32628			0.63											
12/20/22 18:00	0.30396			0.32556			0.63											
12/20/22 19:00	0.3042			0.3261			0.63											
12/20/22 20:00	0.30348			0.3261			0.63											
12/20/22 21:00	0.30246			0.32538			0.63											
12/20/22 22:00	0.30234			0.32418			0.63											
12/20/22 23:00	0.30198			0.32478			0.63											
12/21/22 0:00	0.30198			0.32472			0.63											
12/21/22 1:00	0.30168			0.3249			0.63											
12/21/22 2:00	0.30066			0.32448			0.63											
12/21/22 3:00	0.30084			0.32394			0.62											
12/21/22 4:00	0.3009			0.32322			0.62											
12/21/22 5:00	0.30126			0.32244			0.62											
12/21/22 6:00	0.30654			0.32772			0.63											
12/21/22 7:00	0.3357			0.35874			0.69											
12/21/22 8:00	0.32016			0.3429			0.66											
12/21/22 9:00	0.34656			0.36894			0.72											
12/21/22 10:00	0.33954			0.36174			0.7											
12/21/22 11:00	0.32946			0.35142			0.68											
12/21/22 12:00	0.32694			0.3489			0.68											
12/21/22 13:00	0.33294			0.35478			0.69											
12/21/22 14:00	0.32592			0.3477			0.67											
12/21/22 15:00	0.31092			0.33306			0.64											
12/21/22 16:00	0.32694			0.34896			0.68											
12/21/22 17:00	0.32196			0.34422			0.67											
12/21/22 18:00	0.31824			0.34092			0.66											
12/21/22 19:00	0.32178			0.34452			0.67											
12/21/22 20:00	0.34014			0.3627			0.7											
12/21/22 21:00	0.34176			0.3642			0.71											
12/21/22 22:00	0.312			0.33486			0.65											
12/21/22 23:00	0.30516			0.32796			0.63											
12/22/22 0:00	0.3012			0.32388			0.63											
12/22/22 1:00	0.28716			0.31026			0.6											
12/22/22 2:00	0.28728			0.31074			0.6											
12/22/22 3:00	0.2874			0.31128			0.6											
12/22/22 4:00	0.28674			0.3102			0.6											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/22 5:00	0.28734			0.31116			0.6											
12/22/22 6:00	0.28752			0.3114			0.6											
12/22/22 7:00	0.3075			0.32988			0.64											
12/22/22 8:00	0.306			0.32832			0.63											
12/22/22 9:00	0.34044			0.36228			0.7											
12/22/22 10:00	0.35808			0.37986			0.74											
12/22/22 11:00	0.35604			0.378			0.73											
12/22/22 12:00	0.31956			0.34164			0.66											
12/22/22 13:00	0.30822			0.33042			0.64											
12/22/22 14:00	0.30342			0.32538			0.63											
12/22/22 15:00	0.30678			0.32892			0.64											
12/22/22 16:00	0.32742			0.34914			0.68											
12/22/22 17:00	0.31248			0.33468			0.65											
12/22/22 18:00	0.31164			0.33366			0.65											
12/22/22 19:00	0.30654			0.32868			0.64											
12/22/22 20:00	0.30294			0.32532			0.63											
12/22/22 21:00	0.30822			0.33084			0.64											
12/22/22 22:00	0.30936			0.33174			0.64											
12/22/22 23:00	0.30354			0.32604			0.63											
12/23/22 0:00	0.30348			0.32616			0.63											
12/23/22 1:00	0.30348			0.32574			0.63											
12/23/22 2:00	0.30324			0.32562			0.63											
12/23/22 3:00	0.30324			0.32574			0.63											
12/23/22 4:00	0.30336			0.3258			0.63											
12/23/22 5:00	0.30282			0.32544			0.63											
12/23/22 6:00	0.30222			0.32472			0.63											
12/23/22 7:00	0.33696			0.35952			0.7											
12/23/22 8:00	0.32142			0.34332			0.66											
12/23/22 9:00	0.32628			0.3486			0.67											
12/23/22 10:00	0.3228			0.3453			0.67											
12/23/22 11:00	0.3213			0.34344			0.66											
12/23/22 12:00	0.30006			0.32232			0.62											
12/23/22 13:00	0.19734			0.21264			0.41											
12/23/22 14:00	0.20898			0.2253			0.43											
12/23/22 15:00	0.31584			0.33798			0.65											
12/23/22 16:00	0.34734			0.36888			0.72											
12/23/22 17:00	0.34392			0.36588			0.71											
12/23/22 18:00	0.34152			0.36384			0.71											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/23/22 19:00	0.32916			0.35238			0.68											
12/23/22 20:00	0.32712			0.35046			0.68											
12/23/22 21:00	0.3315			0.3546			0.69											
12/23/22 22:00	0.32718			0.34986			0.68											
12/23/22 23:00	0.31914			0.3414			0.66											
12/24/22 0:00	0.28602			0.30906			0.6											
12/24/22 1:00	0.28644			0.31032			0.6											
12/24/22 2:00	0.28698			0.31098			0.6											
12/24/22 3:00	0.28674			0.3105			0.6											
12/24/22 4:00	0.28638			0.31002			0.6											
12/24/22 5:00	0.28626			0.31014			0.6											
12/24/22 6:00	0.2823			0.30552			0.59											
12/24/22 7:00	0.2037			0.22002			0.42											
12/24/22 8:00	0.17466			0.18846			0.36											
12/24/22 9:00	0.26262			0.28368			0.55											
12/24/22 10:00	0.32292			0.34578			0.67											
12/24/22 11:00	0.30618			0.32826			0.63											
12/24/22 12:00	0.30816			0.33042			0.64											
12/24/22 13:00	0.30648			0.32862			0.64											
12/24/22 14:00	0.30348			0.32502			0.63											
12/24/22 15:00	0.3036			0.3255			0.63											
12/24/22 16:00	0.30636			0.32874			0.64											
12/24/22 17:00	0.30324			0.32436			0.63											
12/24/22 18:00	0.30186			0.32508			0.63											
12/24/22 19:00	0.30372			0.32664			0.63											
12/24/22 20:00	0.27468			0.29658			0.57											
12/24/22 21:00	0.17592			0.18972			0.37											
12/24/22 22:00	0.17718			0.19092			0.37											
12/24/22 23:00	0.17772			0.1914			0.37											
12/25/22 0:00	0.18732			0.20202			0.39											
12/25/22 1:00	0.17838			0.19248			0.37											
12/25/22 2:00	0.17754			0.19152			0.37											
12/25/22 3:00	0.17712			0.19104			0.37											
12/25/22 4:00	0.17706			0.19092			0.37											
12/25/22 5:00	0.17622			0.19014			0.37											
12/25/22 6:00	0.17616			0.18996			0.37											
12/25/22 7:00	0.1743			0.18804			0.36											
12/25/22 8:00	0.17574			0.1896			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/25/22 9:00	0.19566			0.21078			0.41											
12/25/22 10:00	0.17784			0.19182			0.37											
12/25/22 11:00	0.1812			0.19524			0.38											
12/25/22 12:00	0.18882			0.20358			0.39											
12/25/22 13:00	0.17532			0.1887			0.36											
12/25/22 14:00	0.17232			0.18558			0.36											
12/25/22 15:00	0.16872			0.18198			0.35											
12/25/22 16:00	0.22776			0.24582			0.47											
12/25/22 17:00	0.30222			0.32478			0.63											
12/25/22 18:00	0.21198			0.2286			0.44											
12/25/22 19:00	0.17436			0.18786			0.36											
12/25/22 20:00	0.17478			0.18852			0.36											
12/25/22 21:00	0.1749			0.1887			0.36											
12/25/22 22:00	0.17286			0.18678			0.36											
12/25/22 23:00	0.17232			0.18594			0.36											
12/26/22 0:00	0.18558			0.20028			0.39											
12/26/22 1:00	0.17532			0.189			0.36											
12/26/22 2:00	0.18306			0.1977			0.38											
12/26/22 3:00	0.1776			0.19158			0.37											
12/26/22 4:00	0.17508			0.18906			0.36											
12/26/22 5:00	0.2076			0.2241			0.43											
12/26/22 6:00	0.20742			0.22398			0.43											
12/26/22 7:00	0.17604			0.19014			0.37											
12/26/22 8:00	0.16812			0.1815			0.35											
12/26/22 9:00	0.17586			0.18978			0.37											
12/26/22 10:00	0.2259			0.2442			0.47											
12/26/22 11:00	0.2835			0.30522			0.59											
12/26/22 12:00	0.30204			0.32436			0.63											
12/26/22 13:00	0.30954			0.33162			0.64											
12/26/22 14:00	0.32592			0.34794			0.67											
12/26/22 15:00	0.32898			0.35094			0.68											
12/26/22 16:00	0.31854			0.34062			0.66											
12/26/22 17:00	0.32448			0.34806			0.67											
12/26/22 18:00	0.3243			0.34728			0.67											
12/26/22 19:00	0.3063			0.3306			0.64											
12/26/22 20:00	0.30564			0.32994			0.64											
12/26/22 21:00	0.29232			0.31512			0.61											
12/26/22 22:00	0.17772			0.19194			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/26/22 23:00	0.1674			0.18042			0.35											
12/27/22 0:00	0.16956			0.183			0.35											
12/27/22 1:00	0.16674			0.18			0.35											
12/27/22 2:00	0.16656			0.17976			0.35											
12/27/22 3:00	0.16662			0.18			0.35											
12/27/22 4:00	0.16662			0.17982			0.35											
12/27/22 5:00	0.16686			0.18006			0.35											
12/27/22 6:00	0.16914			0.18222			0.35											
12/27/22 7:00	0.16746			0.18054			0.35											
12/27/22 8:00	0.17472			0.1884			0.36											
12/27/22 9:00	0.171			0.18456			0.36											
12/27/22 10:00	0.16716			0.18048			0.35											
12/27/22 11:00	0.16764			0.18084			0.35											
12/27/22 12:00	0.16812			0.18138			0.35											
12/27/22 13:00	0.17448			0.1878			0.36											
12/27/22 14:00	0.17394			0.18738			0.36											
12/27/22 15:00	0.16872			0.18156			0.35											
12/27/22 16:00	0.16908			0.18204			0.35											
12/27/22 17:00	0.16806			0.18096			0.35											
12/27/22 18:00	0.16884			0.18198			0.35											
12/27/22 19:00	0.16788			0.18078			0.35											
12/27/22 20:00	0.16728			0.18042			0.35											
12/27/22 21:00	0.16722			0.18036			0.35											
12/27/22 22:00	0.16704			0.18024			0.35											
12/27/22 23:00	0.1632			0.18312			0.35											
12/28/22 0:00	0.06792			0.20694			0.21											
12/28/22 1:00	0	X		0.18552			0.19											
12/28/22 2:00	0	X		0.18624			0.19											
12/28/22 3:00	0	X		0.18612			0.19											
12/28/22 4:00	0	X		0.18594			0.19											
12/28/22 5:00	0	X		0.18618			0.19											
12/28/22 6:00	0	X		0.18612			0.19											
12/28/22 7:00	0	X		0.1863			0.19											
12/28/22 8:00	0	X		0.18612			0.19											
12/28/22 9:00	0	X		0.18624			0.19											
12/28/22 10:00	0	X		0.18618			0.19											
12/28/22 11:00	0	X		0.18648			0.19											
12/28/22 12:00	0	X		0.18696			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/28/22 13:00	0	X		0.18564			0.19											
12/28/22 14:00	0	X		0.18414			0.18											
12/28/22 15:00	0	X		0.18558			0.19											
12/28/22 16:00	0	X		0.18972			0.19											
12/28/22 17:00	0	X		0.18582			0.19											
12/28/22 18:00	0	X		0.18612			0.19											
12/28/22 19:00	0	X		0.18648			0.19											
12/28/22 20:00	0	X		0.18654			0.19											
12/28/22 21:00	0	X		0.18726			0.19											
12/28/22 22:00	0	X		0.18666			0.19											
12/28/22 23:00	0	X		0.18708			0.19											
12/29/22 0:00	0	X		0.18678			0.19											
12/29/22 1:00	0	X		0.18738			0.19											
12/29/22 2:00	0	X		0.18678			0.19											
12/29/22 3:00	0	X		0.1869			0.19											
12/29/22 4:00	0	X		0.18678			0.19											
12/29/22 5:00	0	X		0.1869			0.19											
12/29/22 6:00	0	X		0.18654			0.19											
12/29/22 7:00	0	X		0.18666			0.19											
12/29/22 8:00	0	X		0.18714			0.19											
12/29/22 9:00	0	X		0.18714			0.19											
12/29/22 10:00	0	X		0.18714			0.19											
12/29/22 11:00	0	X		0.18678			0.19											
12/29/22 12:00	0	X		0.18612			0.19											
12/29/22 13:00	0	X		0.18564			0.19											
12/29/22 14:00	0	X		0.18552			0.19											
12/29/22 15:00	0	X		0.18588			0.19											
12/29/22 16:00	0	X		0.18618			0.19											
12/29/22 17:00	0	X		0.18612			0.19											
12/29/22 18:00	0	X		0.18588			0.19											
12/29/22 19:00	0	X		0.18588			0.19											
12/29/22 20:00	0	X		0.1863			0.19											
12/29/22 21:00	0	X		0.18576			0.19											
12/29/22 22:00	0	X		0.1848			0.18											
12/29/22 23:00	0	X		0.18414			0.18											
12/30/22 0:00	0	X		0.1839			0.18											
12/30/22 1:00	0	X		0.18384			0.18											
12/30/22 2:00	0	X		0.18378			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/30/22 3:00	0	X		0.18432			0.18											
12/30/22 4:00	0	X		0.1845			0.18											
12/30/22 5:00	0	X		0.18396			0.18											
12/30/22 6:00	0	X		0.18438			0.18											
12/30/22 7:00	0	X		0.18426			0.18											
12/30/22 8:00	0	X		0.18402			0.18											
12/30/22 9:00	0	X		0.18366			0.18											
12/30/22 10:00	0	X		0.1842			0.18											
12/30/22 11:00	0	X		0.1839			0.18											
12/30/22 12:00	0	X		0.18426			0.18											
12/30/22 13:00	0	X		0.18426			0.18											
12/30/22 14:00	0	X		0.18462			0.18											
12/30/22 15:00	0	X		0.18498			0.18											
12/30/22 16:00	0	X		0.18516			0.19											
12/30/22 17:00	0	X		0.18564			0.19											
12/30/22 18:00	0	X		0.1857			0.19											
12/30/22 19:00	0	X		0.18636			0.19											
12/30/22 20:00	0	X		0.18756			0.19											
12/30/22 21:00	0	X		0.18822			0.19											
12/30/22 22:00	0	X		0.18846			0.19											
12/30/22 23:00	0	X		0.18852			0.19											
12/31/22 0:00	0	X		0.18834			0.19											
12/31/22 1:00	0	X		0.18828			0.19											
12/31/22 2:00	0	X		0.18828			0.19											
12/31/22 3:00	0	X		0.18792			0.19											
12/31/22 4:00	0	X		0.18768			0.19											
12/31/22 5:00	0	X		0.18774			0.19											
12/31/22 6:00	0	X		0.2106			0.21											
12/31/22 7:00	0	X		0.22116			0.22											
12/31/22 8:00	0	X		0.18828			0.19											
12/31/22 9:00	0	X		0.2034			0.2											
12/31/22 10:00	0	X		0.1233			0.01											
12/31/22 11:00	0	X		0	X		0											
12/31/22 12:00	0	X		0	X		0											
12/31/22 13:00	0	X		0	X		0											
12/31/22 14:00	0	X		0.16338			0.09											
12/31/22 15:00	0	X		0.20976			0.21											
12/31/22 16:00	0	X		0.18612			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/31/22 17:00	0	X		0.1845			0.18											
12/31/22 18:00	0	X		0.18426			0.18											
12/31/22 19:00	0	X		0.18468			0.18											
12/31/22 20:00	0	X		0.18426			0.18											
12/31/22 21:00	0	X		0.18474			0.18											
12/31/22 22:00	0	X		0.18612			0.19											
12/31/22 23:00	0	X		0.1872			0.19											

ATTACHMENT 6

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	4,018.4	0.0	4,018.4	104,400.0	419.5	0.50	0.3	0.8
10/01/2022 01:00	3,829.8	0.0	3,829.8	104,400.0	399.8	0.48	0.2	0.8
10/01/2022 02:00	3,925.9	0.0	3,925.9	104,400.0	409.9	0.49	0.2	0.8
10/01/2022 03:00	4,053.4	0.0	4,053.4	104,400.0	423.2	0.51	0.3	0.8
10/01/2022 04:00	3,930.2	0.0	3,930.2	104,400.0	410.3	0.49	0.2	0.8
10/01/2022 05:00	4,160.8	0.0	4,160.8	104,400.0	434.4	0.52	0.3	0.9
10/01/2022 06:00	3,456.0	0.0	3,456.0	104,400.0	360.8	0.43	0.2	0.7
10/01/2022 07:00	2,632.0	0.0	2,632.0	104,400.0	274.8	0.33	0.2	0.6
10/01/2022 08:00	2,630.9	0.0	2,630.9	104,400.0	274.7	0.33	0.2	0.6
10/01/2022 09:00	2,634.5	0.0	2,634.5	104,400.0	275.0	0.33	0.2	0.6
10/01/2022 10:00	2,638.8	0.0	2,638.8	104,400.0	275.5	0.33	0.2	0.6
10/01/2022 11:00	2,637.2	0.0	2,637.2	104,400.0	275.3	0.33	0.2	0.6
10/01/2022 12:00	2,640.5	0.0	2,640.5	104,400.0	275.7	0.33	0.2	0.6
10/01/2022 13:00	2,679.2	0.0	2,679.2	104,400.0	279.7	0.34	0.2	0.6
10/01/2022 14:00	2,645.3	0.0	2,645.3	104,400.0	276.2	0.33	0.2	0.6
10/01/2022 15:00	2,680.7	0.0	2,680.7	104,400.0	279.9	0.34	0.2	0.6
10/01/2022 16:00	3,644.4	0.0	3,644.4	104,400.0	380.5	0.46	0.2	0.8
10/01/2022 17:00	4,266.0	0.0	4,266.0	104,400.0	445.4	0.53	0.3	0.9
10/01/2022 18:00	4,056.1	0.0	4,056.1	104,400.0	423.5	0.51	0.3	0.8
10/01/2022 19:00	3,842.1	0.0	3,842.1	104,400.0	401.1	0.48	0.2	0.8
10/01/2022 20:00	4,128.2	0.0	4,128.2	104,400.0	431.0	0.52	0.3	0.9
10/01/2022 21:00	3,853.2	0.0	3,853.2	104,400.0	402.3	0.48	0.2	0.8
10/01/2022 22:00	3,118.9	0.0	3,118.9	104,400.0	325.6	0.39	0.2	0.7
10/01/2022 23:00	3,674.9	0.0	3,674.9	104,400.0	383.7	0.46	0.2	0.8
Average/Sum#:	3,407.4	0.0	3,407.4	104,400.0	355.7	0.43	0.2	0.7
Minimum:	2,630.9	0.0	2,630.9	104,400.0	274.7	0.33	0.2	0.6
Maximum:	4,266.0	0.0	4,266.0	104,400.0	445.4	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2022 00:00	3,459.9	0.0	3,459.9	104,400.0	361.2	0.43	0.2	0.7
10/02/2022 01:00	3,386.4	0.0	3,386.4	104,400.0	353.5	0.42	0.2	0.7
10/02/2022 02:00	4,018.9	0.0	4,018.9	104,400.0	419.6	0.50	0.3	0.8
10/02/2022 03:00	4,045.0	0.0	4,045.0	104,400.0	422.3	0.51	0.3	0.8
10/02/2022 04:00	4,237.9	0.0	4,237.9	104,400.0	442.4	0.53	0.3	0.9
10/02/2022 05:00	4,210.2	0.0	4,210.2	104,400.0	439.5	0.53	0.3	0.9
10/02/2022 06:00	3,624.1	0.0	3,624.1	104,400.0	378.4	0.45	0.2	0.8
10/02/2022 07:00	2,645.5	0.0	2,645.5	104,400.0	276.2	0.33	0.2	0.6
10/02/2022 08:00	2,631.3	0.0	2,631.3	104,400.0	274.7	0.33	0.2	0.6
10/02/2022 09:00	2,632.4	0.0	2,632.4	104,400.0	274.8	0.33	0.2	0.6
10/02/2022 10:00	2,633.4	0.0	2,633.4	104,400.0	274.9	0.33	0.2	0.6
10/02/2022 11:00	2,633.6	0.0	2,633.6	104,400.0	274.9	0.33	0.2	0.6
10/02/2022 12:00	2,693.6	0.0	2,693.6	104,400.0	281.2	0.34	0.2	0.6
10/02/2022 13:00	3,237.9	0.0	3,237.9	104,400.0	338.0	0.41	0.2	0.7
10/02/2022 14:00	4,019.5	0.0	4,019.5	104,400.0	419.6	0.50	0.3	0.8
10/02/2022 15:00	3,391.6	0.0	3,391.6	104,400.0	354.1	0.42	0.2	0.7
10/02/2022 16:00	4,147.6	118.1	4,188.9	104,400.0	437.3	0.53	0.3	0.9
10/02/2022 17:00	4,390.9	623.1	5,014.0	104,400.0	523.5	0.63	0.3	1.0
10/02/2022 18:00	4,405.9	565.4	4,971.3	104,400.0	519.0	0.62	0.3	1.0
10/02/2022 19:00	4,433.8	521.8	4,955.6	104,400.0	517.4	0.62	0.3	1.0
10/02/2022 20:00	4,433.8	408.0	4,841.8	104,400.0	505.5	0.61	0.3	1.0
10/02/2022 21:00	3,842.5	1.7	3,842.5	104,400.0	401.2	0.48	0.2	0.8
10/02/2022 22:00	3,433.8	0.0	3,433.8	105,600.0	362.6	0.43	0.2	0.7
10/02/2022 23:00	4,230.1	0.0	4,230.1	105,600.0	446.7	0.54	0.3	0.9
Average/Sum#:	3,617.5	93.3	3,707.5	104,500.0	387.4	0.46	0.2	0.8
Minimum:	2,631.3	0.0	2,631.3	104,400.0	274.7	0.33	0.2	0.6
Maximum:	4,433.8	623.1	5,014.0	105,600.0	523.5	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2022 00:00	4,059.7	0.0	4,059.7	105,600.0	428.7	0.51	0.3	0.9
10/03/2022 01:00	3,999.5	0.0	3,999.5	105,600.0	422.3	0.51	0.3	0.8
10/03/2022 02:00	4,041.2	0.0	4,041.2	105,600.0	426.8	0.51	0.3	0.9
10/03/2022 03:00	4,082.0	0.0	4,082.0	105,600.0	431.1	0.52	0.3	0.9
10/03/2022 04:00	4,199.1	0.0	4,199.1	105,600.0	443.4	0.53	0.3	0.9
10/03/2022 05:00	4,256.9	0.0	4,256.9	105,600.0	449.5	0.54	0.3	0.9
10/03/2022 06:00	3,907.4	0.0	3,907.4	105,600.0	412.6	0.50	0.2	0.8
10/03/2022 07:00	3,039.9	0.0	3,039.9	105,600.0	321.0	0.39	0.2	0.6
10/03/2022 08:00	3,938.2	0.0	3,938.2	105,600.0	415.9	0.50	0.2	0.8
10/03/2022 09:00	2,783.0	0.0	2,783.0	105,600.0	293.9	0.35	0.2	0.6
10/03/2022 10:00	3,114.7	0.0	3,114.7	105,600.0	328.9	0.39	0.2	0.7
10/03/2022 11:00	3,577.6	0.0	3,577.6	105,600.0	377.8	0.45	0.2	0.8
10/03/2022 12:00	4,194.9	0.0	4,194.9	105,600.0	443.0	0.53	0.3	0.9
10/03/2022 13:00	4,220.2	0.0	4,220.2	105,600.0	445.7	0.53	0.3	0.9
10/03/2022 14:00	4,221.7	0.0	4,221.7	105,600.0	445.8	0.53	0.3	0.9
10/03/2022 15:00	4,257.6	0.0	4,257.6	105,600.0	449.6	0.54	0.3	0.9
10/03/2022 16:00	4,125.3	13.8	4,126.3	105,600.0	435.7	0.52	0.3	0.9
10/03/2022 17:00	4,365.9	610.0	4,975.9	105,600.0	525.5	0.63	0.3	1.1
10/03/2022 18:00	4,388.1	606.4	4,994.5	105,600.0	527.4	0.63	0.3	1.1
10/03/2022 19:00	4,415.1	547.0	4,962.1	105,600.0	524.0	0.63	0.3	1.0
10/03/2022 20:00	4,432.2	489.9	4,922.1	105,600.0	519.8	0.62	0.3	1.0
10/03/2022 21:00	4,152.4	160.9	4,236.1	105,600.0	447.3	0.55	0.3	0.9
10/03/2022 22:00	4,190.8	0.0	4,190.8	105,600.0	442.5	0.53	0.3	0.9
10/03/2022 23:00	4,451.6	374.4	4,814.8	105,600.0	508.4	0.61	0.3	1.0
Average/Sum#:	4,017.3	116.8	4,129.8	105,600.0	436.1	0.52	0.3	0.9
Minimum:	2,783.0	0.0	2,783.0	105,600.0	293.9	0.35	0.2	0.6
Maximum:	4,451.6	610.0	4,994.5	105,600.0	527.4	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	4,455.6	385.0	4,840.6	105,600.0	511.2	0.61	0.3	1.0
10/04/2022 01:00	4,462.1	444.4	4,906.5	105,600.0	518.1	0.62	0.3	1.0
10/04/2022 02:00	4,463.1	372.9	4,836.0	105,600.0	510.7	0.61	0.3	1.0
10/04/2022 03:00	4,470.0	375.4	4,845.4	105,600.0	511.7	0.61	0.3	1.0
10/04/2022 04:00	4,480.0	298.1	4,754.3	105,600.0	502.1	0.61	0.3	1.0
10/04/2022 05:00	4,487.7	410.1	4,897.8	105,600.0	517.2	0.62	0.3	1.0
10/04/2022 06:00	4,486.4	290.1	4,756.2	105,600.0	502.3	0.61	0.3	1.0
10/04/2022 07:00	4,408.1	103.7	4,487.9	105,600.0	473.9	0.57	0.3	1.0
10/04/2022 08:00	4,258.3	0.0	4,258.3	105,600.0	449.7	0.54	0.3	0.9
10/04/2022 09:00	4,373.1	192.7	4,463.7	105,600.0	471.4	0.58	0.3	1.0
10/04/2022 10:00	4,446.9	461.4	4,908.3	105,600.0	518.3	0.62	0.3	1.0
10/04/2022 11:00	4,352.3	77.0	4,370.0	105,600.0	461.5	0.56	0.3	0.9
10/04/2022 12:00	4,401.7	728.0	5,129.7	105,600.0	541.7	0.65	0.3	1.1
10/04/2022 13:00	4,380.8	432.4	4,813.2	105,600.0	508.3	0.61	0.3	1.0
10/04/2022 14:00	4,374.2	416.9	4,791.1	105,600.0	505.9	0.61	0.3	1.0
10/04/2022 15:00	4,370.1	572.8	4,942.9	105,600.0	522.0	0.63	0.3	1.0
10/04/2022 16:00	4,366.4	828.9	5,195.3	105,600.0	548.6	0.66	0.3	1.1
10/04/2022 17:00	4,350.9	1,035.6	5,386.5	105,600.0	568.8	0.68	0.3	1.1
10/04/2022 18:00	4,377.8	951.8	5,329.6	105,600.0	562.8	0.68	0.3	1.1
10/04/2022 19:00	4,387.9	863.3	5,251.2	105,600.0	554.5	0.67	0.3	1.1
10/04/2022 20:00	4,400.5	836.9	5,237.4	105,600.0	553.1	0.66	0.3	1.1
10/04/2022 21:00	4,412.7	795.1	5,207.8	105,600.0	549.9	0.66	0.3	1.1
10/04/2022 22:00	4,417.6	574.7	4,992.3	105,600.0	527.2	0.63	0.3	1.1
10/04/2022 23:00	4,420.4	762.9	5,183.3	105,600.0	547.4	0.66	0.3	1.1
Average/Sum#:	4,408.5	508.8	4,907.7	105,600.0	518.3	0.62	0.3	1.0
Minimum:	4,258.3	0.0	4,258.3	105,600.0	449.7	0.54	0.3	0.9
Maximum:	4,487.7	1,035.6	5,386.5	105,600.0	568.8	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2022 00:00	4,430.8	721.9	5,152.7	105,600.0	544.1	0.65	0.3	1.1
10/05/2022 01:00	4,442.0	635.8	5,077.8	105,600.0	536.2	0.64	0.3	1.1
10/05/2022 02:00	4,441.3	651.6	5,092.9	105,600.0	537.8	0.65	0.3	1.1
10/05/2022 03:00	4,443.3	609.8	5,053.1	105,600.0	533.6	0.64	0.3	1.1
10/05/2022 04:00	4,462.2	601.4	5,063.6	105,600.0	534.7	0.64	0.3	1.1
10/05/2022 05:00	4,468.9	579.5	5,048.4	105,600.0	533.1	0.64	0.3	1.1
10/05/2022 06:00	4,462.7	385.0	4,790.0	105,600.0	505.8	0.61	0.3	1.0
10/05/2022 07:00	4,472.6	128.6	4,601.2	105,600.0	485.9	0.58	0.3	1.0
10/05/2022 08:00	4,294.2	83.0	4,337.4	105,600.0	458.0	0.55	0.3	0.9
10/05/2022 09:00	4,110.8	158.7	4,155.2	105,600.0	438.8	0.54	0.3	0.9
10/05/2022 10:00	4,419.5	416.3	4,835.8	105,600.0	510.7	0.61	0.3	1.0
10/05/2022 11:00	4,409.5	426.0	4,835.5	105,600.0	510.6	0.61	0.3	1.0
10/05/2022 12:00	4,393.4	609.5	5,002.9	105,600.0	528.3	0.63	0.3	1.1
10/05/2022 13:00	4,375.2	945.3	5,320.5	105,600.0	561.8	0.67	0.3	1.1
10/05/2022 14:00	4,365.7	1,021.3	5,387.0	105,600.0	568.9	0.68	0.3	1.1
10/05/2022 15:00	4,358.0	848.1	5,206.1	105,600.0	549.8	0.66	0.3	1.1
10/05/2022 16:00	4,351.4	885.1	5,236.5	105,600.0	553.0	0.66	0.3	1.1
10/05/2022 17:00	4,357.6	1,069.7	5,427.3	105,600.0	573.1	0.69	0.3	1.1
10/05/2022 18:00	4,374.1	997.6	5,371.7	105,600.0	567.3	0.68	0.3	1.1
10/05/2022 19:00	4,389.2	907.7	5,296.9	105,600.0	559.4	0.67	0.3	1.1
10/05/2022 20:00	4,411.7	864.5	5,276.2	105,600.0	557.2	0.67	0.3	1.1
10/05/2022 21:00	4,425.2	835.9	5,261.1	105,600.0	555.6	0.67	0.3	1.1
10/05/2022 22:00	4,432.1	610.4	5,042.5	105,600.0	532.5	0.64	0.3	1.1
10/05/2022 23:00	4,299.2	2.1	4,299.2	105,600.0	454.0	0.55	0.3	0.9
Average/Sum#:	4,391.3	624.8	5,007.1	105,600.0	528.8	0.63	0.3	1.1
Minimum:	4,110.8	2.1	4,155.2	105,600.0	438.8	0.54	0.3	0.9
Maximum:	4,472.6	1,069.7	5,427.3	105,600.0	573.1	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2022 00:00	4,291.8	0.0	4,291.8	105,600.0	453.2	0.54	0.3	0.9
10/06/2022 01:00	4,297.8	0.0	4,297.8	105,600.0	453.8	0.54	0.3	0.9
10/06/2022 02:00	4,294.6	0.0	4,294.6	105,600.0	453.5	0.54	0.3	0.9
10/06/2022 03:00	4,284.4	0.0	4,284.4	105,600.0	452.4	0.54	0.3	0.9
10/06/2022 04:00	4,294.2	0.0	4,294.2	105,600.0	453.5	0.54	0.3	0.9
10/06/2022 05:00	4,342.9	54.7	4,354.9	105,600.0	459.9	0.56	0.3	0.9
10/06/2022 06:00	4,484.0	328.6	4,779.7	105,600.0	504.7	0.61	0.3	1.0
10/06/2022 07:00	4,043.9	102.7	4,097.3	105,600.0	432.7	0.53	0.3	0.9
10/06/2022 08:00	2,911.2	0.0	2,911.2	105,600.0	307.4	0.37	0.2	0.6
10/06/2022 09:00	2,764.3	0.0	2,764.3	105,600.0	291.9	0.35	0.2	0.6
10/06/2022 10:00	2,778.6	0.0	2,778.6	105,600.0	293.4	0.35	0.2	0.6
10/06/2022 11:00	3,211.3	0.0	3,211.3	105,600.0	339.1	0.41	0.2	0.7
10/06/2022 12:00	3,679.9	0.0	3,679.9	105,600.0	388.6	0.47	0.2	0.8
10/06/2022 13:00	4,176.0	79.8	4,192.0	105,600.0	442.7	0.54	0.3	0.9
10/06/2022 14:00	4,361.8	772.3	5,134.1	105,600.0	542.2	0.65	0.3	1.1
10/06/2022 15:00	4,348.9	834.3	5,183.2	105,600.0	547.3	0.66	0.3	1.1
10/06/2022 16:00	4,357.0	994.7	5,351.7	105,600.0	565.1	0.68	0.3	1.1
10/06/2022 17:00	4,368.3	1,061.0	5,429.3	105,600.0	573.3	0.69	0.3	1.1
10/06/2022 18:00	4,391.9	974.1	5,366.0	105,600.0	566.6	0.68	0.3	1.1
10/06/2022 19:00	4,403.1	905.3	5,308.4	105,600.0	560.6	0.67	0.3	1.1
10/06/2022 20:00	4,415.3	859.3	5,274.6	105,600.0	557.0	0.67	0.3	1.1
10/06/2022 21:00	4,433.7	772.1	5,205.8	105,600.0	549.7	0.66	0.3	1.1
10/06/2022 22:00	4,469.5	600.4	5,069.9	105,600.0	535.4	0.64	0.3	1.1
10/06/2022 23:00	4,470.4	614.2	5,084.6	105,600.0	536.9	0.64	0.3	1.1
Average/Sum#:	4,078.1	373.1	4,443.3	105,600.0	469.2	0.56	0.3	0.9
Minimum:	2,764.3	0.0	2,764.3	105,600.0	291.9	0.35	0.2	0.6
Maximum:	4,484.0	1,061.0	5,429.3	105,600.0	573.3	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2022 00:00	4,463.9	536.3	5,000.2	105,600.0	528.0	0.63	0.3	1.1
10/07/2022 01:00	4,483.6	480.1	4,963.7	105,600.0	524.2	0.63	0.3	1.0
10/07/2022 02:00	4,497.0	238.5	4,659.2	105,600.0	492.0	0.60	0.3	1.0
10/07/2022 03:00	4,500.4	158.6	4,555.9	105,600.0	481.1	0.59	0.3	1.0
10/07/2022 04:00	4,524.0	463.8	4,955.3	105,600.0	523.3	0.63	0.3	1.1
10/07/2022 05:00	4,531.2	524.4	5,055.6	105,600.0	533.9	0.64	0.3	1.1
10/07/2022 06:00	4,521.9	346.0	4,833.3	105,600.0	510.4	0.62	0.3	1.0
10/07/2022 07:00	4,513.4	202.9	4,716.3	105,600.0	498.0	0.60	0.3	1.0
10/07/2022 08:00	4,505.7	161.1	4,666.8	105,600.0	492.8	0.59	0.3	1.0
10/07/2022 09:00	4,490.5	280.1	4,770.6	105,600.0	503.8	0.60	0.3	1.0
10/07/2022 10:00	4,453.0	801.0	5,254.0	105,600.0	554.8	0.67	0.3	1.1
10/07/2022 11:00	4,434.2	953.2	5,387.4	105,600.0	568.9	0.68	0.3	1.1
10/07/2022 12:00	4,409.1	994.5	5,403.6	105,600.0	570.6	0.68	0.3	1.1
10/07/2022 13:00	4,384.6	799.0	5,183.6	105,600.0	547.4	0.66	0.3	1.1
10/07/2022 14:00	4,364.7	579.7	4,944.4	105,600.0	522.1	0.63	0.3	1.0
10/07/2022 15:00	4,356.9	808.2	5,165.1	105,600.0	545.4	0.65	0.3	1.1
10/07/2022 16:00	4,357.0	957.1	5,314.1	105,600.0	561.2	0.67	0.3	1.1
10/07/2022 17:00	4,364.0	1,077.2	5,441.2	105,600.0	574.6	0.69	0.3	1.1
10/07/2022 18:00	4,376.0	957.1	5,333.1	105,600.0	563.2	0.68	0.3	1.1
10/07/2022 19:00	4,384.9	942.7	5,327.6	105,600.0	562.6	0.68	0.3	1.1
10/07/2022 20:00	4,410.4	861.3	5,271.7	105,600.0	556.7	0.67	0.3	1.1
10/07/2022 21:00	4,427.0	774.3	5,201.3	105,600.0	549.3	0.66	0.3	1.1
10/07/2022 22:00	4,437.8	623.7	5,061.5	105,600.0	534.5	0.64	0.3	1.1
10/07/2022 23:00	4,446.0	651.3	5,097.3	105,600.0	538.3	0.65	0.3	1.1
Average/Sum#:	4,443.2	632.2	5,065.1	105,600.0	534.9	0.64	0.3	1.1
Minimum:	4,356.9	158.6	4,555.9	105,600.0	481.1	0.59	0.3	1.0
Maximum:	4,531.2	1,077.2	5,441.2	105,600.0	574.6	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2022 00:00	4,463.9	635.0	5,098.9	105,600.0	538.4	0.65	0.3	1.1
10/08/2022 01:00	4,481.9	460.6	4,942.5	105,600.0	521.9	0.63	0.3	1.0
10/08/2022 02:00	4,486.0	448.8	4,934.8	105,600.0	521.1	0.63	0.3	1.0
10/08/2022 03:00	4,503.1	449.6	4,952.7	105,600.0	523.0	0.63	0.3	1.0
10/08/2022 04:00	4,510.1	471.3	4,981.4	105,600.0	526.0	0.63	0.3	1.1
10/08/2022 05:00	4,515.9	430.3	4,946.2	105,600.0	522.3	0.63	0.3	1.0
10/08/2022 06:00	4,167.3	119.2	4,229.3	105,600.0	446.6	0.54	0.3	0.9
10/08/2022 07:00	3,147.5	0.0	3,147.5	105,600.0	332.4	0.40	0.2	0.7
10/08/2022 08:00	3,025.2	0.0	3,025.2	105,600.0	319.5	0.38	0.2	0.6
10/08/2022 09:00	3,082.0	0.0	3,082.0	105,600.0	325.5	0.39	0.2	0.7
10/08/2022 10:00	2,779.6	0.0	2,779.6	105,600.0	293.5	0.35	0.2	0.6
10/08/2022 11:00	3,227.4	0.0	3,227.4	105,600.0	340.8	0.41	0.2	0.7
10/08/2022 12:00	3,637.1	1.5	3,637.1	105,600.0	384.1	0.46	0.2	0.8
10/08/2022 13:00	4,304.3	79.4	4,345.6	105,600.0	458.9	0.56	0.3	0.9
10/08/2022 14:00	4,122.2	156.6	4,188.0	105,600.0	442.3	0.54	0.3	0.9
10/08/2022 15:00	4,354.7	789.5	5,144.2	105,600.0	543.2	0.65	0.3	1.1
10/08/2022 16:00	4,354.9	999.8	5,354.7	105,600.0	565.5	0.68	0.3	1.1
10/08/2022 17:00	4,355.8	1,015.8	5,371.6	105,600.0	567.2	0.68	0.3	1.1
10/08/2022 18:00	4,378.3	903.4	5,281.7	105,600.0	557.7	0.67	0.3	1.1
10/08/2022 19:00	4,378.0	905.7	5,283.7	105,600.0	558.0	0.67	0.3	1.1
10/08/2022 20:00	4,398.0	854.4	5,252.4	105,600.0	554.7	0.67	0.3	1.1
10/08/2022 21:00	4,416.0	603.6	4,947.2	105,600.0	522.4	0.64	0.3	1.1
10/08/2022 22:00	3,624.5	175.3	3,682.3	105,600.0	388.9	0.48	0.2	0.8
10/08/2022 23:00	4,437.0	78.8	4,486.6	105,600.0	473.8	0.57	0.3	1.0
Average/Sum#:	4,047.9	399.1	4,430.1	105,600.0	467.8	0.56	0.3	0.9
Minimum:	2,779.6	0.0	2,779.6	105,600.0	293.5	0.35	0.2	0.6
Maximum:	4,515.9	1,015.8	5,371.6	105,600.0	567.2	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2022 00:00	4,458.2	127.5	4,585.7	105,600.0	484.2	0.58	0.3	1.0
10/09/2022 01:00	4,464.3	128.2	4,592.5	105,600.0	485.0	0.58	0.3	1.0
10/09/2022 02:00	4,473.6	127.2	4,600.8	105,600.0	485.8	0.58	0.3	1.0
10/09/2022 03:00	4,479.2	129.1	4,608.3	105,600.0	486.6	0.58	0.3	1.0
10/09/2022 04:00	4,490.9	130.8	4,621.7	105,600.0	488.1	0.59	0.3	1.0
10/09/2022 05:00	4,493.3	130.2	4,623.5	105,600.0	488.2	0.59	0.3	1.0
10/09/2022 06:00	4,505.8	126.7	4,632.5	105,600.0	489.2	0.59	0.3	1.0
10/09/2022 07:00	4,508.2	125.9	4,634.1	105,600.0	489.4	0.59	0.3	1.0
10/09/2022 08:00	4,492.7	124.1	4,616.8	105,600.0	487.5	0.58	0.3	1.0
10/09/2022 09:00	4,476.0	121.9	4,597.9	105,600.0	485.5	0.58	0.3	1.0
10/09/2022 10:00	4,460.0	119.4	4,579.4	105,600.0	483.6	0.58	0.3	1.0
10/09/2022 11:00	4,434.5	119.7	4,554.2	105,600.0	480.9	0.58	0.3	1.0
10/09/2022 12:00	4,409.3	149.3	4,558.6	105,600.0	481.4	0.58	0.3	1.0
10/09/2022 13:00	4,389.4	190.8	4,580.2	105,600.0	483.7	0.58	0.3	1.0
10/09/2022 14:00	4,372.4	206.0	4,578.4	105,600.0	483.5	0.58	0.3	1.0
10/09/2022 15:00	4,365.0	228.9	4,593.9	105,600.0	485.1	0.58	0.3	1.0
10/09/2022 16:00	4,361.3	232.4	4,593.7	105,600.0	485.1	0.58	0.3	1.0
10/09/2022 17:00	4,375.5	214.9	4,590.4	105,600.0	484.7	0.58	0.3	1.0
10/09/2022 18:00	4,395.0	170.0	4,565.0	105,600.0	482.1	0.58	0.3	1.0
10/09/2022 19:00	4,406.2	132.9	4,539.1	105,600.0	479.3	0.58	0.3	1.0
10/09/2022 20:00	4,406.0	129.0	4,535.0	105,600.0	478.9	0.57	0.3	1.0
10/09/2022 21:00	4,419.6	126.4	4,546.0	105,600.0	480.1	0.58	0.3	1.0
10/09/2022 22:00	4,434.0	125.8	4,559.8	105,600.0	481.5	0.58	0.3	1.0
10/09/2022 23:00	4,444.5	126.6	4,571.1	105,600.0	482.7	0.58	0.3	1.0
Average/Sum#:	4,438.1	147.7	4,585.8	105,600.0	484.3	0.58	0.3	1.0
Minimum:	4,361.3	119.4	4,535.0	105,600.0	478.9	0.57	0.3	1.0
Maximum:	4,508.2	232.4	4,634.1	105,600.0	489.4	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2022 00:00	4,462.0	126.9	4,588.9	105,600.0	484.6	0.58	0.3	1.0
10/10/2022 01:00	4,469.7	126.5	4,596.2	105,600.0	485.4	0.58	0.3	1.0
10/10/2022 02:00	4,470.4	127.0	4,597.4	105,600.0	485.5	0.58	0.3	1.0
10/10/2022 03:00	4,478.0	129.3	4,607.3	105,600.0	486.5	0.58	0.3	1.0
10/10/2022 04:00	4,493.5	129.3	4,622.8	105,600.0	488.2	0.59	0.3	1.0
10/10/2022 05:00	4,507.5	338.6	4,846.1	105,600.0	511.7	0.62	0.3	1.0
10/10/2022 06:00	4,518.3	404.4	4,922.7	105,600.0	519.8	0.62	0.3	1.0
10/10/2022 07:00	4,505.0	125.3	4,630.3	105,600.0	489.0	0.59	0.3	1.0
10/10/2022 08:00	4,478.7	124.7	4,603.4	105,600.0	486.1	0.58	0.3	1.0
10/10/2022 09:00	4,459.2	160.1	4,619.3	105,600.0	487.8	0.59	0.3	1.0
10/10/2022 10:00	4,415.8	57.2	4,435.8	105,600.0	468.4	0.57	0.3	0.9
10/10/2022 11:00	2,836.3	0.0	2,836.3	105,600.0	299.5	0.36	0.2	0.6
10/10/2022 12:00	2,743.2	0.0	2,743.2	105,600.0	289.7	0.35	0.2	0.6
10/10/2022 13:00	2,745.8	0.0	2,745.8	105,600.0	290.0	0.35	0.2	0.6
10/10/2022 14:00	2,745.7	0.0	2,745.7	105,600.0	289.9	0.35	0.2	0.6
10/10/2022 15:00	3,708.2	96.8	3,742.1	105,600.0	395.2	0.48	0.2	0.8
10/10/2022 16:00	4,358.1	1,014.8	5,372.9	105,600.0	567.4	0.68	0.3	1.1
10/10/2022 17:00	4,366.4	830.3	5,196.7	105,600.0	548.8	0.66	0.3	1.1
10/10/2022 18:00	4,386.2	185.0	4,571.2	105,600.0	482.7	0.58	0.3	1.0
10/10/2022 19:00	4,395.2	161.0	4,556.2	105,600.0	481.1	0.58	0.3	1.0
10/10/2022 20:00	4,407.5	130.7	4,538.2	105,600.0	479.2	0.58	0.3	1.0
10/10/2022 21:00	4,417.9	124.9	4,542.8	105,600.0	479.7	0.58	0.3	1.0
10/10/2022 22:00	4,435.8	125.2	4,561.0	105,600.0	481.6	0.58	0.3	1.0
10/10/2022 23:00	4,429.0	60.0	4,457.8	105,600.0	470.7	0.57	0.3	0.9
Average/Sum#:	4,134.7	190.8	4,320.0	105,600.0	456.2	0.55	0.3	0.9
Minimum:	2,743.2	0.0	2,743.2	105,600.0	289.7	0.35	0.2	0.6
Maximum:	4,518.3	1,014.8	5,372.9	105,600.0	567.4	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2022 00:00	2,841.5	0.0	2,841.5	105,600.0	300.1	0.36	0.2	0.6
10/11/2022 01:00	2,748.1	0.0	2,748.1	105,600.0	290.2	0.35	0.2	0.6
10/11/2022 02:00	2,752.8	0.0	2,752.8	105,600.0	290.7	0.35	0.2	0.6
10/11/2022 03:00	2,762.5	0.0	2,762.5	105,600.0	291.7	0.35	0.2	0.6
10/11/2022 04:00	2,762.8	0.0	2,762.8	105,600.0	291.8	0.35	0.2	0.6
10/11/2022 05:00	2,760.5	0.0	2,760.5	105,600.0	291.5	0.35	0.2	0.6
10/11/2022 06:00	2,761.8	0.0	2,761.8	105,600.0	291.6	0.35	0.2	0.6
10/11/2022 07:00	2,762.0	0.0	2,762.0	105,600.0	291.7	0.35	0.2	0.6
10/11/2022 08:00	2,753.7	0.0	2,753.7	105,600.0	290.8	0.35	0.2	0.6
10/11/2022 09:00	2,760.4	0.0	2,760.4	105,600.0	291.5	0.35	0.2	0.6
10/11/2022 10:00	2,773.1	0.0	2,773.1	105,600.0	292.8	0.35	0.2	0.6
10/11/2022 11:00	2,765.1	0.0	2,765.1	105,600.0	292.0	0.35	0.2	0.6
10/11/2022 12:00	2,751.4	0.0	2,751.4	105,600.0	290.5	0.35	0.2	0.6
10/11/2022 13:00	2,729.5	0.0	2,729.5	105,600.0	288.2	0.35	0.2	0.6
10/11/2022 14:00	2,722.5	0.0	2,722.5	105,600.0	287.5	0.34	0.2	0.6
10/11/2022 15:00	3,708.4	78.5	3,743.7	105,600.0	395.3	0.48	0.2	0.8
10/11/2022 16:00	4,373.9	206.3	4,580.2	105,600.0	483.7	0.58	0.3	1.0
10/11/2022 17:00	4,386.8	172.9	4,559.7	105,600.0	481.5	0.58	0.3	1.0
10/11/2022 18:00	4,400.5	130.9	4,531.4	105,600.0	478.5	0.57	0.3	1.0
10/11/2022 19:00	4,419.5	127.7	4,547.2	105,600.0	480.2	0.58	0.3	1.0
10/11/2022 20:00	4,448.4	127.8	4,576.2	105,600.0	483.2	0.58	0.3	1.0
10/11/2022 21:00	4,457.4	127.9	4,585.3	105,600.0	484.2	0.58	0.3	1.0
10/11/2022 22:00	4,471.0	126.1	4,597.1	105,600.0	485.5	0.58	0.3	1.0
10/11/2022 23:00	4,482.0	126.1	4,608.1	105,600.0	486.6	0.58	0.3	1.0
Average/Sum#:	3,356.5	51.0	3,405.7	105,600.0	359.6	0.43	0.2	0.7
Minimum:	2,722.5	0.0	2,722.5	105,600.0	287.5	0.34	0.2	0.6
Maximum:	4,482.0	206.3	4,608.1	105,600.0	486.6	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	4,482.9	125.8	4,608.7	105,600.0	486.7	0.58	0.3	1.0
10/12/2022 01:00	4,488.9	126.2	4,615.1	105,600.0	487.4	0.58	0.3	1.0
10/12/2022 02:00	4,493.2	125.9	4,619.1	105,600.0	487.8	0.59	0.3	1.0
10/12/2022 03:00	4,506.0	127.4	4,633.4	105,600.0	489.3	0.59	0.3	1.0
10/12/2022 04:00	4,510.6	128.5	4,639.1	105,600.0	489.9	0.59	0.3	1.0
10/12/2022 05:00	4,518.1	129.2	4,647.3	105,600.0	490.8	0.59	0.3	1.0
10/12/2022 06:00	4,516.7	128.7	4,645.4	105,600.0	490.6	0.59	0.3	1.0
10/12/2022 07:00	4,048.8	32.8	4,057.7	105,600.0	428.5	0.52	0.3	0.9
10/12/2022 08:00	2,755.4	0.0	2,755.4	105,600.0	291.0	0.35	0.2	0.6
10/12/2022 09:00	2,758.1	0.0	2,758.1	105,600.0	291.3	0.35	0.2	0.6
10/12/2022 10:00	2,750.2	0.0	2,750.2	105,600.0	290.4	0.35	0.2	0.6
10/12/2022 11:00	2,745.1	0.0	2,745.1	105,600.0	289.9	0.35	0.2	0.6
10/12/2022 12:00	2,734.9	0.0	2,734.9	105,600.0	288.8	0.35	0.2	0.6
10/12/2022 13:00	2,740.6	0.0	2,740.6	105,600.0	289.4	0.35	0.2	0.6
10/12/2022 14:00	2,734.8	0.0	2,734.8	105,600.0	288.8	0.35	0.2	0.6
10/12/2022 15:00	2,743.8	0.0	2,743.8	105,600.0	289.7	0.35	0.2	0.6
10/12/2022 16:00	2,751.0	0.0	2,751.0	105,600.0	290.5	0.35	0.2	0.6
10/12/2022 17:00	2,751.1	0.0	2,751.1	105,600.0	290.5	0.35	0.2	0.6
10/12/2022 18:00	2,740.8	0.0	2,740.8	105,600.0	289.4	0.35	0.2	0.6
10/12/2022 19:00	2,734.1	0.0	2,734.1	105,600.0	288.7	0.35	0.2	0.6
10/12/2022 20:00	2,730.6	0.0	2,730.6	105,600.0	288.4	0.35	0.2	0.6
10/12/2022 21:00	2,733.9	0.0	2,733.9	105,600.0	288.7	0.35	0.2	0.6
10/12/2022 22:00	2,750.6	0.0	2,750.6	105,600.0	290.5	0.35	0.2	0.6
10/12/2022 23:00	2,742.8	0.0	2,742.8	105,600.0	289.6	0.35	0.2	0.6
Average/Sum#:	3,311.0	38.5	3,348.5	105,600.0	353.6	0.43	0.2	0.7
Minimum:	2,730.6	0.0	2,730.6	105,600.0	288.4	0.35	0.2	0.6
Maximum:	4,518.1	129.2	4,647.3	105,600.0	490.8	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2022 00:00	2,739.8	0.0	2,739.8	105,600.0	289.3	0.35	0.2	0.6
10/13/2022 01:00	2,738.2	0.0	2,738.2	105,600.0	289.2	0.35	0.2	0.6
10/13/2022 02:00	2,733.1	0.0	2,733.1	105,600.0	288.6	0.35	0.2	0.6
10/13/2022 03:00	2,731.9	0.0	2,731.9	105,600.0	288.5	0.35	0.2	0.6
10/13/2022 04:00	2,732.7	0.0	2,732.7	105,600.0	288.6	0.35	0.2	0.6
10/13/2022 05:00	2,742.7	0.0	2,742.7	105,600.0	289.6	0.35	0.2	0.6
10/13/2022 06:00	3,523.8	0.0	3,523.8	105,600.0	372.1	0.45	0.2	0.7
10/13/2022 07:00	2,738.4	0.0	2,738.4	105,600.0	289.2	0.35	0.2	0.6
10/13/2022 08:00	2,738.6	0.0	2,738.6	105,600.0	289.2	0.35	0.2	0.6
10/13/2022 09:00	2,748.9	0.0	2,748.9	105,600.0	290.3	0.35	0.2	0.6
10/13/2022 10:00	2,758.7	0.0	2,758.7	105,600.0	291.3	0.35	0.2	0.6
10/13/2022 11:00	2,733.6	0.0	2,733.6	105,600.0	288.7	0.35	0.2	0.6
10/13/2022 12:00	2,728.2	0.0	2,728.2	105,600.0	288.1	0.35	0.2	0.6
10/13/2022 13:00	2,724.5	0.0	2,724.5	105,600.0	287.7	0.35	0.2	0.6
10/13/2022 14:00	2,725.1	0.0	2,725.1	105,600.0	287.8	0.35	0.2	0.6
10/13/2022 15:00	3,723.2	51.8	3,737.2	105,600.0	394.6	0.48	0.2	0.8
10/13/2022 16:00	4,401.7	331.9	4,733.6	105,600.0	499.9	0.60	0.3	1.0
10/13/2022 17:00	4,409.2	135.7	4,544.9	105,600.0	479.9	0.58	0.3	1.0
10/13/2022 18:00	4,423.6	126.7	4,550.3	105,600.0	480.5	0.58	0.3	1.0
10/13/2022 19:00	4,444.9	125.6	4,570.5	105,600.0	482.6	0.58	0.3	1.0
10/13/2022 20:00	4,440.4	128.1	4,568.5	105,600.0	482.4	0.58	0.3	1.0
10/13/2022 21:00	4,445.1	124.7	4,569.8	105,600.0	482.6	0.58	0.3	1.0
10/13/2022 22:00	4,449.9	125.6	4,575.5	105,600.0	483.2	0.58	0.3	1.0
10/13/2022 23:00	4,454.6	126.1	4,580.7	105,600.0	483.7	0.58	0.3	1.0
Average/Sum#:	3,376.3	53.2	3,427.9	105,600.0	362.0	0.44	0.2	0.7
Minimum:	2,724.5	0.0	2,724.5	105,600.0	287.7	0.35	0.2	0.6
Maximum:	4,454.6	331.9	4,733.6	105,600.0	499.9	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	4,467.6	127.0	4,594.6	105,600.0	485.2	0.58	0.3	1.0
10/14/2022 01:00	4,477.7	127.5	4,605.2	105,600.0	486.3	0.58	0.3	1.0
10/14/2022 02:00	4,480.3	129.5	4,609.8	105,600.0	486.8	0.58	0.3	1.0
10/14/2022 03:00	4,489.1	131.3	4,620.4	105,600.0	487.9	0.59	0.3	1.0
10/14/2022 04:00	4,494.2	131.1	4,625.3	105,600.0	488.4	0.59	0.3	1.0
10/14/2022 05:00	4,509.7	131.7	4,641.4	105,600.0	490.1	0.59	0.3	1.0
10/14/2022 06:00	4,517.8	133.4	4,651.2	105,600.0	491.2	0.59	0.3	1.0
10/14/2022 07:00	4,274.2	66.7	4,308.9	105,600.0	455.0	0.55	0.3	0.9
10/14/2022 08:00	2,745.6	0.0	2,745.6	105,600.0	289.9	0.35	0.2	0.6
10/14/2022 09:00	2,754.1	0.0	2,754.1	105,600.0	290.8	0.35	0.2	0.6
10/14/2022 10:00	2,762.9	0.0	2,762.9	105,600.0	291.8	0.35	0.2	0.6
10/14/2022 11:00	2,763.2	0.0	2,763.2	105,600.0	291.8	0.35	0.2	0.6
10/14/2022 12:00	2,742.6	0.0	2,742.6	105,600.0	289.6	0.35	0.2	0.6
10/14/2022 13:00	2,740.4	0.0	2,740.4	105,600.0	289.4	0.35	0.2	0.6
10/14/2022 14:00	2,740.6	0.0	2,740.6	105,600.0	289.4	0.35	0.2	0.6
10/14/2022 15:00	2,743.3	0.0	2,743.3	105,600.0	289.7	0.35	0.2	0.6
10/14/2022 16:00	3,715.9	87.5	3,755.3	105,600.0	396.6	0.48	0.2	0.8
10/14/2022 17:00	4,390.1	191.7	4,581.8	105,600.0	483.8	0.58	0.3	1.0
10/14/2022 18:00	4,415.6	139.9	4,555.5	105,600.0	481.1	0.58	0.3	1.0
10/14/2022 19:00	4,426.1	157.6	4,583.7	105,600.0	484.0	0.58	0.3	1.0
10/14/2022 20:00	4,415.7	184.9	4,600.6	105,600.0	485.8	0.58	0.3	1.0
10/14/2022 21:00	4,415.6	161.0	4,576.6	105,600.0	483.3	0.58	0.3	1.0
10/14/2022 22:00	4,425.0	136.9	4,561.9	105,600.0	481.7	0.58	0.3	1.0
10/14/2022 23:00	4,436.1	126.4	4,562.5	105,600.0	481.8	0.58	0.3	1.0
Average/Sum#:	3,847.6	90.2	3,934.5	105,600.0	415.5	0.50	0.3	0.9
Minimum:	2,740.4	0.0	2,740.4	105,600.0	289.4	0.35	0.2	0.6
Maximum:	4,517.8	191.7	4,651.2	105,600.0	491.2	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2022 00:00	4,453.3	126.3	4,579.6	105,600.0	483.6	0.58	0.3	1.0
10/15/2022 01:00	4,448.9	95.2	4,522.2	105,600.0	477.5	0.57	0.3	1.0
10/15/2022 02:00	4,360.8	0.0	4,360.8	105,600.0	460.5	0.55	0.3	0.9
10/15/2022 03:00	4,259.4	16.0	4,261.5	105,600.0	450.0	0.54	0.3	0.9
10/15/2022 04:00	4,481.6	129.4	4,611.0	105,600.0	486.9	0.58	0.3	1.0
10/15/2022 05:00	4,490.0	128.8	4,618.8	105,600.0	487.7	0.59	0.3	1.0
10/15/2022 06:00	4,472.2	69.0	4,510.2	105,600.0	476.3	0.58	0.3	1.0
10/15/2022 07:00	3,128.6	0.0	3,128.6	105,600.0	330.4	0.40	0.2	0.7
10/15/2022 08:00	2,743.6	0.0	2,743.6	105,600.0	289.7	0.35	0.2	0.6
10/15/2022 09:00	2,744.1	0.0	2,744.1	105,600.0	289.8	0.35	0.2	0.6
10/15/2022 10:00	2,748.6	0.0	2,748.6	105,600.0	290.3	0.35	0.2	0.6
10/15/2022 11:00	2,744.7	0.0	2,744.7	105,600.0	289.8	0.35	0.2	0.6
10/15/2022 12:00	2,722.8	0.0	2,722.8	105,600.0	287.5	0.35	0.2	0.6
10/15/2022 13:00	2,723.0	0.0	2,723.0	105,600.0	287.5	0.35	0.2	0.6
10/15/2022 14:00	2,722.2	0.0	2,722.2	105,600.0	287.5	0.35	0.2	0.6
10/15/2022 15:00	2,721.3	0.0	2,721.3	105,600.0	287.4	0.34	0.2	0.6
10/15/2022 16:00	2,721.5	0.0	2,721.5	105,600.0	287.4	0.35	0.2	0.6
10/15/2022 17:00	2,722.0	0.0	2,722.0	105,600.0	287.4	0.35	0.2	0.6
10/15/2022 18:00	2,744.7	0.0	2,744.7	105,600.0	289.8	0.35	0.2	0.6
10/15/2022 19:00	2,726.9	0.0	2,726.9	105,600.0	288.0	0.35	0.2	0.6
10/15/2022 20:00	2,722.9	0.0	2,722.9	105,600.0	287.5	0.34	0.2	0.6
10/15/2022 21:00	2,740.0	0.0	2,740.0	105,600.0	289.3	0.35	0.2	0.6
10/15/2022 22:00	2,747.5	0.0	2,747.5	105,600.0	290.1	0.35	0.2	0.6
10/15/2022 23:00	2,749.4	0.0	2,749.4	105,600.0	290.3	0.35	0.2	0.6
Average/Sum#:	3,243.3	23.5	3,264.1	105,600.0	344.7	0.42	0.2	0.7
Minimum:	2,721.3	0.0	2,721.3	105,600.0	287.4	0.34	0.2	0.6
Maximum:	4,490.0	129.4	4,618.8	105,600.0	487.7	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2022 00:00	2,751.3	0.0	2,751.3	105,600.0	290.5	0.35	0.2	0.6
10/16/2022 01:00	2,758.2	0.0	2,758.2	105,600.0	291.3	0.35	0.2	0.6
10/16/2022 02:00	2,752.3	0.0	2,752.3	105,600.0	290.6	0.35	0.2	0.6
10/16/2022 03:00	2,752.8	0.0	2,752.8	105,600.0	290.7	0.35	0.2	0.6
10/16/2022 04:00	2,760.7	0.0	2,760.7	105,600.0	291.5	0.35	0.2	0.6
10/16/2022 05:00	2,764.2	0.0	2,764.2	105,600.0	291.9	0.35	0.2	0.6
10/16/2022 06:00	2,803.2	0.0	2,803.2	105,600.0	296.0	0.36	0.2	0.6
10/16/2022 07:00	2,741.3	0.0	2,741.3	105,600.0	289.5	0.35	0.2	0.6
10/16/2022 08:00	2,754.4	0.0	2,754.4	105,600.0	290.9	0.35	0.2	0.6
10/16/2022 09:00	3,143.7	0.0	3,143.7	105,600.0	332.0	0.40	0.2	0.7
10/16/2022 10:00	4,467.4	23.3	4,472.1	105,600.0	472.3	0.57	0.3	0.9
10/16/2022 11:00	4,492.2	124.1	4,616.3	105,600.0	487.5	0.59	0.3	1.0
10/16/2022 12:00	4,484.4	123.0	4,607.4	105,600.0	486.5	0.58	0.3	1.0
10/16/2022 13:00	4,477.7	121.8	4,599.5	105,600.0	485.7	0.58	0.3	1.0
10/16/2022 14:00	4,469.1	123.2	4,592.3	105,600.0	484.9	0.58	0.3	1.0
10/16/2022 15:00	4,469.2	124.5	4,593.7	105,600.0	485.1	0.58	0.3	1.0
10/16/2022 16:00	4,477.3	125.6	4,602.9	105,600.0	486.1	0.58	0.3	1.0
10/16/2022 17:00	4,489.7	127.2	4,616.9	105,600.0	487.5	0.59	0.3	1.0
10/16/2022 18:00	4,506.0	127.4	4,633.4	105,600.0	489.3	0.59	0.3	1.0
10/16/2022 19:00	4,515.5	127.2	4,642.7	105,600.0	490.3	0.59	0.3	1.0
10/16/2022 20:00	4,520.2	126.9	4,647.1	105,600.0	490.7	0.59	0.3	1.0
10/16/2022 21:00	4,521.9	127.8	4,649.7	105,600.0	491.0	0.59	0.3	1.0
10/16/2022 22:00	4,526.1	128.0	4,654.1	105,600.0	491.5	0.59	0.3	1.0
10/16/2022 23:00	4,527.0	128.2	4,655.2	105,600.0	491.6	0.59	0.3	1.0
Average/Sum#:	3,788.6	69.1	3,856.9	105,600.0	407.3	0.49	0.3	0.8
Minimum:	2,741.3	0.0	2,741.3	105,600.0	289.5	0.35	0.2	0.6
Maximum:	4,527.0	128.2	4,655.2	105,600.0	491.6	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2022 00:00	4,530.6	127.7	4,658.3	105,600.0	491.9	0.59	0.3	1.0
10/17/2022 01:00	4,476.7	74.7	4,521.5	105,600.0	477.5	0.58	0.3	1.0
10/17/2022 02:00	4,336.3	0.0	4,336.3	105,600.0	457.9	0.55	0.3	0.9
10/17/2022 03:00	4,312.9	0.0	4,312.9	105,600.0	455.4	0.55	0.3	0.9
10/17/2022 04:00	4,411.4	49.4	4,429.7	105,600.0	467.8	0.57	0.3	0.9
10/17/2022 05:00	4,570.0	149.2	4,719.2	105,600.0	498.3	0.60	0.3	1.0
10/17/2022 06:00	4,583.8	132.6	4,716.4	105,600.0	498.1	0.60	0.3	1.0
10/17/2022 07:00	4,531.9	104.2	4,612.1	105,600.0	487.0	0.59	0.3	1.0
10/17/2022 08:00	4,187.0	114.8	4,250.1	105,600.0	448.8	0.54	0.3	0.9
10/17/2022 09:00	4,478.4	126.0	4,604.4	105,600.0	486.2	0.58	0.3	1.0
10/17/2022 10:00	4,431.0	128.1	4,559.1	105,600.0	481.4	0.58	0.3	1.0
10/17/2022 11:00	4,392.5	191.5	4,584.0	105,600.0	484.1	0.58	0.3	1.0
10/17/2022 12:00	4,349.9	259.9	4,609.8	105,600.0	486.8	0.58	0.3	1.0
10/17/2022 13:00	4,348.9	226.3	4,575.2	105,600.0	483.1	0.58	0.3	1.0
10/17/2022 14:00	4,317.1	284.1	4,601.2	105,600.0	485.9	0.58	0.3	1.0
10/17/2022 15:00	4,305.9	315.9	4,621.8	105,600.0	488.1	0.59	0.3	1.0
10/17/2022 16:00	4,307.9	303.8	4,611.7	105,600.0	487.0	0.58	0.3	1.0
10/17/2022 17:00	4,334.0	257.7	4,591.7	105,600.0	484.9	0.58	0.3	1.0
10/17/2022 18:00	4,352.7	214.7	4,567.4	105,600.0	482.3	0.58	0.3	1.0
10/17/2022 19:00	4,393.9	154.4	4,548.3	105,600.0	480.3	0.58	0.3	1.0
10/17/2022 20:00	4,439.0	133.6	4,572.6	105,600.0	482.9	0.58	0.3	1.0
10/17/2022 21:00	4,443.8	128.5	4,572.3	105,600.0	482.8	0.58	0.3	1.0
10/17/2022 22:00	4,471.4	251.6	4,723.0	105,600.0	498.7	0.60	0.3	1.0
10/17/2022 23:00	4,502.7	346.3	4,849.0	105,600.0	512.1	0.62	0.3	1.0
Average/Sum#:	4,408.7	169.8	4,572.8	105,600.0	482.9	0.58	0.3	1.0
Minimum:	4,187.0	0.0	4,250.1	105,600.0	448.8	0.54	0.3	0.9
Maximum:	4,583.8	346.3	4,849.0	105,600.0	512.1	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2022 00:00	4,502.9	128.1	4,631.0	105,600.0	489.0	0.59	0.3	1.0
10/18/2022 01:00	4,501.6	130.0	4,631.6	105,600.0	489.1	0.59	0.3	1.0
10/18/2022 02:00	4,514.3	130.4	4,644.7	105,600.0	490.5	0.59	0.3	1.0
10/18/2022 03:00	4,526.8	181.0	4,707.8	105,600.0	497.1	0.60	0.3	1.0
10/18/2022 04:00	4,524.8	370.6	4,895.4	105,600.0	517.0	0.62	0.3	1.0
10/18/2022 05:00	4,548.2	526.2	5,074.4	105,600.0	535.9	0.64	0.3	1.1
10/18/2022 06:00	4,550.8	848.6	5,399.4	105,600.0	570.2	0.68	0.3	1.1
10/18/2022 07:00	4,537.3	294.3	4,752.1	105,600.0	501.8	0.61	0.3	1.0
10/18/2022 08:00	4,514.7	125.8	4,640.5	105,600.0	490.0	0.59	0.3	1.0
10/18/2022 09:00	4,415.5	204.0	4,619.5	105,600.0	487.8	0.59	0.3	1.0
10/18/2022 10:00	4,340.5	344.1	4,684.6	105,600.0	494.7	0.59	0.3	1.0
10/18/2022 11:00	4,301.7	403.4	4,705.1	105,600.0	496.9	0.60	0.3	1.0
10/18/2022 12:00	4,368.7	296.5	4,665.2	105,600.0	492.6	0.59	0.3	1.0
10/18/2022 13:00	4,376.2	153.3	4,488.1	105,600.0	473.9	0.58	0.3	1.0
10/18/2022 14:00	3,235.3	17.5	3,237.9	105,600.0	341.9	0.41	0.2	0.7
10/18/2022 15:00	3,127.8	12.7	3,129.3	105,600.0	330.5	0.40	0.2	0.7
10/18/2022 16:00	4,254.2	378.4	4,443.4	105,600.0	469.2	0.59	0.3	1.0
10/18/2022 17:00	4,461.4	1,203.5	5,664.9	105,600.0	598.2	0.72	0.4	1.2
10/18/2022 18:00	4,464.1	1,049.1	5,513.2	105,600.0	582.2	0.70	0.3	1.2
10/18/2022 19:00	4,471.2	1,565.7	6,036.9	105,600.0	637.5	0.77	0.4	1.3
10/18/2022 20:00	4,499.3	1,081.0	5,580.3	105,600.0	589.3	0.71	0.4	1.2
10/18/2022 21:00	4,513.2	894.9	5,408.1	105,600.0	571.1	0.68	0.3	1.1
10/18/2022 22:00	4,514.9	542.1	5,057.0	105,600.0	534.0	0.64	0.3	1.1
10/18/2022 23:00	4,311.6	1.8	4,311.6	105,600.0	455.3	0.55	0.3	0.9
Average/Sum#:	4,349.0	453.5	4,788.4	105,600.0	505.7	0.61	0.3	1.0
Minimum:	3,127.8	1.8	3,129.3	105,600.0	330.5	0.40	0.2	0.7
Maximum:	4,550.8	1,565.7	6,036.9	105,600.0	637.5	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	4,310.1	0.0	4,310.1	105,600.0	455.1	0.55	0.3	0.9
10/19/2022 01:00	4,152.7	0.0	4,152.7	105,600.0	438.5	0.53	0.3	0.9
10/19/2022 02:00	3,959.5	0.0	3,959.5	105,600.0	418.1	0.50	0.3	0.8
10/19/2022 03:00	4,130.0	0.0	4,130.0	105,600.0	436.1	0.52	0.3	0.9
10/19/2022 04:00	4,286.3	0.0	4,286.3	105,600.0	452.6	0.54	0.3	0.9
10/19/2022 05:00	4,302.8	0.0	4,302.8	105,600.0	454.4	0.55	0.3	0.9
10/19/2022 06:00	3,692.9	0.0	3,692.9	105,600.0	390.0	0.47	0.2	0.8
10/19/2022 07:00	2,644.7	0.0	2,644.7	105,600.0	279.3	0.34	0.2	0.6
10/19/2022 08:00	2,482.3	0.0	2,482.3	105,600.0	262.1	0.34	0.2	0.6
10/19/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.00	0.0	0.0
10/19/2022 16:00	2,392.2	0.0	2,392.2	105,600.0	252.6	0.34	0.2	0.6
10/19/2022 17:00	3,498.3	0.0	3,498.3	105,600.0	369.4	0.44	0.2	0.7
10/19/2022 18:00	4,431.8	132.4	4,560.2	105,600.0	481.6	0.58	0.3	1.0
10/19/2022 19:00	4,457.9	259.2	4,717.1	105,600.0	498.1	0.60	0.3	1.0
10/19/2022 20:00	4,467.2	404.1	4,871.3	105,600.0	514.4	0.62	0.3	1.0
10/19/2022 21:00	4,427.9	276.1	4,640.5	105,600.0	490.0	0.60	0.3	1.0
10/19/2022 22:00	3,255.4	0.0	3,255.4	105,600.0	343.8	0.41	0.2	0.7
10/19/2022 23:00	3,844.7	0.0	3,844.7	105,600.0	406.0	0.49	0.2	0.8
Average/Sum#:	3,808.0	63.0	3,867.1	105,600.0	408.4	0.50	0.3	0.8
Minimum:	2,392.2	0.0	2,392.2	105,600.0	252.6	0.34	0.2	0.6
Maximum:	4,467.2	404.1	4,871.3	105,600.0	514.4	0.62	0.3	1.0
%SI	29.17	29.17	29.17	0.00	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2022 00:00	3,868.6	0.0	3,868.6	105,600.0	408.5	0.49	0.2	0.8
10/20/2022 01:00	3,230.5	0.0	3,230.5	105,600.0	341.1	0.41	0.2	0.7
10/20/2022 02:00	2,819.2	0.0	2,819.2	105,600.0	297.7	0.36	0.2	0.6
10/20/2022 03:00	3,497.8	0.0	3,497.8	105,600.0	369.4	0.44	0.2	0.7
10/20/2022 04:00	4,121.3	0.0	4,121.3	105,600.0	435.2	0.52	0.3	0.9
10/20/2022 05:00	4,367.5	0.0	4,367.5	105,600.0	461.2	0.55	0.3	0.9
10/20/2022 06:00	3,888.2	0.0	3,888.2	105,600.0	410.6	0.49	0.2	0.8
10/20/2022 07:00	2,769.5	0.0	2,769.5	105,600.0	292.5	0.35	0.2	0.6
10/20/2022 08:00	2,690.6	0.0	2,690.6	105,600.0	284.1	0.34	0.2	0.6
10/20/2022 09:00	2,702.9	0.0	2,702.9	105,600.0	285.4	0.34	0.2	0.6
10/20/2022 10:00	2,722.7	0.0	2,722.7	105,600.0	287.5	0.34	0.2	0.6
10/20/2022 11:00	2,677.3	0.0	2,677.3	105,600.0	282.7	0.34	0.2	0.6
10/20/2022 12:00	2,685.8	0.0	2,685.8	105,600.0	283.6	0.34	0.2	0.6
10/20/2022 13:00	2,767.3	0.0	2,767.3	105,600.0	292.2	0.35	0.2	0.6
10/20/2022 14:00	2,847.1	0.0	2,847.1	105,600.0	300.7	0.36	0.2	0.6
10/20/2022 15:00	3,802.9	129.9	3,839.3	105,600.0	405.4	0.50	0.2	0.8
10/20/2022 16:00	4,398.6	1,231.8	5,630.4	105,600.0	594.6	0.71	0.4	1.2
10/20/2022 17:00	4,405.7	864.1	5,269.8	105,600.0	556.5	0.67	0.3	1.1
10/20/2022 18:00	4,425.3	538.3	4,963.6	105,600.0	524.2	0.63	0.3	1.0
10/20/2022 19:00	4,447.3	243.2	4,690.5	105,600.0	495.3	0.60	0.3	1.0
10/20/2022 20:00	4,415.8	201.2	4,570.7	105,600.0	482.7	0.59	0.3	1.0
10/20/2022 21:00	3,025.8	0.0	3,025.8	105,600.0	319.5	0.38	0.2	0.6
10/20/2022 22:00	2,916.1	0.0	2,916.1	105,600.0	307.9	0.37	0.2	0.6
10/20/2022 23:00	4,113.3	0.0	4,113.3	105,600.0	434.4	0.52	0.3	0.9
Average/Sum#:	3,483.6	133.7	3,611.5	105,600.0	381.4	0.46	0.2	0.8
Minimum:	2,677.3	0.0	2,677.3	105,600.0	282.7	0.34	0.2	0.6
Maximum:	4,447.3	1,231.8	5,630.4	105,600.0	594.6	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2022 00:00	3,400.4	0.0	3,400.4	105,600.0	359.1	0.43	0.2	0.7
10/21/2022 01:00	3,240.0	0.0	3,240.0	105,600.0	342.1	0.41	0.2	0.7
10/21/2022 02:00	2,818.2	0.0	2,818.2	105,600.0	297.6	0.36	0.2	0.6
10/21/2022 03:00	2,968.5	0.0	2,968.5	105,600.0	313.5	0.38	0.2	0.6
10/21/2022 04:00	3,247.0	0.0	3,247.0	105,600.0	342.9	0.41	0.2	0.7
10/21/2022 05:00	4,162.5	0.0	4,162.5	105,600.0	439.6	0.53	0.3	0.9
10/21/2022 06:00	4,419.4	146.1	4,488.1	105,600.0	473.9	0.58	0.3	1.0
10/21/2022 07:00	4,405.1	96.0	4,479.0	105,600.0	473.0	0.57	0.3	1.0
10/21/2022 08:00	2,744.0	0.0	2,744.0	105,600.0	289.8	0.35	0.2	0.6
10/21/2022 09:00	2,643.8	0.0	2,643.8	105,600.0	279.2	0.34	0.2	0.6
10/21/2022 10:00	2,641.4	0.0	2,641.4	105,600.0	278.9	0.33	0.2	0.6
10/21/2022 11:00	2,751.7	0.0	2,751.7	105,600.0	290.6	0.35	0.2	0.6
10/21/2022 12:00	2,639.9	0.0	2,639.9	105,600.0	278.8	0.33	0.2	0.6
10/21/2022 13:00	2,686.9	0.0	2,686.9	105,600.0	283.7	0.34	0.2	0.6
10/21/2022 14:00	2,707.4	0.0	2,707.4	105,600.0	285.9	0.34	0.2	0.6
10/21/2022 15:00	3,977.5	82.8	3,995.7	105,600.0	421.9	0.51	0.3	0.9
10/21/2022 16:00	4,395.8	583.1	4,978.9	105,600.0	525.8	0.63	0.3	1.1
10/21/2022 17:00	4,421.4	490.2	4,911.6	105,600.0	518.7	0.62	0.3	1.0
10/21/2022 18:00	4,394.8	194.9	4,544.9	105,600.0	479.9	0.58	0.3	1.0
10/21/2022 19:00	3,583.6	0.0	3,583.6	105,600.0	378.4	0.45	0.2	0.8
10/21/2022 20:00	3,445.2	0.0	3,445.2	105,600.0	363.8	0.44	0.2	0.7
10/21/2022 21:00	4,263.3	0.0	4,263.3	105,600.0	450.2	0.54	0.3	0.9
10/21/2022 22:00	4,406.0	0.0	4,406.0	105,600.0	465.3	0.56	0.3	0.9
10/21/2022 23:00	4,406.0	0.0	4,406.0	105,600.0	465.3	0.56	0.3	0.9
Average/Sum#:	3,532.1	66.4	3,589.8	105,600.0	379.1	0.46	0.2	0.8
Minimum:	2,639.9	0.0	2,639.9	105,600.0	278.8	0.33	0.2	0.6
Maximum:	4,421.4	583.1	4,978.9	105,600.0	525.8	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2022 00:00	4,397.5	0.0	4,397.5	105,600.0	464.4	0.56	0.3	0.9
10/22/2022 01:00	4,410.1	0.0	4,410.1	105,600.0	465.7	0.56	0.3	0.9
10/22/2022 02:00	4,407.8	0.0	4,407.8	105,600.0	465.5	0.56	0.3	0.9
10/22/2022 03:00	4,411.6	0.0	4,411.6	105,600.0	465.9	0.56	0.3	0.9
10/22/2022 04:00	4,400.3	0.0	4,400.3	105,600.0	464.7	0.56	0.3	0.9
10/22/2022 05:00	4,412.4	109.9	4,443.2	105,600.0	469.2	0.57	0.3	1.0
10/22/2022 06:00	4,424.2	1,709.9	6,134.1	105,600.0	647.8	0.78	0.4	1.3
10/22/2022 07:00	4,435.6	1,871.1	6,306.7	105,600.0	666.0	0.80	0.4	1.3
10/22/2022 08:00	4,447.0	1,270.3	5,717.3	105,600.0	603.7	0.72	0.4	1.2
10/22/2022 09:00	4,446.3	1,204.6	5,650.9	105,600.0	596.7	0.72	0.4	1.2
10/22/2022 10:00	4,445.3	989.2	5,434.5	105,600.0	573.9	0.69	0.3	1.1
10/22/2022 11:00	4,456.1	445.7	4,901.8	105,600.0	517.6	0.62	0.3	1.0
10/22/2022 12:00	4,417.1	121.9	4,511.0	105,600.0	476.4	0.58	0.3	1.0
10/22/2022 13:00	4,221.5	0.0	4,221.5	105,600.0	445.8	0.53	0.3	0.9
10/22/2022 14:00	4,118.7	0.0	4,118.7	105,600.0	434.9	0.52	0.3	0.9
10/22/2022 15:00	3,252.5	0.0	3,252.5	105,600.0	343.5	0.41	0.2	0.7
10/22/2022 16:00	3,581.7	0.0	3,581.7	105,600.0	378.2	0.45	0.2	0.8
10/22/2022 17:00	4,063.4	0.0	4,063.4	105,600.0	429.1	0.52	0.3	0.9
10/22/2022 18:00	4,105.9	0.0	4,105.9	105,600.0	433.6	0.52	0.3	0.9
10/22/2022 19:00	4,361.0	0.0	4,361.0	105,600.0	460.5	0.55	0.3	0.9
10/22/2022 20:00	4,425.8	61.3	4,443.0	105,600.0	469.2	0.57	0.3	0.9
10/22/2022 21:00	4,541.1	378.3	4,919.4	105,600.0	519.5	0.62	0.3	1.0
10/22/2022 22:00	4,393.2	2.4	4,393.2	105,600.0	463.9	0.56	0.3	0.9
10/22/2022 23:00	4,388.4	0.0	4,388.4	105,600.0	463.4	0.56	0.3	0.9
Average/Sum#:	4,290.2	340.2	4,624.0	105,600.0	488.3	0.59	0.3	1.0
Minimum:	3,252.5	0.0	3,252.5	105,600.0	343.5	0.41	0.2	0.7
Maximum:	4,541.1	1,871.1	6,306.7	105,600.0	666.0	0.80	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2022 00:00	4,476.7	358.5	4,756.3	105,600.0	502.3	0.61	0.3	1.0
10/23/2022 01:00	4,450.8	146.9	4,527.2	105,600.0	478.1	0.58	0.3	1.0
10/23/2022 02:00	4,400.2	0.0	4,400.2	105,600.0	464.7	0.56	0.3	0.9
10/23/2022 03:00	4,394.0	0.0	4,394.0	105,600.0	464.0	0.56	0.3	0.9
10/23/2022 04:00	4,391.6	0.0	4,391.6	105,600.0	463.8	0.56	0.3	0.9
10/23/2022 05:00	4,392.2	0.0	4,392.2	105,600.0	463.8	0.56	0.3	0.9
10/23/2022 06:00	4,387.7	0.0	4,387.7	105,600.0	463.3	0.56	0.3	0.9
10/23/2022 07:00	4,405.3	175.7	4,489.6	105,600.0	474.1	0.58	0.3	1.0
10/23/2022 08:00	4,518.9	304.0	4,792.5	105,600.0	506.1	0.61	0.3	1.0
10/23/2022 09:00	4,057.2	75.9	4,077.7	105,600.0	430.6	0.52	0.3	0.9
10/23/2022 10:00	3,761.5	0.0	3,761.5	105,600.0	397.2	0.48	0.2	0.8
10/23/2022 11:00	4,419.5	445.9	4,856.5	105,600.0	512.8	0.62	0.3	1.0
10/23/2022 12:00	4,118.5	118.6	4,150.5	105,600.0	438.3	0.54	0.3	0.9
10/23/2022 13:00	3,326.5	0.0	3,326.5	105,600.0	351.3	0.42	0.2	0.7
10/23/2022 14:00	3,394.7	0.0	3,394.7	105,600.0	358.5	0.43	0.2	0.7
10/23/2022 15:00	2,873.7	0.0	2,873.7	105,600.0	303.5	0.36	0.2	0.6
10/23/2022 16:00	3,565.9	0.0	3,565.9	105,600.0	376.6	0.45	0.2	0.8
10/23/2022 17:00	4,282.8	0.0	4,282.8	105,600.0	452.3	0.54	0.3	0.9
10/23/2022 18:00	4,350.9	0.0	4,350.9	105,600.0	459.5	0.55	0.3	0.9
10/23/2022 19:00	4,385.2	0.0	4,385.2	105,600.0	463.1	0.56	0.3	0.9
10/23/2022 20:00	4,481.1	350.4	4,733.4	105,600.0	499.8	0.61	0.3	1.0
10/23/2022 21:00	4,462.2	338.6	4,722.9	105,600.0	498.7	0.61	0.3	1.0
10/23/2022 22:00	3,827.1	0.0	3,827.1	105,600.0	404.1	0.48	0.2	0.8
10/23/2022 23:00	4,410.8	0.0	4,410.8	105,600.0	465.8	0.56	0.3	0.9
Average/Sum#:	4,147.3	96.4	4,218.8	105,600.0	445.5	0.54	0.3	0.9
Minimum:	2,873.7	0.0	2,873.7	105,600.0	303.5	0.36	0.2	0.6
Maximum:	4,518.9	445.9	4,856.5	105,600.0	512.8	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2022 00:00	4,324.6	0.0	4,324.6	105,600.0	456.7	0.55	0.3	0.9
10/24/2022 01:00	4,217.2	0.0	4,217.2	105,600.0	445.3	0.53	0.3	0.9
10/24/2022 02:00	4,393.8	0.0	4,393.8	105,600.0	464.0	0.56	0.3	0.9
10/24/2022 03:00	4,398.8	0.0	4,398.8	105,600.0	464.5	0.56	0.3	0.9
10/24/2022 04:00	4,363.8	0.0	4,363.8	105,600.0	460.8	0.55	0.3	0.9
10/24/2022 05:00	4,392.3	43.5	4,401.9	105,600.0	464.8	0.56	0.3	0.9
10/24/2022 06:00	4,639.5	993.3	5,632.8	105,600.0	594.8	0.71	0.4	1.2
10/24/2022 07:00	4,610.4	580.0	5,190.4	105,600.0	548.1	0.66	0.3	1.1
10/24/2022 08:00	4,568.5	181.4	4,695.5	105,600.0	495.8	0.60	0.3	1.0
10/24/2022 09:00	4,527.2	227.9	4,755.1	105,600.0	502.1	0.60	0.3	1.0
10/24/2022 10:00	4,469.9	190.5	4,660.4	105,600.0	492.1	0.59	0.3	1.0
10/24/2022 11:00	4,077.5	1.7	4,077.5	105,600.0	430.6	0.52	0.3	0.9
10/24/2022 12:00	2,706.7	0.0	2,706.7	105,600.0	285.8	0.34	0.2	0.6
10/24/2022 13:00	2,651.7	0.0	2,651.7	105,600.0	280.0	0.34	0.2	0.6
10/24/2022 14:00	3,834.8	31.8	3,842.1	105,600.0	405.7	0.49	0.2	0.8
10/24/2022 15:00	4,524.6	138.2	4,662.8	105,600.0	492.4	0.59	0.3	1.0
10/24/2022 16:00	4,530.4	712.7	5,243.1	105,600.0	553.7	0.66	0.3	1.1
10/24/2022 17:00	4,530.2	487.0	5,017.2	105,600.0	529.8	0.64	0.3	1.1
10/24/2022 18:00	4,505.2	164.1	4,625.0	105,600.0	488.4	0.59	0.3	1.0
10/24/2022 19:00	4,535.6	308.1	4,812.9	105,600.0	508.2	0.61	0.3	1.0
10/24/2022 20:00	4,479.2	271.7	4,683.0	105,600.0	494.5	0.60	0.3	1.0
10/24/2022 21:00	3,576.2	0.0	3,576.2	105,600.0	377.6	0.45	0.2	0.8
10/24/2022 22:00	2,945.6	0.0	2,945.6	105,600.0	311.1	0.37	0.2	0.6
10/24/2022 23:00	3,152.9	0.0	3,152.9	105,600.0	332.9	0.40	0.2	0.7
Average/Sum#:	4,123.2	180.5	4,293.0	105,600.0	453.3	0.54	0.3	0.9
Minimum:	2,651.7	0.0	2,651.7	105,600.0	280.0	0.34	0.2	0.6
Maximum:	4,639.5	993.3	5,632.8	105,600.0	594.8	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2022 00:00	2,786.7	0.0	2,786.7	105,600.0	294.3	0.35	0.2	0.6
10/25/2022 01:00	2,795.0	0.0	2,795.0	105,600.0	295.2	0.35	0.2	0.6
10/25/2022 02:00	2,788.0	0.0	2,788.0	105,600.0	294.4	0.35	0.2	0.6
10/25/2022 03:00	2,847.2	0.0	2,847.2	105,600.0	300.7	0.36	0.2	0.6
10/25/2022 04:00	3,970.7	0.0	3,970.7	105,600.0	419.3	0.50	0.3	0.8
10/25/2022 05:00	4,281.2	3.1	4,281.3	105,600.0	452.1	0.54	0.3	0.9
10/25/2022 06:00	4,557.7	482.0	5,039.7	105,600.0	532.2	0.64	0.3	1.1
10/25/2022 07:00	4,480.5	341.7	4,743.6	105,600.0	500.9	0.61	0.3	1.0
10/25/2022 08:00	3,594.0	0.0	3,594.0	105,600.0	379.5	0.46	0.2	0.8
10/25/2022 09:00	3,419.5	0.0	3,419.5	105,600.0	361.1	0.43	0.2	0.7
10/25/2022 10:00	2,696.7	0.0	2,696.7	105,600.0	284.8	0.34	0.2	0.6
10/25/2022 11:00	2,781.7	0.0	2,781.7	105,600.0	293.7	0.35	0.2	0.6
10/25/2022 12:00	3,436.6	15.7	3,438.2	105,600.0	363.1	0.44	0.2	0.7
10/25/2022 13:00	4,355.9	482.2	4,838.1	105,600.0	510.9	0.61	0.3	1.0
10/25/2022 14:00	4,354.8	823.2	5,178.0	105,600.0	546.8	0.66	0.3	1.1
10/25/2022 15:00	4,360.6	808.6	5,169.2	105,600.0	545.9	0.66	0.3	1.1
10/25/2022 16:00	4,347.1	1,073.9	5,421.0	105,600.0	572.5	0.69	0.3	1.1
10/25/2022 17:00	4,369.6	941.3	5,310.9	105,600.0	560.8	0.67	0.3	1.1
10/25/2022 18:00	4,409.8	627.4	5,037.2	105,600.0	531.9	0.64	0.3	1.1
10/25/2022 19:00	4,434.6	583.7	5,018.3	105,600.0	529.9	0.64	0.3	1.1
10/25/2022 20:00	4,459.7	659.9	5,119.6	105,600.0	540.6	0.65	0.3	1.1
10/25/2022 21:00	4,418.4	263.5	4,621.3	105,600.0	488.0	0.59	0.3	1.0
10/25/2022 22:00	2,868.9	0.0	2,868.9	105,600.0	303.0	0.36	0.2	0.6
10/25/2022 23:00	3,093.9	0.0	3,093.9	105,600.0	326.7	0.39	0.2	0.7
Average/Sum#:	3,746.2	296.1	4,035.8	105,600.0	426.2	0.51	0.3	0.9
Minimum:	2,696.7	0.0	2,696.7	105,600.0	284.8	0.34	0.2	0.6
Maximum:	4,557.7	1,073.9	5,421.0	105,600.0	572.5	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	2,792.4	0.0	2,792.4	105,600.0	294.9	0.35	0.2	0.6
10/26/2022 01:00	2,796.6	0.0	2,796.6	105,600.0	295.3	0.35	0.2	0.6
10/26/2022 02:00	2,807.8	0.0	2,807.8	105,600.0	296.5	0.36	0.2	0.6
10/26/2022 03:00	3,617.8	0.0	3,617.8	105,600.0	382.0	0.46	0.2	0.8
10/26/2022 04:00	3,978.4	0.0	3,978.4	105,600.0	420.1	0.50	0.3	0.8
10/26/2022 05:00	4,172.1	0.0	4,172.1	105,600.0	440.6	0.53	0.3	0.9
10/26/2022 06:00	4,382.1	0.0	4,382.1	105,600.0	462.7	0.56	0.3	0.9
10/26/2022 07:00	3,994.7	0.0	3,994.7	105,600.0	421.8	0.51	0.3	0.8
10/26/2022 08:00	4,390.8	233.7	4,512.3	105,600.0	476.5	0.59	0.3	1.0
10/26/2022 09:00	4,485.2	402.2	4,847.2	105,600.0	511.9	0.62	0.3	1.0
10/26/2022 10:00	4,450.5	488.6	4,939.1	105,600.0	521.6	0.63	0.3	1.0
10/26/2022 11:00	3,299.7	14.4	3,301.4	105,600.0	348.6	0.42	0.2	0.7
10/26/2022 12:00	2,674.1	0.0	2,674.1	105,600.0	282.4	0.34	0.2	0.6
10/26/2022 13:00	2,662.8	0.0	2,662.8	105,600.0	281.2	0.34	0.2	0.6
10/26/2022 14:00	3,114.4	0.0	3,114.4	105,600.0	328.9	0.40	0.2	0.7
10/26/2022 15:00	3,059.6	0.0	3,059.6	105,600.0	323.1	0.39	0.2	0.6
10/26/2022 16:00	3,873.7	111.3	3,918.2	105,600.0	413.8	0.51	0.3	0.8
10/26/2022 17:00	4,418.7	471.1	4,889.8	105,600.0	516.4	0.62	0.3	1.0
10/26/2022 18:00	4,387.3	170.5	4,518.6	105,600.0	477.2	0.58	0.3	1.0
10/26/2022 19:00	2,944.8	0.0	2,944.8	105,600.0	311.0	0.37	0.2	0.6
10/26/2022 20:00	3,250.4	0.0	3,250.4	105,600.0	343.2	0.41	0.2	0.7
10/26/2022 21:00	2,933.8	0.0	2,933.8	105,600.0	309.8	0.37	0.2	0.6
10/26/2022 22:00	2,776.2	0.0	2,776.2	105,600.0	293.2	0.35	0.2	0.6
10/26/2022 23:00	2,792.7	0.0	2,792.7	105,600.0	294.9	0.35	0.2	0.6
Average/Sum#:	3,502.4	78.8	3,569.9	105,600.0	377.0	0.45	0.2	0.8
Minimum:	2,662.8	0.0	2,662.8	105,600.0	281.2	0.34	0.2	0.6
Maximum:	4,485.2	488.6	4,939.1	105,600.0	521.6	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2022 00:00	2,673.6	0.0	2,673.6	105,600.0	282.3	0.34	0.2	0.6
10/27/2022 01:00	2,720.6	0.0	2,720.6	105,600.0	287.3	0.35	0.2	0.6
10/27/2022 02:00	2,757.5	0.0	2,757.5	105,600.0	291.2	0.35	0.2	0.6
10/27/2022 03:00	2,869.4	0.0	2,869.4	105,600.0	303.0	0.36	0.2	0.6
10/27/2022 04:00	3,307.1	0.0	3,307.1	105,600.0	349.2	0.42	0.2	0.7
10/27/2022 05:00	3,778.2	0.0	3,778.2	105,600.0	399.0	0.48	0.2	0.8
10/27/2022 06:00	3,681.3	0.0	3,681.3	105,600.0	388.7	0.47	0.2	0.8
10/27/2022 07:00	3,930.5	0.0	3,930.5	105,600.0	415.1	0.50	0.2	0.8
10/27/2022 08:00	4,248.5	0.0	4,248.5	105,600.0	448.6	0.54	0.3	0.9
10/27/2022 09:00	4,473.5	183.1	4,616.3	105,600.0	487.5	0.59	0.3	1.0
10/27/2022 10:00	3,997.5	57.9	4,014.9	105,600.0	424.0	0.51	0.3	0.9
10/27/2022 11:00	4,411.9	271.8	4,662.0	105,600.0	492.3	0.59	0.3	1.0
10/27/2022 12:00	4,388.5	353.6	4,742.1	105,600.0	500.8	0.60	0.3	1.0
10/27/2022 13:00	3,991.0	191.9	4,092.7	105,600.0	432.2	0.53	0.3	0.9
10/27/2022 14:00	2,838.3	0.0	2,838.3	105,600.0	299.7	0.36	0.2	0.6
10/27/2022 15:00	3,147.5	4.6	3,147.6	105,600.0	332.4	0.40	0.2	0.7
10/27/2022 16:00	4,504.2	644.1	5,148.3	105,600.0	543.7	0.65	0.3	1.1
10/27/2022 17:00	4,512.7	468.0	4,980.7	105,600.0	526.0	0.63	0.3	1.1
10/27/2022 18:00	4,522.5	222.7	4,745.2	105,600.0	501.1	0.60	0.3	1.0
10/27/2022 19:00	4,551.0	304.3	4,831.0	105,600.0	510.2	0.62	0.3	1.0
10/27/2022 20:00	4,582.7	360.1	4,942.8	105,600.0	522.0	0.63	0.3	1.0
10/27/2022 21:00	4,583.6	378.9	4,936.0	105,600.0	521.2	0.63	0.3	1.0
10/27/2022 22:00	4,512.0	97.2	4,584.9	105,600.0	484.2	0.58	0.3	1.0
10/27/2022 23:00	4,015.6	0.0	4,015.6	105,600.0	424.0	0.51	0.3	0.8
Average/Sum#:	3,875.0	147.4	4,011.0	105,600.0	423.6	0.51	0.3	0.9
Minimum:	2,673.6	0.0	2,673.6	105,600.0	282.3	0.34	0.2	0.6
Maximum:	4,583.6	644.1	5,148.3	105,600.0	543.7	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2022 00:00	3,951.5	0.0	3,951.5	105,600.0	417.3	0.50	0.3	0.8
10/28/2022 01:00	3,777.3	0.0	3,777.3	105,600.0	398.9	0.48	0.2	0.8
10/28/2022 02:00	3,940.3	0.0	3,940.3	105,600.0	416.1	0.50	0.2	0.8
10/28/2022 03:00	4,280.3	31.7	4,287.3	105,600.0	452.7	0.55	0.3	0.9
10/28/2022 04:00	4,621.6	469.8	5,058.5	105,600.0	534.2	0.65	0.3	1.1
10/28/2022 05:00	4,642.3	592.9	5,235.2	105,600.0	552.8	0.66	0.3	1.1
10/28/2022 06:00	4,643.1	503.4	5,146.5	105,600.0	543.5	0.65	0.3	1.1
10/28/2022 07:00	4,533.2	104.1	4,602.9	105,600.0	486.1	0.59	0.3	1.0
10/28/2022 08:00	3,954.9	0.0	3,954.9	105,600.0	417.6	0.50	0.3	0.8
10/28/2022 09:00	4,213.6	0.0	4,213.6	105,600.0	445.0	0.53	0.3	0.9
10/28/2022 10:00	4,472.0	227.2	4,694.7	105,600.0	495.8	0.60	0.3	1.0
10/28/2022 11:00	3,740.7	73.4	3,762.7	105,600.0	397.3	0.48	0.2	0.8
10/28/2022 12:00	3,711.0	0.0	3,711.0	105,600.0	391.9	0.47	0.2	0.8
10/28/2022 13:00	3,552.3	0.0	3,552.3	105,600.0	375.1	0.45	0.2	0.8
10/28/2022 14:00	3,802.7	29.1	3,809.4	105,600.0	402.3	0.48	0.2	0.8
10/28/2022 15:00	4,538.3	500.3	5,038.6	105,600.0	532.1	0.64	0.3	1.1
10/28/2022 16:00	4,529.8	444.8	4,930.1	105,600.0	520.6	0.63	0.3	1.1
10/28/2022 17:00	4,550.6	927.9	5,478.5	105,600.0	578.5	0.69	0.3	1.2
10/28/2022 18:00	4,553.6	974.7	5,528.3	105,600.0	583.8	0.70	0.4	1.2
10/28/2022 19:00	4,561.4	954.9	5,516.3	105,600.0	582.5	0.70	0.3	1.2
10/28/2022 20:00	4,583.6	1,005.1	5,588.7	105,600.0	590.2	0.71	0.4	1.2
10/28/2022 21:00	4,595.7	1,011.3	5,607.0	105,600.0	592.1	0.71	0.4	1.2
10/28/2022 22:00	4,600.7	460.4	5,061.1	105,600.0	534.5	0.64	0.3	1.1
10/28/2022 23:00	4,364.0	2.0	4,364.0	105,600.0	460.8	0.55	0.3	0.9
Average/Sum#:	4,279.8	346.4	4,617.1	105,600.0	487.6	0.59	0.3	1.0
Minimum:	3,552.3	0.0	3,552.3	105,600.0	375.1	0.45	0.2	0.8
Maximum:	4,643.1	1,011.3	5,607.0	105,600.0	592.1	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2022 00:00	3,626.0	0.0	3,626.0	105,600.0	382.9	0.46	0.2	0.8
10/29/2022 01:00	3,702.4	0.0	3,702.4	105,600.0	391.0	0.47	0.2	0.8
10/29/2022 02:00	3,668.9	0.0	3,668.9	105,600.0	387.4	0.47	0.2	0.8
10/29/2022 03:00	2,818.2	0.0	2,818.2	105,600.0	297.6	0.36	0.2	0.6
10/29/2022 04:00	3,538.1	0.0	3,538.1	105,600.0	373.6	0.45	0.2	0.7
10/29/2022 05:00	4,235.6	0.0	4,235.6	105,600.0	447.3	0.54	0.3	0.9
10/29/2022 06:00	3,627.0	0.0	3,627.0	105,600.0	383.0	0.46	0.2	0.8
10/29/2022 07:00	3,612.8	0.0	3,612.8	105,600.0	381.5	0.46	0.2	0.8
10/29/2022 08:00	4,186.0	0.0	4,186.0	105,600.0	442.0	0.53	0.3	0.9
10/29/2022 09:00	3,816.0	0.0	3,816.0	105,600.0	403.0	0.48	0.2	0.8
10/29/2022 10:00	3,927.1	0.0	3,927.1	105,600.0	414.7	0.50	0.2	0.8
10/29/2022 11:00	3,490.8	0.0	3,490.8	105,600.0	368.6	0.44	0.2	0.7
10/29/2022 12:00	2,825.9	0.0	2,825.9	105,600.0	298.4	0.36	0.2	0.6
10/29/2022 13:00	2,969.1	0.0	2,969.1	105,600.0	313.5	0.38	0.2	0.6
10/29/2022 14:00	3,025.7	0.0	3,025.7	105,600.0	319.5	0.38	0.2	0.6
10/29/2022 15:00	3,097.0	0.0	3,097.0	105,600.0	327.0	0.39	0.2	0.7
10/29/2022 16:00	3,530.3	0.0	3,530.3	105,600.0	372.8	0.45	0.2	0.7
10/29/2022 17:00	3,640.4	0.0	3,640.4	105,600.0	384.4	0.46	0.2	0.8
10/29/2022 18:00	3,532.2	0.0	3,532.2	105,600.0	373.0	0.45	0.2	0.7
10/29/2022 19:00	2,981.9	0.0	2,981.9	105,600.0	314.9	0.38	0.2	0.6
10/29/2022 20:00	4,448.6	41.4	4,460.2	105,600.0	471.0	0.57	0.3	0.9
10/29/2022 21:00	4,515.1	203.1	4,702.0	105,600.0	496.5	0.60	0.3	1.0
10/29/2022 22:00	4,038.7	0.0	4,038.7	105,600.0	426.5	0.51	0.3	0.9
10/29/2022 23:00	4,357.3	0.0	4,357.3	105,600.0	460.1	0.55	0.3	0.9
Average/Sum#:	3,633.8	10.2	3,642.1	105,600.0	384.6	0.46	0.2	0.8
Minimum:	2,818.2	0.0	2,818.2	105,600.0	297.6	0.36	0.2	0.6
Maximum:	4,515.1	203.1	4,702.0	105,600.0	496.5	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2022 00:00	4,214.5	0.0	4,214.5	105,600.0	445.1	0.53	0.3	0.9
10/30/2022 01:00	3,954.0	0.0	3,954.0	105,600.0	417.5	0.50	0.3	0.8
10/30/2022 02:00	4,076.7	0.0	4,076.7	105,600.0	430.5	0.52	0.3	0.9
10/30/2022 03:00	4,070.2	0.0	4,070.2	105,600.0	429.8	0.52	0.3	0.9
10/30/2022 04:00	4,146.9	0.0	4,146.9	105,600.0	437.9	0.53	0.3	0.9
10/30/2022 05:00	4,479.9	0.0	4,479.9	105,600.0	473.1	0.57	0.3	0.9
10/30/2022 06:00	4,377.4	0.0	4,377.4	105,600.0	462.3	0.55	0.3	0.9
10/30/2022 07:00	2,826.6	0.0	2,826.6	105,600.0	298.5	0.36	0.2	0.6
10/30/2022 08:00	2,684.0	0.0	2,684.0	105,600.0	283.4	0.34	0.2	0.6
10/30/2022 09:00	2,660.8	0.0	2,660.8	105,600.0	281.0	0.34	0.2	0.6
10/30/2022 10:00	2,660.1	0.0	2,660.1	105,600.0	280.9	0.34	0.2	0.6
10/30/2022 11:00	2,649.2	0.0	2,649.2	105,600.0	279.8	0.34	0.2	0.6
10/30/2022 12:00	2,646.5	0.0	2,646.5	105,600.0	279.5	0.34	0.2	0.6
10/30/2022 13:00	2,645.4	0.0	2,645.4	105,600.0	279.4	0.34	0.2	0.6
10/30/2022 14:00	2,644.6	0.0	2,644.6	105,600.0	279.3	0.34	0.2	0.6
10/30/2022 15:00	2,904.2	0.0	2,904.2	105,600.0	306.7	0.37	0.2	0.6
10/30/2022 16:00	4,134.3	0.0	4,134.3	105,600.0	436.6	0.52	0.3	0.9
10/30/2022 17:00	4,280.2	32.1	4,287.3	105,600.0	452.7	0.55	0.3	0.9
10/30/2022 18:00	4,479.6	130.6	4,610.2	105,600.0	486.8	0.58	0.3	1.0
10/30/2022 19:00	4,082.3	1.9	4,082.3	105,600.0	431.1	0.52	0.3	0.9
10/30/2022 20:00	3,993.1	0.0	3,993.1	105,600.0	421.7	0.50	0.3	0.8
10/30/2022 21:00	4,020.0	0.0	4,020.0	105,600.0	424.5	0.51	0.3	0.8
10/30/2022 22:00	3,891.5	0.0	3,891.5	105,600.0	410.9	0.49	0.2	0.8
10/30/2022 23:00	4,040.6	0.0	4,040.6	105,600.0	426.7	0.51	0.3	0.9
Average/Sum#:	3,606.8	6.9	3,612.5	105,600.0	381.5	0.46	0.3	0.8
Minimum:	2,644.6	0.0	2,644.6	105,600.0	279.3	0.34	0.2	0.6
Maximum:	4,479.9	130.6	4,610.2	105,600.0	486.8	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2022 00:00	4,036.2	0.0	4,036.2	105,600.0	426.2	0.51	0.3	0.9
10/31/2022 01:00	3,976.7	0.0	3,976.7	105,600.0	419.9	0.50	0.3	0.8
10/31/2022 02:00	4,073.1	0.0	4,073.1	105,600.0	430.1	0.52	0.3	0.9
10/31/2022 03:00	4,017.8	0.0	4,017.8	105,600.0	424.3	0.51	0.3	0.8
10/31/2022 04:00	4,258.3	0.0	4,258.3	105,600.0	449.7	0.54	0.3	0.9
10/31/2022 05:00	4,429.7	293.9	4,567.8	105,600.0	482.4	0.60	0.3	1.0
10/31/2022 06:00	4,517.1	491.9	4,974.6	105,600.0	525.3	0.63	0.3	1.1
10/31/2022 07:00	3,817.4	35.6	3,827.0	105,600.0	404.1	0.49	0.2	0.8
10/31/2022 08:00	3,476.1	0.0	3,476.1	105,600.0	367.1	0.44	0.2	0.7
10/31/2022 09:00	3,303.9	0.0	3,303.9	105,600.0	348.9	0.42	0.2	0.7
10/31/2022 10:00	2,966.9	0.0	2,966.9	105,600.0	313.3	0.37	0.2	0.6
10/31/2022 11:00	2,777.0	0.0	2,777.0	105,600.0	293.3	0.35	0.2	0.6
10/31/2022 12:00	2,777.0	0.0	2,777.0	105,600.0	293.3	0.35	0.2	0.6
10/31/2022 13:00	3,194.0	0.0	3,194.0	105,600.0	337.3	0.41	0.2	0.7
10/31/2022 14:00	4,124.7	165.0	4,187.4	105,600.0	442.2	0.54	0.3	0.9
10/31/2022 15:00	4,460.6	339.9	4,800.5	105,600.0	506.9	0.61	0.3	1.0
10/31/2022 16:00	3,596.5	1.7	3,596.5	105,600.0	379.8	0.46	0.2	0.8
10/31/2022 17:00	2,762.5	0.0	2,762.5	105,600.0	291.7	0.35	0.2	0.6
10/31/2022 18:00	2,745.7	0.0	2,745.7	105,600.0	289.9	0.35	0.2	0.6
10/31/2022 19:00	3,066.2	0.0	3,066.2	105,600.0	323.8	0.39	0.2	0.6
10/31/2022 20:00	3,212.1	0.0	3,212.1	105,600.0	339.2	0.41	0.2	0.7
10/31/2022 21:00	3,686.1	0.0	3,686.1	105,600.0	389.3	0.47	0.2	0.8
10/31/2022 22:00	3,236.8	0.0	3,236.8	105,600.0	341.8	0.41	0.2	0.7
10/31/2022 23:00	4,269.7	0.0	4,269.7	105,600.0	450.9	0.54	0.3	0.9
Average/Sum#:	3,615.9	55.3	3,657.9	105,600.0	386.3	0.47	0.2	0.8
Minimum:	2,745.7	0.0	2,745.7	105,600.0	289.9	0.35	0.2	0.6
Maximum:	4,517.1	491.9	4,974.6	105,600.0	525.3	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022 00:00	4,287.9	0.0	4,287.9	105,600.0	452.8	0.54	0.3	0.9
11/01/2022 01:00	4,363.3	67.8	4,382.3	105,600.0	462.8	0.56	0.3	0.9
11/01/2022 02:00	4,497.0	597.5	5,094.5	105,600.0	538.0	0.65	0.3	1.1
11/01/2022 03:00	4,498.0	834.0	5,332.0	105,600.0	563.1	0.68	0.3	1.1
11/01/2022 04:00	4,502.0	1,016.3	5,518.3	105,600.0	582.7	0.70	0.3	1.2
11/01/2022 05:00	4,489.7	881.9	5,371.6	105,600.0	567.2	0.68	0.3	1.1
11/01/2022 06:00	4,498.4	1,262.0	5,760.4	105,600.0	608.3	0.73	0.4	1.2
11/01/2022 07:00	4,486.0	834.1	5,320.1	105,600.0	561.8	0.67	0.3	1.1
11/01/2022 08:00	4,492.3	621.7	5,114.0	105,600.0	540.0	0.65	0.3	1.1
11/01/2022 09:00	4,479.3	330.4	4,809.7	105,600.0	507.9	0.61	0.3	1.0
11/01/2022 10:00	4,481.8	365.9	4,847.7	105,600.0	511.9	0.61	0.3	1.0
11/01/2022 11:00	4,497.6	604.3	5,101.9	105,600.0	538.8	0.65	0.3	1.1
11/01/2022 12:00	4,489.4	792.6	5,282.0	105,600.0	557.8	0.67	0.3	1.1
11/01/2022 13:00	4,503.9	735.2	5,239.1	105,600.0	553.2	0.66	0.3	1.1
11/01/2022 14:00	4,509.1	183.1	4,692.2	105,600.0	495.5	0.59	0.3	1.0
11/01/2022 15:00	4,475.8	303.7	4,779.5	105,600.0	504.7	0.61	0.3	1.0
11/01/2022 16:00	4,491.1	743.2	5,234.3	105,600.0	552.7	0.66	0.3	1.1
11/01/2022 17:00	4,522.0	598.8	5,120.8	105,600.0	540.8	0.65	0.3	1.1
11/01/2022 18:00	4,537.1	517.6	5,054.7	105,600.0	533.8	0.64	0.3	1.1
11/01/2022 19:00	4,570.6	509.4	5,080.0	105,600.0	536.4	0.64	0.3	1.1
11/01/2022 20:00	4,547.4	462.4	5,009.8	105,600.0	529.0	0.64	0.3	1.1
11/01/2022 21:00	4,548.6	276.6	4,805.8	105,600.0	507.5	0.61	0.3	1.0
11/01/2022 22:00	4,546.5	184.2	4,717.8	105,600.0	498.2	0.60	0.3	1.0
11/01/2022 23:00	3,789.0	0.0	3,789.0	105,600.0	400.1	0.48	0.2	0.8
Average/Sum#:	4,462.7	530.1	4,989.4	105,600.0	526.9	0.63	0.3	1.1
Minimum:	3,789.0	0.0	3,789.0	105,600.0	400.1	0.48	0.2	0.8
Maximum:	4,570.6	1,262.0	5,760.4	105,600.0	608.3	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2022 00:00	2,806.4	0.0	2,806.4	105,600.0	296.4	0.35	0.2	0.6
11/02/2022 01:00	3,588.3	0.0	3,588.3	105,600.0	378.9	0.46	0.2	0.8
11/02/2022 02:00	3,209.5	0.0	3,209.5	105,600.0	338.9	0.41	0.2	0.7
11/02/2022 03:00	3,867.1	0.0	3,867.1	105,600.0	408.4	0.49	0.2	0.8
11/02/2022 04:00	4,206.9	0.0	4,206.9	105,600.0	444.2	0.53	0.3	0.9
11/02/2022 05:00	4,404.8	2.6	4,404.9	105,600.0	465.2	0.56	0.3	0.9
11/02/2022 06:00	4,562.3	363.6	4,925.9	105,600.0	520.2	0.62	0.3	1.0
11/02/2022 07:00	3,689.4	35.3	3,698.9	105,600.0	390.6	0.47	0.2	0.8
11/02/2022 08:00	2,865.1	0.0	2,865.1	105,600.0	302.6	0.36	0.2	0.6
11/02/2022 09:00	2,917.9	0.0	2,917.9	105,600.0	308.1	0.37	0.2	0.6
11/02/2022 10:00	3,917.3	0.0	3,917.3	105,600.0	413.7	0.50	0.2	0.8
11/02/2022 11:00	4,522.8	227.5	4,700.3	105,600.0	496.4	0.60	0.3	1.0
11/02/2022 12:00	4,517.8	175.3	4,693.1	105,600.0	495.6	0.59	0.3	1.0
11/02/2022 13:00	4,197.4	1.8	4,197.4	104,046.0	436.7	0.53	0.3	0.9
11/02/2022 14:00	4,482.2	173.6	4,650.6	104,046.0	483.9	0.59	0.3	1.0
11/02/2022 15:00	4,498.5	286.4	4,784.9	104,046.0	497.8	0.61	0.3	1.0
11/02/2022 16:00	4,503.9	647.4	5,151.3	104,046.0	536.0	0.65	0.3	1.1
11/02/2022 17:00	4,506.9	964.4	5,471.3	104,046.0	569.3	0.69	0.3	1.2
11/02/2022 18:00	4,519.1	506.1	5,025.2	104,046.0	522.9	0.64	0.3	1.1
11/02/2022 19:00	4,530.9	485.3	5,016.2	104,046.0	521.9	0.64	0.3	1.1
11/02/2022 20:00	4,589.4	863.9	5,453.3	104,046.0	567.4	0.69	0.3	1.2
11/02/2022 21:00	4,609.8	668.7	5,278.5	104,046.0	549.2	0.67	0.3	1.1
11/02/2022 22:00	4,611.3	464.7	5,076.0	104,046.0	528.1	0.64	0.3	1.1
11/02/2022 23:00	4,474.0	0.8	4,474.0	104,046.0	465.5	0.57	0.3	0.9
Average/Sum#:	4,108.3	244.5	4,349.2	104,887.8	455.7	0.55	0.3	0.9
Minimum:	2,806.4	0.0	2,806.4	104,046.0	296.4	0.35	0.2	0.6
Maximum:	4,611.3	964.4	5,471.3	105,600.0	569.3	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	4,506.6	0.0	4,506.6	104,046.0	468.9	0.57	0.3	1.0
11/03/2022 01:00	4,412.0	0.0	4,412.0	104,046.0	459.1	0.56	0.3	0.9
11/03/2022 02:00	4,393.7	0.0	4,393.7	104,046.0	457.1	0.56	0.3	0.9
11/03/2022 03:00	4,488.9	0.0	4,488.9	104,046.0	467.1	0.57	0.3	0.9
11/03/2022 04:00	4,521.5	32.8	4,529.0	104,046.0	471.2	0.58	0.3	1.0
11/03/2022 05:00	4,673.2	1,239.4	5,912.6	104,046.0	615.2	0.75	0.4	1.2
11/03/2022 06:00	4,648.0	1,516.4	6,164.4	104,046.0	641.4	0.78	0.4	1.3
11/03/2022 07:00	4,570.1	109.9	4,622.9	104,046.0	481.0	0.59	0.3	1.0
11/03/2022 08:00	4,256.8	2.7	4,256.9	104,046.0	442.9	0.54	0.3	0.9
11/03/2022 09:00	4,616.1	139.6	4,744.5	104,046.0	493.6	0.60	0.3	1.0
11/03/2022 10:00	4,592.7	324.2	4,916.9	104,046.0	511.6	0.62	0.3	1.0
11/03/2022 11:00	3,759.0	1.7	3,759.0	104,046.0	391.1	0.48	0.2	0.8
11/03/2022 12:00	2,828.7	0.0	2,828.7	104,046.0	294.3	0.36	0.2	0.6
11/03/2022 13:00	2,796.1	0.0	2,796.1	104,046.0	290.9	0.35	0.2	0.6
11/03/2022 14:00	2,714.6	0.0	2,714.6	104,046.0	282.4	0.34	0.2	0.6
11/03/2022 15:00	2,774.8	0.0	2,774.8	104,046.0	288.7	0.35	0.2	0.6
11/03/2022 16:00	4,042.7	6.0	4,042.9	104,046.0	420.6	0.51	0.3	0.9
11/03/2022 17:00	4,521.7	595.7	5,117.4	104,046.0	532.4	0.65	0.3	1.1
11/03/2022 18:00	4,552.7	500.8	5,053.5	104,046.0	525.8	0.64	0.3	1.1
11/03/2022 19:00	4,576.8	491.5	5,068.3	104,046.0	527.3	0.64	0.3	1.1
11/03/2022 20:00	4,594.1	984.5	5,578.6	104,046.0	580.4	0.71	0.4	1.2
11/03/2022 21:00	4,586.6	1,123.9	5,710.5	104,046.0	594.2	0.72	0.4	1.2
11/03/2022 22:00	4,588.3	641.6	5,185.0	104,046.0	539.5	0.66	0.3	1.1
11/03/2022 23:00	4,557.0	141.2	4,698.2	104,046.0	488.8	0.60	0.3	1.0
Average/Sum#:	4,190.5	327.2	4,511.5	104,046.0	469.4	0.57	0.3	1.0
Minimum:	2,714.6	0.0	2,714.6	104,046.0	282.4	0.34	0.2	0.6
Maximum:	4,673.2	1,516.4	6,164.4	104,046.0	641.4	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2022 00:00	4,320.1	14.5	4,321.8	104,046.0	449.7	0.55	0.3	0.9
11/04/2022 01:00	4,280.8	0.0	4,280.8	104,046.0	445.4	0.54	0.3	0.9
11/04/2022 02:00	3,956.5	0.0	3,956.5	104,046.0	411.7	0.50	0.3	0.8
11/04/2022 03:00	4,109.3	0.0	4,109.3	104,046.0	427.6	0.52	0.3	0.9
11/04/2022 04:00	4,368.9	7.6	4,369.3	104,046.0	454.6	0.55	0.3	0.9
11/04/2022 05:00	4,620.7	684.6	5,305.3	104,046.0	552.0	0.67	0.3	1.1
11/04/2022 06:00	4,637.5	692.9	5,330.4	104,046.0	554.6	0.68	0.3	1.1
11/04/2022 07:00	3,717.2	36.4	3,727.0	104,046.0	387.8	0.47	0.2	0.8
11/04/2022 08:00	2,860.8	0.0	2,860.8	104,046.0	297.7	0.36	0.2	0.6
11/04/2022 09:00	2,915.9	0.0	2,915.9	104,046.0	303.4	0.37	0.2	0.6
11/04/2022 10:00	2,772.4	0.0	2,772.4	104,046.0	288.5	0.35	0.2	0.6
11/04/2022 11:00	2,677.5	0.0	2,677.5	104,046.0	278.6	0.34	0.2	0.6
11/04/2022 12:00	2,759.3	0.0	2,759.3	104,046.0	287.1	0.35	0.2	0.6
11/04/2022 13:00	2,695.5	0.0	2,695.5	104,046.0	280.5	0.34	0.2	0.6
11/04/2022 14:00	2,685.9	0.0	2,685.9	104,046.0	279.5	0.34	0.2	0.6
11/04/2022 15:00	3,239.7	0.0	3,239.7	104,046.0	337.1	0.41	0.2	0.7
11/04/2022 16:00	3,377.1	0.0	3,377.1	104,046.0	351.4	0.43	0.2	0.7
11/04/2022 17:00	4,159.0	0.0	4,159.0	104,046.0	432.7	0.53	0.3	0.9
11/04/2022 18:00	4,488.6	442.8	4,922.5	104,046.0	512.2	0.63	0.3	1.0
11/04/2022 19:00	4,499.7	426.7	4,926.4	104,046.0	512.6	0.62	0.3	1.0
11/04/2022 20:00	4,486.1	301.9	4,736.7	104,046.0	492.8	0.61	0.3	1.0
11/04/2022 21:00	2,888.7	0.0	2,888.7	104,046.0	300.6	0.37	0.2	0.6
11/04/2022 22:00	2,681.3	0.0	2,681.3	104,046.0	279.0	0.34	0.2	0.6
11/04/2022 23:00	3,101.0	0.0	3,101.0	104,046.0	322.6	0.39	0.2	0.7
Average/Sum#:	3,595.8	108.6	3,700.0	104,046.0	385.0	0.47	0.2	0.8
Minimum:	2,677.5	0.0	2,677.5	104,046.0	278.6	0.34	0.2	0.6
Maximum:	4,637.5	692.9	5,330.4	104,046.0	554.6	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	2,777.0	0.0	2,777.0	104,046.0	288.9	0.35	0.2	0.6
11/05/2022 01:00	2,778.4	0.0	2,778.4	104,046.0	289.1	0.35	0.2	0.6
11/05/2022 02:00	2,775.0	0.0	2,775.0	104,046.0	288.7	0.35	0.2	0.6
11/05/2022 03:00	2,764.2	0.0	2,764.2	104,046.0	287.6	0.35	0.2	0.6
11/05/2022 04:00	2,777.6	0.0	2,777.6	104,046.0	289.0	0.35	0.2	0.6
11/05/2022 05:00	3,049.7	0.0	3,049.7	104,046.0	317.3	0.39	0.2	0.6
11/05/2022 06:00	2,769.7	0.0	2,769.7	104,046.0	288.2	0.35	0.2	0.6
11/05/2022 07:00	3,390.3	0.0	3,390.3	104,046.0	352.7	0.42	0.2	0.7
11/05/2022 08:00	2,710.6	0.0	2,710.6	104,046.0	282.0	0.34	0.2	0.6
11/05/2022 09:00	2,749.4	0.0	2,749.4	104,046.0	286.1	0.34	0.2	0.6
11/05/2022 10:00	2,873.7	0.0	2,873.7	104,046.0	299.0	0.36	0.2	0.6
11/05/2022 11:00	3,007.5	0.0	3,007.5	104,046.0	312.9	0.38	0.2	0.6
11/05/2022 12:00	3,692.5	0.0	3,692.5	104,046.0	384.2	0.46	0.2	0.8
11/05/2022 13:00	3,274.2	0.0	3,274.2	104,046.0	340.7	0.41	0.2	0.7
11/05/2022 14:00	4,081.6	0.0	4,081.6	104,046.0	424.7	0.51	0.3	0.8
11/05/2022 15:00	2,769.8	0.0	2,769.8	104,046.0	288.2	0.35	0.2	0.6
11/05/2022 16:00	3,350.7	0.0	3,350.7	104,046.0	348.6	0.42	0.2	0.7
11/05/2022 17:00	4,114.0	52.0	4,129.6	104,046.0	429.7	0.52	0.3	0.9
11/05/2022 18:00	4,451.8	213.2	4,665.0	104,046.0	485.4	0.58	0.3	1.0
11/05/2022 19:00	4,446.0	172.2	4,587.2	104,046.0	477.3	0.58	0.3	1.0
11/05/2022 20:00	3,190.8	0.0	3,190.8	104,046.0	332.0	0.40	0.2	0.7
11/05/2022 21:00	2,874.2	0.0	2,874.2	104,046.0	299.0	0.36	0.2	0.6
11/05/2022 22:00	2,773.6	0.0	2,773.6	104,046.0	288.6	0.35	0.2	0.6
11/05/2022 23:00	3,992.5	0.0	3,992.5	104,046.0	415.4	0.50	0.2	0.8
Average/Sum#:	3,226.5	18.2	3,241.9	104,046.0	337.3	0.41	0.2	0.7
Minimum:	2,710.6	0.0	2,710.6	104,046.0	282.0	0.34	0.2	0.6
Maximum:	4,451.8	213.2	4,665.0	104,046.0	485.4	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2022 00:00	3,922.0	0.0	3,922.0	104,046.0	408.1	0.49	0.2	0.8
11/06/2022 01:00	3,423.9	0.0	3,423.9	104,046.0	356.2	0.43	0.2	0.7
11/06/2022 02:00	3,534.1	0.0	3,534.1	104,046.0	367.7	0.44	0.2	0.7
11/06/2022 03:00	4,133.2	0.0	4,133.2	104,046.0	430.0	0.52	0.3	0.9
11/06/2022 04:00	4,114.3	0.0	4,114.3	104,046.0	428.1	0.51	0.3	0.9
11/06/2022 05:00	4,377.2	0.0	4,377.2	104,046.0	455.4	0.55	0.3	0.9
11/06/2022 06:00	4,434.8	0.0	4,434.8	104,046.0	461.4	0.55	0.3	0.9
11/06/2022 07:00	4,423.0	0.0	4,423.0	104,046.0	460.2	0.55	0.3	0.9
11/06/2022 08:00	4,471.2	376.5	4,836.4	104,046.0	503.2	0.61	0.3	1.0
11/06/2022 09:00	4,415.2	189.2	4,562.8	104,046.0	474.7	0.58	0.3	1.0
11/06/2022 10:00	2,994.8	0.0	2,994.8	104,046.0	311.6	0.37	0.2	0.6
11/06/2022 11:00	2,830.0	0.0	2,830.0	104,046.0	294.5	0.35	0.2	0.6
11/06/2022 12:00	2,735.8	0.0	2,735.8	104,046.0	284.6	0.34	0.2	0.6
11/06/2022 13:00	2,819.4	0.0	2,819.4	104,046.0	293.3	0.35	0.2	0.6
11/06/2022 14:00	3,353.2	0.0	3,353.2	104,046.0	348.9	0.42	0.2	0.7
11/06/2022 15:00	4,444.9	302.0	4,662.3	104,046.0	485.1	0.59	0.3	1.0
11/06/2022 16:00	4,475.1	780.9	5,256.0	104,046.0	546.9	0.66	0.3	1.1
11/06/2022 17:00	4,485.5	436.0	4,921.5	104,046.0	512.1	0.61	0.3	1.0
11/06/2022 18:00	4,497.8	251.0	4,731.2	104,046.0	492.3	0.59	0.3	1.0
11/06/2022 19:00	4,504.2	178.2	4,682.4	104,046.0	487.2	0.58	0.3	1.0
11/06/2022 20:00	4,492.4	216.8	4,709.2	104,046.0	490.0	0.59	0.3	1.0
11/06/2022 21:00	4,499.9	243.7	4,743.6	104,046.0	493.6	0.59	0.3	1.0
11/06/2022 22:00	3,646.9	35.1	3,656.4	104,046.0	380.4	0.46	0.2	0.8
11/06/2022 23:00	2,810.3	0.0	2,810.3	104,046.0	292.4	0.35	0.2	0.6
Average/Sum#:	3,910.0	125.4	4,027.8	104,046.0	419.1	0.50	0.3	0.8
Minimum:	2,735.8	0.0	2,735.8	104,046.0	284.6	0.34	0.2	0.6
Maximum:	4,504.2	780.9	5,256.0	104,046.0	546.9	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2022 00:00	3,154.3	0.0	3,154.3	104,046.0	328.2	0.39	0.2	0.7
11/07/2022 01:00	3,518.0	0.0	3,518.0	104,046.0	366.0	0.44	0.2	0.7
11/07/2022 02:00	3,755.3	0.0	3,755.3	104,046.0	390.7	0.47	0.2	0.8
11/07/2022 03:00	3,531.1	0.0	3,531.1	104,046.0	367.4	0.44	0.2	0.7
11/07/2022 04:00	3,335.0	0.0	3,335.0	104,046.0	347.0	0.42	0.2	0.7
11/07/2022 05:00	4,079.2	0.0	4,079.2	104,046.0	424.4	0.51	0.3	0.8
11/07/2022 06:00	4,395.6	0.0	4,395.6	104,046.0	457.3	0.55	0.3	0.9
11/07/2022 07:00	3,908.2	0.0	3,908.2	104,046.0	406.6	0.49	0.2	0.8
11/07/2022 08:00	2,794.3	0.0	2,794.3	104,046.0	290.7	0.35	0.2	0.6
11/07/2022 09:00	2,787.1	0.0	2,787.1	104,046.0	290.0	0.35	0.2	0.6
11/07/2022 10:00	2,764.8	0.0	2,764.8	104,046.0	287.7	0.35	0.2	0.6
11/07/2022 11:00	2,743.8	0.0	2,743.8	104,046.0	285.5	0.34	0.2	0.6
11/07/2022 12:00	2,765.6	0.0	2,765.6	104,046.0	287.7	0.35	0.2	0.6
11/07/2022 13:00	2,776.1	0.0	2,776.1	104,046.0	288.8	0.35	0.2	0.6
11/07/2022 14:00	3,574.5	0.0	3,574.5	104,046.0	371.9	0.45	0.2	0.7
11/07/2022 15:00	4,315.1	348.5	4,499.8	104,046.0	468.2	0.58	0.3	1.0
11/07/2022 16:00	4,468.8	624.8	5,093.6	104,046.0	530.0	0.64	0.3	1.1
11/07/2022 17:00	4,458.5	615.1	5,073.6	104,046.0	527.9	0.63	0.3	1.1
11/07/2022 18:00	4,481.3	546.7	5,028.0	104,046.0	523.1	0.63	0.3	1.0
11/07/2022 19:00	4,492.5	603.4	5,095.9	104,046.0	530.2	0.64	0.3	1.1
11/07/2022 20:00	4,497.2	608.0	5,105.2	104,046.0	531.2	0.64	0.3	1.1
11/07/2022 21:00	4,496.7	643.6	5,140.3	104,046.0	534.8	0.64	0.3	1.1
11/07/2022 22:00	4,498.4	343.8	4,842.2	104,046.0	503.8	0.60	0.3	1.0
11/07/2022 23:00	3,766.4	84.9	3,789.3	104,046.0	394.3	0.48	0.2	0.8
Average/Sum#:	3,723.2	184.1	3,898.0	104,046.0	405.6	0.49	0.2	0.8
Minimum:	2,743.8	0.0	2,743.8	104,046.0	285.5	0.34	0.2	0.6
Maximum:	4,498.4	643.6	5,140.3	104,046.0	534.8	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2022 00:00	2,943.4	0.0	2,943.4	104,046.0	306.2	0.37	0.2	0.6
11/08/2022 01:00	2,713.4	0.0	2,713.4	104,046.0	282.3	0.34	0.2	0.6
11/08/2022 02:00	2,722.4	0.0	2,722.4	104,046.0	283.3	0.34	0.2	0.6
11/08/2022 03:00	2,722.6	0.0	2,722.6	104,046.0	283.3	0.34	0.2	0.6
11/08/2022 04:00	3,743.1	38.1	3,754.5	104,046.0	390.6	0.47	0.2	0.8
11/08/2022 05:00	4,483.0	176.0	4,659.0	104,046.0	484.8	0.58	0.3	1.0
11/08/2022 06:00	4,484.5	608.3	5,092.8	104,046.0	529.9	0.64	0.3	1.1
11/08/2022 07:00	4,489.9	251.0	4,740.9	104,046.0	493.3	0.59	0.3	1.0
11/08/2022 08:00	4,488.2	361.6	4,849.8	104,046.0	504.6	0.61	0.3	1.0
11/08/2022 09:00	4,482.8	810.0	5,292.8	104,046.0	550.7	0.66	0.3	1.1
11/08/2022 10:00	4,487.8	435.0	4,922.8	104,046.0	512.2	0.61	0.3	1.0
11/08/2022 11:00	4,482.0	263.3	4,745.3	104,046.0	493.7	0.59	0.3	1.0
11/08/2022 12:00	4,480.3	269.7	4,750.0	104,046.0	494.2	0.59	0.3	1.0
11/08/2022 13:00	3,168.1	1.8	3,168.1	104,046.0	329.6	0.40	0.2	0.7
11/08/2022 14:00	2,749.4	0.0	2,749.4	104,046.0	286.1	0.34	0.2	0.6
11/08/2022 15:00	3,774.8	97.9	3,818.9	104,046.0	397.3	0.48	0.2	0.8
11/08/2022 16:00	4,495.0	213.7	4,708.7	104,046.0	489.9	0.59	0.3	1.0
11/08/2022 17:00	4,497.2	279.8	4,777.0	104,046.0	497.0	0.60	0.3	1.0
11/08/2022 18:00	4,505.9	218.8	4,724.7	104,046.0	491.6	0.59	0.3	1.0
11/08/2022 19:00	4,513.0	196.3	4,709.3	104,046.0	490.0	0.59	0.3	1.0
11/08/2022 20:00	4,518.8	183.5	4,702.3	104,046.0	489.3	0.59	0.3	1.0
11/08/2022 21:00	4,523.7	179.3	4,703.0	104,046.0	489.3	0.59	0.3	1.0
11/08/2022 22:00	4,538.8	148.5	4,687.3	104,046.0	487.7	0.59	0.3	1.0
11/08/2022 23:00	4,547.0	139.5	4,686.5	104,046.0	487.6	0.59	0.3	1.0
Average/Sum#:	4,023.1	203.0	4,222.7	104,046.0	439.4	0.53	0.3	0.9
Minimum:	2,713.4	0.0	2,713.4	104,046.0	282.3	0.34	0.2	0.6
Maximum:	4,547.0	810.0	5,292.8	104,046.0	550.7	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	4,553.2	137.7	4,690.9	104,046.0	488.1	0.59	0.3	1.0
11/09/2022 01:00	4,560.4	138.0	4,698.4	104,046.0	488.8	0.59	0.3	1.0
11/09/2022 02:00	4,564.2	137.6	4,701.8	104,046.0	489.2	0.59	0.3	1.0
11/09/2022 03:00	4,566.6	136.7	4,703.3	104,046.0	489.4	0.59	0.3	1.0
11/09/2022 04:00	4,570.7	137.2	4,707.9	104,046.0	489.8	0.59	0.3	1.0
11/09/2022 05:00	4,574.6	137.2	4,711.8	104,046.0	490.2	0.59	0.3	1.0
11/09/2022 06:00	4,583.1	137.6	4,720.7	104,046.0	491.2	0.59	0.3	1.0
11/09/2022 07:00	4,582.3	136.9	4,719.2	104,046.0	491.0	0.59	0.3	1.0
11/09/2022 08:00	4,573.8	136.9	4,710.7	104,046.0	490.1	0.59	0.3	1.0
11/09/2022 09:00	4,166.8	70.0	4,203.2	104,046.0	437.3	0.53	0.3	0.9
11/09/2022 10:00	2,746.1	0.0	2,746.1	104,046.0	285.7	0.34	0.2	0.6
11/09/2022 11:00	2,764.2	0.0	2,764.2	104,046.0	287.6	0.35	0.2	0.6
11/09/2022 12:00	2,757.6	0.0	2,757.6	104,046.0	286.9	0.34	0.2	0.6
11/09/2022 13:00	2,757.2	0.0	2,757.2	104,046.0	286.9	0.34	0.2	0.6
11/09/2022 14:00	2,750.5	0.0	2,750.5	104,046.0	286.2	0.34	0.2	0.6
11/09/2022 15:00	2,738.8	0.0	2,738.8	104,046.0	285.0	0.34	0.2	0.6
11/09/2022 16:00	3,758.9	0.0	3,758.9	104,046.0	391.1	0.47	0.2	0.8
11/09/2022 17:00	4,461.1	0.0	4,461.1	104,046.0	464.2	0.56	0.3	0.9
11/09/2022 18:00	4,531.0	94.3	4,595.1	104,046.0	478.1	0.58	0.3	1.0
11/09/2022 19:00	4,583.1	139.9	4,723.0	104,046.0	491.4	0.59	0.3	1.0
11/09/2022 20:00	4,236.0	99.5	4,305.7	104,046.0	448.0	0.54	0.3	0.9
11/09/2022 21:00	3,050.4	0.0	3,050.4	104,046.0	317.4	0.38	0.2	0.6
11/09/2022 22:00	2,752.5	0.0	2,752.5	104,046.0	286.4	0.34	0.2	0.6
11/09/2022 23:00	2,801.4	0.0	2,801.4	104,046.0	291.5	0.35	0.2	0.6
Average/Sum#:	3,832.7	68.3	3,897.1	104,046.0	405.5	0.49	0.3	0.8
Minimum:	2,738.8	0.0	2,738.8	104,046.0	285.0	0.34	0.2	0.6
Maximum:	4,583.1	139.9	4,723.0	104,046.0	491.4	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2022 00:00	2,856.8	0.0	2,856.8	104,046.0	297.2	0.36	0.2	0.6
11/10/2022 01:00	2,791.0	0.0	2,791.0	104,046.0	290.4	0.35	0.2	0.6
11/10/2022 02:00	2,790.8	0.0	2,790.8	104,046.0	290.4	0.35	0.2	0.6
11/10/2022 03:00	3,201.8	0.0	3,201.8	104,046.0	333.1	0.40	0.2	0.7
11/10/2022 04:00	3,860.2	0.0	3,860.2	104,046.0	401.6	0.48	0.2	0.8
11/10/2022 05:00	4,220.9	68.3	4,236.6	104,046.0	440.8	0.54	0.3	0.9
11/10/2022 06:00	4,665.6	1,038.2	5,703.8	104,046.0	593.5	0.71	0.4	1.2
11/10/2022 07:00	4,659.5	204.4	4,863.9	104,046.0	506.1	0.61	0.3	1.0
11/10/2022 08:00	3,211.3	2.0	3,211.3	104,046.0	334.1	0.40	0.2	0.7
11/10/2022 09:00	3,491.6	0.0	3,491.6	104,046.0	363.3	0.44	0.2	0.7
11/10/2022 10:00	2,668.6	0.0	2,668.6	104,046.0	277.7	0.33	0.2	0.6
11/10/2022 11:00	2,680.6	0.0	2,680.6	104,046.0	278.9	0.33	0.2	0.6
11/10/2022 12:00	2,679.5	0.0	2,679.5	104,046.0	278.8	0.33	0.2	0.6
11/10/2022 13:00	2,676.5	0.0	2,676.5	104,046.0	278.5	0.33	0.2	0.6
11/10/2022 14:00	2,676.3	0.0	2,676.3	104,046.0	278.5	0.33	0.2	0.6
11/10/2022 15:00	3,537.1	81.8	3,555.1	104,046.0	369.9	0.45	0.2	0.8
11/10/2022 16:00	4,516.3	825.1	5,341.4	104,046.0	555.8	0.67	0.3	1.1
11/10/2022 17:00	4,544.2	791.6	5,335.8	104,046.0	555.2	0.67	0.3	1.1
11/10/2022 18:00	4,555.7	531.4	5,087.1	104,046.0	529.3	0.64	0.3	1.1
11/10/2022 19:00	4,556.4	438.6	4,995.0	104,046.0	519.7	0.62	0.3	1.0
11/10/2022 20:00	4,566.4	509.7	5,076.1	104,046.0	528.1	0.63	0.3	1.1
11/10/2022 21:00	4,580.6	773.3	5,353.9	104,046.0	557.1	0.67	0.3	1.1
11/10/2022 22:00	4,594.5	606.4	5,200.9	104,046.0	541.1	0.65	0.3	1.1
11/10/2022 23:00	4,584.1	372.4	4,956.5	104,046.0	515.7	0.62	0.3	1.0
Average/Sum#:	3,715.3	260.1	3,970.5	104,046.0	413.1	0.50	0.3	0.8
Minimum:	2,668.6	0.0	2,668.6	104,046.0	277.7	0.33	0.2	0.6
Maximum:	4,665.6	1,038.2	5,703.8	104,046.0	593.5	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2022 00:00	4,593.6	802.3	5,395.9	104,046.0	561.4	0.67	0.3	1.1
11/11/2022 01:00	4,591.7	666.6	5,258.3	104,046.0	547.1	0.66	0.3	1.1
11/11/2022 02:00	4,551.5	234.7	4,732.2	104,046.0	492.4	0.60	0.3	1.0
11/11/2022 03:00	4,238.8	0.0	4,238.8	104,046.0	441.0	0.53	0.3	0.9
11/11/2022 04:00	4,491.1	86.3	4,515.3	104,046.0	469.8	0.57	0.3	1.0
11/11/2022 05:00	4,625.3	794.6	5,419.9	104,046.0	563.9	0.68	0.3	1.1
11/11/2022 06:00	4,636.4	833.4	5,469.8	104,046.0	569.1	0.68	0.3	1.1
11/11/2022 07:00	4,560.8	136.7	4,666.1	104,046.0	485.5	0.59	0.3	1.0
11/11/2022 08:00	2,795.6	0.0	2,795.6	104,046.0	290.9	0.35	0.2	0.6
11/11/2022 09:00	2,785.5	0.0	2,785.5	104,046.0	289.8	0.35	0.2	0.6
11/11/2022 10:00	2,820.5	0.0	2,820.5	104,046.0	293.5	0.35	0.2	0.6
11/11/2022 11:00	2,783.7	0.0	2,783.7	104,046.0	289.6	0.35	0.2	0.6
11/11/2022 12:00	2,776.3	0.0	2,776.3	104,046.0	288.9	0.35	0.2	0.6
11/11/2022 13:00	2,780.4	0.0	2,780.4	104,046.0	289.3	0.35	0.2	0.6
11/11/2022 14:00	2,844.0	0.0	2,844.0	104,046.0	295.9	0.36	0.2	0.6
11/11/2022 15:00	4,145.3	300.4	4,286.5	104,046.0	446.0	0.55	0.3	0.9
11/11/2022 16:00	4,511.4	691.4	5,202.8	104,046.0	541.3	0.65	0.3	1.1
11/11/2022 17:00	4,529.8	484.7	5,014.5	104,046.0	521.7	0.63	0.3	1.0
11/11/2022 18:00	4,531.5	478.1	5,009.6	104,046.0	521.2	0.63	0.3	1.0
11/11/2022 19:00	4,545.0	451.4	4,996.4	104,046.0	519.9	0.62	0.3	1.0
11/11/2022 20:00	4,557.4	487.4	5,044.8	104,046.0	524.9	0.63	0.3	1.0
11/11/2022 21:00	4,566.9	809.4	5,376.3	104,046.0	559.4	0.67	0.3	1.1
11/11/2022 22:00	4,578.5	719.7	5,298.2	104,046.0	551.3	0.66	0.3	1.1
11/11/2022 23:00	4,582.3	481.1	5,063.4	104,046.0	526.8	0.63	0.3	1.1
Average/Sum#:	4,017.6	352.4	4,357.3	104,046.0	453.4	0.55	0.3	0.9
Minimum:	2,776.3	0.0	2,776.3	104,046.0	288.9	0.35	0.2	0.6
Maximum:	4,636.4	833.4	5,469.8	104,046.0	569.1	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2022 00:00	4,566.0	775.4	5,341.4	104,046.0	555.8	0.67	0.3	1.1
11/12/2022 01:00	4,568.8	772.0	5,340.8	104,046.0	555.7	0.67	0.3	1.1
11/12/2022 02:00	4,573.7	799.5	5,373.2	104,046.0	559.1	0.67	0.3	1.1
11/12/2022 03:00	4,564.5	989.9	5,554.4	104,046.0	577.9	0.69	0.3	1.2
11/12/2022 04:00	4,562.0	939.1	5,501.1	104,046.0	572.4	0.69	0.3	1.1
11/12/2022 05:00	4,572.3	894.3	5,466.6	104,046.0	568.8	0.68	0.3	1.1
11/12/2022 06:00	4,573.6	897.0	5,470.6	104,046.0	569.2	0.68	0.3	1.1
11/12/2022 07:00	4,581.9	240.6	4,822.5	104,046.0	501.8	0.60	0.3	1.0
11/12/2022 08:00	4,571.3	986.0	5,557.3	104,046.0	578.2	0.69	0.3	1.2
11/12/2022 09:00	4,571.9	566.4	5,138.3	104,046.0	534.6	0.64	0.3	1.1
11/12/2022 10:00	4,555.9	367.4	4,923.3	104,046.0	512.2	0.61	0.3	1.0
11/12/2022 11:00	4,453.3	173.9	4,543.7	104,046.0	472.8	0.58	0.3	1.0
11/12/2022 12:00	4,428.4	0.0	4,428.4	104,046.0	460.8	0.55	0.3	0.9
11/12/2022 13:00	4,375.5	0.0	4,375.5	104,046.0	455.3	0.55	0.3	0.9
11/12/2022 14:00	4,466.5	370.0	4,699.6	104,046.0	489.0	0.60	0.3	1.0
11/12/2022 15:00	4,480.3	442.7	4,923.0	104,046.0	512.2	0.61	0.3	1.0
11/12/2022 16:00	4,478.2	649.9	5,128.1	104,046.0	533.6	0.64	0.3	1.1
11/12/2022 17:00	4,499.0	602.0	5,101.0	104,046.0	530.7	0.64	0.3	1.1
11/12/2022 18:00	4,497.1	478.8	4,975.9	104,046.0	517.7	0.62	0.3	1.0
11/12/2022 19:00	4,513.8	668.1	5,181.9	104,046.0	539.2	0.65	0.3	1.1
11/12/2022 20:00	4,527.2	485.2	5,012.4	104,046.0	521.5	0.63	0.3	1.0
11/12/2022 21:00	4,540.9	531.6	5,072.5	104,046.0	527.8	0.63	0.3	1.1
11/12/2022 22:00	4,558.9	598.9	5,157.8	104,046.0	536.6	0.64	0.3	1.1
11/12/2022 23:00	4,574.3	382.9	4,957.2	104,046.0	515.8	0.62	0.3	1.0
Average/Sum#:	4,527.3	567.2	5,085.3	104,046.0	529.1	0.64	0.3	1.1
Minimum:	4,375.5	0.0	4,375.5	104,046.0	455.3	0.55	0.3	0.9
Maximum:	4,581.9	989.9	5,557.3	104,046.0	578.2	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2022 00:00	4,414.7	2.0	4,414.7	104,046.0	459.3	0.55	0.3	0.9
11/13/2022 01:00	4,307.6	0.0	4,307.6	104,046.0	448.2	0.54	0.3	0.9
11/13/2022 02:00	4,271.6	0.0	4,271.6	104,046.0	444.4	0.53	0.3	0.9
11/13/2022 03:00	4,469.8	0.0	4,469.8	104,046.0	465.1	0.56	0.3	0.9
11/13/2022 04:00	4,451.9	0.0	4,451.9	104,046.0	463.2	0.56	0.3	0.9
11/13/2022 05:00	4,452.8	0.0	4,452.8	104,046.0	463.3	0.56	0.3	0.9
11/13/2022 06:00	4,518.8	62.5	4,533.2	104,046.0	471.7	0.57	0.3	1.0
11/13/2022 07:00	4,611.8	436.6	5,048.4	104,046.0	525.3	0.63	0.3	1.1
11/13/2022 08:00	4,513.7	56.9	4,527.9	104,046.0	471.1	0.57	0.3	1.0
11/13/2022 09:00	4,583.4	614.4	5,197.8	104,046.0	540.8	0.65	0.3	1.1
11/13/2022 10:00	4,441.3	2.3	4,441.3	104,046.0	462.1	0.55	0.3	0.9
11/13/2022 11:00	4,370.3	0.0	4,370.3	104,046.0	454.7	0.55	0.3	0.9
11/13/2022 12:00	4,278.4	0.0	4,278.4	104,046.0	445.2	0.53	0.3	0.9
11/13/2022 13:00	4,174.6	0.0	4,174.6	104,046.0	434.4	0.52	0.3	0.9
11/13/2022 14:00	3,856.9	0.0	3,856.9	104,046.0	401.3	0.48	0.2	0.8
11/13/2022 15:00	3,758.3	0.0	3,758.3	104,046.0	391.0	0.47	0.2	0.8
11/13/2022 16:00	4,452.2	866.4	5,292.6	104,046.0	550.7	0.66	0.3	1.1
11/13/2022 17:00	4,496.0	902.1	5,398.1	104,046.0	561.7	0.67	0.3	1.1
11/13/2022 18:00	4,506.1	852.7	5,358.8	104,046.0	557.6	0.67	0.3	1.1
11/13/2022 19:00	4,531.0	625.7	5,156.7	104,046.0	536.5	0.64	0.3	1.1
11/13/2022 20:00	4,548.9	475.4	5,024.3	104,046.0	522.8	0.63	0.3	1.0
11/13/2022 21:00	4,556.1	845.8	5,401.9	104,046.0	562.0	0.67	0.3	1.1
11/13/2022 22:00	4,559.2	754.1	5,313.3	104,046.0	552.8	0.66	0.3	1.1
11/13/2022 23:00	4,559.1	682.5	5,241.6	104,046.0	545.4	0.65	0.3	1.1
Average/Sum#:	4,403.5	299.1	4,697.6	104,046.0	488.8	0.59	0.3	1.0
Minimum:	3,758.3	0.0	3,758.3	104,046.0	391.0	0.47	0.2	0.8
Maximum:	4,611.8	902.1	5,401.9	104,046.0	562.0	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2022 00:00	4,537.3	383.1	4,832.3	104,046.0	502.8	0.61	0.3	1.0
11/14/2022 01:00	4,443.1	0.0	4,443.1	104,046.0	462.3	0.55	0.3	0.9
11/14/2022 02:00	4,435.3	0.0	4,435.3	104,046.0	461.5	0.55	0.3	0.9
11/14/2022 03:00	4,204.9	0.0	4,204.9	104,046.0	437.5	0.53	0.3	0.9
11/14/2022 04:00	4,330.9	0.0	4,330.9	104,046.0	450.6	0.54	0.3	0.9
11/14/2022 05:00	4,626.7	703.2	5,315.8	104,046.0	553.1	0.67	0.3	1.1
11/14/2022 06:00	4,645.5	1,633.9	6,279.4	104,046.0	653.3	0.78	0.4	1.3
11/14/2022 07:00	4,649.6	1,081.4	5,731.0	104,046.0	596.3	0.72	0.4	1.2
11/14/2022 08:00	4,639.9	468.6	5,108.5	104,046.0	531.5	0.64	0.3	1.1
11/14/2022 09:00	4,546.6	357.5	4,821.9	104,046.0	501.7	0.61	0.3	1.0
11/14/2022 10:00	4,312.7	0.0	4,312.7	104,046.0	448.7	0.54	0.3	0.9
11/14/2022 11:00	3,933.2	0.0	3,933.2	104,046.0	409.2	0.49	0.2	0.8
11/14/2022 12:00	3,586.2	0.0	3,586.2	104,046.0	373.1	0.45	0.2	0.7
11/14/2022 13:00	3,931.9	0.0	3,931.9	104,046.0	409.1	0.49	0.2	0.8
11/14/2022 14:00	4,199.1	0.0	4,199.1	104,046.0	436.9	0.52	0.3	0.9
11/14/2022 15:00	4,325.2	362.0	4,513.4	104,046.0	469.6	0.59	0.3	1.0
11/14/2022 16:00	4,500.5	954.6	5,455.1	104,046.0	567.6	0.68	0.3	1.1
11/14/2022 17:00	4,515.6	1,073.2	5,588.8	104,046.0	581.5	0.70	0.3	1.2
11/14/2022 18:00	4,548.2	926.0	5,474.2	104,046.0	569.6	0.68	0.3	1.1
11/14/2022 19:00	4,550.1	805.1	5,355.2	104,046.0	557.2	0.67	0.3	1.1
11/14/2022 20:00	4,544.0	1,009.1	5,553.1	104,046.0	577.8	0.69	0.3	1.2
11/14/2022 21:00	4,570.8	910.6	5,481.4	104,046.0	570.3	0.68	0.3	1.1
11/14/2022 22:00	4,616.8	861.0	5,477.8	104,046.0	569.9	0.68	0.3	1.1
11/14/2022 23:00	4,624.7	586.3	5,211.0	104,046.0	542.2	0.65	0.3	1.1
Average/Sum#:	4,409.1	504.8	4,899.0	104,046.0	509.7	0.61	0.3	1.0
Minimum:	3,586.2	0.0	3,586.2	104,046.0	373.1	0.45	0.2	0.7
Maximum:	4,649.6	1,633.9	6,279.4	104,046.0	653.3	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	4,633.2	973.9	5,607.1	104,046.0	583.4	0.70	0.4	1.2
11/15/2022 01:00	4,635.2	998.0	5,633.2	104,046.0	586.1	0.70	0.4	1.2
11/15/2022 02:00	4,622.2	1,048.0	5,670.2	104,046.0	590.0	0.71	0.4	1.2
11/15/2022 03:00	4,650.8	939.1	5,589.9	104,046.0	581.6	0.70	0.3	1.2
11/15/2022 04:00	4,645.8	1,022.2	5,668.0	104,046.0	589.7	0.71	0.4	1.2
11/15/2022 05:00	4,645.1	1,033.1	5,678.2	104,046.0	590.8	0.71	0.4	1.2
11/15/2022 06:00	4,636.1	1,147.3	5,783.4	104,046.0	601.7	0.72	0.4	1.2
11/15/2022 07:00	4,654.1	1,004.7	5,658.8	104,046.0	588.8	0.71	0.4	1.2
11/15/2022 08:00	4,626.5	547.9	5,174.4	104,046.0	538.4	0.65	0.3	1.1
11/15/2022 09:00	4,227.3	56.7	4,242.6	104,046.0	441.4	0.54	0.3	0.9
11/15/2022 10:00	3,558.3	0.0	3,558.3	104,046.0	370.2	0.44	0.2	0.7
11/15/2022 11:00	3,159.1	0.0	3,159.1	104,046.0	328.7	0.39	0.2	0.7
11/15/2022 12:00	2,752.7	0.0	2,752.7	104,046.0	286.4	0.34	0.2	0.6
11/15/2022 13:00	2,735.5	0.0	2,735.5	104,046.0	284.6	0.34	0.2	0.6
11/15/2022 14:00	2,755.7	0.0	2,755.7	104,046.0	286.7	0.35	0.2	0.6
11/15/2022 15:00	3,571.6	132.0	3,607.2	104,046.0	375.3	0.46	0.2	0.8
11/15/2022 16:00	4,430.2	877.8	5,308.0	104,046.0	552.3	0.66	0.3	1.1
11/15/2022 17:00	4,471.2	988.2	5,459.4	104,046.0	568.0	0.68	0.3	1.1
11/15/2022 18:00	4,497.0	1,051.7	5,548.7	104,046.0	577.3	0.69	0.3	1.2
11/15/2022 19:00	4,529.1	851.9	5,381.0	104,046.0	559.9	0.67	0.3	1.1
11/15/2022 20:00	4,527.4	741.1	5,268.5	104,046.0	548.2	0.66	0.3	1.1
11/15/2022 21:00	4,551.0	783.7	5,334.7	104,046.0	555.1	0.67	0.3	1.1
11/15/2022 22:00	4,573.7	391.5	4,965.2	104,046.0	516.6	0.62	0.3	1.0
11/15/2022 23:00	4,588.5	424.8	5,013.3	104,046.0	521.6	0.63	0.3	1.0
Average/Sum#:	4,194.9	625.6	4,814.7	104,046.0	501.0	0.60	0.3	1.0
Minimum:	2,735.5	0.0	2,735.5	104,046.0	284.6	0.34	0.2	0.6
Maximum:	4,654.1	1,147.3	5,783.4	104,046.0	601.7	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	4,604.3	507.2	5,111.5	104,046.0	531.8	0.64	0.3	1.1
11/16/2022 01:00	4,595.7	531.9	5,127.6	104,046.0	533.5	0.64	0.3	1.1
11/16/2022 02:00	4,606.0	497.6	5,103.6	104,046.0	531.0	0.64	0.3	1.1
11/16/2022 03:00	4,627.4	477.6	5,105.0	104,046.0	531.2	0.64	0.3	1.1
11/16/2022 04:00	4,644.7	727.6	5,372.3	104,046.0	559.0	0.67	0.3	1.1
11/16/2022 05:00	4,675.8	783.7	5,459.5	104,046.0	568.0	0.68	0.3	1.1
11/16/2022 06:00	4,668.8	1,034.0	5,702.8	104,046.0	593.4	0.71	0.4	1.2
11/16/2022 07:00	4,687.4	780.8	5,468.2	104,046.0	568.9	0.68	0.3	1.1
11/16/2022 08:00	4,275.3	61.5	4,303.0	104,046.0	447.7	0.54	0.3	0.9
11/16/2022 09:00	3,884.9	0.0	3,884.9	104,046.0	404.2	0.49	0.2	0.8
11/16/2022 10:00	3,050.3	0.0	3,050.3	104,046.0	317.4	0.38	0.2	0.6
11/16/2022 11:00	2,841.2	0.0	2,841.2	104,046.0	295.6	0.35	0.2	0.6
11/16/2022 12:00	3,720.2	0.0	3,720.2	104,046.0	387.1	0.46	0.2	0.8
11/16/2022 13:00	3,480.5	0.0	3,480.5	104,046.0	362.1	0.43	0.2	0.7
11/16/2022 14:00	2,728.1	0.0	2,728.1	104,046.0	283.8	0.34	0.2	0.6
11/16/2022 15:00	3,850.1	0.0	3,850.1	104,046.0	400.6	0.48	0.2	0.8
11/16/2022 16:00	4,468.4	42.2	4,483.2	104,046.0	466.5	0.56	0.3	0.9
11/16/2022 17:00	4,492.0	139.9	4,631.9	104,046.0	481.9	0.58	0.3	1.0
11/16/2022 18:00	4,545.4	1,072.7	5,618.1	104,046.0	584.5	0.70	0.4	1.2
11/16/2022 19:00	4,563.3	1,041.0	5,604.3	104,046.0	583.1	0.70	0.3	1.2
11/16/2022 20:00	4,585.9	246.5	4,832.4	104,046.0	502.8	0.60	0.3	1.0
11/16/2022 21:00	4,609.5	1,040.3	5,649.8	104,046.0	587.8	0.70	0.4	1.2
11/16/2022 22:00	4,593.5	901.5	5,495.0	104,046.0	571.7	0.69	0.3	1.1
11/16/2022 23:00	4,596.1	663.9	5,260.0	104,046.0	547.3	0.66	0.3	1.1
Average/Sum#:	4,224.8	439.6	4,661.8	104,046.0	485.0	0.58	0.3	1.0
Minimum:	2,728.1	0.0	2,728.1	104,046.0	283.8	0.34	0.2	0.6
Maximum:	4,687.4	1,072.7	5,702.8	104,046.0	593.4	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2022 00:00	4,430.3	1.7	4,430.3	104,046.0	461.0	0.55	0.3	0.9
11/17/2022 01:00	4,444.6	0.0	4,444.6	104,046.0	462.4	0.56	0.3	0.9
11/17/2022 02:00	4,375.7	0.0	4,375.7	104,046.0	455.3	0.55	0.3	0.9
11/17/2022 03:00	4,385.0	0.0	4,385.0	104,046.0	456.2	0.55	0.3	0.9
11/17/2022 04:00	4,431.8	0.0	4,431.8	104,046.0	461.1	0.55	0.3	0.9
11/17/2022 05:00	4,435.0	0.0	4,435.0	104,046.0	461.4	0.55	0.3	0.9
11/17/2022 06:00	4,503.5	74.3	4,523.6	104,046.0	470.7	0.57	0.3	1.0
11/17/2022 07:00	4,660.9	358.2	5,019.1	104,046.0	522.2	0.63	0.3	1.0
11/17/2022 08:00	3,221.9	0.0	3,221.9	104,046.0	335.2	0.40	0.2	0.7
11/17/2022 09:00	4,275.2	2.8	4,275.3	104,046.0	444.8	0.53	0.3	0.9
11/17/2022 10:00	4,572.1	502.5	5,074.6	104,046.0	528.0	0.63	0.3	1.1
11/17/2022 11:00	4,391.0	69.7	4,410.5	104,046.0	458.9	0.56	0.3	0.9
11/17/2022 12:00	4,462.0	9.1	4,462.5	104,046.0	464.3	0.56	0.3	0.9
11/17/2022 13:00	4,463.8	569.1	5,032.9	104,046.0	523.7	0.63	0.3	1.0
11/17/2022 14:00	4,451.7	444.5	4,896.2	104,046.0	509.4	0.61	0.3	1.0
11/17/2022 15:00	4,460.4	745.8	5,206.2	104,046.0	541.7	0.65	0.3	1.1
11/17/2022 16:00	4,460.5	896.7	5,357.2	104,046.0	557.4	0.67	0.3	1.1
11/17/2022 17:00	4,478.8	1,050.2	5,529.0	104,046.0	575.3	0.69	0.3	1.2
11/17/2022 18:00	4,511.0	1,028.2	5,539.2	104,046.0	576.3	0.69	0.3	1.2
11/17/2022 19:00	4,540.8	1,027.2	5,568.0	104,046.0	579.3	0.70	0.3	1.2
11/17/2022 20:00	4,545.6	875.5	5,421.1	104,046.0	564.0	0.68	0.3	1.1
11/17/2022 21:00	4,562.1	669.0	5,231.1	104,046.0	544.3	0.65	0.3	1.1
11/17/2022 22:00	4,598.4	556.3	5,154.7	104,046.0	536.3	0.64	0.3	1.1
11/17/2022 23:00	4,609.4	481.2	5,090.6	104,046.0	529.7	0.63	0.3	1.1
Average/Sum#:	4,428.0	390.1	4,813.2	104,046.0	500.8	0.60	0.3	1.0
Minimum:	3,221.9	0.0	3,221.9	104,046.0	335.2	0.40	0.2	0.7
Maximum:	4,660.9	1,050.2	5,568.0	104,046.0	579.3	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2022 00:00	4,619.2	789.6	5,408.8	104,046.0	562.8	0.68	0.3	1.1
11/18/2022 01:00	4,610.0	636.1	5,246.1	104,046.0	545.8	0.66	0.3	1.1
11/18/2022 02:00	4,624.6	675.1	5,299.7	104,046.0	551.4	0.66	0.3	1.1
11/18/2022 03:00	4,625.6	900.8	5,526.4	104,046.0	575.0	0.69	0.3	1.2
11/18/2022 04:00	4,620.9	977.3	5,598.2	104,046.0	582.5	0.70	0.3	1.2
11/18/2022 05:00	4,627.4	1,165.8	5,793.2	104,046.0	602.8	0.72	0.4	1.2
11/18/2022 06:00	4,621.3	1,804.3	6,425.6	104,046.0	668.6	0.80	0.4	1.3
11/18/2022 07:00	4,626.7	1,101.3	5,728.0	104,046.0	596.0	0.72	0.4	1.2
11/18/2022 08:00	4,613.7	883.7	5,497.4	104,046.0	572.0	0.69	0.3	1.1
11/18/2022 09:00	4,576.3	723.5	5,299.8	104,046.0	551.4	0.66	0.3	1.1
11/18/2022 10:00	4,538.4	604.7	5,143.1	104,046.0	535.1	0.64	0.3	1.1
11/18/2022 11:00	4,494.6	548.1	5,042.7	104,046.0	524.7	0.63	0.3	1.0
11/18/2022 12:00	4,459.9	469.3	4,929.2	104,046.0	512.9	0.62	0.3	1.0
11/18/2022 13:00	4,429.1	531.1	4,960.2	104,046.0	516.1	0.62	0.3	1.0
11/18/2022 14:00	4,415.5	562.1	4,977.6	104,046.0	517.9	0.62	0.3	1.0
11/18/2022 15:00	4,413.5	756.1	5,169.6	104,046.0	537.9	0.65	0.3	1.1
11/18/2022 16:00	4,432.7	1,210.8	5,643.5	104,046.0	587.2	0.71	0.4	1.2
11/18/2022 17:00	4,466.0	1,339.7	5,805.7	104,046.0	604.1	0.72	0.4	1.2
11/18/2022 18:00	4,511.2	1,261.3	5,772.5	104,046.0	600.6	0.72	0.4	1.2
11/18/2022 19:00	4,523.5	1,108.9	5,632.4	104,046.0	586.0	0.70	0.4	1.2
11/18/2022 20:00	4,542.7	1,194.9	5,737.6	104,046.0	597.0	0.72	0.4	1.2
11/18/2022 21:00	4,561.2	1,175.7	5,736.9	104,046.0	596.9	0.72	0.4	1.2
11/18/2022 22:00	4,583.4	1,060.8	5,644.2	104,046.0	587.3	0.70	0.4	1.2
11/18/2022 23:00	4,590.0	894.8	5,484.8	104,046.0	570.7	0.68	0.3	1.1
Average/Sum#:	4,547.0	932.3	5,479.3	104,046.0	570.1	0.68	0.3	1.1
Minimum:	4,413.5	469.3	4,929.2	104,046.0	512.9	0.62	0.3	1.0
Maximum:	4,627.4	1,804.3	6,425.6	104,046.0	668.6	0.80	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2022 00:00	4,594.6	596.3	5,190.9	104,046.0	540.1	0.65	0.3	1.1
11/19/2022 01:00	4,606.1	568.7	5,174.8	104,046.0	538.4	0.65	0.3	1.1
11/19/2022 02:00	4,637.7	499.0	5,136.7	104,046.0	534.5	0.64	0.3	1.1
11/19/2022 03:00	4,660.8	369.5	5,030.3	104,046.0	523.4	0.63	0.3	1.0
11/19/2022 04:00	4,654.2	671.1	5,325.3	104,046.0	554.1	0.67	0.3	1.1
11/19/2022 05:00	4,664.8	857.0	5,521.8	104,046.0	574.5	0.69	0.3	1.1
11/19/2022 06:00	4,681.9	1,003.3	5,685.2	104,046.0	591.5	0.71	0.4	1.2
11/19/2022 07:00	4,671.3	928.3	5,599.6	104,046.0	582.6	0.70	0.3	1.2
11/19/2022 08:00	3,735.4	79.5	3,753.7	104,046.0	390.6	0.48	0.2	0.8
11/19/2022 09:00	2,764.2	0.0	2,764.2	104,046.0	287.6	0.35	0.2	0.6
11/19/2022 10:00	2,804.2	0.0	2,804.2	104,046.0	291.8	0.35	0.2	0.6
11/19/2022 11:00	2,807.9	0.0	2,807.9	104,046.0	292.2	0.35	0.2	0.6
11/19/2022 12:00	2,807.0	0.0	2,807.0	104,046.0	292.1	0.35	0.2	0.6
11/19/2022 13:00	2,804.2	0.0	2,804.2	104,046.0	291.8	0.35	0.2	0.6
11/19/2022 14:00	2,730.2	0.0	2,730.2	104,046.0	284.1	0.34	0.2	0.6
11/19/2022 15:00	3,319.6	25.4	3,321.6	104,046.0	345.6	0.42	0.2	0.7
11/19/2022 16:00	4,466.8	880.5	5,347.3	104,046.0	556.4	0.67	0.3	1.1
11/19/2022 17:00	4,511.5	712.5	5,224.0	104,046.0	543.5	0.65	0.3	1.1
11/19/2022 18:00	4,526.2	695.1	5,221.3	104,046.0	543.3	0.65	0.3	1.1
11/19/2022 19:00	4,542.6	994.7	5,537.3	104,046.0	576.1	0.69	0.3	1.2
11/19/2022 20:00	4,558.1	1,125.1	5,683.2	104,046.0	591.3	0.71	0.4	1.2
11/19/2022 21:00	4,585.8	1,077.7	5,663.5	104,046.0	589.3	0.71	0.4	1.2
11/19/2022 22:00	4,614.6	1,072.8	5,687.4	104,046.0	591.8	0.71	0.4	1.2
11/19/2022 23:00	4,658.2	1,074.0	5,732.2	104,046.0	596.4	0.72	0.4	1.2
Average/Sum#:	4,058.7	551.3	4,606.4	104,046.0	479.3	0.58	0.3	1.0
Minimum:	2,730.2	0.0	2,730.2	104,046.0	284.1	0.34	0.2	0.6
Maximum:	4,681.9	1,125.1	5,732.2	104,046.0	596.4	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2022 00:00	4,649.1	1,077.1	5,726.2	104,046.0	595.8	0.71	0.4	1.2
11/20/2022 01:00	4,679.6	1,079.3	5,758.9	104,046.0	599.2	0.72	0.4	1.2
11/20/2022 02:00	4,682.4	1,080.4	5,762.8	104,046.0	599.6	0.72	0.4	1.2
11/20/2022 03:00	4,676.8	1,080.5	5,757.3	104,046.0	599.0	0.72	0.4	1.2
11/20/2022 04:00	4,674.8	1,081.7	5,756.5	104,046.0	598.9	0.72	0.4	1.2
11/20/2022 05:00	4,672.3	993.0	5,665.3	104,046.0	589.5	0.71	0.4	1.2
11/20/2022 06:00	4,660.8	874.4	5,535.2	104,046.0	575.9	0.69	0.3	1.2
11/20/2022 07:00	4,656.6	526.0	5,182.6	104,046.0	539.2	0.65	0.3	1.1
11/20/2022 08:00	4,478.5	37.5	4,488.6	104,046.0	467.0	0.56	0.3	0.9
11/20/2022 09:00	4,630.7	10.7	4,631.6	104,046.0	481.9	0.58	0.3	1.0
11/20/2022 10:00	4,562.4	127.5	4,689.9	104,046.0	488.0	0.59	0.3	1.0
11/20/2022 11:00	4,528.9	128.5	4,657.4	104,046.0	484.6	0.58	0.3	1.0
11/20/2022 12:00	4,326.2	33.9	4,334.0	104,046.0	450.9	0.54	0.3	0.9
11/20/2022 13:00	4,476.1	494.9	4,961.1	104,046.0	516.2	0.62	0.3	1.0
11/20/2022 14:00	4,239.9	103.1	4,267.7	104,046.0	444.0	0.54	0.3	0.9
11/20/2022 15:00	3,962.2	128.8	4,000.8	104,046.0	416.3	0.51	0.3	0.9
11/20/2022 16:00	4,473.1	807.2	5,280.3	104,046.0	549.4	0.66	0.3	1.1
11/20/2022 17:00	4,501.9	754.9	5,256.8	104,046.0	546.9	0.66	0.3	1.1
11/20/2022 18:00	4,531.9	627.9	5,159.8	104,046.0	536.9	0.65	0.3	1.1
11/20/2022 19:00	4,544.3	607.2	5,151.5	104,046.0	536.0	0.64	0.3	1.1
11/20/2022 20:00	4,565.9	567.8	5,133.7	104,046.0	534.1	0.64	0.3	1.1
11/20/2022 21:00	4,602.4	413.6	5,016.0	104,046.0	521.9	0.63	0.3	1.0
11/20/2022 22:00	4,610.8	378.1	4,988.9	104,046.0	519.1	0.62	0.3	1.0
11/20/2022 23:00	4,637.5	276.6	4,914.1	104,046.0	511.3	0.62	0.3	1.0
Average/Sum#:	4,542.7	553.8	5,086.5	104,046.0	529.2	0.64	0.3	1.1
Minimum:	3,962.2	10.7	4,000.8	104,046.0	416.3	0.51	0.3	0.9
Maximum:	4,682.4	1,081.7	5,762.8	104,046.0	599.6	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	4,661.3	486.6	5,147.9	104,046.0	535.6	0.64	0.3	1.1
11/21/2022 01:00	4,673.6	333.8	5,007.4	104,046.0	521.0	0.63	0.3	1.0
11/21/2022 02:00	4,666.9	325.5	4,992.4	104,046.0	519.4	0.62	0.3	1.0
11/21/2022 03:00	4,660.5	484.7	5,145.2	104,046.0	535.3	0.64	0.3	1.1
11/21/2022 04:00	4,688.6	794.9	5,483.5	104,046.0	570.5	0.68	0.3	1.1
11/21/2022 05:00	4,679.6	788.5	5,468.1	104,046.0	568.9	0.68	0.3	1.1
11/21/2022 06:00	4,651.5	1,029.1	5,680.6	104,046.0	591.0	0.71	0.4	1.2
11/21/2022 07:00	4,657.9	372.4	5,030.3	104,046.0	523.4	0.63	0.3	1.0
11/21/2022 08:00	3,263.2	5.0	3,263.5	104,046.0	339.6	0.41	0.2	0.7
11/21/2022 09:00	2,777.9	0.0	2,777.9	104,046.0	289.0	0.35	0.2	0.6
11/21/2022 10:00	2,791.5	0.0	2,791.5	104,046.0	290.4	0.35	0.2	0.6
11/21/2022 11:00	2,812.8	0.0	2,812.8	104,046.0	292.7	0.35	0.2	0.6
11/21/2022 12:00	2,881.4	0.0	2,881.4	104,046.0	299.8	0.36	0.2	0.6
11/21/2022 13:00	2,789.8	0.0	2,789.8	104,046.0	290.3	0.35	0.2	0.6
11/21/2022 14:00	4,120.2	3.7	4,120.3	104,046.0	428.7	0.52	0.3	0.9
11/21/2022 15:00	4,445.3	837.9	5,174.3	104,046.0	538.4	0.66	0.3	1.1
11/21/2022 16:00	4,454.0	799.2	5,253.2	104,046.0	546.6	0.66	0.3	1.1
11/21/2022 17:00	4,483.3	755.0	5,238.3	104,046.0	545.0	0.65	0.3	1.1
11/21/2022 18:00	4,503.4	675.2	5,178.6	104,046.0	538.8	0.65	0.3	1.1
11/21/2022 19:00	4,532.9	657.9	5,190.8	104,046.0	540.1	0.65	0.3	1.1
11/21/2022 20:00	4,571.9	663.1	5,235.0	104,046.0	544.7	0.65	0.3	1.1
11/21/2022 21:00	4,597.4	753.3	5,350.7	104,046.0	556.7	0.67	0.3	1.1
11/21/2022 22:00	4,591.5	674.8	5,266.3	104,046.0	547.9	0.66	0.3	1.1
11/21/2022 23:00	4,603.4	412.5	5,015.9	104,046.0	521.9	0.62	0.3	1.0
Average/Sum#:	4,148.3	452.2	4,595.7	104,046.0	478.2	0.57	0.3	1.0
Minimum:	2,777.9	0.0	2,777.9	104,046.0	289.0	0.35	0.2	0.6
Maximum:	4,688.6	1,029.1	5,680.6	104,046.0	591.0	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	4,531.8	1.7	4,531.8	104,046.0	471.5	0.57	0.3	0.9
11/22/2022 01:00	4,469.8	0.0	4,469.8	104,046.0	465.1	0.56	0.3	0.9
11/22/2022 02:00	4,439.8	0.0	4,439.8	104,046.0	461.9	0.56	0.3	0.9
11/22/2022 03:00	4,197.8	0.0	4,197.8	104,046.0	436.8	0.52	0.3	0.9
11/22/2022 04:00	4,290.2	0.0	4,290.2	104,046.0	446.4	0.53	0.3	0.9
11/22/2022 05:00	4,383.7	0.0	4,383.7	104,046.0	456.1	0.55	0.3	0.9
11/22/2022 06:00	4,573.7	0.0	4,573.7	104,046.0	475.9	0.57	0.3	1.0
11/22/2022 07:00	3,371.9	0.0	3,371.9	104,046.0	350.8	0.42	0.2	0.7
11/22/2022 08:00	3,948.8	53.4	3,969.1	104,046.0	413.0	0.50	0.2	0.8
11/22/2022 09:00	4,594.7	576.2	5,170.9	104,046.0	538.0	0.65	0.3	1.1
11/22/2022 10:00	4,498.2	62.9	4,515.2	104,046.0	469.8	0.57	0.3	0.9
11/22/2022 11:00	4,531.0	383.7	4,903.2	104,046.0	510.2	0.61	0.3	1.0
11/22/2022 12:00	4,514.0	732.7	5,246.7	104,046.0	545.9	0.65	0.3	1.1
11/22/2022 13:00	4,490.2	806.1	5,296.3	104,046.0	551.1	0.66	0.3	1.1
11/22/2022 14:00	4,465.5	711.4	5,176.9	104,046.0	538.6	0.65	0.3	1.1
11/22/2022 15:00	4,455.4	573.9	5,029.3	104,046.0	523.3	0.63	0.3	1.0
11/22/2022 16:00	4,489.3	540.1	5,029.4	104,046.0	523.3	0.63	0.3	1.0
11/22/2022 17:00	4,510.0	372.1	4,882.1	104,046.0	508.0	0.61	0.3	1.0
11/22/2022 18:00	4,532.5	319.8	4,852.3	104,046.0	504.9	0.61	0.3	1.0
11/22/2022 19:00	4,536.3	301.7	4,838.0	104,046.0	503.4	0.60	0.3	1.0
11/22/2022 20:00	4,550.5	380.3	4,930.8	104,046.0	513.0	0.62	0.3	1.0
11/22/2022 21:00	4,287.5	139.7	4,360.1	104,046.0	453.7	0.55	0.3	0.9
11/22/2022 22:00	3,352.5	0.0	3,352.5	104,046.0	348.8	0.42	0.2	0.7
11/22/2022 23:00	2,888.6	0.0	2,888.6	104,046.0	300.5	0.36	0.2	0.6
Average/Sum#:	4,287.7	248.2	4,529.2	104,046.0	471.3	0.57	0.3	0.9
Minimum:	2,888.6	0.0	2,888.6	104,046.0	300.5	0.36	0.2	0.6
Maximum:	4,594.7	806.1	5,296.3	104,046.0	551.1	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2022 00:00	3,827.9	0.0	3,827.9	104,046.0	398.3	0.48	0.2	0.8
11/23/2022 01:00	3,480.9	0.0	3,480.9	104,046.0	362.2	0.43	0.2	0.7
11/23/2022 02:00	3,733.2	0.0	3,733.2	104,046.0	388.4	0.47	0.2	0.8
11/23/2022 03:00	3,861.5	0.0	3,861.5	104,046.0	401.8	0.48	0.2	0.8
11/23/2022 04:00	3,970.9	0.0	3,970.9	104,046.0	413.2	0.49	0.2	0.8
11/23/2022 05:00	4,228.6	0.0	4,228.6	104,046.0	440.0	0.53	0.3	0.9
11/23/2022 06:00	4,250.9	0.0	4,250.9	104,046.0	442.3	0.53	0.3	0.9
11/23/2022 07:00	3,418.8	0.0	3,418.8	104,046.0	355.7	0.43	0.2	0.7
11/23/2022 08:00	2,933.7	0.0	2,933.7	104,046.0	305.2	0.37	0.2	0.6
11/23/2022 09:00	3,168.1	0.0	3,168.1	104,046.0	329.6	0.40	0.2	0.7
11/23/2022 10:00	3,319.5	0.0	3,319.5	104,046.0	345.4	0.42	0.2	0.7
11/23/2022 11:00	4,270.5	145.1	4,338.7	104,046.0	451.4	0.55	0.3	0.9
11/23/2022 12:00	4,497.2	419.6	4,916.8	104,046.0	511.6	0.61	0.3	1.0
11/23/2022 13:00	4,180.0	223.7	4,296.3	104,046.0	447.0	0.55	0.3	0.9
11/23/2022 14:00	2,772.4	0.0	2,772.4	104,046.0	288.5	0.34	0.2	0.6
11/23/2022 15:00	3,305.3	43.0	3,312.6	104,046.0	344.7	0.42	0.2	0.7
11/23/2022 16:00	4,425.7	730.2	5,155.9	104,046.0	536.5	0.64	0.3	1.1
11/23/2022 17:00	4,441.8	683.0	5,124.8	104,046.0	533.2	0.64	0.3	1.1
11/23/2022 18:00	4,474.7	405.9	4,880.6	104,046.0	507.8	0.61	0.3	1.0
11/23/2022 19:00	4,514.4	330.6	4,845.0	104,046.0	504.1	0.60	0.3	1.0
11/23/2022 20:00	4,541.9	426.8	4,968.7	104,046.0	517.0	0.62	0.3	1.0
11/23/2022 21:00	4,563.9	606.9	5,170.8	104,046.0	538.0	0.65	0.3	1.1
11/23/2022 22:00	4,591.3	571.1	5,162.4	104,046.0	537.1	0.65	0.3	1.1
11/23/2022 23:00	4,600.4	423.0	5,023.4	104,046.0	522.7	0.63	0.3	1.0
Average/Sum#:	3,973.9	208.7	4,173.4	104,046.0	434.2	0.52	0.3	0.9
Minimum:	2,772.4	0.0	2,772.4	104,046.0	288.5	0.34	0.2	0.6
Maximum:	4,600.4	730.2	5,170.8	104,046.0	538.0	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2022 00:00	4,602.9	524.1	5,127.0	104,046.0	533.4	0.64	0.3	1.1
11/24/2022 01:00	4,620.7	409.6	5,030.3	104,046.0	523.4	0.63	0.3	1.0
11/24/2022 02:00	4,179.8	1.6	4,179.8	104,046.0	434.9	0.52	0.3	0.9
11/24/2022 03:00	4,249.9	0.0	4,249.9	104,046.0	442.2	0.53	0.3	0.9
11/24/2022 04:00	4,253.5	0.0	4,253.5	104,046.0	442.6	0.53	0.3	0.9
11/24/2022 05:00	4,460.5	12.0	4,461.7	104,046.0	464.2	0.56	0.3	0.9
11/24/2022 06:00	4,562.8	63.6	4,578.7	104,046.0	476.4	0.58	0.3	1.0
11/24/2022 07:00	4,639.4	596.1	5,193.8	104,046.0	540.4	0.65	0.3	1.1
11/24/2022 08:00	4,610.3	482.1	5,092.4	104,046.0	529.8	0.64	0.3	1.1
11/24/2022 09:00	4,548.8	603.7	5,152.5	104,046.0	536.1	0.64	0.3	1.1
11/24/2022 10:00	4,522.3	657.8	5,180.1	104,046.0	539.0	0.65	0.3	1.1
11/24/2022 11:00	4,488.9	458.1	4,947.0	104,046.0	514.7	0.62	0.3	1.0
11/24/2022 12:00	4,467.2	486.5	4,953.7	104,046.0	515.4	0.62	0.3	1.0
11/24/2022 13:00	4,449.5	500.1	4,949.6	104,046.0	515.0	0.62	0.3	1.0
11/24/2022 14:00	3,228.0	2.3	3,228.0	104,046.0	335.9	0.40	0.2	0.7
11/24/2022 15:00	3,535.2	199.2	3,604.9	104,046.0	375.1	0.47	0.2	0.8
11/24/2022 16:00	4,444.9	751.4	5,196.3	104,046.0	540.7	0.65	0.3	1.1
11/24/2022 17:00	4,476.8	502.0	4,978.8	104,046.0	518.0	0.62	0.3	1.0
11/24/2022 18:00	4,504.8	384.1	4,888.9	104,046.0	508.7	0.61	0.3	1.0
11/24/2022 19:00	4,524.4	343.6	4,868.0	104,046.0	506.5	0.61	0.3	1.0
11/24/2022 20:00	4,547.5	314.7	4,862.2	104,046.0	505.9	0.61	0.3	1.0
11/24/2022 21:00	4,544.8	303.6	4,848.4	104,046.0	504.5	0.60	0.3	1.0
11/24/2022 22:00	4,573.5	330.7	4,904.2	104,046.0	510.3	0.61	0.3	1.0
11/24/2022 23:00	4,598.2	205.8	4,804.0	104,046.0	499.8	0.60	0.3	1.0
Average/Sum#:	4,401.4	338.9	4,730.6	104,046.0	492.2	0.59	0.3	1.0
Minimum:	3,228.0	0.0	3,228.0	104,046.0	335.9	0.40	0.2	0.7
Maximum:	4,639.4	751.4	5,196.3	104,046.0	540.7	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2022 00:00	4,603.1	190.9	4,794.0	104,046.0	498.8	0.60	0.3	1.0
11/25/2022 01:00	4,617.6	158.5	4,776.1	104,046.0	496.9	0.60	0.3	1.0
11/25/2022 02:00	4,634.7	141.6	4,776.3	104,046.0	497.0	0.60	0.3	1.0
11/25/2022 03:00	4,646.1	227.6	4,873.7	104,046.0	507.1	0.61	0.3	1.0
11/25/2022 04:00	4,626.2	398.7	5,024.9	104,046.0	522.8	0.63	0.3	1.0
11/25/2022 05:00	4,655.9	400.8	5,056.7	104,046.0	526.1	0.63	0.3	1.1
11/25/2022 06:00	4,651.9	506.2	5,158.1	104,046.0	536.7	0.64	0.3	1.1
11/25/2022 07:00	4,654.0	333.0	4,987.0	104,046.0	518.9	0.62	0.3	1.0
11/25/2022 08:00	4,651.1	134.3	4,785.4	104,046.0	497.9	0.60	0.3	1.0
11/25/2022 09:00	3,221.2	1.9	3,221.2	104,046.0	335.2	0.40	0.2	0.7
11/25/2022 10:00	2,737.6	0.0	2,737.6	104,046.0	284.8	0.34	0.2	0.6
11/25/2022 11:00	2,681.0	0.0	2,681.0	104,046.0	278.9	0.33	0.2	0.6
11/25/2022 12:00	2,676.4	0.0	2,676.4	104,046.0	278.5	0.33	0.2	0.6
11/25/2022 13:00	2,687.0	0.0	2,687.0	104,046.0	279.6	0.33	0.2	0.6
11/25/2022 14:00	2,734.4	0.0	2,734.4	104,046.0	284.5	0.34	0.2	0.6
11/25/2022 15:00	3,334.7	27.8	3,338.3	104,046.0	347.3	0.42	0.2	0.7
11/25/2022 16:00	4,429.2	600.3	5,029.5	104,046.0	523.3	0.63	0.3	1.0
11/25/2022 17:00	4,464.7	571.4	5,036.1	104,046.0	524.0	0.63	0.3	1.0
11/25/2022 18:00	4,488.8	391.1	4,879.9	104,046.0	507.7	0.61	0.3	1.0
11/25/2022 19:00	4,534.4	305.5	4,839.9	104,046.0	503.6	0.60	0.3	1.0
11/25/2022 20:00	4,545.8	282.1	4,827.9	104,046.0	502.3	0.60	0.3	1.0
11/25/2022 21:00	4,549.0	294.3	4,843.3	104,046.0	503.9	0.60	0.3	1.0
11/25/2022 22:00	4,558.0	476.8	5,034.8	104,046.0	523.9	0.63	0.3	1.0
11/25/2022 23:00	4,570.1	388.1	4,958.2	104,046.0	515.9	0.62	0.3	1.0
Average/Sum#:	4,081.4	243.0	4,323.2	104,046.0	449.8	0.54	0.3	0.9
Minimum:	2,676.4	0.0	2,676.4	104,046.0	278.5	0.33	0.2	0.6
Maximum:	4,655.9	600.3	5,158.1	104,046.0	536.7	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2022 00:00	4,593.3	576.5	5,169.8	104,046.0	537.9	0.65	0.3	1.1
11/26/2022 01:00	4,614.3	527.5	5,141.8	104,046.0	535.0	0.64	0.3	1.1
11/26/2022 02:00	4,608.0	544.7	5,152.7	104,046.0	536.1	0.64	0.3	1.1
11/26/2022 03:00	4,617.0	554.4	5,171.4	104,046.0	538.1	0.65	0.3	1.1
11/26/2022 04:00	4,617.5	556.5	5,174.0	104,046.0	538.3	0.65	0.3	1.1
11/26/2022 05:00	4,588.4	917.2	5,505.6	104,046.0	572.8	0.69	0.3	1.1
11/26/2022 06:00	4,616.0	1,033.9	5,649.9	104,046.0	587.8	0.71	0.4	1.2
11/26/2022 07:00	4,624.6	547.3	5,171.9	104,046.0	538.1	0.65	0.3	1.1
11/26/2022 08:00	4,485.9	94.9	4,522.0	104,046.0	470.5	0.57	0.3	1.0
11/26/2022 09:00	4,562.1	477.2	5,039.3	104,046.0	524.3	0.63	0.3	1.0
11/26/2022 10:00	3,776.7	1.7	3,776.7	104,046.0	393.0	0.47	0.2	0.8
11/26/2022 11:00	2,744.4	0.0	2,744.4	104,046.0	285.5	0.34	0.2	0.6
11/26/2022 12:00	2,762.8	0.0	2,762.8	104,046.0	287.5	0.35	0.2	0.6
11/26/2022 13:00	2,669.2	0.0	2,669.2	104,046.0	277.7	0.33	0.2	0.6
11/26/2022 14:00	2,710.3	0.0	2,710.3	104,046.0	282.0	0.34	0.2	0.6
11/26/2022 15:00	3,557.1	0.0	3,557.1	104,046.0	370.1	0.44	0.2	0.7
11/26/2022 16:00	4,422.3	586.9	4,932.9	104,046.0	513.2	0.63	0.3	1.0
11/26/2022 17:00	4,432.0	573.3	5,005.3	104,046.0	520.8	0.62	0.3	1.0
11/26/2022 18:00	4,458.6	439.8	4,898.4	104,046.0	509.7	0.61	0.3	1.0
11/26/2022 19:00	4,498.8	360.6	4,859.4	104,046.0	505.6	0.61	0.3	1.0
11/26/2022 20:00	4,508.0	534.7	5,042.7	104,046.0	524.7	0.63	0.3	1.1
11/26/2022 21:00	4,536.2	561.2	5,097.4	104,046.0	530.4	0.64	0.3	1.1
11/26/2022 22:00	4,543.2	320.2	4,863.4	104,046.0	506.0	0.61	0.3	1.0
11/26/2022 23:00	4,553.8	344.2	4,898.0	104,046.0	509.6	0.61	0.3	1.0
Average/Sum#:	4,170.9	398.0	4,563.2	104,046.0	474.8	0.57	0.3	1.0
Minimum:	2,669.2	0.0	2,669.2	104,046.0	277.7	0.33	0.2	0.6
Maximum:	4,624.6	1,033.9	5,649.9	104,046.0	587.8	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2022 00:00	4,568.7	651.6	5,220.3	104,046.0	543.2	0.65	0.3	1.1
11/27/2022 01:00	4,582.2	482.2	5,064.4	104,046.0	526.9	0.63	0.3	1.1
11/27/2022 02:00	4,593.8	297.9	4,891.7	104,046.0	509.0	0.61	0.3	1.0
11/27/2022 03:00	4,578.4	570.6	5,149.0	104,046.0	535.7	0.64	0.3	1.1
11/27/2022 04:00	4,598.0	582.8	5,180.8	104,046.0	539.0	0.65	0.3	1.1
11/27/2022 05:00	4,578.3	391.5	4,969.8	104,046.0	517.1	0.62	0.3	1.0
11/27/2022 06:00	4,615.0	523.6	5,138.6	104,046.0	534.7	0.64	0.3	1.1
11/27/2022 07:00	4,248.8	144.4	4,323.9	104,046.0	449.9	0.55	0.3	0.9
11/27/2022 08:00	2,754.0	0.0	2,754.0	104,046.0	286.5	0.34	0.2	0.6
11/27/2022 09:00	2,727.1	0.0	2,727.1	104,046.0	283.7	0.34	0.2	0.6
11/27/2022 10:00	2,784.8	0.0	2,784.8	104,046.0	289.7	0.35	0.2	0.6
11/27/2022 11:00	2,734.5	0.0	2,734.5	104,046.0	284.5	0.34	0.2	0.6
11/27/2022 12:00	2,673.1	0.0	2,673.1	104,046.0	278.1	0.33	0.2	0.6
11/27/2022 13:00	2,674.8	0.0	2,674.8	104,046.0	278.3	0.33	0.2	0.6
11/27/2022 14:00	2,672.7	0.0	2,672.7	104,046.0	278.1	0.33	0.2	0.6
11/27/2022 15:00	3,866.4	196.6	3,964.7	104,046.0	412.5	0.51	0.3	0.8
11/27/2022 16:00	4,459.1	598.5	5,057.6	104,046.0	526.2	0.63	0.3	1.1
11/27/2022 17:00	4,476.7	720.2	5,196.9	104,046.0	540.7	0.65	0.3	1.1
11/27/2022 18:00	4,497.0	670.8	5,167.8	104,046.0	537.7	0.65	0.3	1.1
11/27/2022 19:00	4,509.6	602.6	5,112.2	104,046.0	531.9	0.64	0.3	1.1
11/27/2022 20:00	4,516.5	487.3	5,003.8	104,046.0	520.6	0.63	0.3	1.0
11/27/2022 21:00	4,514.5	794.6	5,309.1	104,046.0	552.4	0.66	0.3	1.1
11/27/2022 22:00	4,513.2	392.5	4,905.7	104,046.0	510.4	0.61	0.3	1.0
11/27/2022 23:00	4,538.3	300.4	4,838.7	104,046.0	503.4	0.60	0.3	1.0
Average/Sum#:	3,969.8	350.3	4,313.2	104,046.0	448.8	0.54	0.3	0.9
Minimum:	2,672.7	0.0	2,672.7	104,046.0	278.1	0.33	0.2	0.6
Maximum:	4,615.0	794.6	5,309.1	104,046.0	552.4	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	4,528.7	481.5	5,010.2	104,046.0	521.3	0.63	0.3	1.0
11/28/2022 01:00	4,560.5	348.5	4,909.0	104,046.0	510.8	0.61	0.3	1.0
11/28/2022 02:00	4,590.2	205.6	4,795.8	104,046.0	499.0	0.60	0.3	1.0
11/28/2022 03:00	4,566.6	264.6	4,831.2	104,046.0	502.7	0.60	0.3	1.0
11/28/2022 04:00	4,598.4	191.6	4,790.0	104,046.0	498.4	0.60	0.3	1.0
11/28/2022 05:00	4,603.2	330.0	4,933.2	104,046.0	513.3	0.62	0.3	1.0
11/28/2022 06:00	4,606.5	770.6	5,377.1	104,046.0	559.5	0.67	0.3	1.1
11/28/2022 07:00	4,602.2	833.6	5,435.8	104,046.0	565.6	0.68	0.3	1.1
11/28/2022 08:00	4,563.6	266.0	4,829.6	104,046.0	502.5	0.60	0.3	1.0
11/28/2022 09:00	3,699.1	73.8	3,719.8	104,046.0	387.0	0.47	0.2	0.8
11/28/2022 10:00	2,794.8	0.0	2,794.8	104,046.0	290.8	0.35	0.2	0.6
11/28/2022 11:00	2,729.5	0.0	2,729.5	104,046.0	284.0	0.34	0.2	0.6
11/28/2022 12:00	2,665.8	0.0	2,665.8	104,046.0	277.4	0.33	0.2	0.6
11/28/2022 13:00	2,676.2	0.0	2,676.2	104,046.0	278.4	0.33	0.2	0.6
11/28/2022 14:00	2,692.7	0.0	2,692.7	104,046.0	280.2	0.33	0.2	0.6
11/28/2022 15:00	3,533.4	229.7	3,613.8	104,046.0	376.0	0.47	0.2	0.8
11/28/2022 16:00	4,449.3	589.4	5,038.7	104,046.0	524.3	0.63	0.3	1.0
11/28/2022 17:00	4,474.3	528.5	5,002.8	104,046.0	520.5	0.62	0.3	1.0
11/28/2022 18:00	4,498.5	361.2	4,859.7	104,046.0	505.6	0.61	0.3	1.0
11/28/2022 19:00	4,522.6	339.1	4,861.7	104,046.0	505.8	0.61	0.3	1.0
11/28/2022 20:00	4,540.2	476.2	5,016.4	104,046.0	521.9	0.63	0.3	1.0
11/28/2022 21:00	4,543.6	775.3	5,318.9	104,046.0	553.4	0.67	0.3	1.1
11/28/2022 22:00	4,572.3	371.7	4,944.0	104,046.0	514.4	0.62	0.3	1.0
11/28/2022 23:00	4,586.7	201.6	4,788.3	104,046.0	498.2	0.60	0.3	1.0
Average/Sum#:	4,091.6	318.3	4,401.5	104,046.0	458.0	0.55	0.3	0.9
Minimum:	2,665.8	0.0	2,665.8	104,046.0	277.4	0.33	0.2	0.6
Maximum:	4,606.5	833.6	5,435.8	104,046.0	565.6	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2022 00:00	4,475.3	1.7	4,475.3	104,046.0	465.6	0.56	0.3	0.9
11/29/2022 01:00	4,537.7	0.0	4,537.7	104,046.0	472.1	0.57	0.3	0.9
11/29/2022 02:00	4,537.3	0.0	4,537.3	104,046.0	472.1	0.57	0.3	0.9
11/29/2022 03:00	4,325.4	0.0	4,325.4	104,046.0	450.0	0.54	0.3	0.9
11/29/2022 04:00	4,375.1	0.0	4,375.1	104,046.0	455.2	0.55	0.3	0.9
11/29/2022 05:00	4,585.4	0.0	4,585.4	104,046.0	477.1	0.57	0.3	1.0
11/29/2022 06:00	4,588.3	129.6	4,636.3	104,046.0	482.4	0.59	0.3	1.0
11/29/2022 07:00	4,616.6	1,575.8	6,192.4	104,046.0	644.3	0.77	0.4	1.3
11/29/2022 08:00	4,532.6	444.1	4,710.2	104,046.0	490.1	0.62	0.3	1.0
11/29/2022 09:00	4,419.7	0.0	4,419.7	104,046.0	459.9	0.55	0.3	0.9
11/29/2022 10:00	4,421.9	0.0	4,421.9	104,046.0	460.1	0.55	0.3	0.9
11/29/2022 11:00	4,442.2	1.0	4,442.2	104,046.0	462.2	0.55	0.3	0.9
11/29/2022 12:00	3,685.7	0.0	3,685.7	104,046.0	383.5	0.46	0.2	0.8
11/29/2022 13:00	4,403.9	0.0	4,403.9	104,046.0	458.2	0.55	0.3	0.9
11/29/2022 14:00	4,485.8	1,214.4	5,700.2	104,046.0	593.1	0.71	0.4	1.2
11/29/2022 15:00	4,480.8	1,197.8	5,678.6	104,046.0	590.8	0.71	0.4	1.2
11/29/2022 16:00	4,488.0	1,283.4	5,771.4	104,046.0	600.5	0.72	0.4	1.2
11/29/2022 17:00	4,511.6	1,190.6	5,702.2	104,046.0	593.3	0.71	0.4	1.2
11/29/2022 18:00	4,532.0	1,158.5	5,690.5	104,046.0	592.1	0.71	0.4	1.2
11/29/2022 19:00	4,539.5	1,181.3	5,720.8	104,046.0	595.2	0.71	0.4	1.2
11/29/2022 20:00	4,573.0	1,192.7	5,765.7	104,046.0	599.9	0.72	0.4	1.2
11/29/2022 21:00	4,577.6	1,149.6	5,727.2	104,046.0	595.9	0.72	0.4	1.2
11/29/2022 22:00	4,582.7	1,053.3	5,636.0	104,046.0	586.4	0.70	0.4	1.2
11/29/2022 23:00	4,605.5	733.1	5,338.6	104,046.0	555.5	0.67	0.3	1.1
Average/Sum#:	4,471.8	562.8	5,020.0	104,046.0	522.3	0.63	0.3	1.0
Minimum:	3,685.7	0.0	3,685.7	104,046.0	383.5	0.46	0.2	0.8
Maximum:	4,616.6	1,575.8	6,192.4	104,046.0	644.3	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	4,542.7	1.7	4,542.7	104,046.0	472.6	0.57	0.3	0.9
11/30/2022 01:00	4,561.8	0.0	4,561.8	104,046.0	474.6	0.57	0.3	0.9
11/30/2022 02:00	4,567.9	0.0	4,567.9	104,046.0	475.3	0.57	0.3	1.0
11/30/2022 03:00	4,561.6	0.0	4,561.6	104,046.0	474.6	0.57	0.3	0.9
11/30/2022 04:00	4,557.0	0.0	4,557.0	104,046.0	474.1	0.57	0.3	0.9
11/30/2022 05:00	4,574.0	92.0	4,599.8	104,046.0	478.6	0.58	0.3	1.0
11/30/2022 06:00	4,626.9	1,150.6	5,777.5	104,046.0	601.1	0.72	0.4	1.2
11/30/2022 07:00	4,617.4	379.0	4,996.4	104,046.0	519.9	0.62	0.3	1.0
11/30/2022 08:00	3,691.1	48.5	3,704.2	104,046.0	385.4	0.47	0.2	0.8
11/30/2022 09:00	3,373.2	0.0	3,373.2	104,046.0	351.0	0.42	0.2	0.7
11/30/2022 10:00	2,792.8	0.0	2,792.8	104,046.0	290.6	0.35	0.2	0.6
11/30/2022 11:00	2,703.6	0.0	2,703.6	104,046.0	281.3	0.34	0.2	0.6
11/30/2022 12:00	2,693.6	0.0	2,693.6	104,046.0	280.3	0.33	0.2	0.6
11/30/2022 13:00	2,708.2	0.0	2,708.2	104,046.0	281.8	0.34	0.2	0.6
11/30/2022 14:00	3,778.6	1.2	3,778.6	104,046.0	393.1	0.47	0.2	0.8
11/30/2022 15:00	3,894.9	136.5	3,933.1	104,046.0	409.2	0.50	0.3	0.8
11/30/2022 16:00	4,467.0	739.5	5,206.5	104,046.0	541.7	0.65	0.3	1.1
11/30/2022 17:00	4,486.9	735.1	5,222.0	104,046.0	543.3	0.65	0.3	1.1
11/30/2022 18:00	4,480.2	713.8	5,194.0	104,046.0	540.4	0.65	0.3	1.1
11/30/2022 19:00	4,493.8	709.9	5,203.7	104,046.0	541.4	0.65	0.3	1.1
11/30/2022 20:00	4,506.7	644.8	5,151.5	104,046.0	536.0	0.64	0.3	1.1
11/30/2022 21:00	4,516.3	579.9	5,096.2	104,046.0	530.2	0.64	0.3	1.1
11/30/2022 22:00	4,485.5	263.1	4,688.1	104,046.0	487.8	0.59	0.3	1.0
11/30/2022 23:00	2,963.2	0.0	2,963.2	104,046.0	308.3	0.37	0.2	0.6
Average/Sum#:	4,026.9	258.2	4,274.1	104,046.0	444.7	0.53	0.3	0.9
Minimum:	2,693.6	0.0	2,693.6	104,046.0	280.3	0.33	0.2	0.6
Maximum:	4,626.9	1,150.6	5,777.5	104,046.0	601.1	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022 00:00	3,895.7	0.0	3,895.7	104,046.0	405.3	0.49	0.2	0.8
12/01/2022 01:00	3,875.9	0.0	3,875.9	104,046.0	403.3	0.48	0.2	0.8
12/01/2022 02:00	4,011.7	0.0	4,011.7	104,046.0	417.4	0.50	0.3	0.8
12/01/2022 03:00	4,045.9	0.0	4,045.9	104,046.0	421.0	0.51	0.3	0.8
12/01/2022 04:00	4,312.0	32.9	4,320.2	104,046.0	449.5	0.54	0.3	0.9
12/01/2022 05:00	4,505.8	680.6	5,186.4	104,046.0	539.6	0.65	0.3	1.1
12/01/2022 06:00	4,504.8	746.1	5,250.9	104,046.0	546.3	0.66	0.3	1.1
12/01/2022 07:00	4,507.9	403.1	4,911.0	104,046.0	511.0	0.61	0.3	1.0
12/01/2022 08:00	4,507.5	994.2	5,501.7	104,046.0	572.4	0.69	0.3	1.1
12/01/2022 09:00	4,520.0	1,374.3	5,894.3	104,046.0	613.3	0.74	0.4	1.2
12/01/2022 10:00	4,537.6	1,035.6	5,573.2	104,046.0	579.9	0.70	0.3	1.2
12/01/2022 11:00	4,538.1	946.0	5,484.1	104,046.0	570.6	0.68	0.3	1.1
12/01/2022 12:00	4,528.2	896.5	5,424.7	104,046.0	564.4	0.68	0.3	1.1
12/01/2022 13:00	4,522.1	1,105.0	5,627.1	104,046.0	585.5	0.70	0.4	1.2
12/01/2022 14:00	4,541.4	1,098.3	5,639.7	104,046.0	586.8	0.70	0.4	1.2
12/01/2022 15:00	4,533.7	647.7	5,181.4	104,046.0	539.1	0.65	0.3	1.1
12/01/2022 16:00	4,536.9	402.4	4,939.3	104,046.0	513.9	0.62	0.3	1.0
12/01/2022 17:00	4,538.2	470.1	5,008.3	104,046.0	521.1	0.63	0.3	1.0
12/01/2022 18:00	4,556.0	300.3	4,856.3	104,046.0	505.3	0.61	0.3	1.0
12/01/2022 19:00	4,553.7	402.3	4,956.0	104,046.0	515.7	0.62	0.3	1.0
12/01/2022 20:00	4,562.8	284.2	4,847.0	104,046.0	504.3	0.60	0.3	1.0
12/01/2022 21:00	4,571.8	244.5	4,816.3	104,046.0	501.1	0.60	0.3	1.0
12/01/2022 22:00	4,576.8	266.8	4,843.6	104,046.0	504.0	0.61	0.3	1.0
12/01/2022 23:00	4,591.0	192.4	4,783.4	104,046.0	497.7	0.60	0.3	1.0
Average/Sum#:	4,432.3	521.8	4,953.1	104,046.0	515.4	0.62	0.3	1.0
Minimum:	3,875.9	0.0	3,875.9	104,046.0	403.3	0.48	0.2	0.8
Maximum:	4,591.0	1,374.3	5,894.3	104,046.0	613.3	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2022 00:00	4,605.3	166.0	4,771.3	104,046.0	496.4	0.60	0.3	1.0
12/02/2022 01:00	4,616.9	141.3	4,758.2	104,046.0	495.1	0.59	0.3	1.0
12/02/2022 02:00	4,621.2	173.3	4,794.5	104,046.0	498.8	0.60	0.3	1.0
12/02/2022 03:00	4,615.8	322.7	4,938.5	104,046.0	513.8	0.62	0.3	1.0
12/02/2022 04:00	4,618.5	277.2	4,895.7	104,046.0	509.4	0.61	0.3	1.0
12/02/2022 05:00	4,626.2	370.1	4,996.3	104,046.0	519.8	0.62	0.3	1.0
12/02/2022 06:00	4,631.4	624.0	5,255.4	104,046.0	546.8	0.66	0.3	1.1
12/02/2022 07:00	4,642.7	1,141.3	5,784.0	104,046.0	601.8	0.72	0.4	1.2
12/02/2022 08:00	4,625.1	617.3	5,242.4	104,046.0	545.5	0.65	0.3	1.1
12/02/2022 09:00	4,613.2	624.5	5,237.7	104,046.0	545.0	0.65	0.3	1.1
12/02/2022 10:00	4,609.8	679.8	5,289.6	104,046.0	550.4	0.66	0.3	1.1
12/02/2022 11:00	4,597.4	637.6	5,235.0	104,046.0	544.7	0.65	0.3	1.1
12/02/2022 12:00	4,573.0	688.9	5,261.9	104,046.0	547.5	0.66	0.3	1.1
12/02/2022 13:00	4,558.6	1,051.9	5,610.5	104,046.0	583.8	0.70	0.4	1.2
12/02/2022 14:00	4,550.0	1,229.2	5,779.2	104,046.0	601.3	0.72	0.4	1.2
12/02/2022 15:00	4,542.7	1,192.6	5,735.3	104,046.0	596.7	0.72	0.4	1.2
12/02/2022 16:00	4,554.8	1,059.9	5,614.7	104,046.0	584.2	0.70	0.4	1.2
12/02/2022 17:00	4,567.5	1,144.7	5,712.2	104,046.0	594.3	0.71	0.4	1.2
12/02/2022 18:00	4,579.5	1,084.7	5,664.2	104,046.0	589.3	0.71	0.4	1.2
12/02/2022 19:00	4,588.6	1,124.8	5,713.4	104,046.0	594.5	0.71	0.4	1.2
12/02/2022 20:00	4,588.0	1,318.6	5,906.6	104,046.0	614.6	0.74	0.4	1.2
12/02/2022 21:00	4,608.1	1,058.3	5,666.4	104,046.0	589.6	0.71	0.4	1.2
12/02/2022 22:00	4,619.0	996.8	5,615.8	104,046.0	584.3	0.70	0.4	1.2
12/02/2022 23:00	4,629.6	591.9	5,221.5	104,046.0	543.3	0.65	0.3	1.1
Average/Sum#:	4,599.3	763.2	5,362.5	104,046.0	558.0	0.67	0.3	1.1
Minimum:	4,542.7	141.3	4,758.2	104,046.0	495.1	0.59	0.3	1.0
Maximum:	4,642.7	1,318.6	5,906.6	104,046.0	614.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2022 00:00	4,632.4	614.0	5,246.4	104,046.0	545.9	0.66	0.3	1.1
12/03/2022 01:00	4,631.6	547.0	5,178.6	104,046.0	538.8	0.65	0.3	1.1
12/03/2022 02:00	4,626.8	504.5	5,131.3	104,046.0	533.9	0.64	0.3	1.1
12/03/2022 03:00	4,623.6	585.8	5,209.4	104,046.0	542.0	0.65	0.3	1.1
12/03/2022 04:00	4,615.5	706.6	5,322.1	104,046.0	553.7	0.66	0.3	1.1
12/03/2022 05:00	4,610.3	799.2	5,409.5	104,046.0	562.8	0.68	0.3	1.1
12/03/2022 06:00	4,612.1	849.7	5,461.8	104,046.0	568.3	0.68	0.3	1.1
12/03/2022 07:00	4,596.7	1,338.2	5,934.9	104,046.0	617.5	0.74	0.4	1.2
12/03/2022 08:00	4,600.9	1,091.5	5,692.4	104,046.0	592.3	0.71	0.4	1.2
12/03/2022 09:00	4,606.7	1,071.8	5,678.5	104,046.0	590.8	0.71	0.4	1.2
12/03/2022 10:00	4,601.9	860.5	5,462.4	104,046.0	568.3	0.68	0.3	1.1
12/03/2022 11:00	4,584.1	601.8	5,185.9	104,046.0	539.6	0.65	0.3	1.1
12/03/2022 12:00	4,592.1	578.3	5,170.4	104,046.0	538.0	0.65	0.3	1.1
12/03/2022 13:00	4,588.2	584.7	5,172.9	104,046.0	538.2	0.65	0.3	1.1
12/03/2022 14:00	4,593.2	671.0	5,264.2	104,046.0	547.7	0.66	0.3	1.1
12/03/2022 15:00	4,597.8	893.9	5,491.7	104,046.0	571.4	0.69	0.3	1.1
12/03/2022 16:00	4,601.3	795.0	5,396.3	104,046.0	561.5	0.67	0.3	1.1
12/03/2022 17:00	4,213.9	465.2	4,562.8	104,046.0	474.7	0.58	0.3	1.0
12/03/2022 18:00	2,707.6	0.0	2,707.6	104,046.0	281.7	0.34	0.2	0.6
12/03/2022 19:00	3,943.3	0.0	3,943.3	104,046.0	410.3	0.49	0.2	0.8
12/03/2022 20:00	4,366.0	0.0	4,366.0	104,046.0	454.3	0.55	0.3	0.9
12/03/2022 21:00	4,392.8	0.0	4,392.8	104,046.0	457.1	0.55	0.3	0.9
12/03/2022 22:00	4,432.4	0.0	4,432.4	104,046.0	461.2	0.55	0.3	0.9
12/03/2022 23:00	4,484.9	0.0	4,484.9	104,046.0	466.6	0.56	0.3	0.9
Average/Sum#:	4,452.3	564.9	5,012.4	104,046.0	521.5	0.63	0.3	1.0
Minimum:	2,707.6	0.0	2,707.6	104,046.0	281.7	0.34	0.2	0.6
Maximum:	4,632.4	1,338.2	5,934.9	104,046.0	617.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2022 00:00	4,592.3	179.4	4,744.8	104,046.0	493.7	0.60	0.3	1.0
12/04/2022 01:00	4,591.6	186.8	4,778.4	104,046.0	497.2	0.60	0.3	1.0
12/04/2022 02:00	4,592.9	236.9	4,829.8	104,046.0	502.5	0.60	0.3	1.0
12/04/2022 03:00	4,574.2	265.5	4,839.7	104,046.0	503.6	0.60	0.3	1.0
12/04/2022 04:00	4,557.7	329.0	4,886.7	104,046.0	508.4	0.61	0.3	1.0
12/04/2022 05:00	4,564.8	417.4	4,982.2	104,046.0	518.4	0.62	0.3	1.0
12/04/2022 06:00	4,557.1	273.9	4,831.0	104,046.0	502.6	0.60	0.3	1.0
12/04/2022 07:00	4,550.5	303.0	4,853.5	104,046.0	505.0	0.61	0.3	1.0
12/04/2022 08:00	4,555.1	437.7	4,992.8	104,046.0	519.5	0.62	0.3	1.0
12/04/2022 09:00	4,539.7	257.6	4,797.3	104,046.0	499.1	0.60	0.3	1.0
12/04/2022 10:00	4,511.2	289.4	4,800.6	104,046.0	499.5	0.60	0.3	1.0
12/04/2022 11:00	4,523.2	278.1	4,801.3	104,046.0	499.6	0.60	0.3	1.0
12/04/2022 12:00	4,547.2	213.5	4,760.7	104,046.0	495.3	0.59	0.3	1.0
12/04/2022 13:00	4,527.2	252.1	4,779.3	104,046.0	497.3	0.60	0.3	1.0
12/04/2022 14:00	4,453.8	12.2	4,455.0	104,046.0	463.5	0.56	0.3	0.9
12/04/2022 15:00	4,478.0	0.0	4,478.0	104,046.0	465.9	0.56	0.3	0.9
12/04/2022 16:00	4,480.1	0.0	4,480.1	104,046.0	466.1	0.56	0.3	0.9
12/04/2022 17:00	4,480.6	0.0	4,480.6	104,046.0	466.2	0.56	0.3	0.9
12/04/2022 18:00	4,482.0	0.0	4,482.0	104,046.0	466.3	0.56	0.3	0.9
12/04/2022 19:00	4,481.6	0.0	4,481.6	104,046.0	466.3	0.56	0.3	0.9
12/04/2022 20:00	4,487.4	0.0	4,487.4	104,046.0	466.9	0.56	0.3	0.9
12/04/2022 21:00	4,487.8	0.0	4,487.8	104,046.0	466.9	0.56	0.3	0.9
12/04/2022 22:00	4,486.0	0.0	4,486.0	104,046.0	466.8	0.56	0.3	0.9
12/04/2022 23:00	4,485.1	0.0	4,485.1	104,046.0	466.7	0.56	0.3	0.9
Average/Sum#:	4,524.5	163.9	4,686.7	104,046.0	487.6	0.59	0.3	1.0
Minimum:	4,453.8	0.0	4,455.0	104,046.0	463.5	0.56	0.3	0.9
Maximum:	4,592.9	437.7	4,992.8	104,046.0	519.5	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2022 00:00	4,483.1	0.0	4,483.1	104,046.0	466.4	0.56	0.3	0.9
12/05/2022 01:00	4,482.9	0.0	4,482.9	104,046.0	466.4	0.56	0.3	0.9
12/05/2022 02:00	4,482.1	0.0	4,482.1	104,046.0	466.3	0.56	0.3	0.9
12/05/2022 03:00	4,482.5	0.0	4,482.5	104,046.0	466.4	0.56	0.3	0.9
12/05/2022 04:00	4,480.3	0.0	4,480.3	104,046.0	466.2	0.56	0.3	0.9
12/05/2022 05:00	4,478.0	0.0	4,478.0	104,046.0	465.9	0.56	0.3	0.9
12/05/2022 06:00	4,513.9	89.0	4,540.6	104,046.0	472.4	0.57	0.3	1.0
12/05/2022 07:00	4,543.6	215.2	4,709.3	104,046.0	490.0	0.59	0.3	1.0
12/05/2022 08:00	4,498.1	0.0	4,498.1	104,046.0	468.0	0.56	0.3	0.9
12/05/2022 09:00	4,494.2	0.0	4,494.2	104,046.0	467.6	0.56	0.3	0.9
12/05/2022 10:00	3,492.9	0.0	3,492.9	104,046.0	363.4	0.44	0.2	0.7
12/05/2022 11:00	2,680.5	0.0	2,680.5	104,046.0	278.9	0.33	0.2	0.6
12/05/2022 12:00	2,673.9	0.0	2,673.9	104,046.0	278.2	0.33	0.2	0.6
12/05/2022 13:00	2,668.2	0.0	2,668.2	104,046.0	277.6	0.33	0.2	0.6
12/05/2022 14:00	2,860.7	0.0	2,860.7	104,046.0	297.6	0.35	0.2	0.6
12/05/2022 15:00	2,903.2	0.0	2,903.2	104,046.0	302.1	0.36	0.2	0.6
12/05/2022 16:00	3,191.4	9.8	3,192.2	104,046.0	332.1	0.40	0.2	0.7
12/05/2022 17:00	3,367.6	0.0	3,367.6	104,046.0	350.4	0.42	0.2	0.7
12/05/2022 18:00	3,495.5	180.9	3,549.8	104,046.0	369.3	0.46	0.2	0.8
12/05/2022 19:00	4,493.2	698.5	5,191.7	104,046.0	540.2	0.65	0.3	1.1
12/05/2022 20:00	4,500.3	663.5	5,163.8	104,046.0	537.3	0.65	0.3	1.1
12/05/2022 21:00	4,505.8	440.7	4,946.5	104,046.0	514.7	0.62	0.3	1.0
12/05/2022 22:00	4,223.1	171.0	4,325.7	104,046.0	450.1	0.55	0.3	0.9
12/05/2022 23:00	3,082.2	0.0	3,082.2	105,000.0	323.6	0.39	0.2	0.6
Average/Sum#:	3,878.2	102.9	3,967.9	104,085.8	413.0	0.50	0.3	0.8
Minimum:	2,668.2	0.0	2,668.2	104,046.0	277.6	0.33	0.2	0.6
Maximum:	4,543.6	698.5	5,191.7	105,000.0	540.2	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	3,555.0	0.0	3,555.0	105,000.0	373.3	0.47	0.2	0.8
12/06/2022 01:00	847.6	0.0	847.6	105,000.0	89.0	0.00	0.0	0.0
12/06/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/06/2022 15:00	2,426.7	0.0	2,426.7	105,000.0	254.8	0.00	0.0	0.0
12/06/2022 16:00	4,019.1	202.2	4,114.1	105,000.0	432.0	0.61	0.3	1.0
12/06/2022 17:00	4,516.6	701.9	5,218.5	105,000.0	547.9	0.66	0.3	1.1
12/06/2022 18:00	4,529.3	653.5	5,182.8	105,000.0	544.2	0.65	0.3	1.1
12/06/2022 19:00	4,539.4	653.4	5,192.8	105,000.0	545.2	0.65	0.3	1.1
12/06/2022 20:00	4,547.6	627.6	5,175.2	105,000.0	543.4	0.65	0.3	1.1
12/06/2022 21:00	4,558.5	569.0	5,127.5	105,000.0	538.4	0.65	0.3	1.1
12/06/2022 22:00	4,578.7	314.3	4,893.0	105,000.0	513.8	0.62	0.3	1.0
12/06/2022 23:00	4,581.9	200.5	4,782.4	105,000.0	502.2	0.60	0.3	1.0
Average/Sum#:	3,881.9	356.6	4,228.7	105,000.0	444.0	0.62	0.3	1.0
Minimum:	847.6	0.0	847.6	105,000.0	89.0	0.47	0.2	0.8
Maximum:	4,581.9	701.9	5,218.5	105,000.0	547.9	0.66	0.3	1.1
%SI	54.17	54.17	54.17	0.00	54.17	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2022 00:00	4,267.9	1.9	4,267.9	105,000.0	448.1	0.54	0.3	0.9
12/07/2022 01:00	4,100.8	0.0	4,100.8	105,000.0	430.6	0.52	0.3	0.9
12/07/2022 02:00	4,237.0	0.0	4,237.0	105,000.0	444.9	0.53	0.3	0.9
12/07/2022 03:00	4,223.1	0.0	4,223.1	105,000.0	443.4	0.53	0.3	0.9
12/07/2022 04:00	4,464.3	126.4	4,530.0	105,000.0	475.7	0.58	0.3	1.0
12/07/2022 05:00	4,623.1	618.2	5,241.3	105,000.0	550.3	0.66	0.3	1.1
12/07/2022 06:00	4,634.8	656.0	5,290.8	105,000.0	555.5	0.67	0.3	1.1
12/07/2022 07:00	4,628.8	198.0	4,826.8	105,000.0	506.8	0.61	0.3	1.0
12/07/2022 08:00	4,633.6	140.8	4,774.4	105,000.0	501.3	0.60	0.3	1.0
12/07/2022 09:00	4,609.1	340.1	4,949.2	105,000.0	519.7	0.62	0.3	1.0
12/07/2022 10:00	4,584.4	309.1	4,893.5	105,000.0	513.8	0.62	0.3	1.0
12/07/2022 11:00	4,562.1	285.1	4,847.2	105,000.0	509.0	0.61	0.3	1.0
12/07/2022 12:00	4,286.2	145.7	4,362.0	105,000.0	458.0	0.56	0.3	0.9
12/07/2022 13:00	2,775.9	0.0	2,775.9	105,000.0	291.5	0.35	0.2	0.6
12/07/2022 14:00	3,128.6	14.9	3,129.8	105,000.0	328.6	0.40	0.2	0.7
12/07/2022 15:00	4,515.2	406.9	4,922.1	105,000.0	516.8	0.62	0.3	1.0
12/07/2022 16:00	4,510.3	342.5	4,852.8	105,000.0	509.5	0.61	0.3	1.0
12/07/2022 17:00	4,508.5	327.7	4,836.2	105,000.0	507.8	0.61	0.3	1.0
12/07/2022 18:00	4,517.6	309.5	4,827.1	105,000.0	506.8	0.61	0.3	1.0
12/07/2022 19:00	4,536.8	498.1	5,034.9	105,000.0	528.7	0.63	0.3	1.1
12/07/2022 20:00	4,566.7	810.9	5,377.6	105,000.0	564.6	0.68	0.3	1.1
12/07/2022 21:00	4,591.5	726.6	5,318.1	105,000.0	558.4	0.67	0.3	1.1
12/07/2022 22:00	4,594.9	322.7	4,917.6	105,000.0	516.3	0.62	0.3	1.0
12/07/2022 23:00	4,610.7	195.2	4,805.9	105,000.0	504.6	0.61	0.3	1.0
Average/Sum#:	4,363.0	282.3	4,639.3	105,000.0	487.1	0.59	0.3	1.0
Minimum:	2,775.9	0.0	2,775.9	105,000.0	291.5	0.35	0.2	0.6
Maximum:	4,634.8	810.9	5,377.6	105,000.0	564.6	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2022 00:00	4,614.1	443.9	5,058.0	105,000.0	531.1	0.64	0.3	1.1
12/08/2022 01:00	4,605.0	321.5	4,926.5	105,000.0	517.3	0.62	0.3	1.0
12/08/2022 02:00	4,600.0	289.4	4,889.4	105,000.0	513.4	0.62	0.3	1.0
12/08/2022 03:00	4,595.1	307.1	4,902.2	105,000.0	514.7	0.62	0.3	1.0
12/08/2022 04:00	4,618.8	439.8	5,058.6	105,000.0	531.2	0.64	0.3	1.1
12/08/2022 05:00	4,651.8	598.3	5,250.1	105,000.0	551.3	0.66	0.3	1.1
12/08/2022 06:00	4,642.1	779.7	5,421.8	105,000.0	569.3	0.68	0.3	1.1
12/08/2022 07:00	4,643.0	582.5	5,225.5	105,000.0	548.7	0.66	0.3	1.1
12/08/2022 08:00	4,617.7	284.2	4,901.9	105,000.0	514.7	0.62	0.3	1.0
12/08/2022 09:00	4,542.2	134.4	4,612.1	105,000.0	484.3	0.59	0.3	1.0
12/08/2022 10:00	4,200.5	0.0	4,200.5	105,000.0	441.1	0.53	0.3	0.9
12/08/2022 11:00	4,538.4	529.9	5,052.4	105,000.0	530.5	0.64	0.3	1.1
12/08/2022 12:00	4,530.2	792.5	5,322.7	105,000.0	558.9	0.67	0.3	1.1
12/08/2022 13:00	4,523.6	792.0	5,315.6	105,000.0	558.1	0.67	0.3	1.1
12/08/2022 14:00	4,509.0	951.5	5,460.5	105,000.0	573.4	0.69	0.3	1.1
12/08/2022 15:00	4,519.9	852.6	5,372.5	105,000.0	564.1	0.68	0.3	1.1
12/08/2022 16:00	4,512.0	957.1	5,469.1	105,000.0	574.3	0.69	0.3	1.1
12/08/2022 17:00	4,511.9	1,120.6	5,632.5	105,000.0	591.4	0.71	0.4	1.2
12/08/2022 18:00	4,513.8	1,169.4	5,683.2	105,000.0	596.7	0.72	0.4	1.2
12/08/2022 19:00	4,515.7	1,161.4	5,677.1	105,000.0	596.1	0.71	0.4	1.2
12/08/2022 20:00	4,521.1	1,140.5	5,661.6	105,000.0	594.5	0.71	0.4	1.2
12/08/2022 21:00	4,535.8	1,082.6	5,618.4	105,000.0	589.9	0.71	0.4	1.2
12/08/2022 22:00	4,538.7	955.7	5,494.4	105,000.0	576.9	0.69	0.3	1.2
12/08/2022 23:00	4,546.9	573.3	5,120.2	105,000.0	537.6	0.64	0.3	1.1
Average/Sum#:	4,547.8	677.5	5,222.0	105,000.0	548.3	0.66	0.3	1.1
Minimum:	4,200.5	0.0	4,200.5	105,000.0	441.1	0.53	0.3	0.9
Maximum:	4,651.8	1,169.4	5,683.2	105,000.0	596.7	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	4,085.6	9.3	4,086.3	105,000.0	429.1	0.52	0.3	0.9
12/09/2022 01:00	3,832.5	0.0	3,832.5	105,000.0	402.4	0.48	0.2	0.8
12/09/2022 02:00	4,061.4	0.0	4,061.4	105,000.0	426.4	0.51	0.3	0.9
12/09/2022 03:00	4,118.5	0.0	4,118.5	105,000.0	432.4	0.52	0.3	0.9
12/09/2022 04:00	4,429.1	67.1	4,464.7	105,000.0	468.8	0.57	0.3	0.9
12/09/2022 05:00	4,552.6	128.1	4,680.7	105,000.0	491.5	0.59	0.3	1.0
12/09/2022 06:00	4,542.7	45.0	4,559.4	105,000.0	478.7	0.58	0.3	1.0
12/09/2022 07:00	4,562.6	577.3	5,139.9	105,000.0	539.7	0.65	0.3	1.1
12/09/2022 08:00	4,026.9	82.6	4,055.8	105,000.0	425.9	0.52	0.3	0.9
12/09/2022 09:00	3,766.2	0.0	3,766.2	105,000.0	395.5	0.48	0.2	0.8
12/09/2022 10:00	2,784.4	0.0	2,784.4	105,000.0	292.4	0.35	0.2	0.6
12/09/2022 11:00	2,818.2	0.0	2,818.2	105,000.0	295.9	0.35	0.2	0.6
12/09/2022 12:00	2,861.3	0.0	2,861.3	105,000.0	300.4	0.36	0.2	0.6
12/09/2022 13:00	4,439.3	0.0	4,439.3	105,000.0	466.1	0.56	0.3	0.9
12/09/2022 14:00	4,457.1	0.0	4,457.1	105,000.0	468.0	0.56	0.3	0.9
12/09/2022 15:00	3,640.9	134.5	3,685.3	105,000.0	387.0	0.48	0.2	0.8
12/09/2022 16:00	4,522.9	684.5	5,207.4	105,000.0	546.8	0.66	0.3	1.1
12/09/2022 17:00	4,522.0	646.3	5,168.3	105,000.0	542.7	0.65	0.3	1.1
12/09/2022 18:00	4,521.3	685.8	5,207.1	105,000.0	546.7	0.66	0.3	1.1
12/09/2022 19:00	4,519.3	860.1	5,379.4	105,000.0	564.8	0.68	0.3	1.1
12/09/2022 20:00	4,511.7	913.9	5,425.6	105,000.0	569.7	0.68	0.3	1.1
12/09/2022 21:00	4,503.5	817.0	5,320.5	105,000.0	558.7	0.67	0.3	1.1
12/09/2022 22:00	4,493.4	786.1	5,279.5	105,000.0	554.3	0.67	0.3	1.1
12/09/2022 23:00	4,495.0	557.0	5,052.0	105,000.0	530.5	0.64	0.3	1.1
Average/Sum#:	4,127.9	291.4	4,410.5	105,000.0	463.1	0.56	0.3	0.9
Minimum:	2,784.4	0.0	2,784.4	105,000.0	292.4	0.35	0.2	0.6
Maximum:	4,562.6	913.9	5,425.6	105,000.0	569.7	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2022 00:00	4,492.5	2.1	4,492.5	105,000.0	471.7	0.57	0.3	0.9
12/10/2022 01:00	4,476.7	0.0	4,476.7	105,000.0	470.1	0.56	0.3	0.9
12/10/2022 02:00	4,480.7	0.0	4,480.7	105,000.0	470.5	0.56	0.3	0.9
12/10/2022 03:00	4,480.9	0.0	4,480.9	105,000.0	470.5	0.56	0.3	0.9
12/10/2022 04:00	4,481.8	0.0	4,481.8	105,000.0	470.6	0.56	0.3	0.9
12/10/2022 05:00	4,482.0	0.0	4,482.0	105,000.0	470.6	0.56	0.3	0.9
12/10/2022 06:00	4,478.4	0.0	4,478.4	105,000.0	470.2	0.56	0.3	0.9
12/10/2022 07:00	2,990.1	0.0	2,990.1	105,000.0	314.0	0.38	0.2	0.6
12/10/2022 08:00	3,233.7	0.0	3,233.7	105,000.0	339.5	0.41	0.2	0.7
12/10/2022 09:00	2,949.4	0.0	2,949.4	105,000.0	309.7	0.37	0.2	0.6
12/10/2022 10:00	2,743.5	0.0	2,743.5	105,000.0	288.1	0.35	0.2	0.6
12/10/2022 11:00	3,202.0	0.0	3,202.0	105,000.0	336.2	0.40	0.2	0.7
12/10/2022 12:00	4,086.3	0.0	4,086.3	105,000.0	429.1	0.52	0.3	0.9
12/10/2022 13:00	4,076.6	31.9	4,083.6	105,000.0	428.8	0.52	0.3	0.9
12/10/2022 14:00	4,442.1	505.0	4,947.1	105,000.0	519.4	0.62	0.3	1.0
12/10/2022 15:00	4,442.3	577.6	5,019.9	105,000.0	527.1	0.63	0.3	1.1
12/10/2022 16:00	4,433.9	621.8	5,055.7	105,000.0	530.8	0.64	0.3	1.1
12/10/2022 17:00	4,434.7	501.0	4,935.7	105,000.0	518.2	0.62	0.3	1.0
12/10/2022 18:00	4,434.7	497.6	4,932.3	105,000.0	517.9	0.62	0.3	1.0
12/10/2022 19:00	4,437.3	803.4	5,240.7	105,000.0	550.3	0.66	0.3	1.1
12/10/2022 20:00	4,441.8	744.1	5,185.9	105,000.0	544.5	0.65	0.3	1.1
12/10/2022 21:00	4,454.0	520.4	4,974.4	105,000.0	522.3	0.63	0.3	1.0
12/10/2022 22:00	4,465.7	430.2	4,895.9	105,000.0	514.1	0.62	0.3	1.0
12/10/2022 23:00	4,473.3	466.7	4,940.0	105,000.0	518.7	0.62	0.3	1.0
Average/Sum#:	4,129.8	237.6	4,366.2	105,000.0	458.5	0.55	0.3	0.9
Minimum:	2,743.5	0.0	2,743.5	105,000.0	288.1	0.35	0.2	0.6
Maximum:	4,492.5	803.4	5,240.7	105,000.0	550.3	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2022 00:00	4,448.7	396.6	4,758.0	105,000.0	499.6	0.61	0.3	1.0
12/11/2022 01:00	3,447.7	0.0	3,447.7	105,000.0	362.0	0.43	0.2	0.7
12/11/2022 02:00	2,971.3	0.0	2,971.3	105,000.0	312.0	0.37	0.2	0.6
12/11/2022 03:00	3,224.1	0.0	3,224.1	105,000.0	338.5	0.41	0.2	0.7
12/11/2022 04:00	3,807.4	0.0	3,807.4	105,000.0	399.8	0.48	0.2	0.8
12/11/2022 05:00	3,949.7	0.0	3,949.7	105,000.0	414.7	0.50	0.2	0.8
12/11/2022 06:00	3,897.3	0.0	3,897.3	105,000.0	409.2	0.49	0.2	0.8
12/11/2022 07:00	2,910.3	0.0	2,910.3	105,000.0	305.6	0.37	0.2	0.6
12/11/2022 08:00	2,690.3	0.0	2,690.3	105,000.0	282.5	0.34	0.2	0.6
12/11/2022 09:00	2,672.9	0.0	2,672.9	105,000.0	280.7	0.34	0.2	0.6
12/11/2022 10:00	2,729.8	0.0	2,729.8	105,000.0	286.6	0.35	0.2	0.6
12/11/2022 11:00	2,670.5	0.0	2,670.5	105,000.0	280.4	0.34	0.2	0.6
12/11/2022 12:00	2,671.3	0.0	2,671.3	105,000.0	280.5	0.34	0.2	0.6
12/11/2022 13:00	2,724.1	0.0	2,724.1	105,000.0	286.0	0.34	0.2	0.6
12/11/2022 14:00	2,791.8	0.0	2,791.8	105,000.0	293.1	0.35	0.2	0.6
12/11/2022 15:00	3,879.2	82.8	3,897.4	105,000.0	409.2	0.50	0.2	0.8
12/11/2022 16:00	4,496.7	416.7	4,913.4	105,000.0	515.9	0.62	0.3	1.0
12/11/2022 17:00	4,525.6	424.5	4,950.1	105,000.0	519.8	0.62	0.3	1.0
12/11/2022 18:00	4,531.3	343.5	4,874.8	105,000.0	511.9	0.61	0.3	1.0
12/11/2022 19:00	4,557.6	339.5	4,897.1	105,000.0	514.2	0.62	0.3	1.0
12/11/2022 20:00	4,563.9	456.8	5,020.7	105,000.0	527.2	0.63	0.3	1.1
12/11/2022 21:00	4,543.9	331.6	4,875.5	105,000.0	511.9	0.61	0.3	1.0
12/11/2022 22:00	3,786.1	75.9	3,806.6	105,000.0	399.7	0.49	0.2	0.8
12/11/2022 23:00	2,781.4	0.0	2,781.4	105,000.0	292.0	0.35	0.2	0.6
Average/Sum#:	3,553.0	119.5	3,663.9	105,000.0	384.7	0.46	0.2	0.8
Minimum:	2,670.5	0.0	2,670.5	105,000.0	280.4	0.34	0.2	0.6
Maximum:	4,563.9	456.8	5,020.7	105,000.0	527.2	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2022 00:00	2,827.2	0.0	2,827.2	105,000.0	296.9	0.36	0.2	0.6
12/12/2022 01:00	2,886.4	0.0	2,886.4	105,000.0	303.1	0.36	0.2	0.6
12/12/2022 02:00	3,133.5	0.0	3,133.5	105,000.0	329.0	0.39	0.2	0.7
12/12/2022 03:00	2,873.6	0.0	2,873.6	105,000.0	301.7	0.36	0.2	0.6
12/12/2022 04:00	3,919.4	124.1	3,971.5	105,000.0	417.0	0.51	0.3	0.8
12/12/2022 05:00	4,588.5	613.2	5,201.7	105,000.0	546.2	0.66	0.3	1.1
12/12/2022 06:00	4,594.3	729.2	5,323.5	105,000.0	559.0	0.67	0.3	1.1
12/12/2022 07:00	4,601.1	518.2	5,119.3	105,000.0	537.5	0.65	0.3	1.1
12/12/2022 08:00	4,609.0	298.4	4,907.4	105,000.0	515.3	0.62	0.3	1.0
12/12/2022 09:00	4,596.6	293.8	4,890.4	105,000.0	513.5	0.62	0.3	1.0
12/12/2022 10:00	4,242.5	125.2	4,307.6	105,000.0	452.3	0.55	0.3	0.9
12/12/2022 11:00	2,766.1	0.0	2,766.1	105,000.0	290.4	0.35	0.2	0.6
12/12/2022 12:00	2,769.4	0.0	2,769.4	105,000.0	290.8	0.35	0.2	0.6
12/12/2022 13:00	2,706.7	0.0	2,706.7	105,000.0	284.2	0.34	0.2	0.6
12/12/2022 14:00	2,694.9	0.0	2,694.9	105,000.0	283.0	0.34	0.2	0.6
12/12/2022 15:00	4,448.9	103.9	4,537.2	105,000.0	476.4	0.57	0.3	1.0
12/12/2022 16:00	4,539.6	126.9	4,666.5	105,000.0	490.0	0.59	0.3	1.0
12/12/2022 17:00	4,558.4	132.1	4,690.5	105,000.0	492.5	0.59	0.3	1.0
12/12/2022 18:00	4,566.4	134.9	4,701.3	105,000.0	493.6	0.59	0.3	1.0
12/12/2022 19:00	4,582.9	131.3	4,714.2	105,000.0	495.0	0.59	0.3	1.0
12/12/2022 20:00	4,596.0	132.5	4,728.5	105,000.0	496.5	0.60	0.3	1.0
12/12/2022 21:00	4,602.2	133.6	4,735.8	105,000.0	497.3	0.60	0.3	1.0
12/12/2022 22:00	4,620.8	136.3	4,757.1	105,000.0	499.5	0.60	0.3	1.0
12/12/2022 23:00	4,625.3	134.4	4,759.7	105,000.0	499.8	0.60	0.3	1.0
Average/Sum#:	3,956.2	161.2	4,111.3	105,000.0	431.7	0.52	0.3	0.9
Minimum:	2,694.9	0.0	2,694.9	105,000.0	283.0	0.34	0.2	0.6
Maximum:	4,625.3	729.2	5,323.5	105,000.0	559.0	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2022 00:00	4,633.6	133.9	4,767.5	105,000.0	500.6	0.60	0.3	1.0
12/13/2022 01:00	4,630.0	134.2	4,764.2	105,000.0	500.2	0.60	0.3	1.0
12/13/2022 02:00	4,645.5	135.7	4,781.2	105,000.0	502.0	0.60	0.3	1.0
12/13/2022 03:00	4,660.7	137.7	4,798.4	105,000.0	503.8	0.61	0.3	1.0
12/13/2022 04:00	4,621.9	138.8	4,760.7	105,000.0	499.9	0.60	0.3	1.0
12/13/2022 05:00	4,618.1	137.9	4,756.0	105,000.0	499.4	0.60	0.3	1.0
12/13/2022 06:00	4,637.7	163.2	4,800.9	105,000.0	504.1	0.60	0.3	1.0
12/13/2022 07:00	4,689.2	401.6	5,090.8	105,000.0	534.5	0.64	0.3	1.1
12/13/2022 08:00	4,641.1	134.7	4,775.8	105,000.0	501.5	0.60	0.3	1.0
12/13/2022 09:00	4,630.5	130.2	4,760.7	105,000.0	499.9	0.60	0.3	1.0
12/13/2022 10:00	4,629.5	130.9	4,760.4	105,000.0	499.8	0.60	0.3	1.0
12/13/2022 11:00	3,266.3	2.2	3,266.3	105,000.0	343.0	0.41	0.2	0.7
12/13/2022 12:00	2,769.2	0.0	2,769.2	105,000.0	290.8	0.35	0.2	0.6
12/13/2022 13:00	2,765.6	0.0	2,765.6	105,000.0	290.4	0.35	0.2	0.6
12/13/2022 14:00	2,771.3	0.0	2,771.3	105,000.0	291.0	0.35	0.2	0.6
12/13/2022 15:00	3,815.5	55.2	3,832.1	105,000.0	402.4	0.49	0.2	0.8
12/13/2022 16:00	4,565.8	162.4	4,728.2	105,000.0	496.5	0.59	0.3	1.0
12/13/2022 17:00	4,588.4	133.4	4,721.8	105,000.0	495.8	0.59	0.3	1.0
12/13/2022 18:00	4,598.2	132.7	4,730.9	105,000.0	496.7	0.60	0.3	1.0
12/13/2022 19:00	4,601.1	133.4	4,734.5	105,000.0	497.1	0.60	0.3	1.0
12/13/2022 20:00	4,616.0	136.0	4,752.0	105,000.0	499.0	0.60	0.3	1.0
12/13/2022 21:00	4,630.1	451.6	5,081.7	105,000.0	533.6	0.64	0.3	1.1
12/13/2022 22:00	4,639.7	286.8	4,926.5	105,000.0	517.3	0.62	0.3	1.0
12/13/2022 23:00	4,642.8	133.5	4,776.3	105,000.0	501.5	0.60	0.3	1.0
Average/Sum#:	4,304.5	141.9	4,444.7	105,000.0	466.7	0.56	0.3	0.9
Minimum:	2,765.6	0.0	2,765.6	105,000.0	290.4	0.35	0.2	0.6
Maximum:	4,689.2	451.6	5,090.8	105,000.0	534.5	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2022 00:00	4,554.0	1.7	4,554.0	105,000.0	478.2	0.57	0.3	1.0
12/14/2022 01:00	4,553.5	0.0	4,553.5	105,000.0	478.1	0.57	0.3	1.0
12/14/2022 02:00	4,557.0	0.0	4,557.0	105,000.0	478.5	0.57	0.3	1.0
12/14/2022 03:00	4,547.1	0.0	4,547.1	105,000.0	477.4	0.57	0.3	1.0
12/14/2022 04:00	4,587.4	5.6	4,587.7	105,000.0	481.7	0.58	0.3	1.0
12/14/2022 05:00	4,614.6	0.0	4,614.6	105,000.0	484.5	0.58	0.3	1.0
12/14/2022 06:00	4,654.5	0.0	4,654.5	105,000.0	488.7	0.59	0.3	1.0
12/14/2022 07:00	4,576.0	0.0	4,576.0	105,000.0	480.5	0.58	0.3	1.0
12/14/2022 08:00	4,594.3	0.0	4,594.3	105,000.0	482.4	0.58	0.3	1.0
12/14/2022 09:00	4,591.5	0.0	4,591.5	105,000.0	482.1	0.58	0.3	1.0
12/14/2022 10:00	4,590.3	0.0	4,590.3	105,000.0	482.0	0.58	0.3	1.0
12/14/2022 11:00	4,451.5	0.0	4,451.5	105,000.0	467.4	0.56	0.3	0.9
12/14/2022 12:00	2,873.9	0.0	2,873.9	105,000.0	301.8	0.36	0.2	0.6
12/14/2022 13:00	2,777.3	0.0	2,777.3	105,000.0	291.6	0.35	0.2	0.6
12/14/2022 14:00	2,777.4	0.0	2,777.4	105,000.0	291.6	0.35	0.2	0.6
12/14/2022 15:00	2,774.4	0.0	2,774.4	105,000.0	291.3	0.35	0.2	0.6
12/14/2022 16:00	3,369.8	1.2	3,369.8	105,000.0	353.8	0.42	0.2	0.7
12/14/2022 17:00	4,575.3	131.4	4,706.7	105,000.0	494.2	0.59	0.3	1.0
12/14/2022 18:00	4,604.6	131.5	4,736.1	105,000.0	497.3	0.60	0.3	1.0
12/14/2022 19:00	4,615.0	133.2	4,748.2	105,000.0	498.6	0.60	0.3	1.0
12/14/2022 20:00	4,616.6	104.1	4,697.8	105,000.0	493.3	0.59	0.3	1.0
12/14/2022 21:00	4,578.3	0.0	4,578.3	105,000.0	480.7	0.58	0.3	1.0
12/14/2022 22:00	4,562.1	0.0	4,562.1	105,000.0	479.0	0.57	0.3	1.0
12/14/2022 23:00	4,582.0	0.0	4,582.0	105,000.0	481.1	0.58	0.3	1.0
Average/Sum#:	4,232.4	21.2	4,252.3	105,000.0	446.5	0.54	0.3	0.9
Minimum:	2,774.4	0.0	2,774.4	105,000.0	291.3	0.35	0.2	0.6
Maximum:	4,654.5	133.2	4,748.2	105,000.0	498.6	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	4,587.5	0.0	4,587.5	105,000.0	481.7	0.58	0.3	1.0
12/15/2022 01:00	4,601.4	0.0	4,601.4	105,000.0	483.1	0.58	0.3	1.0
12/15/2022 02:00	4,589.3	0.0	4,589.3	105,000.0	481.9	0.58	0.3	1.0
12/15/2022 03:00	4,573.7	0.0	4,573.7	105,000.0	480.2	0.58	0.3	1.0
12/15/2022 04:00	4,597.4	0.0	4,597.4	105,000.0	482.7	0.58	0.3	1.0
12/15/2022 05:00	4,591.0	0.0	4,591.0	105,000.0	482.1	0.58	0.3	1.0
12/15/2022 06:00	4,605.1	0.0	4,605.1	105,000.0	483.5	0.58	0.3	1.0
12/15/2022 07:00	4,618.1	0.0	4,618.1	105,000.0	484.9	0.58	0.3	1.0
12/15/2022 08:00	4,597.5	0.0	4,597.5	105,000.0	482.7	0.58	0.3	1.0
12/15/2022 09:00	4,599.3	0.0	4,599.3	105,000.0	482.9	0.58	0.3	1.0
12/15/2022 10:00	4,597.7	0.0	4,597.7	105,000.0	482.8	0.58	0.3	1.0
12/15/2022 11:00	4,579.3	0.0	4,579.3	105,000.0	480.8	0.58	0.3	1.0
12/15/2022 12:00	4,567.9	0.0	4,567.9	105,000.0	479.6	0.58	0.3	1.0
12/15/2022 13:00	4,540.8	0.0	4,540.8	105,000.0	476.8	0.57	0.3	1.0
12/15/2022 14:00	4,535.2	0.0	4,535.2	105,000.0	476.2	0.57	0.3	1.0
12/15/2022 15:00	4,536.4	0.0	4,536.4	105,000.0	476.3	0.57	0.3	1.0
12/15/2022 16:00	4,533.8	0.0	4,533.8	105,000.0	476.0	0.57	0.3	1.0
12/15/2022 17:00	4,544.3	0.0	4,544.3	105,000.0	477.2	0.57	0.3	1.0
12/15/2022 18:00	4,531.2	0.0	4,531.2	105,000.0	475.8	0.57	0.3	1.0
12/15/2022 19:00	4,538.9	0.0	4,538.9	105,000.0	476.6	0.57	0.3	1.0
12/15/2022 20:00	4,541.7	0.0	4,541.7	105,000.0	476.9	0.57	0.3	1.0
12/15/2022 21:00	4,549.7	0.0	4,549.7	105,000.0	477.7	0.57	0.3	1.0
12/15/2022 22:00	4,577.8	0.0	4,577.8	105,000.0	480.7	0.58	0.3	1.0
12/15/2022 23:00	4,595.6	0.0	4,595.6	105,000.0	482.5	0.58	0.3	1.0
Average/Sum#:	4,572.1	0.0	4,572.1	105,000.0	480.1	0.58	0.3	1.0
Minimum:	4,531.2	0.0	4,531.2	105,000.0	475.8	0.57	0.3	1.0
Maximum:	4,618.1	0.0	4,618.1	105,000.0	484.9	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	4,346.4	0.0	4,346.4	105,000.0	456.4	0.55	0.3	0.9
12/16/2022 01:00	2,778.2	0.0	2,778.2	105,000.0	291.7	0.35	0.2	0.6
12/16/2022 02:00	2,775.8	0.0	2,775.8	105,000.0	291.5	0.35	0.2	0.6
12/16/2022 03:00	2,776.8	0.0	2,776.8	105,000.0	291.6	0.35	0.2	0.6
12/16/2022 04:00	2,770.8	0.0	2,770.8	105,000.0	290.9	0.35	0.2	0.6
12/16/2022 05:00	2,773.0	0.0	2,773.0	105,000.0	291.2	0.35	0.2	0.6
12/16/2022 06:00	2,772.9	0.0	2,772.9	105,000.0	291.2	0.35	0.2	0.6
12/16/2022 07:00	2,762.4	0.0	2,762.4	105,000.0	290.1	0.35	0.2	0.6
12/16/2022 08:00	2,776.0	0.0	2,776.0	105,000.0	291.5	0.35	0.2	0.6
12/16/2022 09:00	2,770.0	0.0	2,770.0	105,000.0	290.9	0.35	0.2	0.6
12/16/2022 10:00	2,770.8	0.0	2,770.8	105,000.0	290.9	0.35	0.2	0.6
12/16/2022 11:00	2,772.8	0.0	2,772.8	105,000.0	291.1	0.35	0.2	0.6
12/16/2022 12:00	2,771.8	0.0	2,771.8	105,000.0	291.0	0.35	0.2	0.6
12/16/2022 13:00	2,778.8	0.0	2,778.8	105,000.0	291.8	0.35	0.2	0.6
12/16/2022 14:00	2,781.0	0.0	2,781.0	105,000.0	292.0	0.35	0.2	0.6
12/16/2022 15:00	2,784.1	0.0	2,784.1	105,000.0	292.3	0.35	0.2	0.6
12/16/2022 16:00	2,784.5	0.0	2,784.5	105,000.0	292.4	0.35	0.2	0.6
12/16/2022 17:00	2,781.8	0.0	2,781.8	105,000.0	292.1	0.35	0.2	0.6
12/16/2022 18:00	2,775.3	0.0	2,775.3	105,000.0	291.4	0.35	0.2	0.6
12/16/2022 19:00	2,764.8	0.0	2,764.8	105,000.0	290.3	0.35	0.2	0.6
12/16/2022 20:00	2,772.3	0.0	2,772.3	105,000.0	291.1	0.35	0.2	0.6
12/16/2022 21:00	2,771.4	0.0	2,771.4	105,000.0	291.0	0.35	0.2	0.6
12/16/2022 22:00	2,771.4	0.0	2,771.4	105,000.0	291.0	0.35	0.2	0.6
12/16/2022 23:00	2,778.8	0.0	2,778.8	105,000.0	291.8	0.35	0.2	0.6
Average/Sum#:	2,840.1	0.0	2,840.1	105,000.0	298.2	0.36	0.2	0.6
Minimum:	2,762.4	0.0	2,762.4	105,000.0	290.1	0.35	0.2	0.6
Maximum:	4,346.4	0.0	4,346.4	105,000.0	456.4	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2022 00:00	2,778.9	0.0	2,778.9	105,000.0	291.8	0.35	0.2	0.6
12/17/2022 01:00	2,781.0	0.0	2,781.0	105,000.0	292.0	0.35	0.2	0.6
12/17/2022 02:00	3,789.4	0.0	3,789.4	105,000.0	397.9	0.48	0.2	0.8
12/17/2022 03:00	3,397.6	0.0	3,397.6	105,000.0	356.7	0.43	0.2	0.7
12/17/2022 04:00	2,742.7	0.0	2,742.7	105,000.0	288.0	0.35	0.2	0.6
12/17/2022 05:00	3,647.3	116.4	3,685.7	105,000.0	387.0	0.47	0.2	0.8
12/17/2022 06:00	4,665.1	219.6	4,884.7	105,000.0	512.9	0.61	0.3	1.0
12/17/2022 07:00	4,684.3	254.6	4,938.9	105,000.0	518.6	0.62	0.3	1.0
12/17/2022 08:00	4,363.6	3.6	4,363.7	105,000.0	458.2	0.55	0.3	0.9
12/17/2022 09:00	3,868.8	0.0	3,868.8	105,000.0	406.2	0.49	0.2	0.8
12/17/2022 10:00	2,969.6	0.0	2,969.6	105,000.0	311.8	0.37	0.2	0.6
12/17/2022 11:00	2,726.0	0.0	2,726.0	105,000.0	286.2	0.34	0.2	0.6
12/17/2022 12:00	2,678.6	0.0	2,678.6	105,000.0	281.3	0.34	0.2	0.6
12/17/2022 13:00	2,766.0	0.0	2,766.0	105,000.0	290.4	0.35	0.2	0.6
12/17/2022 14:00	3,164.8	16.3	3,166.1	105,000.0	332.4	0.40	0.2	0.7
12/17/2022 15:00	4,531.2	631.3	5,162.5	105,000.0	542.1	0.65	0.3	1.1
12/17/2022 16:00	4,532.2	789.9	5,322.1	105,000.0	558.8	0.67	0.3	1.1
12/17/2022 17:00	4,540.6	660.0	5,200.6	105,000.0	546.1	0.66	0.3	1.1
12/17/2022 18:00	4,548.0	473.2	5,021.2	105,000.0	527.2	0.63	0.3	1.1
12/17/2022 19:00	4,579.4	774.8	5,354.2	105,000.0	562.2	0.68	0.3	1.1
12/17/2022 20:00	4,588.7	962.0	5,550.7	105,000.0	582.8	0.70	0.3	1.2
12/17/2022 21:00	4,585.0	870.8	5,455.8	105,000.0	572.9	0.69	0.3	1.1
12/17/2022 22:00	4,616.2	735.8	5,352.0	105,000.0	562.0	0.68	0.3	1.1
12/17/2022 23:00	4,632.7	381.0	5,013.7	105,000.0	526.4	0.63	0.3	1.1
Average/Sum#:	3,840.7	287.1	4,123.8	105,000.0	433.0	0.52	0.3	0.9
Minimum:	2,678.6	0.0	2,678.6	105,000.0	281.3	0.34	0.2	0.6
Maximum:	4,684.3	962.0	5,550.7	105,000.0	582.8	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2022 00:00	4,267.9	1.7	4,267.9	105,000.0	448.1	0.54	0.3	0.9
12/18/2022 01:00	4,250.5	0.0	4,250.5	105,000.0	446.3	0.54	0.3	0.9
12/18/2022 02:00	4,073.0	0.0	4,073.0	105,000.0	427.7	0.51	0.3	0.9
12/18/2022 03:00	3,989.6	0.0	3,989.6	105,000.0	418.9	0.50	0.3	0.8
12/18/2022 04:00	4,207.7	0.0	4,207.7	105,000.0	441.8	0.53	0.3	0.9
12/18/2022 05:00	4,361.1	0.0	4,361.1	105,000.0	457.9	0.55	0.3	0.9
12/18/2022 06:00	4,470.3	135.8	4,531.4	105,000.0	475.8	0.58	0.3	1.0
12/18/2022 07:00	4,643.2	1,066.7	5,709.9	105,000.0	599.5	0.72	0.4	1.2
12/18/2022 08:00	4,675.0	740.5	5,415.5	105,000.0	568.6	0.68	0.3	1.1
12/18/2022 09:00	4,657.7	835.6	5,493.3	105,000.0	576.8	0.69	0.3	1.2
12/18/2022 10:00	4,601.7	424.8	4,928.8	105,000.0	517.5	0.63	0.3	1.1
12/18/2022 11:00	4,167.7	0.0	4,167.7	105,000.0	437.6	0.53	0.3	0.9
12/18/2022 12:00	3,488.2	0.0	3,488.2	105,000.0	366.3	0.44	0.2	0.7
12/18/2022 13:00	2,763.4	0.0	2,763.4	105,000.0	290.2	0.35	0.2	0.6
12/18/2022 14:00	3,369.5	0.0	3,369.5	105,000.0	353.8	0.43	0.2	0.7
12/18/2022 15:00	3,373.2	0.0	3,373.2	105,000.0	354.2	0.43	0.2	0.7
12/18/2022 16:00	4,619.0	106.7	4,706.5	105,000.0	494.2	0.60	0.3	1.0
12/18/2022 17:00	4,639.1	386.7	5,025.8	105,000.0	527.7	0.63	0.3	1.1
12/18/2022 18:00	4,639.9	757.1	5,397.0	105,000.0	566.7	0.68	0.3	1.1
12/18/2022 19:00	4,634.9	684.7	5,319.6	105,000.0	558.6	0.67	0.3	1.1
12/18/2022 20:00	4,666.0	598.5	5,264.5	105,000.0	552.8	0.66	0.3	1.1
12/18/2022 21:00	4,663.6	534.9	5,198.5	105,000.0	545.8	0.66	0.3	1.1
12/18/2022 22:00	4,657.6	461.3	5,118.9	105,000.0	537.5	0.64	0.3	1.1
12/18/2022 23:00	4,644.5	295.3	4,939.8	105,000.0	518.7	0.62	0.3	1.0
Average/Sum#:	4,271.8	292.9	4,556.7	105,000.0	478.5	0.58	0.3	1.0
Minimum:	2,763.4	0.0	2,763.4	105,000.0	290.2	0.35	0.2	0.6
Maximum:	4,675.0	1,066.7	5,709.9	105,000.0	599.5	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	4,646.9	598.5	5,245.4	105,000.0	550.8	0.66	0.3	1.1
12/19/2022 01:00	4,659.6	588.2	5,247.8	105,000.0	551.0	0.66	0.3	1.1
12/19/2022 02:00	4,652.6	598.7	5,251.3	105,000.0	551.4	0.66	0.3	1.1
12/19/2022 03:00	4,654.9	594.3	5,249.2	105,000.0	551.2	0.66	0.3	1.1
12/19/2022 04:00	4,663.4	789.2	5,452.6	105,000.0	572.5	0.69	0.3	1.1
12/19/2022 05:00	4,670.5	1,042.9	5,713.4	105,000.0	599.9	0.72	0.4	1.2
12/19/2022 06:00	4,664.0	1,074.8	5,738.8	105,000.0	602.6	0.72	0.4	1.2
12/19/2022 07:00	4,664.4	978.3	5,642.7	105,000.0	592.5	0.71	0.4	1.2
12/19/2022 08:00	4,681.1	796.2	5,477.3	105,000.0	575.1	0.69	0.3	1.2
12/19/2022 09:00	4,670.7	1,206.3	5,877.0	105,000.0	617.1	0.74	0.4	1.2
12/19/2022 10:00	4,662.7	1,128.1	5,790.8	105,000.0	608.0	0.73	0.4	1.2
12/19/2022 11:00	4,668.4	971.9	5,640.3	105,000.0	592.2	0.71	0.4	1.2
12/19/2022 12:00	4,664.6	735.9	5,400.5	105,000.0	567.1	0.68	0.3	1.1
12/19/2022 13:00	4,667.9	801.5	5,469.4	105,000.0	574.3	0.69	0.3	1.1
12/19/2022 14:00	4,656.2	908.4	5,564.6	105,000.0	584.3	0.70	0.4	1.2
12/19/2022 15:00	4,652.0	782.1	5,434.1	105,000.0	570.6	0.68	0.3	1.1
12/19/2022 16:00	4,664.4	998.6	5,663.0	105,000.0	594.6	0.71	0.4	1.2
12/19/2022 17:00	4,669.8	1,023.3	5,693.1	105,000.0	597.8	0.72	0.4	1.2
12/19/2022 18:00	4,670.5	1,012.2	5,682.7	105,000.0	596.7	0.72	0.4	1.2
12/19/2022 19:00	4,662.8	1,013.0	5,675.8	105,000.0	596.0	0.72	0.4	1.2
12/19/2022 20:00	4,663.1	1,013.7	5,676.8	105,000.0	596.1	0.72	0.4	1.2
12/19/2022 21:00	4,665.7	1,013.2	5,678.9	105,000.0	596.3	0.72	0.4	1.2
12/19/2022 22:00	4,674.5	1,004.1	5,678.6	105,000.0	596.3	0.72	0.4	1.2
12/19/2022 23:00	4,669.3	629.2	5,298.5	105,000.0	556.3	0.67	0.3	1.1
Average/Sum#:	4,664.2	887.6	5,551.8	105,000.0	582.9	0.70	0.4	1.2
Minimum:	4,646.9	588.2	5,245.4	105,000.0	550.8	0.66	0.3	1.1
Maximum:	4,681.1	1,206.3	5,877.0	105,000.0	617.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2022 00:00	4,550.2	1.6	4,550.2	105,000.0	477.8	0.57	0.3	1.0
12/20/2022 01:00	4,563.8	0.0	4,563.8	105,000.0	479.2	0.58	0.3	1.0
12/20/2022 02:00	4,563.7	0.0	4,563.7	105,000.0	479.2	0.58	0.3	1.0
12/20/2022 03:00	4,559.7	0.0	4,559.7	105,000.0	478.8	0.57	0.3	1.0
12/20/2022 04:00	4,555.0	0.0	4,555.0	105,000.0	478.3	0.57	0.3	1.0
12/20/2022 05:00	4,574.4	0.0	4,574.4	105,000.0	480.3	0.58	0.3	1.0
12/20/2022 06:00	4,568.2	2.5	4,568.3	105,000.0	479.7	0.58	0.3	1.0
12/20/2022 07:00	4,663.1	980.3	5,643.4	105,000.0	592.6	0.71	0.4	1.2
12/20/2022 08:00	4,665.1	721.9	5,387.0	105,000.0	565.6	0.68	0.3	1.1
12/20/2022 09:00	4,667.5	164.5	4,832.0	105,000.0	507.4	0.61	0.3	1.0
12/20/2022 10:00	4,223.5	67.9	4,258.8	105,000.0	447.2	0.54	0.3	0.9
12/20/2022 11:00	2,766.3	0.0	2,766.3	105,000.0	290.5	0.35	0.2	0.6
12/20/2022 12:00	2,697.1	0.0	2,697.1	105,000.0	283.2	0.34	0.2	0.6
12/20/2022 13:00	2,697.6	0.0	2,697.6	105,000.0	283.2	0.34	0.2	0.6
12/20/2022 14:00	2,689.9	0.0	2,689.9	105,000.0	282.4	0.34	0.2	0.6
12/20/2022 15:00	3,614.0	89.5	3,643.5	105,000.0	382.6	0.47	0.2	0.8
12/20/2022 16:00	4,605.6	245.4	4,851.0	105,000.0	509.4	0.61	0.3	1.0
12/20/2022 17:00	4,617.9	202.9	4,820.8	105,000.0	506.2	0.61	0.3	1.0
12/20/2022 18:00	4,630.8	194.3	4,825.1	105,000.0	506.6	0.61	0.3	1.0
12/20/2022 19:00	4,625.0	203.7	4,828.7	105,000.0	507.0	0.61	0.3	1.0
12/20/2022 20:00	4,608.9	208.5	4,817.4	105,000.0	505.8	0.61	0.3	1.0
12/20/2022 21:00	4,618.3	182.5	4,800.8	105,000.0	504.1	0.61	0.3	1.0
12/20/2022 22:00	4,626.7	172.2	4,798.9	105,000.0	503.9	0.60	0.3	1.0
12/20/2022 23:00	4,625.4	168.0	4,793.4	105,000.0	503.3	0.60	0.3	1.0
Average/Sum#:	4,232.4	150.2	4,378.6	105,000.0	459.8	0.55	0.3	0.9
Minimum:	2,689.9	0.0	2,689.9	105,000.0	282.4	0.34	0.2	0.6
Maximum:	4,667.5	980.3	5,643.4	105,000.0	592.6	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	4,638.9	154.0	4,792.9	105,000.0	503.3	0.60	0.3	1.0
12/21/2022 01:00	4,626.9	161.6	4,788.5	105,000.0	502.8	0.60	0.3	1.0
12/21/2022 02:00	4,632.4	140.3	4,772.7	105,000.0	501.1	0.60	0.3	1.0
12/21/2022 03:00	4,641.9	133.0	4,774.9	105,000.0	501.4	0.60	0.3	1.0
12/21/2022 04:00	4,644.4	131.7	4,776.1	105,000.0	501.5	0.60	0.3	1.0
12/21/2022 05:00	4,650.1	131.6	4,781.7	105,000.0	502.1	0.60	0.3	1.0
12/21/2022 06:00	4,656.7	208.8	4,865.5	105,000.0	510.9	0.61	0.3	1.0
12/21/2022 07:00	4,662.7	665.6	5,328.3	105,000.0	559.5	0.67	0.3	1.1
12/21/2022 08:00	4,667.9	413.8	5,081.7	105,000.0	533.6	0.64	0.3	1.1
12/21/2022 09:00	4,662.8	838.2	5,501.0	105,000.0	577.6	0.69	0.3	1.2
12/21/2022 10:00	4,666.8	722.7	5,389.5	105,000.0	565.9	0.68	0.3	1.1
12/21/2022 11:00	4,665.3	564.0	5,229.3	105,000.0	549.1	0.66	0.3	1.1
12/21/2022 12:00	4,654.1	535.1	5,189.2	105,000.0	544.9	0.65	0.3	1.1
12/21/2022 13:00	4,633.9	650.4	5,284.3	105,000.0	554.9	0.67	0.3	1.1
12/21/2022 14:00	4,613.9	559.4	5,173.3	105,000.0	543.2	0.65	0.3	1.1
12/21/2022 15:00	4,611.8	323.2	4,935.0	105,000.0	518.2	0.62	0.3	1.0
12/21/2022 16:00	4,622.1	567.6	5,189.7	105,000.0	544.9	0.65	0.3	1.1
12/21/2022 17:00	4,630.0	480.2	5,110.2	105,000.0	536.6	0.64	0.3	1.1
12/21/2022 18:00	4,650.0	401.1	5,051.1	105,000.0	530.4	0.64	0.3	1.1
12/21/2022 19:00	4,647.7	460.2	5,107.9	105,000.0	536.3	0.64	0.3	1.1
12/21/2022 20:00	4,631.8	766.8	5,398.6	105,000.0	566.9	0.68	0.3	1.1
12/21/2022 21:00	4,637.8	786.5	5,424.3	105,000.0	569.6	0.68	0.3	1.1
12/21/2022 22:00	4,645.3	307.1	4,952.4	105,000.0	520.0	0.62	0.3	1.0
12/21/2022 23:00	4,639.4	204.7	4,844.1	105,000.0	508.6	0.61	0.3	1.0
Average/Sum#:	4,643.1	429.5	5,072.6	105,000.0	532.6	0.64	0.3	1.1
Minimum:	4,611.8	131.6	4,772.7	105,000.0	501.1	0.60	0.3	1.0
Maximum:	4,667.9	838.2	5,501.0	105,000.0	577.6	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	4,649.4	131.9	4,781.3	105,000.0	502.0	0.60	0.3	1.0
12/22/2022 01:00	4,558.3	1.6	4,558.3	105,000.0	478.6	0.57	0.3	1.0
12/22/2022 02:00	4,560.3	0.0	4,560.3	105,000.0	478.8	0.57	0.3	1.0
12/22/2022 03:00	4,562.3	0.0	4,562.3	105,000.0	479.0	0.57	0.3	1.0
12/22/2022 04:00	4,551.8	0.0	4,551.8	105,000.0	477.9	0.57	0.3	1.0
12/22/2022 05:00	4,561.2	0.0	4,561.2	105,000.0	478.9	0.57	0.3	1.0
12/22/2022 06:00	4,563.8	0.0	4,563.8	105,000.0	479.2	0.57	0.3	1.0
12/22/2022 07:00	4,635.6	250.6	4,881.2	105,000.0	512.5	0.62	0.3	1.0
12/22/2022 08:00	4,633.8	223.8	4,857.6	105,000.0	510.0	0.61	0.3	1.0
12/22/2022 09:00	4,643.3	760.4	5,403.7	105,000.0	567.4	0.68	0.3	1.1
12/22/2022 10:00	4,639.0	1,044.8	5,683.8	105,000.0	596.8	0.72	0.4	1.2
12/22/2022 11:00	4,623.9	1,027.9	5,651.8	105,000.0	593.4	0.71	0.4	1.2
12/22/2022 12:00	4,617.7	454.6	5,072.3	105,000.0	532.6	0.64	0.3	1.1
12/22/2022 13:00	4,626.5	265.8	4,892.3	105,000.0	513.7	0.62	0.3	1.0
12/22/2022 14:00	4,611.8	204.2	4,816.0	105,000.0	505.7	0.61	0.3	1.0
12/22/2022 15:00	4,599.1	270.1	4,869.2	105,000.0	511.3	0.61	0.3	1.0
12/22/2022 16:00	4,596.7	600.6	5,197.3	105,000.0	545.7	0.66	0.3	1.1
12/22/2022 17:00	4,612.1	348.2	4,960.3	105,000.0	520.8	0.62	0.3	1.0
12/22/2022 18:00	4,622.5	324.4	4,946.9	105,000.0	519.4	0.62	0.3	1.0
12/22/2022 19:00	4,628.3	237.3	4,865.6	105,000.0	510.9	0.61	0.3	1.0
12/22/2022 20:00	4,631.5	177.3	4,808.8	105,000.0	504.9	0.61	0.3	1.0
12/22/2022 21:00	4,619.0	273.1	4,892.1	105,000.0	513.7	0.62	0.3	1.0
12/22/2022 22:00	4,624.7	285.7	4,910.4	105,000.0	515.6	0.62	0.3	1.0
12/22/2022 23:00	4,629.2	188.7	4,817.9	105,000.0	505.9	0.61	0.3	1.0
Average/Sum#:	4,608.4	294.6	4,902.8	105,000.0	514.8	0.62	0.3	1.0
Minimum:	4,551.8	0.0	4,551.8	105,000.0	477.9	0.57	0.3	1.0
Maximum:	4,649.4	1,044.8	5,683.8	105,000.0	596.8	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2022 00:00	4,624.2	193.3	4,817.5	105,000.0	505.8	0.61	0.3	1.0
12/23/2022 01:00	4,622.3	195.0	4,817.3	105,000.0	505.8	0.61	0.3	1.0
12/23/2022 02:00	4,620.8	192.1	4,812.9	105,000.0	505.4	0.61	0.3	1.0
12/23/2022 03:00	4,630.3	183.4	4,813.7	105,000.0	505.4	0.61	0.3	1.0
12/23/2022 04:00	4,640.8	174.5	4,815.3	105,000.0	505.6	0.61	0.3	1.0
12/23/2022 05:00	4,637.7	168.9	4,806.6	105,000.0	504.7	0.61	0.3	1.0
12/23/2022 06:00	4,639.2	158.2	4,797.4	105,000.0	503.7	0.60	0.3	1.0
12/23/2022 07:00	4,639.5	709.4	5,348.9	105,000.0	561.6	0.67	0.3	1.1
12/23/2022 08:00	4,653.8	448.1	5,101.9	105,000.0	535.7	0.64	0.3	1.1
12/23/2022 09:00	4,650.7	528.5	5,179.2	105,000.0	543.8	0.65	0.3	1.1
12/23/2022 10:00	4,641.1	482.5	5,123.6	105,000.0	538.0	0.65	0.3	1.1
12/23/2022 11:00	4,629.0	470.9	5,099.9	105,000.0	535.5	0.64	0.3	1.1
12/23/2022 12:00	4,584.7	231.3	4,762.8	105,000.0	500.1	0.61	0.3	1.0
12/23/2022 13:00	3,132.0	0.0	3,132.0	105,000.0	328.9	0.40	0.2	0.7
12/23/2022 14:00	3,314.9	19.1	3,317.2	105,000.0	348.3	0.42	0.2	0.7
12/23/2022 15:00	4,550.6	462.5	5,013.1	105,000.0	526.4	0.63	0.3	1.1
12/23/2022 16:00	4,566.0	947.4	5,513.4	105,000.0	578.9	0.70	0.3	1.2
12/23/2022 17:00	4,584.2	875.2	5,459.4	105,000.0	573.2	0.69	0.3	1.1
12/23/2022 18:00	4,591.3	829.9	5,421.2	105,000.0	569.2	0.68	0.3	1.1
12/23/2022 19:00	4,589.1	635.6	5,224.7	105,000.0	548.6	0.66	0.3	1.1
12/23/2022 20:00	4,603.0	589.8	5,192.8	105,000.0	545.2	0.65	0.3	1.1
12/23/2022 21:00	4,607.3	654.6	5,261.9	105,000.0	552.5	0.66	0.3	1.1
12/23/2022 22:00	4,629.9	563.3	5,193.2	105,000.0	545.3	0.65	0.3	1.1
12/23/2022 23:00	4,638.9	427.0	5,065.9	105,000.0	531.9	0.64	0.3	1.1
Average/Sum#:	4,500.9	422.5	4,920.5	105,000.0	516.6	0.62	0.3	1.0
Minimum:	3,132.0	0.0	3,132.0	105,000.0	328.9	0.40	0.2	0.7
Maximum:	4,653.8	947.4	5,513.4	105,000.0	578.9	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2022 00:00	4,539.9	1.6	4,539.9	105,000.0	476.7	0.57	0.3	1.0
12/24/2022 01:00	4,546.4	0.0	4,546.4	105,000.0	477.4	0.57	0.3	1.0
12/24/2022 02:00	4,555.3	0.0	4,555.3	105,000.0	478.3	0.57	0.3	1.0
12/24/2022 03:00	4,551.2	0.0	4,551.2	105,000.0	477.9	0.57	0.3	1.0
12/24/2022 04:00	4,545.3	0.0	4,545.3	105,000.0	477.3	0.57	0.3	1.0
12/24/2022 05:00	4,543.9	0.0	4,543.9	105,000.0	477.1	0.57	0.3	1.0
12/24/2022 06:00	4,480.7	0.0	4,480.7	105,000.0	470.5	0.56	0.3	0.9
12/24/2022 07:00	3,233.0	0.0	3,233.0	105,000.0	339.5	0.41	0.2	0.7
12/24/2022 08:00	2,772.4	0.0	2,772.4	105,000.0	291.1	0.35	0.2	0.6
12/24/2022 09:00	4,094.0	130.4	4,168.3	105,000.0	437.7	0.53	0.3	0.9
12/24/2022 10:00	4,666.2	459.9	5,126.1	105,000.0	538.2	0.65	0.3	1.1
12/24/2022 11:00	4,651.2	208.9	4,860.1	105,000.0	510.3	0.61	0.3	1.0
12/24/2022 12:00	4,626.4	264.9	4,891.3	105,000.0	513.6	0.62	0.3	1.0
12/24/2022 13:00	4,584.3	280.6	4,864.9	105,000.0	510.8	0.61	0.3	1.0
12/24/2022 14:00	4,572.9	244.0	4,816.9	105,000.0	505.8	0.61	0.3	1.0
12/24/2022 15:00	4,551.9	266.8	4,818.7	105,000.0	506.0	0.61	0.3	1.0
12/24/2022 16:00	4,552.5	310.2	4,862.7	105,000.0	510.6	0.61	0.3	1.0
12/24/2022 17:00	4,571.1	242.4	4,813.5	105,000.0	505.4	0.61	0.3	1.0
12/24/2022 18:00	4,570.9	220.3	4,791.2	105,000.0	503.1	0.60	0.3	1.0
12/24/2022 19:00	4,572.9	247.6	4,820.5	105,000.0	506.2	0.61	0.3	1.0
12/24/2022 20:00	4,298.7	117.5	4,359.8	105,000.0	457.8	0.56	0.3	0.9
12/24/2022 21:00	2,792.7	0.0	2,792.7	105,000.0	293.2	0.35	0.2	0.6
12/24/2022 22:00	2,812.1	0.0	2,812.1	105,000.0	295.3	0.35	0.2	0.6
12/24/2022 23:00	2,820.8	0.0	2,820.8	105,000.0	296.2	0.35	0.2	0.6
Average/Sum#:	4,187.8	124.8	4,307.8	105,000.0	452.3	0.54	0.3	0.9
Minimum:	2,772.4	0.0	2,772.4	105,000.0	291.1	0.35	0.2	0.6
Maximum:	4,666.2	459.9	5,126.1	105,000.0	538.2	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2022 00:00	2,973.2	0.0	2,973.2	105,000.0	312.2	0.38	0.2	0.6
12/25/2022 01:00	2,831.9	0.0	2,831.9	105,000.0	297.3	0.36	0.2	0.6
12/25/2022 02:00	2,817.8	0.0	2,817.8	105,000.0	295.9	0.36	0.2	0.6
12/25/2022 03:00	2,811.9	0.0	2,811.9	105,000.0	295.2	0.35	0.2	0.6
12/25/2022 04:00	2,810.0	0.0	2,810.0	105,000.0	295.1	0.35	0.2	0.6
12/25/2022 05:00	2,797.0	0.0	2,797.0	105,000.0	293.7	0.35	0.2	0.6
12/25/2022 06:00	2,795.9	0.0	2,795.9	105,000.0	293.6	0.35	0.2	0.6
12/25/2022 07:00	2,766.3	0.0	2,766.3	105,000.0	290.5	0.35	0.2	0.6
12/25/2022 08:00	2,789.1	0.0	2,789.1	105,000.0	292.9	0.35	0.2	0.6
12/25/2022 09:00	3,105.3	0.0	3,105.3	105,000.0	326.1	0.39	0.2	0.7
12/25/2022 10:00	2,822.8	0.0	2,822.8	105,000.0	296.4	0.36	0.2	0.6
12/25/2022 11:00	2,876.3	0.0	2,876.3	105,000.0	302.0	0.36	0.2	0.6
12/25/2022 12:00	2,996.9	0.0	2,996.9	105,000.0	314.7	0.38	0.2	0.6
12/25/2022 13:00	2,782.7	0.0	2,782.7	105,000.0	292.2	0.35	0.2	0.6
12/25/2022 14:00	2,735.7	0.0	2,735.7	105,000.0	287.2	0.35	0.2	0.6
12/25/2022 15:00	2,678.1	0.0	2,678.1	105,000.0	281.2	0.34	0.2	0.6
12/25/2022 16:00	3,586.2	87.6	3,615.1	105,000.0	379.6	0.46	0.2	0.8
12/25/2022 17:00	4,589.0	208.0	4,797.0	105,000.0	503.7	0.60	0.3	1.0
12/25/2022 18:00	3,364.9	1.5	3,364.9	105,000.0	353.3	0.43	0.2	0.7
12/25/2022 19:00	2,767.4	0.0	2,767.4	105,000.0	290.6	0.35	0.2	0.6
12/25/2022 20:00	2,774.6	0.0	2,774.6	105,000.0	291.3	0.35	0.2	0.6
12/25/2022 21:00	2,776.4	0.0	2,776.4	105,000.0	291.5	0.35	0.2	0.6
12/25/2022 22:00	2,743.9	0.0	2,743.9	105,000.0	288.1	0.35	0.2	0.6
12/25/2022 23:00	2,735.0	0.0	2,735.0	105,000.0	287.2	0.35	0.2	0.6
Average/Sum#:	2,947.0	12.4	2,956.9	105,000.0	310.5	0.37	0.2	0.6
Minimum:	2,678.1	0.0	2,678.1	105,000.0	281.2	0.34	0.2	0.6
Maximum:	4,589.0	208.0	4,797.0	105,000.0	503.7	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	2,946.1	0.0	2,946.1	105,000.0	309.3	0.37	0.2	0.6
12/26/2022 01:00	2,782.7	0.0	2,782.7	105,000.0	292.2	0.35	0.2	0.6
12/26/2022 02:00	2,905.8	0.0	2,905.8	105,000.0	305.1	0.37	0.2	0.6
12/26/2022 03:00	2,818.9	0.0	2,818.9	105,000.0	296.0	0.36	0.2	0.6
12/26/2022 04:00	2,779.0	0.0	2,779.0	105,000.0	291.8	0.35	0.2	0.6
12/26/2022 05:00	3,295.4	0.0	3,295.4	105,000.0	346.0	0.42	0.2	0.7
12/26/2022 06:00	3,292.8	0.0	3,292.8	105,000.0	345.7	0.42	0.2	0.7
12/26/2022 07:00	2,794.1	0.0	2,794.1	105,000.0	293.4	0.35	0.2	0.6
12/26/2022 08:00	2,668.4	0.0	2,668.4	105,000.0	280.2	0.34	0.2	0.6
12/26/2022 09:00	2,791.8	0.0	2,791.8	105,000.0	293.1	0.35	0.2	0.6
12/26/2022 10:00	3,585.5	0.0	3,585.5	105,000.0	376.5	0.45	0.2	0.8
12/26/2022 11:00	4,449.5	106.7	4,499.6	105,000.0	472.5	0.57	0.3	1.0
12/26/2022 12:00	4,577.5	216.9	4,794.4	105,000.0	503.4	0.60	0.3	1.0
12/26/2022 13:00	4,555.1	358.2	4,913.3	105,000.0	515.9	0.62	0.3	1.0
12/26/2022 14:00	4,547.5	625.6	5,173.1	105,000.0	543.2	0.65	0.3	1.1
12/26/2022 15:00	4,546.1	676.0	5,222.1	105,000.0	548.3	0.66	0.3	1.1
12/26/2022 16:00	4,527.1	529.1	5,056.2	105,000.0	530.9	0.64	0.3	1.1
12/26/2022 17:00	4,503.5	647.2	5,150.7	105,000.0	540.8	0.65	0.3	1.1
12/26/2022 18:00	4,516.6	631.4	5,148.0	105,000.0	540.5	0.65	0.3	1.1
12/26/2022 19:00	4,484.6	377.3	4,861.9	105,000.0	510.5	0.61	0.3	1.0
12/26/2022 20:00	4,468.4	383.0	4,851.4	105,000.0	509.4	0.61	0.3	1.0
12/26/2022 21:00	4,421.8	283.7	4,640.2	105,000.0	487.2	0.59	0.3	1.0
12/26/2022 22:00	2,821.0	0.0	2,821.0	105,000.0	296.2	0.35	0.2	0.6
12/26/2022 23:00	2,657.2	0.0	2,657.2	105,000.0	279.0	0.33	0.2	0.6
Average/Sum#:	3,655.7	201.5	3,852.1	105,000.0	404.5	0.49	0.2	0.8
Minimum:	2,657.2	0.0	2,657.2	105,000.0	279.0	0.33	0.2	0.6
Maximum:	4,577.5	676.0	5,222.1	105,000.0	548.3	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2022 00:00	2,691.9	0.0	2,691.9	105,000.0	282.6	0.34	0.2	0.6
12/27/2022 01:00	2,646.4	0.0	2,646.4	105,000.0	277.9	0.33	0.2	0.6
12/27/2022 02:00	2,644.0	0.0	2,644.0	105,000.0	277.6	0.33	0.2	0.6
12/27/2022 03:00	2,644.9	0.0	2,644.9	105,000.0	277.7	0.33	0.2	0.6
12/27/2022 04:00	2,644.4	0.0	2,644.4	105,000.0	277.7	0.33	0.2	0.6
12/27/2022 05:00	2,648.3	0.0	2,648.3	105,000.0	278.1	0.33	0.2	0.6
12/27/2022 06:00	2,684.5	0.0	2,684.5	105,000.0	281.9	0.34	0.2	0.6
12/27/2022 07:00	2,658.0	0.0	2,658.0	105,000.0	279.1	0.33	0.2	0.6
12/27/2022 08:00	2,773.6	0.0	2,773.6	105,000.0	291.2	0.35	0.2	0.6
12/27/2022 09:00	2,714.6	0.0	2,714.6	105,000.0	285.0	0.34	0.2	0.6
12/27/2022 10:00	2,653.5	0.0	2,653.5	105,000.0	278.6	0.33	0.2	0.6
12/27/2022 11:00	2,661.2	0.0	2,661.2	105,000.0	279.4	0.34	0.2	0.6
12/27/2022 12:00	2,669.0	0.0	2,669.0	105,000.0	280.2	0.34	0.2	0.6
12/27/2022 13:00	2,769.2	0.0	2,769.2	105,000.0	290.8	0.35	0.2	0.6
12/27/2022 14:00	2,761.2	0.0	2,761.2	105,000.0	289.9	0.35	0.2	0.6
12/27/2022 15:00	2,678.1	0.0	2,678.1	105,000.0	281.2	0.34	0.2	0.6
12/27/2022 16:00	2,683.5	0.0	2,683.5	105,000.0	281.8	0.34	0.2	0.6
12/27/2022 17:00	2,667.2	0.0	2,667.2	105,000.0	280.1	0.33	0.2	0.6
12/27/2022 18:00	2,679.6	0.0	2,679.6	105,000.0	281.4	0.34	0.2	0.6
12/27/2022 19:00	2,664.4	0.0	2,664.4	105,000.0	279.8	0.34	0.2	0.6
12/27/2022 20:00	2,655.6	0.0	2,655.6	105,000.0	278.8	0.33	0.2	0.6
12/27/2022 21:00	2,654.2	0.0	2,654.2	105,000.0	278.7	0.33	0.2	0.6
12/27/2022 22:00	2,651.4	0.0	2,651.4	105,000.0	278.4	0.33	0.2	0.6
12/27/2022 23:00	2,590.1	0.0	2,590.1	105,000.0	272.0	0.33	0.2	0.6
Average/Sum#:	2,674.5	0.0	2,674.5	105,000.0	280.8	0.34	0.2	0.6
Minimum:	2,590.1	0.0	2,590.1	105,000.0	272.0	0.33	0.2	0.6
Maximum:	2,773.6	0.0	2,773.6	105,000.0	291.2	0.35	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2022 00:00	1,078.2	0.0	1,078.2	105,000.0	113.2	0.00	0.0	0.0
12/28/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/28/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	1,078.2	0.0	1,078.2	105,000.0	113.2	0.00	0.0	0.0
Minimum:	1,078.2	0.0	1,078.2	105,000.0	113.2	0.00	0.0	0.0
Maximum:	1,078.2	0.0	1,078.2	105,000.0	113.2	0.00	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/29/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/30/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:22 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
12/31/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	4,333.6	0.0	4,333.6	104,400.0	452.4	0.5	0.3	0.9
10/01/2022 01:00	4,127.6	0.0	4,127.6	104,400.0	430.9	0.5	0.3	0.9
10/01/2022 02:00	4,232.5	0.0	4,232.5	104,400.0	441.9	0.5	0.3	0.9
10/01/2022 03:00	4,370.6	0.0	4,370.6	104,400.0	456.3	0.5	0.3	0.9
10/01/2022 04:00	4,237.2	0.0	4,237.2	104,400.0	442.4	0.5	0.3	0.9
10/01/2022 05:00	4,482.6	0.0	4,482.6	104,400.0	468.0	0.6	0.3	0.9
10/01/2022 06:00	3,716.6	0.0	3,716.6	104,400.0	388.0	0.5	0.2	0.8
10/01/2022 07:00	2,829.3	0.0	2,829.3	104,400.0	295.4	0.4	0.2	0.6
10/01/2022 08:00	2,824.8	0.0	2,824.8	104,400.0	294.9	0.4	0.2	0.6
10/01/2022 09:00	2,820.1	0.0	2,820.1	104,400.0	294.4	0.4	0.2	0.6
10/01/2022 10:00	2,818.2	0.0	2,818.2	104,400.0	294.2	0.4	0.2	0.6
10/01/2022 11:00	2,809.7	0.0	2,809.7	104,400.0	293.3	0.4	0.2	0.6
10/01/2022 12:00	2,806.6	0.0	2,806.6	104,400.0	293.0	0.4	0.2	0.6
10/01/2022 13:00	2,847.9	0.0	2,847.9	104,400.0	297.3	0.4	0.2	0.6
10/01/2022 14:00	2,809.6	0.0	2,809.6	104,400.0	293.3	0.4	0.2	0.6
10/01/2022 15:00	2,844.3	0.0	2,844.3	104,400.0	296.9	0.4	0.2	0.6
10/01/2022 16:00	3,886.6	0.0	3,886.6	104,400.0	405.8	0.5	0.2	0.8
10/01/2022 17:00	4,597.7	0.0	4,597.7	104,400.0	480.0	0.6	0.3	1.0
10/01/2022 18:00	4,365.0	0.0	4,365.0	104,400.0	455.7	0.5	0.3	0.9
10/01/2022 19:00	4,139.7	0.0	4,139.7	104,400.0	432.2	0.5	0.3	0.9
10/01/2022 20:00	4,450.9	0.0	4,450.9	104,400.0	464.7	0.6	0.3	0.9
10/01/2022 21:00	4,150.9	0.0	4,150.9	104,400.0	433.4	0.5	0.3	0.9
10/01/2022 22:00	3,351.8	0.0	3,351.8	104,400.0	349.9	0.4	0.2	0.7
10/01/2022 23:00	3,960.6	0.0	3,960.6	104,400.0	413.5	0.5	0.2	0.8
Average/Sum#:	3,658.9	0.0	3,658.9	104,400.0	382.0	0.5	0.2	0.8
Minimum:	2,806.6	0.0	2,806.6	104,400.0	293.0	0.4	0.2	0.6
Maximum:	4,597.7	0.0	4,597.7	104,400.0	480.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2022 00:00	3,732.3	0.0	3,732.3	104,400.0	389.7	0.5	0.2	0.8
10/02/2022 01:00	3,649.7	0.0	3,649.7	104,400.0	381.0	0.5	0.2	0.8
10/02/2022 02:00	4,340.9	0.0	4,340.9	104,400.0	453.2	0.5	0.3	0.9
10/02/2022 03:00	4,368.8	0.0	4,368.8	104,400.0	456.1	0.5	0.3	0.9
10/02/2022 04:00	4,576.1	0.0	4,576.1	104,400.0	477.7	0.6	0.3	1.0
10/02/2022 05:00	4,543.2	0.0	4,543.2	104,400.0	474.3	0.6	0.3	0.9
10/02/2022 06:00	3,907.4	0.0	3,907.4	104,400.0	407.9	0.5	0.2	0.8
10/02/2022 07:00	2,840.8	0.0	2,840.8	104,400.0	296.6	0.4	0.2	0.6
10/02/2022 08:00	2,827.9	0.0	2,827.9	104,400.0	295.2	0.4	0.2	0.6
10/02/2022 09:00	2,822.6	0.0	2,822.6	104,400.0	294.7	0.4	0.2	0.6
10/02/2022 10:00	2,818.5	0.0	2,818.5	104,400.0	294.3	0.4	0.2	0.6
10/02/2022 11:00	2,818.3	0.0	2,818.3	104,400.0	294.2	0.4	0.2	0.6
10/02/2022 12:00	2,877.7	0.0	2,877.7	104,400.0	300.4	0.4	0.2	0.6
10/02/2022 13:00	3,468.3	0.0	3,468.3	104,400.0	362.1	0.4	0.2	0.7
10/02/2022 14:00	4,323.8	0.0	4,323.8	104,400.0	451.4	0.5	0.3	0.9
10/02/2022 15:00	3,613.3	0.0	3,613.3	104,400.0	377.2	0.5	0.2	0.8
10/02/2022 16:00	4,425.3	100.0	4,458.3	104,400.0	465.4	0.6	0.3	0.9
10/02/2022 17:00	4,652.1	618.2	5,270.3	104,400.0	550.2	0.7	0.3	1.1
10/02/2022 18:00	4,696.5	560.7	5,257.2	104,400.0	548.9	0.7	0.3	1.1
10/02/2022 19:00	4,719.0	517.3	5,236.3	104,400.0	546.7	0.7	0.3	1.1
10/02/2022 20:00	4,745.3	404.3	5,149.6	104,400.0	537.6	0.6	0.3	1.1
10/02/2022 21:00	4,139.4	0.7	4,139.4	104,400.0	432.2	0.5	0.3	0.9
10/02/2022 22:00	3,695.9	0.0	3,695.9	105,600.0	390.3	0.5	0.2	0.8
10/02/2022 23:00	4,571.7	0.0	4,571.7	105,600.0	482.8	0.6	0.3	1.0
Average/Sum#:	3,882.3	91.7	3,971.2	104,500.0	415.0	0.5	0.3	0.8
Minimum:	2,818.3	0.0	2,818.3	104,400.0	294.2	0.4	0.2	0.6
Maximum:	4,745.3	618.2	5,270.3	105,600.0	550.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2022 00:00	4,377.5	0.0	4,377.5	105,600.0	462.3	0.6	0.3	0.9
10/03/2022 01:00	4,313.5	0.0	4,313.5	105,600.0	455.5	0.5	0.3	0.9
10/03/2022 02:00	4,361.2	0.0	4,361.2	105,600.0	460.5	0.6	0.3	0.9
10/03/2022 03:00	4,409.4	0.0	4,409.4	105,600.0	465.6	0.6	0.3	0.9
10/03/2022 04:00	4,536.6	0.0	4,536.6	105,600.0	479.1	0.6	0.3	1.0
10/03/2022 05:00	4,588.0	0.0	4,588.0	105,600.0	484.5	0.6	0.3	1.0
10/03/2022 06:00	4,212.1	0.0	4,212.1	105,600.0	444.8	0.5	0.3	0.9
10/03/2022 07:00	3,271.2	0.0	3,271.2	105,600.0	345.4	0.4	0.2	0.7
10/03/2022 08:00	4,250.8	0.0	4,250.8	105,600.0	448.9	0.5	0.3	0.9
10/03/2022 09:00	2,981.7	0.0	2,981.7	105,600.0	314.9	0.4	0.2	0.6
10/03/2022 10:00	3,340.8	0.0	3,340.8	105,600.0	352.8	0.4	0.2	0.7
10/03/2022 11:00	3,856.0	0.0	3,856.0	105,600.0	407.2	0.5	0.2	0.8
10/03/2022 12:00	4,535.5	0.0	4,535.5	105,600.0	478.9	0.6	0.3	1.0
10/03/2022 13:00	4,551.4	0.0	4,551.4	105,600.0	480.6	0.6	0.3	1.0
10/03/2022 14:00	4,541.6	0.0	4,541.6	105,600.0	479.6	0.6	0.3	1.0
10/03/2022 15:00	4,586.8	0.0	4,586.8	105,600.0	484.4	0.6	0.3	1.0
10/03/2022 16:00	4,414.3	10.8	4,415.1	105,600.0	466.2	0.6	0.3	0.9
10/03/2022 17:00	4,627.4	603.5	5,230.9	105,600.0	552.4	0.7	0.3	1.1
10/03/2022 18:00	4,666.2	601.1	5,267.3	105,600.0	556.2	0.7	0.3	1.1
10/03/2022 19:00	4,711.4	542.2	5,253.6	105,600.0	554.8	0.7	0.3	1.1
10/03/2022 20:00	4,725.8	485.6	5,211.4	105,600.0	550.3	0.7	0.3	1.1
10/03/2022 21:00	4,467.8	158.8	4,550.4	105,600.0	480.5	0.6	0.3	1.0
10/03/2022 22:00	4,518.9	0.0	4,518.9	105,600.0	477.2	0.6	0.3	1.0
10/03/2022 23:00	4,781.0	369.3	5,142.9	105,600.0	543.1	0.7	0.3	1.1
Average/Sum#:	4,317.8	115.5	4,429.4	105,600.0	467.7	0.6	0.3	0.9
Minimum:	2,981.7	0.0	2,981.7	105,600.0	314.9	0.4	0.2	0.6
Maximum:	4,781.0	603.5	5,267.3	105,600.0	556.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	4,801.6	381.8	5,183.4	105,600.0	547.4	0.7	0.3	1.1
10/04/2022 01:00	4,792.5	440.3	5,232.8	105,600.0	552.6	0.7	0.3	1.1
10/04/2022 02:00	4,793.9	369.7	5,163.6	105,600.0	545.3	0.7	0.3	1.1
10/04/2022 03:00	4,811.7	371.9	5,183.6	105,600.0	547.4	0.7	0.3	1.1
10/04/2022 04:00	4,815.5	291.6	5,086.7	105,600.0	537.2	0.6	0.3	1.1
10/04/2022 05:00	4,806.3	406.3	5,212.6	105,600.0	550.5	0.7	0.3	1.1
10/04/2022 06:00	4,809.1	284.1	5,070.5	105,600.0	535.4	0.6	0.3	1.1
10/04/2022 07:00	4,744.4	100.5	4,821.8	105,600.0	509.2	0.6	0.3	1.0
10/04/2022 08:00	4,576.5	0.0	4,576.5	105,600.0	483.3	0.6	0.3	1.0
10/04/2022 09:00	4,683.1	189.4	4,774.0	105,600.0	504.1	0.6	0.3	1.0
10/04/2022 10:00	4,734.3	457.8	5,192.1	105,600.0	548.3	0.7	0.3	1.1
10/04/2022 11:00	4,655.0	74.1	4,673.5	105,600.0	493.5	0.6	0.3	1.0
10/04/2022 12:00	4,649.4	532.1	5,181.5	105,600.0	547.2	0.7	0.3	1.1
10/04/2022 13:00	4,633.7	431.8	5,065.5	105,600.0	534.9	0.6	0.3	1.1
10/04/2022 14:00	4,626.2	413.6	5,039.8	105,600.0	532.2	0.6	0.3	1.1
10/04/2022 15:00	4,631.7	523.1	5,154.8	105,600.0	544.3	0.7	0.3	1.1
10/04/2022 16:00	4,609.2	401.6	5,010.8	105,600.0	529.1	0.6	0.3	1.1
10/04/2022 17:00	4,616.8	330.6	4,947.4	105,600.0	522.4	0.6	0.3	1.0
10/04/2022 18:00	4,628.1	332.6	4,960.7	105,600.0	523.8	0.6	0.3	1.0
10/04/2022 19:00	4,658.2	334.2	4,992.4	105,600.0	527.2	0.6	0.3	1.1
10/04/2022 20:00	4,676.4	336.8	5,013.2	105,600.0	529.4	0.6	0.3	1.1
10/04/2022 21:00	4,696.9	338.5	5,035.4	105,600.0	531.7	0.6	0.3	1.1
10/04/2022 22:00	4,720.8	338.2	5,059.0	105,600.0	534.2	0.6	0.3	1.1
10/04/2022 23:00	4,726.8	338.9	5,065.7	105,600.0	534.9	0.6	0.3	1.1
Average/Sum#:	4,704.1	334.1	5,029.1	105,600.0	531.1	0.6	0.3	1.1
Minimum:	4,576.5	0.0	4,576.5	105,600.0	483.3	0.6	0.3	1.0
Maximum:	4,815.5	532.1	5,232.8	105,600.0	552.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2022 00:00	4,740.6	339.7	5,080.3	105,600.0	536.5	0.6	0.3	1.1
10/05/2022 01:00	4,764.7	340.5	5,105.2	105,600.0	539.1	0.6	0.3	1.1
10/05/2022 02:00	4,768.8	340.7	5,109.5	105,600.0	539.6	0.6	0.3	1.1
10/05/2022 03:00	4,773.3	340.8	5,114.1	105,600.0	540.0	0.6	0.3	1.1
10/05/2022 04:00	4,805.8	340.7	5,146.5	105,600.0	543.5	0.7	0.3	1.1
10/05/2022 05:00	4,815.4	340.7	5,156.1	105,600.0	544.5	0.7	0.3	1.1
10/05/2022 06:00	4,815.9	322.8	5,138.7	105,600.0	542.6	0.7	0.3	1.1
10/05/2022 07:00	4,789.0	243.8	5,032.8	105,600.0	531.5	0.6	0.3	1.1
10/05/2022 08:00	4,602.8	101.2	4,655.4	105,600.0	491.6	0.6	0.3	1.0
10/05/2022 09:00	4,416.3	51.7	4,430.8	105,600.0	467.9	0.6	0.3	0.9
10/05/2022 10:00	4,707.1	268.7	4,975.8	105,600.0	525.4	0.6	0.3	1.1
10/05/2022 11:00	4,665.7	295.5	4,961.2	105,600.0	523.9	0.6	0.3	1.0
10/05/2022 12:00	4,640.8	300.9	4,941.7	105,600.0	521.8	0.6	0.3	1.0
10/05/2022 13:00	4,616.6	307.5	4,924.1	105,600.0	520.0	0.6	0.3	1.0
10/05/2022 14:00	4,611.1	326.7	4,937.8	105,600.0	521.4	0.6	0.3	1.0
10/05/2022 15:00	4,594.0	326.6	4,920.6	105,600.0	519.6	0.6	0.3	1.0
10/05/2022 16:00	4,605.9	326.0	4,931.9	105,600.0	520.8	0.6	0.3	1.0
10/05/2022 17:00	4,605.9	328.0	4,933.9	105,600.0	521.0	0.6	0.3	1.0
10/05/2022 18:00	4,627.2	330.1	4,957.3	105,600.0	523.5	0.6	0.3	1.0
10/05/2022 19:00	4,656.2	333.4	4,989.6	105,600.0	526.9	0.6	0.3	1.1
10/05/2022 20:00	4,681.7	334.7	5,016.4	105,600.0	529.7	0.6	0.3	1.1
10/05/2022 21:00	4,682.1	336.1	5,018.2	105,600.0	529.9	0.6	0.3	1.1
10/05/2022 22:00	4,724.3	279.4	5,003.7	105,600.0	528.4	0.6	0.3	1.1
10/05/2022 23:00	4,628.9	0.0	4,628.9	105,600.0	488.8	0.6	0.3	1.0
Average/Sum#:	4,680.8	285.7	4,962.9	105,600.0	524.1	0.6	0.3	1.1
Minimum:	4,416.3	0.0	4,430.8	105,600.0	467.9	0.6	0.3	0.9
Maximum:	4,815.9	340.8	5,156.1	105,600.0	544.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2022 00:00	4,626.9	0.0	4,626.9	105,600.0	488.6	0.6	0.3	1.0
10/06/2022 01:00	4,638.5	0.0	4,638.5	105,600.0	489.8	0.6	0.3	1.0
10/06/2022 02:00	4,637.9	0.0	4,637.9	105,600.0	489.8	0.6	0.3	1.0
10/06/2022 03:00	4,634.3	0.0	4,634.3	105,600.0	489.4	0.6	0.3	1.0
10/06/2022 04:00	4,635.1	0.0	4,635.1	105,600.0	489.5	0.6	0.3	1.0
10/06/2022 05:00	4,684.6	31.2	4,690.2	105,600.0	495.3	0.6	0.3	1.0
10/06/2022 06:00	4,819.5	324.3	5,117.9	105,600.0	540.5	0.7	0.3	1.1
10/06/2022 07:00	4,337.1	96.7	4,387.4	105,600.0	463.3	0.6	0.3	0.9
10/06/2022 08:00	3,119.2	0.0	3,119.2	105,600.0	329.4	0.4	0.2	0.7
10/06/2022 09:00	2,955.8	0.0	2,955.8	105,600.0	312.1	0.4	0.2	0.6
10/06/2022 10:00	2,965.3	0.0	2,965.3	105,600.0	313.1	0.4	0.2	0.6
10/06/2022 11:00	3,433.2	0.0	3,433.2	105,600.0	362.5	0.4	0.2	0.7
10/06/2022 12:00	3,943.0	0.0	3,943.0	105,600.0	416.4	0.5	0.2	0.8
10/06/2022 13:00	4,467.1	79.0	4,482.9	105,600.0	473.4	0.6	0.3	1.0
10/06/2022 14:00	4,605.6	409.1	5,014.7	105,600.0	529.6	0.6	0.3	1.1
10/06/2022 15:00	4,602.3	327.6	4,929.9	105,600.0	520.6	0.6	0.3	1.0
10/06/2022 16:00	4,603.5	328.0	4,931.5	105,600.0	520.8	0.6	0.3	1.0
10/06/2022 17:00	4,614.2	329.5	4,943.7	105,600.0	522.1	0.6	0.3	1.0
10/06/2022 18:00	4,639.6	332.3	4,971.9	105,600.0	525.0	0.6	0.3	1.1
10/06/2022 19:00	4,662.6	335.8	4,998.4	105,600.0	527.8	0.6	0.3	1.1
10/06/2022 20:00	4,686.8	336.3	5,023.1	105,600.0	530.4	0.6	0.3	1.1
10/06/2022 21:00	4,709.1	338.1	5,047.2	105,600.0	533.0	0.6	0.3	1.1
10/06/2022 22:00	4,765.7	338.1	5,103.8	105,600.0	539.0	0.6	0.3	1.1
10/06/2022 23:00	4,780.0	339.4	5,119.4	105,600.0	540.6	0.6	0.3	1.1
Average/Sum#:	4,357.0	164.4	4,514.6	105,600.0	476.8	0.6	0.3	1.0
Minimum:	2,955.8	0.0	2,955.8	105,600.0	312.1	0.4	0.2	0.6
Maximum:	4,819.5	409.1	5,119.4	105,600.0	540.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2022 00:00	4,774.0	341.2	5,115.2	105,600.0	540.2	0.6	0.3	1.1
10/07/2022 01:00	4,784.5	341.1	5,125.6	105,600.0	541.3	0.6	0.3	1.1
10/07/2022 02:00	4,829.0	294.7	5,123.7	105,600.0	541.1	0.6	0.3	1.1
10/07/2022 03:00	4,847.6	180.2	5,027.8	105,600.0	530.9	0.6	0.3	1.1
10/07/2022 04:00	4,849.8	145.9	4,985.5	105,600.0	526.5	0.6	0.3	1.1
10/07/2022 05:00	4,866.6	191.0	5,057.6	105,600.0	534.1	0.6	0.3	1.1
10/07/2022 06:00	4,873.1	174.5	5,047.6	105,600.0	533.0	0.6	0.3	1.1
10/07/2022 07:00	4,843.4	123.3	4,966.7	105,600.0	524.5	0.6	0.3	1.0
10/07/2022 08:00	4,829.3	99.7	4,929.0	105,600.0	520.5	0.6	0.3	1.0
10/07/2022 09:00	4,773.9	112.0	4,885.9	105,600.0	516.0	0.6	0.3	1.0
10/07/2022 10:00	4,746.0	165.9	4,911.9	105,600.0	518.7	0.6	0.3	1.0
10/07/2022 11:00	4,712.5	199.0	4,911.5	105,600.0	518.7	0.6	0.3	1.0
10/07/2022 12:00	4,664.9	257.0	4,921.9	105,600.0	519.8	0.6	0.3	1.0
10/07/2022 13:00	4,636.2	286.0	4,922.2	105,600.0	519.8	0.6	0.3	1.0
10/07/2022 14:00	4,629.7	295.7	4,925.4	105,600.0	520.1	0.6	0.3	1.0
10/07/2022 15:00	4,609.2	295.8	4,905.0	105,600.0	518.0	0.6	0.3	1.0
10/07/2022 16:00	4,619.8	302.0	4,921.8	105,600.0	519.7	0.6	0.3	1.0
10/07/2022 17:00	4,620.1	322.8	4,942.9	105,600.0	522.0	0.6	0.3	1.0
10/07/2022 18:00	4,651.8	327.5	4,979.3	105,600.0	525.8	0.6	0.3	1.1
10/07/2022 19:00	4,654.1	330.4	4,984.5	105,600.0	526.4	0.6	0.3	1.1
10/07/2022 20:00	4,688.7	331.4	5,020.1	105,600.0	530.1	0.6	0.3	1.1
10/07/2022 21:00	4,722.5	330.9	5,053.4	105,600.0	533.6	0.6	0.3	1.1
10/07/2022 22:00	4,734.6	331.2	5,065.8	105,600.0	534.9	0.6	0.3	1.1
10/07/2022 23:00	4,767.8	331.7	5,099.5	105,600.0	538.5	0.6	0.3	1.1
Average/Sum#:	4,738.7	254.6	4,992.9	105,600.0	527.3	0.6	0.3	1.1
Minimum:	4,609.2	99.7	4,885.9	105,600.0	516.0	0.6	0.3	1.0
Maximum:	4,873.1	341.2	5,125.6	105,600.0	541.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2022 00:00	4,766.5	331.2	5,097.7	105,600.0	538.3	0.6	0.3	1.1
10/08/2022 01:00	4,796.7	331.5	5,128.2	105,600.0	541.5	0.7	0.3	1.1
10/08/2022 02:00	4,813.6	332.6	5,146.2	105,600.0	543.4	0.7	0.3	1.1
10/08/2022 03:00	4,824.4	334.7	5,159.1	105,600.0	544.8	0.7	0.3	1.1
10/08/2022 04:00	4,823.6	335.2	5,158.8	105,600.0	544.8	0.7	0.3	1.1
10/08/2022 05:00	4,842.5	335.7	5,178.2	105,600.0	546.8	0.7	0.3	1.1
10/08/2022 06:00	4,498.5	193.8	4,610.9	105,600.0	486.9	0.6	0.3	1.0
10/08/2022 07:00	3,385.7	0.0	3,385.7	105,600.0	357.5	0.4	0.2	0.7
10/08/2022 08:00	3,242.3	0.0	3,242.3	105,600.0	342.4	0.4	0.2	0.7
10/08/2022 09:00	3,306.2	0.0	3,306.2	105,600.0	349.1	0.4	0.2	0.7
10/08/2022 10:00	2,960.9	0.0	2,960.9	105,600.0	312.7	0.4	0.2	0.6
10/08/2022 11:00	3,451.6	0.0	3,451.6	105,600.0	364.5	0.4	0.2	0.7
10/08/2022 12:00	3,877.4	1.6	3,877.4	105,600.0	409.5	0.5	0.2	0.8
10/08/2022 13:00	4,561.9	77.7	4,603.1	105,600.0	486.1	0.6	0.3	1.0
10/08/2022 14:00	4,379.1	157.4	4,445.2	105,600.0	469.4	0.6	0.3	1.0
10/08/2022 15:00	4,586.8	373.7	4,960.5	105,600.0	523.8	0.6	0.3	1.0
10/08/2022 16:00	4,604.7	359.2	4,963.9	105,600.0	524.2	0.6	0.3	1.0
10/08/2022 17:00	4,594.4	392.0	4,986.4	105,600.0	526.6	0.6	0.3	1.1
10/08/2022 18:00	4,632.8	397.0	5,029.8	105,600.0	531.1	0.6	0.3	1.1
10/08/2022 19:00	4,669.3	399.2	5,068.5	105,600.0	535.2	0.6	0.3	1.1
10/08/2022 20:00	4,654.4	399.2	5,053.6	105,600.0	533.7	0.6	0.3	1.1
10/08/2022 21:00	4,711.7	353.9	5,023.1	105,600.0	530.4	0.6	0.3	1.1
10/08/2022 22:00	3,677.4	173.5	3,734.7	105,600.0	394.4	0.5	0.3	0.9
10/08/2022 23:00	1,007.4	0.0	1,007.4	105,600.0	106.4	0.0	0.0	0.0
Average/Sum#:	4,152.9	220.0	4,357.5	105,600.0	460.1	0.6	0.3	1.0
Minimum:	1,007.4	0.0	1,007.4	105,600.0	106.4	0.4	0.2	0.6
Maximum:	4,842.5	399.2	5,178.2	105,600.0	546.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/09/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/10/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/11/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/12/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/13/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/14/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/15/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/16/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 14:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 15:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 16:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 17:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 18:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 19:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 20:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 21:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 22:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/17/2022 23:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2022 00:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 01:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 02:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 03:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 04:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 05:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 06:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 07:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 08:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 09:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 12:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 13:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
10/18/2022 14:00	357.4	0.0	357.4	105,600.0	37.7	0.0	0.0	0.0
10/18/2022 15:00	3,044.1	0.0	3,044.1	105,600.0	321.5	0.4	0.2	0.7
10/18/2022 16:00	4,508.7	371.9	4,694.7	105,600.0	495.8	0.6	0.3	1.0
10/18/2022 17:00	4,710.8	1,193.0	5,903.8	105,600.0	623.4	0.7	0.4	1.2
10/18/2022 18:00	4,721.5	1,039.5	5,761.0	105,600.0	608.4	0.7	0.4	1.2
10/18/2022 19:00	4,758.6	1,552.0	6,310.6	105,600.0	666.4	0.8	0.4	1.3
10/18/2022 20:00	4,798.6	1,071.5	5,870.1	105,600.0	619.9	0.7	0.4	1.2
10/18/2022 21:00	4,808.3	887.1	5,695.4	105,600.0	601.4	0.7	0.4	1.2
10/18/2022 22:00	4,833.2	522.2	5,355.4	105,600.0	565.5	0.7	0.3	1.1
10/18/2022 23:00	4,639.9	0.0	4,639.9	105,600.0	490.0	0.6	0.3	1.0
Average/Sum#:	4,118.1	663.7	4,763.2	105,600.0	503.0	0.7	0.3	1.1
Minimum:	357.4	0.0	357.4	105,600.0	37.7	0.4	0.2	0.7
Maximum:	4,833.2	1,552.0	6,310.6	105,600.0	666.4	0.8	0.4	1.3
%SI	58.33	58.33	58.33	0.00	58.33	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	4,654.2	0.0	4,654.2	105,600.0	491.5	0.6	0.3	1.0
10/19/2022 01:00	4,483.2	0.0	4,483.2	105,600.0	473.4	0.6	0.3	0.9
10/19/2022 02:00	4,277.8	0.0	4,277.8	105,600.0	451.7	0.5	0.3	0.9
10/19/2022 03:00	4,463.0	0.0	4,463.0	105,600.0	471.3	0.6	0.3	0.9
10/19/2022 04:00	4,633.5	0.0	4,633.5	105,600.0	489.3	0.6	0.3	1.0
10/19/2022 05:00	4,653.2	0.0	4,653.2	105,600.0	491.4	0.6	0.3	1.0
10/19/2022 06:00	3,988.0	0.0	3,988.0	105,600.0	421.1	0.5	0.3	0.8
10/19/2022 07:00	2,853.9	0.0	2,853.9	105,600.0	301.4	0.4	0.2	0.6
10/19/2022 08:00	3,602.6	0.1	3,602.6	105,600.0	380.4	0.5	0.2	0.8
10/19/2022 09:00	3,272.7	0.0	3,272.7	105,600.0	345.6	0.4	0.2	0.7
10/19/2022 10:00	2,941.5	0.0	2,941.5	105,600.0	310.6	0.4	0.2	0.6
10/19/2022 11:00	2,928.2	0.0	2,928.2	105,600.0	309.2	0.4	0.2	0.6
10/19/2022 12:00	2,930.7	0.0	2,930.7	105,600.0	309.5	0.4	0.2	0.6
10/19/2022 13:00	2,936.1	0.0	2,936.1	105,600.0	310.1	0.4	0.2	0.6
10/19/2022 14:00	3,960.6	78.8	3,986.6	105,600.0	421.0	0.5	0.3	0.9
10/19/2022 15:00	4,650.7	264.6	4,915.3	105,600.0	519.1	0.6	0.3	1.0
10/19/2022 16:00	3,564.9	10.4	3,565.9	105,600.0	376.6	0.5	0.2	0.8
10/19/2022 17:00	3,721.2	0.0	3,721.2	105,600.0	393.0	0.5	0.2	0.8
10/19/2022 18:00	4,681.7	45.1	4,726.8	105,600.0	499.2	0.6	0.3	1.0
10/19/2022 19:00	4,715.8	256.9	4,972.7	105,600.0	525.1	0.6	0.3	1.1
10/19/2022 20:00	4,735.5	400.7	5,136.2	105,600.0	542.4	0.7	0.3	1.1
10/19/2022 21:00	4,711.7	273.6	4,922.4	105,600.0	519.8	0.6	0.3	1.1
10/19/2022 22:00	3,499.1	0.0	3,499.1	105,600.0	369.5	0.4	0.2	0.7
10/19/2022 23:00	4,141.8	0.0	4,141.8	105,600.0	437.4	0.5	0.3	0.9
Average/Sum#:	3,958.4	55.4	4,008.6	105,600.0	423.3	0.5	0.3	0.9
Minimum:	2,853.9	0.0	2,853.9	105,600.0	301.4	0.4	0.2	0.6
Maximum:	4,735.5	400.7	5,136.2	105,600.0	542.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2022 00:00	4,169.6	0.0	4,169.6	105,600.0	440.3	0.5	0.3	0.9
10/20/2022 01:00	3,477.2	0.0	3,477.2	105,600.0	367.2	0.4	0.2	0.7
10/20/2022 02:00	3,028.5	0.0	3,028.5	105,600.0	319.8	0.4	0.2	0.6
10/20/2022 03:00	3,769.3	0.0	3,769.3	105,600.0	398.0	0.5	0.2	0.8
10/20/2022 04:00	4,460.8	0.0	4,460.8	105,600.0	471.1	0.6	0.3	0.9
10/20/2022 05:00	4,734.4	0.0	4,734.4	105,600.0	500.0	0.6	0.3	1.0
10/20/2022 06:00	4,203.9	0.0	4,203.9	105,600.0	443.9	0.5	0.3	0.9
10/20/2022 07:00	2,974.9	0.0	2,974.9	105,600.0	314.1	0.4	0.2	0.6
10/20/2022 08:00	2,884.4	0.0	2,884.4	105,600.0	304.6	0.4	0.2	0.6
10/20/2022 09:00	2,890.6	0.0	2,890.6	105,600.0	305.2	0.4	0.2	0.6
10/20/2022 10:00	2,907.5	0.0	2,907.5	105,600.0	307.0	0.4	0.2	0.6
10/20/2022 11:00	2,853.4	0.0	2,853.4	105,600.0	301.3	0.4	0.2	0.6
10/20/2022 12:00	2,859.9	0.0	2,859.9	105,600.0	302.0	0.4	0.2	0.6
10/20/2022 13:00	2,946.2	0.0	2,946.2	105,600.0	311.1	0.4	0.2	0.6
10/20/2022 14:00	3,029.6	0.0	3,029.6	105,600.0	319.9	0.4	0.2	0.6
10/20/2022 15:00	4,044.1	128.7	4,080.1	105,600.0	430.9	0.5	0.3	0.9
10/20/2022 16:00	4,651.4	1,222.3	5,873.7	105,600.0	620.3	0.7	0.4	1.2
10/20/2022 17:00	4,665.0	854.9	5,519.9	105,600.0	582.9	0.7	0.3	1.2
10/20/2022 18:00	4,701.8	533.9	5,235.7	105,600.0	552.9	0.7	0.3	1.1
10/20/2022 19:00	4,719.2	241.6	4,960.8	105,600.0	523.9	0.6	0.3	1.0
10/20/2022 20:00	4,706.1	198.6	4,859.0	105,600.0	513.1	0.6	0.3	1.0
10/20/2022 21:00	3,246.3	0.0	3,246.3	105,600.0	342.8	0.4	0.2	0.7
10/20/2022 22:00	3,130.1	0.0	3,130.1	105,600.0	330.5	0.4	0.2	0.7
10/20/2022 23:00	4,439.4	0.0	4,439.4	105,600.0	468.8	0.6	0.3	0.9
Average/Sum#:	3,728.9	132.5	3,855.6	105,600.0	407.2	0.5	0.3	0.8
Minimum:	2,853.4	0.0	2,853.4	105,600.0	301.3	0.4	0.2	0.6
Maximum:	4,734.4	1,222.3	5,873.7	105,600.0	620.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2022 00:00	3,657.6	0.0	3,657.6	105,600.0	386.2	0.5	0.2	0.8
10/21/2022 01:00	3,482.2	0.0	3,482.2	105,600.0	367.7	0.4	0.2	0.7
10/21/2022 02:00	3,030.6	0.0	3,030.6	105,600.0	320.0	0.4	0.2	0.6
10/21/2022 03:00	3,191.3	0.0	3,191.3	105,600.0	337.0	0.4	0.2	0.7
10/21/2022 04:00	3,502.0	0.0	3,502.0	105,600.0	369.8	0.4	0.2	0.7
10/21/2022 05:00	4,484.8	0.0	4,484.8	105,600.0	473.6	0.6	0.3	0.9
10/21/2022 06:00	4,767.9	142.7	4,836.4	105,600.0	510.7	0.6	0.3	1.0
10/21/2022 07:00	4,740.0	67.6	4,792.1	105,600.0	506.0	0.6	0.3	1.0
10/21/2022 08:00	2,943.0	0.0	2,943.0	105,600.0	310.8	0.4	0.2	0.6
10/21/2022 09:00	2,828.7	0.0	2,828.7	105,600.0	298.7	0.4	0.2	0.6
10/21/2022 10:00	2,819.3	0.0	2,819.3	105,600.0	297.7	0.4	0.2	0.6
10/21/2022 11:00	2,933.3	0.0	2,933.3	105,600.0	309.8	0.4	0.2	0.6
10/21/2022 12:00	2,814.7	0.0	2,814.7	105,600.0	297.2	0.4	0.2	0.6
10/21/2022 13:00	2,858.8	0.0	2,858.8	105,600.0	301.9	0.4	0.2	0.6
10/21/2022 14:00	2,881.2	0.0	2,881.2	105,600.0	304.3	0.4	0.2	0.6
10/21/2022 15:00	4,225.3	81.4	4,244.0	105,600.0	448.2	0.5	0.3	0.9
10/21/2022 16:00	4,677.8	578.2	5,256.0	105,600.0	555.0	0.7	0.3	1.1
10/21/2022 17:00	4,719.6	485.5	5,205.1	105,600.0	549.7	0.7	0.3	1.1
10/21/2022 18:00	4,701.8	192.9	4,850.3	105,600.0	512.2	0.6	0.3	1.0
10/21/2022 19:00	3,857.7	0.0	3,857.7	105,600.0	407.4	0.5	0.2	0.8
10/21/2022 20:00	3,708.9	0.0	3,708.9	105,600.0	391.7	0.5	0.2	0.8
10/21/2022 21:00	4,601.6	0.0	4,601.6	105,600.0	485.9	0.6	0.3	1.0
10/21/2022 22:00	4,763.8	0.0	4,763.8	105,600.0	503.1	0.6	0.3	1.0
10/21/2022 23:00	4,763.0	0.0	4,763.0	105,600.0	503.0	0.6	0.3	1.0
Average/Sum#:	3,789.8	64.5	3,846.1	105,600.0	406.2	0.5	0.2	0.8
Minimum:	2,814.7	0.0	2,814.7	105,600.0	297.2	0.4	0.2	0.6
Maximum:	4,767.9	578.2	5,256.0	105,600.0	555.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2022 00:00	4,753.0	0.0	4,753.0	105,600.0	501.9	0.6	0.3	1.0
10/22/2022 01:00	4,748.4	0.0	4,748.4	105,600.0	501.4	0.6	0.3	1.0
10/22/2022 02:00	4,754.8	0.0	4,754.8	105,600.0	502.1	0.6	0.3	1.0
10/22/2022 03:00	4,756.4	0.0	4,756.4	105,600.0	502.3	0.6	0.3	1.0
10/22/2022 04:00	4,748.7	0.0	4,748.7	105,600.0	501.5	0.6	0.3	1.0
10/22/2022 05:00	4,758.8	106.9	4,788.7	105,600.0	505.7	0.6	0.3	1.0
10/22/2022 06:00	4,759.2	1,687.1	6,446.3	105,600.0	680.7	0.8	0.4	1.4
10/22/2022 07:00	4,775.2	1,850.1	6,625.3	105,600.0	699.6	0.8	0.4	1.4
10/22/2022 08:00	4,749.6	1,259.0	6,008.6	105,600.0	634.5	0.8	0.4	1.3
10/22/2022 09:00	4,746.9	1,193.7	5,940.6	105,600.0	627.3	0.8	0.4	1.3
10/22/2022 10:00	4,765.0	980.5	5,745.5	105,600.0	606.7	0.7	0.4	1.2
10/22/2022 11:00	4,771.5	441.3	5,212.8	105,600.0	550.5	0.7	0.3	1.1
10/22/2022 12:00	4,735.1	118.8	4,826.6	105,600.0	509.7	0.6	0.3	1.0
10/22/2022 13:00	4,546.0	0.0	4,546.0	105,600.0	480.1	0.6	0.3	1.0
10/22/2022 14:00	4,439.0	0.0	4,439.0	105,600.0	468.8	0.6	0.3	0.9
10/22/2022 15:00	3,492.5	0.0	3,492.5	105,600.0	368.8	0.4	0.2	0.7
10/22/2022 16:00	3,861.9	0.0	3,861.9	105,600.0	407.8	0.5	0.2	0.8
10/22/2022 17:00	4,381.6	0.0	4,381.6	105,600.0	462.7	0.6	0.3	0.9
10/22/2022 18:00	4,434.9	0.0	4,434.9	105,600.0	468.3	0.6	0.3	0.9
10/22/2022 19:00	4,711.1	0.0	4,711.1	105,600.0	497.5	0.6	0.3	1.0
10/22/2022 20:00	4,782.8	49.7	4,796.7	105,600.0	506.5	0.6	0.3	1.0
10/22/2022 21:00	4,878.3	343.1	5,221.4	105,600.0	551.4	0.7	0.3	1.1
10/22/2022 22:00	4,743.1	0.0	4,743.1	105,600.0	500.9	0.6	0.3	1.0
10/22/2022 23:00	4,738.8	0.0	4,738.8	105,600.0	500.4	0.6	0.3	1.0
Average/Sum#:	4,618.0	334.6	4,946.8	105,600.0	522.4	0.6	0.3	1.0
Minimum:	3,492.5	0.0	3,492.5	105,600.0	368.8	0.4	0.2	0.7
Maximum:	4,878.3	1,850.1	6,625.3	105,600.0	699.6	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2022 00:00	4,828.5	339.2	5,093.1	105,600.0	537.8	0.7	0.3	1.1
10/23/2022 01:00	4,787.5	136.5	4,858.5	105,600.0	513.1	0.6	0.3	1.0
10/23/2022 02:00	4,766.1	0.0	4,766.1	105,600.0	503.3	0.6	0.3	1.0
10/23/2022 03:00	4,754.7	0.0	4,754.7	105,600.0	502.1	0.6	0.3	1.0
10/23/2022 04:00	4,747.8	0.0	4,747.8	105,600.0	501.4	0.6	0.3	1.0
10/23/2022 05:00	4,750.4	0.0	4,750.4	105,600.0	501.6	0.6	0.3	1.0
10/23/2022 06:00	4,740.0	0.0	4,740.0	105,600.0	500.5	0.6	0.3	1.0
10/23/2022 07:00	4,760.7	160.5	4,837.7	105,600.0	510.9	0.6	0.3	1.0
10/23/2022 08:00	4,875.9	297.6	5,149.7	105,600.0	543.8	0.7	0.3	1.1
10/23/2022 09:00	4,372.5	75.9	4,393.0	105,600.0	463.9	0.6	0.3	0.9
10/23/2022 10:00	4,048.0	0.0	4,048.0	105,600.0	427.5	0.5	0.3	0.9
10/23/2022 11:00	4,689.4	442.9	5,123.4	105,600.0	541.0	0.7	0.3	1.1
10/23/2022 12:00	4,418.3	118.1	4,450.2	105,600.0	469.9	0.6	0.3	1.0
10/23/2022 13:00	3,581.6	0.0	3,581.6	105,600.0	378.2	0.5	0.2	0.8
10/23/2022 14:00	3,655.8	0.0	3,655.8	105,600.0	386.1	0.5	0.2	0.8
10/23/2022 15:00	3,088.5	0.0	3,088.5	105,600.0	326.1	0.4	0.2	0.7
10/23/2022 16:00	3,827.3	0.0	3,827.3	105,600.0	404.2	0.5	0.2	0.8
10/23/2022 17:00	4,636.1	0.0	4,636.1	105,600.0	489.6	0.6	0.3	1.0
10/23/2022 18:00	4,705.9	0.0	4,705.9	105,600.0	496.9	0.6	0.3	1.0
10/23/2022 19:00	4,750.3	0.0	4,750.3	105,600.0	501.6	0.6	0.3	1.0
10/23/2022 20:00	4,847.1	341.5	5,096.4	105,600.0	538.2	0.7	0.3	1.1
10/23/2022 21:00	4,804.4	303.5	5,038.1	105,600.0	532.0	0.6	0.3	1.1
10/23/2022 22:00	4,134.3	0.0	4,134.3	105,600.0	436.6	0.5	0.3	0.9
10/23/2022 23:00	4,757.2	0.0	4,757.2	105,600.0	502.4	0.6	0.3	1.0
Average/Sum#:	4,472.0	92.3	4,541.0	105,600.0	479.5	0.6	0.3	1.0
Minimum:	3,088.5	0.0	3,088.5	105,600.0	326.1	0.4	0.2	0.7
Maximum:	4,875.9	442.9	5,149.7	105,600.0	543.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2022 00:00	4,680.8	0.0	4,680.8	105,600.0	494.3	0.6	0.3	1.0
10/24/2022 01:00	4,547.0	0.0	4,547.0	105,600.0	480.2	0.6	0.3	1.0
10/24/2022 02:00	4,751.3	0.0	4,751.3	105,600.0	501.7	0.6	0.3	1.0
10/24/2022 03:00	4,739.6	0.0	4,739.6	105,600.0	500.5	0.6	0.3	1.0
10/24/2022 04:00	4,720.3	0.0	4,720.3	105,600.0	498.5	0.6	0.3	1.0
10/24/2022 05:00	4,732.8	26.4	4,738.9	105,600.0	500.4	0.6	0.3	1.0
10/24/2022 06:00	4,986.3	984.5	5,970.8	105,600.0	630.5	0.8	0.4	1.3
10/24/2022 07:00	4,947.7	548.6	5,496.3	105,600.0	580.4	0.7	0.3	1.2
10/24/2022 08:00	4,923.8	167.3	5,044.3	105,600.0	532.7	0.6	0.3	1.1
10/24/2022 09:00	4,862.8	211.4	5,074.2	105,600.0	535.8	0.6	0.3	1.1
10/24/2022 10:00	4,802.7	186.5	4,989.2	105,600.0	526.9	0.6	0.3	1.1
10/24/2022 11:00	4,403.6	1.1	4,403.6	105,600.0	465.0	0.6	0.3	0.9
10/24/2022 12:00	2,894.9	0.0	2,894.9	105,600.0	305.7	0.4	0.2	0.6
10/24/2022 13:00	2,833.5	0.0	2,833.5	105,600.0	299.2	0.4	0.2	0.6
10/24/2022 14:00	4,121.9	28.7	4,128.5	105,600.0	436.0	0.5	0.3	0.9
10/24/2022 15:00	4,846.8	70.4	4,917.2	105,600.0	519.3	0.6	0.3	1.0
10/24/2022 16:00	4,861.5	684.8	5,546.3	105,600.0	585.7	0.7	0.4	1.2
10/24/2022 17:00	4,882.4	482.4	5,364.8	105,600.0	566.5	0.7	0.3	1.1
10/24/2022 18:00	4,883.9	155.2	5,000.3	105,600.0	528.0	0.6	0.3	1.1
10/24/2022 19:00	4,901.7	302.9	5,180.4	105,600.0	547.1	0.7	0.3	1.1
10/24/2022 20:00	4,846.7	270.5	5,049.6	105,600.0	533.2	0.6	0.3	1.1
10/24/2022 21:00	3,853.6	0.0	3,853.6	105,600.0	406.9	0.5	0.2	0.8
10/24/2022 22:00	3,169.0	0.0	3,169.0	105,600.0	334.6	0.4	0.2	0.7
10/24/2022 23:00	3,398.1	0.0	3,398.1	105,600.0	358.8	0.4	0.2	0.7
Average/Sum#:	4,441.4	171.7	4,603.9	105,600.0	486.2	0.6	0.3	1.0
Minimum:	2,833.5	0.0	2,833.5	105,600.0	299.2	0.4	0.2	0.6
Maximum:	4,986.3	984.5	5,970.8	105,600.0	630.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2022 00:00	2,994.0	0.0	2,994.0	105,600.0	316.2	0.4	0.2	0.6
10/25/2022 01:00	3,002.4	0.0	3,002.4	105,600.0	317.1	0.4	0.2	0.6
10/25/2022 02:00	3,003.3	0.0	3,003.3	105,600.0	317.1	0.4	0.2	0.6
10/25/2022 03:00	3,064.7	0.0	3,064.7	105,600.0	323.6	0.4	0.2	0.6
10/25/2022 04:00	4,289.3	0.0	4,289.3	105,600.0	453.0	0.5	0.3	0.9
10/25/2022 05:00	4,619.4	2.8	4,619.5	105,600.0	487.8	0.6	0.3	1.0
10/25/2022 06:00	4,978.0	471.0	5,449.0	105,600.0	575.4	0.7	0.3	1.2
10/25/2022 07:00	4,884.3	332.8	5,140.6	105,600.0	542.8	0.7	0.3	1.1
10/25/2022 08:00	3,887.5	0.0	3,887.5	105,600.0	410.5	0.5	0.2	0.8
10/25/2022 09:00	3,701.2	0.0	3,701.2	105,600.0	390.8	0.5	0.2	0.8
10/25/2022 10:00	2,901.5	0.0	2,901.5	105,600.0	306.4	0.4	0.2	0.6
10/25/2022 11:00	2,979.3	0.0	2,979.3	105,600.0	314.6	0.4	0.2	0.6
10/25/2022 12:00	3,729.5	10.4	3,730.5	105,600.0	393.9	0.5	0.2	0.8
10/25/2022 13:00	4,827.7	478.4	5,306.1	105,600.0	560.3	0.7	0.3	1.1
10/25/2022 14:00	4,824.0	816.7	5,640.7	105,600.0	595.7	0.7	0.4	1.2
10/25/2022 15:00	4,791.4	801.8	5,593.2	105,600.0	590.6	0.7	0.4	1.2
10/25/2022 16:00	4,826.7	1,065.1	5,891.8	105,600.0	622.2	0.7	0.4	1.2
10/25/2022 17:00	4,830.1	932.6	5,762.7	105,600.0	608.5	0.7	0.4	1.2
10/25/2022 18:00	4,861.7	622.4	5,484.1	105,600.0	579.1	0.7	0.3	1.2
10/25/2022 19:00	4,865.6	578.4	5,444.0	105,600.0	574.9	0.7	0.3	1.1
10/25/2022 20:00	4,889.1	654.3	5,543.4	105,600.0	585.4	0.7	0.4	1.2
10/25/2022 21:00	4,818.8	234.9	4,999.7	105,600.0	528.0	0.6	0.3	1.1
10/25/2022 22:00	3,098.2	0.0	3,098.2	105,600.0	327.2	0.4	0.2	0.7
10/25/2022 23:00	3,340.2	0.0	3,340.2	105,600.0	352.7	0.4	0.2	0.7
Average/Sum#:	4,083.7	291.7	4,369.5	105,600.0	461.4	0.6	0.3	0.9
Minimum:	2,901.5	0.0	2,901.5	105,600.0	306.4	0.4	0.2	0.6
Maximum:	4,978.0	1,065.1	5,891.8	105,600.0	622.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	3,006.3	0.0	3,006.3	105,600.0	317.5	0.4	0.2	0.6
10/26/2022 01:00	3,010.0	0.0	3,010.0	105,600.0	317.9	0.4	0.2	0.6
10/26/2022 02:00	3,028.0	0.0	3,028.0	105,600.0	319.8	0.4	0.2	0.6
10/26/2022 03:00	3,914.3	0.0	3,914.3	105,600.0	413.4	0.5	0.2	0.8
10/26/2022 04:00	4,303.8	0.0	4,303.8	105,600.0	454.5	0.5	0.3	0.9
10/26/2022 05:00	4,513.5	0.0	4,513.5	105,600.0	476.6	0.6	0.3	1.0
10/26/2022 06:00	4,747.7	0.0	4,747.7	105,600.0	501.4	0.6	0.3	1.0
10/26/2022 07:00	4,316.6	0.0	4,316.6	105,600.0	455.8	0.5	0.3	0.9
10/26/2022 08:00	4,733.2	221.6	4,848.4	105,600.0	512.0	0.6	0.3	1.0
10/26/2022 09:00	4,801.9	395.5	5,165.8	105,600.0	545.5	0.7	0.3	1.1
10/26/2022 10:00	4,763.5	485.2	5,248.7	105,600.0	554.3	0.7	0.3	1.1
10/26/2022 11:00	3,515.0	2.9	3,515.4	105,600.0	371.2	0.4	0.2	0.7
10/26/2022 12:00	2,868.1	0.0	2,868.1	105,600.0	302.9	0.4	0.2	0.6
10/26/2022 13:00	2,856.4	0.0	2,856.4	105,600.0	301.6	0.4	0.2	0.6
10/26/2022 14:00	3,348.2	0.0	3,348.2	105,600.0	353.6	0.4	0.2	0.7
10/26/2022 15:00	3,288.0	0.0	3,288.0	105,600.0	347.2	0.4	0.2	0.7
10/26/2022 16:00	4,148.7	105.2	4,190.8	105,600.0	442.5	0.5	0.3	0.9
10/26/2022 17:00	4,710.1	467.2	5,177.3	105,600.0	546.7	0.7	0.3	1.1
10/26/2022 18:00	4,680.7	168.4	4,810.4	105,600.0	508.0	0.6	0.3	1.0
10/26/2022 19:00	3,162.8	0.0	3,162.8	105,600.0	334.0	0.4	0.2	0.7
10/26/2022 20:00	3,502.7	0.0	3,502.7	105,600.0	369.9	0.4	0.2	0.7
10/26/2022 21:00	3,153.9	0.0	3,153.9	105,600.0	333.1	0.4	0.2	0.7
10/26/2022 22:00	2,986.1	0.0	2,986.1	105,600.0	315.3	0.4	0.2	0.6
10/26/2022 23:00	3,010.8	0.0	3,010.8	105,600.0	317.9	0.4	0.2	0.6
Average/Sum#:	3,765.4	76.9	3,832.3	105,600.0	404.7	0.5	0.2	0.8
Minimum:	2,856.4	0.0	2,856.4	105,600.0	301.6	0.4	0.2	0.6
Maximum:	4,801.9	485.2	5,248.7	105,600.0	554.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2022 00:00	2,882.6	0.0	2,882.6	105,600.0	304.4	0.4	0.2	0.6
10/27/2022 01:00	2,936.7	0.0	2,936.7	105,600.0	310.1	0.4	0.2	0.6
10/27/2022 02:00	2,977.7	0.0	2,977.7	105,600.0	314.4	0.4	0.2	0.6
10/27/2022 03:00	3,100.6	0.0	3,100.6	105,600.0	327.4	0.4	0.2	0.7
10/27/2022 04:00	3,574.0	0.0	3,574.0	105,600.0	377.4	0.5	0.2	0.8
10/27/2022 05:00	4,089.1	0.0	4,089.1	105,600.0	431.8	0.5	0.3	0.9
10/27/2022 06:00	3,984.1	0.0	3,984.1	105,600.0	420.7	0.5	0.3	0.8
10/27/2022 07:00	4,252.5	0.0	4,252.5	105,600.0	449.1	0.5	0.3	0.9
10/27/2022 08:00	4,583.1	0.0	4,583.1	105,600.0	484.0	0.6	0.3	1.0
10/27/2022 09:00	4,814.1	176.5	4,951.8	105,600.0	522.9	0.6	0.3	1.1
10/27/2022 10:00	4,282.3	51.0	4,297.6	105,600.0	453.8	0.5	0.3	0.9
10/27/2022 11:00	4,697.0	251.2	4,928.1	105,600.0	520.4	0.6	0.3	1.0
10/27/2022 12:00	4,666.2	351.0	5,017.2	105,600.0	529.8	0.6	0.3	1.1
10/27/2022 13:00	4,269.1	190.7	4,374.0	105,600.0	461.9	0.6	0.3	0.9
10/27/2022 14:00	3,041.1	0.0	3,041.1	105,600.0	321.1	0.4	0.2	0.6
10/27/2022 15:00	3,375.4	2.5	3,375.5	105,600.0	356.5	0.4	0.2	0.7
10/27/2022 16:00	4,809.0	634.3	5,443.3	105,600.0	574.8	0.7	0.3	1.1
10/27/2022 17:00	4,854.5	463.8	5,318.3	105,600.0	561.6	0.7	0.3	1.1
10/27/2022 18:00	4,864.2	172.1	5,036.3	105,600.0	531.8	0.6	0.3	1.1
10/27/2022 19:00	4,892.9	284.4	5,154.5	105,600.0	544.3	0.7	0.3	1.1
10/27/2022 20:00	4,916.2	356.6	5,272.8	105,600.0	556.8	0.7	0.3	1.1
10/27/2022 21:00	4,931.2	373.6	5,278.6	105,600.0	557.4	0.7	0.3	1.1
10/27/2022 22:00	4,803.0	4.4	4,806.3	105,600.0	507.5	0.6	0.3	1.0
10/27/2022 23:00	4,343.6	0.0	4,343.6	105,600.0	458.7	0.5	0.3	0.9
Average/Sum#:	4,164.2	138.0	4,292.5	105,600.0	453.3	0.5	0.3	0.9
Minimum:	2,882.6	0.0	2,882.6	105,600.0	304.4	0.4	0.2	0.6
Maximum:	4,931.2	634.3	5,443.3	105,600.0	574.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2022 00:00	4,272.1	0.0	4,272.1	105,600.0	451.1	0.5	0.3	0.9
10/28/2022 01:00	4,087.2	0.0	4,087.2	105,600.0	431.6	0.5	0.3	0.9
10/28/2022 02:00	4,263.1	0.0	4,263.1	105,600.0	450.2	0.5	0.3	0.9
10/28/2022 03:00	4,621.5	9.3	4,623.6	105,600.0	488.3	0.6	0.3	1.0
10/28/2022 04:00	4,976.3	456.6	5,410.1	105,600.0	571.3	0.7	0.3	1.1
10/28/2022 05:00	4,992.0	587.7	5,579.7	105,600.0	589.2	0.7	0.4	1.2
10/28/2022 06:00	4,999.8	498.1	5,497.9	105,600.0	580.6	0.7	0.3	1.2
10/28/2022 07:00	4,790.7	30.5	4,811.1	105,600.0	508.1	0.6	0.3	1.0
10/28/2022 08:00	4,276.1	0.0	4,276.1	105,600.0	451.6	0.5	0.3	0.9
10/28/2022 09:00	4,549.1	0.0	4,549.1	105,600.0	480.4	0.6	0.3	1.0
10/28/2022 10:00	4,769.9	222.4	4,987.9	105,600.0	526.7	0.6	0.3	1.1
10/28/2022 11:00	4,004.9	73.4	4,026.9	105,600.0	425.2	0.5	0.3	0.9
10/28/2022 12:00	3,993.2	0.0	3,993.2	105,600.0	421.7	0.5	0.3	0.8
10/28/2022 13:00	3,813.1	0.0	3,813.1	105,600.0	402.7	0.5	0.2	0.8
10/28/2022 14:00	4,071.7	27.1	4,077.9	105,600.0	430.6	0.5	0.3	0.9
10/28/2022 15:00	4,853.1	483.8	5,336.9	105,600.0	563.6	0.7	0.3	1.1
10/28/2022 16:00	4,865.0	415.2	5,209.6	105,600.0	550.1	0.7	0.3	1.1
10/28/2022 17:00	4,862.8	919.6	5,782.4	105,600.0	610.6	0.7	0.4	1.2
10/28/2022 18:00	4,896.5	965.7	5,862.2	105,600.0	619.0	0.7	0.4	1.2
10/28/2022 19:00	4,916.0	946.6	5,862.6	105,600.0	619.1	0.7	0.4	1.2
10/28/2022 20:00	4,931.3	996.7	5,928.0	105,600.0	626.0	0.8	0.4	1.3
10/28/2022 21:00	4,938.9	1,002.4	5,941.3	105,600.0	627.4	0.8	0.4	1.3
10/28/2022 22:00	4,957.1	436.3	5,393.4	105,600.0	569.5	0.7	0.3	1.1
10/28/2022 23:00	4,687.6	0.2	4,687.6	105,600.0	495.0	0.6	0.3	1.0
Average/Sum#:	4,599.5	336.3	4,928.0	105,600.0	520.4	0.6	0.3	1.0
Minimum:	3,813.1	0.0	3,813.1	105,600.0	402.7	0.5	0.2	0.8
Maximum:	4,999.8	1,002.4	5,941.3	105,600.0	627.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2022 00:00	3,919.3	0.0	3,919.3	105,600.0	413.9	0.5	0.2	0.8
10/29/2022 01:00	4,007.1	0.0	4,007.1	105,600.0	423.1	0.5	0.3	0.8
10/29/2022 02:00	3,969.5	0.0	3,969.5	105,600.0	419.2	0.5	0.3	0.8
10/29/2022 03:00	3,041.5	0.0	3,041.5	105,600.0	321.2	0.4	0.2	0.6
10/29/2022 04:00	3,821.5	0.0	3,821.5	105,600.0	403.6	0.5	0.2	0.8
10/29/2022 05:00	4,579.1	0.0	4,579.1	105,600.0	483.6	0.6	0.3	1.0
10/29/2022 06:00	3,920.9	0.0	3,920.9	105,600.0	414.0	0.5	0.2	0.8
10/29/2022 07:00	3,911.9	0.0	3,911.9	105,600.0	413.1	0.5	0.2	0.8
10/29/2022 08:00	4,520.6	0.0	4,520.6	105,600.0	477.4	0.6	0.3	1.0
10/29/2022 09:00	4,116.4	0.0	4,116.4	105,600.0	434.7	0.5	0.3	0.9
10/29/2022 10:00	4,232.6	0.0	4,232.6	105,600.0	447.0	0.5	0.3	0.9
10/29/2022 11:00	3,757.2	0.0	3,757.2	105,600.0	396.8	0.5	0.2	0.8
10/29/2022 12:00	3,025.5	0.0	3,025.5	105,600.0	319.5	0.4	0.2	0.6
10/29/2022 13:00	3,183.0	0.0	3,183.0	105,600.0	336.1	0.4	0.2	0.7
10/29/2022 14:00	3,244.9	0.0	3,244.9	105,600.0	342.7	0.4	0.2	0.7
10/29/2022 15:00	3,325.9	0.0	3,325.9	105,600.0	351.2	0.4	0.2	0.7
10/29/2022 16:00	3,795.8	0.0	3,795.8	105,600.0	400.8	0.5	0.2	0.8
10/29/2022 17:00	3,926.7	0.0	3,926.7	105,600.0	414.7	0.5	0.2	0.8
10/29/2022 18:00	3,800.7	0.0	3,800.7	105,600.0	401.4	0.5	0.2	0.8
10/29/2022 19:00	3,236.0	0.0	3,236.0	105,600.0	341.7	0.4	0.2	0.7
10/29/2022 20:00	4,796.8	38.6	4,807.6	105,600.0	507.7	0.6	0.3	1.0
10/29/2022 21:00	4,833.8	184.2	5,003.3	105,600.0	528.3	0.6	0.3	1.1
10/29/2022 22:00	4,356.4	0.0	4,356.4	105,600.0	460.0	0.6	0.3	0.9
10/29/2022 23:00	4,703.0	0.0	4,703.0	105,600.0	496.6	0.6	0.3	1.0
Average/Sum#:	3,917.8	9.3	3,925.3	105,600.0	414.5	0.5	0.2	0.8
Minimum:	3,025.5	0.0	3,025.5	105,600.0	319.5	0.4	0.2	0.6
Maximum:	4,833.8	184.2	5,003.3	105,600.0	528.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2022 00:00	4,558.5	0.0	4,558.5	105,600.0	481.4	0.6	0.3	1.0
10/30/2022 01:00	4,273.5	0.0	4,273.5	105,600.0	451.3	0.5	0.3	0.9
10/30/2022 02:00	4,402.1	0.0	4,402.1	105,600.0	464.9	0.6	0.3	0.9
10/30/2022 03:00	4,400.0	0.0	4,400.0	105,600.0	464.6	0.6	0.3	0.9
10/30/2022 04:00	4,483.5	0.0	4,483.5	105,600.0	473.5	0.6	0.3	0.9
10/30/2022 05:00	4,841.1	0.0	4,841.1	105,600.0	511.2	0.6	0.3	1.0
10/30/2022 06:00	4,731.1	0.0	4,731.1	105,600.0	499.6	0.6	0.3	1.0
10/30/2022 07:00	3,096.5	0.0	3,096.5	105,600.0	327.0	0.4	0.2	0.7
10/30/2022 08:00	2,949.3	0.0	2,949.3	105,600.0	311.4	0.4	0.2	0.6
10/30/2022 09:00	2,928.9	0.0	2,928.9	105,600.0	309.3	0.4	0.2	0.6
10/30/2022 10:00	2,920.8	0.0	2,920.8	105,600.0	308.4	0.4	0.2	0.6
10/30/2022 11:00	2,916.1	0.0	2,916.1	105,600.0	307.9	0.4	0.2	0.6
10/30/2022 12:00	2,910.9	0.0	2,910.9	105,600.0	307.4	0.4	0.2	0.6
10/30/2022 13:00	2,907.4	0.0	2,907.4	105,600.0	307.0	0.4	0.2	0.6
10/30/2022 14:00	2,903.7	0.0	2,903.7	105,600.0	306.6	0.4	0.2	0.6
10/30/2022 15:00	3,159.4	0.0	3,159.4	105,600.0	333.6	0.4	0.2	0.7
10/30/2022 16:00	4,445.1	0.0	4,445.1	105,600.0	469.4	0.6	0.3	0.9
10/30/2022 17:00	4,604.1	29.6	4,610.9	105,600.0	486.9	0.6	0.3	1.0
10/30/2022 18:00	4,813.0	119.2	4,932.2	105,600.0	520.8	0.6	0.3	1.0
10/30/2022 19:00	4,407.1	0.0	4,407.1	105,600.0	465.4	0.6	0.3	0.9
10/30/2022 20:00	4,304.4	0.0	4,304.4	105,600.0	454.5	0.5	0.3	0.9
10/30/2022 21:00	4,335.8	0.0	4,335.8	105,600.0	457.9	0.5	0.3	0.9
10/30/2022 22:00	4,201.2	0.0	4,201.2	105,600.0	443.6	0.5	0.3	0.9
10/30/2022 23:00	4,361.5	0.0	4,361.5	105,600.0	460.6	0.6	0.3	0.9
Average/Sum#:	3,910.6	6.2	3,915.9	105,600.0	413.5	0.5	0.3	0.8
Minimum:	2,903.7	0.0	2,903.7	105,600.0	306.6	0.4	0.2	0.6
Maximum:	4,841.1	119.2	4,932.2	105,600.0	520.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2022 00:00	4,352.6	0.0	4,352.6	105,600.0	459.6	0.6	0.3	0.9
10/31/2022 01:00	4,298.8	0.0	4,298.8	105,600.0	454.0	0.5	0.3	0.9
10/31/2022 02:00	4,401.9	0.0	4,401.9	105,600.0	464.8	0.6	0.3	0.9
10/31/2022 03:00	4,332.9	0.0	4,332.9	105,600.0	457.6	0.5	0.3	0.9
10/31/2022 04:00	4,612.6	0.0	4,612.6	105,600.0	487.1	0.6	0.3	1.0
10/31/2022 05:00	4,809.2	283.0	4,945.0	105,600.0	522.2	0.6	0.3	1.1
10/31/2022 06:00	4,926.8	485.2	5,378.0	105,600.0	567.9	0.7	0.3	1.1
10/31/2022 07:00	4,126.7	27.7	4,134.2	105,600.0	436.6	0.5	0.3	0.9
10/31/2022 08:00	3,752.3	0.0	3,752.3	105,600.0	396.2	0.5	0.2	0.8
10/31/2022 09:00	3,564.6	0.0	3,564.6	105,600.0	376.4	0.5	0.2	0.8
10/31/2022 10:00	3,190.6	0.0	3,190.6	105,600.0	336.9	0.4	0.2	0.7
10/31/2022 11:00	2,972.8	0.0	2,972.8	105,600.0	313.9	0.4	0.2	0.6
10/31/2022 12:00	2,970.0	0.0	2,970.0	105,600.0	313.6	0.4	0.2	0.6
10/31/2022 13:00	3,435.3	0.0	3,435.3	105,600.0	362.8	0.4	0.2	0.7
10/31/2022 14:00	4,455.7	166.0	4,517.1	105,600.0	477.0	0.6	0.3	1.0
10/31/2022 15:00	4,769.0	336.7	5,105.7	105,600.0	539.2	0.6	0.3	1.1
10/31/2022 16:00	3,863.1	0.9	3,863.1	105,600.0	407.9	0.5	0.2	0.8
10/31/2022 17:00	2,961.1	0.0	2,961.1	105,600.0	312.7	0.4	0.2	0.6
10/31/2022 18:00	2,946.6	0.0	2,946.6	105,600.0	311.2	0.4	0.2	0.6
10/31/2022 19:00	3,301.2	0.0	3,301.2	105,600.0	348.6	0.4	0.2	0.7
10/31/2022 20:00	3,463.1	0.0	3,463.1	105,600.0	365.7	0.4	0.2	0.7
10/31/2022 21:00	3,983.2	0.0	3,983.2	105,600.0	420.6	0.5	0.3	0.8
10/31/2022 22:00	3,487.3	0.0	3,487.3	105,600.0	368.3	0.4	0.2	0.7
10/31/2022 23:00	4,627.6	0.0	4,627.6	105,600.0	488.7	0.6	0.3	1.0
Average/Sum#:	3,900.2	54.1	3,941.6	105,600.0	416.2	0.5	0.3	0.8
Minimum:	2,946.6	0.0	2,946.6	105,600.0	311.2	0.4	0.2	0.6
Maximum:	4,926.8	485.2	5,378.0	105,600.0	567.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022 00:00	4,623.5	0.0	4,623.5	105,600.0	488.2	0.6	0.3	1.0
11/01/2022 01:00	4,718.0	59.8	4,734.7	105,600.0	500.0	0.6	0.3	1.0
11/01/2022 02:00	4,856.3	593.1	5,449.4	105,600.0	575.5	0.7	0.3	1.2
11/01/2022 03:00	4,836.9	827.5	5,664.4	105,600.0	598.2	0.7	0.4	1.2
11/01/2022 04:00	4,840.6	1,008.0	5,848.6	105,600.0	617.6	0.7	0.4	1.2
11/01/2022 05:00	4,844.5	874.7	5,719.2	105,600.0	603.9	0.7	0.4	1.2
11/01/2022 06:00	4,815.8	1,252.6	6,068.4	105,600.0	640.8	0.8	0.4	1.3
11/01/2022 07:00	4,801.6	826.6	5,628.2	105,600.0	594.3	0.7	0.4	1.2
11/01/2022 08:00	4,791.9	617.0	5,408.9	105,600.0	571.2	0.7	0.3	1.1
11/01/2022 09:00	4,753.6	327.8	5,081.4	105,600.0	536.6	0.6	0.3	1.1
11/01/2022 10:00	4,757.0	363.0	5,120.0	105,600.0	540.7	0.6	0.3	1.1
11/01/2022 11:00	4,812.5	599.7	5,412.2	105,600.0	571.5	0.7	0.3	1.1
11/01/2022 12:00	4,832.8	785.5	5,618.3	105,600.0	593.3	0.7	0.4	1.2
11/01/2022 13:00	4,835.9	728.5	5,564.4	105,600.0	587.6	0.7	0.4	1.2
11/01/2022 14:00	4,842.9	163.9	5,006.8	105,600.0	528.7	0.6	0.3	1.1
11/01/2022 15:00	4,776.4	300.5	5,076.9	105,600.0	536.1	0.6	0.3	1.1
11/01/2022 16:00	4,772.7	737.0	5,509.7	105,600.0	581.8	0.7	0.3	1.2
11/01/2022 17:00	4,796.3	593.3	5,389.6	105,600.0	569.1	0.7	0.3	1.1
11/01/2022 18:00	4,845.5	512.8	5,358.3	105,600.0	565.8	0.7	0.3	1.1
11/01/2022 19:00	4,851.2	505.3	5,356.5	105,600.0	565.6	0.7	0.3	1.1
11/01/2022 20:00	4,870.6	458.4	5,329.0	105,600.0	562.7	0.7	0.3	1.1
11/01/2022 21:00	4,898.5	270.8	5,150.3	105,600.0	543.9	0.7	0.3	1.1
11/01/2022 22:00	4,918.9	129.6	5,039.4	105,600.0	532.2	0.6	0.3	1.1
11/01/2022 23:00	4,094.8	0.0	4,094.8	105,600.0	432.4	0.5	0.3	0.9
Average/Sum#:	4,782.9	522.3	5,302.2	105,600.0	559.9	0.7	0.3	1.1
Minimum:	4,094.8	0.0	4,094.8	105,600.0	432.4	0.5	0.3	0.9
Maximum:	4,918.9	1,252.6	6,068.4	105,600.0	640.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2022 00:00	3,028.5	0.0	3,028.5	105,600.0	319.8	0.4	0.2	0.6
11/02/2022 01:00	3,886.6	0.0	3,886.6	105,600.0	410.4	0.5	0.2	0.8
11/02/2022 02:00	3,474.8	0.0	3,474.8	105,600.0	366.9	0.4	0.2	0.7
11/02/2022 03:00	4,188.2	0.0	4,188.2	105,600.0	442.3	0.5	0.3	0.9
11/02/2022 04:00	4,554.0	0.0	4,554.0	105,600.0	480.9	0.6	0.3	1.0
11/02/2022 05:00	4,761.3	2.0	4,761.4	105,600.0	502.8	0.6	0.3	1.0
11/02/2022 06:00	4,948.1	346.3	5,294.4	105,600.0	559.1	0.7	0.3	1.1
11/02/2022 07:00	3,976.5	2.7	3,977.2	105,600.0	420.0	0.5	0.3	0.8
11/02/2022 08:00	3,090.3	0.0	3,090.3	105,600.0	326.3	0.4	0.2	0.7
11/02/2022 09:00	3,144.3	0.0	3,144.3	105,600.0	332.0	0.4	0.2	0.7
11/02/2022 10:00	4,223.4	0.0	4,223.4	105,600.0	446.0	0.5	0.3	0.9
11/02/2022 11:00	4,859.8	223.2	5,033.9	105,600.0	531.6	0.6	0.3	1.1
11/02/2022 12:00	4,851.4	141.7	4,993.1	105,600.0	527.3	0.6	0.3	1.1
11/02/2022 13:00	4,510.9	0.0	4,510.9	104,046.0	469.3	0.6	0.3	1.0
11/02/2022 14:00	4,828.9	170.5	4,996.0	104,046.0	519.8	0.6	0.3	1.1
11/02/2022 15:00	4,815.3	283.5	5,098.8	104,046.0	530.5	0.6	0.3	1.1
11/02/2022 16:00	4,828.2	642.1	5,470.3	104,046.0	569.2	0.7	0.3	1.2
11/02/2022 17:00	4,869.9	955.4	5,825.3	104,046.0	606.1	0.7	0.4	1.2
11/02/2022 18:00	4,890.5	501.5	5,392.0	104,046.0	561.0	0.7	0.3	1.1
11/02/2022 19:00	4,909.2	481.2	5,390.4	104,046.0	560.8	0.7	0.3	1.1
11/02/2022 20:00	4,940.2	857.4	5,797.6	104,046.0	603.2	0.7	0.4	1.2
11/02/2022 21:00	4,987.9	662.4	5,650.3	104,046.0	587.9	0.7	0.4	1.2
11/02/2022 22:00	4,956.4	434.3	5,390.7	104,046.0	560.9	0.7	0.3	1.1
11/02/2022 23:00	4,840.8	0.0	4,840.8	104,046.0	503.7	0.6	0.3	1.0
Average/Sum#:	4,431.9	237.7	4,667.2	104,887.8	489.1	0.6	0.3	1.0
Minimum:	3,028.5	0.0	3,028.5	104,046.0	319.8	0.4	0.2	0.6
Maximum:	4,987.9	955.4	5,825.3	105,600.0	606.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	4,852.7	0.0	4,852.7	104,046.0	504.9	0.6	0.3	1.0
11/03/2022 01:00	4,764.2	0.0	4,764.2	104,046.0	495.7	0.6	0.3	1.0
11/03/2022 02:00	4,748.3	0.0	4,748.3	104,046.0	494.0	0.6	0.3	1.0
11/03/2022 03:00	4,856.1	0.0	4,856.1	104,046.0	505.3	0.6	0.3	1.0
11/03/2022 04:00	4,870.1	6.8	4,871.7	104,046.0	506.9	0.6	0.3	1.0
11/03/2022 05:00	5,029.5	1,228.6	6,258.1	104,046.0	651.1	0.8	0.4	1.3
11/03/2022 06:00	5,032.2	1,504.0	6,536.2	104,046.0	680.1	0.8	0.4	1.4
11/03/2022 07:00	4,919.5	70.3	4,953.2	104,046.0	515.4	0.6	0.3	1.1
11/03/2022 08:00	4,602.3	1.6	4,602.3	104,046.0	478.9	0.6	0.3	1.0
11/03/2022 09:00	4,954.3	32.3	4,984.0	104,046.0	518.6	0.6	0.3	1.1
11/03/2022 10:00	4,954.2	315.2	5,269.4	104,046.0	548.3	0.7	0.3	1.1
11/03/2022 11:00	4,055.2	0.2	4,055.2	104,046.0	421.9	0.5	0.3	0.9
11/03/2022 12:00	3,048.2	0.0	3,048.2	104,046.0	317.2	0.4	0.2	0.6
11/03/2022 13:00	3,011.5	0.0	3,011.5	104,046.0	313.3	0.4	0.2	0.6
11/03/2022 14:00	2,922.9	0.0	2,922.9	104,046.0	304.1	0.4	0.2	0.6
11/03/2022 15:00	2,993.1	0.0	2,993.1	104,046.0	311.4	0.4	0.2	0.6
11/03/2022 16:00	4,358.5	4.1	4,358.6	104,046.0	453.5	0.6	0.3	0.9
11/03/2022 17:00	4,867.2	589.4	5,456.6	104,046.0	567.7	0.7	0.3	1.2
11/03/2022 18:00	4,900.9	496.3	5,397.2	104,046.0	561.6	0.7	0.3	1.1
11/03/2022 19:00	4,920.4	487.5	5,407.9	104,046.0	562.7	0.7	0.3	1.1
11/03/2022 20:00	4,960.6	976.7	5,937.3	104,046.0	617.8	0.8	0.4	1.3
11/03/2022 21:00	4,954.9	1,113.8	6,068.7	104,046.0	631.4	0.8	0.4	1.3
11/03/2022 22:00	4,973.6	629.8	5,559.3	104,046.0	578.4	0.7	0.4	1.2
11/03/2022 23:00	5,009.2	138.4	5,147.6	104,046.0	535.6	0.7	0.3	1.1
Average/Sum#:	4,523.3	316.5	4,835.8	104,046.0	503.2	0.6	0.3	1.0
Minimum:	2,922.9	0.0	2,922.9	104,046.0	304.1	0.4	0.2	0.6
Maximum:	5,032.2	1,504.0	6,536.2	104,046.0	680.1	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2022 00:00	4,678.8	14.4	4,680.5	104,046.0	487.0	0.6	0.3	1.0
11/04/2022 01:00	4,624.1	0.0	4,624.1	104,046.0	481.1	0.6	0.3	1.0
11/04/2022 02:00	4,281.8	0.0	4,281.8	104,046.0	445.5	0.5	0.3	0.9
11/04/2022 03:00	4,454.0	0.0	4,454.0	104,046.0	463.4	0.6	0.3	0.9
11/04/2022 04:00	4,721.7	1.8	4,721.8	104,046.0	491.3	0.6	0.3	1.0
11/04/2022 05:00	4,975.0	657.3	5,632.3	104,046.0	586.0	0.7	0.4	1.2
11/04/2022 06:00	5,015.2	685.9	5,701.1	104,046.0	593.2	0.7	0.4	1.2
11/04/2022 07:00	4,011.2	29.5	4,019.2	104,046.0	418.2	0.5	0.3	0.9
11/04/2022 08:00	3,088.0	0.0	3,088.0	104,046.0	321.3	0.4	0.2	0.7
11/04/2022 09:00	3,138.9	0.0	3,138.9	104,046.0	326.6	0.4	0.2	0.7
11/04/2022 10:00	2,979.4	0.0	2,979.4	104,046.0	310.0	0.4	0.2	0.6
11/04/2022 11:00	2,877.9	0.0	2,877.9	104,046.0	299.4	0.4	0.2	0.6
11/04/2022 12:00	2,961.5	0.0	2,961.5	104,046.0	308.1	0.4	0.2	0.6
11/04/2022 13:00	2,894.2	0.0	2,894.2	104,046.0	301.1	0.4	0.2	0.6
11/04/2022 14:00	2,883.3	0.0	2,883.3	104,046.0	300.0	0.4	0.2	0.6
11/04/2022 15:00	3,492.4	0.0	3,492.4	104,046.0	363.4	0.4	0.2	0.7
11/04/2022 16:00	3,634.5	0.0	3,634.5	104,046.0	378.2	0.5	0.2	0.8
11/04/2022 17:00	4,485.1	0.0	4,485.1	104,046.0	466.7	0.6	0.3	0.9
11/04/2022 18:00	4,834.5	432.6	5,258.4	104,046.0	547.1	0.7	0.3	1.1
11/04/2022 19:00	4,840.6	423.2	5,263.8	104,046.0	547.7	0.7	0.3	1.1
11/04/2022 20:00	4,830.1	292.4	5,072.8	104,046.0	527.8	0.6	0.3	1.1
11/04/2022 21:00	3,115.4	0.0	3,115.4	104,046.0	324.1	0.4	0.2	0.7
11/04/2022 22:00	2,894.9	0.0	2,894.9	104,046.0	301.2	0.4	0.2	0.6
11/04/2022 23:00	3,348.5	0.0	3,348.5	104,046.0	348.4	0.4	0.2	0.7
Average/Sum#:	3,877.5	105.7	3,979.3	104,046.0	414.0	0.5	0.3	0.8
Minimum:	2,877.9	0.0	2,877.9	104,046.0	299.4	0.4	0.2	0.6
Maximum:	5,015.2	685.9	5,701.1	104,046.0	593.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	2,994.2	0.0	2,994.2	104,046.0	311.5	0.4	0.2	0.6
11/05/2022 01:00	2,992.9	0.0	2,992.9	104,046.0	311.4	0.4	0.2	0.6
11/05/2022 02:00	2,987.1	0.0	2,987.1	104,046.0	310.8	0.4	0.2	0.6
11/05/2022 03:00	2,975.5	0.0	2,975.5	104,046.0	309.6	0.4	0.2	0.6
11/05/2022 04:00	2,987.3	0.0	2,987.3	104,046.0	310.8	0.4	0.2	0.6
11/05/2022 05:00	3,291.7	0.0	3,291.7	104,046.0	342.5	0.4	0.2	0.7
11/05/2022 06:00	2,983.4	0.0	2,983.4	104,046.0	310.4	0.4	0.2	0.6
11/05/2022 07:00	3,655.2	0.0	3,655.2	104,046.0	380.3	0.5	0.2	0.8
11/05/2022 08:00	2,918.1	0.0	2,918.1	104,046.0	303.6	0.4	0.2	0.6
11/05/2022 09:00	2,951.4	0.0	2,951.4	104,046.0	307.1	0.4	0.2	0.6
11/05/2022 10:00	3,086.9	0.0	3,086.9	104,046.0	321.2	0.4	0.2	0.6
11/05/2022 11:00	3,232.3	0.0	3,232.3	104,046.0	336.3	0.4	0.2	0.7
11/05/2022 12:00	3,976.9	0.0	3,976.9	104,046.0	413.8	0.5	0.2	0.8
11/05/2022 13:00	3,527.4	0.0	3,527.4	104,046.0	367.0	0.4	0.2	0.7
11/05/2022 14:00	4,399.3	0.0	4,399.3	104,046.0	457.7	0.6	0.3	0.9
11/05/2022 15:00	2,974.4	0.0	2,974.4	104,046.0	309.5	0.4	0.2	0.6
11/05/2022 16:00	3,613.0	0.0	3,613.0	104,046.0	375.9	0.5	0.2	0.8
11/05/2022 17:00	4,435.0	47.5	4,449.3	104,046.0	462.9	0.6	0.3	0.9
11/05/2022 18:00	4,786.4	211.2	4,997.6	104,046.0	520.0	0.6	0.3	1.0
11/05/2022 19:00	4,776.1	165.8	4,912.1	104,046.0	511.1	0.6	0.3	1.0
11/05/2022 20:00	3,430.8	0.0	3,430.8	104,046.0	357.0	0.4	0.2	0.7
11/05/2022 21:00	3,087.9	0.0	3,087.9	104,046.0	321.3	0.4	0.2	0.6
11/05/2022 22:00	2,980.2	0.0	2,980.2	104,046.0	310.1	0.4	0.2	0.6
11/05/2022 23:00	4,309.8	0.0	4,309.8	104,046.0	448.4	0.5	0.3	0.9
Average/Sum#:	3,473.1	17.7	3,488.1	104,046.0	362.9	0.5	0.2	0.7
Minimum:	2,918.1	0.0	2,918.1	104,046.0	303.6	0.4	0.2	0.6
Maximum:	4,786.4	211.2	4,997.6	104,046.0	520.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2022 00:00	4,234.3	0.0	4,234.3	104,046.0	440.6	0.5	0.3	0.9
11/06/2022 01:00	3,695.0	0.0	3,695.0	104,046.0	384.4	0.5	0.2	0.8
11/06/2022 02:00	3,815.9	0.0	3,815.9	104,046.0	397.0	0.5	0.2	0.8
11/06/2022 03:00	4,469.7	0.0	4,469.7	104,046.0	465.1	0.6	0.3	0.9
11/06/2022 04:00	4,440.3	0.0	4,440.3	104,046.0	462.0	0.6	0.3	0.9
11/06/2022 05:00	4,716.8	0.0	4,716.8	104,046.0	490.8	0.6	0.3	1.0
11/06/2022 06:00	4,771.9	0.0	4,771.9	104,046.0	496.5	0.6	0.3	1.0
11/06/2022 07:00	4,768.8	0.0	4,768.8	104,046.0	496.2	0.6	0.3	1.0
11/06/2022 08:00	4,829.9	366.8	5,189.4	104,046.0	539.9	0.6	0.3	1.1
11/06/2022 09:00	4,755.7	181.9	4,901.2	104,046.0	510.0	0.6	0.3	1.0
11/06/2022 10:00	3,256.4	0.0	3,256.4	104,046.0	338.8	0.4	0.2	0.7
11/06/2022 11:00	3,037.4	0.0	3,037.4	104,046.0	316.0	0.4	0.2	0.6
11/06/2022 12:00	2,937.6	0.0	2,937.6	104,046.0	305.6	0.4	0.2	0.6
11/06/2022 13:00	3,028.5	0.0	3,028.5	104,046.0	315.1	0.4	0.2	0.6
11/06/2022 14:00	3,614.6	0.0	3,614.6	104,046.0	376.1	0.5	0.2	0.8
11/06/2022 15:00	4,771.9	296.3	4,988.2	104,046.0	519.0	0.6	0.3	1.1
11/06/2022 16:00	4,816.8	771.8	5,588.6	104,046.0	581.5	0.7	0.3	1.2
11/06/2022 17:00	4,825.6	431.5	5,257.1	104,046.0	547.0	0.7	0.3	1.1
11/06/2022 18:00	4,850.9	242.5	5,076.4	104,046.0	528.2	0.6	0.3	1.1
11/06/2022 19:00	4,837.5	142.7	4,980.2	104,046.0	518.2	0.6	0.3	1.0
11/06/2022 20:00	4,846.3	200.3	5,046.6	104,046.0	525.1	0.6	0.3	1.0
11/06/2022 21:00	4,850.5	227.4	5,077.9	104,046.0	528.3	0.6	0.3	1.1
11/06/2022 22:00	3,923.8	25.9	3,930.8	104,046.0	409.0	0.5	0.2	0.8
11/06/2022 23:00	3,025.5	0.0	3,025.5	104,046.0	314.8	0.4	0.2	0.6
Average/Sum#:	4,213.4	120.3	4,327.0	104,046.0	450.2	0.5	0.3	0.9
Minimum:	2,937.6	0.0	2,937.6	104,046.0	305.6	0.4	0.2	0.6
Maximum:	4,850.9	771.8	5,588.6	104,046.0	581.5	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2022 00:00	3,405.6	0.0	3,405.6	104,046.0	354.3	0.4	0.2	0.7
11/07/2022 01:00	3,805.7	0.0	3,805.7	104,046.0	396.0	0.5	0.2	0.8
11/07/2022 02:00	4,059.3	0.0	4,059.3	104,046.0	422.4	0.5	0.3	0.8
11/07/2022 03:00	3,810.3	0.0	3,810.3	104,046.0	396.4	0.5	0.2	0.8
11/07/2022 04:00	3,605.9	0.0	3,605.9	104,046.0	375.2	0.5	0.2	0.8
11/07/2022 05:00	4,413.5	0.0	4,413.5	104,046.0	459.2	0.6	0.3	0.9
11/07/2022 06:00	4,749.4	0.0	4,749.4	104,046.0	494.2	0.6	0.3	1.0
11/07/2022 07:00	4,225.8	0.0	4,225.8	104,046.0	439.7	0.5	0.3	0.9
11/07/2022 08:00	3,012.3	0.0	3,012.3	104,046.0	313.4	0.4	0.2	0.6
11/07/2022 09:00	3,002.9	0.0	3,002.9	104,046.0	312.4	0.4	0.2	0.6
11/07/2022 10:00	2,976.2	0.0	2,976.2	104,046.0	309.7	0.4	0.2	0.6
11/07/2022 11:00	2,945.5	0.0	2,945.5	104,046.0	306.5	0.4	0.2	0.6
11/07/2022 12:00	2,969.3	0.0	2,969.3	104,046.0	308.9	0.4	0.2	0.6
11/07/2022 13:00	2,976.8	0.0	2,976.8	104,046.0	309.7	0.4	0.2	0.6
11/07/2022 14:00	3,853.6	0.0	3,853.6	104,046.0	401.0	0.5	0.2	0.8
11/07/2022 15:00	4,654.8	345.4	4,837.9	104,046.0	503.4	0.6	0.3	1.0
11/07/2022 16:00	4,849.3	619.9	5,469.2	104,046.0	569.0	0.7	0.3	1.1
11/07/2022 17:00	4,858.1	609.5	5,467.6	104,046.0	568.9	0.7	0.3	1.1
11/07/2022 18:00	4,830.0	542.0	5,372.0	104,046.0	558.9	0.7	0.3	1.1
11/07/2022 19:00	4,836.0	598.0	5,434.0	104,046.0	565.4	0.7	0.3	1.1
11/07/2022 20:00	4,867.3	602.3	5,469.6	104,046.0	569.1	0.7	0.3	1.1
11/07/2022 21:00	4,857.6	638.3	5,495.9	104,046.0	571.8	0.7	0.3	1.1
11/07/2022 22:00	4,878.4	341.1	5,219.5	104,046.0	543.1	0.7	0.3	1.1
11/07/2022 23:00	3,990.5	85.2	4,016.1	104,046.0	417.9	0.5	0.3	0.9
Average/Sum#:	4,018.1	182.6	4,191.4	104,046.0	436.1	0.5	0.3	0.9
Minimum:	2,945.5	0.0	2,945.5	104,046.0	306.5	0.4	0.2	0.6
Maximum:	4,878.4	638.3	5,495.9	104,046.0	571.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2022 00:00	891.1	0.0	891.1	104,046.0	92.7	0.0	0.0	0.0
11/08/2022 01:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 02:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 03:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 04:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 05:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 06:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 07:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 08:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 09:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 10:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 11:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 12:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 13:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 14:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 15:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 16:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 17:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 18:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 19:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 20:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 21:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 22:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/08/2022 23:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
Average/Sum#:	891.1	0.0	891.1	104,046.0	92.7	0.0	0.0	0.0
Minimum:	891.1	0.0	891.1	104,046.0	92.7	0.0	0.0	0.0
Maximum:	891.1	0.0	891.1	104,046.0	92.7	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 01:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 02:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 03:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 04:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 05:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 06:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 07:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 08:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 09:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 10:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 11:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 12:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 13:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 14:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 15:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 16:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 17:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 18:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 19:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/09/2022 20:00	2,427.5	0.0	2,427.5	104,046.0	252.6	0.0	0.0	0.0
11/09/2022 21:00	3,317.5	0.0	3,317.5	104,046.0	345.2	0.4	0.2	0.6
11/09/2022 22:00	2,998.7	0.0	2,998.7	104,046.0	312.0	0.4	0.2	0.6
11/09/2022 23:00	3,022.8	0.0	3,022.8	104,046.0	314.5	0.4	0.2	0.6
Average/Sum#:	2,941.6	0.0	2,941.6	104,046.0	306.1	0.4	0.2	0.6
Minimum:	2,427.5	0.0	2,427.5	104,046.0	252.6	0.4	0.2	0.6
Maximum:	3,317.5	0.0	3,317.5	104,046.0	345.2	0.4	0.2	0.6
%SI	83.33	83.33	83.33	0.00	83.33	87.50	87.50	87.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2022 00:00	3,088.1	0.0	3,088.1	104,046.0	321.3	0.4	0.2	0.6
11/10/2022 01:00	3,017.8	0.0	3,017.8	104,046.0	314.0	0.4	0.2	0.6
11/10/2022 02:00	3,025.1	0.0	3,025.1	104,046.0	314.7	0.4	0.2	0.6
11/10/2022 03:00	3,467.1	0.0	3,467.1	104,046.0	360.7	0.4	0.2	0.7
11/10/2022 04:00	4,183.5	0.0	4,183.5	104,046.0	435.3	0.5	0.3	0.9
11/10/2022 05:00	4,574.9	64.7	4,589.8	104,046.0	477.6	0.6	0.3	1.0
11/10/2022 06:00	5,017.8	1,028.8	6,046.6	104,046.0	629.1	0.8	0.4	1.3
11/10/2022 07:00	5,023.6	177.4	5,201.0	104,046.0	541.1	0.7	0.3	1.1
11/10/2022 08:00	3,484.7	0.0	3,484.7	104,046.0	362.6	0.4	0.2	0.7
11/10/2022 09:00	3,570.8	0.0	3,570.8	104,046.0	371.5	0.4	0.2	0.7
11/10/2022 10:00	3,088.9	0.0	3,088.9	104,046.0	321.4	0.4	0.2	0.6
11/10/2022 11:00	2,894.3	0.0	2,894.3	104,046.0	301.1	0.4	0.2	0.6
11/10/2022 12:00	2,893.5	0.0	2,893.5	104,046.0	301.1	0.4	0.2	0.6
11/10/2022 13:00	2,889.7	0.0	2,889.7	104,046.0	300.7	0.4	0.2	0.6
11/10/2022 14:00	2,887.9	0.0	2,887.9	104,046.0	300.5	0.4	0.2	0.6
11/10/2022 15:00	3,796.7	80.3	3,815.2	104,046.0	397.0	0.5	0.2	0.8
11/10/2022 16:00	4,873.8	818.5	5,692.3	104,046.0	592.3	0.7	0.4	1.2
11/10/2022 17:00	4,871.9	783.7	5,655.6	104,046.0	588.4	0.7	0.4	1.2
11/10/2022 18:00	4,907.6	526.4	5,434.0	104,046.0	565.4	0.7	0.3	1.1
11/10/2022 19:00	4,913.1	434.7	5,347.8	104,046.0	556.4	0.7	0.3	1.1
11/10/2022 20:00	4,929.7	505.3	5,435.0	104,046.0	565.5	0.7	0.3	1.1
11/10/2022 21:00	4,947.9	766.1	5,714.0	104,046.0	594.5	0.7	0.4	1.2
11/10/2022 22:00	4,962.9	600.9	5,563.8	104,046.0	578.9	0.7	0.3	1.2
11/10/2022 23:00	4,975.3	368.8	5,344.1	104,046.0	556.0	0.7	0.3	1.1
Average/Sum#:	4,011.9	256.5	4,263.8	104,046.0	443.6	0.5	0.3	0.9
Minimum:	2,887.9	0.0	2,887.9	104,046.0	300.5	0.4	0.2	0.6
Maximum:	5,023.6	1,028.8	6,046.6	104,046.0	629.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2022 00:00	4,973.9	795.6	5,769.5	104,046.0	600.3	0.7	0.4	1.2
11/11/2022 01:00	4,968.3	660.2	5,628.5	104,046.0	585.6	0.7	0.4	1.2
11/11/2022 02:00	4,923.4	230.3	5,100.7	104,046.0	530.7	0.6	0.3	1.1
11/11/2022 03:00	4,586.5	0.0	4,586.5	104,046.0	477.2	0.6	0.3	1.0
11/11/2022 04:00	4,863.1	83.1	4,886.4	104,046.0	508.4	0.6	0.3	1.0
11/11/2022 05:00	4,988.2	787.9	5,776.1	104,046.0	601.0	0.7	0.4	1.2
11/11/2022 06:00	5,007.9	825.4	5,833.3	104,046.0	606.9	0.7	0.4	1.2
11/11/2022 07:00	4,909.2	106.4	4,991.1	104,046.0	519.3	0.6	0.3	1.0
11/11/2022 08:00	3,020.7	0.0	3,020.7	104,046.0	314.3	0.4	0.2	0.6
11/11/2022 09:00	3,002.1	0.0	3,002.1	104,046.0	312.4	0.4	0.2	0.6
11/11/2022 10:00	3,040.0	0.0	3,040.0	104,046.0	316.3	0.4	0.2	0.6
11/11/2022 11:00	2,997.2	0.0	2,997.2	104,046.0	311.8	0.4	0.2	0.6
11/11/2022 12:00	2,985.4	0.0	2,985.4	104,046.0	310.6	0.4	0.2	0.6
11/11/2022 13:00	2,986.7	0.0	2,986.7	104,046.0	310.8	0.4	0.2	0.6
11/11/2022 14:00	3,054.1	0.0	3,054.1	104,046.0	317.8	0.4	0.2	0.6
11/11/2022 15:00	4,469.1	297.8	4,612.0	104,046.0	479.9	0.6	0.3	1.0
11/11/2022 16:00	4,854.8	685.6	5,540.4	104,046.0	576.5	0.7	0.3	1.2
11/11/2022 17:00	4,860.2	480.1	5,340.3	104,046.0	555.6	0.7	0.3	1.1
11/11/2022 18:00	4,882.1	473.9	5,356.0	104,046.0	557.3	0.7	0.3	1.1
11/11/2022 19:00	4,904.1	447.9	5,352.0	104,046.0	556.9	0.7	0.3	1.1
11/11/2022 20:00	4,920.0	483.5	5,403.5	104,046.0	562.2	0.7	0.3	1.1
11/11/2022 21:00	4,923.2	801.8	5,725.0	104,046.0	595.7	0.7	0.4	1.2
11/11/2022 22:00	4,924.1	713.9	5,638.0	104,046.0	586.6	0.7	0.4	1.2
11/11/2022 23:00	4,947.3	476.8	5,424.1	104,046.0	564.4	0.7	0.3	1.1
Average/Sum#:	4,333.0	347.9	4,668.7	104,046.0	485.8	0.6	0.3	1.0
Minimum:	2,985.4	0.0	2,985.4	104,046.0	310.6	0.4	0.2	0.6
Maximum:	5,007.9	825.4	5,833.3	104,046.0	606.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2022 00:00	4,959.3	769.9	5,729.2	104,046.0	596.1	0.7	0.4	1.2
11/12/2022 01:00	4,961.4	765.2	5,726.6	104,046.0	595.8	0.7	0.4	1.2
11/12/2022 02:00	4,946.5	793.0	5,739.5	104,046.0	597.2	0.7	0.4	1.2
11/12/2022 03:00	4,930.1	980.8	5,910.9	104,046.0	615.0	0.7	0.4	1.2
11/12/2022 04:00	4,932.5	931.0	5,863.5	104,046.0	610.1	0.7	0.4	1.2
11/12/2022 05:00	4,939.1	886.0	5,825.1	104,046.0	606.1	0.7	0.4	1.2
11/12/2022 06:00	4,932.7	889.5	5,822.2	104,046.0	605.8	0.7	0.4	1.2
11/12/2022 07:00	4,943.8	238.1	5,181.9	104,046.0	539.2	0.6	0.3	1.1
11/12/2022 08:00	4,932.8	979.0	5,911.8	104,046.0	615.1	0.7	0.4	1.2
11/12/2022 09:00	4,923.1	560.9	5,484.0	104,046.0	570.6	0.7	0.3	1.1
11/12/2022 10:00	4,904.2	364.1	5,268.3	104,046.0	548.1	0.7	0.3	1.1
11/12/2022 11:00	4,799.8	172.8	4,889.7	104,046.0	508.8	0.6	0.3	1.0
11/12/2022 12:00	4,780.7	0.0	4,780.7	104,046.0	497.4	0.6	0.3	1.0
11/12/2022 13:00	4,712.0	0.0	4,712.0	104,046.0	490.3	0.6	0.3	1.0
11/12/2022 14:00	4,822.3	366.3	5,060.4	104,046.0	526.5	0.6	0.3	1.1
11/12/2022 15:00	4,814.1	438.3	5,252.4	104,046.0	546.5	0.7	0.3	1.1
11/12/2022 16:00	4,819.9	644.6	5,464.5	104,046.0	568.6	0.7	0.3	1.1
11/12/2022 17:00	4,826.2	597.0	5,423.2	104,046.0	564.3	0.7	0.3	1.1
11/12/2022 18:00	4,847.8	474.1	5,321.9	104,046.0	553.7	0.7	0.3	1.1
11/12/2022 19:00	4,866.7	662.6	5,529.3	104,046.0	575.3	0.7	0.3	1.2
11/12/2022 20:00	4,880.3	480.4	5,360.7	104,046.0	557.8	0.7	0.3	1.1
11/12/2022 21:00	4,903.3	527.6	5,430.9	104,046.0	565.1	0.7	0.3	1.1
11/12/2022 22:00	4,927.0	593.0	5,520.0	104,046.0	574.3	0.7	0.3	1.1
11/12/2022 23:00	4,932.9	379.5	5,312.4	104,046.0	552.7	0.7	0.3	1.1
Average/Sum#:	4,884.9	562.2	5,438.4	104,046.0	565.9	0.7	0.3	1.1
Minimum:	4,712.0	0.0	4,712.0	104,046.0	490.3	0.6	0.3	1.0
Maximum:	4,961.4	980.8	5,911.8	104,046.0	615.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2022 00:00	4,770.9	0.2	4,770.9	104,046.0	496.4	0.6	0.3	1.0
11/13/2022 01:00	4,663.7	0.0	4,663.7	104,046.0	485.2	0.6	0.3	1.0
11/13/2022 02:00	4,614.7	0.0	4,614.7	104,046.0	480.1	0.6	0.3	1.0
11/13/2022 03:00	4,834.3	0.0	4,834.3	104,046.0	503.0	0.6	0.3	1.0
11/13/2022 04:00	4,835.6	0.0	4,835.6	104,046.0	503.1	0.6	0.3	1.0
11/13/2022 05:00	4,825.6	0.0	4,825.6	104,046.0	502.1	0.6	0.3	1.0
11/13/2022 06:00	4,892.0	58.5	4,905.5	104,046.0	510.4	0.6	0.3	1.0
11/13/2022 07:00	4,975.9	433.3	5,409.2	104,046.0	562.8	0.7	0.3	1.1
11/13/2022 08:00	4,883.1	48.8	4,896.3	104,046.0	509.4	0.6	0.3	1.0
11/13/2022 09:00	4,941.3	609.7	5,551.0	104,046.0	577.6	0.7	0.3	1.2
11/13/2022 10:00	4,820.4	1.9	4,820.4	104,046.0	501.5	0.6	0.3	1.0
11/13/2022 11:00	4,715.3	0.0	4,715.3	104,046.0	490.6	0.6	0.3	1.0
11/13/2022 12:00	4,627.4	0.0	4,627.4	104,046.0	481.5	0.6	0.3	1.0
11/13/2022 13:00	4,512.8	0.0	4,512.8	104,046.0	469.5	0.6	0.3	0.9
11/13/2022 14:00	4,169.9	0.0	4,169.9	104,046.0	433.9	0.5	0.3	0.9
11/13/2022 15:00	4,059.5	0.0	4,059.5	104,046.0	422.4	0.5	0.3	0.8
11/13/2022 16:00	4,805.3	860.0	5,648.1	104,046.0	587.7	0.7	0.4	1.2
11/13/2022 17:00	4,843.1	893.9	5,737.0	104,046.0	596.9	0.7	0.4	1.2
11/13/2022 18:00	4,850.6	845.4	5,696.0	104,046.0	592.6	0.7	0.4	1.2
11/13/2022 19:00	4,882.0	620.1	5,502.1	104,046.0	572.5	0.7	0.3	1.1
11/13/2022 20:00	4,915.2	471.6	5,386.8	104,046.0	560.5	0.7	0.3	1.1
11/13/2022 21:00	4,931.8	838.9	5,770.7	104,046.0	600.4	0.7	0.4	1.2
11/13/2022 22:00	4,946.5	747.2	5,693.7	104,046.0	592.4	0.7	0.4	1.2
11/13/2022 23:00	4,962.4	677.5	5,639.9	104,046.0	586.8	0.7	0.4	1.2
Average/Sum#:	4,761.6	296.1	5,053.6	104,046.0	525.8	0.6	0.3	1.1
Minimum:	4,059.5	0.0	4,059.5	104,046.0	422.4	0.5	0.3	0.8
Maximum:	4,975.9	893.9	5,770.7	104,046.0	600.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2022 00:00	4,925.0	377.9	5,216.0	104,046.0	542.7	0.7	0.3	1.1
11/14/2022 01:00	4,803.9	0.0	4,803.9	104,046.0	499.8	0.6	0.3	1.0
11/14/2022 02:00	4,802.1	0.0	4,802.1	104,046.0	499.6	0.6	0.3	1.0
11/14/2022 03:00	4,551.7	0.0	4,551.7	104,046.0	473.6	0.6	0.3	0.9
11/14/2022 04:00	4,688.1	0.0	4,688.1	104,046.0	487.8	0.6	0.3	1.0
11/14/2022 05:00	4,993.7	694.6	5,674.4	104,046.0	590.4	0.7	0.4	1.2
11/14/2022 06:00	5,016.3	1,621.8	6,638.1	104,046.0	690.7	0.8	0.4	1.4
11/14/2022 07:00	5,015.6	1,072.4	6,088.0	104,046.0	633.4	0.8	0.4	1.3
11/14/2022 08:00	5,014.0	453.0	5,467.0	104,046.0	568.8	0.7	0.3	1.1
11/14/2022 09:00	4,915.0	352.9	5,186.7	104,046.0	539.7	0.7	0.3	1.1
11/14/2022 10:00	4,666.0	0.0	4,666.0	104,046.0	485.5	0.6	0.3	1.0
11/14/2022 11:00	4,240.7	0.0	4,240.7	104,046.0	441.2	0.5	0.3	0.9
11/14/2022 12:00	3,871.7	0.0	3,871.7	104,046.0	402.8	0.5	0.2	0.8
11/14/2022 13:00	4,249.4	0.0	4,249.4	104,046.0	442.1	0.5	0.3	0.9
11/14/2022 14:00	4,535.7	0.0	4,535.7	104,046.0	471.9	0.6	0.3	0.9
11/14/2022 15:00	4,671.0	354.4	4,855.3	104,046.0	505.2	0.6	0.3	1.0
11/14/2022 16:00	4,828.6	946.3	5,774.9	104,046.0	600.9	0.7	0.4	1.2
11/14/2022 17:00	4,853.9	1,063.9	5,917.8	104,046.0	615.7	0.7	0.4	1.2
11/14/2022 18:00	4,854.3	918.2	5,772.5	104,046.0	600.6	0.7	0.4	1.2
11/14/2022 19:00	4,893.4	798.1	5,691.5	104,046.0	592.2	0.7	0.4	1.2
11/14/2022 20:00	4,919.9	1,000.6	5,920.5	104,046.0	616.0	0.7	0.4	1.2
11/14/2022 21:00	4,943.8	902.2	5,846.0	104,046.0	608.3	0.7	0.4	1.2
11/14/2022 22:00	4,977.2	853.6	5,830.8	104,046.0	606.7	0.7	0.4	1.2
11/14/2022 23:00	4,981.8	581.1	5,562.9	104,046.0	578.8	0.7	0.3	1.2
Average/Sum#:	4,758.9	499.6	5,243.8	104,046.0	545.6	0.7	0.3	1.1
Minimum:	3,871.7	0.0	3,871.7	104,046.0	402.8	0.5	0.2	0.8
Maximum:	5,016.3	1,621.8	6,638.1	104,046.0	690.7	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	4,986.3	965.8	5,952.1	104,046.0	619.3	0.7	0.4	1.2
11/15/2022 01:00	4,995.0	988.9	5,983.9	104,046.0	622.6	0.7	0.4	1.2
11/15/2022 02:00	4,991.6	1,039.5	6,031.1	104,046.0	627.5	0.8	0.4	1.3
11/15/2022 03:00	5,026.3	930.7	5,957.0	104,046.0	619.8	0.7	0.4	1.2
11/15/2022 04:00	5,012.1	1,013.0	6,025.1	104,046.0	626.9	0.8	0.4	1.3
11/15/2022 05:00	5,001.0	1,024.3	6,025.3	104,046.0	626.9	0.8	0.4	1.3
11/15/2022 06:00	5,024.2	1,136.9	6,161.1	104,046.0	641.0	0.8	0.4	1.3
11/15/2022 07:00	5,019.7	995.7	6,015.4	104,046.0	625.9	0.8	0.4	1.3
11/15/2022 08:00	4,995.3	542.9	5,538.2	104,046.0	576.2	0.7	0.3	1.2
11/15/2022 09:00	4,576.1	54.8	4,590.9	104,046.0	477.7	0.6	0.3	1.0
11/15/2022 10:00	3,848.7	0.0	3,848.7	104,046.0	400.4	0.5	0.2	0.8
11/15/2022 11:00	3,407.7	0.0	3,407.7	104,046.0	354.6	0.4	0.2	0.7
11/15/2022 12:00	2,961.2	0.0	2,961.2	104,046.0	308.1	0.4	0.2	0.6
11/15/2022 13:00	2,939.7	0.0	2,939.7	104,046.0	305.9	0.4	0.2	0.6
11/15/2022 14:00	2,962.3	0.0	2,962.3	104,046.0	308.2	0.4	0.2	0.6
11/15/2022 15:00	3,838.6	154.9	3,885.1	104,046.0	404.2	0.5	0.2	0.8
11/15/2022 16:00	4,754.8	870.3	5,625.1	104,046.0	585.3	0.7	0.4	1.2
11/15/2022 17:00	4,810.1	979.7	5,789.8	104,046.0	602.4	0.7	0.4	1.2
11/15/2022 18:00	4,833.7	1,042.6	5,876.3	104,046.0	611.4	0.7	0.4	1.2
11/15/2022 19:00	4,868.4	843.7	5,712.1	104,046.0	594.3	0.7	0.4	1.2
11/15/2022 20:00	4,876.2	735.0	5,611.2	104,046.0	583.8	0.7	0.4	1.2
11/15/2022 21:00	4,890.3	777.0	5,667.3	104,046.0	589.7	0.7	0.4	1.2
11/15/2022 22:00	4,931.3	388.1	5,319.4	104,046.0	553.5	0.7	0.3	1.1
11/15/2022 23:00	4,942.8	420.6	5,363.4	104,046.0	558.0	0.7	0.3	1.1
Average/Sum#:	4,520.6	621.0	5,135.4	104,046.0	534.3	0.7	0.3	1.1
Minimum:	2,939.7	0.0	2,939.7	104,046.0	305.9	0.4	0.2	0.6
Maximum:	5,026.3	1,136.9	6,161.1	104,046.0	641.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	4,961.4	503.0	5,464.4	104,046.0	568.5	0.7	0.3	1.1
11/16/2022 01:00	4,954.7	527.7	5,482.4	104,046.0	570.4	0.7	0.3	1.1
11/16/2022 02:00	4,950.9	493.2	5,444.1	104,046.0	566.4	0.7	0.3	1.1
11/16/2022 03:00	5,005.0	474.2	5,479.2	104,046.0	570.1	0.7	0.3	1.1
11/16/2022 04:00	5,020.4	721.7	5,742.1	104,046.0	597.4	0.7	0.4	1.2
11/16/2022 05:00	5,045.9	776.8	5,822.7	104,046.0	605.8	0.7	0.4	1.2
11/16/2022 06:00	5,038.5	1,024.3	6,062.8	104,046.0	630.8	0.8	0.4	1.3
11/16/2022 07:00	5,061.7	773.7	5,835.4	104,046.0	607.2	0.7	0.4	1.2
11/16/2022 08:00	4,606.8	33.2	4,621.7	104,046.0	480.9	0.6	0.3	1.0
11/16/2022 09:00	4,200.4	0.0	4,200.4	104,046.0	437.0	0.5	0.3	0.9
11/16/2022 10:00	3,285.8	0.0	3,285.8	104,046.0	341.9	0.4	0.2	0.7
11/16/2022 11:00	3,058.5	0.0	3,058.5	104,046.0	318.2	0.4	0.2	0.6
11/16/2022 12:00	4,015.4	0.0	4,015.4	104,046.0	417.8	0.5	0.3	0.8
11/16/2022 13:00	3,752.0	0.0	3,752.0	104,046.0	390.4	0.5	0.2	0.8
11/16/2022 14:00	2,924.5	0.0	2,924.5	104,046.0	304.3	0.4	0.2	0.6
11/16/2022 15:00	4,135.3	0.0	4,135.3	104,046.0	430.3	0.5	0.3	0.9
11/16/2022 16:00	4,774.8	11.2	4,778.9	104,046.0	497.2	0.6	0.3	1.0
11/16/2022 17:00	4,805.0	729.6	5,534.6	104,046.0	575.9	0.7	0.3	1.2
11/16/2022 18:00	4,840.6	1,196.1	6,036.7	104,046.0	628.1	0.8	0.4	1.3
11/16/2022 19:00	4,878.9	1,031.9	5,910.8	104,046.0	615.0	0.7	0.4	1.2
11/16/2022 20:00	4,912.4	244.5	5,156.9	104,046.0	536.6	0.6	0.3	1.1
11/16/2022 21:00	4,928.8	1,032.3	5,961.1	104,046.0	620.2	0.7	0.4	1.2
11/16/2022 22:00	4,945.6	893.1	5,838.7	104,046.0	607.5	0.7	0.4	1.2
11/16/2022 23:00	4,949.1	656.6	5,605.7	104,046.0	583.3	0.7	0.3	1.2
Average/Sum#:	4,543.9	463.5	5,006.3	104,046.0	520.9	0.6	0.3	1.0
Minimum:	2,924.5	0.0	2,924.5	104,046.0	304.3	0.4	0.2	0.6
Maximum:	5,061.7	1,196.1	6,062.8	104,046.0	630.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2022 00:00	4,793.1	0.1	4,793.1	104,046.0	498.7	0.6	0.3	1.0
11/17/2022 01:00	4,808.2	0.0	4,808.2	104,046.0	500.3	0.6	0.3	1.0
11/17/2022 02:00	4,739.1	0.0	4,739.1	104,046.0	493.1	0.6	0.3	1.0
11/17/2022 03:00	4,744.1	0.0	4,744.1	104,046.0	493.6	0.6	0.3	1.0
11/17/2022 04:00	4,794.2	0.0	4,794.2	104,046.0	498.8	0.6	0.3	1.0
11/17/2022 05:00	4,799.9	0.0	4,799.9	104,046.0	499.4	0.6	0.3	1.0
11/17/2022 06:00	4,862.4	62.7	4,879.3	104,046.0	507.7	0.6	0.3	1.0
11/17/2022 07:00	5,023.1	348.6	5,371.7	104,046.0	558.9	0.7	0.3	1.1
11/17/2022 08:00	3,479.1	0.0	3,479.1	104,046.0	362.0	0.4	0.2	0.7
11/17/2022 09:00	4,622.2	2.5	4,622.3	104,046.0	480.9	0.6	0.3	1.0
11/17/2022 10:00	4,932.3	495.8	5,428.1	104,046.0	564.8	0.7	0.3	1.1
11/17/2022 11:00	4,737.5	68.2	4,756.6	104,046.0	494.9	0.6	0.3	1.0
11/17/2022 12:00	4,812.4	6.2	4,812.7	104,046.0	500.7	0.6	0.3	1.0
11/17/2022 13:00	4,789.8	562.0	5,351.8	104,046.0	556.8	0.7	0.3	1.1
11/17/2022 14:00	4,765.9	440.6	5,206.5	104,046.0	541.7	0.7	0.3	1.1
11/17/2022 15:00	4,779.6	740.5	5,520.1	104,046.0	574.3	0.7	0.3	1.1
11/17/2022 16:00	4,785.3	889.0	5,674.3	104,046.0	590.4	0.7	0.4	1.2
11/17/2022 17:00	4,818.2	1,041.1	5,859.3	104,046.0	609.6	0.7	0.4	1.2
11/17/2022 18:00	4,843.1	1,019.3	5,862.4	104,046.0	610.0	0.7	0.4	1.2
11/17/2022 19:00	4,871.5	1,018.2	5,889.7	104,046.0	612.8	0.7	0.4	1.2
11/17/2022 20:00	4,914.5	867.5	5,782.0	104,046.0	601.6	0.7	0.4	1.2
11/17/2022 21:00	4,927.9	663.4	5,591.3	104,046.0	581.8	0.7	0.3	1.2
11/17/2022 22:00	4,966.6	551.1	5,517.7	104,046.0	574.1	0.7	0.3	1.1
11/17/2022 23:00	4,981.4	477.2	5,458.6	104,046.0	567.9	0.7	0.3	1.1
Average/Sum#:	4,774.6	385.6	5,155.9	104,046.0	536.5	0.6	0.3	1.1
Minimum:	3,479.1	0.0	3,479.1	104,046.0	362.0	0.4	0.2	0.7
Maximum:	5,023.1	1,041.1	5,889.7	104,046.0	612.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2022 00:00	4,992.6	783.6	5,776.2	104,046.0	601.0	0.7	0.4	1.2
11/18/2022 01:00	4,979.2	630.5	5,609.7	104,046.0	583.7	0.7	0.4	1.2
11/18/2022 02:00	4,981.2	669.5	5,650.7	104,046.0	587.9	0.7	0.4	1.2
11/18/2022 03:00	4,985.4	893.5	5,878.9	104,046.0	611.7	0.7	0.4	1.2
11/18/2022 04:00	4,991.6	969.4	5,961.0	104,046.0	620.2	0.7	0.4	1.2
11/18/2022 05:00	4,998.0	1,156.3	6,154.3	104,046.0	640.3	0.8	0.4	1.3
11/18/2022 06:00	4,990.7	1,789.2	6,779.9	104,046.0	705.4	0.8	0.4	1.4
11/18/2022 07:00	5,004.3	1,091.4	6,095.7	104,046.0	634.2	0.8	0.4	1.3
11/18/2022 08:00	4,975.5	875.7	5,851.2	104,046.0	608.8	0.7	0.4	1.2
11/18/2022 09:00	4,945.7	717.6	5,663.3	104,046.0	589.2	0.7	0.4	1.2
11/18/2022 10:00	4,899.5	599.4	5,498.9	104,046.0	572.1	0.7	0.3	1.1
11/18/2022 11:00	4,843.6	543.2	5,386.8	104,046.0	560.5	0.7	0.3	1.1
11/18/2022 12:00	4,790.8	465.1	5,255.9	104,046.0	546.9	0.7	0.3	1.1
11/18/2022 13:00	4,752.5	526.4	5,278.9	104,046.0	549.2	0.7	0.3	1.1
11/18/2022 14:00	4,724.9	557.4	5,282.3	104,046.0	549.6	0.7	0.3	1.1
11/18/2022 15:00	4,724.9	750.2	5,475.1	104,046.0	569.7	0.7	0.3	1.1
11/18/2022 16:00	4,742.5	1,199.9	5,942.4	104,046.0	618.3	0.7	0.4	1.2
11/18/2022 17:00	4,796.6	1,327.7	6,124.3	104,046.0	637.2	0.8	0.4	1.3
11/18/2022 18:00	4,867.2	1,250.3	6,117.5	104,046.0	636.5	0.8	0.4	1.3
11/18/2022 19:00	4,884.0	1,099.2	5,983.2	104,046.0	622.5	0.7	0.4	1.2
11/18/2022 20:00	4,888.7	1,184.2	6,072.9	104,046.0	631.9	0.8	0.4	1.3
11/18/2022 21:00	4,927.8	1,165.3	6,093.1	104,046.0	634.0	0.8	0.4	1.3
11/18/2022 22:00	4,927.8	1,051.7	5,979.5	104,046.0	622.1	0.7	0.4	1.2
11/18/2022 23:00	4,950.3	887.0	5,837.3	104,046.0	607.3	0.7	0.4	1.2
Average/Sum#:	4,898.6	924.3	5,822.9	104,046.0	605.8	0.7	0.4	1.2
Minimum:	4,724.9	465.1	5,255.9	104,046.0	546.9	0.7	0.3	1.1
Maximum:	5,004.3	1,789.2	6,779.9	104,046.0	705.4	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2022 00:00	4,950.9	591.1	5,542.0	104,046.0	576.6	0.7	0.3	1.2
11/19/2022 01:00	4,964.0	563.6	5,527.6	104,046.0	575.1	0.7	0.3	1.2
11/19/2022 02:00	4,983.0	494.5	5,477.5	104,046.0	569.9	0.7	0.3	1.1
11/19/2022 03:00	5,005.5	366.0	5,371.5	104,046.0	558.9	0.7	0.3	1.1
11/19/2022 04:00	5,020.2	666.4	5,686.6	104,046.0	591.7	0.7	0.4	1.2
11/19/2022 05:00	5,028.9	849.2	5,878.1	104,046.0	611.6	0.7	0.4	1.2
11/19/2022 06:00	5,030.2	994.1	6,024.3	104,046.0	626.8	0.8	0.4	1.3
11/19/2022 07:00	5,028.8	920.5	5,949.3	104,046.0	619.0	0.7	0.4	1.2
11/19/2022 08:00	4,030.0	79.5	4,048.3	104,046.0	421.2	0.5	0.3	0.9
11/19/2022 09:00	2,987.2	0.0	2,987.2	104,046.0	310.8	0.4	0.2	0.6
11/19/2022 10:00	3,028.0	0.0	3,028.0	104,046.0	315.1	0.4	0.2	0.6
11/19/2022 11:00	3,025.9	0.0	3,025.9	104,046.0	314.8	0.4	0.2	0.6
11/19/2022 12:00	3,023.2	0.0	3,023.2	104,046.0	314.6	0.4	0.2	0.6
11/19/2022 13:00	3,019.0	0.0	3,019.0	104,046.0	314.1	0.4	0.2	0.6
11/19/2022 14:00	2,934.5	0.0	2,934.5	104,046.0	305.3	0.4	0.2	0.6
11/19/2022 15:00	3,573.8	17.7	3,575.2	104,046.0	372.0	0.4	0.2	0.7
11/19/2022 16:00	4,812.0	871.5	5,683.5	104,046.0	591.3	0.7	0.4	1.2
11/19/2022 17:00	4,837.3	705.7	5,543.0	104,046.0	576.7	0.7	0.3	1.2
11/19/2022 18:00	4,855.9	688.9	5,544.8	104,046.0	576.9	0.7	0.3	1.2
11/19/2022 19:00	4,907.3	986.5	5,893.8	104,046.0	613.2	0.7	0.4	1.2
11/19/2022 20:00	4,925.8	1,115.5	6,041.3	104,046.0	628.6	0.8	0.4	1.3
11/19/2022 21:00	4,971.7	1,068.2	6,039.9	104,046.0	628.4	0.8	0.4	1.3
11/19/2022 22:00	4,984.3	1,071.3	6,055.6	104,046.0	630.1	0.8	0.4	1.3
11/19/2022 23:00	5,033.4	1,074.7	6,108.1	104,046.0	635.5	0.8	0.4	1.3
Average/Sum#:	4,373.4	546.9	4,917.0	104,046.0	511.6	0.6	0.3	1.0
Minimum:	2,934.5	0.0	2,934.5	104,046.0	305.3	0.4	0.2	0.6
Maximum:	5,033.4	1,115.5	6,108.1	104,046.0	635.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2022 00:00	5,027.0	1,075.8	6,102.8	104,046.0	635.0	0.8	0.4	1.3
11/20/2022 01:00	5,040.4	1,077.2	6,117.6	104,046.0	636.5	0.8	0.4	1.3
11/20/2022 02:00	5,045.4	1,078.6	6,124.0	104,046.0	637.2	0.8	0.4	1.3
11/20/2022 03:00	5,034.7	1,075.3	6,110.0	104,046.0	635.7	0.8	0.4	1.3
11/20/2022 04:00	5,040.6	1,076.5	6,117.1	104,046.0	636.5	0.8	0.4	1.3
11/20/2022 05:00	5,043.3	993.5	6,036.8	104,046.0	628.1	0.8	0.4	1.3
11/20/2022 06:00	5,023.4	866.9	5,890.3	104,046.0	612.9	0.7	0.4	1.2
11/20/2022 07:00	5,038.8	520.1	5,558.9	104,046.0	578.4	0.7	0.3	1.2
11/20/2022 08:00	4,830.2	4.6	4,831.4	104,046.0	502.7	0.6	0.3	1.0
11/20/2022 09:00	4,997.1	0.3	4,997.1	104,046.0	519.9	0.6	0.3	1.0
11/20/2022 10:00	4,919.2	7.5	4,926.7	104,046.0	512.6	0.6	0.3	1.0
11/20/2022 11:00	4,874.9	6.0	4,880.9	104,046.0	507.8	0.6	0.3	1.0
11/20/2022 12:00	4,658.8	1.2	4,659.1	104,046.0	484.8	0.6	0.3	1.0
11/20/2022 13:00	4,809.5	465.6	5,265.8	104,046.0	547.9	0.7	0.3	1.1
11/20/2022 14:00	4,561.5	102.0	4,589.0	104,046.0	477.5	0.6	0.3	1.0
11/20/2022 15:00	4,265.8	122.8	4,300.2	104,046.0	447.4	0.5	0.3	0.9
11/20/2022 16:00	4,801.5	800.4	5,601.9	104,046.0	582.9	0.7	0.3	1.2
11/20/2022 17:00	4,827.9	748.1	5,576.0	104,046.0	580.2	0.7	0.3	1.2
11/20/2022 18:00	4,865.6	622.1	5,487.7	104,046.0	571.0	0.7	0.3	1.1
11/20/2022 19:00	4,911.2	601.9	5,513.1	104,046.0	573.6	0.7	0.3	1.1
11/20/2022 20:00	4,941.9	562.9	5,504.8	104,046.0	572.8	0.7	0.3	1.1
11/20/2022 21:00	4,974.4	409.7	5,384.1	104,046.0	560.2	0.7	0.3	1.1
11/20/2022 22:00	4,985.1	374.9	5,360.0	104,046.0	557.7	0.7	0.3	1.1
11/20/2022 23:00	5,012.9	262.7	5,275.6	104,046.0	548.9	0.7	0.3	1.1
Average/Sum#:	4,897.1	535.7	5,425.5	104,046.0	564.5	0.7	0.3	1.1
Minimum:	4,265.8	0.3	4,300.2	104,046.0	447.4	0.5	0.3	0.9
Maximum:	5,045.4	1,078.6	6,124.0	104,046.0	637.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	5,027.9	482.3	5,510.2	104,046.0	573.3	0.7	0.3	1.1
11/21/2022 01:00	5,035.2	330.9	5,366.1	104,046.0	558.3	0.7	0.3	1.1
11/21/2022 02:00	5,039.0	307.4	5,346.4	104,046.0	556.3	0.7	0.3	1.1
11/21/2022 03:00	5,036.2	480.5	5,516.7	104,046.0	574.0	0.7	0.3	1.1
11/21/2022 04:00	5,062.9	788.3	5,851.2	104,046.0	608.8	0.7	0.4	1.2
11/21/2022 05:00	5,067.8	781.4	5,849.2	104,046.0	608.6	0.7	0.4	1.2
11/21/2022 06:00	5,068.7	1,020.5	6,089.2	104,046.0	633.6	0.8	0.4	1.3
11/21/2022 07:00	5,057.8	335.5	5,393.3	104,046.0	561.2	0.7	0.3	1.1
11/21/2022 08:00	3,497.0	0.0	3,497.0	104,046.0	363.8	0.4	0.2	0.7
11/21/2022 09:00	2,994.0	0.0	2,994.0	104,046.0	311.5	0.4	0.2	0.6
11/21/2022 10:00	3,008.5	0.0	3,008.5	104,046.0	313.0	0.4	0.2	0.6
11/21/2022 11:00	3,028.5	0.0	3,028.5	104,046.0	315.1	0.4	0.2	0.6
11/21/2022 12:00	3,100.7	0.0	3,100.7	104,046.0	322.6	0.4	0.2	0.6
11/21/2022 13:00	2,994.7	0.0	2,994.7	104,046.0	311.6	0.4	0.2	0.6
11/21/2022 14:00	4,433.6	2.6	4,433.7	104,046.0	461.3	0.6	0.3	0.9
11/21/2022 15:00	4,769.8	826.9	5,489.2	104,046.0	571.1	0.7	0.3	1.2
11/21/2022 16:00	4,782.2	792.2	5,574.4	104,046.0	580.0	0.7	0.3	1.2
11/21/2022 17:00	4,839.9	748.9	5,588.8	104,046.0	581.5	0.7	0.3	1.2
11/21/2022 18:00	4,866.6	669.4	5,536.0	104,046.0	576.0	0.7	0.3	1.2
11/21/2022 19:00	4,893.0	652.5	5,545.5	104,046.0	577.0	0.7	0.3	1.2
11/21/2022 20:00	4,935.2	657.5	5,592.7	104,046.0	581.9	0.7	0.3	1.2
11/21/2022 21:00	4,956.1	746.8	5,702.9	104,046.0	593.4	0.7	0.4	1.2
11/21/2022 22:00	4,969.6	669.7	5,639.3	104,046.0	586.7	0.7	0.4	1.2
11/21/2022 23:00	4,973.7	406.0	5,379.7	104,046.0	559.7	0.7	0.3	1.1
Average/Sum#:	4,476.6	445.8	4,917.8	104,046.0	511.7	0.6	0.3	1.0
Minimum:	2,994.0	0.0	2,994.0	104,046.0	311.5	0.4	0.2	0.6
Maximum:	5,068.7	1,020.5	6,089.2	104,046.0	633.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	4,903.0	0.2	4,903.0	104,046.0	510.1	0.6	0.3	1.0
11/22/2022 01:00	4,838.6	0.0	4,838.6	104,046.0	503.4	0.6	0.3	1.0
11/22/2022 02:00	4,799.1	0.0	4,799.1	104,046.0	499.3	0.6	0.3	1.0
11/22/2022 03:00	4,547.4	0.0	4,547.4	104,046.0	473.1	0.6	0.3	0.9
11/22/2022 04:00	4,644.7	0.0	4,644.7	104,046.0	483.3	0.6	0.3	1.0
11/22/2022 05:00	4,749.0	0.0	4,749.0	104,046.0	494.1	0.6	0.3	1.0
11/22/2022 06:00	4,946.7	0.0	4,946.7	104,046.0	514.7	0.6	0.3	1.0
11/22/2022 07:00	3,650.1	0.0	3,650.1	104,046.0	379.8	0.5	0.2	0.8
11/22/2022 08:00	4,210.2	5.8	4,212.2	104,046.0	438.3	0.5	0.3	0.9
11/22/2022 09:00	4,961.2	569.6	5,530.8	104,046.0	575.5	0.7	0.3	1.2
11/22/2022 10:00	4,862.5	62.3	4,879.3	104,046.0	507.7	0.6	0.3	1.0
11/22/2022 11:00	4,881.3	375.2	5,245.2	104,046.0	545.7	0.7	0.3	1.1
11/22/2022 12:00	4,860.7	726.4	5,587.1	104,046.0	581.3	0.7	0.3	1.2
11/22/2022 13:00	4,822.9	799.2	5,622.1	104,046.0	585.0	0.7	0.4	1.2
11/22/2022 14:00	4,793.6	705.3	5,498.9	104,046.0	572.1	0.7	0.3	1.1
11/22/2022 15:00	4,785.3	568.6	5,353.9	104,046.0	557.1	0.7	0.3	1.1
11/22/2022 16:00	4,834.5	535.4	5,369.9	104,046.0	558.7	0.7	0.3	1.1
11/22/2022 17:00	4,837.4	368.2	5,205.6	104,046.0	541.6	0.7	0.3	1.1
11/22/2022 18:00	4,869.8	317.2	5,187.0	104,046.0	539.7	0.6	0.3	1.1
11/22/2022 19:00	4,907.9	299.2	5,207.1	104,046.0	541.8	0.7	0.3	1.1
11/22/2022 20:00	4,914.7	377.3	5,292.0	104,046.0	550.6	0.7	0.3	1.1
11/22/2022 21:00	4,635.5	137.3	4,706.9	104,046.0	489.7	0.6	0.3	1.0
11/22/2022 22:00	3,625.9	0.0	3,625.9	104,046.0	377.3	0.5	0.2	0.8
11/22/2022 23:00	3,121.9	0.0	3,121.9	104,046.0	324.8	0.4	0.2	0.6
Average/Sum#:	4,625.2	243.6	4,863.5	104,046.0	506.0	0.6	0.3	1.0
Minimum:	3,121.9	0.0	3,121.9	104,046.0	324.8	0.4	0.2	0.6
Maximum:	4,961.2	799.2	5,622.1	104,046.0	585.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2022 00:00	4,145.0	0.0	4,145.0	104,046.0	431.3	0.5	0.3	0.9
11/23/2022 01:00	3,767.1	0.0	3,767.1	104,046.0	392.0	0.5	0.2	0.8
11/23/2022 02:00	4,046.6	0.0	4,046.6	104,046.0	421.0	0.5	0.3	0.8
11/23/2022 03:00	4,183.4	0.0	4,183.4	104,046.0	435.3	0.5	0.3	0.9
11/23/2022 04:00	4,307.4	0.0	4,307.4	104,046.0	448.2	0.5	0.3	0.9
11/23/2022 05:00	4,574.8	0.1	4,574.8	104,046.0	476.0	0.6	0.3	1.0
11/23/2022 06:00	4,601.0	0.0	4,601.0	104,046.0	478.7	0.6	0.3	1.0
11/23/2022 07:00	3,702.8	0.0	3,702.8	104,046.0	385.3	0.5	0.2	0.8
11/23/2022 08:00	3,172.5	0.0	3,172.5	104,046.0	330.1	0.4	0.2	0.7
11/23/2022 09:00	3,421.5	0.0	3,421.5	104,046.0	356.0	0.4	0.2	0.7
11/23/2022 10:00	3,590.2	0.0	3,590.2	104,046.0	373.5	0.4	0.2	0.7
11/23/2022 11:00	4,604.7	119.2	4,661.9	104,046.0	485.1	0.6	0.3	1.0
11/23/2022 12:00	4,838.2	416.0	5,254.2	104,046.0	546.7	0.7	0.3	1.1
11/23/2022 13:00	4,488.0	222.1	4,603.5	104,046.0	479.0	0.6	0.3	1.0
11/23/2022 14:00	2,978.2	0.0	2,978.2	104,046.0	309.9	0.4	0.2	0.6
11/23/2022 15:00	3,551.4	40.3	3,558.7	104,046.0	370.3	0.4	0.2	0.7
11/23/2022 16:00	4,757.9	724.7	5,482.6	104,046.0	570.4	0.7	0.3	1.1
11/23/2022 17:00	4,796.5	676.8	5,473.3	104,046.0	569.5	0.7	0.3	1.1
11/23/2022 18:00	4,843.2	401.8	5,245.0	104,046.0	545.7	0.7	0.3	1.1
11/23/2022 19:00	4,865.9	327.7	5,193.6	104,046.0	540.4	0.6	0.3	1.1
11/23/2022 20:00	4,892.1	423.2	5,315.3	104,046.0	553.0	0.7	0.3	1.1
11/23/2022 21:00	4,918.5	602.0	5,520.5	104,046.0	574.4	0.7	0.3	1.1
11/23/2022 22:00	4,942.8	566.0	5,508.8	104,046.0	573.2	0.7	0.3	1.1
11/23/2022 23:00	4,947.9	419.4	5,367.3	104,046.0	558.4	0.7	0.3	1.1
Average/Sum#:	4,289.1	205.8	4,486.5	104,046.0	466.8	0.6	0.3	0.9
Minimum:	2,978.2	0.0	2,978.2	104,046.0	309.9	0.4	0.2	0.6
Maximum:	4,947.9	724.7	5,520.5	104,046.0	574.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2022 00:00	4,956.9	519.8	5,476.7	104,046.0	569.8	0.7	0.3	1.1
11/24/2022 01:00	4,975.5	404.1	5,379.6	104,046.0	559.7	0.7	0.3	1.1
11/24/2022 02:00	4,523.5	0.6	4,523.5	104,046.0	470.7	0.6	0.3	0.9
11/24/2022 03:00	4,598.9	0.0	4,598.9	104,046.0	478.5	0.6	0.3	1.0
11/24/2022 04:00	4,598.4	0.0	4,598.4	104,046.0	478.4	0.6	0.3	1.0
11/24/2022 05:00	4,807.6	0.0	4,807.6	104,046.0	500.2	0.6	0.3	1.0
11/24/2022 06:00	4,943.4	57.4	4,957.8	104,046.0	515.8	0.6	0.3	1.0
11/24/2022 07:00	5,022.9	649.9	5,672.8	104,046.0	590.2	0.7	0.4	1.2
11/24/2022 08:00	4,975.7	478.7	5,454.4	104,046.0	567.5	0.7	0.3	1.1
11/24/2022 09:00	4,911.2	598.4	5,509.6	104,046.0	573.3	0.7	0.3	1.1
11/24/2022 10:00	4,873.0	652.1	5,525.1	104,046.0	574.9	0.7	0.3	1.2
11/24/2022 11:00	4,829.6	453.8	5,283.4	104,046.0	549.7	0.7	0.3	1.1
11/24/2022 12:00	4,792.9	482.2	5,275.1	104,046.0	548.9	0.7	0.3	1.1
11/24/2022 13:00	4,762.8	496.0	5,258.8	104,046.0	547.2	0.7	0.3	1.1
11/24/2022 14:00	3,460.9	2.4	3,460.9	104,046.0	360.1	0.4	0.2	0.7
11/24/2022 15:00	3,792.0	195.1	3,860.3	104,046.0	401.6	0.5	0.2	0.8
11/24/2022 16:00	4,770.7	744.2	5,514.9	104,046.0	573.8	0.7	0.3	1.1
11/24/2022 17:00	4,803.2	497.7	5,300.9	104,046.0	551.5	0.7	0.3	1.1
11/24/2022 18:00	4,844.2	380.6	5,224.8	104,046.0	543.6	0.7	0.3	1.1
11/24/2022 19:00	4,874.0	340.5	5,214.5	104,046.0	542.5	0.7	0.3	1.1
11/24/2022 20:00	4,891.3	312.2	5,203.5	104,046.0	541.4	0.6	0.3	1.1
11/24/2022 21:00	4,908.6	300.9	5,209.5	104,046.0	542.0	0.7	0.3	1.1
11/24/2022 22:00	4,925.9	328.5	5,254.4	104,046.0	546.7	0.7	0.3	1.1
11/24/2022 23:00	4,957.3	204.5	5,161.8	104,046.0	537.1	0.6	0.3	1.1
Average/Sum#:	4,741.7	337.5	5,072.0	104,046.0	527.7	0.7	0.3	1.1
Minimum:	3,460.9	0.0	3,460.9	104,046.0	360.1	0.4	0.2	0.7
Maximum:	5,022.9	744.2	5,672.8	104,046.0	590.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2022 00:00	4,974.0	189.4	5,163.4	104,046.0	537.2	0.6	0.3	1.1
11/25/2022 01:00	4,989.7	157.5	5,147.2	104,046.0	535.5	0.6	0.3	1.1
11/25/2022 02:00	5,002.2	122.1	5,124.3	104,046.0	533.2	0.6	0.3	1.1
11/25/2022 03:00	5,004.3	218.6	5,222.9	104,046.0	543.4	0.7	0.3	1.1
11/25/2022 04:00	4,993.7	396.2	5,389.9	104,046.0	560.8	0.7	0.3	1.1
11/25/2022 05:00	5,031.3	392.8	5,424.1	104,046.0	564.4	0.7	0.3	1.1
11/25/2022 06:00	5,023.5	502.0	5,525.5	104,046.0	574.9	0.7	0.3	1.1
11/25/2022 07:00	5,034.3	314.8	5,349.1	104,046.0	556.6	0.7	0.3	1.1
11/25/2022 08:00	5,008.7	82.0	5,090.7	104,046.0	529.7	0.6	0.3	1.1
11/25/2022 09:00	3,467.1	0.0	3,467.1	104,046.0	360.7	0.4	0.2	0.7
11/25/2022 10:00	2,945.8	0.0	2,945.8	104,046.0	306.5	0.4	0.2	0.6
11/25/2022 11:00	2,886.8	0.0	2,886.8	104,046.0	300.4	0.4	0.2	0.6
11/25/2022 12:00	2,878.5	0.0	2,878.5	104,046.0	299.5	0.4	0.2	0.6
11/25/2022 13:00	2,882.8	0.0	2,882.8	104,046.0	299.9	0.4	0.2	0.6
11/25/2022 14:00	2,931.9	0.0	2,931.9	104,046.0	305.1	0.4	0.2	0.6
11/25/2022 15:00	3,583.3	25.8	3,587.2	104,046.0	373.2	0.5	0.2	0.8
11/25/2022 16:00	4,753.4	595.9	5,349.3	104,046.0	556.6	0.7	0.3	1.1
11/25/2022 17:00	4,801.2	565.8	5,367.0	104,046.0	558.4	0.7	0.3	1.1
11/25/2022 18:00	4,838.3	388.0	5,226.3	104,046.0	543.8	0.7	0.3	1.1
11/25/2022 19:00	4,878.3	303.2	5,181.5	104,046.0	539.1	0.6	0.3	1.1
11/25/2022 20:00	4,913.3	279.8	5,193.1	104,046.0	540.3	0.6	0.3	1.1
11/25/2022 21:00	4,911.9	291.8	5,203.7	104,046.0	541.4	0.7	0.3	1.1
11/25/2022 22:00	4,912.1	473.2	5,385.3	104,046.0	560.3	0.7	0.3	1.1
11/25/2022 23:00	4,931.5	384.9	5,316.4	104,046.0	553.2	0.7	0.3	1.1
Average/Sum#:	4,399.1	236.8	4,635.0	104,046.0	482.3	0.6	0.3	1.0
Minimum:	2,878.5	0.0	2,878.5	104,046.0	299.5	0.4	0.2	0.6
Maximum:	5,034.3	595.9	5,525.5	104,046.0	574.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2022 00:00	4,956.9	571.9	5,528.8	104,046.0	575.2	0.7	0.3	1.1
11/26/2022 01:00	4,981.9	523.4	5,505.3	104,046.0	572.8	0.7	0.3	1.1
11/26/2022 02:00	4,986.4	540.2	5,526.6	104,046.0	575.0	0.7	0.3	1.2
11/26/2022 03:00	4,967.8	549.9	5,517.7	104,046.0	574.1	0.7	0.3	1.1
11/26/2022 04:00	4,960.2	551.9	5,512.1	104,046.0	573.5	0.7	0.3	1.1
11/26/2022 05:00	4,959.8	909.4	5,869.2	104,046.0	610.7	0.7	0.4	1.2
11/26/2022 06:00	4,977.7	1,025.5	6,003.2	104,046.0	624.6	0.7	0.4	1.2
11/26/2022 07:00	4,985.3	534.6	5,519.9	104,046.0	574.3	0.7	0.3	1.1
11/26/2022 08:00	4,825.5	77.3	4,858.7	104,046.0	505.5	0.6	0.3	1.0
11/26/2022 09:00	4,925.4	473.7	5,399.1	104,046.0	561.8	0.7	0.3	1.1
11/26/2022 10:00	4,076.8	1.4	4,076.8	104,046.0	424.2	0.5	0.3	0.8
11/26/2022 11:00	2,946.6	0.0	2,946.6	104,046.0	306.6	0.4	0.2	0.6
11/26/2022 12:00	2,968.3	0.0	2,968.3	104,046.0	308.8	0.4	0.2	0.6
11/26/2022 13:00	2,871.3	0.0	2,871.3	104,046.0	298.7	0.4	0.2	0.6
11/26/2022 14:00	2,913.7	0.0	2,913.7	104,046.0	303.2	0.4	0.2	0.6
11/26/2022 15:00	3,822.3	0.0	3,822.3	104,046.0	397.7	0.5	0.2	0.8
11/26/2022 16:00	4,735.1	577.5	5,226.0	104,046.0	543.7	0.7	0.3	1.1
11/26/2022 17:00	4,753.5	568.1	5,321.6	104,046.0	553.7	0.7	0.3	1.1
11/26/2022 18:00	4,802.3	435.9	5,238.2	104,046.0	545.0	0.7	0.3	1.1
11/26/2022 19:00	4,862.4	357.5	5,219.9	104,046.0	543.1	0.7	0.3	1.1
11/26/2022 20:00	4,867.6	530.5	5,398.1	104,046.0	561.7	0.7	0.3	1.1
11/26/2022 21:00	4,903.6	556.8	5,460.4	104,046.0	568.1	0.7	0.3	1.1
11/26/2022 22:00	4,922.2	317.6	5,239.8	104,046.0	545.2	0.7	0.3	1.1
11/26/2022 23:00	4,921.4	341.3	5,262.7	104,046.0	547.6	0.7	0.3	1.1
Average/Sum#:	4,495.6	393.5	4,883.6	104,046.0	508.1	0.6	0.3	1.0
Minimum:	2,871.3	0.0	2,871.3	104,046.0	298.7	0.4	0.2	0.6
Maximum:	4,986.4	1,025.5	6,003.2	104,046.0	624.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2022 00:00	4,940.7	646.6	5,587.3	104,046.0	581.3	0.7	0.3	1.2
11/27/2022 01:00	4,957.7	478.0	5,435.7	104,046.0	565.6	0.7	0.3	1.1
11/27/2022 02:00	4,952.6	295.9	5,248.5	104,046.0	546.1	0.7	0.3	1.1
11/27/2022 03:00	4,957.7	566.3	5,524.0	104,046.0	574.8	0.7	0.3	1.1
11/27/2022 04:00	4,952.3	578.0	5,530.3	104,046.0	575.4	0.7	0.3	1.2
11/27/2022 05:00	4,969.1	387.8	5,356.9	104,046.0	557.4	0.7	0.3	1.1
11/27/2022 06:00	4,976.0	519.1	5,495.1	104,046.0	571.7	0.7	0.3	1.1
11/27/2022 07:00	4,566.7	140.2	4,639.6	104,046.0	482.7	0.6	0.3	1.0
11/27/2022 08:00	2,972.6	0.0	2,972.6	104,046.0	309.3	0.4	0.2	0.6
11/27/2022 09:00	2,939.4	0.0	2,939.4	104,046.0	305.8	0.4	0.2	0.6
11/27/2022 10:00	2,996.9	0.0	2,996.9	104,046.0	311.8	0.4	0.2	0.6
11/27/2022 11:00	2,939.9	0.0	2,939.9	104,046.0	305.9	0.4	0.2	0.6
11/27/2022 12:00	2,872.3	0.0	2,872.3	104,046.0	298.9	0.4	0.2	0.6
11/27/2022 13:00	2,870.7	0.0	2,870.7	104,046.0	298.7	0.4	0.2	0.6
11/27/2022 14:00	2,869.0	0.0	2,869.0	104,046.0	298.5	0.4	0.2	0.6
11/27/2022 15:00	4,149.8	166.8	4,233.2	104,046.0	440.4	0.5	0.3	0.9
11/27/2022 16:00	4,796.8	584.1	5,380.9	104,046.0	559.9	0.7	0.3	1.1
11/27/2022 17:00	4,823.2	713.7	5,536.9	104,046.0	576.1	0.7	0.3	1.2
11/27/2022 18:00	4,852.6	664.9	5,517.5	104,046.0	574.1	0.7	0.3	1.1
11/27/2022 19:00	4,861.3	597.7	5,459.0	104,046.0	568.0	0.7	0.3	1.1
11/27/2022 20:00	4,874.5	483.0	5,357.5	104,046.0	557.4	0.7	0.3	1.1
11/27/2022 21:00	4,886.7	788.3	5,675.0	104,046.0	590.5	0.7	0.4	1.2
11/27/2022 22:00	4,902.3	388.8	5,291.1	104,046.0	550.5	0.7	0.3	1.1
11/27/2022 23:00	4,902.8	298.2	5,201.0	104,046.0	541.1	0.6	0.3	1.1
Average/Sum#:	4,282.7	345.7	4,622.1	104,046.0	480.9	0.6	0.3	1.0
Minimum:	2,869.0	0.0	2,869.0	104,046.0	298.5	0.4	0.2	0.6
Maximum:	4,976.0	788.3	5,675.0	104,046.0	590.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	4,900.2	477.9	5,378.1	104,046.0	559.6	0.7	0.3	1.1
11/28/2022 01:00	4,919.2	346.1	5,265.3	104,046.0	547.8	0.7	0.3	1.1
11/28/2022 02:00	4,950.3	204.2	5,154.5	104,046.0	536.3	0.6	0.3	1.1
11/28/2022 03:00	4,936.7	262.1	5,198.8	104,046.0	540.9	0.6	0.3	1.1
11/28/2022 04:00	4,971.4	191.0	5,162.4	104,046.0	537.1	0.6	0.3	1.1
11/28/2022 05:00	4,976.0	326.7	5,302.7	104,046.0	551.7	0.7	0.3	1.1
11/28/2022 06:00	4,976.0	764.2	5,740.2	104,046.0	597.2	0.7	0.4	1.2
11/28/2022 07:00	4,965.6	826.6	5,792.2	104,046.0	602.7	0.7	0.4	1.2
11/28/2022 08:00	4,933.4	263.9	5,197.3	104,046.0	540.8	0.7	0.3	1.1
11/28/2022 09:00	3,998.0	72.3	4,019.7	104,046.0	418.2	0.5	0.3	0.8
11/28/2022 10:00	3,008.8	0.0	3,008.8	104,046.0	313.1	0.4	0.2	0.6
11/28/2022 11:00	2,936.7	0.0	2,936.7	104,046.0	305.6	0.4	0.2	0.6
11/28/2022 12:00	2,870.5	0.0	2,870.5	104,046.0	298.7	0.4	0.2	0.6
11/28/2022 13:00	2,875.6	0.0	2,875.6	104,046.0	299.2	0.4	0.2	0.6
11/28/2022 14:00	2,890.8	0.0	2,890.8	104,046.0	300.8	0.4	0.2	0.6
11/28/2022 15:00	3,798.9	228.6	3,878.9	104,046.0	403.6	0.5	0.3	0.8
11/28/2022 16:00	4,768.0	584.2	5,352.2	104,046.0	556.9	0.7	0.3	1.1
11/28/2022 17:00	4,817.7	524.1	5,341.8	104,046.0	555.8	0.7	0.3	1.1
11/28/2022 18:00	4,854.0	357.9	5,211.9	104,046.0	542.3	0.7	0.3	1.1
11/28/2022 19:00	4,878.2	336.3	5,214.5	104,046.0	542.5	0.7	0.3	1.1
11/28/2022 20:00	4,899.1	472.4	5,371.5	104,046.0	558.9	0.7	0.3	1.1
11/28/2022 21:00	4,896.1	768.8	5,664.9	104,046.0	589.4	0.7	0.4	1.2
11/28/2022 22:00	4,919.8	369.1	5,288.9	104,046.0	550.3	0.7	0.3	1.1
11/28/2022 23:00	4,952.9	198.5	5,151.4	104,046.0	536.0	0.6	0.3	1.1
Average/Sum#:	4,412.2	315.6	4,719.6	104,046.0	491.1	0.6	0.3	1.0
Minimum:	2,870.5	0.0	2,870.5	104,046.0	298.7	0.4	0.2	0.6
Maximum:	4,976.0	826.6	5,792.2	104,046.0	602.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2022 00:00	4,836.2	0.5	4,836.2	104,046.0	503.2	0.6	0.3	1.0
11/29/2022 01:00	4,915.4	0.2	4,915.4	104,046.0	511.4	0.6	0.3	1.0
11/29/2022 02:00	4,908.9	0.0	4,908.9	104,046.0	510.8	0.6	0.3	1.0
11/29/2022 03:00	4,678.9	0.0	4,678.9	104,046.0	486.8	0.6	0.3	1.0
11/29/2022 04:00	4,738.4	0.0	4,738.4	104,046.0	493.0	0.6	0.3	1.0
11/29/2022 05:00	4,966.0	0.0	4,966.0	104,046.0	516.7	0.6	0.3	1.0
11/29/2022 06:00	4,959.4	114.7	4,996.1	104,046.0	519.8	0.6	0.3	1.1
11/29/2022 07:00	4,945.1	1,315.6	6,260.7	104,046.0	651.4	0.8	0.4	1.3
11/29/2022 08:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/29/2022 09:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/29/2022 10:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
11/29/2022 11:00	951.1	0.0	951.1	104,046.0	99.0	0.0	0.0	0.0
11/29/2022 12:00	3,807.7	0.0	3,807.7	104,046.0	396.2	0.6	0.3	1.0
11/29/2022 13:00	4,761.1	0.0	4,761.1	104,046.0	495.4	0.6	0.3	1.0
11/29/2022 14:00	4,820.1	1,199.7	5,995.8	104,046.0	623.8	0.8	0.4	1.3
11/29/2022 15:00	4,813.7	1,187.2	6,000.9	104,046.0	624.4	0.7	0.4	1.2
11/29/2022 16:00	4,816.2	1,272.2	6,088.4	104,046.0	633.5	0.8	0.4	1.3
11/29/2022 17:00	4,857.6	1,180.1	6,037.7	104,046.0	628.2	0.8	0.4	1.3
11/29/2022 18:00	4,896.5	1,148.5	6,045.0	104,046.0	629.0	0.8	0.4	1.3
11/29/2022 19:00	4,904.3	1,171.3	6,075.6	104,046.0	632.1	0.8	0.4	1.3
11/29/2022 20:00	4,916.4	1,182.7	6,099.1	104,046.0	634.6	0.8	0.4	1.3
11/29/2022 21:00	4,938.6	1,139.8	6,078.4	104,046.0	632.4	0.8	0.4	1.3
11/29/2022 22:00	4,951.2	1,044.1	5,995.3	104,046.0	623.8	0.7	0.4	1.2
11/29/2022 23:00	4,949.8	726.6	5,676.4	104,046.0	590.6	0.7	0.4	1.2
Average/Sum#:	4,634.9	604.0	5,234.0	104,046.0	544.6	0.7	0.4	1.2
Minimum:	951.1	0.0	951.1	104,046.0	99.0	0.6	0.3	1.0
Maximum:	4,966.0	1,315.6	6,260.7	104,046.0	651.4	0.8	0.4	1.3
%SI	12.50	12.50	12.50	0.00	12.50	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	4,935.5	1.4	4,935.5	104,046.0	513.5	0.6	0.3	1.0
11/30/2022 01:00	4,944.5	0.0	4,944.5	104,046.0	514.5	0.6	0.3	1.0
11/30/2022 02:00	4,958.8	0.0	4,958.8	104,046.0	515.9	0.6	0.3	1.0
11/30/2022 03:00	4,940.3	0.0	4,940.3	104,046.0	514.0	0.6	0.3	1.0
11/30/2022 04:00	4,937.5	0.0	4,937.5	104,046.0	513.7	0.6	0.3	1.0
11/30/2022 05:00	4,943.2	86.4	4,970.8	104,046.0	517.2	0.6	0.3	1.0
11/30/2022 06:00	4,973.7	1,141.8	6,115.5	104,046.0	636.3	0.8	0.4	1.3
11/30/2022 07:00	4,961.7	370.4	5,332.1	104,046.0	554.8	0.7	0.3	1.1
11/30/2022 08:00	3,986.1	46.0	3,998.5	104,046.0	416.0	0.5	0.3	0.8
11/30/2022 09:00	3,646.3	0.0	3,646.3	104,046.0	379.4	0.5	0.2	0.8
11/30/2022 10:00	3,010.1	0.0	3,010.1	104,046.0	313.2	0.4	0.2	0.6
11/30/2022 11:00	2,913.5	0.0	2,913.5	104,046.0	303.1	0.4	0.2	0.6
11/30/2022 12:00	2,902.6	0.0	2,902.6	104,046.0	302.0	0.4	0.2	0.6
11/30/2022 13:00	2,916.2	0.0	2,916.2	104,046.0	303.4	0.4	0.2	0.6
11/30/2022 14:00	4,085.9	0.0	4,085.9	104,046.0	425.1	0.5	0.3	0.9
11/30/2022 15:00	4,203.7	135.5	4,241.6	104,046.0	441.3	0.5	0.3	0.9
11/30/2022 16:00	4,817.3	733.2	5,550.5	104,046.0	577.5	0.7	0.3	1.2
11/30/2022 17:00	4,839.5	728.8	5,568.3	104,046.0	579.4	0.7	0.3	1.2
11/30/2022 18:00	4,852.7	707.9	5,560.6	104,046.0	578.6	0.7	0.3	1.2
11/30/2022 19:00	4,869.0	704.0	5,573.0	104,046.0	579.8	0.7	0.3	1.2
11/30/2022 20:00	4,876.9	639.0	5,515.9	104,046.0	573.9	0.7	0.3	1.1
11/30/2022 21:00	4,886.6	575.3	5,461.9	104,046.0	568.3	0.7	0.3	1.1
11/30/2022 22:00	4,852.1	262.1	5,053.9	104,046.0	525.8	0.6	0.3	1.1
11/30/2022 23:00	3,193.3	0.0	3,193.3	104,046.0	332.3	0.4	0.2	0.7
Average/Sum#:	4,352.0	255.5	4,597.0	104,046.0	478.3	0.6	0.3	1.0
Minimum:	2,902.6	0.0	2,902.6	104,046.0	302.0	0.4	0.2	0.6
Maximum:	4,973.7	1,141.8	6,115.5	104,046.0	636.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022 00:00	4,210.7	0.0	4,210.7	104,046.0	438.1	0.5	0.3	0.9
12/01/2022 01:00	4,194.1	0.0	4,194.1	104,046.0	436.4	0.5	0.3	0.9
12/01/2022 02:00	4,332.9	0.0	4,332.9	104,046.0	450.8	0.5	0.3	0.9
12/01/2022 03:00	4,382.7	0.0	4,382.7	104,046.0	456.0	0.5	0.3	0.9
12/01/2022 04:00	4,669.2	1.2	4,669.5	104,046.0	485.8	0.6	0.3	1.0
12/01/2022 05:00	4,881.0	507.1	5,347.5	104,046.0	556.4	0.7	0.3	1.1
12/01/2022 06:00	4,870.7	739.9	5,610.6	104,046.0	583.8	0.7	0.4	1.2
12/01/2022 07:00	4,867.6	399.1	5,266.7	104,046.0	548.0	0.7	0.3	1.1
12/01/2022 08:00	4,868.3	986.3	5,854.6	104,046.0	609.1	0.7	0.4	1.2
12/01/2022 09:00	4,880.1	1,364.1	6,244.2	104,046.0	649.7	0.8	0.4	1.3
12/01/2022 10:00	4,895.4	1,026.9	5,922.3	104,046.0	616.2	0.7	0.4	1.2
12/01/2022 11:00	4,895.8	938.4	5,834.2	104,046.0	607.0	0.7	0.4	1.2
12/01/2022 12:00	4,885.1	889.4	5,774.5	104,046.0	600.8	0.7	0.4	1.2
12/01/2022 13:00	4,877.6	1,095.3	5,972.9	104,046.0	621.5	0.7	0.4	1.2
12/01/2022 14:00	4,878.6	1,088.3	5,966.9	104,046.0	620.8	0.7	0.4	1.2
12/01/2022 15:00	4,879.1	642.2	5,521.3	104,046.0	574.5	0.7	0.3	1.1
12/01/2022 16:00	4,884.0	398.8	5,282.8	104,046.0	549.7	0.7	0.3	1.1
12/01/2022 17:00	4,894.9	466.1	5,361.0	104,046.0	557.8	0.7	0.3	1.1
12/01/2022 18:00	4,915.9	297.9	5,213.8	104,046.0	542.5	0.7	0.3	1.1
12/01/2022 19:00	4,915.6	399.0	5,314.6	104,046.0	553.0	0.7	0.3	1.1
12/01/2022 20:00	4,934.7	282.4	5,217.1	104,046.0	542.8	0.7	0.3	1.1
12/01/2022 21:00	4,948.8	242.5	5,191.3	104,046.0	540.1	0.6	0.3	1.1
12/01/2022 22:00	4,960.7	265.4	5,226.1	104,046.0	543.8	0.7	0.3	1.1
12/01/2022 23:00	4,976.2	191.5	5,167.7	104,046.0	537.7	0.6	0.3	1.1
Average/Sum#:	4,787.5	509.2	5,295.0	104,046.0	550.9	0.7	0.3	1.1
Minimum:	4,194.1	0.0	4,194.1	104,046.0	436.4	0.5	0.3	0.9
Maximum:	4,976.2	1,364.1	6,244.2	104,046.0	649.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2022 00:00	4,992.0	165.3	5,157.3	104,046.0	536.6	0.6	0.3	1.1
12/02/2022 01:00	4,999.6	142.3	5,141.9	104,046.0	535.0	0.6	0.3	1.1
12/02/2022 02:00	5,005.6	171.8	5,177.4	104,046.0	538.7	0.6	0.3	1.1
12/02/2022 03:00	5,020.0	319.4	5,339.4	104,046.0	555.5	0.7	0.3	1.1
12/02/2022 04:00	5,012.9	275.2	5,288.1	104,046.0	550.2	0.7	0.3	1.1
12/02/2022 05:00	5,012.9	367.4	5,380.3	104,046.0	559.8	0.7	0.3	1.1
12/02/2022 06:00	5,022.6	618.8	5,641.4	104,046.0	587.0	0.7	0.4	1.2
12/02/2022 07:00	5,015.7	1,131.5	6,147.2	104,046.0	639.6	0.8	0.4	1.3
12/02/2022 08:00	4,997.7	611.8	5,609.5	104,046.0	583.6	0.7	0.4	1.2
12/02/2022 09:00	4,989.4	619.2	5,608.6	104,046.0	583.6	0.7	0.4	1.2
12/02/2022 10:00	4,979.6	674.6	5,654.2	104,046.0	588.3	0.7	0.4	1.2
12/02/2022 11:00	4,953.9	632.3	5,586.2	104,046.0	581.2	0.7	0.3	1.2
12/02/2022 12:00	4,934.9	682.6	5,617.5	104,046.0	584.5	0.7	0.4	1.2
12/02/2022 13:00	4,920.6	1,043.3	5,963.9	104,046.0	620.5	0.7	0.4	1.2
12/02/2022 14:00	4,902.2	1,218.4	6,120.6	104,046.0	636.8	0.8	0.4	1.3
12/02/2022 15:00	4,899.7	1,182.2	6,081.9	104,046.0	632.8	0.8	0.4	1.3
12/02/2022 16:00	4,908.2	1,049.7	5,957.9	104,046.0	619.9	0.7	0.4	1.2
12/02/2022 17:00	4,926.2	1,134.6	6,060.8	104,046.0	630.6	0.8	0.4	1.3
12/02/2022 18:00	4,940.1	1,075.0	6,015.1	104,046.0	625.8	0.8	0.4	1.3
12/02/2022 19:00	4,938.9	1,114.6	6,053.5	104,046.0	629.8	0.8	0.4	1.3
12/02/2022 20:00	4,953.4	1,307.4	6,260.8	104,046.0	651.4	0.8	0.4	1.3
12/02/2022 21:00	4,970.5	1,049.1	6,019.6	104,046.0	626.3	0.8	0.4	1.3
12/02/2022 22:00	4,989.3	988.3	5,977.6	104,046.0	621.9	0.7	0.4	1.2
12/02/2022 23:00	4,986.9	586.1	5,573.0	104,046.0	579.8	0.7	0.3	1.2
Average/Sum#:	4,969.7	756.7	5,726.4	104,046.0	595.8	0.7	0.4	1.2
Minimum:	4,899.7	142.3	5,141.9	104,046.0	535.0	0.6	0.3	1.1
Maximum:	5,022.6	1,307.4	6,260.8	104,046.0	651.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2022 00:00	4,990.3	609.1	5,599.4	104,046.0	582.6	0.7	0.3	1.2
12/03/2022 01:00	4,993.7	541.9	5,535.6	104,046.0	576.0	0.7	0.3	1.2
12/03/2022 02:00	4,989.7	500.2	5,489.9	104,046.0	571.2	0.7	0.3	1.1
12/03/2022 03:00	4,986.5	581.0	5,567.5	104,046.0	579.3	0.7	0.3	1.2
12/03/2022 04:00	4,979.0	700.9	5,679.9	104,046.0	591.0	0.7	0.4	1.2
12/03/2022 05:00	4,985.4	792.2	5,777.6	104,046.0	601.1	0.7	0.4	1.2
12/03/2022 06:00	4,980.9	841.7	5,822.6	104,046.0	605.8	0.7	0.4	1.2
12/03/2022 07:00	4,957.7	1,326.5	6,284.2	104,046.0	653.8	0.8	0.4	1.3
12/03/2022 08:00	4,964.4	1,081.8	6,046.2	104,046.0	629.1	0.8	0.4	1.3
12/03/2022 09:00	4,970.6	1,062.5	6,033.1	104,046.0	627.7	0.8	0.4	1.3
12/03/2022 10:00	4,965.2	852.7	5,817.9	104,046.0	605.3	0.7	0.4	1.2
12/03/2022 11:00	4,946.6	596.7	5,543.3	104,046.0	576.8	0.7	0.3	1.2
12/03/2022 12:00	4,953.5	573.6	5,527.1	104,046.0	575.1	0.7	0.3	1.2
12/03/2022 13:00	4,948.9	579.3	5,528.2	104,046.0	575.2	0.7	0.3	1.2
12/03/2022 14:00	4,965.0	665.2	5,630.2	104,046.0	585.8	0.7	0.4	1.2
12/03/2022 15:00	4,962.4	885.8	5,848.2	104,046.0	608.5	0.7	0.4	1.2
12/03/2022 16:00	4,963.7	788.2	5,751.9	104,046.0	598.5	0.7	0.4	1.2
12/03/2022 17:00	4,484.8	454.4	4,825.6	104,046.0	502.1	0.6	0.3	1.1
12/03/2022 18:00	1,137.5	0.0	1,137.5	104,046.0	118.4	0.0	0.0	0.0
12/03/2022 19:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/03/2022 20:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/03/2022 21:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/03/2022 22:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/03/2022 23:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,743.5	707.0	5,444.5	104,046.0	566.5	0.7	0.4	1.2
Minimum:	1,137.5	0.0	1,137.5	104,046.0	118.4	0.6	0.3	1.1
Maximum:	4,993.7	1,326.5	6,284.2	104,046.0	653.8	0.8	0.4	1.3
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2022 00:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 01:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 02:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 03:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 04:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 05:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 06:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 07:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 08:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 09:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 10:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 11:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 12:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 13:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 14:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 15:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 16:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 17:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 18:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 19:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 20:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 21:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 22:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/04/2022 23:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2022 00:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 01:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 02:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 03:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 04:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 05:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 06:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 07:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 08:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 09:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 10:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 11:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 12:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 13:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 14:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 15:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 16:00	0.0	0.0	0.0	104,046.0	0.0	0.0	0.0	0.0
12/05/2022 17:00	2,759.3	0.0	2,759.3	104,046.0	287.1	0.0	0.0	0.0
12/05/2022 18:00	3,769.1	179.9	3,823.1	104,046.0	397.8	0.6	0.3	1.1
12/05/2022 19:00	4,848.7	808.3	5,657.0	104,046.0	588.6	0.7	0.4	1.2
12/05/2022 20:00	4,866.8	730.8	5,597.6	104,046.0	582.4	0.7	0.3	1.2
12/05/2022 21:00	4,877.3	439.6	5,316.9	104,046.0	553.2	0.7	0.3	1.1
12/05/2022 22:00	4,546.5	160.7	4,646.1	104,046.0	483.4	0.6	0.3	1.0
12/05/2022 23:00	3,334.0	0.0	3,334.0	105,000.0	350.1	0.4	0.2	0.7
Average/Sum#:	4,143.1	331.3	4,447.7	104,085.8	463.2	0.6	0.3	1.1
Minimum:	2,759.3	0.0	2,759.3	104,046.0	287.1	0.4	0.2	0.7
Maximum:	4,877.3	808.3	5,657.0	105,000.0	588.6	0.7	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	3,948.2	0.0	3,948.2	105,000.0	414.6	0.5	0.2	0.8
12/06/2022 01:00	3,291.9	0.0	3,291.9	105,000.0	345.6	0.4	0.2	0.7
12/06/2022 02:00	3,033.6	0.0	3,033.6	105,000.0	318.5	0.4	0.2	0.6
12/06/2022 03:00	2,971.0	0.0	2,971.0	105,000.0	312.0	0.4	0.2	0.6
12/06/2022 04:00	2,975.8	0.0	2,975.8	105,000.0	312.5	0.4	0.2	0.6
12/06/2022 05:00	2,975.4	0.0	2,975.4	105,000.0	312.4	0.4	0.2	0.6
12/06/2022 06:00	2,979.1	0.0	2,979.1	105,000.0	312.8	0.4	0.2	0.6
12/06/2022 07:00	2,977.2	0.0	2,977.2	105,000.0	312.6	0.4	0.2	0.6
12/06/2022 08:00	2,976.6	0.0	2,976.6	105,000.0	312.5	0.4	0.2	0.6
12/06/2022 09:00	3,176.9	0.0	3,176.9	105,000.0	333.6	0.4	0.2	0.7
12/06/2022 10:00	3,374.9	0.0	3,374.9	105,000.0	354.4	0.4	0.2	0.7
12/06/2022 11:00	2,976.4	0.0	2,976.4	105,000.0	312.5	0.4	0.2	0.6
12/06/2022 12:00	2,985.7	0.0	2,985.7	105,000.0	313.5	0.4	0.2	0.6
12/06/2022 13:00	2,961.8	0.0	2,961.8	105,000.0	311.0	0.4	0.2	0.6
12/06/2022 14:00	3,125.7	0.0	3,125.7	105,000.0	328.2	0.4	0.2	0.7
12/06/2022 15:00	3,737.1	0.1	3,737.1	105,000.0	392.4	0.5	0.2	0.8
12/06/2022 16:00	4,318.5	198.6	4,413.8	105,000.0	463.4	0.6	0.3	0.9
12/06/2022 17:00	4,859.9	798.2	5,658.1	105,000.0	594.1	0.7	0.4	1.2
12/06/2022 18:00	4,877.2	653.1	5,530.3	105,000.0	580.7	0.7	0.3	1.2
12/06/2022 19:00	4,886.4	682.9	5,569.3	105,000.0	584.8	0.7	0.4	1.2
12/06/2022 20:00	4,899.5	625.2	5,524.7	105,000.0	580.1	0.7	0.3	1.2
12/06/2022 21:00	4,916.8	618.3	5,535.1	105,000.0	581.2	0.7	0.3	1.2
12/06/2022 22:00	4,944.1	312.2	5,256.3	105,000.0	551.9	0.7	0.3	1.1
12/06/2022 23:00	4,955.8	197.3	5,153.1	105,000.0	541.1	0.6	0.3	1.1
Average/Sum#:	3,713.6	170.2	3,879.5	105,000.0	407.4	0.5	0.2	0.8
Minimum:	2,961.8	0.0	2,961.8	105,000.0	311.0	0.4	0.2	0.6
Maximum:	4,955.8	798.2	5,658.1	105,000.0	594.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2022 00:00	4,611.3	0.5	4,611.3	105,000.0	484.2	0.6	0.3	1.0
12/07/2022 01:00	4,429.1	0.0	4,429.1	105,000.0	465.1	0.6	0.3	0.9
12/07/2022 02:00	4,585.3	0.0	4,585.3	105,000.0	481.5	0.6	0.3	1.0
12/07/2022 03:00	4,566.5	0.0	4,566.5	105,000.0	479.5	0.6	0.3	1.0
12/07/2022 04:00	4,769.1	89.5	4,807.6	105,000.0	504.8	0.6	0.3	1.0
12/07/2022 05:00	4,998.6	701.7	5,700.3	105,000.0	598.5	0.7	0.4	1.2
12/07/2022 06:00	5,007.5	691.5	5,699.0	105,000.0	598.4	0.7	0.4	1.2
12/07/2022 07:00	5,014.5	193.3	5,207.8	105,000.0	546.8	0.7	0.3	1.1
12/07/2022 08:00	5,005.4	132.8	5,138.2	105,000.0	539.5	0.6	0.3	1.1
12/07/2022 09:00	4,970.9	336.4	5,307.3	105,000.0	557.3	0.7	0.3	1.1
12/07/2022 10:00	4,939.4	306.0	5,245.4	105,000.0	550.8	0.7	0.3	1.1
12/07/2022 11:00	4,912.6	282.3	5,194.9	105,000.0	545.5	0.7	0.3	1.1
12/07/2022 12:00	4,616.2	144.9	4,691.5	105,000.0	492.6	0.6	0.3	1.0
12/07/2022 13:00	2,977.5	0.0	2,977.5	105,000.0	312.6	0.4	0.2	0.6
12/07/2022 14:00	3,361.3	12.8	3,362.6	105,000.0	353.1	0.4	0.2	0.7
12/07/2022 15:00	4,853.3	402.4	5,255.7	105,000.0	551.8	0.7	0.3	1.1
12/07/2022 16:00	4,858.6	339.1	5,197.7	105,000.0	545.8	0.7	0.3	1.1
12/07/2022 17:00	4,877.3	324.7	5,202.0	105,000.0	546.2	0.7	0.3	1.1
12/07/2022 18:00	4,898.1	307.0	5,205.1	105,000.0	546.5	0.7	0.3	1.1
12/07/2022 19:00	4,920.1	493.6	5,413.7	105,000.0	568.4	0.7	0.3	1.1
12/07/2022 20:00	4,940.1	804.1	5,744.2	105,000.0	603.1	0.7	0.4	1.2
12/07/2022 21:00	4,960.8	719.8	5,680.6	105,000.0	596.5	0.7	0.4	1.2
12/07/2022 22:00	4,974.5	320.2	5,294.7	105,000.0	555.9	0.7	0.3	1.1
12/07/2022 23:00	4,974.4	193.0	5,167.4	105,000.0	542.6	0.7	0.3	1.1
Average/Sum#:	4,709.3	283.2	4,986.9	105,000.0	523.6	0.6	0.3	1.1
Minimum:	2,977.5	0.0	2,977.5	105,000.0	312.6	0.4	0.2	0.6
Maximum:	5,014.5	804.1	5,744.2	105,000.0	603.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2022 00:00	4,978.0	440.2	5,418.2	105,000.0	568.9	0.7	0.3	1.1
12/08/2022 01:00	4,975.9	318.6	5,294.5	105,000.0	555.9	0.7	0.3	1.1
12/08/2022 02:00	4,969.2	287.5	5,256.7	105,000.0	552.0	0.7	0.3	1.1
12/08/2022 03:00	4,982.3	303.8	5,286.1	105,000.0	555.0	0.7	0.3	1.1
12/08/2022 04:00	4,999.2	436.1	5,435.3	105,000.0	570.7	0.7	0.3	1.1
12/08/2022 05:00	5,021.6	593.2	5,614.8	105,000.0	589.6	0.7	0.4	1.2
12/08/2022 06:00	5,016.8	772.9	5,789.7	105,000.0	607.9	0.7	0.4	1.2
12/08/2022 07:00	5,012.8	573.7	5,586.5	105,000.0	586.6	0.7	0.4	1.2
12/08/2022 08:00	4,991.9	281.4	5,273.3	105,000.0	553.7	0.7	0.3	1.1
12/08/2022 09:00	4,903.6	132.6	4,972.6	105,000.0	522.1	0.6	0.3	1.1
12/08/2022 10:00	4,535.5	0.0	4,535.5	105,000.0	476.2	0.6	0.3	1.0
12/08/2022 11:00	4,881.2	502.0	5,373.2	105,000.0	564.2	0.7	0.3	1.1
12/08/2022 12:00	4,890.2	785.7	5,675.9	105,000.0	596.0	0.7	0.4	1.2
12/08/2022 13:00	4,881.5	784.6	5,666.1	105,000.0	594.9	0.7	0.4	1.2
12/08/2022 14:00	4,868.6	943.7	5,812.3	105,000.0	610.3	0.7	0.4	1.2
12/08/2022 15:00	4,871.3	844.7	5,716.0	105,000.0	600.2	0.7	0.4	1.2
12/08/2022 16:00	4,875.4	949.3	5,824.7	105,000.0	611.6	0.7	0.4	1.2
12/08/2022 17:00	4,876.1	1,110.8	5,986.9	105,000.0	628.6	0.8	0.4	1.3
12/08/2022 18:00	4,878.4	1,159.0	6,037.4	105,000.0	633.9	0.8	0.4	1.3
12/08/2022 19:00	4,881.6	1,151.6	6,033.2	105,000.0	633.5	0.8	0.4	1.3
12/08/2022 20:00	4,897.6	1,130.6	6,028.2	105,000.0	633.0	0.8	0.4	1.3
12/08/2022 21:00	4,906.2	1,072.3	5,978.5	105,000.0	627.7	0.8	0.4	1.3
12/08/2022 22:00	4,909.8	947.1	5,856.9	105,000.0	615.0	0.7	0.4	1.2
12/08/2022 23:00	4,918.4	567.4	5,485.8	105,000.0	576.0	0.7	0.3	1.2
Average/Sum#:	4,913.5	670.4	5,580.8	105,000.0	586.0	0.7	0.4	1.2
Minimum:	4,535.5	0.0	4,535.5	105,000.0	476.2	0.6	0.3	1.0
Maximum:	5,021.6	1,159.0	6,037.4	105,000.0	633.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	4,394.5	1.1	4,394.6	105,000.0	461.4	0.6	0.3	0.9
12/09/2022 01:00	4,140.8	0.0	4,140.8	105,000.0	434.8	0.5	0.3	0.9
12/09/2022 02:00	4,385.7	0.0	4,385.7	105,000.0	460.5	0.6	0.3	0.9
12/09/2022 03:00	4,452.3	0.0	4,452.3	105,000.0	467.5	0.6	0.3	0.9
12/09/2022 04:00	4,720.0	0.6	4,720.3	105,000.0	495.6	0.6	0.3	1.0
12/09/2022 05:00	4,761.8	0.1	4,761.9	105,000.0	500.0	0.6	0.3	1.0
12/09/2022 06:00	4,865.5	4.6	4,867.1	105,000.0	511.0	0.6	0.3	1.0
12/09/2022 07:00	4,938.3	570.7	5,509.0	105,000.0	578.4	0.7	0.3	1.2
12/09/2022 08:00	4,348.6	81.4	4,377.1	105,000.0	459.6	0.6	0.3	0.9
12/09/2022 09:00	4,062.2	0.0	4,062.2	105,000.0	426.5	0.5	0.3	0.9
12/09/2022 10:00	2,987.1	0.0	2,987.1	105,000.0	313.6	0.4	0.2	0.6
12/09/2022 11:00	3,026.6	0.0	3,026.6	105,000.0	317.8	0.4	0.2	0.6
12/09/2022 12:00	3,076.7	0.0	3,076.7	105,000.0	323.1	0.4	0.2	0.6
12/09/2022 13:00	4,797.6	0.0	4,797.6	105,000.0	503.7	0.6	0.3	1.0
12/09/2022 14:00	4,812.3	0.0	4,812.3	105,000.0	505.3	0.6	0.3	1.0
12/09/2022 15:00	3,929.3	129.3	3,972.0	105,000.0	417.1	0.5	0.3	0.9
12/09/2022 16:00	4,876.3	679.0	5,555.3	105,000.0	583.3	0.7	0.3	1.2
12/09/2022 17:00	4,881.2	641.5	5,522.7	105,000.0	579.9	0.7	0.3	1.2
12/09/2022 18:00	4,881.5	679.6	5,561.1	105,000.0	583.9	0.7	0.4	1.2
12/09/2022 19:00	4,876.3	852.6	5,728.9	105,000.0	601.5	0.7	0.4	1.2
12/09/2022 20:00	4,874.5	906.7	5,781.2	105,000.0	607.0	0.7	0.4	1.2
12/09/2022 21:00	4,876.9	809.8	5,686.7	105,000.0	597.1	0.7	0.4	1.2
12/09/2022 22:00	4,870.9	780.1	5,651.0	105,000.0	593.4	0.7	0.4	1.2
12/09/2022 23:00	4,867.2	552.4	5,419.6	105,000.0	569.1	0.7	0.3	1.1
Average/Sum#:	4,446.0	278.7	4,718.7	105,000.0	495.5	0.6	0.3	1.0
Minimum:	2,987.1	0.0	2,987.1	105,000.0	313.6	0.4	0.2	0.6
Maximum:	4,938.3	906.7	5,781.2	105,000.0	607.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2022 00:00	4,861.9	1.5	4,861.9	105,000.0	510.5	0.6	0.3	1.0
12/10/2022 01:00	4,838.7	0.0	4,838.7	105,000.0	508.1	0.6	0.3	1.0
12/10/2022 02:00	4,840.2	0.0	4,840.2	105,000.0	508.2	0.6	0.3	1.0
12/10/2022 03:00	4,837.2	0.0	4,837.2	105,000.0	507.9	0.6	0.3	1.0
12/10/2022 04:00	4,835.7	0.0	4,835.7	105,000.0	507.7	0.6	0.3	1.0
12/10/2022 05:00	4,840.4	0.0	4,840.4	105,000.0	508.2	0.6	0.3	1.0
12/10/2022 06:00	4,845.4	0.0	4,845.4	105,000.0	508.8	0.6	0.3	1.0
12/10/2022 07:00	3,226.1	0.0	3,226.1	105,000.0	338.7	0.4	0.2	0.7
12/10/2022 08:00	3,486.3	0.0	3,486.3	105,000.0	366.1	0.4	0.2	0.7
12/10/2022 09:00	3,182.0	0.0	3,182.0	105,000.0	334.1	0.4	0.2	0.7
12/10/2022 10:00	2,959.3	0.0	2,959.3	105,000.0	310.7	0.4	0.2	0.6
12/10/2022 11:00	3,457.3	0.0	3,457.3	105,000.0	363.0	0.4	0.2	0.7
12/10/2022 12:00	4,434.3	0.0	4,434.3	105,000.0	465.6	0.6	0.3	0.9
12/10/2022 13:00	4,405.0	9.3	4,407.1	105,000.0	462.7	0.6	0.3	0.9
12/10/2022 14:00	4,805.3	499.4	5,304.7	105,000.0	557.0	0.7	0.3	1.1
12/10/2022 15:00	4,796.1	572.9	5,369.0	105,000.0	563.7	0.7	0.3	1.1
12/10/2022 16:00	4,792.8	616.5	5,409.3	105,000.0	568.0	0.7	0.3	1.1
12/10/2022 17:00	4,793.8	496.3	5,290.1	105,000.0	555.5	0.7	0.3	1.1
12/10/2022 18:00	4,793.9	493.2	5,287.1	105,000.0	555.1	0.7	0.3	1.1
12/10/2022 19:00	4,793.8	796.9	5,590.7	105,000.0	587.0	0.7	0.4	1.2
12/10/2022 20:00	4,801.6	738.2	5,539.8	105,000.0	581.7	0.7	0.3	1.2
12/10/2022 21:00	4,812.3	515.9	5,328.2	105,000.0	559.5	0.7	0.3	1.1
12/10/2022 22:00	4,824.6	426.5	5,251.1	105,000.0	551.4	0.7	0.3	1.1
12/10/2022 23:00	4,836.9	462.6	5,299.5	105,000.0	556.4	0.7	0.3	1.1
Average/Sum#:	4,462.5	234.6	4,696.7	105,000.0	493.2	0.6	0.3	1.0
Minimum:	2,959.3	0.0	2,959.3	105,000.0	310.7	0.4	0.2	0.6
Maximum:	4,861.9	796.9	5,590.7	105,000.0	587.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2022 00:00	4,806.2	393.2	5,120.8	105,000.0	537.7	0.7	0.3	1.1
12/11/2022 01:00	3,728.0	0.0	3,728.0	105,000.0	391.4	0.5	0.2	0.8
12/11/2022 02:00	3,209.6	0.0	3,209.6	105,000.0	337.0	0.4	0.2	0.7
12/11/2022 03:00	3,484.8	0.0	3,484.8	105,000.0	365.9	0.4	0.2	0.7
12/11/2022 04:00	4,116.1	0.0	4,116.1	105,000.0	432.2	0.5	0.3	0.9
12/11/2022 05:00	4,273.1	0.0	4,273.1	105,000.0	448.7	0.5	0.3	0.9
12/11/2022 06:00	4,208.7	0.0	4,208.7	105,000.0	441.9	0.5	0.3	0.9
12/11/2022 07:00	3,143.0	0.0	3,143.0	105,000.0	330.0	0.4	0.2	0.7
12/11/2022 08:00	2,903.3	0.0	2,903.3	105,000.0	304.8	0.4	0.2	0.6
12/11/2022 09:00	2,883.2	0.0	2,883.2	105,000.0	302.7	0.4	0.2	0.6
12/11/2022 10:00	2,942.1	0.0	2,942.1	105,000.0	308.9	0.4	0.2	0.6
12/11/2022 11:00	2,876.5	0.0	2,876.5	105,000.0	302.0	0.4	0.2	0.6
12/11/2022 12:00	2,876.8	0.0	2,876.8	105,000.0	302.1	0.4	0.2	0.6
12/11/2022 13:00	2,931.9	0.0	2,931.9	105,000.0	307.8	0.4	0.2	0.6
12/11/2022 14:00	3,001.0	0.0	3,001.0	105,000.0	315.1	0.4	0.2	0.6
12/11/2022 15:00	4,181.4	81.4	4,200.1	105,000.0	441.0	0.5	0.3	0.9
12/11/2022 16:00	4,871.7	413.2	5,284.9	105,000.0	554.9	0.7	0.3	1.1
12/11/2022 17:00	4,883.9	420.5	5,304.4	105,000.0	557.0	0.7	0.3	1.1
12/11/2022 18:00	4,900.8	340.8	5,241.6	105,000.0	550.4	0.7	0.3	1.1
12/11/2022 19:00	4,916.2	336.4	5,252.6	105,000.0	551.5	0.7	0.3	1.1
12/11/2022 20:00	4,920.9	453.0	5,373.9	105,000.0	564.3	0.7	0.3	1.1
12/11/2022 21:00	4,903.9	328.9	5,232.8	105,000.0	549.4	0.7	0.3	1.1
12/11/2022 22:00	4,087.2	75.6	4,107.6	105,000.0	431.3	0.5	0.3	0.9
12/11/2022 23:00	3,003.3	0.0	3,003.3	105,000.0	315.3	0.4	0.2	0.6
Average/Sum#:	3,835.6	118.5	3,945.8	105,000.0	414.3	0.5	0.3	0.8
Minimum:	2,876.5	0.0	2,876.5	105,000.0	302.0	0.4	0.2	0.6
Maximum:	4,920.9	453.0	5,373.9	105,000.0	564.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2022 00:00	3,055.7	0.0	3,055.7	105,000.0	320.8	0.4	0.2	0.6
12/12/2022 01:00	3,117.9	0.0	3,117.9	105,000.0	327.4	0.4	0.2	0.7
12/12/2022 02:00	3,384.5	0.0	3,384.5	105,000.0	355.4	0.4	0.2	0.7
12/12/2022 03:00	3,099.6	0.0	3,099.6	105,000.0	325.5	0.4	0.2	0.7
12/12/2022 04:00	4,220.9	102.5	4,265.0	105,000.0	447.8	0.5	0.3	0.9
12/12/2022 05:00	4,954.8	608.8	5,563.6	105,000.0	584.2	0.7	0.4	1.2
12/12/2022 06:00	4,958.0	722.8	5,680.8	105,000.0	596.5	0.7	0.4	1.2
12/12/2022 07:00	4,962.7	513.0	5,475.7	105,000.0	574.9	0.7	0.3	1.1
12/12/2022 08:00	4,960.1	296.4	5,256.5	105,000.0	551.9	0.7	0.3	1.1
12/12/2022 09:00	4,950.0	291.1	5,241.1	105,000.0	550.3	0.7	0.3	1.1
12/12/2022 10:00	4,587.9	123.6	4,652.2	105,000.0	488.5	0.6	0.3	1.0
12/12/2022 11:00	2,982.7	0.0	2,982.7	105,000.0	313.2	0.4	0.2	0.6
12/12/2022 12:00	2,986.4	0.0	2,986.4	105,000.0	313.6	0.4	0.2	0.6
12/12/2022 13:00	2,922.7	0.0	2,922.7	105,000.0	306.9	0.4	0.2	0.6
12/12/2022 14:00	2,815.7	0.0	2,815.7	105,000.0	295.6	0.4	0.2	0.6
12/12/2022 15:00	1,152.2	0.0	1,152.2	105,000.0	121.0	0.0	0.0	0.0
12/12/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/12/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,694.5	166.1	3,853.3	105,000.0	404.6	0.5	0.3	0.8
Minimum:	1,152.2	0.0	1,152.2	105,000.0	121.0	0.4	0.2	0.6
Maximum:	4,962.7	722.8	5,680.8	105,000.0	596.5	0.7	0.4	1.2
%SI	33.33	33.33	33.33	0.00	33.33	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/13/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/14/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/15/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 06:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 07:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 08:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 09:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 10:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/16/2022 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2022 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/17/2022 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/17/2022 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/17/2022 03:00	2,775.8	0.0	2,775.8	105,000.0	291.5	0.4	0.2	0.6
12/17/2022 04:00	2,974.7	0.0	2,974.7	105,000.0	312.3	0.4	0.2	0.6
12/17/2022 05:00	3,954.8	110.3	3,991.2	105,000.0	419.1	0.5	0.3	0.9
12/17/2022 06:00	5,032.1	217.4	5,249.5	105,000.0	551.2	0.7	0.3	1.1
12/17/2022 07:00	5,058.7	236.8	5,295.5	105,000.0	556.0	0.7	0.3	1.1
12/17/2022 08:00	4,728.3	0.0	4,728.3	105,000.0	496.5	0.6	0.3	1.0
12/17/2022 09:00	4,193.1	0.0	4,193.1	105,000.0	440.3	0.5	0.3	0.9
12/17/2022 10:00	3,202.3	0.0	3,202.3	105,000.0	336.2	0.4	0.2	0.7
12/17/2022 11:00	2,936.0	0.0	2,936.0	105,000.0	308.3	0.4	0.2	0.6
12/17/2022 12:00	2,891.7	0.0	2,891.7	105,000.0	303.6	0.4	0.2	0.6
12/17/2022 13:00	2,979.4	0.0	2,979.4	105,000.0	312.8	0.4	0.2	0.6
12/17/2022 14:00	3,404.2	14.1	3,405.6	105,000.0	357.6	0.4	0.2	0.7
12/17/2022 15:00	4,879.3	625.5	5,504.8	105,000.0	578.0	0.7	0.3	1.2
12/17/2022 16:00	4,876.0	783.1	5,659.1	105,000.0	594.2	0.7	0.4	1.2
12/17/2022 17:00	4,881.8	653.5	5,535.3	105,000.0	581.2	0.7	0.3	1.2
12/17/2022 18:00	4,909.3	468.5	5,377.8	105,000.0	564.7	0.7	0.3	1.1
12/17/2022 19:00	4,940.0	768.4	5,708.4	105,000.0	599.4	0.7	0.4	1.2
12/17/2022 20:00	4,948.3	953.3	5,901.6	105,000.0	619.7	0.7	0.4	1.2
12/17/2022 21:00	4,942.6	862.9	5,805.5	105,000.0	609.6	0.7	0.4	1.2
12/17/2022 22:00	4,972.3	728.9	5,701.2	105,000.0	598.6	0.7	0.4	1.2
12/17/2022 23:00	4,987.1	377.0	5,364.1	105,000.0	563.2	0.7	0.3	1.1
Average/Sum#:	4,212.8	323.8	4,532.4	105,000.0	475.9	0.6	0.3	1.0
Minimum:	2,775.8	0.0	2,775.8	105,000.0	291.5	0.4	0.2	0.6
Maximum:	5,058.7	953.3	5,901.6	105,000.0	619.7	0.7	0.4	1.2
%SI	12.50	12.50	12.50	0.00	12.50	12.50	12.50	12.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2022 00:00	4,614.9	0.2	4,614.9	105,000.0	484.6	0.6	0.3	1.0
12/18/2022 01:00	4,598.9	0.0	4,598.9	105,000.0	482.9	0.6	0.3	1.0
12/18/2022 02:00	4,409.6	0.0	4,409.6	105,000.0	463.0	0.6	0.3	0.9
12/18/2022 03:00	4,320.3	0.0	4,320.3	105,000.0	453.6	0.5	0.3	0.9
12/18/2022 04:00	4,552.6	0.0	4,552.6	105,000.0	478.0	0.6	0.3	1.0
12/18/2022 05:00	4,716.4	0.0	4,716.4	105,000.0	495.2	0.6	0.3	1.0
12/18/2022 06:00	4,801.7	113.6	4,847.1	105,000.0	508.9	0.6	0.3	1.0
12/18/2022 07:00	5,002.4	1,057.7	6,060.1	105,000.0	636.3	0.8	0.4	1.3
12/18/2022 08:00	5,026.4	733.8	5,760.2	105,000.0	604.8	0.7	0.4	1.2
12/18/2022 09:00	5,013.3	828.8	5,842.1	105,000.0	613.4	0.7	0.4	1.2
12/18/2022 10:00	4,934.5	419.1	5,257.2	105,000.0	552.0	0.7	0.3	1.1
12/18/2022 11:00	4,501.9	0.0	4,501.9	105,000.0	472.7	0.6	0.3	0.9
12/18/2022 12:00	3,765.4	0.0	3,765.4	105,000.0	395.4	0.5	0.2	0.8
12/18/2022 13:00	2,980.9	0.0	2,980.9	105,000.0	313.0	0.4	0.2	0.6
12/18/2022 14:00	3,631.7	0.0	3,631.7	105,000.0	381.3	0.5	0.2	0.8
12/18/2022 15:00	3,647.1	0.0	3,647.1	105,000.0	382.9	0.5	0.2	0.8
12/18/2022 16:00	4,988.4	4.7	4,992.3	105,000.0	524.2	0.6	0.3	1.0
12/18/2022 17:00	5,010.7	117.8	5,120.3	105,000.0	537.6	0.6	0.3	1.1
12/18/2022 18:00	5,006.6	750.3	5,756.9	105,000.0	604.5	0.7	0.4	1.2
12/18/2022 19:00	4,997.7	679.2	5,676.9	105,000.0	596.1	0.7	0.4	1.2
12/18/2022 20:00	5,026.4	593.2	5,619.6	105,000.0	590.1	0.7	0.4	1.2
12/18/2022 21:00	5,030.5	530.8	5,561.3	105,000.0	583.9	0.7	0.4	1.2
12/18/2022 22:00	5,017.8	457.4	5,475.2	105,000.0	574.9	0.7	0.3	1.2
12/18/2022 23:00	5,009.7	293.4	5,303.1	105,000.0	556.8	0.7	0.3	1.1
Average/Sum#:	4,608.6	274.2	4,875.5	105,000.0	511.9	0.6	0.3	1.0
Minimum:	2,980.9	0.0	2,980.9	105,000.0	313.0	0.4	0.2	0.6
Maximum:	5,030.5	1,057.7	6,060.1	105,000.0	636.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	5,011.0	593.1	5,604.1	105,000.0	588.4	0.7	0.4	1.2
12/19/2022 01:00	5,016.7	583.2	5,599.9	105,000.0	588.0	0.7	0.4	1.2
12/19/2022 02:00	5,015.8	593.5	5,609.3	105,000.0	589.0	0.7	0.4	1.2
12/19/2022 03:00	5,015.0	589.3	5,604.3	105,000.0	588.5	0.7	0.4	1.2
12/19/2022 04:00	5,026.4	782.9	5,809.3	105,000.0	610.0	0.7	0.4	1.2
12/19/2022 05:00	5,031.2	1,033.6	6,064.8	105,000.0	636.8	0.8	0.4	1.3
12/19/2022 06:00	5,036.9	1,065.2	6,102.1	105,000.0	640.7	0.8	0.4	1.3
12/19/2022 07:00	5,034.0	968.6	6,002.6	105,000.0	630.3	0.8	0.4	1.3
12/19/2022 08:00	5,043.3	789.9	5,833.2	105,000.0	612.5	0.7	0.4	1.2
12/19/2022 09:00	5,048.2	1,196.6	6,244.8	105,000.0	655.7	0.8	0.4	1.3
12/19/2022 10:00	5,045.2	1,117.6	6,162.8	105,000.0	647.1	0.8	0.4	1.3
12/19/2022 11:00	5,036.0	963.3	5,999.3	105,000.0	629.9	0.8	0.4	1.3
12/19/2022 12:00	5,030.0	729.3	5,759.3	105,000.0	604.7	0.7	0.4	1.2
12/19/2022 13:00	5,024.7	794.7	5,819.4	105,000.0	611.0	0.7	0.4	1.2
12/19/2022 14:00	5,019.8	901.0	5,920.8	105,000.0	621.7	0.7	0.4	1.2
12/19/2022 15:00	5,012.3	775.0	5,787.3	105,000.0	607.7	0.7	0.4	1.2
12/19/2022 16:00	5,026.9	989.6	6,016.5	105,000.0	631.7	0.8	0.4	1.3
12/19/2022 17:00	5,035.8	1,014.4	6,050.2	105,000.0	635.3	0.8	0.4	1.3
12/19/2022 18:00	5,030.4	1,003.6	6,034.0	105,000.0	633.6	0.8	0.4	1.3
12/19/2022 19:00	5,037.2	1,004.4	6,041.6	105,000.0	634.4	0.8	0.4	1.3
12/19/2022 20:00	5,034.3	1,004.6	6,038.9	105,000.0	634.1	0.8	0.4	1.3
12/19/2022 21:00	5,038.7	1,004.6	6,043.3	105,000.0	634.5	0.8	0.4	1.3
12/19/2022 22:00	5,026.5	995.3	6,021.8	105,000.0	632.3	0.8	0.4	1.3
12/19/2022 23:00	5,042.9	608.1	5,651.0	105,000.0	593.4	0.7	0.4	1.2
Average/Sum#:	5,030.0	879.2	5,909.2	105,000.0	620.5	0.8	0.4	1.3
Minimum:	5,011.0	583.2	5,599.9	105,000.0	588.0	0.7	0.4	1.2
Maximum:	5,048.2	1,196.6	6,244.8	105,000.0	655.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2022 00:00	4,919.0	0.0	4,919.0	105,000.0	516.5	0.6	0.3	1.0
12/20/2022 01:00	4,933.1	0.0	4,933.1	105,000.0	518.0	0.6	0.3	1.0
12/20/2022 02:00	4,937.1	0.0	4,937.1	105,000.0	518.4	0.6	0.3	1.0
12/20/2022 03:00	4,941.6	0.0	4,941.6	105,000.0	518.9	0.6	0.3	1.0
12/20/2022 04:00	4,932.2	0.0	4,932.2	105,000.0	517.9	0.6	0.3	1.0
12/20/2022 05:00	4,945.7	0.0	4,945.7	105,000.0	519.3	0.6	0.3	1.0
12/20/2022 06:00	4,944.9	2.4	4,945.0	105,000.0	519.2	0.6	0.3	1.0
12/20/2022 07:00	5,042.6	970.0	6,012.6	105,000.0	631.3	0.8	0.4	1.3
12/20/2022 08:00	5,041.6	709.2	5,750.8	105,000.0	603.8	0.7	0.4	1.2
12/20/2022 09:00	5,040.6	125.8	5,166.4	105,000.0	542.5	0.7	0.3	1.1
12/20/2022 10:00	4,538.1	28.1	4,552.7	105,000.0	478.0	0.6	0.3	1.0
12/20/2022 11:00	2,977.8	0.0	2,977.8	105,000.0	312.7	0.4	0.2	0.6
12/20/2022 12:00	2,909.4	0.0	2,909.4	105,000.0	305.5	0.4	0.2	0.6
12/20/2022 13:00	2,913.7	0.0	2,913.7	105,000.0	305.9	0.4	0.2	0.6
12/20/2022 14:00	2,903.5	0.0	2,903.5	105,000.0	304.9	0.4	0.2	0.6
12/20/2022 15:00	3,892.7	80.5	3,920.9	105,000.0	411.7	0.5	0.3	0.8
12/20/2022 16:00	4,951.7	243.3	5,195.0	105,000.0	545.5	0.7	0.3	1.1
12/20/2022 17:00	4,976.7	202.2	5,178.9	105,000.0	543.8	0.7	0.3	1.1
12/20/2022 18:00	4,975.0	192.6	5,167.6	105,000.0	542.6	0.7	0.3	1.1
12/20/2022 19:00	4,974.0	202.3	5,176.3	105,000.0	543.5	0.7	0.3	1.1
12/20/2022 20:00	4,969.5	206.6	5,176.1	105,000.0	543.5	0.7	0.3	1.1
12/20/2022 21:00	4,982.9	181.4	5,164.3	105,000.0	542.3	0.7	0.3	1.1
12/20/2022 22:00	4,975.2	170.9	5,146.1	105,000.0	540.3	0.6	0.3	1.1
12/20/2022 23:00	4,986.9	167.9	5,154.8	105,000.0	541.3	0.6	0.3	1.1
Average/Sum#:	4,566.9	145.1	4,709.2	105,000.0	494.5	0.6	0.3	1.0
Minimum:	2,903.5	0.0	2,903.5	105,000.0	304.9	0.4	0.2	0.6
Maximum:	5,042.6	970.0	6,012.6	105,000.0	631.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	4,999.8	154.5	5,154.3	105,000.0	541.2	0.7	0.3	1.1
12/21/2022 01:00	4,996.5	160.8	5,157.3	105,000.0	541.5	0.7	0.3	1.1
12/21/2022 02:00	5,010.0	140.4	5,150.4	105,000.0	540.8	0.7	0.3	1.1
12/21/2022 03:00	5,020.6	121.7	5,142.3	105,000.0	539.9	0.6	0.3	1.1
12/21/2022 04:00	5,023.6	106.5	5,130.1	105,000.0	538.7	0.6	0.3	1.1
12/21/2022 05:00	5,027.1	91.1	5,118.2	105,000.0	537.4	0.6	0.3	1.1
12/21/2022 06:00	5,030.6	171.3	5,201.9	105,000.0	546.2	0.7	0.3	1.1
12/21/2022 07:00	5,032.9	661.0	5,693.9	105,000.0	597.9	0.7	0.4	1.2
12/21/2022 08:00	5,032.9	409.6	5,442.5	105,000.0	571.5	0.7	0.3	1.1
12/21/2022 09:00	5,024.1	831.7	5,855.8	105,000.0	614.9	0.7	0.4	1.2
12/21/2022 10:00	5,025.4	716.3	5,741.7	105,000.0	602.9	0.7	0.4	1.2
12/21/2022 11:00	5,019.6	558.7	5,578.3	105,000.0	585.7	0.7	0.4	1.2
12/21/2022 12:00	5,007.4	530.5	5,537.9	105,000.0	581.5	0.7	0.3	1.2
12/21/2022 13:00	4,986.2	645.1	5,631.3	105,000.0	591.3	0.7	0.4	1.2
12/21/2022 14:00	4,964.8	554.7	5,519.5	105,000.0	579.5	0.7	0.3	1.2
12/21/2022 15:00	4,966.0	320.2	5,286.2	105,000.0	555.1	0.7	0.3	1.1
12/21/2022 16:00	4,975.7	563.0	5,538.7	105,000.0	581.6	0.7	0.3	1.2
12/21/2022 17:00	4,988.3	475.5	5,463.8	105,000.0	573.7	0.7	0.3	1.1
12/21/2022 18:00	5,013.9	397.2	5,411.1	105,000.0	568.2	0.7	0.3	1.1
12/21/2022 19:00	5,012.0	456.1	5,468.1	105,000.0	574.2	0.7	0.3	1.1
12/21/2022 20:00	4,997.1	760.4	5,757.5	105,000.0	604.5	0.7	0.4	1.2
12/21/2022 21:00	5,001.3	779.9	5,781.2	105,000.0	607.0	0.7	0.4	1.2
12/21/2022 22:00	5,010.9	304.8	5,315.7	105,000.0	558.1	0.7	0.3	1.1
12/21/2022 23:00	5,002.2	203.3	5,205.5	105,000.0	546.6	0.7	0.3	1.1
Average/Sum#:	5,007.0	421.4	5,428.5	105,000.0	570.0	0.7	0.3	1.1
Minimum:	4,964.8	91.1	5,118.2	105,000.0	537.4	0.6	0.3	1.1
Maximum:	5,032.9	831.7	5,855.8	105,000.0	614.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	5,009.2	131.4	5,140.6	105,000.0	539.8	0.6	0.3	1.1
12/22/2022 01:00	4,925.0	0.1	4,925.0	105,000.0	517.1	0.6	0.3	1.0
12/22/2022 02:00	4,932.5	0.0	4,932.5	105,000.0	517.9	0.6	0.3	1.0
12/22/2022 03:00	4,941.0	0.0	4,941.0	105,000.0	518.8	0.6	0.3	1.0
12/22/2022 04:00	4,924.1	0.0	4,924.1	105,000.0	517.0	0.6	0.3	1.0
12/22/2022 05:00	4,939.2	0.0	4,939.2	105,000.0	518.6	0.6	0.3	1.0
12/22/2022 06:00	4,942.6	0.0	4,942.6	105,000.0	519.0	0.6	0.3	1.0
12/22/2022 07:00	4,994.2	246.6	5,235.9	105,000.0	549.8	0.7	0.3	1.1
12/22/2022 08:00	4,991.3	220.5	5,211.8	105,000.0	547.2	0.7	0.3	1.1
12/22/2022 09:00	4,996.5	754.4	5,750.9	105,000.0	603.8	0.7	0.4	1.2
12/22/2022 10:00	4,994.1	1,035.6	6,029.7	105,000.0	633.1	0.8	0.4	1.3
12/22/2022 11:00	4,980.9	1,019.3	6,000.2	105,000.0	630.0	0.8	0.4	1.3
12/22/2022 12:00	4,973.3	449.8	5,423.1	105,000.0	569.4	0.7	0.3	1.1
12/22/2022 13:00	4,980.6	263.9	5,244.5	105,000.0	550.7	0.7	0.3	1.1
12/22/2022 14:00	4,962.1	202.5	5,164.6	105,000.0	542.3	0.7	0.3	1.1
12/22/2022 15:00	4,953.4	267.3	5,220.7	105,000.0	548.2	0.7	0.3	1.1
12/22/2022 16:00	4,946.8	595.5	5,542.3	105,000.0	581.9	0.7	0.3	1.2
12/22/2022 17:00	4,967.5	345.1	5,312.6	105,000.0	557.8	0.7	0.3	1.1
12/22/2022 18:00	4,974.5	321.5	5,296.0	105,000.0	556.1	0.7	0.3	1.1
12/22/2022 19:00	4,980.7	236.1	5,216.8	105,000.0	547.8	0.7	0.3	1.1
12/22/2022 20:00	4,988.4	175.0	5,163.4	105,000.0	542.2	0.7	0.3	1.1
12/22/2022 21:00	4,980.7	270.4	5,251.1	105,000.0	551.4	0.7	0.3	1.1
12/22/2022 22:00	4,981.8	283.8	5,265.6	105,000.0	552.9	0.7	0.3	1.1
12/22/2022 23:00	4,988.5	187.1	5,175.6	105,000.0	543.4	0.7	0.3	1.1
Average/Sum#:	4,968.7	291.9	5,260.4	105,000.0	552.3	0.7	0.3	1.1
Minimum:	4,924.1	0.0	4,924.1	105,000.0	517.0	0.6	0.3	1.0
Maximum:	5,009.2	1,035.6	6,029.7	105,000.0	633.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2022 00:00	4,985.4	191.5	5,176.9	105,000.0	543.6	0.7	0.3	1.1
12/23/2022 01:00	4,977.0	193.4	5,170.4	105,000.0	542.9	0.7	0.3	1.1
12/23/2022 02:00	4,977.9	190.3	5,168.2	105,000.0	542.7	0.7	0.3	1.1
12/23/2022 03:00	4,988.2	182.3	5,170.5	105,000.0	542.9	0.7	0.3	1.1
12/23/2022 04:00	4,998.7	172.9	5,171.6	105,000.0	543.0	0.7	0.3	1.1
12/23/2022 05:00	4,998.0	167.9	5,165.9	105,000.0	542.4	0.7	0.3	1.1
12/23/2022 06:00	4,996.1	158.1	5,154.2	105,000.0	541.2	0.7	0.3	1.1
12/23/2022 07:00	5,003.2	703.0	5,706.2	105,000.0	599.2	0.7	0.4	1.2
12/23/2022 08:00	5,010.3	438.9	5,449.2	105,000.0	572.2	0.7	0.3	1.1
12/23/2022 09:00	5,010.5	523.3	5,533.8	105,000.0	581.0	0.7	0.3	1.2
12/23/2022 10:00	5,003.1	478.1	5,481.2	105,000.0	575.5	0.7	0.3	1.2
12/23/2022 11:00	4,985.1	466.8	5,451.9	105,000.0	572.4	0.7	0.3	1.1
12/23/2022 12:00	4,940.4	228.6	5,116.4	105,000.0	537.2	0.7	0.3	1.1
12/23/2022 13:00	3,375.6	0.0	3,375.6	105,000.0	354.4	0.4	0.2	0.7
12/23/2022 14:00	3,574.7	11.5	3,576.2	105,000.0	375.5	0.5	0.2	0.8
12/23/2022 15:00	4,907.1	457.2	5,364.3	105,000.0	563.3	0.7	0.3	1.1
12/23/2022 16:00	4,915.3	939.6	5,854.9	105,000.0	614.8	0.7	0.4	1.2
12/23/2022 17:00	4,939.7	867.5	5,807.2	105,000.0	609.8	0.7	0.4	1.2
12/23/2022 18:00	4,953.1	822.5	5,775.6	105,000.0	606.4	0.7	0.4	1.2
12/23/2022 19:00	4,963.1	630.2	5,593.3	105,000.0	587.3	0.7	0.4	1.2
12/23/2022 20:00	4,977.6	585.2	5,562.8	105,000.0	584.1	0.7	0.4	1.2
12/23/2022 21:00	4,979.3	649.0	5,628.3	105,000.0	591.0	0.7	0.4	1.2
12/23/2022 22:00	4,995.0	558.4	5,553.4	105,000.0	583.1	0.7	0.3	1.2
12/23/2022 23:00	5,001.0	418.4	5,419.4	105,000.0	569.0	0.7	0.3	1.1
Average/Sum#:	4,852.3	418.1	5,267.8	105,000.0	553.1	0.7	0.3	1.1
Minimum:	3,375.6	0.0	3,375.6	105,000.0	354.4	0.4	0.2	0.7
Maximum:	5,010.5	939.6	5,854.9	105,000.0	614.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2022 00:00	4,905.3	0.0	4,905.3	105,000.0	515.1	0.6	0.3	1.0
12/24/2022 01:00	4,925.6	0.0	4,925.6	105,000.0	517.2	0.6	0.3	1.0
12/24/2022 02:00	4,936.5	0.0	4,936.5	105,000.0	518.3	0.6	0.3	1.0
12/24/2022 03:00	4,928.2	0.0	4,928.2	105,000.0	517.5	0.6	0.3	1.0
12/24/2022 04:00	4,921.3	0.0	4,921.3	105,000.0	516.7	0.6	0.3	1.0
12/24/2022 05:00	4,923.0	0.0	4,923.0	105,000.0	516.9	0.6	0.3	1.0
12/24/2022 06:00	4,849.8	0.0	4,849.8	105,000.0	509.2	0.6	0.3	1.0
12/24/2022 07:00	3,492.0	0.0	3,492.0	105,000.0	366.7	0.4	0.2	0.7
12/24/2022 08:00	2,991.7	0.0	2,991.7	105,000.0	314.1	0.4	0.2	0.6
12/24/2022 09:00	4,430.9	123.5	4,502.5	105,000.0	472.8	0.6	0.3	1.0
12/24/2022 10:00	5,032.1	456.2	5,488.3	105,000.0	576.3	0.7	0.3	1.2
12/24/2022 11:00	5,010.1	200.0	5,210.1	105,000.0	547.1	0.7	0.3	1.1
12/24/2022 12:00	4,981.3	263.1	5,244.4	105,000.0	550.7	0.7	0.3	1.1
12/24/2022 13:00	4,938.1	278.3	5,216.4	105,000.0	547.7	0.7	0.3	1.1
12/24/2022 14:00	4,916.8	242.1	5,158.9	105,000.0	541.7	0.7	0.3	1.1
12/24/2022 15:00	4,901.7	264.6	5,166.3	105,000.0	542.5	0.7	0.3	1.1
12/24/2022 16:00	4,910.5	307.6	5,218.1	105,000.0	547.9	0.7	0.3	1.1
12/24/2022 17:00	4,908.0	240.5	5,148.5	105,000.0	540.6	0.6	0.3	1.1
12/24/2022 18:00	4,937.6	222.7	5,160.3	105,000.0	541.8	0.6	0.3	1.1
12/24/2022 19:00	4,939.1	246.1	5,185.2	105,000.0	544.4	0.7	0.3	1.1
12/24/2022 20:00	4,646.8	116.4	4,707.3	105,000.0	494.3	0.6	0.3	1.0
12/24/2022 21:00	3,011.3	0.0	3,011.3	105,000.0	316.2	0.4	0.2	0.6
12/24/2022 22:00	3,030.2	0.0	3,030.2	105,000.0	318.2	0.4	0.2	0.6
12/24/2022 23:00	3,038.0	0.0	3,038.0	105,000.0	319.0	0.4	0.2	0.6
Average/Sum#:	4,521.1	123.4	4,640.0	105,000.0	487.2	0.6	0.3	1.0
Minimum:	2,991.7	0.0	2,991.7	105,000.0	314.1	0.4	0.2	0.6
Maximum:	5,032.1	456.2	5,488.3	105,000.0	576.3	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2022 00:00	3,206.2	0.0	3,206.2	105,000.0	336.7	0.4	0.2	0.7
12/25/2022 01:00	3,055.2	0.0	3,055.2	105,000.0	320.8	0.4	0.2	0.6
12/25/2022 02:00	3,040.4	0.0	3,040.4	105,000.0	319.2	0.4	0.2	0.6
12/25/2022 03:00	3,032.5	0.0	3,032.5	105,000.0	318.4	0.4	0.2	0.6
12/25/2022 04:00	3,030.7	0.0	3,030.7	105,000.0	318.2	0.4	0.2	0.6
12/25/2022 05:00	3,018.5	0.0	3,018.5	105,000.0	316.9	0.4	0.2	0.6
12/25/2022 06:00	3,015.4	0.0	3,015.4	105,000.0	316.6	0.4	0.2	0.6
12/25/2022 07:00	2,984.7	0.0	2,984.7	105,000.0	313.4	0.4	0.2	0.6
12/25/2022 08:00	3,009.9	0.0	3,009.9	105,000.0	316.0	0.4	0.2	0.6
12/25/2022 09:00	3,345.8	0.0	3,345.8	105,000.0	351.3	0.4	0.2	0.7
12/25/2022 10:00	3,044.6	0.0	3,044.6	105,000.0	319.7	0.4	0.2	0.6
12/25/2022 11:00	3,098.6	0.0	3,098.6	105,000.0	325.4	0.4	0.2	0.6
12/25/2022 12:00	3,231.2	0.0	3,231.2	105,000.0	339.3	0.4	0.2	0.7
12/25/2022 13:00	2,995.2	0.0	2,995.2	105,000.0	314.5	0.4	0.2	0.6
12/25/2022 14:00	2,945.6	0.0	2,945.6	105,000.0	309.3	0.4	0.2	0.6
12/25/2022 15:00	2,888.7	0.0	2,888.7	105,000.0	303.3	0.4	0.2	0.6
12/25/2022 16:00	3,875.8	78.8	3,901.8	105,000.0	409.7	0.5	0.2	0.8
12/25/2022 17:00	4,949.4	205.8	5,155.2	105,000.0	541.3	0.6	0.3	1.1
12/25/2022 18:00	3,628.7	0.3	3,628.7	105,000.0	381.0	0.5	0.2	0.8
12/25/2022 19:00	2,982.3	0.0	2,982.3	105,000.0	313.1	0.4	0.2	0.6
12/25/2022 20:00	2,992.3	0.0	2,992.3	105,000.0	314.2	0.4	0.2	0.6
12/25/2022 21:00	2,995.1	0.0	2,995.1	105,000.0	314.5	0.4	0.2	0.6
12/25/2022 22:00	2,964.5	0.0	2,964.5	105,000.0	311.3	0.4	0.2	0.6
12/25/2022 23:00	2,951.8	0.0	2,951.8	105,000.0	309.9	0.4	0.2	0.6
Average/Sum#:	3,178.5	11.9	3,188.1	105,000.0	334.8	0.4	0.2	0.7
Minimum:	2,888.7	0.0	2,888.7	105,000.0	303.3	0.4	0.2	0.6
Maximum:	4,949.4	205.8	5,155.2	105,000.0	541.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	3,178.7	0.0	3,178.7	105,000.0	333.8	0.4	0.2	0.7
12/26/2022 01:00	2,999.7	0.0	2,999.7	105,000.0	315.0	0.4	0.2	0.6
12/26/2022 02:00	3,138.3	0.0	3,138.3	105,000.0	329.5	0.4	0.2	0.7
12/26/2022 03:00	3,040.5	0.0	3,040.5	105,000.0	319.3	0.4	0.2	0.6
12/26/2022 04:00	3,000.5	0.0	3,000.5	105,000.0	315.1	0.4	0.2	0.6
12/26/2022 05:00	3,557.3	0.0	3,557.3	105,000.0	373.5	0.4	0.2	0.7
12/26/2022 06:00	3,555.7	0.0	3,555.7	105,000.0	373.3	0.4	0.2	0.7
12/26/2022 07:00	3,018.2	0.0	3,018.2	105,000.0	316.9	0.4	0.2	0.6
12/26/2022 08:00	2,880.8	0.0	2,880.8	105,000.0	302.5	0.4	0.2	0.6
12/26/2022 09:00	3,012.4	0.0	3,012.4	105,000.0	316.3	0.4	0.2	0.6
12/26/2022 10:00	3,876.2	0.0	3,876.2	105,000.0	407.0	0.5	0.2	0.8
12/26/2022 11:00	4,796.9	101.5	4,844.6	105,000.0	508.7	0.6	0.3	1.0
12/26/2022 12:00	4,933.8	215.1	5,148.9	105,000.0	540.6	0.6	0.3	1.1
12/26/2022 13:00	4,909.1	354.4	5,263.5	105,000.0	552.7	0.7	0.3	1.1
12/26/2022 14:00	4,901.9	621.2	5,523.1	105,000.0	579.9	0.7	0.3	1.2
12/26/2022 15:00	4,901.1	669.8	5,570.9	105,000.0	584.9	0.7	0.4	1.2
12/26/2022 16:00	4,882.8	524.3	5,407.1	105,000.0	567.7	0.7	0.3	1.1
12/26/2022 17:00	4,883.2	641.8	5,525.0	105,000.0	580.1	0.7	0.3	1.2
12/26/2022 18:00	4,886.5	626.2	5,512.7	105,000.0	578.8	0.7	0.3	1.2
12/26/2022 19:00	4,873.9	373.7	5,247.6	105,000.0	551.0	0.7	0.3	1.1
12/26/2022 20:00	4,856.6	380.4	5,237.0	105,000.0	549.9	0.7	0.3	1.1
12/26/2022 21:00	4,784.8	282.0	5,001.9	105,000.0	525.2	0.6	0.3	1.1
12/26/2022 22:00	3,047.1	0.0	3,047.1	105,000.0	319.9	0.4	0.2	0.6
12/26/2022 23:00	2,863.9	0.0	2,863.9	105,000.0	300.7	0.4	0.2	0.6
Average/Sum#:	3,949.2	199.6	4,143.8	105,000.0	435.1	0.5	0.3	0.9
Minimum:	2,863.9	0.0	2,863.9	105,000.0	300.7	0.4	0.2	0.6
Maximum:	4,933.8	669.8	5,570.9	105,000.0	584.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2022 00:00	2,904.4	0.0	2,904.4	105,000.0	305.0	0.4	0.2	0.6
12/27/2022 01:00	2,856.7	0.0	2,856.7	105,000.0	300.0	0.4	0.2	0.6
12/27/2022 02:00	2,853.7	0.0	2,853.7	105,000.0	299.6	0.4	0.2	0.6
12/27/2022 03:00	2,857.2	0.0	2,857.2	105,000.0	300.0	0.4	0.2	0.6
12/27/2022 04:00	2,854.3	0.0	2,854.3	105,000.0	299.7	0.4	0.2	0.6
12/27/2022 05:00	2,858.1	0.0	2,858.1	105,000.0	300.1	0.4	0.2	0.6
12/27/2022 06:00	2,892.7	0.0	2,892.7	105,000.0	303.7	0.4	0.2	0.6
12/27/2022 07:00	2,865.9	0.0	2,865.9	105,000.0	300.9	0.4	0.2	0.6
12/27/2022 08:00	2,990.1	0.0	2,990.1	105,000.0	314.0	0.4	0.2	0.6
12/27/2022 09:00	2,929.1	0.0	2,929.1	105,000.0	307.6	0.4	0.2	0.6
12/27/2022 10:00	2,864.8	0.0	2,864.8	105,000.0	300.8	0.4	0.2	0.6
12/27/2022 11:00	2,870.3	0.0	2,870.3	105,000.0	301.4	0.4	0.2	0.6
12/27/2022 12:00	2,878.9	0.0	2,878.9	105,000.0	302.3	0.4	0.2	0.6
12/27/2022 13:00	2,980.7	0.0	2,980.7	105,000.0	313.0	0.4	0.2	0.6
12/27/2022 14:00	2,974.3	0.0	2,974.3	105,000.0	312.3	0.4	0.2	0.6
12/27/2022 15:00	2,882.1	0.0	2,882.1	105,000.0	302.6	0.4	0.2	0.6
12/27/2022 16:00	2,889.3	0.0	2,889.3	105,000.0	303.4	0.4	0.2	0.6
12/27/2022 17:00	2,872.3	0.0	2,872.3	105,000.0	301.6	0.4	0.2	0.6
12/27/2022 18:00	2,888.5	0.0	2,888.5	105,000.0	303.3	0.4	0.2	0.6
12/27/2022 19:00	2,869.3	0.0	2,869.3	105,000.0	301.3	0.4	0.2	0.6
12/27/2022 20:00	2,864.1	0.0	2,864.1	105,000.0	300.7	0.4	0.2	0.6
12/27/2022 21:00	2,862.5	0.0	2,862.5	105,000.0	300.6	0.4	0.2	0.6
12/27/2022 22:00	2,860.8	0.0	2,860.8	105,000.0	300.4	0.4	0.2	0.6
12/27/2022 23:00	2,906.8	0.0	2,906.8	105,000.0	305.2	0.4	0.2	0.6
Average/Sum#:	2,888.6	0.0	2,888.6	105,000.0	303.3	0.4	0.2	0.6
Minimum:	2,853.7	0.0	2,853.7	105,000.0	299.6	0.4	0.2	0.6
Maximum:	2,990.1	0.0	2,990.1	105,000.0	314.0	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2022 00:00	3,285.1	0.0	3,285.1	105,000.0	344.9	0.4	0.2	0.7
12/28/2022 01:00	2,944.9	0.0	2,944.9	105,000.0	309.2	0.4	0.2	0.6
12/28/2022 02:00	2,955.9	0.0	2,955.9	105,000.0	310.4	0.4	0.2	0.6
12/28/2022 03:00	2,954.2	0.0	2,954.2	105,000.0	310.2	0.4	0.2	0.6
12/28/2022 04:00	2,951.8	0.0	2,951.8	105,000.0	309.9	0.4	0.2	0.6
12/28/2022 05:00	2,955.7	0.0	2,955.7	105,000.0	310.3	0.4	0.2	0.6
12/28/2022 06:00	2,953.9	0.0	2,953.9	105,000.0	310.2	0.4	0.2	0.6
12/28/2022 07:00	2,957.4	0.0	2,957.4	105,000.0	310.5	0.4	0.2	0.6
12/28/2022 08:00	2,954.2	0.0	2,954.2	105,000.0	310.2	0.4	0.2	0.6
12/28/2022 09:00	2,956.6	0.0	2,956.6	105,000.0	310.4	0.4	0.2	0.6
12/28/2022 10:00	2,955.7	0.0	2,955.7	105,000.0	310.3	0.4	0.2	0.6
12/28/2022 11:00	2,959.6	0.0	2,959.6	105,000.0	310.8	0.4	0.2	0.6
12/28/2022 12:00	2,967.5	0.0	2,967.5	105,000.0	311.6	0.4	0.2	0.6
12/28/2022 13:00	2,946.3	0.0	2,946.3	105,000.0	309.4	0.4	0.2	0.6
12/28/2022 14:00	2,923.3	0.0	2,923.3	105,000.0	306.9	0.4	0.2	0.6
12/28/2022 15:00	2,946.0	0.0	2,946.0	105,000.0	309.3	0.4	0.2	0.6
12/28/2022 16:00	3,011.4	0.0	3,011.4	105,000.0	316.2	0.4	0.2	0.6
12/28/2022 17:00	2,949.6	0.0	2,949.6	105,000.0	309.7	0.4	0.2	0.6
12/28/2022 18:00	2,954.3	0.0	2,954.3	105,000.0	310.2	0.4	0.2	0.6
12/28/2022 19:00	2,960.3	0.0	2,960.3	105,000.0	310.8	0.4	0.2	0.6
12/28/2022 20:00	2,961.4	0.0	2,961.4	105,000.0	310.9	0.4	0.2	0.6
12/28/2022 21:00	2,972.5	0.0	2,972.5	105,000.0	312.1	0.4	0.2	0.6
12/28/2022 22:00	2,963.0	0.0	2,963.0	105,000.0	311.1	0.4	0.2	0.6
12/28/2022 23:00	2,969.8	0.0	2,969.8	105,000.0	311.8	0.4	0.2	0.6
Average/Sum#:	2,971.3	0.0	2,971.3	105,000.0	312.0	0.4	0.2	0.6
Minimum:	2,923.3	0.0	2,923.3	105,000.0	306.9	0.4	0.2	0.6
Maximum:	3,285.1	0.0	3,285.1	105,000.0	344.9	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	2,964.8	0.0	2,964.8	105,000.0	311.3	0.4	0.2	0.6
12/29/2022 01:00	2,974.4	0.0	2,974.4	105,000.0	312.3	0.4	0.2	0.6
12/29/2022 02:00	2,964.9	0.0	2,964.9	105,000.0	311.3	0.4	0.2	0.6
12/29/2022 03:00	2,967.0	0.0	2,967.0	105,000.0	311.5	0.4	0.2	0.6
12/29/2022 04:00	2,964.5	0.0	2,964.5	105,000.0	311.3	0.4	0.2	0.6
12/29/2022 05:00	2,966.5	0.0	2,966.5	105,000.0	311.5	0.4	0.2	0.6
12/29/2022 06:00	2,961.1	0.0	2,961.1	105,000.0	310.9	0.4	0.2	0.6
12/29/2022 07:00	2,962.8	0.0	2,962.8	105,000.0	311.1	0.4	0.2	0.6
12/29/2022 08:00	2,970.5	0.0	2,970.5	105,000.0	311.9	0.4	0.2	0.6
12/29/2022 09:00	2,970.1	0.0	2,970.1	105,000.0	311.9	0.4	0.2	0.6
12/29/2022 10:00	2,970.5	0.0	2,970.5	105,000.0	311.9	0.4	0.2	0.6
12/29/2022 11:00	2,964.9	0.0	2,964.9	105,000.0	311.3	0.4	0.2	0.6
12/29/2022 12:00	2,954.1	0.0	2,954.1	105,000.0	310.2	0.4	0.2	0.6
12/29/2022 13:00	2,946.6	0.0	2,946.6	105,000.0	309.4	0.4	0.2	0.6
12/29/2022 14:00	2,944.4	0.0	2,944.4	105,000.0	309.2	0.4	0.2	0.6
12/29/2022 15:00	2,950.8	0.0	2,950.8	105,000.0	309.8	0.4	0.2	0.6
12/29/2022 16:00	2,955.6	0.0	2,955.6	105,000.0	310.3	0.4	0.2	0.6
12/29/2022 17:00	2,954.2	0.0	2,954.2	105,000.0	310.2	0.4	0.2	0.6
12/29/2022 18:00	2,950.5	0.0	2,950.5	105,000.0	309.8	0.4	0.2	0.6
12/29/2022 19:00	2,950.4	0.0	2,950.4	105,000.0	309.8	0.4	0.2	0.6
12/29/2022 20:00	2,956.9	0.0	2,956.9	105,000.0	310.5	0.4	0.2	0.6
12/29/2022 21:00	2,948.3	0.0	2,948.3	105,000.0	309.6	0.4	0.2	0.6
12/29/2022 22:00	2,933.1	0.0	2,933.1	105,000.0	308.0	0.4	0.2	0.6
12/29/2022 23:00	2,923.1	0.0	2,923.1	105,000.0	306.9	0.4	0.2	0.6
Average/Sum#:	2,957.1	0.0	2,957.1	105,000.0	310.5	0.4	0.2	0.6
Minimum:	2,923.1	0.0	2,923.1	105,000.0	306.9	0.4	0.2	0.6
Maximum:	2,974.4	0.0	2,974.4	105,000.0	312.3	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2022 00:00	2,918.7	0.0	2,918.7	105,000.0	306.5	0.4	0.2	0.6
12/30/2022 01:00	2,918.1	0.0	2,918.1	105,000.0	306.4	0.4	0.2	0.6
12/30/2022 02:00	2,916.8	0.0	2,916.8	105,000.0	306.3	0.4	0.2	0.6
12/30/2022 03:00	2,926.0	0.0	2,926.0	105,000.0	307.2	0.4	0.2	0.6
12/30/2022 04:00	2,928.1	0.0	2,928.1	105,000.0	307.5	0.4	0.2	0.6
12/30/2022 05:00	2,920.3	0.0	2,920.3	105,000.0	306.6	0.4	0.2	0.6
12/30/2022 06:00	2,926.7	0.0	2,926.7	105,000.0	307.3	0.4	0.2	0.6
12/30/2022 07:00	2,924.3	0.0	2,924.3	105,000.0	307.1	0.4	0.2	0.6
12/30/2022 08:00	2,921.4	0.0	2,921.4	105,000.0	306.7	0.4	0.2	0.6
12/30/2022 09:00	2,915.0	0.0	2,915.0	105,000.0	306.1	0.4	0.2	0.6
12/30/2022 10:00	2,923.4	0.0	2,923.4	105,000.0	307.0	0.4	0.2	0.6
12/30/2022 11:00	2,919.1	0.0	2,919.1	105,000.0	306.5	0.4	0.2	0.6
12/30/2022 12:00	2,924.5	0.0	2,924.5	105,000.0	307.1	0.4	0.2	0.6
12/30/2022 13:00	2,925.0	0.0	2,925.0	105,000.0	307.1	0.4	0.2	0.6
12/30/2022 14:00	2,930.1	0.0	2,930.1	105,000.0	307.7	0.4	0.2	0.6
12/30/2022 15:00	2,936.0	0.0	2,936.0	105,000.0	308.3	0.4	0.2	0.6
12/30/2022 16:00	2,939.2	0.0	2,939.2	105,000.0	308.6	0.4	0.2	0.6
12/30/2022 17:00	2,946.2	0.0	2,946.2	105,000.0	309.4	0.4	0.2	0.6
12/30/2022 18:00	2,947.3	0.0	2,947.3	105,000.0	309.5	0.4	0.2	0.6
12/30/2022 19:00	2,958.3	0.0	2,958.3	105,000.0	310.6	0.4	0.2	0.6
12/30/2022 20:00	2,976.9	0.0	2,976.9	105,000.0	312.6	0.4	0.2	0.6
12/30/2022 21:00	2,987.8	0.0	2,987.8	105,000.0	313.7	0.4	0.2	0.6
12/30/2022 22:00	2,991.5	0.0	2,991.5	105,000.0	314.1	0.4	0.2	0.6
12/30/2022 23:00	2,992.2	0.0	2,992.2	105,000.0	314.2	0.4	0.2	0.6
Average/Sum#:	2,938.0	0.0	2,938.0	105,000.0	308.5	0.4	0.2	0.6
Minimum:	2,915.0	0.0	2,915.0	105,000.0	306.1	0.4	0.2	0.6
Maximum:	2,992.2	0.0	2,992.2	105,000.0	314.2	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2022 00:00	2,989.9	0.0	2,989.9	105,000.0	313.9	0.4	0.2	0.6
12/31/2022 01:00	2,989.0	0.0	2,989.0	105,000.0	313.8	0.4	0.2	0.6
12/31/2022 02:00	2,988.4	0.0	2,988.4	105,000.0	313.8	0.4	0.2	0.6
12/31/2022 03:00	2,982.6	0.0	2,982.6	105,000.0	313.2	0.4	0.2	0.6
12/31/2022 04:00	2,979.4	0.0	2,979.4	105,000.0	312.8	0.4	0.2	0.6
12/31/2022 05:00	2,979.9	0.0	2,979.9	105,000.0	312.9	0.4	0.2	0.6
12/31/2022 06:00	3,343.2	0.0	3,343.2	105,000.0	351.0	0.4	0.2	0.7
12/31/2022 07:00	3,510.0	0.0	3,510.0	105,000.0	368.6	0.4	0.2	0.7
12/31/2022 08:00	2,989.0	0.0	2,989.0	105,000.0	313.8	0.4	0.2	0.6
12/31/2022 09:00	3,228.1	0.0	3,228.1	105,000.0	339.0	0.4	0.2	0.7
12/31/2022 10:00	1,957.2	0.0	1,957.2	105,000.0	205.5	0.0	0.0	0.0
12/31/2022 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/31/2022 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/31/2022 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
12/31/2022 14:00	2,593.3	0.0	2,593.3	105,000.0	272.3	0.0	0.0	0.0
12/31/2022 15:00	3,329.3	0.0	3,329.3	105,000.0	349.6	0.4	0.2	0.7
12/31/2022 16:00	2,954.2	0.0	2,954.2	105,000.0	310.2	0.4	0.2	0.6
12/31/2022 17:00	2,928.9	0.0	2,928.9	105,000.0	307.5	0.4	0.2	0.6
12/31/2022 18:00	2,925.0	0.0	2,925.0	105,000.0	307.1	0.4	0.2	0.6
12/31/2022 19:00	2,931.5	0.0	2,931.5	105,000.0	307.8	0.4	0.2	0.6
12/31/2022 20:00	2,924.3	0.0	2,924.3	105,000.0	307.1	0.4	0.2	0.6
12/31/2022 21:00	2,932.0	0.0	2,932.0	105,000.0	307.9	0.4	0.2	0.6
12/31/2022 22:00	2,954.2	0.0	2,954.2	105,000.0	310.2	0.4	0.2	0.6
12/31/2022 23:00	2,971.7	0.0	2,971.7	105,000.0	312.0	0.4	0.2	0.6
Average/Sum#:	2,970.5	0.0	2,970.5	105,000.0	311.9	0.4	0.2	0.6
Minimum:	1,957.2	0.0	1,957.2	105,000.0	205.5	0.4	0.2	0.6
Maximum:	3,510.0	0.0	3,510.0	105,000.0	368.6	0.4	0.2	0.7
%SI	12.50	12.50	12.50	0.00	12.50	20.83	20.83	20.83

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

10/19,25,26/22 Taylor Sullivan

Q3 EDR

Cylinder Gas Audit

01/03/2023

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scal CO / High

Test Date: 10/04/2022
Test **Pass**

Instrument CT2_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Referen ce	Measure d Value	Ref Value As Pct Span
10/04/2022	08:23	L	200	49.400	50.000	24.7 %
10/04/2022	08:29	M	200	112.700	116.400	56.4 %
10/04/2022	08:41	L	200	49.400	49.900	24.7 %
10/04/2022	08:46	M	200	112.700	116.400	56.4 %
10/04/2022	08:58	L	200	49.400	50.000	24.7 %
10/04/2022	09:03	M	200	112.700	116.400	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.400	49.967	Std	1.1
M	112.700	116.400	Std	3.3

Cylinder Gas Audit

01/03/2023

Page 2

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	08:26	L	200	50.300	49.700	25.2 %
10/04/2022	08:31	M	200	112.800	114.700	56.4 %
10/04/2022	08:43	L	200	50.300	49.700	25.2 %
10/04/2022	08:48	M	200	112.800	114.400	56.4 %
10/04/2022	09:00	L	200	50.300	49.700	25.2 %
10/04/2022	09:05	M	200	112.800	114.400	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	50.300	49.700	Std	1.2
M	112.800	114.500	Std	1.5

Cylinder Gas Audit

01/03/2023

Page 3

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	12:28	L	10	2.400	2.200	24.0 %
10/04/2022	12:33	M	10	5.700	5.600	57.0 %
10/04/2022	12:40	L	10	2.400	2.200	24.0 %
10/04/2022	12:45	M	10	5.700	5.500	57.0 %
10/04/2022	12:52	L	10	2.400	2.200	24.0 %
10/04/2022	12:57	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference	Mean	CEMS Mean	Specification	Results
L	2.400		2.200	Std	8.3
M	5.700		5.533	Std	2.9

Cylinder Gas Audit

01/03/2023

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT2_CODualRg_P_Instr
Unit/Stack:	CT2	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	12:25	L	10	2.400	2.200	24.0 %
10/04/2022	12:31	M	10	5.700	5.600	57.0 %
10/04/2022	12:38	L	10	2.400	2.200	24.0 %
10/04/2022	12:43	M	10	5.700	5.500	57.0 %
10/04/2022	12:50	L	10	2.400	2.200	24.0 %
10/04/2022	12:55	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference	Mean	CEMS Mean	Specification	Results
L	2.400		2.200	Std	8.3
M	5.700		5.533	Std	2.9

CEMs Log

Date/Time	Operator	Description
12/20/22 0:56	Operator (RC)	CT-2 LO NOX, CYL# EB0068598 NO@ 8.891, CO @ 8.950, EXP 7-28-23
12/19/22 8:53	Operator (GAB)	CHANGED UNIT 1 O2 DAILY CALIBRATION CYCLINDER EB0022072, EXP 3/2/22
12/18/22 16:05	Operator (LHR)	CHANGED UNIT 2 HI NOX/CO DAILY CALIBRATION CYLINDER CC751091 EXP 10/2/2030
12/10/22 11:07	Operator (JB)	CHANGED 2 SEPARATE BOTTLES ON UNIT 1 HIGH CO/NOX CYLINDER #EB0038215 CO 180 PPM NO 181.3 PPM EXP DATE 9/20/30 SCR INLET NOX CYLINDER #EB0078105 NO 24.3 PPM EXP DATE 7/20/25
12/05/22 23:49	Operator (LHR)	UPDATED GCV VALUE FOR DECEMBER TO 105,000
11/26/22 15:36	Operator (RC)	CHANGED UNIT 2 STACK INLET NOX CYLINDER # CC723474, EXP DATE 09/13/2025
11/22/22 3:03	Operator (RC)	CHANGED UNIT 1 LO NOX/CO, BOTTLE # EB0061315, EXP DATE 12-1-23
11/19/22 10:57	Operator (CC)	CHANGED UNIT 2 O2 DAILY CALIBRATION CYLINDER EB0012456, EXP 11-18-26
11/18/22 15:57	Operator (GB)	CHANGED UNIT 1 O2 DAILY CALIBRATION CYLINDER SG9152174, EXP 3-3-27
11/14/22 13:36	Operator (JB)	REPLACED UNIT 2 HIGH NOX/CO BOTTLE. CYLINDER # EB0025001 CONCENTRATION NOX 181.5 CO 184.1 EXPIRATION DATE 1-5-25
11/08/22 11:20	Operator (DWN)	DAYLIGHT SAVINGS BIAS UPDATED TO -60
11/07/22 9:32	Operator (RG)	CT2 CORRECTED AMMONIA BIAS FROM 1.39 TO .139
11/02/22 12:17	Operator (RV)	UPDATED GCV FOR NOVEMBER TO 104,046
11/02/22 9:24	Operator (RGG)	CHANGED UNIT 2 INLET NOX CYLINDER EB0144594 EXP 12/28/24
11/02/22 9:18	Operator (RGG)	CHANGED UNIT 1 HI NOX/CO DAILY CALIBRATION CYLINDER EB0144769 EXP 1/6/25
10/27/22 12:06	Operator (BRB)	CHANGED UNIT 2 NH3 CORRECTION FACTOR FROM 0.128 TO 1.39 CHANGED UNIT 2 NOX CORRECTION BIAS FROM 1.00 TO 1.111 UNIT 1 NOX CORRECTION BIAS WAS ALREADY AT DESIRED SETPOINT AT 1.0 SO I DID NOT CHANGE IT.
10/25/22 13:32	Operator (BRB)	CHANGED UNIT 1 NH3 CORRECTION FACTOR FROM 0.319 to .0164
10/24/22 16:40	Operator (CC)	CHANGED UNIT 2 STACK LOW CO/NOX BOTTLE. BOTTLE #EB0126745. CO 8.212 PPM, NOX 9.572 PPM. EXP 10/21/23
10/15/22 13:14	Operator (JB)	CHANGED OUT UNIT 1 O2 BOTTLE CYLINDER # EB0105790 CERTIFIED CONCENTRATION 18.18% EXPERATION DATE 3/3/27

Date/Time	Operator	Description
10/07/22 21:19	Operator (DE)	CHANGED OUT UNIT 2 O2 BOTTLE ID#EB0025148 EXP DATE 1/3/27
10/05/22 10:32	Operator (RGG)	CHANGED OUT UNIT 2 HI NOX/CO DAILY CALIBRATION CYLINDER EB0144772 EXP 1/6/25
10/02/22 22:56	Operator (JB)	UPDATED GCV VALUE FOR OCTOBER TO 105,600

Linearity Report

01/03/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	123	Highest	2.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0823	L	200.0	48.2	47.1		24.1 %
10/04/2022	0829	M	200.0	106.0	108.4		53.0 %
10/04/2022	0834	H	200.0	180.0	180.5		90.0 %
10/04/2022	0841	L	200.0	48.2	47.9		24.1 %
10/04/2022	0846	M	200.0	106.0	108.7		53.0 %
10/04/2022	0851	H	200.0	180.0	180.4		90.0 %
10/04/2022	0858	L	200.0	48.2	48.3		24.1 %
10/04/2022	0903	M	200.0	106.0	108.7		53.0 %
10/04/2022	0908	H	200.0	180.0	180.3		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	47.767	No	0.9
M	106.000	108.600	No	2.5
H	180.000	180.400	No	0.2

Linearity Report

01/03/2023

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	124	Highest	0.0
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1024	L	21.0	5.0	5.0		23.8 %
10/04/2022	1030	M	21.0	11.2	11.2		53.3 %
10/04/2022	1035	H	21.0	18.3	18.3		87.1 %
10/04/2022	1042	L	21.0	5.0	5.0		23.8 %
10/04/2022	1047	M	21.0	11.2	11.2		53.3 %
10/04/2022	1052	H	21.0	18.3	18.3		87.1 %
10/04/2022	1059	L	21.0	5.0	5.0		23.8 %
10/04/2022	1104	M	21.0	11.2	11.2		53.3 %
10/04/2022	1109	H	21.0	18.3	18.3		87.1 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.200	11.200	No	0.0
H	18.300	18.300	No	0.0

Linearity Report

01/03/2023

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	120	Highest	2.6
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0826	L	200.0	47.8	45.0		23.9 %
10/04/2022	0831	M	200.0	105.0	107.3		52.5 %
10/04/2022	0836	H	200.0	180.0	180.6		90.0 %
10/04/2022	0843	L	200.0	47.8	48.9		23.9 %
10/04/2022	0848	M	200.0	105.0	107.9		52.5 %
10/04/2022	0853	H	200.0	180.0	180.8		90.0 %
10/04/2022	0900	L	200.0	47.8	49.5		23.9 %
10/04/2022	0905	M	200.0	105.0	108.1		52.5 %
10/04/2022	0910	H	200.0	180.0	181.0		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.800	47.800	No	0.0
M	105.000	107.767	No	2.6
H	180.000	180.800	No	0.4

Linearity Report

01/03/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	121	Highest	1.8
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1027	L	21.0	5.7	5.6		27.1 %
10/04/2022	1032	M	21.0	11.1	11.1		52.9 %
10/04/2022	1037	H	21.0	18.1	18.2		86.2 %
10/04/2022	1044	L	21.0	5.7	5.6		27.1 %
10/04/2022	1049	M	21.0	11.1	11.1		52.9 %
10/04/2022	1054	H	21.0	18.1	18.2		86.2 %
10/04/2022	1101	L	21.0	5.7	5.6		27.1 %
10/04/2022	1106	M	21.0	11.1	11.1		52.9 %
10/04/2022	1111	H	21.0	18.1	18.2		86.2 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.700	5.600	No	1.8
M	11.100	11.100	No	0.0
H	18.100	18.200	No	0.6

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 02:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 02:20	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 02:25	200.0	180.0	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 02:20	30.0	26.7	26.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 03:25	200.0	183.7	184.7	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/01/22 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/22 03:15	21.0	18.1	18.3	R-A		0.2
	Zero	10/01/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 03:25	200.0	183.5	185.0	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/22 03:19	10.0	8.6	8.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/22 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/01/22 03:25	200.0	180.0	180.8	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/22 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/01/22 03:19	10.0	8.3	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/22 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/01/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 02:24	200.0	180.0	179.8	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 02:20	30.0	26.7	26.7	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 02:24	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:25	200.0	183.7	184.7	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/02/22 03:14	21.0	18.1	18.3	R-A		0.2
	Zero	10/02/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:25	200.0	183.5	185.0	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/22 03:19	10.0	8.6	8.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/22 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/02/22 03:25	200.0	180.0	180.6	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/22 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/02/22 03:19	10.0	8.3	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/02/22 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/02/22 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/03/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 02:25	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/03/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/03/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 02:25	200.0	180.0	179.8	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/03/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 02:20	30.0	26.7	26.6	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:24	200.0	183.5	184.0	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:19	10.0	8.6	8.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/03/22 03:24	200.0	180.0	180.3	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/03/22 03:19	10.0	8.3	8.2	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/22 03:14	21.0	18.3	R-A		0.0
	Zero	10/03/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:25	200.0	183.7	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:20	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:25	200.0	180.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/22 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/22 03:14	21.0	18.1	R-A		0.2
	Zero	10/03/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 02:25	200.0	180.0	R-A /Span * 100		0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 02:20	30.0	27.2	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 02:25	200.0	180.0	R-A /Span * 100		1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 02:19	30.0	26.7	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 03:25	200.0	183.7	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 03:19	10.0	9.7	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 03:25	200.0	180.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/22 03:14	21.0	18.1	R-A		0.2
	Zero	10/04/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/22 03:25	200.0	183.5	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/04/22 03:20	10.0	8.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/04/22 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/22 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/04/22 03:20	10.0	8.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/22 03:14	21.0	18.3	R-A		0.0
	Zero	10/04/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/05/22 02:25	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/05/22 02:20	30.0	27.2	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/05/22 02:25	200.0	180.0	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/05/22 02:20	30.0	26.7	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/22 03:24	200.0	183.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/05/22 03:20	10.0	9.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/22 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/05/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/05/22 03:14	21.0	18.1		R-A	0.1
	Zero	10/05/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/22 03:25	200.0	183.5		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/05/22 03:20	10.0	8.6		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/05/22 03:25	200.0	180.0		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/05/22 03:20	10.0	8.3		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/05/22 03:14	21.0	18.3		R-A	0.0
	Zero	10/05/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/06/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/06/22 02:25	200.0	180.0		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/06/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/06/22 02:20	30.0	27.2		R-A /Span * 100	1.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 02:25	200.0	181.0	177.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 02:19	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:25	200.0	183.7	183.8	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/22 03:15	21.0	18.1	18.3	R-A		0.2
	Zero	10/06/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:25	200.0	183.5	184.4	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/22 03:20	10.0	8.6	8.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/06/22 03:25	200.0	181.0	179.9	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/22 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/06/22 03:20	10.0	8.3	8.1	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/22 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/06/22 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 02:24	200.0	181.0	177.9	R-A /Span * 100		1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 02:19	30.0	26.7	26.3	R-A /Span * 100		1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 02:24	200.0	180.0	179.4	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 02:19	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:25	200.0	183.7	183.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/22 03:15	21.0	18.1	18.3	R-A		0.2
	Zero	10/07/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:25	200.0	183.5	183.9	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/22 03:20	10.0	8.6	8.7	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/07/22 03:25	200.0	181.0	180.2	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/22 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/07/22 03:20	10.0	8.3	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/22 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/07/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 02:25	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 02:20	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 02:24	200.0	181.0	178.8	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 02:20	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 03:25	200.0	183.7	183.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/08/22 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	10/08/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/22 03:25	200.0	183.5	184.0	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/22 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/08/22 03:20	10.0	8.6	8.6	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/22 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/08/22 03:25	200.0	181.0	180.1	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/22 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/08/22 03:20	10.0	8.3	8.2	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/08/22 03:15	21.0	18.1	18.1	R-A	0.0
	Zero	10/08/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 02:25	200.0	180.0	179.3	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 02:20	30.0	27.2	26.6	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 03:25	200.0	183.7	183.8	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 03:19	10.0	9.7	9.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 03:25	200.0	180.0	179.3	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/22 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/09/22 03:15	21.0	18.1	18.3	R-A	0.2
	Zero	10/09/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/10/22 02:24	200.0	180.0	179.2	R-A /Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/22 02:19	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/10/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/22 03:25	200.0	183.7	183.8	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/22 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/10/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/22 03:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/22 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/10/22 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	10/10/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 02:25	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 03:25	200.0	183.7	183.9	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 03:25	200.0	180.0	176.5	R-A /Span * 100		1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/22 03:20	10.0	8.8	8.6	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/11/22 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	10/11/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 02:24	200.0	180.0	180.1	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 02:20	30.0	27.2	26.6	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 03:25	200.0	183.7	183.6	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 03:19	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 03:25	200.0	180.0	176.2	R-A /Span * 100	1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/22 03:19	10.0	8.8	8.5	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/12/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	10/12/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/22 02:25	200.0	180.0	179.6	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/22 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/22 02:20	30.0	27.2	26.8	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/22 03:25	200.0	183.7	183.6	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/22 03:20	10.0	9.7	9.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/13/22 03:25	200.0	180.0		R-A /Span * 100	1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/13/22 03:20	10.0	8.8		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/22 03:15	21.0	18.1		R-A	0.1
	Zero	10/13/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 02:25	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 02:20	30.0	27.2		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 03:25	200.0	183.7		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 03:25	200.0	180.0		R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/14/22 03:19	10.0	8.8		R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/14/22 03:14	21.0	18.1		R-A	0.1
	Zero	10/14/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/15/22 02:25	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/15/22 02:19	30.0	27.2		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/15/22 03:25	200.0	183.7		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/15/22 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/15/22 03:25	200.0	180.0		R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/15/22 03:19	10.0	8.8	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/22 03:14	21.0	18.1		R-A	0.1
	Zero	10/15/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/16/22 02:25	200.0	180.0		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/16/22 02:20	30.0	27.2		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/16/22 03:25	200.0	183.7		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/16/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/16/22 03:25	200.0	180.0		R-A /Span * 100	1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/16/22 03:20	10.0	8.8	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/22 03:14	21.0	18.2		R-A	0.2
	Zero	10/16/22 03:20	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/22 02:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/22 02:19	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/22 03:25	200.0	183.7	183.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/17/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/22 03:25	200.0	180.0	175.8	R-A /Span * 100		2.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/22 03:19	10.0	8.8	8.5	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/17/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	10/17/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/22 02:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/22 02:19	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/22 03:25	200.0	183.7	183.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/22 03:25	200.0	180.0	179.3	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/18/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/18/22 03:15	21.0	18.2		R-A	0.2
	Zero	10/18/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/22 16:51	200.0	0.0		R-A /Span * 100	0.0
	High	10/18/22 17:02	200.0	183.5		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/22 16:51	10.0	0.0		R-A /Span * 100	0.0
	High	10/18/22 16:57	10.0	8.6		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/22 16:51	200.0	0.0		R-A /Span * 100	0.0
	High	10/18/22 17:02	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/22 16:51	10.0	0.0		R-A /Span * 100	0.0
	High	10/18/22 16:57	10.0	8.3		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/18/22 16:51	21.0	18.1		R-A	0.1
	Zero	10/18/22 16:57	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/19/22 02:25	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/19/22 02:20	30.0	27.2		R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/19/22 02:24	200.0	181.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/19/22 02:19	30.0	26.7		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/19/22 03:25	200.0	183.7		R-A /Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:20	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:25	200.0	180.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/19/22 03:14	21.0	18.2	R-A		0.2
	Zero	10/19/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:25	200.0	183.5	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:20	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:25	200.0	181.0	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/19/22 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/19/22 03:15	21.0	18.1	R-A		0.1
	Zero	10/19/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 02:24	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 02:19	30.0	27.2	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 02:24	200.0	181.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 02:19	30.0	26.7	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:24	200.0	183.7	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:20	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:24	200.0	180.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/20/22 03:14	21.0	18.2	R-A		0.2
	Zero	10/20/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:24	200.0	183.5	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:20	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:24	200.0	181.0	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/20/22 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/20/22 03:14	21.0	18.1	R-A		0.1
	Zero	10/20/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 02:24	200.0	181.0	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 02:19	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 02:25	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 02:20	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:25	200.0	183.7	183.9	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:25	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/21/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	10/21/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:25	200.0	183.5	184.7	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:19	10.0	8.6	8.7	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:25	200.0	181.0	177.8	R-A /Span * 100		1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/22 03:19	10.0	8.3	8.2	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/21/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/21/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 02:24	200.0	180.0	180.9	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 02:20	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 02:25	200.0	181.0	177.6	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 02:19	30.0	26.7	26.3	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 03:25	200.0	183.7	184.6	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/22/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 03:25	200.0	180.0	179.2	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/22/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	10/22/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 03:25	200.0	183.5	185.3	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/22 03:20	10.0	8.6	8.7	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/22/22 03:25	200.0	181.0		R-A /Span * 100	1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/22/22 03:20	10.0	8.3		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/22/22 03:15	21.0	18.1		R-A	0.1
	Zero	10/22/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 02:24	200.0	181.0		R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 02:19	30.0	26.7		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 02:25	200.0	180.0		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 02:20	30.0	27.2		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 03:25	200.0	183.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 03:20	10.0	9.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 03:25	200.0	180.0		R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/23/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/23/22 03:14	21.0	18.2		R-A	0.2
	Zero	10/23/22 03:20	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/22 03:25	200.0	183.5	185.0	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/22 03:20	10.0	8.6	8.7	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/22 03:25	200.0	181.0	178.3	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/22 03:20	10.0	8.3	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/23/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	10/23/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 02:25	200.0	180.0	181.4	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 02:20	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 02:24	200.0	181.0	179.0	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 02:20	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:24	200.0	183.5	183.5	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:19	10.0	8.6	8.7	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:24	200.0	181.0	178.3	R-A /Span * 100		1.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:19	10.0	8.3	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/24/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/24/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:25	200.0	183.7	182.8	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:25	200.0	180.0	178.2	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/24/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	10/24/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/25/22 02:25	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 02:19	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 02:25	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 02:20	30.0	26.7	26.6	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:25	200.0	183.7	182.8	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:25	200.0	180.0	178.2	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/25/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	10/25/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/25/22 03:25	200.0	183.5	183.8	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/25/22 03:20	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:25	200.0	181.0	178.1	R-A /Span * 100		1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/22 03:20	10.0	8.2	8.2	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/25/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/25/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/26/22 02:25	200.0	180.0	181.3	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 02:20	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 02:25	200.0	181.0	179.3	R-A /Span * 100		0.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 02:20	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:25	200.0	183.7	183.3	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:25	200.0	180.0	178.7	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/26/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	10/26/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/26/22 03:24	200.0	183.5	184.2	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/26/22 03:19	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:24	200.0	181.0	177.9	R-A /Span * 100		1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/26/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/26/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/27/22 02:25	200.0	180.0	181.5	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 02:15	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	10/27/22 02:20	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 02:25	200.0	181.0	179.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 02:20	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:25	200.0	183.7	183.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:25	200.0	180.0	179.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/27/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	10/27/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/27/22 03:25	200.0	183.5	184.9	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/27/22 03:19	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:25	200.0	181.0	178.4	R-A /Span * 100		1.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/22 03:19	10.0	8.2	8.2	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/27/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	10/27/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 02:25	200.0	180.0	181.2	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 02:20	30.0	27.2	27.0	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 02:25	200.0	181.0	180.4	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 02:20	30.0	26.7	26.7	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 03:24	200.0	183.7	183.5	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/28/22 03:19	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 03:24	200.0	180.0	178.1	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/28/22 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/28/22 03:15	21.0	18.2	18.0	R-A	0.2
	Zero	10/28/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/28/22 03:24	200.0	183.5	184.3	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/28/22 03:20	10.0	9.6	9.8	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/28/22 03:24	200.0	181.0		R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/28/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/28/22 03:15	21.0	18.1		R-A	0.1
	Zero	10/28/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 02:24	200.0	180.0		R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 02:19	30.0	27.2		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 02:25	200.0	181.0		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 02:20	30.0	26.7		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 03:25	200.0	183.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 03:25	200.0	180.0		R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/29/22 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/22 03:15	21.0	18.2		R-A	0.2
	Zero	10/29/22 03:20	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/29/22 03:25	200.0	183.5	184.2	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/29/22 03:20	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/22 03:25	200.0	181.0	177.7	R-A /Span * 100		1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/29/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	10/29/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/22 02:25	200.0	180.0	181.4	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/30/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/22 02:19	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/22 02:25	200.0	181.0	180.1	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/30/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/22 02:19	30.0	26.7	26.7	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/30/22 03:24	200.0	183.5	184.7	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	10/30/22 03:19	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/22 03:24	200.0	181.0	177.7	R-A /Span * 100		1.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/22 03:19	10.0	8.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/22 03:15	21.0	18.1		R-A	0.1
	Zero	10/30/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/30/22 03:25	200.0	183.7		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/30/22 03:25	200.0	180.0		R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/22 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/22 03:15	21.0	18.2		R-A	0.2
	Zero	10/30/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/31/22 02:25	200.0	180.0		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/31/22 02:19	30.0	27.2		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/31/22 02:24	200.0	181.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/31/22 02:20	30.0	26.7		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/31/22 03:25	200.0	183.7		R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/31/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/22 03:25	200.0	180.0	178.5	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/22 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/31/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	10/31/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/31/22 03:25	200.0	183.5	185.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/31/22 03:20	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/22 03:25	200.0	181.0	177.9	R-A /Span * 100		1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/31/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	10/31/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 02:25	200.0	180.0	180.7	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 02:20	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 02:25	200.0	181.0	179.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 02:20	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/01/22 03:25	200.0	183.7	184.6	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/01/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 03:25	200.0	180.0	178.7	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/01/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/01/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/01/22 03:25	200.0	183.5	186.0	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/01/22 03:19	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 03:25	200.0	181.0	177.4	R-A /Span * 100		1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/01/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/01/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 02:24	200.0	181.0	179.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 02:19	30.0	26.7	26.5	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 02:25	200.0	180.0	181.3	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 02:19	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 03:24	200.0	183.7	183.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/02/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 03:24	200.0	180.0	179.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/02/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/02/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/02/22 03:24	200.0	183.5	185.3	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/02/22 03:20	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 03:24	200.0	181.0	177.4	R-A /Span * 100		1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/02/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/02/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 02:25	200.0	181.0	179.2	R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 02:20	30.0	27.2	26.7	R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 02:25	200.0	181.0	179.7	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 02:19	30.0	27.5	27.0	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 03:24	200.0	183.4	182.8	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/03/22 03:20	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 03:24	200.0	181.0	178.5	R-A /Span * 100	1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/22 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/03/22 03:14	21.0	18.2	18.0	R-A	0.2
	Zero	11/03/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/03/22 03:24	200.0	183.5	185.0	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/03/22 03:20	10.0	9.6	9.8	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/03/22 03:24	200.0	181.0		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/03/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/03/22 03:14	21.0	18.1		R-A	0.1
	Zero	11/03/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 02:24	200.0	181.0		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 02:19	30.0	27.2		R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 02:25	200.0	181.0		R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 02:20	30.0	27.5		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:25	200.0	183.4		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:25	200.0	181.0		R-A /Span * 100	1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/22 03:15	21.0	18.2		R-A	0.2
	Zero	11/04/22 03:19	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/04/22 03:24	200.0	183.5		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	10.0	0.0		R-A /Span * 100	2.0
	High	11/04/22 03:20	10.0	9.6		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:24	200.0	181.0		R-A /Span * 100	1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/04/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/22 03:15	21.0	18.1		R-A	0.1
	Zero	11/04/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/22 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/05/22 02:25	200.0	181.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/05/22 02:20	30.0	27.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/22 02:24	200.0	181.0		R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/05/22 02:19	30.0	27.5	>1x Alert	R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/22 03:25	200.0	183.4		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/05/22 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/22 03:25	200.0	181.0		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/05/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	11/05/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/05/22 03:25	200.0	183.5	183.9	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/05/22 03:20	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/22 03:25	200.0	181.0	177.7	R-A /Span * 100		1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/05/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/05/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 02:24	200.0	181.0	177.6	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 02:19	30.0	27.5	26.8	R-A /Span * 100		2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 02:25	200.0	181.0	180.3	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/06/22 03:24	200.0	183.4	183.8	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/06/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 03:24	200.0	181.0	178.8	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/06/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/06/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/06/22 03:25	200.0	183.5	185.1	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/06/22 03:20	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 03:25	200.0	181.0	176.9	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/06/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/06/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/07/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 02:24	200.0	181.0	177.9	R-A /Span * 100		1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/07/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 02:19	30.0	27.5	26.8	R-A /Span * 100		2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/07/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 02:25	200.0	181.0	180.4	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 02:20	30.0	27.2	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/22 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	11/07/22 03:25	200.0	183.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/22 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	11/07/22 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 03:25	200.0	181.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/22 03:14	21.0	18.2	R-A		0.2
	Zero	11/07/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/22 03:15	200.0	0.1	R-A /Span * 100		0.1
	High	11/07/22 03:24	200.0	183.5	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/22 03:15	10.0	0.2	R-A /Span * 100		2.0
	High	11/07/22 03:20	10.0	9.6	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 03:24	200.0	181.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	11/07/22 03:20	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/22 03:15	21.0	18.1	R-A		0.1
	Zero	11/07/22 03:20	21.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/22 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	11/08/22 02:25	200.0	181.0	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/22 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	11/08/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/08/22 03:25	200.0	183.4	184.3	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/08/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/22 03:25	200.0	181.0	179.7	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/08/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/08/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/22 02:25	200.0	181.0	181.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/09/22 03:25	200.0	183.4	184.2	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/09/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/22 03:25	200.0	181.0	179.2	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/09/22 03:14	21.0	18.2	18.0	R-A	0.2
	Zero	11/09/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/22 21:59	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/09/22 22:10	200.0	183.5	183.5	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/22 21:59	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/09/22 22:04	10.0	9.6	9.8	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/22 21:59	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/09/22 22:10	200.0	181.0	177.8	R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/22 21:59	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/09/22 22:04	10.0	8.2	8.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/09/22 21:59	21.0	18.1	18.0	R-A	0.1
	Zero	11/09/22 22:04	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/10/22 02:24	200.0	181.0	180.6	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	11/10/22 02:19	30.0	27.2	26.8	R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/22 02:24	200.0	181.0	182.8	R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/22 02:19	30.0	27.5	28.1	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/10/22 03:24	200.0	183.5	183.6	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/10/22 03:19	10.0	9.6	9.8	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/10/22 03:24	200.0	181.0		R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/10/22 03:19	10.0	8.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/10/22 03:14	21.0	18.1		R-A	0.1
	Zero	11/10/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/10/22 03:25	200.0	183.4		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/10/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/10/22 03:25	200.0	181.0		R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/10/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/10/22 03:15	21.0	18.2		R-A	0.2
	Zero	11/10/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/11/22 02:25	200.0	181.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/11/22 02:19	30.0	27.2		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/11/22 02:24	200.0	181.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/11/22 02:20	30.0	27.5		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/11/22 03:24	200.0	183.5	183.8	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/11/22 03:19	10.0	9.6	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/22 03:24	200.0	181.0	178.0	R-A /Span * 100		1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/22 03:19	10.0	8.2	8.2	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/11/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/11/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/11/22 03:25	200.0	183.4	183.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/11/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/22 03:25	200.0	181.0	179.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/11/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/11/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 02:25	200.0	181.0	181.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 02:25	200.0	181.0	180.6	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 02:20	30.0	27.5	27.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/12/22 03:24	200.0	183.4	183.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/12/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 03:24	200.0	181.0	179.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/12/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/12/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/12/22 03:24	200.0	183.5	185.1	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/12/22 03:19	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/12/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 03:24	200.0	181.0	177.8	R-A /Span * 100		1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/12/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/12/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/12/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/12/22 03:19	21.0	0.0	0.1	R-A		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 02:24	200.0	181.0	181.1	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 02:25	200.0	181.0	179.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 02:20	30.0	27.5	27.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/13/22 03:24	200.0	183.4	183.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/13/22 03:19	10.0	9.7	9.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 03:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/13/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/13/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/13/22 03:24	200.0	183.5	184.7	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/13/22 03:19	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 03:24	200.0	181.0	178.1	R-A /Span * 100		1.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/13/22 03:19	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/13/22 03:14	21.0	18.1	R-A		0.1
	Zero	11/13/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 02:25	200.0	181.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 02:20	30.0	27.2	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 02:25	200.0	181.5	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 02:19	30.0	27.5	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/22 03:15	200.0	0.0	R-A /Span * 100		0.2
	High	11/14/22 03:24	200.0	184.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/22 03:15	10.0	0.0	R-A /Span * 100		2.0
	High	11/14/22 03:19	10.0	9.6	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 03:24	200.0	181.5	R-A /Span * 100		1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 03:19	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/14/22 03:15	21.0	18.1	R-A		0.1
	Zero	11/14/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/22 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/14/22 03:25	200.0	183.4	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/14/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 03:25	200.0	181.0	178.7	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/22 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/14/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/14/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 02:25	200.0	181.0	181.4	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 02:19	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 02:25	200.0	182.0	181.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 02:20	30.0	27.5	27.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/15/22 03:24	200.0	183.4	182.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/15/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 03:24	200.0	181.0	179.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/15/22 03:14	21.0	18.2	18.0	R-A	0.2
	Zero	11/15/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/15/22 03:24	200.0	184.1	185.3	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/15/22 03:20	10.0	9.6	9.9	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/15/22 03:24	200.0	182.0	179.2	R-A /Span * 100	1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/15/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/15/22 03:20	10.0	8.2	8.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/15/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/15/22 03:20	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/16/22 02:25	200.0	181.0	181.5	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/16/22 02:20	30.0	27.2	26.9	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/16/22 02:25	200.0	182.0	182.5	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/16/22 02:20	30.0	27.5	27.3	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/16/22 03:24	200.0	184.1	184.3	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/16/22 03:19	10.0	9.6	10.0	R-A /Span * 100	4.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/16/22 03:24	200.0	182.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/16/22 03:19	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/16/22 03:14	21.0	18.1		R-A	0.1
	Zero	11/16/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/16/22 03:25	200.0	183.4		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/16/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/16/22 03:25	200.0	181.0		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/16/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/16/22 03:15	21.0	18.2		R-A	0.2
	Zero	11/16/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 02:25	200.0	181.0		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 02:20	30.0	27.2		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 02:25	200.0	182.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 02:20	30.0	27.5		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/17/22 03:25	200.0	183.4		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/17/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 03:25	200.0	181.0		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/17/22 03:15	21.0	18.2		R-A	0.2
	Zero	11/17/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/17/22 03:25	200.0	184.1		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	10.0	0.0		R-A /Span * 100	2.0
	High	11/17/22 03:20	10.0	9.6		R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 03:25	200.0	182.0		R-A /Span * 100	1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/17/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/17/22 03:15	21.0	18.1		R-A	0.1
	Zero	11/17/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/18/22 02:24	200.0	181.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/18/22 02:20	30.0	27.2		R-A /Span * 100	1.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 02:25	200.0	182.0	182.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 02:20	30.0	27.5	27.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/22 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/18/22 03:24	200.0	184.1	186.1	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/22 03:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/18/22 03:20	10.0	9.6	10.0	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 03:24	200.0	182.0	179.6	R-A /Span * 100		1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/18/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/18/22 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/18/22 03:25	200.0	183.4	183.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/18/22 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 03:25	200.0	181.0	179.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/22 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/18/22 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	11/18/22 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 02:25	200.0	181.0	181.8	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/19/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 02:25	200.0	182.0	180.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/19/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 02:20	30.0	27.5	27.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 03:25	200.0	183.4	182.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/19/22 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 03:25	200.0	181.0	178.8	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/19/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/19/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/19/22 03:24	200.0	184.1	184.9	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/19/22 03:20	10.0	9.6	9.9	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/19/22 03:24	200.0	182.0	179.9	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/19/22 03:20	10.0	8.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/19/22 03:14	21.0	18.1		R-A	0.1
	Zero	11/19/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	11/20/22 02:24	200.0	181.5		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	11/20/22 02:19	30.0	27.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/20/22 02:24	200.0	182.0		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/20/22 02:19	30.0	27.5		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	200.0	0.1		R-A /Span * 100	0.1
	High	11/20/22 03:25	200.0	183.4		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	10.0	0.1		R-A /Span * 100	1.0
	High	11/20/22 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/20/22 03:25	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/20/22 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/20/22 03:15	21.0	18.1		R-A	0.1
	Zero	11/20/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	200.0	0.3		R-A /Span * 100	0.2
	High	11/20/22 03:25	200.0	184.1		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/20/22 03:19	10.0	9.6	9.9	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/22 03:25	200.0	182.0	179.5	R-A /Span * 100	1.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/22 03:19	10.0	8.2	8.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/20/22 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	11/20/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 02:25	200.0	181.0	181.3	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 02:19	30.0	27.2	26.9	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 02:25	200.0	182.0	179.7	R-A /Span * 100	1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 02:20	30.0	27.5	26.8	R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/21/22 03:25	200.0	183.4	182.6	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/21/22 03:20	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 03:25	200.0	181.0	178.6	R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/22 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/21/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/21/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/21/22 03:25	200.0	184.1	185.3	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/21/22 03:20	10.0	9.6	10.1	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/21/22 03:25	200.0	182.0	179.6	R-A /Span * 100		1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/21/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/21/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/21/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/21/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 02:25	200.0	181.0	181.2	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 02:25	200.0	182.0	180.3	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 02:20	30.0	27.5	26.9	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/22/22 03:25	200.0	183.4	182.6	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/22/22 03:20	10.0	8.7	8.8	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 03:25	200.0	181.0	178.4	R-A /Span * 100		1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 03:20	10.0	8.5	8.8	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/22/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/22/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/22/22 03:25	200.0	184.1	185.4	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/22/22 03:20	10.0	9.6	10.0	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 03:25	200.0	182.0	179.8	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/22/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/22/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 02:24	200.0	181.0	181.2	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 02:25	200.0	182.0	179.3	R-A /Span * 100		1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 02:20	30.0	27.5	26.7	>1x Alert R-A /Span * 100		2.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/23/22 03:24	200.0	183.4	183.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/23/22 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 03:24	200.0	181.0	178.1	R-A /Span * 100		1.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 03:19	10.0	8.5	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/23/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/23/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/23/22 03:25	200.0	184.1	185.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/23/22 03:20	10.0	9.6	10.0	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 03:25	200.0	182.0	179.0	R-A /Span * 100		1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/23/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/23/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/22 07:27	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 07:37	200.0	182.0	182.9	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/22 07:27	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/22 07:32	30.0	27.5	27.7	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 02:24	200.0	181.0	181.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 02:25	200.0	182.0	181.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 02:19	30.0	27.5	27.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/24/22 03:25	200.0	183.4	183.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/24/22 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 03:25	200.0	181.0	178.4	R-A /Span * 100		1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 03:19	10.0	8.5	8.8	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/24/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/24/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/24/22 03:25	200.0	184.1	185.3	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/24/22 03:20	10.0	9.6	10.0	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 03:25	200.0	182.0	179.0	R-A /Span * 100		1.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/24/22 03:20	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/24/22 03:14	21.0	18.1	R-A		0.1
	Zero	11/24/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 02:24	200.0	181.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 02:20	30.0	27.2	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 02:25	200.0	182.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 02:19	30.0	27.5	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/25/22 03:25	200.0	183.4	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/25/22 03:20	10.0	8.7	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 03:25	200.0	181.0	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/25/22 03:20	10.0	8.5	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/25/22 03:14	21.0	18.1	R-A		0.1
	Zero	11/25/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	200.0	0.0	R-A /Span * 100		0.2
	High	11/25/22 03:24	200.0	184.1	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	10.0	0.0		R-A /Span * 100	3.0
	High	11/25/22 03:19	10.0	9.6		R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/25/22 03:24	200.0	182.0		R-A /Span * 100	1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/25/22 03:19	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/25/22 03:14	21.0	18.1		R-A	0.1
	Zero	11/25/22 03:19	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 02:25	200.0	181.0		R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 02:19	30.0	27.2		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 02:25	200.0	182.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 02:20	30.0	27.5		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/26/22 03:25	200.0	183.4		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/26/22 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 03:25	200.0	181.0		R-A /Span * 100	1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/26/22 03:19	10.0	8.5	>1x Alert	R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/26/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/26/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/26/22 03:25	200.0	184.1	185.7	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/26/22 03:19	10.0	9.6	10.1	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/22 03:25	200.0	182.0	179.2	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/26/22 03:14	21.0	18.1	17.9	R-A		0.2
	Zero	11/26/22 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/22 02:24	200.0	181.0	181.7	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/22 02:20	30.0	27.2	26.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/22 02:25	200.0	182.0	182.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/22 02:19	30.0	24.5	23.9	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/27/22 03:25	200.0	183.4	183.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/27/22 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/27/22 03:25	200.0	181.0	178.6	R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/22 03:19	10.0	8.5	8.8	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/27/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/27/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/27/22 03:24	200.0	184.1	185.8	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/27/22 03:19	10.0	9.6	10.1	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/27/22 03:24	200.0	182.0	179.6	R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/27/22 03:19	10.0	8.2	8.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/27/22 03:14	21.0	18.1	17.9	R-A	0.2
	Zero	11/27/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/28/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/22 02:25	200.0	181.0	181.8	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/22 02:20	30.0	27.2	26.8	R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/28/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/22 02:25	200.0	182.0	182.4	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/22 02:19	30.0	24.5	23.8	R-A /Span * 100	2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/28/22 03:24	200.0	183.4	184.2	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/28/22 03:19	10.0	8.7	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/22 03:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/22 03:19	10.0	8.5	8.8	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/28/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/28/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/22 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/28/22 03:25	200.0	184.1	187.2	R-A /Span * 100		1.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/22 03:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/28/22 03:20	10.0	9.6	10.1	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/22 03:25	200.0	182.0	179.3	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/28/22 03:15	21.0	18.1	17.9	R-A		0.2
	Zero	11/28/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/29/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/29/22 02:24	200.0	181.0	182.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/29/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/29/22 02:19	30.0	27.2	26.9	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 02:24	200.0	182.0		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 02:19	30.0	24.5		R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	200.0	0.1		R-A /Span * 100	0.1
	High	11/29/22 03:25	200.0	183.4		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	10.0	0.1		R-A /Span * 100	1.0
	High	11/29/22 03:20	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 03:25	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 03:20	10.0	8.5	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/22 03:15	21.0	18.1		R-A	0.1
	Zero	11/29/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	200.0	0.0		R-A /Span * 100	0.2
	High	11/29/22 03:25	200.0	184.1		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	10.0	0.0		R-A /Span * 100	3.0
	High	11/29/22 03:20	10.0	9.6	>1x Alert	R-A /Span * 100	6.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 03:25	200.0	182.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/29/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/22 03:15	21.0	18.1		R-A	0.2
	Zero	11/29/22 03:20	21.0	0.0		R-A	0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 14:02	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/29/22 14:13	200.0	184.1	186.4	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 14:02	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/29/22 14:08	10.0	9.6	10.1	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/22 14:02	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/22 14:13	200.0	182.0	179.8	R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/22 14:02	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/22 14:08	10.0	8.2	8.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/22 14:02	21.0	18.1	18.0	R-A	0.1
	Zero	11/29/22 14:08	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 02:25	200.0	181.0	181.9	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 02:20	30.0	27.2	27.0	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 02:25	200.0	182.0	183.4	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 02:20	30.0	24.5	24.0	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 03:25	200.0	183.4	183.6	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 03:19	10.0	8.7	8.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/22 03:25	200.0	181.0	180.5	R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/30/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/30/22 03:14	21.0	18.0		R-A	0.1
	Zero	11/30/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 03:15	200.0	0.4		R-A /Span * 100	0.2
	High	11/30/22 03:25	200.0	184.1		R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 03:15	10.0	0.4		R-A /Span * 100	4.0
	High	11/30/22 03:20	10.0	10.2	>1x Alert	R-A /Span * 100	6.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/30/22 03:25	200.0	182.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/30/22 03:20	10.0	8.1		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/30/22 03:15	21.0	17.9		R-A	0.2
	Zero	11/30/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/01/22 02:25	200.0	181.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/01/22 02:20	30.0	27.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/01/22 02:25	200.0	182.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/01/22 02:19	30.0	24.5		R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/01/22 03:25	200.0	183.4		R-A /Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:25	200.0	181.0	180.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:19	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/01/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/01/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:25	200.0	184.1	185.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/01/22 03:20	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:25	200.0	182.0	179.3	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/01/22 03:14	21.0	18.1	17.9	R-A		0.2
	Zero	12/01/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/22 02:25	200.0	181.0	181.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/22 02:20	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/22 02:25	200.0	182.0	181.5	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 02:20	30.0	24.5	23.6 >1x Alert	R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 03:25	200.0	183.4	183.3	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 03:25	200.0	181.0	180.7	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 03:20	10.0	8.5	8.5	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/02/22 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	12/02/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/02/22 03:25	200.0	184.1	183.6	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/22 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/02/22 03:20	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/02/22 03:25	200.0	182.0	179.3	R-A /Span * 100	1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/02/22 03:20	10.0	8.2	8.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/02/22 03:14	21.0	18.1	17.9	R-A	0.2
	Zero	12/02/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/22 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/22 02:25	200.0	181.0	180.9	R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 02:20	30.0	27.2	26.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 02:25	200.0	182.0	181.8	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 02:19	30.0	24.5	23.8	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:25	200.0	183.4	183.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/03/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:25	200.0	181.0	180.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/03/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/03/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:24	200.0	184.1	183.9	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:20	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:24	200.0	182.0	179.1	R-A /Span * 100		1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/22 03:20	10.0	8.2	8.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/03/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	12/03/22 03:20	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/22 02:25	200.0	181.0	180.9	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/22 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/22 02:20	30.0	27.2	26.7	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/22 03:24	200.0	183.4	183.6	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/22 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/04/22 03:19	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/22 03:24	200.0	181.0	180.6	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/22 03:19	10.0	8.5	8.5	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/04/22 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	12/04/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/22 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/05/22 02:24	200.0	181.0	181.1	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/22 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/05/22 02:20	30.0	27.2	26.8	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/22 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/05/22 03:25	200.0	183.4	184.0	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/22 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/05/22 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 03:25	200.0	181.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 03:20	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/05/22 03:15	21.0	18.1		R-A	0.1
	Zero	12/05/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/22 19:10	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 19:20	200.0	184.1		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/22 19:10	10.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 19:14	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/22 19:10	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 19:20	200.0	182.0		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/22 19:10	10.0	0.0		R-A /Span * 100	0.0
	High	12/05/22 19:14	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/05/22 19:10	21.0	18.1		R-A	0.1
	Zero	12/05/22 19:14	21.0	0.0		R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/06/22 02:25	200.0	182.0		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/06/22 02:20	30.0	24.5		R-A /Span * 100	1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/06/22 03:25	200.0	184.1		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/06/22 03:19	10.0	9.6		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 03:25	200.0	182.0	R-A /Span * 100		1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 03:19	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/06/22 03:14	21.0	18.1	R-A		0.1
	Zero	12/06/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/22 17:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 17:24	200.0	183.4	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/22 17:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 17:19	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/22 17:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 17:24	200.0	181.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/22 17:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/06/22 17:19	10.0	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/06/22 17:14	21.0	18.1	R-A		0.1
	Zero	12/06/22 17:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 02:25	200.0	181.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 02:19	30.0	27.2	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 02:25	200.0	182.0	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 02:19	30.0	24.5	R-A /Span * 100		2.7

>1x Alert

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:24	200.0	183.4	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	12/07/22 03:19	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:24	200.0	181.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:19	10.0	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/07/22 03:14	21.0	18.1	R-A		0.1
	Zero	12/07/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:25	200.0	184.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	12/07/22 03:19	10.0	9.6	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:25	200.0	182.0	R-A /Span * 100		1.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/07/22 03:19	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/07/22 03:14	21.0	18.1	R-A		0.1
	Zero	12/07/22 03:19	21.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/08/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 02:25	200.0	181.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/08/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 02:20	30.0	27.2	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 02:25	200.0	182.0	181.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 02:19	30.0	24.5	24.3	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:25	200.0	183.4	183.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:25	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/08/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/08/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:24	200.0	184.1	183.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:24	200.0	182.0	179.3	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/08/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/08/22 03:19	21.0	0.0	0.1	R-A		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 02:25	200.0	181.0	180.7	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 02:20	30.0	27.2	26.6	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 02:25	200.0	182.0	180.9	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 02:19	30.0	24.5	24.3	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:24	200.0	184.1	183.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:19	10.0	9.6	9.4	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:24	200.0	182.0	178.6	R-A /Span * 100		1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/09/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	12/09/22 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/09/22 03:25	200.0	183.4	183.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/09/22 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:25	200.0	181.0	180.1	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/22 03:19	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/09/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	12/09/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 02:25	200.0	181.0	181.4	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 02:25	200.0	182.0	181.9	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 02:19	30.0	24.5	24.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/10/22 03:25	200.0	183.4	184.4	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/10/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:25	200.0	181.0	180.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/10/22 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/10/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:24	200.0	184.1	185.6	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:19	10.0	9.6	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:24	200.0	182.0	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/10/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/10/22 03:19	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/10/22 03:15	21.0	18.1	R-A		0.2
	Zero	12/10/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 02:25	200.0	181.3	R-A /Span * 100		2.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 02:20	30.0	24.3	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 02:25	200.0	182.0	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 02:20	30.0	24.5	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:24	200.0	180.0	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	12/11/22 03:19	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:24	200.0	181.3	R-A /Span * 100		2.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:19	10.0	8.5	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/11/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	12/11/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:25	200.0	184.1	186.0	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:25	200.0	182.0	179.2	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/11/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/11/22 03:19	10.0	8.2	8.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/11/22 03:14	21.0	18.1	17.9	R-A		0.2
	Zero	12/11/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/12/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/12/22 02:24	200.0	181.3	177.2	R-A /Span * 100		2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/12/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/12/22 02:20	30.0	24.3	24.7	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/12/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/12/22 02:24	200.0	182.0	180.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/12/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/12/22 02:19	30.0	24.5	24.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/12/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/12/22 03:25	200.0	180.0	178.8	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/12/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/12/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:25	200.0	181.3		R-A /Span * 100	1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:20	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/12/22 03:14	21.0	18.1		R-A	0.1
	Zero	12/12/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:25	200.0	184.1		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:20	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:25	200.0	182.0		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/12/22 03:15	21.0	18.1		R-A	0.2
	Zero	12/12/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/22 09:15	200.0	0.0		R-A /Span * 100	0.1
	High	12/12/22 09:26	200.0	180.0		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/22 09:15	10.0	0.0		R-A /Span * 100	1.0
	High	12/12/22 09:21	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/22 09:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 09:26	200.0	181.3		R-A /Span * 100	1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/22 09:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/12/22 09:21	10.0	8.5		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/12/22 09:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/12/22 09:21	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/13/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 02:24	200.0	181.3	178.0	R-A /Span * 100		1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 02:19	30.0	24.3	24.6	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/13/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/13/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 03:25	200.0	181.3	177.5	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/13/22 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	12/13/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/14/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/22 02:25	200.0	181.3	177.8	R-A /Span * 100		1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/14/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/22 02:20	30.0	24.3	24.7	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/14/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/22 03:24	200.0	180.0	178.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/14/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/22 03:19	10.0	8.7	8.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/14/22 03:24	200.0	181.3		R-A /Span * 100	2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/14/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/14/22 03:14	21.0	18.1		R-A	0.1
	Zero	12/14/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/15/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 02:24	200.0	181.3		R-A /Span * 100	1.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/15/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 02:19	30.0	24.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/15/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 03:24	200.0	180.0		R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/15/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/15/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 03:24	200.0	181.3		R-A /Span * 100	2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/15/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/15/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/15/22 03:14	21.0	18.1		R-A	0.1
	Zero	12/15/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/16/22 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/16/22 02:25	200.0	181.3		R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/16/22 02:14	30.0	0.0		R-A /Span * 100	0.3
	High	12/16/22 02:20	30.0	24.3		R-A /Span * 100	1.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/16/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/16/22 03:24	200.0	180.0		R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/16/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/16/22 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/16/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/16/22 03:24	200.0	181.3		R-A /Span * 100	2.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/16/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/16/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/16/22 03:14	21.0	18.2		R-A	0.2
	Zero	12/16/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/22 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/17/22 02:24	200.0	181.3		R-A /Span * 100	1.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/22 02:14	30.0	0.0		R-A /Span * 100	0.3
	High	12/17/22 02:20	30.0	24.3		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/22 03:24	200.0	180.0		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/17/22 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/22 03:24	200.0	181.3		R-A /Span * 100	1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/17/22 03:19	10.0	8.5		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/17/22 03:14	21.0	18.2		R-A	0.2
	Zero	12/17/22 03:19	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/17/22 05:10	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/17/22 05:19	200.0	184.1	183.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/17/22 05:10	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/17/22 05:14	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/17/22 05:10	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/17/22 05:19	200.0	182.0	180.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/17/22 05:10	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/17/22 05:14	10.0	8.2	8.2	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/17/22 05:10	21.0	18.1	18.0	R-A		0.1
	Zero	12/17/22 05:14	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/18/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 02:24	200.0	181.3	177.6	R-A /Span * 100		1.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/18/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 02:20	30.0	24.3	24.6	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/18/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 02:24	200.0	182.0	182.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/18/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 02:19	30.0	24.5	24.5	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/18/22 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/18/22 03:24	200.0	180.0	179.2	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/18/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/18/22 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/18/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:24	200.0	181.3	177.1	R-A /Span * 100		2.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:20	10.0	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/18/22 03:14	21.0	18.2	R-A		0.2
	Zero	12/18/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:25	200.0	184.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:20	10.0	9.6	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/22 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:25	200.0	182.0	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/22 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/18/22 03:20	10.0	8.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/18/22 03:15	21.0	18.1	R-A		0.1
	Zero	12/18/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/22 02:25	200.0	181.3	R-A /Span * 100		2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/19/22 02:19	30.0	24.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/22 02:25	200.0	182.0	R-A /Span * 100		3.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/19/22 02:20	30.0	24.5	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/22 03:24	200.0	185.0	R-A /Span * 100		4.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/19/22 03:20	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/19/22 03:24	200.0	182.0	>1x Alert	R-A /Span * 100	3.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/19/22 03:20	10.0	8.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/19/22 03:14	21.0	18.1		R-A	0.1
	Zero	12/19/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/19/22 03:25	200.0	180.0		R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/19/22 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/19/22 03:25	200.0	181.3		R-A /Span * 100	2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/19/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/19/22 03:14	21.0	18.2		R-A	0.2
	Zero	12/19/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 02:24	200.0	181.3		R-A /Span * 100	2.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 02:20	30.0	24.3		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 02:24	200.0	182.0		R-A /Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 02:20	30.0	24.5		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:25	200.0	180.0		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	10.0	0.1		R-A /Span * 100	1.0
	High	12/20/22 03:20	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:25	200.0	181.3		R-A /Span * 100	2.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:20	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/20/22 03:15	21.0	18.2		R-A	0.1
	Zero	12/20/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:25	200.0	185.0		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:25	200.0	182.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/20/22 03:19	10.0	8.9		R-A	0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/20/22 03:15	21.0	18.1		R-A	0.0
	Zero	12/20/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/21/22 02:25	200.0	181.3		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 02:20	30.0	24.3	24.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/22 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 02:25	200.0	182.0	180.4	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 02:20	30.0	24.5	24.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:25	200.0	180.0	178.8	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/21/22 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:25	200.0	181.3	176.8	R-A /Span * 100		2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:19	10.0	8.5	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/21/22 03:14	21.0	18.2	18.1	R-A		0.1
	Zero	12/21/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:25	200.0	185.0	185.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/21/22 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:25	200.0	182.0	182.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/22 03:19	10.0	8.9	8.0	R-A		0.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/21/22 03:14	21.0	18.1	R-A		0.0
	Zero	12/21/22 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 02:25	200.0	181.3	R-A /Span * 100		2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 02:20	30.0	24.3	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 02:24	200.0	182.0	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 02:20	30.0	24.5	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/22/22 03:25	200.0	180.0	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	12/22/22 03:20	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 03:25	200.0	181.3	R-A /Span * 100		2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 03:20	10.0	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/22/22 03:14	21.0	18.2	R-A		0.1
	Zero	12/22/22 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 03:25	200.0	185.0	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/22/22 03:19	10.0	9.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/22 03:25	200.0	182.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/22 03:19	10.0	8.9		R-A	0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/22/22 03:14	21.0	18.1		R-A	0.0
	Zero	12/22/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/23/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 02:24	200.0	180.2		R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 02:19	30.0	24.5		R-A /Span * 100	1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/23/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 02:25	200.0	181.3		R-A /Span * 100	2.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 02:20	30.0	24.3		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/23/22 03:25	200.0	180.0		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/23/22 03:19	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 03:25	200.0	181.3		R-A /Span * 100	2.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/23/22 03:19	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/23/22 03:14	21.0	18.2		R-A	0.2
	Zero	12/23/22 03:19	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/22 03:25	200.0	185.0	184.7	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/22 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/22 03:25	200.0	182.0	182.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/22 03:20	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/23/22 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/23/22 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/24/22 02:24	200.0	181.3	177.2	R-A /Span * 100		2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/24/22 02:19	30.0	24.3	24.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/24/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/24/22 02:25	200.0	182.0	181.9	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/24/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/24/22 02:19	30.0	23.4	22.8	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/24/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/24/22 03:25	200.0	180.0	178.9	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/24/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/24/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/24/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/24/22 03:25	200.0	181.3	176.8	R-A /Span * 100		2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/24/22 03:20	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/24/22 03:15	21.0	18.2		R-A	0.1
	Zero	12/24/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/22 03:14	200.0	-0.1		R-A /Span * 100	0.1
	High	12/24/22 03:25	200.0	185.3		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/22 03:14	10.0	-0.1		R-A /Span * 100	1.0
	High	12/24/22 03:20	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/24/22 03:25	200.0	182.4		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/24/22 03:20	10.0	8.9		R-A	0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/24/22 03:14	21.0	18.0		R-A	0.0
	Zero	12/24/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/22 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	12/25/22 02:25	200.0	176.6		R-A /Span * 100	2.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/22 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	12/25/22 02:19	30.0	24.6		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/25/22 02:25	200.0	180.9		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/25/22 02:20	30.0	23.4		R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/22 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	12/25/22 03:25	200.0	178.8		R-A /Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/25/22 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/25/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/25/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/25/22 03:25	200.0	181.3	177.2	R-A /Span * 100		2.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/25/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/25/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/25/22 03:14	21.0	18.2	18.1	R-A		0.1
	Zero	12/25/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/25/22 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/25/22 03:25	200.0	185.0	185.4	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/25/22 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	12/25/22 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/25/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/25/22 03:25	200.0	182.0	182.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/25/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/25/22 03:19	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/25/22 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	12/25/22 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/22 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/26/22 02:24	200.0	181.3	177.1	R-A /Span * 100		2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/26/22 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/26/22 02:19	30.0	24.3	24.6	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/22 02:25	200.0	182.0	180.3	R-A /Span * 100		0.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/26/22 02:20	30.0	23.4	22.6 >1x Alert	R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/22 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	12/26/22 03:25	200.0	180.0	179.2	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/22 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	12/26/22 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/26/22 03:25	200.0	181.3	177.4	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/26/22 03:20	10.0	8.5	8.5	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/26/22 03:15	21.0	18.2	18.1	R-A	0.1
	Zero	12/26/22 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/22 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/26/22 03:25	200.0	185.0	185.8	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/22 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/26/22 03:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/22 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/26/22 03:25	200.0	182.0	182.4	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/22 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/26/22 03:19	10.0	8.9	8.0	R-A	0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/26/22 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	12/26/22 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/22 02:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/27/22 02:24	200.0	181.3	176.6	R-A /Span * 100	2.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 02:15	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/27/22 02:20	30.0	24.3	24.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 02:25	200.0	182.0	179.7	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 02:20	30.0	23.4	22.5	>1x Alert R-A /Span * 100		3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/22 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/27/22 03:24	200.0	185.0	187.6	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	12/27/22 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 03:24	200.0	182.0	181.6	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 03:20	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/27/22 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	12/27/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/22 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/27/22 03:25	200.0	180.0	180.6	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/27/22 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/22 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 03:25	200.0	181.3	178.0	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/22 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/22 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/27/22 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	12/27/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/22 02:24	200.0	182.0	182.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/22 02:20	30.0	23.4	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/22 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/28/22 03:25	200.0	185.0	186.8	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/22 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	12/28/22 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/22 03:25	200.0	182.0	182.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/22 03:20	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/28/22 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	12/28/22 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/29/22 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/29/22 02:25	200.0	182.0	182.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/29/22 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/29/22 02:19	30.0	23.4	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/29/22 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/29/22 03:25	200.0	185.0	186.9	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/29/22 03:15	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	12/29/22 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:02 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/22 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/22 03:25	200.0	182.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/22 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/29/22 03:20	10.0	8.9		R-A	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/29/22 03:15	21.0	18.0		R-A	0.0
	Zero	12/29/22 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/22 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/30/22 02:25	200.0	182.0		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/22 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/30/22 02:20	30.0	23.4		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/22 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/30/22 03:24	200.0	185.0		R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/22 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	12/30/22 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/22 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/30/22 03:24	200.0	182.0		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/22 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/30/22 03:19	10.0	8.9		R-A	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/30/22 03:14	21.0	18.0		R-A	0.0
	Zero	12/30/22 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/22 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/31/22 02:25	200.0	182.0		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/22 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/31/22 02:20	30.0	23.4		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/03/2023 15:02

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/31/22 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/31/22 03:25	200.0	185.0	186.3	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/31/22 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	12/31/22 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/31/22 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/31/22 03:25	200.0	182.0	181.5	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/31/22 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/31/22 03:20	10.0	8.9	7.9	R-A		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/31/22 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	12/31/22 03:20	21.0	0.0	0.0	R-A		0.0

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/22 0:00	1			49			50											
10/01/22 1:00	1			55			57											
10/01/22 2:00	1			55			56											
10/01/22 3:00	1			55			56											
10/01/22 4:00	1			56			57											
10/01/22 5:00	1			57			58											
10/01/22 6:00	1			53			54											
10/01/22 7:00	1			45			47											
10/01/22 8:00	1			37			38											
10/01/22 9:00	1			32			33											
10/01/22 10:00	1			32			33											
10/01/22 11:00	1			32			33											
10/01/22 12:00	1			32			33											
10/01/22 13:00	1			32			33											
10/01/22 14:00	1			32			33											
10/01/22 15:00	1			33			33											
10/01/22 16:00	1			38			39											
10/01/22 17:00	1			47			48											
10/01/22 18:00	1			55			57											
10/01/22 19:00	1			57			59											
10/01/22 20:00	1			57			58											
10/01/22 21:00	1			56			57											
10/01/22 22:00	1			51			52											
10/01/22 23:00	1			48			50											
10/02/22 0:00	1			46			47											
10/02/22 1:00	1			47			49											
10/02/22 2:00	1			49			51											
10/02/22 3:00	1			53			54											
10/02/22 4:00	1			58			59											
10/02/22 5:00	1			59			60											
10/02/22 6:00	1			57			58											
10/02/22 7:00	1			47			48											
10/02/22 8:00	1			38			39											
10/02/22 9:00	1			32			33											
10/02/22 10:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/22 11:00	1			32			33											
10/02/22 12:00	1			32			33											
10/02/22 13:00	1			36			37											
10/02/22 14:00	1			44			45											
10/02/22 15:00	1			48			49											
10/02/22 16:00	1			54			54											
10/02/22 17:00	1			58			59											
10/02/22 18:00	1			66			67											
10/02/22 19:00	1			69			70											
10/02/22 20:00	1			69			70											
10/02/22 21:00	1			64			65											
10/02/22 22:00	1			56			57											
10/02/22 23:00	1			53			54											
10/03/22 0:00	1			54			55											
10/03/22 1:00	1			58			59											
10/03/22 2:00	1			57			58											
10/03/22 3:00	1			57			58											
10/03/22 4:00	1			58			59											
10/03/22 5:00	1			59			61											
10/03/22 6:00	1			58			60											
10/03/22 7:00	1			51			53											
10/03/22 8:00	1			49			51											
10/03/22 9:00	1			43			44											
10/03/22 10:00	1			43			44											
10/03/22 11:00	1			41			42											
10/03/22 12:00	1			49			51											
10/03/22 13:00	1			56			57											
10/03/22 14:00	1			60			61											
10/03/22 15:00	1			60			61											
10/03/22 16:00	1			59			61											
10/03/22 17:00	1			62			63											
10/03/22 18:00	1			65			66											
10/03/22 19:00	1			69			70											
10/03/22 20:00	1			69			70											
10/03/22 21:00	1			66			67											
10/03/22 22:00	1			63			64											
10/03/22 23:00	1			62			64											
10/04/22 0:00	1			65			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/22 1:00	1			68			69											
10/04/22 2:00	1			68			69											
10/04/22 3:00	1			68			69											
10/04/22 4:00	1			68			69											
10/04/22 5:00	1			68			69											
10/04/22 6:00	1			67			69											
10/04/22 7:00	1			66			68											
10/04/22 8:00	1			64			66											
10/04/22 9:00	1			63			64											
10/04/22 10:00	1			64			65											
10/04/22 11:00	1			65			66											
10/04/22 12:00	1			66			67											
10/04/22 13:00	1			66			66											
10/04/22 14:00	1			68			68											
10/04/22 15:00	1			67			67											
10/04/22 16:00	1			68			68											
10/04/22 17:00	1			69			68											
10/04/22 18:00	1			70			68											
10/04/22 19:00	1			71			68											
10/04/22 20:00	1			70			68											
10/04/22 21:00	1			70			68											
10/04/22 22:00	1			70			69											
10/04/22 23:00	1			70			69											
10/05/22 0:00	1			70			69											
10/05/22 1:00	1			70			69											
10/05/22 2:00	1			69			69											
10/05/22 3:00	1			69			69											
10/05/22 4:00	1			69			69											
10/05/22 5:00	1			69			69											
10/05/22 6:00	1			69			69											
10/05/22 7:00	1			68			69											
10/05/22 8:00	1			65			67											
10/05/22 9:00	1			62			64											
10/05/22 10:00	1			63			63											
10/05/22 11:00	1			64			65											
10/05/22 12:00	1			67			67											
10/05/22 13:00	1			68			67											
10/05/22 14:00	1			70			67											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/22 15:00	1			70			67											
10/05/22 16:00	1			70			67											
10/05/22 17:00	1			70			67											
10/05/22 18:00	1			70			68											
10/05/22 19:00	1			71			68											
10/05/22 20:00	1			70			68											
10/05/22 21:00	1			70			68											
10/05/22 22:00	1			70			68											
10/05/22 23:00	1			67			66											
10/06/22 0:00	1			64			64											
10/06/22 1:00	1			61			62											
10/06/22 2:00	1			61			62											
10/06/22 3:00	1			61			62											
10/06/22 4:00	1			61			62											
10/06/22 5:00	1			61			63											
10/06/22 6:00	1			64			65											
10/06/22 7:00	1			63			64											
10/06/22 8:00	1			54			55											
10/06/22 9:00	1			43			44											
10/06/22 10:00	1			35			36											
10/06/22 11:00	1			37			38											
10/06/22 12:00	1			42			43											
10/06/22 13:00	1			50			52											
10/06/22 14:00	1			59			60											
10/06/22 15:00	1			66			65											
10/06/22 16:00	1			69			67											
10/06/22 17:00	1			70			67											
10/06/22 18:00	1			71			68											
10/06/22 19:00	1			71			68											
10/06/22 20:00	1			71			68											
10/06/22 21:00	1			70			68											
10/06/22 22:00	1			70			69											
10/06/22 23:00	1			69			69											
10/07/22 0:00	1			69			69											
10/07/22 1:00	1			69			69											
10/07/22 2:00	1			68			69											
10/07/22 3:00	1			67			69											
10/07/22 4:00	1			67			69											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/22 5:00	1			68			69											
10/07/22 6:00	1			69			69											
10/07/22 7:00	1			68			69											
10/07/22 8:00	1			67			68											
10/07/22 9:00	1			67			67											
10/07/22 10:00	1			68			67											
10/07/22 11:00	1			69			68											
10/07/22 12:00	1			71			68											
10/07/22 13:00	1			70			68											
10/07/22 14:00	1			69			67											
10/07/22 15:00	1			68			67											
10/07/22 16:00	1			69			67											
10/07/22 17:00	1			70			67											
10/07/22 18:00	1			70			68											
10/07/22 19:00	1			71			68											
10/07/22 20:00	1			70			68											
10/07/22 21:00	1			70			68											
10/07/22 22:00	1			70			69											
10/07/22 23:00	1			69			69											
10/08/22 0:00	1			69			69											
10/08/22 1:00	1			69			69											
10/08/22 2:00	1			69			69											
10/08/22 3:00	1			69			69											
10/08/22 4:00	1			69			69											
10/08/22 5:00	1			69			69											
10/08/22 6:00	1			66			67											
10/08/22 7:00	1			57			58											
10/08/22 8:00	1			47			48											
10/08/22 9:00	1			40			41											
10/08/22 10:00	1			38			39											
10/08/22 11:00	1			39			40											
10/08/22 12:00	1			42			43											
10/08/22 13:00	1			51			52											
10/08/22 14:00	1			57			58											
10/08/22 15:00	1			64			63											
10/08/22 16:00	1			67			65											
10/08/22 17:00	1			70			67											
10/08/22 18:00	1			71			68											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 19:00	1			70			68											
10/08/22 20:00	1			70			68											
10/08/22 21:00	1			69			68											
10/08/22 22:00	1			63			62											
10/08/22 23:00	1			60			39											
10/09/22 0:00	1			59			16											
10/09/22 1:00	1			63			0											
10/09/22 2:00	1			63			0											
10/09/22 3:00	1			63			0											
10/09/22 4:00	1			63			0											
10/09/22 5:00	1			64			0											
10/09/22 6:00	1			64			0											
10/09/22 7:00	1			64			0											
10/09/22 8:00	1			64			0											
10/09/22 9:00	1			63			0											
10/09/22 10:00	1			63			0											
10/09/22 11:00	1			63			0											
10/09/22 12:00	1			63			0											
10/09/22 13:00	1			62			0											
10/09/22 14:00	1			62			0											
10/09/22 15:00	1			62			0											
10/09/22 16:00	1			62			0											
10/09/22 17:00	1			62			0											
10/09/22 18:00	1			62			0											
10/09/22 19:00	1			62			0											
10/09/22 20:00	1			62			0											
10/09/22 21:00	1			63			0											
10/09/22 22:00	1			63			0											
10/09/22 23:00	1			63			0											
10/10/22 0:00	1			63			0											
10/10/22 1:00	1			63			0											
10/10/22 2:00	1			64			0											
10/10/22 3:00	1			64			0											
10/10/22 4:00	1			64			0											
10/10/22 5:00	1			64			0											
10/10/22 6:00	1			65			0											
10/10/22 7:00	1			65			0											
10/10/22 8:00	1			64			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/22 9:00	1			63			0											
10/10/22 10:00	1			62			0											
10/10/22 11:00	1			52			0											
10/10/22 12:00	1			42			0											
10/10/22 13:00	1			32			0											
10/10/22 14:00	1			32			0											
10/10/22 15:00	1			37			0											
10/10/22 16:00	1			50			0											
10/10/22 17:00	1			63			0											
10/10/22 18:00	1			67			0											
10/10/22 19:00	1			65			0											
10/10/22 20:00	1			62			0											
10/10/22 21:00	1			62			0											
10/10/22 22:00	1			63			0											
10/10/22 23:00	1			63			0											
10/11/22 0:00	1			53			0											
10/11/22 1:00	1			42			0											
10/11/22 2:00	1			32			0											
10/11/22 3:00	1			32			0											
10/11/22 4:00	1			32			0											
10/11/22 5:00	1			32			0											
10/11/22 6:00	1			32			0											
10/11/22 7:00	1			32			0											
10/11/22 8:00	1			32			0											
10/11/22 9:00	1			31			0											
10/11/22 10:00	1			31			0											
10/11/22 11:00	1			31			0											
10/11/22 12:00	1			31			0											
10/11/22 13:00	1			31			0											
10/11/22 14:00	1			31			0											
10/11/22 15:00	1			37			0											
10/11/22 16:00	1			47			0											
10/11/22 17:00	1			58			0											
10/11/22 18:00	1			62			0											
10/11/22 19:00	1			62			0											
10/11/22 20:00	1			63			0											
10/11/22 21:00	1			63			0											
10/11/22 22:00	1			63			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/22 23:00	1			63			0											
10/12/22 0:00	1			63			0											
10/12/22 1:00	1			63			0											
10/12/22 2:00	1			63			0											
10/12/22 3:00	1			64			0											
10/12/22 4:00	1			64			0											
10/12/22 5:00	1			64			0											
10/12/22 6:00	1			64			0											
10/12/22 7:00	1			61			0											
10/12/22 8:00	1			50			0											
10/12/22 9:00	1			39			0											
10/12/22 10:00	1			32			0											
10/12/22 11:00	1			32			0											
10/12/22 12:00	1			31			0											
10/12/22 13:00	1			31			0											
10/12/22 14:00	1			31			0											
10/12/22 15:00	1			31			0											
10/12/22 16:00	1			31			0											
10/12/22 17:00	1			31			0											
10/12/22 18:00	1			31			0											
10/12/22 19:00	1			31			0											
10/12/22 20:00	1			31			0											
10/12/22 21:00	1			31			0											
10/12/22 22:00	1			31			0											
10/12/22 23:00	1			31			0											
10/13/22 0:00	1			31			0											
10/13/22 1:00	1			31			0											
10/13/22 2:00	1			31			0											
10/13/22 3:00	1			31			0											
10/13/22 4:00	1			31			0											
10/13/22 5:00	1			31			0											
10/13/22 6:00	1			36			0											
10/13/22 7:00	1			36			0											
10/13/22 8:00	1			36			0											
10/13/22 9:00	1			31			0											
10/13/22 10:00	1			31			0											
10/13/22 11:00	1			31			0											
10/13/22 12:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/22 13:00	1			31			0											
10/13/22 14:00	1			31			0											
10/13/22 15:00	1			37			0											
10/13/22 16:00	1			48			0											
10/13/22 17:00	1			59			0											
10/13/22 18:00	1			63			0											
10/13/22 19:00	1			63			0											
10/13/22 20:00	1			63			0											
10/13/22 21:00	1			63			0											
10/13/22 22:00	1			63			0											
10/13/22 23:00	1			63			0											
10/14/22 0:00	1			63			0											
10/14/22 1:00	1			63			0											
10/14/22 2:00	1			63			0											
10/14/22 3:00	1			64			0											
10/14/22 4:00	1			64			0											
10/14/22 5:00	1			64			0											
10/14/22 6:00	1			64			0											
10/14/22 7:00	1			62			0											
10/14/22 8:00	1			51			0											
10/14/22 9:00	1			40			0											
10/14/22 10:00	1			31			0											
10/14/22 11:00	1			31			0											
10/14/22 12:00	1			31			0											
10/14/22 13:00	1			31			0											
10/14/22 14:00	1			31			0											
10/14/22 15:00	1			31			0											
10/14/22 16:00	1			37			0											
10/14/22 17:00	1			47			0											
10/14/22 18:00	1			58			0											
10/14/22 19:00	1			62			0											
10/14/22 20:00	1			62			0											
10/14/22 21:00	1			62			0											
10/14/22 22:00	1			62			0											
10/14/22 23:00	1			62			0											
10/15/22 0:00	1			63			0											
10/15/22 1:00	1			63			0											
10/15/22 2:00	1			62			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/22 3:00	1			60			0											
10/15/22 4:00	1			60			0											
10/15/22 5:00	1			61			0											
10/15/22 6:00	1			63			0											
10/15/22 7:00	1			54			0											
10/15/22 8:00	1			44			0											
10/15/22 9:00	1			33			0											
10/15/22 10:00	1			31			0											
10/15/22 11:00	1			31			0											
10/15/22 12:00	1			31			0											
10/15/22 13:00	1			31			0											
10/15/22 14:00	1			31			0											
10/15/22 15:00	1			31			0											
10/15/22 16:00	1			31			0											
10/15/22 17:00	1			31			0											
10/15/22 18:00	1			31			0											
10/15/22 19:00	1			31			0											
10/15/22 20:00	1			31			0											
10/15/22 21:00	1			31			0											
10/15/22 22:00	1			31			0											
10/15/22 23:00	1			31			0											
10/16/22 0:00	1			31			0											
10/16/22 1:00	1			31			0											
10/16/22 2:00	1			31			0											
10/16/22 3:00	1			31			0											
10/16/22 4:00	1			31			0											
10/16/22 5:00	1			31			0											
10/16/22 6:00	1			31			0											
10/16/22 7:00	1			31			0											
10/16/22 8:00	1			31			0											
10/16/22 9:00	1			33			0											
10/16/22 10:00	1			43			0											
10/16/22 11:00	1			54			0											
10/16/22 12:00	1			63			0											
10/16/22 13:00	1			63			0											
10/16/22 14:00	1			63			0											
10/16/22 15:00	1			63			0											
10/16/22 16:00	1			63			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/22 17:00	1			64			0											
10/16/22 18:00	1			64			0											
10/16/22 19:00	1			64			0											
10/16/22 20:00	1			64			0											
10/16/22 21:00	1			64			0											
10/16/22 22:00	1			64			0											
10/16/22 23:00	1			64			0											
10/17/22 0:00	1			64			0											
10/17/22 1:00	1			64			0											
10/17/22 2:00	1			62			0											
10/17/22 3:00	1			60			0											
10/17/22 4:00	1			60			0											
10/17/22 5:00	1			62			0											
10/17/22 6:00	1			64			0											
10/17/22 7:00	1			64			0											
10/17/22 8:00	1			62			0											
10/17/22 9:00	1			61			0											
10/17/22 10:00	1			61			0											
10/17/22 11:00	1			62			0											
10/17/22 12:00	1			62			0											
10/17/22 13:00	1			62			0											
10/17/22 14:00	1			62			0											
10/17/22 15:00	1			62			0											
10/17/22 16:00	1			62			0											
10/17/22 17:00	1			62			0											
10/17/22 18:00	1			62			0											
10/17/22 19:00	1			62			0											
10/17/22 20:00	1			62			0											
10/17/22 21:00	1			63			0											
10/17/22 22:00	1			63			0											
10/17/22 23:00	1			64			0											
10/18/22 0:00	1			65			0											
10/18/22 1:00	1			65			0											
10/18/22 2:00	1			64			0											
10/18/22 3:00	1			64			0											
10/18/22 4:00	1			65			0											
10/18/22 5:00	1			67			0											
10/18/22 6:00	1			69			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 7:00	1			68			0											
10/18/22 8:00	1			67			0											
10/18/22 9:00	1			64			0											
10/18/22 10:00	1			63			0											
10/18/22 11:00	1			63			0											
10/18/22 12:00	1			63			0											
10/18/22 13:00	1			63			0											
10/18/22 14:00	1			55			0											
10/18/22 15:00	1			46			10											
10/18/22 16:00	1			46			31											
10/18/22 17:00	1			58			57											
10/18/22 18:00	1			71			71											
10/18/22 19:00	1			76			77											
10/18/22 20:00	1			76			77											
10/18/22 21:00	1			76			77											
10/18/22 22:00	1			73			74											
10/18/22 23:00	1			69			69											
10/19/22 0:00	1			64			65											
10/19/22 1:00	1			60			62											
10/19/22 2:00	1			58			60											
10/19/22 3:00	1			57			59											
10/19/22 4:00	1			58			60											
10/19/22 5:00	1			60			61											
10/19/22 6:00	1			57			58											
10/19/22 7:00	1			47			48											
10/19/22 8:00	1			35			42											
10/19/22 9:00	1			19			38											
10/19/22 10:00	1			8			37											
10/19/22 11:00	1			0			33											
10/19/22 12:00	1			0			31											
10/19/22 13:00	1			0			31											
10/19/22 14:00	1			0			37											
10/19/22 15:00	1			0			47											
10/19/22 16:00	1			8			51											
10/19/22 17:00	1			23			50											
10/19/22 18:00	1			45			51											
10/19/22 19:00	1			59			59											
10/19/22 20:00	1			66			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 21:00	1			67			67											
10/19/22 22:00	1			59			60											
10/19/22 23:00	1			54			55											
10/20/22 0:00	1			50			51											
10/20/22 1:00	1			49			51											
10/20/22 2:00	1			43			45											
10/20/22 3:00	1			41			43											
10/20/22 4:00	1			47			48											
10/20/22 5:00	1			56			57											
10/20/22 6:00	1			58			59											
10/20/22 7:00	1			50			51											
10/20/22 8:00	1			40			41											
10/20/22 9:00	1			33			34											
10/20/22 10:00	1			33			33											
10/20/22 11:00	1			33			33											
10/20/22 12:00	1			32			33											
10/20/22 13:00	1			33			34											
10/20/22 14:00	1			34			35											
10/20/22 15:00	1			41			42											
10/20/22 16:00	1			54			55											
10/20/22 17:00	1			66			67											
10/20/22 18:00	1			72			72											
10/20/22 19:00	1			69			69											
10/20/22 20:00	1			67			67											
10/20/22 21:00	1			57			58											
10/20/22 22:00	1			47			48											
10/20/22 23:00	1			44			46											
10/21/22 0:00	1			46			48											
10/21/22 1:00	1			48			49											
10/21/22 2:00	1			41			42											
10/21/22 3:00	1			38			39											
10/21/22 4:00	1			39			40											
10/21/22 5:00	1			46			47											
10/21/22 6:00	1			55			56											
10/21/22 7:00	1			62			63											
10/21/22 8:00	1			54			55											
10/21/22 9:00	1			43			44											
10/21/22 10:00	1			33			34											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/22 11:00	1			33			34											
10/21/22 12:00	1			33			34											
10/21/22 13:00	1			33			34											
10/21/22 14:00	1			33			34											
10/21/22 15:00	1			41			42											
10/21/22 16:00	1			52			53											
10/21/22 17:00	1			64			65											
10/21/22 18:00	1			67			68											
10/21/22 19:00	1			61			62											
10/21/22 20:00	1			53			54											
10/21/22 21:00	1			52			53											
10/21/22 22:00	1			56			57											
10/21/22 23:00	1			61			63											
10/22/22 0:00	1			62			64											
10/22/22 1:00	1			62			64											
10/22/22 2:00	1			62			64											
10/22/22 3:00	1			62			64											
10/22/22 4:00	1			62			64											
10/22/22 5:00	1			62			64											
10/22/22 6:00	1			68			70											
10/22/22 7:00	1			75			76											
10/22/22 8:00	1			79			81											
10/22/22 9:00	1			78			79											
10/22/22 10:00	1			75			77											
10/22/22 11:00	1			73			74											
10/22/22 12:00	1			69			70											
10/22/22 13:00	1			65			66											
10/22/22 14:00	1			61			62											
10/22/22 15:00	1			54			55											
10/22/22 16:00	1			50			51											
10/22/22 17:00	1			50			51											
10/22/22 18:00	1			55			56											
10/22/22 19:00	1			59			60											
10/22/22 20:00	1			61			62											
10/22/22 21:00	1			65			66											
10/22/22 22:00	1			65			66											
10/22/22 23:00	1			64			66											
10/23/22 0:00	1			64			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/22 1:00	1			65			67											
10/23/22 2:00	1			65			67											
10/23/22 3:00	1			63			65											
10/23/22 4:00	1			62			64											
10/23/22 5:00	1			62			64											
10/23/22 6:00	1			62			64											
10/23/22 7:00	1			63			65											
10/23/22 8:00	1			65			66											
10/23/22 9:00	1			63			65											
10/23/22 10:00	1			59			60											
10/23/22 11:00	1			59			60											
10/23/22 12:00	1			60			60											
10/23/22 13:00	1			57			58											
10/23/22 14:00	1			49			50											
10/23/22 15:00	1			42			43											
10/23/22 16:00	1			43			44											
10/23/22 17:00	1			48			49											
10/23/22 18:00	1			57			58											
10/23/22 19:00	1			61			63											
10/23/22 20:00	1			64			65											
10/23/22 21:00	1			65			67											
10/23/22 22:00	1			62			64											
10/23/22 23:00	1			61			62											
10/24/22 0:00	1			59			60											
10/24/22 1:00	1			61			62											
10/24/22 2:00	1			61			62											
10/24/22 3:00	1			61			63											
10/24/22 4:00	1			62			64											
10/24/22 5:00	1			62			64											
10/24/22 6:00	1			67			68											
10/24/22 7:00	1			71			72											
10/24/22 8:00	1			72			73											
10/24/22 9:00	1			70			71											
10/24/22 10:00	1			67			68											
10/24/22 11:00	1			64			65											
10/24/22 12:00	1			52			53											
10/24/22 13:00	1			41			42											
10/24/22 14:00	1			39			40											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/22 15:00	1			51			52											
10/24/22 16:00	1			64			65											
10/24/22 17:00	1			70			71											
10/24/22 18:00	1			69			71											
10/24/22 19:00	1			68			70											
10/24/22 20:00	1			67			69											
10/24/22 21:00	1			61			63											
10/24/22 22:00	1			50			52											
10/24/22 23:00	1			42			43											
10/25/22 0:00	1			37			38											
10/25/22 1:00	1			36			37											
10/25/22 2:00	1			34			35											
10/25/22 3:00	1			34			35											
10/25/22 4:00	1			41			42											
10/25/22 5:00	1			50			51											
10/25/22 6:00	1			62			63											
10/25/22 7:00	1			66			68											
10/25/22 8:00	1			62			64											
10/25/22 9:00	1			54			56											
10/25/22 10:00	1			43			44											
10/25/22 11:00	1			38			39											
10/25/22 12:00	1			38			39											
10/25/22 13:00	1			49			51											
10/25/22 14:00	1			61			64											
10/25/22 15:00	1			69			73											
10/25/22 16:00	1			71			75											
10/25/22 17:00	1			71			76											
10/25/22 18:00	1			71			75											
10/25/22 19:00	1			70			74											
10/25/22 20:00	1			69			73											
10/25/22 21:00	1			68			71											
10/25/22 22:00	1			57			59											
10/25/22 23:00	1			47			49											
10/26/22 0:00	1			37			38											
10/26/22 1:00	1			36			37											
10/26/22 2:00	1			34			35											
10/26/22 3:00	1			39			40											
10/26/22 4:00	1			46			48											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/22 5:00	1			54			56											
10/26/22 6:00	1			58			60											
10/26/22 7:00	1			58			60											
10/26/22 8:00	1			60			62											
10/26/22 9:00	1			62			64											
10/26/22 10:00	1			67			68											
10/26/22 11:00	1			60			61											
10/26/22 12:00	1			48			49											
10/26/22 13:00	1			36			37											
10/26/22 14:00	1			35			36											
10/26/22 15:00	1			37			38											
10/26/22 16:00	1			45			46											
10/26/22 17:00	1			54			55											
10/26/22 18:00	1			63			64											
10/26/22 19:00	1			57			58											
10/26/22 20:00	1			48			49											
10/26/22 21:00	1			39			40											
10/26/22 22:00	1			38			39											
10/26/22 23:00	1			35			36											
10/27/22 0:00	1			33			34											
10/27/22 1:00	1			33			34											
10/27/22 2:00	1			33			34											
10/27/22 3:00	1			34			35											
10/27/22 4:00	1			38			39											
10/27/22 5:00	1			44			45											
10/27/22 6:00	1			49			50											
10/27/22 7:00	1			52			54											
10/27/22 8:00	1			55			56											
10/27/22 9:00	1			60			61											
10/27/22 10:00	1			61			62											
10/27/22 11:00	1			63			64											
10/27/22 12:00	1			63			64											
10/27/22 13:00	1			63			64											
10/27/22 14:00	1			53			54											
10/27/22 15:00	1			45			46											
10/27/22 16:00	1			49			50											
10/27/22 17:00	1			61			62											
10/27/22 18:00	1			69			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/22 19:00	1			68			69											
10/27/22 20:00	1			68			69											
10/27/22 21:00	1			69			70											
10/27/22 22:00	1			68			69											
10/27/22 23:00	1			63			65											
10/28/22 0:00	1			59			60											
10/28/22 1:00	1			54			55											
10/28/22 2:00	1			54			55											
10/28/22 3:00	1			55			57											
10/28/22 4:00	1			61			63											
10/28/22 5:00	1			67			69											
10/28/22 6:00	1			71			73											
10/28/22 7:00	1			70			71											
10/28/22 8:00	1			64			65											
10/28/22 9:00	1			60			61											
10/28/22 10:00	1			60			62											
10/28/22 11:00	1			59			60											
10/28/22 12:00	1			56			57											
10/28/22 13:00	1			50			51											
10/28/22 14:00	1			50			51											
10/28/22 15:00	1			57			57											
10/28/22 16:00	1			64			64											
10/28/22 17:00	1			71			72											
10/28/22 18:00	1			73			74											
10/28/22 19:00	1			75			76											
10/28/22 20:00	1			75			77											
10/28/22 21:00	1			75			77											
10/28/22 22:00	1			74			75											
10/28/22 23:00	1			70			71											
10/29/22 0:00	1			61			62											
10/29/22 1:00	1			54			55											
10/29/22 2:00	1			50			51											
10/29/22 3:00	1			45			46											
10/29/22 4:00	1			44			45											
10/29/22 5:00	1			47			49											
10/29/22 6:00	1			52			54											
10/29/22 7:00	1			53			54											
10/29/22 8:00	1			52			54											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/22 9:00	1			53			55											
10/29/22 10:00	1			55			57											
10/29/22 11:00	1			51			53											
10/29/22 12:00	1			45			47											
10/29/22 13:00	1			40			41											
10/29/22 14:00	1			37			38											
10/29/22 15:00	1			39			40											
10/29/22 16:00	1			42			43											
10/29/22 17:00	1			46			47											
10/29/22 18:00	1			48			50											
10/29/22 19:00	1			45			47											
10/29/22 20:00	1			50			51											
10/29/22 21:00	1			56			58											
10/29/22 22:00	1			62			63											
10/29/22 23:00	1			61			63											
10/30/22 0:00	1			59			60											
10/30/22 1:00	1			58			60											
10/30/22 2:00	1			57			58											
10/30/22 3:00	1			56			57											
10/30/22 4:00	1			57			59											
10/30/22 5:00	1			59			61											
10/30/22 6:00	1			61			63											
10/30/22 7:00	1			53			55											
10/30/22 8:00	1			43			45											
10/30/22 9:00	1			33			35											
10/30/22 10:00	1			32			34											
10/30/22 11:00	1			32			34											
10/30/22 12:00	1			32			34											
10/30/22 13:00	1			32			34											
10/30/22 14:00	1			32			34											
10/30/22 15:00	1			33			35											
10/30/22 16:00	1			42			44											
10/30/22 17:00	1			52			53											
10/30/22 18:00	1			62			63											
10/30/22 19:00	1			61			63											
10/30/22 20:00	1			60			61											
10/30/22 21:00	1			56			58											
10/30/22 22:00	1			55			57											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/22 23:00	1			56			57											
10/31/22 0:00	1			56			57											
10/31/22 1:00	1			57			58											
10/31/22 2:00	1			57			58											
10/31/22 3:00	1			56			58											
10/31/22 4:00	1			58			59											
10/31/22 5:00	1			61			62											
10/31/22 6:00	1			65			67											
10/31/22 7:00	1			63			65											
10/31/22 8:00	1			57			58											
10/31/22 9:00	1			48			49											
10/31/22 10:00	1			43			44											
10/31/22 11:00	1			39			40											
10/31/22 12:00	1			35			36											
10/31/22 13:00	1			37			38											
10/31/22 14:00	1			45			46											
10/31/22 15:00	1			56			57											
10/31/22 16:00	1			58			60											
10/31/22 17:00	1			50			51											
10/31/22 18:00	1			39			40											
10/31/22 19:00	1			36			37											
10/31/22 20:00	1			39			40											
10/31/22 21:00	1			44			45											
10/31/22 22:00	1			45			46											
10/31/22 23:00	1			51			52											
11/01/22 0:00	1			54			55											
11/01/22 1:00	1			61			62											
11/01/22 2:00	1			64			66											
11/01/22 3:00	1			68			70											
11/01/22 4:00	1			72			74											
11/01/22 5:00	1			73			75											
11/01/22 6:00	1			74			76											
11/01/22 7:00	1			74			76											
11/01/22 8:00	1			73			75											
11/01/22 9:00	1			70			71											
11/01/22 10:00	1			69			69											
11/01/22 11:00	1			69			69											
11/01/22 12:00	1			70			71											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/22 13:00	1			71			72											
11/01/22 14:00	1			70			71											
11/01/22 15:00	1			69			70											
11/01/22 16:00	1			69			69											
11/01/22 17:00	1			70			71											
11/01/22 18:00	1			71			72											
11/01/22 19:00	1			70			71											
11/01/22 20:00	1			70			71											
11/01/22 21:00	1			69			70											
11/01/22 22:00	1			68			70											
11/01/22 23:00	1			62			64											
11/02/22 0:00	1			51			53											
11/02/22 1:00	1			45			47											
11/02/22 2:00	1			42			43											
11/02/22 3:00	1			48			49											
11/02/22 4:00	1			51			53											
11/02/22 5:00	1			58			59											
11/02/22 6:00	1			63			64											
11/02/22 7:00	1			60			62											
11/02/22 8:00	1			51			53											
11/02/22 9:00	1			41			42											
11/02/22 10:00	1			42			43											
11/02/22 11:00	1			52			53											
11/02/22 12:00	1			62			63											
11/02/22 13:00	1			64			65											
11/02/22 14:00	1			64			65											
11/02/22 15:00	1			64			65											
11/02/22 16:00	1			68			69											
11/02/22 17:00	1			70			72											
11/02/22 18:00	1			71			73											
11/02/22 19:00	1			71			72											
11/02/22 20:00	1			71			72											
11/02/22 21:00	1			72			73											
11/02/22 22:00	1			72			74											
11/02/22 23:00	1			69			70											
11/03/22 0:00	1			66			67											
11/03/22 1:00	1			63			64											
11/03/22 2:00	1			62			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/22 3:00	1			62			64											
11/03/22 4:00	1			63			64											
11/03/22 5:00	1			68			70											
11/03/22 6:00	1			74			76											
11/03/22 7:00	1			75			77											
11/03/22 8:00	1			69			71											
11/03/22 9:00	1			64			66											
11/03/22 10:00	1			65			67											
11/03/22 11:00	1			63			64											
11/03/22 12:00	1			52			53											
11/03/22 13:00	1			41			42											
11/03/22 14:00	1			34			35											
11/03/22 15:00	1			34			35											
11/03/22 16:00	1			41			42											
11/03/22 17:00	1			53			55											
11/03/22 18:00	1			65			67											
11/03/22 19:00	1			70			72											
11/03/22 20:00	1			72			74											
11/03/22 21:00	1			74			76											
11/03/22 22:00	1			75			77											
11/03/22 23:00	1			72			74											
11/04/22 0:00	1			67			69											
11/04/22 1:00	1			63			65											
11/04/22 2:00	1			59			61											
11/04/22 3:00	1			58			59											
11/04/22 4:00	1			58			60											
11/04/22 5:00	1			64			65											
11/04/22 6:00	1			69			71											
11/04/22 7:00	1			66			67											
11/04/22 8:00	1			53			55											
11/04/22 9:00	1			41			43											
11/04/22 10:00	1			36			37											
11/04/22 11:00	1			34			35											
11/04/22 12:00	1			33			34											
11/04/22 13:00	1			32			33											
11/04/22 14:00	1			32			33											
11/04/22 15:00	1			35			36											
11/04/22 16:00	1			39			41											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/22 17:00	1			48			49											
11/04/22 18:00	1			57			58											
11/04/22 19:00	1			65			66											
11/04/22 20:00	1			68			69											
11/04/22 21:00	1			57			59											
11/04/22 22:00	1			46			47											
11/04/22 23:00	1			37			38											
11/05/22 0:00	1			36			37											
11/05/22 1:00	1			36			37											
11/05/22 2:00	1			34			35											
11/05/22 3:00	1			34			35											
11/05/22 4:00	1			34			35											
11/05/22 5:00	1			36			37											
11/05/22 6:00	1			36			37											
11/05/22 7:00	1			39			40											
11/05/22 8:00	1			37			38											
11/05/22 9:00	1			37			38											
11/05/22 10:00	1			34			35											
11/05/22 11:00	1			36			37											
11/05/22 12:00	1			41			42											
11/05/22 13:00	1			44			45											
11/05/22 14:00	1			50			51											
11/05/22 15:00	1			45			46											
11/05/22 16:00	1			45			46											
11/05/22 17:00	1			45			47											
11/05/22 18:00	1			56			57											
11/05/22 19:00	1			63			64											
11/05/22 20:00	1			58			59											
11/05/22 21:00	1			48			49											
11/05/22 22:00	1			38			39											
11/05/22 23:00	1			42			43											
11/06/22 0:00	1			49			50											
11/06/22 1:00	1			52			54											
11/06/22 2:00	1			50			51											
11/06/22 3:00	1			51			52											
11/06/22 4:00	1			55			56											
11/06/22 5:00	1			59			61											
11/06/22 6:00	1			61			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/22 7:00	1			63			65											
11/06/22 8:00	1			65			66											
11/06/22 9:00	1			65			67											
11/06/22 10:00	1			57			59											
11/06/22 11:00	1			46			48											
11/06/22 12:00	1			36			37											
11/06/22 13:00	1			35			36											
11/06/22 14:00	1			38			39											
11/06/22 15:00	1			49			50											
11/06/22 16:00	1			61			63											
11/06/22 17:00	1			69			71											
11/06/22 18:00	1			69			71											
11/06/22 19:00	1			68			69											
11/06/22 20:00	1			67			68											
11/06/22 21:00	1			67			68											
11/06/22 22:00	1			61			62											
11/06/22 23:00	1			51			52											
11/07/22 0:00	1			42			43											
11/07/22 1:00	1			41			42											
11/07/22 2:00	1			47			48											
11/07/22 3:00	1			49			50											
11/07/22 4:00	1			48			49											
11/07/22 5:00	1			50			51											
11/07/22 6:00	1			54			56											
11/07/22 7:00	1			58			59											
11/07/22 8:00	1			51			52											
11/07/22 9:00	1			42			43											
11/07/22 10:00	1			35			36											
11/07/22 11:00	1			34			35											
11/07/22 12:00	1			34			35											
11/07/22 13:00	1			34			35											
11/07/22 14:00	1			39			40											
11/07/22 15:00	1			49			50											
11/07/22 16:00	1			62			63											
11/07/22 17:00	1			69			71											
11/07/22 18:00	1			70			73											
11/07/22 19:00	1			70			72											
11/07/22 20:00	1			71			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 21:00	1			71			73											
11/07/22 22:00	1			70			72											
11/07/22 23:00	1			64			65											
11/08/22 0:00	1			52			41											
11/08/22 1:00	1			40			18											
11/08/22 2:00	1			33			0											
11/08/22 3:00	1			32			0											
11/08/22 4:00	1			38			0											
11/08/22 5:00	1			49			0											
11/08/22 6:00	1			61			0											
11/08/22 7:00	1			66			0											
11/08/22 8:00	1			66			0											
11/08/22 9:00	1			67			0											
11/08/22 10:00	1			68			0											
11/08/22 11:00	1			67			0											
11/08/22 12:00	1			66			0											
11/08/22 13:00	1			56			0											
11/08/22 14:00	1			45			0											
11/08/22 15:00	1			40			0											
11/08/22 16:00	1			49			0											
11/08/22 17:00	1			60			0											
11/08/22 18:00	1			65			0											
11/08/22 19:00	1			65			0											
11/08/22 20:00	1			65			0											
11/08/22 21:00	1			65			0											
11/08/22 22:00	1			65			0											
11/08/22 23:00	1			65			0											
11/09/22 0:00	1			65			0											
11/09/22 1:00	1			65			0											
11/09/22 2:00	1			65			0											
11/09/22 3:00	1			65			0											
11/09/22 4:00	1			65			0											
11/09/22 5:00	1			65			0											
11/09/22 6:00	1			65			0											
11/09/22 7:00	1			65			0											
11/09/22 8:00	1			65			0											
11/09/22 9:00	1			62			0											
11/09/22 10:00	1			51			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 11:00	1			40			0											
11/09/22 12:00	1			31			0											
11/09/22 13:00	1			31			0											
11/09/22 14:00	1			31			0											
11/09/22 15:00	1			31			0											
11/09/22 16:00	1			37			0											
11/09/22 17:00	1			47			0											
11/09/22 18:00	1			58			0											
11/09/22 19:00	1			63			0											
11/09/22 20:00	1			61			6											
11/09/22 21:00	1			52			19											
11/09/22 22:00	1			41			30											
11/09/22 23:00	1			34			36											
11/10/22 0:00	1			34			35											
11/10/22 1:00	1			34			35											
11/10/22 2:00	1			34			36											
11/10/22 3:00	1			37			38											
11/10/22 4:00	1			43			45											
11/10/22 5:00	1			52			53											
11/10/22 6:00	1			63			65											
11/10/22 7:00	1			69			70											
11/10/22 8:00	1			63			64											
11/10/22 9:00	1			53			53											
11/10/22 10:00	1			40			41											
11/10/22 11:00	1			37			38											
11/10/22 12:00	1			32			34											
11/10/22 13:00	1			32			33											
11/10/22 14:00	1			32			33											
11/10/22 15:00	1			37			38											
11/10/22 16:00	1			51			52											
11/10/22 17:00	1			65			66											
11/10/22 18:00	1			72			74											
11/10/22 19:00	1			71			73											
11/10/22 20:00	1			71			72											
11/10/22 21:00	1			72			73											
11/10/22 22:00	1			72			74											
11/10/22 23:00	1			72			74											
11/11/22 0:00	1			72			74											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/22 1:00	1			72			74											
11/11/22 2:00	1			71			73											
11/11/22 3:00	1			67			69											
11/11/22 4:00	1			64			66											
11/11/22 5:00	1			66			68											
11/11/22 6:00	1			71			73											
11/11/22 7:00	1			72			73											
11/11/22 8:00	1			59			60											
11/11/22 9:00	1			45			46											
11/11/22 10:00	1			35			36											
11/11/22 11:00	1			34			35											
11/11/22 12:00	1			34			35											
11/11/22 13:00	1			34			35											
11/11/22 14:00	1			34			35											
11/11/22 15:00	1			43			44											
11/11/22 16:00	1			56			57											
11/11/22 17:00	1			68			69											
11/11/22 18:00	1			71			72											
11/11/22 19:00	1			70			71											
11/11/22 20:00	1			70			72											
11/11/22 21:00	1			71			73											
11/11/22 22:00	1			72			74											
11/11/22 23:00	1			73			74											
11/12/22 0:00	1			72			74											
11/12/22 1:00	1			72			74											
11/12/22 2:00	1			73			75											
11/12/22 3:00	1			74			76											
11/12/22 4:00	1			75			76											
11/12/22 5:00	1			75			77											
11/12/22 6:00	1			75			76											
11/12/22 7:00	1			73			74											
11/12/22 8:00	1			73			74											
11/12/22 9:00	1			72			73											
11/12/22 10:00	1			72			73											
11/12/22 11:00	1			69			70											
11/12/22 12:00	1			66			68											
11/12/22 13:00	1			64			65											
11/12/22 14:00	1			64			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/22 15:00	1			66			68											
11/12/22 16:00	1			69			71											
11/12/22 17:00	1			70			72											
11/12/22 18:00	1			71			72											
11/12/22 19:00	1			71			72											
11/12/22 20:00	1			71			72											
11/12/22 21:00	1			71			72											
11/12/22 22:00	1			71			72											
11/12/22 23:00	1			71			72											
11/13/22 0:00	1			68			70											
11/13/22 1:00	1			65			67											
11/13/22 2:00	1			62			63											
11/13/22 3:00	1			62			63											
11/13/22 4:00	1			63			64											
11/13/22 5:00	1			63			65											
11/13/22 6:00	1			64			65											
11/13/22 7:00	1			66			67											
11/13/22 8:00	1			66			68											
11/13/22 9:00	1			68			70											
11/13/22 10:00	1			66			68											
11/13/22 11:00	1			65			67											
11/13/22 12:00	1			62			63											
11/13/22 13:00	1			61			62											
11/13/22 14:00	1			58			59											
11/13/22 15:00	1			55			56											
11/13/22 16:00	1			59			60											
11/13/22 17:00	1			66			67											
11/13/22 18:00	1			73			74											
11/13/22 19:00	1			72			74											
11/13/22 20:00	1			71			73											
11/13/22 21:00	1			72			74											
11/13/22 22:00	1			72			74											
11/13/22 23:00	1			73			75											
11/14/22 0:00	1			71			74											
11/14/22 1:00	1			68			70											
11/14/22 2:00	1			65			67											
11/14/22 3:00	1			62			64											
11/14/22 4:00	1			62			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/22 5:00	1			65			66											
11/14/22 6:00	1			73			74											
11/14/22 7:00	1			78			80											
11/14/22 8:00	1			78			79											
11/14/22 9:00	1			73			75											
11/14/22 10:00	1			67			69											
11/14/22 11:00	1			62			63											
11/14/22 12:00	1			55			56											
11/14/22 13:00	1			53			54											
11/14/22 14:00	1			54			56											
11/14/22 15:00	1			60			61											
11/14/22 16:00	1			66			67											
11/14/22 17:00	1			72			73											
11/14/22 18:00	1			75			76											
11/14/22 19:00	1			75			76											
11/14/22 20:00	1			75			76											
11/14/22 21:00	1			75			76											
11/14/22 22:00	1			75			77											
11/14/22 23:00	1			74			76											
11/15/22 0:00	1			74			76											
11/15/22 1:00	1			75			76											
11/15/22 2:00	1			76			78											
11/15/22 3:00	1			76			78											
11/15/22 4:00	1			77			78											
11/15/22 5:00	1			77			78											
11/15/22 6:00	1			77			79											
11/15/22 7:00	1			77			79											
11/15/22 8:00	1			75			77											
11/15/22 9:00	1			69			71											
11/15/22 10:00	1			60			62											
11/15/22 11:00	1			50			52											
11/15/22 12:00	1			41			43											
11/15/22 13:00	1			36			38											
11/15/22 14:00	1			34			35											
11/15/22 15:00	1			39			40											
11/15/22 16:00	1			52			53											
11/15/22 17:00	1			65			67											
11/15/22 18:00	1			74			76											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/22 19:00	1			74			76											
11/15/22 20:00	1			74			76											
11/15/22 21:00	1			74			75											
11/15/22 22:00	1			72			74											
11/15/22 23:00	1			72			73											
11/16/22 0:00	1			71			72											
11/16/22 1:00	1			72			73											
11/16/22 2:00	1			72			73											
11/16/22 3:00	1			72			73											
11/16/22 4:00	1			73			74											
11/16/22 5:00	1			74			75											
11/16/22 6:00	1			75			77											
11/16/22 7:00	1			76			78											
11/16/22 8:00	1			72			73											
11/16/22 9:00	1			64			65											
11/16/22 10:00	1			52			53											
11/16/22 11:00	1			43			44											
11/16/22 12:00	1			42			43											
11/16/22 13:00	1			44			45											
11/16/22 14:00	1			44			45											
11/16/22 15:00	1			44			45											
11/16/22 16:00	1			50			51											
11/16/22 17:00	1			61			63											
11/16/22 18:00	1			69			71											
11/16/22 19:00	1			73			75											
11/16/22 20:00	1			74			75											
11/16/22 21:00	1			74			75											
11/16/22 22:00	1			73			74											
11/16/22 23:00	1			75			76											
11/17/22 0:00	1			70			72											
11/17/22 1:00	1			66			68											
11/17/22 2:00	1			63			65											
11/17/22 3:00	1			62			64											
11/17/22 4:00	1			62			64											
11/17/22 5:00	1			63			65											
11/17/22 6:00	1			64			65											
11/17/22 7:00	1			66			68											
11/17/22 8:00	1			59			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/22 9:00	1			58			59											
11/17/22 10:00	1			57			59											
11/17/22 11:00	1			65			66											
11/17/22 12:00	1			66			67											
11/17/22 13:00	1			66			67											
11/17/22 14:00	1			68			69											
11/17/22 15:00	1			70			71											
11/17/22 16:00	1			71			72											
11/17/22 17:00	1			73			74											
11/17/22 18:00	1			74			76											
11/17/22 19:00	1			75			77											
11/17/22 20:00	1			75			77											
11/17/22 21:00	1			74			76											
11/17/22 22:00	1			73			75											
11/17/22 23:00	1			72			74											
11/18/22 0:00	1			72			74											
11/18/22 1:00	1			72			74											
11/18/22 2:00	1			73			75											
11/18/22 3:00	1			73			75											
11/18/22 4:00	1			75			76											
11/18/22 5:00	1			76			78											
11/18/22 6:00	1			79			81											
11/18/22 7:00	1			80			82											
11/18/22 8:00	1			79			81											
11/18/22 9:00	1			75			77											
11/18/22 10:00	1			73			75											
11/18/22 11:00	1			71			73											
11/18/22 12:00	1			70			71											
11/18/22 13:00	1			69			70											
11/18/22 14:00	1			69			70											
11/18/22 15:00	1			69			70											
11/18/22 16:00	1			71			72											
11/18/22 17:00	1			74			75											
11/18/22 18:00	1			76			77											
11/18/22 19:00	1			76			78											
11/18/22 20:00	1			76			78											
11/18/22 21:00	1			76			78											
11/18/22 22:00	1			77			78											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/22 23:00	1			76			78											
11/19/22 0:00	1			74			76											
11/19/22 1:00	1			73			74											
11/19/22 2:00	1			72			73											
11/19/22 3:00	1			72			73											
11/19/22 4:00	1			72			73											
11/19/22 5:00	1			73			75											
11/19/22 6:00	1			75			77											
11/19/22 7:00	1			76			78											
11/19/22 8:00	1			68			70											
11/19/22 9:00	1			54			55											
11/19/22 10:00	1			40			41											
11/19/22 11:00	1			34			35											
11/19/22 12:00	1			34			35											
11/19/22 13:00	1			34			35											
11/19/22 14:00	1			34			35											
11/19/22 15:00	1			37			38											
11/19/22 16:00	1			50			51											
11/19/22 17:00	1			63			64											
11/19/22 18:00	1			72			73											
11/19/22 19:00	1			73			74											
11/19/22 20:00	1			75			76											
11/19/22 21:00	1			76			78											
11/19/22 22:00	1			77			79											
11/19/22 23:00	1			77			79											
11/20/22 0:00	1			77			79											
11/20/22 1:00	1			78			80											
11/20/22 2:00	1			78			80											
11/20/22 3:00	1			78			80											
11/20/22 4:00	1			78			80											
11/20/22 5:00	1			78			80											
11/20/22 6:00	1			77			79											
11/20/22 7:00	1			75			77											
11/20/22 8:00	1			71			72											
11/20/22 9:00	1			67			69											
11/20/22 10:00	1			66			67											
11/20/22 11:00	1			66			67											
11/20/22 12:00	1			65			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/22 13:00	1			65			66											
11/20/22 14:00	1			63			65											
11/20/22 15:00	1			62			63											
11/20/22 16:00	1			63			65											
11/20/22 17:00	1			67			68											
11/20/22 18:00	1			72			73											
11/20/22 19:00	1			72			73											
11/20/22 20:00	1			72			73											
11/20/22 21:00	1			72			73											
11/20/22 22:00	1			71			72											
11/20/22 23:00	1			70			72											
11/21/22 0:00	1			71			72											
11/21/22 1:00	1			71			72											
11/21/22 2:00	1			71			72											
11/21/22 3:00	1			71			72											
11/21/22 4:00	1			72			74											
11/21/22 5:00	1			74			75											
11/21/22 6:00	1			75			77											
11/21/22 7:00	1			74			76											
11/21/22 8:00	1			63			65											
11/21/22 9:00	1			49			51											
11/21/22 10:00	1			37			38											
11/21/22 11:00	1			34			35											
11/21/22 12:00	1			35			36											
11/21/22 13:00	1			35			36											
11/21/22 14:00	1			43			44											
11/21/22 15:00	1			55			56											
11/21/22 16:00	1			67			69											
11/21/22 17:00	1			72			74											
11/21/22 18:00	1			72			74											
11/21/22 19:00	1			72			74											
11/21/22 20:00	1			72			74											
11/21/22 21:00	1			73			74											
11/21/22 22:00	1			73			75											
11/21/22 23:00	1			73			74											
11/22/22 0:00	1			70			71											
11/22/22 1:00	1			67			68											
11/22/22 2:00	1			64			65											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/22 3:00	1			62			64											
11/22/22 4:00	1			61			63											
11/22/22 5:00	1			60			62											
11/22/22 6:00	1			62			64											
11/22/22 7:00	1			57			58											
11/22/22 8:00	1			55			56											
11/22/22 9:00	1			57			58											
11/22/22 10:00	1			64			65											
11/22/22 11:00	1			68			70											
11/22/22 12:00	1			69			70											
11/22/22 13:00	1			71			72											
11/22/22 14:00	1			72			73											
11/22/22 15:00	1			71			73											
11/22/22 16:00	1			70			72											
11/22/22 17:00	1			70			71											
11/22/22 18:00	1			69			70											
11/22/22 19:00	1			69			70											
11/22/22 20:00	1			69			70											
11/22/22 21:00	1			66			68											
11/22/22 22:00	1			58			60											
11/22/22 23:00	1			47			49											
11/23/22 0:00	1			44			45											
11/23/22 1:00	1			45			46											
11/23/22 2:00	1			50			52											
11/23/22 3:00	1			50			52											
11/23/22 4:00	1			53			55											
11/23/22 5:00	1			56			58											
11/23/22 6:00	1			58			60											
11/23/22 7:00	1			55			56											
11/23/22 8:00	1			48			49											
11/23/22 9:00	1			41			42											
11/23/22 10:00	1			40			42											
11/23/22 11:00	1			48			50											
11/23/22 12:00	1			57			59											
11/23/22 13:00	1			63			65											
11/23/22 14:00	1			55			56											
11/23/22 15:00	1			47			48											
11/23/22 16:00	1			50			51											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/22 17:00	1			61			63											
11/23/22 18:00	1			69			71											
11/23/22 19:00	1			69			71											
11/23/22 20:00	1			69			70											
11/23/22 21:00	1			70			71											
11/23/22 22:00	1			71			72											
11/23/22 23:00	1			72			73											
11/24/22 0:00	1			71			73											
11/24/22 1:00	1			71			72											
11/24/22 2:00	1			67			69											
11/24/22 3:00	1			63			65											
11/24/22 4:00	1			60			62											
11/24/22 5:00	1			61			63											
11/24/22 6:00	1			63			65											
11/24/22 7:00	1			67			69											
11/24/22 8:00	1			70			72											
11/24/22 9:00	1			71			74											
11/24/22 10:00	1			71			73											
11/24/22 11:00	1			70			72											
11/24/22 12:00	1			70			71											
11/24/22 13:00	1			69			70											
11/24/22 14:00	1			60			61											
11/24/22 15:00	1			54			55											
11/24/22 16:00	1			54			55											
11/24/22 17:00	1			63			64											
11/24/22 18:00	1			69			71											
11/24/22 19:00	1			68			70											
11/24/22 20:00	1			68			70											
11/24/22 21:00	1			68			70											
11/24/22 22:00	1			68			70											
11/24/22 23:00	1			68			70											
11/25/22 0:00	1			68			70											
11/25/22 1:00	1			68			70											
11/25/22 2:00	1			68			70											
11/25/22 3:00	1			68			70											
11/25/22 4:00	1			69			71											
11/25/22 5:00	1			70			72											
11/25/22 6:00	1			71			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/22 7:00	1			71			73											
11/25/22 8:00	1			70			72											
11/25/22 9:00	1			60			62											
11/25/22 10:00	1			48			49											
11/25/22 11:00	1			36			37											
11/25/22 12:00	1			33			34											
11/25/22 13:00	1			33			34											
11/25/22 14:00	1			33			34											
11/25/22 15:00	1			37			38											
11/25/22 16:00	1			49			50											
11/25/22 17:00	1			61			62											
11/25/22 18:00	1			69			70											
11/25/22 19:00	1			69			70											
11/25/22 20:00	1			69			70											
11/25/22 21:00	1			68			70											
11/25/22 22:00	1			69			71											
11/25/22 23:00	1			69			71											
11/26/22 0:00	1			70			72											
11/26/22 1:00	1			71			72											
11/26/22 2:00	1			72			73											
11/26/22 3:00	1			72			73											
11/26/22 4:00	1			72			73											
11/26/22 5:00	1			73			74											
11/26/22 6:00	1			75			76											
11/26/22 7:00	1			75			76											
11/26/22 8:00	1			72			73											
11/26/22 9:00	1			70			71											
11/26/22 10:00	1			63			64											
11/26/22 11:00	1			53			54											
11/26/22 12:00	1			40			41											
11/26/22 13:00	1			33			34											
11/26/22 14:00	1			33			34											
11/26/22 15:00	1			38			39											
11/26/22 16:00	1			50			51											
11/26/22 17:00	1			62			63											
11/26/22 18:00	1			69			70											
11/26/22 19:00	1			69			70											
11/26/22 20:00	1			69			71											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/22 21:00	1			70			72											
11/26/22 22:00	1			70			72											
11/26/22 23:00	1			70			71											
11/27/22 0:00	1			70			71											
11/27/22 1:00	1			70			72											
11/27/22 2:00	1			70			72											
11/27/22 3:00	1			70			72											
11/27/22 4:00	1			71			72											
11/27/22 5:00	1			71			73											
11/27/22 6:00	1			71			73											
11/27/22 7:00	1			68			69											
11/27/22 8:00	1			56			57											
11/27/22 9:00	1			43			44											
11/27/22 10:00	1			34			35											
11/27/22 11:00	1			33			34											
11/27/22 12:00	1			33			34											
11/27/22 13:00	1			32			33											
11/27/22 14:00	1			32			33											
11/27/22 15:00	1			40			41											
11/27/22 16:00	1			52			54											
11/27/22 17:00	1			66			67											
11/27/22 18:00	1			71			73											
11/27/22 19:00	1			72			73											
11/27/22 20:00	1			71			72											
11/27/22 21:00	1			71			73											
11/27/22 22:00	1			71			73											
11/27/22 23:00	1			70			72											
11/28/22 0:00	1			69			71											
11/28/22 1:00	1			69			71											
11/28/22 2:00	1			69			71											
11/28/22 3:00	1			68			70											
11/28/22 4:00	1			68			70											
11/28/22 5:00	1			69			70											
11/28/22 6:00	1			70			72											
11/28/22 7:00	1			72			74											
11/28/22 8:00	1			72			74											
11/28/22 9:00	1			65			66											
11/28/22 10:00	1			52			53											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/22 11:00	1			40			41											
11/28/22 12:00	1			33			34											
11/28/22 13:00	1			32			33											
11/28/22 14:00	1			32			33											
11/28/22 15:00	1			38			39											
11/28/22 16:00	1			51			52											
11/28/22 17:00	1			63			64											
11/28/22 18:00	1			69			71											
11/28/22 19:00	1			68			70											
11/28/22 20:00	1			69			70											
11/28/22 21:00	1			70			72											
11/28/22 22:00	1			71			72											
11/28/22 23:00	1			70			72											
11/29/22 0:00	1			67			69											
11/29/22 1:00	1			66			67											
11/29/22 2:00	1			65			66											
11/29/22 3:00	1			64			65											
11/29/22 4:00	1			63			64											
11/29/22 5:00	1			63			65											
11/29/22 6:00	1			65			66											
11/29/22 7:00	1			71			66											
11/29/22 8:00	1			72			44											
11/29/22 9:00	1			70			21											
11/29/22 10:00	1			63			0											
11/29/22 11:00	1			61			0											
11/29/22 12:00	1			56			15											
11/29/22 13:00	1			57			36											
11/29/22 14:00	1			62			62											
11/29/22 15:00	1			71			73											
11/29/22 16:00	1			76			78											
11/29/22 17:00	1			77			78											
11/29/22 18:00	1			77			79											
11/29/22 19:00	1			77			79											
11/29/22 20:00	1			77			79											
11/29/22 21:00	1			77			78											
11/29/22 22:00	1			77			78											
11/29/22 23:00	1			75			77											
11/30/22 0:00	1			71			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/22 1:00	1			67			69											
11/30/22 2:00	1			64			66											
11/30/22 3:00	1			65			66											
11/30/22 4:00	1			65			66											
11/30/22 5:00	1			65			66											
11/30/22 6:00	1			70			71											
11/30/22 7:00	1			72			73											
11/30/22 8:00	1			67			68											
11/30/22 9:00	1			56			57											
11/30/22 10:00	1			43			45											
11/30/22 11:00	1			37			39											
11/30/22 12:00	1			33			35											
11/30/22 13:00	1			33			34											
11/30/22 14:00	1			39			40											
11/30/22 15:00	1			47			48											
11/30/22 16:00	1			59			61											
11/30/22 17:00	1			66			68											
11/30/22 18:00	1			71			73											
11/30/22 19:00	1			72			73											
11/30/22 20:00	1			71			73											
11/30/22 21:00	1			71			73											
11/30/22 22:00	1			70			72											
11/30/22 23:00	1			59			60											
12/01/22 0:00	1			53			54											
12/01/22 1:00	1			49			50											
12/01/22 2:00	1			55			56											
12/01/22 3:00	1			55			57											
12/01/22 4:00	1			58			59											
12/01/22 5:00	1			62			64											
12/01/22 6:00	1			68			69											
12/01/22 7:00	1			70			71											
12/01/22 8:00	1			71			73											
12/01/22 9:00	1			73			75											
12/01/22 10:00	1			76			78											
12/01/22 11:00	1			76			78											
12/01/22 12:00	1			75			77											
12/01/22 13:00	1			75			77											
12/01/22 14:00	1			75			77											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/22 15:00	1			75			76											
12/01/22 16:00	1			73			74											
12/01/22 17:00	1			71			72											
12/01/22 18:00	1			70			71											
12/01/22 19:00	1			69			71											
12/01/22 20:00	1			69			70											
12/01/22 21:00	1			69			70											
12/01/22 22:00	1			69			70											
12/01/22 23:00	1			68			70											
12/02/22 0:00	1			68			70											
12/02/22 1:00	1			68			70											
12/02/22 2:00	1			68			70											
12/02/22 3:00	1			68			70											
12/02/22 4:00	1			69			70											
12/02/22 5:00	1			69			71											
12/02/22 6:00	1			70			72											
12/02/22 7:00	1			73			75											
12/02/22 8:00	1			74			75											
12/02/22 9:00	1			73			75											
12/02/22 10:00	1			72			73											
12/02/22 11:00	1			72			73											
12/02/22 12:00	1			72			73											
12/02/22 13:00	1			73			74											
12/02/22 14:00	1			74			76											
12/02/22 15:00	1			76			78											
12/02/22 16:00	1			76			78											
12/02/22 17:00	1			77			78											
12/02/22 18:00	1			76			78											
12/02/22 19:00	1			77			78											
12/02/22 20:00	1			77			79											
12/02/22 21:00	1			78			79											
12/02/22 22:00	1			77			79											
12/02/22 23:00	1			75			77											
12/03/22 0:00	1			74			75											
12/03/22 1:00	1			72			74											
12/03/22 2:00	1			72			73											
12/03/22 3:00	1			72			73											
12/03/22 4:00	1			72			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 5:00	1			73			74											
12/03/22 6:00	1			74			75											
12/03/22 7:00	1			75			77											
12/03/22 8:00	1			76			78											
12/03/22 9:00	1			77			79											
12/03/22 10:00	1			76			77											
12/03/22 11:00	1			75			76											
12/03/22 12:00	1			73			74											
12/03/22 13:00	1			72			73											
12/03/22 14:00	1			72			73											
12/03/22 15:00	1			73			74											
12/03/22 16:00	1			74			75											
12/03/22 17:00	1			69			70											
12/03/22 18:00	1			51			45											
12/03/22 19:00	1			44			20											
12/03/22 20:00	1			45			1											
12/03/22 21:00	1			58			0											
12/03/22 22:00	1			60			0											
12/03/22 23:00	1			60			0											
12/04/22 0:00	1			62			0											
12/04/22 1:00	1			64			0											
12/04/22 2:00	1			66			0											
12/04/22 3:00	1			66			0											
12/04/22 4:00	1			66			0											
12/04/22 5:00	1			66			0											
12/04/22 6:00	1			66			0											
12/04/22 7:00	1			66			0											
12/04/22 8:00	1			66			0											
12/04/22 9:00	1			66			0											
12/04/22 10:00	1			66			0											
12/04/22 11:00	1			66			0											
12/04/22 12:00	1			66			0											
12/04/22 13:00	1			66			0											
12/04/22 14:00	1			65			0											
12/04/22 15:00	1			63			0											
12/04/22 16:00	1			62			0											
12/04/22 17:00	1			62			0											
12/04/22 18:00	1			62			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/22 19:00	1			62			0											
12/04/22 20:00	1			62			0											
12/04/22 21:00	1			62			0											
12/04/22 22:00	1			62			0											
12/04/22 23:00	1			62			0											
12/05/22 0:00	1			62			0											
12/05/22 1:00	1			62			0											
12/05/22 2:00	1			62			0											
12/05/22 3:00	1			62			0											
12/05/22 4:00	1			62			0											
12/05/22 5:00	1			62			0											
12/05/22 6:00	1			62			0											
12/05/22 7:00	1			63			0											
12/05/22 8:00	1			63			0											
12/05/22 9:00	1			63			0											
12/05/22 10:00	1			56			0											
12/05/22 11:00	1			46			0											
12/05/22 12:00	1			36			0											
12/05/22 13:00	1			31			0											
12/05/22 14:00	1			31			0											
12/05/22 15:00	1			31			0											
12/05/22 16:00	1			34			0											
12/05/22 17:00	1			37			9											
12/05/22 18:00	1			42			25											
12/05/22 19:00	1			53			50											
12/05/22 20:00	1			64			66											
12/05/22 21:00	1			71			73											
12/05/22 22:00	1			68			69											
12/05/22 23:00	1			57			58											
12/06/22 0:00	1			50			51											
12/06/22 1:00	1			30			42											
12/06/22 2:00	1			16			39											
12/06/22 3:00	1			0			33											
12/06/22 4:00	1			0			32											
12/06/22 5:00	1			0			32											
12/06/22 6:00	1			0			32											
12/06/22 7:00	1			0			32											
12/06/22 8:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 9:00	1			0			32											
12/06/22 10:00	1			0			32											
12/06/22 11:00	1			0			32											
12/06/22 12:00	1			0			32											
12/06/22 13:00	1			0			32											
12/06/22 14:00	1			0			33											
12/06/22 15:00	1			8			36											
12/06/22 16:00	1			27			44											
12/06/22 17:00	1			51			58											
12/06/22 18:00	1			67			68											
12/06/22 19:00	1			72			74											
12/06/22 20:00	1			72			73											
12/06/22 21:00	1			71			73											
12/06/22 22:00	1			70			72											
12/06/22 23:00	1			69			71											
12/07/22 0:00	1			66			68											
12/07/22 1:00	1			62			64											
12/07/22 2:00	1			60			61											
12/07/22 3:00	1			59			60											
12/07/22 4:00	1			62			63											
12/07/22 5:00	1			66			67											
12/07/22 6:00	1			70			72											
12/07/22 7:00	1			72			74											
12/07/22 8:00	1			70			72											
12/07/22 9:00	1			69			71											
12/07/22 10:00	1			69			70											
12/07/22 11:00	1			69			70											
12/07/22 12:00	1			66			68											
12/07/22 13:00	1			55			56											
12/07/22 14:00	1			45			47											
12/07/22 15:00	1			48			49											
12/07/22 16:00	1			59			61											
12/07/22 17:00	1			68			70											
12/07/22 18:00	1			68			70											
12/07/22 19:00	1			69			71											
12/07/22 20:00	1			70			72											
12/07/22 21:00	1			72			74											
12/07/22 22:00	1			72			74											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/22 23:00	1			70			72											
12/08/22 0:00	1			69			71											
12/08/22 1:00	1			69			71											
12/08/22 2:00	1			70			71											
12/08/22 3:00	1			69			71											
12/08/22 4:00	1			70			71											
12/08/22 5:00	1			71			72											
12/08/22 6:00	1			72			74											
12/08/22 7:00	1			73			75											
12/08/22 8:00	1			72			74											
12/08/22 9:00	1			69			71											
12/08/22 10:00	1			65			67											
12/08/22 11:00	1			65			67											
12/08/22 12:00	1			67			69											
12/08/22 13:00	1			72			74											
12/08/22 14:00	1			73			75											
12/08/22 15:00	1			73			75											
12/08/22 16:00	1			74			76											
12/08/22 17:00	1			74			76											
12/08/22 18:00	1			76			78											
12/08/22 19:00	1			77			79											
12/08/22 20:00	1			77			79											
12/08/22 21:00	1			77			79											
12/08/22 22:00	1			76			78											
12/08/22 23:00	1			74			76											
12/09/22 0:00	1			68			70											
12/09/22 1:00	1			61			62											
12/09/22 2:00	1			56			57											
12/09/22 3:00	1			56			57											
12/09/22 4:00	1			60			60											
12/09/22 5:00	1			63			63											
12/09/22 6:00	1			66			65											
12/09/22 7:00	1			68			68											
12/09/22 8:00	1			65			66											
12/09/22 9:00	1			60			62											
12/09/22 10:00	1			48			49											
12/09/22 11:00	1			40			41											
12/09/22 12:00	1			35			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/22 13:00	1			45			46											
12/09/22 14:00	1			54			56											
12/09/22 15:00	1			59			61											
12/09/22 16:00	1			62			63											
12/09/22 17:00	1			65			66											
12/09/22 18:00	1			72			73											
12/09/22 19:00	1			72			74											
12/09/22 20:00	1			73			75											
12/09/22 21:00	1			73			75											
12/09/22 22:00	1			73			75											
12/09/22 23:00	1			72			74											
12/10/22 0:00	1			69			71											
12/10/22 1:00	1			66			68											
12/10/22 2:00	1			64			65											
12/10/22 3:00	1			64			65											
12/10/22 4:00	1			64			65											
12/10/22 5:00	1			64			65											
12/10/22 6:00	1			64			65											
12/10/22 7:00	1			55			56											
12/10/22 8:00	1			48			49											
12/10/22 9:00	1			39			41											
12/10/22 10:00	1			38			39											
12/10/22 11:00	1			38			39											
12/10/22 12:00	1			44			46											
12/10/22 13:00	1			52			54											
12/10/22 14:00	1			61			63											
12/10/22 15:00	1			65			67											
12/10/22 16:00	1			69			71											
12/10/22 17:00	1			69			71											
12/10/22 18:00	1			69			70											
12/10/22 19:00	1			69			71											
12/10/22 20:00	1			70			72											
12/10/22 21:00	1			70			72											
12/10/22 22:00	1			69			71											
12/10/22 23:00	1			69			70											
12/11/22 0:00	1			68			70											
12/11/22 1:00	1			61			63											
12/11/22 2:00	1			51			52											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/22 3:00	1			42			43											
12/11/22 4:00	1			44			45											
12/11/22 5:00	1			50			51											
12/11/22 6:00	1			54			55											
12/11/22 7:00	1			49			50											
12/11/22 8:00	1			41			42											
12/11/22 9:00	1			34			35											
12/11/22 10:00	1			33			34											
12/11/22 11:00	1			32			33											
12/11/22 12:00	1			32			33											
12/11/22 13:00	1			32			33											
12/11/22 14:00	1			33			34											
12/11/22 15:00	1			40			41											
12/11/22 16:00	1			52			53											
12/11/22 17:00	1			64			65											
12/11/22 18:00	1			68			70											
12/11/22 19:00	1			69			70											
12/11/22 20:00	1			69			70											
12/11/22 21:00	1			69			70											
12/11/22 22:00	1			64			65											
12/11/22 23:00	1			52			53											
12/12/22 0:00	1			41			42											
12/12/22 1:00	1			35			36											
12/12/22 2:00	1			37			38											
12/12/22 3:00	1			38			39											
12/12/22 4:00	1			44			45											
12/12/22 5:00	1			54			55											
12/12/22 6:00	1			67			68											
12/12/22 7:00	1			72			74											
12/12/22 8:00	1			71			73											
12/12/22 9:00	1			70			71											
12/12/22 10:00	1			66			68											
12/12/22 11:00	1			55			56											
12/12/22 12:00	1			43			44											
12/12/22 13:00	1			34			35											
12/12/22 14:00	1			33			34											
12/12/22 15:00	1			43			22											
12/12/22 16:00	1			53			11											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 17:00	1			64			0											
12/12/22 18:00	1			65			0											
12/12/22 19:00	1			65			0											
12/12/22 20:00	1			65			0											
12/12/22 21:00	1			65			0											
12/12/22 22:00	1			66			0											
12/12/22 23:00	1			66			0											
12/13/22 0:00	1			66			0											
12/13/22 1:00	1			66			0											
12/13/22 2:00	1			66			0											
12/13/22 3:00	1			66			0											
12/13/22 4:00	1			66			0											
12/13/22 5:00	1			66			0											
12/13/22 6:00	1			66			0											
12/13/22 7:00	1			67			0											
12/13/22 8:00	1			67			0											
12/13/22 9:00	1			67			0											
12/13/22 10:00	1			66			0											
12/13/22 11:00	1			57			0											
12/13/22 12:00	1			46			0											
12/13/22 13:00	1			34			0											
12/13/22 14:00	1			31			0											
12/13/22 15:00	1			37			0											
12/13/22 16:00	1			49			0											
12/13/22 17:00	1			60			0											
12/13/22 18:00	1			65			0											
12/13/22 19:00	1			65			0											
12/13/22 20:00	1			65			0											
12/13/22 21:00	1			67			0											
12/13/22 22:00	1			67			0											
12/13/22 23:00	1			67			0											
12/14/22 0:00	1			65			0											
12/14/22 1:00	1			64			0											
12/14/22 2:00	1			63			0											
12/14/22 3:00	1			63			0											
12/14/22 4:00	1			63			0											
12/14/22 5:00	1			64			0											
12/14/22 6:00	1			64			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/22 7:00	1			64			0											
12/14/22 8:00	1			63			0											
12/14/22 9:00	1			63			0											
12/14/22 10:00	1			63			0											
12/14/22 11:00	1			62			0											
12/14/22 12:00	1			52			0											
12/14/22 13:00	1			42			0											
12/14/22 14:00	1			32			0											
12/14/22 15:00	1			31			0											
12/14/22 16:00	1			35			0											
12/14/22 17:00	1			46			0											
12/14/22 18:00	1			57			0											
12/14/22 19:00	1			65			0											
12/14/22 20:00	1			65			0											
12/14/22 21:00	1			64			0											
12/14/22 22:00	1			63			0											
12/14/22 23:00	1			63			0											
12/15/22 0:00	1			63			0											
12/15/22 1:00	1			63			0											
12/15/22 2:00	1			63			0											
12/15/22 3:00	1			63			0											
12/15/22 4:00	1			63			0											
12/15/22 5:00	1			63			0											
12/15/22 6:00	1			63			0											
12/15/22 7:00	1			63			0											
12/15/22 8:00	1			63			0											
12/15/22 9:00	1			63			0											
12/15/22 10:00	1			63			0											
12/15/22 11:00	1			63			0											
12/15/22 12:00	1			62			0											
12/15/22 13:00	1			62			0											
12/15/22 14:00	1			62			0											
12/15/22 15:00	1			62			0											
12/15/22 16:00	1			62			0											
12/15/22 17:00	1			62			0											
12/15/22 18:00	1			62			0											
12/15/22 19:00	1			62			0											
12/15/22 20:00	1			62			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/22 21:00	1			62			0											
12/15/22 22:00	1			62			0											
12/15/22 23:00	1			62			0											
12/16/22 0:00	1			61			0											
12/16/22 1:00	1			51			0											
12/16/22 2:00	1			41			0											
12/16/22 3:00	1			32			0											
12/16/22 4:00	1			32			0											
12/16/22 5:00	1			32			0											
12/16/22 6:00	1			32			0											
12/16/22 7:00	1			32			0											
12/16/22 8:00	1			32			0											
12/16/22 9:00	1			32			0											
12/16/22 10:00	1			32			0											
12/16/22 11:00	1			32			0											
12/16/22 12:00	1			32			0											
12/16/22 13:00	1			32			0											
12/16/22 14:00	1			32			0											
12/16/22 15:00	1			32			0											
12/16/22 16:00	1			32			0											
12/16/22 17:00	1			32			0											
12/16/22 18:00	1			32			0											
12/16/22 19:00	1			32			0											
12/16/22 20:00	1			32			0											
12/16/22 21:00	1			32			0											
12/16/22 22:00	1			32			0											
12/16/22 23:00	1			32			0											
12/17/22 0:00	1			32			0											
12/17/22 1:00	1			32			0											
12/17/22 2:00	1			38			0											
12/17/22 3:00	1			40			9											
12/17/22 4:00	1			40			20											
12/17/22 5:00	1			40			37											
12/17/22 6:00	1			50			51											
12/17/22 7:00	1			63			64											
12/17/22 8:00	1			67			68											
12/17/22 9:00	1			61			63											
12/17/22 10:00	1			51			52											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 11:00	1			41			42											
12/17/22 12:00	1			34			35											
12/17/22 13:00	1			33			34											
12/17/22 14:00	1			36			37											
12/17/22 15:00	1			49			50											
12/17/22 16:00	1			62			63											
12/17/22 17:00	1			72			73											
12/17/22 18:00	1			72			73											
12/17/22 19:00	1			72			73											
12/17/22 20:00	1			73			74											
12/17/22 21:00	1			74			76											
12/17/22 22:00	1			74			76											
12/17/22 23:00	1			72			74											
12/18/22 0:00	1			68			69											
12/18/22 1:00	1			63			65											
12/18/22 2:00	1			59			60											
12/18/22 3:00	1			57			59											
12/18/22 4:00	1			57			58											
12/18/22 5:00	1			58			60											
12/18/22 6:00	1			61			63											
12/18/22 7:00	1			67			68											
12/18/22 8:00	1			71			72											
12/18/22 9:00	1			75			76											
12/18/22 10:00	1			73			74											
12/18/22 11:00	1			68			69											
12/18/22 12:00	1			59			60											
12/18/22 13:00	1			47			48											
12/18/22 14:00	1			42			43											
12/18/22 15:00	1			41			42											
12/18/22 16:00	1			52			53											
12/18/22 17:00	1			60			61											
12/18/22 18:00	1			70			71											
12/18/22 19:00	1			71			73											
12/18/22 20:00	1			72			74											
12/18/22 21:00	1			72			73											
12/18/22 22:00	1			71			73											
12/18/22 23:00	1			70			72											
12/19/22 0:00	1			71			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/22 1:00	1			71			72											
12/19/22 2:00	1			72			73											
12/19/22 3:00	1			72			73											
12/19/22 4:00	1			73			74											
12/19/22 5:00	1			74			75											
12/19/22 6:00	1			76			77											
12/19/22 7:00	1			76			78											
12/19/22 8:00	1			76			78											
12/19/22 9:00	1			76			78											
12/19/22 10:00	1			77			79											
12/19/22 11:00	1			77			79											
12/19/22 12:00	1			76			78											
12/19/22 13:00	1			75			77											
12/19/22 14:00	1			75			76											
12/19/22 15:00	1			75			76											
12/19/22 16:00	1			75			77											
12/19/22 17:00	1			76			77											
12/19/22 18:00	1			77			78											
12/19/22 19:00	1			77			78											
12/19/22 20:00	1			77			79											
12/19/22 21:00	1			77			79											
12/19/22 22:00	1			77			79											
12/19/22 23:00	1			76			77											
12/20/22 0:00	1			72			73											
12/20/22 1:00	1			68			69											
12/20/22 2:00	1			65			66											
12/20/22 3:00	1			65			66											
12/20/22 4:00	1			65			66											
12/20/22 5:00	1			65			67											
12/20/22 6:00	1			65			67											
12/20/22 7:00	1			69			71											
12/20/22 8:00	1			72			74											
12/20/22 9:00	1			73			75											
12/20/22 10:00	1			68			69											
12/20/22 11:00	1			54			55											
12/20/22 12:00	1			42			43											
12/20/22 13:00	1			33			34											
12/20/22 14:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/22 15:00	1			38			39											
12/20/22 16:00	1			50			51											
12/20/22 17:00	1			62			63											
12/20/22 18:00	1			68			70											
12/20/22 19:00	1			68			70											
12/20/22 20:00	1			68			70											
12/20/22 21:00	1			68			70											
12/20/22 22:00	1			68			70											
12/20/22 23:00	1			68			70											
12/21/22 0:00	1			68			70											
12/21/22 1:00	1			68			70											
12/21/22 2:00	1			68			70											
12/21/22 3:00	1			68			70											
12/21/22 4:00	1			68			70											
12/21/22 5:00	1			68			70											
12/21/22 6:00	1			69			70											
12/21/22 7:00	1			71			72											
12/21/22 8:00	1			71			73											
12/21/22 9:00	1			73			75											
12/21/22 10:00	1			73			75											
12/21/22 11:00	1			74			76											
12/21/22 12:00	1			73			74											
12/21/22 13:00	1			72			74											
12/21/22 14:00	1			72			73											
12/21/22 15:00	1			71			73											
12/21/22 16:00	1			71			72											
12/21/22 17:00	1			71			72											
12/21/22 18:00	1			71			73											
12/21/22 19:00	1			71			73											
12/21/22 20:00	1			72			74											
12/21/22 21:00	1			73			75											
12/21/22 22:00	1			73			74											
12/21/22 23:00	1			71			72											
12/22/22 0:00	1			69			70											
12/22/22 1:00	1			67			69											
12/22/22 2:00	1			66			67											
12/22/22 3:00	1			65			66											
12/22/22 4:00	1			65			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/22 5:00	1			65			66											
12/22/22 6:00	1			65			66											
12/22/22 7:00	1			66			67											
12/22/22 8:00	1			68			69											
12/22/22 9:00	1			71			72											
12/22/22 10:00	1			73			74											
12/22/22 11:00	1			76			77											
12/22/22 12:00	1			75			76											
12/22/22 13:00	1			72			74											
12/22/22 14:00	1			69			71											
12/22/22 15:00	1			69			70											
12/22/22 16:00	1			70			71											
12/22/22 17:00	1			70			71											
12/22/22 18:00	1			70			72											
12/22/22 19:00	1			69			71											
12/22/22 20:00	1			69			70											
12/22/22 21:00	1			69			70											
12/22/22 22:00	1			69			71											
12/22/22 23:00	1			69			71											
12/23/22 0:00	1			68			70											
12/23/22 1:00	1			68			70											
12/23/22 2:00	1			68			70											
12/23/22 3:00	1			68			70											
12/23/22 4:00	1			68			70											
12/23/22 5:00	1			68			70											
12/23/22 6:00	1			68			70											
12/23/22 7:00	1			70			72											
12/23/22 8:00	1			71			73											
12/23/22 9:00	1			72			74											
12/23/22 10:00	1			71			73											
12/23/22 11:00	1			71			73											
12/23/22 12:00	1			70			72											
12/23/22 13:00	1			60			61											
12/23/22 14:00	1			50			52											
12/23/22 15:00	1			51			53											
12/23/22 16:00	1			62			64											
12/23/22 17:00	1			73			74											
12/23/22 18:00	1			74			76											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/22 19:00	1			73			75											
12/23/22 20:00	1			73			75											
12/23/22 21:00	1			72			74											
12/23/22 22:00	1			72			74											
12/23/22 23:00	1			72			74											
12/24/22 0:00	1			69			71											
12/24/22 1:00	1			67			68											
12/24/22 2:00	1			65			66											
12/24/22 3:00	1			65			66											
12/24/22 4:00	1			65			66											
12/24/22 5:00	1			65			66											
12/24/22 6:00	1			65			66											
12/24/22 7:00	1			57			58											
12/24/22 8:00	1			47			48											
12/24/22 9:00	1			45			46											
12/24/22 10:00	1			54			55											
12/24/22 11:00	1			66			67											
12/24/22 12:00	1			70			71											
12/24/22 13:00	1			69			71											
12/24/22 14:00	1			69			70											
12/24/22 15:00	1			68			70											
12/24/22 16:00	1			68			70											
12/24/22 17:00	1			69			70											
12/24/22 18:00	1			69			70											
12/24/22 19:00	1			68			70											
12/24/22 20:00	1			66			68											
12/24/22 21:00	1			55			56											
12/24/22 22:00	1			43			45											
12/24/22 23:00	1			34			35											
12/25/22 0:00	1			35			36											
12/25/22 1:00	1			35			36											
12/25/22 2:00	1			35			36											
12/25/22 3:00	1			34			35											
12/25/22 4:00	1			34			35											
12/25/22 5:00	1			34			35											
12/25/22 6:00	1			34			35											
12/25/22 7:00	1			34			35											
12/25/22 8:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/22 9:00	1			36			37											
12/25/22 10:00	1			36			37											
12/25/22 11:00	1			37			38											
12/25/22 12:00	1			36			37											
12/25/22 13:00	1			36			37											
12/25/22 14:00	1			35			36											
12/25/22 15:00	1			33			34											
12/25/22 16:00	1			38			39											
12/25/22 17:00	1			50			51											
12/25/22 18:00	1			54			55											
12/25/22 19:00	1			49			50											
12/25/22 20:00	1			38			39											
12/25/22 21:00	1			34			35											
12/25/22 22:00	1			34			35											
12/25/22 23:00	1			34			35											
12/26/22 0:00	1			35			36											
12/26/22 1:00	1			35			36											
12/26/22 2:00	1			36			37											
12/26/22 3:00	1			35			36											
12/26/22 4:00	1			35			36											
12/26/22 5:00	1			38			39											
12/26/22 6:00	1			41			42											
12/26/22 7:00	1			41			42											
12/26/22 8:00	1			37			38											
12/26/22 9:00	1			34			35											
12/26/22 10:00	1			38			39											
12/26/22 11:00	1			49			50											
12/26/22 12:00	1			60			62											
12/26/22 13:00	1			67			69											
12/26/22 14:00	1			69			71											
12/26/22 15:00	1			71			73											
12/26/22 16:00	1			71			73											
12/26/22 17:00	1			72			73											
12/26/22 18:00	1			72			73											
12/26/22 19:00	1			71			73											
12/26/22 20:00	1			70			72											
12/26/22 21:00	1			68			70											
12/26/22 22:00	1			57			59											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/22 23:00	1			45			46											
12/27/22 0:00	1			34			35											
12/27/22 1:00	1			32			33											
12/27/22 2:00	1			32			33											
12/27/22 3:00	1			32			33											
12/27/22 4:00	1			32			33											
12/27/22 5:00	1			32			33											
12/27/22 6:00	1			32			33											
12/27/22 7:00	1			32			33											
12/27/22 8:00	1			33			34											
12/27/22 9:00	1			33			34											
12/27/22 10:00	1			33			34											
12/27/22 11:00	1			32			33											
12/27/22 12:00	1			32			33											
12/27/22 13:00	1			33			34											
12/27/22 14:00	1			33			34											
12/27/22 15:00	1			33			34											
12/27/22 16:00	1			33			34											
12/27/22 17:00	1			32			33											
12/27/22 18:00	1			32			33											
12/27/22 19:00	1			32			33											
12/27/22 20:00	1			32			33											
12/27/22 21:00	1			32			33											
12/27/22 22:00	1			32			33											
12/27/22 23:00	1			32			33											
12/28/22 0:00	1			21			35											
12/28/22 1:00	1			11			34											
12/28/22 2:00	1			0			33											
12/28/22 3:00	1			0			32											
12/28/22 4:00	1			0			32											
12/28/22 5:00	1			0			32											
12/28/22 6:00	1			0			31											
12/28/22 7:00	1			0			31											
12/28/22 8:00	1			0			31											
12/28/22 9:00	1			0			31											
12/28/22 10:00	1			0			32											
12/28/22 11:00	1			0			32											
12/28/22 12:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/22 13:00	1			0			32											
12/28/22 14:00	1			0			32											
12/28/22 15:00	1			0			31											
12/28/22 16:00	1			0			31											
12/28/22 17:00	1			0			31											
12/28/22 18:00	1			0			31											
12/28/22 19:00	1			0			31											
12/28/22 20:00	1			0			32											
12/28/22 21:00	1			0			32											
12/28/22 22:00	1			0			32											
12/28/22 23:00	1			0			32											
12/29/22 0:00	1			0			32											
12/29/22 1:00	1			0			32											
12/29/22 2:00	1			0			32											
12/29/22 3:00	1			0			32											
12/29/22 4:00	1			0			32											
12/29/22 5:00	1			0			32											
12/29/22 6:00	1			0			32											
12/29/22 7:00	1			0			32											
12/29/22 8:00	1			0			32											
12/29/22 9:00	1			0			32											
12/29/22 10:00	1			0			32											
12/29/22 11:00	1			0			32											
12/29/22 12:00	1			0			32											
12/29/22 13:00	1			0			32											
12/29/22 14:00	1			0			32											
12/29/22 15:00	1			0			32											
12/29/22 16:00	1			0			32											
12/29/22 17:00	1			0			32											
12/29/22 18:00	1			0			31											
12/29/22 19:00	1			0			31											
12/29/22 20:00	1			0			31											
12/29/22 21:00	1			0			32											
12/29/22 22:00	1			0			32											
12/29/22 23:00	1			0			32											
12/30/22 0:00	1			0			32											
12/30/22 1:00	1			0			32											
12/30/22 2:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/22 3:00	1			0			32											
12/30/22 4:00	1			0			32											
12/30/22 5:00	1			0			32											
12/30/22 6:00	1			0			32											
12/30/22 7:00	1			0			32											
12/30/22 8:00	1			0			32											
12/30/22 9:00	1			0			32											
12/30/22 10:00	1			0			32											
12/30/22 11:00	1			0			31											
12/30/22 12:00	1			0			31											
12/30/22 13:00	1			0			31											
12/30/22 14:00	1			0			31											
12/30/22 15:00	1			0			32											
12/30/22 16:00	1			0			32											
12/30/22 17:00	1			0			32											
12/30/22 18:00	1			0			32											
12/30/22 19:00	1			0			32											
12/30/22 20:00	1			0			32											
12/30/22 21:00	1			0			32											
12/30/22 22:00	1			0			32											
12/30/22 23:00	1			0			32											
12/31/22 0:00	1			0			32											
12/31/22 1:00	1			0			32											
12/31/22 2:00	1			0			32											
12/31/22 3:00	1			0			32											
12/31/22 4:00	1			0			32											
12/31/22 5:00	1			0			32											
12/31/22 6:00	1			0			32											
12/31/22 7:00	1			0			32											
12/31/22 8:00	1			0			32											
12/31/22 9:00	1			0			32											
12/31/22 10:00	1			0			24											
12/31/22 11:00	0			0			13											
12/31/22 12:00	0			0			3											
12/31/22 13:00	0			0			0											
12/31/22 14:00	1			0			6											
12/31/22 15:00	1			0			17											
12/31/22 16:00	1			0			27											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 17:00	1			0			32											
12/31/22 18:00	1			0			32											
12/31/22 19:00	1			0			32											
12/31/22 20:00	1			0			32											
12/31/22 21:00	1			0			32											
12/31/22 22:00	1			0			32											
12/31/22 23:00	1			0			32											

Monthly Summary Report

Units CT1 and CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:52 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Oct 22	736.47	736.47	324.18	324.18	512.12	512.12	193.64	193.64
Nov 22	720.00	1,456.47	421.74	745.92	671.03	1,183.15	392.29	585.93
Dec 22	633.90	2,090.37	340.24	1,086.16	584.59	1,767.74	293.02	878.95
Sum/Avg	2,090.37		1,086.16		1,767.74		878.95	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2022	0.6338	6.9447	1.5229	13.9715	0.3310	2.9119	0.1656	1.4563	0.5515	4.8538
Nov 2022	0.7748	7.3343	1.8689	14.5482	0.4031	3.0270	0.2017	1.5140	0.6720	5.0462
Dec 2022	0.6728	7.4389	1.5792	14.5596	0.3385	3.0207	0.1697	1.5116	0.5644	5.0359
Sum/Avg	7.4389		14.5596		3.0207		1.5116		5.0359	
Limit Value										

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:11 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,093.00 Hour(s)
Operating time for CMS: 2,093.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:15 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,093.00 Hour(s)
Operating time for CMS: 2,093.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:15 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:16 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	1
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	0.06
5. Time in compliance as percentage of operating time	99.94

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:17 Location: Roseville, CA



Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 2,093.00 Hour(s)
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/12/2022 08:00	12/12/2022 08:59	1	1 - Monitor equipment malfunctions	12 - Replaced sample pump diaphragm

Total Operating Time:	2,093.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Monitor equipment malfunctions	1	100.00
12	Action	Replaced sample pump diaphragm	1	100.00

NOx Invalid Data

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:17 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 2,093.00 Hour(s)
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/12/2022 08:00	12/12/2022 08:59	1	1 - Monitor equipment malfunctions	12 - Replaced sample pump diaphragm

Total Operating Time:	2,093.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Monitor equipment malfunctions	1	100.00
12	Action	Replaced sample pump diaphragm	1	100.00

NOx SCR Invalid Data

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:18 Location: Roseville, CA



Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 2,093.00 Hour(s)
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/12/2022 08:00	12/12/2022 08:59	1	1 - Monitor equipment malfunctions	12 - Replaced sample pump diaphragm

Total Operating Time:	2,093.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Monitor equipment malfunctions	1	100.00
12	Action	Replaced sample pump diaphragm	1	100.00

02 Invalid Data

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:19 Location: Roseville, CA



Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 2,093.00 Hour(s)
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/12/2022 08:00	12/12/2022 08:59	1	1 - Monitor equipment malfunctions	12 - Replaced sample pump diaphragm

Total Operating Time:	2,093.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Monitor equipment malfunctions	1	100.00
12	Action	Replaced sample pump diaphragm	1	100.00

CO Invalid Data

CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:19 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,776.00 Hour(s)
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,776.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:20 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,776.00 Hour(s)
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,776.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:21 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,776.00 Hour(s)
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,776.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:20 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 1,776.00 Hour(s)
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,776.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

ATTACHMENT 7

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Year: 2022 Non-Compliance Event Number: 008

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK		5120 PHILLIP ROAD	
2. Title V Source Status	Major Yes ☒ No ☐		Synthetic Minor Yes ☐ No ☒	
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☐			
4. Emission Exceedances	NOx ☒	SOx ☐	PM ☐	VOC ☐ CO ☐ Opacity ☐ None ☐ check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒			
6. Detection of Non-Compliance Event	Date	12-03-22	Time	17:40 ☐ AM ☒ PM
7. Start of Non-Compliance Event	Date	12-03-22	Time	17:37 ☐ AM ☒ PM ☐ Not known
8. Violation	Permit No. REPR-20-02	Condition No. 49	Rule	Section
9. Unit / Equipment Involved	CT2			
10. Description / Cause of Non-Compliance Event	Facility electric protection detected a system fault which triggered a trip on all turbine supporting equipment. ☐ additional information attached			
11. Immediate Corrective Actions	Operator initiated a turbine shut down. ☐ additional information attached			
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☒ No ☐			
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404				
	Yes ☒	No ☐	Not Able to Determine at this Time ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I	
13. Submitted By	Matt Garner		Telephone	(916) 746 - 1691
Signature	<i>Matt Garner</i>		Date	10-05-22 Time 11:35 ☒ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	Time	☐ AM ☐ PM
15. Duration of Non-Compliance Event	Hours	Minutes	
16. Excess Emissions Estimates	NOx	SOx	PM
	VOC	CO	Opacity % for minutes Other
17. Variance in Effect	Yes ☐ Variance # No ☐		
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions (b) Correct Event (c) Prevent Future Events ☐ additional information attached		
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404		
	Yes ☐	No ☐	If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I
Telephone			
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.			
Signature	Date	Time	☐ AM ☐ PM

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Company Name	Roseville Energy Park	Address	5120 Phillip Rd.	
Detection of Non-Compliance Event	Date	12-03-2022	Time	17:40 ☐ AM ☒ PM

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes No

☒	☐	1. Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions.
☒	☐	2. The amount and duration of emissions as a result of the event have been minimized.
☒	☐	3. The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance.
☒	☐	4. The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated).
☒	☐	5. The event is not the result of improper equipment design.
☒	☐	6. The event is not the result of improper preventative maintenance of equipment.
☒	☐	7. The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator.
☒	☐	8. The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices.
☒	☐	9. The event has not resulted in a nuisance.
☒	☐	10. The event is not the result of the disregard of air pollution rules or regulations.
☒	☐	11. This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event.
☒	☐	12. Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form.

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature Matt Garner

You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.



Year Non-Compliance Event Number 2 0 2 2 0 1 0

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org

Erik C. White, Air Pollution Control Office

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK	5120 PHILLIP ROAD
2. Title V Source Status	Major Yes ☒ No ☐	Synthetic Minor Yes ☐ No ☐
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☒	
4. Emission Exceedances	NOx ☐ SOx ☐ PM ☐ VOC ☐ CO ☐ Opacity ☐ None ☒	check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☒ No ☐	
6. Detection of Non-Compliance Event	Date 12-12-22 Time 4:00	☒ AM ☐ PM
7. Start of Non-Compliance Event	Date 12-12-22 Time 3:47	☒ AM ☐ PM ☐ Not known
8. Violation	Permit No. REPR-20-01 Condition No. Rule Section	
9. Unit / Equipment Involved	CT1 CEMS	
10. Description / Cause of Non-Compliance Event	CO analyzer fault ☐ additional information attached	
11. Immediate Corrective Actions	Replaced sample pump diaphragm ☒ additional information attached	
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☒ No ☐	
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404		
Yes ☒ No ☐ Not Able to Determine at this Time ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I		
13. Submitted By	Tony Johnson	Telephone (916) 746 - 1656
Signature		Date 12-12-22 Time 9:50 ☒ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date 12-12-22 Time 09:00	☒ AM ☐ PM
15. Duration of Non-Compliance Event	Hours 5 Minutes	
16. Excess Emissions Estimates	NOx VOC CO Opacity %, for minutes Other	
17. Variance in Effect	Yes ☐ Variance # No ☒	
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions (b) Correct Event (c) Prevent Future Events REPAIRED PUMP, INSTALL NEW DIAPHRAGM ☐ additional information attached	
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404	
Yes ☐ No ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I		
20. Submitted By	Tony Johnson	Telephone (916) 746 - 1656
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.		
Signature		Date 12-12-22 Time 09:50 ☒ AM ☐ PM

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Non-Compliance
Event Number

Company Name	ROSEVILLE ENERGY PARK	Address	5120 PHILLIP RD. ROSEVILLE		
Detection of Non-Compliance Event	Date	12-12-22	Time	4:00	☐ AM ☐ PM


Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes No


☒	☐	1. Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions.
☒	☐	2. The amount and duration of emissions as a result of the event have been minimized.
☒	☐	3. The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance.
☒	☐	4. The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated).
☒	☐	5. The event is not the result of improper equipment design.
☒	☐	6. The event is not the result of improper preventative maintenance of equipment.
☒	☐	7. The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator.
☒	☐	8. The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices.
☒	☐	9. The event has not resulted in a nuisance.
☒	☐	10. The event is not the result of the disregard of air pollution rules or regulations.
☒	☐	11. This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event.
☒	☐	12. Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form.

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature



You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.



Broken pump diaphragm CT1 CO Analyzer 12-12-22



110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org

Erik C. White, Air Pollution Control Officer

Year Non-Compliance Event Number 2 0 2 2 0 1 2

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK		5120 PHILLIP ROAD	
2. Title V Source Status	Major Yes ☒ No ☐		Synthetic Minor Yes ☐ No ☒	
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(I)	Yes ☐ No ☐			
4. Emission Exceedances	NOx ☒	SOx ☐	PM ☐	VOC ☐ CO ☐ Opacity ☐ None ☐ check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒			
6. Detection of Non-Compliance Event	Date	12-03-22	Time	17:40 ☐ AM ☒ PM
7. Start of Non-Compliance Event	Date	12-03-22	Time	17:37 ☐ AM ☒ PM ☐ Not known
8. Violation	Permit No. REPR-20-02	Condition No. 49	Rule	Section
9. Unit / Equipment Involved	CT2			
10. Description / Cause of Non-Compliance Event	Facility electric protection detected a system fault which triggered a trip on all turbine supporting equipment. ☐ additional information attached			
11. Immediate Corrective Actions	Operator initiated a turbine shut down. ☐ additional information attached			
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☒ No ☐			
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404				
	Yes ☒	No ☐	Not Able to Determine at this Time ☐	If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I
13. Submitted By	Matt Garner		Telephone	(916) 746 - 1691
Signature	Date	12-3-22	Time	11:35 ☒ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	12-3-22	Time	18:00 ☐ AM ☒ PM
15. Duration of Non-Compliance Event	Hours	(	Minutes	
16. Excess Emissions Estimates	NOx	2.6	SOx	PM
	VOC	CO	Opacity	%, for minutes Other
17. Variance in Effect	Yes ☐ Variance #		No ☒	
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions		(b) Correct Event	(c) Prevent Future Events
☒ additional information attached				
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☒ No ☐			
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404				
	Yes ☒	No ☐	If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I	
Telephone 916-746-1656				
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.				
Signature	Tom Johnson		Date	12-14-22 Time 07:30 ☒ AM ☐ PM

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Year							
2	0	2	2	-	0	1	2
Non-Compliance Event Number							

Company Name	Roseville Energy Park			Address	5120 Phillip Rd.		
Detection of Non-Compliance Event	Date	12-03-2022	Time	17:40	☐ AM	☒ PM	

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes	No	
☒	☐	1. Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions.
☒	☐	2. The amount and duration of emissions as a result of the event have been minimized.
☒	☐	3. The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance.
☒	☐	4. The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated).
☒	☐	5. The event is not the result of improper equipment design.
☒	☐	6. The event is not the result of improper preventative maintenance of equipment.
☒	☐	7. The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator.
☒	☐	8. The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices.
☒	☐	9. The event has not resulted in a nuisance.
☒	☐	10. The event is not the result of the disregard of air pollution rules or regulations.
☒	☐	11. This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event.
☒	☐	12. Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form.

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature _____

You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.



Roseville Electric
Roseville Energy Park
5120 Phillip Road
Roseville, California 95747

Tony Johnson
Operations and Maintenance Supervisor
Roseville Energy Park
5120 Phillip Road
Roseville, California 95747

Subject: Non-Compliance Event Notification Form #22-008 – (Please note this form number has been corrected to #22-012)

To Whom It May Concern:

This memo is to provide additional information for Non-Compliance Event Notification Form #22-012 Part I.

On December 3rd 2022, Roseville Energy Park's Combustion Turbine #2 (REP-20-02) exceeded allowable NOx emissions when several auxiliary systems failed as boiler feedpump motor 1000-B suffered a major electrical fault. The support equipment that shut down due to a protective relay "trip" included the ammonia dilution blowers that help deliver ammonia to control NOx emissions. The recorded emissions for the hour were 2.6 ppmvdc, above the permit limit of 2.0. After troubleshooting and isolating the failed equipment the unit was returned to service.

We respectfully request shielding from this event pursuant to Rule 404 Upset Conditions, Breakdown.

Let me know if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Tony Johnson", is written over a horizontal line.

Tony Johnson

NOX Ppmvdc 1-Hour Block Excess Emissions CT2



From: 12/01/2022 00:00 To: 12/13/2022 13:14 Facility Name: ROSEVILLE ENERGY
Generated: 12/13/2022 13:18 Location: Roseville, CA

Tag Name: CT2_NOX_Ppmvdc_1H

Total Operating Time: 234.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 68.00 Hour(s) Report Time: 302.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	12/03/22 17:00	12/03/22 17:59	1	2.6	2.0	3 - Process Problems	

Total Operating Time:

234.00 Hour(s)

Total Duration (Online only):

1.00 Hour(s)

Time in exceedance as a percentage of operating time:

0.43 %

Time in compliance as a percentage of operating time:

99.57 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Process Problems	1	100.00

ATTACHMENT 8

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

ATTACHMENT 9

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

01/03/2023

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scal CO / High

Test Date: 10/04/2022
Test **Pass**

Instrument CT2_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	08:23	L	200	49.400	50.000	24.7 %
10/04/2022	08:29	M	200	112.700	116.400	56.4 %
10/04/2022	08:41	L	200	49.400	49.900	24.7 %
10/04/2022	08:46	M	200	112.700	116.400	56.4 %
10/04/2022	08:58	L	200	49.400	50.000	24.7 %
10/04/2022	09:03	M	200	112.700	116.400	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.400	49.967	Std	1.1
M	112.700	116.400	Std	3.3

Cylinder Gas Audit

01/03/2023

Page 2

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	08:26	L	200	50.300	49.700	25.2 %
10/04/2022	08:31	M	200	112.800	114.700	56.4 %
10/04/2022	08:43	L	200	50.300	49.700	25.2 %
10/04/2022	08:48	M	200	112.800	114.400	56.4 %
10/04/2022	09:00	L	200	50.300	49.700	25.2 %
10/04/2022	09:05	M	200	112.800	114.400	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	50.300	49.700	Std	1.2
M	112.800	114.500	Std	1.5

Cylinder Gas Audit

01/03/2023

Page 3

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	12:28	L	10	2.400	2.200	24.0 %
10/04/2022	12:33	M	10	5.700	5.600	57.0 %
10/04/2022	12:40	L	10	2.400	2.200	24.0 %
10/04/2022	12:45	M	10	5.700	5.500	57.0 %
10/04/2022	12:52	L	10	2.400	2.200	24.0 %
10/04/2022	12:57	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference	Mean	CEMS Mean	Specification	Results
L	2.400		2.200	Std	8.3
M	5.700		5.533	Std	2.9

Cylinder Gas Audit

01/03/2023

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT2_CODualRg_P_Instr
Unit/Stack:	CT2	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/04/2022	12:25	L	10	2.400	2.200	24.0 %
10/04/2022	12:31	M	10	5.700	5.600	57.0 %
10/04/2022	12:38	L	10	2.400	2.200	24.0 %
10/04/2022	12:43	M	10	5.700	5.500	57.0 %
10/04/2022	12:50	L	10	2.400	2.200	24.0 %
10/04/2022	12:55	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference	Mean	CEMS Mean	Specification	Results
L	2.400		2.200	Std	8.3
M	5.700		5.533	Std	2.9

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

10/19,25,26/22 Taylor Sullivan

Q3 EDR

Linearity Report

01/03/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	123	Highest	2.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0823	L	200.0	48.2	47.1		24.1 %
10/04/2022	0829	M	200.0	106.0	108.4		53.0 %
10/04/2022	0834	H	200.0	180.0	180.5		90.0 %
10/04/2022	0841	L	200.0	48.2	47.9		24.1 %
10/04/2022	0846	M	200.0	106.0	108.7		53.0 %
10/04/2022	0851	H	200.0	180.0	180.4		90.0 %
10/04/2022	0858	L	200.0	48.2	48.3		24.1 %
10/04/2022	0903	M	200.0	106.0	108.7		53.0 %
10/04/2022	0908	H	200.0	180.0	180.3		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	47.767	No	0.9
M	106.000	108.600	No	2.5
H	180.000	180.400	No	0.2

Linearity Report

01/03/2023

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	124	Highest	0.0
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1024	L	21.0	5.0	5.0		23.8 %
10/04/2022	1030	M	21.0	11.2	11.2		53.3 %
10/04/2022	1035	H	21.0	18.3	18.3		87.1 %
10/04/2022	1042	L	21.0	5.0	5.0		23.8 %
10/04/2022	1047	M	21.0	11.2	11.2		53.3 %
10/04/2022	1052	H	21.0	18.3	18.3		87.1 %
10/04/2022	1059	L	21.0	5.0	5.0		23.8 %
10/04/2022	1104	M	21.0	11.2	11.2		53.3 %
10/04/2022	1109	H	21.0	18.3	18.3		87.1 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.200	11.200	No	0.0
H	18.300	18.300	No	0.0

Linearity Report

01/03/2023

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	120	Highest	2.6
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	0826	L	200.0	47.8	45.0		23.9 %
10/04/2022	0831	M	200.0	105.0	107.3		52.5 %
10/04/2022	0836	H	200.0	180.0	180.6		90.0 %
10/04/2022	0843	L	200.0	47.8	48.9		23.9 %
10/04/2022	0848	M	200.0	105.0	107.9		52.5 %
10/04/2022	0853	H	200.0	180.0	180.8		90.0 %
10/04/2022	0900	L	200.0	47.8	49.5		23.9 %
10/04/2022	0905	M	200.0	105.0	108.1		52.5 %
10/04/2022	0910	H	200.0	180.0	181.0		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.800	47.800	No	0.0
M	105.000	107.767	No	2.6
H	180.000	180.800	No	0.4

Linearity Report

01/03/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	10/04/2022	Scale:	High
Performance	5 %	Test No.:	121	Highest	1.8
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/04/2022	1027	L	21.0	5.7	5.6		27.1 %
10/04/2022	1032	M	21.0	11.1	11.1		52.9 %
10/04/2022	1037	H	21.0	18.1	18.2		86.2 %
10/04/2022	1044	L	21.0	5.7	5.6		27.1 %
10/04/2022	1049	M	21.0	11.1	11.1		52.9 %
10/04/2022	1054	H	21.0	18.1	18.2		86.2 %
10/04/2022	1101	L	21.0	5.7	5.6		27.1 %
10/04/2022	1106	M	21.0	11.1	11.1		52.9 %
10/04/2022	1111	H	21.0	18.1	18.2		86.2 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.700	5.600	No	1.8
M	11.100	11.100	No	0.0
H	18.100	18.200	No	0.6

ATTACHMENT 10

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:05 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:03 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:04 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:05 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:05 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:32 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:31 Location: Roseville, CA



Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:35 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:32 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:36 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:33 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:34 Location: Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:35 Location: Roseville, CA



Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:34 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:33 Location: Roseville, CA



Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,093.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 115.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,093.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:37 Location: Roseville, CA



Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:37 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:38 Location: Roseville, CA

Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:38 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:40 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:40 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:41 Location: Roseville, CA

Tag Name: CT2_SO2_Norm_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:41 Location: Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:39 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:39 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 1,776.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	12/03/22 17:00	12/03/22 17:59	1	2.6	2.0	3 - Process Problems	

Total Operating Time:	1,776.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.06 %
Time in compliance as a percentage of operating time:	99.94 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Process Problems	1	100.00

ATTACHMENT 11

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 16:00 Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOx, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Oct 22	1.5229	1.5229	0.5515	0.5515
Nov 22	1.8689	3.3918	0.6720	1.2235
Dec 22	1.5792	4.9710	0.5644	1.7879
Sum/Avg	4.9710		1.7879	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:42 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOx, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOx, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2022	0.3256	3.0647	0.8706	6.8331	736.47	6,135.13	0.3083	3.8468	0.6525	7.1386	512.12	5,966.98
Nov 2022	0.3357	3.2090	0.9259	7.1284	720.00	6,142.75	0.4390	4.0919	0.9424	7.4202	671.03	5,918.01
Dec 2022	0.3279	3.2820	0.8070	7.1714	633.90	6,032.65	0.3450	4.1232	0.7725	7.3889	584.59	5,758.60
Sum/Avg	3.2820		7.1714		6,032.65		4.1232		7.3889		5,758.60	
Limit Value												

ATTACHMENT 12

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 13

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

ATTACHMENT 14

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	1	1.6	6.7	14.5	14.9	897,614.9	0.00	1.00
10/01/2022 01:00	1	1.6	6.7	14.4	13.6	842,301.3	0.00	1.00
10/01/2022 02:00	1	1.4	7.0	14.4	16.8	863,580.1	0.00	1.00
10/01/2022 03:00	1	1.4	6.9	14.5	17.3	905,531.9	0.00	1.00
10/01/2022 04:00	1	1.5	6.9	14.5	15.0	877,929.4	0.00	1.00
10/01/2022 05:00	1	1.7	7.1	14.5	17.6	929,496.8	0.00	1.00
10/01/2022 06:00	3	1.6	9.9	14.6	23.8	784,267.2	0.00	1.00
10/01/2022 07:00	3	1.5	13.8	14.8	26.3	616,914.5	0.00	1.00
10/01/2022 08:00	3	1.5	13.1	14.8	24.8	616,690.0	0.00	1.00
10/01/2022 09:00	2	1.5	12.3	14.9	22.4	627,652.8	0.00	1.00
10/01/2022 10:00	2	1.5	11.9	14.9	21.2	628,794.0	0.00	1.00
10/01/2022 11:00	2	1.5	11.8	14.9	20.7	628,337.6	0.00	1.00
10/01/2022 12:00	2	1.5	11.3	14.9	19.4	629,250.5	0.00	1.00
10/01/2022 13:00	1	1.5	10.4	14.9	15.4	638,380.0	0.00	1.00
10/01/2022 14:00	2	1.5	10.8	14.9	18.8	630,391.7	0.00	1.00
10/01/2022 15:00	1	1.5	10.2	14.9	14.7	638,836.5	0.00	1.00
10/01/2022 16:00	0	1.5	7.5	14.7	9.6	840,429.0	0.00	1.00
10/01/2022 17:00	0	1.6	6.4	14.6	10.8	968,161.3	0.00	1.00
10/01/2022 18:00	1	1.6	6.6	14.5	13.8	906,173.8	0.00	1.00
10/01/2022 19:00	1	1.6	6.6	14.4	13.4	845,040.2	0.00	1.00
10/01/2022 20:00	1	1.6	6.6	14.5	15.6	922,221.7	0.00	1.00
10/01/2022 21:00	1	1.6	7.0	14.4	15.9	847,568.4	0.00	1.00
10/01/2022 22:00	2	1.6	9.2	14.5	18.7	696,694.7	0.00	1.00
10/01/2022 23:00	1	1.6	6.7	14.4	12.6	808,381.7	0.00	1.00
Average/Sum#:	1	1.5	8.9	14.6	17.2	774,610.0	0.00 #	24.00 #
Minimum:	0	1.4	6.4	14.4	9.6	616,690.0	0.00	1.00
Maximum:	3	1.7	13.8	14.9	26.3	968,161.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2022 00:00	2	1.6	7.8	14.4	17.6	760,978.6	0.00	1.00
10/02/2022 01:00	1	1.5	7.9	14.5	15.0	756,393.0	0.00	1.00
10/02/2022 02:00	2	1.4	7.1	14.5	18.1	897,828.9	0.00	1.00
10/02/2022 03:00	1	1.7	6.9	14.5	16.8	903,606.1	0.00	1.00
10/02/2022 04:00	1	1.7	6.8	14.5	17.3	946,614.6	0.00	1.00
10/02/2022 05:00	1	1.7	6.8	14.5	17.4	940,409.4	0.00	1.00
10/02/2022 06:00	3	1.7	8.9	14.5	22.5	809,672.2	0.00	1.00
10/02/2022 07:00	3	1.6	14.5	14.8	28.2	620,057.4	0.00	1.00
10/02/2022 08:00	3	1.7	13.8	14.8	26.8	616,690.0	0.00	1.00
10/02/2022 09:00	3	1.7	13.3	14.8	25.0	616,914.5	0.00	1.00
10/02/2022 10:00	3	1.6	13.0	14.8	23.9	617,139.0	0.00	1.00
10/02/2022 11:00	2	1.6	12.7	14.9	23.0	627,424.6	0.00	1.00
10/02/2022 12:00	1	1.6	11.2	14.8	17.4	631,282.2	0.00	1.00
10/02/2022 13:00	0	1.6	8.0	14.6	9.7	734,707.1	0.00	1.00
10/02/2022 14:00	0	1.7	6.4	14.5	8.8	897,828.9	0.00	1.00
10/02/2022 15:00	1	1.6	8.0	14.6	12.9	769,703.5	0.00	1.00
10/02/2022 16:00	1	1.8	7.0	14.4	13.3	921,306.6	0.00	1.00
10/02/2022 17:00	1	2.0	9.4	13.7	19.8	995,685.6	0.00	1.00
10/02/2022 18:00	1	2.0	9.3	13.7	20.2	987,126.7	0.00	1.00
10/02/2022 19:00	1	1.9	9.3	13.8	21.1	997,943.9	0.00	1.00
10/02/2022 20:00	1	1.9	8.9	13.9	20.8	988,920.0	0.00	1.00
10/02/2022 21:00	1	1.7	6.9	14.4	13.6	845,250.9	0.00	1.00
10/02/2022 22:00	2	1.7	8.2	14.5	16.7	775,864.5	0.00	1.00
10/02/2022 23:00	1	1.7	6.5	14.5	14.4	955,815.4	0.00	1.00
Average/Sum#:	2	1.7	9.1	14.5	18.3	817,298.5	0.00 #	24.00 #
Minimum:	0	1.4	6.4	13.7	8.8	616,690.0	0.00	1.00
Maximum:	3	2.0	14.5	14.9	28.2	997,943.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2022 00:00	1	1.7	6.6	14.5	16.1	917,300.4	0.00	1.00
10/03/2022 01:00	1	1.8	6.8	14.5	16.3	903,606.1	0.00	1.00
10/03/2022 02:00	2	1.8	7.0	14.5	16.0	913,234.9	0.00	1.00
10/03/2022 03:00	2	1.4	6.9	14.5	19.2	922,435.7	0.00	1.00
10/03/2022 04:00	1	1.7	6.9	14.5	16.3	948,754.3	0.00	1.00
10/03/2022 05:00	2	1.7	6.9	14.5	18.9	961,806.7	0.00	1.00
10/03/2022 06:00	2	1.5	7.6	14.5	19.7	882,850.8	0.00	1.00
10/03/2022 07:00	2	1.4	9.8	14.5	18.8	686,851.9	0.00	1.00
10/03/2022 08:00	1	1.5	6.8	14.5	13.9	889,911.9	0.00	1.00
10/03/2022 09:00	2	1.5	10.5	14.7	21.2	649,151.3	0.00	1.00
10/03/2022 10:00	1	1.4	8.6	14.6	13.0	714,926.5	0.00	1.00
10/03/2022 11:00	1	1.5	7.5	14.6	12.9	821,219.9	0.00	1.00
10/03/2022 12:00	1	1.5	6.4	14.6	13.5	962,944.4	0.00	1.00
10/03/2022 13:00	1	1.5	6.4	14.6	13.7	968,813.4	0.00	1.00
10/03/2022 14:00	1	1.5	6.3	14.6	13.3	969,030.8	0.00	1.00
10/03/2022 15:00	1	1.5	6.4	14.6	13.7	977,290.8	0.00	1.00
10/03/2022 16:00	1	1.5	6.6	14.5	13.5	932,278.4	0.00	1.00
10/03/2022 17:00	1	1.7	9.2	13.7	21.2	999,489.6	0.00	1.00
10/03/2022 18:00	1	1.7	9.4	13.7	21.6	1,003,103.4	0.00	1.00
10/03/2022 19:00	1	1.7	9.3	13.8	21.9	1,010,673.8	0.00	1.00
10/03/2022 20:00	1	1.7	9.1	13.8	22.0	1,002,573.0	0.00	1.00
10/03/2022 21:00	1	1.5	7.6	14.2	17.1	914,244.1	0.00	1.00
10/03/2022 22:00	1	1.5	6.4	14.5	15.8	946,828.6	0.00	1.00
10/03/2022 23:00	2	1.7	8.7	14.0	22.6	1,009,007.8	0.00	1.00
Average/Sum#:	1	1.6	7.7	14.4	17.2	912,847.0	0.00 #	24.00 #
Minimum:	1	1.4	6.3	13.7	12.9	649,151.3	0.00	1.00
Maximum:	2	1.8	10.5	14.7	22.6	1,010,673.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	2	1.7	8.7	14.0	22.6	1,014,564.8	0.00	1.00
10/04/2022 01:00	2	1.7	8.9	13.9	23.5	1,013,569.7	0.00	1.00
10/04/2022 02:00	2	1.5	9.2	14.0	24.0	1,013,572.5	0.00	1.00
10/04/2022 03:00	2	1.8	9.0	14.0	22.5	1,015,557.2	0.00	1.00
10/04/2022 04:00	2	1.8	8.6	14.1	22.4	1,011,158.8	0.00	1.00
10/04/2022 05:00	2	1.8	9.0	13.9	23.7	1,011,809.0	0.00	1.00
10/04/2022 06:00	2	1.7	8.6	14.1	23.1	1,011,561.6	0.00	1.00
10/04/2022 07:00	1	1.7	7.7	14.3	19.8	983,288.2	0.00	1.00
10/04/2022 08:00	1	1.6	6.6	14.5	8.7	962,234.6	0.00	1.00
10/04/2022 09:00	2	1.3	7.6	14.2	17.5	963,502.5	0.00	1.00
10/04/2022 10:00	1	1.9	9.0	13.8	21.2	999,679.8	0.00	1.00
10/04/2022 11:00	1	1.6	6.9	14.4	15.9	972,291.3	0.00	1.00
10/04/2022 12:00	1	1.9	9.6	13.6	28.8	1,016,187.9	0.00	1.00
10/04/2022 13:00	0	1.6	8.5	13.9	15.3	994,397.7	0.00	1.00
10/04/2022 14:00	1	1.8	8.6	13.9	18.2	989,702.6	0.00	1.00
10/04/2022 15:00	1	1.8	9.0	13.7	20.1	992,832.7	0.00	1.00
10/04/2022 16:00	2	1.9	9.8	13.4	22.2	1,001,688.3	0.00	1.00
10/04/2022 17:00	2	2.0	10.7	13.1	24.5	998,626.4	0.00	1.00
10/04/2022 18:00	2	2.0	10.5	13.2	24.6	1,000,924.7	0.00	1.00
10/04/2022 19:00	2	1.9	10.1	13.3	23.8	999,139.2	0.00	1.00
10/04/2022 20:00	2	1.9	10.0	13.4	24.1	1,009,904.8	0.00	1.00
10/04/2022 21:00	2	1.9	9.9	13.4	24.4	1,004,062.0	0.00	1.00
10/04/2022 22:00	2	1.8	9.2	13.7	22.4	1,002,723.0	0.00	1.00
10/04/2022 23:00	2	1.9	9.7	13.5	23.9	1,013,003.9	0.00	1.00
Average/Sum#:	2	1.8	9.0	13.8	21.6	999,832.6	0.00 #	24.00 #
Minimum:	0	1.3	6.6	13.1	8.7	962,234.6	0.00	1.00
Maximum:	2	2.0	10.7	14.5	28.8	1,016,187.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2022 00:00	2	1.9	9.6	13.5	23.8	1,006,897.0	0.00	1.00
10/05/2022 01:00	2	1.9	9.3	13.6	23.4	1,005,870.3	0.00	1.00
10/05/2022 02:00	2	1.9	9.7	13.6	23.5	1,008,871.8	0.00	1.00
10/05/2022 03:00	2	1.9	9.5	13.7	23.9	1,014,895.6	0.00	1.00
10/05/2022 04:00	2	1.8	9.3	13.7	24.1	1,016,987.8	0.00	1.00
10/05/2022 05:00	2	1.8	9.2	13.7	24.3	1,013,944.6	0.00	1.00
10/05/2022 06:00	2	1.8	8.7	13.9	22.8	989,506.9	0.00	1.00
10/05/2022 07:00	1	1.7	8.0	14.3	19.8	1,008,186.8	0.00	1.00
10/05/2022 08:00	1	1.7	7.3	14.4	17.0	964,917.5	0.00	1.00
10/05/2022 09:00	1	1.7	7.1	14.3	16.2	910,459.7	0.00	1.00
10/05/2022 10:00	1	1.8	8.6	13.9	19.0	999,092.9	0.00	1.00
10/05/2022 11:00	1	1.8	8.6	13.9	19.0	998,897.3	0.00	1.00
10/05/2022 12:00	1	1.9	9.1	13.7	20.3	1,004,815.1	0.00	1.00
10/05/2022 13:00	2	2.0	10.2	13.2	22.9	999,146.3	0.00	1.00
10/05/2022 14:00	2	2.0	10.6	13.1	23.8	998,802.0	0.00	1.00
10/05/2022 15:00	1	1.9	9.8	13.4	21.7	1,003,879.4	0.00	1.00
10/05/2022 16:00	1	1.9	9.9	13.3	22.0	996,436.4	0.00	1.00
10/05/2022 17:00	2	2.0	10.8	13.1	24.4	1,006,175.8	0.00	1.00
10/05/2022 18:00	2	2.0	10.6	13.2	24.3	1,008,927.9	0.00	1.00
10/05/2022 19:00	2	2.0	10.3	13.3	23.9	1,007,968.4	0.00	1.00
10/05/2022 20:00	2	1.9	10.1	13.3	24.1	1,004,004.3	0.00	1.00
10/05/2022 21:00	2	1.9	10.1	13.4	24.3	1,014,469.6	0.00	1.00
10/05/2022 22:00	2	1.8	9.4	13.6	22.5	998,929.4	0.00	1.00
10/05/2022 23:00	1	1.6	6.5	14.5	14.9	971,435.4	0.00	1.00
Average/Sum#:	2	1.9	9.3	13.7	21.9	998,063.3	0.00 #	24.00 #
Minimum:	1	1.6	6.5	13.1	14.9	910,459.7	0.00	1.00
Maximum:	2	2.0	10.8	14.5	24.4	1,016,987.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2022 00:00	1	1.6	6.5	14.5	15.5	969,723.6	0.00	1.00
10/06/2022 01:00	1	1.6	6.6	14.5	15.2	971,007.5	0.00	1.00
10/06/2022 02:00	1	1.7	7.0	14.5	16.0	970,365.6	0.00	1.00
10/06/2022 03:00	1	1.6	6.9	14.5	17.1	968,011.9	0.00	1.00
10/06/2022 04:00	1	1.6	6.8	14.5	16.4	970,365.6	0.00	1.00
10/06/2022 05:00	1	1.7	7.2	14.4	19.0	968,920.4	0.00	1.00
10/06/2022 06:00	2	1.7	8.9	14.0	23.3	1,001,664.5	0.00	1.00
10/06/2022 07:00	2	1.6	8.2	14.3	19.7	897,802.9	0.00	1.00
10/06/2022 08:00	2	1.5	9.4	14.6	16.9	668,192.2	0.00	1.00
10/06/2022 09:00	2	1.6	9.8	14.7	16.9	644,733.8	0.00	1.00
10/06/2022 10:00	1	1.6	9.1	14.8	15.2	658,670.7	0.00	1.00
10/06/2022 11:00	1	1.5	7.5	14.6	10.3	737,098.1	0.00	1.00
10/06/2022 12:00	0	1.6	6.1	14.5	8.1	831,497.4	0.00	1.00
10/06/2022 13:00	1	1.7	6.6	14.5	12.8	947,256.5	0.00	1.00
10/06/2022 14:00	1	1.9	9.7	13.5	21.5	1,003,380.9	0.00	1.00
10/06/2022 15:00	1	1.9	9.8	13.4	21.7	999,314.6	0.00	1.00
10/06/2022 16:00	2	2.0	10.4	13.2	23.7	1,005,015.2	0.00	1.00
10/06/2022 17:00	2	2.0	10.9	13.1	24.7	1,006,526.9	0.00	1.00
10/06/2022 18:00	2	2.0	10.6	13.2	24.4	1,007,682.9	0.00	1.00
10/06/2022 19:00	2	1.9	10.3	13.3	24.0	1,010,130.7	0.00	1.00
10/06/2022 20:00	2	1.9	10.2	13.3	24.2	1,003,643.9	0.00	1.00
10/06/2022 21:00	2	1.9	10.0	13.5	23.9	1,017,260.2	0.00	1.00
10/06/2022 22:00	2	1.8	9.4	13.7	23.2	1,018,319.2	0.00	1.00
10/06/2022 23:00	2	1.8	9.3	13.7	23.6	1,021,172.2	0.00	1.00
Average/Sum#:	1	1.7	8.6	14.0	19.1	929,073.2	0.00 #	24.00 #
Minimum:	0	1.5	6.1	13.1	8.1	644,733.8	0.00	1.00
Maximum:	2	2.0	10.9	14.8	24.7	1,021,172.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2022 00:00	2	1.8	9.1	13.8	23.3	1,018,388.8	0.00	1.00
10/07/2022 01:00	2	1.8	9.0	13.8	23.5	1,011,059.5	0.00	1.00
10/07/2022 02:00	1	1.7	8.7	14.2	21.8	1,005,607.2	0.00	1.00
10/07/2022 03:00	2	1.7	8.6	14.2	22.8	983,328.5	0.00	1.00
10/07/2022 04:00	2	1.8	9.6	13.9	24.2	1,023,742.5	0.00	1.00
10/07/2022 05:00	2	1.8	9.8	13.8	25.4	1,029,768.6	0.00	1.00
10/07/2022 06:00	2	1.8	9.1	14.0	23.8	1,012,977.1	0.00	1.00
10/07/2022 07:00	1	1.7	8.6	14.2	21.4	1,017,870.7	0.00	1.00
10/07/2022 08:00	1	1.7	8.2	14.2	20.3	1,007,242.3	0.00	1.00
10/07/2022 09:00	1	1.7	8.5	14.1	20.5	1,014,582.4	0.00	1.00
10/07/2022 10:00	2	1.9	10.0	13.5	24.3	1,026,698.2	0.00	1.00
10/07/2022 11:00	2	1.9	10.6	13.2	24.7	1,011,773.4	0.00	1.00
10/07/2022 12:00	2	2.0	10.8	13.2	25.2	1,014,796.8	0.00	1.00
10/07/2022 13:00	1	1.9	10.0	13.5	22.5	1,013,003.9	0.00	1.00
10/07/2022 14:00	1	1.8	8.9	13.7	19.3	993,022.9	0.00	1.00
10/07/2022 15:00	2	1.9	9.8	13.4	22.4	995,845.4	0.00	1.00
10/07/2022 16:00	2	1.9	10.4	13.3	23.2	1,011,211.8	0.00	1.00
10/07/2022 17:00	2	2.0	11.0	13.1	25.0	1,008,809.3	0.00	1.00
10/07/2022 18:00	2	2.0	10.6	13.2	24.1	1,001,636.1	0.00	1.00
10/07/2022 19:00	2	2.0	10.5	13.2	24.8	1,000,569.0	0.00	1.00
10/07/2022 20:00	2	1.9	10.3	13.3	24.0	1,003,103.4	0.00	1.00
10/07/2022 21:00	2	1.9	10.0	13.5	23.7	1,016,520.0	0.00	1.00
10/07/2022 22:00	2	1.8	9.5	13.7	23.0	1,016,607.4	0.00	1.00
10/07/2022 23:00	2	1.9	9.7	13.6	23.2	1,009,809.8	0.00	1.00
Average/Sum#:	2	1.8	9.6	13.7	23.2	1,010,332.3	0.00 #	24.00 #
Minimum:	1	1.7	8.2	13.1	19.3	983,328.5	0.00	1.00
Maximum:	2	2.0	11.0	14.2	25.4	1,029,768.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2022 00:00	2	1.9	9.7	13.7	23.9	1,024,025.1	0.00	1.00
10/08/2022 01:00	2	1.8	9.3	13.9	22.7	1,021,003.7	0.00	1.00
10/08/2022 02:00	1	1.8	9.9	13.9	23.1	1,019,438.6	0.00	1.00
10/08/2022 03:00	2	1.8	9.7	13.9	24.1	1,023,155.6	0.00	1.00
10/08/2022 04:00	2	1.8	9.6	13.9	24.3	1,029,024.6	0.00	1.00
10/08/2022 05:00	2	1.8	9.4	13.9	24.2	1,021,786.2	0.00	1.00
10/08/2022 06:00	2	1.7	8.1	14.3	20.6	926,643.8	0.00	1.00
10/08/2022 07:00	2	1.5	9.0	14.5	17.4	711,244.8	0.00	1.00
10/08/2022 08:00	1	1.6	9.3	14.6	15.2	694,493.8	0.00	1.00
10/08/2022 09:00	1	1.5	8.6	14.6	12.9	707,535.9	0.00	1.00
10/08/2022 10:00	2	1.6	10.0	14.8	18.2	658,895.2	0.00	1.00
10/08/2022 11:00	1	1.5	8.0	14.6	11.1	740,793.4	0.00	1.00
10/08/2022 12:00	1	1.6	7.1	14.5	11.8	821,868.6	0.00	1.00
10/08/2022 13:00	1	1.7	7.2	14.4	14.3	966,813.6	0.00	1.00
10/08/2022 14:00	1	1.7	7.1	14.3	13.3	917,721.8	0.00	1.00
10/08/2022 15:00	1	1.9	9.8	13.5	22.0	1,005,231.5	0.00	1.00
10/08/2022 16:00	2	2.0	10.6	13.2	24.3	1,005,726.6	0.00	1.00
10/08/2022 17:00	2	2.0	10.8	13.2	24.5	1,008,750.0	0.00	1.00
10/08/2022 18:00	2	1.9	10.3	13.3	23.4	1,004,905.2	0.00	1.00
10/08/2022 19:00	2	1.9	10.2	13.3	23.4	1,005,445.8	0.00	1.00
10/08/2022 20:00	2	1.9	10.1	13.4	23.5	1,012,826.3	0.00	1.00
10/08/2022 21:00	1	1.8	9.3	13.7	21.0	993,593.5	0.00	1.00
10/08/2022 22:00	1	1.6	8.8	14.3	16.9	806,922.9	0.00	1.00
10/08/2022 23:00	1	1.7	7.5	14.4	16.3	998,205.0	0.00	1.00
Average/Sum#:	2	1.8	9.1	14.0	19.7	921,918.8	0.00 #	24.00 #
Minimum:	1	1.5	7.1	13.2	11.1	658,895.2	0.00	1.00
Maximum:	2	2.0	10.8	14.8	24.5	1,029,024.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2022 00:00	1	1.7	7.9	14.3	19.2	1,004,659.5	0.00	1.00
10/09/2022 01:00	1	1.7	7.9	14.3	19.7	1,006,319.4	0.00	1.00
10/09/2022 02:00	1	1.7	8.4	14.3	20.1	1,007,979.3	0.00	1.00
10/09/2022 03:00	1	1.7	8.2	14.3	20.9	1,009,639.3	0.00	1.00
10/09/2022 04:00	1	1.7	8.2	14.3	21.3	1,012,751.6	0.00	1.00
10/09/2022 05:00	2	1.7	8.1	14.3	21.4	1,012,959.1	0.00	1.00
10/09/2022 06:00	2	1.7	8.2	14.3	21.5	1,015,034.0	0.00	1.00
10/09/2022 07:00	1	1.7	8.1	14.3	20.7	1,015,448.9	0.00	1.00
10/09/2022 08:00	1	1.7	8.0	14.3	19.7	1,011,506.6	0.00	1.00
10/09/2022 09:00	1	1.7	7.8	14.3	18.9	1,007,356.9	0.00	1.00
10/09/2022 10:00	1	1.7	7.7	14.3	18.5	1,003,414.6	0.00	1.00
10/09/2022 11:00	1	1.7	7.6	14.3	17.8	997,812.4	0.00	1.00
10/09/2022 12:00	1	1.7	7.6	14.3	17.4	998,849.8	0.00	1.00
10/09/2022 13:00	1	1.7	7.7	14.2	17.3	988,642.6	0.00	1.00
10/09/2022 14:00	1	1.7	7.7	14.2	17.0	988,233.9	0.00	1.00
10/09/2022 15:00	1	1.7	7.8	14.2	17.1	991,504.1	0.00	1.00
10/09/2022 16:00	1	1.7	7.8	14.2	16.9	991,504.1	0.00	1.00
10/09/2022 17:00	1	1.7	7.8	14.2	17.2	990,686.6	0.00	1.00
10/09/2022 18:00	1	1.7	7.8	14.3	17.5	1,000,302.3	0.00	1.00
10/09/2022 19:00	1	1.7	7.7	14.3	17.7	994,492.6	0.00	1.00
10/09/2022 20:00	1	1.7	7.7	14.3	17.9	993,662.6	0.00	1.00
10/09/2022 21:00	1	1.7	7.7	14.3	18.1	996,152.5	0.00	1.00
10/09/2022 22:00	1	1.7	7.8	14.3	18.6	999,057.3	0.00	1.00
10/09/2022 23:00	1	1.7	7.9	14.3	19.1	1,001,547.2	0.00	1.00
Average/Sum#:	1	1.7	7.9	14.3	18.8	1,001,646.6	0.00 #	24.00 #
Minimum:	1	1.7	7.6	14.2	16.9	988,233.9	0.00	1.00
Maximum:	2	1.7	8.4	14.3	21.5	1,015,448.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2022 00:00	1	1.7	7.9	14.3	19.6	1,005,489.5	0.00	1.00
10/10/2022 01:00	1	1.7	8.0	14.3	19.9	1,007,149.4	0.00	1.00
10/10/2022 02:00	1	1.7	8.4	14.3	20.1	1,007,356.9	0.00	1.00
10/10/2022 03:00	1	1.7	8.2	14.3	21.1	1,009,431.8	0.00	1.00
10/10/2022 04:00	1	1.7	8.2	14.3	21.2	1,012,959.1	0.00	1.00
10/10/2022 05:00	2	1.8	8.8	14.0	24.2	1,015,557.2	0.00	1.00
10/10/2022 06:00	2	1.8	9.2	13.9	23.5	1,016,895.4	0.00	1.00
10/10/2022 07:00	1	1.7	8.1	14.3	20.7	1,014,619.0	0.00	1.00
10/10/2022 08:00	1	1.7	8.0	14.3	19.9	1,008,601.8	0.00	1.00
10/10/2022 09:00	1	1.7	8.0	14.2	19.3	997,022.7	0.00	1.00
10/10/2022 10:00	1	1.6	7.3	14.5	17.0	1,002,247.5	0.00	1.00
10/10/2022 11:00	1	1.5	9.4	14.7	15.8	661,520.3	0.00	1.00
10/10/2022 12:00	1	1.5	9.4	14.8	14.1	650,364.3	0.00	1.00
10/10/2022 13:00	3	0.7	9.1	14.7	19.1	640,537.2	0.00	1.00
10/10/2022 14:00	0	1.6	9.0	14.7	9.9	640,316.3	0.00	1.00
10/10/2022 15:00	1	1.6	7.7	14.4	12.7	832,610.0	0.00	1.00
10/10/2022 16:00	2	2.0	10.8	13.0	25.8	983,558.7	0.00	1.00
10/10/2022 17:00	1	1.9	10.5	13.2	21.5	976,026.1	0.00	1.00
10/10/2022 18:00	1	1.8	8.0	14.0	16.6	958,001.7	0.00	1.00
10/10/2022 19:00	1	1.7	7.9	14.1	17.2	968,867.8	0.00	1.00
10/10/2022 20:00	1	1.7	7.8	14.1	17.5	965,041.4	0.00	1.00
10/10/2022 21:00	1	1.7	7.9	14.1	17.8	966,048.3	0.00	1.00
10/10/2022 22:00	1	1.7	8.0	14.1	18.3	969,874.7	0.00	1.00
10/10/2022 23:00	1	1.7	7.7	14.2	17.6	962,071.7	0.00	1.00
Average/Sum#:	1	1.7	8.5	14.2	18.8	928,007.0	0.00 #	24.00 #
Minimum:	0	0.7	7.3	13.0	9.9	640,316.3	0.00	1.00
Maximum:	3	2.0	10.8	14.8	25.8	1,016,895.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2022 00:00	2	1.6	10.4	14.4	19.4	632,252.7	0.00	1.00
10/11/2022 01:00	2	1.6	11.1	14.5	19.6	620,948.4	0.00	1.00
10/11/2022 02:00	2	1.7	11.5	14.5	19.6	622,018.2	0.00	1.00
10/11/2022 03:00	2	1.6	11.1	14.5	20.0	624,158.0	0.00	1.00
10/11/2022 04:00	2	1.6	11.2	14.5	20.4	624,371.9	0.00	1.00
10/11/2022 05:00	3	1.6	11.4	14.5	21.4	623,730.0	0.00	1.00
10/11/2022 06:00	3	1.6	11.7	14.5	22.2	623,944.0	0.00	1.00
10/11/2022 07:00	3	1.6	11.5	14.5	21.5	624,158.0	0.00	1.00
10/11/2022 08:00	2	1.6	11.1	14.5	19.9	622,232.2	0.00	1.00
10/11/2022 09:00	2	1.6	10.5	14.6	17.7	633,630.5	0.00	1.00
10/11/2022 10:00	2	1.6	10.0	14.6	16.9	636,456.3	0.00	1.00
10/11/2022 11:00	1	1.6	9.8	14.6	15.8	634,717.3	0.00	1.00
10/11/2022 12:00	1	1.6	9.6	14.6	15.2	631,456.8	0.00	1.00
10/11/2022 13:00	1	1.6	9.6	14.7	15.0	636,561.5	0.00	1.00
10/11/2022 14:00	1	1.6	9.4	14.7	14.4	635,015.3	0.00	1.00
10/11/2022 15:00	1	1.6	8.0	14.3	12.4	820,202.2	0.00	1.00
10/11/2022 16:00	1	1.8	8.3	14.0	16.9	959,986.3	0.00	1.00
10/11/2022 17:00	1	1.7	8.0	14.1	17.9	969,673.3	0.00	1.00
10/11/2022 18:00	1	1.7	7.9	14.1	18.3	963,631.7	0.00	1.00
10/11/2022 19:00	1	1.7	7.9	14.1	18.8	967,055.3	0.00	1.00
10/11/2022 20:00	1	1.7	8.2	14.1	19.6	973,096.9	0.00	1.00
10/11/2022 21:00	1	1.7	8.2	14.1	20.0	975,110.7	0.00	1.00
10/11/2022 22:00	1	1.7	8.4	14.1	20.0	977,728.7	0.00	1.00
10/11/2022 23:00	1	1.7	8.5	14.1	20.6	979,944.0	0.00	1.00
Average/Sum#:	2	1.6	9.7	14.4	18.5	750,503.3	0.00 #	24.00 #
Minimum:	1	1.6	7.9	14.0	12.4	620,948.4	0.00	1.00
Maximum:	3	1.8	11.7	14.7	22.2	979,944.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	2	1.7	8.5	14.1	21.1	980,145.4	0.00	1.00
10/12/2022 01:00	1	1.7	8.0	14.1	20.1	981,555.1	0.00	1.00
10/12/2022 02:00	1	1.8	8.4	14.1	20.3	982,360.6	0.00	1.00
10/12/2022 03:00	2	1.8	8.3	14.1	21.2	985,381.4	0.00	1.00
10/12/2022 04:00	2	1.7	8.2	14.1	21.3	986,589.7	0.00	1.00
10/12/2022 05:00	2	1.7	8.2	14.0	21.6	974,077.5	0.00	1.00
10/12/2022 06:00	2	1.7	8.1	14.1	21.9	987,999.4	0.00	1.00
10/12/2022 07:00	2	1.7	8.0	14.2	19.6	875,818.4	0.00	1.00
10/12/2022 08:00	2	1.6	11.4	14.5	20.3	622,660.1	0.00	1.00
10/12/2022 09:00	2	1.6	10.9	14.5	19.1	623,302.1	0.00	1.00
10/12/2022 10:00	2	1.6	10.6	14.6	18.3	631,239.4	0.00	1.00
10/12/2022 11:00	2	1.6	10.3	14.6	17.1	630,152.6	0.00	1.00
10/12/2022 12:00	2	1.6	10.2	14.6	16.6	627,761.5	0.00	1.00
10/12/2022 13:00	2	1.6	9.9	14.6	16.0	629,065.7	0.00	1.00
10/12/2022 14:00	1	1.6	9.8	14.6	14.9	627,761.5	0.00	1.00
10/12/2022 15:00	1	1.6	9.5	14.6	13.9	629,717.8	0.00	1.00
10/12/2022 16:00	1	1.6	9.4	14.6	14.1	631,456.8	0.00	1.00
10/12/2022 17:00	1	1.6	9.7	14.6	15.2	631,456.8	0.00	1.00
10/12/2022 18:00	2	1.6	10.0	14.6	16.7	629,065.7	0.00	1.00
10/12/2022 19:00	2	1.6	10.5	14.6	18.2	627,544.2	0.00	1.00
10/12/2022 20:00	2	1.6	10.8	14.5	19.2	617,096.9	0.00	1.00
10/12/2022 21:00	2	1.6	11.1	14.5	20.1	617,738.8	0.00	1.00
10/12/2022 22:00	2	1.6	11.0	14.5	20.1	621,590.3	0.00	1.00
10/12/2022 23:00	3	1.6	11.5	14.5	21.5	619,664.5	0.00	1.00
Average/Sum#:	2	1.6	9.7	14.4	18.7	740,466.8	0.00 #	24.00 #
Minimum:	1	1.6	8.0	14.0	13.9	617,096.9	0.00	1.00
Maximum:	3	1.8	11.5	14.6	21.9	987,999.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2022 00:00	3	1.6	11.9	14.5	22.9	619,022.6	0.00	1.00
10/13/2022 01:00	3	1.6	12.4	14.5	24.2	618,808.6	0.00	1.00
10/13/2022 02:00	3	1.5	13.0	14.5	24.8	617,524.8	0.00	1.00
10/13/2022 03:00	3	1.7	13.0	14.5	24.7	617,310.8	0.00	1.00
10/13/2022 04:00	3	1.6	13.0	14.5	25.6	617,524.8	0.00	1.00
10/13/2022 05:00	3	1.6	12.8	14.5	24.5	619,664.5	0.00	1.00
10/13/2022 06:00	1	1.6	9.2	14.3	15.9	772,064.9	0.00	1.00
10/13/2022 07:00	4	1.6	12.9	14.5	26.7	618,808.6	0.00	1.00
10/13/2022 08:00	3	1.6	12.4	14.5	23.3	618,808.6	0.00	1.00
10/13/2022 09:00	2	1.6	11.6	14.5	20.3	621,162.3	0.00	1.00
10/13/2022 10:00	2	1.6	10.9	14.5	18.7	623,302.1	0.00	1.00
10/13/2022 11:00	2	1.6	10.9	14.6	18.2	627,544.2	0.00	1.00
10/13/2022 12:00	2	1.6	10.5	14.6	16.8	626,239.9	0.00	1.00
10/13/2022 13:00	1	1.6	10.2	14.6	15.9	625,370.5	0.00	1.00
10/13/2022 14:00	1	1.6	9.9	14.6	14.8	625,587.8	0.00	1.00
10/13/2022 15:00	1	1.6	8.0	14.3	11.5	818,749.8	0.00	1.00
10/13/2022 16:00	1	1.8	8.3	13.8	17.3	964,190.5	0.00	1.00
10/13/2022 17:00	1	1.7	7.7	14.1	16.4	966,451.1	0.00	1.00
10/13/2022 18:00	1	1.7	7.8	14.1	17.5	967,659.4	0.00	1.00
10/13/2022 19:00	1	1.7	7.8	14.1	18.1	971,888.5	0.00	1.00
10/13/2022 20:00	1	1.7	7.8	14.1	18.3	971,485.8	0.00	1.00
10/13/2022 21:00	1	1.7	7.8	14.1	18.6	971,888.5	0.00	1.00
10/13/2022 22:00	1	1.7	7.8	14.1	18.8	973,096.9	0.00	1.00
10/13/2022 23:00	1	1.7	7.9	14.1	19.3	974,103.8	0.00	1.00
Average/Sum#:	2	1.6	10.2	14.4	19.7	752,010.8	0.00 #	24.00 #
Minimum:	1	1.5	7.7	13.8	11.5	617,310.8	0.00	1.00
Maximum:	4	1.8	13.0	14.6	26.7	974,103.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	2	1.7	8.0	14.1	19.7	977,124.6	0.00	1.00
10/14/2022 01:00	2	1.7	8.1	14.0	20.3	965,146.5	0.00	1.00
10/14/2022 02:00	2	1.7	8.5	14.0	20.6	966,138.8	0.00	1.00
10/14/2022 03:00	2	1.8	8.4	14.0	21.4	968,322.0	0.00	1.00
10/14/2022 04:00	2	1.7	8.2	14.0	21.7	969,314.3	0.00	1.00
10/14/2022 05:00	2	1.8	8.4	14.0	22.5	972,688.2	0.00	1.00
10/14/2022 06:00	2	1.7	8.5	14.0	22.8	974,871.4	0.00	1.00
10/14/2022 07:00	2	1.7	8.2	14.1	20.3	916,306.0	0.00	1.00
10/14/2022 08:00	3	1.6	11.8	14.5	22.3	620,306.5	0.00	1.00
10/14/2022 09:00	2	1.6	11.0	14.5	18.8	622,232.2	0.00	1.00
10/14/2022 10:00	2	1.6	10.2	14.5	16.3	624,371.9	0.00	1.00
10/14/2022 11:00	1	1.6	9.7	14.5	15.0	624,371.9	0.00	1.00
10/14/2022 12:00	1	1.6	9.8	14.6	15.5	629,500.5	0.00	1.00
10/14/2022 13:00	1	1.6	9.5	14.6	13.8	629,065.7	0.00	1.00
10/14/2022 14:00	1	1.6	9.4	14.6	13.2	629,065.7	0.00	1.00
10/14/2022 15:00	1	1.6	9.4	14.6	13.4	629,717.8	0.00	1.00
10/14/2022 16:00	1	1.6	7.9	14.3	11.6	822,899.6	0.00	1.00
10/14/2022 17:00	1	1.8	8.0	14.0	16.0	960,184.8	0.00	1.00
10/14/2022 18:00	1	1.8	7.8	14.1	17.0	968,867.8	0.00	1.00
10/14/2022 19:00	1	1.8	7.9	14.0	17.6	960,581.7	0.00	1.00
10/14/2022 20:00	1	1.8	8.0	14.0	17.8	964,154.2	0.00	1.00
10/14/2022 21:00	1	1.8	7.8	14.0	17.9	959,192.5	0.00	1.00
10/14/2022 22:00	1	1.7	7.8	14.0	18.3	956,017.0	0.00	1.00
10/14/2022 23:00	1	1.7	7.8	14.1	18.8	970,277.5	0.00	1.00
Average/Sum#:	2	1.7	8.8	14.2	18.0	845,030.0	0.00 #	24.00 #
Minimum:	1	1.6	7.8	14.0	11.6	620,306.5	0.00	1.00
Maximum:	3	1.8	11.8	14.6	22.8	977,124.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2022 00:00	1	1.7	8.0	14.1	19.6	973,902.4	0.00	1.00
10/15/2022 01:00	1	1.7	7.8	14.1	19.3	961,617.9	0.00	1.00
10/15/2022 02:00	1	1.7	7.4	14.3	17.2	955,484.7	0.00	1.00
10/15/2022 03:00	1	1.7	7.4	14.2	18.2	919,762.6	0.00	1.00
10/15/2022 04:00	2	1.8	8.2	14.0	21.4	966,337.3	0.00	1.00
10/15/2022 05:00	2	1.7	8.2	14.0	21.6	967,925.0	0.00	1.00
10/15/2022 06:00	2	1.7	7.8	14.1	20.2	959,201.2	0.00	1.00
10/15/2022 07:00	3	1.6	10.5	14.4	21.9	696,088.9	0.00	1.00
10/15/2022 08:00	2	1.6	11.8	14.5	21.4	619,878.5	0.00	1.00
10/15/2022 09:00	2	1.6	11.3	14.5	19.7	620,092.5	0.00	1.00
10/15/2022 10:00	2	1.6	10.8	14.5	17.7	621,162.3	0.00	1.00
10/15/2022 11:00	2	1.6	10.5	14.5	17.3	620,092.5	0.00	1.00
10/15/2022 12:00	2	1.6	10.5	14.6	17.2	624,935.7	0.00	1.00
10/15/2022 13:00	2	1.6	10.2	14.6	16.3	624,935.7	0.00	1.00
10/15/2022 14:00	1	1.6	10.1	14.6	15.2	624,935.7	0.00	1.00
10/15/2022 15:00	1	1.6	10.1	14.6	15.5	624,718.4	0.00	1.00
10/15/2022 16:00	1	1.6	10.1	14.6	15.1	624,718.4	0.00	1.00
10/15/2022 17:00	2	1.6	10.6	14.5	17.3	614,957.1	0.00	1.00
10/15/2022 18:00	2	1.6	10.9	14.5	19.1	620,092.5	0.00	1.00
10/15/2022 19:00	2	1.6	11.7	14.5	21.3	616,241.0	0.00	1.00
10/15/2022 20:00	3	1.6	12.1	14.5	22.4	615,171.1	0.00	1.00
10/15/2022 21:00	2	1.6	11.9	14.5	21.5	619,022.6	0.00	1.00
10/15/2022 22:00	3	1.6	11.7	14.5	21.4	620,734.4	0.00	1.00
10/15/2022 23:00	3	1.6	11.8	14.5	22.1	621,162.3	0.00	1.00
Average/Sum#:	2	1.6	10.1	14.4	19.2	722,215.4	0.00 #	24.00 #
Minimum:	1	1.6	7.4	14.0	15.1	614,957.1	0.00	1.00
Maximum:	3	1.8	12.1	14.6	22.4	973,902.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2022 00:00	2	1.6	11.7	14.5	21.1	621,590.3	0.00	1.00
10/16/2022 01:00	2	1.6	11.7	14.5	21.4	623,302.1	0.00	1.00
10/16/2022 02:00	2	1.6	12.3	14.5	22.3	621,804.3	0.00	1.00
10/16/2022 03:00	2	1.6	12.2	14.5	22.9	622,018.2	0.00	1.00
10/16/2022 04:00	2	1.6	11.9	14.5	21.6	623,730.0	0.00	1.00
10/16/2022 05:00	3	1.6	12.0	14.5	22.5	624,585.9	0.00	1.00
10/16/2022 06:00	3	1.6	11.8	14.5	21.3	633,358.8	0.00	1.00
10/16/2022 07:00	3	1.6	12.4	14.5	23.0	619,450.6	0.00	1.00
10/16/2022 08:00	2	1.6	11.9	14.5	20.9	622,446.2	0.00	1.00
10/16/2022 09:00	1	1.5	9.8	14.4	15.6	699,459.8	0.00	1.00
10/16/2022 10:00	1	1.7	7.3	14.3	14.4	979,968.4	0.00	1.00
10/16/2022 11:00	1	1.7	8.0	14.1	18.4	981,756.5	0.00	1.00
10/16/2022 12:00	1	1.7	7.9	14.1	18.5	979,742.6	0.00	1.00
10/16/2022 13:00	1	1.7	7.9	14.1	18.4	978,131.5	0.00	1.00
10/16/2022 14:00	1	1.7	7.8	14.1	18.2	976,520.4	0.00	1.00
10/16/2022 15:00	1	1.7	7.8	14.1	18.2	976,923.2	0.00	1.00
10/16/2022 16:00	1	1.7	7.9	14.1	18.4	978,937.0	0.00	1.00
10/16/2022 17:00	1	1.7	8.0	14.1	19.0	981,756.5	0.00	1.00
10/16/2022 18:00	1	1.7	8.0	14.1	19.8	985,381.4	0.00	1.00
10/16/2022 19:00	1	1.7	8.1	14.1	20.2	987,395.3	0.00	1.00
10/16/2022 20:00	2	1.7	8.1	14.1	20.5	988,200.8	0.00	1.00
10/16/2022 21:00	2	1.7	8.1	14.1	21.0	988,805.0	0.00	1.00
10/16/2022 22:00	2	1.7	8.1	14.1	21.3	989,811.9	0.00	1.00
10/16/2022 23:00	2	1.7	8.2	14.1	21.6	990,013.3	0.00	1.00
Average/Sum#:	2	1.7	9.5	14.3	20.0	836,462.1	0.00 #	24.00 #
Minimum:	1	1.5	7.3	14.1	14.4	619,450.6	0.00	1.00
Maximum:	3	1.7	12.4	14.5	23.0	990,013.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2022 00:00	2	1.7	8.1	14.1	21.6	990,617.4	0.00	1.00
10/17/2022 01:00	2	1.7	7.7	14.2	20.2	975,970.4	0.00	1.00
10/17/2022 02:00	1	1.7	7.8	14.3	18.8	950,090.0	0.00	1.00
10/17/2022 03:00	2	1.7	7.7	14.3	20.4	944,902.8	0.00	1.00
10/17/2022 04:00	2	1.7	8.3	14.2	22.8	956,144.4	0.00	1.00
10/17/2022 05:00	2	1.8	9.7	14.0	26.2	988,962.6	0.00	1.00
10/17/2022 06:00	2	1.7	8.8	14.1	25.1	1,003,103.4	0.00	1.00
10/17/2022 07:00	2	1.5	8.2	14.1	23.3	980,749.5	0.00	1.00
10/17/2022 08:00	1	1.7	8.0	14.1	19.0	903,820.1	0.00	1.00
10/17/2022 09:00	2	1.7	8.2	14.1	20.9	979,138.4	0.00	1.00
10/17/2022 10:00	2	1.7	8.0	14.1	20.1	969,471.9	0.00	1.00
10/17/2022 11:00	1	1.7	8.1	14.1	19.7	974,909.3	0.00	1.00
10/17/2022 12:00	1	1.8	8.2	14.0	19.7	966,138.8	0.00	1.00
10/17/2022 13:00	1	1.7	8.2	14.1	19.3	972,895.5	0.00	1.00
10/17/2022 14:00	2	1.8	8.3	14.0	20.2	964,352.6	0.00	1.00
10/17/2022 15:00	1	1.8	8.2	14.0	19.2	968,718.9	0.00	1.00
10/17/2022 16:00	1	1.8	8.2	14.0	19.2	966,535.8	0.00	1.00
10/17/2022 17:00	1	1.8	8.2	14.0	19.2	962,367.9	0.00	1.00
10/17/2022 18:00	1	1.7	8.1	14.1	19.4	971,284.4	0.00	1.00
10/17/2022 19:00	2	1.7	8.1	14.1	20.3	967,256.7	0.00	1.00
10/17/2022 20:00	2	1.7	8.3	14.1	21.2	972,492.7	0.00	1.00
10/17/2022 21:00	2	1.7	8.3	14.1	21.2	972,291.3	0.00	1.00
10/17/2022 22:00	2	1.8	8.6	14.0	23.2	989,756.4	0.00	1.00
10/17/2022 23:00	2	1.8	9.2	13.8	23.3	987,721.4	0.00	1.00
Average/Sum#:	2	1.7	8.3	14.1	21.0	969,987.2	0.00 #	24.00 #
Minimum:	1	1.5	7.7	13.8	18.8	903,820.1	0.00	1.00
Maximum:	2	1.8	9.7	14.3	26.2	1,003,103.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2022 00:00	2	1.7	8.4	14.1	22.6	984,777.2	0.00	1.00
10/18/2022 01:00	2	1.7	8.4	14.1	22.5	984,978.6	0.00	1.00
10/18/2022 02:00	2	1.7	8.9	14.1	22.9	987,798.0	0.00	1.00
10/18/2022 03:00	2	1.8	8.9	14.0	23.9	986,581.0	0.00	1.00
10/18/2022 04:00	2	1.8	9.4	13.8	25.2	997,172.4	0.00	1.00
10/18/2022 05:00	2	1.9	9.9	13.6	26.9	1,005,307.6	0.00	1.00
10/18/2022 06:00	2	2.0	11.3	13.2	28.7	1,014,085.4	0.00	1.00
10/18/2022 07:00	2	1.8	9.0	13.9	23.6	981,681.7	0.00	1.00
10/18/2022 08:00	2	1.7	8.4	14.1	21.7	986,791.1	0.00	1.00
10/18/2022 09:00	2	1.7	8.6	14.1	21.1	982,360.6	0.00	1.00
10/18/2022 10:00	1	1.8	8.9	13.9	20.8	967,791.8	0.00	1.00
10/18/2022 11:00	1	1.8	9.1	13.9	20.4	972,095.7	0.00	1.00
10/18/2022 12:00	1	1.8	8.6	13.9	18.8	963,683.5	0.00	1.00
10/18/2022 13:00	1	1.7	7.9	14.1	17.0	954,368.0	0.00	1.00
10/18/2022 14:00	1	1.6	8.9	14.4	14.0	720,317.2	0.00	1.00
10/18/2022 15:00	2	1.6	9.4	14.4	16.4	696,299.6	0.00	1.00
10/18/2022 16:00	1	1.7	8.4	13.9	16.9	917,905.6	0.00	1.00
10/18/2022 17:00	2	2.1	11.8	12.7	27.1	999,011.8	0.00	1.00
10/18/2022 18:00	2	2.0	11.0	12.9	25.7	996,598.6	0.00	1.00
10/18/2022 19:00	3	2.2	12.9	12.2	32.5	1,003,457.5	0.00	1.00
10/18/2022 20:00	2	2.0	11.3	12.9	27.5	1,008,752.2	0.00	1.00
10/18/2022 21:00	2	2.0	10.6	13.1	26.3	1,002,664.4	0.00	1.00
10/18/2022 22:00	2	1.9	9.5	13.5	23.7	988,206.2	0.00	1.00
10/18/2022 23:00	1	1.7	6.9	14.3	17.1	944,695.3	0.00	1.00
Average/Sum#:	2	1.8	9.4	13.7	22.6	960,307.5	0.00 #	24.00 #
Minimum:	1	1.6	6.9	12.2	14.0	696,299.6	0.00	1.00
Maximum:	3	2.2	12.9	14.4	32.5	1,014,085.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	1	1.7	7.0	14.3	17.8	944,280.4	0.00	1.00
10/19/2022 01:00	2	1.7	7.1	14.2	18.0	896,257.6	0.00	1.00
10/19/2022 02:00	2	1.8	7.4	14.2	16.2	854,561.7	0.00	1.00
10/19/2022 03:00	2	1.7	7.2	14.3	18.4	904,857.5	0.00	1.00
10/19/2022 04:00	2	1.7	7.2	14.3	18.9	939,093.1	0.00	1.00
10/19/2022 05:00	2	1.7	7.1	14.3	18.7	942,827.9	0.00	1.00
10/19/2022 06:00	3	1.7	9.2	14.3	23.6	809,205.3	0.00	1.00
10/19/2022 07:00	5	1.6	16.5	14.6	35.2	607,111.5	0.00	1.00
10/19/2022 08:00	4	2.6	18.1	14.8	23.9	588,403.5	0.13	0.62
10/19/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2022 16:00	4	6.0	16.4	15.5	13.0	640,586.3	0.72	0.85
10/19/2022 17:00	1	1.5	8.7	14.4	13.2	778,254.4	0.00	1.00
10/19/2022 18:00	1	1.7	8.1	14.1	18.4	969,874.7	0.00	1.00
10/19/2022 19:00	1	1.8	8.6	14.0	19.9	988,565.6	0.00	1.00
10/19/2022 20:00	2	1.8	9.1	13.8	21.6	992,157.6	0.00	1.00
10/19/2022 21:00	1	1.8	8.6	13.9	19.9	958,597.1	0.00	1.00
10/19/2022 22:00	2	1.6	9.6	14.4	18.7	724,320.2	0.00	1.00
10/19/2022 23:00	1	1.7	6.8	14.3	11.9	842,403.5	0.00	1.00
Average/Sum#:	2	2.0	9.6	14.3	19.3	845,962.2	0.85 #	16.47 #
Minimum:	1	1.5	6.8	13.8	11.9	588,403.5	0.00	0.00
Maximum:	5	6.0	18.1	15.5	35.2	992,157.6	0.72	1.00
%SI	29.17	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2022 00:00	1	1.7	7.2	14.2	15.6	834,940.1	0.00	1.00
10/20/2022 01:00	2	1.6	9.3	14.3	18.6	707,743.4	0.00	1.00
10/20/2022 02:00	2	1.6	11.6	14.5	20.3	636,996.3	0.00	1.00
10/20/2022 03:00	1	1.7	8.4	14.2	15.6	755,022.9	0.00	1.00
10/20/2022 04:00	1	1.7	7.4	14.3	17.2	902,990.1	0.00	1.00
10/20/2022 05:00	2	1.7	7.5	14.3	19.4	956,937.2	0.00	1.00
10/20/2022 06:00	2	1.7	8.7	14.3	21.9	851,948.0	0.00	1.00
10/20/2022 07:00	3	1.6	12.4	14.5	24.7	625,869.7	0.00	1.00
10/20/2022 08:00	3	1.6	13.1	14.6	25.9	617,545.2	0.00	1.00
10/20/2022 09:00	2	1.6	11.9	14.6	20.4	620,371.0	0.00	1.00
10/20/2022 10:00	2	1.6	10.9	14.6	19.8	624,935.7	0.00	1.00
10/20/2022 11:00	2	1.6	11.6	14.7	20.0	624,413.3	0.00	1.00
10/20/2022 12:00	2	1.6	11.0	14.7	19.7	626,401.2	0.00	1.00
10/20/2022 13:00	1	1.5	9.6	14.6	13.8	635,152.1	0.00	1.00
10/20/2022 14:00	1	1.5	9.2	14.5	14.5	643,415.5	0.00	1.00
10/20/2022 15:00	1	1.7	8.0	14.3	12.9	841,158.6	0.00	1.00
10/20/2022 16:00	2	2.1	11.8	12.7	26.6	992,999.7	0.00	1.00
10/20/2022 17:00	2	2.0	10.5	13.2	22.8	989,720.4	0.00	1.00
10/20/2022 18:00	2	1.9	9.3	13.6	21.7	983,359.3	0.00	1.00
10/20/2022 19:00	1	1.8	8.6	14.0	20.3	983,008.5	0.00	1.00
10/20/2022 20:00	1	1.7	8.4	14.0	19.5	958,001.7	0.00	1.00
10/20/2022 21:00	2	1.6	9.4	14.3	17.4	662,925.9	0.00	1.00
10/20/2022 22:00	2	1.6	10.0	14.4	18.0	648,685.8	0.00	1.00
10/20/2022 23:00	1	1.6	7.0	14.3	12.5	901,330.2	0.00	1.00
Average/Sum#:	2	1.7	9.7	14.2	19.1	776,078.0	0.00 #	24.00 #
Minimum:	1	1.5	7.0	12.7	12.5	617,545.2	0.00	1.00
Maximum:	3	2.1	13.1	14.7	26.6	992,999.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2022 00:00	2	1.7	8.7	14.3	17.2	745,091.4	0.00	1.00
10/21/2022 01:00	2	1.6	8.9	14.3	16.9	709,818.3	0.00	1.00
10/21/2022 02:00	2	1.6	11.7	14.5	20.7	636,782.3	0.00	1.00
10/21/2022 03:00	2	1.7	10.4	14.3	18.9	650,476.6	0.00	1.00
10/21/2022 04:00	2	1.5	9.2	14.2	17.2	700,859.1	0.00	1.00
10/21/2022 05:00	1	1.7	7.3	14.3	16.2	912,119.6	0.00	1.00
10/21/2022 06:00	2	1.8	8.1	14.1	21.7	954,368.0	0.00	1.00
10/21/2022 07:00	2	1.7	8.1	14.1	21.0	952,555.5	0.00	1.00
10/21/2022 08:00	3	1.6	12.2	14.5	24.9	620,092.5	0.00	1.00
10/21/2022 09:00	3	1.6	13.5	14.6	25.6	606,894.1	0.00	1.00
10/21/2022 10:00	3	1.6	12.9	14.7	23.6	616,020.1	0.00	1.00
10/21/2022 11:00	1	1.6	10.3	14.6	16.0	631,674.2	0.00	1.00
10/21/2022 12:00	3	1.6	12.0	14.7	22.5	615,799.2	0.00	1.00
10/21/2022 13:00	2	1.6	11.1	14.7	17.7	626,622.1	0.00	1.00
10/21/2022 14:00	2	1.6	10.6	14.7	17.4	631,481.3	0.00	1.00
10/21/2022 15:00	0	1.6	7.1	14.2	10.6	862,328.6	0.00	1.00
10/21/2022 16:00	1	1.9	9.4	13.5	19.9	973,031.5	0.00	1.00
10/21/2022 17:00	1	1.9	9.0	13.7	20.6	986,556.1	0.00	1.00
10/21/2022 18:00	1	1.7	8.1	14.0	18.5	952,444.6	0.00	1.00
10/21/2022 19:00	1	1.7	6.8	14.2	11.5	773,418.2	0.00	1.00
10/21/2022 20:00	1	1.7	7.9	14.2	14.8	743,577.0	0.00	1.00
10/21/2022 21:00	1	1.7	6.9	14.3	16.3	934,113.4	0.00	1.00
10/21/2022 22:00	1	1.7	7.3	14.4	18.6	980,297.2	0.00	1.00
10/21/2022 23:00	1	1.7	7.3	14.3	18.3	965,444.2	0.00	1.00
Average/Sum#:	2	1.7	9.4	14.3	18.6	782,577.7	0.00 #	24.00 #
Minimum:	0	1.5	6.8	13.5	10.6	606,894.1	0.00	1.00
Maximum:	3	1.9	13.5	14.7	25.6	986,556.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2022 00:00	1	1.7	7.3	14.3	18.5	963,576.8	0.00	1.00
10/22/2022 01:00	1	1.7	7.4	14.3	18.4	966,274.1	0.00	1.00
10/22/2022 02:00	1	1.7	7.8	14.3	18.0	965,859.2	0.00	1.00
10/22/2022 03:00	2	1.7	7.6	14.3	18.2	966,689.1	0.00	1.00
10/22/2022 04:00	1	1.7	7.4	14.3	18.3	964,199.3	0.00	1.00
10/22/2022 05:00	2	1.7	7.8	14.2	19.9	959,005.9	0.00	1.00
10/22/2022 06:00	3	2.3	13.1	12.0	36.2	996,756.3	0.00	1.00
10/22/2022 07:00	4	2.3	13.3	11.8	38.9	1,002,238.1	0.00	1.00
10/22/2022 08:00	2	2.1	11.9	12.6	29.7	996,050.0	0.00	1.00
10/22/2022 09:00	2	2.1	11.8	12.7	29.6	996,506.7	0.00	1.00
10/22/2022 10:00	2	2.0	11.0	13.0	27.0	994,826.1	0.00	1.00
10/22/2022 11:00	2	1.8	9.1	13.7	22.8	984,464.0	0.00	1.00
10/22/2022 12:00	1	1.7	8.2	14.1	19.5	959,402.6	0.00	1.00
10/22/2022 13:00	1	1.7	7.3	14.3	16.9	924,983.9	0.00	1.00
10/22/2022 14:00	1	1.7	7.4	14.3	16.1	902,367.7	0.00	1.00
10/22/2022 15:00	2	1.6	10.2	14.4	18.1	723,688.1	0.00	1.00
10/22/2022 16:00	2	1.6	9.1	14.4	17.0	796,794.3	0.00	1.00
10/22/2022 17:00	1	1.7	7.5	14.3	16.3	890,333.3	0.00	1.00
10/22/2022 18:00	1	1.7	7.5	14.3	16.9	899,670.3	0.00	1.00
10/22/2022 19:00	1	1.7	7.6	14.3	18.9	955,484.7	0.00	1.00
10/22/2022 20:00	2	1.7	8.0	14.2	20.9	959,005.9	0.00	1.00
10/22/2022 21:00	2	1.8	9.7	13.8	24.9	1,001,994.3	0.00	1.00
10/22/2022 22:00	2	1.7	8.0	14.3	20.4	962,539.4	0.00	1.00
10/22/2022 23:00	2	1.7	8.0	14.3	20.3	961,501.9	0.00	1.00
Average/Sum#:	2	1.8	8.9	13.9	21.7	945,592.2	0.00 #	24.00 #
Minimum:	1	1.6	7.3	11.8	16.1	723,688.1	0.00	1.00
Maximum:	4	2.3	13.3	14.4	38.9	1,002,238.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2022 00:00	2	1.8	9.9	13.9	27.3	982,659.8	0.00	1.00
10/23/2022 01:00	2	1.7	9.0	14.1	23.8	962,826.2	0.00	1.00
10/23/2022 02:00	1	1.6	8.6	14.4	21.7	979,033.1	0.00	1.00
10/23/2022 03:00	2	1.7	8.4	14.4	22.2	977,558.3	0.00	1.00
10/23/2022 04:00	2	1.7	8.3	14.3	22.2	962,331.9	0.00	1.00
10/23/2022 05:00	2	1.7	8.3	14.3	22.1	962,331.9	0.00	1.00
10/23/2022 06:00	2	1.7	8.2	14.3	22.2	961,294.4	0.00	1.00
10/23/2022 07:00	2	1.7	9.0	14.1	24.7	954,770.7	0.00	1.00
10/23/2022 08:00	2	1.8	9.8	13.9	26.8	990,093.8	0.00	1.00
10/23/2022 09:00	2	1.7	8.3	14.2	19.6	880,110.7	0.00	1.00
10/23/2022 10:00	2	1.7	8.1	14.4	17.6	836,823.6	0.00	1.00
10/23/2022 11:00	2	1.8	10.3	13.9	26.6	1,003,201.2	0.00	1.00
10/23/2022 12:00	2	1.7	8.7	14.2	20.5	895,848.8	0.00	1.00
10/23/2022 13:00	2	1.6	9.0	14.5	16.7	751,685.6	0.00	1.00
10/23/2022 14:00	2	1.6	8.7	14.4	17.3	755,290.2	0.00	1.00
10/23/2022 15:00	3	1.6	12.0	14.6	22.3	659,714.8	0.00	1.00
10/23/2022 16:00	2	1.7	10.1	14.5	19.6	805,820.7	0.00	1.00
10/23/2022 17:00	1	1.6	7.9	14.5	18.6	967,797.9	0.00	1.00
10/23/2022 18:00	1	1.7	8.0	14.4	19.9	968,077.7	0.00	1.00
10/23/2022 19:00	1	1.7	8.0	14.4	20.5	975,662.2	0.00	1.00
10/23/2022 20:00	2	1.8	9.6	13.9	25.7	977,769.0	0.00	1.00
10/23/2022 21:00	2	1.8	9.8	13.9	26.1	975,617.1	0.00	1.00
10/23/2022 22:00	2	1.7	7.7	14.3	17.4	838,461.2	0.00	1.00
10/23/2022 23:00	2	1.7	8.0	14.4	22.2	981,350.6	0.00	1.00
Average/Sum#:	2	1.7	8.9	14.3	21.8	916,922.1	0.00 #	24.00 #
Minimum:	1	1.6	7.7	13.9	16.7	659,714.8	0.00	1.00
Maximum:	3	1.8	12.0	14.6	27.3	1,003,201.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2022 00:00	2	1.7	8.1	14.3	21.3	947,600.2	0.00	1.00
10/24/2022 01:00	2	1.7	8.0	14.3	21.1	923,946.5	0.00	1.00
10/24/2022 02:00	2	1.7	8.6	14.3	22.5	962,746.8	0.00	1.00
10/24/2022 03:00	2	1.7	8.5	14.3	22.8	963,784.3	0.00	1.00
10/24/2022 04:00	2	1.7	8.3	14.3	23.2	956,107.2	0.00	1.00
10/24/2022 05:00	2	1.7	8.4	14.2	24.2	950,012.6	0.00	1.00
10/24/2022 06:00	3	2.0	12.2	13.1	36.1	1,044,273.9	0.00	1.00
10/24/2022 07:00	3	1.9	10.9	13.5	31.2	1,014,299.3	0.00	1.00
10/24/2022 08:00	2	1.7	9.4	14.1	26.7	998,471.5	0.00	1.00
10/24/2022 09:00	2	1.8	9.7	14.0	26.1	996,504.3	0.00	1.00
10/24/2022 10:00	2	1.7	9.5	14.1	25.0	991,020.2	0.00	1.00
10/24/2022 11:00	1	1.6	7.8	14.4	18.5	907,191.0	0.00	1.00
10/24/2022 12:00	3	1.6	13.4	14.6	27.6	621,240.5	0.00	1.00
10/24/2022 13:00	4	1.6	14.7	14.7	30.2	618,449.7	0.00	1.00
10/24/2022 14:00	1	1.6	9.4	14.4	14.4	854,731.5	0.00	1.00
10/24/2022 15:00	1	1.8	8.5	14.1	20.1	991,624.4	0.00	1.00
10/24/2022 16:00	2	1.9	10.4	13.4	25.6	1,011,000.4	0.00	1.00
10/24/2022 17:00	2	1.8	9.4	13.7	23.4	1,007,668.1	0.00	1.00
10/24/2022 18:00	1	1.7	8.4	14.1	20.3	983,568.9	0.00	1.00
10/24/2022 19:00	2	1.8	9.1	13.9	22.4	994,202.1	0.00	1.00
10/24/2022 20:00	2	1.8	9.1	13.9	21.7	967,400.5	0.00	1.00
10/24/2022 21:00	2	1.7	8.4	14.2	17.5	771,783.1	0.00	1.00
10/24/2022 22:00	3	1.6	11.6	14.4	23.4	655,427.6	0.00	1.00
10/24/2022 23:00	2	1.6	10.6	14.3	19.6	690,729.4	0.00	1.00
Average/Sum#:	2	1.7	9.7	14.1	23.5	909,324.3	0.00 #	24.00 #
Minimum:	1	1.6	7.8	13.1	14.4	618,449.7	0.00	1.00
Maximum:	4	2.0	14.7	14.7	36.1	1,044,273.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2022 00:00	3	1.6	12.6	14.5	24.2	629,721.2	0.00	1.00
10/25/2022 01:00	3	1.6	12.3	14.5	23.6	631,647.0	0.00	1.00
10/25/2022 02:00	3	1.7	13.2	14.5	25.2	629,935.2	0.00	1.00
10/25/2022 03:00	3	1.6	12.2	14.5	23.8	643,415.5	0.00	1.00
10/25/2022 04:00	1	1.6	7.6	14.2	12.5	857,014.4	0.00	1.00
10/25/2022 05:00	2	1.7	7.6	14.3	18.8	938,055.7	0.00	1.00
10/25/2022 06:00	2	1.8	10.2	13.7	28.4	1,012,232.9	0.00	1.00
10/25/2022 07:00	2	1.8	9.8	13.9	26.6	979,921.0	0.00	1.00
10/25/2022 08:00	1	1.7	7.7	14.2	15.3	775,666.5	0.00	1.00
10/25/2022 09:00	2	1.7	8.3	14.3	18.1	749,241.1	0.00	1.00
10/25/2022 10:00	4	1.6	13.7	14.7	28.5	629,051.7	0.00	1.00
10/25/2022 11:00	2	1.6	11.6	14.6	19.5	638,412.6	0.00	1.00
10/25/2022 12:00	1	1.6	9.3	14.5	16.4	776,934.4	0.00	1.00
10/25/2022 13:00	1	1.8	9.8	13.8	22.4	985,406.9	0.00	1.00
10/25/2022 14:00	1	1.9	11.1	13.3	27.1	985,264.8	0.00	1.00
10/25/2022 15:00	1	1.9	10.8	13.3	26.4	983,643.1	0.00	1.00
10/25/2022 16:00	1	2.0	11.9	13.0	30.1	992,399.3	0.00	1.00
10/25/2022 17:00	1	2.0	11.4	13.2	27.9	997,367.8	0.00	1.00
10/25/2022 18:00	1	1.9	10.2	13.5	26.0	984,320.0	0.00	1.00
10/25/2022 19:00	1	1.9	9.9	13.6	26.3	994,052.0	0.00	1.00
10/25/2022 20:00	1	1.9	10.4	13.5	27.3	1,000,420.0	0.00	1.00
10/25/2022 21:00	1	1.8	9.1	13.9	23.5	954,684.4	0.00	1.00
10/25/2022 22:00	2	1.6	11.6	14.4	23.7	638,362.4	0.00	1.00
10/25/2022 23:00	1	1.7	9.6	14.3	16.9	677,865.1	0.00	1.00
Average/Sum#:	2	1.8	10.5	14.0	23.3	836,876.5	0.00 #	24.00 #
Minimum:	1	1.6	7.6	13.0	12.5	629,051.7	0.00	1.00
Maximum:	4	2.0	13.7	14.7	30.1	1,012,232.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	1	1.6	11.8	14.5	22.7	631,005.1	0.00	1.00
10/26/2022 01:00	1	1.6	12.0	14.5	23.6	631,861.0	0.00	1.00
10/26/2022 02:00	1	1.6	12.3	14.5	22.3	634,428.6	0.00	1.00
10/26/2022 03:00	1	1.7	8.7	14.3	15.3	792,606.2	0.00	1.00
10/26/2022 04:00	1	1.7	7.9	14.2	20.1	858,649.5	0.00	1.00
10/26/2022 05:00	1	1.7	7.8	14.3	20.6	914,194.5	0.00	1.00
10/26/2022 06:00	1	1.7	8.1	14.3	22.6	960,049.5	0.00	1.00
10/26/2022 07:00	1	1.6	8.4	14.3	21.3	875,186.7	0.00	1.00
10/26/2022 08:00	1	1.8	8.6	14.1	22.9	959,604.0	0.00	1.00
10/26/2022 09:00	1	1.8	9.7	13.8	25.0	987,335.7	0.00	1.00
10/26/2022 10:00	1	1.8	10.1	13.7	24.8	992,071.9	0.00	1.00
10/26/2022 11:00	1	1.6	10.8	14.4	22.4	734,432.8	0.00	1.00
10/26/2022 12:00	2	1.6	13.4	14.6	27.2	613,849.9	0.00	1.00
10/26/2022 13:00	2	1.6	13.7	14.6	26.4	611,241.5	0.00	1.00
10/26/2022 14:00	1	1.6	10.2	14.5	15.0	703,755.7	0.00	1.00
10/26/2022 15:00	1	1.4	11.2	14.6	22.6	702,319.1	0.00	1.00
10/26/2022 16:00	1	1.6	8.7	14.3	16.9	858,587.6	0.00	1.00
10/26/2022 17:00	1	1.8	10.2	13.8	23.9	996,015.1	0.00	1.00
10/26/2022 18:00	1	1.7	9.1	14.2	22.3	975,357.2	0.00	1.00
10/26/2022 19:00	1	1.6	11.1	14.4	21.4	655,216.9	0.00	1.00
10/26/2022 20:00	1	1.6	9.7	14.4	20.2	723,056.1	0.00	1.00
10/26/2022 21:00	1	1.6	11.2	14.4	22.1	652,688.7	0.00	1.00
10/26/2022 22:00	2	1.7	13.3	14.5	28.5	627,367.5	0.00	1.00
10/26/2022 23:00	2	1.5	13.2	14.5	25.8	631,005.1	0.00	1.00
Average/Sum#:	1	1.6	10.5	14.3	22.3	780,078.6	0.00 #	24.00 #
Minimum:	1	1.4	7.8	13.7	15.0	611,241.5	0.00	1.00
Maximum:	2	1.8	13.7	14.6	28.5	996,015.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2022 00:00	3	1.6	16.7	14.6	37.6	613,632.5	0.00	1.00
10/27/2022 01:00	2	1.6	15.7	14.6	32.1	624,501.0	0.00	1.00
10/27/2022 02:00	2	1.7	15.3	14.5	30.6	623,088.1	0.00	1.00
10/27/2022 03:00	1	1.6	13.6	14.4	26.6	638,362.4	0.00	1.00
10/27/2022 04:00	1	1.7	11.0	14.4	21.3	735,696.9	0.00	1.00
10/27/2022 05:00	1	1.7	8.8	14.3	20.2	827,879.3	0.00	1.00
10/27/2022 06:00	2	1.7	10.6	14.3	29.7	806,508.0	0.00	1.00
10/27/2022 07:00	1	1.6	8.0	14.2	15.6	848,429.9	0.00	1.00
10/27/2022 08:00	1	1.7	7.8	14.3	20.1	930,793.6	0.00	1.00
10/27/2022 09:00	1	1.7	9.2	14.1	24.1	981,756.5	0.00	1.00
10/27/2022 10:00	1	1.7	8.4	14.2	18.8	866,620.8	0.00	1.00
10/27/2022 11:00	1	1.8	9.0	14.1	22.6	991,423.0	0.00	1.00
10/27/2022 12:00	1	1.8	9.5	14.0	23.2	993,924.2	0.00	1.00
10/27/2022 13:00	1	1.7	9.1	14.1	21.9	870,390.0	0.00	1.00
10/27/2022 14:00	1	1.6	12.5	14.5	21.2	641,275.8	0.00	1.00
10/27/2022 15:00	1	1.6	12.1	14.6	21.6	722,534.4	0.00	1.00
10/27/2022 16:00	1	1.9	10.1	13.5	23.4	1,006,156.8	0.00	1.00
10/27/2022 17:00	1	1.8	9.4	13.7	22.9	1,000,440.6	0.00	1.00
10/27/2022 18:00	1	1.8	8.7	14.0	21.8	994,519.7	0.00	1.00
10/27/2022 19:00	1	1.8	9.2	13.9	23.5	998,114.7	0.00	1.00
10/27/2022 20:00	1	1.8	9.6	13.8	24.8	1,006,816.2	0.00	1.00
10/27/2022 21:00	1	1.8	9.6	13.8	25.0	1,005,273.2	0.00	1.00
10/27/2022 22:00	1	1.7	8.5	14.1	22.7	975,110.7	0.00	1.00
10/27/2022 23:00	1	1.7	7.4	14.2	17.0	866,620.8	0.00	1.00
Average/Sum#:	1	1.7	10.4	14.2	23.7	857,077.9	0.00 #	24.00 #
Minimum:	1	1.6	7.4	13.5	15.6	613,632.5	0.00	1.00
Maximum:	3	1.9	16.7	14.6	37.6	1,006,816.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2022 00:00	1	1.7	7.5	14.2	17.6	852,926.6	0.00	1.00
10/28/2022 01:00	1	1.7	7.4	14.2	16.4	815,318.5	0.00	1.00
10/28/2022 02:00	1	1.8	7.7	14.2	17.4	850,473.9	0.00	1.00
10/28/2022 03:00	1	1.8	7.9	14.2	19.6	925,281.2	0.00	1.00
10/28/2022 04:00	1	1.8	10.2	13.7	28.8	1,016,036.8	0.00	1.00
10/28/2022 05:00	1	1.9	10.8	13.5	30.9	1,022,997.0	0.00	1.00
10/28/2022 06:00	1	1.9	10.5	13.6	30.4	1,019,564.6	0.00	1.00
10/28/2022 07:00	1	1.7	8.9	14.1	25.2	978,937.0	0.00	1.00
10/28/2022 08:00	1	1.7	7.5	14.3	18.3	866,472.2	0.00	1.00
10/28/2022 09:00	1	1.7	7.5	14.4	19.0	937,529.0	0.00	1.00
10/28/2022 10:00	1	1.7	9.0	14.1	23.5	998,471.5	0.00	1.00
10/28/2022 11:00	1	1.6	9.0	14.3	20.5	824,352.0	0.00	1.00
10/28/2022 12:00	0	1.6	7.1	14.4	12.4	825,657.6	0.00	1.00
10/28/2022 13:00	1	1.6	7.8	14.4	14.5	790,263.2	0.00	1.00
10/28/2022 14:00	1	1.7	8.2	14.4	16.5	847,568.4	0.00	1.00
10/28/2022 15:00	1	1.9	9.6	13.7	23.3	1,012,042.7	0.00	1.00
10/28/2022 16:00	1	1.8	9.3	13.7	23.2	990,169.9	0.00	1.00
10/28/2022 17:00	1	2.0	11.0	13.1	27.2	1,015,656.4	0.00	1.00
10/28/2022 18:00	1	2.0	11.2	13.1	28.2	1,024,961.5	0.00	1.00
10/28/2022 19:00	1	2.0	11.1	13.1	28.0	1,022,679.1	0.00	1.00
10/28/2022 20:00	1	2.0	11.4	13.0	30.0	1,023,081.4	0.00	1.00
10/28/2022 21:00	1	2.0	11.5	13.0	30.4	1,026,374.9	0.00	1.00
10/28/2022 22:00	1	1.8	9.7	13.6	26.3	1,002,681.3	0.00	1.00
10/28/2022 23:00	1	1.7	7.4	14.3	19.2	956,107.2	0.00	1.00
Average/Sum#:	1	1.8	9.1	13.9	22.8	943,566.8	0.00 #	24.00 #
Minimum:	0	1.6	7.1	13.0	12.4	790,263.2	0.00	1.00
Maximum:	1	2.0	11.5	14.4	30.9	1,026,374.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2022 00:00	1	1.7	7.9	14.2	17.3	782,615.8	0.00	1.00
10/29/2022 01:00	1	1.7	7.5	14.2	17.8	799,171.5	0.00	1.00
10/29/2022 02:00	1	1.6	7.9	14.2	18.1	791,813.4	0.00	1.00
10/29/2022 03:00	2	1.6	13.2	14.4	30.4	626,985.7	0.00	1.00
10/29/2022 04:00	1	1.7	9.2	14.3	16.6	775,177.2	0.00	1.00
10/29/2022 05:00	1	1.7	7.8	14.3	21.1	928,096.3	0.00	1.00
10/29/2022 06:00	2	1.7	9.2	14.2	24.4	782,820.2	0.00	1.00
10/29/2022 07:00	1	1.6	9.0	14.3	18.4	791,568.8	0.00	1.00
10/29/2022 08:00	1	1.7	7.6	14.3	19.4	917,099.4	0.00	1.00
10/29/2022 09:00	1	1.7	7.5	14.3	16.7	836,178.8	0.00	1.00
10/29/2022 10:00	1	1.7	7.2	14.3	16.1	860,455.0	0.00	1.00
10/29/2022 11:00	1	1.6	8.5	14.4	16.8	776,569.0	0.00	1.00
10/29/2022 12:00	1	1.6	10.8	14.6	21.3	648,628.9	0.00	1.00
10/29/2022 13:00	1	1.5	9.8	14.5	16.5	670,804.0	0.00	1.00
10/29/2022 14:00	1	1.6	9.8	14.5	17.0	683,642.3	0.00	1.00
10/29/2022 15:00	1	1.5	10.2	14.6	18.1	710,796.5	0.00	1.00
10/29/2022 16:00	1	1.6	8.1	14.5	14.5	797,689.7	0.00	1.00
10/29/2022 17:00	1	1.7	7.5	14.3	13.5	797,586.0	0.00	1.00
10/29/2022 18:00	1	1.6	9.4	14.5	21.2	798,117.6	0.00	1.00
10/29/2022 19:00	1	1.6	10.5	14.5	17.1	673,799.6	0.00	1.00
10/29/2022 20:00	1	1.7	7.9	14.3	20.1	977,271.0	0.00	1.00
10/29/2022 21:00	1	1.7	9.1	14.1	23.9	999,881.2	0.00	1.00
10/29/2022 22:00	1	1.7	7.4	14.3	17.1	884,938.6	0.00	1.00
10/29/2022 23:00	1	1.7	7.5	14.4	19.3	969,341.8	0.00	1.00
Average/Sum#:	1	1.6	8.8	14.4	18.9	803,377.0	0.00 #	24.00 #
Minimum:	1	1.5	7.2	14.1	13.5	626,985.7	0.00	1.00
Maximum:	2	1.7	13.2	14.6	30.4	999,881.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2022 00:00	1	1.7	7.4	14.3	18.7	923,531.5	0.00	1.00
10/30/2022 01:00	1	1.7	7.5	14.3	18.0	866,264.7	0.00	1.00
10/30/2022 02:00	1	1.7	7.9	14.3	19.2	893,238.2	0.00	1.00
10/30/2022 03:00	1	1.7	7.7	14.3	19.9	891,785.8	0.00	1.00
10/30/2022 04:00	1	1.7	7.7	14.3	20.6	908,592.3	0.00	1.00
10/30/2022 05:00	1	1.7	7.8	14.4	22.4	996,730.3	0.00	1.00
10/30/2022 06:00	1	1.7	7.8	14.3	21.1	959,219.5	0.00	1.00
10/30/2022 07:00	3	1.5	15.7	14.5	42.4	638,708.1	0.00	1.00
10/30/2022 08:00	2	1.2	16.3	14.6	35.8	616,023.6	0.00	1.00
10/30/2022 09:00	2	1.3	15.4	14.6	34.4	610,806.7	0.00	1.00
10/30/2022 10:00	2	1.3	14.7	14.6	31.6	610,589.4	0.00	1.00
10/30/2022 11:00	2	1.3	14.5	14.7	30.7	618,008.0	0.00	1.00
10/30/2022 12:00	1	1.5	13.9	14.7	25.5	617,345.3	0.00	1.00
10/30/2022 13:00	1	1.6	13.7	14.7	25.3	617,124.5	0.00	1.00
10/30/2022 14:00	1	1.6	13.6	14.7	25.3	616,903.6	0.00	1.00
10/30/2022 15:00	1	1.5	11.5	14.6	18.1	666,670.6	0.00	1.00
10/30/2022 16:00	0	1.7	7.2	14.4	11.1	919,831.8	0.00	1.00
10/30/2022 17:00	1	1.7	7.4	14.3	16.0	939,300.6	0.00	1.00
10/30/2022 18:00	1	1.7	8.1	14.1	20.1	980,346.8	0.00	1.00
10/30/2022 19:00	1	1.7	7.0	14.3	15.4	894,483.1	0.00	1.00
10/30/2022 20:00	1	1.7	6.9	14.3	15.2	874,979.2	0.00	1.00
10/30/2022 21:00	1	1.7	7.0	14.3	15.8	880,788.9	0.00	1.00
10/30/2022 22:00	1	1.7	7.0	14.2	15.1	839,845.5	0.00	1.00
10/30/2022 23:00	1	1.7	7.1	14.2	16.7	872,139.4	0.00	1.00
Average/Sum#:	1	1.6	10.0	14.4	22.3	802,219.1	0.00 #	24.00 #
Minimum:	0	1.2	6.9	14.1	11.1	610,589.4	0.00	1.00
Maximum:	3	1.7	16.3	14.7	42.4	996,730.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2022 00:00	1	1.7	7.2	14.2	17.2	871,117.4	0.00	1.00
10/31/2022 01:00	1	1.7	7.3	14.2	17.4	858,240.7	0.00	1.00
10/31/2022 02:00	1	1.7	7.7	14.2	18.9	879,088.7	0.00	1.00
10/31/2022 03:00	1	1.7	7.7	14.2	20.0	867,234.0	0.00	1.00
10/31/2022 04:00	1	1.7	7.6	14.3	19.8	933,076.0	0.00	1.00
10/31/2022 05:00	1	1.8	9.2	14.0	25.7	957,406.3	0.00	1.00
10/31/2022 06:00	1	1.9	10.2	13.6	27.5	985,422.8	0.00	1.00
10/31/2022 07:00	1	1.7	9.6	14.3	24.2	838,461.2	0.00	1.00
10/31/2022 08:00	1	1.7	9.3	14.3	18.9	761,690.4	0.00	1.00
10/31/2022 09:00	1	1.6	8.8	14.4	14.2	735,064.9	0.00	1.00
10/31/2022 10:00	1	1.6	10.2	14.4	20.6	660,062.6	0.00	1.00
10/31/2022 11:00	1	1.6	10.8	14.5	19.8	627,581.5	0.00	1.00
10/31/2022 12:00	1	1.6	10.8	14.5	19.4	627,581.5	0.00	1.00
10/31/2022 13:00	0	1.6	8.5	14.4	12.6	710,625.9	0.00	1.00
10/31/2022 14:00	1	1.7	8.1	14.1	16.9	890,528.6	0.00	1.00
10/31/2022 15:00	1	1.8	9.1	13.8	21.0	977,691.9	0.00	1.00
10/31/2022 16:00	0	1.6	7.7	14.2	12.0	776,279.7	0.00	1.00
10/31/2022 17:00	1	1.7	10.9	14.5	21.7	624,158.0	0.00	1.00
10/31/2022 18:00	1	1.6	11.2	14.5	20.3	620,306.5	0.00	1.00
10/31/2022 19:00	1	1.6	9.5	14.3	16.4	671,847.9	0.00	1.00
10/31/2022 20:00	1	1.7	8.7	14.2	15.6	693,296.6	0.00	1.00
10/31/2022 21:00	1	1.6	6.9	14.2	12.3	795,696.9	0.00	1.00
10/31/2022 22:00	1	1.7	9.3	14.3	18.9	709,195.8	0.00	1.00
10/31/2022 23:00	1	1.7	6.9	14.3	15.7	935,565.8	0.00	1.00
Average/Sum#:	1	1.7	8.9	14.2	18.6	791,967.6	0.00 #	24.00 #
Minimum:	0	1.6	6.9	13.6	12.0	620,306.5	0.00	1.00
Maximum:	1	1.9	11.2	14.5	27.5	985,422.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022 00:00	1	1.7	7.0	14.3	17.9	939,508.1	0.00	1.00
11/01/2022 01:00	1	1.7	7.5	14.2	19.9	945,924.8	0.00	1.00
11/01/2022 02:00	1	1.9	10.2	13.5	25.2	995,608.5	0.00	1.00
11/01/2022 03:00	1	2.0	10.7	13.1	28.9	988,619.1	0.00	1.00
11/01/2022 04:00	1	2.0	11.4	12.9	29.8	997,454.5	0.00	1.00
11/01/2022 05:00	1	2.0	10.7	13.1	27.8	995,817.3	0.00	1.00
11/01/2022 06:00	1	2.1	11.9	12.7	32.6	1,015,879.1	0.00	1.00
11/01/2022 07:00	1	2.0	10.5	13.1	27.2	986,336.7	0.00	1.00
11/01/2022 08:00	1	1.9	9.9	13.5	24.5	999,309.7	0.00	1.00
11/01/2022 09:00	1	1.8	8.8	13.8	21.8	979,620.6	0.00	1.00
11/01/2022 10:00	1	1.8	8.9	13.8	22.3	987,335.7	0.00	1.00
11/01/2022 11:00	1	1.9	9.7	13.5	25.3	997,089.0	0.00	1.00
11/01/2022 12:00	1	1.9	10.2	13.2	27.2	992,032.4	0.00	1.00
11/01/2022 13:00	1	1.9	10.1	13.3	27.8	996,796.8	0.00	1.00
11/01/2022 14:00	1	1.8	8.3	13.9	23.7	969,356.8	0.00	1.00
11/01/2022 15:00	1	1.8	8.6	13.8	23.4	973,448.6	0.00	1.00
11/01/2022 16:00	1	1.9	10.2	13.3	26.9	995,895.9	0.00	1.00
11/01/2022 17:00	1	1.9	9.7	13.5	26.2	1,000,790.1	0.00	1.00
11/01/2022 18:00	1	1.9	9.4	13.6	27.0	1,001,368.1	0.00	1.00
11/01/2022 19:00	1	1.9	9.3	13.6	27.3	1,006,245.5	0.00	1.00
11/01/2022 20:00	1	1.8	9.1	13.7	26.6	1,006,146.5	0.00	1.00
11/01/2022 21:00	1	1.8	8.7	13.9	25.1	992,832.7	0.00	1.00
11/01/2022 22:00	1	1.8	8.6	14.0	25.1	988,764.1	0.00	1.00
11/01/2022 23:00	1	1.7	7.7	14.2	19.6	817,771.2	0.00	1.00
Average/Sum#:	1	1.9	9.5	13.6	25.4	982,081.3	0.00 #	24.00 #
Minimum:	1	1.7	7.0	12.7	17.9	817,771.2	0.00	1.00
Maximum:	1	2.1	11.9	14.3	32.6	1,015,879.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2022 00:00	2	1.6	12.4	14.4	27.7	624,457.5	0.00	1.00
11/02/2022 01:00	1	1.7	7.4	14.2	14.9	774,440.1	0.00	1.00
11/02/2022 02:00	1	1.9	8.8	14.3	19.7	703,178.7	0.00	1.00
11/02/2022 03:00	1	1.8	7.5	14.2	19.0	834,735.7	0.00	1.00
11/02/2022 04:00	1	1.7	7.6	14.3	21.7	921,664.1	0.00	1.00
11/02/2022 05:00	1	1.7	7.7	14.3	22.8	965,236.7	0.00	1.00
11/02/2022 06:00	1	1.8	9.7	13.8	28.4	1,003,344.5	0.00	1.00
11/02/2022 07:00	2	1.7	9.9	14.3	26.6	810,450.2	0.00	1.00
11/02/2022 08:00	2	1.6	12.1	14.4	25.8	637,519.7	0.00	1.00
11/02/2022 09:00	2	1.6	11.2	14.4	23.2	649,107.2	0.00	1.00
11/02/2022 10:00	0	1.7	7.7	14.3	14.8	858,380.1	0.00	1.00
11/02/2022 11:00	1	1.7	8.9	14.1	23.6	999,679.8	0.00	1.00
11/02/2022 12:00	1	1.8	8.9	14.0	23.5	983,603.9	0.00	1.00
11/02/2022 13:00	1	1.7	7.5	14.3	18.7	906,102.5	0.00	1.00
11/02/2022 14:00	1	1.7	8.6	14.1	23.6	974,506.6	0.00	1.00
11/02/2022 15:00	1	1.8	9.3	14.0	24.4	987,970.2	0.00	1.00
11/02/2022 16:00	1	1.9	10.5	13.5	28.6	991,907.4	0.00	1.00
11/02/2022 17:00	1	2.0	11.5	13.1	31.2	999,504.2	0.00	1.00
11/02/2022 18:00	1	1.8	9.7	13.7	26.8	994,544.5	0.00	1.00
11/02/2022 19:00	1	1.8	9.6	13.7	27.5	992,642.5	0.00	1.00
11/02/2022 20:00	1	2.0	11.1	13.2	32.3	1,009,105.7	0.00	1.00
11/02/2022 21:00	1	1.9	10.4	13.4	31.1	1,002,783.8	0.00	1.00
11/02/2022 22:00	1	1.8	9.8	13.7	29.3	1,004,434.7	0.00	1.00
11/02/2022 23:00	1	1.7	7.9	14.3	23.2	965,859.2	0.00	1.00
Average/Sum#:	1	1.8	9.4	14.0	24.5	899,798.3	0.00 #	24.00 #
Minimum:	0	1.6	7.4	13.1	14.8	624,457.5	0.00	1.00
Maximum:	2	2.0	12.4	14.4	32.3	1,009,105.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	1	1.7	8.0	14.3	23.9	972,913.8	0.00	1.00
11/03/2022 01:00	1	1.7	8.0	14.3	23.8	952,579.9	0.00	1.00
11/03/2022 02:00	1	1.6	8.2	14.3	23.7	948,430.1	0.00	1.00
11/03/2022 03:00	1	1.7	8.0	14.3	24.9	969,179.0	0.00	1.00
11/03/2022 04:00	1	1.7	8.4	14.3	25.8	977,686.0	0.00	1.00
11/03/2022 05:00	2	2.1	12.7	12.7	38.3	1,027,402.3	0.00	1.00
11/03/2022 06:00	2	2.2	13.7	12.3	42.4	1,021,335.8	0.00	1.00
11/03/2022 07:00	1	1.7	8.4	14.1	26.3	968,666.4	0.00	1.00
11/03/2022 08:00	1	1.7	7.8	14.2	22.8	905,250.8	0.00	1.00
11/03/2022 09:00	1	1.7	8.9	14.1	27.6	994,041.0	0.00	1.00
11/03/2022 10:00	1	2.1	9.5	13.9	26.0	1,000,853.6	0.00	1.00
11/03/2022 11:00	1	1.6	7.7	14.3	18.3	811,487.7	0.00	1.00
11/03/2022 12:00	2	1.6	13.0	14.5	30.7	629,721.2	0.00	1.00
11/03/2022 13:00	2	1.6	12.9	14.5	25.5	622,446.2	0.00	1.00
11/03/2022 14:00	2	1.6	14.4	14.6	29.0	613,849.9	0.00	1.00
11/03/2022 15:00	2	1.6	14.8	14.6	29.2	627,544.2	0.00	1.00
11/03/2022 16:00	1	1.7	8.5	14.4	16.9	886,122.9	0.00	1.00
11/03/2022 17:00	1	1.9	10.3	13.6	27.1	998,741.8	0.00	1.00
11/03/2022 18:00	1	1.8	9.9	13.7	27.8	1,000,060.2	0.00	1.00
11/03/2022 19:00	1	1.8	10.3	13.7	28.9	1,002,913.2	0.00	1.00
11/03/2022 20:00	1	2.0	12.1	13.1	34.3	1,018,992.2	0.00	1.00
11/03/2022 21:00	2	2.0	12.7	12.9	37.0	1,017,140.0	0.00	1.00
11/03/2022 22:00	1	1.9	10.8	13.5	30.7	998,384.4	0.00	1.00
11/03/2022 23:00	1	1.7	8.7	14.1	26.2	984,374.5	0.00	1.00
Average/Sum#:	1	1.8	10.3	13.9	27.8	914,588.2	0.00 #	24.00 #
Minimum:	1	1.6	7.7	12.3	16.9	613,849.9	0.00	1.00
Maximum:	2	2.2	14.8	14.6	42.4	1,027,402.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2022 00:00	1	1.7	8.0	14.2	23.2	919,149.5	0.00	1.00
11/04/2022 01:00	1	1.7	7.9	14.3	23.1	924,154.0	0.00	1.00
11/04/2022 02:00	1	1.8	8.0	14.2	21.2	841,480.6	0.00	1.00
11/04/2022 03:00	1	1.7	7.8	14.3	22.5	887,221.0	0.00	1.00
11/04/2022 04:00	1	1.7	8.0	14.3	23.7	943,242.9	0.00	1.00
11/04/2022 05:00	1	1.9	11.2	13.4	33.3	1,007,896.3	0.00	1.00
11/04/2022 06:00	1	1.9	11.1	13.4	32.5	1,012,643.7	0.00	1.00
11/04/2022 07:00	2	1.7	11.3	14.3	31.8	804,640.6	0.00	1.00
11/04/2022 08:00	2	1.5	14.8	14.5	29.7	636,996.3	0.00	1.00
11/04/2022 09:00	2	1.6	12.1	14.4	25.5	639,205.2	0.00	1.00
11/04/2022 10:00	2	1.6	13.4	14.5	27.4	617,310.8	0.00	1.00
11/04/2022 11:00	3	1.6	16.3	14.6	36.3	605,589.9	0.00	1.00
11/04/2022 12:00	1	1.6	13.6	14.6	24.5	624,066.3	0.00	1.00
11/04/2022 13:00	2	1.6	14.9	14.6	30.2	609,719.9	0.00	1.00
11/04/2022 14:00	2	1.6	14.9	14.6	31.0	607,546.2	0.00	1.00
11/04/2022 15:00	1	1.5	11.4	14.5	18.4	721,301.5	0.00	1.00
11/04/2022 16:00	1	1.6	9.3	14.4	16.1	740,331.9	0.00	1.00
11/04/2022 17:00	1	1.7	7.6	14.4	17.2	911,615.3	0.00	1.00
11/04/2022 18:00	1	1.8	9.8	13.8	25.4	987,914.3	0.00	1.00
11/04/2022 19:00	1	1.8	9.8	13.8	26.3	988,685.8	0.00	1.00
11/04/2022 20:00	1	1.8	9.5	13.9	26.0	964,074.8	0.00	1.00
11/04/2022 21:00	2	1.6	11.7	14.4	26.5	633,306.1	0.00	1.00
11/04/2022 22:00	3	1.6	15.9	14.6	36.2	606,459.4	0.00	1.00
11/04/2022 23:00	1	1.6	10.2	14.3	17.2	669,358.0	0.00	1.00
Average/Sum#:	1	1.7	11.2	14.3	26.1	787,662.9	0.00 #	24.00 #
Minimum:	1	1.5	7.6	13.4	16.1	605,589.9	0.00	1.00
Maximum:	3	1.9	16.3	14.6	36.3	1,012,643.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	2	1.6	12.5	14.5	25.8	618,166.7	0.00	1.00
11/05/2022 01:00	2	1.6	12.8	14.5	26.4	618,594.7	0.00	1.00
11/05/2022 02:00	2	1.6	13.2	14.5	25.9	617,738.8	0.00	1.00
11/05/2022 03:00	2	1.6	13.2	14.5	28.4	615,385.1	0.00	1.00
11/05/2022 04:00	2	1.6	12.6	14.5	25.1	618,380.7	0.00	1.00
11/05/2022 05:00	1	1.6	10.7	14.4	19.4	668,489.8	0.00	1.00
11/05/2022 06:00	2	1.5	12.9	14.5	31.2	616,668.9	0.00	1.00
11/05/2022 07:00	1	1.6	10.1	14.3	17.5	731,812.1	0.00	1.00
11/05/2022 08:00	3	1.6	14.5	14.6	34.2	612,980.4	0.00	1.00
11/05/2022 09:00	1	1.6	13.0	14.5	23.2	612,175.5	0.00	1.00
11/05/2022 10:00	1	1.6	10.8	14.5	19.2	639,778.0	0.00	1.00
11/05/2022 11:00	1	1.6	9.7	14.4	17.6	659,219.8	0.00	1.00
11/05/2022 12:00	1	1.6	8.0	14.4	13.6	809,435.2	0.00	1.00
11/05/2022 13:00	1	1.7	8.3	14.3	14.6	706,913.5	0.00	1.00
11/05/2022 14:00	1	1.7	7.2	14.3	16.9	881,203.8	0.00	1.00
11/05/2022 15:00	2	1.6	12.2	14.5	24.0	616,668.9	0.00	1.00
11/05/2022 16:00	1	1.6	9.0	14.4	16.8	734,432.8	0.00	1.00
11/05/2022 17:00	1	1.7	7.5	14.2	17.6	878,271.1	0.00	1.00
11/05/2022 18:00	1	1.8	8.4	14.0	22.0	963,360.3	0.00	1.00
11/05/2022 19:00	1	1.7	8.3	14.1	21.8	961,215.1	0.00	1.00
11/05/2022 20:00	1	1.6	8.6	14.3	17.3	688,862.0	0.00	1.00
11/05/2022 21:00	1	1.6	9.9	14.4	19.9	629,935.2	0.00	1.00
11/05/2022 22:00	1	1.6	10.9	14.5	19.4	617,524.8	0.00	1.00
11/05/2022 23:00	1	1.7	6.6	14.3	13.7	861,907.4	0.00	1.00
Average/Sum#:	1	1.6	10.5	14.4	21.3	707,463.4	0.00 #	24.00 #
Minimum:	1	1.5	6.6	14.0	13.6	612,175.5	0.00	1.00
Maximum:	3	1.8	14.5	14.6	34.2	963,360.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2022 00:00	1	1.7	6.8	14.2	16.1	834,122.5	0.00	1.00
11/06/2022 01:00	1	1.7	7.2	14.1	14.4	717,336.7	0.00	1.00
11/06/2022 02:00	1	2.1	6.8	14.3	14.4	762,935.4	0.00	1.00
11/06/2022 03:00	1	1.6	7.0	14.3	18.3	892,200.7	0.00	1.00
11/06/2022 04:00	1	1.7	7.2	14.3	18.5	888,258.5	0.00	1.00
11/06/2022 05:00	1	1.7	7.4	14.4	20.0	959,439.8	0.00	1.00
11/06/2022 06:00	1	1.7	7.4	14.4	20.4	972,080.6	0.00	1.00
11/06/2022 07:00	1	1.7	7.5	14.4	20.6	969,552.5	0.00	1.00
11/06/2022 08:00	1	1.8	9.4	13.8	25.1	970,555.4	0.00	1.00
11/06/2022 09:00	1	1.7	8.8	14.0	22.7	942,124.3	0.00	1.00
11/06/2022 10:00	1	1.6	10.9	14.4	18.9	656,481.0	0.00	1.00
11/06/2022 11:00	1	1.7	10.2	14.4	19.3	620,454.6	0.00	1.00
11/06/2022 12:00	1	1.6	11.8	14.5	22.4	608,965.9	0.00	1.00
11/06/2022 13:00	1	1.6	10.6	14.5	19.8	627,581.5	0.00	1.00
11/06/2022 14:00	1	1.6	9.0	14.5	14.1	746,550.3	0.00	1.00
11/06/2022 15:00	1	1.8	8.8	13.9	20.8	949,011.1	0.00	1.00
11/06/2022 16:00	1	2.0	10.7	13.3	27.3	985,445.0	0.00	1.00
11/06/2022 17:00	1	1.8	9.4	13.7	24.0	974,003.1	0.00	1.00
11/06/2022 18:00	1	1.8	8.9	13.9	23.2	963,096.6	0.00	1.00
11/06/2022 19:00	1	1.8	8.6	14.0	23.4	966,932.7	0.00	1.00
11/06/2022 20:00	1	1.8	8.7	14.0	23.2	972,489.8	0.00	1.00
11/06/2022 21:00	1	1.8	8.9	13.9	23.5	965,639.8	0.00	1.00
11/06/2022 22:00	1	1.7	9.3	14.2	22.2	777,506.0	0.00	1.00
11/06/2022 23:00	1	1.7	11.2	14.4	21.6	616,030.3	0.00	1.00
Average/Sum#:	1	1.7	8.9	14.2	20.6	847,449.8	0.00 #	24.00 #
Minimum:	1	1.6	6.8	13.3	14.1	608,965.9	0.00	1.00
Maximum:	1	2.1	11.8	14.5	27.3	985,445.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2022 00:00	1	1.6	8.9	14.2	17.1	670,813.6	0.00	1.00
11/07/2022 01:00	1	1.6	8.4	14.3	17.7	759,408.1	0.00	1.00
11/07/2022 02:00	1	1.9	7.4	14.2	16.8	798,558.4	0.00	1.00
11/07/2022 03:00	2	1.8	7.7	14.2	20.3	750,935.1	0.00	1.00
11/07/2022 04:00	1	1.6	8.8	14.2	19.0	709,239.2	0.00	1.00
11/07/2022 05:00	1	1.7	7.4	14.3	21.1	880,581.4	0.00	1.00
11/07/2022 06:00	1	1.7	7.6	14.3	22.4	948,845.1	0.00	1.00
11/07/2022 07:00	1	1.7	7.4	14.2	19.3	831,056.6	0.00	1.00
11/07/2022 08:00	2	1.6	12.2	14.4	27.9	612,448.7	0.00	1.00
11/07/2022 09:00	2	1.6	11.8	14.4	24.0	610,974.0	0.00	1.00
11/07/2022 10:00	2	1.6	12.2	14.5	24.9	615,599.1	0.00	1.00
11/07/2022 11:00	2	1.6	12.7	14.5	27.0	610,891.7	0.00	1.00
11/07/2022 12:00	1	1.6	12.6	14.5	23.3	615,599.1	0.00	1.00
11/07/2022 13:00	1	1.6	11.9	14.5	22.8	617,952.8	0.00	1.00
11/07/2022 14:00	1	1.5	8.1	14.3	13.5	771,649.9	0.00	1.00
11/07/2022 15:00	1	1.8	8.9	13.9	21.8	915,949.3	0.00	1.00
11/07/2022 16:00	1	1.9	10.1	13.5	27.1	980,804.0	0.00	1.00
11/07/2022 17:00	1	1.9	10.0	13.5	28.0	976,917.7	0.00	1.00
11/07/2022 18:00	1	1.9	9.6	13.6	27.4	981,295.7	0.00	1.00
11/07/2022 19:00	1	1.9	9.8	13.5	28.1	981,174.1	0.00	1.00
11/07/2022 20:00	1	1.9	9.8	13.5	28.7	983,024.6	0.00	1.00
11/07/2022 21:00	1	1.9	10.0	13.4	28.7	976,490.9	0.00	1.00
11/07/2022 22:00	1	1.8	9.2	13.8	26.4	971,712.7	0.00	1.00
11/07/2022 23:00	1	1.7	9.3	14.2	23.7	805,916.5	0.00	1.00
Average/Sum#:	1	1.7	9.7	14.1	23.2	807,409.9	0.00 #	24.00 #
Minimum:	1	1.5	7.4	13.4	13.5	610,891.7	0.00	1.00
Maximum:	2	1.9	12.7	14.5	28.7	983,024.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2022 00:00	2	1.7	11.4	14.4	24.3	645,104.2	0.00	1.00
11/08/2022 01:00	2	1.6	13.3	14.5	27.8	604,044.5	0.00	1.00
11/08/2022 02:00	2	1.7	13.7	14.5	28.0	606,184.3	0.00	1.00
11/08/2022 03:00	2	1.7	13.3	14.4	28.7	596,858.4	0.00	1.00
11/08/2022 04:00	1	1.6	9.7	14.3	20.0	810,450.2	0.00	1.00
11/08/2022 05:00	1	1.8	8.8	14.0	25.1	962,169.5	0.00	1.00
11/08/2022 06:00	1	1.9	10.2	13.5	29.8	980,618.9	0.00	1.00
11/08/2022 07:00	1	1.8	9.0	13.9	26.4	965,052.9	0.00	1.00
11/08/2022 08:00	1	1.8	9.5	13.8	27.6	973,255.7	0.00	1.00
11/08/2022 09:00	2	2.0	11.0	13.2	32.8	979,405.2	0.00	1.00
11/08/2022 10:00	1	1.8	9.6	13.7	26.4	974,193.3	0.00	1.00
11/08/2022 11:00	1	1.8	9.0	13.9	25.8	965,835.5	0.00	1.00
11/08/2022 12:00	1	1.8	9.1	13.9	26.0	966,813.6	0.00	1.00
11/08/2022 13:00	2	1.7	10.7	14.3	25.5	683,882.2	0.00	1.00
11/08/2022 14:00	2	1.6	12.1	14.4	26.1	602,757.4	0.00	1.00
11/08/2022 15:00	1	1.7	9.5	14.2	20.8	812,048.2	0.00	1.00
11/08/2022 16:00	1	1.8	8.8	14.0	25.3	972,291.3	0.00	1.00
11/08/2022 17:00	1	1.8	9.1	13.9	26.9	972,291.3	0.00	1.00
11/08/2022 18:00	1	1.8	8.9	14.0	26.4	975,665.3	0.00	1.00
11/08/2022 19:00	1	1.8	8.8	14.0	26.7	972,489.8	0.00	1.00
11/08/2022 20:00	1	1.8	8.8	14.0	27.0	971,100.5	0.00	1.00
11/08/2022 21:00	1	1.8	8.8	14.0	26.7	971,100.5	0.00	1.00
11/08/2022 22:00	1	1.8	8.6	14.0	26.4	967,925.0	0.00	1.00
11/08/2022 23:00	1	1.7	8.7	14.1	27.0	981,957.8	0.00	1.00
Average/Sum#:	1	1.8	10.0	14.0	26.4	871,395.6	0.00 #	24.00 #
Minimum:	1	1.6	8.6	13.2	20.0	596,858.4	0.00	1.00
Maximum:	2	2.0	13.7	14.5	32.8	981,957.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	1	1.7	8.7	14.1	27.0	982,964.8	0.00	1.00
11/09/2022 01:00	1	1.7	8.7	14.1	26.6	984,374.5	0.00	1.00
11/09/2022 02:00	1	1.7	9.2	14.1	26.9	985,180.0	0.00	1.00
11/09/2022 03:00	1	1.7	8.9	14.1	26.9	985,582.8	0.00	1.00
11/09/2022 04:00	1	1.7	8.8	14.1	26.8	986,388.3	0.00	1.00
11/09/2022 05:00	1	1.7	8.7	14.1	27.1	987,193.9	0.00	1.00
11/09/2022 06:00	1	1.7	8.8	14.1	27.2	989,207.7	0.00	1.00
11/09/2022 07:00	1	1.7	8.8	14.1	27.5	988,805.0	0.00	1.00
11/09/2022 08:00	1	1.7	8.7	14.1	26.6	986,992.5	0.00	1.00
11/09/2022 09:00	1	1.7	8.8	14.2	25.7	893,804.9	0.00	1.00
11/09/2022 10:00	2	1.6	13.4	14.5	27.5	611,319.6	0.00	1.00
11/09/2022 11:00	2	1.6	13.1	14.5	26.6	615,385.1	0.00	1.00
11/09/2022 12:00	2	1.6	13.2	14.5	27.3	613,887.3	0.00	1.00
11/09/2022 13:00	2	1.6	13.0	14.5	26.7	613,887.3	0.00	1.00
11/09/2022 14:00	2	1.6	13.4	14.5	27.3	612,389.5	0.00	1.00
11/09/2022 15:00	2	1.6	13.6	14.5	26.8	609,821.8	0.00	1.00
11/09/2022 16:00	1	1.6	9.3	14.4	18.8	823,972.1	0.00	1.00
11/09/2022 17:00	1	1.7	7.6	14.4	22.5	977,979.7	0.00	1.00
11/09/2022 18:00	1	1.7	8.5	14.2	25.6	977,196.7	0.00	1.00
11/09/2022 19:00	1	1.7	8.7	14.1	26.6	989,610.5	0.00	1.00
11/09/2022 20:00	1	1.7	8.8	14.1	25.2	902,209.0	0.00	1.00
11/09/2022 21:00	2	1.7	10.5	14.3	25.5	658,568.6	0.00	1.00
11/09/2022 22:00	3	1.7	15.2	14.5	37.2	612,817.4	0.00	1.00
11/09/2022 23:00	2	1.6	13.6	14.4	29.0	614,134.2	0.00	1.00
Average/Sum#:	1	1.7	10.4	14.3	26.7	833,486.4	0.00 #	24.00 #
Minimum:	1	1.6	7.6	14.1	18.8	609,821.8	0.00	1.00
Maximum:	3	1.7	15.2	14.5	37.2	989,610.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2022 00:00	2	1.6	13.2	14.4	28.1	626,143.0	0.00	1.00
11/10/2022 01:00	3	1.7	14.4	14.4	33.7	611,816.7	0.00	1.00
11/10/2022 02:00	2	1.7	15.0	14.4	32.6	611,816.7	0.00	1.00
11/10/2022 03:00	1	1.7	11.7	14.2	23.5	680,828.7	0.00	1.00
11/10/2022 04:00	1	1.7	8.2	14.2	20.6	820,837.1	0.00	1.00
11/10/2022 05:00	1	1.7	8.2	14.2	23.5	900,958.6	0.00	1.00
11/10/2022 06:00	2	2.0	12.2	13.0	36.3	1,028,801.7	0.00	1.00
11/10/2022 07:00	1	1.8	9.3	14.0	29.6	1,004,443.0	0.00	1.00
11/10/2022 08:00	2	1.7	13.1	14.4	32.6	703,884.1	0.00	1.00
11/10/2022 09:00	1	1.6	8.7	14.2	20.1	742,555.0	0.00	1.00
11/10/2022 10:00	3	1.7	17.5	14.7	41.8	613,369.6	0.00	1.00
11/10/2022 11:00	3	1.6	16.5	14.6	36.3	606,242.0	0.00	1.00
11/10/2022 12:00	2	1.6	16.0	14.6	34.3	606,024.6	0.00	1.00
11/10/2022 13:00	2	1.6	15.7	14.6	33.8	605,372.5	0.00	1.00
11/10/2022 14:00	2	1.6	15.4	14.6	32.1	605,372.5	0.00	1.00
11/10/2022 15:00	1	1.6	11.5	14.4	20.8	779,307.8	0.00	1.00
11/10/2022 16:00	1	2.0	12.1	13.3	29.0	1,001,481.7	0.00	1.00
11/10/2022 17:00	1	2.0	12.0	13.3	31.4	1,000,400.5	0.00	1.00
11/10/2022 18:00	1	1.9	10.9	13.6	30.2	992,926.5	0.00	1.00
11/10/2022 19:00	1	1.8	10.0	13.8	29.4	1,002,380.1	0.00	1.00
11/10/2022 20:00	1	1.8	9.4	13.7	29.3	1,004,434.7	0.00	1.00
11/10/2022 21:00	1	1.9	10.5	13.3	31.9	1,003,824.1	0.00	1.00
11/10/2022 22:00	1	1.9	10.1	13.5	30.6	1,001,345.3	0.00	1.00
11/10/2022 23:00	1	1.8	9.3	13.8	28.2	994,665.0	0.00	1.00
Average/Sum#:	2	1.8	12.1	14.1	30.0	814,551.3	0.00 #	24.00 #
Minimum:	1	1.6	8.2	13.0	20.1	605,372.5	0.00	1.00
Maximum:	3	2.0	17.5	14.7	41.8	1,028,801.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2022 00:00	1	2.0	10.7	13.3	31.6	1,011,572.2	0.00	1.00
11/11/2022 01:00	1	1.9	10.2	13.4	31.1	998,949.4	0.00	1.00
11/11/2022 02:00	1	1.8	9.0	14.0	26.8	977,253.0	0.00	1.00
11/11/2022 03:00	1	1.7	7.7	14.3	22.8	915,024.5	0.00	1.00
11/11/2022 04:00	1	1.7	8.3	14.2	26.0	960,232.2	0.00	1.00
11/11/2022 05:00	2	1.9	11.3	13.3	34.5	1,016,076.9	0.00	1.00
11/11/2022 06:00	2	2.0	11.3	13.2	34.4	1,012,129.1	0.00	1.00
11/11/2022 07:00	1	1.7	9.0	14.0	27.7	963,558.8	0.00	1.00
11/11/2022 08:00	3	1.6	14.6	14.5	36.7	622,446.2	0.00	1.00
11/11/2022 09:00	2	1.6	13.4	14.5	27.1	620,092.5	0.00	1.00
11/11/2022 10:00	2	1.6	12.7	14.5	26.4	628,009.5	0.00	1.00
11/11/2022 11:00	2	1.6	12.5	14.5	25.7	619,664.5	0.00	1.00
11/11/2022 12:00	2	1.6	12.2	14.5	24.3	618,166.7	0.00	1.00
11/11/2022 13:00	2	1.6	12.1	14.5	23.5	619,022.6	0.00	1.00
11/11/2022 14:00	1	1.6	11.7	14.5	21.9	633,144.8	0.00	1.00
11/11/2022 15:00	1	1.7	8.9	14.0	17.9	885,164.2	0.00	1.00
11/11/2022 16:00	1	1.9	10.1	13.4	25.8	988,359.2	0.00	1.00
11/11/2022 17:00	1	1.9	9.4	13.7	26.2	992,262.1	0.00	1.00
11/11/2022 18:00	1	1.8	9.4	13.7	26.9	991,311.1	0.00	1.00
11/11/2022 19:00	1	1.8	9.3	13.7	27.4	988,838.5	0.00	1.00
11/11/2022 20:00	1	1.8	9.9	13.7	28.8	998,348.4	0.00	1.00
11/11/2022 21:00	1	2.0	10.8	13.2	31.3	994,877.9	0.00	1.00
11/11/2022 22:00	1	1.9	10.5	13.3	30.7	993,373.2	0.00	1.00
11/11/2022 23:00	1	1.8	9.4	13.7	28.6	1,001,962.2	0.00	1.00
Average/Sum#:	1	1.8	10.6	13.9	27.7	877,076.7	0.00 #	24.00 #
Minimum:	1	1.6	7.7	13.2	17.9	618,166.7	0.00	1.00
Maximum:	3	2.0	14.6	14.5	36.7	1,016,076.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2022 00:00	1	1.9	10.5	13.3	30.6	1,001,481.7	0.00	1.00
11/12/2022 01:00	1	1.9	10.6	13.3	30.9	1,001,301.5	0.00	1.00
11/12/2022 02:00	1	1.9	11.3	13.3	31.9	1,007,427.9	0.00	1.00
11/12/2022 03:00	2	2.0	11.8	13.0	33.5	1,001,759.9	0.00	1.00
11/12/2022 04:00	1	2.0	11.4	13.1	33.0	1,004,946.8	0.00	1.00
11/12/2022 05:00	1	2.0	11.2	13.1	32.4	998,626.4	0.00	1.00
11/12/2022 06:00	2	2.0	11.2	13.1	32.6	999,328.7	0.00	1.00
11/12/2022 07:00	1	1.8	9.0	14.0	26.6	995,908.9	0.00	1.00
11/12/2022 08:00	2	2.0	11.4	13.0	33.1	1,002,280.0	0.00	1.00
11/12/2022 09:00	1	1.9	9.7	13.6	28.3	1,002,868.9	0.00	1.00
11/12/2022 10:00	1	1.8	9.0	13.8	25.9	987,914.3	0.00	1.00
11/12/2022 11:00	1	1.7	8.3	14.1	22.3	952,152.7	0.00	1.00
11/12/2022 12:00	1	1.7	7.6	14.3	20.8	956,107.2	0.00	1.00
11/12/2022 13:00	1	1.7	7.5	14.4	19.7	959,229.1	0.00	1.00
11/12/2022 14:00	1	1.8	9.2	13.9	24.4	956,640.7	0.00	1.00
11/12/2022 15:00	1	1.8	9.4	13.7	25.0	974,193.3	0.00	1.00
11/12/2022 16:00	1	1.9	10.1	13.5	27.3	987,466.0	0.00	1.00
11/12/2022 17:00	1	1.9	9.9	13.5	28.4	982,099.4	0.00	1.00
11/12/2022 18:00	1	1.8	9.5	13.7	27.3	984,654.2	0.00	1.00
11/12/2022 19:00	1	1.9	10.6	13.4	29.5	984,524.8	0.00	1.00
11/12/2022 20:00	1	1.8	10.3	13.7	28.6	991,881.7	0.00	1.00
11/12/2022 21:00	1	1.9	10.6	13.6	29.9	990,112.6	0.00	1.00
11/12/2022 22:00	1	1.9	11.3	13.5	31.1	993,017.7	0.00	1.00
11/12/2022 23:00	1	1.8	9.7	13.8	27.4	994,857.9	0.00	1.00
Average/Sum#:	1	1.9	10.0	13.6	28.4	987,949.3	0.00 #	24.00 #
Minimum:	1	1.7	7.5	13.0	19.7	952,152.7	0.00	1.00
Maximum:	2	2.0	11.8	14.4	33.5	1,007,427.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2022 00:00	1	1.7	7.5	14.3	21.7	952,994.9	0.00	1.00
11/13/2022 01:00	1	1.7	7.5	14.3	22.0	929,963.6	0.00	1.00
11/13/2022 02:00	1	1.7	8.2	14.3	22.3	922,079.1	0.00	1.00
11/13/2022 03:00	1	1.7	8.9	14.3	25.8	965,029.2	0.00	1.00
11/13/2022 04:00	1	1.7	8.0	14.3	23.6	961,086.9	0.00	1.00
11/13/2022 05:00	1	1.7	7.8	14.3	24.0	961,294.4	0.00	1.00
11/13/2022 06:00	1	1.7	8.2	14.2	25.5	964,115.6	0.00	1.00
11/13/2022 07:00	1	1.8	9.9	13.7	30.5	999,109.2	0.00	1.00
11/13/2022 08:00	1	1.7	8.1	14.2	25.2	962,889.3	0.00	1.00
11/13/2022 09:00	1	1.9	10.4	13.5	30.5	1,000,790.1	0.00	1.00
11/13/2022 10:00	1	1.6	7.7	14.4	22.0	973,555.4	0.00	1.00
11/13/2022 11:00	1	1.7	7.5	14.4	20.8	957,965.0	0.00	1.00
11/13/2022 12:00	1	1.7	7.4	14.4	19.9	937,950.4	0.00	1.00
11/13/2022 13:00	1	1.7	7.4	14.4	19.0	915,196.8	0.00	1.00
11/13/2022 14:00	1	1.7	7.4	14.3	16.6	832,651.5	0.00	1.00
11/13/2022 15:00	1	1.6	7.9	14.4	17.5	823,761.4	0.00	1.00
11/13/2022 16:00	1	2.0	11.3	13.3	30.1	992,292.1	0.00	1.00
11/13/2022 17:00	1	2.0	11.4	13.2	30.1	998,968.4	0.00	1.00
11/13/2022 18:00	1	2.0	11.1	13.2	30.9	991,676.7	0.00	1.00
11/13/2022 19:00	1	1.9	10.2	13.5	28.3	992,832.7	0.00	1.00
11/13/2022 20:00	1	1.8	9.6	13.7	29.4	994,354.3	0.00	1.00
11/13/2022 21:00	2	2.0	11.0	13.2	33.0	999,502.0	0.00	1.00
11/13/2022 22:00	1	1.9	10.7	13.3	31.5	996,076.1	0.00	1.00
11/13/2022 23:00	1	1.9	10.5	13.4	30.8	995,845.4	0.00	1.00
Average/Sum#:	1	1.8	9.0	13.9	25.5	959,249.2	0.00 #	24.00 #
Minimum:	1	1.6	7.4	13.2	16.6	823,761.4	0.00	1.00
Maximum:	2	2.0	11.4	14.4	33.0	1,000,790.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2022 00:00	1	1.8	9.5	13.8	27.7	969,783.9	0.00	1.00
11/14/2022 01:00	1	1.7	8.3	14.3	24.6	959,219.5	0.00	1.00
11/14/2022 02:00	1	1.7	8.4	14.3	23.7	957,559.6	0.00	1.00
11/14/2022 03:00	1	1.7	8.0	14.3	23.1	907,762.4	0.00	1.00
11/14/2022 04:00	1	1.7	8.0	14.3	23.2	934,943.4	0.00	1.00
11/14/2022 05:00	2	1.9	11.1	13.4	34.1	1,009,904.8	0.00	1.00
11/14/2022 06:00	2	2.2	14.7	12.2	45.7	1,028,327.5	0.00	1.00
11/14/2022 07:00	2	2.0	12.6	12.9	39.0	1,020,734.7	0.00	1.00
11/14/2022 08:00	1	1.8	10.3	13.7	32.1	1,010,901.5	0.00	1.00
11/14/2022 09:00	1	1.8	9.6	13.8	28.3	967,662.3	0.00	1.00
11/14/2022 10:00	1	1.7	7.6	14.3	21.2	931,001.1	0.00	1.00
11/14/2022 11:00	1	1.7	7.8	14.3	19.8	849,043.1	0.00	1.00
11/14/2022 12:00	1	1.7	7.3	14.2	14.0	762,585.4	0.00	1.00
11/14/2022 13:00	1	1.7	7.2	14.3	17.7	848,835.6	0.00	1.00
11/14/2022 14:00	1	1.7	7.5	14.4	19.5	920,463.9	0.00	1.00
11/14/2022 15:00	1	1.8	9.0	13.9	24.1	918,688.1	0.00	1.00
11/14/2022 16:00	1	2.0	11.5	13.1	31.6	996,519.6	0.00	1.00
11/14/2022 17:00	1	2.0	12.0	13.0	33.0	1,008,000.4	0.00	1.00
11/14/2022 18:00	1	2.0	11.5	13.1	32.6	1,000,030.9	0.00	1.00
11/14/2022 19:00	2	1.9	10.9	13.3	32.6	1,004,004.3	0.00	1.00
11/14/2022 20:00	2	2.0	11.9	13.0	35.4	1,001,586.6	0.00	1.00
11/14/2022 21:00	2	2.0	11.6	13.1	34.3	1,001,259.9	0.00	1.00
11/14/2022 22:00	2	2.0	11.4	13.2	33.8	1,013,551.9	0.00	1.00
11/14/2022 23:00	1	1.9	10.2	13.5	32.0	1,003,380.9	0.00	1.00
Average/Sum#:	1	1.9	9.9	13.7	28.5	959,406.3	0.00 #	24.00 #
Minimum:	1	1.7	7.2	12.2	14.0	762,585.4	0.00	1.00
Maximum:	2	2.2	14.7	14.4	45.7	1,028,327.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	2	2.0	11.8	13.0	35.5	1,011,293.9	0.00	1.00
11/15/2022 01:00	2	2.0	11.9	13.0	36.3	1,015,974.2	0.00	1.00
11/15/2022 02:00	2	1.9	12.7	12.9	37.8	1,009,950.5	0.00	1.00
11/15/2022 03:00	2	2.0	12.0	13.1	35.4	1,021,099.0	0.00	1.00
11/15/2022 04:00	2	2.0	12.2	13.0	36.8	1,022,214.6	0.00	1.00
11/15/2022 05:00	2	2.0	12.2	13.0	36.8	1,024,121.4	0.00	1.00
11/15/2022 06:00	2	2.1	12.7	12.8	38.5	1,017,262.5	0.00	1.00
11/15/2022 07:00	2	2.0	12.1	13.0	36.8	1,020,654.5	0.00	1.00
11/15/2022 08:00	1	1.9	10.4	13.6	31.9	1,009,997.4	0.00	1.00
11/15/2022 09:00	1	1.7	8.2	14.2	22.5	902,185.0	0.00	1.00
11/15/2022 10:00	1	1.7	7.4	14.3	16.6	768,122.6	0.00	1.00
11/15/2022 11:00	1	1.7	9.3	14.4	20.8	692,507.4	0.00	1.00
11/15/2022 12:00	2	1.6	12.0	14.6	24.4	622,544.7	0.00	1.00
11/15/2022 13:00	2	1.6	12.1	14.6	23.8	618,632.0	0.00	1.00
11/15/2022 14:00	1	1.6	11.6	14.6	22.1	623,196.8	0.00	1.00
11/15/2022 15:00	1	1.6	10.2	14.4	18.7	790,684.6	0.00	1.00
11/15/2022 16:00	1	2.0	11.3	13.3	28.4	995,175.1	0.00	1.00
11/15/2022 17:00	1	2.0	11.7	13.1	31.5	997,221.9	0.00	1.00
11/15/2022 18:00	1	2.0	12.1	13.0	32.6	1,000,719.9	0.00	1.00
11/15/2022 19:00	1	2.0	11.2	13.3	31.7	1,008,869.4	0.00	1.00
11/15/2022 20:00	1	1.9	10.7	13.4	30.7	1,000,957.9	0.00	1.00
11/15/2022 21:00	1	1.9	11.0	13.3	32.1	1,000,220.4	0.00	1.00
11/15/2022 22:00	1	1.8	9.5	13.8	28.6	996,400.9	0.00	1.00
11/15/2022 23:00	1	1.8	10.0	13.8	28.5	1,006,044.7	0.00	1.00
Average/Sum#:	1	1.9	11.1	13.6	30.0	924,002.1	0.00 #	24.00 #
Minimum:	1	1.6	7.4	12.8	16.6	618,632.0	0.00	1.00
Maximum:	2	2.1	12.7	14.6	38.5	1,024,121.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	1	1.8	10.4	13.7	30.4	1,011,472.1	0.00	1.00
11/16/2022 01:00	1	1.9	10.5	13.6	31.5	1,000,805.4	0.00	1.00
11/16/2022 02:00	1	1.8	10.8	13.7	30.5	1,009,950.5	0.00	1.00
11/16/2022 03:00	1	1.9	10.6	13.7	31.2	1,010,330.9	0.00	1.00
11/16/2022 04:00	2	1.9	11.1	13.4	34.0	1,020,677.6	0.00	1.00
11/16/2022 05:00	2	1.9	11.3	13.3	35.6	1,023,464.5	0.00	1.00
11/16/2022 06:00	2	2.0	12.2	13.0	37.7	1,028,628.4	0.00	1.00
11/16/2022 07:00	2	2.0	11.4	13.2	36.0	1,011,773.4	0.00	1.00
11/16/2022 08:00	1	1.7	8.8	14.1	26.0	901,604.8	0.00	1.00
11/16/2022 09:00	1	1.7	7.4	14.3	18.3	838,668.7	0.00	1.00
11/16/2022 10:00	2	1.6	9.6	14.3	22.0	658,568.6	0.00	1.00
11/16/2022 11:00	1	1.5	11.8	14.5	23.1	632,502.9	0.00	1.00
11/16/2022 12:00	1	1.7	7.1	14.3	13.3	803,188.2	0.00	1.00
11/16/2022 13:00	1	1.7	7.5	14.3	14.5	751,316.0	0.00	1.00
11/16/2022 14:00	2	1.6	12.7	14.6	27.5	616,893.1	0.00	1.00
11/16/2022 15:00	1	1.6	8.7	14.4	16.6	843,986.8	0.00	1.00
11/16/2022 16:00	1	1.7	8.3	14.3	21.2	967,934.1	0.00	1.00
11/16/2022 17:00	1	1.7	8.7	14.1	23.2	970,478.8	0.00	1.00
11/16/2022 18:00	1	2.0	12.0	13.0	33.4	1,013,200.7	0.00	1.00
11/16/2022 19:00	2	2.0	11.9	12.9	33.4	998,139.2	0.00	1.00
11/16/2022 20:00	1	1.8	9.2	14.0	26.8	997,893.6	0.00	1.00
11/16/2022 21:00	2	2.0	11.8	13.0	34.8	1,018,921.1	0.00	1.00
11/16/2022 22:00	2	2.0	11.2	13.2	33.8	1,016,753.1	0.00	1.00
11/16/2022 23:00	1	1.9	10.6	13.4	31.2	999,314.6	0.00	1.00
Average/Sum#:	1	1.8	10.2	13.8	27.8	922,769.5	0.00 #	24.00 #
Minimum:	1	1.5	7.1	12.9	13.3	616,893.1	0.00	1.00
Maximum:	2	2.0	12.7	14.6	37.7	1,028,628.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2022 00:00	1	1.7	7.8	14.3	23.3	956,522.2	0.00	1.00
11/17/2022 01:00	1	1.7	7.8	14.3	23.9	959,427.0	0.00	1.00
11/17/2022 02:00	1	1.7	8.2	14.3	23.4	944,695.3	0.00	1.00
11/17/2022 03:00	1	1.7	8.2	14.3	24.7	946,562.7	0.00	1.00
11/17/2022 04:00	1	1.7	8.1	14.3	23.8	956,729.7	0.00	1.00
11/17/2022 05:00	1	1.7	7.9	14.3	24.3	957,352.1	0.00	1.00
11/17/2022 06:00	1	1.7	8.4	14.2	26.6	962,071.7	0.00	1.00
11/17/2022 07:00	1	1.8	10.3	13.8	31.4	1,007,202.0	0.00	1.00
11/17/2022 08:00	2	1.7	12.5	14.4	33.6	706,201.6	0.00	1.00
11/17/2022 09:00	1	1.6	7.6	14.3	16.0	922,909.0	0.00	1.00
11/17/2022 10:00	1	1.9	9.8	13.7	28.7	1,004,244.5	0.00	1.00
11/17/2022 11:00	1	1.7	7.9	14.3	21.5	952,164.9	0.00	1.00
11/17/2022 12:00	1	1.7	7.6	14.4	21.6	978,190.4	0.00	1.00
11/17/2022 13:00	1	1.8	9.8	13.6	26.3	982,421.3	0.00	1.00
11/17/2022 14:00	1	1.8	9.3	13.8	25.5	982,513.8	0.00	1.00
11/17/2022 15:00	1	1.9	10.5	13.4	28.1	989,089.6	0.00	1.00
11/17/2022 16:00	1	1.9	11.1	13.2	29.8	991,321.0	0.00	1.00
11/17/2022 17:00	1	2.0	11.9	13.0	32.2	997,253.0	0.00	1.00
11/17/2022 18:00	1	2.0	11.8	13.0	32.4	998,986.4	0.00	1.00
11/17/2022 19:00	2	2.0	11.8	13.0	33.8	1,004,186.8	0.00	1.00
11/17/2022 20:00	2	2.0	11.1	13.2	33.0	1,003,058.9	0.00	1.00
11/17/2022 21:00	1	1.9	10.4	13.4	31.1	993,836.9	0.00	1.00
11/17/2022 22:00	1	1.9	10.0	13.6	30.8	1,006,057.9	0.00	1.00
11/17/2022 23:00	1	1.8	9.6	13.7	30.2	1,007,477.9	0.00	1.00
Average/Sum#:	1	1.8	9.6	13.8	27.3	967,103.2	0.00 #	24.00 #
Minimum:	1	1.6	7.6	13.0	16.0	706,201.6	0.00	1.00
Maximum:	2	2.0	12.5	14.4	33.8	1,007,477.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2022 00:00	2	1.9	10.8	13.2	33.5	1,000,924.7	0.00	1.00
11/18/2022 01:00	1	1.9	10.2	13.5	31.5	1,010,043.0	0.00	1.00
11/18/2022 02:00	2	2.1	11.0	13.4	31.0	1,006,800.8	0.00	1.00
11/18/2022 03:00	2	2.0	11.6	13.1	35.6	1,009,511.6	0.00	1.00
11/18/2022 04:00	2	2.0	11.8	13.0	35.2	1,009,733.8	0.00	1.00
11/18/2022 05:00	2	2.1	12.2	12.8	37.6	1,019,122.2	0.00	1.00
11/18/2022 06:00	2	2.3	14.3	11.9	46.5	1,017,330.2	0.00	1.00
11/18/2022 07:00	2	2.0	12.1	12.8	37.4	1,007,625.8	0.00	1.00
11/18/2022 08:00	2	2.0	11.1	13.1	33.5	1,004,244.5	0.00	1.00
11/18/2022 09:00	1	1.9	10.4	13.4	31.2	1,006,800.8	0.00	1.00
11/18/2022 10:00	1	1.9	10.0	13.5	29.4	990,241.9	0.00	1.00
11/18/2022 11:00	1	1.9	9.9	13.6	28.0	984,297.2	0.00	1.00
11/18/2022 12:00	1	1.8	9.9	13.8	26.8	989,264.5	0.00	1.00
11/18/2022 13:00	1	1.8	10.2	13.7	26.7	981,611.0	0.00	1.00
11/18/2022 14:00	1	1.8	10.3	13.7	26.7	985,034.6	0.00	1.00
11/18/2022 15:00	1	1.9	11.0	13.4	28.5	982,151.2	0.00	1.00
11/18/2022 16:00	2	2.1	12.6	12.8	34.1	992,748.1	0.00	1.00
11/18/2022 17:00	2	2.1	13.2	12.6	36.5	996,710.0	0.00	1.00
11/18/2022 18:00	2	2.1	12.9	12.7	36.5	1,003,019.9	0.00	1.00
11/18/2022 19:00	2	2.0	12.3	12.9	35.6	1,003,103.4	0.00	1.00
11/18/2022 20:00	2	2.1	12.8	12.8	37.0	1,009,316.5	0.00	1.00
11/18/2022 21:00	2	2.1	12.7	12.8	37.1	1,009,147.4	0.00	1.00
11/18/2022 22:00	2	2.0	12.3	13.0	36.2	1,018,054.4	0.00	1.00
11/18/2022 23:00	2	2.0	11.6	13.2	34.8	1,014,974.7	0.00	1.00
Average/Sum#:	2	2.0	11.6	13.1	33.6	1,002,158.8	0.00 #	24.00 #
Minimum:	1	1.8	9.9	11.9	26.7	981,611.0	0.00	1.00
Maximum:	2	2.3	14.3	13.8	46.5	1,019,122.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2022 00:00	1	1.9	10.3	13.6	31.2	1,013,186.5	0.00	1.00
11/19/2022 01:00	1	1.9	10.1	13.6	31.4	1,009,997.4	0.00	1.00
11/19/2022 02:00	1	1.9	10.9	13.6	31.4	1,002,681.3	0.00	1.00
11/19/2022 03:00	1	1.8	10.3	13.9	32.0	1,023,938.2	0.00	1.00
11/19/2022 04:00	2	1.9	11.1	13.4	33.9	1,011,730.7	0.00	1.00
11/19/2022 05:00	2	2.0	11.6	13.2	35.7	1,021,732.9	0.00	1.00
11/19/2022 06:00	2	2.0	12.2	13.0	38.0	1,025,334.8	0.00	1.00
11/19/2022 07:00	2	2.0	12.0	13.1	37.5	1,022,854.7	0.00	1.00
11/19/2022 08:00	2	1.7	10.7	14.2	29.5	798,354.0	0.00	1.00
11/19/2022 09:00	2	1.6	14.9	14.5	33.9	615,385.1	0.00	1.00
11/19/2022 10:00	2	1.6	13.6	14.5	28.8	624,371.9	0.00	1.00
11/19/2022 11:00	2	1.6	13.0	14.5	27.4	625,227.8	0.00	1.00
11/19/2022 12:00	2	1.6	12.5	14.5	26.0	625,013.8	0.00	1.00
11/19/2022 13:00	2	1.6	11.8	14.5	23.9	624,371.9	0.00	1.00
11/19/2022 14:00	2	1.6	13.0	14.6	26.8	617,545.2	0.00	1.00
11/19/2022 15:00	1	1.6	10.7	14.5	19.6	739,489.2	0.00	1.00
11/19/2022 16:00	1	2.0	11.3	13.3	27.8	1,002,562.8	0.00	1.00
11/19/2022 17:00	1	1.9	10.6	13.5	28.8	1,005,786.7	0.00	1.00
11/19/2022 18:00	1	1.9	10.5	13.5	29.5	1,005,416.6	0.00	1.00
11/19/2022 19:00	2	2.0	11.8	13.1	34.9	1,011,442.8	0.00	1.00
11/19/2022 20:00	2	2.0	12.4	12.9	36.5	1,012,175.8	0.00	1.00
11/19/2022 21:00	2	2.0	12.3	12.9	36.2	1,008,752.2	0.00	1.00
11/19/2022 22:00	2	2.0	12.2	12.9	36.1	1,013,031.7	0.00	1.00
11/19/2022 23:00	2	2.0	12.2	12.9	37.0	1,020,905.9	0.00	1.00
Average/Sum#:	2	1.8	11.8	13.7	31.4	895,053.7	0.00 #	24.00 #
Minimum:	1	1.6	10.1	12.9	19.6	615,385.1	0.00	1.00
Maximum:	2	2.0	14.9	14.6	38.0	1,025,334.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2022 00:00	2	2.0	12.3	12.9	37.6	1,019,878.8	0.00	1.00
11/20/2022 01:00	2	2.0	12.4	12.9	38.1	1,025,698.9	0.00	1.00
11/20/2022 02:00	2	2.0	12.9	12.9	38.5	1,026,383.6	0.00	1.00
11/20/2022 03:00	2	2.1	12.6	12.9	38.6	1,025,356.5	0.00	1.00
11/20/2022 04:00	2	2.0	12.5	12.9	38.5	1,025,185.3	0.00	1.00
11/20/2022 05:00	2	2.0	12.0	13.0	36.9	1,021,867.9	0.00	1.00
11/20/2022 06:00	2	2.0	11.4	13.2	36.1	1,024,222.7	0.00	1.00
11/20/2022 07:00	2	1.9	10.1	13.6	32.7	1,011,498.1	0.00	1.00
11/20/2022 08:00	1	1.7	8.1	14.2	25.3	954,509.2	0.00	1.00
11/20/2022 09:00	1	1.7	8.3	14.3	26.6	999,887.3	0.00	1.00
11/20/2022 10:00	1	1.7	8.7	14.1	25.8	982,763.4	0.00	1.00
11/20/2022 11:00	1	1.7	8.6	14.1	24.6	975,916.3	0.00	1.00
11/20/2022 12:00	1	1.7	7.9	14.3	21.3	935,565.8	0.00	1.00
11/20/2022 13:00	1	1.8	9.8	13.8	26.1	995,629.4	0.00	1.00
11/20/2022 14:00	1	1.7	8.0	14.2	20.4	907,499.1	0.00	1.00
11/20/2022 15:00	1	1.7	8.0	14.2	19.0	850,882.6	0.00	1.00
11/20/2022 16:00	1	1.9	10.8	13.4	29.3	1,003,149.0	0.00	1.00
11/20/2022 17:00	1	1.9	10.5	13.4	28.7	998,584.3	0.00	1.00
11/20/2022 18:00	1	1.9	10.1	13.5	28.6	993,572.9	0.00	1.00
11/20/2022 19:00	1	1.9	10.4	13.6	29.4	1,005,495.2	0.00	1.00
11/20/2022 20:00	1	1.9	10.3	13.6	29.8	1,001,930.9	0.00	1.00
11/20/2022 21:00	1	1.8	10.0	13.8	29.5	1,006,623.4	0.00	1.00
11/20/2022 22:00	1	1.8	9.8	13.8	29.4	1,001,222.8	0.00	1.00
11/20/2022 23:00	1	1.8	9.4	13.9	29.4	1,000,266.7	0.00	1.00
Average/Sum#:	1	1.9	10.2	13.6	30.0	991,399.6	0.00 #	24.00 #
Minimum:	1	1.7	7.9	12.9	19.0	850,882.6	0.00	1.00
Maximum:	2	2.1	12.9	14.3	38.6	1,026,383.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	1	1.9	9.8	13.7	31.3	1,018,699.6	0.00	1.00
11/21/2022 01:00	1	1.8	9.6	13.8	31.1	1,004,887.5	0.00	1.00
11/21/2022 02:00	1	1.8	10.2	13.8	31.3	1,001,801.4	0.00	1.00
11/21/2022 03:00	1	1.9	10.5	13.6	31.9	1,004,182.0	0.00	1.00
11/21/2022 04:00	2	2.0	11.4	13.2	35.6	1,014,619.0	0.00	1.00
11/21/2022 05:00	2	1.9	11.1	13.3	35.4	1,025,086.2	0.00	1.00
11/21/2022 06:00	2	2.0	12.2	13.0	37.5	1,024,468.1	0.00	1.00
11/21/2022 07:00	2	1.8	9.8	13.7	32.2	995,495.4	0.00	1.00
11/21/2022 08:00	2	1.7	12.5	14.3	33.0	704,631.1	0.00	1.00
11/21/2022 09:00	2	1.6	14.8	14.5	32.8	618,380.7	0.00	1.00
11/21/2022 10:00	2	1.6	13.6	14.5	28.6	621,376.3	0.00	1.00
11/21/2022 11:00	2	1.6	12.6	14.5	25.7	626,297.7	0.00	1.00
11/21/2022 12:00	2	1.5	11.5	14.5	23.1	641,489.7	0.00	1.00
11/21/2022 13:00	2	1.6	12.3	14.5	24.3	621,162.3	0.00	1.00
11/21/2022 14:00	0	1.7	7.9	14.4	15.8	903,188.1	0.00	1.00
11/21/2022 15:00	1	1.9	11.4	13.3	30.1	970,129.1	0.00	1.00
11/21/2022 16:00	1	1.9	11.1	13.4	29.7	998,036.5	0.00	1.00
11/21/2022 17:00	1	1.9	10.8	13.4	30.2	995,115.1	0.00	1.00
11/21/2022 18:00	1	1.9	10.4	13.5	30.1	997,089.0	0.00	1.00
11/21/2022 19:00	1	1.9	10.3	13.5	31.1	999,494.7	0.00	1.00
11/21/2022 20:00	1	1.9	10.4	13.4	31.8	994,567.3	0.00	1.00
11/21/2022 21:00	2	1.9	10.9	13.3	33.1	1,003,103.4	0.00	1.00
11/21/2022 22:00	2	1.9	10.7	13.4	32.7	1,000,410.2	0.00	1.00
11/21/2022 23:00	1	1.8	9.7	13.7	30.1	992,642.5	0.00	1.00
Average/Sum#:	1	1.8	11.1	13.8	30.4	907,348.0	0.00 #	24.00 #
Minimum:	0	1.5	7.9	13.0	15.8	618,380.7	0.00	1.00
Maximum:	2	2.0	14.8	14.5	37.5	1,025,086.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	1	1.7	8.0	14.3	24.9	978,308.5	0.00	1.00
11/22/2022 01:00	1	1.7	8.1	14.3	25.2	965,029.2	0.00	1.00
11/22/2022 02:00	1	1.8	8.6	14.3	25.0	958,389.6	0.00	1.00
11/22/2022 03:00	1	1.7	8.4	14.2	25.6	892,782.9	0.00	1.00
11/22/2022 04:00	1	1.7	8.5	14.2	26.7	912,404.5	0.00	1.00
11/22/2022 05:00	1	1.7	8.5	14.3	26.4	946,355.2	0.00	1.00
11/22/2022 06:00	1	1.7	8.5	14.3	27.5	987,438.0	0.00	1.00
11/22/2022 07:00	2	1.7	12.0	14.3	32.7	727,869.8	0.00	1.00
11/22/2022 08:00	1	1.7	10.2	14.3	24.5	856,927.7	0.00	1.00
11/22/2022 09:00	1	1.9	10.8	13.6	30.6	1,009,247.0	0.00	1.00
11/22/2022 10:00	1	1.7	8.6	14.3	24.7	974,781.2	0.00	1.00
11/22/2022 11:00	1	1.8	10.0	13.9	27.4	998,114.7	0.00	1.00
11/22/2022 12:00	1	1.9	10.8	13.4	29.5	996,758.4	0.00	1.00
11/22/2022 13:00	1	1.9	11.1	13.3	30.0	993,012.9	0.00	1.00
11/22/2022 14:00	1	1.9	10.7	13.5	28.6	996,718.9	0.00	1.00
11/22/2022 15:00	1	1.8	10.1	13.6	27.5	981,670.9	0.00	1.00
11/22/2022 16:00	1	1.8	10.0	13.7	27.1	995,305.3	0.00	1.00
11/22/2022 17:00	1	1.8	10.0	13.9	26.8	993,810.8	0.00	1.00
11/22/2022 18:00	1	1.8	9.9	13.9	27.7	987,746.2	0.00	1.00
11/22/2022 19:00	1	1.8	9.8	13.9	28.1	984,811.8	0.00	1.00
11/22/2022 20:00	1	1.8	10.1	13.8	28.7	989,457.3	0.00	1.00
11/22/2022 21:00	1	1.7	9.1	14.1	25.0	913,688.0	0.00	1.00
11/22/2022 22:00	2	1.7	10.3	14.3	26.7	723,720.0	0.00	1.00
11/22/2022 23:00	2	1.6	12.6	14.4	27.3	633,095.4	0.00	1.00
Average/Sum#:	1	1.8	9.8	14.0	27.3	933,226.8	0.00 #	24.00 #
Minimum:	1	1.6	8.0	13.3	24.5	633,095.4	0.00	1.00
Maximum:	2	1.9	12.6	14.4	32.7	1,009,247.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2022 00:00	1	1.7	7.5	14.2	17.6	814,092.1	0.00	1.00
11/23/2022 01:00	1	1.7	8.5	14.1	21.0	729,419.9	0.00	1.00
11/23/2022 02:00	1	1.9	8.2	14.2	20.2	793,857.4	0.00	1.00
11/23/2022 03:00	1	1.7	7.9	14.2	21.9	821,245.8	0.00	1.00
11/23/2022 04:00	1	1.7	7.6	14.2	22.3	844,546.5	0.00	1.00
11/23/2022 05:00	1	1.7	7.7	14.3	23.9	912,949.6	0.00	1.00
11/23/2022 06:00	1	1.7	7.8	14.2	24.3	904,024.5	0.00	1.00
11/23/2022 07:00	2	1.7	9.0	14.1	23.8	716,329.8	0.00	1.00
11/23/2022 08:00	3	1.6	13.9	14.4	34.8	642,997.4	0.00	1.00
11/23/2022 09:00	1	1.6	10.7	14.3	21.9	683,882.2	0.00	1.00
11/23/2022 10:00	1	1.6	9.8	14.3	19.8	716,665.4	0.00	1.00
11/23/2022 11:00	1	1.7	8.1	14.1	19.7	909,056.1	0.00	1.00
11/23/2022 12:00	1	1.8	9.6	13.8	24.9	986,757.1	0.00	1.00
11/23/2022 13:00	1	1.7	8.6	14.0	21.1	887,148.8	0.00	1.00
11/23/2022 14:00	2	1.6	11.9	14.5	25.4	617,310.8	0.00	1.00
11/23/2022 15:00	1	1.6	10.3	14.5	18.5	737,563.4	0.00	1.00
11/23/2022 16:00	1	1.9	10.4	13.4	25.7	979,594.9	0.00	1.00
11/23/2022 17:00	1	1.9	10.0	13.5	26.4	986,725.8	0.00	1.00
11/23/2022 18:00	1	1.8	9.2	13.8	24.6	979,427.7	0.00	1.00
11/23/2022 19:00	1	1.8	9.3	13.9	25.3	986,181.2	0.00	1.00
11/23/2022 20:00	1	1.8	9.7	13.8	27.4	997,172.4	0.00	1.00
11/23/2022 21:00	1	1.9	10.4	13.5	29.3	995,608.5	0.00	1.00
11/23/2022 22:00	1	1.9	10.3	13.6	29.7	1,007,558.7	0.00	1.00
11/23/2022 23:00	1	1.8	9.5	13.7	29.0	994,164.1	0.00	1.00
Average/Sum#:	1	1.7	9.4	14.0	24.1	860,178.3	0.00 #	24.00 #
Minimum:	1	1.6	7.5	13.4	17.6	617,310.8	0.00	1.00
Maximum:	3	1.9	13.9	14.5	34.8	1,007,558.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2022 00:00	1	1.8	10.1	13.6	29.9	1,000,617.8	0.00	1.00
11/24/2022 01:00	1	1.8	9.9	13.7	29.4	995,495.4	0.00	1.00
11/24/2022 02:00	1	1.5	8.2	14.2	24.0	888,899.5	0.00	1.00
11/24/2022 03:00	1	1.7	8.0	14.3	23.5	917,514.3	0.00	1.00
11/24/2022 04:00	1	1.7	7.9	14.3	23.5	918,344.3	0.00	1.00
11/24/2022 05:00	1	1.7	7.8	14.3	24.7	963,161.8	0.00	1.00
11/24/2022 06:00	1	1.7	8.2	14.2	27.0	973,722.1	0.00	1.00
11/24/2022 07:00	2	1.9	10.4	13.5	33.1	1,000,049.9	0.00	1.00
11/24/2022 08:00	1	1.8	10.1	13.7	31.0	1,007,668.1	0.00	1.00
11/24/2022 09:00	1	1.9	10.4	13.6	29.6	1,005,682.8	0.00	1.00
11/24/2022 10:00	1	1.9	10.3	13.5	27.9	997,459.1	0.00	1.00
11/24/2022 11:00	1	1.8	9.3	13.8	26.0	992,736.2	0.00	1.00
11/24/2022 12:00	1	1.8	9.3	13.8	25.4	994,086.4	0.00	1.00
11/24/2022 13:00	1	1.8	9.3	13.7	25.1	979,518.8	0.00	1.00
11/24/2022 14:00	1	1.6	9.7	14.5	21.3	718,733.8	0.00	1.00
11/24/2022 15:00	1	1.7	9.8	14.2	19.5	766,673.3	0.00	1.00
11/24/2022 16:00	1	1.9	10.2	13.4	26.2	987,263.7	0.00	1.00
11/24/2022 17:00	1	1.8	9.3	13.7	25.4	985,224.8	0.00	1.00
11/24/2022 18:00	1	1.8	9.1	13.8	25.3	981,163.6	0.00	1.00
11/24/2022 19:00	1	1.8	9.1	13.9	25.7	990,876.4	0.00	1.00
11/24/2022 20:00	1	1.8	9.0	13.9	26.4	989,702.6	0.00	1.00
11/24/2022 21:00	1	1.8	9.0	13.9	25.6	986,963.7	0.00	1.00
11/24/2022 22:00	1	1.8	9.3	13.9	26.8	998,310.4	0.00	1.00
11/24/2022 23:00	1	1.8	8.9	14.0	27.8	991,939.6	0.00	1.00
Average/Sum#:	1	1.8	9.3	13.9	26.3	959,658.7	0.00 #	24.00 #
Minimum:	1	1.5	7.8	13.4	19.5	718,733.8	0.00	1.00
Maximum:	2	1.9	10.4	14.5	33.1	1,007,668.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2022 00:00	1	1.8	9.1	14.0	28.1	989,954.9	0.00	1.00
11/25/2022 01:00	1	1.7	9.0	14.1	28.1	1,000,686.7	0.00	1.00
11/25/2022 02:00	1	1.8	9.3	14.1	27.4	1,000,888.1	0.00	1.00
11/25/2022 03:00	1	1.8	9.5	13.9	28.9	992,050.2	0.00	1.00
11/25/2022 04:00	1	1.8	9.9	13.8	30.3	1,008,359.3	0.00	1.00
11/25/2022 05:00	1	1.8	9.9	13.8	30.3	1,014,724.2	0.00	1.00
11/25/2022 06:00	1	1.8	10.3	13.6	30.6	1,006,808.3	0.00	1.00
11/25/2022 07:00	1	1.8	9.7	13.8	30.4	1,000,837.1	0.00	1.00
11/25/2022 08:00	1	1.7	9.0	14.1	28.6	1,002,700.6	0.00	1.00
11/25/2022 09:00	2	1.7	12.2	14.4	30.0	706,201.6	0.00	1.00
11/25/2022 10:00	2	1.6	14.3	14.5	31.0	609,393.9	0.00	1.00
11/25/2022 11:00	2	1.6	15.5	14.6	33.2	606,242.0	0.00	1.00
11/25/2022 12:00	2	1.6	15.0	14.6	31.1	605,372.5	0.00	1.00
11/25/2022 13:00	2	1.6	13.8	14.6	26.8	607,763.6	0.00	1.00
11/25/2022 14:00	1	1.6	12.2	14.6	22.7	618,414.7	0.00	1.00
11/25/2022 15:00	1	1.6	10.1	14.5	16.9	743,126.7	0.00	1.00
11/25/2022 16:00	1	1.9	10.1	13.6	23.4	981,670.9	0.00	1.00
11/25/2022 17:00	1	1.9	9.9	13.6	25.9	982,984.1	0.00	1.00
11/25/2022 18:00	1	1.8	9.3	13.9	26.0	993,223.9	0.00	1.00
11/25/2022 19:00	1	1.8	9.4	13.9	26.7	985,203.0	0.00	1.00
11/25/2022 20:00	1	1.8	9.3	13.9	27.2	982,659.8	0.00	1.00
11/25/2022 21:00	1	1.8	9.4	13.9	27.2	985,789.9	0.00	1.00
11/25/2022 22:00	1	1.8	10.1	13.7	28.6	996,446.4	0.00	1.00
11/25/2022 23:00	1	1.8	10.0	13.8	28.9	995,050.8	0.00	1.00
Average/Sum#:	1	1.7	10.7	14.1	27.8	892,356.4	0.00 #	24.00 #
Minimum:	1	1.6	9.0	13.6	16.9	605,372.5	0.00	1.00
Maximum:	2	1.9	15.5	14.6	33.2	1,014,724.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2022 00:00	1	1.9	10.5	13.6	29.8	1,009,059.4	0.00	1.00
11/26/2022 01:00	1	1.9	10.3	13.6	30.0	1,003,619.2	0.00	1.00
11/26/2022 02:00	1	1.8	10.8	13.6	30.4	1,005,682.8	0.00	1.00
11/26/2022 03:00	1	1.9	10.6	13.6	30.5	1,009,434.6	0.00	1.00
11/26/2022 04:00	1	1.9	10.5	13.6	30.8	1,009,809.8	0.00	1.00
11/26/2022 05:00	2	2.0	11.6	13.2	33.8	1,018,709.5	0.00	1.00
11/26/2022 06:00	2	2.0	11.8	13.0	34.0	1,018,921.1	0.00	1.00
11/26/2022 07:00	1	1.9	10.0	13.6	30.4	1,009,434.6	0.00	1.00
11/26/2022 08:00	1	1.7	8.0	14.2	24.7	961,662.9	0.00	1.00
11/26/2022 09:00	1	1.8	9.9	13.7	28.1	997,207.2	0.00	1.00
11/26/2022 10:00	1	1.6	7.7	14.3	18.0	815,430.0	0.00	1.00
11/26/2022 11:00	2	1.6	12.7	14.6	26.8	620,588.4	0.00	1.00
11/26/2022 12:00	2	1.6	11.7	14.5	23.1	615,171.1	0.00	1.00
11/26/2022 13:00	2	1.6	13.4	14.6	27.1	603,633.6	0.00	1.00
11/26/2022 14:00	1	1.6	12.4	14.6	22.7	612,980.4	0.00	1.00
11/26/2022 15:00	1	1.6	9.1	14.5	16.3	791,912.4	0.00	1.00
11/26/2022 16:00	1	1.9	10.0	13.6	24.2	962,724.1	0.00	1.00
11/26/2022 17:00	1	1.9	9.7	13.6	25.2	976,981.1	0.00	1.00
11/26/2022 18:00	1	1.8	9.4	13.8	25.2	983,092.4	0.00	1.00
11/26/2022 19:00	1	1.8	9.5	13.9	26.4	989,115.7	0.00	1.00
11/26/2022 20:00	1	1.8	10.0	13.7	27.9	997,968.0	0.00	1.00
11/26/2022 21:00	1	1.9	10.3	13.6	29.1	994,990.0	0.00	1.00
11/26/2022 22:00	1	1.8	9.4	13.9	26.8	989,898.2	0.00	1.00
11/26/2022 23:00	1	1.8	9.5	13.9	27.8	996,941.0	0.00	1.00
Average/Sum#:	1	1.8	10.4	13.9	27.0	916,457.0	0.00 #	24.00 #
Minimum:	1	1.6	7.7	13.0	16.3	603,633.6	0.00	1.00
Maximum:	2	2.0	13.4	14.6	34.0	1,018,921.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2022 00:00	1	1.9	10.6	13.5	30.3	1,005,231.5	0.00	1.00
11/27/2022 01:00	1	1.8	10.0	13.7	29.0	1,002,152.4	0.00	1.00
11/27/2022 02:00	1	1.7	10.0	13.9	28.9	995,767.2	0.00	1.00
11/27/2022 03:00	1	1.9	10.6	13.6	30.7	1,004,932.4	0.00	1.00
11/27/2022 04:00	1	1.9	10.6	13.5	30.3	997,459.1	0.00	1.00
11/27/2022 05:00	1	1.8	9.8	13.8	28.2	997,365.3	0.00	1.00
11/27/2022 06:00	1	1.9	10.3	13.6	30.2	1,003,056.5	0.00	1.00
11/27/2022 07:00	2	1.7	9.2	14.0	28.2	892,904.4	0.00	1.00
11/27/2022 08:00	2	1.6	14.3	14.5	31.1	613,031.4	0.00	1.00
11/27/2022 09:00	2	1.6	14.4	14.6	31.4	616,675.7	0.00	1.00
11/27/2022 10:00	1	1.6	12.4	14.5	23.4	619,878.5	0.00	1.00
11/27/2022 11:00	2	1.6	12.6	14.5	25.6	608,751.9	0.00	1.00
11/27/2022 12:00	2	1.6	13.6	14.6	27.5	604,503.0	0.00	1.00
11/27/2022 13:00	2	1.6	13.6	14.6	27.2	604,937.8	0.00	1.00
11/27/2022 14:00	2	1.6	13.6	14.6	27.1	604,503.0	0.00	1.00
11/27/2022 15:00	1	1.6	9.5	14.2	17.0	843,115.8	0.00	1.00
11/27/2022 16:00	1	1.9	10.1	13.6	24.0	987,111.1	0.00	1.00
11/27/2022 17:00	1	1.9	10.3	13.4	27.8	987,263.7	0.00	1.00
11/27/2022 18:00	1	1.9	10.2	13.5	28.7	995,053.4	0.00	1.00
11/27/2022 19:00	1	1.9	9.9	13.5	29.2	984,320.0	0.00	1.00
11/27/2022 20:00	1	1.8	9.5	13.7	27.8	990,169.9	0.00	1.00
11/27/2022 21:00	1	1.9	10.7	13.3	30.6	995,355.3	0.00	1.00
11/27/2022 22:00	1	1.8	9.4	13.8	26.3	984,442.5	0.00	1.00
11/27/2022 23:00	1	1.8	9.3	13.9	27.4	984,811.8	0.00	1.00
Average/Sum#:	1	1.8	11.0	13.9	27.8	871,783.1	0.00 #	24.00 #
Minimum:	1	1.6	9.2	13.3	17.0	604,503.0	0.00	1.00
Maximum:	2	1.9	14.4	14.6	31.4	1,005,231.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	1	1.8	9.9	13.7	28.0	991,501.3	0.00	1.00
11/28/2022 01:00	1	1.8	9.6	13.8	27.5	985,214.0	0.00	1.00
11/28/2022 02:00	1	1.8	9.6	14.0	27.4	990,351.8	0.00	1.00
11/28/2022 03:00	1	1.8	9.5	13.9	28.2	983,442.3	0.00	1.00
11/28/2022 04:00	1	1.8	9.2	14.0	27.9	989,161.0	0.00	1.00
11/28/2022 05:00	1	1.8	9.6	13.8	29.2	990,036.0	0.00	1.00
11/28/2022 06:00	1	1.9	11.1	13.3	33.2	1,008,148.6	0.00	1.00
11/28/2022 07:00	2	2.0	11.4	13.2	33.8	1,005,904.5	0.00	1.00
11/28/2022 08:00	1	1.8	9.3	13.9	27.8	983,051.1	0.00	1.00
11/28/2022 09:00	2	1.7	9.9	14.2	25.2	790,995.9	0.00	1.00
11/28/2022 10:00	2	1.6	12.1	14.5	24.6	622,232.2	0.00	1.00
11/28/2022 11:00	2	1.6	12.8	14.5	26.6	607,682.1	0.00	1.00
11/28/2022 12:00	2	1.6	14.0	14.6	28.7	602,981.5	0.00	1.00
11/28/2022 13:00	2	1.6	14.1	14.6	27.9	605,155.2	0.00	1.00
11/28/2022 14:00	2	1.6	13.1	14.6	25.0	609,067.8	0.00	1.00
11/28/2022 15:00	1	1.7	10.4	14.2	19.9	768,512.8	0.00	1.00
11/28/2022 16:00	1	1.9	10.0	13.6	24.1	983,546.9	0.00	1.00
11/28/2022 17:00	1	1.9	10.1	13.7	26.6	989,979.7	0.00	1.00
11/28/2022 18:00	1	1.8	9.6	13.9	25.6	989,115.7	0.00	1.00
11/28/2022 19:00	1	1.8	9.5	13.9	25.7	989,506.9	0.00	1.00
11/28/2022 20:00	1	1.8	9.8	13.7	26.8	992,642.5	0.00	1.00
11/28/2022 21:00	1	1.9	10.8	13.3	30.8	997,157.2	0.00	1.00
11/28/2022 22:00	1	1.8	9.5	13.8	27.8	992,157.6	0.00	1.00
11/28/2022 23:00	1	1.8	9.1	14.0	28.3	988,764.1	0.00	1.00
Average/Sum#:	1	1.8	10.6	13.9	27.4	894,012.9	0.00 #	24.00 #
Minimum:	1	1.6	9.1	13.2	19.9	602,981.5	0.00	1.00
Maximum:	2	2.0	14.1	14.6	33.8	1,008,148.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2022 00:00	1	1.7	8.0	14.3	23.9	966,066.7	0.00	1.00
11/29/2022 01:00	1	1.7	8.2	14.3	25.2	979,553.4	0.00	1.00
11/29/2022 02:00	1	1.7	8.6	14.3	25.5	979,553.4	0.00	1.00
11/29/2022 03:00	1	1.7	8.2	14.3	24.5	933,698.4	0.00	1.00
11/29/2022 04:00	1	1.7	8.1	14.3	24.4	944,487.8	0.00	1.00
11/29/2022 05:00	1	1.7	8.3	14.3	26.2	989,927.8	0.00	1.00
11/29/2022 06:00	1	1.7	9.0	14.2	29.1	985,985.6	0.00	1.00
11/29/2022 07:00	2	2.2	14.6	12.3	46.7	1,025,953.6	0.00	1.00
11/29/2022 08:00	1	1.8	10.3	13.7	28.6	932,159.6	0.00	1.00
11/29/2022 09:00	1	1.7	7.9	14.3	23.2	954,239.8	0.00	1.00
11/29/2022 10:00	1	1.7	7.8	14.3	22.7	954,654.8	0.00	1.00
11/29/2022 11:00	1	1.7	7.9	14.4	22.4	973,766.1	0.00	1.00
11/29/2022 12:00	1	1.6	8.9	14.3	20.2	795,718.6	0.00	1.00
11/29/2022 13:00	1	1.6	7.8	14.4	20.4	965,338.9	0.00	1.00
11/29/2022 14:00	2	1.7	13.0	12.8	41.1	1,002,723.0	0.00	1.00
11/29/2022 15:00	2	1.8	13.0	12.8	36.0	998,834.5	0.00	1.00
11/29/2022 16:00	2	1.8	13.3	12.7	37.7	1,002,852.9	0.00	1.00
11/29/2022 17:00	2	1.8	12.8	12.8	37.2	1,003,061.1	0.00	1.00
11/29/2022 18:00	2	1.8	12.6	12.8	37.5	1,001,032.3	0.00	1.00
11/29/2022 19:00	2	1.8	12.7	12.8	38.5	1,006,273.3	0.00	1.00
11/29/2022 20:00	2	1.8	12.9	12.8	38.6	1,014,219.4	0.00	1.00
11/29/2022 21:00	2	1.8	12.9	12.8	38.2	1,007,456.8	0.00	1.00
11/29/2022 22:00	2	1.8	12.4	12.9	36.7	1,003,788.1	0.00	1.00
11/29/2022 23:00	1	1.8	11.2	13.3	32.6	1,000,941.1	0.00	1.00
Average/Sum#:	1	1.8	10.4	13.6	30.7	975,928.6	0.00 #	24.00 #
Minimum:	1	1.6	7.8	12.3	20.2	795,718.6	0.00	1.00
Maximum:	2	2.2	14.6	14.4	46.7	1,025,953.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	1	1.7	8.1	14.3	23.2	980,590.9	0.00	1.00
11/30/2022 01:00	1	1.7	8.2	14.3	24.4	984,740.6	0.00	1.00
11/30/2022 02:00	1	1.7	8.7	14.3	25.2	986,193.0	0.00	1.00
11/30/2022 03:00	1	1.7	8.8	14.3	26.2	984,740.6	0.00	1.00
11/30/2022 04:00	1	1.7	8.3	14.3	24.8	983,703.2	0.00	1.00
11/30/2022 05:00	1	1.7	8.7	14.2	27.5	978,218.7	0.00	1.00
11/30/2022 06:00	2	2.1	13.2	12.8	38.4	1,016,248.1	0.00	1.00
11/30/2022 07:00	1	1.8	10.3	13.7	30.9	988,838.5	0.00	1.00
11/30/2022 08:00	2	1.7	10.8	14.2	28.5	787,725.6	0.00	1.00
11/30/2022 09:00	1	1.6	9.3	14.3	18.2	728,284.8	0.00	1.00
11/30/2022 10:00	2	1.6	12.6	14.5	25.9	621,804.3	0.00	1.00
11/30/2022 11:00	2	1.6	14.3	14.6	30.1	611,458.9	0.00	1.00
11/30/2022 12:00	2	1.6	13.9	14.6	26.5	609,285.2	0.00	1.00
11/30/2022 13:00	2	1.6	13.7	14.6	26.6	612,545.7	0.00	1.00
11/30/2022 14:00	0	1.6	7.8	14.3	12.9	815,637.5	0.00	1.00
11/30/2022 15:00	1	1.7	8.9	14.2	18.9	836,370.8	0.00	1.00
11/30/2022 16:00	1	1.9	10.8	13.4	26.8	989,089.6	0.00	1.00
11/30/2022 17:00	1	1.9	10.6	13.4	27.2	992,011.0	0.00	1.00
11/30/2022 18:00	1	1.9	10.5	13.4	27.4	986,715.9	0.00	1.00
11/30/2022 19:00	1	1.9	10.5	13.4	27.6	988,541.8	0.00	1.00
11/30/2022 20:00	1	1.9	10.2	13.5	27.1	991,907.4	0.00	1.00
11/30/2022 21:00	1	1.9	10.0	13.5	26.8	981,174.1	0.00	1.00
11/30/2022 22:00	1	1.8	9.0	13.9	23.5	954,293.2	0.00	1.00
11/30/2022 23:00	2	1.6	11.5	14.4	23.6	649,528.5	0.00	1.00
Average/Sum#:	1	1.7	10.4	14.0	25.8	877,485.3	0.00 #	24.00 #
Minimum:	0	1.6	7.8	12.8	12.9	609,285.2	0.00	1.00
Maximum:	2	2.1	14.3	14.6	38.4	1,016,248.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022 00:00	1	1.7	7.3	14.2	15.9	828,399.6	0.00	1.00
12/01/2022 01:00	1	1.7	7.2	14.2	17.4	824,311.7	0.00	1.00
12/01/2022 02:00	1	1.8	7.9	14.3	18.4	866,057.2	0.00	1.00
12/01/2022 03:00	1	1.7	7.6	14.3	19.2	873,526.8	0.00	1.00
12/01/2022 04:00	1	1.7	8.2	14.3	22.5	932,661.0	0.00	1.00
12/01/2022 05:00	1	1.9	10.7	13.4	29.8	985,255.2	0.00	1.00
12/01/2022 06:00	1	1.9	11.0	13.3	29.9	984,363.9	0.00	1.00
12/01/2022 07:00	1	1.8	9.4	13.8	26.8	985,599.8	0.00	1.00
12/01/2022 08:00	1	2.0	11.5	13.0	31.7	992,226.0	0.00	1.00
12/01/2022 09:00	2	2.2	13.1	12.5	36.4	999,842.8	0.00	1.00
12/01/2022 10:00	1	2.0	12.2	12.9	33.1	992,661.5	0.00	1.00
12/01/2022 11:00	1	2.0	11.7	13.0	31.7	989,105.8	0.00	1.00
12/01/2022 12:00	1	2.0	11.3	13.1	31.1	990,901.4	0.00	1.00
12/01/2022 13:00	1	2.1	12.2	12.8	33.0	989,874.0	0.00	1.00
12/01/2022 14:00	1	2.1	12.1	12.8	32.8	992,071.9	0.00	1.00
12/01/2022 15:00	1	1.9	10.1	13.4	28.3	984,342.2	0.00	1.00
12/01/2022 16:00	1	1.8	9.5	13.7	27.0	977,426.7	0.00	1.00
12/01/2022 17:00	1	1.8	9.9	13.7	28.2	991,120.9	0.00	1.00
12/01/2022 18:00	1	1.8	9.5	13.8	27.2	974,605.8	0.00	1.00
12/01/2022 19:00	1	1.8	9.8	13.8	28.1	994,665.0	0.00	1.00
12/01/2022 20:00	1	1.8	9.4	13.9	27.2	986,572.5	0.00	1.00
12/01/2022 21:00	1	1.8	9.2	13.9	27.3	980,312.2	0.00	1.00
12/01/2022 22:00	1	1.8	9.4	13.9	27.4	985,985.6	0.00	1.00
12/01/2022 23:00	1	1.8	9.1	14.0	27.1	987,771.8	0.00	1.00
Average/Sum#:	1	1.9	10.0	13.6	27.4	962,069.2	0.00 #	24.00 #
Minimum:	1	1.7	7.2	12.5	15.9	824,311.7	0.00	1.00
Maximum:	2	2.2	13.1	14.3	36.4	999,842.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2022 00:00	1	1.8	9.1	14.0	27.3	985,191.7	0.00	1.00
12/02/2022 01:00	1	1.7	9.0	14.0	26.9	982,611.6	0.00	1.00
12/02/2022 02:00	1	1.8	9.8	14.0	27.9	989,954.9	0.00	1.00
12/02/2022 03:00	1	1.8	10.0	13.9	30.0	1,005,157.5	0.00	1.00
12/02/2022 04:00	1	1.8	9.8	13.9	29.5	996,549.7	0.00	1.00
12/02/2022 05:00	1	1.8	10.1	13.8	30.1	1,002,573.0	0.00	1.00
12/02/2022 06:00	1	1.9	11.0	13.5	32.5	1,011,893.6	0.00	1.00
12/02/2022 07:00	2	2.1	13.0	12.8	38.8	1,017,431.6	0.00	1.00
12/02/2022 08:00	1	1.9	10.8	13.5	32.8	1,009,487.8	0.00	1.00
12/02/2022 09:00	1	1.9	10.5	13.5	32.0	1,008,562.6	0.00	1.00
12/02/2022 10:00	1	1.9	10.5	13.4	30.7	1,004,974.9	0.00	1.00
12/02/2022 11:00	1	1.9	10.3	13.5	29.4	1,008,007.4	0.00	1.00
12/02/2022 12:00	1	1.9	10.4	13.5	29.8	1,013,189.0	0.00	1.00
12/02/2022 13:00	1	2.0	12.1	13.0	33.1	1,011,987.3	0.00	1.00
12/02/2022 14:00	2	2.1	12.9	12.7	35.1	1,004,188.9	0.00	1.00
12/02/2022 15:00	1	2.1	12.9	12.8	34.6	1,008,809.3	0.00	1.00
12/02/2022 16:00	1	2.0	12.2	12.9	33.5	1,000,022.2	0.00	1.00
12/02/2022 17:00	2	2.1	12.6	12.8	34.7	1,004,751.7	0.00	1.00
12/02/2022 18:00	2	2.0	12.4	12.9	34.3	1,008,752.2	0.00	1.00
12/02/2022 19:00	2	2.1	12.5	12.9	35.5	1,017,653.5	0.00	1.00
12/02/2022 20:00	2	2.1	13.3	12.6	38.1	1,014,034.0	0.00	1.00
12/02/2022 21:00	2	2.0	12.2	12.9	35.1	1,009,265.8	0.00	1.00
12/02/2022 22:00	2	2.0	12.0	13.0	34.9	1,012,854.0	0.00	1.00
12/02/2022 23:00	1	1.9	10.3	13.5	31.0	1,005,416.6	0.00	1.00
Average/Sum#:	1	1.9	11.2	13.3	32.4	1,005,555.0	0.00 #	24.00 #
Minimum:	1	1.7	9.0	12.6	26.9	982,611.6	0.00	1.00
Maximum:	2	2.1	13.3	14.0	38.8	1,017,653.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2022 00:00	1	1.9	10.4	13.5	31.4	1,010,228.1	0.00	1.00
12/03/2022 01:00	1	1.9	10.0	13.6	30.6	1,010,747.8	0.00	1.00
12/03/2022 02:00	1	1.7	11.1	13.6	31.5	1,001,555.7	0.00	1.00
12/03/2022 03:00	1	1.9	10.9	13.5	30.5	1,003,010.8	0.00	1.00
12/03/2022 04:00	1	1.9	11.0	13.4	31.4	1,011,000.4	0.00	1.00
12/03/2022 05:00	1	2.0	11.0	13.2	32.2	1,000,924.7	0.00	1.00
12/03/2022 06:00	2	2.0	11.1	13.2	32.9	1,010,706.3	0.00	1.00
12/03/2022 07:00	2	2.1	13.1	12.6	37.5	1,018,818.7	0.00	1.00
12/03/2022 08:00	2	2.0	12.0	12.9	34.0	1,013,887.6	0.00	1.00
12/03/2022 09:00	2	2.0	11.9	12.9	33.8	1,011,319.9	0.00	1.00
12/03/2022 10:00	1	2.0	11.0	13.2	31.4	1,010,706.3	0.00	1.00
12/03/2022 11:00	1	1.9	9.9	13.5	28.9	998,569.5	0.00	1.00
12/03/2022 12:00	1	1.9	9.8	13.5	28.7	995,608.5	0.00	1.00
12/03/2022 13:00	1	1.9	9.8	13.5	28.7	995,978.7	0.00	1.00
12/03/2022 14:00	1	1.9	10.2	13.4	29.6	1,000,045.0	0.00	1.00
12/03/2022 15:00	1	2.0	11.2	13.1	32.2	1,003,191.1	0.00	1.00
12/03/2022 16:00	1	2.0	10.8	13.2	30.6	998,612.7	0.00	1.00
12/03/2022 17:00	2	1.8	10.3	13.6	28.5	890,501.0	0.00	1.00
12/03/2022 18:00	3	1.7	14.8	14.5	33.9	602,760.7	0.00	1.00
12/03/2022 19:00	1	1.6	7.7	14.2	14.9	838,619.1	0.00	1.00
12/03/2022 20:00	1	1.7	7.5	14.3	21.6	942,620.5	0.00	1.00
12/03/2022 21:00	1	1.7	7.8	14.3	22.4	948,430.1	0.00	1.00
12/03/2022 22:00	1	1.7	7.9	14.3	22.6	956,937.2	0.00	1.00
12/03/2022 23:00	1	1.7	8.0	14.3	22.9	968,141.5	0.00	1.00
Average/Sum#:	1	1.9	10.4	13.6	29.3	968,455.1	0.00 #	24.00 #
Minimum:	1	1.6	7.5	12.6	14.9	602,760.7	0.00	1.00
Maximum:	3	2.1	14.8	14.5	37.5	1,018,818.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2022 00:00	1	1.8	9.0	14.0	27.7	979,833.1	0.00	1.00
12/04/2022 01:00	1	1.8	9.2	14.0	28.1	986,779.4	0.00	1.00
12/04/2022 02:00	1	1.8	9.9	13.9	28.0	983,051.1	0.00	1.00
12/04/2022 03:00	1	1.8	9.7	13.9	27.7	985,203.0	0.00	1.00
12/04/2022 04:00	1	1.8	9.8	13.8	27.4	980,585.0	0.00	1.00
12/04/2022 05:00	1	1.8	10.0	13.7	27.7	985,985.6	0.00	1.00
12/04/2022 06:00	1	1.8	9.6	13.9	26.9	983,246.7	0.00	1.00
12/04/2022 07:00	1	1.8	10.1	13.9	28.2	987,941.9	0.00	1.00
12/04/2022 08:00	1	1.8	11.7	13.7	31.7	988,077.7	0.00	1.00
12/04/2022 09:00	1	1.8	11.0	13.9	29.1	976,399.6	0.00	1.00
12/04/2022 10:00	1	1.8	11.1	13.9	28.2	977,182.1	0.00	1.00
12/04/2022 11:00	1	1.8	9.3	13.9	23.3	977,377.7	0.00	1.00
12/04/2022 12:00	1	1.8	9.0	14.0	25.8	983,008.5	0.00	1.00
12/04/2022 13:00	1	1.8	9.2	13.9	25.1	972,878.2	0.00	1.00
12/04/2022 14:00	1	1.7	7.5	14.3	20.3	961,709.4	0.00	1.00
12/04/2022 15:00	1	1.7	7.6	14.4	21.0	981,561.3	0.00	1.00
12/04/2022 16:00	1	1.7	7.6	14.4	21.2	981,982.6	0.00	1.00
12/04/2022 17:00	1	1.7	7.7	14.3	21.7	967,311.6	0.00	1.00
12/04/2022 18:00	1	1.7	7.6	14.3	21.8	967,519.1	0.00	1.00
12/04/2022 19:00	1	1.7	7.6	14.3	21.9	967,519.1	0.00	1.00
12/04/2022 20:00	1	1.7	7.7	14.3	22.5	968,764.0	0.00	1.00
12/04/2022 21:00	1	1.7	7.6	14.3	22.3	968,764.0	0.00	1.00
12/04/2022 22:00	1	1.7	7.6	14.3	22.1	968,556.5	0.00	1.00
12/04/2022 23:00	1	1.7	7.6	14.3	21.8	968,349.0	0.00	1.00
Average/Sum#:	1	1.8	8.9	14.1	25.1	977,066.1	0.00 #	24.00 #
Minimum:	1	1.7	7.5	13.7	20.3	961,709.4	0.00	1.00
Maximum:	1	1.8	11.7	14.4	31.7	988,077.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2022 00:00	1	1.7	7.5	14.3	21.8	967,726.6	0.00	1.00
12/05/2022 01:00	1	1.7	7.6	14.3	21.9	967,726.6	0.00	1.00
12/05/2022 02:00	1	1.7	8.0	14.3	21.0	967,519.1	0.00	1.00
12/05/2022 03:00	1	1.7	7.8	14.3	21.8	967,726.6	0.00	1.00
12/05/2022 04:00	1	1.7	7.7	14.3	21.5	967,311.6	0.00	1.00
12/05/2022 05:00	1	1.7	7.7	14.3	22.4	966,689.1	0.00	1.00
12/05/2022 06:00	1	1.7	8.2	14.2	23.8	965,546.4	0.00	1.00
12/05/2022 07:00	1	1.7	8.8	14.0	24.9	972,489.8	0.00	1.00
12/05/2022 08:00	1	1.7	7.5	14.3	21.4	971,046.4	0.00	1.00
12/05/2022 09:00	1	1.7	7.6	14.3	21.2	970,216.4	0.00	1.00
12/05/2022 10:00	2	1.6	10.4	14.4	25.4	765,613.6	0.00	1.00
12/05/2022 11:00	2	1.5	13.8	14.5	28.1	596,769.5	0.00	1.00
12/05/2022 12:00	2	1.5	14.0	14.6	28.4	604,720.4	0.00	1.00
12/05/2022 13:00	2	1.5	14.3	14.5	30.1	593,987.8	0.00	1.00
12/05/2022 14:00	2	1.4	12.6	14.4	23.7	626,985.7	0.00	1.00
12/05/2022 15:00	1	1.6	9.7	14.4	18.2	636,466.3	0.00	1.00
12/05/2022 16:00	1	1.5	11.1	14.4	21.6	699,670.5	0.00	1.00
12/05/2022 17:00	1	1.6	8.9	14.3	19.7	727,039.9	0.00	1.00
12/05/2022 18:00	1	1.6	9.8	14.2	20.3	754,818.5	0.00	1.00
12/05/2022 19:00	1	1.9	10.2	13.4	26.5	986,350.7	0.00	1.00
12/05/2022 20:00	1	1.9	9.9	13.4	28.1	981,055.6	0.00	1.00
12/05/2022 21:00	1	1.8	9.3	13.7	25.9	978,948.2	0.00	1.00
12/05/2022 22:00	1	1.7	8.7	14.0	23.8	893,301.3	0.00	1.00
12/05/2022 23:00	2	1.6	10.3	14.3	22.8	671,432.9	0.00	1.00
Average/Sum#:	1	1.7	9.6	14.2	23.5	841,715.0	0.00 #	24.00 #
Minimum:	1	1.4	7.5	13.4	18.2	593,987.8	0.00	1.00
Maximum:	2	1.9	14.3	14.6	30.1	986,350.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	1	2.1	10.3	14.3	20.2	774,554.7	0.10	1.00
12/06/2022 01:00	0	12.7	26.8	17.2	0.0	329,402.1	0.03	0.03
12/06/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2022 15:00	0	11.3	16.3	15.5	3.2	646,165.4	0.85	0.85
12/06/2022 16:00	1	3.0	10.5	14.1	22.7	869,987.3	0.40	1.00
12/06/2022 17:00	1	1.9	10.8	13.4	28.3	1,000,410.2	0.00	1.00
12/06/2022 18:00	1	1.9	10.5	13.5	28.2	1,007,082.1	0.00	1.00
12/06/2022 19:00	1	1.9	10.5	13.5	28.4	1,008,932.7	0.00	1.00
12/06/2022 20:00	1	1.9	10.2	13.5	29.0	1,005,601.6	0.00	1.00
12/06/2022 21:00	1	1.9	10.2	13.6	28.3	1,009,997.4	0.00	1.00
12/06/2022 22:00	1	1.8	9.5	13.9	27.7	1,005,157.5	0.00	1.00
12/06/2022 23:00	1	1.8	9.3	14.0	26.9	996,702.8	0.00	1.00
Average/Sum#:	1	3.8	12.3	14.2	22.1	877,635.8	1.38 #	9.88 #
Minimum:	1	1.8	9.3	13.4	0.0	329,402.1	0.00	0.00
Maximum:	1	12.7	26.8	17.2	29.0	1,009,997.4	0.85	1.00
%SI	62.50	54.17	54.17	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2022 00:00	1	1.7	7.9	14.3	22.4	929,756.2	0.00	1.00
12/07/2022 01:00	1	1.7	8.0	14.2	22.5	880,110.7	0.00	1.00
12/07/2022 02:00	1	1.7	8.5	14.2	22.6	909,338.7	0.00	1.00
12/07/2022 03:00	1	1.7	8.2	14.2	23.0	906,272.8	0.00	1.00
12/07/2022 04:00	1	1.7	8.8	14.1	26.9	957,992.9	0.00	1.00
12/07/2022 05:00	1	1.9	10.8	13.5	31.7	1,018,370.6	0.00	1.00
12/07/2022 06:00	1	1.9	10.8	13.4	32.9	1,014,287.0	0.00	1.00
12/07/2022 07:00	1	1.8	9.5	14.0	29.2	1,005,832.3	0.00	1.00
12/07/2022 08:00	1	1.7	9.3	14.0	28.3	994,916.6	0.00	1.00
12/07/2022 09:00	1	1.8	9.8	13.8	28.3	1,002,380.1	0.00	1.00
12/07/2022 10:00	1	1.8	9.8	13.9	26.8	1,005,157.5	0.00	1.00
12/07/2022 11:00	1	1.8	9.6	13.9	25.7	995,767.2	0.00	1.00
12/07/2022 12:00	1	1.7	9.1	14.1	23.2	922,347.6	0.00	1.00
12/07/2022 13:00	2	1.7	13.2	14.5	27.4	623,730.0	0.00	1.00
12/07/2022 14:00	1	1.6	12.1	14.5	23.0	703,113.8	0.00	1.00
12/07/2022 15:00	1	1.8	9.9	13.8	23.4	996,786.7	0.00	1.00
12/07/2022 16:00	1	1.8	9.8	13.9	24.8	996,745.3	0.00	1.00
12/07/2022 17:00	1	1.8	9.7	13.9	25.0	993,419.6	0.00	1.00
12/07/2022 18:00	1	1.8	9.7	13.9	25.3	991,463.3	0.00	1.00
12/07/2022 19:00	1	1.9	10.0	13.7	26.7	1,005,575.9	0.00	1.00
12/07/2022 20:00	1	1.9	11.0	13.3	30.6	1,017,338.2	0.00	1.00
12/07/2022 21:00	1	1.9	10.8	13.4	29.9	1,019,582.1	0.00	1.00
12/07/2022 22:00	1	1.8	9.5	13.9	27.3	1,010,048.3	0.00	1.00
12/07/2022 23:00	1	1.8	9.2	14.0	27.0	1,001,466.0	0.00	1.00
Average/Sum#:	1	1.8	9.8	13.9	26.4	954,241.6	0.00 #	24.00 #
Minimum:	1	1.6	7.9	13.3	22.4	623,730.0	0.00	1.00
Maximum:	2	1.9	13.2	14.5	32.9	1,019,582.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2022 00:00	1	1.8	10.1	13.7	28.7	1,010,140.7	0.00	1.00
12/08/2022 01:00	1	1.8	9.8	13.9	28.1	1,012,004.6	0.00	1.00
12/08/2022 02:00	1	1.7	10.0	13.9	28.0	1,004,375.0	0.00	1.00
12/08/2022 03:00	1	1.8	9.9	13.9	27.5	1,006,918.2	0.00	1.00
12/08/2022 04:00	1	1.8	10.2	13.7	28.8	1,010,330.9	0.00	1.00
12/08/2022 05:00	1	1.9	10.7	13.5	31.0	1,020,221.2	0.00	1.00
12/08/2022 06:00	1	1.9	11.1	13.3	32.8	1,025,807.0	0.00	1.00
12/08/2022 07:00	1	1.9	10.6	13.5	31.3	1,015,409.7	0.00	1.00
12/08/2022 08:00	1	1.8	9.7	13.9	28.2	1,006,918.2	0.00	1.00
12/08/2022 09:00	1	1.7	8.7	14.1	24.4	975,312.1	0.00	1.00
12/08/2022 10:00	1	1.7	7.7	14.3	19.5	915,232.0	0.00	1.00
12/08/2022 11:00	1	1.9	9.9	13.7	26.5	1,008,999.5	0.00	1.00
12/08/2022 12:00	1	1.9	10.7	13.3	28.2	1,007,067.5	0.00	1.00
12/08/2022 13:00	1	1.9	10.7	13.3	27.5	1,005,626.0	0.00	1.00
12/08/2022 14:00	1	2.0	11.4	13.1	29.8	1,006,702.5	0.00	1.00
12/08/2022 15:00	1	1.9	10.9	13.3	28.5	1,016,437.2	0.00	1.00
12/08/2022 16:00	1	2.0	11.4	13.1	29.9	1,008,282.6	0.00	1.00
12/08/2022 17:00	1	2.0	12.1	12.9	31.3	1,012,347.0	0.00	1.00
12/08/2022 18:00	1	2.1	12.3	12.8	32.1	1,008,809.3	0.00	1.00
12/08/2022 19:00	1	2.1	12.3	12.8	32.1	1,007,794.9	0.00	1.00
12/08/2022 20:00	1	2.1	12.1	12.8	32.0	1,005,089.9	0.00	1.00
12/08/2022 21:00	1	2.0	11.8	12.9	31.6	1,009,779.3	0.00	1.00
12/08/2022 22:00	1	2.0	11.3	13.1	30.3	1,012,847.3	0.00	1.00
12/08/2022 23:00	1	1.9	9.9	13.5	26.9	994,868.3	0.00	1.00
Average/Sum#:	1	1.9	10.6	13.4	29.0	1,004,471.7	0.00 #	24.00 #
Minimum:	1	1.7	7.7	12.8	19.5	915,232.0	0.00	1.00
Maximum:	1	2.1	12.3	14.3	32.8	1,025,807.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	1	1.7	7.4	14.2	19.5	877,044.8	0.00	1.00
12/09/2022 01:00	1	1.7	7.1	14.2	17.2	822,472.2	0.00	1.00
12/09/2022 02:00	1	1.7	7.5	14.3	19.1	884,731.1	0.00	1.00
12/09/2022 03:00	1	1.7	7.4	14.3	19.5	897,180.5	0.00	1.00
12/09/2022 04:00	1	1.7	8.1	14.2	22.8	958,188.3	0.00	1.00
12/09/2022 05:00	1	1.7	8.6	14.1	24.4	989,811.9	0.00	1.00
12/09/2022 06:00	1	1.7	8.0	14.3	22.7	993,247.7	0.00	1.00
12/09/2022 07:00	1	1.9	9.9	13.5	27.4	998,754.5	0.00	1.00
12/09/2022 08:00	1	1.7	8.8	14.2	24.5	870,504.2	0.00	1.00
12/09/2022 09:00	1	1.6	7.6	14.2	16.9	808,369.2	0.00	1.00
12/09/2022 10:00	2	1.6	13.3	14.5	28.9	625,655.8	0.00	1.00
12/09/2022 11:00	2	1.6	12.8	14.5	24.9	633,144.8	0.00	1.00
12/09/2022 12:00	2	1.6	12.2	14.5	24.6	642,773.6	0.00	1.00
12/09/2022 13:00	1	1.7	8.3	14.4	18.8	981,982.6	0.00	1.00
12/09/2022 14:00	1	1.7	8.4	14.4	21.5	985,985.6	0.00	1.00
12/09/2022 15:00	1	1.6	10.0	14.2	21.9	790,995.9	0.00	1.00
12/09/2022 16:00	1	1.9	10.5	13.4	27.0	998,401.7	0.00	1.00
12/09/2022 17:00	1	1.9	10.2	13.5	27.0	1,004,306.2	0.00	1.00
12/09/2022 18:00	1	1.9	10.3	13.4	27.8	998,219.1	0.00	1.00
12/09/2022 19:00	1	2.0	11.0	13.2	29.4	1,004,481.7	0.00	1.00
12/09/2022 20:00	1	2.0	11.2	13.1	29.8	1,000,206.5	0.00	1.00
12/09/2022 21:00	1	1.9	10.7	13.3	28.7	1,006,707.1	0.00	1.00
12/09/2022 22:00	1	1.9	10.7	13.3	27.5	998,778.9	0.00	1.00
12/09/2022 23:00	1	1.9	9.9	13.6	25.9	995,177.6	0.00	1.00
Average/Sum#:	1	1.8	9.6	14.0	24.1	906,963.4	0.00 #	24.00 #
Minimum:	1	1.6	7.1	13.1	16.9	625,655.8	0.00	1.00
Maximum:	2	2.0	13.3	14.5	29.8	1,006,707.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2022 00:00	1	1.7	8.3	14.4	22.0	993,780.7	0.00	1.00
12/10/2022 01:00	1	1.7	8.0	14.4	20.7	990,409.9	0.00	1.00
12/10/2022 02:00	1	1.7	8.4	14.4	20.9	991,252.6	0.00	1.00
12/10/2022 03:00	1	1.7	8.6	14.4	21.8	991,252.6	0.00	1.00
12/10/2022 04:00	1	1.7	8.6	14.4	22.2	991,463.3	0.00	1.00
12/10/2022 05:00	1	1.7	8.6	14.4	22.3	991,463.3	0.00	1.00
12/10/2022 06:00	1	1.7	8.2	14.3	21.6	975,611.1	0.00	1.00
12/10/2022 07:00	2	1.6	11.2	14.3	23.4	651,514.0	0.00	1.00
12/10/2022 08:00	1	1.6	9.6	14.3	19.2	704,423.6	0.00	1.00
12/10/2022 09:00	2	1.6	10.5	14.3	22.4	642,592.0	0.00	1.00
12/10/2022 10:00	2	1.6	12.4	14.4	24.9	606,971.0	0.00	1.00
12/10/2022 11:00	1	1.6	9.3	14.3	17.7	697,576.5	0.00	1.00
12/10/2022 12:00	1	1.6	7.3	14.3	16.5	890,333.3	0.00	1.00
12/10/2022 13:00	1	1.7	7.6	14.2	18.4	876,431.6	0.00	1.00
12/10/2022 14:00	1	1.8	10.3	13.7	26.2	987,887.5	0.00	1.00
12/10/2022 15:00	1	1.9	10.4	13.5	25.8	975,437.3	0.00	1.00
12/10/2022 16:00	1	1.9	9.9	13.5	26.3	982,284.4	0.00	1.00
12/10/2022 17:00	1	1.9	8.9	13.6	23.7	972,103.7	0.00	1.00
12/10/2022 18:00	1	1.8	8.8	13.7	23.9	985,034.6	0.00	1.00
12/10/2022 19:00	1	2.0	10.1	13.2	26.8	978,693.8	0.00	1.00
12/10/2022 20:00	1	1.9	9.9	13.3	26.0	981,120.5	0.00	1.00
12/10/2022 21:00	1	1.9	9.0	13.6	24.5	979,795.0	0.00	1.00
12/10/2022 22:00	1	1.8	8.8	13.7	24.8	977,807.0	0.00	1.00
12/10/2022 23:00	1	1.8	9.3	13.7	25.2	986,556.1	0.00	1.00
Average/Sum#:	1	1.7	9.3	14.0	22.8	908,408.1	0.00 #	24.00 #
Minimum:	1	1.6	7.3	13.2	16.5	606,971.0	0.00	1.00
Maximum:	2	2.0	12.4	14.4	26.8	993,780.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2022 00:00	1	1.8	8.9	13.7	24.4	950,228.4	0.00	1.00
12/11/2022 01:00	1	1.7	8.5	14.2	19.8	739,898.0	0.00	1.00
12/11/2022 02:00	1	1.7	10.3	14.3	23.0	647,364.3	0.00	1.00
12/11/2022 03:00	1	1.6	9.8	14.2	18.4	691,865.9	0.00	1.00
12/11/2022 04:00	1	1.7	7.4	14.2	17.4	817,158.0	0.00	1.00
12/11/2022 05:00	1	1.7	7.5	14.2	19.4	847,612.4	0.00	1.00
12/11/2022 06:00	1	1.7	7.4	14.2	19.8	836,370.8	0.00	1.00
12/11/2022 07:00	2	1.7	12.4	14.3	29.1	634,085.0	0.00	1.00
12/11/2022 08:00	2	1.6	15.3	14.6	34.1	614,067.3	0.00	1.00
12/11/2022 09:00	2	1.6	15.9	14.6	34.7	610,154.6	0.00	1.00
12/11/2022 10:00	2	1.6	14.2	14.5	28.5	613,245.4	0.00	1.00
12/11/2022 11:00	2	1.6	15.5	14.6	33.8	609,502.5	0.00	1.00
12/11/2022 12:00	2	1.6	15.7	14.6	32.5	609,719.9	0.00	1.00
12/11/2022 13:00	2	1.6	14.3	14.5	27.6	611,961.5	0.00	1.00
12/11/2022 14:00	2	1.6	12.6	14.5	24.6	627,153.6	0.00	1.00
12/11/2022 15:00	1	1.7	9.5	14.3	17.8	849,043.1	0.00	1.00
12/11/2022 16:00	1	1.8	9.7	13.8	23.7	995,050.8	0.00	1.00
12/11/2022 17:00	1	1.8	9.8	13.7	26.1	988,648.3	0.00	1.00
12/11/2022 18:00	1	1.8	9.4	13.8	25.9	987,335.7	0.00	1.00
12/11/2022 19:00	1	1.8	9.4	13.8	26.4	991,771.9	0.00	1.00
12/11/2022 20:00	1	1.8	9.8	13.7	27.2	1,002,723.0	0.00	1.00
12/11/2022 21:00	1	1.8	9.3	13.8	26.5	987,335.7	0.00	1.00
12/11/2022 22:00	2	1.7	10.1	14.2	27.0	816,953.6	0.00	1.00
12/11/2022 23:00	2	1.7	14.1	14.4	30.3	615,187.6	0.00	1.00
Average/Sum#:	1	1.7	11.1	14.2	25.8	778,934.9	0.00 #	24.00 #
Minimum:	1	1.6	7.4	13.7	17.4	609,502.5	0.00	1.00
Maximum:	2	1.8	15.9	14.6	34.7	1,002,723.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2022 00:00	2	1.6	13.8	14.4	28.6	625,510.9	0.00	1.00
12/12/2022 01:00	2	1.6	12.4	14.3	27.8	628,897.8	0.00	1.00
12/12/2022 02:00	1	2.0	11.9	14.2	18.7	672,448.7	0.00	1.00
12/12/2022 03:00	2	1.9	13.1	14.3	28.3	625,992.9	0.00	1.00
12/12/2022 04:00	1	1.8	9.4	14.1	24.3	839,779.4	0.00	1.00
12/12/2022 05:00	2	0.9	10.9	13.5	42.8	1,010,783.2	0.00	1.00
12/12/2022 06:00	2	1.0	11.2	13.3	42.0	1,007,247.7	0.00	1.00
12/12/2022 07:00	2	1.0	10.4	13.5	38.8	994,683.3	0.00	1.00
12/12/2022 08:00	0	0.0	0.0	0.0	38.8	337,638.5	0.00	1.00
12/12/2022 09:00	1	1.6	9.6	13.9	27.3	1,004,570.6	0.00	1.00
12/12/2022 10:00	1	1.7	9.0	14.1	23.7	910,868.6	0.00	1.00
12/12/2022 11:00	2	1.6	13.7	14.5	29.2	621,376.3	0.00	1.00
12/12/2022 12:00	2	1.6	13.5	14.5	27.8	622,232.2	0.00	1.00
12/12/2022 13:00	2	1.6	15.2	14.6	33.3	617,762.6	0.00	1.00
12/12/2022 14:00	2	1.6	15.8	14.6	32.8	615,154.1	0.00	1.00
12/12/2022 15:00	0	1.6	8.5	14.2	16.8	973,722.1	0.00	1.00
12/12/2022 16:00	1	1.7	9.0	14.1	22.7	986,791.1	0.00	1.00
12/12/2022 17:00	1	1.7	9.0	14.1	24.5	991,825.7	0.00	1.00
12/12/2022 18:00	1	1.7	9.0	14.1	25.7	994,041.0	0.00	1.00
12/12/2022 19:00	1	1.7	9.0	14.1	25.9	996,860.4	0.00	1.00
12/12/2022 20:00	1	1.7	9.0	14.1	26.2	999,881.2	0.00	1.00
12/12/2022 21:00	1	1.7	9.0	14.0	26.6	986,977.9	0.00	1.00
12/12/2022 22:00	1	1.8	9.1	14.0	27.2	991,344.2	0.00	1.00
12/12/2022 23:00	1	1.8	9.2	14.0	27.3	991,939.6	0.00	1.00
Average/Sum#:	1	1.6	10.9	14.1	28.6	856,986.6	0.00 #	24.00 #
Minimum:	0	0.9	8.5	13.3	16.8	615,154.1	0.00	1.00
Maximum:	2	2.0	15.8	14.6	42.8	1,010,783.2	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2022 00:00	1	1.8	9.3	14.0	27.9	993,527.3	0.00	1.00
12/13/2022 01:00	1	1.7	9.3	14.0	27.9	992,733.4	0.00	1.00
12/13/2022 02:00	1	1.7	9.9	14.0	28.6	996,305.9	0.00	1.00
12/13/2022 03:00	1	1.8	9.7	14.0	29.1	999,878.3	0.00	1.00
12/13/2022 04:00	1	1.7	9.5	14.0	28.1	992,138.0	0.00	1.00
12/13/2022 05:00	1	1.7	9.4	14.0	28.3	991,145.7	0.00	1.00
12/13/2022 06:00	1	1.8	9.5	14.0	29.3	1,000,473.7	0.00	1.00
12/13/2022 07:00	1	1.8	10.4	13.7	31.5	1,016,607.4	0.00	1.00
12/13/2022 08:00	1	1.7	9.4	14.0	28.7	995,313.5	0.00	1.00
12/13/2022 09:00	1	1.7	9.3	14.1	28.0	1,006,728.3	0.00	1.00
12/13/2022 10:00	1	1.7	9.2	14.1	27.4	1,006,526.9	0.00	1.00
12/13/2022 11:00	2	1.7	12.2	14.4	29.8	722,634.7	0.00	1.00
12/13/2022 12:00	2	1.6	14.7	14.5	30.9	622,232.2	0.00	1.00
12/13/2022 13:00	2	1.6	14.5	14.5	30.1	621,376.3	0.00	1.00
12/13/2022 14:00	2	1.6	14.1	14.5	28.2	622,660.1	0.00	1.00
12/13/2022 15:00	1	1.6	10.1	14.3	19.0	834,933.9	0.00	1.00
12/13/2022 16:00	1	1.8	9.2	14.1	23.3	999,881.2	0.00	1.00
12/13/2022 17:00	1	1.8	9.1	14.1	25.7	998,471.5	0.00	1.00
12/13/2022 18:00	1	1.7	9.3	14.1	27.9	1,000,284.0	0.00	1.00
12/13/2022 19:00	1	1.7	9.6	14.1	27.5	1,001,089.5	0.00	1.00
12/13/2022 20:00	1	1.7	9.2	14.0	26.8	990,351.8	0.00	1.00
12/13/2022 21:00	1	1.8	10.3	13.7	29.6	1,014,895.6	0.00	1.00
12/13/2022 22:00	1	1.8	9.8	13.8	28.3	997,751.0	0.00	1.00
12/13/2022 23:00	1	1.7	9.3	14.0	27.6	995,313.5	0.00	1.00
Average/Sum#:	1	1.7	10.3	14.1	27.9	933,885.6	0.00 #	24.00 #
Minimum:	1	1.6	9.1	13.7	19.0	621,376.3	0.00	1.00
Maximum:	2	1.8	14.7	14.5	31.5	1,016,607.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2022 00:00	1	1.7	8.2	14.3	24.1	992,210.2	0.00	1.00
12/14/2022 01:00	1	1.7	8.2	14.3	24.6	992,002.7	0.00	1.00
12/14/2022 02:00	1	1.7	8.8	14.3	25.2	992,832.7	0.00	1.00
12/14/2022 03:00	1	1.7	8.6	14.3	25.3	990,550.3	0.00	1.00
12/14/2022 04:00	1	1.7	8.5	14.3	26.1	999,472.3	0.00	1.00
12/14/2022 05:00	1	1.7	8.7	14.3	27.1	1,005,282.0	0.00	1.00
12/14/2022 06:00	1	1.7	8.8	14.3	27.9	1,013,996.5	0.00	1.00
12/14/2022 07:00	1	1.7	8.3	14.3	25.2	996,982.4	0.00	1.00
12/14/2022 08:00	1	1.7	8.2	14.3	25.4	1,000,924.7	0.00	1.00
12/14/2022 09:00	1	1.7	8.2	14.3	24.9	1,000,302.3	0.00	1.00
12/14/2022 10:00	1	1.7	8.2	14.3	24.2	1,000,094.8	0.00	1.00
12/14/2022 11:00	1	1.6	8.1	14.3	22.6	969,801.5	0.00	1.00
12/14/2022 12:00	2	1.7	13.2	14.4	29.5	635,834.3	0.00	1.00
12/14/2022 13:00	2	1.6	13.9	14.5	28.6	623,944.0	0.00	1.00
12/14/2022 14:00	2	1.6	13.7	14.5	27.9	623,944.0	0.00	1.00
12/14/2022 15:00	2	1.6	13.8	14.5	28.1	623,302.1	0.00	1.00
12/14/2022 16:00	1	1.6	11.1	14.4	20.5	745,388.2	0.00	1.00
12/14/2022 17:00	1	1.8	8.9	14.1	23.1	995,249.3	0.00	1.00
12/14/2022 18:00	1	1.7	8.9	14.1	25.3	1,001,492.3	0.00	1.00
12/14/2022 19:00	1	1.8	8.9	14.1	26.4	1,004,110.3	0.00	1.00
12/14/2022 20:00	1	1.7	8.7	14.1	25.9	993,436.8	0.00	1.00
12/14/2022 21:00	1	1.7	7.9	14.3	23.9	997,397.4	0.00	1.00
12/14/2022 22:00	1	1.7	8.0	14.3	24.0	993,870.1	0.00	1.00
12/14/2022 23:00	1	1.7	8.0	14.3	24.3	998,227.4	0.00	1.00
Average/Sum#:	1	1.7	9.4	14.3	25.4	924,610.4	0.00 #	24.00 #
Minimum:	1	1.6	7.9	14.1	20.5	623,302.1	0.00	1.00
Maximum:	2	1.8	13.9	14.5	29.5	1,013,996.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	1	1.7	8.1	14.3	24.5	999,472.3	0.00	1.00
12/15/2022 01:00	1	1.7	8.1	14.3	24.9	1,002,377.2	0.00	1.00
12/15/2022 02:00	1	1.7	8.5	14.3	24.6	999,887.3	0.00	1.00
12/15/2022 03:00	1	1.7	8.4	14.3	25.3	996,360.0	0.00	1.00
12/15/2022 04:00	1	1.7	8.3	14.3	25.0	1,001,547.2	0.00	1.00
12/15/2022 05:00	1	1.7	8.3	14.3	25.0	1,000,302.3	0.00	1.00
12/15/2022 06:00	1	1.7	8.4	14.3	25.9	1,003,207.1	0.00	1.00
12/15/2022 07:00	1	1.7	8.5	14.3	26.4	1,006,111.9	0.00	1.00
12/15/2022 08:00	1	1.7	8.4	14.3	25.7	1,001,547.2	0.00	1.00
12/15/2022 09:00	1	1.7	8.2	14.3	25.2	1,001,962.2	0.00	1.00
12/15/2022 10:00	1	1.7	8.1	14.3	24.7	1,001,754.7	0.00	1.00
12/15/2022 11:00	1	1.7	8.0	14.3	23.9	997,604.9	0.00	1.00
12/15/2022 12:00	1	1.7	8.0	14.4	23.1	1,010,424.5	0.00	1.00
12/15/2022 13:00	1	1.7	8.1	14.4	22.5	1,004,525.5	0.00	1.00
12/15/2022 14:00	1	1.7	8.3	14.4	22.6	1,003,261.4	0.00	1.00
12/15/2022 15:00	1	1.7	8.5	14.4	23.0	1,003,472.1	0.00	1.00
12/15/2022 16:00	1	1.7	8.4	14.4	22.3	1,002,840.0	0.00	1.00
12/15/2022 17:00	1	1.7	8.3	14.4	22.3	1,005,368.2	0.00	1.00
12/15/2022 18:00	1	1.7	8.1	14.4	22.2	1,002,418.6	0.00	1.00
12/15/2022 19:00	1	1.7	8.1	14.3	23.2	988,890.4	0.00	1.00
12/15/2022 20:00	1	1.7	8.1	14.3	23.5	989,512.9	0.00	1.00
12/15/2022 21:00	1	1.7	8.1	14.3	23.9	991,172.8	0.00	1.00
12/15/2022 22:00	1	1.7	8.2	14.3	24.3	997,397.4	0.00	1.00
12/15/2022 23:00	1	1.7	8.3	14.3	25.0	1,001,132.2	0.00	1.00
Average/Sum#:	1	1.7	8.2	14.3	24.1	1,000,522.9	0.00 #	24.00 #
Minimum:	1	1.7	8.0	14.3	22.2	988,890.4	0.00	1.00
Maximum:	1	1.7	8.5	14.4	26.4	1,010,424.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	1	1.7	8.6	14.3	25.4	946,977.7	0.00	1.00
12/16/2022 01:00	3	1.7	15.4	14.5	35.9	624,158.0	0.00	1.00
12/16/2022 02:00	2	1.7	16.1	14.5	35.0	623,730.0	0.00	1.00
12/16/2022 03:00	3	1.6	15.9	14.5	36.6	623,944.0	0.00	1.00
12/16/2022 04:00	3	1.6	15.8	14.5	35.9	622,446.2	0.00	1.00
12/16/2022 05:00	3	1.6	15.7	14.5	35.5	623,088.1	0.00	1.00
12/16/2022 06:00	3	1.6	15.8	14.5	36.1	623,088.1	0.00	1.00
12/16/2022 07:00	3	1.6	16.3	14.5	38.1	620,734.4	0.00	1.00
12/16/2022 08:00	3	1.6	16.0	14.5	36.6	623,730.0	0.00	1.00
12/16/2022 09:00	3	1.6	15.7	14.5	36.2	622,446.2	0.00	1.00
12/16/2022 10:00	2	1.6	15.1	14.5	33.6	622,446.2	0.00	1.00
12/16/2022 11:00	2	1.6	14.2	14.5	30.0	622,874.1	0.00	1.00
12/16/2022 12:00	2	1.6	13.7	14.5	28.3	622,660.1	0.00	1.00
12/16/2022 13:00	2	1.6	13.3	14.5	27.2	624,371.9	0.00	1.00
12/16/2022 14:00	2	1.6	13.1	14.5	26.3	624,799.9	0.00	1.00
12/16/2022 15:00	2	1.6	13.0	14.5	26.4	625,441.8	0.00	1.00
12/16/2022 16:00	2	1.6	13.1	14.5	26.9	625,655.8	0.00	1.00
12/16/2022 17:00	2	1.6	13.2	14.5	27.0	625,013.8	0.00	1.00
12/16/2022 18:00	2	1.6	13.9	14.5	29.8	623,516.0	0.00	1.00
12/16/2022 19:00	2	1.6	14.5	14.5	32.2	621,162.3	0.00	1.00
12/16/2022 20:00	2	1.6	14.7	14.5	32.6	622,874.1	0.00	1.00
12/16/2022 21:00	2	1.6	14.8	14.5	33.2	622,660.1	0.00	1.00
12/16/2022 22:00	2	1.6	15.3	14.4	34.4	613,080.8	0.00	1.00
12/16/2022 23:00	2	1.6	15.3	14.4	34.4	614,766.2	0.00	1.00
Average/Sum#:	2	1.6	14.5	14.5	32.2	636,069.4	0.00 #	24.00 #
Minimum:	1	1.6	8.6	14.3	25.4	613,080.8	0.00	1.00
Maximum:	3	1.7	16.3	14.5	38.1	946,977.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2022 00:00	3	1.6	15.5	14.4	35.2	614,766.2	0.00	1.00
12/17/2022 01:00	2	1.6	15.3	14.4	33.9	615,187.6	0.00	1.00
12/17/2022 02:00	1	1.5	10.2	14.3	23.3	825,596.9	0.00	1.00
12/17/2022 03:00	2	1.7	11.6	14.3	30.1	740,111.6	0.00	1.00
12/17/2022 04:00	3	1.6	15.8	14.5	37.3	616,241.0	0.00	1.00
12/17/2022 05:00	1	1.6	11.5	14.2	24.6	790,995.9	0.00	1.00
12/17/2022 06:00	1	1.8	9.5	14.0	27.3	1,017,938.8	0.00	1.00
12/17/2022 07:00	1	1.8	9.8	13.9	30.0	1,014,547.8	0.00	1.00
12/17/2022 08:00	1	1.7	8.1	14.2	24.4	936,522.8	0.00	1.00
12/17/2022 09:00	1	1.7	8.7	14.2	24.2	830,239.1	0.00	1.00
12/17/2022 10:00	2	1.7	12.2	14.3	27.9	646,949.3	0.00	1.00
12/17/2022 11:00	2	1.6	15.3	14.5	34.0	612,389.5	0.00	1.00
12/17/2022 12:00	2	1.6	16.4	14.6	35.9	611,458.9	0.00	1.00
12/17/2022 13:00	2	1.6	14.0	14.5	27.4	621,376.3	0.00	1.00
12/17/2022 14:00	1	1.6	11.5	14.5	22.0	711,244.8	0.00	1.00
12/17/2022 15:00	1	1.9	10.4	13.5	24.4	1,003,195.9	0.00	1.00
12/17/2022 16:00	1	1.9	10.8	13.3	28.8	1,006,887.3	0.00	1.00
12/17/2022 17:00	1	1.9	10.4	13.5	28.5	1,010,598.2	0.00	1.00
12/17/2022 18:00	1	1.8	9.7	13.7	28.1	1,002,723.0	0.00	1.00
12/17/2022 19:00	1	1.9	10.8	13.3	31.5	1,013,013.7	0.00	1.00
12/17/2022 20:00	1	2.0	11.5	13.1	33.3	1,023,205.8	0.00	1.00
12/17/2022 21:00	1	2.0	11.2	13.2	32.6	1,018,887.3	0.00	1.00
12/17/2022 22:00	1	1.9	10.8	13.3	31.7	1,012,653.3	0.00	1.00
12/17/2022 23:00	1	1.8	9.6	13.7	29.9	1,001,201.4	0.00	1.00
Average/Sum#:	1	1.7	11.7	14.0	29.4	845,747.2	0.00 #	24.00 #
Minimum:	1	1.5	8.1	13.1	22.0	611,458.9	0.00	1.00
Maximum:	3	2.0	16.4	14.6	37.3	1,023,205.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2022 00:00	1	1.7	7.9	14.2	23.2	915,879.2	0.00	1.00
12/18/2022 01:00	1	1.7	8.0	14.2	24.1	912,200.2	0.00	1.00
12/18/2022 02:00	1	1.6	8.2	14.2	22.9	874,183.3	0.00	1.00
12/18/2022 03:00	1	1.7	7.9	14.2	22.6	856,196.8	0.00	1.00
12/18/2022 04:00	1	1.7	8.0	14.2	24.1	903,002.5	0.00	1.00
12/18/2022 05:00	1	1.7	8.2	14.2	25.1	935,909.6	0.00	1.00
12/18/2022 06:00	1	1.7	9.0	14.1	28.2	958,194.3	0.00	1.00
12/18/2022 07:00	2	2.0	12.7	12.9	37.6	1,026,212.4	0.00	1.00
12/18/2022 08:00	2	1.9	11.3	13.3	34.4	1,024,545.7	0.00	1.00
12/18/2022 09:00	2	1.9	11.3	13.2	34.4	1,025,823.4	0.00	1.00
12/18/2022 10:00	1	1.8	9.8	13.7	29.5	984,273.8	0.00	1.00
12/18/2022 11:00	1	1.7	7.6	14.2	20.9	894,418.1	0.00	1.00
12/18/2022 12:00	2	1.7	10.4	14.3	27.3	760,030.5	0.00	1.00
12/18/2022 13:00	3	1.7	15.5	14.5	35.3	620,948.4	0.00	1.00
12/18/2022 14:00	1	1.6	11.3	14.3	20.8	734,094.5	0.00	1.00
12/18/2022 15:00	2	1.7	11.0	14.3	24.1	734,924.4	0.00	1.00
12/18/2022 16:00	1	1.8	8.7	14.1	24.7	995,249.3	0.00	1.00
12/18/2022 17:00	1	1.8	9.8	13.7	29.7	1,003,674.0	0.00	1.00
12/18/2022 18:00	1	1.9	10.9	13.3	31.6	1,021,122.1	0.00	1.00
12/18/2022 19:00	1	1.9	10.6	13.4	30.8	1,019,947.3	0.00	1.00
12/18/2022 20:00	1	1.9	10.4	13.5	31.4	1,022,997.0	0.00	1.00
12/18/2022 21:00	1	1.9	10.0	13.6	30.6	1,023,879.2	0.00	1.00
12/18/2022 22:00	1	1.8	10.0	13.7	30.6	1,022,313.3	0.00	1.00
12/18/2022 23:00	1	1.8	9.8	13.9	29.1	1,014,743.5	0.00	1.00
Average/Sum#:	1	1.8	9.9	13.9	28.0	928,531.8	0.00 #	24.00 #
Minimum:	1	1.6	7.6	12.9	20.8	620,948.4	0.00	1.00
Maximum:	3	2.0	15.5	14.5	37.6	1,026,212.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	1	1.9	10.4	13.5	31.1	1,019,295.9	0.00	1.00
12/19/2022 01:00	1	1.9	10.4	13.5	31.1	1,019,666.0	0.00	1.00
12/19/2022 02:00	1	1.8	10.8	13.5	31.3	1,020,406.2	0.00	1.00
12/19/2022 03:00	1	1.9	10.6	13.5	31.3	1,020,036.1	0.00	1.00
12/19/2022 04:00	1	1.9	11.2	13.3	33.4	1,031,573.0	0.00	1.00
12/19/2022 05:00	2	2.0	12.2	12.9	35.7	1,026,897.1	0.00	1.00
12/19/2022 06:00	2	2.0	12.3	12.9	36.0	1,031,518.9	0.00	1.00
12/19/2022 07:00	2	2.0	11.9	13.0	35.0	1,027,068.3	0.00	1.00
12/19/2022 08:00	2	1.9	11.2	13.3	33.9	1,036,257.8	0.00	1.00
12/19/2022 09:00	2	2.1	12.8	12.8	37.5	1,043,298.5	0.00	1.00
12/19/2022 10:00	2	2.0	12.5	12.9	36.9	1,040,762.5	0.00	1.00
12/19/2022 11:00	2	2.0	11.7	13.0	34.8	1,026,548.3	0.00	1.00
12/19/2022 12:00	1	1.9	10.8	13.3	32.1	1,021,842.9	0.00	1.00
12/19/2022 13:00	1	1.9	10.9	13.3	32.5	1,034,816.3	0.00	1.00
12/19/2022 14:00	1	2.0	11.4	13.1	33.4	1,025,839.3	0.00	1.00
12/19/2022 15:00	1	1.9	10.9	13.3	31.8	1,028,149.4	0.00	1.00
12/19/2022 16:00	2	2.0	11.8	13.0	34.4	1,030,708.5	0.00	1.00
12/19/2022 17:00	2	2.0	11.9	13.0	34.7	1,036,255.6	0.00	1.00
12/19/2022 18:00	2	2.0	11.9	13.0	35.2	1,034,348.8	0.00	1.00
12/19/2022 19:00	2	2.0	12.0	13.0	35.2	1,033,135.4	0.00	1.00
12/19/2022 20:00	2	2.0	12.0	13.0	35.3	1,033,308.7	0.00	1.00
12/19/2022 21:00	2	2.0	11.9	13.0	35.0	1,033,655.4	0.00	1.00
12/19/2022 22:00	2	2.0	11.9	13.0	35.6	1,033,655.4	0.00	1.00
12/19/2022 23:00	1	1.9	10.9	13.4	33.0	1,015,747.7	0.00	1.00
Average/Sum#:	2	2.0	11.5	13.1	34.0	1,029,366.3	0.00 #	24.00 #
Minimum:	1	1.8	10.4	12.8	31.1	1,015,747.7	0.00	1.00
Maximum:	2	2.1	12.8	13.5	37.5	1,043,298.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2022 00:00	1	1.7	8.1	14.3	24.5	991,380.3	0.00	1.00
12/20/2022 01:00	1	1.7	7.9	14.3	23.7	994,285.1	0.00	1.00
12/20/2022 02:00	1	1.7	8.1	14.3	23.3	994,285.1	0.00	1.00
12/20/2022 03:00	1	1.7	8.0	14.3	23.9	993,455.1	0.00	1.00
12/20/2022 04:00	1	1.7	7.8	14.3	23.8	992,417.7	0.00	1.00
12/20/2022 05:00	1	1.7	7.8	14.3	23.5	996,567.5	0.00	1.00
12/20/2022 06:00	1	1.7	7.8	14.3	23.3	995,322.5	0.00	1.00
12/20/2022 07:00	2	2.0	11.7	13.1	35.0	1,040,411.4	0.00	1.00
12/20/2022 08:00	1	1.9	10.8	13.3	32.1	1,019,140.0	0.00	1.00
12/20/2022 09:00	1	1.8	8.9	14.0	27.7	1,007,023.1	0.00	1.00
12/20/2022 10:00	2	1.7	9.0	14.1	27.4	900,597.9	0.00	1.00
12/20/2022 11:00	3	1.6	15.8	14.6	37.3	631,456.8	0.00	1.00
12/20/2022 12:00	3	1.6	17.4	14.7	40.2	625,517.7	0.00	1.00
12/20/2022 13:00	3	1.6	16.6	14.6	37.9	615,588.9	0.00	1.00
12/20/2022 14:00	3	1.6	16.7	14.6	37.6	613,849.9	0.00	1.00
12/20/2022 15:00	1	1.6	11.2	14.3	20.6	793,851.2	0.00	1.00
12/20/2022 16:00	1	1.8	9.1	14.0	23.7	1,010,992.4	0.00	1.00
12/20/2022 17:00	1	1.8	9.2	14.0	25.6	1,004,641.5	0.00	1.00
12/20/2022 18:00	1	1.8	9.1	14.0	26.1	1,005,435.4	0.00	1.00
12/20/2022 19:00	1	1.8	9.3	14.0	26.8	1,006,229.2	0.00	1.00
12/20/2022 20:00	1	1.8	8.7	14.0	26.8	1,003,847.6	0.00	1.00
12/20/2022 21:00	1	1.7	8.6	14.0	26.4	1,000,473.7	0.00	1.00
12/20/2022 22:00	1	1.7	9.5	14.0	27.1	1,000,076.7	0.00	1.00
12/20/2022 23:00	1	1.8	9.1	14.0	26.6	998,885.9	0.00	1.00
Average/Sum#:	1	1.7	10.3	14.1	28.0	926,488.9	0.00 #	24.00 #
Minimum:	1	1.6	7.8	13.1	20.6	613,849.9	0.00	1.00
Maximum:	3	2.0	17.4	14.7	40.2	1,040,411.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	1	1.8	8.6	14.0	26.3	998,885.9	0.00	1.00
12/21/2022 01:00	1	1.8	8.7	14.0	26.4	997,893.6	0.00	1.00
12/21/2022 02:00	1	1.7	9.1	14.0	26.3	994,519.7	0.00	1.00
12/21/2022 03:00	1	1.8	8.9	14.0	26.7	995,115.1	0.00	1.00
12/21/2022 04:00	1	1.7	8.8	14.1	26.7	1,009,950.5	0.00	1.00
12/21/2022 05:00	1	1.7	8.7	14.0	26.7	996,504.3	0.00	1.00
12/21/2022 06:00	1	1.8	8.9	14.0	27.5	1,013,969.4	0.00	1.00
12/21/2022 07:00	1	1.9	10.4	13.4	30.8	1,021,590.6	0.00	1.00
12/21/2022 08:00	1	1.8	9.6	13.8	28.9	1,029,189.9	0.00	1.00
12/21/2022 09:00	1	2.0	10.8	13.2	32.3	1,027,246.1	0.00	1.00
12/21/2022 10:00	1	1.9	10.5	13.3	30.5	1,019,680.6	0.00	1.00
12/21/2022 11:00	1	1.9	9.7	13.6	28.9	1,030,069.8	0.00	1.00
12/21/2022 12:00	1	1.9	9.5	13.6	28.1	1,022,190.9	0.00	1.00
12/21/2022 13:00	1	1.9	9.9	13.5	28.9	1,026,883.2	0.00	1.00
12/21/2022 14:00	1	1.9	9.6	13.6	27.6	1,019,001.8	0.00	1.00
12/21/2022 15:00	1	1.8	9.1	13.9	26.1	1,013,765.3	0.00	1.00
12/21/2022 16:00	1	1.9	10.0	13.6	27.9	1,022,190.9	0.00	1.00
12/21/2022 17:00	1	1.9	9.4	13.7	28.1	1,020,601.6	0.00	1.00
12/21/2022 18:00	1	1.8	9.2	13.7	28.2	1,008,809.3	0.00	1.00
12/21/2022 19:00	1	1.8	9.5	13.7	28.3	1,020,031.0	0.00	1.00
12/21/2022 20:00	1	1.9	10.3	13.3	31.0	1,021,482.5	0.00	1.00
12/21/2022 21:00	1	1.9	10.4	13.3	31.1	1,026,347.5	0.00	1.00
12/21/2022 22:00	1	1.8	8.8	13.8	27.4	1,002,958.7	0.00	1.00
12/21/2022 23:00	1	1.8	8.6	13.9	26.6	994,984.6	0.00	1.00
Average/Sum#:	1	1.8	9.5	13.7	28.2	1,013,911.0	0.00 #	24.00 #
Minimum:	1	1.7	8.6	13.2	26.1	994,519.7	0.00	1.00
Maximum:	1	2.0	10.8	14.1	32.3	1,030,069.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	1	1.7	8.4	14.0	26.1	996,305.9	0.00	1.00
12/22/2022 01:00	1	1.7	7.4	14.3	22.4	993,040.2	0.00	1.00
12/22/2022 02:00	1	1.7	8.0	14.3	22.7	993,455.1	0.00	1.00
12/22/2022 03:00	1	1.7	7.9	14.3	23.2	993,870.1	0.00	1.00
12/22/2022 04:00	1	1.7	7.8	14.3	23.0	991,587.7	0.00	1.00
12/22/2022 05:00	1	1.7	7.7	14.3	22.9	993,662.6	0.00	1.00
12/22/2022 06:00	1	1.7	7.7	14.3	23.0	994,285.1	0.00	1.00
12/22/2022 07:00	1	1.8	9.1	13.9	27.4	1,002,614.3	0.00	1.00
12/22/2022 08:00	1	1.8	8.9	14.0	27.4	1,012,183.2	0.00	1.00
12/22/2022 09:00	1	1.9	10.5	13.3	30.8	1,022,383.4	0.00	1.00
12/22/2022 10:00	1	2.0	11.7	13.0	33.7	1,034,522.1	0.00	1.00
12/22/2022 11:00	1	2.0	11.7	13.0	33.6	1,028,628.4	0.00	1.00
12/22/2022 12:00	1	1.8	9.5	13.7	28.0	1,012,993.6	0.00	1.00
12/22/2022 13:00	1	1.8	9.2	13.9	26.3	1,004,961.9	0.00	1.00
12/22/2022 14:00	1	1.8	8.9	14.0	26.4	1,003,649.1	0.00	1.00
12/22/2022 15:00	1	1.8	9.1	13.9	26.9	1,000,266.7	0.00	1.00
12/22/2022 16:00	1	1.9	10.1	13.5	29.3	1,009,858.0	0.00	1.00
12/22/2022 17:00	1	1.8	9.3	13.8	26.4	1,004,501.7	0.00	1.00
12/22/2022 18:00	1	1.8	9.3	13.9	26.8	1,016,112.9	0.00	1.00
12/22/2022 19:00	1	1.8	9.0	13.9	26.7	999,484.2	0.00	1.00
12/22/2022 20:00	1	1.8	8.7	14.0	26.4	1,002,061.4	0.00	1.00
12/22/2022 21:00	1	1.8	9.1	13.9	27.0	1,004,961.9	0.00	1.00
12/22/2022 22:00	1	1.8	9.2	13.9	26.7	1,008,678.9	0.00	1.00
12/22/2022 23:00	1	1.8	8.8	14.0	25.9	1,004,046.1	0.00	1.00
Average/Sum#:	1	1.8	9.0	13.9	26.6	1,005,338.1	0.00 #	24.00 #
Minimum:	1	1.7	7.4	13.0	22.4	991,587.7	0.00	1.00
Maximum:	1	2.0	11.7	14.3	33.7	1,034,522.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2022 00:00	1	1.8	8.8	14.0	26.0	1,003,847.6	0.00	1.00
12/23/2022 01:00	1	1.8	8.8	14.0	26.5	1,003,847.6	0.00	1.00
12/23/2022 02:00	1	1.8	9.3	14.0	26.4	1,003,053.7	0.00	1.00
12/23/2022 03:00	1	1.8	9.0	14.0	26.7	1,003,053.7	0.00	1.00
12/23/2022 04:00	1	1.8	8.7	14.0	25.5	1,003,450.7	0.00	1.00
12/23/2022 05:00	1	1.8	8.8	14.0	26.4	1,001,664.5	0.00	1.00
12/23/2022 06:00	1	1.8	8.6	14.0	26.3	999,679.8	0.00	1.00
12/23/2022 07:00	1	1.9	10.5	13.4	31.9	1,025,425.0	0.00	1.00
12/23/2022 08:00	1	1.8	9.8	13.6	29.7	1,004,932.4	0.00	1.00
12/23/2022 09:00	1	1.9	10.1	13.6	29.7	1,020,127.4	0.00	1.00
12/23/2022 10:00	1	1.8	9.8	13.7	28.8	1,023,264.3	0.00	1.00
12/23/2022 11:00	1	1.8	9.7	13.7	28.0	1,018,509.4	0.00	1.00
12/23/2022 12:00	1	1.8	8.6	14.0	24.8	992,535.0	0.00	1.00
12/23/2022 13:00	1	1.7	10.4	14.3	21.5	682,429.8	0.00	1.00
12/23/2022 14:00	1	1.5	10.3	14.4	20.4	733,800.8	0.00	1.00
12/23/2022 15:00	1	1.9	9.7	13.7	25.8	1,001,201.4	0.00	1.00
12/23/2022 16:00	1	2.0	11.3	13.1	30.9	1,016,358.7	0.00	1.00
12/23/2022 17:00	1	2.0	10.8	13.2	29.6	1,019,420.9	0.00	1.00
12/23/2022 18:00	1	2.0	10.7	13.2	30.5	1,012,307.0	0.00	1.00
12/23/2022 19:00	1	1.9	10.0	13.5	29.4	1,015,224.6	0.00	1.00
12/23/2022 20:00	1	1.9	9.8	13.5	29.7	1,008,932.7	0.00	1.00
12/23/2022 21:00	1	1.9	10.1	13.5	30.6	1,022,441.9	0.00	1.00
12/23/2022 22:00	1	1.9	9.8	13.6	29.9	1,022,941.3	0.00	1.00
12/23/2022 23:00	1	1.8	9.6	13.7	29.6	1,011,662.3	0.00	1.00
Average/Sum#:	1	1.8	9.7	13.7	27.7	985,421.4	0.00 #	24.00 #
Minimum:	1	1.5	8.6	13.1	20.4	682,429.8	0.00	1.00
Maximum:	1	2.0	11.3	14.4	31.9	1,025,425.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2022 00:00	1	1.7	7.8	14.3	23.9	989,097.9	0.00	1.00
12/24/2022 01:00	1	1.7	7.9	14.3	24.1	990,550.3	0.00	1.00
12/24/2022 02:00	1	1.7	8.4	14.3	23.8	992,417.7	0.00	1.00
12/24/2022 03:00	1	1.7	8.2	14.3	24.4	991,587.7	0.00	1.00
12/24/2022 04:00	1	1.7	8.0	14.3	24.2	990,342.8	0.00	1.00
12/24/2022 05:00	1	1.7	8.1	14.3	24.6	989,927.8	0.00	1.00
12/24/2022 06:00	1	1.7	8.0	14.3	24.2	976,233.6	0.00	1.00
12/24/2022 07:00	2	1.8	12.4	14.3	33.0	704,423.6	0.00	1.00
12/24/2022 08:00	2	1.6	16.0	14.5	35.1	622,874.1	0.00	1.00
12/24/2022 09:00	1	1.6	10.2	14.2	23.0	894,622.5	0.00	1.00
12/24/2022 10:00	1	1.8	9.8	13.7	27.3	1,023,644.7	0.00	1.00
12/24/2022 11:00	1	1.8	8.9	14.0	25.6	1,012,778.6	0.00	1.00
12/24/2022 12:00	1	1.8	8.8	13.9	24.6	1,004,766.2	0.00	1.00
12/24/2022 13:00	1	1.8	9.2	13.9	25.0	999,288.5	0.00	1.00
12/24/2022 14:00	1	1.8	8.9	14.0	24.7	1,003,847.6	0.00	1.00
12/24/2022 15:00	1	1.8	9.0	14.0	24.2	1,004,244.5	0.00	1.00
12/24/2022 16:00	1	1.8	9.1	13.9	24.4	998,897.3	0.00	1.00
12/24/2022 17:00	1	1.8	8.8	14.0	24.6	1,003,053.7	0.00	1.00
12/24/2022 18:00	1	1.8	9.1	14.0	25.9	998,489.0	0.00	1.00
12/24/2022 19:00	1	1.8	9.1	14.0	25.3	1,004,641.5	0.00	1.00
12/24/2022 20:00	1	1.7	8.4	14.1	23.1	921,944.8	0.00	1.00
12/24/2022 21:00	2	1.7	13.1	14.5	29.1	627,367.5	0.00	1.00
12/24/2022 22:00	2	1.6	13.0	14.4	28.5	622,140.0	0.00	1.00
12/24/2022 23:00	2	1.6	12.9	14.4	27.8	624,036.2	0.00	1.00
Average/Sum#:	1	1.7	9.7	14.2	25.9	916,300.8	0.00 #	24.00 #
Minimum:	1	1.6	7.8	13.7	23.0	622,140.0	0.00	1.00
Maximum:	2	1.8	16.0	14.5	35.1	1,023,644.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2022 00:00	2	1.6	11.8	14.3	25.4	647,779.2	0.00	1.00
12/25/2022 01:00	2	1.6	13.2	14.4	29.4	626,353.6	0.00	1.00
12/25/2022 02:00	2	1.6	13.5	14.4	28.4	623,404.1	0.00	1.00
12/25/2022 03:00	2	1.7	13.5	14.4	29.4	621,929.4	0.00	1.00
12/25/2022 04:00	2	1.7	13.5	14.4	29.5	621,718.7	0.00	1.00
12/25/2022 05:00	2	1.6	13.6	14.4	29.9	618,769.1	0.00	1.00
12/25/2022 06:00	2	1.7	14.0	14.4	31.2	618,558.5	0.00	1.00
12/25/2022 07:00	3	1.7	15.6	14.5	37.2	621,590.3	0.00	1.00
12/25/2022 08:00	2	1.6	15.0	14.4	32.2	617,083.7	0.00	1.00
12/25/2022 09:00	2	1.6	12.4	14.3	26.3	676,620.1	0.00	1.00
12/25/2022 10:00	2	1.7	14.8	14.4	32.5	624,457.5	0.00	1.00
12/25/2022 11:00	2	1.6	13.6	14.4	27.5	636,255.6	0.00	1.00
12/25/2022 12:00	2	1.7	12.4	14.3	27.4	652,966.4	0.00	1.00
12/25/2022 13:00	2	1.6	14.0	14.4	30.1	615,608.9	0.00	1.00
12/25/2022 14:00	2	1.6	15.1	14.5	32.5	614,529.2	0.00	1.00
12/25/2022 15:00	3	1.6	16.8	14.6	38.1	611,241.5	0.00	1.00
12/25/2022 16:00	1	1.6	11.3	14.3	22.6	787,626.5	0.00	1.00
12/25/2022 17:00	1	1.8	9.2	14.0	24.5	999,679.8	0.00	1.00
12/25/2022 18:00	2	1.7	12.0	14.4	31.1	744,334.8	0.00	1.00
12/25/2022 19:00	2	1.6	14.1	14.4	31.1	612,238.0	0.00	1.00
12/25/2022 20:00	2	1.6	13.8	14.4	30.1	613,712.8	0.00	1.00
12/25/2022 21:00	2	1.6	14.0	14.4	30.2	614,134.2	0.00	1.00
12/25/2022 22:00	3	1.7	14.7	14.5	33.7	616,454.9	0.00	1.00
12/25/2022 23:00	2	1.6	15.0	14.5	33.9	614,529.2	0.00	1.00
Average/Sum#:	2	1.6	13.6	14.4	30.2	652,149.0	0.00 #	24.00 #
Minimum:	1	1.6	9.2	14.0	22.6	611,241.5	0.00	1.00
Maximum:	3	1.8	16.8	14.6	38.1	999,679.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	2	1.7	12.2	14.3	23.8	641,762.1	0.00	1.00
12/26/2022 01:00	2	1.6	14.1	14.4	31.0	615,608.9	0.00	1.00
12/26/2022 02:00	2	1.6	13.2	14.4	27.0	642,786.7	0.00	1.00
12/26/2022 03:00	2	1.6	13.8	14.4	33.2	623,614.8	0.00	1.00
12/26/2022 04:00	2	1.7	14.2	14.4	30.6	614,766.2	0.00	1.00
12/26/2022 05:00	1	1.7	10.0	14.2	19.1	707,195.3	0.00	1.00
12/26/2022 06:00	1	1.7	9.9	14.3	20.1	717,287.9	0.00	1.00
12/26/2022 07:00	3	1.7	14.2	14.4	35.8	618,137.1	0.00	1.00
12/26/2022 08:00	3	1.6	17.6	14.6	41.4	609,067.8	0.00	1.00
12/26/2022 09:00	2	1.6	13.7	14.4	27.8	617,505.1	0.00	1.00
12/26/2022 10:00	1	1.6	8.8	14.3	15.6	781,194.4	0.00	1.00
12/26/2022 11:00	1	1.8	8.5	14.1	22.8	951,548.6	0.00	1.00
12/26/2022 12:00	1	1.8	9.1	14.0	26.6	999,084.4	0.00	1.00
12/26/2022 13:00	1	1.8	9.6	13.8	27.3	995,050.8	0.00	1.00
12/26/2022 14:00	1	1.9	10.5	13.5	28.8	1,005,231.5	0.00	1.00
12/26/2022 15:00	1	1.9	10.4	13.4	28.7	1,001,140.5	0.00	1.00
12/26/2022 16:00	1	1.8	10.1	13.6	28.0	995,928.0	0.00	1.00
12/26/2022 17:00	1	1.9	10.5	13.5	28.0	1,000,790.1	0.00	1.00
12/26/2022 18:00	1	1.9	10.3	13.5	28.0	1,000,235.0	0.00	1.00
12/26/2022 19:00	1	1.8	9.4	13.8	26.1	984,635.4	0.00	1.00
12/26/2022 20:00	1	1.8	9.5	13.8	25.2	982,513.8	0.00	1.00
12/26/2022 21:00	1	1.8	9.0	13.9	23.4	953,119.4	0.00	1.00
12/26/2022 22:00	2	1.6	11.7	14.4	25.9	624,036.2	0.00	1.00
12/26/2022 23:00	2	1.6	13.6	14.5	27.7	596,983.4	0.00	1.00
Average/Sum#:	2	1.7	11.4	14.1	27.2	803,301.0	0.00 #	24.00 #
Minimum:	1	1.6	8.5	13.4	15.6	596,983.4	0.00	1.00
Maximum:	3	1.9	17.6	14.6	41.4	1,005,231.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2022 00:00	2	1.6	12.8	14.5	26.0	604,686.5	0.00	1.00
12/27/2022 01:00	2	1.6	14.2	14.5	29.7	594,629.7	0.00	1.00
12/27/2022 02:00	2	1.6	15.1	14.5	30.1	593,987.8	0.00	1.00
12/27/2022 03:00	2	1.6	14.8	14.5	30.5	594,201.8	0.00	1.00
12/27/2022 04:00	2	1.6	14.5	14.5	29.5	594,201.8	0.00	1.00
12/27/2022 05:00	2	1.6	14.1	14.5	28.7	595,057.7	0.00	1.00
12/27/2022 06:00	2	1.6	13.3	14.5	25.4	603,188.6	0.00	1.00
12/27/2022 07:00	2	1.6	13.7	14.5	28.8	597,197.4	0.00	1.00
12/27/2022 08:00	1	1.6	11.0	14.4	20.5	613,502.1	0.00	1.00
12/27/2022 09:00	2	1.6	12.4	14.5	26.2	609,821.8	0.00	1.00
12/27/2022 10:00	2	1.6	14.1	14.5	29.4	596,127.6	0.00	1.00
12/27/2022 11:00	2	1.6	14.0	14.5	28.8	597,839.3	0.00	1.00
12/27/2022 12:00	2	1.6	13.8	14.5	27.9	599,551.1	0.00	1.00
12/27/2022 13:00	1	1.6	11.3	14.4	20.3	612,659.4	0.00	1.00
12/27/2022 14:00	1	1.6	11.3	14.4	21.6	610,763.3	0.00	1.00
12/27/2022 15:00	2	1.6	13.1	14.5	27.1	601,690.8	0.00	1.00
12/27/2022 16:00	2	1.6	12.9	14.5	25.1	602,974.7	0.00	1.00
12/27/2022 17:00	2	1.6	13.4	14.5	28.5	599,337.1	0.00	1.00
12/27/2022 18:00	2	1.6	13.6	14.5	28.1	602,118.8	0.00	1.00
12/27/2022 19:00	2	1.6	14.2	14.5	29.8	598,695.2	0.00	1.00
12/27/2022 20:00	2	1.6	14.5	14.5	30.5	596,555.5	0.00	1.00
12/27/2022 21:00	2	1.6	15.1	14.5	32.3	596,341.5	0.00	1.00
12/27/2022 22:00	2	1.6	15.2	14.5	32.7	595,699.6	0.00	1.00
12/27/2022 23:00	2	2.1	16.5	14.6	29.2	591,243.5	0.10	1.00
Average/Sum#:	2	1.6	13.7	14.5	27.8	600,086.4	0.10 #	24.00 #
Minimum:	1	1.6	11.0	14.4	20.3	591,243.5	0.00	1.00
Maximum:	2	2.1	16.5	14.6	32.7	613,502.1	0.10	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2022 00:00	0	8.8	26.3	17.1	0.0	407,944.3	0.02	0.02
12/28/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	8.8	26.3	17.1	0.0	407,944.3	0.02 #	0.02 #
Minimum:	0	8.8	26.3	17.1	0.0	407,944.3	0.00	0.00
Maximum:	0	8.8	26.3	17.1	0.0	407,944.3	0.02	0.02
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:29 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022 00:00	0	1.7	7.5	14.4	11.7	953,119.4	0.00	1.00
10/01/2022 01:00	0	1.7	7.5	14.3	11.5	894,068.1	0.00	1.00
10/01/2022 02:00	0	1.4	7.7	14.4	14.1	930,997.9	0.00	1.00
10/01/2022 03:00	0	1.4	7.7	14.4	14.5	961,335.9	0.00	1.00
10/01/2022 04:00	0	1.5	7.7	14.4	12.7	932,051.3	0.00	1.00
10/01/2022 05:00	0	1.7	8.0	14.4	14.7	985,985.6	0.00	1.00
10/01/2022 06:00	1	1.6	11.8	14.5	21.9	830,213.5	0.00	1.00
10/01/2022 07:00	1	1.6	16.9	14.7	25.9	652,464.5	0.00	1.00
10/01/2022 08:00	1	1.6	16.1	14.7	24.4	651,360.1	0.00	1.00
10/01/2022 09:00	1	1.6	15.6	14.8	23.5	660,915.6	0.00	1.00
10/01/2022 10:00	1	1.6	15.1	14.8	22.3	660,466.6	0.00	1.00
10/01/2022 11:00	1	1.6	14.6	14.8	21.1	658,446.2	0.00	1.00
10/01/2022 12:00	1	1.6	14.3	14.8	20.6	657,772.7	0.00	1.00
10/01/2022 13:00	1	1.5	13.1	14.8	17.9	667,426.0	0.00	1.00
10/01/2022 14:00	1	1.5	14.0	14.8	21.2	658,446.2	0.00	1.00
10/01/2022 15:00	0	1.5	12.9	14.8	17.2	666,528.0	0.00	1.00
10/01/2022 16:00	0	1.4	8.8	14.6	9.4	882,083.2	0.00	1.00
10/01/2022 17:00	0	1.6	7.3	14.5	11.8	1,027,068.3	0.00	1.00
10/01/2022 18:00	0	1.6	7.2	14.4	12.3	960,071.8	0.00	1.00
10/01/2022 19:00	0	1.7	7.3	14.3	11.9	896,765.5	0.00	1.00
10/01/2022 20:00	0	1.7	7.3	14.4	13.3	979,033.1	0.00	1.00
10/01/2022 21:00	1	1.6	7.8	14.3	14.3	899,255.3	0.00	1.00
10/01/2022 22:00	1	1.6	11.0	14.4	16.8	737,171.7	0.00	1.00
10/01/2022 23:00	0	1.6	7.6	14.3	9.7	857,965.1	0.00	1.00
Average/Sum#:	0	1.6	10.6	14.5	16.4	819,208.8	0.00 #	24.00 #
Minimum:	0	1.4	7.2	14.3	9.4	651,360.1	0.00	1.00
Maximum:	1	1.7	16.9	14.8	25.9	1,027,068.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2022 00:00	1	1.6	9.0	14.3	14.8	808,582.9	0.00	1.00
10/02/2022 01:00	1	1.4	9.6	14.4	11.9	802,693.4	0.00	1.00
10/02/2022 02:00	0	1.5	7.8	14.4	14.0	954,804.8	0.00	1.00
10/02/2022 03:00	0	1.7	7.7	14.4	13.2	960,914.6	0.00	1.00
10/02/2022 04:00	0	1.8	7.7	14.4	14.3	1,006,421.6	0.00	1.00
10/02/2022 05:00	0	1.8	7.7	14.4	14.3	999,258.4	0.00	1.00
10/02/2022 06:00	1	1.7	10.6	14.4	20.7	859,366.5	0.00	1.00
10/02/2022 07:00	1	1.7	17.8	14.7	27.5	655,115.0	0.00	1.00
10/02/2022 08:00	1	1.7	17.1	14.7	26.2	652,022.7	0.00	1.00
10/02/2022 09:00	1	1.7	16.5	14.7	25.3	650,918.3	0.00	1.00
10/02/2022 10:00	1	1.7	16.0	14.7	24.2	650,034.8	0.00	1.00
10/02/2022 11:00	1	1.7	15.5	14.8	23.0	660,466.6	0.00	1.00
10/02/2022 12:00	1	1.6	13.9	14.8	19.1	674,385.4	0.00	1.00
10/02/2022 13:00	0	1.5	9.8	14.5	9.7	774,794.6	0.00	1.00
10/02/2022 14:00	0	1.8	7.1	14.4	7.1	951,012.6	0.00	1.00
10/02/2022 15:00	0	1.6	9.7	14.5	13.1	807,104.5	0.00	1.00
10/02/2022 16:00	0	1.8	7.5	14.3	12.1	965,651.7	0.00	1.00
10/02/2022 17:00	1	2.0	9.6	13.6	18.4	1,032,133.3	0.00	1.00
10/02/2022 18:00	1	2.0	9.6	13.7	18.8	1,043,995.9	0.00	1.00
10/02/2022 19:00	1	2.0	9.5	13.7	19.1	1,039,811.5	0.00	1.00
10/02/2022 20:00	1	1.9	9.2	13.8	18.9	1,036,905.0	0.00	1.00
10/02/2022 21:00	0	1.7	7.9	14.3	13.4	896,765.5	0.00	1.00
10/02/2022 22:00	1	1.6	9.8	14.4	15.7	822,286.7	0.00	1.00
10/02/2022 23:00	0	1.7	7.3	14.4	12.0	1,017,166.3	0.00	1.00
Average/Sum#:	1	1.7	10.6	14.4	17.0	863,442.2	0.00 #	24.00 #
Minimum:	0	1.4	7.1	13.6	7.1	650,034.8	0.00	1.00
Maximum:	1	2.0	17.8	14.8	27.5	1,043,995.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2022 00:00	0	1.8	7.5	14.4	13.7	973,976.8	0.00	1.00
10/03/2022 01:00	0	1.8	7.6	14.4	13.5	959,650.5	0.00	1.00
10/03/2022 02:00	1	1.8	7.8	14.4	14.1	970,184.5	0.00	1.00
10/03/2022 03:00	0	1.4	7.7	14.4	15.3	980,929.2	0.00	1.00
10/03/2022 04:00	0	1.8	7.7	14.4	13.6	1,009,371.1	0.00	1.00
10/03/2022 05:00	0	1.7	7.7	14.4	15.4	1,020,747.9	0.00	1.00
10/03/2022 06:00	1	1.5	8.8	14.4	17.7	937,107.6	0.00	1.00
10/03/2022 07:00	1	1.2	12.1	14.4	18.2	727,691.0	0.00	1.00
10/03/2022 08:00	0	1.4	7.7	14.4	9.8	945,745.5	0.00	1.00
10/03/2022 09:00	1	1.5	13.5	14.6	22.9	684,494.8	0.00	1.00
10/03/2022 10:00	0	1.3	11.1	14.6	13.4	766,877.7	0.00	1.00
10/03/2022 11:00	0	1.4	8.9	14.5	11.5	871,296.3	0.00	1.00
10/03/2022 12:00	0	1.5	7.2	14.5	12.6	1,024,714.6	0.00	1.00
10/03/2022 13:00	0	1.5	7.2	14.5	13.3	1,028,352.1	0.00	1.00
10/03/2022 14:00	0	1.5	7.1	14.5	13.1	1,026,212.4	0.00	1.00
10/03/2022 15:00	0	1.5	7.2	14.5	13.8	1,036,483.1	0.00	1.00
10/03/2022 16:00	0	1.5	7.4	14.4	13.2	982,193.3	0.00	1.00
10/03/2022 17:00	1	1.7	9.4	13.7	19.5	1,050,652.8	0.00	1.00
10/03/2022 18:00	1	1.7	9.5	13.6	19.9	1,043,388.8	0.00	1.00
10/03/2022 19:00	1	1.7	9.4	13.7	20.0	1,055,217.6	0.00	1.00
10/03/2022 20:00	1	1.7	9.3	13.8	20.1	1,061,400.3	0.00	1.00
10/03/2022 21:00	0	1.6	8.3	14.1	15.9	967,659.4	0.00	1.00
10/03/2022 22:00	0	1.5	7.2	14.4	13.9	1,005,368.2	0.00	1.00
10/03/2022 23:00	1	1.7	9.1	13.9	20.1	1,062,477.7	0.00	1.00
Average/Sum#:	0	1.6	8.6	14.3	15.6	966,341.4	0.00 #	24.00 #
Minimum:	0	1.2	7.1	13.6	9.8	684,494.8	0.00	1.00
Maximum:	1	1.8	13.5	14.6	22.9	1,062,477.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2022 00:00	1	1.7	9.1	13.9	20.1	1,070,889.9	0.00	1.00
10/04/2022 01:00	1	1.7	9.2	13.8	20.4	1,065,836.5	0.00	1.00
10/04/2022 02:00	1	1.5	9.2	13.9	20.3	1,066,781.6	0.00	1.00
10/04/2022 03:00	1	1.8	9.2	13.9	19.4	1,070,889.9	0.00	1.00
10/04/2022 04:00	1	1.8	8.9	14.0	18.9	1,066,166.3	0.00	1.00
10/04/2022 05:00	1	1.8	9.1	13.8	19.6	1,061,786.1	0.00	1.00
10/04/2022 06:00	1	1.8	8.8	14.0	19.2	1,062,593.9	0.00	1.00
10/04/2022 07:00	1	1.7	8.2	14.2	17.0	1,040,762.5	0.00	1.00
10/04/2022 08:00	0	1.7	7.2	14.4	13.5	1,018,219.7	0.00	1.00
10/04/2022 09:00	1	1.8	8.0	14.1	16.5	1,015,186.5	0.00	1.00
10/04/2022 10:00	1	1.8	9.0	13.7	19.7	1,042,854.7	0.00	1.00
10/04/2022 11:00	0	1.6	7.3	14.4	12.9	1,039,709.1	0.00	1.00
10/04/2022 12:00	1	1.9	9.0	13.6	20.5	1,026,505.5	0.00	1.00
10/04/2022 13:00	0	1.8	8.6	13.9	14.6	1,046,435.9	0.00	1.00
10/04/2022 14:00	1	1.8	8.5	13.9	16.7	1,041,153.8	0.00	1.00
10/04/2022 15:00	1	1.8	8.9	13.7	17.5	1,035,246.8	0.00	1.00
10/04/2022 16:00	0	1.8	8.5	13.9	16.1	1,035,089.2	0.00	1.00
10/04/2022 17:00	0	1.8	8.3	14.0	16.3	1,036,793.2	0.00	1.00
10/04/2022 18:00	1	1.8	8.3	14.0	16.5	1,039,571.7	0.00	1.00
10/04/2022 19:00	1	1.8	8.4	14.0	17.0	1,046,319.6	0.00	1.00
10/04/2022 20:00	1	1.8	8.5	14.0	17.2	1,050,685.9	0.00	1.00
10/04/2022 21:00	1	1.8	8.5	13.9	17.3	1,040,175.6	0.00	1.00
10/04/2022 22:00	1	1.8	8.5	13.9	17.8	1,045,066.4	0.00	1.00
10/04/2022 23:00	1	1.8	8.6	13.9	17.7	1,046,435.9	0.00	1.00
Average/Sum#:	1	1.8	8.6	14.0	17.6	1,046,298.2	0.00 #	24.00 #
Minimum:	0	1.5	7.2	13.6	12.9	1,015,186.5	0.00	1.00
Maximum:	1	1.9	9.2	14.4	20.5	1,070,889.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2022 00:00	1	1.8	8.7	13.9	17.9	1,049,566.0	0.00	1.00
10/05/2022 01:00	1	1.8	8.7	13.9	18.1	1,054,652.4	0.00	1.00
10/05/2022 02:00	1	1.8	9.1	13.9	18.4	1,055,630.6	0.00	1.00
10/05/2022 03:00	1	1.8	9.0	13.9	18.6	1,056,413.1	0.00	1.00
10/05/2022 04:00	1	1.8	9.0	13.9	18.8	1,063,260.2	0.00	1.00
10/05/2022 05:00	1	1.8	8.9	13.9	18.9	1,065,216.5	0.00	1.00
10/05/2022 06:00	1	1.8	8.8	13.9	18.9	1,061,499.5	0.00	1.00
10/05/2022 07:00	1	1.7	8.5	14.0	17.9	1,054,853.7	0.00	1.00
10/05/2022 08:00	0	1.7	7.8	14.2	15.0	1,004,789.6	0.00	1.00
10/05/2022 09:00	0	1.7	7.3	14.3	12.6	970,838.9	0.00	1.00
10/05/2022 10:00	1	1.8	8.3	14.0	16.9	1,042,747.2	0.00	1.00
10/05/2022 11:00	0	1.8	8.3	14.0	16.2	1,039,770.2	0.00	1.00
10/05/2022 12:00	0	1.8	8.2	14.0	16.0	1,035,602.4	0.00	1.00
10/05/2022 13:00	0	1.8	8.2	14.0	15.9	1,032,030.0	0.00	1.00
10/05/2022 14:00	0	1.8	8.2	14.0	16.0	1,034,808.5	0.00	1.00
10/05/2022 15:00	0	1.8	8.1	14.0	15.8	1,031,236.1	0.00	1.00
10/05/2022 16:00	0	1.8	8.2	14.0	16.1	1,033,617.7	0.00	1.00
10/05/2022 17:00	0	1.8	8.2	14.0	15.9	1,034,014.6	0.00	1.00
10/05/2022 18:00	0	1.8	8.2	14.0	16.2	1,038,976.3	0.00	1.00
10/05/2022 19:00	1	1.8	8.4	14.0	16.9	1,045,724.2	0.00	1.00
10/05/2022 20:00	1	1.8	8.5	14.0	17.2	1,051,281.3	0.00	1.00
10/05/2022 21:00	1	1.8	8.4	13.9	17.2	1,036,654.3	0.00	1.00
10/05/2022 22:00	1	1.8	8.4	14.0	17.3	1,048,701.2	0.00	1.00
10/05/2022 23:00	0	1.6	7.1	14.5	13.1	1,045,897.9	0.00	1.00
Average/Sum#:	1	1.8	8.4	14.0	16.7	1,041,157.6	0.00 #	24.00 #
Minimum:	0	1.6	7.1	13.9	12.6	970,838.9	0.00	1.00
Maximum:	1	1.8	9.1	14.5	18.9	1,065,216.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2022 00:00	0	1.6	7.2	14.5	13.5	1,045,469.9	0.00	1.00
10/06/2022 01:00	0	1.6	7.3	14.5	13.8	1,048,037.6	0.00	1.00
10/06/2022 02:00	0	1.7	7.5	14.4	13.9	1,031,913.9	0.00	1.00
10/06/2022 03:00	0	1.7	7.5	14.4	14.1	1,031,071.2	0.00	1.00
10/06/2022 04:00	0	1.7	7.4	14.4	14.0	1,031,281.9	0.00	1.00
10/06/2022 05:00	0	1.7	7.8	14.4	15.3	1,043,501.4	0.00	1.00
10/06/2022 06:00	1	1.8	9.3	13.9	19.4	1,057,391.3	0.00	1.00
10/06/2022 07:00	1	1.6	9.1	14.2	17.9	946,946.7	0.00	1.00
10/06/2022 08:00	1	1.4	11.7	14.5	17.2	704,825.6	0.00	1.00
10/06/2022 09:00	1	1.6	12.7	14.6	18.7	678,408.5	0.00	1.00
10/06/2022 10:00	1	1.6	11.8	14.7	16.9	691,559.3	0.00	1.00
10/06/2022 11:00	0	1.5	9.2	14.5	8.8	775,650.5	0.00	1.00
10/06/2022 12:00	0	1.7	7.0	14.4	7.5	877,274.3	0.00	1.00
10/06/2022 13:00	0	1.7	7.4	14.4	12.4	997,362.3	0.00	1.00
10/06/2022 14:00	0	1.8	8.7	13.9	16.1	1,036,067.4	0.00	1.00
10/06/2022 15:00	0	1.8	8.3	14.0	15.9	1,033,220.8	0.00	1.00
10/06/2022 16:00	0	1.8	8.3	14.0	16.2	1,033,617.7	0.00	1.00
10/06/2022 17:00	0	1.8	8.3	14.0	16.1	1,036,197.8	0.00	1.00
10/06/2022 18:00	0	1.8	8.4	14.0	16.3	1,041,953.3	0.00	1.00
10/06/2022 19:00	0	1.8	8.5	14.0	16.8	1,047,510.4	0.00	1.00
10/06/2022 20:00	1	1.8	8.5	14.0	17.0	1,052,670.6	0.00	1.00
10/06/2022 21:00	1	1.8	8.6	14.0	17.4	1,057,830.7	0.00	1.00
10/06/2022 22:00	1	1.8	8.8	13.9	18.3	1,054,456.8	0.00	1.00
10/06/2022 23:00	1	1.8	8.9	13.9	18.5	1,057,586.9	0.00	1.00
Average/Sum#:	0	1.7	8.7	14.2	15.5	975,492.0	0.00 #	24.00 #
Minimum:	0	1.4	7.0	13.9	7.5	678,408.5	0.00	1.00
Maximum:	1	1.8	12.7	14.7	19.4	1,057,830.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2022 00:00	1	1.8	8.9	13.9	18.5	1,056,804.4	0.00	1.00
10/07/2022 01:00	1	1.8	8.9	13.9	18.9	1,058,956.3	0.00	1.00
10/07/2022 02:00	1	1.8	9.2	14.0	19.1	1,073,906.6	0.00	1.00
10/07/2022 03:00	1	1.7	9.0	14.1	18.7	1,069,157.9	0.00	1.00
10/07/2022 04:00	1	1.7	8.8	14.1	18.4	1,060,297.0	0.00	1.00
10/07/2022 05:00	1	1.7	9.0	14.1	19.1	1,075,602.3	0.00	1.00
10/07/2022 06:00	1	1.7	8.9	14.1	19.1	1,073,387.1	0.00	1.00
10/07/2022 07:00	0	1.7	8.6	14.2	18.1	1,072,034.5	0.00	1.00
10/07/2022 08:00	0	1.7	8.5	14.2	17.6	1,063,858.8	0.00	1.00
10/07/2022 09:00	0	1.7	8.4	14.2	16.8	1,054,661.2	0.00	1.00
10/07/2022 10:00	0	1.7	8.3	14.2	16.2	1,060,179.7	0.00	1.00
10/07/2022 11:00	0	1.7	8.3	14.1	16.3	1,044,588.9	0.00	1.00
10/07/2022 12:00	0	1.7	8.4	14.1	16.6	1,046,804.1	0.00	1.00
10/07/2022 13:00	0	1.7	8.4	14.1	16.6	1,046,804.1	0.00	1.00
10/07/2022 14:00	1	1.8	8.4	14.0	16.6	1,032,228.4	0.00	1.00
10/07/2022 15:00	0	1.7	8.3	14.0	16.2	1,028,060.6	0.00	1.00
10/07/2022 16:00	1	1.8	8.3	14.0	16.3	1,031,434.6	0.00	1.00
10/07/2022 17:00	0	1.8	8.4	14.0	16.2	1,035,999.3	0.00	1.00
10/07/2022 18:00	0	1.8	8.5	14.0	16.7	1,043,541.1	0.00	1.00
10/07/2022 19:00	0	1.8	8.4	14.0	16.5	1,044,731.9	0.00	1.00
10/07/2022 20:00	1	1.8	8.6	14.0	17.3	1,052,075.2	0.00	1.00
10/07/2022 21:00	1	1.8	8.8	14.0	17.7	1,059,021.5	0.00	1.00
10/07/2022 22:00	1	1.8	8.9	14.0	18.4	1,061,601.6	0.00	1.00
10/07/2022 23:00	1	1.8	9.0	14.0	18.6	1,068,746.4	0.00	1.00
Average/Sum#:	1	1.8	8.6	14.1	17.5	1,054,770.1	0.00 #	24.00 #
Minimum:	0	1.7	8.3	13.9	16.2	1,028,060.6	0.00	1.00
Maximum:	1	1.8	9.2	14.2	19.1	1,075,602.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2022 00:00	1	1.8	9.0	14.0	18.7	1,068,349.5	0.00	1.00
10/08/2022 01:00	1	1.8	9.1	14.0	19.1	1,074,700.4	0.00	1.00
10/08/2022 02:00	0	1.8	9.6	14.0	19.5	1,078,471.3	0.00	1.00
10/08/2022 03:00	1	1.8	9.5	13.9	19.7	1,065,803.4	0.00	1.00
10/08/2022 04:00	1	1.8	9.3	13.9	19.8	1,065,803.4	0.00	1.00
10/08/2022 05:00	1	1.8	9.3	13.9	20.0	1,069,716.1	0.00	1.00
10/08/2022 06:00	1	1.7	9.1	14.1	18.7	980,548.1	0.00	1.00
10/08/2022 07:00	1	1.5	11.3	14.4	17.7	753,183.4	0.00	1.00
10/08/2022 08:00	1	1.4	11.7	14.5	16.2	732,642.0	0.00	1.00
10/08/2022 09:00	0	1.4	11.2	14.5	13.7	746,978.2	0.00	1.00
10/08/2022 10:00	1	1.6	13.3	14.7	20.0	690,675.8	0.00	1.00
10/08/2022 11:00	0	1.5	9.7	14.5	8.9	779,930.0	0.00	1.00
10/08/2022 12:00	1	1.8	8.5	14.4	9.1	862,737.4	0.00	1.00
10/08/2022 13:00	0	1.7	7.8	14.3	13.7	1,008,601.8	0.00	1.00
10/08/2022 14:00	0	1.7	7.8	14.2	13.3	959,414.6	0.00	1.00
10/08/2022 15:00	0	1.8	8.7	14.0	16.5	1,039,571.7	0.00	1.00
10/08/2022 16:00	0	1.8	8.6	14.0	16.8	1,040,365.6	0.00	1.00
10/08/2022 17:00	0	1.8	8.7	13.9	16.8	1,030,198.4	0.00	1.00
10/08/2022 18:00	1	1.8	8.8	13.9	17.5	1,039,001.8	0.00	1.00
10/08/2022 19:00	1	1.8	8.7	13.9	17.1	1,047,022.8	0.00	1.00
10/08/2022 20:00	1	1.8	8.7	13.9	17.4	1,044,088.3	0.00	1.00
10/08/2022 21:00	1	1.8	8.7	14.0	18.0	1,052,670.6	0.00	1.00
10/08/2022 22:00	1	2.5	12.7	14.3	17.6	818,334.8	0.12	1.00
10/08/2022 23:00	0	17.4	28.2	17.4	0.0	416,305.0	0.02	0.02
Average/Sum#:	1	2.4	10.3	14.3	16.1	936,046.4	0.14 #	23.02 #
Minimum:	0	1.4	7.8	13.9	0.0	416,305.0	0.00	0.02
Maximum:	1	17.4	28.2	17.4	20.0	1,078,471.3	0.12	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2022 14:00	0	2.2	4.8	20.0	0.0	573,636.7	0.10	0.10
10/18/2022 15:00	3	9.7	17.4	14.7	18.5	710,112.8	0.73	1.00
10/18/2022 16:00	0	0.9	10.3	14.2	5.3	1,013,374.0	0.00	1.00
10/18/2022 17:00	1	2.1	14.0	12.8	24.1	1,053,949.6	0.00	1.00
10/18/2022 18:00	0	2.0	13.3	13.0	22.4	1,054,630.1	0.00	1.00
10/18/2022 19:00	1	2.2	15.4	12.3	28.9	1,061,144.7	0.00	1.00
10/18/2022 20:00	1	2.0	13.7	12.9	23.8	1,061,132.7	0.00	1.00
10/18/2022 21:00	0	2.0	12.8	13.1	22.1	1,055,861.3	0.00	1.00
10/18/2022 22:00	0	1.9	11.4	13.6	19.5	1,060,834.9	0.00	1.00
10/18/2022 23:00	0	1.7	8.1	14.3	13.3	1,016,693.9	0.00	1.00
Average/Sum#:	1	2.7	12.1	14.1	17.8	966,137.1	0.83 #	9.10 #
Minimum:	0	0.9	4.8	12.3	0.0	573,636.7	0.00	0.00
Maximum:	3	9.7	17.4	20.0	28.9	1,061,144.7	0.73	1.00
%SI	62.50	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2022 00:00	0	1.7	8.2	14.3	14.1	1,019,806.2	0.00	1.00
10/19/2022 01:00	0	1.7	8.2	14.3	14.0	982,250.8	0.00	1.00
10/19/2022 02:00	0	1.8	8.3	14.2	12.9	923,237.3	0.00	1.00
10/19/2022 03:00	0	1.7	8.1	14.3	13.7	977,893.5	0.00	1.00
10/19/2022 04:00	0	1.7	8.2	14.3	14.5	1,015,241.4	0.00	1.00
10/19/2022 05:00	0	1.7	8.2	14.3	14.6	1,019,598.7	0.00	1.00
10/19/2022 06:00	1	1.7	11.0	14.3	20.3	873,734.3	0.00	1.00
10/19/2022 07:00	1	1.6	19.7	14.6	30.5	655,150.0	0.00	1.00
10/19/2022 08:00	0	1.4	13.5	14.5	15.7	813,951.6	0.00	1.00
10/19/2022 09:00	1	1.6	12.7	14.4	19.4	728,112.4	0.00	1.00
10/19/2022 10:00	1	1.6	14.0	14.6	19.6	675,148.0	0.00	1.00
10/19/2022 11:00	1	1.6	13.6	14.6	18.9	672,104.8	0.00	1.00
10/19/2022 12:00	0	1.6	13.3	14.6	17.9	672,756.9	0.00	1.00
10/19/2022 13:00	0	1.6	12.5	14.6	15.3	674,061.1	0.00	1.00
10/19/2022 14:00	0	1.5	9.6	14.4	11.5	886,965.6	0.00	1.00
10/19/2022 15:00	0	1.8	8.8	14.0	15.0	1,030,243.8	0.00	1.00
10/19/2022 16:00	1	1.5	11.2	14.4	20.1	793,423.4	0.00	1.00
10/19/2022 17:00	0	1.3	10.9	14.4	8.5	827,975.1	0.00	1.00
10/19/2022 18:00	0	1.8	8.1	14.2	13.9	1,020,323.4	0.00	1.00
10/19/2022 19:00	0	1.8	9.0	14.0	17.1	1,042,151.8	0.00	1.00
10/19/2022 20:00	0	1.8	10.7	13.8	17.3	1,046,163.1	0.00	1.00
10/19/2022 21:00	0	1.8	9.9	13.9	16.1	1,016,895.4	0.00	1.00
10/19/2022 22:00	1	1.6	11.1	14.4	17.3	778,465.1	0.00	1.00
10/19/2022 23:00	0	1.6	7.4	14.2	8.3	894,009.3	0.00	1.00
Average/Sum#:	0	1.6	10.7	14.3	16.1	876,652.6	0.00 #	24.00 #
Minimum:	0	1.3	7.4	13.8	8.3	655,150.0	0.00	1.00
Maximum:	1	1.8	19.7	14.6	30.5	1,046,163.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2022 00:00	1	1.7	7.9	14.2	13.4	899,936.7	0.00	1.00
10/20/2022 01:00	1	1.5	10.8	14.3	15.8	761,897.9	0.00	1.00
10/20/2022 02:00	1	1.6	14.1	14.5	20.2	684,284.2	0.00	1.00
10/20/2022 03:00	0	1.7	9.3	14.2	9.6	813,479.0	0.00	1.00
10/20/2022 04:00	0	1.7	7.8	14.3	13.0	977,478.5	0.00	1.00
10/20/2022 05:00	0	1.7	7.9	14.3	15.1	1,037,442.7	0.00	1.00
10/20/2022 06:00	1	1.7	9.7	14.3	18.8	921,041.6	0.00	1.00
10/20/2022 07:00	1	1.6	15.2	14.5	23.0	672,087.8	0.00	1.00
10/20/2022 08:00	1	1.6	16.0	14.6	24.8	662,105.8	0.00	1.00
10/20/2022 09:00	1	1.6	15.0	14.6	21.1	663,410.0	0.00	1.00
10/20/2022 10:00	1	1.6	13.7	14.6	19.8	667,322.7	0.00	1.00
10/20/2022 11:00	1	1.5	14.5	14.7	20.3	665,496.1	0.00	1.00
10/20/2022 12:00	1	1.5	14.0	14.7	20.5	667,042.2	0.00	1.00
10/20/2022 13:00	0	1.5	11.9	14.6	14.3	676,234.8	0.00	1.00
10/20/2022 14:00	0	1.5	11.3	14.5	14.7	684,498.2	0.00	1.00
10/20/2022 15:00	0	1.7	9.4	14.3	11.0	894,068.1	0.00	1.00
10/20/2022 16:00	1	2.1	13.1	12.7	22.7	1,035,919.4	0.00	1.00
10/20/2022 17:00	0	1.9	11.7	13.2	19.0	1,036,672.0	0.00	1.00
10/20/2022 18:00	0	1.9	10.3	13.6	18.0	1,037,198.3	0.00	1.00
10/20/2022 19:00	0	1.8	9.0	14.0	16.9	1,039,770.2	0.00	1.00
10/20/2022 20:00	0	1.8	8.7	14.0	15.7	1,018,335.7	0.00	1.00
10/20/2022 21:00	1	1.6	11.6	14.3	18.4	711,270.7	0.00	1.00
10/20/2022 22:00	1	1.5	12.4	14.4	17.2	696,299.6	0.00	1.00
10/20/2022 23:00	0	1.6	7.5	14.3	8.6	972,706.3	0.00	1.00
Average/Sum#:	1	1.7	11.4	14.2	17.2	828,999.9	0.00 #	24.00 #
Minimum:	0	1.5	7.5	12.7	8.6	662,105.8	0.00	1.00
Maximum:	1	2.1	16.0	14.7	24.8	1,039,770.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2022 00:00	1	1.7	10.2	14.3	16.2	801,320.8	0.00	1.00
10/21/2022 01:00	1	1.5	10.6	14.3	15.3	762,935.4	0.00	1.00
10/21/2022 02:00	1	1.5	14.2	14.4	20.3	674,178.2	0.00	1.00
10/21/2022 03:00	1	1.6	12.3	14.3	16.4	699,236.4	0.00	1.00
10/21/2022 04:00	1	1.4	10.5	14.2	13.8	755,840.5	0.00	1.00
10/21/2022 05:00	0	1.6	7.6	14.3	10.8	982,665.7	0.00	1.00
10/21/2022 06:00	0	1.7	8.7	14.1	15.4	1,028,478.0	0.00	1.00
10/21/2022 07:00	0	1.8	8.7	14.1	16.1	1,019,012.9	0.00	1.00
10/21/2022 08:00	1	1.6	15.0	14.5	25.1	665,026.7	0.00	1.00
10/21/2022 09:00	1	1.6	16.3	14.6	24.4	649,281.1	0.00	1.00
10/21/2022 10:00	1	1.6	15.8	14.7	23.2	657,544.6	0.00	1.00
10/21/2022 11:00	0	1.5	13.0	14.6	17.1	673,409.0	0.00	1.00
10/21/2022 12:00	1	1.6	15.2	14.7	22.7	656,440.2	0.00	1.00
10/21/2022 13:00	1	1.6	14.0	14.7	18.9	666,821.3	0.00	1.00
10/21/2022 14:00	1	1.6	13.4	14.7	18.2	672,122.3	0.00	1.00
10/21/2022 15:00	0	1.4	7.8	14.2	7.1	916,083.6	0.00	1.00
10/21/2022 16:00	0	1.9	11.1	13.5	16.8	1,027,068.3	0.00	1.00
10/21/2022 17:00	0	1.9	10.0	13.7	17.8	1,045,517.5	0.00	1.00
10/21/2022 18:00	0	1.8	8.7	14.0	15.5	1,016,549.5	0.00	1.00
10/21/2022 19:00	0	1.7	7.7	14.2	10.3	832,691.8	0.00	1.00
10/21/2022 20:00	1	1.6	9.0	14.2	13.6	800,602.3	0.00	1.00
10/21/2022 21:00	0	1.7	7.4	14.3	12.0	1,008,186.8	0.00	1.00
10/21/2022 22:00	0	1.7	7.8	14.3	14.5	1,043,874.9	0.00	1.00
10/21/2022 23:00	0	1.7	7.7	14.3	14.7	1,043,667.4	0.00	1.00
Average/Sum#:	1	1.6	10.9	14.3	16.5	837,439.8	0.00 #	24.00 #
Minimum:	0	1.4	7.4	13.5	7.1	649,281.1	0.00	1.00
Maximum:	1	1.9	16.3	14.7	25.1	1,045,517.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2022 00:00	0	1.7	7.6	14.3	14.4	1,041,385.0	0.00	1.00
10/22/2022 01:00	0	1.7	7.6	14.3	14.7	1,040,347.6	0.00	1.00
10/22/2022 02:00	0	1.7	7.9	14.3	14.7	1,041,800.0	0.00	1.00
10/22/2022 03:00	0	1.7	7.8	14.3	14.2	1,042,215.0	0.00	1.00
10/22/2022 04:00	0	1.7	7.6	14.3	14.8	1,040,555.0	0.00	1.00
10/22/2022 05:00	0	1.7	8.3	14.2	16.6	1,033,608.8	0.00	1.00
10/22/2022 06:00	1	2.3	14.5	12.1	29.7	1,059,280.9	0.00	1.00
10/22/2022 07:00	2	2.3	15.0	11.9	32.6	1,064,499.2	0.00	1.00
10/22/2022 08:00	1	2.1	13.4	12.6	24.9	1,046,867.2	0.00	1.00
10/22/2022 09:00	1	2.1	13.2	12.7	23.9	1,047,609.7	0.00	1.00
10/22/2022 10:00	1	2.0	12.4	13.0	22.1	1,051,683.3	0.00	1.00
10/22/2022 11:00	0	1.8	10.1	13.7	18.7	1,047,039.1	0.00	1.00
10/22/2022 12:00	0	1.7	8.8	14.1	15.6	1,026,464.1	0.00	1.00
10/22/2022 13:00	0	1.7	7.7	14.3	13.4	996,152.5	0.00	1.00
10/22/2022 14:00	0	1.7	7.7	14.3	12.9	972,706.3	0.00	1.00
10/22/2022 15:00	1	1.5	11.9	14.4	15.0	776,990.3	0.00	1.00
10/22/2022 16:00	0	1.5	10.4	14.4	14.2	859,155.8	0.00	1.00
10/22/2022 17:00	0	1.7	7.8	14.3	12.4	960,049.5	0.00	1.00
10/22/2022 18:00	0	1.7	7.9	14.3	13.3	971,668.8	0.00	1.00
10/22/2022 19:00	0	1.7	8.0	14.3	15.2	1,032,255.5	0.00	1.00
10/22/2022 20:00	0	1.7	8.4	14.2	16.7	1,035,244.0	0.00	1.00
10/22/2022 21:00	1	1.8	10.3	13.8	20.1	1,063,522.0	0.00	1.00
10/22/2022 22:00	0	1.7	8.1	14.3	15.4	1,039,310.1	0.00	1.00
10/22/2022 23:00	0	1.7	8.1	14.3	15.6	1,038,272.7	0.00	1.00
Average/Sum#:	0	1.8	9.6	13.9	17.5	1,013,695.1	0.00 #	24.00 #
Minimum:	0	1.5	7.6	11.9	12.4	776,990.3	0.00	1.00
Maximum:	2	2.3	15.0	14.4	32.6	1,064,499.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2022 00:00	1	1.8	10.4	13.9	21.0	1,052,109.2	0.00	1.00
10/23/2022 01:00	0	1.8	9.3	14.1	18.2	1,033,311.3	0.00	1.00
10/23/2022 02:00	0	1.7	8.7	14.4	16.7	1,060,355.8	0.00	1.00
10/23/2022 03:00	0	1.7	8.7	14.4	16.9	1,057,827.7	0.00	1.00
10/23/2022 04:00	0	1.7	8.6	14.3	16.6	1,040,347.6	0.00	1.00
10/23/2022 05:00	0	1.7	8.5	14.3	16.6	1,040,762.5	0.00	1.00
10/23/2022 06:00	0	1.7	8.5	14.3	16.8	1,038,480.2	0.00	1.00
10/23/2022 07:00	0	1.7	9.8	14.1	19.2	1,028,880.8	0.00	1.00
10/23/2022 08:00	0	1.8	11.2	13.9	20.7	1,063,847.1	0.00	1.00
10/23/2022 09:00	0	1.7	9.2	14.2	15.3	948,173.1	0.00	1.00
10/23/2022 10:00	0	1.6	9.2	14.4	14.5	900,659.9	0.00	1.00
10/23/2022 11:00	0	1.8	12.2	13.8	21.6	1,043,462.8	0.00	1.00
10/23/2022 12:00	0	1.7	9.6	14.3	15.8	974,988.7	0.00	1.00
10/23/2022 13:00	0	1.5	10.7	14.5	14.0	809,244.2	0.00	1.00
10/23/2022 14:00	1	2.0	10.9	14.4	16.1	813,438.1	0.00	1.00
10/23/2022 15:00	1	1.7	15.1	14.6	21.7	708,840.1	0.00	1.00
10/23/2022 16:00	0	1.6	11.7	14.5	15.6	864,877.1	0.00	1.00
10/23/2022 17:00	0	1.7	8.7	14.4	16.3	1,031,492.6	0.00	1.00
10/23/2022 18:00	0	1.7	8.5	14.4	16.7	1,046,872.3	0.00	1.00
10/23/2022 19:00	0	1.6	8.3	14.4	16.5	1,056,774.3	0.00	1.00
10/23/2022 20:00	1	1.8	10.5	13.9	20.9	1,052,891.7	0.00	1.00
10/23/2022 21:00	1	1.8	10.5	13.9	20.5	1,040,762.5	0.00	1.00
10/23/2022 22:00	0	1.7	8.4	14.3	13.7	905,895.0	0.00	1.00
10/23/2022 23:00	0	1.7	8.3	14.4	17.0	1,058,459.7	0.00	1.00
Average/Sum#:	0	1.7	9.8	14.3	17.5	986,364.8	0.00 #	24.00 #
Minimum:	0	1.5	8.3	13.8	13.7	708,840.1	0.00	1.00
Maximum:	1	2.0	15.1	14.6	21.7	1,063,847.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2022 00:00	0	1.7	8.4	14.3	16.6	1,025,615.9	0.00	1.00
10/24/2022 01:00	0	1.7	8.4	14.3	16.0	996,360.0	0.00	1.00
10/24/2022 02:00	0	1.7	8.7	14.3	17.0	1,040,970.0	0.00	1.00
10/24/2022 03:00	0	1.7	8.7	14.3	17.2	1,038,480.2	0.00	1.00
10/24/2022 04:00	0	1.7	8.6	14.3	17.0	1,034,330.4	0.00	1.00
10/24/2022 05:00	0	1.7	9.0	14.2	18.3	1,022,776.1	0.00	1.00
10/24/2022 06:00	1	2.0	13.8	13.1	28.1	1,106,951.4	0.00	1.00
10/24/2022 07:00	1	1.9	12.1	13.5	24.4	1,074,072.9	0.00	1.00
10/24/2022 08:00	0	1.7	10.5	14.1	21.4	1,072,782.9	0.00	1.00
10/24/2022 09:00	0	1.8	10.9	14.0	21.4	1,063,387.8	0.00	1.00
10/24/2022 10:00	0	1.7	10.5	14.1	20.5	1,061,102.5	0.00	1.00
10/24/2022 11:00	0	1.7	8.8	14.4	16.0	979,665.1	0.00	1.00
10/24/2022 12:00	1	1.9	17.3	14.6	26.9	664,496.9	0.00	1.00
10/24/2022 13:00	1	1.6	18.4	14.7	29.4	660,857.7	0.00	1.00
10/24/2022 14:00	0	1.5	10.8	14.4	12.2	918,567.7	0.00	1.00
10/24/2022 15:00	0	1.7	9.2	14.2	18.1	1,061,406.1	0.00	1.00
10/24/2022 16:00	1	1.9	12.1	13.5	22.9	1,083,880.9	0.00	1.00
10/24/2022 17:00	1	1.8	10.9	13.7	21.5	1,077,470.7	0.00	1.00
10/24/2022 18:00	0	1.7	9.5	14.1	19.0	1,063,317.8	0.00	1.00
10/24/2022 19:00	0	1.8	10.9	13.9	20.5	1,070,303.0	0.00	1.00
10/24/2022 20:00	0	1.8	10.8	13.9	19.7	1,043,110.1	0.00	1.00
10/24/2022 21:00	1	1.6	10.0	14.2	16.8	831,669.8	0.00	1.00
10/24/2022 22:00	1	1.5	14.5	14.4	22.7	704,937.5	0.00	1.00
10/24/2022 23:00	1	1.5	12.8	14.3	17.3	744,468.9	0.00	1.00
Average/Sum#:	0	1.7	11.1	14.1	20.0	976,707.6	0.00 #	24.00 #
Minimum:	0	1.5	8.4	13.1	12.2	660,857.7	0.00	1.00
Maximum:	1	2.0	18.4	14.7	29.4	1,106,951.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2022 00:00	1	1.6	16.3	14.5	25.1	676,581.2	0.00	1.00
10/25/2022 01:00	1	1.6	15.6	14.5	23.5	678,507.0	0.00	1.00
10/25/2022 02:00	1	1.7	16.0	14.5	23.6	678,507.0	0.00	1.00
10/25/2022 03:00	1	1.6	15.0	14.5	22.3	692,415.2	0.00	1.00
10/25/2022 04:00	0	1.6	8.4	14.2	7.7	925,894.4	0.00	1.00
10/25/2022 05:00	0	1.7	8.1	14.3	14.3	1,012,129.1	0.00	1.00
10/25/2022 06:00	1	1.9	10.9	13.7	21.7	1,094,398.3	0.00	1.00
10/25/2022 07:00	1	1.8	10.4	13.8	20.2	1,046,934.6	0.00	1.00
10/25/2022 08:00	0	1.6	8.9	14.1	13.6	826,689.3	0.00	1.00
10/25/2022 09:00	1	1.6	9.8	14.2	16.4	798,762.8	0.00	1.00
10/25/2022 10:00	1	1.6	17.1	14.6	27.0	666,018.5	0.00	1.00
10/25/2022 11:00	1	1.6	14.6	14.6	20.8	683,842.7	0.00	1.00
10/25/2022 12:00	0	1.5	11.0	14.5	13.6	842,837.9	0.00	1.00
10/25/2022 13:00	0	1.8	11.5	13.7	18.0	1,065,678.4	0.00	1.00
10/25/2022 14:00	0	2.0	12.5	13.3	22.1	1,073,376.5	0.00	1.00
10/25/2022 15:00	1	1.9	11.8	13.3	21.9	1,064,186.9	0.00	1.00
10/25/2022 16:00	1	2.0	13.0	13.0	25.0	1,078,551.7	0.00	1.00
10/25/2022 17:00	1	2.0	12.5	13.1	23.2	1,068,326.6	0.00	1.00
10/25/2022 18:00	1	1.9	11.2	13.5	21.5	1,071,667.1	0.00	1.00
10/25/2022 19:00	1	1.9	10.9	13.6	21.4	1,078,468.6	0.00	1.00
10/25/2022 20:00	1	1.9	11.3	13.4	22.3	1,068,881.4	0.00	1.00
10/25/2022 21:00	0	1.8	9.7	13.9	18.3	1,032,937.2	0.00	1.00
10/25/2022 22:00	1	1.6	15.1	14.4	24.9	689,347.2	0.00	1.00
10/25/2022 23:00	1	1.6	11.8	14.2	16.4	720,889.5	0.00	1.00
Average/Sum#:	1	1.7	12.2	14.0	20.2	901,492.9	0.00 #	24.00 #
Minimum:	0	1.5	8.1	13.0	7.7	666,018.5	0.00	1.00
Maximum:	1	2.0	17.1	14.6	27.0	1,094,398.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2022 00:00	1	1.6	15.2	14.5	23.3	679,362.9	0.00	1.00
10/26/2022 01:00	1	1.6	15.2	14.5	23.1	680,218.8	0.00	1.00
10/26/2022 02:00	1	1.6	15.3	14.5	22.2	684,284.2	0.00	1.00
10/26/2022 03:00	0	1.7	9.5	14.3	9.2	857,757.6	0.00	1.00
10/26/2022 04:00	0	1.7	8.3	14.3	13.5	943,035.4	0.00	1.00
10/26/2022 05:00	0	1.7	8.3	14.3	14.3	988,890.4	0.00	1.00
10/26/2022 06:00	0	1.7	8.4	14.3	16.3	1,040,347.6	0.00	1.00
10/26/2022 07:00	0	1.6	9.1	14.3	16.1	945,732.8	0.00	1.00
10/26/2022 08:00	0	1.7	9.5	14.1	17.9	1,031,096.0	0.00	1.00
10/26/2022 09:00	1	1.8	10.4	13.9	20.9	1,067,172.9	0.00	1.00
10/26/2022 10:00	1	1.8	10.7	13.7	21.0	1,054,266.6	0.00	1.00
10/26/2022 11:00	1	1.6	12.5	14.4	20.4	782,046.7	0.00	1.00
10/26/2022 12:00	1	1.6	16.0	14.6	25.5	658,410.5	0.00	1.00
10/26/2022 13:00	1	1.6	16.2	14.7	24.4	666,158.7	0.00	1.00
10/26/2022 14:00	0	1.6	12.6	14.5	15.7	756,607.0	0.00	1.00
10/26/2022 15:00	1	1.4	13.4	14.6	18.5	754,705.0	0.00	1.00
10/26/2022 16:00	1	1.5	10.2	14.3	16.2	918,136.8	0.00	1.00
10/26/2022 17:00	0	1.8	10.8	13.8	20.1	1,054,456.8	0.00	1.00
10/26/2022 18:00	0	1.7	9.6	14.2	18.9	1,038,309.8	0.00	1.00
10/26/2022 19:00	1	1.6	13.3	14.4	21.1	703,673.5	0.00	1.00
10/26/2022 20:00	1	1.6	11.2	14.4	16.8	779,307.8	0.00	1.00
10/26/2022 21:00	1	1.6	13.7	14.4	20.8	701,777.3	0.00	1.00
10/26/2022 22:00	1	1.7	15.9	14.5	26.0	674,655.5	0.00	1.00
10/26/2022 23:00	1	1.5	16.0	14.5	24.1	680,218.8	0.00	1.00
Average/Sum#:	1	1.6	12.1	14.3	19.4	839,192.9	0.00 #	24.00 #
Minimum:	0	1.4	8.3	13.7	9.2	658,410.5	0.00	1.00
Maximum:	1	1.8	16.2	14.7	26.0	1,067,172.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2022 00:00	2	1.6	19.8	14.6	33.2	661,671.1	0.00	1.00
10/27/2022 01:00	1	1.6	18.3	14.6	28.0	674,061.1	0.00	1.00
10/27/2022 02:00	1	1.6	17.8	14.5	27.1	672,729.7	0.00	1.00
10/27/2022 03:00	1	1.6	16.1	14.4	23.0	689,768.5	0.00	1.00
10/27/2022 04:00	1	1.5	12.9	14.4	16.3	795,108.9	0.00	1.00
10/27/2022 05:00	0	1.5	9.8	14.3	14.3	895,935.5	0.00	1.00
10/27/2022 06:00	1	1.7	11.7	14.3	22.8	872,904.3	0.00	1.00
10/27/2022 07:00	0	1.5	8.6	14.2	8.0	917,923.1	0.00	1.00
10/27/2022 08:00	0	1.7	8.2	14.4	14.8	1,019,694.5	0.00	1.00
10/27/2022 09:00	1	1.7	9.5	14.1	19.7	1,053,047.1	0.00	1.00
10/27/2022 10:00	1	1.7	9.6	14.2	15.4	927,529.5	0.00	1.00
10/27/2022 11:00	1	1.9	10.1	14.1	19.2	1,048,012.4	0.00	1.00
10/27/2022 12:00	2	1.8	11.2	14.0	19.8	1,051,479.8	0.00	1.00
10/27/2022 13:00	4	1.7	10.7	14.1	19.3	930,201.7	0.00	1.00
10/27/2022 14:00	4	1.6	14.7	14.5	20.1	687,065.9	0.00	1.00
10/27/2022 15:00	5	1.5	13.8	14.6	20.2	774,920.3	0.00	1.00
10/27/2022 16:00	3	1.9	11.1	13.5	20.2	1,063,709.6	0.00	1.00
10/27/2022 17:00	3	1.9	10.4	13.7	20.1	1,068,151.0	0.00	1.00
10/27/2022 18:00	3	1.8	9.3	14.0	18.8	1,055,449.1	0.00	1.00
10/27/2022 19:00	3	1.8	9.7	13.9	19.6	1,064,825.3	0.00	1.00
10/27/2022 20:00	3	1.8	11.0	13.8	20.7	1,073,937.3	0.00	1.00
10/27/2022 21:00	2	1.8	11.3	13.8	20.4	1,075,094.6	0.00	1.00
10/27/2022 22:00	3	1.7	8.7	14.1	17.1	1,022,033.6	0.00	1.00
10/27/2022 23:00	2	1.7	7.9	14.2	13.2	937,544.7	0.00	1.00
Average/Sum#:	2	1.7	11.8	14.2	19.6	918,033.3	0.00 #	24.00 #
Minimum:	0	1.5	7.9	13.5	8.0	661,671.1	0.00	1.00
Maximum:	5	1.9	19.8	14.6	33.2	1,075,094.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2022 00:00	3	1.7	8.1	14.2	13.8	922,011.0	0.00	1.00
10/28/2022 01:00	2	1.7	8.1	14.1	12.9	869,181.7	0.00	1.00
10/28/2022 02:00	2	1.7	8.0	14.2	13.7	920,171.4	0.00	1.00
10/28/2022 03:00	4	1.8	8.2	14.2	14.6	998,044.7	0.00	1.00
10/28/2022 04:00	3	1.8	11.8	13.7	21.7	1,086,600.2	0.00	1.00
10/28/2022 05:00	3	1.9	12.3	13.6	24.0	1,105,294.3	0.00	1.00
10/28/2022 06:00	4	1.9	11.3	13.6	23.8	1,089,161.4	0.00	1.00
10/28/2022 07:00	3	1.7	9.0	14.1	17.7	1,023,242.0	0.00	1.00
10/28/2022 08:00	2	1.7	8.4	14.3	14.6	937,018.3	0.00	1.00
10/28/2022 09:00	3	1.7	8.1	14.4	16.1	1,012,110.0	0.00	1.00
10/28/2022 10:00	3	1.7	9.5	14.1	19.7	1,060,699.7	0.00	1.00
10/28/2022 11:00	8	1.5	10.7	14.3	21.0	882,241.3	0.00	1.00
10/28/2022 12:00	1	1.6	7.9	14.4	8.0	888,440.4	0.00	1.00
10/28/2022 13:00	5	1.9	9.7	14.4	13.9	848,411.1	0.00	1.00
10/28/2022 14:00	2	1.6	9.7	14.4	14.7	907,191.0	0.00	1.00
10/28/2022 15:00	3	1.8	10.7	13.7	20.3	1,071,955.0	0.00	1.00
10/28/2022 16:00	3	1.8	10.4	13.8	19.9	1,061,014.6	0.00	1.00
10/28/2022 17:00	4	2.0	12.3	13.1	23.5	1,072,013.5	0.00	1.00
10/28/2022 18:00	5	2.0	12.6	13.1	24.8	1,086,761.1	0.00	1.00
10/28/2022 19:00	5	2.0	12.6	13.1	24.7	1,086,936.7	0.00	1.00
10/28/2022 20:00	5	2.0	13.0	13.0	25.9	1,085,138.8	0.00	1.00
10/28/2022 21:00	5	2.0	13.0	13.0	25.8	1,087,565.6	0.00	1.00
10/28/2022 22:00	4	1.9	10.8	13.7	21.6	1,083,176.6	0.00	1.00
10/28/2022 23:00	2	1.7	8.0	14.3	15.1	1,027,068.3	0.00	1.00
Average/Sum#:	4	1.8	10.2	13.9	18.8	1,008,810.4	0.00 #	24.00 #
Minimum:	1	1.5	7.9	13.0	8.0	848,411.1	0.00	1.00
Maximum:	8	2.0	13.0	14.4	25.9	1,105,294.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2022 00:00	3	1.7	9.0	14.1	13.9	833,536.4	0.00	1.00
10/29/2022 01:00	3	1.7	8.5	14.1	13.2	852,063.9	0.00	1.00
10/29/2022 02:00	1	1.5	8.9	14.2	12.7	856,810.0	0.00	1.00
10/29/2022 03:00	8	1.6	15.8	14.4	26.1	676,706.3	0.00	1.00
10/29/2022 04:00	0	1.6	10.5	14.3	12.4	837,423.8	0.00	1.00
10/29/2022 05:00	2	1.7	8.3	14.3	15.3	1,003,414.6	0.00	1.00
10/29/2022 06:00	6	1.7	10.4	14.2	19.5	846,181.6	0.00	1.00
10/29/2022 07:00	2	1.5	10.4	14.3	13.4	857,135.2	0.00	1.00
10/29/2022 08:00	2	1.7	8.2	14.3	14.1	990,550.3	0.00	1.00
10/29/2022 09:00	2	1.7	8.2	14.3	13.3	901,952.7	0.00	1.00
10/29/2022 10:00	2	1.7	8.0	14.3	13.5	927,473.8	0.00	1.00
10/29/2022 11:00	3	1.9	10.1	14.4	13.6	835,980.9	0.00	1.00
10/29/2022 12:00	10	1.6	13.8	14.6	24.0	694,493.8	0.00	1.00
10/29/2022 13:00	2	1.3	12.2	14.5	15.3	719,161.8	0.00	1.00
10/29/2022 14:00	2	1.5	12.1	14.5	15.1	733,284.0	0.00	1.00
10/29/2022 15:00	4	1.8	12.5	14.6	15.0	763,399.8	0.00	1.00
10/29/2022 16:00	3	2.0	9.8	14.5	11.7	857,602.0	0.00	1.00
10/29/2022 17:00	3	2.1	9.0	14.4	10.7	873,692.8	0.00	1.00
10/29/2022 18:00	5	1.9	11.2	14.5	18.5	858,885.9	0.00	1.00
10/29/2022 19:00	3	1.6	12.5	14.5	17.0	731,144.2	0.00	1.00
10/29/2022 20:00	2	1.7	8.5	14.3	16.3	1,053,419.3	0.00	1.00
10/29/2022 21:00	3	1.8	10.0	14.1	19.0	1,063,921.9	0.00	1.00
10/29/2022 22:00	2	1.7	8.2	14.3	14.0	954,447.3	0.00	1.00
10/29/2022 23:00	3	1.7	8.0	14.4	16.1	1,046,240.2	0.00	1.00
Average/Sum#:	3	1.7	10.2	14.4	15.6	865,371.8	0.00 #	24.00 #
Minimum:	0	1.3	8.0	14.1	10.7	676,706.3	0.00	1.00
Maximum:	10	2.1	15.8	14.6	26.1	1,063,921.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2022 00:00	3	1.7	8.0	14.3	15.3	998,849.8	0.00	1.00
10/30/2022 01:00	2	1.7	8.2	14.3	14.2	936,395.8	0.00	1.00
10/30/2022 02:00	2	1.7	8.5	14.3	15.1	964,614.2	0.00	1.00
10/30/2022 03:00	3	1.7	8.5	14.3	15.3	963,991.8	0.00	1.00
10/30/2022 04:00	2	1.7	8.4	14.3	15.3	982,458.3	0.00	1.00
10/30/2022 05:00	3	1.7	8.4	14.4	17.2	1,076,999.6	0.00	1.00
10/30/2022 06:00	3	1.7	8.3	14.3	16.5	1,036,612.8	0.00	1.00
10/30/2022 07:00	9	1.6	16.0	14.4	27.4	688,925.8	0.00	1.00
10/30/2022 08:00	6	1.7	16.9	14.5	25.0	666,310.6	0.00	1.00
10/30/2022 09:00	6	1.7	16.2	14.6	24.6	672,322.2	0.00	1.00
10/30/2022 10:00	6	1.7	15.5	14.6	22.9	670,365.8	0.00	1.00
10/30/2022 11:00	5	1.7	15.1	14.6	22.2	669,279.0	0.00	1.00
10/30/2022 12:00	5	1.7	14.6	14.6	21.3	668,192.2	0.00	1.00
10/30/2022 13:00	5	1.7	14.4	14.6	21.0	667,322.7	0.00	1.00
10/30/2022 14:00	5	1.7	14.4	14.6	20.7	666,453.2	0.00	1.00
10/30/2022 15:00	2	1.6	12.6	14.6	15.6	725,142.8	0.00	1.00
10/30/2022 16:00	-1	1.7	7.8	14.4	10.3	988,935.1	0.00	1.00
10/30/2022 17:00	2	1.7	7.9	14.3	13.9	1,010,261.7	0.00	1.00
10/30/2022 18:00	3	1.7	8.8	14.1	17.6	1,048,818.0	0.00	1.00
10/30/2022 19:00	2	1.7	7.6	14.3	12.8	965,651.7	0.00	1.00
10/30/2022 20:00	2	1.7	7.6	14.3	12.8	943,035.4	0.00	1.00
10/30/2022 21:00	2	1.7	7.8	14.3	13.3	950,090.0	0.00	1.00
10/30/2022 22:00	2	1.7	8.0	14.2	13.0	906,681.6	0.00	1.00
10/30/2022 23:00	2	1.7	7.8	14.3	13.7	955,692.2	0.00	1.00
Average/Sum#:	3	1.7	10.7	14.4	17.4	867,641.8	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.1	10.3	666,310.6	0.00	1.00
Maximum:	9	1.7	16.9	14.6	27.4	1,076,999.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2022 00:00	2	1.7	8.0	14.2	13.9	939,384.2	0.00	1.00
10/31/2022 01:00	2	1.7	7.9	14.2	13.5	927,938.3	0.00	1.00
10/31/2022 02:00	2	1.7	8.1	14.3	14.0	964,406.7	0.00	1.00
10/31/2022 03:00	1	1.7	8.4	14.2	13.6	935,296.4	0.00	1.00
10/31/2022 04:00	2	1.7	8.1	14.3	15.0	1,010,676.7	0.00	1.00
10/31/2022 05:00	3	1.7	9.9	13.9	19.4	1,021,590.6	0.00	1.00
10/31/2022 06:00	4	1.9	11.0	13.6	22.0	1,065,337.1	0.00	1.00
10/31/2022 07:00	5	1.6	10.8	14.2	19.9	892,374.2	0.00	1.00
10/31/2022 08:00	5	1.6	10.7	14.3	16.9	822,069.6	0.00	1.00
10/31/2022 09:00	1	1.5	10.6	14.3	11.4	780,986.9	0.00	1.00
10/31/2022 10:00	6	1.6	12.8	14.4	20.7	709,783.2	0.00	1.00
10/31/2022 11:00	5	1.6	13.7	14.5	20.0	671,659.9	0.00	1.00
10/31/2022 12:00	5	1.6	13.6	14.5	19.7	671,017.9	0.00	1.00
10/31/2022 13:00	1	1.5	10.2	14.3	11.0	752,768.4	0.00	1.00
10/31/2022 14:00	1	1.7	9.1	14.1	13.5	960,610.9	0.00	1.00
10/31/2022 15:00	1	1.8	10.5	13.8	17.3	1,039,991.0	0.00	1.00
10/31/2022 16:00	2	1.5	8.8	14.2	11.0	833,713.7	0.00	1.00
10/31/2022 17:00	7	1.6	13.8	14.5	22.3	669,092.2	0.00	1.00
10/31/2022 18:00	5	1.6	14.4	14.5	20.9	665,882.6	0.00	1.00
10/31/2022 19:00	4	1.5	11.6	14.3	14.9	723,305.1	0.00	1.00
10/31/2022 20:00	2	1.5	10.3	14.2	11.9	747,460.4	0.00	1.00
10/31/2022 21:00	0	1.6	7.8	14.2	8.2	859,671.5	0.00	1.00
10/31/2022 22:00	5	1.6	11.3	14.3	17.1	764,180.3	0.00	1.00
10/31/2022 23:00	1	1.6	7.5	14.3	11.6	1,013,996.5	0.00	1.00
Average/Sum#:	3	1.6	10.4	14.2	15.8	851,799.8	0.00 #	24.00 #
Minimum:	0	1.5	7.5	13.6	8.2	665,882.6	0.00	1.00
Maximum:	7	1.9	14.4	14.5	22.3	1,065,337.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022 00:00	2	1.7	7.7	14.3	14.3	1,012,959.1	0.00	1.00
11/01/2022 01:00	3	1.7	8.1	14.2	16.3	1,021,958.5	0.00	1.00
11/01/2022 02:00	3	1.7	11.4	13.5	21.7	1,065,005.0	0.00	1.00
11/01/2022 03:00	4	1.9	12.3	13.2	24.2	1,063,882.7	0.00	1.00
11/01/2022 04:00	4	2.0	13.1	13.0	24.9	1,070,577.8	0.00	1.00
11/01/2022 05:00	4	2.0	12.6	13.2	23.5	1,074,020.0	0.00	1.00
11/01/2022 06:00	6	2.1	13.8	12.7	28.0	1,070,155.1	0.00	1.00
11/01/2022 07:00	5	2.0	12.2	13.2	23.4	1,056,946.6	0.00	1.00
11/01/2022 08:00	4	1.9	11.0	13.5	21.2	1,057,047.6	0.00	1.00
11/01/2022 09:00	3	1.8	9.8	13.8	18.8	1,034,976.2	0.00	1.00
11/01/2022 10:00	3	1.8	9.8	13.8	19.2	1,042,884.2	0.00	1.00
11/01/2022 11:00	3	1.9	10.8	13.5	20.4	1,057,602.8	0.00	1.00
11/01/2022 12:00	4	1.9	11.6	13.3	21.6	1,069,052.0	0.00	1.00
11/01/2022 13:00	4	2.0	11.7	13.3	22.4	1,058,781.3	0.00	1.00
11/01/2022 14:00	3	1.8	9.3	14.0	18.7	1,049,296.6	0.00	1.00
11/01/2022 15:00	3	1.8	9.6	13.9	19.0	1,048,783.4	0.00	1.00
11/01/2022 16:00	4	1.9	11.6	13.4	22.3	1,062,308.1	0.00	1.00
11/01/2022 17:00	3	1.9	11.2	13.6	21.4	1,067,588.2	0.00	1.00
11/01/2022 18:00	4	1.9	10.9	13.7	22.0	1,076,139.3	0.00	1.00
11/01/2022 19:00	4	1.8	11.0	13.7	22.2	1,075,758.9	0.00	1.00
11/01/2022 20:00	4	1.8	10.8	13.7	21.8	1,070,243.2	0.00	1.00
11/01/2022 21:00	3	1.8	10.1	13.9	20.2	1,064,042.7	0.00	1.00
11/01/2022 22:00	3	1.8	10.0	14.0	19.9	1,056,243.0	0.00	1.00
11/01/2022 23:00	4	1.7	9.0	14.2	15.7	883,789.7	0.00	1.00
Average/Sum#:	4	1.9	10.8	13.6	21.0	1,050,418.4	0.00 #	24.00 #
Minimum:	2	1.7	7.7	12.7	14.3	883,789.7	0.00	1.00
Maximum:	6	2.1	13.8	14.3	28.0	1,076,139.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2022 00:00	8	1.6	15.4	14.4	24.7	673,756.8	0.00	1.00
11/02/2022 01:00	0	1.6	8.6	14.2	9.7	838,823.5	0.00	1.00
11/02/2022 02:00	1	1.8	10.4	14.3	15.0	761,275.5	0.00	1.00
11/02/2022 03:00	2	1.8	8.2	14.2	13.2	904,024.5	0.00	1.00
11/02/2022 04:00	2	1.7	8.2	14.3	15.1	997,812.4	0.00	1.00
11/02/2022 05:00	3	1.7	8.3	14.3	16.3	1,043,252.4	0.00	1.00
11/02/2022 06:00	3	1.8	11.4	13.8	21.7	1,078,373.5	0.00	1.00
11/02/2022 07:00	6	1.6	11.7	14.3	21.3	871,451.9	0.00	1.00
11/02/2022 08:00	6	1.6	14.9	14.4	22.6	687,451.0	0.00	1.00
11/02/2022 09:00	6	1.6	13.8	14.4	20.6	699,459.8	0.00	1.00
11/02/2022 10:00	-1	1.6	8.6	14.3	10.1	925,398.9	0.00	1.00
11/02/2022 11:00	3	1.7	9.7	14.1	19.2	1,070,567.7	0.00	1.00
11/02/2022 12:00	3	1.8	9.5	14.1	19.1	1,061,908.1	0.00	1.00
11/02/2022 13:00	2	1.7	8.2	14.3	15.2	973,743.7	0.00	1.00
11/02/2022 14:00	3	1.7	9.5	14.1	19.7	1,046,804.1	0.00	1.00
11/02/2022 15:00	3	1.8	10.0	14.0	20.2	1,052,869.0	0.00	1.00
11/02/2022 16:00	4	1.8	11.5	13.5	23.3	1,053,346.4	0.00	1.00
11/02/2022 17:00	5	2.0	13.0	13.1	25.0	1,064,113.0	0.00	1.00
11/02/2022 18:00	4	1.8	11.0	13.7	21.7	1,067,009.8	0.00	1.00
11/02/2022 19:00	4	1.8	10.9	13.7	22.4	1,066,629.4	0.00	1.00
11/02/2022 20:00	4	1.9	12.6	13.2	25.1	1,072,775.0	0.00	1.00
11/02/2022 21:00	4	1.9	11.8	13.4	23.9	1,073,446.1	0.00	1.00
11/02/2022 22:00	4	1.9	10.9	13.7	22.0	1,066,819.6	0.00	1.00
11/02/2022 23:00	3	1.7	8.4	14.3	16.7	1,045,119.8	0.00	1.00
Average/Sum#:	3	1.7	10.7	14.0	19.3	966,509.7	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	13.1	9.7	673,756.8	0.00	1.00
Maximum:	8	2.0	15.4	14.4	25.1	1,078,373.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2022 00:00	3	1.7	8.5	14.3	17.3	1,047,609.7	0.00	1.00
11/03/2022 01:00	3	1.7	8.4	14.3	16.8	1,028,520.7	0.00	1.00
11/03/2022 02:00	2	1.6	8.7	14.3	17.1	1,024,993.4	0.00	1.00
11/03/2022 03:00	2	1.7	8.7	14.3	17.8	1,048,439.6	0.00	1.00
11/03/2022 04:00	3	1.7	8.8	14.3	17.8	1,051,759.4	0.00	1.00
11/03/2022 05:00	7	2.1	14.6	12.8	31.0	1,100,780.5	0.00	1.00
11/03/2022 06:00	8	2.2	15.9	12.4	34.1	1,095,700.6	0.00	1.00
11/03/2022 07:00	3	1.7	9.5	14.1	18.9	1,037,943.1	0.00	1.00
11/03/2022 08:00	2	1.7	8.6	14.2	15.5	978,831.8	0.00	1.00
11/03/2022 09:00	4	1.7	9.3	14.1	19.9	1,044,387.5	0.00	1.00
11/03/2022 10:00	4	2.0	10.7	13.9	21.4	1,072,650.6	0.00	1.00
11/03/2022 11:00	3	1.6	8.8	14.2	14.0	862,328.6	0.00	1.00
11/03/2022 12:00	10	1.6	15.7	14.5	27.9	678,721.0	0.00	1.00
11/03/2022 13:00	6	1.6	15.5	14.5	23.0	670,376.0	0.00	1.00
11/03/2022 14:00	7	1.5	17.2	14.6	26.3	661,019.0	0.00	1.00
11/03/2022 15:00	6	1.6	17.2	14.6	25.5	676,886.9	0.00	1.00
11/03/2022 16:00	1	1.6	9.5	14.4	14.1	955,436.9	0.00	1.00
11/03/2022 17:00	3	1.9	11.5	13.6	22.0	1,064,961.9	0.00	1.00
11/03/2022 18:00	4	1.8	11.1	13.7	22.7	1,068,151.0	0.00	1.00
11/03/2022 19:00	4	1.8	11.1	13.7	23.3	1,070,243.2	0.00	1.00
11/03/2022 20:00	5	2.0	13.5	13.1	27.2	1,084,654.3	0.00	1.00
11/03/2022 21:00	6	2.0	14.2	12.9	29.0	1,080,818.2	0.00	1.00
11/03/2022 22:00	4	1.9	12.2	13.5	24.8	1,070,371.7	0.00	1.00
11/03/2022 23:00	4	1.7	9.9	14.1	21.8	1,078,623.1	0.00	1.00
Average/Sum#:	4	1.8	11.6	13.9	22.1	981,425.4	0.00 #	24.00 #
Minimum:	1	1.5	8.4	12.4	14.0	661,019.0	0.00	1.00
Maximum:	10	2.2	17.2	14.6	34.1	1,100,780.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2022 00:00	3	1.7	8.7	14.3	16.6	1,010,469.2	0.00	1.00
11/04/2022 01:00	3	1.7	8.5	14.3	16.6	998,227.4	0.00	1.00
11/04/2022 02:00	2	1.8	8.7	14.2	14.6	910,565.0	0.00	1.00
11/04/2022 03:00	3	1.7	8.4	14.3	15.3	961,501.9	0.00	1.00
11/04/2022 04:00	3	1.7	8.3	14.3	16.4	1,019,391.2	0.00	1.00
11/04/2022 05:00	5	1.9	12.2	13.5	25.3	1,084,436.1	0.00	1.00
11/04/2022 06:00	4	1.9	12.4	13.4	24.9	1,083,123.4	0.00	1.00
11/04/2022 07:00	9	1.7	12.9	14.3	26.0	867,717.1	0.00	1.00
11/04/2022 08:00	5	1.5	17.7	14.6	25.3	698,406.4	0.00	1.00
11/04/2022 09:00	8	1.5	14.6	14.4	23.4	688,083.1	0.00	1.00
11/04/2022 10:00	7	1.6	16.1	14.5	24.9	663,314.9	0.00	1.00
11/04/2022 11:00	10	1.6	19.4	14.7	32.5	661,299.5	0.00	1.00
11/04/2022 12:00	5	1.6	16.3	14.6	23.9	669,713.7	0.00	1.00
11/04/2022 13:00	7	1.7	17.5	14.6	26.8	654,497.9	0.00	1.00
11/04/2022 14:00	7	1.8	17.3	14.7	26.7	662,624.7	0.00	1.00
11/04/2022 15:00	2	1.5	12.8	14.5	14.9	777,576.3	0.00	1.00
11/04/2022 16:00	3	1.7	11.0	14.5	14.1	809,244.2	0.00	1.00
11/04/2022 17:00	1	1.8	7.9	14.4	11.4	983,246.7	0.00	1.00
11/04/2022 18:00	1	2.0	11.7	13.8	19.6	1,055,228.3	0.00	1.00
11/04/2022 19:00	1	2.0	11.9	13.8	20.2	1,056,385.5	0.00	1.00
11/04/2022 20:00	1	2.0	10.9	13.9	18.3	1,032,546.0	0.00	1.00
11/04/2022 21:00	8	2.2	14.9	14.4	23.5	682,816.1	0.00	1.00
11/04/2022 22:00	10	1.8	18.9	14.6	31.6	654,715.3	0.00	1.00
11/04/2022 23:00	9	0.8	12.3	14.3	19.2	722,890.1	0.00	1.00
Average/Sum#:	5	1.7	13.0	14.3	21.3	850,334.2	0.00 #	24.00 #
Minimum:	1	0.8	7.9	13.4	11.4	654,497.9	0.00	1.00
Maximum:	10	2.2	19.4	14.7	32.5	1,084,436.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2022 00:00	7	1.8	15.8	14.5	24.2	666,524.5	0.00	1.00
11/05/2022 01:00	6	1.8	15.7	14.5	23.7	666,310.6	0.00	1.00
11/05/2022 02:00	5	1.8	16.1	14.5	23.5	665,026.7	0.00	1.00
11/05/2022 03:00	7	1.8	15.9	14.5	24.6	662,459.0	0.00	1.00
11/05/2022 04:00	6	1.8	15.3	14.5	22.4	665,026.7	0.00	1.00
11/05/2022 05:00	3	1.6	12.7	14.4	16.2	721,581.3	0.00	1.00
11/05/2022 06:00	10	1.7	15.7	14.5	26.8	664,170.8	0.00	1.00
11/05/2022 07:00	2	1.6	11.2	14.4	12.9	801,218.6	0.00	1.00
11/05/2022 08:00	9	1.7	17.1	14.6	27.4	659,932.1	0.00	1.00
11/05/2022 09:00	5	1.7	15.6	14.5	22.2	657,109.7	0.00	1.00
11/05/2022 10:00	4	1.7	13.2	14.5	18.0	687,279.9	0.00	1.00
11/05/2022 11:00	4	1.6	11.7	14.4	16.0	708,519.1	0.00	1.00
11/05/2022 12:00	0	1.6	8.8	14.4	8.9	871,796.6	0.00	1.00
11/05/2022 13:00	2	1.6	9.7	14.3	11.3	761,483.0	0.00	1.00
11/05/2022 14:00	1	1.8	7.4	14.3	10.2	949,675.1	0.00	1.00
11/05/2022 15:00	8	1.7	15.0	14.5	23.4	662,245.1	0.00	1.00
11/05/2022 16:00	2	1.5	10.6	14.4	11.4	791,948.7	0.00	1.00
11/05/2022 17:00	1	1.9	7.8	14.2	11.3	946,129.2	0.00	1.00
11/05/2022 18:00	3	1.9	8.7	14.0	16.5	1,032,030.0	0.00	1.00
11/05/2022 19:00	3	1.9	8.6	14.1	16.3	1,029,283.5	0.00	1.00
11/05/2022 20:00	5	1.7	10.3	14.3	15.6	740,734.1	0.00	1.00
11/05/2022 21:00	6	1.7	12.4	14.4	18.9	676,917.0	0.00	1.00
11/05/2022 22:00	5	1.7	13.5	14.5	18.6	663,528.9	0.00	1.00
11/05/2022 23:00	-1	1.7	6.9	14.3	6.0	930,378.6	0.00	1.00
Average/Sum#:	4	1.7	12.3	14.4	17.8	761,721.2	0.00 #	24.00 #
Minimum:	-1	1.5	6.9	14.0	6.0	657,109.7	0.00	1.00
Maximum:	10	1.9	17.1	14.6	27.4	1,032,030.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2022 00:00	2	1.8	7.2	14.3	11.0	914,194.5	0.00	1.00
11/06/2022 01:00	2	1.8	7.9	14.1	11.0	774,127.5	0.00	1.00
11/06/2022 02:00	-1	1.8	7.2	14.3	10.1	823,729.5	0.00	1.00
11/06/2022 03:00	2	1.8	7.4	14.3	12.3	965,029.2	0.00	1.00
11/06/2022 04:00	2	1.8	7.8	14.3	13.5	958,597.1	0.00	1.00
11/06/2022 05:00	2	1.8	7.9	14.4	14.9	1,034,020.8	0.00	1.00
11/06/2022 06:00	2	1.8	7.9	14.4	15.0	1,046,029.5	0.00	1.00
11/06/2022 07:00	2	1.8	7.8	14.4	15.1	1,045,397.5	0.00	1.00
11/06/2022 08:00	3	1.9	10.6	13.8	19.5	1,041,341.2	0.00	1.00
11/06/2022 09:00	2	1.9	9.8	14.0	17.0	1,012,183.2	0.00	1.00
11/06/2022 10:00	5	1.7	11.9	14.4	16.3	713,786.1	0.00	1.00
11/06/2022 11:00	6	1.9	12.8	14.5	19.8	676,153.3	0.00	1.00
11/06/2022 12:00	5	1.8	14.6	14.5	20.8	653,900.1	0.00	1.00
11/06/2022 13:00	6	1.8	13.0	14.5	18.8	674,227.5	0.00	1.00
11/06/2022 14:00	0	1.7	10.6	14.4	10.5	792,370.0	0.00	1.00
11/06/2022 15:00	2	2.0	9.6	13.9	15.9	1,015,330.4	0.00	1.00
11/06/2022 16:00	4	2.2	11.6	13.3	21.7	1,047,789.8	0.00	1.00
11/06/2022 17:00	3	2.1	10.2	13.7	18.0	1,040,382.1	0.00	1.00
11/06/2022 18:00	3	2.0	9.4	14.0	17.8	1,048,304.3	0.00	1.00
11/06/2022 19:00	3	2.0	9.1	14.0	17.6	1,028,457.6	0.00	1.00
11/06/2022 20:00	3	2.0	9.0	14.0	17.4	1,042,151.8	0.00	1.00
11/06/2022 21:00	3	2.0	9.6	14.0	17.1	1,048,502.8	0.00	1.00
11/06/2022 22:00	5	1.9	10.5	14.3	18.0	848,628.1	0.00	1.00
11/06/2022 23:00	5	1.8	13.3	14.4	19.1	663,222.8	0.00	1.00
Average/Sum#:	3	1.9	9.9	14.2	16.2	912,827.4	0.00 #	24.00 #
Minimum:	-1	1.7	7.2	13.3	10.1	653,900.1	0.00	1.00
Maximum:	6	2.2	14.6	14.5	21.7	1,048,502.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2022 00:00	4	1.6	10.3	14.2	13.0	724,159.8	0.00	1.00
11/07/2022 01:00	2	1.7	9.5	14.3	11.5	821,654.6	0.00	1.00
11/07/2022 02:00	1	2.1	7.8	14.2	9.4	863,350.5	0.00	1.00
11/07/2022 03:00	3	1.9	8.5	14.2	12.8	810,208.7	0.00	1.00
11/07/2022 04:00	3	1.7	10.0	14.3	11.0	778,497.0	0.00	1.00
11/07/2022 05:00	2	1.8	7.8	14.3	12.0	952,787.4	0.00	1.00
11/07/2022 06:00	2	1.9	8.0	14.3	14.6	1,025,408.4	0.00	1.00
11/07/2022 07:00	2	1.9	7.8	14.2	12.3	898,710.3	0.00	1.00
11/07/2022 08:00	8	1.8	14.6	14.4	23.3	660,273.2	0.00	1.00
11/07/2022 09:00	3	1.7	14.1	14.5	21.2	668,450.3	0.00	1.00
11/07/2022 10:00	1	1.6	14.7	14.5	22.4	662,673.0	0.00	1.00
11/07/2022 11:00	1	1.6	15.4	14.5	24.9	655,825.9	0.00	1.00
11/07/2022 12:00	0	1.6	15.0	14.5	21.3	660,961.2	0.00	1.00
11/07/2022 13:00	1	1.6	14.5	14.5	21.9	662,673.0	0.00	1.00
11/07/2022 14:00	0	1.3	9.4	14.3	9.3	832,029.1	0.00	1.00
11/07/2022 15:00	0	1.8	9.9	13.9	16.0	984,811.8	0.00	1.00
11/07/2022 16:00	0	1.9	11.1	13.5	21.1	1,052,976.3	0.00	1.00
11/07/2022 17:00	0	1.9	11.0	13.5	21.5	1,052,791.3	0.00	1.00
11/07/2022 18:00	0	1.9	10.6	13.6	21.0	1,048,453.8	0.00	1.00
11/07/2022 19:00	0	1.9	10.8	13.6	21.0	1,060,647.3	0.00	1.00
11/07/2022 20:00	0	1.9	10.8	13.5	21.4	1,053,161.4	0.00	1.00
11/07/2022 21:00	0	1.9	11.1	13.5	22.2	1,058,157.9	0.00	1.00
11/07/2022 22:00	0	1.8	9.9	13.9	20.1	1,062,477.7	0.00	1.00
11/07/2022 23:00	1	2.2	12.3	14.3	18.6	867,094.6	0.12	1.00
Average/Sum#:	1	1.8	11.0	14.1	17.7	871,593.1	0.12 #	24.00 #
Minimum:	0	1.3	7.8	13.5	9.3	655,825.9	0.00	1.00
Maximum:	8	2.2	15.4	14.5	24.9	1,062,477.7	0.12	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2022 00:00	0	14.3	28.9	17.4	0.0	362,701.8	0.03	0.03
11/08/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	14.3	28.9	17.4	0.0	362,701.8	0.03 #	0.03 #
Minimum:	0	14.3	28.9	17.4	0.0	362,701.8	0.00	0.00
Maximum:	0	14.3	28.9	17.4	0.0	362,701.8	0.03	0.03
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2022 20:00	0	16.6	20.3	16.1	0.0	720,659.6	0.48	0.48
11/09/2022 21:00	1	3.2	14.5	14.3	21.3	716,250.5	0.53	1.00
11/09/2022 22:00	1	1.7	18.5	14.5	27.2	667,594.4	0.00	1.00
11/09/2022 23:00	0	1.6	18.1	14.5	24.9	672,943.7	0.00	1.00
Average/Sum#:	1	5.8	17.9	14.9	18.4	694,362.1	1.01 #	3.48 #
Minimum:	0	1.6	14.5	14.3	0.0	667,594.4	0.00	0.00
Maximum:	1	16.6	20.3	16.1	27.2	720,659.6	0.53	1.00
%SI	87.50	83.33	83.33	83.33	83.33	83.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2022 00:00	0	1.5	17.1	14.4	23.2	676,917.0	0.00	1.00
11/10/2022 01:00	1	1.6	19.0	14.5	28.2	671,873.8	0.00	1.00
11/10/2022 02:00	1	1.6	19.1	14.5	26.9	673,371.6	0.00	1.00
11/10/2022 03:00	0	1.5	14.2	14.3	13.6	748,411.2	0.00	1.00
11/10/2022 04:00	0	1.8	9.2	14.2	9.4	889,717.1	0.00	1.00
11/10/2022 05:00	0	1.7	9.4	14.2	14.7	976,174.8	0.00	1.00
11/10/2022 06:00	0	2.0	14.5	13.0	26.1	1,090,512.5	0.00	1.00
11/10/2022 07:00	0	1.8	11.0	14.0	20.7	1,073,906.6	0.00	1.00
11/10/2022 08:00	1	1.6	15.8	14.4	24.1	763,928.1	0.00	1.00
11/10/2022 09:00	0	1.4	11.1	14.2	14.0	759,315.2	0.00	1.00
11/10/2022 10:00	1	1.5	18.3	14.6	29.6	698,623.8	0.00	1.00
11/10/2022 11:00	1	1.6	20.2	14.7	30.1	665,054.3	0.00	1.00
11/10/2022 12:00	1	1.6	19.4	14.6	28.8	654,497.9	0.00	1.00
11/10/2022 13:00	1	1.6	18.9	14.6	27.8	653,628.4	0.00	1.00
11/10/2022 14:00	1	1.6	18.6	14.6	27.4	653,193.7	0.00	1.00
11/10/2022 15:00	0	1.5	13.3	14.4	15.4	836,402.3	0.00	1.00
11/10/2022 16:00	0	2.0	12.8	13.3	21.2	1,067,250.1	0.00	1.00
11/10/2022 17:00	0	1.9	12.3	13.3	23.1	1,060,222.8	0.00	1.00
11/10/2022 18:00	0	1.9	11.1	13.7	20.9	1,075,378.5	0.00	1.00
11/10/2022 19:00	0	1.8	10.7	13.8	20.6	1,073,165.8	0.00	1.00
11/10/2022 20:00	0	1.8	10.9	13.7	21.2	1,075,568.7	0.00	1.00
11/10/2022 21:00	0	1.9	12.2	13.3	23.5	1,071,214.2	0.00	1.00
11/10/2022 22:00	0	1.9	11.6	13.5	22.8	1,071,297.0	0.00	1.00
11/10/2022 23:00	0	1.8	10.6	13.8	21.2	1,072,394.3	0.00	1.00
Average/Sum#:	0	1.7	14.2	14.1	22.3	877,167.5	0.00 #	24.00 #
Minimum:	0	1.4	9.2	13.0	9.4	653,193.7	0.00	1.00
Maximum:	1	2.0	20.2	14.7	30.1	1,090,512.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2022 00:00	0	1.9	12.4	13.3	24.0	1,081,665.1	0.00	1.00
11/11/2022 01:00	0	1.9	11.7	13.5	23.0	1,083,695.8	0.00	1.00
11/11/2022 02:00	0	2.0	9.7	14.0	18.1	1,053,266.0	0.00	1.00
11/11/2022 03:00	0	1.7	8.3	14.3	14.7	990,135.3	0.00	1.00
11/11/2022 04:00	0	1.7	9.0	14.2	18.4	1,039,127.4	0.00	1.00
11/11/2022 05:00	0	1.9	13.0	13.3	23.6	1,082,926.4	0.00	1.00
11/11/2022 06:00	0	2.0	12.8	13.2	25.0	1,079,355.4	0.00	1.00
11/11/2022 07:00	0	1.7	9.7	14.1	18.9	1,045,797.2	0.00	1.00
11/11/2022 08:00	1	1.6	17.4	14.5	30.1	672,515.8	0.00	1.00
11/11/2022 09:00	1	1.6	16.5	14.5	24.2	668,450.3	0.00	1.00
11/11/2022 10:00	1	1.6	15.4	14.5	23.2	676,795.2	0.00	1.00
11/11/2022 11:00	1	1.6	15.2	14.5	22.9	667,166.4	0.00	1.00
11/11/2022 12:00	1	1.6	15.0	14.5	22.4	664,598.8	0.00	1.00
11/11/2022 13:00	1	1.6	14.9	14.5	22.0	665,026.7	0.00	1.00
11/11/2022 14:00	0	1.6	14.3	14.5	20.1	680,004.8	0.00	1.00
11/11/2022 15:00	0	1.7	10.1	14.0	14.3	952,444.6	0.00	1.00
11/11/2022 16:00	0	1.9	11.4	13.5	21.2	1,066,855.6	0.00	1.00
11/11/2022 17:00	0	1.8	10.5	13.7	20.3	1,056,739.1	0.00	1.00
11/11/2022 18:00	0	1.8	10.5	13.7	20.5	1,059,972.5	0.00	1.00
11/11/2022 19:00	0	1.8	10.5	13.7	20.7	1,059,211.7	0.00	1.00
11/11/2022 20:00	0	1.8	10.6	13.7	21.3	1,069,292.2	0.00	1.00
11/11/2022 21:00	0	2.0	12.2	13.3	23.4	1,073,376.5	0.00	1.00
11/11/2022 22:00	0	1.9	11.9	13.4	23.1	1,071,072.5	0.00	1.00
11/11/2022 23:00	0	1.8	10.7	13.7	21.2	1,073,476.6	0.00	1.00
Average/Sum#:	0	1.8	12.2	13.9	21.5	943,040.3	0.00 #	24.00 #
Minimum:	0	1.6	8.3	13.2	14.3	664,598.8	0.00	1.00
Maximum:	1	2.0	17.4	14.5	30.1	1,083,695.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2022 00:00	0	1.9	12.1	13.3	23.6	1,074,097.2	0.00	1.00
11/12/2022 01:00	0	1.9	12.1	13.3	23.7	1,073,556.6	0.00	1.00
11/12/2022 02:00	0	1.9	12.5	13.3	24.3	1,076,079.3	0.00	1.00
11/12/2022 03:00	1	2.0	13.4	13.0	24.9	1,066,070.9	0.00	1.00
11/12/2022 04:00	0	2.0	13.0	13.1	25.3	1,071,135.7	0.00	1.00
11/12/2022 05:00	0	2.0	12.6	13.2	24.4	1,077,932.6	0.00	1.00
11/12/2022 06:00	0	2.0	12.7	13.1	24.4	1,063,586.3	0.00	1.00
11/12/2022 07:00	0	1.8	9.8	14.0	19.5	1,070,135.7	0.00	1.00
11/12/2022 08:00	0	2.0	12.9	13.1	25.3	1,079,914.0	0.00	1.00
11/12/2022 09:00	0	1.9	11.1	13.6	21.6	1,070,402.1	0.00	1.00
11/12/2022 10:00	0	1.8	10.2	13.8	20.2	1,057,157.0	0.00	1.00
11/12/2022 11:00	0	1.7	9.0	14.1	16.8	1,024,651.7	0.00	1.00
11/12/2022 12:00	0	1.7	7.9	14.4	15.1	1,047,925.7	0.00	1.00
11/12/2022 13:00	0	1.7	7.9	14.4	14.9	1,032,967.3	0.00	1.00
11/12/2022 14:00	0	1.8	10.2	13.9	19.6	1,030,002.8	0.00	1.00
11/12/2022 15:00	0	1.8	10.4	13.8	20.2	1,054,071.0	0.00	1.00
11/12/2022 16:00	0	1.9	11.3	13.5	21.8	1,052,236.1	0.00	1.00
11/12/2022 17:00	0	1.9	11.0	13.6	21.4	1,058,583.8	0.00	1.00
11/12/2022 18:00	0	1.8	10.5	13.7	20.5	1,053,125.4	0.00	1.00
11/12/2022 19:00	0	1.9	11.3	13.5	21.7	1,064,634.9	0.00	1.00
11/12/2022 20:00	0	1.8	10.4	13.7	20.6	1,060,923.5	0.00	1.00
11/12/2022 21:00	0	1.8	10.7	13.6	21.1	1,060,084.5	0.00	1.00
11/12/2022 22:00	0	1.9	11.2	13.5	21.9	1,062,784.4	0.00	1.00
11/12/2022 23:00	0	1.8	10.4	13.8	20.6	1,066,029.4	0.00	1.00
Average/Sum#:	0	1.9	11.0	13.6	21.4	1,060,337.0	0.00 #	24.00 #
Minimum:	0	1.7	7.9	13.0	14.9	1,024,651.7	0.00	1.00
Maximum:	1	2.0	13.4	14.4	25.3	1,079,914.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2022 00:00	0	1.7	8.1	14.3	15.4	1,029,973.1	0.00	1.00
11/13/2022 01:00	0	1.7	8.2	14.3	15.2	1,006,734.4	0.00	1.00
11/13/2022 02:00	0	1.7	8.3	14.3	14.7	996,152.5	0.00	1.00
11/13/2022 03:00	0	1.7	8.5	14.3	16.6	1,043,667.4	0.00	1.00
11/13/2022 04:00	0	1.7	8.5	14.3	16.5	1,043,874.9	0.00	1.00
11/13/2022 05:00	0	1.7	8.5	14.3	16.6	1,041,800.0	0.00	1.00
11/13/2022 06:00	0	1.7	9.0	14.2	18.3	1,043,215.2	0.00	1.00
11/13/2022 07:00	0	1.8	11.1	13.7	22.1	1,070,433.4	0.00	1.00
11/13/2022 08:00	0	1.7	8.7	14.2	17.6	1,041,171.3	0.00	1.00
11/13/2022 09:00	0	1.9	11.4	13.5	22.3	1,068,891.2	0.00	1.00
11/13/2022 10:00	0	1.7	8.2	14.4	16.1	1,056,563.6	0.00	1.00
11/13/2022 11:00	0	1.7	8.2	14.4	15.9	1,033,599.4	0.00	1.00
11/13/2022 12:00	0	1.7	8.2	14.4	15.5	1,014,427.4	0.00	1.00
11/13/2022 13:00	0	1.7	8.1	14.4	14.7	989,145.8	0.00	1.00
11/13/2022 14:00	0	1.7	8.3	14.3	13.0	900,292.8	0.00	1.00
11/13/2022 15:00	0	1.5	9.1	14.3	13.6	876,431.6	0.00	1.00
11/13/2022 16:00	0	1.9	13.3	13.3	25.0	1,058,961.5	0.00	1.00
11/13/2022 17:00	0	2.0	13.0	13.2	25.3	1,061,570.7	0.00	1.00
11/13/2022 18:00	0	2.0	12.8	13.3	25.2	1,067,790.6	0.00	1.00
11/13/2022 19:00	0	1.9	11.8	13.5	22.9	1,059,453.3	0.00	1.00
11/13/2022 20:00	0	1.8	11.1	13.7	22.4	1,066,058.8	0.00	1.00
11/13/2022 21:00	0	1.9	12.7	13.3	25.4	1,081,845.3	0.00	1.00
11/13/2022 22:00	0	1.9	12.3	13.3	24.6	1,067,430.3	0.00	1.00
11/13/2022 23:00	0	1.9	12.0	13.4	24.0	1,071,437.6	0.00	1.00
Average/Sum#:	0	1.8	10.0	13.9	19.1	1,032,955.1	0.00 #	24.00 #
Minimum:	0	1.5	8.1	13.2	13.0	876,431.6	0.00	1.00
Maximum:	0	2.0	13.3	14.4	25.4	1,081,845.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2022 00:00	0	1.8	10.7	13.8	20.9	1,046,741.7	0.00	1.00
11/14/2022 01:00	0	1.7	8.4	14.3	16.6	1,037,027.7	0.00	1.00
11/14/2022 02:00	0	1.7	8.7	14.3	16.8	1,036,612.8	0.00	1.00
11/14/2022 03:00	0	1.7	8.4	14.3	15.6	982,665.7	0.00	1.00
11/14/2022 04:00	0	1.7	8.5	14.3	16.3	1,012,129.1	0.00	1.00
11/14/2022 05:00	0	1.9	12.5	13.4	25.2	1,078,010.9	0.00	1.00
11/14/2022 06:00	1	2.2	16.2	12.3	34.9	1,099,838.9	0.00	1.00
11/14/2022 07:00	1	2.0	14.1	12.9	28.7	1,084,241.8	0.00	1.00
11/14/2022 08:00	0	1.8	11.3	13.7	23.0	1,081,845.3	0.00	1.00
11/14/2022 09:00	0	1.8	10.5	13.8	20.8	1,040,955.4	0.00	1.00
11/14/2022 10:00	0	1.7	8.2	14.3	15.5	1,007,356.9	0.00	1.00
11/14/2022 11:00	0	1.7	8.7	14.3	15.5	915,439.5	0.00	1.00
11/14/2022 12:00	0	1.6	8.5	14.2	11.9	823,289.8	0.00	1.00
11/14/2022 13:00	0	1.7	7.9	14.3	13.4	917,306.8	0.00	1.00
11/14/2022 14:00	0	1.7	8.1	14.4	14.8	994,202.1	0.00	1.00
11/14/2022 15:00	0	1.8	10.2	13.9	19.2	988,333.1	0.00	1.00
11/14/2022 16:00	0	2.0	13.0	13.2	25.7	1,068,684.6	0.00	1.00
11/14/2022 17:00	1	2.0	13.6	13.0	26.6	1,067,284.3	0.00	1.00
11/14/2022 18:00	1	2.0	13.0	13.2	25.7	1,068,151.0	0.00	1.00
11/14/2022 19:00	0	1.7	12.5	13.3	25.5	1,067,069.9	0.00	1.00
11/14/2022 20:00	0	2.0	13.5	13.1	26.8	1,081,494.1	0.00	1.00
11/14/2022 21:00	0	2.0	13.1	13.2	26.0	1,081,845.3	0.00	1.00
11/14/2022 22:00	0	2.0	12.8	13.2	25.6	1,078,999.7	0.00	1.00
11/14/2022 23:00	0	1.9	11.5	13.6	24.0	1,085,784.7	0.00	1.00
Average/Sum#:	0	1.8	11.0	13.7	21.5	1,031,054.6	0.00 #	24.00 #
Minimum:	0	1.6	7.9	12.3	11.9	823,289.8	0.00	1.00
Maximum:	1	2.2	16.2	14.4	34.9	1,099,838.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2022 00:00	0	2.0	13.3	13.1	26.6	1,087,287.8	0.00	1.00
11/15/2022 01:00	1	2.0	13.5	13.1	27.3	1,093,081.6	0.00	1.00
11/15/2022 02:00	0	1.8	13.9	13.0	28.8	1,087,739.0	0.00	1.00
11/15/2022 03:00	1	2.0	13.5	13.1	26.1	1,088,165.7	0.00	1.00
11/15/2022 04:00	1	2.0	13.7	13.0	27.9	1,086,698.9	0.00	1.00
11/15/2022 05:00	1	2.0	13.8	13.0	28.0	1,086,698.9	0.00	1.00
11/15/2022 06:00	1	2.1	14.3	12.9	29.3	1,097,251.3	0.00	1.00
11/15/2022 07:00	1	2.0	13.7	13.0	27.7	1,084,965.5	0.00	1.00
11/15/2022 08:00	0	1.9	11.7	13.6	23.7	1,080,907.3	0.00	1.00
11/15/2022 09:00	0	1.7	8.9	14.2	16.0	976,379.1	0.00	1.00
11/15/2022 10:00	0	1.6	8.6	14.2	12.6	818,384.4	0.00	1.00
11/15/2022 11:00	1	1.6	11.4	14.4	18.7	747,073.7	0.00	1.00
11/15/2022 12:00	1	1.6	15.2	14.6	23.0	669,713.7	0.00	1.00
11/15/2022 13:00	1	1.6	15.5	14.6	23.8	664,931.6	0.00	1.00
11/15/2022 14:00	1	1.6	14.4	14.6	21.5	669,931.1	0.00	1.00
11/15/2022 15:00	0	1.6	12.3	14.3	16.6	838,668.7	0.00	1.00
11/15/2022 16:00	0	2.0	12.9	13.3	23.1	1,054,637.0	0.00	1.00
11/15/2022 17:00	0	2.0	13.2	13.1	25.8	1,057,617.0	0.00	1.00
11/15/2022 18:00	1	2.0	13.6	13.1	26.6	1,073,418.0	0.00	1.00
11/15/2022 19:00	0	1.9	12.8	13.3	25.0	1,070,853.8	0.00	1.00
11/15/2022 20:00	0	1.9	12.3	13.5	24.5	1,080,364.8	0.00	1.00
11/15/2022 21:00	0	1.9	12.6	13.4	25.3	1,076,732.7	0.00	1.00
11/15/2022 22:00	0	1.8	10.9	13.8	22.5	1,067,572.4	0.00	1.00
11/15/2022 23:00	0	1.8	11.0	13.8	22.5	1,076,251.8	0.00	1.00
Average/Sum#:	0	1.9	12.8	13.6	23.9	988,971.9	0.00 #	24.00 #
Minimum:	0	1.6	8.6	12.9	12.6	664,931.6	0.00	1.00
Maximum:	1	2.1	15.5	14.6	29.3	1,097,251.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2022 00:00	0	1.8	11.3	13.7	23.3	1,081,274.7	0.00	1.00
11/16/2022 01:00	0	1.8	11.4	13.7	23.7	1,084,888.4	0.00	1.00
11/16/2022 02:00	0	1.8	11.4	13.7	23.1	1,077,280.5	0.00	1.00
11/16/2022 03:00	0	1.8	11.3	13.7	23.8	1,084,317.8	0.00	1.00
11/16/2022 04:00	0	1.9	12.4	13.4	25.3	1,090,792.2	0.00	1.00
11/16/2022 05:00	0	1.9	12.6	13.3	26.0	1,091,575.4	0.00	1.00
11/16/2022 06:00	1	2.0	13.6	13.0	28.2	1,093,459.4	0.00	1.00
11/16/2022 07:00	0	1.9	12.8	13.3	25.9	1,094,098.0	0.00	1.00
11/16/2022 08:00	0	1.7	9.7	14.1	18.5	968,465.0	0.00	1.00
11/16/2022 09:00	0	1.7	8.3	14.2	12.3	893,191.7	0.00	1.00
11/16/2022 10:00	1	1.5	12.0	14.3	20.9	709,403.3	0.00	1.00
11/16/2022 11:00	1	1.5	15.0	14.5	21.5	680,860.7	0.00	1.00
11/16/2022 12:00	0	1.6	7.9	14.3	7.8	866,887.1	0.00	1.00
11/16/2022 13:00	0	1.7	8.6	14.2	12.5	797,945.2	0.00	1.00
11/16/2022 14:00	1	1.6	16.7	14.6	28.2	661,453.7	0.00	1.00
11/16/2022 15:00	0	1.5	10.0	14.4	13.4	906,558.9	0.00	1.00
11/16/2022 16:00	0	1.7	8.7	14.4	17.0	1,047,504.3	0.00	1.00
11/16/2022 17:00	0	1.9	11.8	13.5	23.3	1,065,745.3	0.00	1.00
11/16/2022 18:00	1	2.0	14.2	12.9	27.7	1,075,169.3	0.00	1.00
11/16/2022 19:00	0	2.0	13.6	13.0	26.2	1,066,070.9	0.00	1.00
11/16/2022 20:00	0	1.8	10.0	14.0	20.4	1,064,975.5	0.00	1.00
11/16/2022 21:00	1	2.0	13.3	13.0	26.5	1,075,084.8	0.00	1.00
11/16/2022 22:00	0	2.0	12.9	13.2	26.0	1,080,422.5	0.00	1.00
11/16/2022 23:00	0	1.9	12.0	13.4	23.5	1,065,047.0	0.00	1.00
Average/Sum#:	0	1.8	11.7	13.7	21.9	988,436.3	0.00 #	24.00 #
Minimum:	0	1.5	7.9	12.9	7.8	661,453.7	0.00	1.00
Maximum:	1	2.0	16.7	14.6	28.2	1,094,098.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2022 00:00	0	1.7	8.4	14.3	16.1	1,034,745.4	0.00	1.00
11/17/2022 01:00	0	1.7	8.4	14.3	16.6	1,038,065.2	0.00	1.00
11/17/2022 02:00	0	1.7	8.5	14.3	16.3	1,023,126.0	0.00	1.00
11/17/2022 03:00	0	1.7	8.5	14.3	16.6	1,024,163.4	0.00	1.00
11/17/2022 04:00	0	1.7	8.5	14.3	16.7	1,034,952.9	0.00	1.00
11/17/2022 05:00	0	1.7	8.5	14.3	16.9	1,036,197.8	0.00	1.00
11/17/2022 06:00	0	1.7	8.9	14.2	18.9	1,037,696.7	0.00	1.00
11/17/2022 07:00	0	1.8	10.7	13.8	21.2	1,077,987.7	0.00	1.00
11/17/2022 08:00	1	1.6	14.2	14.4	26.6	762,664.0	0.00	1.00
11/17/2022 09:00	0	1.5	8.2	14.3	9.9	997,812.4	0.00	1.00
11/17/2022 10:00	0	1.9	10.9	13.7	22.3	1,074,237.4	0.00	1.00
11/17/2022 11:00	0	1.7	8.4	14.3	16.5	1,026,860.8	0.00	1.00
11/17/2022 12:00	0	1.7	8.5	14.4	17.9	1,054,878.1	0.00	1.00
11/17/2022 13:00	0	1.8	11.1	13.7	21.4	1,059,021.5	0.00	1.00
11/17/2022 14:00	0	1.8	10.5	13.8	21.0	1,044,812.9	0.00	1.00
11/17/2022 15:00	0	1.9	11.9	13.4	23.8	1,048,613.9	0.00	1.00
11/17/2022 16:00	0	1.9	12.6	13.3	24.8	1,063,826.5	0.00	1.00
11/17/2022 17:00	1	2.0	13.5	13.0	26.4	1,056,710.3	0.00	1.00
11/17/2022 18:00	1	2.0	13.4	13.1	26.3	1,070,960.1	0.00	1.00
11/17/2022 19:00	1	2.0	13.5	13.1	26.6	1,075,876.0	0.00	1.00
11/17/2022 20:00	0	2.0	12.8	13.2	25.5	1,069,929.5	0.00	1.00
11/17/2022 21:00	0	1.9	11.9	13.5	23.5	1,076,663.7	0.00	1.00
11/17/2022 22:00	0	1.9	11.3	13.6	23.1	1,076,967.9	0.00	1.00
11/17/2022 23:00	0	1.8	11.0	13.7	22.6	1,080,133.5	0.00	1.00
Average/Sum#:	0	1.8	10.6	13.8	20.7	1,039,454.3	0.00 #	24.00 #
Minimum:	0	1.5	8.2	13.0	9.9	762,664.0	0.00	1.00
Maximum:	1	2.0	14.2	14.4	26.6	1,080,133.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2022 00:00	0	1.9	12.4	13.3	25.2	1,082,926.4	0.00	1.00
11/18/2022 01:00	0	1.9	11.7	13.5	23.9	1,080,179.7	0.00	1.00
11/18/2022 02:00	0	1.4	12.2	13.5	26.1	1,087,952.2	0.00	1.00
11/18/2022 03:00	0	2.0	13.1	13.1	26.8	1,073,944.7	0.00	1.00
11/18/2022 04:00	1	2.0	13.3	13.0	26.7	1,075,084.8	0.00	1.00
11/18/2022 05:00	1	2.1	14.0	12.8	28.7	1,082,521.5	0.00	1.00
11/18/2022 06:00	1	2.3	16.4	12.0	36.6	1,085,384.2	0.00	1.00
11/18/2022 07:00	1	2.0	14.0	12.9	28.2	1,085,611.2	0.00	1.00
11/18/2022 08:00	0	2.0	12.9	13.2	25.6	1,082,734.5	0.00	1.00
11/18/2022 09:00	0	1.9	12.0	13.4	24.0	1,075,819.8	0.00	1.00
11/18/2022 10:00	0	1.9	11.4	13.6	23.0	1,073,216.0	0.00	1.00
11/18/2022 11:00	0	1.9	11.3	13.7	22.5	1,066,058.8	0.00	1.00
11/18/2022 12:00	0	1.8	10.7	13.8	21.3	1,054,842.5	0.00	1.00
11/18/2022 13:00	0	1.8	11.0	13.7	21.9	1,044,566.5	0.00	1.00
11/18/2022 14:00	0	1.8	11.1	13.7	21.9	1,045,327.3	0.00	1.00
11/18/2022 15:00	0	1.9	12.0	13.5	23.7	1,054,271.7	0.00	1.00
11/18/2022 16:00	1	2.1	14.2	12.9	28.6	1,058,393.9	0.00	1.00
11/18/2022 17:00	1	2.1	14.9	12.7	30.3	1,064,142.9	0.00	1.00
11/18/2022 18:00	1	2.1	14.6	12.8	29.6	1,076,097.1	0.00	1.00
11/18/2022 19:00	1	2.0	14.0	13.0	28.2	1,079,071.7	0.00	1.00
11/18/2022 20:00	1	2.1	14.4	12.8	29.1	1,068,320.1	0.00	1.00
11/18/2022 21:00	1	2.0	14.4	12.9	29.0	1,085,268.8	0.00	1.00
11/18/2022 22:00	1	2.0	13.9	13.0	28.0	1,078,378.4	0.00	1.00
11/18/2022 23:00	0	2.0	13.2	13.2	26.6	1,080,066.8	0.00	1.00
Average/Sum#:	0	2.0	13.0	13.2	26.5	1,072,507.6	0.00 #	24.00 #
Minimum:	0	1.4	10.7	12.0	21.3	1,044,566.5	0.00	1.00
Maximum:	1	2.3	16.4	13.8	36.6	1,087,952.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2022 00:00	0	1.9	11.7	13.6	24.1	1,081,657.7	0.00	1.00
11/19/2022 01:00	0	1.9	11.5	13.6	23.9	1,078,843.8	0.00	1.00
11/19/2022 02:00	0	1.8	11.6	13.7	23.7	1,083,937.4	0.00	1.00
11/19/2022 03:00	0	1.8	10.9	13.9	23.5	1,093,387.6	0.00	1.00
11/19/2022 04:00	0	1.9	12.0	13.5	25.1	1,094,984.3	0.00	1.00
11/19/2022 05:00	1	2.0	12.9	13.3	27.0	1,102,026.3	0.00	1.00
11/19/2022 06:00	1	2.0	13.6	13.1	28.3	1,100,455.4	0.00	1.00
11/19/2022 07:00	1	2.0	13.4	13.1	28.2	1,086,761.1	0.00	1.00
11/19/2022 08:00	1	1.7	12.3	14.2	23.4	860,897.8	0.00	1.00
11/19/2022 09:00	1	1.6	17.5	14.5	28.6	665,026.7	0.00	1.00
11/19/2022 10:00	1	1.5	16.1	14.5	25.2	674,227.5	0.00	1.00
11/19/2022 11:00	1	1.6	15.3	14.5	23.7	673,585.6	0.00	1.00
11/19/2022 12:00	1	1.6	14.7	14.5	23.0	673,157.7	0.00	1.00
11/19/2022 13:00	1	1.6	14.4	14.5	22.1	672,087.8	0.00	1.00
11/19/2022 14:00	1	1.6	16.0	14.6	25.4	663,627.4	0.00	1.00
11/19/2022 15:00	0	1.5	12.8	14.5	17.4	795,977.9	0.00	1.00
11/19/2022 16:00	0	1.9	13.0	13.3	23.3	1,065,448.2	0.00	1.00
11/19/2022 17:00	0	1.9	12.1	13.5	23.9	1,067,225.7	0.00	1.00
11/19/2022 18:00	0	1.9	11.9	13.5	24.0	1,067,595.8	0.00	1.00
11/19/2022 19:00	1	2.0	13.4	13.1	27.4	1,076,578.2	0.00	1.00
11/19/2022 20:00	1	2.0	14.1	12.9	28.4	1,076,025.2	0.00	1.00
11/19/2022 21:00	1	2.0	13.9	13.0	28.1	1,089,299.1	0.00	1.00
11/19/2022 22:00	1	2.0	13.8	13.0	28.1	1,092,246.0	0.00	1.00
11/19/2022 23:00	1	2.0	13.9	12.9	28.7	1,087,836.5	0.00	1.00
Average/Sum#:	1	1.8	13.5	13.7	25.2	959,287.4	0.00 #	24.00 #
Minimum:	0	1.5	10.9	12.9	17.4	663,627.4	0.00	1.00
Maximum:	1	2.0	17.5	14.6	28.7	1,102,026.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2022 00:00	1	2.0	13.9	13.0	28.6	1,100,739.9	0.00	1.00
11/20/2022 01:00	1	2.0	13.9	12.9	28.8	1,089,548.3	0.00	1.00
11/20/2022 02:00	1	2.0	14.2	12.9	28.9	1,090,746.5	0.00	1.00
11/20/2022 03:00	1	2.0	14.1	12.9	28.7	1,088,178.9	0.00	1.00
11/20/2022 04:00	1	2.0	14.1	12.9	28.8	1,089,548.3	0.00	1.00
11/20/2022 05:00	1	2.0	13.7	13.0	27.9	1,088,779.1	0.00	1.00
11/20/2022 06:00	1	2.0	12.9	13.2	26.6	1,090,026.2	0.00	1.00
11/20/2022 07:00	0	1.8	11.5	13.6	23.7	1,085,034.3	0.00	1.00
11/20/2022 08:00	0	1.7	9.0	14.2	17.9	1,027,477.1	0.00	1.00
11/20/2022 09:00	0	1.7	9.3	14.3	20.4	1,078,732.9	0.00	1.00
11/20/2022 10:00	0	1.7	9.5	14.2	20.7	1,047,711.8	0.00	1.00
11/20/2022 11:00	0	1.7	9.4	14.2	20.3	1,037,901.0	0.00	1.00
11/20/2022 12:00	0	1.7	8.7	14.3	17.1	1,005,904.5	0.00	1.00
11/20/2022 13:00	0	1.8	11.9	13.8	22.1	1,056,771.3	0.00	1.00
11/20/2022 14:00	0	1.7	9.2	14.2	15.8	975,970.4	0.00	1.00
11/20/2022 15:00	0	1.6	9.4	14.2	16.1	914,448.5	0.00	1.00
11/20/2022 16:00	0	1.9	13.0	13.4	24.7	1,064,316.6	0.00	1.00
11/20/2022 17:00	0	1.9	12.2	13.4	24.1	1,059,386.7	0.00	1.00
11/20/2022 18:00	0	1.9	11.6	13.6	23.4	1,071,152.5	0.00	1.00
11/20/2022 19:00	0	1.9	11.6	13.6	23.9	1,076,029.9	0.00	1.00
11/20/2022 20:00	0	1.9	11.4	13.6	23.4	1,074,529.2	0.00	1.00
11/20/2022 21:00	0	1.8	10.7	13.8	22.7	1,080,495.1	0.00	1.00
11/20/2022 22:00	0	1.8	10.6	13.8	22.5	1,075,673.2	0.00	1.00
11/20/2022 23:00	0	1.8	10.2	13.9	22.2	1,073,824.3	0.00	1.00
Average/Sum#:	0	1.8	11.5	13.6	23.3	1,060,121.9	0.00 #	24.00 #
Minimum:	0	1.6	8.7	12.9	15.8	914,448.5	0.00	1.00
Maximum:	1	2.0	14.2	14.3	28.9	1,100,739.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2022 00:00	0	1.8	11.1	13.7	23.4	1,090,404.2	0.00	1.00
11/21/2022 01:00	0	1.8	10.5	13.8	22.7	1,076,830.5	0.00	1.00
11/21/2022 02:00	0	1.7	10.6	13.8	23.2	1,072,972.9	0.00	1.00
11/21/2022 03:00	0	1.9	11.2	13.6	23.4	1,076,780.3	0.00	1.00
11/21/2022 04:00	1	1.9	12.5	13.3	26.6	1,096,981.0	0.00	1.00
11/21/2022 05:00	1	1.9	12.5	13.3	26.5	1,096,620.6	0.00	1.00
11/21/2022 06:00	1	2.0	13.7	13.0	28.5	1,098,313.0	0.00	1.00
11/21/2022 07:00	0	1.8	10.9	13.8	23.2	1,082,423.9	0.00	1.00
11/21/2022 08:00	1	1.6	14.0	14.4	25.2	766,456.3	0.00	1.00
11/21/2022 09:00	1	1.6	17.0	14.5	27.6	666,524.5	0.00	1.00
11/21/2022 10:00	1	1.6	16.0	14.5	25.3	669,734.1	0.00	1.00
11/21/2022 11:00	1	1.6	15.0	14.5	23.5	674,227.5	0.00	1.00
11/21/2022 12:00	1	1.4	13.7	14.5	21.0	690,275.5	0.00	1.00
11/21/2022 13:00	1	1.6	14.7	14.5	22.4	666,738.5	0.00	1.00
11/21/2022 14:00	0	1.6	8.3	14.4	10.5	971,870.0	0.00	1.00
11/21/2022 15:00	0	1.9	12.4	13.4	23.8	1,042,771.0	0.00	1.00
11/21/2022 16:00	0	1.9	12.2	13.4	23.9	1,059,021.5	0.00	1.00
11/21/2022 17:00	0	1.9	12.1	13.4	24.4	1,061,760.4	0.00	1.00
11/21/2022 18:00	0	1.9	11.8	13.5	23.4	1,065,930.3	0.00	1.00
11/21/2022 19:00	0	1.9	11.7	13.5	23.7	1,067,780.9	0.00	1.00
11/21/2022 20:00	0	1.9	11.7	13.5	24.0	1,076,848.7	0.00	1.00
11/21/2022 21:00	0	1.9	12.2	13.4	24.8	1,083,488.6	0.00	1.00
11/21/2022 22:00	0	1.9	11.9	13.5	24.4	1,085,731.5	0.00	1.00
11/21/2022 23:00	0	1.8	10.8	13.8	22.6	1,079,530.7	0.00	1.00
Average/Sum#:	0	1.8	12.4	13.8	23.7	975,834.0	0.00 #	24.00 #
Minimum:	0	1.4	8.3	13.0	10.5	666,524.5	0.00	1.00
Maximum:	1	2.0	17.0	14.5	28.5	1,098,313.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2022 00:00	0	1.7	8.5	14.3	17.2	1,058,399.1	0.00	1.00
11/22/2022 01:00	0	1.7	8.5	14.4	16.9	1,060,566.5	0.00	1.00
11/22/2022 02:00	0	1.7	8.7	14.3	17.3	1,035,990.3	0.00	1.00
11/22/2022 03:00	0	1.7	8.4	14.3	15.2	981,628.3	0.00	1.00
11/22/2022 04:00	0	1.7	8.4	14.3	16.3	1,002,792.1	0.00	1.00
11/22/2022 05:00	0	1.7	8.6	14.3	17.2	1,025,200.9	0.00	1.00
11/22/2022 06:00	0	1.7	8.7	14.3	18.6	1,067,943.5	0.00	1.00
11/22/2022 07:00	1	1.6	13.3	14.3	24.7	788,041.5	0.00	1.00
11/22/2022 08:00	0	1.6	10.7	14.3	15.1	909,422.3	0.00	1.00
11/22/2022 09:00	0	1.9	12.5	13.6	23.5	1,079,594.2	0.00	1.00
11/22/2022 10:00	0	1.7	9.1	14.3	18.7	1,053,419.3	0.00	1.00
11/22/2022 11:00	0	1.8	10.9	13.9	21.2	1,067,564.1	0.00	1.00
11/22/2022 12:00	0	1.9	12.1	13.5	23.9	1,075,738.4	0.00	1.00
11/22/2022 13:00	0	1.9	12.2	13.4	24.1	1,068,151.0	0.00	1.00
11/22/2022 14:00	0	1.9	11.9	13.5	23.6	1,058,713.1	0.00	1.00
11/22/2022 15:00	0	1.8	11.3	13.7	22.6	1,059,592.1	0.00	1.00
11/22/2022 16:00	0	1.9	11.1	13.7	22.5	1,062,635.3	0.00	1.00
11/22/2022 17:00	0	1.8	10.5	13.9	21.4	1,059,543.2	0.00	1.00
11/22/2022 18:00	0	1.8	10.2	13.9	21.4	1,055,826.2	0.00	1.00
11/22/2022 19:00	0	1.8	10.1	13.9	21.6	1,059,934.5	0.00	1.00
11/22/2022 20:00	0	1.8	10.4	13.8	21.8	1,061,979.0	0.00	1.00
11/22/2022 21:00	0	1.7	9.3	14.1	17.5	986,186.9	0.00	1.00
11/22/2022 22:00	1	1.7	11.7	14.3	21.7	782,854.3	0.00	1.00
11/22/2022 23:00	1	1.5	14.7	14.4	22.9	684,290.8	0.00	1.00
Average/Sum#:	0	1.8	10.5	14.0	20.3	1,006,083.6	0.00 #	24.00 #
Minimum:	0	1.5	8.4	13.4	15.1	684,290.8	0.00	1.00
Maximum:	1	1.9	14.7	14.4	24.7	1,079,594.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2022 00:00	0	1.6	7.7	14.2	7.6	881,541.4	0.00	1.00
11/23/2022 01:00	0	1.7	9.3	14.1	14.6	789,432.9	0.00	1.00
11/23/2022 02:00	0	1.7	8.1	14.2	12.6	860,489.1	0.00	1.00
11/23/2022 03:00	0	1.7	7.9	14.2	13.4	889,717.1	0.00	1.00
11/23/2022 04:00	0	1.7	8.0	14.2	14.1	916,083.6	0.00	1.00
11/23/2022 05:00	0	1.7	8.1	14.2	15.3	972,904.5	0.00	1.00
11/23/2022 06:00	0	1.7	8.1	14.2	15.2	978,423.1	0.00	1.00
11/23/2022 07:00	1	1.8	10.7	14.1	18.1	775,940.0	0.00	1.00
11/23/2022 08:00	1	1.6	16.5	14.4	24.4	695,456.9	0.00	1.00
11/23/2022 09:00	1	1.5	13.1	14.3	17.6	738,659.2	0.00	1.00
11/23/2022 10:00	0	1.5	11.6	14.3	14.7	774,969.7	0.00	1.00
11/23/2022 11:00	0	1.6	8.8	14.2	12.2	991,504.1	0.00	1.00
11/23/2022 12:00	0	1.8	11.6	13.8	20.2	1,054,456.8	0.00	1.00
11/23/2022 13:00	0	1.8	10.3	14.0	16.4	950,658.4	0.00	1.00
11/23/2022 14:00	1	1.5	15.0	14.6	25.1	673,626.4	0.00	1.00
11/23/2022 15:00	0	1.5	12.7	14.5	16.2	792,340.4	0.00	1.00
11/23/2022 16:00	0	1.9	12.4	13.5	21.1	1,055,567.1	0.00	1.00
11/23/2022 17:00	0	1.9	11.6	13.5	22.2	1,053,901.6	0.00	1.00
11/23/2022 18:00	0	1.8	10.4	13.9	20.6	1,067,564.1	0.00	1.00
11/23/2022 19:00	0	1.8	10.1	13.9	20.2	1,057,195.6	0.00	1.00
11/23/2022 20:00	0	1.8	10.5	13.8	21.3	1,066,608.0	0.00	1.00
11/23/2022 21:00	0	1.9	11.4	13.6	22.5	1,077,530.6	0.00	1.00
11/23/2022 22:00	0	1.9	11.3	13.6	22.7	1,075,279.5	0.00	1.00
11/23/2022 23:00	0	1.8	10.7	13.8	21.7	1,077,023.3	0.00	1.00
Average/Sum#:	0	1.7	10.7	14.0	17.9	927,786.4	0.00 #	24.00 #
Minimum:	0	1.5	7.7	13.5	7.6	673,626.4	0.00	1.00
Maximum:	1	1.9	16.5	14.6	25.1	1,077,530.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2022 00:00	0	1.8	11.0	13.7	22.3	1,083,747.2	0.00	1.00
11/24/2022 01:00	0	1.8	10.7	13.7	21.9	1,064,537.3	0.00	1.00
11/24/2022 02:00	0	1.4	8.4	14.2	15.6	962,071.7	0.00	1.00
11/24/2022 03:00	0	1.7	8.3	14.3	15.2	992,832.7	0.00	1.00
11/24/2022 04:00	0	1.7	8.3	14.3	15.4	992,625.2	0.00	1.00
11/24/2022 05:00	0	1.7	8.5	14.3	17.0	1,037,857.7	0.00	1.00
11/24/2022 06:00	0	1.7	8.9	14.2	19.5	1,054,252.4	0.00	1.00
11/24/2022 07:00	0	1.9	12.0	13.5	23.6	1,092,208.5	0.00	1.00
11/24/2022 08:00	0	1.8	11.0	13.7	22.8	1,079,372.7	0.00	1.00
11/24/2022 09:00	0	1.9	11.5	13.6	23.5	1,075,467.1	0.00	1.00
11/24/2022 10:00	0	1.9	11.8	13.6	23.4	1,078,468.6	0.00	1.00
11/24/2022 11:00	0	1.8	10.7	13.8	21.2	1,060,243.1	0.00	1.00
11/24/2022 12:00	0	1.8	10.6	13.8	21.0	1,058,700.1	0.00	1.00
11/24/2022 13:00	0	1.8	10.8	13.8	20.9	1,055,421.2	0.00	1.00
11/24/2022 14:00	1	1.6	12.0	14.5	19.8	770,515.2	0.00	1.00
11/24/2022 15:00	0	1.6	11.8	14.3	16.2	833,274.0	0.00	1.00
11/24/2022 16:00	0	1.9	11.8	13.4	22.4	1,047,700.9	0.00	1.00
11/24/2022 17:00	0	1.8	11.0	13.7	21.5	1,048,941.0	0.00	1.00
11/24/2022 18:00	0	1.8	10.4	13.9	20.7	1,063,455.9	0.00	1.00
11/24/2022 19:00	0	1.8	10.3	13.9	20.8	1,061,303.9	0.00	1.00
11/24/2022 20:00	0	1.8	10.1	13.9	20.4	1,059,151.9	0.00	1.00
11/24/2022 21:00	0	1.8	10.0	13.9	20.6	1,060,325.7	0.00	1.00
11/24/2022 22:00	0	1.8	10.2	13.9	21.1	1,069,520.4	0.00	1.00
11/24/2022 23:00	0	1.8	9.9	14.0	20.7	1,065,967.9	0.00	1.00
Average/Sum#:	0	1.8	10.4	13.9	20.3	1,031,998.4	0.00 #	24.00 #
Minimum:	0	1.4	8.3	13.4	15.2	770,515.2	0.00	1.00
Maximum:	1	1.9	12.0	14.5	23.6	1,092,208.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2022 00:00	0	1.8	9.7	14.0	20.5	1,066,166.3	0.00	1.00
11/25/2022 01:00	0	1.8	9.7	14.0	20.8	1,062,792.4	0.00	1.00
11/25/2022 02:00	0	1.8	9.9	14.1	20.7	1,073,789.8	0.00	1.00
11/25/2022 03:00	0	1.8	10.1	13.9	21.0	1,063,064.6	0.00	1.00
11/25/2022 04:00	0	1.8	10.6	13.8	22.4	1,081,652.4	0.00	1.00
11/25/2022 05:00	0	1.8	10.7	13.8	22.9	1,088,595.9	0.00	1.00
11/25/2022 06:00	0	1.8	11.1	13.6	23.1	1,078,468.6	0.00	1.00
11/25/2022 07:00	0	1.8	10.5	13.8	22.3	1,073,551.6	0.00	1.00
11/25/2022 08:00	0	1.7	9.6	14.1	20.8	1,066,741.3	0.00	1.00
11/25/2022 09:00	1	1.6	14.1	14.4	25.3	759,925.2	0.00	1.00
11/25/2022 10:00	1	1.6	17.2	14.6	28.3	666,235.8	0.00	1.00
11/25/2022 11:00	1	1.6	17.7	14.6	27.7	652,976.3	0.00	1.00
11/25/2022 12:00	1	1.6	17.3	14.7	27.1	661,520.3	0.00	1.00
11/25/2022 13:00	1	1.6	16.7	14.7	25.6	662,403.8	0.00	1.00
11/25/2022 14:00	1	1.6	15.4	14.6	22.5	663,192.7	0.00	1.00
11/25/2022 15:00	0	1.5	12.2	14.5	16.2	798,545.6	0.00	1.00
11/25/2022 16:00	0	1.9	11.4	13.6	19.3	1,044,139.2	0.00	1.00
11/25/2022 17:00	0	1.9	11.1	13.7	21.5	1,062,064.7	0.00	1.00
11/25/2022 18:00	0	1.8	10.5	13.9	20.6	1,063,847.1	0.00	1.00
11/25/2022 19:00	0	1.8	10.1	13.9	20.5	1,054,652.4	0.00	1.00
11/25/2022 20:00	0	1.8	10.0	13.9	20.7	1,057,000.0	0.00	1.00
11/25/2022 21:00	0	1.8	10.1	13.9	20.7	1,059,151.9	0.00	1.00
11/25/2022 22:00	0	1.8	10.9	13.7	22.0	1,065,678.4	0.00	1.00
11/25/2022 23:00	0	1.8	10.7	13.8	22.0	1,066,993.8	0.00	1.00
Average/Sum#:	0	1.7	12.0	14.1	22.3	958,047.9	0.00 #	24.00 #
Minimum:	0	1.5	9.6	13.6	16.2	652,976.3	0.00	1.00
Maximum:	1	1.9	17.7	14.7	28.3	1,088,595.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2022 00:00	0	1.9	11.6	13.6	23.1	1,079,031.4	0.00	1.00
11/26/2022 01:00	0	1.9	11.3	13.6	23.1	1,074,529.2	0.00	1.00
11/26/2022 02:00	0	1.9	11.7	13.6	23.0	1,078,656.2	0.00	1.00
11/26/2022 03:00	0	1.9	11.6	13.6	23.3	1,076,967.9	0.00	1.00
11/26/2022 04:00	0	1.9	11.6	13.6	23.6	1,075,842.3	0.00	1.00
11/26/2022 05:00	0	2.0	13.2	13.2	26.4	1,086,113.6	0.00	1.00
11/26/2022 06:00	0	2.0	13.7	13.0	27.1	1,082,712.0	0.00	1.00
11/26/2022 07:00	0	1.9	11.6	13.6	23.4	1,077,343.0	0.00	1.00
11/26/2022 08:00	0	1.7	8.9	14.2	18.0	1,033,200.0	0.00	1.00
11/26/2022 09:00	0	1.8	10.9	13.7	22.1	1,068,531.4	0.00	1.00
11/26/2022 10:00	0	1.6	8.8	14.3	14.4	880,166.4	0.00	1.00
11/26/2022 11:00	1	1.7	15.7	14.6	25.4	666,453.2	0.00	1.00
11/26/2022 12:00	1	1.6	14.8	14.6	22.6	671,235.3	0.00	1.00
11/26/2022 13:00	1	1.6	16.9	14.6	26.2	649,281.1	0.00	1.00
11/26/2022 14:00	1	1.6	15.5	14.6	22.3	659,062.7	0.00	1.00
11/26/2022 15:00	0	1.5	10.8	14.5	13.4	850,968.9	0.00	1.00
11/26/2022 16:00	0	1.9	11.6	13.7	20.0	1,034,105.6	0.00	1.00
11/26/2022 17:00	0	1.9	11.2	13.7	21.6	1,053,125.4	0.00	1.00
11/26/2022 18:00	0	1.8	10.8	13.8	21.1	1,051,177.9	0.00	1.00
11/26/2022 19:00	0	1.8	10.5	13.9	21.2	1,062,477.7	0.00	1.00
11/26/2022 20:00	0	1.8	11.2	13.7	22.2	1,068,341.2	0.00	1.00
11/26/2022 21:00	0	1.9	11.5	13.6	23.2	1,065,712.3	0.00	1.00
11/26/2022 22:00	0	1.8	10.6	13.9	21.3	1,066,586.0	0.00	1.00
11/26/2022 23:00	0	1.8	10.6	13.9	21.8	1,071,281.1	0.00	1.00
Average/Sum#:	0	1.8	11.9	13.9	22.1	982,620.9	0.00 #	24.00 #
Minimum:	0	1.5	8.8	13.0	13.4	649,281.1	0.00	1.00
Maximum:	1	2.0	16.9	14.6	27.1	1,086,113.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2022 00:00	0	1.9	12.0	13.5	23.8	1,075,738.4	0.00	1.00
11/27/2022 01:00	0	1.9	11.3	13.7	22.8	1,075,758.9	0.00	1.00
11/27/2022 02:00	0	1.6	11.0	13.9	22.4	1,068,346.7	0.00	1.00
11/27/2022 03:00	0	1.8	11.9	13.6	24.2	1,078,281.0	0.00	1.00
11/27/2022 04:00	0	1.9	11.9	13.5	23.6	1,064,820.0	0.00	1.00
11/27/2022 05:00	0	1.8	11.1	13.8	22.6	1,075,094.6	0.00	1.00
11/27/2022 06:00	0	1.8	11.7	13.6	23.7	1,072,465.6	0.00	1.00
11/27/2022 07:00	1	1.7	10.6	14.1	22.3	972,089.9	0.00	1.00
11/27/2022 08:00	1	1.6	17.4	14.5	26.7	661,817.1	0.00	1.00
11/27/2022 09:00	1	1.6	17.4	14.5	28.1	654,328.1	0.00	1.00
11/27/2022 10:00	1	1.6	15.3	14.5	22.1	667,166.4	0.00	1.00
11/27/2022 11:00	1	1.6	16.0	14.5	25.3	654,542.1	0.00	1.00
11/27/2022 12:00	1	1.6	17.4	14.6	27.0	649,715.8	0.00	1.00
11/27/2022 13:00	1	1.6	17.1	14.6	26.3	649,281.1	0.00	1.00
11/27/2022 14:00	1	1.6	17.1	14.6	26.4	648,846.3	0.00	1.00
11/27/2022 15:00	0	1.5	10.9	14.2	14.1	900,141.0	0.00	1.00
11/27/2022 16:00	0	1.9	12.1	13.6	20.6	1,050,329.7	0.00	1.00
11/27/2022 17:00	0	1.9	12.0	13.4	23.2	1,051,900.5	0.00	1.00
11/27/2022 18:00	0	1.9	12.0	13.5	23.1	1,062,414.2	0.00	1.00
11/27/2022 19:00	0	1.9	11.6	13.6	23.0	1,065,524.7	0.00	1.00
11/27/2022 20:00	0	1.9	11.1	13.7	22.1	1,060,162.7	0.00	1.00
11/27/2022 21:00	0	1.9	12.6	13.3	24.6	1,064,006.7	0.00	1.00
11/27/2022 22:00	0	1.8	10.9	13.8	21.8	1,061,786.1	0.00	1.00
11/27/2022 23:00	0	1.8	10.4	13.9	21.4	1,058,565.0	0.00	1.00
Average/Sum#:	0	1.8	13.0	13.9	23.4	935,130.1	0.00 #	24.00 #
Minimum:	0	1.5	10.4	13.3	14.1	648,846.3	0.00	1.00
Maximum:	1	1.9	17.4	14.6	28.1	1,078,281.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2022 00:00	0	1.8	11.2	13.7	22.4	1,064,347.1	0.00	1.00
11/28/2022 01:00	0	1.8	10.8	13.8	22.0	1,056,578.4	0.00	1.00
11/28/2022 02:00	0	1.8	10.6	14.0	21.4	1,064,380.1	0.00	1.00
11/28/2022 03:00	0	1.8	10.7	13.9	21.5	1,058,173.8	0.00	1.00
11/28/2022 04:00	0	1.8	10.4	14.0	21.6	1,065,967.9	0.00	1.00
11/28/2022 05:00	0	1.8	11.0	13.8	22.9	1,064,100.6	0.00	1.00
11/28/2022 06:00	0	1.9	12.8	13.3	25.9	1,076,079.3	0.00	1.00
11/28/2022 07:00	1	2.0	13.4	13.2	26.7	1,071,885.8	0.00	1.00
11/28/2022 08:00	0	1.8	10.8	13.9	22.1	1,057,978.2	0.00	1.00
11/28/2022 09:00	1	1.7	11.9	14.2	21.5	854,766.1	0.00	1.00
11/28/2022 10:00	1	1.6	15.6	14.5	24.1	669,948.1	0.00	1.00
11/28/2022 11:00	1	1.6	16.4	14.5	26.1	653,900.1	0.00	1.00
11/28/2022 12:00	1	1.6	17.7	14.6	27.5	649,281.1	0.00	1.00
11/28/2022 13:00	1	1.6	17.4	14.6	26.0	650,367.9	0.00	1.00
11/28/2022 14:00	1	1.6	16.8	14.6	25.4	653,845.8	0.00	1.00
11/28/2022 15:00	0	1.6	12.6	14.2	16.9	824,924.9	0.00	1.00
11/28/2022 16:00	0	1.9	11.4	13.6	19.9	1,044,702.0	0.00	1.00
11/28/2022 17:00	0	1.9	11.3	13.7	22.0	1,057,119.5	0.00	1.00
11/28/2022 18:00	0	1.8	10.6	13.9	21.3	1,060,912.6	0.00	1.00
11/28/2022 19:00	0	1.8	10.5	13.9	21.2	1,061,303.9	0.00	1.00
11/28/2022 20:00	0	1.8	11.2	13.7	22.3	1,063,015.7	0.00	1.00
11/28/2022 21:00	0	1.9	12.6	13.3	24.9	1,062,024.6	0.00	1.00
11/28/2022 22:00	0	1.8	11.0	13.8	22.3	1,061,400.3	0.00	1.00
11/28/2022 23:00	0	1.8	10.4	14.0	21.6	1,063,784.7	0.00	1.00
Average/Sum#:	0	1.8	12.5	13.9	22.9	958,782.9	0.00 #	24.00 #
Minimum:	0	1.6	10.4	13.2	16.9	649,281.1	0.00	1.00
Maximum:	1	2.0	17.7	14.6	27.5	1,076,079.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2022 00:00	0	1.7	8.9	14.3	17.0	1,044,082.3	0.00	1.00
11/29/2022 01:00	0	1.7	9.0	14.3	18.6	1,061,096.4	0.00	1.00
11/29/2022 02:00	0	1.6	9.3	14.3	18.7	1,059,851.5	0.00	1.00
11/29/2022 03:00	0	1.7	9.0	14.3	17.0	1,010,054.2	0.00	1.00
11/29/2022 04:00	0	1.7	9.0	14.3	17.4	1,022,918.5	0.00	1.00
11/29/2022 05:00	0	1.7	9.8	14.3	20.7	1,072,093.3	0.00	1.00
11/29/2022 06:00	0	1.7	10.2	14.2	21.8	1,062,428.1	0.00	1.00
11/29/2022 07:00	1	2.1	15.3	12.7	30.5	1,087,857.4	0.02	0.35
11/29/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2022 11:00	0	5.8	15.5	19.0	0.0	713,542.2	0.17	0.17
11/29/2022 12:00	0	7.1	15.8	14.5	14.1	847,759.3	0.57	1.00
11/29/2022 13:00	0	1.7	9.2	14.4	17.7	1,043,712.1	0.00	1.00
11/29/2022 14:00	1	2.2	15.1	12.4	31.0	1,004,996.4	0.00	1.00
11/29/2022 15:00	1	2.0	15.2	12.9	29.7	1,068,835.7	0.00	1.00
11/29/2022 16:00	1	2.1	15.5	12.8	30.6	1,071,025.1	0.00	1.00
11/29/2022 17:00	1	2.0	15.2	12.9	29.6	1,075,340.5	0.00	1.00
11/29/2022 18:00	1	2.0	15.2	12.9	29.4	1,076,709.9	0.00	1.00
11/29/2022 19:00	1	2.1	15.2	12.9	29.4	1,082,016.4	0.00	1.00
11/29/2022 20:00	1	2.1	15.2	12.8	29.3	1,072,884.8	0.00	1.00
11/29/2022 21:00	0	2.1	15.0	12.9	28.9	1,082,530.0	0.00	1.00
11/29/2022 22:00	0	2.0	14.6	13.0	28.0	1,081,325.2	0.00	1.00
11/29/2022 23:00	0	1.9	13.3	13.3	25.4	1,064,186.9	0.00	1.00
Average/Sum#:	0	2.3	12.9	13.8	23.1	1,033,583.2	0.76 #	19.52 #
Minimum:	0	1.6	8.9	12.4	0.0	713,542.2	0.00	0.00
Maximum:	1	7.1	15.8	19.0	31.0	1,087,857.4	0.57	1.00
%SI	16.67	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2022 00:00	0	1.7	9.4	14.4	18.0	1,081,845.3	0.00	1.00
11/30/2022 01:00	0	1.7	9.4	14.3	18.6	1,067,528.6	0.00	1.00
11/30/2022 02:00	0	1.7	10.0	14.3	19.3	1,070,433.4	0.00	1.00
11/30/2022 03:00	0	1.7	9.8	14.3	19.5	1,066,491.1	0.00	1.00
11/30/2022 04:00	0	1.7	9.8	14.3	19.8	1,065,868.6	0.00	1.00
11/30/2022 05:00	0	1.7	9.9	14.2	21.2	1,057,113.9	0.00	1.00
11/30/2022 06:00	1	2.1	14.9	12.9	28.9	1,089,205.9	0.00	1.00
11/30/2022 07:00	0	1.8	11.6	13.7	23.1	1,055,217.6	0.00	1.00
11/30/2022 08:00	1	1.6	12.9	14.3	23.2	863,152.3	0.00	1.00
11/30/2022 09:00	0	1.5	11.2	14.3	14.3	787,211.5	0.00	1.00
11/30/2022 10:00	1	1.6	15.9	14.5	24.1	670,162.1	0.00	1.00
11/30/2022 11:00	0	1.4	17.9	14.6	27.4	658,845.3	0.00	1.00
11/30/2022 12:00	1	1.6	17.6	14.6	26.2	656,454.2	0.00	1.00
11/30/2022 13:00	1	1.6	17.2	14.6	25.7	659,497.4	0.00	1.00
11/30/2022 14:00	0	1.5	8.9	14.3	8.9	882,033.8	0.00	1.00
11/30/2022 15:00	0	1.6	10.5	14.2	16.1	901,980.6	0.00	1.00
11/30/2022 16:00	0	1.9	12.6	13.4	22.3	1,054,456.8	0.00	1.00
11/30/2022 17:00	0	1.9	12.2	13.4	22.9	1,057,926.0	0.00	1.00
11/30/2022 18:00	0	1.9	12.0	13.4	22.9	1,056,465.3	0.00	1.00
11/30/2022 19:00	0	1.9	12.1	13.4	23.2	1,058,656.3	0.00	1.00
11/30/2022 20:00	0	1.9	11.7	13.5	22.5	1,062,044.1	0.00	1.00
11/30/2022 21:00	0	1.9	11.4	13.6	22.1	1,066,087.5	0.00	1.00
11/30/2022 22:00	0	1.8	9.9	14.0	19.1	1,043,541.1	0.00	1.00
11/30/2022 23:00	1	1.6	14.6	14.4	22.8	700,091.9	0.00	1.00
Average/Sum#:	0	1.7	12.2	14.0	21.3	947,179.6	0.00 #	24.00 #
Minimum:	0	1.4	8.9	12.9	8.9	656,454.2	0.00	1.00
Maximum:	1	2.1	17.9	14.6	28.9	1,089,205.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022 00:00	0	1.6	7.9	14.3	9.6	909,007.3	0.00	1.00
12/01/2022 01:00	0	1.7	7.9	14.3	12.7	905,480.0	0.00	1.00
12/01/2022 02:00	0	1.7	8.2	14.3	13.3	935,358.4	0.00	1.00
12/01/2022 03:00	0	1.7	8.1	14.3	13.6	946,147.8	0.00	1.00
12/01/2022 04:00	0	1.7	8.6	14.3	16.2	1,007,979.3	0.00	1.00
12/01/2022 05:00	0	1.8	11.1	13.6	20.8	1,043,764.0	0.00	1.00
12/01/2022 06:00	0	1.9	12.0	13.3	22.5	1,051,934.2	0.00	1.00
12/01/2022 07:00	0	1.8	10.4	13.8	20.1	1,056,964.2	0.00	1.00
12/01/2022 08:00	0	2.0	12.9	13.1	24.3	1,069,380.0	0.00	1.00
12/01/2022 09:00	1	2.1	14.5	12.6	28.4	1,071,945.8	0.00	1.00
12/01/2022 10:00	0	2.0	13.3	13.0	24.7	1,068,151.0	0.00	1.00
12/01/2022 11:00	0	2.0	12.9	13.1	24.0	1,065,693.1	0.00	1.00
12/01/2022 12:00	0	2.0	12.5	13.1	24.0	1,054,807.9	0.00	1.00
12/01/2022 13:00	0	2.0	13.5	12.9	25.1	1,063,871.6	0.00	1.00
12/01/2022 14:00	0	2.0	13.5	12.9	25.3	1,062,673.3	0.00	1.00
12/01/2022 15:00	0	1.9	11.5	13.4	21.3	1,048,979.1	0.00	1.00
12/01/2022 16:00	0	1.8	10.4	13.8	20.0	1,060,243.1	0.00	1.00
12/01/2022 17:00	0	1.8	10.6	13.7	20.3	1,060,923.5	0.00	1.00
12/01/2022 18:00	0	1.8	10.1	13.9	20.0	1,061,303.9	0.00	1.00
12/01/2022 19:00	0	1.8	10.5	13.8	20.6	1,066,608.0	0.00	1.00
12/01/2022 20:00	0	1.8	10.1	13.9	20.1	1,061,890.8	0.00	1.00
12/01/2022 21:00	0	1.8	9.9	13.9	19.9	1,056,608.7	0.00	1.00
12/01/2022 22:00	0	1.8	10.1	13.9	20.3	1,063,847.1	0.00	1.00
12/01/2022 23:00	0	1.8	9.9	14.0	20.2	1,067,158.7	0.00	1.00
Average/Sum#:	0	1.8	10.9	13.6	20.3	1,035,863.4	0.00 #	24.00 #
Minimum:	0	1.6	7.9	12.6	9.6	905,480.0	0.00	1.00
Maximum:	1	2.1	14.5	14.3	28.4	1,071,945.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2022 00:00	0	1.8	9.9	14.0	20.1	1,064,975.5	0.00	1.00
12/02/2022 01:00	0	1.8	9.8	14.0	20.3	1,061,800.1	0.00	1.00
12/02/2022 02:00	0	1.8	10.4	14.0	20.3	1,069,143.4	0.00	1.00
12/02/2022 03:00	0	1.8	10.8	13.9	22.2	1,086,736.1	0.00	1.00
12/02/2022 04:00	0	1.8	10.7	13.9	21.9	1,076,367.6	0.00	1.00
12/02/2022 05:00	0	1.8	11.0	13.8	22.2	1,079,723.6	0.00	1.00
12/02/2022 06:00	0	1.9	11.9	13.5	24.1	1,086,286.6	0.00	1.00
12/02/2022 07:00	1	2.1	14.6	12.9	29.3	1,094,854.8	0.00	1.00
12/02/2022 08:00	0	1.9	12.1	13.5	24.2	1,079,994.7	0.00	1.00
12/02/2022 09:00	0	1.9	11.9	13.5	23.8	1,079,994.7	0.00	1.00
12/02/2022 10:00	0	1.9	12.0	13.4	23.4	1,074,176.5	0.00	1.00
12/02/2022 11:00	0	1.9	11.6	13.5	22.9	1,075,553.3	0.00	1.00
12/02/2022 12:00	0	1.9	11.8	13.5	23.4	1,081,660.2	0.00	1.00
12/02/2022 13:00	0	2.0	13.6	13.0	26.4	1,075,604.8	0.00	1.00
12/02/2022 14:00	1	2.1	14.4	12.8	28.3	1,076,604.3	0.00	1.00
12/02/2022 15:00	1	2.1	14.3	12.9	27.9	1,083,214.7	0.00	1.00
12/02/2022 16:00	0	2.0	13.6	13.0	26.5	1,074,564.8	0.00	1.00
12/02/2022 17:00	1	2.0	14.1	12.9	27.6	1,079,448.8	0.00	1.00
12/02/2022 18:00	0	2.0	13.9	13.0	26.9	1,084,792.1	0.00	1.00
12/02/2022 19:00	1	2.0	14.1	12.9	27.3	1,078,079.3	0.00	1.00
12/02/2022 20:00	1	2.1	14.9	12.7	30.0	1,087,857.4	0.00	1.00
12/02/2022 21:00	0	2.0	13.8	13.0	27.0	1,085,658.9	0.00	1.00
12/02/2022 22:00	0	2.0	13.7	13.1	26.5	1,091,852.6	0.00	1.00
12/02/2022 23:00	0	1.9	11.8	13.5	23.1	1,072,962.5	0.00	1.00
Average/Sum#:	0	1.9	12.5	13.3	24.8	1,079,246.1	0.00 #	24.00 #
Minimum:	0	1.8	9.8	12.7	20.1	1,061,800.1	0.00	1.00
Maximum:	1	2.1	14.9	14.0	30.0	1,094,854.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2022 00:00	0	1.9	12.0	13.5	23.5	1,078,144.1	0.00	1.00
12/03/2022 01:00	0	1.9	11.5	13.6	22.9	1,080,532.1	0.00	1.00
12/03/2022 02:00	0	1.5	11.9	13.6	24.2	1,071,527.7	0.00	1.00
12/03/2022 03:00	0	1.9	11.8	13.5	23.0	1,072,037.2	0.00	1.00
12/03/2022 04:00	0	1.9	12.1	13.4	23.7	1,079,106.4	0.00	1.00
12/03/2022 05:00	0	1.9	12.5	13.3	24.5	1,083,106.6	0.00	1.00
12/03/2022 06:00	0	2.0	12.6	13.2	25.0	1,077,399.1	0.00	1.00
12/03/2022 07:00	1	2.1	14.6	12.6	29.4	1,078,710.4	0.00	1.00
12/03/2022 08:00	1	2.0	13.6	12.9	26.4	1,076,881.1	0.00	1.00
12/03/2022 09:00	1	2.0	13.7	12.9	26.8	1,074,484.6	0.00	1.00
12/03/2022 10:00	0	2.0	12.8	13.2	25.0	1,076,509.8	0.00	1.00
12/03/2022 11:00	0	1.9	11.4	13.5	22.2	1,067,410.8	0.00	1.00
12/03/2022 12:00	0	1.9	11.4	13.5	22.6	1,064,264.8	0.00	1.00
12/03/2022 13:00	0	1.9	11.3	13.5	22.4	1,064,449.9	0.00	1.00
12/03/2022 14:00	0	1.9	11.8	13.4	23.4	1,069,611.7	0.00	1.00
12/03/2022 15:00	0	2.0	12.7	13.2	25.2	1,082,201.0	0.00	1.00
12/03/2022 16:00	0	1.9	12.5	13.3	24.3	1,078,421.7	0.00	1.00
12/03/2022 17:00	0	4.9	13.2	13.7	14.5	954,983.3	0.08	1.00
12/03/2022 18:00	0	28.9	32.4	17.1	0.0	426,683.8	0.05	0.05
12/03/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	3.5	13.5	13.5	22.6	1,034,550.8	0.13 #	18.05 #
Minimum:	0	1.5	11.3	12.6	0.0	426,683.8	0.00	0.00
Maximum:	1	28.9	32.4	17.1	29.4	1,083,106.6	0.08	1.00
%SI	25.00	20.83	20.83	20.83	20.83	20.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2022 17:00	0	14.3	16.8	15.2	0.0	689,757.4	0.90	0.90
12/05/2022 18:00	0	7.2	13.3	14.2	11.5	813,070.2	0.55	1.00
12/05/2022 19:00	1	1.5	12.6	13.3	20.4	1,060,583.1	0.00	1.00
12/05/2022 20:00	0	1.9	12.3	13.4	22.3	1,063,403.7	0.00	1.00
12/05/2022 21:00	0	1.8	11.1	13.7	20.2	1,052,174.4	0.00	1.00
12/05/2022 22:00	0	1.7	10.0	14.0	16.8	959,390.9	0.00	1.00
12/05/2022 23:00	0	1.6	12.6	14.3	17.9	726,417.4	0.00	1.00
Average/Sum#:	0	4.3	12.7	14.0	15.6	909,256.7	1.45 #	6.90 #
Minimum:	0	1.5	10.0	13.3	0.0	689,757.4	0.00	0.00
Maximum:	1	14.3	16.8	15.2	22.3	1,063,403.7	0.90	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2022 00:00	0	1.5	9.6	14.3	12.9	860,247.5	0.00	1.00
12/06/2022 01:00	0	1.5	12.0	14.3	14.2	717,080.4	0.00	1.00
12/06/2022 02:00	1	1.8	15.9	14.4	25.2	671,017.9	0.00	1.00
12/06/2022 03:00	0	1.2	17.1	14.5	25.6	667,594.4	0.00	1.00
12/06/2022 04:00	1	1.7	16.8	14.5	24.6	668,664.2	0.00	1.00
12/06/2022 05:00	1	1.6	16.7	14.5	24.7	668,450.3	0.00	1.00
12/06/2022 06:00	1	1.6	16.6	14.5	24.9	669,306.2	0.00	1.00
12/06/2022 07:00	1	1.6	16.5	14.5	24.9	668,878.2	0.00	1.00
12/06/2022 08:00	1	1.6	16.4	14.5	24.6	668,664.2	0.00	1.00
12/06/2022 09:00	0	1.5	14.3	14.4	18.2	702,830.7	0.00	1.00
12/06/2022 10:00	0	1.7	11.7	14.3	15.8	735,339.4	0.00	1.00
12/06/2022 11:00	1	1.6	15.5	14.5	22.8	668,664.2	0.00	1.00
12/06/2022 12:00	1	1.6	14.8	14.5	22.2	670,804.0	0.00	1.00
12/06/2022 13:00	1	1.6	15.0	14.5	21.9	665,454.7	0.00	1.00
12/06/2022 14:00	0	1.5	13.9	14.5	18.7	702,257.9	0.00	1.00
12/06/2022 15:00	0	1.6	10.4	14.4	15.7	826,711.0	0.00	1.00
12/06/2022 16:00	0	1.6	10.4	14.2	12.8	947,151.1	0.00	1.00
12/06/2022 17:00	0	2.0	11.8	13.3	21.6	1,070,493.5	0.00	1.00
12/06/2022 18:00	0	1.9	11.1	13.5	21.3	1,074,628.0	0.00	1.00
12/06/2022 19:00	0	1.9	11.4	13.4	21.6	1,067,785.8	0.00	1.00
12/06/2022 20:00	0	1.9	11.0	13.5	21.5	1,073,517.7	0.00	1.00
12/06/2022 21:00	0	1.9	11.3	13.5	21.5	1,075,553.3	0.00	1.00
12/06/2022 22:00	0	1.8	10.1	13.9	19.9	1,079,693.3	0.00	1.00
12/06/2022 23:00	0	1.8	9.6	14.0	19.3	1,073,906.6	0.00	1.00
Average/Sum#:	0	1.7	13.3	14.2	20.7	820,612.3	0.00 #	24.00 #
Minimum:	0	1.2	9.6	13.3	12.8	665,454.7	0.00	1.00
Maximum:	1	2.0	17.1	14.5	25.6	1,079,693.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2022 00:00	0	1.7	8.1	14.3	13.8	1,004,659.5	0.00	1.00
12/07/2022 01:00	0	1.7	8.0	14.2	13.5	950,625.8	0.00	1.00
12/07/2022 02:00	0	1.6	8.2	14.3	14.7	999,057.3	0.00	1.00
12/07/2022 03:00	0	1.7	8.1	14.3	14.5	994,907.6	0.00	1.00
12/07/2022 04:00	0	1.7	8.8	14.2	18.2	1,031,769.3	0.00	1.00
12/07/2022 05:00	0	1.9	12.8	13.4	23.3	1,092,800.7	0.00	1.00
12/07/2022 06:00	0	1.9	12.0	13.4	23.9	1,092,618.1	0.00	1.00
12/07/2022 07:00	0	1.8	10.2	13.9	21.6	1,069,716.1	0.00	1.00
12/07/2022 08:00	0	1.7	10.1	14.1	19.7	1,086,477.1	0.00	1.00
12/07/2022 09:00	0	1.8	10.6	13.9	20.8	1,090,257.4	0.00	1.00
12/07/2022 10:00	0	1.8	10.2	13.9	19.9	1,077,541.4	0.00	1.00
12/07/2022 11:00	0	1.8	9.9	14.0	19.5	1,082,639.1	0.00	1.00
12/07/2022 12:00	0	1.7	9.4	14.1	17.8	992,027.1	0.00	1.00
12/07/2022 13:00	1	1.6	16.0	14.5	24.3	668,878.2	0.00	1.00
12/07/2022 14:00	0	1.5	14.2	14.5	18.7	755,537.1	0.00	1.00
12/07/2022 15:00	0	1.8	11.4	13.9	17.9	1,079,497.7	0.00	1.00
12/07/2022 16:00	0	1.8	11.1	13.9	19.7	1,067,759.8	0.00	1.00
12/07/2022 17:00	0	1.8	11.2	13.9	19.7	1,068,542.3	0.00	1.00
12/07/2022 18:00	0	1.8	11.1	13.9	19.8	1,069,129.2	0.00	1.00
12/07/2022 19:00	0	1.8	11.4	13.7	20.8	1,081,084.5	0.00	1.00
12/07/2022 20:00	0	1.9	12.4	13.3	23.9	1,086,710.3	0.00	1.00
12/07/2022 21:00	0	1.9	12.2	13.4	22.9	1,089,148.9	0.00	1.00
12/07/2022 22:00	0	1.8	10.5	13.9	20.5	1,087,518.6	0.00	1.00
12/07/2022 23:00	0	1.8	9.8	14.0	19.6	1,076,883.6	0.00	1.00
Average/Sum#:	0	1.8	10.7	14.0	19.5	1,028,991.1	0.00 #	24.00 #
Minimum:	0	1.5	8.0	13.3	13.5	668,878.2	0.00	1.00
Maximum:	1	1.9	16.0	14.5	24.3	1,092,800.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2022 00:00	0	1.8	10.8	13.7	21.2	1,082,035.5	0.00	1.00
12/08/2022 01:00	0	1.8	10.4	13.9	20.6	1,087,518.6	0.00	1.00
12/08/2022 02:00	0	1.8	10.4	13.9	20.3	1,079,888.9	0.00	1.00
12/08/2022 03:00	0	1.8	10.5	13.9	20.6	1,085,757.9	0.00	1.00
12/08/2022 04:00	0	1.8	11.0	13.7	21.6	1,085,459.0	0.00	1.00
12/08/2022 05:00	0	1.9	11.8	13.5	23.1	1,091,098.1	0.00	1.00
12/08/2022 06:00	0	1.9	12.6	13.3	24.5	1,095,359.3	0.00	1.00
12/08/2022 07:00	0	1.9	12.0	13.5	23.3	1,085,546.4	0.00	1.00
12/08/2022 08:00	0	1.8	10.5	13.9	20.8	1,083,214.7	0.00	1.00
12/08/2022 09:00	0	1.7	9.4	14.1	17.9	1,051,436.0	0.00	1.00
12/08/2022 10:00	0	1.7	8.2	14.3	14.3	988,060.4	0.00	1.00
12/08/2022 11:00	0	1.8	11.0	13.7	21.1	1,073,096.2	0.00	1.00
12/08/2022 12:00	0	1.9	12.2	13.4	23.2	1,088,235.9	0.00	1.00
12/08/2022 13:00	0	1.9	12.2	13.3	22.6	1,071,935.0	0.00	1.00
12/08/2022 14:00	0	2.0	13.2	13.2	24.3	1,085,402.2	0.00	1.00
12/08/2022 15:00	0	1.9	12.6	13.3	23.5	1,081,484.9	0.00	1.00
12/08/2022 16:00	0	2.0	13.1	13.1	24.7	1,073,769.2	0.00	1.00
12/08/2022 17:00	0	2.0	13.9	12.9	25.7	1,076,025.2	0.00	1.00
12/08/2022 18:00	0	2.0	14.2	12.9	26.4	1,085,097.6	0.00	1.00
12/08/2022 19:00	0	2.0	14.1	12.9	26.2	1,084,412.9	0.00	1.00
12/08/2022 20:00	0	2.0	13.9	12.9	25.9	1,083,557.0	0.00	1.00
12/08/2022 21:00	0	2.0	13.7	13.0	25.3	1,088,085.7	0.00	1.00
12/08/2022 22:00	0	2.0	13.2	13.1	24.0	1,079,738.5	0.00	1.00
12/08/2022 23:00	0	1.9	11.3	13.6	21.0	1,080,532.1	0.00	1.00
Average/Sum#:	0	1.9	11.9	13.5	22.6	1,077,781.1	0.00 #	24.00 #
Minimum:	0	1.7	8.2	12.9	14.3	988,060.4	0.00	1.00
Maximum:	0	2.0	14.2	14.3	26.4	1,095,359.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2022 00:00	0	1.7	8.1	14.2	12.5	943,063.3	0.00	1.00
12/09/2022 01:00	0	1.7	7.7	14.2	11.3	888,695.1	0.00	1.00
12/09/2022 02:00	0	1.7	7.9	14.3	12.7	955,484.7	0.00	1.00
12/09/2022 03:00	0	1.7	7.9	14.3	13.2	970,008.9	0.00	1.00
12/09/2022 04:00	0	1.7	8.3	14.2	15.0	1,012,965.3	0.00	1.00
12/09/2022 05:00	0	1.7	8.5	14.1	15.7	1,006,929.7	0.00	1.00
12/09/2022 06:00	0	1.7	8.4	14.3	16.2	1,060,266.5	0.00	1.00
12/09/2022 07:00	0	1.9	11.3	13.6	21.2	1,085,034.3	0.00	1.00
12/09/2022 08:00	0	1.7	9.9	14.2	18.7	939,384.2	0.00	1.00
12/09/2022 09:00	0	1.6	7.9	14.2	7.9	871,730.6	0.00	1.00
12/09/2022 10:00	1	1.7	16.3	14.5	25.3	671,017.9	0.00	1.00
12/09/2022 11:00	0	1.6	15.6	14.5	21.9	680,004.8	0.00	1.00
12/09/2022 12:00	0	1.6	15.2	14.4	21.6	680,709.3	0.00	1.00
12/09/2022 13:00	0	1.6	8.3	14.4	12.4	1,061,198.6	0.00	1.00
12/09/2022 14:00	0	1.7	8.8	14.3	16.1	1,048,439.6	0.00	1.00
12/09/2022 15:00	0	1.5	11.6	14.2	17.5	852,517.8	0.00	1.00
12/09/2022 16:00	0	1.9	11.7	13.5	21.0	1,079,439.5	0.00	1.00
12/09/2022 17:00	0	1.9	11.5	13.5	21.2	1,073,147.6	0.00	1.00
12/09/2022 18:00	0	1.9	11.6	13.4	21.6	1,066,142.5	0.00	1.00
12/09/2022 19:00	0	2.0	12.4	13.2	23.0	1,069,751.6	0.00	1.00
12/09/2022 20:00	0	2.0	12.8	13.1	23.3	1,065,693.1	0.00	1.00
12/09/2022 21:00	0	1.9	12.3	13.3	22.3	1,075,899.1	0.00	1.00
12/09/2022 22:00	0	1.9	12.2	13.3	22.2	1,069,232.1	0.00	1.00
12/09/2022 23:00	0	1.9	11.2	13.6	20.7	1,067,588.2	0.00	1.00
Average/Sum#:	0	1.8	10.7	14.0	18.1	970,597.7	0.00 #	24.00 #
Minimum:	0	1.5	7.7	13.1	7.9	671,017.9	0.00	1.00
Maximum:	1	2.0	16.3	14.5	25.3	1,085,034.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2022 00:00	0	1.7	8.9	14.3	16.8	1,059,229.0	0.00	1.00
12/10/2022 01:00	0	1.7	8.3	14.4	15.4	1,070,468.5	0.00	1.00
12/10/2022 02:00	0	1.6	8.7	14.4	16.4	1,070,679.2	0.00	1.00
12/10/2022 03:00	0	1.7	8.9	14.4	16.7	1,070,047.1	0.00	1.00
12/10/2022 04:00	0	1.7	9.0	14.4	17.0	1,069,625.8	0.00	1.00
12/10/2022 05:00	0	1.7	8.9	14.3	16.9	1,054,456.8	0.00	1.00
12/10/2022 06:00	0	1.7	8.7	14.3	16.2	1,055,701.7	0.00	1.00
12/10/2022 07:00	1	1.6	13.3	14.3	19.4	702,763.7	0.00	1.00
12/10/2022 08:00	0	1.5	11.1	14.3	13.3	759,615.6	0.00	1.00
12/10/2022 09:00	0	1.5	12.4	14.3	17.4	693,219.2	0.00	1.00
12/10/2022 10:00	1	1.6	15.3	14.4	21.3	654,584.9	0.00	1.00
12/10/2022 11:00	0	1.5	10.8	14.3	11.9	753,183.4	0.00	1.00
12/10/2022 12:00	0	1.6	7.4	14.3	8.5	966,066.7	0.00	1.00
12/10/2022 13:00	0	1.7	7.8	14.2	11.5	945,720.4	0.00	1.00
12/10/2022 14:00	0	1.8	11.7	13.6	18.6	1,044,889.6	0.00	1.00
12/10/2022 15:00	0	1.9	10.8	13.5	19.7	1,043,168.3	0.00	1.00
12/10/2022 16:00	0	1.9	11.0	13.5	20.1	1,051,125.7	0.00	1.00
12/10/2022 17:00	0	1.9	10.5	13.6	18.8	1,042,075.7	0.00	1.00
12/10/2022 18:00	0	1.9	10.4	13.7	18.7	1,055,788.2	0.00	1.00
12/10/2022 19:00	0	1.9	11.9	13.2	21.2	1,043,963.8	0.00	1.00
12/10/2022 20:00	0	1.9	11.6	13.3	20.8	1,048,150.2	0.00	1.00
12/10/2022 21:00	0	1.9	10.6	13.6	19.2	1,049,579.4	0.00	1.00
12/10/2022 22:00	0	1.8	10.2	13.7	19.0	1,048,750.8	0.00	1.00
12/10/2022 23:00	0	1.8	10.5	13.7	19.7	1,058,260.7	0.00	1.00
Average/Sum#:	0	1.7	10.4	14.0	17.3	975,463.1	0.00 #	24.00 #
Minimum:	0	1.5	7.4	13.2	8.5	654,584.9	0.00	1.00
Maximum:	1	1.9	15.3	14.4	21.3	1,070,679.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2022 00:00	0	1.8	10.3	13.7	18.2	1,022,693.7	0.00	1.00
12/11/2022 01:00	0	1.7	9.6	14.2	14.2	799,989.1	0.00	1.00
12/11/2022 02:00	0	1.6	12.2	14.3	17.7	699,236.4	0.00	1.00
12/11/2022 03:00	0	1.6	11.6	14.2	12.7	747,869.2	0.00	1.00
12/11/2022 04:00	0	1.7	7.8	14.2	10.1	883,380.9	0.00	1.00
12/11/2022 05:00	0	1.7	7.8	14.2	12.3	917,105.6	0.00	1.00
12/11/2022 06:00	0	1.7	7.9	14.2	12.2	903,206.9	0.00	1.00
12/11/2022 07:00	1	1.7	14.8	14.3	23.4	684,712.2	0.00	1.00
12/11/2022 08:00	1	1.6	18.7	14.6	28.9	662,540.6	0.00	1.00
12/11/2022 09:00	1	1.6	19.4	14.6	29.2	657,975.8	0.00	1.00
12/11/2022 10:00	1	1.6	17.6	14.5	24.5	660,961.2	0.00	1.00
12/11/2022 11:00	1	1.6	18.9	14.6	29.0	656,454.2	0.00	1.00
12/11/2022 12:00	1	1.6	18.8	14.6	27.7	656,671.6	0.00	1.00
12/11/2022 13:00	0	1.6	17.4	14.5	24.2	658,607.5	0.00	1.00
12/11/2022 14:00	0	1.6	15.7	14.5	22.1	674,227.5	0.00	1.00
12/11/2022 15:00	0	1.5	10.6	14.3	12.2	915,024.5	0.00	1.00
12/11/2022 16:00	0	1.8	11.8	13.8	18.5	1,070,272.7	0.00	1.00
12/11/2022 17:00	0	1.8	11.9	13.7	19.9	1,059,401.9	0.00	1.00
12/11/2022 18:00	0	1.8	11.3	13.8	19.5	1,061,593.2	0.00	1.00
12/11/2022 19:00	0	1.8	11.2	13.8	20.1	1,063,714.9	0.00	1.00
12/11/2022 20:00	0	1.9	12.3	13.7	20.2	1,073,286.4	0.00	1.00
12/11/2022 21:00	0	1.8	11.2	13.8	19.6	1,059,664.4	0.00	1.00
12/11/2022 22:00	0	1.7	11.6	14.2	19.8	881,541.4	0.00	1.00
12/11/2022 23:00	1	1.7	16.6	14.4	24.7	664,276.2	0.00	1.00
Average/Sum#:	0	1.7	13.2	14.2	20.0	838,933.7	0.00 #	24.00 #
Minimum:	0	1.5	7.8	13.7	10.1	656,454.2	0.00	1.00
Maximum:	1	1.9	19.4	14.6	29.2	1,073,286.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2022 00:00	1	1.6	16.3	14.4	23.0	675,863.6	0.00	1.00
12/12/2022 01:00	1	1.5	14.2	14.3	20.3	679,317.5	0.00	1.00
12/12/2022 02:00	0	1.7	13.0	14.2	12.9	726,408.1	0.00	1.00
12/12/2022 03:00	1	1.7	14.9	14.3	22.4	675,375.2	0.00	1.00
12/12/2022 04:00	0	1.6	10.5	14.1	12.6	901,806.2	0.00	1.00
12/12/2022 05:00	0	1.9	12.0	13.5	20.4	1,081,105.0	0.00	1.00
12/12/2022 06:00	0	1.9	12.1	13.4	22.7	1,089,148.9	0.00	1.00
12/12/2022 07:00	0	1.9	11.2	13.6	21.4	1,078,468.6	0.00	1.00
12/12/2022 08:00	0	1.8	10.3	13.9	20.1	1,079,693.3	0.00	1.00
12/12/2022 09:00	0	1.8	10.2	13.9	19.7	1,076,563.2	0.00	1.00
12/12/2022 10:00	0	1.7	9.7	14.1	18.7	983,770.3	0.00	1.00
12/12/2022 11:00	1	1.6	16.8	14.5	25.1	670,162.1	0.00	1.00
12/12/2022 12:00	1	1.6	16.4	14.5	23.9	671,017.9	0.00	1.00
12/12/2022 13:00	1	1.6	17.7	14.6	27.0	667,105.3	0.00	1.00
12/12/2022 14:00	1	2.1	20.0	14.7	24.4	652,906.2	0.12	1.00
12/12/2022 15:00	0	11.3	30.5	17.3	0.0	460,278.8	0.02	0.02
12/12/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.3	14.7	14.3	19.7	823,061.9	0.14 #	15.02 #
Minimum:	0	1.5	9.7	13.4	0.0	460,278.8	0.00	0.00
Maximum:	1	11.3	30.5	17.3	27.0	1,089,148.9	0.12	1.00
%SI	37.50	33.33	33.33	33.33	33.33	33.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2022 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2022 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2022 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2022 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2022 03:00	4	10.6	20.9	15.5	14.5	739,235.6	0.88	0.92
12/17/2022 04:00	0	1.4	22.0	14.6	28.3	678,843.2	0.00	1.00
12/17/2022 05:00	0	1.4	15.6	14.1	18.4	844,008.5	0.00	1.00
12/17/2022 06:00	0	1.9	12.1	14.0	19.6	1,093,951.8	0.00	1.00
12/17/2022 07:00	0	1.8	12.4	13.9	21.2	1,087,714.2	0.00	1.00
12/17/2022 08:00	0	1.7	9.2	14.3	13.4	1,030,180.6	0.00	1.00
12/17/2022 09:00	0	1.6	9.7	14.2	15.4	899,936.7	0.00	1.00
12/17/2022 10:00	0	1.6	15.2	14.4	21.5	708,308.4	0.00	1.00
12/17/2022 11:00	1	1.6	19.3	14.6	28.9	670,148.5	0.00	1.00
12/17/2022 12:00	1	1.6	20.0	14.6	29.4	659,932.1	0.00	1.00
12/17/2022 13:00	0	1.6	17.0	14.5	22.7	669,306.2	0.00	1.00
12/17/2022 14:00	0	1.5	13.7	14.5	17.2	765,165.9	0.00	1.00
12/17/2022 15:00	0	1.9	12.1	13.6	17.6	1,084,284.0	0.00	1.00
12/17/2022 16:00	0	1.9	12.4	13.4	21.9	1,084,949.3	0.00	1.00
12/17/2022 17:00	0	1.9	11.9	13.5	21.4	1,075,553.3	0.00	1.00
12/17/2022 18:00	0	1.8	11.1	13.7	20.6	1,074,047.2	0.00	1.00
12/17/2022 19:00	0	1.9	12.5	13.3	23.1	1,080,043.4	0.00	1.00
12/17/2022 20:00	0	2.0	13.5	13.1	24.7	1,087,990.1	0.00	1.00
12/17/2022 21:00	0	2.0	13.0	13.2	23.9	1,084,157.3	0.00	1.00
12/17/2022 22:00	0	1.9	12.5	13.3	22.7	1,078,601.9	0.00	1.00
12/17/2022 23:00	0	1.8	10.8	13.8	20.4	1,086,281.4	0.00	1.00
Average/Sum#:	0	2.2	14.1	14.0	21.3	932,506.6	0.88 #	20.92 #
Minimum:	0	1.4	9.2	13.1	13.4	659,932.1	0.00	0.00
Maximum:	4	10.6	22.0	15.5	29.4	1,093,951.8	0.88	1.00
%SI	12.50	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2022 00:00	0	1.7	8.2	14.3	13.5	1,005,489.5	0.00	1.00
12/18/2022 01:00	0	1.7	8.0	14.3	14.1	1,001,962.2	0.00	1.00
12/18/2022 02:00	0	1.6	8.9	14.2	14.6	946,333.6	0.00	1.00
12/18/2022 03:00	0	1.7	8.7	14.2	13.7	927,120.7	0.00	1.00
12/18/2022 04:00	0	1.7	8.5	14.3	14.5	991,795.2	0.00	1.00
12/18/2022 05:00	0	1.7	8.6	14.3	15.7	1,027,483.3	0.00	1.00
12/18/2022 06:00	0	1.7	9.5	14.1	18.2	1,024,853.0	0.00	1.00
12/18/2022 07:00	0	2.0	14.5	13.0	27.5	1,102,993.3	0.00	1.00
12/18/2022 08:00	0	1.9	13.3	13.3	25.2	1,089,773.5	0.00	1.00
12/18/2022 09:00	0	1.9	13.4	13.3	25.6	1,105,269.6	0.00	1.00
12/18/2022 10:00	0	1.8	11.5	13.7	21.1	1,049,892.0	0.00	1.00
12/18/2022 11:00	0	1.7	8.6	14.3	14.5	980,798.3	0.00	1.00
12/18/2022 12:00	1	1.7	12.1	14.3	20.8	820,409.7	0.00	1.00
12/18/2022 13:00	1	1.6	18.5	14.5	29.0	669,734.1	0.00	1.00
12/18/2022 14:00	0	1.5	13.1	14.3	13.4	791,153.8	0.00	1.00
12/18/2022 15:00	0	1.6	13.1	14.4	17.8	806,696.3	0.00	1.00
12/18/2022 16:00	0	1.8	9.6	14.2	18.1	1,071,421.3	0.00	1.00
12/18/2022 17:00	0	1.7	10.2	14.0	19.9	1,066,960.2	0.00	1.00
12/18/2022 18:00	0	1.9	12.5	13.3	23.3	1,089,232.9	0.00	1.00
12/18/2022 19:00	0	1.9	12.3	13.4	22.9	1,088,418.5	0.00	1.00
12/18/2022 20:00	0	1.9	12.0	13.5	23.0	1,092,023.4	0.00	1.00
12/18/2022 21:00	0	1.9	11.7	13.6	22.3	1,095,351.9	0.00	1.00
12/18/2022 22:00	0	1.8	11.4	13.7	22.0	1,093,447.3	0.00	1.00
12/18/2022 23:00	0	1.8	10.7	13.9	20.8	1,089,279.3	0.00	1.00
Average/Sum#:	0	1.8	11.2	13.9	19.6	1,001,162.2	0.00 #	24.00 #
Minimum:	0	1.5	8.0	13.0	13.4	669,734.1	0.00	1.00
Maximum:	1	2.0	18.5	14.5	29.0	1,105,269.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2022 00:00	0	1.9	11.8	13.5	22.5	1,088,877.4	0.00	1.00
12/19/2022 01:00	0	1.9	11.9	13.6	22.7	1,103,043.2	0.00	1.00
12/19/2022 02:00	0	1.9	12.1	13.5	22.5	1,089,987.8	0.00	1.00
12/19/2022 03:00	0	1.9	12.1	13.5	23.0	1,089,062.5	0.00	1.00
12/19/2022 04:00	0	1.9	12.9	13.3	24.4	1,099,143.3	0.00	1.00
12/19/2022 05:00	0	2.0	14.1	13.0	26.7	1,103,860.1	0.00	1.00
12/19/2022 06:00	0	2.0	14.3	13.0	26.8	1,110,620.5	0.00	1.00
12/19/2022 07:00	0	2.0	13.9	13.1	26.1	1,106,600.2	0.00	1.00
12/19/2022 08:00	0	1.9	13.0	13.3	24.5	1,103,647.9	0.00	1.00
12/19/2022 09:00	0	2.1	14.8	12.8	28.4	1,108,557.5	0.00	1.00
12/19/2022 10:00	0	2.0	14.6	12.9	27.7	1,107,693.1	0.00	1.00
12/19/2022 11:00	0	2.0	13.8	13.1	26.0	1,105,898.0	0.00	1.00
12/19/2022 12:00	0	1.9	12.8	13.4	23.9	1,104,121.2	0.00	1.00
12/19/2022 13:00	0	1.9	13.0	13.3	24.9	1,100,945.1	0.00	1.00
12/19/2022 14:00	0	2.0	13.6	13.2	25.7	1,105,676.8	0.00	1.00
12/19/2022 15:00	0	1.9	14.2	13.1	25.7	1,066,922.0	0.00	1.00
12/19/2022 16:00	0	2.0	14.0	13.2	26.4	1,123,461.5	0.00	1.00
12/19/2022 17:00	0	2.0	14.1	13.1	26.7	1,115,378.6	0.00	1.00
12/19/2022 18:00	0	2.0	14.0	13.1	26.6	1,112,394.0	0.00	1.00
12/19/2022 19:00	0	2.0	14.0	13.1	26.6	1,113,798.5	0.00	1.00
12/19/2022 20:00	0	2.0	14.0	13.1	26.5	1,113,271.8	0.00	1.00
12/19/2022 21:00	0	2.0	14.1	13.1	26.8	1,113,974.1	0.00	1.00
12/19/2022 22:00	0	2.0	14.0	13.2	26.6	1,124,528.6	0.00	1.00
12/19/2022 23:00	0	1.9	12.5	13.6	23.7	1,113,173.2	0.00	1.00
Average/Sum#:	0	2.0	13.5	13.2	25.5	1,105,193.2	0.00 #	24.00 #
Minimum:	0	1.9	11.8	12.8	22.5	1,066,922.0	0.00	1.00
Maximum:	0	2.1	14.8	13.6	28.4	1,124,528.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2022 00:00	0	1.7	8.8	14.4	16.2	1,088,165.7	0.00	1.00
12/20/2022 01:00	0	1.7	8.8	14.4	16.9	1,091,325.9	0.00	1.00
12/20/2022 02:00	0	1.6	9.0	14.4	17.0	1,092,168.6	0.00	1.00
12/20/2022 03:00	0	1.7	8.9	14.4	16.9	1,093,222.0	0.00	1.00
12/20/2022 04:00	0	1.7	9.0	14.4	17.0	1,091,115.2	0.00	1.00
12/20/2022 05:00	0	1.7	8.9	14.4	17.0	1,094,064.7	0.00	1.00
12/20/2022 06:00	0	1.6	8.9	14.4	17.2	1,093,854.1	0.00	1.00
12/20/2022 07:00	0	1.9	13.7	13.2	26.7	1,122,750.1	0.00	1.00
12/20/2022 08:00	0	1.9	12.7	13.5	24.2	1,117,376.3	0.00	1.00
12/20/2022 09:00	0	1.7	10.1	14.2	20.2	1,108,825.0	0.00	1.00
12/20/2022 10:00	0	1.7	10.4	14.3	20.5	991,795.2	0.00	1.00
12/20/2022 11:00	1	1.5	19.0	14.7	30.8	690,675.8	0.00	1.00
12/20/2022 12:00	1	1.6	20.7	14.8	33.0	685,834.7	0.00	1.00
12/20/2022 13:00	1	1.6	19.9	14.8	31.4	686,732.7	0.00	1.00
12/20/2022 14:00	1	1.6	19.9	14.8	31.3	684,487.7	0.00	1.00
12/20/2022 15:00	0	1.5	12.9	14.4	15.9	867,372.3	0.00	1.00
12/20/2022 16:00	0	1.8	9.8	14.1	18.2	1,098,560.3	0.00	1.00
12/20/2022 17:00	0	1.7	10.4	14.1	18.6	1,095,136.7	0.00	1.00
12/20/2022 18:00	0	1.7	10.3	14.1	19.3	1,092,720.1	0.00	1.00
12/20/2022 19:00	0	1.7	10.4	14.1	19.6	1,094,532.6	0.00	1.00
12/20/2022 20:00	0	1.7	10.5	14.1	19.7	1,094,532.6	0.00	1.00
12/20/2022 21:00	0	1.7	10.3	14.1	19.6	1,092,115.9	0.00	1.00
12/20/2022 22:00	0	1.7	10.2	14.1	19.4	1,088,088.2	0.00	1.00
12/20/2022 23:00	0	1.7	10.3	14.1	19.7	1,090,102.1	0.00	1.00
Average/Sum#:	0	1.7	11.8	14.3	21.1	1,014,398.1	0.00 #	24.00 #
Minimum:	0	1.5	8.8	13.2	15.9	684,487.7	0.00	1.00
Maximum:	1	1.9	20.7	14.8	33.0	1,122,750.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2022 00:00	0	1.7	10.1	14.1	19.5	1,089,900.7	0.00	1.00
12/21/2022 01:00	0	1.7	10.1	14.1	19.6	1,090,504.9	0.00	1.00
12/21/2022 02:00	0	1.7	10.5	14.1	19.6	1,089,095.2	0.00	1.00
12/21/2022 03:00	0	1.7	10.3	14.2	19.4	1,103,510.8	0.00	1.00
12/21/2022 04:00	0	1.7	10.2	14.2	20.1	1,101,058.1	0.00	1.00
12/21/2022 05:00	0	1.7	10.1	14.2	20.0	1,098,401.0	0.00	1.00
12/21/2022 06:00	0	1.7	10.4	14.1	20.8	1,099,970.0	0.00	1.00
12/21/2022 07:00	0	1.9	12.2	13.5	23.1	1,106,457.9	0.00	1.00
12/21/2022 08:00	0	1.8	10.9	13.9	21.9	1,118,037.2	0.00	1.00
12/21/2022 09:00	0	1.9	12.8	13.4	25.0	1,122,745.4	0.00	1.00
12/21/2022 10:00	0	1.9	12.5	13.5	24.1	1,115,710.8	0.00	1.00
12/21/2022 11:00	0	1.8	11.6	13.7	22.6	1,113,988.7	0.00	1.00
12/21/2022 12:00	0	1.8	11.4	13.7	22.2	1,106,000.4	0.00	1.00
12/21/2022 13:00	0	1.9	11.8	13.6	22.9	1,109,233.8	0.00	1.00
12/21/2022 14:00	0	1.8	11.4	13.7	21.9	1,102,196.4	0.00	1.00
12/21/2022 15:00	0	1.8	10.4	14.0	20.6	1,101,692.0	0.00	1.00
12/21/2022 16:00	0	1.8	11.5	13.7	22.1	1,106,190.6	0.00	1.00
12/21/2022 17:00	0	1.8	11.1	13.8	21.9	1,106,533.5	0.00	1.00
12/21/2022 18:00	0	1.8	10.9	13.9	21.6	1,111,581.3	0.00	1.00
12/21/2022 19:00	0	1.8	11.1	13.8	21.8	1,107,497.9	0.00	1.00
12/21/2022 20:00	0	1.9	12.3	13.4	24.0	1,103,756.1	0.00	1.00
12/21/2022 21:00	0	1.9	12.6	13.4	24.0	1,108,320.8	0.00	1.00
12/21/2022 22:00	0	1.8	10.6	13.9	20.9	1,091,822.5	0.00	1.00
12/21/2022 23:00	0	1.7	10.2	14.1	20.3	1,100,775.5	0.00	1.00
Average/Sum#:	0	1.8	11.1	13.8	21.7	1,104,374.2	0.00 #	24.00 #
Minimum:	0	1.7	10.1	13.4	19.4	1,089,095.2	0.00	1.00
Maximum:	0	1.9	12.8	14.2	25.0	1,122,745.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2022 00:00	0	1.7	9.9	14.1	19.9	1,087,081.3	0.00	1.00
12/22/2022 01:00	0	1.7	8.6	14.4	16.3	1,089,429.8	0.00	1.00
12/22/2022 02:00	0	1.7	8.8	14.4	16.5	1,091,115.2	0.00	1.00
12/22/2022 03:00	0	1.6	8.8	14.4	16.7	1,093,011.3	0.00	1.00
12/22/2022 04:00	0	1.7	8.8	14.4	16.5	1,089,219.1	0.00	1.00
12/22/2022 05:00	0	1.7	8.7	14.4	16.5	1,092,590.0	0.00	1.00
12/22/2022 06:00	0	1.7	8.7	14.4	16.8	1,093,432.7	0.00	1.00
12/22/2022 07:00	0	1.7	10.8	14.0	19.9	1,091,173.2	0.00	1.00
12/22/2022 08:00	0	1.7	10.6	14.1	20.7	1,101,983.9	0.00	1.00
12/22/2022 09:00	0	1.9	12.4	13.4	22.8	1,102,477.9	0.00	1.00
12/22/2022 10:00	0	2.0	13.8	13.1	26.2	1,111,516.1	0.00	1.00
12/22/2022 11:00	0	2.0	13.8	13.1	25.9	1,106,073.5	0.00	1.00
12/22/2022 12:00	0	1.8	11.2	13.8	21.2	1,098,239.8	0.00	1.00
12/22/2022 13:00	0	1.7	10.4	14.0	20.4	1,092,959.4	0.00	1.00
12/22/2022 14:00	0	1.7	10.1	14.1	19.7	1,092,115.9	0.00	1.00
12/22/2022 15:00	0	1.7	10.2	14.0	20.0	1,087,997.7	0.00	1.00
12/22/2022 16:00	0	1.8	11.7	13.7	22.1	1,106,761.2	0.00	1.00
12/22/2022 17:00	0	1.8	10.5	13.9	20.2	1,091,235.6	0.00	1.00
12/22/2022 18:00	0	1.8	10.4	14.0	20.6	1,103,676.7	0.00	1.00
12/22/2022 19:00	0	1.7	10.2	14.0	19.8	1,087,203.9	0.00	1.00
12/22/2022 20:00	0	1.7	9.8	14.1	19.6	1,091,914.6	0.00	1.00
12/22/2022 21:00	0	1.8	10.1	14.0	19.8	1,094,348.7	0.00	1.00
12/22/2022 22:00	0	1.8	10.2	14.0	19.9	1,097,325.7	0.00	1.00
12/22/2022 23:00	0	1.7	9.9	14.1	19.6	1,094,331.2	0.00	1.00
Average/Sum#:	0	1.8	10.4	14.0	19.9	1,095,300.6	0.00 #	24.00 #
Minimum:	0	1.6	8.6	13.1	16.3	1,087,081.3	0.00	1.00
Maximum:	0	2.0	13.8	14.4	26.2	1,111,516.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2022 00:00	0	1.7	9.8	14.1	19.5	1,094,734.0	0.00	1.00
12/23/2022 01:00	0	1.7	9.8	14.1	19.5	1,093,324.3	0.00	1.00
12/23/2022 02:00	0	1.7	10.1	14.1	19.6	1,092,921.5	0.00	1.00
12/23/2022 03:00	0	1.7	10.1	14.1	19.7	1,093,324.3	0.00	1.00
12/23/2022 04:00	0	1.7	9.9	14.1	19.6	1,093,525.6	0.00	1.00
12/23/2022 05:00	0	1.7	9.8	14.1	19.6	1,092,317.3	0.00	1.00
12/23/2022 06:00	0	1.7	9.8	14.1	19.6	1,089,900.7	0.00	1.00
12/23/2022 07:00	0	1.9	11.9	13.5	23.0	1,108,863.6	0.00	1.00
12/23/2022 08:00	0	1.8	11.2	13.8	21.5	1,103,640.3	0.00	1.00
12/23/2022 09:00	0	1.8	11.1	13.7	21.8	1,105,049.4	0.00	1.00
12/23/2022 10:00	0	1.8	10.9	13.8	21.4	1,110,005.3	0.00	1.00
12/23/2022 11:00	0	1.8	10.9	13.8	20.9	1,104,026.1	0.00	1.00
12/23/2022 12:00	0	1.7	9.8	14.1	18.9	1,081,845.3	0.00	1.00
12/23/2022 13:00	0	1.5	12.2	14.4	18.1	746,652.3	0.00	1.00
12/23/2022 14:00	0	1.4	12.1	14.5	15.7	803,467.0	0.00	1.00
12/23/2022 15:00	0	1.8	11.7	13.8	19.5	1,086,474.3	0.00	1.00
12/23/2022 16:00	0	2.0	13.5	13.2	24.0	1,093,405.3	0.00	1.00
12/23/2022 17:00	0	1.9	12.7	13.3	23.8	1,098,782.9	0.00	1.00
12/23/2022 18:00	0	1.9	12.6	13.3	23.7	1,092,656.5	0.00	1.00
12/23/2022 19:00	0	1.9	11.8	13.6	21.9	1,101,730.1	0.00	1.00
12/23/2022 20:00	0	1.9	11.6	13.6	21.7	1,095,727.1	0.00	1.00
12/23/2022 21:00	0	1.9	11.9	13.6	22.5	1,108,671.0	0.00	1.00
12/23/2022 22:00	0	1.9	11.5	13.7	22.3	1,109,043.6	0.00	1.00
12/23/2022 23:00	0	1.8	11.1	13.8	21.3	1,097,468.3	0.00	1.00
Average/Sum#:	0	1.8	11.2	13.8	20.8	1,070,731.5	0.00 #	24.00 #
Minimum:	0	1.4	9.8	13.2	15.7	746,652.3	0.00	1.00
Maximum:	0	2.0	13.5	14.5	24.0	1,110,005.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2022 00:00	0	1.7	8.7	14.4	16.1	1,085,216.2	0.00	1.00
12/24/2022 01:00	0	1.7	8.6	14.4	16.5	1,089,640.4	0.00	1.00
12/24/2022 02:00	0	1.6	9.0	14.4	16.7	1,091,957.9	0.00	1.00
12/24/2022 03:00	0	1.7	8.9	14.4	16.7	1,090,272.5	0.00	1.00
12/24/2022 04:00	0	1.7	8.8	14.4	16.5	1,088,587.0	0.00	1.00
12/24/2022 05:00	0	1.7	8.8	14.4	16.7	1,089,008.4	0.00	1.00
12/24/2022 06:00	0	1.7	8.8	14.4	16.5	1,072,786.0	0.00	1.00
12/24/2022 07:00	1	1.7	14.4	14.4	25.2	772,566.0	0.00	1.00
12/24/2022 08:00	1	1.6	18.6	14.6	27.3	682,755.9	0.00	1.00
12/24/2022 09:00	0	1.6	11.4	14.3	15.8	981,005.8	0.00	1.00
12/24/2022 10:00	0	1.8	12.1	13.8	20.8	1,111,548.3	0.00	1.00
12/24/2022 11:00	0	1.7	10.7	14.1	20.0	1,101,782.5	0.00	1.00
12/24/2022 12:00	0	1.8	10.8	14.0	19.2	1,092,959.4	0.00	1.00
12/24/2022 13:00	0	1.7	10.7	14.0	19.5	1,087,005.4	0.00	1.00
12/24/2022 14:00	0	1.8	10.4	14.1	19.0	1,090,907.6	0.00	1.00
12/24/2022 15:00	0	1.7	10.6	14.1	19.1	1,092,518.7	0.00	1.00
12/24/2022 16:00	0	1.7	10.9	14.0	19.1	1,087,402.3	0.00	1.00
12/24/2022 17:00	0	1.8	10.5	14.1	18.7	1,088,692.4	0.00	1.00
12/24/2022 18:00	0	1.7	10.4	14.1	18.9	1,091,109.0	0.00	1.00
12/24/2022 19:00	0	1.8	10.6	14.0	19.0	1,080,456.0	0.00	1.00
12/24/2022 20:00	0	1.7	9.8	14.2	17.0	1,010,308.2	0.00	1.00
12/24/2022 21:00	1	1.6	15.9	14.5	24.4	676,581.2	0.00	1.00
12/24/2022 22:00	1	1.6	15.6	14.5	22.9	680,860.7	0.00	1.00
12/24/2022 23:00	1	1.6	15.7	14.5	23.1	682,572.5	0.00	1.00
Average/Sum#:	0	1.7	11.3	14.3	19.4	1,000,770.8	0.00 #	24.00 #
Minimum:	0	1.6	8.6	13.8	15.8	676,581.2	0.00	1.00
Maximum:	1	1.8	18.6	14.6	27.3	1,111,548.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2022 00:00	0	1.5	14.1	14.4	20.2	709,361.8	0.00	1.00
12/25/2022 01:00	1	1.6	15.5	14.5	22.8	686,424.0	0.00	1.00
12/25/2022 02:00	0	1.6	16.6	14.5	23.7	683,000.4	0.00	1.00
12/25/2022 03:00	1	1.6	16.7	14.5	24.5	681,288.6	0.00	1.00
12/25/2022 04:00	1	1.6	16.7	14.5	24.6	680,860.7	0.00	1.00
12/25/2022 05:00	1	1.6	16.9	14.5	25.5	678,079.0	0.00	1.00
12/25/2022 06:00	1	1.6	17.3	14.5	26.0	677,437.1	0.00	1.00
12/25/2022 07:00	1	1.6	18.6	14.6	29.8	681,234.3	0.00	1.00
12/25/2022 08:00	1	1.6	17.8	14.5	25.6	676,153.3	0.00	1.00
12/25/2022 09:00	0	1.4	14.1	14.4	19.4	740,121.2	0.00	1.00
12/25/2022 10:00	1	1.6	17.0	14.5	25.4	684,070.3	0.00	1.00
12/25/2022 11:00	0	1.6	16.1	14.5	22.2	696,266.7	0.00	1.00
12/25/2022 12:00	1	1.6	14.5	14.4	21.2	714,839.5	0.00	1.00
12/25/2022 13:00	1	1.6	16.7	14.5	24.7	672,943.7	0.00	1.00
12/25/2022 14:00	1	1.6	17.9	14.6	26.8	672,322.2	0.00	1.00
12/25/2022 15:00	1	1.6	19.4	14.7	30.3	669,913.6	0.00	1.00
12/25/2022 16:00	0	1.5	12.7	14.4	15.9	863,158.7	0.00	1.00
12/25/2022 17:00	0	1.8	9.4	14.1	16.7	1,090,102.1	0.00	1.00
12/25/2022 18:00	1	1.6	13.5	14.5	24.2	815,235.5	0.00	1.00
12/25/2022 19:00	1	1.6	17.0	14.5	25.7	669,948.1	0.00	1.00
12/25/2022 20:00	1	1.6	16.9	14.5	25.2	672,301.8	0.00	1.00
12/25/2022 21:00	0	1.6	16.8	14.5	24.0	672,943.7	0.00	1.00
12/25/2022 22:00	1	1.6	17.6	14.6	27.7	676,669.5	0.00	1.00
12/25/2022 23:00	1	1.6	17.8	14.6	26.9	673,626.4	0.00	1.00
Average/Sum#:	1	1.6	16.2	14.5	24.1	714,095.9	0.00 #	24.00 #
Minimum:	0	1.4	9.4	14.1	15.9	669,913.6	0.00	1.00
Maximum:	1	1.8	19.4	14.7	30.3	1,090,102.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2022 00:00	0	1.5	14.3	14.4	18.2	703,252.1	0.00	1.00
12/26/2022 01:00	1	1.6	16.8	14.5	25.0	674,013.6	0.00	1.00
12/26/2022 02:00	0	1.6	15.2	14.5	20.6	705,039.6	0.00	1.00
12/26/2022 03:00	1	1.6	16.2	14.4	25.1	672,703.4	0.00	1.00
12/26/2022 04:00	1	1.6	17.0	14.5	25.1	674,227.5	0.00	1.00
12/26/2022 05:00	0	1.5	11.3	14.3	10.7	774,969.7	0.00	1.00
12/26/2022 06:00	0	1.5	11.1	14.3	12.1	774,554.7	0.00	1.00
12/26/2022 07:00	1	1.6	16.7	14.5	28.6	678,079.0	0.00	1.00
12/26/2022 08:00	1	1.6	20.5	14.8	32.6	679,099.8	0.00	1.00
12/26/2022 09:00	0	1.6	16.5	14.5	23.3	676,795.2	0.00	1.00
12/26/2022 10:00	0	1.4	9.6	14.3	6.5	844,478.4	0.00	1.00
12/26/2022 11:00	0	1.8	8.7	14.2	13.2	1,039,740.6	0.00	1.00
12/26/2022 12:00	0	1.7	9.5	14.1	18.0	1,088,692.4	0.00	1.00
12/26/2022 13:00	0	1.8	10.0	13.9	18.6	1,081,258.4	0.00	1.00
12/26/2022 14:00	0	1.9	11.3	13.6	21.0	1,087,848.2	0.00	1.00
12/26/2022 15:00	0	1.9	11.5	13.5	20.9	1,082,400.4	0.00	1.00
12/26/2022 16:00	0	1.8	10.8	13.7	20.3	1,079,753.1	0.00	1.00
12/26/2022 17:00	0	1.9	11.4	13.6	21.0	1,088,223.4	0.00	1.00
12/26/2022 18:00	0	1.9	11.3	13.6	20.8	1,085,784.7	0.00	1.00
12/26/2022 19:00	0	1.8	10.2	13.9	19.1	1,077,932.6	0.00	1.00
12/26/2022 20:00	0	1.8	10.1	13.9	18.6	1,075,780.7	0.00	1.00
12/26/2022 21:00	0	1.8	9.4	14.0	16.8	1,042,350.3	0.00	1.00
12/26/2022 22:00	1	1.6	14.7	14.5	23.5	684,498.2	0.00	1.00
12/26/2022 23:00	1	1.6	16.7	14.6	24.1	653,628.4	0.00	1.00
Average/Sum#:	0	1.7	13.0	14.2	20.2	876,046.0	0.00 #	24.00 #
Minimum:	0	1.4	8.7	13.5	6.5	653,628.4	0.00	1.00
Maximum:	1	1.9	20.5	14.8	32.6	1,088,692.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2022 00:00	1	1.6	15.7	14.6	22.5	662,975.3	0.00	1.00
12/27/2022 01:00	1	1.6	17.1	14.6	24.9	652,106.8	0.00	1.00
12/27/2022 02:00	1	1.6	17.8	14.6	25.3	651,237.4	0.00	1.00
12/27/2022 03:00	1	1.6	17.6	14.6	25.0	652,106.8	0.00	1.00
12/27/2022 04:00	1	1.6	17.1	14.6	24.4	651,454.7	0.00	1.00
12/27/2022 05:00	1	1.6	16.8	14.6	23.9	652,324.2	0.00	1.00
12/27/2022 06:00	0	1.6	16.1	14.6	21.6	660,149.5	0.00	1.00
12/27/2022 07:00	1	1.6	16.6	14.6	24.6	654,063.2	0.00	1.00
12/27/2022 08:00	0	1.6	14.8	14.5	18.4	671,873.8	0.00	1.00
12/27/2022 09:00	0	1.6	16.0	14.6	21.9	668,626.9	0.00	1.00
12/27/2022 10:00	0	1.6	17.7	14.6	24.6	653,845.8	0.00	1.00
12/27/2022 11:00	0	1.6	17.6	14.6	24.3	655,150.0	0.00	1.00
12/27/2022 12:00	0	1.6	17.3	14.6	23.7	657,106.3	0.00	1.00
12/27/2022 13:00	0	1.6	14.7	14.5	18.1	669,734.1	0.00	1.00
12/27/2022 14:00	0	1.6	14.8	14.5	19.8	668,236.3	0.00	1.00
12/27/2022 15:00	1	1.6	16.9	14.6	24.1	657,758.4	0.00	1.00
12/27/2022 16:00	0	1.6	16.9	14.6	22.2	659,497.4	0.00	1.00
12/27/2022 17:00	1	1.6	17.6	14.6	25.2	655,584.8	0.00	1.00
12/27/2022 18:00	1	1.6	17.5	14.6	24.2	659,280.0	0.00	1.00
12/27/2022 19:00	1	1.6	18.1	14.6	25.6	654,932.6	0.00	1.00
12/27/2022 20:00	1	1.6	18.5	14.6	26.2	653,628.4	0.00	1.00
12/27/2022 21:00	1	1.6	18.8	14.7	27.1	663,950.0	0.00	1.00
12/27/2022 22:00	1	1.6	19.0	14.7	27.3	663,508.2	0.00	1.00
12/27/2022 23:00	0	1.6	18.7	14.7	26.0	674,110.2	0.00	1.00
Average/Sum#:	1	1.6	17.1	14.6	23.8	659,301.7	0.00 #	24.00 #
Minimum:	0	1.6	14.7	14.5	18.1	651,237.4	0.00	1.00
Maximum:	1	1.6	19.0	14.7	27.3	674,110.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2022 00:00	0	1.4	14.4	14.5	19.3	737,991.4	0.00	1.00
12/28/2022 01:00	0	1.6	17.2	14.6	24.1	672,104.8	0.00	1.00
12/28/2022 02:00	0	1.6	17.6	14.5	24.3	664,170.8	0.00	1.00
12/28/2022 03:00	0	1.6	17.5	14.5	24.2	663,742.9	0.00	1.00
12/28/2022 04:00	0	1.6	17.6	14.6	24.6	673,626.4	0.00	1.00
12/28/2022 05:00	0	1.6	17.6	14.5	24.6	663,956.9	0.00	1.00
12/28/2022 06:00	0	1.6	17.7	14.5	25.0	663,742.9	0.00	1.00
12/28/2022 07:00	1	1.6	18.7	14.6	27.0	674,930.6	0.00	1.00
12/28/2022 08:00	0	1.6	18.2	14.6	25.3	674,278.5	0.00	1.00
12/28/2022 09:00	0	1.6	17.2	14.6	23.8	674,713.2	0.00	1.00
12/28/2022 10:00	0	1.6	16.6	14.6	22.6	674,495.9	0.00	1.00
12/28/2022 11:00	0	1.6	16.2	14.6	21.9	675,582.7	0.00	1.00
12/28/2022 12:00	0	1.6	15.9	14.6	21.7	677,321.6	0.00	1.00
12/28/2022 13:00	0	1.6	16.3	14.6	22.6	672,539.5	0.00	1.00
12/28/2022 14:00	0	1.6	16.7	14.6	23.1	667,105.3	0.00	1.00
12/28/2022 15:00	0	1.6	16.5	14.6	22.7	672,322.2	0.00	1.00
12/28/2022 16:00	1	1.5	15.9	14.5	23.0	676,581.2	0.00	1.00
12/28/2022 17:00	0	1.6	16.8	14.6	22.5	673,191.6	0.00	1.00
12/28/2022 18:00	0	1.6	16.7	14.6	23.2	674,278.5	0.00	1.00
12/28/2022 19:00	0	1.6	16.6	14.5	22.9	665,026.7	0.00	1.00
12/28/2022 20:00	0	1.6	16.5	14.5	22.7	665,240.7	0.00	1.00
12/28/2022 21:00	0	1.6	16.4	14.5	22.5	667,808.4	0.00	1.00
12/28/2022 22:00	0	1.6	16.5	14.5	22.6	665,668.6	0.00	1.00
12/28/2022 23:00	0	1.6	16.6	14.5	22.9	667,166.4	0.00	1.00
Average/Sum#:	0	1.6	16.8	14.6	23.3	673,232.8	0.00 #	24.00 #
Minimum:	0	1.4	14.4	14.5	19.3	663,742.9	0.00	1.00
Maximum:	1	1.6	18.7	14.6	27.0	737,991.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2022 00:00	0	1.6	17.0	14.5	23.8	666,096.6	0.00	1.00
12/29/2022 01:00	0	1.6	16.7	14.5	23.1	668,236.3	0.00	1.00
12/29/2022 02:00	0	1.5	17.2	14.5	23.7	666,096.6	0.00	1.00
12/29/2022 03:00	0	1.6	17.0	14.5	23.4	666,524.5	0.00	1.00
12/29/2022 04:00	0	1.6	16.8	14.5	22.8	666,096.6	0.00	1.00
12/29/2022 05:00	0	1.6	16.8	14.5	23.2	666,524.5	0.00	1.00
12/29/2022 06:00	0	1.6	16.8	14.5	23.0	665,240.7	0.00	1.00
12/29/2022 07:00	0	1.6	16.7	14.5	23.0	665,668.6	0.00	1.00
12/29/2022 08:00	0	1.6	16.5	14.5	22.8	667,380.4	0.00	1.00
12/29/2022 09:00	0	1.6	16.6	14.5	22.9	667,380.4	0.00	1.00
12/29/2022 10:00	0	1.6	16.5	14.5	22.8	667,380.4	0.00	1.00
12/29/2022 11:00	0	1.6	16.6	14.6	22.8	676,669.5	0.00	1.00
12/29/2022 12:00	0	1.6	16.7	14.6	22.8	674,278.5	0.00	1.00
12/29/2022 13:00	0	1.6	16.7	14.6	22.6	672,539.5	0.00	1.00
12/29/2022 14:00	0	1.6	16.6	14.6	22.1	672,104.8	0.00	1.00
12/29/2022 15:00	0	1.6	16.4	14.6	22.0	673,409.0	0.00	1.00
12/29/2022 16:00	0	1.6	16.2	14.6	21.4	674,495.9	0.00	1.00
12/29/2022 17:00	0	1.6	16.2	14.6	21.7	674,278.5	0.00	1.00
12/29/2022 18:00	0	1.6	16.4	14.6	22.0	673,409.0	0.00	1.00
12/29/2022 19:00	0	1.6	16.3	14.6	21.5	673,409.0	0.00	1.00
12/29/2022 20:00	0	1.6	16.2	14.6	21.4	674,930.6	0.00	1.00
12/29/2022 21:00	0	1.6	16.5	14.6	21.8	672,974.3	0.00	1.00
12/29/2022 22:00	0	1.6	16.8	14.6	22.5	669,496.4	0.00	1.00
12/29/2022 23:00	0	1.6	17.0	14.6	22.9	667,105.3	0.00	1.00
Average/Sum#:	0	1.6	16.6	14.6	22.6	670,071.9	0.00 #	24.00 #
Minimum:	0	1.5	16.2	14.5	21.4	665,240.7	0.00	1.00
Maximum:	0	1.6	17.2	14.6	23.8	676,669.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2022 00:00	0	1.6	17.1	14.6	23.2	666,235.8	0.00	1.00
12/30/2022 01:00	0	1.6	17.1	14.6	22.8	666,018.5	0.00	1.00
12/30/2022 02:00	0	1.5	17.6	14.6	23.6	665,801.1	0.00	1.00
12/30/2022 03:00	0	1.6	17.1	14.6	22.6	667,757.4	0.00	1.00
12/30/2022 04:00	0	1.6	17.0	14.6	22.7	668,409.5	0.00	1.00
12/30/2022 05:00	0	1.6	16.8	14.6	22.0	666,453.2	0.00	1.00
12/30/2022 06:00	0	1.6	16.7	14.6	22.1	667,974.8	0.00	1.00
12/30/2022 07:00	0	1.6	16.7	14.6	22.1	667,540.0	0.00	1.00
12/30/2022 08:00	0	1.6	16.5	14.6	21.6	666,670.6	0.00	1.00
12/30/2022 09:00	0	1.6	16.4	14.6	21.6	665,366.4	0.00	1.00
12/30/2022 10:00	0	1.6	16.1	14.6	20.8	667,322.7	0.00	1.00
12/30/2022 11:00	0	1.6	16.0	14.6	20.8	666,235.8	0.00	1.00
12/30/2022 12:00	0	1.6	15.4	14.6	19.7	667,540.0	0.00	1.00
12/30/2022 13:00	0	1.6	15.2	14.6	19.4	667,540.0	0.00	1.00
12/30/2022 14:00	0	1.6	15.0	14.6	19.1	668,844.3	0.00	1.00
12/30/2022 15:00	0	1.6	14.8	14.6	18.7	670,148.5	0.00	1.00
12/30/2022 16:00	0	1.6	14.6	14.6	18.3	670,800.6	0.00	1.00
12/30/2022 17:00	0	1.6	14.5	14.6	18.1	672,539.5	0.00	1.00
12/30/2022 18:00	0	1.6	14.3	14.6	17.6	672,756.9	0.00	1.00
12/30/2022 19:00	0	1.6	14.0	14.6	16.9	675,148.0	0.00	1.00
12/30/2022 20:00	0	1.6	13.6	14.6	15.9	679,495.3	0.00	1.00
12/30/2022 21:00	0	1.6	13.2	14.6	14.5	681,886.4	0.00	1.00
12/30/2022 22:00	0	1.5	13.2	14.6	14.6	682,755.9	0.00	1.00
12/30/2022 23:00	0	1.6	13.3	14.5	14.8	672,301.8	0.00	1.00
Average/Sum#:	0	1.6	15.5	14.6	19.7	670,147.6	0.00 #	24.00 #
Minimum:	0	1.5	13.2	14.5	14.5	665,366.4	0.00	1.00
Maximum:	0	1.6	17.6	14.6	23.6	682,755.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2022 00:00	0	1.6	13.4	14.6	15.3	682,321.1	0.00	1.00
12/31/2022 01:00	0	1.6	13.4	14.5	15.1	671,445.9	0.00	1.00
12/31/2022 02:00	0	1.7	13.9	14.5	16.0	671,445.9	0.00	1.00
12/31/2022 03:00	0	1.6	13.7	14.5	16.0	670,162.1	0.00	1.00
12/31/2022 04:00	0	1.6	13.7	14.5	15.5	669,306.2	0.00	1.00
12/31/2022 05:00	0	1.6	13.8	14.5	15.9	669,520.1	0.00	1.00
12/31/2022 06:00	0	1.2	10.8	14.4	7.8	739,489.2	0.00	1.00
12/31/2022 07:00	0	1.6	9.3	14.3	7.7	764,802.8	0.00	1.00
12/31/2022 08:00	0	1.6	14.0	14.5	16.8	671,445.9	0.00	1.00
12/31/2022 09:00	0	1.5	12.0	14.5	11.3	725,367.0	0.08	1.00
12/31/2022 10:00	0	12.4	28.2	15.8	0.0	551,797.5	0.12	0.12
12/31/2022 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2022 14:00	0	12.0	18.3	16.0	2.0	761,008.7	0.58	0.58
12/31/2022 15:00	0	1.9	12.7	14.4	18.5	736,539.6	0.37	1.00
12/31/2022 16:00	0	1.6	17.2	14.6	22.5	674,278.5	0.00	1.00
12/31/2022 17:00	0	1.6	17.6	14.6	23.6	668,409.5	0.00	1.00
12/31/2022 18:00	0	1.6	17.7	14.6	23.9	667,540.0	0.00	1.00
12/31/2022 19:00	0	1.6	17.6	14.6	23.5	669,061.6	0.00	1.00
12/31/2022 20:00	0	1.6	17.7	14.6	24.4	667,540.0	0.00	1.00
12/31/2022 21:00	0	1.6	17.5	14.6	23.6	669,279.0	0.00	1.00
12/31/2022 22:00	0	1.6	16.7	14.6	22.0	674,278.5	0.00	1.00
12/31/2022 23:00	0	1.6	16.0	14.6	20.9	678,191.1	0.00	1.00
Average/Sum#:	0	2.6	15.5	14.7	16.3	683,487.2	1.15 #	19.70 #
Minimum:	0	1.2	9.3	14.3	0.0	551,797.5	0.00	0.00
Maximum:	0	12.4	28.2	16.0	24.4	764,802.8	0.58	1.00
%SI	20.83	12.50	12.50	12.50	12.50	12.50	0.00	0.00

ATTACHMENT 15

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NO_x	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/19/2022 09:00	10/19/2022 15:00	7
12/06/2022 02:00	12/06/2022 14:00	13
12/28/2022 01:00	12/31/2022 23:00	95

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	115.00 Hour(s)
Offline Percentage:	5.21 %
Total Online:	2,093.00 Hour(s)
Online Percentage:	94.79 %

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/19/2022 08:29	10/19/2022 08:36	Shutdown	8
2	10/19/2022 16:09	10/19/2022 16:51	cold Startup	43
3	12/06/2022 00:54	12/06/2022 01:01	Shutdown	8
4	12/06/2022 15:09	12/06/2022 16:23	cold Startup	75
5	12/27/2022 23:54	12/28/2022 00:00	Shutdown	7

Startup / Shutdown Events

CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:46 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	118	0.09
Warm Startup	0		0.00
Shutdown	3	23	0.02
Total Process Events:	5	141	0.11

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,090.37 Hour(s)
Total Startup Time:	118 Minute(s)
Total Shutdown Time:	23 Minute(s)
Total Startup/Shutdown Time:	141 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.11 %

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/09/2022 00:00	10/18/2022 13:00	230
11/08/2022 01:00	11/09/2022 19:00	43
11/29/2022 08:00	11/29/2022 10:00	3
12/03/2022 19:00	12/05/2022 16:00	46
12/12/2022 16:00	12/17/2022 02:00	107
12/31/2022 11:00	12/31/2022 13:00	3

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	432.00 Hour(s)
Offline Percentage:	19.57 %
Total Online:	1,776.00 Hour(s)
Online Percentage:	80.43 %

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/08/2022 22:53	10/08/2022 23:00	Shutdown	8
2	10/18/2022 14:54	10/18/2022 15:43	cold Startup	50
3	11/07/2022 23:53	11/08/2022 00:01	Shutdown	9
4	11/09/2022 20:31	11/09/2022 21:31	cold Startup	61
5	11/29/2022 07:20	11/29/2022 07:20	Shutdown	1
6	11/29/2022 11:50	11/29/2022 12:33	cold Startup	44
7	12/03/2022 17:55	12/03/2022 18:02	Shutdown	8
8	12/05/2022 17:06	12/05/2022 18:32	cold Startup	87
9	12/12/2022 14:53	12/12/2022 15:00	Shutdown	8
10	12/17/2022 03:05	12/17/2022 03:57	cold Startup	53
11	12/31/2022 09:55	12/31/2022 10:06	Shutdown	12
12	12/31/2022 14:25	12/31/2022 15:21	cold Startup	57

Startup / Shutdown Events

CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:44 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	6	352	0.33
Warm Startup	0		0.00
Shutdown	6	46	0.04
Total Process Events:	12	398	0.38

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,767.73 Hour(s)
Total Startup Time:	352 Minute(s)
Total Shutdown Time:	46 Minute(s)
Total Startup/Shutdown Time:	398 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.38 %

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2022	23.99	94.97	10.63	21.25	35.40
10/02/2022	38.90	110.10	11.54	23.10	38.51
10/03/2022	48.06	113.38	13.02	26.00	43.38
10/04/2022	85.68	137.90	15.11	30.20	50.34
10/05/2022	68.63	141.28	15.16	30.31	50.56
10/06/2022	52.28	125.69	13.62	27.26	45.42
10/07/2022	71.36	141.34	15.29	30.58	51.00
10/08/2022	73.95	123.81	13.30	26.62	44.33
10/09/2022	35.57	64.88	6.96	13.96	23.26
10/10/2022	27.67	59.52	6.55	13.14	21.90
10/11/2022	17.92	47.24	5.17	10.36	17.25
10/12/2022	15.66	46.66	5.01	10.22	16.98
10/13/2022	16.66	47.21	5.17	10.48	17.41
10/14/2022	26.11	54.89	5.95	11.99	19.93
10/15/2022	15.42	45.23	4.92	9.95	16.56
10/16/2022	27.92	53.05	5.80	11.75	19.52
10/17/2022	32.37	63.74	6.95	13.90	23.19
10/18/2022	50.34	102.68	10.26	20.59	34.26
10/19/2022	75.01	97.70	10.21	20.36	33.92
10/20/2022	29.13	103.49	11.33	22.70	37.88
10/21/2022	32.32	102.93	11.32	22.61	37.71
10/22/2022	34.84	134.28	14.55	29.09	48.52
10/23/2022	40.33	124.08	13.31	26.65	44.41
10/24/2022	46.76	124.44	13.56	27.05	45.09
10/25/2022	37.75	117.15	12.77	25.54	42.60
10/26/2022	32.94	101.99	11.27	22.50	37.52
10/27/2022	48.24	115.96	12.65	25.26	42.06
10/28/2022	50.59	134.17	14.50	29.00	48.37
10/29/2022	37.35	106.67	11.50	23.03	38.37
10/30/2022	35.20	105.48	11.44	22.91	38.15
10/31/2022	38.22	104.11	11.54	23.12	38.52
Monthly Avg/Sum*:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
Daily Min:	15.42	45.23	4.92	9.95	16.56
Daily Max:	85.68	141.34	15.29	30.58	51.00
Oct 2022 - Oct 2022	1,267.17	3,046.02	330.36	661.48	1,102.32
QTD:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
YTD 2022:	11,980.84 *	22,223.38 *	2,278.01 *	4,557.33 *	7,596.69 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2022	57.32	144.53	15.65	31.30	52.21
11/02/2022	49.02	125.51	13.60	27.18	45.35
11/03/2022	46.77	129.29	13.99	28.00	46.67
11/04/2022	36.74	107.04	11.51	23.00	38.38
11/05/2022	30.29	94.08	10.08	20.19	33.62
11/06/2022	44.82	122.08	12.51	25.03	41.71
11/07/2022	44.12	113.74	12.13	24.26	40.41
11/08/2022	36.05	59.15	6.32	12.68	21.10
11/09/2022	54.79	69.43	6.44	12.98	21.63
11/10/2022	40.54	113.02	12.35	24.68	41.12
11/11/2022	47.96	124.31	13.53	27.04	45.02
11/12/2022	56.08	145.56	15.78	31.54	52.56
11/13/2022	47.82	135.29	14.62	29.21	48.70
11/14/2022	46.53	140.29	15.22	30.37	50.66
11/15/2022	43.33	137.03	14.91	29.79	49.69
11/16/2022	51.07	132.38	14.47	28.97	48.27
11/17/2022	53.64	137.91	14.98	29.86	49.78
11/18/2022	48.88	156.10	16.93	33.86	56.43
11/19/2022	44.93	131.37	14.24	28.54	47.54
11/20/2022	61.24	145.00	15.75	31.49	52.52
11/21/2022	57.81	130.39	14.27	28.52	47.52
11/22/2022	57.43	130.21	14.11	28.17	46.92
11/23/2022	52.86	118.68	12.97	25.94	43.25
11/24/2022	65.70	134.77	14.70	29.37	48.96
11/25/2022	63.23	124.07	13.44	26.84	44.75
11/26/2022	61.11	131.31	14.16	28.31	47.24
11/27/2022	56.41	122.51	13.40	26.77	44.62
11/28/2022	63.30	126.35	13.69	27.33	45.56
11/29/2022	86.13	134.44	14.09	28.13	46.91
11/30/2022	43.45	121.76	13.26	26.60	44.32
Monthly Avg/Sum*:	1,549.37 *	3,737.60 *	403.10 *	805.95 *	1,343.42 *
Daily Min:	30.29	59.15	6.32	12.68	21.10
Daily Max:	86.13	156.10	16.93	33.86	56.43
Oct 2022 - Nov 2022	2,816.54	6,783.62	733.46	1,467.43	2,445.74
QTD:	2,816.54 *	6,783.62 *	733.46 *	1,467.43 *	2,445.74 *
YTD 2022:	13,530.21 *	25,960.98 *	2,681.11 *	5,363.28 *	8,940.11 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2022	49.73	141.71	15.37	30.74	51.19
12/02/2022	48.73	154.05	16.60	33.22	55.38
12/03/2022	57.60	133.32	13.90	27.82	46.34
12/04/2022	26.90	65.43	7.03	14.04	23.40
12/05/2022	46.29	90.20	7.88	15.75	26.25
12/06/2022	74.57	90.63	8.75	17.46	29.10
12/07/2022	54.58	134.25	14.54	29.13	48.53
12/08/2022	47.82	150.29	16.33	32.68	54.45
12/09/2022	44.57	126.83	13.77	27.58	46.00
12/10/2022	43.22	125.54	13.72	27.39	45.70
12/11/2022	36.11	105.16	11.50	23.02	38.32
12/12/2022	49.17	85.18	10.04	20.07	33.42
12/13/2022	32.01	61.34	6.71	13.43	22.38
12/14/2022	20.94	59.61	6.44	12.85	21.41
12/15/2022	18.28	64.78	6.96	13.83	23.04
12/16/2022	9.74	39.11	4.25	8.60	14.25
12/17/2022	74.10	121.27	12.22	24.43	40.71
12/18/2022	51.25	130.58	14.25	28.53	47.60
12/19/2022	46.53	159.43	17.31	34.70	57.76
12/20/2022	52.81	126.80	13.75	27.47	45.84
12/21/2022	71.80	146.39	15.88	31.75	52.92
12/22/2022	63.04	142.01	15.40	30.71	51.24
12/23/2022	66.86	141.94	15.41	30.80	51.36
12/24/2022	56.07	125.48	13.57	27.05	45.10
12/25/2022	27.43	84.27	9.30	18.56	30.95
12/26/2022	44.99	110.59	12.10	24.18	40.31
12/27/2022	21.27	77.21	8.44	16.80	28.06
12/28/2022	17.92	40.81	4.57	8.93	14.95
12/29/2022	9.78	40.71	4.54	8.88	14.87
12/30/2022	8.88	40.65	4.40	8.92	14.79
12/31/2022	72.44	42.70	3.74	7.53	12.53
Monthly Avg/Sum*:	1,345.43 *	3,158.27 *	338.67 *	676.85 *	1,128.15 *
Daily Min:	8.88	39.11	3.74	7.53	12.53
Daily Max:	74.57	159.43	17.31	34.70	57.76
Oct 2022 - Dec 2022	4,161.97	9,941.89	1,072.13	2,144.28	3,573.89
QTD:	4,161.97 *	9,941.89 *	1,072.13 *	2,144.28 *	3,573.89 *
YTD 2022:	14,875.64 *	29,119.25 *	3,019.78 *	6,040.13 *	10,068.26 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2022	0.0	0.0	0.0	0.0
10/02/2022	0.0	0.0	0.0	0.0
10/03/2022	0.0	0.0	0.0	0.0
10/04/2022	0.0	0.0	0.0	0.0
10/05/2022	0.0	0.0	0.0	0.0
10/06/2022	0.0	0.0	0.0	0.0
10/07/2022	0.0	0.0	0.0	0.0
10/08/2022	0.0	0.0	10.5	1.1
10/09/2022	0.0	0.0	0.0	0.0
10/10/2022	0.0	0.0	0.0	0.0
10/11/2022	0.0	0.0	0.0	0.0
10/12/2022	0.0	0.0	0.0	0.0
10/13/2022	0.0	0.0	0.0	0.0
10/14/2022	0.0	0.0	0.0	0.0
10/15/2022	0.0	0.0	0.0	0.0
10/16/2022	0.0	0.0	0.0	0.0
10/17/2022	0.0	0.0	0.0	0.0
10/18/2022	0.0	0.0	18.9	11.3
10/19/2022	44.8	5.9	0.0	0.0
10/20/2022	0.0	0.0	0.0	0.0
10/21/2022	0.0	0.0	0.0	0.0
10/22/2022	0.0	0.0	0.0	0.0
10/23/2022	0.0	0.0	0.0	0.0
10/24/2022	0.0	0.0	0.0	0.0
10/25/2022	0.0	0.0	0.0	0.0
10/26/2022	0.0	0.0	0.0	0.0
10/27/2022	0.0	0.0	0.0	0.0
10/28/2022	0.0	0.0	0.0	0.0
10/29/2022	0.0	0.0	0.0	0.0
10/30/2022	0.0	0.0	0.0	0.0
10/31/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	44.8 *	5.9 *	29.4 *	12.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	44.8	5.9	18.9	11.3
Oct 2022 - Oct 2022	44.8	5.9	29.4	12.4
QTD:	44.8 *	5.9 *	29.4 *	12.4 *
YTD 2022:	1,997.1 *	326.1 *	2,270.4 *	512.4 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2022	0.0	0.0	0.0	0.0
11/02/2022	0.0	0.0	0.0	0.0
11/03/2022	0.0	0.0	0.0	0.0
11/04/2022	0.0	0.0	0.0	0.0
11/05/2022	0.0	0.0	0.0	0.0
11/06/2022	0.0	0.0	0.0	0.0
11/07/2022	0.0	0.0	2.9	0.6
11/08/2022	0.0	0.0	8.7	0.3
11/09/2022	0.0	0.0	27.7	12.3
11/10/2022	0.0	0.0	0.0	0.0
11/11/2022	0.0	0.0	0.0	0.0
11/12/2022	0.0	0.0	0.0	0.0
11/13/2022	0.0	0.0	0.0	0.0
11/14/2022	0.0	0.0	0.0	0.0
11/15/2022	0.0	0.0	0.0	0.0
11/16/2022	0.0	0.0	0.0	0.0
11/17/2022	0.0	0.0	0.0	0.0
11/18/2022	0.0	0.0	0.0	0.0
11/19/2022	0.0	0.0	0.0	0.0
11/20/2022	0.0	0.0	0.0	0.0
11/21/2022	0.0	0.0	0.0	0.0
11/22/2022	0.0	0.0	0.0	0.0
11/23/2022	0.0	0.0	0.0	0.0
11/24/2022	0.0	0.0	0.0	0.0
11/25/2022	0.0	0.0	0.0	0.0
11/26/2022	0.0	0.0	0.0	0.0
11/27/2022	0.0	0.0	0.0	0.0
11/28/2022	0.0	0.0	0.0	0.0
11/29/2022	0.0	0.0	44.2	8.9
11/30/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	83.5 *	22.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	44.2	12.3
Oct 2022 - Nov 2022	44.8	5.9	112.9	34.5
QTD:	44.8 *	5.9 *	112.9 *	34.5 *
YTD 2022:	1,997.1 *	326.1 *	2,353.9 *	534.5 *

Monthly Summary By Day Report



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2022	0.0	0.0	0.0	0.0
12/02/2022	0.0	0.0	0.0	0.0
12/03/2022	0.0	0.0	11.6	2.9
12/04/2022	0.0	0.0	0.0	0.0
12/05/2022	0.0	0.0	24.2	21.6
12/06/2022	48.2	12.8	0.0	0.0
12/07/2022	0.0	0.0	0.0	0.0
12/08/2022	0.0	0.0	0.0	0.0
12/09/2022	0.0	0.0	0.0	0.0
12/10/2022	0.0	0.0	0.0	0.0
12/11/2022	0.0	0.0	0.0	0.0
12/12/2022	0.0	0.0	11.9	0.7
12/13/2022	0.0	0.0	0.0	0.0
12/14/2022	0.0	0.0	0.0	0.0
12/15/2022	0.0	0.0	0.0	0.0
12/16/2022	0.0	0.0	0.0	0.0
12/17/2022	0.0	0.0	28.1	9.8
12/18/2022	0.0	0.0	0.0	0.0
12/19/2022	0.0	0.0	0.0	0.0
12/20/2022	0.0	0.0	0.0	0.0
12/21/2022	0.0	0.0	0.0	0.0
12/22/2022	0.0	0.0	0.0	0.0
12/23/2022	0.0	0.0	0.0	0.0
12/24/2022	0.0	0.0	0.0	0.0
12/25/2022	0.0	0.0	0.0	0.0
12/26/2022	0.0	0.0	0.0	0.0
12/27/2022	3.0	0.5	0.0	0.0
12/28/2022	6.4	0.1	0.0	0.0
12/29/2022	0.0	0.0	0.0	0.0
12/30/2022	0.0	0.0	0.0	0.0
12/31/2022	0.0	0.0	62.2	11.1
Monthly Avg/Sum*:	57.6 *	13.4 *	138.0 *	46.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	48.2	12.8	62.2	21.6
Oct 2022 - Dec 2022	102.4	19.3	250.9	80.6
QTD:	102.4 *	19.3 *	250.9 *	80.6 *
YTD 2022:	2,054.7 *	339.5 *	2,491.9 *	580.6 *

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 8:24	264395.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:25	264626.9			0.6			1.5			0.35			1.54			0		
10/19/22 8:26	264087.8			0.6			1.5			0.35			1.54			0		
10/19/22 8:27	264395.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:28	264087.8			0.5			1.5			0.29			1.54			0		
10/19/22 8:29	264318.8			0.5			1.5			0.29			1.54			1		
10/19/22 8:30	252381.3			0.5			1.5			0.28			1.47			1		
10/19/22 8:31	229507.6			0.5			2.09			0.26			1.87			1		
10/19/22 8:32	207096			0.4			6.82			0.2			5.49			1		
10/19/22 8:33	182681.9			1.9			10.02			0.82			7.12			1		
10/19/22 8:34	161810.6			109			12.06			41.71			7.59			1		
10/19/22 8:35	144559			718.4			13.67			245.55			7.69			1		
10/19/22 8:36	67466			1675.1			14.75			266.98			3.87			1		
10/19/22 8:37	19716.1			0			17.7			113.4			1.36			0		
10/19/22 8:38	20255.2			0			2.95			60.77			0.23			0		
10/19/22 8:39	20486.2			0			2.95			5.71			0.23			0		
10/19/22 8:40	20948.3			0			2.95			3.79			0.24			0		
10/19/22 8:41	20871.3			0			2.95			3.63			0.24			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 16:04	36736.6			0			0			0			0			0		
10/19/22 16:05	36813.6			0			0			0			0			0		
10/19/22 16:06	36890.7			0			0			0			0			0		
10/19/22 16:07	36736.6			0			0			0			0			0		
10/19/22 16:08	36813.6			0			0			0			0			0		
10/19/22 16:09	39509.2			-5.9			0			-0.55			0			1		
10/19/22 16:10	43206			0			0			0			0			1		
10/19/22 16:11	50907.6			30.5			4.92			3.67			0.97			1		
10/19/22 16:12	59764.4			699.3			4.16			98.78			0.97			1		
10/19/22 16:13	69545.4			430.7			6.79			70.77			1.83			1		
10/19/22 16:14	85872.8			200.3			8.85			40.67			2.96			1		
10/19/22 16:15	125073.9			128.1			11.8			37.87			5.74			1		
10/19/22 16:16	141632.4			85.1			16.01			28.51			8.83			1		
10/19/22 16:17	149796.1			339.9			23.24			120.36			13.55			1		
10/19/22 16:18	164891.2			1803			22.04			702.65			14.13			1		
10/19/22 16:19	185608.5			1153.4			24.72			506.03			17.85			1		
10/19/22 16:20	209329.4			230.8			26.97			114.23			21.97			1		
10/19/22 16:21	230046.7			20.4			29.38			11.09			26.29			1		
10/19/22 16:22	253228.5			1.9			31.28			1.13			30.81			1		
10/19/22 16:23	277642.6			1.3			23.4			0.85			25.28			1		
10/19/22 16:24	297743.8			1.2			11.16			0.83			12.93			1		
10/19/22 16:25	306677.6			1.2			7.84			0.89			9.35			1		
10/19/22 16:26	308834.1			1.3			7.04			0.96			8.46			1		
10/19/22 16:27	309681.2			1.2			6.16			0.9			7.43			1		
10/19/22 16:28	309835.3			1.1			5.9			0.77			7.11			1		
10/19/22 16:29	309373.2			1			5.64			0.7			6.79			1		
10/19/22 16:30	307986.9			1			5.47			0.69			6.55			1		
10/19/22 16:31	306061.5			0.9			5.28			0.64			6.29			1		
10/19/22 16:32	303365.9			0.8			5.02			0.57			5.92			1		
10/19/22 16:33	302903.8			0.8			4.76			0.57			5.6			1		
10/19/22 16:34	301902.6			0.7			4.58			0.5			5.38			1		
10/19/22 16:35	302056.7			0.7			4.56			0.51			5.36			1		
10/19/22 16:36	295818.3			0.7			4.56			0.5			5.25			1		
10/19/22 16:37	278412.8			0.7			4.56			0.47			4.94			1		
10/19/22 16:38	273560.7			0.6			5.17			0.41			5.51			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 16:39	270942.2			0.6			6.08			0.35			6.41			1		
10/19/22 16:40	267861.6			0.5			4.96			0.3			5.17			1		
10/19/22 16:41	267784.5			0.5			3.75			0.3			3.9			1		
10/19/22 16:42	266937.4			0.5			3.28			0.3			3.4			1		
10/19/22 16:43	267707.5			0.5			3.14			0.3			3.27			1		
10/19/22 16:44	267014.4			0.4			2.85			0.24			2.97			1		
10/19/22 16:45	266706.3			0.4			2.66			0.24			2.76			1		
10/19/22 16:46	266706.3			0.4			2.38			0.24			2.47			1		
10/19/22 16:47	266244.2			0.4			2.28			0.24			2.37			1		
10/19/22 16:48	266783.3			0.4			2.09			0.24			2.17			1		
10/19/22 16:49	266244.2			0.4			1.9			0.24			1.97			1		
10/19/22 16:50	266167.2			0.4			1.81			0.24			1.87			1		
10/19/22 16:51	266167.2			0.4			1.71			0.24			1.77			1		
10/19/22 16:52	266398.3			0.4			1.62			0.24			1.68			0		
10/19/22 16:53	266244.2			0.4			1.52			0.24			1.58			0		
10/19/22 16:54	265859.1			0.4			1.43			0.24			1.48			0		
10/19/22 16:55	265859.1			0.4			1.43			0.24			1.48			0		
10/19/22 16:56	265628.1			0.4			1.33			0.24			1.38			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 0:49	271481.3			0.6			1.43			0.4			1.5			0		
12/06/22 0:50	266167.2			0.6			1.54			0.4			1.59			0		
12/06/22 0:51	268708.7			0.6			2.25			0.35			2.34			0		
12/06/22 0:52	271173.3			0.5			2.15			0.3			2.26			0		
12/06/22 0:53	271789.4			0.5			1.66			0.29			1.74			0		
12/06/22 0:54	267245.4			0.5			1.38			0.29			1.43			1		
12/06/22 0:55	245526.9			0.5			1.29			0.27			1.23			1		
12/06/22 0:56	224655.6			0.5			3.29			0.26			2.86			1		
12/06/22 0:57	199625.4			0.3			8.74			0.15			6.75			1		
12/06/22 0:58	176058.5			3.5			11.45			1.44			7.8			1		
12/06/22 0:59	157266.6			316.5			15.82			116.95			9.62			1		
12/06/22 1:00	138166.7			1189.8			19.06			386.46			10.19			1		
12/06/22 1:01	31345.5			1781.6			21.58			131.21			2.62			1		
12/06/22 1:02	0			0			24.09			0			0			0		
12/06/22 1:03	0			0			5.9			0			0			0		
12/06/22 1:04	0			0			2.95			0			0			0		
12/06/22 1:05	0			0			2.95			0			0			0		
12/06/22 1:06	0			0			2.95			0			0			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 15:04	0			0			0			0			0			0		
12/06/22 15:05	0			0			0			0			0			0		
12/06/22 15:06	0			0			0			0			0			0		
12/06/22 15:07	0			0			0			0			0			0		
12/06/22 15:08	0			0			0			0			0			0		
12/06/22 15:09	0			0			0			0			0			1		
12/06/22 15:10	15634.2			0			0			0			0			1		
12/06/22 15:11	29959.2			62			11.8			4.37			1.37			1		
12/06/22 15:12	41896.7			1038.4			12.71			102.27			2.06			1		
12/06/22 15:13	54989.4			895.8			16.06			115.7			3.41			1		
12/06/22 15:14	69160.3			550.8			22.13			89.51			5.92			1		
12/06/22 15:15	103278.4			386.2			25.75			93.71			10.28			1		
12/06/22 15:16	140169.1			268			36.63			88.29			19.86			1		
12/06/22 15:17	146561.4			155.8			52.9			53.66			29.99			1		
12/06/22 15:18	162503.7			1418.7			46.31			541.77			29.1			1		
12/06/22 15:19	180525.4			1702.5			47.86			722.55			33.43			1		
12/06/22 15:20	203861.3			728.4			48.97			349.07			38.62			1		
12/06/22 15:21	227428.2			110.9			49.56			59.29			43.6			1		
12/06/22 15:22	246220.1			7.3			45.93			4.22			43.74			1		
12/06/22 15:23	272405.5			1.9			42.78			1.21			45.07			1		
12/06/22 15:24	278258.7			1.6			24.37			1.08			26.24			1		
12/06/22 15:25	279413.9			1.5			13.77			1			14.88			1		
12/06/22 15:26	293353.8			1.6			13.14			1.11			14.91			1		
12/06/22 15:27	309373.2			1.5			11.54			1.09			13.8			1		
12/06/22 15:28	311452.6			1.4			8.42			1.02			10.14			1		
12/06/22 15:29	309373.2			1.4			7.55			1.01			9.03			1		
12/06/22 15:30	307755.8			1.2			6.85			0.88			8.16			1		
12/06/22 15:31	307832.8			1.1			6.42			0.82			7.64			1		
12/06/22 15:32	307139.7			1			6.33			0.75			7.53			1		
12/06/22 15:33	306292.5			1.1			6.25			0.76			7.41			1		
12/06/22 15:34	306523.6			1			6.08			0.7			7.2			1		
12/06/22 15:35	305907.4			1			5.9			0.7			6.98			1		
12/06/22 15:36	305599.4			0.9			5.81			0.63			6.87			1		
12/06/22 15:37	305214.3			0.9			5.81			0.63			6.86			1		
12/06/22 15:38	304521.2			0.8			5.72			0.57			6.74			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 15:39	305368.3			0.8			5.72			0.57			6.76			1		
12/06/22 15:40	305214.3			0.8			5.72			0.58			6.76			1		
12/06/22 15:41	306138.5			0.8			5.72			0.58			6.77			1		
12/06/22 15:42	306061.5			0.8			5.72			0.58			6.77			1		
12/06/22 15:43	304598.2			0.7			5.81			0.51			6.85			1		
12/06/22 15:44	303674			0.7			5.9			0.51			6.93			1		
12/06/22 15:45	302903.8			0.7			5.9			0.51			6.91			1		
12/06/22 15:46	299823.2			0.7			5.9			0.5			6.84			1		
12/06/22 15:47	281185.3			0.7			5.99			0.47			6.51			1		
12/06/22 15:48	272790.6			0.6			6.44			0.41			6.8			1		
12/06/22 15:49	270788.2			0.6			8.2			0.41			8.59			1		
12/06/22 15:50	268323.7			0.6			8.3			0.35			8.61			1		
12/06/22 15:51	268554.7			0.5			7.74			0.29			8.04			1		
12/06/22 15:52	269016.8			0.5			7.56			0.29			7.87			1		
12/06/22 15:53	268246.6			0.5			7.38			0.29			7.65			1		
12/06/22 15:54	267861.6			0.5			7.19			0.29			7.45			1		
12/06/22 15:55	267784.5			0.5			7.1			0.29			7.35			1		
12/06/22 15:56	268323.7			0.5			7.01			0.29			7.27			1		
12/06/22 15:57	268246.6			0.5			6.91			0.29			7.18			1		
12/06/22 15:58	268015.6			0.5			6.91			0.29			7.17			1		
12/06/22 15:59	270788.2			0.5			6.82			0.29			7.14			1		
12/06/22 16:00	273175.7			0.5			6.93			0.3			7.32			1		
12/06/22 16:01	273560.7			0.5			6.73			0.3			7.12			1		
12/06/22 16:02	271789.4			0.5			6.55			0.29			6.88			1		
12/06/22 16:03	270403.1			0.5			6.45			0.29			6.75			1		
12/06/22 16:04	270711.2			0.5			6.27			0.29			6.56			1		
12/06/22 16:05	270711.2			0.5			6.08			0.29			6.37			1		
12/06/22 16:06	271327.3			0.5			5.81			0.29			6.1			1		
12/06/22 16:07	272174.4			0.5			5.72			0.29			6.02			1		
12/06/22 16:08	283033.7			0.5			5.62			0.31			6.16			1		
12/06/22 16:09	303751			0.6			5.25			0.39			6.17			1		
12/06/22 16:10	323467.1			0.5			3.99			0.41			5			1		
12/06/22 16:11	329551.3			0.6			3.79			0.48			4.83			1		
12/06/22 16:12	325084.4			0.7			3.79			0.54			4.76			1		
12/06/22 16:13	329551.3			0.7			4.23			0.55			5.39			1		
12/06/22 16:14	346186.8			0.7			4.14			0.57			5.54			1		
12/06/22 16:15	363361.3			0.7			2.68			0.61			3.77			1		
12/06/22 16:16	374451.7			0.6			2.18			0.56			3.16			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 16:17	376916.2			0.6			2.09			0.56			3.04			1		
12/06/22 16:18	387082.3			0.6			2.06			0.57			3.08			1		
12/06/22 16:19	399250.8			0.6			2.09			0.6			3.22			1		
12/06/22 16:20	409879			0.6			1.94			0.62			3.07			1		
12/06/22 16:21	413190.7			0.6			1.82			0.62			2.9			1		
12/06/22 16:22	412959.7			0.6			1.91			0.62			3.04			1		
12/06/22 16:23	423895.9			0.6			1.91			0.63			3.13			1		
12/06/22 16:24	437142.7			0.6			1.91			0.65			3.22			0		
12/06/22 16:25	438297.9			0.6			1.84			0.66			3.13			0		
12/06/22 16:26	441532.6			0.6			1.84			0.67			3.15			0		
12/06/22 16:27	446153.5			0.6			1.94			0.68			3.34			0		
12/06/22 16:28	447539.8			0.6			2.03			0.68			3.51			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/27/22 23:49	267707.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:50	266937.4			0.6			1.48			0.35			1.52			0		
12/27/22 23:51	267245.4			0.6			1.48			0.41			1.52			0		
12/27/22 23:52	267476.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:53	267399.5			0.6			1.48			0.35			1.53			0		
12/27/22 23:54	257464.4			0.6			1.48			0.33			1.47			1		
12/27/22 23:55	236362			0.6			1.69			0.31			1.54			1		
12/27/22 23:56	214412.5			0.5			5.7			0.25			4.73			1		
12/27/22 23:57	189151.2			0.9			9.4			0.39			6.87			1		
12/27/22 23:58	167894.8			8.8			11.08			3.47			7.19			1		
12/27/22 23:59	150258.2			497			12.62			175.55			7.34			1		
12/28/22 0:00	107822.4			1483.7			13.66			375.96			5.7			1		
12/28/22 0:01	0			0			14.36			0			0			0		
12/28/22 0:02	0			0			8.85			0			0			0		
12/28/22 0:03	0			0			2.95			0			0			0		
12/28/22 0:04	0			0			2.95			0			0			0		
12/28/22 0:05	0			0			2.95			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 22:48	285036.1			0.5			1.24			0.32			1.37			0		
10/08/22 22:49	290273.2			0.5			1.24			0.33			1.4			0		
10/08/22 22:50	291428.4			0.5			1.24			0.33			1.4			0		
10/08/22 22:51	290889.3			0.6			1.22			0.39			1.38			0		
10/08/22 22:52	290504.3			0.6			1.24			0.39			1.4			0		
10/08/22 22:53	287115.5			0.5			1.33			0.32			1.49			1		
10/08/22 22:54	271866.4			0.5			1.43			0.31			1.51			1		
10/08/22 22:55	246990.2			0.5			2.51			0.28			2.42			1		
10/08/22 22:56	223577.4			0.4			7.45			0.22			6.48			1		
10/08/22 22:57	197237.9			2.2			16.11			1.01			12.36			1		
10/08/22 22:58	174595.2			112.6			20.27			46.48			13.77			1		
10/08/22 22:59	153415.8			662			24.63			240.05			14.7			1		
10/08/22 23:00	100736.9			1436.6			29.33			342.15			11.5			1		
10/08/22 23:01	0			0			32.8			0			0			0		
10/08/22 23:02	0			0			11.8			0			0			0		
10/08/22 23:03	0			0			0.1			0			0			0		
10/08/22 23:04	0			0			0			0			0			0		
10/08/22 23:05	0			0			0			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 14:49	0			0			0			0			0			0		
10/18/22 14:50	0			0			0			0			0			0		
10/18/22 14:51	0			0			0			0			0			0		
10/18/22 14:52	0			0			0			0			0			0		
10/18/22 14:53	0			0			0			0			0			0		
10/18/22 14:54	1925.4			0			0			0			0			1		
10/18/22 14:55	15172.1			0			0			0			0			1		
10/18/22 14:56	30190.3			26.6			2.95			1.9			0.35			1		
10/18/22 14:57	43745.1			1083.6			10.82			112.07			1.84			1		
10/18/22 14:58	56144.6			872.9			14.09			115.87			3.08			1		
10/18/22 14:59	67234.9			518.1			17.7			82.34			4.63			1		
10/18/22 15:00	98426.4			356.3			21.29			82.87			8.15			1		
10/18/22 15:01	144636			219.2			22.66			74.94			12.74			1		
10/18/22 15:02	158498.9			141.2			46.44			52.92			28.64			1		
10/18/22 15:03	200010.5			770.1			43.9			364.09			34.16			1		
10/18/22 15:04	230354.8			377.9			56.27			205.72			50.41			1		
10/18/22 15:05	255847.1			25.6			57.07			15.51			56.81			1		
10/18/22 15:06	282032.5			1.7			55.94			1.12			61.38			1		
10/18/22 15:07	308294.9			1.3			37.62			0.92			45.13			1		
10/18/22 15:08	328319.1			1.3			20.96			1.03			26.77			1		
10/18/22 15:09	332786			1.5			16.66			1.16			21.57			1		
10/18/22 15:10	332092.9			1.6			15.18			1.23			19.62			1		
10/18/22 15:11	331784.8			1.6			13.71			1.22			17.7			1		
10/18/22 15:12	345570.7			1.5			13.12			1.22			17.64			1		
10/18/22 15:13	358355.3			1.4			11.62			1.19			16.2			1		
10/18/22 15:14	358663.4			1.4			8.59			1.18			11.98			1		
10/18/22 15:15	358201.3			1.4			8.07			1.18			11.25			1		
10/18/22 15:16	358047.3			1.4			7.31			1.19			10.18			1		
10/18/22 15:17	358432.3			1.3			6.96			1.12			9.7			1		
10/18/22 15:18	356892			1.2			6.43			1.04			8.93			1		
10/18/22 15:19	357739.2			1.1			6.16			0.97			8.58			1		
10/18/22 15:20	348882.3			1.1			5.99			0.87			8.13			1		
10/18/22 15:21	330629.6			1.1			6.34			0.83			8.15			1		
10/18/22 15:22	328319.1			1			7.13			0.75			9.11			1		
10/18/22 15:23	325546.5			1			7.51			0.76			9.51			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 15:24	324545.3			0.9			7.62			0.7			9.63			1		
10/18/22 15:25	325469.5			0.9			7.62			0.7			9.65			1		
10/18/22 15:26	323621.1			0.8			7.72			0.62			9.71			1		
10/18/22 15:27	324160.2			0.8			7.72			0.63			9.73			1		
10/18/22 15:28	323852.2			0.8			7.81			0.63			9.84			1		
10/18/22 15:29	323621.1			0.8			7.81			0.62			9.83			1		
10/18/22 15:30	322542.9			0.8			7.99			0.62			10.02			1		
10/18/22 15:31	323621.1			0.8			8.08			0.62			10.17			1		
10/18/22 15:32	322542.9			0.7			8.17			0.55			10.25			1		
10/18/22 15:33	314071.1			0.7			8.17			0.54			9.98			1		
10/18/22 15:34	311606.6			0.7			8.2			0.54			9.95			1		
10/18/22 15:35	305907.4			0.6			8.11			0.47			9.65			1		
10/18/22 15:36	299592.1			0.6			8.3			0.46			9.67			1		
10/18/22 15:37	294432.1			0.7			8.99			0.46			10.3			1		
10/18/22 15:38	288193.8			0.6			5.9			0.38			6.61			1		
10/18/22 15:39	284651			0.6			3.09			0.38			3.42			1		
10/18/22 15:40	282725.6			0.6			2.28			0.38			2.51			1		
10/18/22 15:41	283110.7			0.5			1.71			0.32			1.89			1		
10/18/22 15:42	284651			0.5			1.43			0.32			1.58			1		
10/18/22 15:43	284343			0.5			1.24			0.32			1.37			1		
10/18/22 15:44	288270.8			0.5			1.05			0.32			1.17			0		
10/18/22 15:45	287269.6			0.5			0.86			0.32			0.96			0		
10/18/22 15:46	288116.8			0.5			0.66			0.32			0.73			0		
10/18/22 15:47	288732.9			0.5			0.66			0.32			0.74			0		
10/18/22 15:48	289888.1			0.5			0.56			0.32			0.63			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 23:48	303057.8			0.9			1.25			0.63			1.45			0		
11/07/22 23:49	285421.2			0.9			1.36			0.6			1.49			0		
11/07/22 23:50	282340.6			0.8			2.12			0.55			2.29			0		
11/07/22 23:51	281185.3			0.8			2.38			0.5			2.56			0		
11/07/22 23:52	287500.6			0.7			2.19			0.45			2.41			0		
11/07/22 23:53	290273.2			0.7			1.78			0.44			1.98			1		
11/07/22 23:54	280261.1			0.6			1.38			0.42			1.49			1		
11/07/22 23:55	257926.5			0.7			1.31			0.39			1.3			1		
11/07/22 23:56	234744.7			0.7			4.1			0.38			3.69			1		
11/07/22 23:57	208636.3			1			8.74			0.48			6.99			1		
11/07/22 23:58	184761.3			7.7			11.56			3.32			8.18			1		
11/07/22 23:59	163273.9			449.9			16.19			171.11			10.13			1		
11/08/22 0:00	143942.9			1153			21.12			386.62			11.65			1		
11/08/22 0:01	34272.1			1707.4			26.64			136.45			3.5			1		
11/08/22 0:02	0			0			28.91			0			0			0		
11/08/22 0:03	0			0			2.95			0			0			0		
11/08/22 0:04	0			0			2.95			0			0			0		
11/08/22 0:05	0			0			5.9			0			0			0		
11/08/22 0:06	0			0			5.9			0			0			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 20:26	0			0			0			0			0			0		
11/09/22 20:27	0			0			0			0			0			0		
11/09/22 20:28	0			0			0			0			0			0		
11/09/22 20:29	0			0			0			0			0			0		
11/09/22 20:30	0			0			0			0			0			0		
11/09/22 20:31	4698			11.8			0			0.13			0			1		
11/09/22 20:32	22257.6			11.8			0			0.61			0			1		
11/09/22 20:33	38431			42.3			9.83			3.79			1.45			1		
11/09/22 20:34	50599.5			1241.4			10.23			146.16			1.98			1		
11/09/22 20:35	61843.8			887			13.44			127.66			3.18			1		
11/09/22 20:36	78479.3			596.5			16.23			109.09			4.88			1		
11/09/22 20:37	120530			467.7			18.24			131.29			8.42			1		
11/09/22 20:38	154186			343.1			21.24			123.21			12.55			1		
11/09/22 20:39	181218.6			281.9			38.06			119			26.45			1		
11/09/22 20:40	204631.4			1013.1			45.81			482.79			35.93			1		
11/09/22 20:41	226889			427.9			51.55			226.14			44.84			1		
11/09/22 20:42	251303.1			114.2			56.95			66.82			54.86			1		
11/09/22 20:43	276487.3			12.7			56.92			8.2			60.33			1		
11/09/22 20:44	302287.7			4.3			55.42			3.04			64.21			1		
11/09/22 20:45	310605.4			3.6			27.5			2.62			32.75			1		
11/09/22 20:46	311067.5			3.5			19.67			2.53			23.45			1		
11/09/22 20:47	312761.9			3.7			18.84			2.69			22.59			1		
11/09/22 20:48	318769.1			4.3			18.14			3.2			22.17			1		
11/09/22 20:49	341950.9			5.4			17.44			4.28			22.85			1		
11/09/22 20:50	349960.6			10.8			13.1			8.77			17.57			1		
11/09/22 20:51	344492.4			14.3			11.8			11.46			15.58			1		
11/09/22 20:52	357585.2			14			10.86			11.68			14.89			1		
11/09/22 20:53	359356.5			9.4			10.69			7.87			14.72			1		
11/09/22 20:54	347419.1			6.9			10			5.6			13.32			1		
11/09/22 20:55	343260.2			6.3			8.81			5.06			11.59			1		
11/09/22 20:56	341411.8			5.6			8.07			4.42			10.56			1		
11/09/22 20:57	341950.9			4.6			7.9			3.66			10.35			1		
11/09/22 20:58	343337.2			3.8			7.64			3.05			10.05			1		
11/09/22 20:59	342027.9			3.1			7.29			2.49			9.56			1		
11/09/22 21:00	343183.2			2.7			7.03			2.15			9.25			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 21:01	345031.6			2.3			6.85			1.81			9.07			1		
11/09/22 21:02	342413			2			6.77			1.59			8.88			1		
11/09/22 21:03	350499.7			1.9			6.87			1.58			9.23			1		
11/09/22 21:04	370292.8			1.8			6.78			1.59			9.62			1		
11/09/22 21:05	389238.7			1.7			6.07			1.57			9.06			1		
11/09/22 21:06	395477			1.7			4.05			1.54			6.14			1		
11/09/22 21:07	399250.8			1.7			4.38			1.58			6.7			1		
11/09/22 21:08	397941.5			1.6			4.76			1.47			7.25			1		
11/09/22 21:09	402870.6			1.4			4.76			1.32			7.34			1		
11/09/22 21:10	400560.1			1.2			4.84			1.15			7.44			1		
11/09/22 21:11	401946.3			1.1			4.93			1.07			7.6			1		
11/09/22 21:12	402023.4			1.1			4.93			1.07			7.6			1		
11/09/22 21:13	404410.9			1.1			5.02			1			7.78			1		
11/09/22 21:14	404641.9			1.1			4.84			1			7.51			1		
11/09/22 21:15	399096.8			1.1			3.08			0.98			4.71			1		
11/09/22 21:16	389084.7			1.1			2.2			0.96			3.28			1		
11/09/22 21:17	383616.6			1			2.78			0.93			4.08			1		
11/09/22 21:18	369214.6			1			2.95			0.9			4.17			1		
11/09/22 21:19	348420.3			1			2.95			0.84			3.94			1		
11/09/22 21:20	326008.6			1			3.56			0.79			4.45			1		
11/09/22 21:21	319385.3			1.1			2.47			0.79			3.02			1		
11/09/22 21:22	313532			1			2.15			0.72			2.58			1		
11/09/22 21:23	310374.4			0.9			2			0.66			2.38			1		
11/09/22 21:24	308371.9			0.9			2.09			0.65			2.47			1		
11/09/22 21:25	309219.1			0.9			2.09			0.65			2.47			1		
11/09/22 21:26	310297.3			0.8			2.09			0.59			2.48			1		
11/09/22 21:27	307986.9			0.8			2			0.59			2.36			1		
11/09/22 21:28	306138.5			0.8			1.91			0.58			2.24			1		
11/09/22 21:29	306446.6			0.8			1.82			0.58			2.13			1		
11/09/22 21:30	306908.7			0.8			1.82			0.58			2.14			1		
11/09/22 21:31	305214.3			0.8			1.82			0.58			2.12			1		
11/09/22 21:32	305830.4			0.8			1.72			0.58			2.02			0		
11/09/22 21:33	306446.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:34	306831.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:35	306831.6			0.8			1.63			0.58			1.92			0		
11/09/22 21:36	306908.7			0.8			1.54			0.58			1.82			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 7:15	500526.8			0.6			1.44			0.96			3.68			0		
11/29/22 7:16	500295.8			0.6			1.63			0.94			4.12			0		
11/29/22 7:17	499833.7			0.5			1.7			0.83			4.25			0		
11/29/22 7:18	503068.3			0.5			1.65			0.85			4.2			0		
11/29/22 7:19	494519.6			0.5			1.51			0.85			3.86			0		
11/29/22 7:20	420584.2			0.5			1.56			0.74			3.51			1		
11/29/22 7:21	0			0			2.07			0			0			0		
11/29/22 7:22	0			0			7.38			0			0			0		
11/29/22 7:23	0			0			0			0			0			0		
11/29/22 7:24	0			0			0			0			0			0		
11/29/22 7:25	0			0			0			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 11:45	0			0			0			0			0			0		
11/29/22 11:46	0			0			0			0			0			0		
11/29/22 11:47	0			0			0			0			0			0		
11/29/22 11:48	0			0			0			0			0			0		
11/29/22 11:49	8471.8			0			0			0.23			0			0		
11/29/22 11:50	15326.2			11.8			0			0.42			0			1		
11/29/22 11:51	30190.3			25.6			0			1.8			0			1		
11/29/22 11:52	44053.1			1005.3			1.36			103.06			0.23			1		
11/29/22 11:53	55836.6			871.5			4.51			113.34			0.97			1		
11/29/22 11:54	68005.1			532.8			7.08			84.44			1.85			1		
11/29/22 11:55	97502.2			406.3			9.83			92.21			3.67			1		
11/29/22 11:56	145406.2			279.1			16.16			94.52			9.01			1		
11/29/22 11:57	153569.8			182.5			18.31			65.28			10.78			1		
11/29/22 11:58	160963.4			1046.3			29.68			392.31			18.32			1		
11/29/22 11:59	180217.4			1814.7			34.68			761.65			23.96			1		
11/29/22 12:00	199086.3			1319.1			37.04			611.54			28.26			1		
11/29/22 12:01	225502.8			485.8			39.43			255.12			34.08			1		
11/29/22 12:02	249531.8			76.1			43.35			44.2			41.46			1		
11/29/22 12:03	272251.5			7.1			46.04			4.48			48.05			1		
11/29/22 12:04	287577.6			2.1			40.16			1.39			44.27			1		
11/29/22 12:05	291890.5			1.8			20.41			1.25			22.83			1		
11/29/22 12:06	291197.4			1.7			17.61			1.14			19.65			1		
11/29/22 12:07	308063.9			1.5			17.23			1.08			20.35			1		
11/29/22 12:08	333248.1			1.4			15.16			1.06			19.36			1		
11/29/22 12:09	346648.9			1.4			11.02			1.12			14.64			1		
11/29/22 12:10	347650.1			1.5			9.89			1.19			13.18			1		
11/29/22 12:11	349421.5			1.5			9.8			1.2			13.13			1		
11/29/22 12:12	351115.8			1.5			9.72			1.21			13.08			1		
11/29/22 12:13	346879.9			1.5			9.63			1.19			12.8			1		
11/29/22 12:14	346648.9			1.4			9.54			1.12			12.68			1		
11/29/22 12:15	346725.9			1.4			9.46			1.12			12.57			1		
11/29/22 12:16	345647.7			1.3			9.37			1.05			12.41			1		
11/29/22 12:17	345108.6			1.3			9.46			1.05			12.51			1		
11/29/22 12:18	344338.4			1.2			8.85			0.97			11.68			1		
11/29/22 12:19	330937.6			1.2			5.55			0.95			7.04			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/29/22 12:20	323621.1			1.2			3.17			0.93			3.93			1		
11/29/22 12:21	311298.6			1.2			3.58			0.84			4.27			1		
11/29/22 12:22	301440.5			1.1			4.9			0.76			5.66			1		
11/29/22 12:23	297589.7			1.1			6.63			0.75			7.56			1		
11/29/22 12:24	297204.6			0.9			5.16			0.64			5.88			1		
11/29/22 12:25	296588.5			0.9			3.13			0.64			3.56			1		
11/29/22 12:26	297897.8			0.9			2.21			0.64			2.53			1		
11/29/22 12:27	296665.5			0.9			2.21			0.64			2.52			1		
11/29/22 12:28	305830.4			0.8			2.4			0.59			2.81			1		
11/29/22 12:29	327317.9			0.8			2.67			0.63			3.35			1		
11/29/22 12:30	350499.7			0.9			2.18			0.74			2.93			1		
11/29/22 12:31	363053.3			1			1.85			0.82			2.57			1		
11/29/22 12:32	362899.3			1.1			1.41			0.89			1.96			1		
11/29/22 12:33	369214.6			1.1			0.97			0.91			1.37			1		
11/29/22 12:34	383539.5			1.1			0.88			0.94			1.29			0		
11/29/22 12:35	404102.8			1.1			0.63			1.01			0.97			0		
11/29/22 12:36	413190.7			1.1			0.54			1.05			0.86			0		
11/29/22 12:37	413806.8			1			0.45			0.96			0.72			0		
11/29/22 12:38	421970.5			1			0.45			0.97			0.72			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 17:50	319077.2			0.9			5.81			0.7			7.11			0		
12/03/22 17:51	298128.8			1			6.16			0.67			7.04			0		
12/03/22 17:52	291351.4			0.8			8.26			0.55			9.22			0		
12/03/22 17:53	291967.6			0.6			10.33			0.44			11.56			0		
12/03/22 17:54	290427.2			0.6			10.86			0.38			12.09			0		
12/03/22 17:55	282186.5			0.5			11.24			0.31			12.16			1		
12/03/22 17:56	259697.9			0.5			13.99			0.29			13.92			1		
12/03/22 17:57	239442.7			0.5			29.6			0.28			27.16			1		
12/03/22 17:58	212102			1.3			38.9			0.65			31.62			1		
12/03/22 17:59	188073			10.4			42.65			4.58			30.75			1		
12/03/22 18:00	167509.7			463.5			45.14			180.84			28.99			1		
12/03/22 18:01	148409.8			1175.2			44.41			406.17			25.26			1		
12/03/22 18:02	25338.3			1711.4			45.05			101.13			4.38			1		
12/03/22 18:03	0			0			38.08			0			0			0		
12/03/22 18:04	0			0			11.8			0			0			0		
12/03/22 18:05	0			0			8.85			0			0			0		
12/03/22 18:06	0			0			5.9			0			0			0		
12/03/22 18:07	0			0			5.9			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 17:01	0			0			0			0			0			0		
12/05/22 17:02	0			0			0			0			0			0		
12/05/22 17:03	0			0			0			0			0			0		
12/05/22 17:04	0			0			0			0			0			0		
12/05/22 17:05	0			0			0			0			0			0		
12/05/22 17:06	14093.9			0			0			0			0			1		
12/05/22 17:07	29651.1			23.6			5.9			1.63			0.67			1		
12/05/22 17:08	43591			1198.8			13.41			121.83			2.24			1		
12/05/22 17:09	56298.7			1046			13.88			137.21			3			1		
12/05/22 17:10	67851.1			663.5			17.7			104.85			4.6			1		
12/05/22 17:11	94960.7			472.8			20.92			104.57			7.61			1		
12/05/22 17:12	143172.7			381.2			23.6			127.14			12.95			1		
12/05/22 17:13	158344.8			248.2			43.41			91.51			26.34			1		
12/05/22 17:14	202012.9			746.6			50.24			351.3			38.9			1		
12/05/22 17:15	229892.7			623.4			61.12			333.81			53.86			1		
12/05/22 17:16	255770			52.9			57.28			31.48			56.15			1		
12/05/22 17:17	280415.2			3.8			57.22			2.47			61.51			1		
12/05/22 17:18	299361.1			1.3			44.5			0.91			51.07			1		
12/05/22 17:19	301825.6			1.3			20.1			0.91			23.25			1		
12/05/22 17:20	313763.1			1.3			17.7			0.98			21.29			1		
12/05/22 17:21	333017.1			1.4			17.08			1.09			21.81			1		
12/05/22 17:22	337484			1.4			13.01			1.09			16.83			1		
12/05/22 17:23	336636.8			1.5			11.29			1.14			14.57			1		
12/05/22 17:24	335173.5			1.5			11.19			1.15			14.38			1		
12/05/22 17:25	332477.9			1.5			10.76			1.14			13.71			1		
12/05/22 17:26	333094.1			1.4			10.24			1.08			13.07			1		
12/05/22 17:27	331399.7			1.2			9.89			0.94			12.56			1		
12/05/22 17:28	331168.7			1.1			9.77			0.88			12.41			1		
12/05/22 17:29	329705.4			1.1			9.6			0.88			12.13			1		
12/05/22 17:30	328088			1.1			9.42			0.81			11.85			1		
12/05/22 17:31	328165.1			1			8.01			0.74			10.08			1		
12/05/22 17:32	327240.9			1			8.63			0.74			10.83			1		
12/05/22 17:33	328396.1			0.9			8.63			0.67			10.86			1		
12/05/22 17:34	327240.9			0.9			8.76			0.68			10.99			1		
12/05/22 17:35	325777.6			0.9			8.76			0.68			10.94			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 17:36	325777.6			0.9			8.67			0.68			10.83			1		
12/05/22 17:37	327548.9			0.9			8.67			0.68			10.89			1		
12/05/22 17:38	327086.8			0.9			8.58			0.68			10.76			1		
12/05/22 17:39	325315.5			0.9			8.58			0.68			10.7			1		
12/05/22 17:40	325623.5			0.9			8.49			0.68			10.6			1		
12/05/22 17:41	325700.5			0.8			8.49			0.61			10.6			1		
12/05/22 17:42	326239.7			0.8			8.49			0.61			10.62			1		
12/05/22 17:43	337330			0.8			8.49			0.63			10.98			1		
12/05/22 17:44	332786			0.8			8.58			0.62			10.95			1		
12/05/22 17:45	313686.1			0.8			8.54			0.58			10.27			1		
12/05/22 17:46	310066.3			0.8			8.58			0.58			10.2			1		
12/05/22 17:47	302980.8			0.7			10.62			0.51			12.33			1		
12/05/22 17:48	297204.6			0.7			11.71			0.5			13.34			1		
12/05/22 17:49	289734.1			0.6			12.81			0.44			14.23			1		
12/05/22 17:50	288039.8			0.6			14.01			0.43			15.47			1		
12/05/22 17:51	288963.9			0.6			14.66			0.43			16.24			1		
12/05/22 17:52	288501.8			0.6			15.08			0.38			16.67			1		
12/05/22 17:53	298205.8			0.6			15.27			0.39			17.45			1		
12/05/22 17:54	303519.9			0.6			14.2			0.39			16.52			1		
12/05/22 17:55	304906.2			0.6			12.54			0.39			14.65			1		
12/05/22 17:56	301748.6			0.6			12.07			0.45			13.96			1		
12/05/22 17:57	301594.6			0.6			12.26			0.45			14.17			1		
12/05/22 17:58	301902.6			0.6			12.54			0.45			14.51			1		
12/05/22 17:59	299823.2			0.6			12.72			0.45			14.62			1		
12/05/22 18:00	300593.3			0.6			12.81			0.45			14.77			1		
12/05/22 18:01	301132.4			0.6			12.72			0.45			14.68			1		
12/05/22 18:02	300208.3			0.6			12.81			0.45			14.75			1		
12/05/22 18:03	299900.2			0.6			12.81			0.39			14.73			1		
12/05/22 18:04	300901.4			0.6			12.81			0.39			14.78			1		
12/05/22 18:05	298822			0.6			12.81			0.45			14.68			1		
12/05/22 18:06	299207.1			0.6			12.81			0.45			14.7			1		
12/05/22 18:07	299592.1			0.6			12.81			0.45			14.71			1		
12/05/22 18:08	301517.5			0.6			12.81			0.45			14.81			1		
12/05/22 18:09	300747.4			0.6			12.81			0.39			14.77			1		
12/05/22 18:10	298359.9			0.6			12.81			0.38			14.65			1		
12/05/22 18:11	300054.2			0.6			12.91			0.39			14.84			1		
12/05/22 18:12	299515.1			0.6			12.81			0.45			14.71			1		
12/05/22 18:13	300670.3			0.6			12.91			0.45			14.87			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/05/22 18:14	301055.4			0.6			12.91			0.45			14.89			1		
12/05/22 18:15	300978.4			0.6			12.91			0.45			14.89			1		
12/05/22 18:16	299900.2			0.6			12.91			0.45			14.83			1		
12/05/22 18:17	300131.3			0.6			12.91			0.45			14.85			1		
12/05/22 18:18	301363.5			0.6			13			0.45			15.02			1		
12/05/22 18:19	300901.4			0.6			13			0.45			14.99			1		
12/05/22 18:20	300208.3			0.6			13			0.45			14.96			1		
12/05/22 18:21	301902.6			0.6			12.91			0.45			14.93			1		
12/05/22 18:22	302980.8			0.6			12.91			0.46			14.99			1		
12/05/22 18:23	302287.7			0.6			12.81			0.45			14.85			1		
12/05/22 18:24	302133.7			0.6			12.63			0.45			14.63			1		
12/05/22 18:25	301979.6			0.6			12.44			0.45			14.39			1		
12/05/22 18:26	300208.3			0.6			12.63			0.45			14.54			1		
12/05/22 18:27	299592.1			0.6			10.69			0.45			12.28			1		
12/05/22 18:28	298436.9			0.6			4.89			0.45			5.59			1		
12/05/22 18:29	290504.3			0.6			2.58			0.44			2.87			1		
12/05/22 18:30	299438.1			0.6			1.75			0.45			2.01			1		
12/05/22 18:31	326855.8			0.6			1.57			0.42			1.96			1		
12/05/22 18:32	345031.6			0.6			0.91			0.51			1.2			1		
12/05/22 18:33	365286.8			0.7			0.7			0.6			0.99			0		
12/05/22 18:34	384771.8			0.7			0.62			0.63			0.91			0		
12/05/22 18:35	404410.9			0.8			0.54			0.76			0.83			0		
12/05/22 18:36	426899.5			0.8			0.45			0.81			0.74			0		
12/05/22 18:37	455241.4			0.7			0.45			0.77			0.79			0		

CT2 SUSD EVENT 9

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 14:48	287654.7			0.5			1.5			0.32			1.67			0		
12/12/22 14:49	287115.5			0.5			1.5			0.32			1.66			0		
12/12/22 14:50	288347.8			0.5			1.5			0.32			1.67			0		
12/12/22 14:51	286730.5			0.5			1.5			0.32			1.66			0		
12/12/22 14:52	287885.7			0.5			1.5			0.32			1.67			0		
12/12/22 14:53	290966.3			0.5			1.5			0.32			1.69			1		
12/12/22 14:54	277026.4			0.5			1.5			0.3			1.61			1		
12/12/22 14:55	254152.7			0.5			2.09			0.28			2.06			1		
12/12/22 14:56	229122.5			0.4			6.83			0.22			6.06			1		
12/12/22 14:57	202012.9			2.5			10.67			1.19			8.33			1		
12/12/22 14:58	179909.3			119.4			12.55			50.48			8.74			1		
12/12/22 14:59	159346			705			15.69			264.01			9.67			1		
12/12/22 15:00	115215.9			1455.2			18.52			394.14			8.26			1		
12/12/22 15:01	0			0			18.96			0			0			0		
12/12/22 15:02	0			0			11.8			0			0			0		
12/12/22 15:03	0			0			2.95			0			0			0		
12/12/22 15:04	0			0			2.95			0			0			0		
12/12/22 15:05	0			0			2.95			0			0			0		

CT2 SUSD EVENT 10

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 3:00	0			0			0			0			0			0		
12/17/22 3:01	0			0			0			0			0			0		
12/17/22 3:02	0			0			0			0			0			0		
12/17/22 3:03	0			0			0			0			0			0		
12/17/22 3:04	1232.3			0			0			0.09			0			0		
12/17/22 3:05	13246.7			29.5			0			0.92			0			1		
12/17/22 3:06	26416.5			53.1			0			3.29			0			1		
12/17/22 3:07	41280.6			70.8			7.38			6.86			1.18			1		
12/17/22 3:08	52447.9			1142			8.85			140.86			1.8			1		
12/17/22 3:09	64770.4			796.2			13.35			121.19			3.34			1		
12/17/22 3:10	82715.2			582.9			17.41			113.39			5.57			1		
12/17/22 3:11	129309.8			464.5			19.58			141.2			9.79			1		
12/17/22 3:12	160578.3			349.5			22.42			131.91			13.93			1		
12/17/22 3:13	193233.1			353.4			39.78			160.52			29.73			1		
12/17/22 3:14	213719.3			1026.8			43.27			515.75			35.77			1		
12/17/22 3:15	238133.4			469.8			49.73			262.88			45.8			1		
12/17/22 3:16	259851.9			88			51.97			53.74			52.23			1		
12/17/22 3:17	282956.7			6.4			54.01			4.23			59.11			1		
12/17/22 3:18	297050.6			1.7			52.48			1.16			60.3			1		
12/17/22 3:19	300208.3			1.4			29.5			1.01			34.26			1		
12/17/22 3:20	312992.9			2.2		X	21.89		X	1.6		X	26.5		X	1		
12/17/22 3:21	338254.2			1.4		X	19.81		X	1.09		X	25.92		X	1		
12/17/22 3:22	343491.3			1.1		X	15.9		X	0.9		X	21.13		X	1		
12/17/22 3:23	341950.9			1.3		X	11.97		X	1.08		X	15.83		X	1		
12/17/22 3:24	341488.8			1.6		X	10.26		X	1.3		X	13.56		X	1		
12/17/22 3:25	338716.3			1.6		X	8.98		X	1.29		X	11.77		X	1		
12/17/22 3:26	339178.3			1.5		X	7.87		X	1.23		X	10.32		X	1		
12/17/22 3:27	337407			1.5		X	7.01		X	1.15		X	9.15		X	1		
12/17/22 3:28	343645.3			1.4			6.68			1.12			8.88			1		
12/17/22 3:29	350499.7			1.3			6.07			1.07			8.23			1		
12/17/22 3:30	352348.1			1.2			5.81			0.99			7.93			1		
12/17/22 3:31	349883.6			1.2			5.73			0.98			7.75			1		
12/17/22 3:32	346802.9			1.2			5.56			0.98			7.46			1		
12/17/22 3:33	346417.8			1.2			5.39			0.97			7.22			1		
12/17/22 3:34	346957			1.2			5.38			0.99			7.22			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 3:35	347111			1.2			5.29			0.99			7.11			1		
12/17/22 3:36	347111			1.2			5.29			0.99			7.11			1		
12/17/22 3:37	348112.2			1.3			5.29			1.06			7.13			1		
12/17/22 3:38	348497.3			1.4			5.38			1.14			7.25			1		
12/17/22 3:39	345262.6			1.4			5.47			1.13			7.3			1		
12/17/22 3:40	323775.2			1.4			5.47			1.06			6.85			1		
12/17/22 3:41	311760.7			1.4			6.16			1.03			7.43			1		
12/17/22 3:42	310682.4			1.3			8.05			0.98			9.67			1		
12/17/22 3:43	302672.8			1.3			8.58			0.89			10.05			1		
12/17/22 3:44	299284.1			1.2			8.9			0.83			10.3			1		
12/17/22 3:45	299207.1			1.1			11.15			0.78			12.91			1		
12/17/22 3:46	300054.2			1			11.61			0.73			13.48			1		
12/17/22 3:47	300978.4			1			12.17			0.73			14.17			1		
12/17/22 3:48	301363.5			0.9			12.17			0.65			14.18			1		
12/17/22 3:49	301825.6			0.9			11.89			0.65			13.88			1		
12/17/22 3:50	300978.4			0.9			10.79			0.65			12.56			1		
12/17/22 3:51	301979.6			0.9			5.44			0.65			6.35			1		
12/17/22 3:52	300208.3			0.9			3.32			0.65			3.85			1		
12/17/22 3:53	299900.2			0.9			2.3			0.65			2.67			1		
12/17/22 3:54	296896.6			0.9			2.03			0.64			2.33			1		
12/17/22 3:55	297358.7			0.9			1.78			0.65			2.05			1		
12/17/22 3:56	298128.8			0.9			1.5			0.66			1.73			1		
12/17/22 3:57	297204.6			0.9			1.31			0.65			1.51			1		
12/17/22 3:58	299515.1			0.9			1.12			0.66			1.3			0		
12/17/22 3:59	301209.5			0.9			1.01			0.65			1.18			0		
12/17/22 4:00	300054.2			0.9			0.92			0.65			1.07			0		
12/17/22 4:01	302133.7			1			0.83			0.72			0.97			0		
12/17/22 4:02	302518.8			1			0.74			0.72			0.86			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 9:50	379149.6			0.7			0.98			0.64			1.44			0		
12/31/22 9:51	380458.9			0.8			0.98			0.72			1.45			0		
12/31/22 9:52	377532.3			0.7			0.98			0.63			1.44			0		
12/31/22 9:53	372911.3			0.7			0.98			0.63			1.42			0		
12/31/22 9:54	373065.4			0.8			1.06			0.69			1.52			0		
12/31/22 9:55	372603.3			0.8			1.06			0.69			1.52			1		
12/31/22 9:56	363900.5			0.8			1.07			0.69			1.51			1		
12/31/22 9:57	341334.8			0.8			1.06			0.64			1.4			1		
12/31/22 9:58	317844.9			0.8			1.41			0.59			1.73			1		
12/31/22 9:59	296665.5			0.8			1.7			0.56			1.95			1		
12/31/22 10:00	270557.1			0.7			2.21			0.47			2.32			1		
12/31/22 10:01	247529.3			0.7			4.09			0.39			3.92			1		
12/31/22 10:02	223423.3			0.5			8.53			0.28			7.38			1		
12/31/22 10:03	196929.8			3			21.17			1.39			16.13			1		
12/31/22 10:04	175057.3			160.7			23.73			66.12			16.07			1		
12/31/22 10:05	155341.2			830.9			26.7			303.34			16.04			1		
12/31/22 10:06	101199			1668.7			28.83			397.06			11.29			1		
12/31/22 10:07	0			0			28.08			0			0			0		
12/31/22 10:08	0			0			23.6			0			0			0		
12/31/22 10:09	0			0			0.2			0			0			0		
12/31/22 10:10	0			0			0.1			0			0			0		
12/31/22 10:11	0			0			0.1			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 14:20	0			0			0			0			0			0		
12/31/22 14:21	0			0			0			0			0			0		
12/31/22 14:22	0			0			0			0			0			0		
12/31/22 14:23	0			0			0			0			0			0		
12/31/22 14:24	0			0			0			0			0			0		
12/31/22 14:25	6238.3			-0.1			0			0			0			1		
12/31/22 14:26	23643.9			-0.1			0			0			0			1		
12/31/22 14:27	38354			55.1			13.77			4.97			2.04			1		
12/31/22 14:28	49906.4			1314.9			8.65			154.23			1.67			1		
12/31/22 14:29	61843.8			955.8			13.19			138.86			3.15			1		
12/31/22 14:30	77786.1			627			16.15			114.66			4.86			1		
12/31/22 14:31	122840.5			477.6			20.79			137.92			9.88			1		
12/31/22 14:32	149719			321.7			23.6			113.19			13.67			1		
12/31/22 14:33	154340			397.1			42.09			144.08			25.13			1		
12/31/22 14:34	171360.5			1949.5			42.06			785.05			27.88			1		
12/31/22 14:35	192539.9			1770.5			46.16			801.37			34.38			1		
12/31/22 14:36	216723			831.6			44.02			423.68			36.91			1		
12/31/22 14:37	241522.1			179.4			45.32			101.85			42.34			1		
12/31/22 14:38	264087.8			14.2			46			8.82			46.99			1		
12/31/22 14:39	289195			2			44.09			1.39			49.33			1		
12/31/22 14:40	316920.7			1.5			20.89			1.15			25.61			1		
12/31/22 14:41	329782.4			1.4			13.77			1.11			17.56			1		
12/31/22 14:42	330860.6			1.4			10.18			1.06			13.02			1		
12/31/22 14:43	330090.5			1.5			8.85			1.14			11.3			1		
12/31/22 14:44	338100.1			1.4			8.24			1.1			10.78			1		
12/31/22 14:45	354042.4			1.3			7.98			1.08			10.93			1		
12/31/22 14:46	355351.7			1.2			7.9			1.01			10.85			1		
12/31/22 14:47	357277.1			1.2			7.35			1.01			10.16			1		
12/31/22 14:48	357431.1			1.1			7.46			0.95			10.32			1		
12/31/22 14:49	355890.8			1			7.29			0.87			10.03			1		
12/31/22 14:50	354581.5			1			7.29			0.87			10			1		
12/31/22 14:51	343953.3			1			7.2			0.77			9.58			1		
12/31/22 14:52	357739.2			1			7.29			0.8			10.08			1		
12/31/22 14:53	360819.8			0.9			7.22			0.75			10.08			1		
12/31/22 14:54	361513			0.9			7.13			0.75			9.97			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 14:55	360280.7			0.9			7.13			0.75			9.94			1		
12/31/22 14:56	351963			0.9			6.52			0.73			8.87			1		
12/31/22 14:57	364593.6			0.9			3.79			0.75			5.34			1		
12/31/22 14:58	366673			0.8			2.55			0.68			3.62			1		
12/31/22 14:59	368521.4			0.8			2.29			0.69			3.26			1		
12/31/22 15:00	365440.8			0.8			2.38			0.68			3.36			1		
12/31/22 15:01	366442			0.8			2.55			0.68			3.62			1		
12/31/22 15:02	368290.4			0.8			2.91			0.69			4.14			1		
12/31/22 15:03	367135.1			0.8			2.99			0.68			4.25			1		
12/31/22 15:04	369368.6			0.8			3.08			0.69			4.4			1		
12/31/22 15:05	366596			0.8			3.17			0.68			4.5			1		
12/31/22 15:06	368983.5			0.8			3.26			0.69			4.65			1		
12/31/22 15:07	366519			0.8			3.26			0.68			4.62			1		
12/31/22 15:08	366056.9			0.8			3.35			0.68			4.74			1		
12/31/22 15:09	366442			0.8			3.17			0.68			4.49			1		
12/31/22 15:10	366442			0.8			2.91			0.68			4.12			1		
12/31/22 15:11	365055.7			0.8			2.64			0.68			3.73			1		
12/31/22 15:12	365132.7			0.7			2.55			0.6			3.61			1		
12/31/22 15:13	366210.9			0.8			2.55			0.68			3.62			1		
12/31/22 15:14	366750.1			0.8			2.47			0.68			3.5			1		
12/31/22 15:15	365055.7			0.8			2.29			0.68			3.23			1		
12/31/22 15:16	364131.5			0.8			2.11			0.68			2.98			1		
12/31/22 15:17	364362.6			0.8			2.03			0.68			2.85			1		
12/31/22 15:18	371987.2			0.8			1.76			0.69			2.53			1		
12/31/22 15:19	379765.8			0.8			1.5			0.71			2.2			1		
12/31/22 15:20	380921			0.8			1.16			0.72			1.71			1		
12/31/22 15:21	382153.3			0.7			0.98			0.64			1.45			1		
12/31/22 15:22	381152			0.7			0.89			0.64			1.32			0		
12/31/22 15:23	379842.8			0.7			0.8			0.64			1.18			0		
12/31/22 15:24	381537.1			0.8			0.72			0.72			1.06			0		
12/31/22 15:25	381152			0.8			0.63			0.72			0.92			0		
12/31/22 15:26	368444.4			0.8			0.62			0.69			0.88			0		

ATTACHMENT 16

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/22 0:00	0.7			1.5			1			0.5			0.2517			0.84		
10/01/22 1:00	0.7			1.5			1			0.48			0.23988			0.8		
10/01/22 2:00	0.7			1.3			1			0.49			0.24594			0.82		
10/01/22 3:00	0.7			1.3			1			0.51			0.25392			0.85		
10/01/22 4:00	0.7			1.4			1			0.49			0.24618			0.82		
10/01/22 5:00	0.6			1.5			1			0.52			0.26064			0.87		
10/01/22 6:00	0.6			1.5			3			0.43			0.21648			0.72		
10/01/22 7:00	0.5			1.5			3			0.33			0.16488			0.55		
10/01/22 8:00	0.5			1.5			3			0.33			0.16482			0.55		
10/01/22 9:00	0.4			1.5			2			0.33			0.165			0.55		
10/01/22 10:00	0.4			1.5			2			0.33			0.1653			0.55		
10/01/22 11:00	0.4			1.5			2			0.33			0.16518			0.55		
10/01/22 12:00	0.4			1.5			2			0.33			0.16542			0.55		
10/01/22 13:00	0.4			1.5			1			0.34			0.16782			0.56		
10/01/22 14:00	0.4			1.5			2			0.33			0.16572			0.55		
10/01/22 15:00	0.4			1.5			1			0.34			0.16794			0.56		
10/01/22 16:00	0.6			1.4			0			0.46			0.2283			0.76		
10/01/22 17:00	0.6			1.5			0			0.53			0.26724			0.89		
10/01/22 18:00	0.6			1.5			1			0.51			0.2541			0.85		
10/01/22 19:00	0.6			1.5			1			0.48			0.24066			0.8		
10/01/22 20:00	0.6			1.5			1			0.52			0.2586			0.86		
10/01/22 21:00	0.6			1.5			1			0.48			0.24138			0.8		
10/01/22 22:00	0.6			1.5			2			0.39			0.19536			0.65		
10/01/22 23:00	0.6			1.5			1			0.46			0.23022			0.77		
10/02/22 0:00	0.7			1.5			2			0.43			0.21672			0.72		
10/02/22 1:00	0.6			1.4			1			0.42			0.2121			0.71		
10/02/22 2:00	0.6			1.3			2			0.5			0.25176			0.84		
10/02/22 3:00	0.6			1.5			1			0.51			0.25338			0.84		
10/02/22 4:00	0.6			1.6			1			0.53			0.26544			0.88		
10/02/22 5:00	0.6			1.6			1			0.53			0.2637			0.88		
10/02/22 6:00	0.6			1.6			3			0.45			0.22704			0.76		
10/02/22 7:00	0.4			1.6			3			0.33			0.16572			0.55		
10/02/22 8:00	0.4			1.6			3			0.33			0.16482			0.55		
10/02/22 9:00	0.4			1.6			3			0.33			0.16488			0.55		
10/02/22 10:00	0.4			1.6			3			0.33			0.16494			0.55		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/22 11:00	0.4			1.6			2			0.33			0.16494			0.55		
10/02/22 12:00	0.4			1.6			1			0.34			0.16872			0.56		
10/02/22 13:00	0.6			1.5			0			0.41			0.2028			0.68		
10/02/22 14:00	0.6			1.6			0			0.5			0.25176			0.84		
10/02/22 15:00	0.6			1.5			1			0.42			0.21246			0.71		
10/02/22 16:00	0.9			1.6			1			0.52			0.26238			0.87		
10/02/22 17:00	0.7			1.6			1			0.63			0.3141			1.05		
10/02/22 18:00	0.8			1.6			1			0.62			0.3114			1.04		
10/02/22 19:00	0.9			1.6			1			0.62			0.31044			1.03		
10/02/22 20:00	1.1			1.6			1			0.61			0.3033			1.01		
10/02/22 21:00	0.7			1.6			1			0.48			0.24072			0.8		
10/02/22 22:00	0.6			1.6			2			0.44			0.21756			0.73		
10/02/22 23:00	0.6			1.6			1			0.54			0.26802			0.89		
10/03/22 0:00	0.6			1.6			1			0.51			0.25722			0.86		
10/03/22 1:00	0.6			1.6			1			0.51			0.25338			0.84		
10/03/22 2:00	0.6			1.7			2			0.51			0.25608			0.85		
10/03/22 3:00	0.7			1.3			2			0.52			0.25866			0.86		
10/03/22 4:00	0.6			1.6			1			0.53			0.26604			0.89		
10/03/22 5:00	0.6			1.5			2			0.54			0.2697			0.9		
10/03/22 6:00	0.6			1.4			2			0.5			0.24756			0.83		
10/03/22 7:00	0.6			1.3			2			0.39			0.1926			0.64		
10/03/22 8:00	0.6			1.3			1			0.5			0.24954			0.83		
10/03/22 9:00	0.5			1.4			2			0.35			0.17634			0.59		
10/03/22 10:00	0.5			1.4			1			0.39			0.19734			0.66		
10/03/22 11:00	0.6			1.4			1			0.45			0.22668			0.76		
10/03/22 12:00	0.6			1.4			1			0.53			0.2658			0.89		
10/03/22 13:00	0.6			1.4			1			0.53			0.26742			0.89		
10/03/22 14:00	0.6			1.4			1			0.53			0.26748			0.89		
10/03/22 15:00	0.6			1.4			1			0.54			0.26976			0.9		
10/03/22 16:00	0.7			1.4			1			0.52			0.26142			0.87		
10/03/22 17:00	0.8			1.4			1			0.63			0.3153			1.05		
10/03/22 18:00	0.8			1.4			1			0.63			0.31644			1.05		
10/03/22 19:00	0.9			1.4			1			0.63			0.3144			1.05		
10/03/22 20:00	1			1.4			1			0.62			0.31188			1.04		
10/03/22 21:00	1			1.4			1			0.54			0.26838			0.89		
10/03/22 22:00	0.6			1.4			1			0.53			0.2655			0.89		
10/03/22 23:00	1.3			1.4			2			0.61			0.30504			1.02		
10/04/22 0:00	1.2			1.4			2			0.61			0.30672			1.02		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/22 1:00	1.1			1.4			2			0.62			0.31086			1.04		
10/04/22 2:00	1.2			1.3			2			0.61			0.30642			1.02		
10/04/22 3:00	1.3			1.5			2			0.61			0.30702			1.02		
10/04/22 4:00	1.3			1.6			2			0.6			0.30126			1		
10/04/22 5:00	1.1			1.5			2			0.62			0.31032			1.03		
10/04/22 6:00	1.4			1.5			2			0.6			0.30138			1		
10/04/22 7:00	1.2			1.5			1			0.57			0.28434			0.95		
10/04/22 8:00	0.6			1.5			1			0.54			0.26982			0.9		
10/04/22 9:00	1.1			1.1			2			0.57			0.28284			0.94		
10/04/22 10:00	0.9			1.6			1			0.62			0.31098			1.04		
10/04/22 11:00	0.8			1.5			1			0.55			0.2769			0.92		
10/04/22 12:00	0.7			1.5			1			0.65			0.32502			1.08		
10/04/22 13:00	1			1.4			0			0.61			0.30498			1.02		
10/04/22 14:00	1			1.5			1			0.61			0.30354			1.01		
10/04/22 15:00	0.8			1.5			1			0.63			0.3132			1.04		
10/04/22 16:00	0.6			1.5			2			0.66			0.32916			1.1		
10/04/22 17:00	0.4			1.5			2			0.68			0.34128			1.14		
10/04/22 18:00	0.4			1.5			2			0.68			0.33768			1.13		
10/04/22 19:00	0.5			1.5			2			0.67			0.3327			1.11		
10/04/22 20:00	0.6			1.5			2			0.66			0.33186			1.11		
10/04/22 21:00	0.6			1.5			2			0.66			0.32994			1.1		
10/04/22 22:00	0.8			1.5			2			0.63			0.31632			1.05		
10/04/22 23:00	0.6			1.5			2			0.66			0.32844			1.09		
10/05/22 0:00	0.7			1.5			2			0.65			0.32646			1.09		
10/05/22 1:00	0.8			1.5			2			0.64			0.32172			1.07		
10/05/22 2:00	0.8			1.5			2			0.65			0.32268			1.08		
10/05/22 3:00	0.9			1.5			2			0.64			0.32016			1.07		
10/05/22 4:00	0.9			1.5			2			0.64			0.32082			1.07		
10/05/22 5:00	1			1.5			2			0.64			0.31986			1.07		
10/05/22 6:00	1.2			1.5			2			0.61			0.30348			1.01		
10/05/22 7:00	1.7			1.5			1			0.58			0.29154			0.97		
10/05/22 8:00	1.1			1.5			1			0.55			0.2748			0.92		
10/05/22 9:00	0.8			1.5			1			0.53			0.26328			0.88		
10/05/22 10:00	1			1.5			1			0.61			0.30642			1.02		
10/05/22 11:00	1			1.5			1			0.61			0.30636			1.02		
10/05/22 12:00	0.8			1.5			1			0.63			0.31698			1.06		
10/05/22 13:00	0.5			1.5			2			0.67			0.33708			1.12		
10/05/22 14:00	0.4			1.5			2			0.68			0.34134			1.14		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/22 15:00	0.6			1.5			1			0.66			0.32988			1.1		
10/05/22 16:00	0.5			1.5			1			0.66			0.3318			1.11		
10/05/22 17:00	0.3			1.5			2			0.69			0.34386			1.15		
10/05/22 18:00	0.4			1.5			2			0.68			0.34038			1.13		
10/05/22 19:00	0.6			1.5			2			0.67			0.33564			1.12		
10/05/22 20:00	0.5			1.5			2			0.67			0.33432			1.11		
10/05/22 21:00	0.6			1.5			2			0.67			0.33336			1.11		
10/05/22 22:00	0.8			1.5			2			0.64			0.3195			1.07		
10/05/22 23:00	0.7			1.5			1			0.54			0.2724			0.91		
10/06/22 0:00	0.6			1.5			1			0.54			0.27192			0.91		
10/06/22 1:00	0.6			1.5			1			0.54			0.27228			0.91		
10/06/22 2:00	0.6			1.6			1			0.54			0.2721			0.91		
10/06/22 3:00	0.6			1.5			1			0.54			0.27144			0.9		
10/06/22 4:00	0.6			1.5			1			0.54			0.2721			0.91		
10/06/22 5:00	0.9			1.5			1			0.55			0.27594			0.92		
10/06/22 6:00	1.4			1.5			2			0.61			0.30282			1.01		
10/06/22 7:00	1.3			1.5			2			0.52			0.25962			0.87		
10/06/22 8:00	0.7			1.4			2			0.37			0.18444			0.61		
10/06/22 9:00	0.5			1.5			2			0.35			0.17514			0.58		
10/06/22 10:00	0.5			1.5			1			0.35			0.17604			0.59		
10/06/22 11:00	0.6			1.5			1			0.41			0.20346			0.68		
10/06/22 12:00	0.6			1.5			0			0.47			0.23316			0.78		
10/06/22 13:00	0.7			1.5			1			0.53			0.26562			0.89		
10/06/22 14:00	0.6			1.5			1			0.65			0.32532			1.08		
10/06/22 15:00	0.6			1.5			1			0.66			0.32838			1.09		
10/06/22 16:00	0.4			1.5			2			0.68			0.33906			1.13		
10/06/22 17:00	0.4			1.5			2			0.69			0.34398			1.15		
10/06/22 18:00	0.4			1.5			2			0.68			0.33996			1.13		
10/06/22 19:00	0.5			1.5			2			0.67			0.33636			1.12		
10/06/22 20:00	0.6			1.5			2			0.67			0.3342			1.11		
10/06/22 21:00	0.6			1.5			2			0.66			0.32982			1.1		
10/06/22 22:00	0.9			1.5			2			0.64			0.32124			1.07		
10/06/22 23:00	0.9			1.5			2			0.64			0.32214			1.07		
10/07/22 0:00	1			1.5			2			0.63			0.3168			1.06		
10/07/22 1:00	1.2			1.5			2			0.63			0.31452			1.05		
10/07/22 2:00	1.2			1.5			1			0.59			0.2952			0.98		
10/07/22 3:00	1.1			1.5			2			0.58			0.28866			0.96		
10/07/22 4:00	1.2			1.5			2			0.63			0.31398			1.05		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/22 5:00	1.2			1.5			2			0.64			0.32034			1.07		
10/07/22 6:00	1.5			1.5			2			0.61			0.30624			1.02		
10/07/22 7:00	1.5			1.5			1			0.6			0.2988			1		
10/07/22 8:00	1.3			1.5			1			0.59			0.29568			0.99		
10/07/22 9:00	1			1.5			1			0.6			0.30228			1.01		
10/07/22 10:00	0.6			1.5			2			0.67			0.33288			1.11		
10/07/22 11:00	0.4			1.5			2			0.68			0.34134			1.14		
10/07/22 12:00	0.4			1.5			2			0.68			0.34236			1.14		
10/07/22 13:00	0.6			1.5			1			0.66			0.32844			1.09		
10/07/22 14:00	0.8			1.5			1			0.63			0.31326			1.04		
10/07/22 15:00	0.6			1.5			2			0.65			0.32724			1.09		
10/07/22 16:00	0.5			1.5			2			0.67			0.33672			1.12		
10/07/22 17:00	0.4			1.5			2			0.69			0.34476			1.15		
10/07/22 18:00	0.4			1.5			2			0.68			0.33792			1.13		
10/07/22 19:00	0.5			1.5			2			0.68			0.33756			1.13		
10/07/22 20:00	0.5			1.5			2			0.67			0.33402			1.11		
10/07/22 21:00	0.6			1.5			2			0.66			0.32958			1.1		
10/07/22 22:00	0.8			1.5			2			0.64			0.3207			1.07		
10/07/22 23:00	0.8			1.5			2			0.65			0.32298			1.08		
10/08/22 0:00	0.8			1.5			2			0.65			0.32304			1.08		
10/08/22 1:00	1.1			1.5			2			0.63			0.31314			1.04		
10/08/22 2:00	1.1			1.5			1			0.63			0.31266			1.04		
10/08/22 3:00	1.2			1.5			2			0.63			0.3138			1.05		
10/08/22 4:00	1.2			1.5			2			0.63			0.3156			1.05		
10/08/22 5:00	1.2			1.5			2			0.63			0.31338			1.04		
10/08/22 6:00	1.2			1.5			2			0.54			0.26796			0.89		
10/08/22 7:00	0.7			1.4			2			0.4			0.19944			0.66		
10/08/22 8:00	0.6			1.5			1			0.38			0.1917			0.64		
10/08/22 9:00	0.6			1.4			1			0.39			0.1953			0.65		
10/08/22 10:00	0.5			1.5			2			0.35			0.1761			0.59		
10/08/22 11:00	0.6			1.4			1			0.41			0.20448			0.68		
10/08/22 12:00	0.6			1.5			1			0.46			0.23046			0.77		
10/08/22 13:00	1.2			1.5			1			0.55			0.27534			0.92		
10/08/22 14:00	0.9			1.5			1			0.53			0.26538			0.88		
10/08/22 15:00	0.6			1.5			1			0.65			0.32592			1.09		
10/08/22 16:00	0.4			1.5			2			0.68			0.3393			1.13		
10/08/22 17:00	0.3			1.5			2			0.68			0.34032			1.13		
10/08/22 18:00	0.5			1.5			2			0.67			0.33462			1.12		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 19:00	0.5			1.5			2			0.67			0.3348			1.12		
10/08/22 20:00	0.6			1.5			2			0.67			0.33282			1.11		
10/08/22 21:00	0.8			1.5			1			0.63			0.31344			1.04		
10/08/22 22:00	0.8			1.4			1			0.47			0.23334			0.78		
10/08/22 23:00	1.4			1.5			1			0.57			0.28428			0.95		
10/09/22 0:00	1.6			1.5			1			0.58			0.29052			0.97		
10/09/22 1:00	1.6			1.5			1			0.58			0.291			0.97		
10/09/22 2:00	1.5			1.5			1			0.58			0.29148			0.97		
10/09/22 3:00	1.5			1.5			1			0.58			0.29196			0.97		
10/09/22 4:00	1.5			1.5			1			0.59			0.29286			0.98		
10/09/22 5:00	1.5			1.5			2			0.59			0.29292			0.98		
10/09/22 6:00	1.5			1.5			2			0.59			0.29352			0.98		
10/09/22 7:00	1.5			1.5			1			0.59			0.29364			0.98		
10/09/22 8:00	1.5			1.5			1			0.59			0.2925			0.98		
10/09/22 9:00	1.4			1.5			1			0.58			0.2913			0.97		
10/09/22 10:00	1.4			1.5			1			0.58			0.29016			0.97		
10/09/22 11:00	1.4			1.5			1			0.58			0.28854			0.96		
10/09/22 12:00	1.3			1.5			1			0.58			0.28884			0.96		
10/09/22 13:00	1.1			1.5			1			0.58			0.29022			0.97		
10/09/22 14:00	1.1			1.5			1			0.58			0.2901			0.97		
10/09/22 15:00	1.1			1.5			1			0.58			0.29106			0.97		
10/09/22 16:00	1.1			1.5			1			0.58			0.29106			0.97		
10/09/22 17:00	1.1			1.5			1			0.58			0.29082			0.97		
10/09/22 18:00	1.2			1.5			1			0.58			0.28926			0.96		
10/09/22 19:00	1.3			1.5			1			0.58			0.28758			0.96		
10/09/22 20:00	1.4			1.5			1			0.57			0.28734			0.96		
10/09/22 21:00	1.3			1.5			1			0.58			0.28806			0.96		
10/09/22 22:00	1.3			1.5			1			0.58			0.2889			0.96		
10/09/22 23:00	1.3			1.5			1			0.58			0.28962			0.97		
10/10/22 0:00	1.3			1.5			1			0.58			0.29076			0.97		
10/10/22 1:00	1.3			1.5			1			0.58			0.29124			0.97		
10/10/22 2:00	1.3			1.5			1			0.58			0.2913			0.97		
10/10/22 3:00	1.4			1.5			1			0.58			0.2919			0.97		
10/10/22 4:00	1.4			1.5			1			0.59			0.29292			0.98		
10/10/22 5:00	1.2			1.5			2			0.61			0.30702			1.02		
10/10/22 6:00	1.2			1.5			2			0.62			0.31188			1.04		
10/10/22 7:00	1.5			1.5			1			0.59			0.2934			0.98		
10/10/22 8:00	1.5			1.5			1			0.58			0.29166			0.97		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/22 9:00	1.3			1.5			1			0.59			0.29268			0.98		
10/10/22 10:00	0.9			1.5			1			0.56			0.28104			0.94		
10/10/22 11:00	0.5			1.5			1			0.36			0.1797			0.6		
10/10/22 12:00	0.5			1.5			1			0.35			0.17382			0.58		
10/10/22 13:00	0.5			0.6			3			0.35			0.174			0.58		
10/10/22 14:00	0.5			1.5			0			0.35			0.17394			0.58		
10/10/22 15:00	0.8			1.4			1			0.47			0.23712			0.79		
10/10/22 16:00	0.6			1.5			2			0.68			0.34044			1.13		
10/10/22 17:00	0.6			1.5			1			0.66			0.32928			1.1		
10/10/22 18:00	1.4			1.5			1			0.58			0.28962			0.97		
10/10/22 19:00	1.3			1.5			1			0.58			0.28866			0.96		
10/10/22 20:00	1.4			1.5			1			0.58			0.28752			0.96		
10/10/22 21:00	1.4			1.5			1			0.58			0.28782			0.96		
10/10/22 22:00	1.3			1.5			1			0.58			0.28896			0.96		
10/10/22 23:00	1			1.5			1			0.56			0.28242			0.94		
10/11/22 0:00	0.6			1.5			2			0.36			0.18006			0.6		
10/11/22 1:00	0.6			1.5			2			0.35			0.17412			0.58		
10/11/22 2:00	0.6			1.6			2			0.35			0.17442			0.58		
10/11/22 3:00	0.6			1.5			2			0.35			0.17502			0.58		
10/11/22 4:00	0.6			1.5			2			0.35			0.17508			0.58		
10/11/22 5:00	0.6			1.5			3			0.35			0.1749			0.58		
10/11/22 6:00	0.6			1.5			3			0.35			0.17496			0.58		
10/11/22 7:00	0.6			1.5			3			0.35			0.17502			0.58		
10/11/22 8:00	0.6			1.5			2			0.35			0.17448			0.58		
10/11/22 9:00	0.5			1.5			2			0.35			0.1749			0.58		
10/11/22 10:00	0.5			1.5			2			0.35			0.17568			0.59		
10/11/22 11:00	0.5			1.5			1			0.35			0.1752			0.58		
10/11/22 12:00	0.5			1.5			1			0.35			0.1743			0.58		
10/11/22 13:00	0.5			1.5			1			0.35			0.17292			0.58		
10/11/22 14:00	0.5			1.5			1			0.35			0.1725			0.58		
10/11/22 15:00	0.9			1.5			1			0.47			0.23718			0.79		
10/11/22 16:00	1.2			1.5			1			0.58			0.29022			0.97		
10/11/22 17:00	1.3			1.5			1			0.58			0.2889			0.96		
10/11/22 18:00	1.3			1.5			1			0.57			0.2871			0.96		
10/11/22 19:00	1.4			1.5			1			0.58			0.28812			0.96		
10/11/22 20:00	1.4			1.5			1			0.58			0.28992			0.97		
10/11/22 21:00	1.5			1.5			1			0.58			0.29052			0.97		
10/11/22 22:00	1.5			1.5			1			0.58			0.2913			0.97		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/22 23:00	1.5			1.5			1			0.58			0.29196			0.97		
10/12/22 0:00	1.3			1.5			2			0.58			0.29202			0.97		
10/12/22 1:00	1.3			1.5			1			0.58			0.29244			0.97		
10/12/22 2:00	1.3			1.5			1			0.59			0.29268			0.98		
10/12/22 3:00	1.3			1.5			2			0.59			0.29358			0.98		
10/12/22 4:00	1.3			1.5			2			0.59			0.29394			0.98		
10/12/22 5:00	1.3			1.5			2			0.59			0.29448			0.98		
10/12/22 6:00	1.3			1.5			2			0.59			0.29436			0.98		
10/12/22 7:00	0.9			1.5			2			0.51			0.2571			0.86		
10/12/22 8:00	0.6			1.5			2			0.35			0.1746			0.58		
10/12/22 9:00	0.5			1.5			2			0.35			0.17478			0.58		
10/12/22 10:00	0.5			1.5			2			0.35			0.17424			0.58		
10/12/22 11:00	0.5			1.5			2			0.35			0.17394			0.58		
10/12/22 12:00	0.5			1.5			2			0.35			0.17328			0.58		
10/12/22 13:00	0.5			1.5			2			0.35			0.17364			0.58		
10/12/22 14:00	0.5			1.5			1			0.35			0.17328			0.58		
10/12/22 15:00	0.5			1.5			1			0.35			0.17382			0.58		
10/12/22 16:00	0.5			1.5			1			0.35			0.1743			0.58		
10/12/22 17:00	0.5			1.5			1			0.35			0.1743			0.58		
10/12/22 18:00	0.5			1.5			2			0.35			0.17364			0.58		
10/12/22 19:00	0.5			1.5			2			0.35			0.17322			0.58		
10/12/22 20:00	0.5			1.5			2			0.35			0.17304			0.58		
10/12/22 21:00	0.5			1.5			2			0.35			0.17322			0.58		
10/12/22 22:00	0.5			1.5			2			0.35			0.1743			0.58		
10/12/22 23:00	0.5			1.5			3			0.35			0.17376			0.58		
10/13/22 0:00	0.5			1.5			3			0.35			0.17358			0.58		
10/13/22 1:00	0.5			1.5			3			0.35			0.17352			0.58		
10/13/22 2:00	0.5			1.4			3			0.35			0.17316			0.58		
10/13/22 3:00	0.5			1.5			3			0.35			0.1731			0.58		
10/13/22 4:00	0.5			1.5			3			0.35			0.17316			0.58		
10/13/22 5:00	0.5			1.5			3			0.35			0.17376			0.58		
10/13/22 6:00	0.6			1.4			1			0.45			0.22326			0.74		
10/13/22 7:00	0.5			1.5			4			0.35			0.17352			0.58		
10/13/22 8:00	0.5			1.5			3			0.35			0.17352			0.58		
10/13/22 9:00	0.5			1.5			2			0.35			0.17418			0.58		
10/13/22 10:00	0.5			1.5			2			0.35			0.17478			0.58		
10/13/22 11:00	0.5			1.5			2			0.35			0.17322			0.58		
10/13/22 12:00	0.5			1.5			2			0.35			0.17286			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/22 13:00	0.5			1.5			1			0.35			0.17262			0.58		
10/13/22 14:00	0.5			1.5			1			0.35			0.17268			0.58		
10/13/22 15:00	0.9			1.5			1			0.47			0.23676			0.79		
10/13/22 16:00	1.1			1.5			1			0.6			0.29994			1		
10/13/22 17:00	1.3			1.5			1			0.58			0.28794			0.96		
10/13/22 18:00	1.3			1.5			1			0.58			0.2883			0.96		
10/13/22 19:00	1.3			1.5			1			0.58			0.28956			0.97		
10/13/22 20:00	1.3			1.5			1			0.58			0.28944			0.96		
10/13/22 21:00	1.3			1.5			1			0.58			0.28956			0.97		
10/13/22 22:00	1.3			1.5			1			0.58			0.28992			0.97		
10/13/22 23:00	1.4			1.5			1			0.58			0.29022			0.97		
10/14/22 0:00	1.3			1.5			2			0.58			0.29112			0.97		
10/14/22 1:00	1.3			1.5			2			0.58			0.29178			0.97		
10/14/22 2:00	1.3			1.5			2			0.58			0.29208			0.97		
10/14/22 3:00	1.4			1.5			2			0.59			0.29274			0.98		
10/14/22 4:00	1.4			1.5			2			0.59			0.29304			0.98		
10/14/22 5:00	1.4			1.5			2			0.59			0.29406			0.98		
10/14/22 6:00	1.4			1.5			2			0.59			0.29472			0.98		
10/14/22 7:00	1.2			1.5			2			0.55			0.273			0.91		
10/14/22 8:00	0.6			1.5			3			0.35			0.17394			0.58		
10/14/22 9:00	0.6			1.5			2			0.35			0.17448			0.58		
10/14/22 10:00	0.6			1.5			2			0.35			0.17508			0.58		
10/14/22 11:00	0.5			1.5			1			0.35			0.17508			0.58		
10/14/22 12:00	0.5			1.5			1			0.35			0.17376			0.58		
10/14/22 13:00	0.5			1.5			1			0.35			0.17364			0.58		
10/14/22 14:00	0.5			1.5			1			0.35			0.17364			0.58		
10/14/22 15:00	0.5			1.5			1			0.35			0.17382			0.58		
10/14/22 16:00	1			1.5			1			0.48			0.23796			0.79		
10/14/22 17:00	1.4			1.5			1			0.58			0.29028			0.97		
10/14/22 18:00	1.6			1.5			1			0.58			0.28866			0.96		
10/14/22 19:00	1.5			1.5			1			0.58			0.2904			0.97		
10/14/22 20:00	1.4			1.5			1			0.58			0.29148			0.97		
10/14/22 21:00	1.5			1.5			1			0.58			0.28998			0.97		
10/14/22 22:00	1.5			1.5			1			0.58			0.28902			0.96		
10/14/22 23:00	1.6			1.5			1			0.58			0.28908			0.96		
10/15/22 0:00	1.6			1.5			1			0.58			0.29016			0.97		
10/15/22 1:00	1.4			1.5			1			0.57			0.2865			0.96		
10/15/22 2:00	0.6			1.5			1			0.55			0.2763			0.92		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/22 3:00	1			1.5			1			0.54			0.27			0.9		
10/15/22 4:00	1.8			1.5			2			0.58			0.29214			0.97		
10/15/22 5:00	1.7			1.5			2			0.59			0.29262			0.98		
10/15/22 6:00	1.3			1.5			2			0.57			0.28578			0.95		
10/15/22 7:00	0.6			1.5			3			0.4			0.19824			0.66		
10/15/22 8:00	0.5			1.5			2			0.35			0.17382			0.58		
10/15/22 9:00	0.6			1.5			2			0.35			0.17388			0.58		
10/15/22 10:00	0.5			1.5			2			0.35			0.17418			0.58		
10/15/22 11:00	0.5			1.5			2			0.35			0.17388			0.58		
10/15/22 12:00	0.5			1.5			2			0.35			0.1725			0.58		
10/15/22 13:00	0.5			1.5			2			0.35			0.1725			0.58		
10/15/22 14:00	0.5			1.5			1			0.35			0.1725			0.58		
10/15/22 15:00	0.5			1.5			1			0.34			0.17244			0.57		
10/15/22 16:00	0.5			1.5			1			0.34			0.17244			0.57		
10/15/22 17:00	0.5			1.5			2			0.34			0.17244			0.57		
10/15/22 18:00	0.5			1.5			2			0.35			0.17388			0.58		
10/15/22 19:00	0.5			1.5			2			0.35			0.1728			0.58		
10/15/22 20:00	0.5			1.5			3			0.35			0.1725			0.58		
10/15/22 21:00	0.5			1.5			2			0.35			0.17358			0.58		
10/15/22 22:00	0.5			1.5			3			0.35			0.17406			0.58		
10/15/22 23:00	0.5			1.5			3			0.35			0.17418			0.58		
10/16/22 0:00	0.5			1.5			2			0.35			0.1743			0.58		
10/16/22 1:00	0.5			1.5			2			0.35			0.17478			0.58		
10/16/22 2:00	0.5			1.5			2			0.35			0.17436			0.58		
10/16/22 3:00	0.5			1.5			2			0.35			0.17442			0.58		
10/16/22 4:00	0.5			1.5			2			0.35			0.1749			0.58		
10/16/22 5:00	0.5			1.5			3			0.35			0.17514			0.58		
10/16/22 6:00	0.5			1.5			3			0.36			0.1776			0.59		
10/16/22 7:00	0.5			1.5			3			0.35			0.1737			0.58		
10/16/22 8:00	0.5			1.5			2			0.35			0.17454			0.58		
10/16/22 9:00	0.5			1.4			1			0.4			0.1992			0.66		
10/16/22 10:00	1			1.5			1			0.57			0.28338			0.94		
10/16/22 11:00	1.8			1.5			1			0.59			0.2925			0.98		
10/16/22 12:00	1.6			1.5			1			0.58			0.2919			0.97		
10/16/22 13:00	1.6			1.5			1			0.58			0.29142			0.97		
10/16/22 14:00	1.6			1.5			1			0.58			0.29094			0.97		
10/16/22 15:00	1.6			1.5			1			0.58			0.29106			0.97		
10/16/22 16:00	1.6			1.5			1			0.58			0.29166			0.97		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/22 17:00	1.6			1.5			1			0.59			0.2925			0.98		
10/16/22 18:00	1.6			1.5			1			0.59			0.29358			0.98		
10/16/22 19:00	1.6			1.5			1			0.59			0.29418			0.98		
10/16/22 20:00	1.6			1.5			2			0.59			0.29442			0.98		
10/16/22 21:00	1.6			1.5			2			0.59			0.2946			0.98		
10/16/22 22:00	1.6			1.5			2			0.59			0.2949			0.98		
10/16/22 23:00	1.7			1.5			2			0.59			0.29496			0.98		
10/17/22 0:00	1.6			1.5			2			0.59			0.29514			0.98		
10/17/22 1:00	1.3			1.5			2			0.57			0.2865			0.96		
10/17/22 2:00	0.6			1.5			1			0.55			0.27474			0.92		
10/17/22 3:00	0.7			1.5			2			0.55			0.27324			0.91		
10/17/22 4:00	1.2			1.5			2			0.56			0.28068			0.94		
10/17/22 5:00	1.8			1.5			2			0.6			0.29898			1		
10/17/22 6:00	1.7			1.5			2			0.6			0.29886			1		
10/17/22 7:00	1.5			1.3			2			0.58			0.2922			0.97		
10/17/22 8:00	1.2			1.5			1			0.54			0.26928			0.9		
10/17/22 9:00	1.5			1.5			2			0.58			0.29172			0.97		
10/17/22 10:00	1.4			1.5			2			0.58			0.28884			0.96		
10/17/22 11:00	1.2			1.5			1			0.58			0.29046			0.97		
10/17/22 12:00	1			1.5			1			0.58			0.29208			0.97		
10/17/22 13:00	1.1			1.5			1			0.58			0.28986			0.97		
10/17/22 14:00	0.9			1.5			2			0.58			0.29154			0.97		
10/17/22 15:00	0.9			1.5			1			0.59			0.29286			0.98		
10/17/22 16:00	0.9			1.5			1			0.58			0.2922			0.97		
10/17/22 17:00	1			1.5			1			0.58			0.29094			0.97		
10/17/22 18:00	1.2			1.5			1			0.58			0.28938			0.96		
10/17/22 19:00	1.3			1.5			2			0.58			0.28818			0.96		
10/17/22 20:00	1.5			1.5			2			0.58			0.28974			0.97		
10/17/22 21:00	1.5			1.5			2			0.58			0.28968			0.97		
10/17/22 22:00	1.3			1.5			2			0.6			0.29922			1		
10/17/22 23:00	1.3			1.5			2			0.61			0.30726			1.02		
10/18/22 0:00	1.6			1.5			2			0.59			0.2934			0.98		
10/18/22 1:00	1.5			1.5			2			0.59			0.29346			0.98		
10/18/22 2:00	1.5			1.5			2			0.59			0.2943			0.98		
10/18/22 3:00	1.5			1.5			2			0.6			0.29826			0.99		
10/18/22 4:00	1.3			1.5			2			0.62			0.3102			1.03		
10/18/22 5:00	1.1			1.5			2			0.64			0.32154			1.07		
10/18/22 6:00	0.7			1.5			2			0.68			0.34212			1.14		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 7:00	1.2			1.5			2			0.6			0.30108			1		
10/18/22 8:00	1.5			1.5			2			0.59			0.294			0.98		
10/18/22 9:00	1.2			1.5			2			0.59			0.29268			0.98		
10/18/22 10:00	1			1.5			1			0.59			0.29682			0.99		
10/18/22 11:00	1			1.5			1			0.6			0.29814			0.99		
10/18/22 12:00	1.1			1.5			1			0.59			0.29556			0.99		
10/18/22 13:00	1.1			1.5			1			0.57			0.28434			0.95		
10/18/22 14:00	0.7			1.4			1			0.41			0.20514			0.68		
10/18/22 15:00	0.8			1.5			2			0.4			0.1983			0.66		
10/18/22 16:00	0.7			1.4			1			0.56			0.28152			0.94		
10/18/22 17:00	0.3			1.5			2			0.72			0.35892			1.2		
10/18/22 18:00	0.4			1.5			2			0.7			0.34932			1.16		
10/18/22 19:00	0.2			1.5			3			0.77			0.3825			1.28		
10/18/22 20:00	0.4			1.5			2			0.71			0.35358			1.18		
10/18/22 21:00	0.5			1.5			2			0.69			0.34266			1.14		
10/18/22 22:00	1.1			1.5			2			0.64			0.3204			1.07		
10/18/22 23:00	0.8			1.5			1			0.55			0.27318			0.91		
10/19/22 0:00	0.7			1.5			1			0.55			0.27306			0.91		
10/19/22 1:00	0.7			1.5			2			0.53			0.2631			0.88		
10/19/22 2:00	0.7			1.6			2			0.5			0.25086			0.84		
10/19/22 3:00	0.9			1.5			2			0.52			0.26166			0.87		
10/19/22 4:00	0.8			1.5			2			0.54			0.27156			0.91		
10/19/22 5:00	0.8			1.5			2			0.55			0.27264			0.91		
10/19/22 6:00	0.8			1.5			3			0.47			0.234			0.78		
10/19/22 7:00	0.6			1.5			5			0.34			0.16758			0.56		
10/19/22 8:00	0.6			1.5			4			0.31			0.15726			0.52		
10/19/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/22 16:00	0.4			1.4			4			0.3			0.15156			0.51		
10/19/22 17:00	0.6			1.4			1			0.44			0.22164			0.74		
10/19/22 18:00	1.6			1.5			1			0.58			0.28896			0.96		
10/19/22 19:00	1.1			1.5			1			0.6			0.29886			1		
10/19/22 20:00	1.2			1.5			2			0.62			0.30864			1.03		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 21:00	1.2			1.5			1			0.59			0.294			0.98		
10/19/22 22:00	0.7			1.5			2			0.41			0.20628			0.69		
10/19/22 23:00	0.7			1.5			1			0.49			0.2436			0.81		
10/20/22 0:00	0.7			1.5			1			0.49			0.2451			0.82		
10/20/22 1:00	0.7			1.4			2			0.41			0.20466			0.68		
10/20/22 2:00	0.6			1.5			2			0.36			0.17862			0.6		
10/20/22 3:00	0.8			1.5			1			0.44			0.22164			0.74		
10/20/22 4:00	0.8			1.5			1			0.52			0.26112			0.87		
10/20/22 5:00	0.7			1.5			2			0.55			0.27672			0.92		
10/20/22 6:00	0.7			1.5			2			0.49			0.24636			0.82		
10/20/22 7:00	0.6			1.5			3			0.35			0.1755			0.59		
10/20/22 8:00	0.6			1.5			3			0.34			0.17046			0.57		
10/20/22 9:00	0.5			1.5			2			0.34			0.17124			0.57		
10/20/22 10:00	0.5			1.5			2			0.35			0.1725			0.58		
10/20/22 11:00	0.5			1.5			2			0.34			0.16962			0.57		
10/20/22 12:00	0.4			1.5			2			0.34			0.17016			0.57		
10/20/22 13:00	0.5			1.4			1			0.35			0.17532			0.58		
10/20/22 14:00	0.5			1.4			1			0.36			0.18042			0.6		
10/20/22 15:00	0.7			1.5			1			0.49			0.24324			0.81		
10/20/22 16:00	0.3			1.5			2			0.71			0.35676			1.19		
10/20/22 17:00	0.5			1.5			2			0.67			0.3339			1.11		
10/20/22 18:00	0.8			1.5			2			0.63			0.31452			1.05		
10/20/22 19:00	1.3			1.5			1			0.59			0.29718			0.99		
10/20/22 20:00	1.2			1.5			1			0.58			0.28962			0.97		
10/20/22 21:00	0.7			1.5			2			0.38			0.1917			0.64		
10/20/22 22:00	0.6			1.5			2			0.37			0.18474			0.62		
10/20/22 23:00	0.7			1.5			1			0.52			0.26064			0.87		
10/21/22 0:00	0.7			1.5			2			0.43			0.21546			0.72		
10/21/22 1:00	0.7			1.4			2			0.41			0.20526			0.68		
10/21/22 2:00	0.6			1.5			2			0.36			0.17856			0.6		
10/21/22 3:00	0.7			1.5			2			0.38			0.1881			0.63		
10/21/22 4:00	0.7			1.4			2			0.41			0.20574			0.69		
10/21/22 5:00	0.7			1.5			1			0.53			0.26376			0.88		
10/21/22 6:00	1.1			1.5			2			0.57			0.28434			0.95		
10/21/22 7:00	1.4			1.5			2			0.57			0.2838			0.95		
10/21/22 8:00	0.6			1.5			3			0.35			0.17388			0.58		
10/21/22 9:00	0.5			1.5			3			0.34			0.16752			0.56		
10/21/22 10:00	0.5			1.5			3			0.33			0.16734			0.56		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/22 11:00	0.6			1.5			1			0.35			0.17436			0.58		
10/21/22 12:00	0.5			1.5			3			0.33			0.16728			0.56		
10/21/22 13:00	0.4			1.5			2			0.34			0.17022			0.57		
10/21/22 14:00	0.4			1.5			2			0.34			0.17154			0.57		
10/21/22 15:00	0.8			1.4			0			0.51			0.25314			0.84		
10/21/22 16:00	0.8			1.5			1			0.63			0.31548			1.05		
10/21/22 17:00	1			1.5			1			0.62			0.31122			1.04		
10/21/22 18:00	1.1			1.5			1			0.58			0.28794			0.96		
10/21/22 19:00	0.7			1.5			1			0.45			0.22704			0.76		
10/21/22 20:00	0.7			1.5			1			0.44			0.21828			0.73		
10/21/22 21:00	0.6			1.5			1			0.54			0.27012			0.9		
10/21/22 22:00	0.6			1.5			1			0.56			0.27918			0.93		
10/21/22 23:00	0.6			1.5			1			0.56			0.27918			0.93		
10/22/22 0:00	0.6			1.5			1			0.56			0.27864			0.93		
10/22/22 1:00	0.6			1.5			1			0.56			0.27942			0.93		
10/22/22 2:00	0.6			1.5			1			0.56			0.2793			0.93		
10/22/22 3:00	0.6			1.5			2			0.56			0.27954			0.93		
10/22/22 4:00	0.6			1.5			1			0.56			0.27882			0.93		
10/22/22 5:00	0.8			1.5			2			0.56			0.28152			0.94		
10/22/22 6:00	0.3			1.5			3			0.78			0.38868			1.3		
10/22/22 7:00	0.2			1.5			4			0.8			0.3996			1.33		
10/22/22 8:00	0.3			1.5			2			0.72			0.36222			1.21		
10/22/22 9:00	0.3			1.5			2			0.72			0.35802			1.19		
10/22/22 10:00	0.4			1.5			2			0.69			0.34434			1.15		
10/22/22 11:00	1			1.5			2			0.62			0.31056			1.04		
10/22/22 12:00	1.1			1.5			1			0.57			0.28584			0.95		
10/22/22 13:00	0.6			1.5			1			0.53			0.26748			0.89		
10/22/22 14:00	0.6			1.5			1			0.52			0.26094			0.87		
10/22/22 15:00	0.5			1.4			2			0.41			0.2061			0.69		
10/22/22 16:00	0.5			1.5			2			0.45			0.22692			0.76		
10/22/22 17:00	0.6			1.5			1			0.51			0.25746			0.86		
10/22/22 18:00	0.6			1.5			1			0.52			0.26016			0.87		
10/22/22 19:00	0.6			1.5			1			0.55			0.2763			0.92		
10/22/22 20:00	0.9			1.5			2			0.56			0.28152			0.94		
10/22/22 21:00	1.1			1.5			2			0.62			0.3117			1.04		
10/22/22 22:00	0.7			1.5			2			0.56			0.27834			0.93		
10/22/22 23:00	0.6			1.5			2			0.56			0.27804			0.93		
10/23/22 0:00	1			1.5			2			0.6			0.30138			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/22 1:00	0.9			1.5			2			0.57			0.28686			0.96		
10/23/22 2:00	0.6			1.5			1			0.56			0.27882			0.93		
10/23/22 3:00	0.7			1.5			2			0.56			0.2784			0.93		
10/23/22 4:00	0.6			1.5			2			0.56			0.27828			0.93		
10/23/22 5:00	0.6			1.5			2			0.56			0.27828			0.93		
10/23/22 6:00	0.6			1.5			2			0.56			0.27798			0.93		
10/23/22 7:00	1			1.5			2			0.57			0.28446			0.95		
10/23/22 8:00	1.1			1.5			2			0.61			0.30366			1.01		
10/23/22 9:00	0.8			1.5			2			0.52			0.25836			0.86		
10/23/22 10:00	0.6			1.5			2			0.48			0.23832			0.79		
10/23/22 11:00	1			1.5			2			0.62			0.30768			1.03		
10/23/22 12:00	0.7			1.5			2			0.53			0.26298			0.88		
10/23/22 13:00	0.6			1.5			2			0.42			0.21078			0.7		
10/23/22 14:00	0.6			1.5			2			0.43			0.2151			0.72		
10/23/22 15:00	0.5			1.5			3			0.36			0.1821			0.61		
10/23/22 16:00	0.5			1.5			2			0.45			0.22596			0.75		
10/23/22 17:00	0.6			1.5			1			0.54			0.27138			0.9		
10/23/22 18:00	0.6			1.5			1			0.55			0.2757			0.92		
10/23/22 19:00	0.6			1.5			1			0.56			0.27786			0.93		
10/23/22 20:00	1			1.5			2			0.6			0.29988			1		
10/23/22 21:00	0.9			1.5			2			0.6			0.29922			1		
10/23/22 22:00	0.7			1.5			2			0.48			0.24246			0.81		
10/23/22 23:00	0.6			1.5			2			0.56			0.27948			0.93		
10/24/22 0:00	0.6			1.5			2			0.55			0.27402			0.91		
10/24/22 1:00	0.6			1.5			2			0.53			0.26718			0.89		
10/24/22 2:00	0.6			1.5			2			0.56			0.2784			0.93		
10/24/22 3:00	0.7			1.5			2			0.56			0.2787			0.93		
10/24/22 4:00	0.6			1.5			2			0.55			0.27648			0.92		
10/24/22 5:00	0.9			1.5			2			0.56			0.27888			0.93		
10/24/22 6:00	0.6			1.5			3			0.71			0.35688			1.19		
10/24/22 7:00	1			1.5			3			0.66			0.32886			1.1		
10/24/22 8:00	1.2			1.5			2			0.59			0.29748			0.99		
10/24/22 9:00	1			1.5			2			0.6			0.30126			1		
10/24/22 10:00	1			1.5			2			0.59			0.29526			0.98		
10/24/22 11:00	0.7			1.5			1			0.52			0.25836			0.86		
10/24/22 12:00	0.4			1.5			3			0.34			0.17148			0.57		
10/24/22 13:00	0.4			1.5			4			0.34			0.168			0.56		
10/24/22 14:00	0.7			1.4			1			0.49			0.24342			0.81		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/22 15:00	1.5			1.5			1			0.59			0.29544			0.98		
10/24/22 16:00	0.7			1.5			2			0.66			0.33222			1.11		
10/24/22 17:00	1			1.5			2			0.64			0.31788			1.06		
10/24/22 18:00	1.4			1.5			1			0.59			0.29304			0.98		
10/24/22 19:00	1.2			1.5			2			0.61			0.30492			1.02		
10/24/22 20:00	1.1			1.5			2			0.59			0.2967			0.99		
10/24/22 21:00	0.7			1.5			2			0.45			0.22656			0.76		
10/24/22 22:00	0.6			1.4			3			0.37			0.18666			0.62		
10/24/22 23:00	0.6			1.5			2			0.4			0.19974			0.67		
10/25/22 0:00	0.6			1.5			3			0.35			0.17658			0.59		
10/25/22 1:00	0.6			1.5			3			0.35			0.17712			0.59		
10/25/22 2:00	0.6			1.5			3			0.35			0.17664			0.59		
10/25/22 3:00	0.6			1.5			3			0.36			0.18042			0.6		
10/25/22 4:00	0.7			1.5			1			0.5			0.25158			0.84		
10/25/22 5:00	0.7			1.5			2			0.54			0.27126			0.9		
10/25/22 6:00	1.3			1.5			2			0.64			0.31932			1.06		
10/25/22 7:00	1			1.5			2			0.6			0.30054			1		
10/25/22 8:00	0.8			1.5			1			0.46			0.2277			0.76		
10/25/22 9:00	0.7			1.5			2			0.43			0.21666			0.72		
10/25/22 10:00	0.5			1.5			4			0.34			0.17088			0.57		
10/25/22 11:00	0.5			1.5			2			0.35			0.17622			0.59		
10/25/22 12:00	0.6			1.5			1			0.44			0.21786			0.73		
10/25/22 13:00	0.9			1.5			1			0.61			0.30654			1.02		
10/25/22 14:00	0.6			1.5			1			0.66			0.32808			1.09		
10/25/22 15:00	0.6			1.5			1			0.66			0.32754			1.09		
10/25/22 16:00	0.4			1.5			1			0.69			0.3435			1.15		
10/25/22 17:00	0.5			1.5			1			0.67			0.33648			1.12		
10/25/22 18:00	0.8			1.5			1			0.64			0.31914			1.06		
10/25/22 19:00	0.9			1.5			1			0.64			0.31794			1.06		
10/25/22 20:00	0.9			1.5			1			0.65			0.32436			1.08		
10/25/22 21:00	1.1			1.5			1			0.59			0.2928			0.98		
10/25/22 22:00	0.6			1.5			2			0.36			0.1818			0.61		
10/25/22 23:00	0.7			1.5			1			0.39			0.19602			0.65		
10/26/22 0:00	0.6			1.5			1			0.35			0.17694			0.59		
10/26/22 1:00	0.6			1.5			1			0.35			0.17718			0.59		
10/26/22 2:00	0.6			1.5			1			0.36			0.1779			0.59		
10/26/22 3:00	0.7			1.6			1			0.46			0.2292			0.76		
10/26/22 4:00	0.7			1.5			1			0.5			0.25206			0.84		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/22 5:00	0.7			1.5			1			0.53			0.26436			0.88		
10/26/22 6:00	0.6			1.5			1			0.56			0.27762			0.93		
10/26/22 7:00	0.7			1.5			1			0.51			0.25308			0.84		
10/26/22 8:00	0.9			1.5			1			0.57			0.2859			0.95		
10/26/22 9:00	1			1.5			1			0.61			0.30714			1.02		
10/26/22 10:00	1			1.5			1			0.63			0.31296			1.04		
10/26/22 11:00	0.8			1.4			1			0.42			0.20916			0.7		
10/26/22 12:00	0.4			1.5			2			0.34			0.16944			0.56		
10/26/22 13:00	0.4			1.5			2			0.34			0.16872			0.56		
10/26/22 14:00	0.6			1.4			1			0.39			0.19734			0.66		
10/26/22 15:00	0.5			1.3			1			0.39			0.19386			0.65		
10/26/22 16:00	0.8			1.4			1			0.5			0.24828			0.83		
10/26/22 17:00	0.8			1.5			1			0.62			0.30984			1.03		
10/26/22 18:00	1.1			1.5			1			0.57			0.28632			0.95		
10/26/22 19:00	0.6			1.5			1			0.37			0.1866			0.62		
10/26/22 20:00	0.6			1.4			1			0.41			0.20592			0.69		
10/26/22 21:00	0.6			1.5			1			0.37			0.18588			0.62		
10/26/22 22:00	0.5			1.5			2			0.35			0.17592			0.59		
10/26/22 23:00	0.5			1.4			2			0.35			0.17694			0.59		
10/27/22 0:00	0.4			1.5			3			0.34			0.16938			0.56		
10/27/22 1:00	0.5			1.5			2			0.34			0.17238			0.57		
10/27/22 2:00	0.6			1.6			2			0.35			0.17472			0.58		
10/27/22 3:00	0.9			1.5			1			0.36			0.1818			0.61		
10/27/22 4:00	0.8			1.5			1			0.42			0.20952			0.7		
10/27/22 5:00	0.8			1.5			1			0.48			0.2394			0.8		
10/27/22 6:00	0.7			1.6			2			0.47			0.23322			0.78		
10/27/22 7:00	0.8			1.4			1			0.5			0.24906			0.83		
10/27/22 8:00	0.7			1.5			1			0.54			0.26916			0.9		
10/27/22 9:00	1.2			1.5			1			0.59			0.2925			0.98		
10/27/22 10:00	0.9			1.5			1			0.51			0.2544			0.85		
10/27/22 11:00	1			1.5			1			0.59			0.29538			0.98		
10/27/22 12:00	0.9			1.5			1			0.6			0.30048			1		
10/27/22 13:00	0.9			1.5			1			0.52			0.25932			0.86		
10/27/22 14:00	0.5			1.5			1			0.36			0.17982			0.6		
10/27/22 15:00	0.5			1.5			1			0.4			0.19944			0.66		
10/27/22 16:00	1			1.6			1			0.65			0.32622			1.09		
10/27/22 17:00	1			1.5			1			0.63			0.3156			1.05		
10/27/22 18:00	1.3			1.5			1			0.6			0.30066			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/22 19:00	1.4			1.5			1			0.61			0.30612			1.02		
10/27/22 20:00	1.3			1.5			1			0.63			0.3132			1.04		
10/27/22 21:00	1.2			1.5			1			0.63			0.31272			1.04		
10/27/22 22:00	1.6			1.5			1			0.58			0.29052			0.97		
10/27/22 23:00	0.7			1.5			1			0.51			0.2544			0.85		
10/28/22 0:00	0.7			1.5			1			0.5			0.25038			0.83		
10/28/22 1:00	0.7			1.5			1			0.48			0.23934			0.8		
10/28/22 2:00	0.7			1.6			1			0.5			0.24966			0.83		
10/28/22 3:00	1.3			1.6			1			0.54			0.27162			0.91		
10/28/22 4:00	1.1			1.5			1			0.64			0.32052			1.07		
10/28/22 5:00	1			1.5			1			0.66			0.33168			1.11		
10/28/22 6:00	1			1.5			1			0.65			0.3261			1.09		
10/28/22 7:00	1.3			1.5			1			0.58			0.29166			0.97		
10/28/22 8:00	0.8			1.5			1			0.5			0.25056			0.84		
10/28/22 9:00	0.6			1.5			1			0.53			0.267			0.89		
10/28/22 10:00	1.2			1.5			1			0.59			0.29748			0.99		
10/28/22 11:00	0.8			1.5			1			0.48			0.23838			0.79		
10/28/22 12:00	0.7			1.5			0			0.47			0.23514			0.78		
10/28/22 13:00	0.7			1.4			1			0.45			0.22506			0.75		
10/28/22 14:00	0.9			1.5			1			0.48			0.24138			0.8		
10/28/22 15:00	1.1			1.5			1			0.64			0.31926			1.06		
10/28/22 16:00	1.1			1.5			1			0.62			0.31236			1.04		
10/28/22 17:00	0.5			1.5			1			0.69			0.3471			1.16		
10/28/22 18:00	0.5			1.5			1			0.7			0.35028			1.17		
10/28/22 19:00	0.6			1.5			1			0.7			0.3495			1.17		
10/28/22 20:00	0.4			1.5			1			0.71			0.35412			1.18		
10/28/22 21:00	0.5			1.5			1			0.71			0.35526			1.18		
10/28/22 22:00	1.1			1.5			1			0.64			0.3207			1.07		
10/28/22 23:00	0.8			1.5			1			0.55			0.27648			0.92		
10/29/22 0:00	0.9			1.5			1			0.46			0.22974			0.77		
10/29/22 1:00	0.9			1.5			1			0.47			0.2346			0.78		
10/29/22 2:00	0.8			1.4			1			0.46			0.23244			0.77		
10/29/22 3:00	0.6			1.5			2			0.36			0.17856			0.6		
10/29/22 4:00	0.7			1.5			1			0.45			0.22416			0.75		
10/29/22 5:00	0.9			1.5			1			0.54			0.26838			0.89		
10/29/22 6:00	0.8			1.5			2			0.46			0.2298			0.77		
10/29/22 7:00	0.8			1.5			1			0.46			0.2289			0.76		
10/29/22 8:00	0.8			1.5			1			0.53			0.2652			0.88		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/22 9:00	0.7			1.5			1			0.48			0.2418			0.81		
10/29/22 10:00	0.7			1.5			1			0.5			0.24882			0.83		
10/29/22 11:00	0.7			1.5			1			0.44			0.22116			0.74		
10/29/22 12:00	0.5			1.5			1			0.36			0.17904			0.6		
10/29/22 13:00	0.6			1.4			1			0.38			0.1881			0.63		
10/29/22 14:00	0.6			1.4			1			0.38			0.1917			0.64		
10/29/22 15:00	0.6			1.4			1			0.39			0.1962			0.65		
10/29/22 16:00	0.6			1.5			1			0.45			0.22368			0.75		
10/29/22 17:00	0.7			1.5			1			0.46			0.23064			0.77		
10/29/22 18:00	0.7			1.5			1			0.45			0.2238			0.75		
10/29/22 19:00	0.7			1.5			1			0.38			0.18894			0.63		
10/29/22 20:00	1			1.6			1			0.57			0.2826			0.94		
10/29/22 21:00	1.4			1.5			1			0.6			0.2979			0.99		
10/29/22 22:00	0.8			1.5			1			0.51			0.2559			0.85		
10/29/22 23:00	0.7			1.5			1			0.55			0.27606			0.92		
10/30/22 0:00	0.7			1.5			1			0.53			0.26706			0.89		
10/30/22 1:00	0.7			1.5			1			0.5			0.2505			0.84		
10/30/22 2:00	0.7			1.5			1			0.52			0.2583			0.86		
10/30/22 3:00	0.8			1.5			1			0.52			0.25788			0.86		
10/30/22 4:00	0.8			1.5			1			0.53			0.26274			0.88		
10/30/22 5:00	0.7			1.5			1			0.57			0.28386			0.95		
10/30/22 6:00	0.7			1.5			1			0.55			0.27738			0.92		
10/30/22 7:00	0.8			1.4			3			0.36			0.1791			0.6		
10/30/22 8:00	0.5			1.2			2			0.34			0.17004			0.57		
10/30/22 9:00	0.5			1.2			2			0.34			0.1686			0.56		
10/30/22 10:00	0.5			1.2			2			0.34			0.16854			0.56		
10/30/22 11:00	0.4			1.2			2			0.34			0.16788			0.56		
10/30/22 12:00	0.5			1.4			1			0.34			0.1677			0.56		
10/30/22 13:00	0.5			1.5			1			0.34			0.16764			0.56		
10/30/22 14:00	0.5			1.5			1			0.34			0.16758			0.56		
10/30/22 15:00	0.5			1.4			1			0.37			0.18402			0.61		
10/30/22 16:00	0.6			1.5			0			0.52			0.26196			0.87		
10/30/22 17:00	0.9			1.5			1			0.54			0.27162			0.91		
10/30/22 18:00	1.7			1.5			1			0.58			0.29208			0.97		
10/30/22 19:00	0.8			1.5			1			0.52			0.25866			0.86		
10/30/22 20:00	0.8			1.5			1			0.51			0.25302			0.84		
10/30/22 21:00	0.7			1.5			1			0.51			0.2547			0.85		
10/30/22 22:00	0.8			1.5			1			0.49			0.24654			0.82		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/22 23:00	0.7			1.5			1			0.51			0.25602			0.85		
10/31/22 0:00	0.7			1.5			1			0.51			0.25572			0.85		
10/31/22 1:00	0.7			1.5			1			0.5			0.25194			0.84		
10/31/22 2:00	0.7			1.5			1			0.52			0.25806			0.86		
10/31/22 3:00	0.8			1.5			1			0.51			0.25458			0.85		
10/31/22 4:00	0.7			1.5			1			0.54			0.26982			0.9		
10/31/22 5:00	1			1.5			1			0.58			0.28944			0.96		
10/31/22 6:00	1.1			1.5			1			0.63			0.31518			1.05		
10/31/22 7:00	1			1.5			1			0.48			0.24246			0.81		
10/31/22 8:00	0.7			1.5			1			0.44			0.22026			0.73		
10/31/22 9:00	0.7			1.5			1			0.42			0.20934			0.7		
10/31/22 10:00	0.6			1.5			1			0.38			0.18798			0.63		
10/31/22 11:00	0.6			1.5			1			0.35			0.17598			0.59		
10/31/22 12:00	0.6			1.5			1			0.35			0.17598			0.59		
10/31/22 13:00	0.6			1.5			0			0.4			0.20238			0.67		
10/31/22 14:00	0.9			1.5			1			0.53			0.26532			0.88		
10/31/22 15:00	1.2			1.5			1			0.61			0.30414			1.01		
10/31/22 16:00	0.8			1.4			0			0.46			0.22788			0.76		
10/31/22 17:00	0.6			1.5			1			0.35			0.17502			0.58		
10/31/22 18:00	0.6			1.5			1			0.35			0.17394			0.58		
10/31/22 19:00	0.7			1.5			1			0.39			0.19428			0.65		
10/31/22 20:00	0.8			1.5			1			0.41			0.20352			0.68		
10/31/22 21:00	0.8			1.4			1			0.47			0.23358			0.78		
10/31/22 22:00	0.7			1.5			1			0.41			0.20508			0.68		
10/31/22 23:00	0.7			1.5			1			0.54			0.27054			0.9		
11/01/22 0:00	0.7			1.5			1			0.54			0.27168			0.91		
11/01/22 1:00	1			1.5			1			0.56			0.27768			0.93		
11/01/22 2:00	1			1.5			1			0.65			0.3228			1.08		
11/01/22 3:00	0.7			1.5			1			0.68			0.33786			1.13		
11/01/22 4:00	0.5			1.5			1			0.7			0.34962			1.17		
11/01/22 5:00	0.6			1.5			1			0.68			0.34032			1.13		
11/01/22 6:00	0.5			1.5			1			0.73			0.36498			1.22		
11/01/22 7:00	0.8			1.5			1			0.67			0.33708			1.12		
11/01/22 8:00	1			1.5			1			0.65			0.324			1.08		
11/01/22 9:00	1.2			1.5			1			0.61			0.30474			1.02		
11/01/22 10:00	1.2			1.5			1			0.61			0.30714			1.02		
11/01/22 11:00	0.9			1.5			1			0.65			0.32328			1.08		
11/01/22 12:00	0.7			1.5			1			0.67			0.33468			1.12		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/22 13:00	0.7			1.5			1			0.66			0.33192			1.11		
11/01/22 14:00	1.4			1.5			1			0.59			0.2973			0.99		
11/01/22 15:00	1.3			1.5			1			0.61			0.30282			1.01		
11/01/22 16:00	0.8			1.5			1			0.66			0.33162			1.11		
11/01/22 17:00	0.9			1.5			1			0.65			0.32448			1.08		
11/01/22 18:00	1.1			1.5			1			0.64			0.32028			1.07		
11/01/22 19:00	1.1			1.5			1			0.64			0.32184			1.07		
11/01/22 20:00	1.1			1.5			1			0.63			0.3174			1.06		
11/01/22 21:00	1.4			1.5			1			0.61			0.3045			1.02		
11/01/22 22:00	1.6			1.5			1			0.6			0.29892			1		
11/01/22 23:00	0.8			1.5			1			0.48			0.24006			0.8		
11/02/22 0:00	0.5			1.5			2			0.36			0.17784			0.59		
11/02/22 1:00	0.7			1.5			1			0.45			0.22734			0.76		
11/02/22 2:00	0.7			1.7			1			0.41			0.20334			0.68		
11/02/22 3:00	0.8			1.6			1			0.49			0.24504			0.82		
11/02/22 4:00	0.7			1.5			1			0.53			0.26652			0.89		
11/02/22 5:00	0.7			1.5			1			0.56			0.27912			0.93		
11/02/22 6:00	1.4			1.5			1			0.62			0.31212			1.04		
11/02/22 7:00	1			1.5			2			0.47			0.23436			0.78		
11/02/22 8:00	0.6			1.5			2			0.36			0.18156			0.61		
11/02/22 9:00	0.6			1.5			2			0.37			0.18486			0.62		
11/02/22 10:00	0.6			1.5			0			0.5			0.24822			0.83		
11/02/22 11:00	1.1			1.5			1			0.6			0.29784			0.99		
11/02/22 12:00	1.2			1.5			1			0.59			0.29736			0.99		
11/02/22 13:00	0.7			1.5			1			0.52			0.26202			0.87		
11/02/22 14:00	1.3			1.5			1			0.58			0.29034			0.97		
11/02/22 15:00	1.1			1.5			1			0.6			0.29868			1		
11/02/22 16:00	0.8			1.5			1			0.64			0.3216			1.07		
11/02/22 17:00	0.5			1.5			1			0.68			0.34158			1.14		
11/02/22 18:00	1.1			1.5			1			0.63			0.31374			1.05		
11/02/22 19:00	1.1			1.5			1			0.63			0.31314			1.04		
11/02/22 20:00	0.6			1.5			1			0.68			0.34044			1.13		
11/02/22 21:00	0.9			1.5			1			0.66			0.32952			1.1		
11/02/22 22:00	1.1			1.5			1			0.63			0.31686			1.06		
11/02/22 23:00	0.7			1.5			1			0.56			0.2793			0.93		
11/03/22 0:00	0.6			1.5			1			0.56			0.28134			0.94		
11/03/22 1:00	0.6			1.5			1			0.55			0.27546			0.92		
11/03/22 2:00	0.6			1.5			1			0.55			0.27426			0.91		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/22 3:00	0.7			1.5			1			0.56			0.28026			0.93		
11/03/22 4:00	1			1.5			1			0.57			0.28272			0.94		
11/03/22 5:00	0.5			1.5			2			0.74			0.36912			1.23		
11/03/22 6:00	0.3			1.5			2			0.77			0.38484			1.28		
11/03/22 7:00	1.1			1.5			1			0.58			0.2886			0.96		
11/03/22 8:00	0.7			1.5			1			0.53			0.26574			0.89		
11/03/22 9:00	1.6			1.5			1			0.59			0.29616			0.99		
11/03/22 10:00	1.2			1.7			1			0.61			0.30696			1.02		
11/03/22 11:00	0.7			1.4			1			0.47			0.23466			0.78		
11/03/22 12:00	0.5			1.5			2			0.35			0.17658			0.59		
11/03/22 13:00	0.5			1.5			2			0.35			0.17454			0.58		
11/03/22 14:00	0.5			1.5			2			0.34			0.16944			0.56		
11/03/22 15:00	0.5			1.5			2			0.35			0.17322			0.58		
11/03/22 16:00	0.6			1.5			1			0.5			0.25236			0.84		
11/03/22 17:00	0.9			1.5			1			0.64			0.31944			1.06		
11/03/22 18:00	1			1.5			1			0.63			0.31548			1.05		
11/03/22 19:00	1.1			1.5			1			0.63			0.31638			1.05		
11/03/22 20:00	0.5			1.5			1			0.7			0.34824			1.16		
11/03/22 21:00	0.4			1.5			2			0.71			0.35652			1.19		
11/03/22 22:00	0.9			1.5			1			0.65			0.3237			1.08		
11/03/22 23:00	1.3			1.5			1			0.59			0.29328			0.98		
11/04/22 0:00	0.8			1.5			1			0.54			0.26982			0.9		
11/04/22 1:00	0.7			1.5			1			0.53			0.26724			0.89		
11/04/22 2:00	0.8			1.6			1			0.49			0.24702			0.82		
11/04/22 3:00	0.7			1.5			1			0.51			0.25656			0.86		
11/04/22 4:00	0.7			1.5			1			0.55			0.27276			0.91		
11/04/22 5:00	1			1.5			1			0.66			0.3312			1.1		
11/04/22 6:00	0.8			1.5			1			0.67			0.33276			1.11		
11/04/22 7:00	0.9			1.5			2			0.47			0.23268			0.78		
11/04/22 8:00	0.6			1.4			2			0.36			0.17862			0.6		
11/04/22 9:00	0.6			1.5			2			0.36			0.18204			0.61		
11/04/22 10:00	0.5			1.5			2			0.35			0.1731			0.58		
11/04/22 11:00	0.5			1.5			3			0.33			0.16716			0.56		
11/04/22 12:00	0.5			1.5			1			0.34			0.17226			0.57		
11/04/22 13:00	0.5			1.5			2			0.34			0.1683			0.56		
11/04/22 14:00	0.5			1.5			2			0.34			0.1677			0.56		
11/04/22 15:00	0.6			1.4			1			0.4			0.20226			0.67		
11/04/22 16:00	0.6			1.5			1			0.42			0.21084			0.7		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/22 17:00	0.7			1.5			1			0.52			0.25962			0.87		
11/04/22 18:00	1.1			1.5			1			0.61			0.30732			1.02		
11/04/22 19:00	1.2			1.5			1			0.62			0.30756			1.03		
11/04/22 20:00	1.3			1.5			1			0.59			0.29568			0.99		
11/04/22 21:00	0.7			1.5			2			0.36			0.18036			0.6		
11/04/22 22:00	0.5			1.5			3			0.33			0.1674			0.56		
11/04/22 23:00	0.7			1.4			1			0.39			0.19356			0.65		
11/05/22 0:00	0.6			1.5			2			0.35			0.17334			0.58		
11/05/22 1:00	0.6			1.5			2			0.35			0.17346			0.58		
11/05/22 2:00	0.6			1.5			2			0.35			0.17322			0.58		
11/05/22 3:00	0.6			1.5			2			0.35			0.17256			0.58		
11/05/22 4:00	0.6			1.5			2			0.35			0.1734			0.58		
11/05/22 5:00	0.6			1.4			1			0.38			0.19038			0.63		
11/05/22 6:00	0.6			1.4			2			0.35			0.17292			0.58		
11/05/22 7:00	0.7			1.5			1			0.42			0.21162			0.71		
11/05/22 8:00	0.5			1.5			3			0.34			0.1692			0.56		
11/05/22 9:00	0.6			1.5			1			0.34			0.17166			0.57		
11/05/22 10:00	0.6			1.5			1			0.36			0.1794			0.6		
11/05/22 11:00	0.7			1.4			1			0.38			0.18774			0.63		
11/05/22 12:00	0.6			1.5			1			0.46			0.23052			0.77		
11/05/22 13:00	0.7			1.5			1			0.41			0.20442			0.68		
11/05/22 14:00	0.7			1.5			1			0.51			0.25482			0.85		
11/05/22 15:00	0.6			1.5			2			0.35			0.17292			0.58		
11/05/22 16:00	0.6			1.5			1			0.42			0.20916			0.7		
11/05/22 17:00	1			1.5			1			0.52			0.25782			0.86		
11/05/22 18:00	1.4			1.5			1			0.58			0.29124			0.97		
11/05/22 19:00	1.3			1.5			1			0.57			0.28638			0.95		
11/05/22 20:00	0.7			1.5			1			0.4			0.1992			0.66		
11/05/22 21:00	0.6			1.5			1			0.36			0.1794			0.6		
11/05/22 22:00	0.6			1.5			1			0.35			0.17316			0.58		
11/05/22 23:00	0.7			1.5			1			0.5			0.24924			0.83		
11/06/22 0:00	0.7			1.5			1			0.49			0.24486			0.82		
11/06/22 1:00	0.8			1.5			1			0.43			0.21372			0.71		
11/06/22 2:00	0.7			1.9			1			0.44			0.22062			0.74		
11/06/22 3:00	0.7			1.5			1			0.52			0.258			0.86		
11/06/22 4:00	0.7			1.5			1			0.51			0.25686			0.86		
11/06/22 5:00	0.6			1.5			1			0.55			0.27324			0.91		
11/06/22 6:00	0.6			1.5			1			0.55			0.27684			0.92		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/22 7:00	0.7			1.5			1			0.55			0.27612			0.92		
11/06/22 8:00	1.3			1.5			1			0.6			0.30192			1.01		
11/06/22 9:00	1.2			1.5			1			0.57			0.28482			0.95		
11/06/22 10:00	0.6			1.5			1			0.37			0.18696			0.62		
11/06/22 11:00	0.6			1.5			1			0.35			0.1767			0.59		
11/06/22 12:00	0.6			1.5			1			0.34			0.17076			0.57		
11/06/22 13:00	0.6			1.5			1			0.35			0.17598			0.59		
11/06/22 14:00	0.6			1.5			1			0.42			0.20934			0.7		
11/06/22 15:00	1.1			1.5			1			0.58			0.29106			0.97		
11/06/22 16:00	0.8			1.5			1			0.66			0.32814			1.09		
11/06/22 17:00	1.1			1.5			1			0.61			0.30726			1.02		
11/06/22 18:00	1.2			1.5			1			0.59			0.29538			0.98		
11/06/22 19:00	1.3			1.5			1			0.58			0.29232			0.97		
11/06/22 20:00	1.2			1.5			1			0.59			0.294			0.98		
11/06/22 21:00	1.2			1.5			1			0.59			0.29616			0.99		
11/06/22 22:00	0.9			1.5			1			0.46			0.22824			0.76		
11/06/22 23:00	0.5			1.5			1			0.35			0.17544			0.58		
11/07/22 0:00	0.7			1.4			1			0.39			0.19692			0.66		
11/07/22 1:00	0.7			1.5			1			0.44			0.2196			0.73		
11/07/22 2:00	0.7			1.7			1			0.47			0.23442			0.78		
11/07/22 3:00	0.8			1.5			2			0.44			0.22044			0.73		
11/07/22 4:00	0.7			1.4			1			0.42			0.2082			0.69		
11/07/22 5:00	0.7			1.5			1			0.51			0.25464			0.85		
11/07/22 6:00	0.7			1.5			1			0.55			0.27438			0.91		
11/07/22 7:00	0.8			1.5			1			0.49			0.24396			0.81		
11/07/22 8:00	0.6			1.5			2			0.35			0.17442			0.58		
11/07/22 9:00	0.6			1.5			2			0.35			0.174			0.58		
11/07/22 10:00	0.6			1.5			2			0.35			0.17262			0.58		
11/07/22 11:00	0.6			1.5			2			0.34			0.1713			0.57		
11/07/22 12:00	0.6			1.5			1			0.35			0.17262			0.58		
11/07/22 13:00	0.6			1.5			1			0.35			0.17328			0.58		
11/07/22 14:00	0.7			1.4			1			0.45			0.22314			0.74		
11/07/22 15:00	0.8			1.5			1			0.56			0.28092			0.94		
11/07/22 16:00	0.9			1.5			1			0.64			0.318			1.06		
11/07/22 17:00	1			1.5			1			0.63			0.31674			1.06		
11/07/22 18:00	1.1			1.5			1			0.63			0.31386			1.05		
11/07/22 19:00	1			1.5			1			0.64			0.31812			1.06		
11/07/22 20:00	0.9			1.5			1			0.64			0.31872			1.06		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 21:00	0.9			1.5			1			0.64			0.32088			1.07		
11/07/22 22:00	1.2			1.5			1			0.6			0.30228			1.01		
11/07/22 23:00	0.9			1.5			1			0.47			0.23658			0.79		
11/08/22 0:00	0.6			1.5			2			0.37			0.18372			0.61		
11/08/22 1:00	0.6			1.5			2			0.34			0.16938			0.56		
11/08/22 2:00	0.5			1.5			2			0.34			0.16998			0.57		
11/08/22 3:00	0.6			1.5			2			0.34			0.16998			0.57		
11/08/22 4:00	1			1.5			1			0.47			0.23436			0.78		
11/08/22 5:00	1.5			1.5			1			0.58			0.29088			0.97		
11/08/22 6:00	0.9			1.5			1			0.64			0.31794			1.06		
11/08/22 7:00	1.3			1.5			1			0.59			0.29598			0.99		
11/08/22 8:00	1.2			1.5			1			0.61			0.30276			1.01		
11/08/22 9:00	0.8			1.5			2			0.66			0.33042			1.1		
11/08/22 10:00	1.1			1.5			1			0.61			0.30732			1.02		
11/08/22 11:00	1.3			1.5			1			0.59			0.29622			0.99		
11/08/22 12:00	1.3			1.5			1			0.59			0.29652			0.99		
11/08/22 13:00	0.7			1.5			2			0.4			0.19776			0.66		
11/08/22 14:00	0.5			1.5			2			0.34			0.17166			0.57		
11/08/22 15:00	0.9			1.5			1			0.48			0.23838			0.79		
11/08/22 16:00	1.3			1.5			1			0.59			0.29394			0.98		
11/08/22 17:00	1.1			1.5			1			0.6			0.2982			0.99		
11/08/22 18:00	1.3			1.5			1			0.59			0.29496			0.98		
11/08/22 19:00	1.5			1.5			1			0.59			0.294			0.98		
11/08/22 20:00	1.4			1.5			1			0.59			0.29358			0.98		
11/08/22 21:00	1.4			1.5			1			0.59			0.29358			0.98		
11/08/22 22:00	2			1.5			1			0.59			0.29262			0.98		
11/08/22 23:00	1.4			1.5			1			0.59			0.29256			0.98		
11/09/22 0:00	1.4			1.5			1			0.59			0.29286			0.98		
11/09/22 1:00	1.4			1.5			1			0.59			0.29328			0.98		
11/09/22 2:00	1.4			1.5			1			0.59			0.29352			0.98		
11/09/22 3:00	1.5			1.5			1			0.59			0.29364			0.98		
11/09/22 4:00	1.4			1.5			1			0.59			0.29388			0.98		
11/09/22 5:00	1.4			1.5			1			0.59			0.29412			0.98		
11/09/22 6:00	1.4			1.5			1			0.59			0.29472			0.98		
11/09/22 7:00	1.4			1.5			1			0.59			0.2946			0.98		
11/09/22 8:00	1.4			1.5			1			0.59			0.29406			0.98		
11/09/22 9:00	1.1			1.5			1			0.52			0.26238			0.87		
11/09/22 10:00	0.6			1.5			2			0.34			0.17142			0.57		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 11:00	0.6			1.5			2			0.35			0.17256			0.58		
11/09/22 12:00	0.6			1.5			2			0.34			0.17214			0.57		
11/09/22 13:00	0.6			1.5			2			0.34			0.17214			0.57		
11/09/22 14:00	0.5			1.5			2			0.34			0.17172			0.57		
11/09/22 15:00	0.5			1.5			2			0.34			0.171			0.57		
11/09/22 16:00	1.1			1.5			1			0.47			0.23466			0.78		
11/09/22 17:00	1.6			1.5			1			0.56			0.27852			0.93		
11/09/22 18:00	1.4			1.5			1			0.57			0.28686			0.96		
11/09/22 19:00	1.7			1.5			1			0.59			0.29484			0.98		
11/09/22 20:00	1.4			1.5			1			0.54			0.2688			0.9		
11/09/22 21:00	0.7			1.5			2			0.38			0.19044			0.63		
11/09/22 22:00	0.5			1.6			3			0.34			0.17184			0.57		
11/09/22 23:00	0.6			1.5			2			0.35			0.1749			0.58		
11/10/22 0:00	0.6			1.5			2			0.36			0.17832			0.59		
11/10/22 1:00	0.6			1.6			3			0.35			0.17424			0.58		
11/10/22 2:00	0.5			1.5			2			0.35			0.17424			0.58		
11/10/22 3:00	0.8			1.5			1			0.4			0.19986			0.67		
11/10/22 4:00	0.8			1.5			1			0.48			0.24096			0.8		
11/10/22 5:00	1			1.5			1			0.53			0.26448			0.88		
11/10/22 6:00	0.6			1.5			2			0.71			0.3561			1.19		
11/10/22 7:00	1.4			1.5			1			0.61			0.30366			1.01		
11/10/22 8:00	0.7			1.6			2			0.4			0.20046			0.67		
11/10/22 9:00	0.8			1.4			1			0.44			0.21798			0.73		
11/10/22 10:00	0.4			1.6			3			0.33			0.16662			0.56		
11/10/22 11:00	0.4			1.5			3			0.33			0.16734			0.56		
11/10/22 12:00	0.5			1.5			2			0.33			0.16728			0.56		
11/10/22 13:00	0.5			1.5			2			0.33			0.1671			0.56		
11/10/22 14:00	0.5			1.5			2			0.33			0.1671			0.56		
11/10/22 15:00	0.7			1.4			1			0.44			0.22194			0.74		
11/10/22 16:00	0.8			1.5			1			0.67			0.33348			1.11		
11/10/22 17:00	0.7			1.5			1			0.67			0.33312			1.11		
11/10/22 18:00	1			1.5			1			0.64			0.31758			1.06		
11/10/22 19:00	1.2			1.5			1			0.62			0.31182			1.04		
11/10/22 20:00	1.1			1.5			1			0.63			0.31686			1.06		
11/10/22 21:00	0.8			1.5			1			0.67			0.33426			1.11		
11/10/22 22:00	1			1.5			1			0.65			0.32466			1.08		
11/10/22 23:00	1.3			1.5			1			0.62			0.30942			1.03		
11/11/22 0:00	0.8			1.5			1			0.67			0.33684			1.12		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/22 1:00	0.9			1.5			1			0.66			0.32826			1.09		
11/11/22 2:00	1.3			1.5			1			0.59			0.29544			0.98		
11/11/22 3:00	0.8			1.5			1			0.53			0.2646			0.88		
11/11/22 4:00	0.9			1.5			1			0.56			0.28188			0.94		
11/11/22 5:00	0.9			1.5			2			0.68			0.33834			1.13		
11/11/22 6:00	0.7			1.5			2			0.68			0.34146			1.14		
11/11/22 7:00	1.3			1.5			1			0.58			0.2913			0.97		
11/11/22 8:00	0.6			1.5			3			0.35			0.17454			0.58		
11/11/22 9:00	0.6			1.5			2			0.35			0.17388			0.58		
11/11/22 10:00	0.6			1.5			2			0.35			0.1761			0.59		
11/11/22 11:00	0.6			1.5			2			0.35			0.17376			0.58		
11/11/22 12:00	0.6			1.5			2			0.35			0.17334			0.58		
11/11/22 13:00	0.6			1.5			2			0.35			0.17358			0.58		
11/11/22 14:00	0.6			1.5			1			0.36			0.17754			0.59		
11/11/22 15:00	0.8			1.5			1			0.54			0.2676			0.89		
11/11/22 16:00	0.9			1.5			1			0.65			0.32478			1.08		
11/11/22 17:00	1.1			1.5			1			0.63			0.31302			1.04		
11/11/22 18:00	1.2			1.5			1			0.63			0.31272			1.04		
11/11/22 19:00	1.1			1.5			1			0.62			0.31194			1.04		
11/11/22 20:00	1.2			1.5			1			0.63			0.31494			1.05		
11/11/22 21:00	0.8			1.5			1			0.67			0.33564			1.12		
11/11/22 22:00	0.9			1.5			1			0.66			0.33078			1.1		
11/11/22 23:00	1.1			1.5			1			0.63			0.31608			1.05		
11/12/22 0:00	0.8			1.5			1			0.67			0.33348			1.11		
11/12/22 1:00	0.8			1.5			1			0.67			0.33342			1.11		
11/12/22 2:00	0.8			1.5			1			0.67			0.33546			1.12		
11/12/22 3:00	0.6			1.5			2			0.69			0.34674			1.16		
11/12/22 4:00	0.6			1.5			1			0.69			0.34344			1.14		
11/12/22 5:00	0.6			1.5			1			0.68			0.34128			1.14		
11/12/22 6:00	0.6			1.5			2			0.68			0.34152			1.14		
11/12/22 7:00	1.4			1.5			1			0.6			0.30108			1		
11/12/22 8:00	0.6			1.5			2			0.69			0.34692			1.16		
11/12/22 9:00	1			1.5			1			0.64			0.32076			1.07		
11/12/22 10:00	1.2			1.5			1			0.61			0.30732			1.02		
11/12/22 11:00	1			1.5			1			0.57			0.28368			0.95		
11/12/22 12:00	0.7			1.5			1			0.55			0.27648			0.92		
11/12/22 13:00	0.7			1.5			1			0.55			0.27318			0.91		
11/12/22 14:00	0.9			1.5			1			0.59			0.2934			0.98		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/22 15:00	1.1			1.5			1			0.61			0.30732			1.02		
11/12/22 16:00	0.9			1.5			1			0.64			0.32016			1.07		
11/12/22 17:00	1			1.5			1			0.64			0.31842			1.06		
11/12/22 18:00	1.1			1.5			1			0.62			0.31062			1.04		
11/12/22 19:00	1.1			1.5			1			0.65			0.32352			1.08		
11/12/22 20:00	1.3			1.5			1			0.63			0.3129			1.04		
11/12/22 21:00	1			1.5			1			0.63			0.31668			1.06		
11/12/22 22:00	0.9			1.5			1			0.64			0.32196			1.07		
11/12/22 23:00	1.2			1.5			1			0.62			0.30948			1.03		
11/13/22 0:00	0.8			1.5			1			0.55			0.27558			0.92		
11/13/22 1:00	0.7			1.5			1			0.54			0.26892			0.9		
11/13/22 2:00	0.7			1.6			1			0.53			0.26664			0.89		
11/13/22 3:00	0.8			1.5			1			0.56			0.27906			0.93		
11/13/22 4:00	0.7			1.5			1			0.56			0.27792			0.93		
11/13/22 5:00	0.7			1.5			1			0.56			0.27798			0.93		
11/13/22 6:00	0.9			1.5			1			0.57			0.28302			0.94		
11/13/22 7:00	1.1			1.5			1			0.63			0.31518			1.05		
11/13/22 8:00	1			1.5			1			0.57			0.28266			0.94		
11/13/22 9:00	0.9			1.5			1			0.65			0.32448			1.08		
11/13/22 10:00	0.7			1.5			1			0.55			0.27726			0.92		
11/13/22 11:00	0.6			1.5			1			0.55			0.27282			0.91		
11/13/22 12:00	0.6			1.5			1			0.53			0.26712			0.89		
11/13/22 13:00	0.7			1.5			1			0.52			0.26064			0.87		
11/13/22 14:00	0.7			1.5			1			0.48			0.24078			0.8		
11/13/22 15:00	0.7			1.5			1			0.47			0.2346			0.78		
11/13/22 16:00	0.7			1.5			1			0.66			0.33042			1.1		
11/13/22 17:00	0.6			1.5			1			0.67			0.33702			1.12		
11/13/22 18:00	0.6			1.5			1			0.67			0.33456			1.12		
11/13/22 19:00	0.9			1.5			1			0.64			0.3219			1.07		
11/13/22 20:00	1.1			1.5			1			0.63			0.31368			1.05		
11/13/22 21:00	0.7			1.5			2			0.67			0.3372			1.12		
11/13/22 22:00	0.8			1.5			1			0.66			0.33168			1.11		
11/13/22 23:00	0.9			1.5			1			0.65			0.32724			1.09		
11/14/22 0:00	1.1			1.5			1			0.6			0.30168			1.01		
11/14/22 1:00	0.7			1.5			1			0.55			0.27738			0.92		
11/14/22 2:00	0.7			1.5			1			0.55			0.2769			0.92		
11/14/22 3:00	0.8			1.5			1			0.53			0.2625			0.88		
11/14/22 4:00	0.7			1.5			1			0.54			0.27036			0.9		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/22 5:00	1			1.5			2			0.66			0.33186			1.11		
11/14/22 6:00	0.3			1.5			2			0.78			0.39198			1.31		
11/14/22 7:00	0.6			1.5			2			0.72			0.35778			1.19		
11/14/22 8:00	1.1			1.5			1			0.64			0.3189			1.06		
11/14/22 9:00	1.1			1.5			1			0.6			0.30102			1		
11/14/22 10:00	0.7			1.5			1			0.54			0.26922			0.9		
11/14/22 11:00	0.7			1.5			1			0.49			0.24552			0.82		
11/14/22 12:00	0.7			1.5			1			0.45			0.22386			0.75		
11/14/22 13:00	0.7			1.5			1			0.49			0.24546			0.82		
11/14/22 14:00	0.7			1.5			1			0.52			0.26214			0.87		
11/14/22 15:00	0.8			1.5			1			0.56			0.28176			0.94		
11/14/22 16:00	0.6			1.5			1			0.68			0.34056			1.14		
11/14/22 17:00	0.4			1.5			1			0.7			0.3489			1.16		
11/14/22 18:00	0.6			1.5			1			0.68			0.34176			1.14		
11/14/22 19:00	0.8			1.5			2			0.67			0.33432			1.11		
11/14/22 20:00	0.6			1.5			2			0.69			0.34668			1.16		
11/14/22 21:00	0.7			1.5			2			0.68			0.34218			1.14		
11/14/22 22:00	0.7			1.5			2			0.68			0.34194			1.14		
11/14/22 23:00	1			1.5			1			0.65			0.32532			1.08		
11/15/22 0:00	0.7			1.5			2			0.7			0.35004			1.17		
11/15/22 1:00	0.6			1.5			2			0.7			0.35166			1.17		
11/15/22 2:00	0.5			1.4			2			0.71			0.354			1.18		
11/15/22 3:00	0.7			1.5			2			0.7			0.34896			1.16		
11/15/22 4:00	0.6			1.5			2			0.71			0.35382			1.18		
11/15/22 5:00	0.6			1.5			2			0.71			0.35448			1.18		
11/15/22 6:00	0.5			1.5			2			0.72			0.36102			1.2		
11/15/22 7:00	0.6			1.5			2			0.71			0.35328			1.18		
11/15/22 8:00	1.1			1.5			1			0.65			0.32304			1.08		
11/15/22 9:00	1			1.5			1			0.53			0.26484			0.88		
11/15/22 10:00	0.7			1.5			1			0.44			0.22212			0.74		
11/15/22 11:00	0.7			1.5			1			0.39			0.19722			0.66		
11/15/22 12:00	0.6			1.5			2			0.34			0.17184			0.57		
11/15/22 13:00	0.6			1.5			2			0.34			0.17076			0.57		
11/15/22 14:00	0.6			1.5			1			0.34			0.17202			0.57		
11/15/22 15:00	0.7			1.5			1			0.45			0.22518			0.75		
11/15/22 16:00	0.6			1.5			1			0.66			0.33138			1.1		
11/15/22 17:00	0.5			1.5			1			0.68			0.3408			1.14		
11/15/22 18:00	0.4			1.5			1			0.69			0.34638			1.15		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/22 19:00	0.6			1.5			1			0.67			0.33594			1.12		
11/15/22 20:00	0.8			1.5			1			0.66			0.32892			1.1		
11/15/22 21:00	0.7			1.5			1			0.67			0.33306			1.11		
11/15/22 22:00	1.1			1.5			1			0.62			0.30996			1.03		
11/15/22 23:00	1.1			1.5			1			0.63			0.31296			1.04		
11/16/22 0:00	1.1			1.5			1			0.64			0.31908			1.06		
11/16/22 1:00	1.1			1.5			1			0.64			0.3201			1.07		
11/16/22 2:00	1.1			1.5			1			0.64			0.3186			1.06		
11/16/22 3:00	1.2			1.5			1			0.64			0.31872			1.06		
11/16/22 4:00	0.9			1.5			2			0.67			0.3354			1.12		
11/16/22 5:00	0.8			1.5			2			0.68			0.3408			1.14		
11/16/22 6:00	0.6			1.5			2			0.71			0.35604			1.19		
11/16/22 7:00	0.8			1.5			2			0.68			0.34134			1.14		
11/16/22 8:00	1.3			1.5			1			0.54			0.26862			0.9		
11/16/22 9:00	0.8			1.5			1			0.49			0.24252			0.81		
11/16/22 10:00	0.7			1.4			2			0.38			0.19044			0.63		
11/16/22 11:00	0.6			1.4			1			0.35			0.17736			0.59		
11/16/22 12:00	0.7			1.5			1			0.46			0.23226			0.77		
11/16/22 13:00	0.8			1.5			1			0.43			0.21726			0.72		
11/16/22 14:00	0.5			1.5			2			0.34			0.17028			0.57		
11/16/22 15:00	0.6			1.5			1			0.48			0.24036			0.8		
11/16/22 16:00	1			1.5			1			0.56			0.2799			0.93		
11/16/22 17:00	1.3			1.5			1			0.58			0.28914			0.96		
11/16/22 18:00	0.5			1.5			1			0.7			0.3507			1.17		
11/16/22 19:00	0.5			1.5			2			0.7			0.34986			1.17		
11/16/22 20:00	1.4			1.5			1			0.6			0.30168			1.01		
11/16/22 21:00	0.6			1.5			2			0.71			0.35268			1.18		
11/16/22 22:00	0.7			1.5			2			0.69			0.34302			1.14		
11/16/22 23:00	0.9			1.5			1			0.66			0.32838			1.09		
11/17/22 0:00	0.8			1.5			1			0.55			0.2766			0.92		
11/17/22 1:00	0.7			1.5			1			0.55			0.27744			0.92		
11/17/22 2:00	0.7			1.5			1			0.55			0.27318			0.91		
11/17/22 3:00	0.8			1.5			1			0.55			0.27372			0.91		
11/17/22 4:00	0.7			1.5			1			0.55			0.27666			0.92		
11/17/22 5:00	0.8			1.5			1			0.55			0.27684			0.92		
11/17/22 6:00	1			1.5			1			0.56			0.28242			0.94		
11/17/22 7:00	1.3			1.5			1			0.63			0.31332			1.04		
11/17/22 8:00	0.8			1.5			2			0.4			0.20112			0.67		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/22 9:00	0.8			1.4			1			0.53			0.26688			0.89		
11/17/22 10:00	1.2			1.5			1			0.63			0.3168			1.06		
11/17/22 11:00	0.9			1.5			1			0.55			0.27534			0.92		
11/17/22 12:00	0.7			1.5			1			0.56			0.27858			0.93		
11/17/22 13:00	1			1.5			1			0.63			0.31422			1.05		
11/17/22 14:00	1.1			1.5			1			0.61			0.30564			1.02		
11/17/22 15:00	0.8			1.5			1			0.65			0.32502			1.08		
11/17/22 16:00	0.6			1.5			1			0.67			0.33444			1.11		
11/17/22 17:00	0.5			1.5			1			0.69			0.34518			1.15		
11/17/22 18:00	0.5			1.5			1			0.69			0.34578			1.15		
11/17/22 19:00	0.6			1.5			2			0.7			0.34758			1.16		
11/17/22 20:00	0.9			1.5			2			0.68			0.3384			1.13		
11/17/22 21:00	1.1			1.5			1			0.65			0.32658			1.09		
11/17/22 22:00	1.3			1.5			1			0.64			0.32178			1.07		
11/17/22 23:00	1.3			1.5			1			0.64			0.31782			1.06		
11/18/22 0:00	0.9			1.5			2			0.68			0.33768			1.13		
11/18/22 1:00	1			1.5			1			0.65			0.32748			1.09		
11/18/22 2:00	1.1			1.6			2			0.66			0.33084			1.1		
11/18/22 3:00	0.8			1.5			2			0.69			0.345			1.15		
11/18/22 4:00	0.7			1.5			2			0.7			0.3495			1.17		
11/18/22 5:00	0.6			1.5			2			0.72			0.36168			1.21		
11/18/22 6:00	0.3			1.5			2			0.8			0.40116			1.34		
11/18/22 7:00	0.6			1.5			2			0.72			0.3576			1.19		
11/18/22 8:00	0.7			1.5			2			0.69			0.3432			1.14		
11/18/22 9:00	0.9			1.5			1			0.66			0.33084			1.1		
11/18/22 10:00	1			1.5			1			0.64			0.32106			1.07		
11/18/22 11:00	1			1.5			1			0.63			0.31482			1.05		
11/18/22 12:00	1.1			1.5			1			0.62			0.30774			1.03		
11/18/22 13:00	1			1.5			1			0.62			0.30966			1.03		
11/18/22 14:00	1			1.5			1			0.62			0.31074			1.04		
11/18/22 15:00	0.8			1.5			1			0.65			0.32274			1.08		
11/18/22 16:00	0.4			1.5			2			0.7			0.35232			1.17		
11/18/22 17:00	0.3			1.5			2			0.72			0.36246			1.21		
11/18/22 18:00	0.4			1.5			2			0.72			0.36036			1.2		
11/18/22 19:00	0.4			1.5			2			0.7			0.3516			1.17		
11/18/22 20:00	0.4			1.5			2			0.72			0.3582			1.19		
11/18/22 21:00	0.4			1.5			2			0.72			0.35814			1.19		
11/18/22 22:00	0.5			1.5			2			0.7			0.35238			1.17		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/22 23:00	0.6			1.5			2			0.68			0.34242			1.14		
11/19/22 0:00	1			1.5			1			0.65			0.32406			1.08		
11/19/22 1:00	1.1			1.5			1			0.65			0.32304			1.08		
11/19/22 2:00	1.1			1.5			1			0.64			0.3207			1.07		
11/19/22 3:00	1.2			1.5			1			0.63			0.31404			1.05		
11/19/22 4:00	1			1.5			2			0.66			0.33246			1.11		
11/19/22 5:00	0.7			1.5			2			0.69			0.3447			1.15		
11/19/22 6:00	0.6			1.5			2			0.71			0.3549			1.18		
11/19/22 7:00	0.8			1.5			2			0.7			0.34956			1.17		
11/19/22 8:00	0.9			1.5			2			0.47			0.23436			0.78		
11/19/22 9:00	0.6			1.5			2			0.35			0.17256			0.58		
11/19/22 10:00	0.6			1.5			2			0.35			0.17508			0.58		
11/19/22 11:00	0.6			1.5			2			0.35			0.17532			0.58		
11/19/22 12:00	0.6			1.5			2			0.35			0.17526			0.58		
11/19/22 13:00	0.6			1.5			2			0.35			0.17508			0.58		
11/19/22 14:00	0.5			1.5			2			0.34			0.17046			0.57		
11/19/22 15:00	0.6			1.5			1			0.41			0.20736			0.69		
11/19/22 16:00	0.7			1.5			1			0.67			0.33384			1.11		
11/19/22 17:00	0.8			1.5			1			0.65			0.3261			1.09		
11/19/22 18:00	0.9			1.5			1			0.65			0.32598			1.09		
11/19/22 19:00	0.6			1.5			2			0.69			0.34566			1.15		
11/19/22 20:00	0.5			1.5			2			0.71			0.35478			1.18		
11/19/22 21:00	0.5			1.5			2			0.71			0.35358			1.18		
11/19/22 22:00	0.5			1.5			2			0.71			0.35508			1.18		
11/19/22 23:00	0.6			1.5			2			0.72			0.35784			1.19		
11/20/22 0:00	0.6			1.5			2			0.71			0.35748			1.19		
11/20/22 1:00	0.6			1.5			2			0.72			0.35952			1.2		
11/20/22 2:00	0.7			1.5			2			0.72			0.35976			1.2		
11/20/22 3:00	0.7			1.5			2			0.72			0.3594			1.2		
11/20/22 4:00	0.6			1.5			2			0.72			0.35934			1.2		
11/20/22 5:00	0.7			1.5			2			0.71			0.3537			1.18		
11/20/22 6:00	0.8			1.5			2			0.69			0.34554			1.15		
11/20/22 7:00	1.1			1.5			2			0.65			0.32352			1.08		
11/20/22 8:00	1.1			1.5			1			0.56			0.2802			0.93		
11/20/22 9:00	0.8			1.5			1			0.58			0.28914			0.96		
11/20/22 10:00	1.3			1.5			1			0.59			0.2928			0.98		
11/20/22 11:00	1.2			1.5			1			0.58			0.29076			0.97		
11/20/22 12:00	0.8			1.5			1			0.54			0.27054			0.9		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/22 13:00	1			1.5			1			0.62			0.30972			1.03		
11/20/22 14:00	0.8			1.5			1			0.53			0.2664			0.89		
11/20/22 15:00	0.8			1.5			1			0.5			0.24978			0.83		
11/20/22 16:00	0.7			1.5			1			0.66			0.32964			1.1		
11/20/22 17:00	0.8			1.5			1			0.66			0.32814			1.09		
11/20/22 18:00	1			1.5			1			0.64			0.32214			1.07		
11/20/22 19:00	1.1			1.5			1			0.64			0.3216			1.07		
11/20/22 20:00	1.2			1.5			1			0.64			0.32046			1.07		
11/20/22 21:00	1.3			1.5			1			0.63			0.31314			1.04		
11/20/22 22:00	1.3			1.5			1			0.62			0.31146			1.04		
11/20/22 23:00	1.4			1.5			1			0.61			0.30678			1.02		
11/21/22 0:00	1.3			1.5			1			0.64			0.32136			1.07		
11/21/22 1:00	1.5			1.5			1			0.63			0.3126			1.04		
11/21/22 2:00	1.5			1.5			1			0.62			0.31164			1.04		
11/21/22 3:00	1.4			1.5			1			0.64			0.32118			1.07		
11/21/22 4:00	1			1.5			2			0.68			0.3423			1.14		
11/21/22 5:00	1.2			1.5			2			0.68			0.34134			1.14		
11/21/22 6:00	0.6			1.5			2			0.71			0.3546			1.18		
11/21/22 7:00	1.3			1.5			2			0.63			0.31404			1.05		
11/21/22 8:00	1			1.5			2			0.41			0.20376			0.68		
11/21/22 9:00	0.6			1.5			2			0.35			0.1734			0.58		
11/21/22 10:00	0.6			1.5			2			0.35			0.17424			0.58		
11/21/22 11:00	0.6			1.5			2			0.35			0.17562			0.59		
11/21/22 12:00	0.6			1.4			2			0.36			0.17988			0.6		
11/21/22 13:00	0.6			1.5			2			0.35			0.17418			0.58		
11/21/22 14:00	0.8			1.5			0			0.51			0.25722			0.86		
11/21/22 15:00	0.7			1.5			1			0.65			0.32304			1.08		
11/21/22 16:00	0.8			1.5			1			0.66			0.32796			1.09		
11/21/22 17:00	0.8			1.5			1			0.65			0.327			1.09		
11/21/22 18:00	0.9			1.5			1			0.65			0.32328			1.08		
11/21/22 19:00	1			1.5			1			0.65			0.32406			1.08		
11/21/22 20:00	1			1.5			1			0.65			0.32682			1.09		
11/21/22 21:00	1			1.5			2			0.67			0.33402			1.11		
11/21/22 22:00	1			1.5			2			0.66			0.32874			1.1		
11/21/22 23:00	1.3			1.5			1			0.63			0.31314			1.04		
11/22/22 0:00	0.9			1.5			1			0.57			0.2829			0.94		
11/22/22 1:00	0.8			1.5			1			0.56			0.27906			0.93		
11/22/22 2:00	0.9			1.6			1			0.55			0.27714			0.92		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/22 3:00	1			1.5			1			0.52			0.26208			0.87		
11/22/22 4:00	0.9			1.5			1			0.54			0.26784			0.89		
11/22/22 5:00	0.8			1.5			1			0.55			0.27366			0.91		
11/22/22 6:00	0.7			1.5			1			0.57			0.28554			0.95		
11/22/22 7:00	0.8			1.5			2			0.42			0.21048			0.7		
11/22/22 8:00	1.2			1.5			1			0.5			0.2478			0.83		
11/22/22 9:00	1.1			1.5			1			0.65			0.3228			1.08		
11/22/22 10:00	0.9			1.5			1			0.56			0.28188			0.94		
11/22/22 11:00	1.1			1.5			1			0.61			0.30612			1.02		
11/22/22 12:00	0.8			1.5			1			0.66			0.32754			1.09		
11/22/22 13:00	0.7			1.5			1			0.66			0.33066			1.1		
11/22/22 14:00	0.8			1.5			1			0.65			0.32316			1.08		
11/22/22 15:00	1			1.5			1			0.63			0.31398			1.05		
11/22/22 16:00	1			1.5			1			0.63			0.31398			1.05		
11/22/22 17:00	1.2			1.5			1			0.61			0.3048			1.02		
11/22/22 18:00	1.3			1.5			1			0.61			0.30294			1.01		
11/22/22 19:00	1.3			1.5			1			0.6			0.30204			1.01		
11/22/22 20:00	1.3			1.5			1			0.62			0.3078			1.03		
11/22/22 21:00	1.3			1.5			1			0.54			0.27222			0.91		
11/22/22 22:00	1.1			1.5			2			0.42			0.20928			0.7		
11/22/22 23:00	0.7			1.5			2			0.36			0.1803			0.6		
11/23/22 0:00	1			1.5			1			0.48			0.23898			0.8		
11/23/22 1:00	0.9			1.5			1			0.43			0.21732			0.72		
11/23/22 2:00	0.9			1.7			1			0.47			0.23304			0.78		
11/23/22 3:00	0.9			1.5			1			0.48			0.24108			0.8		
11/23/22 4:00	0.9			1.5			1			0.5			0.24792			0.83		
11/23/22 5:00	0.8			1.5			1			0.53			0.264			0.88		
11/23/22 6:00	0.8			1.5			1			0.53			0.26538			0.88		
11/23/22 7:00	0.9			1.5			2			0.43			0.21342			0.71		
11/23/22 8:00	0.7			1.5			3			0.37			0.18312			0.61		
11/23/22 9:00	0.7			1.4			1			0.4			0.19776			0.66		
11/23/22 10:00	0.7			1.4			1			0.41			0.20724			0.69		
11/23/22 11:00	1.1			1.5			1			0.54			0.27084			0.9		
11/23/22 12:00	1.2			1.5			1			0.61			0.30696			1.02		
11/23/22 13:00	1			1.5			1			0.54			0.2682			0.89		
11/23/22 14:00	0.6			1.5			2			0.35			0.1731			0.58		
11/23/22 15:00	0.7			1.5			1			0.41			0.20682			0.69		
11/23/22 16:00	0.8			1.5			1			0.64			0.3219			1.07		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/22 17:00	0.9			1.5			1			0.64			0.31992			1.07		
11/23/22 18:00	1.3			1.5			1			0.61			0.30468			1.02		
11/23/22 19:00	1.3			1.5			1			0.6			0.30246			1.01		
11/23/22 20:00	1.3			1.5			1			0.62			0.3102			1.03		
11/23/22 21:00	1.1			1.5			1			0.65			0.3228			1.08		
11/23/22 22:00	1.2			1.5			1			0.64			0.32226			1.07		
11/23/22 23:00	1.4			1.5			1			0.63			0.31362			1.05		
11/24/22 0:00	1.3			1.5			1			0.64			0.32004			1.07		
11/24/22 1:00	1.4			1.5			1			0.63			0.31404			1.05		
11/24/22 2:00	1			1.3			1			0.52			0.26094			0.87		
11/24/22 3:00	0.9			1.5			1			0.53			0.26532			0.88		
11/24/22 4:00	0.8			1.5			1			0.53			0.26556			0.89		
11/24/22 5:00	1			1.5			1			0.56			0.27852			0.93		
11/24/22 6:00	1			1.5			1			0.57			0.28584			0.95		
11/24/22 7:00	1.2			1.5			2			0.65			0.32424			1.08		
11/24/22 8:00	1.2			1.5			1			0.64			0.31788			1.06		
11/24/22 9:00	1			1.5			1			0.64			0.32166			1.07		
11/24/22 10:00	0.9			1.5			1			0.65			0.3234			1.08		
11/24/22 11:00	1.2			1.5			1			0.62			0.30882			1.03		
11/24/22 12:00	1.1			1.5			1			0.62			0.30924			1.03		
11/24/22 13:00	1.1			1.5			1			0.62			0.309			1.03		
11/24/22 14:00	0.8			1.5			1			0.4			0.20154			0.67		
11/24/22 15:00	0.8			1.5			1			0.45			0.22506			0.75		
11/24/22 16:00	0.8			1.5			1			0.65			0.32442			1.08		
11/24/22 17:00	1.1			1.5			1			0.62			0.3108			1.04		
11/24/22 18:00	1.3			1.5			1			0.61			0.30522			1.02		
11/24/22 19:00	1.3			1.5			1			0.61			0.3039			1.01		
11/24/22 20:00	1.3			1.5			1			0.61			0.30354			1.01		
11/24/22 21:00	1.3			1.5			1			0.61			0.3027			1.01		
11/24/22 22:00	1.4			1.5			1			0.61			0.30618			1.02		
11/24/22 23:00	1.5			1.5			1			0.6			0.29988			1		
11/25/22 0:00	1.4			1.5			1			0.6			0.29928			1		
11/25/22 1:00	1.5			1.5			1			0.6			0.29814			0.99		
11/25/22 2:00	1.5			1.5			1			0.6			0.2982			0.99		
11/25/22 3:00	1.4			1.5			1			0.61			0.30426			1.01		
11/25/22 4:00	1.3			1.5			1			0.63			0.31368			1.05		
11/25/22 5:00	1.4			1.5			1			0.63			0.31566			1.05		
11/25/22 6:00	1.2			1.5			1			0.64			0.32202			1.07		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/22 7:00	1.4			1.5			1			0.62			0.31134			1.04		
11/25/22 8:00	1.6			1.5			1			0.6			0.29874			1		
11/25/22 9:00	0.8			1.5			2			0.4			0.20112			0.67		
11/25/22 10:00	0.6			1.5			2			0.34			0.17088			0.57		
11/25/22 11:00	0.6			1.5			2			0.33			0.16734			0.56		
11/25/22 12:00	0.6			1.5			2			0.33			0.1671			0.56		
11/25/22 13:00	0.6			1.5			2			0.34			0.16776			0.56		
11/25/22 14:00	0.6			1.5			1			0.34			0.1707			0.57		
11/25/22 15:00	0.7			1.5			1			0.42			0.20838			0.69		
11/25/22 16:00	1			1.5			1			0.63			0.31398			1.05		
11/25/22 17:00	1			1.5			1			0.63			0.3144			1.05		
11/25/22 18:00	1.2			1.5			1			0.61			0.30462			1.02		
11/25/22 19:00	1.3			1.5			1			0.6			0.30216			1.01		
11/25/22 20:00	1.4			1.5			1			0.6			0.30138			1		
11/25/22 21:00	1.4			1.5			1			0.6			0.30234			1.01		
11/25/22 22:00	1.2			1.5			1			0.63			0.31434			1.05		
11/25/22 23:00	1.3			1.5			1			0.62			0.30954			1.03		
11/26/22 0:00	1.2			1.5			1			0.65			0.32274			1.08		
11/26/22 1:00	1.4			1.5			1			0.64			0.321			1.07		
11/26/22 2:00	1.3			1.5			1			0.64			0.32166			1.07		
11/26/22 3:00	1.2			1.5			1			0.65			0.32286			1.08		
11/26/22 4:00	1.2			1.5			1			0.65			0.32298			1.08		
11/26/22 5:00	0.8			1.5			2			0.69			0.34368			1.15		
11/26/22 6:00	0.6			1.5			2			0.71			0.35268			1.18		
11/26/22 7:00	1.2			1.5			1			0.65			0.32286			1.08		
11/26/22 8:00	1.3			1.5			1			0.56			0.2823			0.94		
11/26/22 9:00	1.2			1.5			1			0.63			0.31458			1.05		
11/26/22 10:00	0.9			1.5			1			0.47			0.2358			0.79		
11/26/22 11:00	0.6			1.5			2			0.34			0.1713			0.57		
11/26/22 12:00	0.6			1.5			2			0.35			0.1725			0.58		
11/26/22 13:00	0.6			1.5			2			0.33			0.16662			0.56		
11/26/22 14:00	0.6			1.5			1			0.34			0.1692			0.56		
11/26/22 15:00	0.7			1.5			1			0.44			0.22206			0.74		
11/26/22 16:00	0.9			1.5			1			0.62			0.30792			1.03		
11/26/22 17:00	1.1			1.5			1			0.62			0.31248			1.04		
11/26/22 18:00	1.2			1.5			1			0.61			0.30582			1.02		
11/26/22 19:00	1.3			1.5			1			0.61			0.30336			1.01		
11/26/22 20:00	1.1			1.5			1			0.63			0.31482			1.05		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/22 21:00	1.1			1.5			1			0.64			0.31824			1.06		
11/26/22 22:00	1.3			1.5			1			0.61			0.3036			1.01		
11/26/22 23:00	1.3			1.5			1			0.61			0.30576			1.02		
11/27/22 0:00	1			1.5			1			0.65			0.32592			1.09		
11/27/22 1:00	1.2			1.5			1			0.63			0.31614			1.05		
11/27/22 2:00	1.5			1.5			1			0.61			0.3054			1.02		
11/27/22 3:00	1.2			1.5			1			0.64			0.32142			1.07		
11/27/22 4:00	1.1			1.5			1			0.65			0.3234			1.08		
11/27/22 5:00	1.3			1.5			1			0.62			0.31026			1.03		
11/27/22 6:00	1.2			1.5			1			0.64			0.32082			1.07		
11/27/22 7:00	1.2			1.5			2			0.54			0.26994			0.9		
11/27/22 8:00	0.7			1.5			2			0.34			0.1719			0.57		
11/27/22 9:00	0.6			1.5			2			0.34			0.17022			0.57		
11/27/22 10:00	0.6			1.5			1			0.35			0.17382			0.58		
11/27/22 11:00	0.6			1.5			2			0.34			0.1707			0.57		
11/27/22 12:00	0.6			1.5			2			0.33			0.16686			0.56		
11/27/22 13:00	0.6			1.5			2			0.33			0.16698			0.56		
11/27/22 14:00	0.6			1.5			2			0.33			0.16686			0.56		
11/27/22 15:00	0.9			1.4			1			0.5			0.2475			0.83		
11/27/22 16:00	1			1.5			1			0.63			0.31572			1.05		
11/27/22 17:00	0.8			1.5			1			0.65			0.32442			1.08		
11/27/22 18:00	1			1.5			1			0.65			0.32262			1.08		
11/27/22 19:00	1.1			1.5			1			0.64			0.31914			1.06		
11/27/22 20:00	1.2			1.5			1			0.62			0.31236			1.04		
11/27/22 21:00	0.9			1.5			1			0.66			0.33144			1.1		
11/27/22 22:00	1.2			1.5			1			0.61			0.30624			1.02		
11/27/22 23:00	1.3			1.5			1			0.6			0.30204			1.01		
11/28/22 0:00	1.2			1.5			1			0.63			0.31278			1.04		
11/28/22 1:00	1.4			1.5			1			0.61			0.30648			1.02		
11/28/22 2:00	1.7			1.5			1			0.6			0.2994			1		
11/28/22 3:00	1.5			1.5			1			0.6			0.30162			1.01		
11/28/22 4:00	1.5			1.5			1			0.6			0.29904			1		
11/28/22 5:00	1.4			1.5			1			0.62			0.30798			1.03		
11/28/22 6:00	1			1.5			1			0.67			0.3357			1.12		
11/28/22 7:00	0.9			1.5			2			0.68			0.33936			1.13		
11/28/22 8:00	1.4			1.5			1			0.6			0.3015			1.01		
11/28/22 9:00	1			1.5			2			0.46			0.2322			0.77		
11/28/22 10:00	0.6			1.5			2			0.35			0.17448			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/22 11:00	0.7			1.5			2			0.34			0.1704			0.57		
11/28/22 12:00	0.7			1.5			2			0.33			0.16644			0.55		
11/28/22 13:00	0.6			1.5			2			0.33			0.16704			0.56		
11/28/22 14:00	0.6			1.5			2			0.34			0.16812			0.56		
11/28/22 15:00	0.7			1.5			1			0.45			0.2256			0.75		
11/28/22 16:00	1.1			1.5			1			0.63			0.31458			1.05		
11/28/22 17:00	1.2			1.5			1			0.62			0.3123			1.04		
11/28/22 18:00	1.4			1.5			1			0.61			0.30336			1.01		
11/28/22 19:00	1.3			1.5			1			0.61			0.30348			1.01		
11/28/22 20:00	1.1			1.5			1			0.63			0.31314			1.04		
11/28/22 21:00	0.9			1.5			1			0.66			0.33204			1.11		
11/28/22 22:00	1.3			1.5			1			0.62			0.30864			1.03		
11/28/22 23:00	1.6			1.5			1			0.6			0.29892			1		
11/29/22 0:00	0.9			1.5			1			0.56			0.27936			0.93		
11/29/22 1:00	0.9			1.5			1			0.57			0.28326			0.94		
11/29/22 2:00	0.8			1.5			1			0.57			0.28326			0.94		
11/29/22 3:00	0.9			1.5			1			0.54			0.27			0.9		
11/29/22 4:00	0.8			1.5			1			0.55			0.27312			0.91		
11/29/22 5:00	0.8			1.5			1			0.57			0.28626			0.95		
11/29/22 6:00	1			1.5			1			0.58			0.28944			0.96		
11/29/22 7:00	0.4			1.5			2			0.77			0.38658			1.29		
11/29/22 8:00	0.7			1.5			1			0.59			0.29406			0.98		
11/29/22 9:00	0.8			1.5			1			0.55			0.27594			0.92		
11/29/22 10:00	0.7			1.5			1			0.55			0.27606			0.92		
11/29/22 11:00	0.8			1.5			1			0.55			0.27732			0.92		
11/29/22 12:00	0.8			1.4			1			0.46			0.2301			0.77		
11/29/22 13:00	0.7			1.5			1			0.55			0.27492			0.92		
11/29/22 14:00	0.5			1.3			2			0.71			0.35586			1.19		
11/29/22 15:00	0.3			1.3			2			0.71			0.35448			1.18		
11/29/22 16:00	0.3			1.3			2			0.72			0.3603			1.2		
11/29/22 17:00	0.5			1.3			2			0.71			0.35598			1.19		
11/29/22 18:00	0.4			1.3			2			0.71			0.35526			1.18		
11/29/22 19:00	0.4			1.3			2			0.71			0.35712			1.19		
11/29/22 20:00	0.4			1.3			2			0.72			0.35994			1.2		
11/29/22 21:00	0.4			1.3			2			0.72			0.35754			1.19		
11/29/22 22:00	0.5			1.3			2			0.7			0.35184			1.17		
11/29/22 23:00	0.8			1.4			1			0.67			0.3333			1.11		
11/30/22 0:00	0.7			1.5			1			0.57			0.28356			0.95		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/22 1:00	0.6			1.5			1			0.57			0.28476			0.95		
11/30/22 2:00	0.7			1.5			1			0.57			0.28518			0.95		
11/30/22 3:00	0.7			1.5			1			0.57			0.28476			0.95		
11/30/22 4:00	0.7			1.5			1			0.57			0.28446			0.95		
11/30/22 5:00	1			1.5			1			0.57			0.28716			0.96		
11/30/22 6:00	0.5			1.5			2			0.72			0.36066			1.2		
11/30/22 7:00	1.2			1.5			1			0.62			0.31194			1.04		
11/30/22 8:00	0.9			1.5			2			0.46			0.23124			0.77		
11/30/22 9:00	0.7			1.4			1			0.42			0.2106			0.7		
11/30/22 10:00	0.6			1.5			2			0.35			0.17436			0.58		
11/30/22 11:00	0.5			1.5			2			0.34			0.16878			0.56		
11/30/22 12:00	0.5			1.5			2			0.34			0.16818			0.56		
11/30/22 13:00	0.5			1.5			2			0.34			0.16908			0.56		
11/30/22 14:00	0.7			1.4			0			0.47			0.23586			0.79		
11/30/22 15:00	0.8			1.5			1			0.49			0.24552			0.82		
11/30/22 16:00	0.7			1.5			1			0.65			0.32502			1.08		
11/30/22 17:00	0.7			1.5			1			0.65			0.32598			1.09		
11/30/22 18:00	0.8			1.5			1			0.65			0.32424			1.08		
11/30/22 19:00	0.8			1.5			1			0.65			0.32484			1.08		
11/30/22 20:00	0.9			1.5			1			0.64			0.3216			1.07		
11/30/22 21:00	1			1.5			1			0.64			0.31812			1.06		
11/30/22 22:00	1.1			1.5			1			0.59			0.29268			0.98		
11/30/22 23:00	0.6			1.5			2			0.37			0.18498			0.62		
12/01/22 0:00	0.7			1.5			1			0.49			0.24318			0.81		
12/01/22 1:00	0.7			1.5			1			0.48			0.24198			0.81		
12/01/22 2:00	0.7			1.6			1			0.5			0.25044			0.83		
12/01/22 3:00	0.8			1.5			1			0.51			0.2526			0.84		
12/01/22 4:00	1			1.5			1			0.54			0.2697			0.9		
12/01/22 5:00	0.9			1.5			1			0.65			0.32376			1.08		
12/01/22 6:00	0.7			1.5			1			0.66			0.32778			1.09		
12/01/22 7:00	1.2			1.5			1			0.61			0.3066			1.02		
12/01/22 8:00	0.5			1.5			1			0.69			0.34344			1.14		
12/01/22 9:00	0.3			1.5			2			0.74			0.36798			1.23		
12/01/22 10:00	0.5			1.5			1			0.7			0.34794			1.16		
12/01/22 11:00	0.5			1.5			1			0.68			0.34236			1.14		
12/01/22 12:00	0.7			1.5			1			0.68			0.33864			1.13		
12/01/22 13:00	0.5			1.5			1			0.7			0.3513			1.17		
12/01/22 14:00	0.5			1.5			1			0.7			0.35208			1.17		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/22 15:00	0.8			1.5			1			0.65			0.32346			1.08		
12/01/22 16:00	1.1			1.5			1			0.62			0.30834			1.03		
12/01/22 17:00	1.1			1.5			1			0.63			0.31266			1.04		
12/01/22 18:00	1.2			1.5			1			0.61			0.30318			1.01		
12/01/22 19:00	1.2			1.5			1			0.62			0.30942			1.03		
12/01/22 20:00	1.3			1.5			1			0.61			0.30258			1.01		
12/01/22 21:00	1.3			1.5			1			0.6			0.30066			1		
12/01/22 22:00	1.4			1.5			1			0.6			0.3024			1.01		
12/01/22 23:00	1.4			1.5			1			0.6			0.29862			1		
12/02/22 0:00	1.3			1.5			1			0.6			0.29784			0.99		
12/02/22 1:00	1.3			1.5			1			0.59			0.29706			0.99		
12/02/22 2:00	1.3			1.5			1			0.6			0.29928			1		
12/02/22 3:00	1.2			1.5			1			0.62			0.30828			1.03		
12/02/22 4:00	1.2			1.5			1			0.61			0.30564			1.02		
12/02/22 5:00	1.2			1.5			1			0.62			0.31188			1.04		
12/02/22 6:00	1.1			1.5			1			0.66			0.32808			1.09		
12/02/22 7:00	0.4			1.5			2			0.72			0.36108			1.2		
12/02/22 8:00	0.9			1.5			1			0.65			0.3273			1.09		
12/02/22 9:00	1			1.5			1			0.65			0.327			1.09		
12/02/22 10:00	0.9			1.5			1			0.66			0.33024			1.1		
12/02/22 11:00	0.9			1.5			1			0.65			0.32682			1.09		
12/02/22 12:00	0.9			1.5			1			0.66			0.3285			1.1		
12/02/22 13:00	0.4			1.5			1			0.7			0.35028			1.17		
12/02/22 14:00	0.4			1.5			2			0.72			0.36078			1.2		
12/02/22 15:00	0.4			1.5			1			0.72			0.35802			1.19		
12/02/22 16:00	0.5			1.5			1			0.7			0.35052			1.17		
12/02/22 17:00	0.4			1.5			2			0.71			0.35658			1.19		
12/02/22 18:00	0.4			1.5			2			0.71			0.35358			1.18		
12/02/22 19:00	0.5			1.5			2			0.71			0.3567			1.19		
12/02/22 20:00	0.4			1.5			2			0.74			0.36876			1.23		
12/02/22 21:00	0.5			1.5			2			0.71			0.35376			1.18		
12/02/22 22:00	0.5			1.5			2			0.7			0.35058			1.17		
12/02/22 23:00	1			1.5			1			0.65			0.32598			1.09		
12/03/22 0:00	1.1			1.5			1			0.66			0.32754			1.09		
12/03/22 1:00	1.1			1.5			1			0.65			0.32328			1.08		
12/03/22 2:00	1.1			1.4			1			0.64			0.32034			1.07		
12/03/22 3:00	1.1			1.5			1			0.65			0.3252			1.08		
12/03/22 4:00	0.9			1.5			1			0.66			0.33222			1.11		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 5:00	0.8			1.5			1			0.68			0.33768			1.13		
12/03/22 6:00	0.8			1.5			2			0.68			0.34098			1.14		
12/03/22 7:00	0.4			1.5			2			0.74			0.3705			1.24		
12/03/22 8:00	0.5			1.5			2			0.71			0.35538			1.18		
12/03/22 9:00	0.5			1.5			2			0.71			0.35448			1.18		
12/03/22 10:00	0.7			1.5			1			0.68			0.34098			1.14		
12/03/22 11:00	1			1.5			1			0.65			0.32376			1.08		
12/03/22 12:00	1			1.5			1			0.65			0.3228			1.08		
12/03/22 13:00	1			1.5			1			0.65			0.32292			1.08		
12/03/22 14:00	0.9			1.5			1			0.66			0.32862			1.1		
12/03/22 15:00	0.6			1.5			1			0.69			0.34284			1.14		
12/03/22 16:00	0.7			1.5			1			0.67			0.3369			1.12		
12/03/22 17:00	0.9			1.5			2			0.57			0.28482			0.95		
12/03/22 18:00	0.5			1.5			3			0.34			0.16902			0.56		
12/03/22 19:00	0.7			1.4			1			0.49			0.24618			0.82		
12/03/22 20:00	0.7			1.5			1			0.55			0.27258			0.91		
12/03/22 21:00	0.7			1.5			1			0.55			0.27426			0.91		
12/03/22 22:00	0.6			1.5			1			0.55			0.27672			0.92		
12/03/22 23:00	0.6			1.5			1			0.56			0.27996			0.93		
12/04/22 0:00	1.4			1.5			1			0.59			0.29622			0.99		
12/04/22 1:00	1.4			1.5			1			0.6			0.29832			0.99		
12/04/22 2:00	1.3			1.5			1			0.6			0.3015			1.01		
12/04/22 3:00	1.2			1.5			1			0.6			0.30216			1.01		
12/04/22 4:00	1.2			1.5			1			0.61			0.30504			1.02		
12/04/22 5:00	1.1			1.5			1			0.62			0.31104			1.04		
12/04/22 6:00	1.3			1.5			1			0.6			0.30156			1.01		
12/04/22 7:00	1.3			1.5			1			0.61			0.303			1.01		
12/04/22 8:00	1.1			1.5			1			0.62			0.3117			1.04		
12/04/22 9:00	1.3			1.5			1			0.6			0.29946			1		
12/04/22 10:00	1.2			1.5			1			0.6			0.2997			1		
12/04/22 11:00	1.2			1.5			1			0.6			0.29976			1		
12/04/22 12:00	1.3			1.5			1			0.59			0.29718			0.99		
12/04/22 13:00	1.1			1.5			1			0.6			0.29838			0.99		
12/04/22 14:00	0.7			1.5			1			0.56			0.2781			0.93		
12/04/22 15:00	0.7			1.5			1			0.56			0.27954			0.93		
12/04/22 16:00	0.7			1.5			1			0.56			0.27966			0.93		
12/04/22 17:00	0.7			1.5			1			0.56			0.27972			0.93		
12/04/22 18:00	0.6			1.5			1			0.56			0.27978			0.93		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/22 19:00	0.6			1.5			1			0.56			0.27978			0.93		
12/04/22 20:00	0.7			1.5			1			0.56			0.28014			0.93		
12/04/22 21:00	0.6			1.5			1			0.56			0.28014			0.93		
12/04/22 22:00	0.7			1.5			1			0.56			0.28008			0.93		
12/04/22 23:00	0.7			1.5			1			0.56			0.28002			0.93		
12/05/22 0:00	0.7			1.5			1			0.56			0.27984			0.93		
12/05/22 1:00	0.7			1.5			1			0.56			0.27984			0.93		
12/05/22 2:00	0.6			1.5			1			0.56			0.27978			0.93		
12/05/22 3:00	0.7			1.5			1			0.56			0.27984			0.93		
12/05/22 4:00	0.6			1.5			1			0.56			0.27972			0.93		
12/05/22 5:00	0.6			1.5			1			0.56			0.27954			0.93		
12/05/22 6:00	0.8			1.5			1			0.57			0.28344			0.94		
12/05/22 7:00	1.2			1.5			1			0.59			0.294			0.98		
12/05/22 8:00	0.7			1.5			1			0.56			0.2808			0.94		
12/05/22 9:00	0.7			1.5			1			0.56			0.28056			0.94		
12/05/22 10:00	0.6			1.5			2			0.44			0.21804			0.73		
12/05/22 11:00	0.5			1.4			2			0.33			0.16734			0.56		
12/05/22 12:00	0.5			1.4			2			0.33			0.16692			0.56		
12/05/22 13:00	0.5			1.4			2			0.33			0.16656			0.56		
12/05/22 14:00	0.6			1.3			2			0.36			0.17856			0.6		
12/05/22 15:00	0.6			1.4			1			0.36			0.18126			0.6		
12/05/22 16:00	0.7			1.3			1			0.4			0.19926			0.66		
12/05/22 17:00	0.7			1.4			1			0.42			0.21024			0.7		
12/05/22 18:00	0.7			1.4			1			0.44			0.22158			0.74		
12/05/22 19:00	0.9			1.5			1			0.65			0.32412			1.08		
12/05/22 20:00	0.9			1.5			1			0.64			0.32238			1.07		
12/05/22 21:00	1.1			1.5			1			0.62			0.30882			1.03		
12/05/22 22:00	1.2			1.5			1			0.54			0.27006			0.9		
12/05/22 23:00	0.7			1.4			2			0.39			0.19416			0.65		
12/06/22 0:00	0.9			1.5			1			0.45			0.22398			0.75		
12/06/22 1:00	0			0			0	X		0.11			0.0534			0.18		
12/06/22 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/22 15:00	0			0			0	X		0.31			0.15288			0.51		
12/06/22 16:00	1.1			1.6			1			0.52			0.2592			0.86		
12/06/22 17:00	0.8			1.5			1			0.66			0.32874			1.1		
12/06/22 18:00	1			1.5			1			0.65			0.32652			1.09		
12/06/22 19:00	0.9			1.5			1			0.65			0.32712			1.09		
12/06/22 20:00	0.9			1.5			1			0.65			0.32604			1.09		
12/06/22 21:00	1			1.5			1			0.65			0.32304			1.08		
12/06/22 22:00	1.3			1.5			1			0.62			0.30828			1.03		
12/06/22 23:00	1.4			1.5			1			0.6			0.30132			1		
12/07/22 0:00	0.7			1.5			1			0.54			0.26886			0.9		
12/07/22 1:00	0.8			1.5			1			0.52			0.25836			0.86		
12/07/22 2:00	0.8			1.5			1			0.53			0.26694			0.89		
12/07/22 3:00	0.8			1.5			1			0.53			0.26604			0.89		
12/07/22 4:00	1.2			1.5			1			0.57			0.28542			0.95		
12/07/22 5:00	1			1.5			1			0.66			0.33018			1.1		
12/07/22 6:00	0.9			1.5			1			0.67			0.3333			1.11		
12/07/22 7:00	1.3			1.5			1			0.61			0.30408			1.01		
12/07/22 8:00	1.4			1.5			1			0.6			0.30078			1		
12/07/22 9:00	1.2			1.5			1			0.62			0.31182			1.04		
12/07/22 10:00	1.1			1.5			1			0.62			0.30828			1.03		
12/07/22 11:00	1			1.5			1			0.61			0.3054			1.02		
12/07/22 12:00	0.9			1.5			1			0.55			0.2748			0.92		
12/07/22 13:00	0.5			1.5			2			0.35			0.1749			0.58		
12/07/22 14:00	0.6			1.4			1			0.39			0.19716			0.66		
12/07/22 15:00	1.1			1.5			1			0.62			0.31008			1.03		
12/07/22 16:00	1.1			1.5			1			0.61			0.3057			1.02		
12/07/22 17:00	1.1			1.5			1			0.61			0.30468			1.02		
12/07/22 18:00	1.1			1.5			1			0.61			0.30408			1.01		
12/07/22 19:00	1.1			1.5			1			0.63			0.31722			1.06		
12/07/22 20:00	0.8			1.5			1			0.68			0.33876			1.13		
12/07/22 21:00	0.8			1.5			1			0.67			0.33504			1.12		
12/07/22 22:00	1.3			1.5			1			0.62			0.30978			1.03		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/22 23:00	1.5			1.5			1			0.61			0.30276			1.01		
12/08/22 0:00	1.2			1.5			1			0.64			0.31866			1.06		
12/08/22 1:00	1.3			1.5			1			0.62			0.31038			1.03		
12/08/22 2:00	1.3			1.5			1			0.62			0.30804			1.03		
12/08/22 3:00	1.2			1.5			1			0.62			0.30882			1.03		
12/08/22 4:00	1.1			1.5			1			0.64			0.31872			1.06		
12/08/22 5:00	1			1.5			1			0.66			0.33078			1.1		
12/08/22 6:00	0.8			1.5			1			0.68			0.34158			1.14		
12/08/22 7:00	0.9			1.5			1			0.66			0.32922			1.1		
12/08/22 8:00	1.2			1.5			1			0.62			0.30882			1.03		
12/08/22 9:00	0.9			1.5			1			0.58			0.29058			0.97		
12/08/22 10:00	0.7			1.5			1			0.53			0.26466			0.88		
12/08/22 11:00	0.9			1.5			1			0.64			0.3183			1.06		
12/08/22 12:00	0.7			1.5			1			0.67			0.33534			1.12		
12/08/22 13:00	0.7			1.5			1			0.67			0.33486			1.12		
12/08/22 14:00	0.5			1.5			1			0.69			0.34404			1.15		
12/08/22 15:00	0.6			1.5			1			0.68			0.33846			1.13		
12/08/22 16:00	0.5			1.5			1			0.69			0.34458			1.15		
12/08/22 17:00	0.4			1.5			1			0.71			0.35484			1.18		
12/08/22 18:00	0.4			1.5			1			0.72			0.35802			1.19		
12/08/22 19:00	0.4			1.5			1			0.72			0.35766			1.19		
12/08/22 20:00	0.4			1.5			1			0.71			0.3567			1.19		
12/08/22 21:00	0.4			1.5			1			0.71			0.35394			1.18		
12/08/22 22:00	0.5			1.5			1			0.69			0.34614			1.15		
12/08/22 23:00	1			1.5			1			0.65			0.32256			1.08		
12/09/22 0:00	0.9			1.5			1			0.51			0.25746			0.86		
12/09/22 1:00	0.7			1.5			1			0.48			0.24144			0.8		
12/09/22 2:00	0.7			1.5			1			0.51			0.25584			0.85		
12/09/22 3:00	0.7			1.5			1			0.52			0.25944			0.86		
12/09/22 4:00	1.2			1.5			1			0.56			0.28128			0.94		
12/09/22 5:00	1.4			1.5			1			0.59			0.2949			0.98		
12/09/22 6:00	1			1.5			1			0.57			0.28722			0.96		
12/09/22 7:00	1			1.5			1			0.65			0.32382			1.08		
12/09/22 8:00	1			1.5			1			0.51			0.25554			0.85		
12/09/22 9:00	0.8			1.5			1			0.47			0.2373			0.79		
12/09/22 10:00	0.6			1.5			2			0.35			0.17544			0.58		
12/09/22 11:00	0.6			1.5			2			0.36			0.17754			0.59		
12/09/22 12:00	0.6			1.5			2			0.36			0.18024			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/22 13:00	0.7			1.5			1			0.56			0.27966			0.93		
12/09/22 14:00	0.7			1.5			1			0.56			0.2808			0.94		
12/09/22 15:00	0.9			1.4			1			0.46			0.2322			0.77		
12/09/22 16:00	0.9			1.5			1			0.66			0.32808			1.09		
12/09/22 17:00	0.9			1.5			1			0.65			0.32562			1.09		
12/09/22 18:00	0.9			1.5			1			0.66			0.32802			1.09		
12/09/22 19:00	0.7			1.5			1			0.68			0.33888			1.13		
12/09/22 20:00	0.6			1.5			1			0.68			0.34182			1.14		
12/09/22 21:00	0.8			1.5			1			0.67			0.33522			1.12		
12/09/22 22:00	0.8			1.5			1			0.67			0.33258			1.11		
12/09/22 23:00	1			1.5			1			0.64			0.3183			1.06		
12/10/22 0:00	0.8			1.5			1			0.57			0.28302			0.94		
12/10/22 1:00	0.6			1.5			1			0.56			0.28206			0.94		
12/10/22 2:00	0.6			1.5			1			0.56			0.2823			0.94		
12/10/22 3:00	0.7			1.5			1			0.56			0.2823			0.94		
12/10/22 4:00	0.7			1.5			1			0.56			0.28236			0.94		
12/10/22 5:00	0.7			1.5			1			0.56			0.28236			0.94		
12/10/22 6:00	0.6			1.5			1			0.56			0.28212			0.94		
12/10/22 7:00	0.6			1.5			2			0.38			0.1884			0.63		
12/10/22 8:00	0.6			1.4			1			0.41			0.2037			0.68		
12/10/22 9:00	0.6			1.4			2			0.37			0.18582			0.62		
12/10/22 10:00	0.5			1.5			2			0.35			0.17286			0.58		
12/10/22 11:00	0.6			1.5			1			0.4			0.20172			0.67		
12/10/22 12:00	0.6			1.5			1			0.51			0.25746			0.86		
12/10/22 13:00	0.9			1.5			1			0.51			0.25728			0.86		
12/10/22 14:00	1.1			1.5			1			0.62			0.31164			1.04		
12/10/22 15:00	1			1.5			1			0.63			0.31626			1.05		
12/10/22 16:00	0.9			1.5			1			0.64			0.31848			1.06		
12/10/22 17:00	1.1			1.5			1			0.62			0.31092			1.04		
12/10/22 18:00	1.1			1.5			1			0.62			0.31074			1.04		
12/10/22 19:00	0.7			1.5			1			0.66			0.33018			1.1		
12/10/22 20:00	0.8			1.5			1			0.65			0.3267			1.09		
12/10/22 21:00	1			1.5			1			0.63			0.31338			1.04		
12/10/22 22:00	1.1			1.5			1			0.62			0.30846			1.03		
12/10/22 23:00	1.1			1.5			1			0.62			0.31122			1.04		
12/11/22 0:00	1.1			1.5			1			0.6			0.29976			1		
12/11/22 1:00	0.8			1.5			1			0.43			0.2172			0.72		
12/11/22 2:00	0.6			1.6			1			0.37			0.1872			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/22 3:00	0.8			1.4			1			0.41			0.2031			0.68		
12/11/22 4:00	0.7			1.5			1			0.48			0.23988			0.8		
12/11/22 5:00	0.7			1.5			1			0.5			0.24882			0.83		
12/11/22 6:00	0.7			1.5			1			0.49			0.24552			0.82		
12/11/22 7:00	0.6			1.5			2			0.37			0.18336			0.61		
12/11/22 8:00	0.5			1.5			2			0.34			0.1695			0.57		
12/11/22 9:00	0.5			1.5			2			0.34			0.16842			0.56		
12/11/22 10:00	0.5			1.5			2			0.34			0.17196			0.57		
12/11/22 11:00	0.5			1.5			2			0.34			0.16824			0.56		
12/11/22 12:00	0.5			1.5			2			0.34			0.1683			0.56		
12/11/22 13:00	0.5			1.5			2			0.34			0.1716			0.57		
12/11/22 14:00	0.6			1.5			2			0.35			0.17586			0.59		
12/11/22 15:00	0.8			1.5			1			0.49			0.24552			0.82		
12/11/22 16:00	1.2			1.5			1			0.62			0.30954			1.03		
12/11/22 17:00	1.2			1.5			1			0.62			0.31188			1.04		
12/11/22 18:00	1.2			1.5			1			0.61			0.30714			1.02		
12/11/22 19:00	1.3			1.5			1			0.62			0.30852			1.03		
12/11/22 20:00	1.1			1.5			1			0.63			0.31632			1.05		
12/11/22 21:00	1.2			1.5			1			0.61			0.30714			1.02		
12/11/22 22:00	0.9			1.5			2			0.48			0.23982			0.8		
12/11/22 23:00	0.5			1.5			2			0.35			0.1752			0.58		
12/12/22 0:00	0.5			1.5			2			0.36			0.17814			0.59		
12/12/22 1:00	0.6			1.4			2			0.36			0.18186			0.61		
12/12/22 2:00	0.7			1.8			1			0.39			0.1974			0.66		
12/12/22 3:00	0.6			1.7			2			0.36			0.18102			0.6		
12/12/22 4:00	0.9			1.6			1			0.5			0.2502			0.83		
12/12/22 5:00	0.9			0.7			2			0.66			0.32772			1.09		
12/12/22 6:00	0.8			0.7			2			0.67			0.3354			1.12		
12/12/22 7:00	0.9			0.8			2			0.65			0.3225			1.08		
12/12/22 8:00	0	X		0	X		0	X		0.62			0.30918			1.03		
12/12/22 9:00	1.3			1.4			1			0.62			0.3081			1.03		
12/12/22 10:00	1.1			1.5			1			0.54			0.27138			0.9		
12/12/22 11:00	0.6			1.5			2			0.35			0.17424			0.58		
12/12/22 12:00	0.6			1.5			2			0.35			0.17448			0.58		
12/12/22 13:00	0.5			1.5			2			0.34			0.17052			0.57		
12/12/22 14:00	0.5			1.5			2			0.34			0.1698			0.57		
12/12/22 15:00	1.2			1.4			0			0.57			0.28584			0.95		
12/12/22 16:00	1.2			1.5			1			0.59			0.294			0.98		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 17:00	1.2			1.5			1			0.59			0.2955			0.99		
12/12/22 18:00	1.3			1.5			1			0.59			0.29616			0.99		
12/12/22 19:00	1.3			1.5			1			0.59			0.297			0.99		
12/12/22 20:00	1.4			1.5			1			0.6			0.2979			0.99		
12/12/22 21:00	1.5			1.5			1			0.6			0.29838			0.99		
12/12/22 22:00	1.4			1.5			1			0.6			0.2997			1		
12/12/22 23:00	1.4			1.5			1			0.6			0.29988			1		
12/13/22 0:00	1.4			1.5			1			0.6			0.30036			1		
12/13/22 1:00	1.4			1.5			1			0.6			0.30012			1		
12/13/22 2:00	1.3			1.5			1			0.6			0.3012			1		
12/13/22 3:00	1.4			1.5			1			0.6			0.30228			1.01		
12/13/22 4:00	1.5			1.5			1			0.6			0.29994			1		
12/13/22 5:00	1.5			1.5			1			0.6			0.29964			1		
12/13/22 6:00	1.4			1.5			1			0.6			0.30246			1.01		
12/13/22 7:00	1.3			1.5			1			0.64			0.3207			1.07		
12/13/22 8:00	1.5			1.5			1			0.6			0.3009			1		
12/13/22 9:00	1.3			1.5			1			0.6			0.29994			1		
12/13/22 10:00	1.3			1.5			1			0.6			0.29988			1		
12/13/22 11:00	0.7			1.5			2			0.41			0.2058			0.69		
12/13/22 12:00	0.6			1.5			2			0.35			0.17448			0.58		
12/13/22 13:00	0.5			1.5			2			0.35			0.17424			0.58		
12/13/22 14:00	0.5			1.5			2			0.35			0.1746			0.58		
12/13/22 15:00	0.9			1.5			1			0.48			0.24144			0.8		
12/13/22 16:00	1.4			1.5			1			0.6			0.2979			0.99		
12/13/22 17:00	1.5			1.5			1			0.59			0.29748			0.99		
12/13/22 18:00	1.5			1.5			1			0.6			0.29802			0.99		
12/13/22 19:00	1.4			1.5			1			0.6			0.29826			0.99		
12/13/22 20:00	1.4			1.5			1			0.6			0.2994			1		
12/13/22 21:00	1.2			1.5			1			0.64			0.32016			1.07		
12/13/22 22:00	1.4			1.5			1			0.62			0.31038			1.03		
12/13/22 23:00	1.5			1.5			1			0.6			0.3009			1		
12/14/22 0:00	0.8			1.5			1			0.57			0.28692			0.96		
12/14/22 1:00	0.7			1.5			1			0.57			0.28686			0.96		
12/14/22 2:00	0.7			1.5			1			0.57			0.2871			0.96		
12/14/22 3:00	0.8			1.5			1			0.57			0.28644			0.95		
12/14/22 4:00	0.9			1.5			1			0.58			0.28902			0.96		
12/14/22 5:00	0.8			1.5			1			0.58			0.2907			0.97		
12/14/22 6:00	0.8			1.5			1			0.59			0.29322			0.98		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/22 7:00	0.7			1.5			1			0.58			0.2883			0.96		
12/14/22 8:00	0.6			1.5			1			0.58			0.28944			0.96		
12/14/22 9:00	0.7			1.5			1			0.58			0.28926			0.96		
12/14/22 10:00	0.6			1.5			1			0.58			0.2892			0.96		
12/14/22 11:00	0.6			1.5			1			0.56			0.28044			0.93		
12/14/22 12:00	0.6			1.5			2			0.36			0.18108			0.6		
12/14/22 13:00	0.5			1.5			2			0.35			0.17496			0.58		
12/14/22 14:00	0.5			1.5			2			0.35			0.17496			0.58		
12/14/22 15:00	0.5			1.5			2			0.35			0.17478			0.58		
12/14/22 16:00	0.6			1.5			1			0.42			0.21228			0.71		
12/14/22 17:00	1.7			1.5			1			0.59			0.29652			0.99		
12/14/22 18:00	1.6			1.5			1			0.6			0.29838			0.99		
12/14/22 19:00	1.5			1.5			1			0.6			0.29916			1		
12/14/22 20:00	1.4			1.5			1			0.59			0.29598			0.99		
12/14/22 21:00	0.9			1.5			1			0.58			0.28842			0.96		
12/14/22 22:00	0.8			1.5			1			0.57			0.2874			0.96		
12/14/22 23:00	1			1.5			1			0.58			0.28866			0.96		
12/15/22 0:00	0.7			1.5			1			0.58			0.28902			0.96		
12/15/22 1:00	0.7			1.5			1			0.58			0.28986			0.97		
12/15/22 2:00	0.7			1.5			1			0.58			0.28914			0.96		
12/15/22 3:00	0.7			1.5			1			0.58			0.28812			0.96		
12/15/22 4:00	0.7			1.5			1			0.58			0.28962			0.97		
12/15/22 5:00	0.7			1.5			1			0.58			0.28926			0.96		
12/15/22 6:00	0.7			1.5			1			0.58			0.2901			0.97		
12/15/22 7:00	0.8			1.5			1			0.58			0.29094			0.97		
12/15/22 8:00	0.7			1.5			1			0.58			0.28962			0.97		
12/15/22 9:00	0.7			1.5			1			0.58			0.28974			0.97		
12/15/22 10:00	0.7			1.5			1			0.58			0.28968			0.97		
12/15/22 11:00	0.6			1.5			1			0.58			0.28848			0.96		
12/15/22 12:00	0.6			1.5			1			0.58			0.28776			0.96		
12/15/22 13:00	0.6			1.5			1			0.57			0.28608			0.95		
12/15/22 14:00	0.7			1.5			1			0.57			0.28572			0.95		
12/15/22 15:00	0.7			1.5			1			0.57			0.28578			0.95		
12/15/22 16:00	0.7			1.5			1			0.57			0.2856			0.95		
12/15/22 17:00	0.7			1.5			1			0.57			0.28632			0.95		
12/15/22 18:00	0.7			1.5			1			0.57			0.28548			0.95		
12/15/22 19:00	0.7			1.5			1			0.57			0.28596			0.95		
12/15/22 20:00	0.7			1.5			1			0.57			0.28614			0.95		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/22 21:00	0.7			1.5			1			0.57			0.28662			0.96		
12/15/22 22:00	0.7			1.5			1			0.58			0.28842			0.96		
12/15/22 23:00	0.7			1.5			1			0.58			0.2895			0.97		
12/16/22 0:00	0.8			1.5			1			0.55			0.27384			0.91		
12/16/22 1:00	0.6			1.5			3			0.35			0.17502			0.58		
12/16/22 2:00	0.6			1.5			2			0.35			0.1749			0.58		
12/16/22 3:00	0.6			1.5			3			0.35			0.17496			0.58		
12/16/22 4:00	0.6			1.5			3			0.35			0.17454			0.58		
12/16/22 5:00	0.6			1.5			3			0.35			0.17472			0.58		
12/16/22 6:00	0.6			1.5			3			0.35			0.17472			0.58		
12/16/22 7:00	0.6			1.5			3			0.35			0.17406			0.58		
12/16/22 8:00	0.6			1.5			3			0.35			0.1749			0.58		
12/16/22 9:00	0.6			1.5			3			0.35			0.17454			0.58		
12/16/22 10:00	0.6			1.5			2			0.35			0.17454			0.58		
12/16/22 11:00	0.6			1.5			2			0.35			0.17466			0.58		
12/16/22 12:00	0.6			1.5			2			0.35			0.1746			0.58		
12/16/22 13:00	0.6			1.5			2			0.35			0.17508			0.58		
12/16/22 14:00	0.6			1.5			2			0.35			0.1752			0.58		
12/16/22 15:00	0.6			1.5			2			0.35			0.17538			0.58		
12/16/22 16:00	0.6			1.5			2			0.35			0.17544			0.58		
12/16/22 17:00	0.6			1.5			2			0.35			0.17526			0.58		
12/16/22 18:00	0.6			1.5			2			0.35			0.17484			0.58		
12/16/22 19:00	0.8			1.5			2			0.35			0.17418			0.58		
12/16/22 20:00	0.6			1.5			2			0.35			0.17466			0.58		
12/16/22 21:00	0.6			1.5			2			0.35			0.1746			0.58		
12/16/22 22:00	0.7			1.5			2			0.35			0.1746			0.58		
12/16/22 23:00	0.7			1.5			2			0.35			0.17508			0.58		
12/17/22 0:00	0.7			1.5			3			0.35			0.17508			0.58		
12/17/22 1:00	0.7			1.5			2			0.35			0.1752			0.58		
12/17/22 2:00	0.8			1.3			1			0.48			0.23874			0.8		
12/17/22 3:00	0.9			1.5			2			0.43			0.21402			0.71		
12/17/22 4:00	0.7			1.5			3			0.35			0.1728			0.58		
12/17/22 5:00	0.9			1.5			1			0.46			0.2322			0.77		
12/17/22 6:00	1.5			1.5			1			0.62			0.30774			1.03		
12/17/22 7:00	1.5			1.5			1			0.62			0.31116			1.04		
12/17/22 8:00	1			1.5			1			0.55			0.27492			0.92		
12/17/22 9:00	0.9			1.5			1			0.49			0.24372			0.81		
12/17/22 10:00	0.7			1.5			2			0.37			0.18708			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 11:00	0.5			1.5			2			0.34			0.17172			0.57		
12/17/22 12:00	0.5			1.5			2			0.34			0.16878			0.56		
12/17/22 13:00	0.6			1.5			2			0.35			0.17424			0.58		
12/17/22 14:00	0.7			1.4			1			0.4			0.19944			0.66		
12/17/22 15:00	0.9			1.5			1			0.65			0.32526			1.08		
12/17/22 16:00	0.7			1.5			1			0.67			0.33528			1.12		
12/17/22 17:00	0.9			1.5			1			0.66			0.32766			1.09		
12/17/22 18:00	1.1			1.5			1			0.63			0.31632			1.05		
12/17/22 19:00	0.9			1.5			1			0.67			0.33732			1.12		
12/17/22 20:00	0.7			1.5			1			0.7			0.34968			1.17		
12/17/22 21:00	0.8			1.5			1			0.69			0.34374			1.15		
12/17/22 22:00	0.9			1.5			1			0.67			0.3372			1.12		
12/17/22 23:00	1.4			1.5			1			0.63			0.31584			1.05		
12/18/22 0:00	1			1.5			1			0.54			0.26886			0.9		
12/18/22 1:00	0.9			1.5			1			0.54			0.26778			0.89		
12/18/22 2:00	0.9			1.4			1			0.51			0.25662			0.86		
12/18/22 3:00	0.9			1.5			1			0.5			0.25134			0.84		
12/18/22 4:00	0.8			1.5			1			0.53			0.26508			0.88		
12/18/22 5:00	0.8			1.5			1			0.55			0.27474			0.92		
12/18/22 6:00	1.1			1.5			1			0.57			0.28548			0.95		
12/18/22 7:00	0.6			1.5			2			0.72			0.3597			1.2		
12/18/22 8:00	0.8			1.5			2			0.68			0.34116			1.14		
12/18/22 9:00	0.8			1.5			2			0.69			0.34608			1.15		
12/18/22 10:00	1			1.5			1			0.62			0.3105			1.04		
12/18/22 11:00	0.8			1.5			1			0.53			0.26256			0.88		
12/18/22 12:00	0.8			1.5			2			0.44			0.21978			0.73		
12/18/22 13:00	0.6			1.5			3			0.35			0.17412			0.58		
12/18/22 14:00	0.7			1.4			1			0.42			0.21228			0.71		
12/18/22 15:00	0.7			1.5			2			0.43			0.21252			0.71		
12/18/22 16:00	1.7			1.5			1			0.59			0.29652			0.99		
12/18/22 17:00	1.5			1.5			1			0.63			0.31662			1.06		
12/18/22 18:00	0.8			1.5			1			0.68			0.34002			1.13		
12/18/22 19:00	0.9			1.5			1			0.67			0.33516			1.12		
12/18/22 20:00	1			1.5			1			0.66			0.33168			1.11		
12/18/22 21:00	1.1			1.5			1			0.65			0.32748			1.09		
12/18/22 22:00	1.1			1.5			1			0.65			0.3225			1.08		
12/18/22 23:00	1.3			1.5			1			0.62			0.31122			1.04		
12/19/22 0:00	1			1.5			1			0.66			0.33048			1.1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/22 1:00	1			1.5			1			0.66			0.3306			1.1		
12/19/22 2:00	1			1.5			1			0.66			0.33084			1.1		
12/19/22 3:00	1			1.5			1			0.66			0.33072			1.1		
12/19/22 4:00	0.8			1.5			1			0.69			0.3435			1.15		
12/19/22 5:00	0.5			1.5			2			0.72			0.35994			1.2		
12/19/22 6:00	0.5			1.5			2			0.72			0.36156			1.21		
12/19/22 7:00	0.6			1.5			2			0.71			0.3555			1.19		
12/19/22 8:00	0.8			1.5			2			0.69			0.34506			1.15		
12/19/22 9:00	0.5			1.5			2			0.74			0.37026			1.23		
12/19/22 10:00	0.5			1.5			2			0.73			0.3648			1.22		
12/19/22 11:00	0.6			1.5			2			0.71			0.35532			1.18		
12/19/22 12:00	0.9			1.5			1			0.68			0.34026			1.13		
12/19/22 13:00	0.8			1.5			1			0.69			0.34458			1.15		
12/19/22 14:00	0.6			1.5			1			0.7			0.35058			1.17		
12/19/22 15:00	0.8			1.5			1			0.68			0.34236			1.14		
12/19/22 16:00	0.5			1.5			2			0.71			0.35676			1.19		
12/19/22 17:00	0.5			1.5			2			0.72			0.35868			1.2		
12/19/22 18:00	0.6			1.5			2			0.72			0.35802			1.19		
12/19/22 19:00	0.6			1.5			2			0.72			0.3576			1.19		
12/19/22 20:00	0.6			1.5			2			0.72			0.35766			1.19		
12/19/22 21:00	0.5			1.5			2			0.72			0.35778			1.19		
12/19/22 22:00	0.7			1.5			2			0.72			0.35778			1.19		
12/19/22 23:00	1			1.5			1			0.67			0.33378			1.11		
12/20/22 0:00	0.9			1.5			1			0.57			0.28668			0.96		
12/20/22 1:00	0.7			1.5			1			0.58			0.28752			0.96		
12/20/22 2:00	0.7			1.5			1			0.58			0.28752			0.96		
12/20/22 3:00	0.8			1.5			1			0.57			0.28728			0.96		
12/20/22 4:00	0.7			1.5			1			0.57			0.28698			0.96		
12/20/22 5:00	0.7			1.5			1			0.58			0.28818			0.96		
12/20/22 6:00	0.7			1.5			1			0.58			0.28782			0.96		
12/20/22 7:00	0.8			1.5			2			0.71			0.35556			1.19		
12/20/22 8:00	0.9			1.5			1			0.68			0.33936			1.13		
12/20/22 9:00	1.5			1.5			1			0.61			0.30444			1.01		
12/20/22 10:00	1.2			1.5			2			0.54			0.26832			0.89		
12/20/22 11:00	0.5			1.5			3			0.35			0.1743			0.58		
12/20/22 12:00	0.5			1.5			3			0.34			0.16992			0.57		
12/20/22 13:00	0.5			1.5			3			0.34			0.16992			0.57		
12/20/22 14:00	0.5			1.5			3			0.34			0.16944			0.56		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/22 15:00	0.8			1.4			1			0.46			0.22956			0.77		
12/20/22 16:00	1.4			1.5			1			0.61			0.30564			1.02		
12/20/22 17:00	1.4			1.5			1			0.61			0.30372			1.01		
12/20/22 18:00	1.3			1.5			1			0.61			0.30396			1.01		
12/20/22 19:00	1.3			1.5			1			0.61			0.3042			1.01		
12/20/22 20:00	1.5			1.5			1			0.61			0.30348			1.01		
12/20/22 21:00	1.4			1.5			1			0.6			0.30246			1.01		
12/20/22 22:00	1.4			1.5			1			0.6			0.30234			1.01		
12/20/22 23:00	1.4			1.5			1			0.6			0.30198			1.01		
12/21/22 0:00	1.5			1.5			1			0.6			0.30198			1.01		
12/21/22 1:00	1.5			1.5			1			0.6			0.30168			1.01		
12/21/22 2:00	1.6			1.5			1			0.6			0.30066			1		
12/21/22 3:00	1.7			1.5			1			0.6			0.30084			1		
12/21/22 4:00	1.6			1.5			1			0.6			0.3009			1		
12/21/22 5:00	1.5			1.5			1			0.6			0.30126			1		
12/21/22 6:00	1.4			1.5			1			0.61			0.30654			1.02		
12/21/22 7:00	1.1			1.5			1			0.67			0.3357			1.12		
12/21/22 8:00	1.3			1.5			1			0.64			0.32016			1.07		
12/21/22 9:00	0.8			1.5			1			0.69			0.34656			1.16		
12/21/22 10:00	0.9			1.5			1			0.68			0.33954			1.13		
12/21/22 11:00	1.1			1.5			1			0.66			0.32946			1.1		
12/21/22 12:00	1.1			1.5			1			0.65			0.32694			1.09		
12/21/22 13:00	1			1.5			1			0.67			0.33294			1.11		
12/21/22 14:00	1.1			1.5			1			0.65			0.32592			1.09		
12/21/22 15:00	1.4			1.5			1			0.62			0.31092			1.04		
12/21/22 16:00	1.1			1.5			1			0.65			0.32694			1.09		
12/21/22 17:00	1.2			1.5			1			0.64			0.32196			1.07		
12/21/22 18:00	1.2			1.5			1			0.64			0.31824			1.06		
12/21/22 19:00	1.2			1.5			1			0.64			0.32178			1.07		
12/21/22 20:00	0.9			1.5			1			0.68			0.34014			1.13		
12/21/22 21:00	0.8			1.5			1			0.68			0.34176			1.14		
12/21/22 22:00	1.3			1.5			1			0.62			0.312			1.04		
12/21/22 23:00	1.4			1.5			1			0.61			0.30516			1.02		
12/22/22 0:00	1.5			1.5			1			0.6			0.3012			1		
12/22/22 1:00	0.8			1.5			1			0.57			0.28716			0.96		
12/22/22 2:00	0.8			1.5			1			0.57			0.28728			0.96		
12/22/22 3:00	0.8			1.5			1			0.57			0.2874			0.96		
12/22/22 4:00	0.8			1.5			1			0.57			0.28674			0.96		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/22 5:00	0.7			1.5			1			0.57			0.28734			0.96		
12/22/22 6:00	0.7			1.5			1			0.58			0.28752			0.96		
12/22/22 7:00	1.4			1.5			1			0.62			0.3075			1.03		
12/22/22 8:00	1.4			1.5			1			0.61			0.306			1.02		
12/22/22 9:00	0.9			1.5			1			0.68			0.34044			1.13		
12/22/22 10:00	0.5			1.5			1			0.72			0.35808			1.19		
12/22/22 11:00	0.6			1.5			1			0.71			0.35604			1.19		
12/22/22 12:00	1.2			1.5			1			0.64			0.31956			1.07		
12/22/22 13:00	1.3			1.5			1			0.62			0.30822			1.03		
12/22/22 14:00	1.4			1.5			1			0.61			0.30342			1.01		
12/22/22 15:00	1.3			1.5			1			0.61			0.30678			1.02		
12/22/22 16:00	1.1			1.5			1			0.65			0.32742			1.09		
12/22/22 17:00	1.3			1.5			1			0.62			0.31248			1.04		
12/22/22 18:00	1.3			1.5			1			0.62			0.31164			1.04		
12/22/22 19:00	1.4			1.5			1			0.61			0.30654			1.02		
12/22/22 20:00	1.5			1.5			1			0.61			0.30294			1.01		
12/22/22 21:00	1.4			1.5			1			0.62			0.30822			1.03		
12/22/22 22:00	1.3			1.5			1			0.62			0.30936			1.03		
12/22/22 23:00	1.4			1.5			1			0.61			0.30354			1.01		
12/23/22 0:00	1.4			1.5			1			0.61			0.30348			1.01		
12/23/22 1:00	1.5			1.5			1			0.61			0.30348			1.01		
12/23/22 2:00	1.5			1.5			1			0.61			0.30324			1.01		
12/23/22 3:00	1.5			1.5			1			0.61			0.30324			1.01		
12/23/22 4:00	1.5			1.5			1			0.61			0.30336			1.01		
12/23/22 5:00	1.5			1.5			1			0.61			0.30282			1.01		
12/23/22 6:00	1.6			1.5			1			0.6			0.30222			1.01		
12/23/22 7:00	1			1.5			1			0.67			0.33696			1.12		
12/23/22 8:00	1.2			1.5			1			0.64			0.32142			1.07		
12/23/22 9:00	1.2			1.5			1			0.65			0.32628			1.09		
12/23/22 10:00	1.2			1.5			1			0.65			0.3228			1.08		
12/23/22 11:00	1.2			1.5			1			0.64			0.3213			1.07		
12/23/22 12:00	1.3			1.5			1			0.6			0.30006			1		
12/23/22 13:00	0.8			1.5			1			0.39			0.19734			0.66		
12/23/22 14:00	0.8			1.4			1			0.42			0.20898			0.7		
12/23/22 15:00	1.2			1.5			1			0.63			0.31584			1.05		
12/23/22 16:00	0.7			1.5			1			0.69			0.34734			1.16		
12/23/22 17:00	0.7			1.5			1			0.69			0.34392			1.15		
12/23/22 18:00	0.8			1.5			1			0.68			0.34152			1.14		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/22 19:00	1			1.5			1			0.66			0.32916			1.1		
12/23/22 20:00	1.1			1.5			1			0.65			0.32712			1.09		
12/23/22 21:00	1			1.5			1			0.66			0.3315			1.11		
12/23/22 22:00	1.3			1.5			1			0.65			0.32718			1.09		
12/23/22 23:00	1.4			1.5			1			0.64			0.31914			1.06		
12/24/22 0:00	1			1.5			1			0.57			0.28602			0.95		
12/24/22 1:00	0.9			1.5			1			0.57			0.28644			0.95		
12/24/22 2:00	0.9			1.5			1			0.57			0.28698			0.96		
12/24/22 3:00	0.9			1.5			1			0.57			0.28674			0.96		
12/24/22 4:00	0.9			1.5			1			0.57			0.28638			0.95		
12/24/22 5:00	0.9			1.5			1			0.57			0.28626			0.95		
12/24/22 6:00	0.9			1.5			1			0.56			0.2823			0.94		
12/24/22 7:00	0.8			1.6			2			0.41			0.2037			0.68		
12/24/22 8:00	0.6			1.5			2			0.35			0.17466			0.58		
12/24/22 9:00	1.2			1.4			1			0.53			0.26262			0.88		
12/24/22 10:00	1.2			1.5			1			0.65			0.32292			1.08		
12/24/22 11:00	1.5			1.5			1			0.61			0.30618			1.02		
12/24/22 12:00	1.3			1.5			1			0.62			0.30816			1.03		
12/24/22 13:00	1.4			1.5			1			0.61			0.30648			1.02		
12/24/22 14:00	1.3			1.5			1			0.61			0.30348			1.01		
12/24/22 15:00	1.2			1.5			1			0.61			0.3036			1.01		
12/24/22 16:00	1.2			1.5			1			0.61			0.30636			1.02		
12/24/22 17:00	1.3			1.5			1			0.61			0.30324			1.01		
12/24/22 18:00	1.4			1.5			1			0.6			0.30186			1.01		
12/24/22 19:00	1.3			1.5			1			0.61			0.30372			1.01		
12/24/22 20:00	1.2			1.5			1			0.55			0.27468			0.92		
12/24/22 21:00	0.7			1.5			2			0.35			0.17592			0.59		
12/24/22 22:00	0.7			1.5			2			0.35			0.17718			0.59		
12/24/22 23:00	0.7			1.5			2			0.36			0.17772			0.59		
12/25/22 0:00	0.8			1.5			2			0.37			0.18732			0.62		
12/25/22 1:00	0.7			1.5			2			0.36			0.17838			0.59		
12/25/22 2:00	0.7			1.5			2			0.36			0.17754			0.59		
12/25/22 3:00	0.8			1.5			2			0.35			0.17712			0.59		
12/25/22 4:00	0.7			1.5			2			0.35			0.17706			0.59		
12/25/22 5:00	0.7			1.5			2			0.35			0.17622			0.59		
12/25/22 6:00	0.7			1.5			2			0.35			0.17616			0.59		
12/25/22 7:00	0.7			1.5			3			0.35			0.1743			0.58		
12/25/22 8:00	0.7			1.5			2			0.35			0.17574			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/22 9:00	0.8			1.5			2			0.39			0.19566			0.65		
12/25/22 10:00	0.6			1.5			2			0.36			0.17784			0.59		
12/25/22 11:00	0.7			1.5			2			0.36			0.1812			0.6		
12/25/22 12:00	0.7			1.5			2			0.38			0.18882			0.63		
12/25/22 13:00	0.6			1.5			2			0.35			0.17532			0.58		
12/25/22 14:00	0.6			1.5			2			0.34			0.17232			0.57		
12/25/22 15:00	0.6			1.5			3			0.34			0.16872			0.56		
12/25/22 16:00	0.9			1.5			1			0.46			0.22776			0.76		
12/25/22 17:00	1.4			1.5			1			0.6			0.30222			1.01		
12/25/22 18:00	0.8			1.5			2			0.42			0.21198			0.71		
12/25/22 19:00	0.7			1.5			2			0.35			0.17436			0.58		
12/25/22 20:00	0.7			1.5			2			0.35			0.17478			0.58		
12/25/22 21:00	0.7			1.5			2			0.35			0.1749			0.58		
12/25/22 22:00	0.7			1.5			3			0.35			0.17286			0.58		
12/25/22 23:00	0.7			1.5			2			0.34			0.17232			0.57		
12/26/22 0:00	0.8			1.5			2			0.37			0.18558			0.62		
12/26/22 1:00	0.7			1.5			2			0.35			0.17532			0.58		
12/26/22 2:00	0.7			1.4			2			0.37			0.18306			0.61		
12/26/22 3:00	0.8			1.5			2			0.36			0.1776			0.59		
12/26/22 4:00	0.6			1.5			2			0.35			0.17508			0.58		
12/26/22 5:00	0.8			1.5			1			0.42			0.2076			0.69		
12/26/22 6:00	0.8			1.5			1			0.41			0.20742			0.69		
12/26/22 7:00	0.7			1.5			3			0.35			0.17604			0.59		
12/26/22 8:00	0.7			1.5			3			0.34			0.16812			0.56		
12/26/22 9:00	0.7			1.5			2			0.35			0.17586			0.59		
12/26/22 10:00	0.9			1.5			1			0.45			0.2259			0.75		
12/26/22 11:00	1.2			1.5			1			0.57			0.2835			0.95		
12/26/22 12:00	1.6			1.5			1			0.6			0.30204			1.01		
12/26/22 13:00	1.3			1.5			1			0.62			0.30954			1.03		
12/26/22 14:00	1			1.5			1			0.65			0.32592			1.09		
12/26/22 15:00	0.9			1.5			1			0.66			0.32898			1.1		
12/26/22 16:00	1.1			1.5			1			0.64			0.31854			1.06		
12/26/22 17:00	1			1.5			1			0.65			0.32448			1.08		
12/26/22 18:00	1			1.5			1			0.65			0.3243			1.08		
12/26/22 19:00	1.2			1.5			1			0.61			0.3063			1.02		
12/26/22 20:00	1.2			1.5			1			0.61			0.30564			1.02		
12/26/22 21:00	1.2			1.5			1			0.58			0.29232			0.97		
12/26/22 22:00	0.7			1.5			2			0.36			0.17772			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/22 23:00	0.6			1.5			2			0.33			0.1674			0.56		
12/27/22 0:00	0.6			1.5			2			0.34			0.16956			0.57		
12/27/22 1:00	0.6			1.5			2			0.33			0.16674			0.56		
12/27/22 2:00	0.6			1.5			2			0.33			0.16656			0.56		
12/27/22 3:00	0.6			1.5			2			0.33			0.16662			0.56		
12/27/22 4:00	0.6			1.5			2			0.33			0.16662			0.56		
12/27/22 5:00	0.6			1.5			2			0.33			0.16686			0.56		
12/27/22 6:00	0.6			1.5			2			0.34			0.16914			0.56		
12/27/22 7:00	0.6			1.5			2			0.33			0.16746			0.56		
12/27/22 8:00	0.6			1.5			1			0.35			0.17472			0.58		
12/27/22 9:00	0.6			1.5			2			0.34			0.171			0.57		
12/27/22 10:00	0.6			1.5			2			0.33			0.16716			0.56		
12/27/22 11:00	0.6			1.5			2			0.34			0.16764			0.56		
12/27/22 12:00	0.6			1.5			2			0.34			0.16812			0.56		
12/27/22 13:00	0.6			1.5			1			0.35			0.17448			0.58		
12/27/22 14:00	0.6			1.5			1			0.35			0.17394			0.58		
12/27/22 15:00	0.6			1.5			2			0.34			0.16872			0.56		
12/27/22 16:00	0.6			1.5			2			0.34			0.16908			0.56		
12/27/22 17:00	0.6			1.5			2			0.34			0.16806			0.56		
12/27/22 18:00	0.6			1.5			2			0.34			0.16884			0.56		
12/27/22 19:00	0.6			1.5			2			0.34			0.16788			0.56		
12/27/22 20:00	0.6			1.5			2			0.33			0.16728			0.56		
12/27/22 21:00	0.6			1.5			2			0.33			0.16722			0.56		
12/27/22 22:00	0.6			1.5			2			0.33			0.16704			0.56		
12/27/22 23:00	0.6			1.5			2			0.33			0.1632			0.54		
12/28/22 0:00	0			0			0	X		0.14			0.06792			0.23		
12/28/22 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/22 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/22 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/22 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/22 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/22 0:00	0.7			0			1.5			0.5			0.27144			0.9		
10/01/22 1:00	0.7			0			1.5			0.48			0.25854			0.86		
10/01/22 2:00	0.7			0			1.2			0.49			0.26514			0.88		
10/01/22 3:00	0.7			0			1.3			0.51			0.27378			0.91		
10/01/22 4:00	0.7			0			1.4			0.49			0.26544			0.88		
10/01/22 5:00	0.7			0			1.5			0.52			0.2808			0.94		
10/01/22 6:00	0.6			1			1.5			0.43			0.2328			0.78		
10/01/22 7:00	0.5			1			1.5			0.33			0.17724			0.59		
10/01/22 8:00	0.5			1			1.5			0.33			0.17694			0.59		
10/01/22 9:00	0.5			1			1.5			0.33			0.17664			0.59		
10/01/22 10:00	0.5			1			1.5			0.33			0.17652			0.59		
10/01/22 11:00	0.4			1			1.5			0.33			0.17598			0.59		
10/01/22 12:00	0.5			1			1.5			0.33			0.1758			0.59		
10/01/22 13:00	0.5			1			1.5			0.34			0.17838			0.59		
10/01/22 14:00	0.4			1			1.5			0.33			0.17598			0.59		
10/01/22 15:00	0.5			0			1.5			0.34			0.17814			0.59		
10/01/22 16:00	0.6			0			1.3			0.46			0.24348			0.81		
10/01/22 17:00	0.6			0			1.5			0.53			0.288			0.96		
10/01/22 18:00	0.6			0			1.5			0.51			0.27342			0.91		
10/01/22 19:00	0.7			0			1.5			0.48			0.25932			0.86		
10/01/22 20:00	0.6			0			1.5			0.52			0.27882			0.93		
10/01/22 21:00	0.7			1			1.5			0.48			0.26004			0.87		
10/01/22 22:00	0.6			1			1.4			0.39			0.20994			0.7		
10/01/22 23:00	0.7			0			1.4			0.46			0.2481			0.83		
10/02/22 0:00	0.7			1			1.4			0.43			0.23382			0.78		
10/02/22 1:00	0.6			1			1.2			0.42			0.2286			0.76		
10/02/22 2:00	0.6			0			1.4			0.5			0.27192			0.91		
10/02/22 3:00	0.6			0			1.5			0.51			0.27366			0.91		
10/02/22 4:00	0.6			0			1.6			0.53			0.28662			0.96		
10/02/22 5:00	0.6			0			1.6			0.53			0.28458			0.95		
10/02/22 6:00	0.6			1			1.6			0.45			0.24474			0.82		
10/02/22 7:00	0.4			1			1.6			0.33			0.17796			0.59		
10/02/22 8:00	0.4			1			1.6			0.33			0.17712			0.59		
10/02/22 9:00	0.4			1			1.6			0.33			0.17682			0.59		
10/02/22 10:00	0.4			1			1.6			0.33			0.17658			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/22 11:00	0.4			1			1.6			0.33			0.17652			0.59		
10/02/22 12:00	0.4			1			1.6			0.34			0.18024			0.6		
10/02/22 13:00	0.6			0			1.4			0.41			0.21726			0.72		
10/02/22 14:00	0.6			0			1.6			0.5			0.27084			0.9		
10/02/22 15:00	0.6			0			1.5			0.42			0.22632			0.75		
10/02/22 16:00	1.1			0			1.6			0.52			0.27924			0.93		
10/02/22 17:00	3.5			1			1.6			0.63			0.33012			1.1		
10/02/22 18:00	3.1			1			1.6			0.62			0.32934			1.1		
10/02/22 19:00	2.8			1			1.6			0.62			0.32802			1.09		
10/02/22 20:00	2.4			1			1.6			0.61			0.32256			1.08		
10/02/22 21:00	0.8			0			1.5			0.48			0.25932			0.86		
10/02/22 22:00	0.6			1			1.5			0.44			0.23418			0.78		
10/02/22 23:00	0.6			0			1.5			0.54			0.28968			0.97		
10/03/22 0:00	0.7			0			1.6			0.51			0.27738			0.92		
10/03/22 1:00	0.7			0			1.6			0.51			0.2733			0.91		
10/03/22 2:00	0.7			1			1.6			0.51			0.2763			0.92		
10/03/22 3:00	0.6			0			1.3			0.52			0.27936			0.93		
10/03/22 4:00	0.6			0			1.6			0.53			0.28746			0.96		
10/03/22 5:00	0.6			0			1.5			0.54			0.2907			0.97		
10/03/22 6:00	0.7			1			1.4			0.5			0.26688			0.89		
10/03/22 7:00	0.6			1			1.1			0.39			0.20724			0.69		
10/03/22 8:00	0.6			0			1.3			0.5			0.26934			0.9		
10/03/22 9:00	0.5			1			1.4			0.35			0.18894			0.63		
10/03/22 10:00	0.6			0			1.2			0.39			0.21168			0.71		
10/03/22 11:00	0.6			0			1.3			0.45			0.24432			0.81		
10/03/22 12:00	0.6			0			1.4			0.53			0.28734			0.96		
10/03/22 13:00	0.6			0			1.4			0.53			0.28836			0.96		
10/03/22 14:00	0.6			0			1.4			0.53			0.28776			0.96		
10/03/22 15:00	0.6			0			1.4			0.54			0.29064			0.97		
10/03/22 16:00	0.7			0			1.4			0.52			0.27972			0.93		
10/03/22 17:00	3.4			1			1.4			0.63			0.33144			1.1		
10/03/22 18:00	3.4			1			1.4			0.63			0.33372			1.11		
10/03/22 19:00	3.1			1			1.4			0.63			0.33288			1.11		
10/03/22 20:00	2.7			1			1.4			0.62			0.33018			1.1		
10/03/22 21:00	1.5			0			1.4			0.54			0.2883			0.96		
10/03/22 22:00	0.6			0			1.4			0.53			0.28632			0.95		
10/03/22 23:00	2.3			1			1.4			0.61			0.32586			1.09		
10/04/22 0:00	2.3			1			1.4			0.61			0.32844			1.09		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/22 1:00	2.4			1			1.4			0.62			0.33156			1.11		
10/04/22 2:00	2.1			1			1.3			0.61			0.32718			1.09		
10/04/22 3:00	2.1			1			1.5			0.61			0.32844			1.09		
10/04/22 4:00	2			1			1.6			0.6			0.32232			1.07		
10/04/22 5:00	2.2			1			1.5			0.62			0.3303			1.1		
10/04/22 6:00	2.2			1			1.5			0.6			0.32124			1.07		
10/04/22 7:00	1.4			1			1.5			0.57			0.30552			1.02		
10/04/22 8:00	0.6			0			1.5			0.54			0.28998			0.97		
10/04/22 9:00	1.8			1			1.5			0.57			0.30246			1.01		
10/04/22 10:00	3			1			1.5			0.62			0.32898			1.1		
10/04/22 11:00	1			0			1.5			0.55			0.2961			0.99		
10/04/22 12:00	3.7			1			1.5			0.65			0.32832			1.09		
10/04/22 13:00	2.6			0			1.5			0.61			0.32094			1.07		
10/04/22 14:00	2.3			1			1.5			0.61			0.31932			1.06		
10/04/22 15:00	3.2			1			1.5			0.63			0.32658			1.09		
10/04/22 16:00	2.5			0			1.5			0.66			0.31746			1.06		
10/04/22 17:00	1.9			0			1.5			0.68			0.31344			1.04		
10/04/22 18:00	1.9			1			1.5			0.68			0.31428			1.05		
10/04/22 19:00	1.9			1			1.5			0.67			0.31632			1.05		
10/04/22 20:00	2			1			1.5			0.66			0.31764			1.06		
10/04/22 21:00	1.9			1			1.5			0.66			0.31902			1.06		
10/04/22 22:00	1.9			1			1.5			0.63			0.32052			1.07		
10/04/22 23:00	1.9			1			1.5			0.66			0.32094			1.07		
10/05/22 0:00	1.9			1			1.5			0.65			0.3219			1.07		
10/05/22 1:00	1.9			1			1.5			0.64			0.32346			1.08		
10/05/22 2:00	1.9			1			1.5			0.65			0.32376			1.08		
10/05/22 3:00	1.9			1			1.5			0.64			0.324			1.08		
10/05/22 4:00	1.9			1			1.5			0.64			0.3261			1.09		
10/05/22 5:00	1.9			1			1.5			0.64			0.3267			1.09		
10/05/22 6:00	1.9			1			1.5			0.61			0.32556			1.09		
10/05/22 7:00	1.7			1			1.5			0.58			0.3189			1.06		
10/05/22 8:00	1.2			0			1.5			0.55			0.29496			0.98		
10/05/22 9:00	1.2			0			1.5			0.53			0.28074			0.94		
10/05/22 10:00	1.6			1			1.5			0.61			0.31524			1.05		
10/05/22 11:00	1.5			0			1.5			0.61			0.31434			1.05		
10/05/22 12:00	1.5			0			1.5			0.63			0.31308			1.04		
10/05/22 13:00	1.5			0			1.5			0.67			0.312			1.04		
10/05/22 14:00	1.6			0			1.5			0.68			0.31284			1.04		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/22 15:00	1.6			0			1.5			0.66			0.31176			1.04		
10/05/22 16:00	1.6			0			1.5			0.66			0.31248			1.04		
10/05/22 17:00	1.6			0			1.5			0.69			0.3126			1.04		
10/05/22 18:00	1.6			0			1.5			0.68			0.3141			1.05		
10/05/22 19:00	1.8			1			1.5			0.67			0.31614			1.05		
10/05/22 20:00	1.8			1			1.5			0.67			0.31782			1.06		
10/05/22 21:00	1.7			1			1.5			0.67			0.31794			1.06		
10/05/22 22:00	1.7			1			1.5			0.64			0.31704			1.06		
10/05/22 23:00	0.8			0			1.5			0.54			0.29328			0.98		
10/06/22 0:00	0.6			0			1.5			0.54			0.29316			0.98		
10/06/22 1:00	0.6			0			1.5			0.54			0.29388			0.98		
10/06/22 2:00	0.6			0			1.5			0.54			0.29388			0.98		
10/06/22 3:00	0.7			0			1.5			0.54			0.29364			0.98		
10/06/22 4:00	0.6			0			1.5			0.54			0.2937			0.98		
10/06/22 5:00	1.1			0			1.5			0.55			0.29718			0.99		
10/06/22 6:00	2.1			1			1.5			0.61			0.3243			1.08		
10/06/22 7:00	1.5			1			1.4			0.52			0.27798			0.93		
10/06/22 8:00	0.7			1			1.3			0.37			0.19764			0.66		
10/06/22 9:00	0.6			1			1.5			0.35			0.18726			0.62		
10/06/22 10:00	0.6			1			1.5			0.35			0.18786			0.63		
10/06/22 11:00	0.6			0			1.4			0.41			0.2175			0.73		
10/06/22 12:00	0.6			0			1.5			0.47			0.24984			0.83		
10/06/22 13:00	0.9			0			1.5			0.53			0.28404			0.95		
10/06/22 14:00	2.2			0			1.5			0.65			0.31776			1.06		
10/06/22 15:00	1.8			0			1.5			0.66			0.31236			1.04		
10/06/22 16:00	1.8			0			1.5			0.68			0.31248			1.04		
10/06/22 17:00	1.8			0			1.5			0.69			0.31326			1.04		
10/06/22 18:00	1.9			0			1.5			0.68			0.315			1.05		
10/06/22 19:00	2			0			1.5			0.67			0.31668			1.06		
10/06/22 20:00	2			1			1.5			0.67			0.31824			1.06		
10/06/22 21:00	2			1			1.5			0.66			0.3198			1.07		
10/06/22 22:00	2			1			1.5			0.64			0.3234			1.08		
10/06/22 23:00	1.9			1			1.5			0.64			0.32436			1.08		
10/07/22 0:00	2			1			1.5			0.63			0.32412			1.08		
10/07/22 1:00	2			1			1.5			0.63			0.32478			1.08		
10/07/22 2:00	1.9			1			1.5			0.59			0.32466			1.08		
10/07/22 3:00	1.6			1			1.5			0.58			0.31854			1.06		
10/07/22 4:00	1.9			1			1.5			0.63			0.3159			1.05		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/22 5:00	1.8			1			1.5			0.64			0.32046			1.07		
10/07/22 6:00	1.9			1			1.5			0.61			0.3198			1.07		
10/07/22 7:00	1.8			0			1.5			0.6			0.3147			1.05		
10/07/22 8:00	1.6			0			1.5			0.59			0.3123			1.04		
10/07/22 9:00	1.6			0			1.5			0.6			0.3096			1.03		
10/07/22 10:00	1.5			0			1.5			0.67			0.31122			1.04		
10/07/22 11:00	1.4			0			1.5			0.68			0.31122			1.04		
10/07/22 12:00	1.5			0			1.5			0.68			0.31188			1.04		
10/07/22 13:00	1.5			0			1.5			0.66			0.31188			1.04		
10/07/22 14:00	1.5			1			1.5			0.63			0.31206			1.04		
10/07/22 15:00	1.5			0			1.5			0.65			0.3108			1.04		
10/07/22 16:00	1.5			1			1.5			0.67			0.31182			1.04		
10/07/22 17:00	1.6			0			1.5			0.69			0.3132			1.04		
10/07/22 18:00	1.7			0			1.5			0.68			0.31548			1.05		
10/07/22 19:00	1.7			0			1.5			0.68			0.31584			1.05		
10/07/22 20:00	1.8			1			1.5			0.67			0.31806			1.06		
10/07/22 21:00	1.7			1			1.5			0.66			0.32016			1.07		
10/07/22 22:00	1.7			1			1.5			0.64			0.32094			1.07		
10/07/22 23:00	1.7			1			1.5			0.65			0.3231			1.08		
10/08/22 0:00	1.7			1			1.5			0.65			0.32298			1.08		
10/08/22 1:00	1.7			1			1.5			0.63			0.3249			1.08		
10/08/22 2:00	1.7			0			1.5			0.63			0.32604			1.09		
10/08/22 3:00	1.8			1			1.5			0.63			0.32688			1.09		
10/08/22 4:00	1.8			1			1.5			0.63			0.32688			1.09		
10/08/22 5:00	1.8			1			1.5			0.63			0.32808			1.09		
10/08/22 6:00	1.5			1			1.5			0.54			0.29214			0.97		
10/08/22 7:00	0.8			1			1.3			0.4			0.2145			0.72		
10/08/22 8:00	0.8			1			1.3			0.38			0.20544			0.68		
10/08/22 9:00	0.7			0			1.3			0.39			0.20946			0.7		
10/08/22 10:00	0.6			1			1.5			0.35			0.18762			0.63		
10/08/22 11:00	0.6			0			1.4			0.41			0.2187			0.73		
10/08/22 12:00	0.7			1			1.6			0.46			0.2457			0.82		
10/08/22 13:00	1.3			0			1.5			0.55			0.29166			0.97		
10/08/22 14:00	1.3			0			1.5			0.53			0.28164			0.94		
10/08/22 15:00	2.1			0			1.5			0.65			0.31428			1.05		
10/08/22 16:00	2			0			1.5			0.68			0.31452			1.05		
10/08/22 17:00	2.1			0			1.5			0.68			0.31596			1.05		
10/08/22 18:00	2.2			1			1.5			0.67			0.31866			1.06		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/22 19:00	2.2			1			1.5			0.67			0.32112			1.07		
10/08/22 20:00	2.2			1			1.5			0.67			0.32022			1.07		
10/08/22 21:00	2.2			1			1.5			0.63			0.31824			1.06		
10/08/22 22:00	1.8			1			1.4			0.47			0.23664			0.79		
10/08/22 23:00	0			0	X		0			0.57			0.06384			0.21		
10/09/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 3:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 4:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/09/22 5:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/09/22 6:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/09/22 7:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/09/22 8:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/09/22 9:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 11:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 12:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 13:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 14:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 15:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 16:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 17:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 18:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 20:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/09/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/09/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 3:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 4:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/10/22 5:00	0	X		0	X		0	X		0.61			0	X		0	X	
10/10/22 6:00	0	X		0	X		0	X		0.62			0	X		0	X	
10/10/22 7:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/10/22 8:00	0	X		0	X		0	X		0.58			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/22 9:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/10/22 10:00	0	X		0	X		0	X		0.56			0	X		0	X	
10/10/22 11:00	0	X		0	X		0	X		0.36			0	X		0	X	
10/10/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/10/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/10/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/10/22 15:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/10/22 16:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/10/22 17:00	0	X		0	X		0	X		0.66			0	X		0	X	
10/10/22 18:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/10/22 23:00	0	X		0	X		0	X		0.56			0	X		0	X	
10/11/22 0:00	0	X		0	X		0	X		0.36			0	X		0	X	
10/11/22 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/11/22 15:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/11/22 16:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/11/22 17:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/11/22 18:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/11/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/11/22 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/11/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/11/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/12/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/12/22 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/12/22 2:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/12/22 3:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/12/22 4:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/12/22 5:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/12/22 6:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/12/22 7:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/12/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/12/22 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 6:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/13/22 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/13/22 15:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/13/22 16:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/13/22 17:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 18:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/13/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 3:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/14/22 4:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/14/22 5:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/14/22 6:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/14/22 7:00	0	X		0	X		0	X		0.55			0	X		0	X	
10/14/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/14/22 16:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/14/22 17:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 18:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/14/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/15/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/15/22 1:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/15/22 2:00	0	X		0	X		0	X		0.55			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/22 3:00	0	X		0	X		0	X		0.54			0	X		0	X	
10/15/22 4:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/15/22 5:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/15/22 6:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/15/22 7:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/15/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 15:00	0	X		0	X		0	X		0.34			0	X		0	X	
10/15/22 16:00	0	X		0	X		0	X		0.34			0	X		0	X	
10/15/22 17:00	0	X		0	X		0	X		0.34			0	X		0	X	
10/15/22 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/15/22 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 6:00	0	X		0	X		0	X		0.36			0	X		0	X	
10/16/22 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
10/16/22 9:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/16/22 10:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/16/22 11:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 12:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/16/22 13:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/16/22 14:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/16/22 15:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/16/22 16:00	0	X		0	X		0	X		0.58			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/22 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 18:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 20:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 21:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 22:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/16/22 23:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/17/22 0:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/17/22 1:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/17/22 2:00	0	X		0	X		0	X		0.55			0	X		0	X	
10/17/22 3:00	0	X		0	X		0	X		0.55			0	X		0	X	
10/17/22 4:00	0	X		0	X		0	X		0.56			0	X		0	X	
10/17/22 5:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/17/22 6:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/17/22 7:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 8:00	0	X		0	X		0	X		0.54			0	X		0	X	
10/17/22 9:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 11:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 12:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 13:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 14:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 15:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/17/22 16:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 17:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 18:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/17/22 22:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/17/22 23:00	0	X		0	X		0	X		0.61			0	X		0	X	
10/18/22 0:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 1:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 2:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 3:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/18/22 4:00	0	X		0	X		0	X		0.62			0	X		0	X	
10/18/22 5:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/18/22 6:00	0	X		0	X		0	X		0.68			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/22 7:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/18/22 8:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 9:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 10:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 11:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/18/22 12:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/18/22 13:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/18/22 14:00	0			0	X		0			0.41			0.02262			0.08		
10/18/22 15:00	0.5			3			0.5			0.4			0.1929			0.64		
10/18/22 16:00	0.9			0			0.8			0.56			0.29748			0.99		
10/18/22 17:00	0.3			1			1.6			0.72			0.37404			1.25		
10/18/22 18:00	0.4			0			1.5			0.7			0.36504			1.22		
10/18/22 19:00	0.3			1			1.5			0.77			0.39984			1.33		
10/18/22 20:00	0.5			1			1.5			0.71			0.37194			1.24		
10/18/22 21:00	0.6			0			1.5			0.69			0.36084			1.2		
10/18/22 22:00	1.1			0			1.5			0.64			0.3393			1.13		
10/18/22 23:00	0.8			0			1.5			0.55			0.294			0.98		
10/19/22 0:00	0.7			0			1.5			0.55			0.2949			0.98		
10/19/22 1:00	0.7			0			1.5			0.53			0.28404			0.95		
10/19/22 2:00	0.8			0			1.6			0.5			0.27102			0.9		
10/19/22 3:00	0.9			0			1.5			0.52			0.28278			0.94		
10/19/22 4:00	0.8			0			1.5			0.54			0.29358			0.98		
10/19/22 5:00	0.8			0			1.5			0.55			0.29484			0.98		
10/19/22 6:00	0.8			1			1.5			0.47			0.25266			0.84		
10/19/22 7:00	0.6			1			1.5			0.34			0.18084			0.6		
10/19/22 8:00	0.7			0			1.3			0.31			0.22824			0.76		
10/19/22 9:00	0.6			1			1.5			0	X		0.20736			0.69		
10/19/22 10:00	0.6			1			1.5			0	X		0.18636			0.62		
10/19/22 11:00	0.6			1			1.5			0	X		0.18552			0.62		
10/19/22 12:00	0.5			0			1.5			0	X		0.1857			0.62		
10/19/22 13:00	0.5			0			1.5			0	X		0.18606			0.62		
10/19/22 14:00	0.8			0			1.4			0	X		0.2526			0.84		
10/19/22 15:00	1			0			1.5			0	X		0.31146			1.04		
10/19/22 16:00	0.7			1			1.4			0.3			0.22596			0.75		
10/19/22 17:00	0.6			0			1.2			0.44			0.2358			0.79		
10/19/22 18:00	1.9			0			1.6			0.58			0.29952			1		
10/19/22 19:00	1.1			0			1.5			0.6			0.31506			1.05		
10/19/22 20:00	1			0			1.5			0.62			0.32544			1.08		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/22 21:00	1.1			0			1.5			0.59			0.31188			1.04		
10/19/22 22:00	0.7			1			1.4			0.41			0.2217			0.74		
10/19/22 23:00	0.8			0			1.4			0.49			0.26244			0.87		
10/20/22 0:00	0.7			1			1.5			0.49			0.26418			0.88		
10/20/22 1:00	0.7			1			1.4			0.41			0.22032			0.73		
10/20/22 2:00	0.6			1			1.4			0.36			0.19188			0.64		
10/20/22 3:00	0.8			0			1.5			0.44			0.2388			0.8		
10/20/22 4:00	0.8			0			1.5			0.52			0.28266			0.94		
10/20/22 5:00	0.7			0			1.5			0.55			0.3			1		
10/20/22 6:00	0.7			1			1.5			0.49			0.26634			0.89		
10/20/22 7:00	0.6			1			1.5			0.35			0.18846			0.63		
10/20/22 8:00	0.7			1			1.5			0.34			0.18276			0.61		
10/20/22 9:00	0.6			1			1.5			0.34			0.18312			0.61		
10/20/22 10:00	0.6			1			1.5			0.35			0.1842			0.61		
10/20/22 11:00	0.5			1			1.5			0.34			0.18078			0.6		
10/20/22 12:00	0.5			1			1.4			0.34			0.1812			0.6		
10/20/22 13:00	0.6			0			1.4			0.35			0.18666			0.62		
10/20/22 14:00	0.6			0			1.4			0.36			0.19194			0.64		
10/20/22 15:00	0.8			0			1.5			0.49			0.25854			0.86		
10/20/22 16:00	0.3			1			1.5			0.71			0.37218			1.24		
10/20/22 17:00	0.5			0			1.5			0.67			0.34974			1.17		
10/20/22 18:00	0.8			0			1.5			0.63			0.33174			1.11		
10/20/22 19:00	1.2			0			1.5			0.59			0.31434			1.05		
10/20/22 20:00	1.1			0			1.5			0.58			0.30786			1.03		
10/20/22 21:00	0.7			1			1.5			0.38			0.20568			0.69		
10/20/22 22:00	0.7			1			1.4			0.37			0.1983			0.66		
10/20/22 23:00	0.7			0			1.4			0.52			0.28128			0.94		
10/21/22 0:00	0.7			1			1.5			0.43			0.23172			0.77		
10/21/22 1:00	0.7			1			1.3			0.41			0.22062			0.74		
10/21/22 2:00	0.6			1			1.4			0.36			0.192			0.64		
10/21/22 3:00	0.7			1			1.4			0.38			0.2022			0.67		
10/21/22 4:00	0.8			1			1.2			0.41			0.22188			0.74		
10/21/22 5:00	0.8			0			1.4			0.53			0.28416			0.95		
10/21/22 6:00	1.4			0			1.5			0.57			0.30642			1.02		
10/21/22 7:00	1.4			0			1.5			0.57			0.3036			1.01		
10/21/22 8:00	0.6			1			1.5			0.35			0.18648			0.62		
10/21/22 9:00	0.6			1			1.5			0.34			0.17922			0.6		
10/21/22 10:00	0.5			1			1.5			0.33			0.17862			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/22 11:00	0.6			0			1.4			0.35			0.18588			0.62		
10/21/22 12:00	0.5			1			1.5			0.33			0.17832			0.59		
10/21/22 13:00	0.5			1			1.5			0.34			0.18114			0.6		
10/21/22 14:00	0.5			1			1.5			0.34			0.18258			0.61		
10/21/22 15:00	0.9			0			1.3			0.51			0.26892			0.9		
10/21/22 16:00	0.9			0			1.5			0.63			0.333			1.11		
10/21/22 17:00	1			0			1.5			0.62			0.32982			1.1		
10/21/22 18:00	1			0			1.5			0.58			0.30732			1.02		
10/21/22 19:00	0.8			0			1.5			0.45			0.24444			0.81		
10/21/22 20:00	0.7			1			1.4			0.44			0.23502			0.78		
10/21/22 21:00	0.7			0			1.5			0.54			0.29154			0.97		
10/21/22 22:00	0.6			0			1.5			0.56			0.30186			1.01		
10/21/22 23:00	0.6			0			1.5			0.56			0.3018			1.01		
10/22/22 0:00	0.6			0			1.5			0.56			0.30114			1		
10/22/22 1:00	0.6			0			1.5			0.56			0.30084			1		
10/22/22 2:00	0.6			0			1.5			0.56			0.30126			1		
10/22/22 3:00	0.7			0			1.5			0.56			0.30138			1		
10/22/22 4:00	0.6			0			1.5			0.56			0.3009			1		
10/22/22 5:00	1			0			1.5			0.56			0.30342			1.01		
10/22/22 6:00	0.3			1			1.5			0.78			0.40842			1.36		
10/22/22 7:00	0.2			2			1.5			0.8			0.41976			1.4		
10/22/22 8:00	0.3			1			1.5			0.72			0.3807			1.27		
10/22/22 9:00	0.4			1			1.5			0.72			0.37638			1.25		
10/22/22 10:00	0.5			1			1.5			0.69			0.36402			1.21		
10/22/22 11:00	1			0			1.5			0.62			0.3303			1.1		
10/22/22 12:00	1.1			0			1.5			0.57			0.30582			1.02		
10/22/22 13:00	0.6			0			1.5			0.53			0.28806			0.96		
10/22/22 14:00	0.7			0			1.5			0.52			0.28128			0.94		
10/22/22 15:00	0.6			1			1.3			0.41			0.22128			0.74		
10/22/22 16:00	0.6			0			1.4			0.45			0.24468			0.82		
10/22/22 17:00	0.7			0			1.5			0.51			0.27762			0.93		
10/22/22 18:00	0.7			0			1.5			0.52			0.28098			0.94		
10/22/22 19:00	0.7			0			1.5			0.55			0.2985			1		
10/22/22 20:00	1.2			0			1.5			0.56			0.3039			1.01		
10/22/22 21:00	1.1			1			1.5			0.62			0.33084			1.1		
10/22/22 22:00	0.7			0			1.5			0.56			0.30054			1		
10/22/22 23:00	0.7			0			1.5			0.56			0.30024			1		
10/23/22 0:00	1.3			1			1.5			0.6			0.32268			1.08		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/22 1:00	1			0			1.5			0.57			0.30786			1.03		
10/23/22 2:00	0.7			0			1.5			0.56			0.30198			1.01		
10/23/22 3:00	0.7			0			1.5			0.56			0.30126			1		
10/23/22 4:00	0.7			0			1.5			0.56			0.30084			1		
10/23/22 5:00	0.7			0			1.5			0.56			0.30096			1		
10/23/22 6:00	0.7			0			1.5			0.56			0.3003			1		
10/23/22 7:00	1.3			0			1.5			0.57			0.30654			1.02		
10/23/22 8:00	1.2			0			1.5			0.61			0.32628			1.09		
10/23/22 9:00	0.9			0			1.5			0.52			0.27834			0.93		
10/23/22 10:00	0.8			0			1.5			0.48			0.2565			0.86		
10/23/22 11:00	1			0			1.5			0.62			0.3246			1.08		
10/23/22 12:00	0.8			0			1.5			0.53			0.28194			0.94		
10/23/22 13:00	0.7			0			1.4			0.42			0.22692			0.76		
10/23/22 14:00	0.7			1			1.9			0.43			0.23166			0.77		
10/23/22 15:00	0.6			1			1.5			0.36			0.19566			0.65		
10/23/22 16:00	0.6			0			1.5			0.45			0.24252			0.81		
10/23/22 17:00	0.7			0			1.5			0.54			0.29376			0.98		
10/23/22 18:00	0.7			0			1.5			0.55			0.29814			0.99		
10/23/22 19:00	0.7			0			1.5			0.56			0.30096			1		
10/23/22 20:00	1.2			1			1.5			0.6			0.32292			1.08		
10/23/22 21:00	1.1			1			1.5			0.6			0.3192			1.06		
10/23/22 22:00	0.8			0			1.5			0.48			0.26196			0.87		
10/23/22 23:00	0.7			0			1.5			0.56			0.30144			1		
10/24/22 0:00	0.7			0			1.5			0.55			0.29658			0.99		
10/24/22 1:00	0.8			0			1.5			0.53			0.28812			0.96		
10/24/22 2:00	0.7			0			1.5			0.56			0.30102			1		
10/24/22 3:00	0.8			0			1.5			0.56			0.3003			1		
10/24/22 4:00	0.8			0			1.5			0.55			0.2991			1		
10/24/22 5:00	1.2			0			1.5			0.56			0.30024			1		
10/24/22 6:00	0.8			1			1.5			0.71			0.3783			1.26		
10/24/22 7:00	1.1			1			1.5			0.66			0.34824			1.16		
10/24/22 8:00	1.3			0			1.5			0.59			0.31962			1.07		
10/24/22 9:00	1.2			0			1.5			0.6			0.32148			1.07		
10/24/22 10:00	1.1			0			1.5			0.59			0.31614			1.05		
10/24/22 11:00	0.8			0			1.5			0.52			0.279			0.93		
10/24/22 12:00	0.6			1			1.8			0.34			0.18342			0.61		
10/24/22 13:00	0.5			1			1.5			0.34			0.17952			0.6		
10/24/22 14:00	1			0			1.4			0.49			0.2616			0.87		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/22 15:00	1.7			0			1.5			0.59			0.31158			1.04		
10/24/22 16:00	0.9			1			1.5			0.66			0.35142			1.17		
10/24/22 17:00	1.1			1			1.5			0.64			0.3399			1.13		
10/24/22 18:00	1.7			0			1.5			0.59			0.3168			1.06		
10/24/22 19:00	1.3			0			1.5			0.61			0.32826			1.09		
10/24/22 20:00	1.1			0			1.5			0.59			0.31992			1.07		
10/24/22 21:00	0.8			1			1.4			0.45			0.24414			0.81		
10/24/22 22:00	0.7			1			1.4			0.37			0.20076			0.67		
10/24/22 23:00	0.7			1			1.4			0.4			0.21528			0.72		
10/25/22 0:00	0.6			1			1.5			0.35			0.18972			0.63		
10/25/22 1:00	0.6			1			1.5			0.35			0.19026			0.63		
10/25/22 2:00	0.6			1			1.5			0.35			0.19026			0.63		
10/25/22 3:00	0.7			1			1.5			0.36			0.19416			0.65		
10/25/22 4:00	0.8			0			1.4			0.5			0.2718			0.91		
10/25/22 5:00	0.8			0			1.5			0.54			0.29268			0.98		
10/25/22 6:00	1.5			1			1.5			0.64			0.34524			1.15		
10/25/22 7:00	1.2			1			1.5			0.6			0.32568			1.09		
10/25/22 8:00	1			0			1.4			0.46			0.2463			0.82		
10/25/22 9:00	0.8			1			1.4			0.43			0.23448			0.78		
10/25/22 10:00	0.6			1			1.5			0.34			0.18384			0.61		
10/25/22 11:00	0.7			1			1.5			0.35			0.18876			0.63		
10/25/22 12:00	1			0			1.4			0.44			0.23634			0.79		
10/25/22 13:00	1.1			0			1.5			0.61			0.33618			1.12		
10/25/22 14:00	0.8			0			1.5			0.66			0.35742			1.19		
10/25/22 15:00	0.7			1			1.5			0.66			0.35436			1.18		
10/25/22 16:00	0.6			1			1.5			0.69			0.37332			1.24		
10/25/22 17:00	0.6			1			1.5			0.67			0.3651			1.22		
10/25/22 18:00	1			1			1.5			0.64			0.34746			1.16		
10/25/22 19:00	1			1			1.5			0.64			0.34494			1.15		
10/25/22 20:00	1			1			1.5			0.65			0.35124			1.17		
10/25/22 21:00	1.2			0			1.5			0.59			0.3168			1.06		
10/25/22 22:00	0.7			1			1.5			0.36			0.19632			0.65		
10/25/22 23:00	0.9			1			1.4			0.39			0.21162			0.71		
10/26/22 0:00	0.6			1			1.5			0.35			0.1905			0.64		
10/26/22 1:00	0.6			1			1.5			0.35			0.19074			0.64		
10/26/22 2:00	0.6			1			1.5			0.36			0.19188			0.64		
10/26/22 3:00	0.8			0			1.6			0.46			0.24804			0.83		
10/26/22 4:00	0.9			0			1.5			0.5			0.2727			0.91		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/22 5:00	0.9			0			1.5			0.53			0.28596			0.95		
10/26/22 6:00	0.8			0			1.5			0.56			0.30084			1		
10/26/22 7:00	0.8			0			1.5			0.51			0.27348			0.91		
10/26/22 8:00	1.2			0			1.5			0.57			0.3072			1.02		
10/26/22 9:00	1.2			1			1.5			0.61			0.3273			1.09		
10/26/22 10:00	1.1			1			1.5			0.63			0.33258			1.11		
10/26/22 11:00	0.9			1			1.4			0.42			0.22272			0.74		
10/26/22 12:00	0.6			1			1.5			0.34			0.18174			0.61		
10/26/22 13:00	0.6			1			1.5			0.34			0.18096			0.6		
10/26/22 14:00	0.7			0			1.5			0.39			0.21216			0.71		
10/26/22 15:00	0.7			1			1.3			0.39			0.20832			0.69		
10/26/22 16:00	1			1			1.3			0.5			0.2655			0.89		
10/26/22 17:00	1			0			1.5			0.62			0.32802			1.09		
10/26/22 18:00	1.1			0			1.5			0.57			0.3048			1.02		
10/26/22 19:00	0.7			1			1.4			0.37			0.2004			0.67		
10/26/22 20:00	0.8			1			1.4			0.41			0.22194			0.74		
10/26/22 21:00	0.7			1			1.4			0.37			0.19986			0.67		
10/26/22 22:00	0.6			1			1.5			0.35			0.18918			0.63		
10/26/22 23:00	0.6			1			1.4			0.35			0.19074			0.64		
10/27/22 0:00	0.6			2			1.5			0.34			0.18264			0.61		
10/27/22 1:00	0.6			1			1.5			0.34			0.18606			0.62		
10/27/22 2:00	0.7			1			1.5			0.35			0.18864			0.63		
10/27/22 3:00	1			1			1.4			0.36			0.19644			0.65		
10/27/22 4:00	0.9			1			1.4			0.42			0.22644			0.75		
10/27/22 5:00	0.9			0			1.4			0.48			0.25908			0.86		
10/27/22 6:00	0.9			1			1.5			0.47			0.25242			0.84		
10/27/22 7:00	0.9			0			1.4			0.5			0.26946			0.9		
10/27/22 8:00	0.8			0			1.5			0.54			0.2904			0.97		
10/27/22 9:00	1.4			1			1.5			0.59			0.31374			1.05		
10/27/22 10:00	1.1			1			1.5			0.51			0.27228			0.91		
10/27/22 11:00	1.2			1			1.6			0.59			0.31224			1.04		
10/27/22 12:00	1			2			1.5			0.6			0.31788			1.06		
10/27/22 13:00	1			4			1.5			0.52			0.27714			0.92		
10/27/22 14:00	0.7			4			1.5			0.36			0.19266			0.64		
10/27/22 15:00	0.7			5			1.4			0.4			0.2139			0.71		
10/27/22 16:00	1.2			3			1.5			0.65			0.34488			1.15		
10/27/22 17:00	1.1			3			1.5			0.63			0.33696			1.12		
10/27/22 18:00	1.3			3			1.5			0.6			0.31908			1.06		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/22 19:00	1.5			3			1.5			0.61			0.32658			1.09		
10/27/22 20:00	1.3			3			1.5			0.63			0.33408			1.11		
10/27/22 21:00	1.2			2			1.5			0.63			0.33444			1.11		
10/27/22 22:00	1.9			3			1.5			0.58			0.3045			1.02		
10/27/22 23:00	0.9			2			1.5			0.51			0.27522			0.92		
10/28/22 0:00	0.9			3			1.5			0.5			0.27066			0.9		
10/28/22 1:00	1			2			1.5			0.48			0.25896			0.86		
10/28/22 2:00	0.9			2			1.5			0.5			0.27012			0.9		
10/28/22 3:00	1.9			4			1.5			0.54			0.29298			0.98		
10/28/22 4:00	1.3			3			1.5			0.64			0.34278			1.14		
10/28/22 5:00	1			3			1.5			0.66			0.35352			1.18		
10/28/22 6:00	1.1			4			1.5			0.65			0.34836			1.16		
10/28/22 7:00	1.9			3			1.5			0.58			0.30486			1.02		
10/28/22 8:00	0.9			2			1.5			0.5			0.27096			0.9		
10/28/22 9:00	0.8			3			1.5			0.53			0.28824			0.96		
10/28/22 10:00	1.4			3			1.5			0.59			0.31602			1.05		
10/28/22 11:00	1			8			1.3			0.48			0.25512			0.85		
10/28/22 12:00	0.9			1			1.5			0.47			0.25302			0.84		
10/28/22 13:00	0.8			5			1.7			0.45			0.24162			0.81		
10/28/22 14:00	1.2			2			1.4			0.48			0.25836			0.86		
10/28/22 15:00	1.3			3			1.5			0.64			0.33816			1.13		
10/28/22 16:00	1.4			3			1.5			0.62			0.33006			1.1		
10/28/22 17:00	0.7			4			1.5			0.69			0.36636			1.22		
10/28/22 18:00	0.7			5			1.5			0.7			0.3714			1.24		
10/28/22 19:00	0.7			5			1.5			0.7			0.37146			1.24		
10/28/22 20:00	0.7			5			1.5			0.71			0.3756			1.25		
10/28/22 21:00	0.7			5			1.5			0.71			0.37644			1.25		
10/28/22 22:00	1.2			4			1.5			0.64			0.3417			1.14		
10/28/22 23:00	1			2			1.5			0.55			0.297			0.99		
10/29/22 0:00	1			3			1.4			0.46			0.24834			0.83		
10/29/22 1:00	1			3			1.5			0.47			0.25386			0.85		
10/29/22 2:00	1			1			1.3			0.46			0.25152			0.84		
10/29/22 3:00	0.8			8			1.5			0.36			0.19272			0.64		
10/29/22 4:00	0.9			0			1.4			0.45			0.24216			0.81		
10/29/22 5:00	1.1			2			1.5			0.54			0.29016			0.97		
10/29/22 6:00	1.1			6			1.5			0.46			0.2484			0.83		
10/29/22 7:00	1			2			1.4			0.46			0.24786			0.83		
10/29/22 8:00	1			2			1.5			0.53			0.28644			0.95		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/22 9:00	0.9			2			1.5			0.48			0.26082			0.87		
10/29/22 10:00	0.9			2			1.5			0.5			0.2682			0.89		
10/29/22 11:00	0.8			3			1.7			0.44			0.23808			0.79		
10/29/22 12:00	0.7			10			1.5			0.36			0.1917			0.64		
10/29/22 13:00	0.8			2			1.2			0.38			0.20166			0.67		
10/29/22 14:00	0.8			2			1.4			0.38			0.20562			0.69		
10/29/22 15:00	0.7			4			1.7			0.39			0.21072			0.7		
10/29/22 16:00	0.8			3			1.9			0.45			0.24048			0.8		
10/29/22 17:00	0.9			3			1.9			0.46			0.24882			0.83		
10/29/22 18:00	0.8			5			1.8			0.45			0.24084			0.8		
10/29/22 19:00	0.9			3			1.4			0.38			0.20502			0.68		
10/29/22 20:00	1.3			2			1.5			0.57			0.30462			1.02		
10/29/22 21:00	1.5			3			1.5			0.6			0.31698			1.06		
10/29/22 22:00	0.9			2			1.5			0.51			0.276			0.92		
10/29/22 23:00	0.9			3			1.5			0.55			0.29796			0.99		
10/30/22 0:00	0.9			3			1.5			0.53			0.28884			0.96		
10/30/22 1:00	0.9			2			1.5			0.5			0.27078			0.9		
10/30/22 2:00	0.9			2			1.5			0.52			0.27894			0.93		
10/30/22 3:00	0.9			3			1.5			0.52			0.27876			0.93		
10/30/22 4:00	0.9			2			1.5			0.53			0.2841			0.95		
10/30/22 5:00	0.8			3			1.5			0.57			0.30672			1.02		
10/30/22 6:00	0.9			3			1.5			0.55			0.29976			1		
10/30/22 7:00	0.9			9			1.5			0.36			0.1962			0.65		
10/30/22 8:00	0.7			6			1.6			0.34			0.18684			0.62		
10/30/22 9:00	0.7			6			1.6			0.34			0.18558			0.62		
10/30/22 10:00	0.7			6			1.6			0.34			0.18504			0.62		
10/30/22 11:00	0.7			5			1.6			0.34			0.18474			0.62		
10/30/22 12:00	0.7			5			1.6			0.34			0.18444			0.61		
10/30/22 13:00	0.7			5			1.6			0.34			0.1842			0.61		
10/30/22 14:00	0.7			5			1.6			0.34			0.18396			0.61		
10/30/22 15:00	0.7			2			1.5			0.37			0.20016			0.67		
10/30/22 16:00	0.8			-1			1.5			0.52			0.28164			0.94		
10/30/22 17:00	1.3			2			1.5			0.54			0.29214			0.97		
10/30/22 18:00	1.7			3			1.5			0.58			0.31248			1.04		
10/30/22 19:00	1			2			1.5			0.52			0.27924			0.93		
10/30/22 20:00	1			2			1.5			0.51			0.2727			0.91		
10/30/22 21:00	0.9			2			1.5			0.51			0.27474			0.92		
10/30/22 22:00	0.9			2			1.5			0.49			0.26616			0.89		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/22 23:00	0.9			2			1.5			0.51			0.27636			0.92		
10/31/22 0:00	0.9			2			1.5			0.51			0.27576			0.92		
10/31/22 1:00	0.9			2			1.5			0.5			0.2724			0.91		
10/31/22 2:00	0.9			2			1.5			0.52			0.27888			0.93		
10/31/22 3:00	1			1			1.5			0.51			0.27456			0.92		
10/31/22 4:00	0.9			2			1.5			0.54			0.29226			0.97		
10/31/22 5:00	1.4			3			1.5			0.58			0.31332			1.04		
10/31/22 6:00	1.2			4			1.5			0.63			0.34074			1.14		
10/31/22 7:00	1.3			5			1.5			0.48			0.26196			0.87		
10/31/22 8:00	0.9			5			1.4			0.44			0.23772			0.79		
10/31/22 9:00	0.9			1			1.3			0.42			0.22584			0.75		
10/31/22 10:00	0.8			6			1.5			0.38			0.20214			0.67		
10/31/22 11:00	0.7			5			1.5			0.35			0.18834			0.63		
10/31/22 12:00	0.7			5			1.5			0.35			0.18816			0.63		
10/31/22 13:00	0.8			1			1.3			0.4			0.21768			0.73		
10/31/22 14:00	1.3			1			1.4			0.53			0.2862			0.95		
10/31/22 15:00	1.2			1			1.5			0.61			0.32352			1.08		
10/31/22 16:00	0.9			2			1.4			0.46			0.24474			0.82		
10/31/22 17:00	0.7			7			1.5			0.35			0.18762			0.63		
10/31/22 18:00	0.7			5			1.5			0.35			0.18672			0.62		
10/31/22 19:00	0.9			4			1.4			0.39			0.20916			0.7		
10/31/22 20:00	1			2			1.3			0.41			0.21942			0.73		
10/31/22 21:00	1			0			1.4			0.47			0.25236			0.84		
10/31/22 22:00	0.9			5			1.4			0.41			0.22098			0.74		
10/31/22 23:00	0.9			1			1.5			0.54			0.29322			0.98		
11/01/22 0:00	0.9			2			1.5			0.54			0.29292			0.98		
11/01/22 1:00	1.3			3			1.5			0.56			0.3			1		
11/01/22 2:00	1.1			3			1.4			0.65			0.3453			1.15		
11/01/22 3:00	0.8			4			1.5			0.68			0.35892			1.2		
11/01/22 4:00	0.6			4			1.5			0.7			0.37056			1.24		
11/01/22 5:00	0.8			4			1.5			0.68			0.36234			1.21		
11/01/22 6:00	0.6			6			1.5			0.73			0.38448			1.28		
11/01/22 7:00	0.8			5			1.5			0.67			0.35658			1.19		
11/01/22 8:00	1			4			1.5			0.65			0.34272			1.14		
11/01/22 9:00	1.2			3			1.5			0.61			0.32196			1.07		
11/01/22 10:00	1.2			3			1.5			0.61			0.32442			1.08		
11/01/22 11:00	1			3			1.5			0.65			0.3429			1.14		
11/01/22 12:00	0.9			4			1.5			0.67			0.35598			1.19		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/22 13:00	0.9			4			1.5			0.66			0.35256			1.18		
11/01/22 14:00	1.4			3			1.5			0.59			0.31722			1.06		
11/01/22 15:00	1.3			3			1.5			0.61			0.32166			1.07		
11/01/22 16:00	0.9			4			1.5			0.66			0.34908			1.16		
11/01/22 17:00	1			3			1.5			0.65			0.34146			1.14		
11/01/22 18:00	1.1			4			1.5			0.64			0.33948			1.13		
11/01/22 19:00	1.1			4			1.5			0.64			0.33936			1.13		
11/01/22 20:00	1.1			4			1.5			0.63			0.33762			1.13		
11/01/22 21:00	1.4			3			1.5			0.61			0.32634			1.09		
11/01/22 22:00	1.8			3			1.5			0.6			0.31932			1.06		
11/01/22 23:00	1			4			1.5			0.48			0.25944			0.86		
11/02/22 0:00	0.7			8			1.5			0.36			0.19188			0.64		
11/02/22 1:00	0.9			0			1.4			0.45			0.24624			0.82		
11/02/22 2:00	0.8			1			1.6			0.41			0.22014			0.73		
11/02/22 3:00	0.9			2			1.6			0.49			0.26538			0.88		
11/02/22 4:00	0.9			2			1.5			0.53			0.28854			0.96		
11/02/22 5:00	0.9			3			1.5			0.56			0.30168			1.01		
11/02/22 6:00	1.6			3			1.5			0.62			0.33546			1.12		
11/02/22 7:00	1.1			6			1.5			0.47			0.252			0.84		
11/02/22 8:00	0.7			6			1.5			0.36			0.19578			0.65		
11/02/22 9:00	0.8			6			1.4			0.37			0.1992			0.66		
11/02/22 10:00	0.9			-1			1.4			0.5			0.2676			0.89		
11/02/22 11:00	1.5			3			1.5			0.6			0.31896			1.06		
11/02/22 12:00	1.4			3			1.5			0.59			0.31638			1.05		
11/02/22 13:00	0.9			2			1.5			0.52			0.28158			0.94		
11/02/22 14:00	1.6			3			1.5			0.58			0.31188			1.04		
11/02/22 15:00	1.3			3			1.5			0.6			0.3183			1.06		
11/02/22 16:00	1			4			1.5			0.64			0.34152			1.14		
11/02/22 17:00	0.7			5			1.5			0.68			0.36366			1.21		
11/02/22 18:00	1.1			4			1.5			0.63			0.3366			1.12		
11/02/22 19:00	1.1			4			1.5			0.63			0.33648			1.12		
11/02/22 20:00	0.8			4			1.5			0.68			0.36192			1.21		
11/02/22 21:00	1			4			1.5			0.66			0.35274			1.18		
11/02/22 22:00	1.2			4			1.5			0.63			0.33654			1.12		
11/02/22 23:00	0.9			3			1.5			0.56			0.30222			1.01		
11/03/22 0:00	0.8			3			1.5			0.56			0.30294			1.01		
11/03/22 1:00	0.9			3			1.5			0.55			0.29742			0.99		
11/03/22 2:00	0.9			2			1.5			0.55			0.2964			0.99		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/22 3:00	0.9			2			1.5			0.56			0.30318			1.01		
11/03/22 4:00	1.5			3			1.5			0.57			0.30414			1.01		
11/03/22 5:00	0.7			7			1.5			0.74			0.39066			1.3		
11/03/22 6:00	0.4			8			1.5			0.77			0.40806			1.36		
11/03/22 7:00	1.2			3			1.5			0.58			0.30924			1.03		
11/03/22 8:00	0.9			2			1.5			0.53			0.28734			0.96		
11/03/22 9:00	2.4			4			1.5			0.59			0.31116			1.04		
11/03/22 10:00	1.4			4			1.6			0.61			0.32898			1.1		
11/03/22 11:00	1			3			1.4			0.47			0.25314			0.84		
11/03/22 12:00	0.7			10			1.5			0.35			0.19032			0.63		
11/03/22 13:00	0.7			6			1.4			0.35			0.18798			0.63		
11/03/22 14:00	0.7			7			1.5			0.34			0.18246			0.61		
11/03/22 15:00	0.7			6			1.4			0.35			0.18684			0.62		
11/03/22 16:00	0.8			1			1.4			0.5			0.2721			0.91		
11/03/22 17:00	1.1			3			1.5			0.64			0.34062			1.14		
11/03/22 18:00	1.1			4			1.5			0.63			0.33696			1.12		
11/03/22 19:00	1.2			4			1.5			0.63			0.33762			1.13		
11/03/22 20:00	0.7			5			1.5			0.7			0.37068			1.24		
11/03/22 21:00	0.6			6			1.5			0.71			0.37884			1.26		
11/03/22 22:00	1.2			4			1.5			0.65			0.34704			1.16		
11/03/22 23:00	1.8			4			1.5			0.59			0.32136			1.07		
11/04/22 0:00	1.1			3			1.5			0.54			0.2922			0.97		
11/04/22 1:00	1			3			1.5			0.53			0.28866			0.96		
11/04/22 2:00	1			2			1.6			0.49			0.2673			0.89		
11/04/22 3:00	0.9			3			1.5			0.51			0.27804			0.93		
11/04/22 4:00	1			3			1.5			0.55			0.29478			0.98		
11/04/22 5:00	1.2			5			1.5			0.66			0.3516			1.17		
11/04/22 6:00	1			4			1.5			0.67			0.35592			1.19		
11/04/22 7:00	1.1			9			1.5			0.47			0.25092			0.84		
11/04/22 8:00	0.7			5			1.4			0.36			0.19278			0.64		
11/04/22 9:00	0.8			8			1.3			0.36			0.19596			0.65		
11/04/22 10:00	0.7			7			1.5			0.35			0.186			0.62		
11/04/22 11:00	0.7			10			1.5			0.33			0.17964			0.6		
11/04/22 12:00	0.6			5			1.5			0.34			0.18486			0.62		
11/04/22 13:00	0.7			7			1.6			0.34			0.18066			0.6		
11/04/22 14:00	0.7			7			1.7			0.34			0.18			0.6		
11/04/22 15:00	0.7			2			1.4			0.4			0.21804			0.73		
11/04/22 16:00	0.8			3			1.5			0.42			0.22692			0.76		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/22 17:00	0.9			1			1.7			0.52			0.28002			0.93		
11/04/22 18:00	1.3			1			1.6			0.61			0.32826			1.09		
11/04/22 19:00	1.2			1			1.7			0.62			0.32862			1.1		
11/04/22 20:00	1.4			1			1.7			0.59			0.31668			1.06		
11/04/22 21:00	0.8			8			2			0.36			0.19446			0.65		
11/04/22 22:00	0.7			10			1.7			0.33			0.18072			0.6		
11/04/22 23:00	0.9			9			0.7			0.39			0.20904			0.7		
11/05/22 0:00	0.7			7			1.6			0.35			0.1869			0.62		
11/05/22 1:00	0.7			6			1.7			0.35			0.18684			0.62		
11/05/22 2:00	0.7			5			1.7			0.35			0.18648			0.62		
11/05/22 3:00	0.7			7			1.7			0.35			0.18576			0.62		
11/05/22 4:00	0.7			6			1.7			0.35			0.18648			0.62		
11/05/22 5:00	0.8			3			1.4			0.38			0.2055			0.69		
11/05/22 6:00	0.7			10			1.6			0.35			0.18624			0.62		
11/05/22 7:00	0.8			2			1.4			0.42			0.22818			0.76		
11/05/22 8:00	0.7			9			1.6			0.34			0.18216			0.61		
11/05/22 9:00	0.7			5			1.6			0.34			0.18426			0.61		
11/05/22 10:00	0.7			4			1.5			0.36			0.19272			0.64		
11/05/22 11:00	0.8			4			1.5			0.38			0.20178			0.67		
11/05/22 12:00	0.8			0			1.5			0.46			0.24828			0.83		
11/05/22 13:00	0.8			2			1.4			0.41			0.2202			0.73		
11/05/22 14:00	0.9			1			1.6			0.51			0.27462			0.92		
11/05/22 15:00	0.7			8			1.5			0.35			0.1857			0.62		
11/05/22 16:00	0.7			2			1.4			0.42			0.22554			0.75		
11/05/22 17:00	1.2			1			1.6			0.52			0.27774			0.93		
11/05/22 18:00	1.5			3			1.6			0.58			0.312			1.04		
11/05/22 19:00	1.5			3			1.6			0.57			0.30666			1.02		
11/05/22 20:00	0.8			5			1.5			0.4			0.2142			0.71		
11/05/22 21:00	0.7			6			1.5			0.36			0.19278			0.64		
11/05/22 22:00	0.6			5			1.6			0.35			0.18606			0.62		
11/05/22 23:00	0.8			-1			1.5			0.5			0.26904			0.9		
11/06/22 0:00	0.9			2			1.6			0.49			0.26436			0.88		
11/06/22 1:00	1			2			1.6			0.43			0.23064			0.77		
11/06/22 2:00	0.9			-1			1.6			0.44			0.2382			0.79		
11/06/22 3:00	0.8			2			1.6			0.52			0.27906			0.93		
11/06/22 4:00	0.9			2			1.6			0.51			0.2772			0.92		
11/06/22 5:00	0.8			2			1.6			0.55			0.29448			0.98		
11/06/22 6:00	0.8			2			1.6			0.55			0.2979			0.99		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/22 7:00	0.8			2			1.6			0.55			0.29772			0.99		
11/06/22 8:00	1.5			3			1.6			0.6			0.32394			1.08		
11/06/22 9:00	1.3			2			1.6			0.57			0.306			1.02		
11/06/22 10:00	0.8			5			1.5			0.37			0.20328			0.68		
11/06/22 11:00	0.7			6			1.7			0.35			0.1896			0.63		
11/06/22 12:00	0.7			5			1.7			0.34			0.18336			0.61		
11/06/22 13:00	0.7			6			1.6			0.35			0.18906			0.63		
11/06/22 14:00	0.8			0			1.5			0.42			0.22566			0.75		
11/06/22 15:00	1.4			2			1.7			0.58			0.3114			1.04		
11/06/22 16:00	0.9			4			1.7			0.66			0.3489			1.16		
11/06/22 17:00	1.1			3			1.7			0.61			0.3282			1.09		
11/06/22 18:00	1.4			3			1.7			0.59			0.31692			1.06		
11/06/22 19:00	1.5			3			1.7			0.58			0.31092			1.04		
11/06/22 20:00	1.4			3			1.7			0.59			0.31506			1.05		
11/06/22 21:00	1.4			3			1.7			0.59			0.31698			1.06		
11/06/22 22:00	1			5			1.7			0.46			0.2454			0.82		
11/06/22 23:00	0.7			5			1.7			0.35			0.18888			0.63		
11/07/22 0:00	0.9			4			1.4			0.39			0.21258			0.71		
11/07/22 1:00	0.9			2			1.5			0.44			0.2376			0.79		
11/07/22 2:00	0.9			1			1.8			0.47			0.25344			0.84		
11/07/22 3:00	0.9			3			1.7			0.44			0.23784			0.79		
11/07/22 4:00	0.9			3			1.5			0.42			0.22512			0.75		
11/07/22 5:00	0.9			2			1.6			0.51			0.27552			0.92		
11/07/22 6:00	0.8			2			1.7			0.55			0.29652			0.99		
11/07/22 7:00	0.9			2			1.7			0.49			0.26382			0.88		
11/07/22 8:00	0.7			8			1.6			0.35			0.18804			0.63		
11/07/22 9:00	0.7			3			1.5			0.35			0.18744			0.62		
11/07/22 10:00	0.7			1			1.5			0.35			0.18582			0.62		
11/07/22 11:00	0.7			1			1.5			0.34			0.1839			0.61		
11/07/22 12:00	0.7			0			1.5			0.35			0.18534			0.62		
11/07/22 13:00	0.7			1			1.5			0.35			0.18582			0.62		
11/07/22 14:00	0.9			0			1.1			0.45			0.2406			0.8		
11/07/22 15:00	1			0			1.5			0.56			0.30204			1.01		
11/07/22 16:00	1			0			1.5			0.64			0.3414			1.14		
11/07/22 17:00	1			0			1.5			0.63			0.34134			1.14		
11/07/22 18:00	1.1			0			1.5			0.63			0.33534			1.12		
11/07/22 19:00	1			0			1.5			0.64			0.33924			1.13		
11/07/22 20:00	1			0			1.5			0.64			0.34146			1.14		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/22 21:00	1			0			1.5			0.64			0.34308			1.14		
11/07/22 22:00	1.2			0			1.5			0.6			0.32586			1.09		
11/07/22 23:00	1.1			1			1.5			0.47			0.25074			0.84		
11/08/22 0:00	0			0	X		0			0.37			0.05562			0.19		
11/08/22 1:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/08/22 2:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/08/22 3:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/08/22 4:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/08/22 5:00	0	X		0	X		0	X		0.58			0	X		0	X	
11/08/22 6:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/08/22 7:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 8:00	0	X		0	X		0	X		0.61			0	X		0	X	
11/08/22 9:00	0	X		0	X		0	X		0.66			0	X		0	X	
11/08/22 10:00	0	X		0	X		0	X		0.61			0	X		0	X	
11/08/22 11:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 12:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 13:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/08/22 14:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/08/22 15:00	0	X		0	X		0	X		0.48			0	X		0	X	
11/08/22 16:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 17:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/08/22 18:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 20:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 21:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 22:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/22 23:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 0:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 1:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 2:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 3:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 4:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 5:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 6:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 7:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 8:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 9:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/09/22 10:00	0	X		0	X		0	X		0.34			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
11/09/22 12:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/09/22 13:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/09/22 14:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/09/22 15:00	0	X		0	X		0	X		0.34			0	X		0	X	
11/09/22 16:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/09/22 17:00	0	X		0	X		0	X		0.56			0	X		0	X	
11/09/22 18:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/09/22 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/22 20:00	0			0	X		0			0.54			0.15156			0.51		
11/09/22 21:00	0.8			1			1.5			0.38			0.20712			0.69		
11/09/22 22:00	0.7			1			1.5			0.34			0.1872			0.62		
11/09/22 23:00	0.7			0			1.5			0.35			0.1887			0.63		
11/10/22 0:00	0.7			0			1.4			0.36			0.19278			0.64		
11/10/22 1:00	0.7			1			1.5			0.35			0.1884			0.63		
11/10/22 2:00	0.7			1			1.5			0.35			0.18882			0.63		
11/10/22 3:00	0.9			0			1.3			0.4			0.21642			0.72		
11/10/22 4:00	1			0			1.6			0.48			0.26118			0.87		
11/10/22 5:00	1.2			0			1.5			0.53			0.28656			0.96		
11/10/22 6:00	0.7			0			1.5			0.71			0.37746			1.26		
11/10/22 7:00	1.5			0			1.5			0.61			0.32466			1.08		
11/10/22 8:00	0.8			1			1.4			0.4			0.21756			0.73		
11/10/22 9:00	0.9			0			1.2			0.44			0.2229			0.74		
11/10/22 10:00	0.7			1			1.4			0.33			0.19284			0.64		
11/10/22 11:00	0.6			1			1.5			0.33			0.18066			0.6		
11/10/22 12:00	0.6			1			1.5			0.33			0.18066			0.6		
11/10/22 13:00	0.6			1			1.5			0.33			0.18042			0.6		
11/10/22 14:00	0.7			1			1.5			0.33			0.1803			0.6		
11/10/22 15:00	0.8			0			1.4			0.44			0.2382			0.79		
11/10/22 16:00	0.8			0			1.5			0.67			0.35538			1.18		
11/10/22 17:00	0.8			0			1.5			0.67			0.35304			1.18		
11/10/22 18:00	1.1			0			1.5			0.64			0.33924			1.13		
11/10/22 19:00	1.2			0			1.5			0.62			0.33384			1.11		
11/10/22 20:00	1.2			0			1.5			0.63			0.3393			1.13		
11/10/22 21:00	0.9			0			1.5			0.67			0.3567			1.19		
11/10/22 22:00	1			0			1.5			0.65			0.34734			1.16		
11/10/22 23:00	1.3			0			1.5			0.62			0.3336			1.11		
11/11/22 0:00	0.9			0			1.5			0.67			0.36018			1.2		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/22 1:00	1			0			1.5			0.66			0.35136			1.17		
11/11/22 2:00	1.2			0			1.7			0.59			0.31842			1.06		
11/11/22 3:00	0.9			0			1.5			0.53			0.28632			0.95		
11/11/22 4:00	1.1			0			1.5			0.56			0.30504			1.02		
11/11/22 5:00	0.9			0			1.5			0.68			0.3606			1.2		
11/11/22 6:00	0.8			0			1.5			0.68			0.36414			1.21		
11/11/22 7:00	1.4			0			1.5			0.58			0.31158			1.04		
11/11/22 8:00	0.8			1			1.5			0.35			0.18858			0.63		
11/11/22 9:00	0.7			1			1.5			0.35			0.18744			0.62		
11/11/22 10:00	0.7			1			1.5			0.35			0.18978			0.63		
11/11/22 11:00	0.7			1			1.5			0.35			0.18708			0.62		
11/11/22 12:00	0.7			1			1.5			0.35			0.18636			0.62		
11/11/22 13:00	0.7			1			1.5			0.35			0.18648			0.62		
11/11/22 14:00	0.7			0			1.5			0.36			0.19068			0.64		
11/11/22 15:00	1			0			1.4			0.54			0.28794			0.96		
11/11/22 16:00	1			0			1.5			0.65			0.3459			1.15		
11/11/22 17:00	1.2			0			1.5			0.63			0.33336			1.11		
11/11/22 18:00	1.1			0			1.5			0.63			0.33438			1.11		
11/11/22 19:00	1.1			0			1.5			0.62			0.33414			1.11		
11/11/22 20:00	1.2			0			1.5			0.63			0.33732			1.12		
11/11/22 21:00	0.9			0			1.5			0.67			0.35742			1.19		
11/11/22 22:00	1			0			1.5			0.66			0.35196			1.17		
11/11/22 23:00	1.2			0			1.5			0.63			0.33864			1.13		
11/12/22 0:00	0.9			0			1.5			0.67			0.35766			1.19		
11/12/22 1:00	0.9			0			1.5			0.67			0.35748			1.19		
11/12/22 2:00	0.9			0			1.5			0.67			0.35832			1.19		
11/12/22 3:00	0.7			1			1.5			0.69			0.369			1.23		
11/12/22 4:00	0.8			0			1.5			0.69			0.36606			1.22		
11/12/22 5:00	0.8			0			1.5			0.68			0.36366			1.21		
11/12/22 6:00	0.8			0			1.5			0.68			0.36348			1.21		
11/12/22 7:00	1.4			0			1.5			0.6			0.32352			1.08		
11/12/22 8:00	0.8			0			1.5			0.69			0.36906			1.23		
11/12/22 9:00	1.1			0			1.5			0.64			0.34236			1.14		
11/12/22 10:00	1.2			0			1.5			0.61			0.32886			1.1		
11/12/22 11:00	1.1			0			1.5			0.57			0.30528			1.02		
11/12/22 12:00	0.9			0			1.5			0.55			0.29844			0.99		
11/12/22 13:00	0.9			0			1.5			0.55			0.29418			0.98		
11/12/22 14:00	1.1			0			1.5			0.59			0.3159			1.05		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/22 15:00	1.1			0			1.5			0.61			0.3279			1.09		
11/12/22 16:00	1			0			1.5			0.64			0.34116			1.14		
11/12/22 17:00	1.1			0			1.5			0.64			0.33858			1.13		
11/12/22 18:00	1.1			0			1.5			0.62			0.33222			1.11		
11/12/22 19:00	1.1			0			1.5			0.65			0.34518			1.15		
11/12/22 20:00	1.2			0			1.5			0.63			0.33468			1.12		
11/12/22 21:00	1.1			0			1.5			0.63			0.33906			1.13		
11/12/22 22:00	1			0			1.5			0.64			0.34458			1.15		
11/12/22 23:00	1.2			0			1.5			0.62			0.33162			1.11		
11/13/22 0:00	1			0			1.5			0.55			0.29784			0.99		
11/13/22 1:00	0.9			0			1.5			0.54			0.29112			0.97		
11/13/22 2:00	0.9			0			1.5			0.53			0.28806			0.96		
11/13/22 3:00	0.9			0			1.5			0.56			0.3018			1.01		
11/13/22 4:00	0.9			0			1.5			0.56			0.30186			1.01		
11/13/22 5:00	0.9			0			1.5			0.56			0.30126			1		
11/13/22 6:00	1.1			0			1.5			0.57			0.30624			1.02		
11/13/22 7:00	1.2			0			1.5			0.63			0.33768			1.13		
11/13/22 8:00	1.3			0			1.5			0.57			0.30564			1.02		
11/13/22 9:00	1			0			1.5			0.65			0.34656			1.16		
11/13/22 10:00	0.9			0			1.5			0.55			0.3009			1		
11/13/22 11:00	0.9			0			1.5			0.55			0.29436			0.98		
11/13/22 12:00	0.9			0			1.5			0.53			0.2889			0.96		
11/13/22 13:00	0.9			0			1.5			0.52			0.2817			0.94		
11/13/22 14:00	0.9			0			1.5			0.48			0.26034			0.87		
11/13/22 15:00	0.9			0			1.4			0.47			0.25344			0.84		
11/13/22 16:00	0.9			0			1.5			0.66			0.35262			1.18		
11/13/22 17:00	0.8			0			1.5			0.67			0.35814			1.19		
11/13/22 18:00	0.8			0			1.5			0.67			0.35556			1.19		
11/13/22 19:00	1			0			1.5			0.64			0.3435			1.15		
11/13/22 20:00	1.2			0			1.5			0.63			0.3363			1.12		
11/13/22 21:00	0.9			0			1.5			0.67			0.36024			1.2		
11/13/22 22:00	1			0			1.5			0.66			0.35544			1.18		
11/13/22 23:00	1			0			1.5			0.65			0.35208			1.17		
11/14/22 0:00	1.2			0			1.5			0.6			0.32562			1.09		
11/14/22 1:00	0.9			0			1.5			0.55			0.29988			1		
11/14/22 2:00	0.9			0			1.5			0.55			0.29976			1		
11/14/22 3:00	1			0			1.5			0.53			0.28416			0.95		
11/14/22 4:00	0.9			0			1.5			0.54			0.29268			0.98		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/22 5:00	1.1			0			1.5			0.66			0.35424			1.18		
11/14/22 6:00	0.4			1			1.5			0.78			0.41442			1.38		
11/14/22 7:00	0.7			1			1.5			0.72			0.38004			1.27		
11/14/22 8:00	1.2			0			1.5			0.64			0.34128			1.14		
11/14/22 9:00	1.2			0			1.5			0.6			0.32382			1.08		
11/14/22 10:00	0.9			0			1.5			0.54			0.2913			0.97		
11/14/22 11:00	0.9			0			1.5			0.49			0.26472			0.88		
11/14/22 12:00	1			0			1.4			0.45			0.24168			0.81		
11/14/22 13:00	0.9			0			1.5			0.49			0.26526			0.88		
11/14/22 14:00	0.9			0			1.5			0.52			0.28314			0.94		
11/14/22 15:00	1			0			1.5			0.56			0.30312			1.01		
11/14/22 16:00	0.8			0			1.5			0.68			0.36054			1.2		
11/14/22 17:00	0.6			1			1.5			0.7			0.36942			1.23		
11/14/22 18:00	0.8			1			1.5			0.68			0.36036			1.2		
11/14/22 19:00	1			0			1.3			0.67			0.35532			1.18		
11/14/22 20:00	0.8			0			1.5			0.69			0.3696			1.23		
11/14/22 21:00	0.9			0			1.5			0.68			0.36498			1.22		
11/14/22 22:00	0.9			0			1.5			0.68			0.36402			1.21		
11/14/22 23:00	1.1			0			1.5			0.65			0.34728			1.16		
11/15/22 0:00	0.9			0			1.5			0.7			0.37158			1.24		
11/15/22 1:00	0.8			1			1.5			0.7			0.37356			1.25		
11/15/22 2:00	0.7			0			1.3			0.71			0.3765			1.26		
11/15/22 3:00	0.8			1			1.5			0.7			0.37188			1.24		
11/15/22 4:00	0.7			1			1.5			0.71			0.37614			1.25		
11/15/22 5:00	0.8			1			1.5			0.71			0.37614			1.25		
11/15/22 6:00	0.7			1			1.5			0.72			0.3846			1.28		
11/15/22 7:00	0.8			1			1.5			0.71			0.37554			1.25		
11/15/22 8:00	1.1			0			1.5			0.65			0.34572			1.15		
11/15/22 9:00	1.1			0			1.5			0.53			0.28662			0.96		
11/15/22 10:00	1			0			1.4			0.44			0.24024			0.8		
11/15/22 11:00	0.9			1			1.4			0.39			0.21276			0.71		
11/15/22 12:00	0.7			1			1.5			0.34			0.18486			0.62		
11/15/22 13:00	0.7			1			1.5			0.34			0.18354			0.61		
11/15/22 14:00	0.7			1			1.5			0.34			0.18492			0.62		
11/15/22 15:00	0.9			0			1.4			0.45			0.24252			0.81		
11/15/22 16:00	0.8			0			1.5			0.66			0.35118			1.17		
11/15/22 17:00	0.7			0			1.5			0.68			0.36144			1.2		
11/15/22 18:00	0.7			1			1.5			0.69			0.36684			1.22		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/22 19:00	0.9			0			1.5			0.67			0.35658			1.19		
11/15/22 20:00	1			0			1.5			0.66			0.35028			1.17		
11/15/22 21:00	0.9			0			1.5			0.67			0.35382			1.18		
11/15/22 22:00	1.2			0			1.5			0.62			0.3321			1.11		
11/15/22 23:00	1.2			0			1.5			0.63			0.3348			1.12		
11/16/22 0:00	1.2			0			1.5			0.64			0.3411			1.14		
11/16/22 1:00	1.2			0			1.5			0.64			0.34224			1.14		
11/16/22 2:00	1.2			0			1.5			0.64			0.33984			1.13		
11/16/22 3:00	1.2			0			1.5			0.64			0.34206			1.14		
11/16/22 4:00	1			0			1.5			0.67			0.35844			1.19		
11/16/22 5:00	1			0			1.5			0.68			0.36348			1.21		
11/16/22 6:00	0.8			1			1.5			0.71			0.37848			1.26		
11/16/22 7:00	1			0			1.5			0.68			0.36432			1.21		
11/16/22 8:00	1.7			0			1.5			0.54			0.28854			0.96		
11/16/22 9:00	1			0			1.5			0.49			0.2622			0.87		
11/16/22 10:00	0.9			1			1.4			0.38			0.20514			0.68		
11/16/22 11:00	0.8			1			1.4			0.35			0.19092			0.64		
11/16/22 12:00	1			0			1.5			0.46			0.25068			0.84		
11/16/22 13:00	1			0			1.5			0.43			0.23424			0.78		
11/16/22 14:00	0.7			1			1.5			0.34			0.18258			0.61		
11/16/22 15:00	0.9			0			1.4			0.48			0.25818			0.86		
11/16/22 16:00	1.3			0			1.5			0.56			0.29832			0.99		
11/16/22 17:00	1			0			1.5			0.58			0.34554			1.15		
11/16/22 18:00	0.6			1			1.5			0.7			0.37686			1.26		
11/16/22 19:00	0.7			0			1.5			0.7			0.369			1.23		
11/16/22 20:00	1.3			0			1.5			0.6			0.32196			1.07		
11/16/22 21:00	0.8			1			1.5			0.71			0.37212			1.24		
11/16/22 22:00	0.9			0			1.5			0.69			0.3645			1.22		
11/16/22 23:00	1			0			1.5			0.66			0.34998			1.17		
11/17/22 0:00	1			0			1.5			0.55			0.29922			1		
11/17/22 1:00	1			0			1.5			0.55			0.30018			1		
11/17/22 2:00	1			0			1.5			0.55			0.29586			0.99		
11/17/22 3:00	1			0			1.5			0.55			0.29616			0.99		
11/17/22 4:00	1			0			1.5			0.55			0.29928			1		
11/17/22 5:00	1			0			1.5			0.55			0.29964			1		
11/17/22 6:00	1.4			0			1.5			0.56			0.30462			1.02		
11/17/22 7:00	1.4			0			1.5			0.63			0.33534			1.12		
11/17/22 8:00	1.1			1			1.5			0.4			0.2172			0.72		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/22 9:00	1			0			1.3			0.53			0.28854			0.96		
11/17/22 10:00	1.3			0			1.5			0.63			0.33888			1.13		
11/17/22 11:00	1.1			0			1.5			0.55			0.29694			0.99		
11/17/22 12:00	0.9			0			1.5			0.56			0.30042			1		
11/17/22 13:00	1.1			0			1.5			0.63			0.33408			1.11		
11/17/22 14:00	1.2			0			1.5			0.61			0.32502			1.08		
11/17/22 15:00	0.9			0			1.5			0.65			0.34458			1.15		
11/17/22 16:00	0.8			0			1.5			0.67			0.35424			1.18		
11/17/22 17:00	0.7			1			1.5			0.69			0.36576			1.22		
11/17/22 18:00	0.7			1			1.5			0.69			0.366			1.22		
11/17/22 19:00	0.8			1			1.5			0.7			0.36768			1.23		
11/17/22 20:00	1			0			1.5			0.68			0.36096			1.2		
11/17/22 21:00	1.2			0			1.5			0.65			0.34908			1.16		
11/17/22 22:00	1.3			0			1.5			0.64			0.34446			1.15		
11/17/22 23:00	1.4			0			1.5			0.64			0.34074			1.14		
11/18/22 0:00	1.1			0			1.5			0.68			0.3606			1.2		
11/18/22 1:00	1.2			0			1.5			0.65			0.35022			1.17		
11/18/22 2:00	1.2			0			1.1			0.66			0.35274			1.18		
11/18/22 3:00	1			0			1.5			0.69			0.36702			1.22		
11/18/22 4:00	0.9			1			1.5			0.7			0.37212			1.24		
11/18/22 5:00	0.8			1			1.5			0.72			0.38418			1.28		
11/18/22 6:00	0.5			1			1.5			0.8			0.42324			1.41		
11/18/22 7:00	0.8			1			1.5			0.72			0.38052			1.27		
11/18/22 8:00	0.9			0			1.5			0.69			0.36528			1.22		
11/18/22 9:00	1			0			1.5			0.66			0.35352			1.18		
11/18/22 10:00	1.1			0			1.5			0.64			0.34326			1.14		
11/18/22 11:00	1.1			0			1.5			0.63			0.3363			1.12		
11/18/22 12:00	1.2			0			1.5			0.62			0.32814			1.09		
11/18/22 13:00	1.1			0			1.5			0.62			0.32952			1.1		
11/18/22 14:00	1.1			0			1.5			0.62			0.32976			1.1		
11/18/22 15:00	0.9			0			1.5			0.65			0.34182			1.14		
11/18/22 16:00	0.6			1			1.5			0.7			0.37098			1.24		
11/18/22 17:00	0.5			1			1.5			0.72			0.38232			1.27		
11/18/22 18:00	0.5			1			1.5			0.72			0.3819			1.27		
11/18/22 19:00	0.7			1			1.5			0.7			0.3735			1.25		
11/18/22 20:00	0.6			1			1.5			0.72			0.37914			1.26		
11/18/22 21:00	0.6			1			1.5			0.72			0.3804			1.27		
11/18/22 22:00	0.7			1			1.5			0.7			0.37326			1.24		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/22 23:00	0.9			0			1.5			0.68			0.36438			1.21		
11/19/22 0:00	1.1			0			1.5			0.65			0.34596			1.15		
11/19/22 1:00	1.2			0			1.5			0.65			0.34506			1.15		
11/19/22 2:00	1.2			0			1.5			0.64			0.34194			1.14		
11/19/22 3:00	1.4			0			1.5			0.63			0.33534			1.12		
11/19/22 4:00	1.1			0			1.5			0.66			0.35502			1.18		
11/19/22 5:00	0.9			1			1.5			0.69			0.36696			1.22		
11/19/22 6:00	0.8			1			1.5			0.71			0.37608			1.25		
11/19/22 7:00	0.9			1			1.5			0.7			0.3714			1.24		
11/19/22 8:00	1			1			1.5			0.47			0.25272			0.84		
11/19/22 9:00	0.7			1			1.5			0.35			0.18648			0.62		
11/19/22 10:00	0.8			1			1.4			0.35			0.18906			0.63		
11/19/22 11:00	0.8			1			1.5			0.35			0.18888			0.63		
11/19/22 12:00	0.8			1			1.5			0.35			0.18876			0.63		
11/19/22 13:00	0.8			1			1.5			0.35			0.18846			0.63		
11/19/22 14:00	0.7			1			1.5			0.34			0.18318			0.61		
11/19/22 15:00	0.9			0			1.4			0.41			0.2232			0.74		
11/19/22 16:00	0.9			0			1.5			0.67			0.35478			1.18		
11/19/22 17:00	1			0			1.5			0.65			0.34602			1.15		
11/19/22 18:00	1.2			0			1.5			0.65			0.34614			1.15		
11/19/22 19:00	0.8			1			1.5			0.69			0.36792			1.23		
11/19/22 20:00	0.7			1			1.5			0.71			0.37716			1.26		
11/19/22 21:00	0.7			1			1.5			0.71			0.37704			1.26		
11/19/22 22:00	0.7			1			1.5			0.71			0.37806			1.26		
11/19/22 23:00	0.8			1			1.5			0.72			0.3813			1.27		
11/20/22 0:00	0.7			1			1.5			0.71			0.381			1.27		
11/20/22 1:00	0.8			1			1.5			0.72			0.3819			1.27		
11/20/22 2:00	0.9			1			1.5			0.72			0.38232			1.27		
11/20/22 3:00	0.8			1			1.5			0.72			0.38142			1.27		
11/20/22 4:00	0.8			1			1.5			0.72			0.3819			1.27		
11/20/22 5:00	0.9			1			1.5			0.71			0.37686			1.26		
11/20/22 6:00	1			1			1.5			0.69			0.36774			1.23		
11/20/22 7:00	1.3			0			1.5			0.65			0.34704			1.16		
11/20/22 8:00	1.3			0			1.5			0.56			0.30162			1.01		
11/20/22 9:00	1.2			0			1.5			0.58			0.31194			1.04		
11/20/22 10:00	2			0			1.5			0.59			0.30756			1.03		
11/20/22 11:00	1.8			0			1.5			0.58			0.30468			1.02		
11/20/22 12:00	1.2			0			1.5			0.54			0.29088			0.97		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/22 13:00	1.2			0			1.5			0.62			0.32874			1.1		
11/20/22 14:00	1.1			0			1.5			0.53			0.2865			0.96		
11/20/22 15:00	1.1			0			1.5			0.5			0.26844			0.89		
11/20/22 16:00	0.9			0			1.5			0.66			0.34974			1.17		
11/20/22 17:00	1			0			1.5			0.66			0.34812			1.16		
11/20/22 18:00	1.2			0			1.5			0.64			0.3426			1.14		
11/20/22 19:00	1.2			0			1.5			0.64			0.34416			1.15		
11/20/22 20:00	1.3			0			1.5			0.64			0.34368			1.15		
11/20/22 21:00	1.5			0			1.5			0.63			0.33612			1.12		
11/20/22 22:00	1.4			0			1.5			0.62			0.33462			1.12		
11/20/22 23:00	1.5			0			1.5			0.61			0.32934			1.1		
11/21/22 0:00	1.4			0			1.5			0.64			0.34398			1.15		
11/21/22 1:00	1.5			0			1.5			0.63			0.33498			1.12		
11/21/22 2:00	1.6			0			1.4			0.62			0.33378			1.11		
11/21/22 3:00	1.5			0			1.5			0.64			0.3444			1.15		
11/21/22 4:00	1.2			1			1.5			0.68			0.36528			1.22		
11/21/22 5:00	1.4			1			1.5			0.68			0.36516			1.22		
11/21/22 6:00	0.9			1			1.5			0.71			0.38016			1.27		
11/21/22 7:00	1.6			0			1.5			0.63			0.33672			1.12		
11/21/22 8:00	1.2			1			1.5			0.41			0.21828			0.73		
11/21/22 9:00	0.8			1			1.5			0.35			0.1869			0.62		
11/21/22 10:00	0.8			1			1.5			0.35			0.1878			0.63		
11/21/22 11:00	0.8			1			1.4			0.35			0.18906			0.63		
11/21/22 12:00	0.8			1			1.3			0.36			0.19356			0.65		
11/21/22 13:00	0.8			1			1.5			0.35			0.18696			0.62		
11/21/22 14:00	1.1			0			1.4			0.51			0.27678			0.92		
11/21/22 15:00	0.9			0			1.5			0.65			0.34266			1.14		
11/21/22 16:00	0.9			0			1.5			0.66			0.348			1.16		
11/21/22 17:00	1			0			1.5			0.65			0.3489			1.16		
11/21/22 18:00	1			0			1.5			0.65			0.3456			1.15		
11/21/22 19:00	1.1			0			1.5			0.65			0.3462			1.15		
11/21/22 20:00	1.2			0			1.5			0.65			0.34914			1.16		
11/21/22 21:00	1.1			0			1.5			0.67			0.35604			1.19		
11/21/22 22:00	1.2			0			1.5			0.66			0.35202			1.17		
11/21/22 23:00	1.4			0			1.5			0.63			0.33582			1.12		
11/22/22 0:00	1.1			0			1.5			0.57			0.30606			1.02		
11/22/22 1:00	1			0			1.5			0.56			0.30204			1.01		
11/22/22 2:00	1.2			0			1.5			0.55			0.29958			1		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/22 3:00	1.2			0			1.5			0.52			0.28386			0.95		
11/22/22 4:00	1.1			0			1.5			0.54			0.28998			0.97		
11/22/22 5:00	1			0			1.5			0.55			0.29646			0.99		
11/22/22 6:00	1			0			1.5			0.57			0.30882			1.03		
11/22/22 7:00	1.1			1			1.5			0.42			0.22788			0.76		
11/22/22 8:00	1.6			0			1.4			0.5			0.26298			0.88		
11/22/22 9:00	1.3			0			1.5			0.65			0.3453			1.15		
11/22/22 10:00	1.2			0			1.5			0.56			0.30462			1.02		
11/22/22 11:00	1.3			0			1.5			0.61			0.32742			1.09		
11/22/22 12:00	1			0			1.5			0.66			0.34878			1.16		
11/22/22 13:00	0.9			0			1.5			0.66			0.351			1.17		
11/22/22 14:00	1			0			1.5			0.65			0.34326			1.14		
11/22/22 15:00	1.1			0			1.5			0.63			0.33426			1.11		
11/22/22 16:00	1.2			0			1.5			0.63			0.33522			1.12		
11/22/22 17:00	1.3			0			1.5			0.61			0.32496			1.08		
11/22/22 18:00	1.4			0			1.5			0.61			0.32382			1.08		
11/22/22 19:00	1.4			0			1.5			0.6			0.32508			1.08		
11/22/22 20:00	1.3			0			1.5			0.62			0.33036			1.1		
11/22/22 21:00	1.5			0			1.5			0.54			0.29382			0.98		
11/22/22 22:00	1.3			1			1.5			0.42			0.22638			0.75		
11/22/22 23:00	1.1			1			1.4			0.36			0.19488			0.65		
11/23/22 0:00	1.2			0			1.4			0.48			0.25878			0.86		
11/23/22 1:00	1.2			0			1.5			0.43			0.2352			0.78		
11/23/22 2:00	1.1			0			1.5			0.47			0.2526			0.84		
11/23/22 3:00	1.1			0			1.5			0.48			0.26118			0.87		
11/23/22 4:00	1.1			0			1.5			0.5			0.26892			0.9		
11/23/22 5:00	1.2			0			1.5			0.53			0.2856			0.95		
11/23/22 6:00	1.1			0			1.5			0.53			0.28722			0.96		
11/23/22 7:00	1.2			1			1.6			0.43			0.23118			0.77		
11/23/22 8:00	1			1			1.4			0.37			0.19806			0.66		
11/23/22 9:00	1			1			1.3			0.4			0.2136			0.71		
11/23/22 10:00	1			0			1.3			0.41			0.2241			0.75		
11/23/22 11:00	1.4			0			1.4			0.54			0.29106			0.97		
11/23/22 12:00	1.2			0			1.5			0.61			0.32802			1.09		
11/23/22 13:00	1.2			0			1.5			0.54			0.2874			0.96		
11/23/22 14:00	0.8			1			1.4			0.35			0.18594			0.62		
11/23/22 15:00	1			0			1.4			0.41			0.22218			0.74		
11/23/22 16:00	1			0			1.5			0.64			0.34224			1.14		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/22 17:00	1.1			0			1.5			0.64			0.3417			1.14		
11/23/22 18:00	1.3			0			1.5			0.61			0.32742			1.09		
11/23/22 19:00	1.3			0			1.5			0.6			0.32424			1.08		
11/23/22 20:00	1.3			0			1.5			0.62			0.3318			1.11		
11/23/22 21:00	1.3			0			1.5			0.65			0.34464			1.15		
11/23/22 22:00	1.3			0			1.5			0.64			0.34392			1.15		
11/23/22 23:00	1.4			0			1.5			0.63			0.33504			1.12		
11/24/22 0:00	1.3			0			1.5			0.64			0.34188			1.14		
11/24/22 1:00	1.4			0			1.5			0.63			0.33582			1.12		
11/24/22 2:00	1.2			0			1.3			0.52			0.28242			0.94		
11/24/22 3:00	1.1			0			1.5			0.53			0.2871			0.96		
11/24/22 4:00	1.1			0			1.5			0.53			0.28704			0.96		
11/24/22 5:00	1.4			0			1.5			0.56			0.30012			1		
11/24/22 6:00	1.5			0			1.5			0.57			0.30948			1.03		
11/24/22 7:00	1.3			0			1.5			0.65			0.35412			1.18		
11/24/22 8:00	1.3			0			1.5			0.64			0.3405			1.14		
11/24/22 9:00	1.2			0			1.5			0.64			0.34398			1.15		
11/24/22 10:00	1.1			0			1.5			0.65			0.34494			1.15		
11/24/22 11:00	1.2			0			1.5			0.62			0.32982			1.1		
11/24/22 12:00	1.2			0			1.5			0.62			0.32934			1.1		
11/24/22 13:00	1.2			0			1.5			0.62			0.32832			1.09		
11/24/22 14:00	1			1			1.5			0.4			0.21606			0.72		
11/24/22 15:00	1			0			1.4			0.45			0.24096			0.8		
11/24/22 16:00	1			0			1.5			0.65			0.34428			1.15		
11/24/22 17:00	1.2			0			1.5			0.62			0.3309			1.1		
11/24/22 18:00	1.3			0			1.5			0.61			0.32616			1.09		
11/24/22 19:00	1.3			0			1.5			0.61			0.3255			1.09		
11/24/22 20:00	1.3			0			1.5			0.61			0.32484			1.08		
11/24/22 21:00	1.3			0			1.5			0.61			0.3252			1.08		
11/24/22 22:00	1.4			0			1.5			0.61			0.32802			1.09		
11/24/22 23:00	1.5			0			1.5			0.6			0.32226			1.07		
11/25/22 0:00	1.5			0			1.5			0.6			0.32232			1.07		
11/25/22 1:00	1.6			0			1.5			0.6			0.3213			1.07		
11/25/22 2:00	1.7			0			1.5			0.6			0.31992			1.07		
11/25/22 3:00	1.6			0			1.5			0.61			0.32604			1.09		
11/25/22 4:00	1.4			0			1.5			0.63			0.33648			1.12		
11/25/22 5:00	1.5			0			1.5			0.63			0.33864			1.13		
11/25/22 6:00	1.3			0			1.5			0.64			0.34494			1.15		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/22 7:00	1.5			0			1.5			0.62			0.33396			1.11		
11/25/22 8:00	1.7			0			1.5			0.6			0.31782			1.06		
11/25/22 9:00	1.1			1			1.5			0.4			0.21642			0.72		
11/25/22 10:00	0.8			1			1.5			0.34			0.1839			0.61		
11/25/22 11:00	0.8			1			1.5			0.33			0.18024			0.6		
11/25/22 12:00	0.8			1			1.5			0.33			0.1797			0.6		
11/25/22 13:00	0.8			1			1.5			0.34			0.17994			0.6		
11/25/22 14:00	0.8			1			1.5			0.34			0.18306			0.61		
11/25/22 15:00	1			0			1.4			0.42			0.22392			0.75		
11/25/22 16:00	1.2			0			1.5			0.63			0.33396			1.11		
11/25/22 17:00	1.1			0			1.5			0.63			0.33504			1.12		
11/25/22 18:00	1.3			0			1.5			0.61			0.32628			1.09		
11/25/22 19:00	1.4			0			1.5			0.6			0.32346			1.08		
11/25/22 20:00	1.4			0			1.5			0.6			0.32418			1.08		
11/25/22 21:00	1.5			0			1.5			0.6			0.32484			1.08		
11/25/22 22:00	1.4			0			1.5			0.63			0.33618			1.12		
11/25/22 23:00	1.4			0			1.5			0.62			0.33192			1.11		
11/26/22 0:00	1.3			0			1.5			0.65			0.34512			1.15		
11/26/22 1:00	1.5			0			1.5			0.64			0.34368			1.15		
11/26/22 2:00	1.5			0			1.6			0.64			0.345			1.15		
11/26/22 3:00	1.5			0			1.5			0.65			0.34446			1.15		
11/26/22 4:00	1.5			0			1.5			0.65			0.3441			1.15		
11/26/22 5:00	1			0			1.5			0.69			0.36642			1.22		
11/26/22 6:00	0.8			0			1.5			0.71			0.37476			1.25		
11/26/22 7:00	1.3			0			1.5			0.65			0.34458			1.15		
11/26/22 8:00	1.9			0			1.5			0.56			0.3033			1.01		
11/26/22 9:00	1.4			0			1.5			0.63			0.33708			1.12		
11/26/22 10:00	1.2			0			1.4			0.47			0.25452			0.85		
11/26/22 11:00	0.8			1			1.6			0.34			0.18396			0.61		
11/26/22 12:00	0.8			1			1.5			0.35			0.18528			0.62		
11/26/22 13:00	0.8			1			1.5			0.33			0.17922			0.6		
11/26/22 14:00	0.8			1			1.5			0.34			0.18192			0.61		
11/26/22 15:00	0.9			0			1.4			0.44			0.23862			0.8		
11/26/22 16:00	1.1			0			1.5			0.62			0.32622			1.09		
11/26/22 17:00	1.2			0			1.5			0.62			0.33222			1.11		
11/26/22 18:00	1.3			0			1.5			0.61			0.327			1.09		
11/26/22 19:00	1.3			0			1.5			0.61			0.32586			1.09		
11/26/22 20:00	1.2			0			1.5			0.63			0.33702			1.12		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/22 21:00	1.2			0			1.5			0.64			0.34086			1.14		
11/26/22 22:00	1.4			0			1.5			0.61			0.32712			1.09		
11/26/22 23:00	1.5			0			1.5			0.61			0.32856			1.1		
11/27/22 0:00	1.3			0			1.5			0.65			0.34878			1.16		
11/27/22 1:00	1.4			0			1.5			0.63			0.33936			1.13		
11/27/22 2:00	1.5			0			1.4			0.61			0.32766			1.09		
11/27/22 3:00	1.3			0			1.5			0.64			0.34488			1.15		
11/27/22 4:00	1.3			0			1.5			0.65			0.34524			1.15		
11/27/22 5:00	1.4			0			1.5			0.62			0.33444			1.11		
11/27/22 6:00	1.3			0			1.5			0.64			0.34302			1.14		
11/27/22 7:00	1.4			1			1.5			0.54			0.28962			0.97		
11/27/22 8:00	1			1			1.5			0.34			0.18558			0.62		
11/27/22 9:00	0.9			1			1.5			0.34			0.18348			0.61		
11/27/22 10:00	0.9			1			1.5			0.35			0.18708			0.62		
11/27/22 11:00	0.9			1			1.5			0.34			0.18354			0.61		
11/27/22 12:00	0.8			1			1.5			0.33			0.17934			0.6		
11/27/22 13:00	0.8			1			1.5			0.33			0.17922			0.6		
11/27/22 14:00	0.8			1			1.5			0.33			0.1791			0.6		
11/27/22 15:00	1.1			0			1.3			0.5			0.26424			0.88		
11/27/22 16:00	1.1			0			1.5			0.63			0.33594			1.12		
11/27/22 17:00	1.1			0			1.5			0.65			0.34566			1.15		
11/27/22 18:00	1.2			0			1.5			0.65			0.34446			1.15		
11/27/22 19:00	1.3			0			1.5			0.64			0.3408			1.14		
11/27/22 20:00	1.4			0			1.5			0.62			0.33444			1.11		
11/27/22 21:00	1.1			0			1.5			0.66			0.3543			1.18		
11/27/22 22:00	1.3			0			1.5			0.61			0.3303			1.1		
11/27/22 23:00	1.4			0			1.5			0.6			0.32466			1.08		
11/28/22 0:00	1.4			0			1.5			0.63			0.33576			1.12		
11/28/22 1:00	1.5			0			1.5			0.61			0.32868			1.1		
11/28/22 2:00	1.8			0			1.6			0.6			0.32178			1.07		
11/28/22 3:00	1.6			0			1.5			0.6			0.32454			1.08		
11/28/22 4:00	1.7			0			1.5			0.6			0.32226			1.07		
11/28/22 5:00	1.6			0			1.5			0.62			0.33102			1.1		
11/28/22 6:00	1.2			0			1.5			0.67			0.35832			1.19		
11/28/22 7:00	1			1			1.5			0.68			0.36162			1.21		
11/28/22 8:00	1.5			0			1.5			0.6			0.32448			1.08		
11/28/22 9:00	1.3			1			1.5			0.46			0.25092			0.84		
11/28/22 10:00	1			1			1.5			0.35			0.18786			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/22 11:00	0.9			1			1.5			0.34			0.18336			0.61		
11/28/22 12:00	0.8			1			1.5			0.33			0.17922			0.6		
11/28/22 13:00	0.8			1			1.5			0.33			0.17952			0.6		
11/28/22 14:00	0.8			1			1.5			0.34			0.18048			0.6		
11/28/22 15:00	1			0			1.4			0.45			0.24216			0.81		
11/28/22 16:00	1.2			0			1.5			0.63			0.33414			1.11		
11/28/22 17:00	1.4			0			1.5			0.62			0.33348			1.11		
11/28/22 18:00	1.4			0			1.5			0.61			0.32538			1.08		
11/28/22 19:00	1.3			0			1.5			0.61			0.3255			1.09		
11/28/22 20:00	1.2			0			1.5			0.63			0.33534			1.12		
11/28/22 21:00	1.1			0			1.5			0.66			0.35364			1.18		
11/28/22 22:00	1.4			0			1.5			0.62			0.33018			1.1		
11/28/22 23:00	1.6			0			1.5			0.6			0.3216			1.07		
11/29/22 0:00	1.3			0			1.5			0.56			0.30192			1.01		
11/29/22 1:00	1.3			0			1.5			0.57			0.30684			1.02		
11/29/22 2:00	1.2			0			1.5			0.57			0.30648			1.02		
11/29/22 3:00	1.2			0			1.5			0.54			0.29208			0.97		
11/29/22 4:00	1.1			0			1.5			0.55			0.2958			0.99		
11/29/22 5:00	1.1			0			1.5			0.57			0.31002			1.03		
11/29/22 6:00	1.5			0			1.5			0.58			0.31188			1.04		
11/29/22 7:00	0.8			1			1.5			0.77			0.39084			1.3		
11/29/22 8:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/29/22 9:00	0	X		0	X		0	X		0.55			0	X		0	X	
11/29/22 10:00	0	X		0	X		0	X		0.55			0	X		0	X	
11/29/22 11:00	0			0	X		0			0.55			0.0594			0.2		
11/29/22 12:00	1			0			0.7			0.46			0.23772			0.79		
11/29/22 13:00	1			0			1.5			0.55			0.29724			0.99		
11/29/22 14:00	0.5			1			1.5			0.71			0.37428			1.25		
11/29/22 15:00	0.6			1			1.5			0.71			0.37464			1.25		
11/29/22 16:00	0.6			1			1.5			0.72			0.3801			1.27		
11/29/22 17:00	0.7			1			1.5			0.71			0.37692			1.26		
11/29/22 18:00	0.7			1			1.5			0.71			0.3774			1.26		
11/29/22 19:00	0.7			1			1.5			0.71			0.37926			1.26		
11/29/22 20:00	0.7			1			1.5			0.72			0.38076			1.27		
11/29/22 21:00	0.7			0			1.5			0.72			0.37944			1.26		
11/29/22 22:00	0.8			0			1.5			0.7			0.37428			1.25		
11/29/22 23:00	1			0			1.5			0.67			0.35436			1.18		
11/30/22 0:00	1.1			0			1.5			0.57			0.3081			1.03		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/22 1:00	1.1			0			1.5			0.57			0.3087			1.03		
11/30/22 2:00	1.1			0			1.5			0.57			0.30954			1.03		
11/30/22 3:00	1.1			0			1.5			0.57			0.3084			1.03		
11/30/22 4:00	1.1			0			1.5			0.57			0.30822			1.03		
11/30/22 5:00	1.7			0			1.5			0.57			0.31032			1.03		
11/30/22 6:00	0.8			1			1.5			0.72			0.38178			1.27		
11/30/22 7:00	1.4			0			1.5			0.62			0.33288			1.11		
11/30/22 8:00	1.2			1			1.5			0.46			0.2496			0.83		
11/30/22 9:00	1.1			0			1.4			0.42			0.22764			0.76		
11/30/22 10:00	0.9			1			1.4			0.35			0.18792			0.63		
11/30/22 11:00	0.6			0			1.3			0.34			0.18186			0.61		
11/30/22 12:00	0.6			1			1.5			0.34			0.1812			0.6		
11/30/22 13:00	0.6			1			1.5			0.34			0.18204			0.61		
11/30/22 14:00	0.8			0			1.3			0.47			0.25506			0.85		
11/30/22 15:00	0.9			0			1.4			0.49			0.26478			0.88		
11/30/22 16:00	0.8			0			1.5			0.65			0.3465			1.16		
11/30/22 17:00	0.9			0			1.5			0.65			0.34764			1.16		
11/30/22 18:00	0.9			0			1.5			0.65			0.34716			1.16		
11/30/22 19:00	0.9			0			1.5			0.65			0.34788			1.16		
11/30/22 20:00	1			0			1.5			0.64			0.34434			1.15		
11/30/22 21:00	1			0			1.5			0.64			0.34098			1.14		
11/30/22 22:00	1.1			0			1.5			0.59			0.31548			1.05		
11/30/22 23:00	0.7			1			1.4			0.37			0.19938			0.66		
12/01/22 0:00	0.8			0			1.4			0.49			0.26286			0.88		
12/01/22 1:00	0.8			0			1.5			0.48			0.26184			0.87		
12/01/22 2:00	0.8			0			1.5			0.5			0.27048			0.9		
12/01/22 3:00	0.8			0			1.5			0.51			0.2736			0.91		
12/01/22 4:00	1.2			0			1.5			0.54			0.29148			0.97		
12/01/22 5:00	1.2			0			1.5			0.65			0.33384			1.11		
12/01/22 6:00	0.9			0			1.5			0.66			0.35028			1.17		
12/01/22 7:00	1.1			0			1.5			0.61			0.3288			1.1		
12/01/22 8:00	0.7			0			1.5			0.69			0.36546			1.22		
12/01/22 9:00	0.4			1			1.5			0.74			0.38982			1.3		
12/01/22 10:00	0.6			0			1.5			0.7			0.36972			1.23		
12/01/22 11:00	0.6			0			1.5			0.68			0.3642			1.21		
12/01/22 12:00	0.7			0			1.5			0.68			0.36048			1.2		
12/01/22 13:00	0.5			0			1.5			0.7			0.3729			1.24		
12/01/22 14:00	0.5			0			1.5			0.7			0.37248			1.24		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/22 15:00	0.9			0			1.5			0.65			0.3447			1.15		
12/01/22 16:00	1.1			0			1.5			0.62			0.32982			1.1		
12/01/22 17:00	1.1			0			1.5			0.63			0.33468			1.12		
12/01/22 18:00	1.1			0			1.5			0.61			0.3255			1.09		
12/01/22 19:00	1.1			0			1.5			0.62			0.3318			1.11		
12/01/22 20:00	1.1			0			1.5			0.61			0.32568			1.09		
12/01/22 21:00	1.1			0			1.5			0.6			0.32406			1.08		
12/01/22 22:00	1.2			0			1.5			0.6			0.32628			1.09		
12/01/22 23:00	1.3			0			1.5			0.6			0.32262			1.08		
12/02/22 0:00	1.3			0			1.5			0.6			0.32196			1.07		
12/02/22 1:00	1.4			0			1.5			0.59			0.321			1.07		
12/02/22 2:00	1.3			0			1.5			0.6			0.32322			1.08		
12/02/22 3:00	1.2			0			1.5			0.62			0.3333			1.11		
12/02/22 4:00	1.1			0			1.5			0.61			0.33012			1.1		
12/02/22 5:00	1.1			0			1.5			0.62			0.33588			1.12		
12/02/22 6:00	1			0			1.5			0.66			0.3522			1.17		
12/02/22 7:00	0.5			1			1.5			0.72			0.38376			1.28		
12/02/22 8:00	1			0			1.5			0.65			0.35016			1.17		
12/02/22 9:00	1			0			1.5			0.65			0.35016			1.17		
12/02/22 10:00	0.9			0			1.5			0.66			0.35298			1.18		
12/02/22 11:00	1			0			1.5			0.65			0.34872			1.16		
12/02/22 12:00	0.9			0			1.5			0.66			0.3507			1.17		
12/02/22 13:00	0.5			0			1.5			0.7			0.3723			1.24		
12/02/22 14:00	0.4			1			1.5			0.72			0.38208			1.27		
12/02/22 15:00	0.4			1			1.5			0.72			0.37968			1.27		
12/02/22 16:00	0.5			0			1.5			0.7			0.37194			1.24		
12/02/22 17:00	0.4			1			1.5			0.71			0.37836			1.26		
12/02/22 18:00	0.5			0			1.5			0.71			0.37548			1.25		
12/02/22 19:00	0.5			1			1.5			0.71			0.37788			1.26		
12/02/22 20:00	0.4			1			1.5			0.74			0.39084			1.3		
12/02/22 21:00	0.6			0			1.5			0.71			0.37578			1.25		
12/02/22 22:00	0.7			0			1.5			0.7			0.37314			1.24		
12/02/22 23:00	1			0			1.5			0.65			0.34788			1.16		
12/03/22 0:00	1			0			1.5			0.66			0.34956			1.17		
12/03/22 1:00	1.1			0			1.5			0.65			0.3456			1.15		
12/03/22 2:00	1.1			0			1.2			0.64			0.34272			1.14		
12/03/22 3:00	1			0			1.5			0.65			0.34758			1.16		
12/03/22 4:00	0.9			0			1.5			0.66			0.3546			1.18		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/22 5:00	0.9			0			1.5			0.68			0.36066			1.2		
12/03/22 6:00	0.9			0			1.5			0.68			0.36348			1.21		
12/03/22 7:00	0.4			1			1.5			0.74			0.39228			1.31		
12/03/22 8:00	0.6			1			1.5			0.71			0.37746			1.26		
12/03/22 9:00	0.6			1			1.5			0.71			0.37662			1.26		
12/03/22 10:00	0.8			0			1.5			0.68			0.36318			1.21		
12/03/22 11:00	1			0			1.5			0.65			0.34608			1.15		
12/03/22 12:00	1			0			1.5			0.65			0.34506			1.15		
12/03/22 13:00	1			0			1.5			0.65			0.34512			1.15		
12/03/22 14:00	0.9			0			1.5			0.66			0.35148			1.17		
12/03/22 15:00	0.7			0			1.5			0.69			0.3651			1.22		
12/03/22 16:00	0.8			0			1.5			0.67			0.3591			1.2		
12/03/22 17:00	1			0			2.6			0.57			0.30126			1		
12/03/22 18:00	0			0	X		0			0.34			0.07104			0.24		
12/03/22 19:00	0	X		0	X		0	X		0.49			0	X		0	X	
12/03/22 20:00	0	X		0	X		0	X		0.55			0	X		0	X	
12/03/22 21:00	0	X		0	X		0	X		0.55			0	X		0	X	
12/03/22 22:00	0	X		0	X		0	X		0.55			0	X		0	X	
12/03/22 23:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 0:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/04/22 1:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 2:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 3:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 4:00	0	X		0	X		0	X		0.61			0	X		0	X	
12/04/22 5:00	0	X		0	X		0	X		0.62			0	X		0	X	
12/04/22 6:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 7:00	0	X		0	X		0	X		0.61			0	X		0	X	
12/04/22 8:00	0	X		0	X		0	X		0.62			0	X		0	X	
12/04/22 9:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 10:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 11:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 12:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/04/22 13:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/04/22 14:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 15:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 16:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 17:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 18:00	0	X		0	X		0	X		0.56			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/22 19:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 20:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 21:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 22:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/04/22 23:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 0:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 1:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 2:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 3:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 4:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 5:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 6:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/05/22 7:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/05/22 8:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 9:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/05/22 10:00	0	X		0	X		0	X		0.44			0	X		0	X	
12/05/22 11:00	0	X		0	X		0	X		0.33			0	X		0	X	
12/05/22 12:00	0	X		0	X		0	X		0.33			0	X		0	X	
12/05/22 13:00	0	X		0	X		0	X		0.33			0	X		0	X	
12/05/22 14:00	0	X		0	X		0	X		0.36			0	X		0	X	
12/05/22 15:00	0	X		0	X		0	X		0.36			0	X		0	X	
12/05/22 16:00	0	X		0	X		0	X		0.4			0	X		0	X	
12/05/22 17:00	0			0	X		0			0.42			0.17226			0.57		
12/05/22 18:00	1			0			1			0.44			0.23868			0.8		
12/05/22 19:00	0.8			1			1.2			0.65			0.35316			1.18		
12/05/22 20:00	0.8			0			1.5			0.64			0.34944			1.16		
12/05/22 21:00	1			0			1.5			0.62			0.33192			1.11		
12/05/22 22:00	1.2			0			1.5			0.54			0.29004			0.97		
12/05/22 23:00	0.8			0			1.4			0.39			0.21006			0.7		
12/06/22 0:00	0.8			0			1.4			0.45			0.24876			0.83		
12/06/22 1:00	0.7			0			1.3			0.11			0.20736			0.69		
12/06/22 2:00	0.6			1			1.7			0	X		0.1911			0.64		
12/06/22 3:00	0.6			0			1.1			0	X		0.1872			0.62		
12/06/22 4:00	0.6			1			1.5			0	X		0.1875			0.63		
12/06/22 5:00	0.6			1			1.5			0	X		0.18744			0.62		
12/06/22 6:00	0.6			1			1.5			0	X		0.18768			0.63		
12/06/22 7:00	0.6			1			1.5			0	X		0.18756			0.63		
12/06/22 8:00	0.6			1			1.5			0	X		0.1875			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/22 9:00	0.6			0			1.3			0	X		0.20016			0.67		
12/06/22 10:00	0.7			0			1.5			0	X		0.21264			0.71		
12/06/22 11:00	0.6			1			1.5			0	X		0.1875			0.63		
12/06/22 12:00	0.6			1			1.5			0	X		0.1881			0.63		
12/06/22 13:00	0.6			1			1.5			0	X		0.1866			0.62		
12/06/22 14:00	0.6			0			1.4			0	X		0.19692			0.66		
12/06/22 15:00	0.7			0			1.5			0.31			0.23544			0.78		
12/06/22 16:00	1			0			1.4			0.52			0.27804			0.93		
12/06/22 17:00	0.8			0			1.5			0.66			0.35646			1.19		
12/06/22 18:00	0.9			0			1.5			0.65			0.34842			1.16		
12/06/22 19:00	0.9			0			1.5			0.65			0.35088			1.17		
12/06/22 20:00	0.9			0			1.5			0.65			0.34806			1.16		
12/06/22 21:00	0.9			0			1.5			0.65			0.34872			1.16		
12/06/22 22:00	1.1			0			1.5			0.62			0.33114			1.1		
12/06/22 23:00	1.2			0			1.5			0.6			0.32466			1.08		
12/07/22 0:00	0.8			0			1.5			0.54			0.29052			0.97		
12/07/22 1:00	0.8			0			1.5			0.52			0.27906			0.93		
12/07/22 2:00	0.8			0			1.5			0.53			0.2889			0.96		
12/07/22 3:00	0.8			0			1.5			0.53			0.2877			0.96		
12/07/22 4:00	1.4			0			1.5			0.57			0.30288			1.01		
12/07/22 5:00	0.9			0			1.5			0.66			0.3591			1.2		
12/07/22 6:00	0.9			0			1.5			0.67			0.35904			1.2		
12/07/22 7:00	1.2			0			1.5			0.61			0.32808			1.09		
12/07/22 8:00	1.4			0			1.5			0.6			0.3237			1.08		
12/07/22 9:00	1.1			0			1.5			0.62			0.33438			1.11		
12/07/22 10:00	1			0			1.5			0.62			0.33048			1.1		
12/07/22 11:00	1			0			1.5			0.61			0.3273			1.09		
12/07/22 12:00	0.9			0			1.5			0.55			0.29556			0.99		
12/07/22 13:00	0.6			1			1.5			0.35			0.18756			0.63		
12/07/22 14:00	0.7			0			1.4			0.39			0.21186			0.71		
12/07/22 15:00	1			0			1.5			0.62			0.33108			1.1		
12/07/22 16:00	1			0			1.5			0.61			0.32748			1.09		
12/07/22 17:00	1			0			1.5			0.61			0.32772			1.09		
12/07/22 18:00	1.1			0			1.5			0.61			0.3279			1.09		
12/07/22 19:00	1.1			0			1.5			0.63			0.34104			1.14		
12/07/22 20:00	0.8			0			1.5			0.68			0.36186			1.21		
12/07/22 21:00	0.9			0			1.5			0.67			0.3579			1.19		
12/07/22 22:00	1.2			0			1.5			0.62			0.33354			1.11		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/22 23:00	1.2			0			1.5			0.61			0.32556			1.09		
12/08/22 0:00	1.1			0			1.5			0.64			0.34134			1.14		
12/08/22 1:00	1.1			0			1.5			0.62			0.33354			1.11		
12/08/22 2:00	1.1			0			1.5			0.62			0.3312			1.1		
12/08/22 3:00	1.1			0			1.5			0.62			0.333			1.11		
12/08/22 4:00	1			0			1.5			0.64			0.34242			1.14		
12/08/22 5:00	1			0			1.5			0.66			0.35376			1.18		
12/08/22 6:00	0.9			0			1.5			0.68			0.36474			1.22		
12/08/22 7:00	1			0			1.5			0.66			0.35196			1.17		
12/08/22 8:00	1.2			0			1.5			0.62			0.33222			1.11		
12/08/22 9:00	1			0			1.5			0.58			0.31326			1.04		
12/08/22 10:00	0.8			0			1.5			0.53			0.28572			0.95		
12/08/22 11:00	1.1			0			1.5			0.64			0.33852			1.13		
12/08/22 12:00	0.7			0			1.5			0.67			0.3576			1.19		
12/08/22 13:00	0.8			0			1.5			0.67			0.35694			1.19		
12/08/22 14:00	0.6			0			1.5			0.69			0.36618			1.22		
12/08/22 15:00	0.7			0			1.5			0.68			0.36012			1.2		
12/08/22 16:00	0.6			0			1.5			0.69			0.36696			1.22		
12/08/22 17:00	0.5			0			1.5			0.71			0.37716			1.26		
12/08/22 18:00	0.4			0			1.5			0.72			0.38034			1.27		
12/08/22 19:00	0.4			0			1.5			0.72			0.3801			1.27		
12/08/22 20:00	0.4			0			1.5			0.71			0.3798			1.27		
12/08/22 21:00	0.5			0			1.5			0.71			0.37662			1.26		
12/08/22 22:00	0.6			0			1.5			0.69			0.369			1.23		
12/08/22 23:00	0.9			0			1.5			0.65			0.3456			1.15		
12/09/22 0:00	1			0			1.5			0.51			0.27684			0.92		
12/09/22 1:00	0.8			0			1.5			0.48			0.26088			0.87		
12/09/22 2:00	0.7			0			1.6			0.51			0.2763			0.92		
12/09/22 3:00	0.7			0			1.5			0.52			0.2805			0.94		
12/09/22 4:00	1.4			0			1.5			0.56			0.29736			0.99		
12/09/22 5:00	1.7			0			1.5			0.59			0.3			1		
12/09/22 6:00	1.2			0			1.5			0.57			0.3066			1.02		
12/09/22 7:00	1			0			1.5			0.65			0.34704			1.16		
12/09/22 8:00	0.9			0			1.5			0.51			0.27576			0.92		
12/09/22 9:00	0.8			0			1.4			0.47			0.2559			0.85		
12/09/22 10:00	0.6			1			1.5			0.35			0.18816			0.63		
12/09/22 11:00	0.6			0			1.5			0.36			0.19068			0.64		
12/09/22 12:00	0.6			0			1.5			0.36			0.19386			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/22 13:00	0.7			0			1.4			0.56			0.30222			1.01		
12/09/22 14:00	0.7			0			1.5			0.56			0.30318			1.01		
12/09/22 15:00	0.9			0			1.4			0.46			0.25026			0.83		
12/09/22 16:00	0.9			0			1.5			0.66			0.34998			1.17		
12/09/22 17:00	0.9			0			1.5			0.65			0.34794			1.16		
12/09/22 18:00	0.9			0			1.5			0.66			0.35034			1.17		
12/09/22 19:00	0.7			0			1.5			0.68			0.3609			1.2		
12/09/22 20:00	0.7			0			1.5			0.68			0.3642			1.21		
12/09/22 21:00	0.8			0			1.5			0.67			0.35826			1.19		
12/09/22 22:00	0.8			0			1.5			0.67			0.35604			1.19		
12/09/22 23:00	1			0			1.5			0.64			0.34146			1.14		
12/10/22 0:00	0.8			0			1.5			0.57			0.3063			1.02		
12/10/22 1:00	0.7			0			1.5			0.56			0.30486			1.02		
12/10/22 2:00	0.7			0			1.4			0.56			0.30492			1.02		
12/10/22 3:00	0.7			0			1.5			0.56			0.30474			1.02		
12/10/22 4:00	0.7			0			1.5			0.56			0.30462			1.02		
12/10/22 5:00	0.7			0			1.5			0.56			0.30492			1.02		
12/10/22 6:00	0.7			0			1.5			0.56			0.30528			1.02		
12/10/22 7:00	0.6			1			1.4			0.38			0.20322			0.68		
12/10/22 8:00	0.7			0			1.3			0.41			0.21966			0.73		
12/10/22 9:00	0.6			0			1.4			0.37			0.20046			0.67		
12/10/22 10:00	0.5			1			1.5			0.35			0.18642			0.62		
12/10/22 11:00	0.6			0			1.4			0.4			0.2178			0.73		
12/10/22 12:00	0.7			0			1.4			0.51			0.27936			0.93		
12/10/22 13:00	1.2			0			1.5			0.51			0.27762			0.93		
12/10/22 14:00	1.1			0			1.5			0.62			0.3342			1.11		
12/10/22 15:00	1			0			1.5			0.63			0.33822			1.13		
12/10/22 16:00	1			0			1.5			0.64			0.3408			1.14		
12/10/22 17:00	1.1			0			1.5			0.62			0.3333			1.11		
12/10/22 18:00	1.1			0			1.5			0.62			0.33306			1.11		
12/10/22 19:00	0.8			0			1.5			0.66			0.3522			1.17		
12/10/22 20:00	0.8			0			1.5			0.65			0.34902			1.16		
12/10/22 21:00	1			0			1.5			0.63			0.3357			1.12		
12/10/22 22:00	1.1			0			1.5			0.62			0.33084			1.1		
12/10/22 23:00	1.1			0			1.5			0.62			0.33384			1.11		
12/11/22 0:00	1.1			0			1.5			0.6			0.32262			1.08		
12/11/22 1:00	0.8			0			1.5			0.43			0.23484			0.78		
12/11/22 2:00	0.7			0			1.4			0.37			0.2022			0.67		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/22 3:00	0.8			0			1.4			0.41			0.21954			0.73		
12/11/22 4:00	0.8			0			1.5			0.48			0.25932			0.86		
12/11/22 5:00	0.7			0			1.5			0.5			0.26922			0.9		
12/11/22 6:00	0.8			0			1.5			0.49			0.26514			0.88		
12/11/22 7:00	0.6			1			1.5			0.37			0.198			0.66		
12/11/22 8:00	0.5			1			1.5			0.34			0.18288			0.61		
12/11/22 9:00	0.5			1			1.5			0.34			0.18162			0.61		
12/11/22 10:00	0.5			1			1.5			0.34			0.18534			0.62		
12/11/22 11:00	0.5			1			1.5			0.34			0.1812			0.6		
12/11/22 12:00	0.5			1			1.5			0.34			0.18126			0.6		
12/11/22 13:00	0.5			0			1.5			0.34			0.18468			0.62		
12/11/22 14:00	0.6			0			1.5			0.35			0.18906			0.63		
12/11/22 15:00	0.8			0			1.4			0.49			0.2646			0.88		
12/11/22 16:00	1.1			0			1.5			0.62			0.33294			1.11		
12/11/22 17:00	1.1			0			1.5			0.62			0.3342			1.11		
12/11/22 18:00	1.1			0			1.5			0.61			0.33024			1.1		
12/11/22 19:00	1.1			0			1.5			0.62			0.3309			1.1		
12/11/22 20:00	1.1			0			1.5			0.63			0.33858			1.13		
12/11/22 21:00	1.1			0			1.5			0.61			0.32964			1.1		
12/11/22 22:00	0.9			0			1.5			0.48			0.25878			0.86		
12/11/22 23:00	0.6			1			1.5			0.35			0.18918			0.63		
12/12/22 0:00	0.6			1			1.5			0.36			0.19248			0.64		
12/12/22 1:00	0.6			1			1.3			0.36			0.19644			0.65		
12/12/22 2:00	0.8			0			1.5			0.39			0.21324			0.71		
12/12/22 3:00	0.7			1			1.5			0.36			0.1953			0.65		
12/12/22 4:00	1.1			0			1.4			0.5			0.26868			0.9		
12/12/22 5:00	1			0			1.5			0.66			0.35052			1.17		
12/12/22 6:00	0.9			0			1.5			0.67			0.3579			1.19		
12/12/22 7:00	1			0			1.5			0.65			0.34494			1.15		
12/12/22 8:00	1.1			0			1.5			0.62			0.33114			1.1		
12/12/22 9:00	1.2			0			1.5			0.62			0.33018			1.1		
12/12/22 10:00	1.1			0			1.5			0.54			0.2931			0.98		
12/12/22 11:00	0.6			1			1.5			0.35			0.18792			0.63		
12/12/22 12:00	0.6			1			1.5			0.35			0.18816			0.63		
12/12/22 13:00	0.5			1			1.5			0.34			0.18414			0.61		
12/12/22 14:00	0.5			1			1.5			0.34			0.17736			0.59		
12/12/22 15:00	0			0	X		0			0.57			0.0726			0.24		
12/12/22 16:00	0	X		0	X		0	X		0.59			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/22 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/12/22 18:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/12/22 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/12/22 20:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/12/22 21:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/12/22 22:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/12/22 23:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 0:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 1:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 2:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 3:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 4:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 5:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 6:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 7:00	0	X		0	X		0	X		0.64			0	X		0	X	
12/13/22 8:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 9:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 10:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 11:00	0	X		0	X		0	X		0.41			0	X		0	X	
12/13/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/13/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/13/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/13/22 15:00	0	X		0	X		0	X		0.48			0	X		0	X	
12/13/22 16:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/13/22 18:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 19:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 20:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/13/22 21:00	0	X		0	X		0	X		0.64			0	X		0	X	
12/13/22 22:00	0	X		0	X		0	X		0.62			0	X		0	X	
12/13/22 23:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/14/22 0:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/14/22 1:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/14/22 2:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/14/22 3:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/14/22 4:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 5:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 6:00	0	X		0	X		0	X		0.59			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/22 7:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 8:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 9:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 11:00	0	X		0	X		0	X		0.56			0	X		0	X	
12/14/22 12:00	0	X		0	X		0	X		0.36			0	X		0	X	
12/14/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/14/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/14/22 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/14/22 16:00	0	X		0	X		0	X		0.42			0	X		0	X	
12/14/22 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/14/22 18:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/14/22 19:00	0	X		0	X		0	X		0.6			0	X		0	X	
12/14/22 20:00	0	X		0	X		0	X		0.59			0	X		0	X	
12/14/22 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/14/22 22:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/14/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 3:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 4:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 5:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 6:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 7:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 8:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 9:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 11:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 12:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 13:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 14:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 15:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 16:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 17:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 18:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 19:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 20:00	0	X		0	X		0	X		0.57			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/22 21:00	0	X		0	X		0	X		0.57			0	X		0	X	
12/15/22 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/15/22 23:00	0	X		0	X		0	X		0.58			0	X		0	X	
12/16/22 0:00	0	X		0	X		0	X		0.55			0	X		0	X	
12/16/22 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/16/22 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/17/22 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/17/22 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
12/17/22 2:00	0	X		0	X		0	X		0.48			0	X		0	X	
12/17/22 3:00	0.9			4			1.1			0.43			0.1749			0.58		
12/17/22 4:00	0.8			0			1.3			0.35			0.18738			0.62		
12/17/22 5:00	1.1			0			1.2			0.46			0.25146			0.84		
12/17/22 6:00	1.5			0			1.6			0.62			0.33072			1.1		
12/17/22 7:00	1.4			0			1.5			0.62			0.3336			1.11		
12/17/22 8:00	1.1			0			1.5			0.55			0.2979			0.99		
12/17/22 9:00	0.9			0			1.4			0.49			0.26418			0.88		
12/17/22 10:00	0.7			0			1.5			0.37			0.20172			0.67		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/22 11:00	0.5			1			1.5			0.34			0.18498			0.62		
12/17/22 12:00	0.5			1			1.5			0.34			0.18216			0.61		
12/17/22 13:00	0.6			0			1.5			0.35			0.18768			0.63		
12/17/22 14:00	0.7			0			1.4			0.4			0.21456			0.72		
12/17/22 15:00	0.9			0			1.6			0.65			0.3468			1.16		
12/17/22 16:00	0.8			0			1.5			0.67			0.35652			1.19		
12/17/22 17:00	0.9			0			1.5			0.66			0.34872			1.16		
12/17/22 18:00	1			0			1.5			0.63			0.33882			1.13		
12/17/22 19:00	0.9			0			1.5			0.67			0.35964			1.2		
12/17/22 20:00	0.7			0			1.5			0.7			0.37182			1.24		
12/17/22 21:00	0.8			0			1.5			0.69			0.36576			1.22		
12/17/22 22:00	0.9			0			1.5			0.67			0.35916			1.2		
12/17/22 23:00	1.3			0			1.5			0.63			0.33792			1.13		
12/18/22 0:00	1			0			1.5			0.54			0.29076			0.97		
12/18/22 1:00	0.8			0			1.5			0.54			0.28974			0.97		
12/18/22 2:00	0.8			0			1.5			0.51			0.2778			0.93		
12/18/22 3:00	0.8			0			1.5			0.5			0.27216			0.91		
12/18/22 4:00	0.8			0			1.5			0.53			0.2868			0.96		
12/18/22 5:00	0.8			0			1.5			0.55			0.29712			0.99		
12/18/22 6:00	1.2			0			1.5			0.57			0.30534			1.02		
12/18/22 7:00	0.6			0			1.5			0.72			0.38178			1.27		
12/18/22 8:00	0.9			0			1.5			0.68			0.36288			1.21		
12/18/22 9:00	0.8			0			1.5			0.69			0.36804			1.23		
12/18/22 10:00	1			0			1.5			0.62			0.3312			1.1		
12/18/22 11:00	0.8			0			1.5			0.53			0.28362			0.95		
12/18/22 12:00	0.8			1			1.5			0.44			0.23724			0.79		
12/18/22 13:00	0.6			1			1.5			0.35			0.1878			0.63		
12/18/22 14:00	0.7			0			1.4			0.42			0.22878			0.76		
12/18/22 15:00	0.8			0			1.4			0.43			0.22974			0.77		
12/18/22 16:00	1.9			0			1.6			0.59			0.31452			1.05		
12/18/22 17:00	1.7			0			1.5			0.63			0.32256			1.08		
12/18/22 18:00	0.9			0			1.5			0.68			0.3627			1.21		
12/18/22 19:00	1			0			1.5			0.67			0.35766			1.19		
12/18/22 20:00	1			0			1.5			0.66			0.35406			1.18		
12/18/22 21:00	1.1			0			1.5			0.65			0.35034			1.17		
12/18/22 22:00	1.1			0			1.5			0.65			0.34494			1.15		
12/18/22 23:00	1.2			0			1.5			0.62			0.33408			1.11		
12/19/22 0:00	1			0			1.5			0.66			0.35304			1.18		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/22 1:00	1.1			0			1.5			0.66			0.3528			1.18		
12/19/22 2:00	1			0			1.5			0.66			0.3534			1.18		
12/19/22 3:00	1			0			1.5			0.66			0.3531			1.18		
12/19/22 4:00	0.9			0			1.5			0.69			0.366			1.22		
12/19/22 5:00	0.6			0			1.5			0.72			0.38208			1.27		
12/19/22 6:00	0.6			0			1.5			0.72			0.38442			1.28		
12/19/22 7:00	0.7			0			1.5			0.71			0.37818			1.26		
12/19/22 8:00	0.8			0			1.5			0.69			0.3675			1.23		
12/19/22 9:00	0.5			0			1.5			0.74			0.39342			1.31		
12/19/22 10:00	0.5			0			1.5			0.73			0.38826			1.29		
12/19/22 11:00	0.7			0			1.5			0.71			0.37794			1.26		
12/19/22 12:00	0.9			0			1.5			0.68			0.36282			1.21		
12/19/22 13:00	0.8			0			1.5			0.69			0.3666			1.22		
12/19/22 14:00	0.7			0			1.5			0.7			0.37302			1.24		
12/19/22 15:00	0.6			0			1.5			0.68			0.36462			1.22		
12/19/22 16:00	0.6			0			1.5			0.71			0.37902			1.26		
12/19/22 17:00	0.6			0			1.5			0.72			0.38118			1.27		
12/19/22 18:00	0.7			0			1.5			0.72			0.38016			1.27		
12/19/22 19:00	0.7			0			1.5			0.72			0.38064			1.27		
12/19/22 20:00	0.6			0			1.5			0.72			0.38046			1.27		
12/19/22 21:00	0.6			0			1.5			0.72			0.3807			1.27		
12/19/22 22:00	0.6			0			1.5			0.72			0.37938			1.26		
12/19/22 23:00	1			0			1.5			0.67			0.35604			1.19		
12/20/22 0:00	0.9			0			1.5			0.57			0.3099			1.03		
12/20/22 1:00	0.8			0			1.5			0.58			0.3108			1.04		
12/20/22 2:00	0.8			0			1.5			0.58			0.31104			1.04		
12/20/22 3:00	0.8			0			1.5			0.57			0.31134			1.04		
12/20/22 4:00	0.8			0			1.5			0.57			0.31074			1.04		
12/20/22 5:00	0.8			0			1.5			0.58			0.31158			1.04		
12/20/22 6:00	0.8			0			1.5			0.58			0.31152			1.04		
12/20/22 7:00	1			0			1.5			0.71			0.37878			1.26		
12/20/22 8:00	0.9			0			1.5			0.68			0.36228			1.21		
12/20/22 9:00	1.4			0			1.5			0.61			0.3255			1.09		
12/20/22 10:00	1.2			0			1.5			0.54			0.2868			0.96		
12/20/22 11:00	0.6			1			1.4			0.35			0.18762			0.63		
12/20/22 12:00	0.5			1			1.5			0.34			0.1833			0.61		
12/20/22 13:00	0.6			1			1.5			0.34			0.18354			0.61		
12/20/22 14:00	0.5			1			1.5			0.34			0.18294			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/22 15:00	0.9			0			1.4			0.46			0.24702			0.82		
12/20/22 16:00	1.2			0			1.5			0.61			0.3273			1.09		
12/20/22 17:00	1.3			0			1.5			0.61			0.32628			1.09		
12/20/22 18:00	1.4			0			1.5			0.61			0.32556			1.09		
12/20/22 19:00	1.3			0			1.5			0.61			0.3261			1.09		
12/20/22 20:00	1.4			0			1.5			0.61			0.3261			1.09		
12/20/22 21:00	1.5			0			1.5			0.6			0.32538			1.08		
12/20/22 22:00	1.3			0			1.5			0.6			0.32418			1.08		
12/20/22 23:00	1.4			0			1.5			0.6			0.32478			1.08		
12/21/22 0:00	1.4			0			1.5			0.6			0.32472			1.08		
12/21/22 1:00	1.4			0			1.5			0.6			0.3249			1.08		
12/21/22 2:00	1.6			0			1.5			0.6			0.32448			1.08		
12/21/22 3:00	1.8			0			1.5			0.6			0.32394			1.08		
12/21/22 4:00	1.6			0			1.5			0.6			0.32322			1.08		
12/21/22 5:00	1.5			0			1.5			0.6			0.32244			1.07		
12/21/22 6:00	1.4			0			1.5			0.61			0.32772			1.09		
12/21/22 7:00	1.1			0			1.5			0.67			0.35874			1.2		
12/21/22 8:00	1.3			0			1.5			0.64			0.3429			1.14		
12/21/22 9:00	0.9			0			1.5			0.69			0.36894			1.23		
12/21/22 10:00	1			0			1.5			0.68			0.36174			1.21		
12/21/22 11:00	1.1			0			1.5			0.66			0.35142			1.17		
12/21/22 12:00	1.1			0			1.5			0.65			0.3489			1.16		
12/21/22 13:00	1			0			1.5			0.67			0.35478			1.18		
12/21/22 14:00	1.1			0			1.5			0.65			0.3477			1.16		
12/21/22 15:00	1.4			0			1.5			0.62			0.33306			1.11		
12/21/22 16:00	1.1			0			1.5			0.65			0.34896			1.16		
12/21/22 17:00	1.1			0			1.5			0.64			0.34422			1.15		
12/21/22 18:00	1.2			0			1.5			0.64			0.34092			1.14		
12/21/22 19:00	1.2			0			1.5			0.64			0.34452			1.15		
12/21/22 20:00	0.9			0			1.5			0.68			0.3627			1.21		
12/21/22 21:00	0.9			0			1.5			0.68			0.3642			1.21		
12/21/22 22:00	1.3			0			1.5			0.62			0.33486			1.12		
12/21/22 23:00	1.4			0			1.5			0.61			0.32796			1.09		
12/22/22 0:00	1.5			0			1.5			0.6			0.32388			1.08		
12/22/22 1:00	0.9			0			1.5			0.57			0.31026			1.03		
12/22/22 2:00	0.8			0			1.5			0.57			0.31074			1.04		
12/22/22 3:00	0.8			0			1.5			0.57			0.31128			1.04		
12/22/22 4:00	0.8			0			1.5			0.57			0.3102			1.03		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/22 5:00	0.8			0			1.5			0.57			0.31116			1.04		
12/22/22 6:00	0.8			0			1.5			0.58			0.3114			1.04		
12/22/22 7:00	1.5			0			1.5			0.62			0.32988			1.1		
12/22/22 8:00	1.3			0			1.5			0.61			0.32832			1.09		
12/22/22 9:00	0.9			0			1.5			0.68			0.36228			1.21		
12/22/22 10:00	0.6			0			1.5			0.72			0.37986			1.27		
12/22/22 11:00	0.6			0			1.5			0.71			0.378			1.26		
12/22/22 12:00	1.2			0			1.5			0.64			0.34164			1.14		
12/22/22 13:00	1.3			0			1.5			0.62			0.33042			1.1		
12/22/22 14:00	1.3			0			1.5			0.61			0.32538			1.08		
12/22/22 15:00	1.2			0			1.5			0.61			0.32892			1.1		
12/22/22 16:00	1			0			1.5			0.65			0.34914			1.16		
12/22/22 17:00	1.2			0			1.5			0.62			0.33468			1.12		
12/22/22 18:00	1.2			0			1.5			0.62			0.33366			1.11		
12/22/22 19:00	1.4			0			1.5			0.61			0.32868			1.1		
12/22/22 20:00	1.5			0			1.5			0.61			0.32532			1.08		
12/22/22 21:00	1.3			0			1.5			0.62			0.33084			1.1		
12/22/22 22:00	1.3			0			1.5			0.62			0.33174			1.11		
12/22/22 23:00	1.3			0			1.5			0.61			0.32604			1.09		
12/23/22 0:00	1.3			0			1.5			0.61			0.32616			1.09		
12/23/22 1:00	1.4			0			1.5			0.61			0.32574			1.09		
12/23/22 2:00	1.5			0			1.5			0.61			0.32562			1.09		
12/23/22 3:00	1.5			0			1.5			0.61			0.32574			1.09		
12/23/22 4:00	1.4			0			1.5			0.61			0.3258			1.09		
12/23/22 5:00	1.4			0			1.5			0.61			0.32544			1.08		
12/23/22 6:00	1.5			0			1.5			0.6			0.32472			1.08		
12/23/22 7:00	1			0			1.5			0.67			0.35952			1.2		
12/23/22 8:00	1.2			0			1.5			0.64			0.34332			1.14		
12/23/22 9:00	1.1			0			1.5			0.65			0.3486			1.16		
12/23/22 10:00	1.1			0			1.5			0.65			0.3453			1.15		
12/23/22 11:00	1.1			0			1.5			0.64			0.34344			1.14		
12/23/22 12:00	1.3			0			1.5			0.6			0.32232			1.07		
12/23/22 13:00	0.8			0			1.3			0.39			0.21264			0.71		
12/23/22 14:00	0.9			0			1.3			0.42			0.2253			0.75		
12/23/22 15:00	1.1			0			1.5			0.63			0.33798			1.13		
12/23/22 16:00	0.7			0			1.5			0.69			0.36888			1.23		
12/23/22 17:00	0.8			0			1.5			0.69			0.36588			1.22		
12/23/22 18:00	0.8			0			1.5			0.68			0.36384			1.21		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/22 19:00	1			0			1.5			0.66			0.35238			1.17		
12/23/22 20:00	1.1			0			1.5			0.65			0.35046			1.17		
12/23/22 21:00	1			0			1.5			0.66			0.3546			1.18		
12/23/22 22:00	1.2			0			1.5			0.65			0.34986			1.17		
12/23/22 23:00	1.3			0			1.5			0.64			0.3414			1.14		
12/24/22 0:00	1			0			1.5			0.57			0.30906			1.03		
12/24/22 1:00	1			0			1.5			0.57			0.31032			1.03		
12/24/22 2:00	0.9			0			1.5			0.57			0.31098			1.04		
12/24/22 3:00	0.9			0			1.5			0.57			0.3105			1.04		
12/24/22 4:00	0.9			0			1.5			0.57			0.31002			1.03		
12/24/22 5:00	0.9			0			1.5			0.57			0.31014			1.03		
12/24/22 6:00	0.9			0			1.5			0.56			0.30552			1.02		
12/24/22 7:00	0.8			1			1.5			0.41			0.22002			0.73		
12/24/22 8:00	0.7			1			1.5			0.35			0.18846			0.63		
12/24/22 9:00	1.4			0			1.4			0.53			0.28368			0.95		
12/24/22 10:00	1.2			0			1.5			0.65			0.34578			1.15		
12/24/22 11:00	1.4			0			1.5			0.61			0.32826			1.09		
12/24/22 12:00	1.3			0			1.5			0.62			0.33042			1.1		
12/24/22 13:00	1.2			0			1.5			0.61			0.32862			1.1		
12/24/22 14:00	1.4			0			1.5			0.61			0.32502			1.08		
12/24/22 15:00	1.3			0			1.5			0.61			0.3255			1.09		
12/24/22 16:00	1.3			0			1.5			0.61			0.32874			1.1		
12/24/22 17:00	1.4			0			1.5			0.61			0.32436			1.08		
12/24/22 18:00	1.5			0			1.5			0.6			0.32508			1.08		
12/24/22 19:00	1.5			0			1.5			0.61			0.32664			1.09		
12/24/22 20:00	1.3			0			1.5			0.55			0.29658			0.99		
12/24/22 21:00	0.7			1			1.5			0.35			0.18972			0.63		
12/24/22 22:00	0.7			1			1.5			0.35			0.19092			0.64		
12/24/22 23:00	0.7			1			1.5			0.36			0.1914			0.64		
12/25/22 0:00	0.8			0			1.4			0.37			0.20202			0.67		
12/25/22 1:00	0.7			1			1.4			0.36			0.19248			0.64		
12/25/22 2:00	0.7			0			1.5			0.36			0.19152			0.64		
12/25/22 3:00	0.7			1			1.5			0.35			0.19104			0.64		
12/25/22 4:00	0.7			1			1.5			0.35			0.19092			0.64		
12/25/22 5:00	0.7			1			1.5			0.35			0.19014			0.63		
12/25/22 6:00	0.7			1			1.5			0.35			0.18996			0.63		
12/25/22 7:00	0.7			1			1.5			0.35			0.18804			0.63		
12/25/22 8:00	0.7			1			1.5			0.35			0.1896			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/22 9:00	0.8			0			1.3			0.39			0.21078			0.7		
12/25/22 10:00	0.7			1			1.4			0.36			0.19182			0.64		
12/25/22 11:00	0.7			0			1.4			0.36			0.19524			0.65		
12/25/22 12:00	0.8			1			1.5			0.38			0.20358			0.68		
12/25/22 13:00	0.7			1			1.5			0.35			0.1887			0.63		
12/25/22 14:00	0.7			1			1.5			0.34			0.18558			0.62		
12/25/22 15:00	0.6			1			1.5			0.34			0.18198			0.61		
12/25/22 16:00	1			0			1.4			0.46			0.24582			0.82		
12/25/22 17:00	1.3			0			1.5			0.6			0.32478			1.08		
12/25/22 18:00	0.9			1			1.5			0.42			0.2286			0.76		
12/25/22 19:00	0.7			1			1.5			0.35			0.18786			0.63		
12/25/22 20:00	0.7			1			1.5			0.35			0.18852			0.63		
12/25/22 21:00	0.7			0			1.5			0.35			0.1887			0.63		
12/25/22 22:00	0.7			1			1.5			0.35			0.18678			0.62		
12/25/22 23:00	0.7			1			1.5			0.34			0.18594			0.62		
12/26/22 0:00	0.8			0			1.4			0.37			0.20028			0.67		
12/26/22 1:00	0.7			1			1.5			0.35			0.189			0.63		
12/26/22 2:00	0.7			0			1.4			0.37			0.1977			0.66		
12/26/22 3:00	0.7			1			1.4			0.36			0.19158			0.64		
12/26/22 4:00	0.7			1			1.5			0.35			0.18906			0.63		
12/26/22 5:00	0.9			0			1.4			0.42			0.2241			0.75		
12/26/22 6:00	0.9			0			1.4			0.41			0.22398			0.75		
12/26/22 7:00	0.7			1			1.5			0.35			0.19014			0.63		
12/26/22 8:00	0.7			1			1.5			0.34			0.1815			0.61		
12/26/22 9:00	0.7			0			1.4			0.35			0.18978			0.63		
12/26/22 10:00	0.9			0			1.2			0.45			0.2442			0.81		
12/26/22 11:00	1.4			0			1.6			0.57			0.30522			1.02		
12/26/22 12:00	1.7			0			1.5			0.6			0.32436			1.08		
12/26/22 13:00	1.4			0			1.5			0.62			0.33162			1.11		
12/26/22 14:00	1.1			0			1.5			0.65			0.34794			1.16		
12/26/22 15:00	1			0			1.5			0.66			0.35094			1.17		
12/26/22 16:00	1.1			0			1.5			0.64			0.34062			1.14		
12/26/22 17:00	1.1			0			1.5			0.65			0.34806			1.16		
12/26/22 18:00	1.1			0			1.5			0.65			0.34728			1.16		
12/26/22 19:00	1.2			0			1.5			0.61			0.3306			1.1		
12/26/22 20:00	1.1			0			1.5			0.61			0.32994			1.1		
12/26/22 21:00	1.1			0			1.5			0.58			0.31512			1.05		
12/26/22 22:00	0.7			1			1.5			0.36			0.19194			0.64		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/22 23:00	0.6			1			1.5			0.33			0.18042			0.6		
12/27/22 0:00	0.6			1			1.5			0.34			0.183			0.61		
12/27/22 1:00	0.6			1			1.5			0.33			0.18			0.6		
12/27/22 2:00	0.6			1			1.5			0.33			0.17976			0.6		
12/27/22 3:00	0.6			1			1.5			0.33			0.18			0.6		
12/27/22 4:00	0.6			1			1.5			0.33			0.17982			0.6		
12/27/22 5:00	0.6			1			1.5			0.33			0.18006			0.6		
12/27/22 6:00	0.6			0			1.5			0.34			0.18222			0.61		
12/27/22 7:00	0.6			1			1.5			0.33			0.18054			0.6		
12/27/22 8:00	0.6			0			1.5			0.35			0.1884			0.63		
12/27/22 9:00	0.6			0			1.5			0.34			0.18456			0.62		
12/27/22 10:00	0.6			0			1.5			0.33			0.18048			0.6		
12/27/22 11:00	0.6			0			1.5			0.34			0.18084			0.6		
12/27/22 12:00	0.6			0			1.5			0.34			0.18138			0.6		
12/27/22 13:00	0.6			0			1.5			0.35			0.1878			0.63		
12/27/22 14:00	0.6			0			1.5			0.35			0.18738			0.62		
12/27/22 15:00	0.6			1			1.5			0.34			0.18156			0.61		
12/27/22 16:00	0.6			0			1.5			0.34			0.18204			0.61		
12/27/22 17:00	0.6			1			1.5			0.34			0.18096			0.6		
12/27/22 18:00	0.6			1			1.5			0.34			0.18198			0.61		
12/27/22 19:00	0.6			1			1.5			0.34			0.18078			0.6		
12/27/22 20:00	0.6			1			1.5			0.33			0.18042			0.6		
12/27/22 21:00	0.6			1			1.5			0.33			0.18036			0.6		
12/27/22 22:00	0.6			1			1.5			0.33			0.18024			0.6		
12/27/22 23:00	0.6			0			1.5			0.33			0.18312			0.61		
12/28/22 0:00	0.7			0			1.3			0.14			0.20694			0.69		
12/28/22 1:00	0.6			0			1.5			0	X		0.18552			0.62		
12/28/22 2:00	0.6			0			1.5			0	X		0.18624			0.62		
12/28/22 3:00	0.7			0			1.5			0	X		0.18612			0.62		
12/28/22 4:00	0.6			0			1.5			0	X		0.18594			0.62		
12/28/22 5:00	0.6			0			1.5			0	X		0.18618			0.62		
12/28/22 6:00	0.6			0			1.5			0	X		0.18612			0.62		
12/28/22 7:00	0.7			1			1.5			0	X		0.1863			0.62		
12/28/22 8:00	0.7			0			1.5			0	X		0.18612			0.62		
12/28/22 9:00	0.7			0			1.5			0	X		0.18624			0.62		
12/28/22 10:00	0.6			0			1.5			0	X		0.18618			0.62		
12/28/22 11:00	0.6			0			1.5			0	X		0.18648			0.62		
12/28/22 12:00	0.6			0			1.5			0	X		0.18696			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/22 13:00	0.6			0			1.5			0	X		0.18564			0.62		
12/28/22 14:00	0.6			0			1.5			0	X		0.18414			0.61		
12/28/22 15:00	0.6			0			1.5			0	X		0.18558			0.62		
12/28/22 16:00	0.6			1			1.4			0	X		0.18972			0.63		
12/28/22 17:00	0.6			0			1.5			0	X		0.18582			0.62		
12/28/22 18:00	0.6			0			1.5			0	X		0.18612			0.62		
12/28/22 19:00	0.6			0			1.5			0	X		0.18648			0.62		
12/28/22 20:00	0.7			0			1.5			0	X		0.18654			0.62		
12/28/22 21:00	0.6			0			1.5			0	X		0.18726			0.62		
12/28/22 22:00	0.7			0			1.5			0	X		0.18666			0.62		
12/28/22 23:00	0.6			0			1.5			0	X		0.18708			0.62		
12/29/22 0:00	0.6			0			1.5			0	X		0.18678			0.62		
12/29/22 1:00	0.6			0			1.5			0	X		0.18738			0.62		
12/29/22 2:00	0.6			0			1.4			0	X		0.18678			0.62		
12/29/22 3:00	0.6			0			1.5			0	X		0.1869			0.62		
12/29/22 4:00	0.6			0			1.5			0	X		0.18678			0.62		
12/29/22 5:00	0.6			0			1.5			0	X		0.1869			0.62		
12/29/22 6:00	0.6			0			1.5			0	X		0.18654			0.62		
12/29/22 7:00	0.6			0			1.5			0	X		0.18666			0.62		
12/29/22 8:00	0.6			0			1.5			0	X		0.18714			0.62		
12/29/22 9:00	0.6			0			1.5			0	X		0.18714			0.62		
12/29/22 10:00	0.6			0			1.5			0	X		0.18714			0.62		
12/29/22 11:00	0.6			0			1.5			0	X		0.18678			0.62		
12/29/22 12:00	0.6			0			1.5			0	X		0.18612			0.62		
12/29/22 13:00	0.6			0			1.5			0	X		0.18564			0.62		
12/29/22 14:00	0.6			0			1.5			0	X		0.18552			0.62		
12/29/22 15:00	0.6			0			1.5			0	X		0.18588			0.62		
12/29/22 16:00	0.6			0			1.5			0	X		0.18618			0.62		
12/29/22 17:00	0.6			0			1.5			0	X		0.18612			0.62		
12/29/22 18:00	0.6			0			1.5			0	X		0.18588			0.62		
12/29/22 19:00	0.6			0			1.5			0	X		0.18588			0.62		
12/29/22 20:00	0.6			0			1.5			0	X		0.1863			0.62		
12/29/22 21:00	0.6			0			1.5			0	X		0.18576			0.62		
12/29/22 22:00	0.6			0			1.5			0	X		0.1848			0.62		
12/29/22 23:00	0.6			0			1.5			0	X		0.18414			0.61		
12/30/22 0:00	0.6			0			1.5			0	X		0.1839			0.61		
12/30/22 1:00	0.6			0			1.5			0	X		0.18384			0.61		
12/30/22 2:00	0.6			0			1.4			0	X		0.18378			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/22 3:00	0.6			0			1.5			0	X		0.18432			0.61		
12/30/22 4:00	0.6			0			1.5			0	X		0.1845			0.62		
12/30/22 5:00	0.6			0			1.5			0	X		0.18396			0.61		
12/30/22 6:00	0.6			0			1.5			0	X		0.18438			0.61		
12/30/22 7:00	0.6			0			1.5			0	X		0.18426			0.61		
12/30/22 8:00	0.6			0			1.5			0	X		0.18402			0.61		
12/30/22 9:00	0.6			0			1.5			0	X		0.18366			0.61		
12/30/22 10:00	0.6			0			1.5			0	X		0.1842			0.61		
12/30/22 11:00	0.6			0			1.5			0	X		0.1839			0.61		
12/30/22 12:00	0.5			0			1.5			0	X		0.18426			0.61		
12/30/22 13:00	0.5			0			1.5			0	X		0.18426			0.61		
12/30/22 14:00	0.5			0			1.5			0	X		0.18462			0.62		
12/30/22 15:00	0.5			0			1.5			0	X		0.18498			0.62		
12/30/22 16:00	0.5			0			1.5			0	X		0.18516			0.62		
12/30/22 17:00	0.6			0			1.5			0	X		0.18564			0.62		
12/30/22 18:00	0.6			0			1.5			0	X		0.1857			0.62		
12/30/22 19:00	0.6			0			1.5			0	X		0.18636			0.62		
12/30/22 20:00	0.6			0			1.5			0	X		0.18756			0.63		
12/30/22 21:00	0.6			0			1.5			0	X		0.18822			0.63		
12/30/22 22:00	0.5			0			1.4			0	X		0.18846			0.63		
12/30/22 23:00	0.5			0			1.5			0	X		0.18852			0.63		
12/31/22 0:00	0.6			0			1.5			0	X		0.18834			0.63		
12/31/22 1:00	0.5			0			1.5			0	X		0.18828			0.63		
12/31/22 2:00	0.6			0			1.6			0	X		0.18828			0.63		
12/31/22 3:00	0.6			0			1.5			0	X		0.18792			0.63		
12/31/22 4:00	0.6			0			1.5			0	X		0.18768			0.63		
12/31/22 5:00	0.6			0			1.5			0	X		0.18774			0.63		
12/31/22 6:00	0.7			0			1.1			0	X		0.2106			0.7		
12/31/22 7:00	0.7			0			1.5			0	X		0.22116			0.74		
12/31/22 8:00	0.6			0			1.5			0	X		0.18828			0.63		
12/31/22 9:00	0.6			0			1.3			0	X		0.2034			0.68		
12/31/22 10:00	0			0	X		0			0	X		0.1233			0.41		
12/31/22 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/22 14:00	0			0	X		0			0	X		0.16338			0.54		
12/31/22 15:00	0.6			0			1.2			0	X		0.20976			0.7		
12/31/22 16:00	0.5			0			1.5			0	X		0.18612			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/22 17:00	0.5			0			1.5			0	X		0.1845			0.62		
12/31/22 18:00	0.5			0			1.5			0	X		0.18426			0.61		
12/31/22 19:00	0.5			0			1.5			0	X		0.18468			0.62		
12/31/22 20:00	0.5			0			1.5			0	X		0.18426			0.61		
12/31/22 21:00	0.5			0			1.5			0	X		0.18474			0.62		
12/31/22 22:00	0.5			0			1.5			0	X		0.18612			0.62		
12/31/22 23:00	0.5			0			1.5			0	X		0.1872			0.62		

ATTACHMENT 17

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2022	11.29	45.63	5.4	10.24	17.07
10/02/2022	13.89	53.19	5.9	11.15	18.59
10/03/2022	16.76	55.19	6.6	12.54	20.94
10/04/2022	24.42	67.48	7.2	14.92	24.86
10/05/2022	21.66	70.69	7.2	15.21	25.40
10/06/2022	17.07	61.99	6.7	13.50	22.52
10/07/2022	23.41	71.04	7.2	15.41	25.69
10/08/2022	20.31	62.05	6.5	13.50	22.45
10/09/2022	35.57	64.88	7.2	13.96	23.26
10/10/2022	27.67	59.52	6.7	13.14	21.90
10/11/2022	17.92	47.24	5.6	10.36	17.25
10/12/2022	15.66	46.66	5.6	10.22	16.98
10/13/2022	16.66	47.21	5.6	10.48	17.41
10/14/2022	26.11	54.89	6.3	11.99	19.93
10/15/2022	15.42	45.23	5.5	9.95	16.56
10/16/2022	27.92	53.05	6.2	11.75	19.52
10/17/2022	32.37	63.74	7.2	13.90	23.19
10/18/2022	25.70	66.87	7.3	14.59	24.27
10/19/2022	55.83	42.31	4.2	8.18	13.62
10/20/2022	13.88	50.28	5.7	10.97	18.33
10/21/2022	15.13	50.18	5.8	10.93	18.22
10/22/2022	16.16	64.96	7.4	14.05	23.46
10/23/2022	18.10	59.53	6.6	12.85	21.40
10/24/2022	20.70	60.09	6.7	13.05	21.76
10/25/2022	16.35	56.48	6.1	12.27	20.45
10/26/2022	14.22	49.28	5.7	10.85	18.08
10/27/2022	21.73	56.28	6.2	12.21	20.32
10/28/2022	21.44	64.87	6.9	14.01	23.40
10/29/2022	16.11	50.55	5.4	11.09	18.47
10/30/2022	15.10	49.50	6.2	11.01	18.31
10/31/2022	16.18	50.91	5.8	11.13	18.53
Monthly Avg/Sum*:	650.74 *	1,741.77 *	194.6 *	379.41 *	632.14 *
Daily Min:	11.29	42.31	4.2	8.18	13.62
Daily Max:	55.83	71.04	7.4	15.41	25.69
Oct 2022 - Oct 2022	650.74	1,741.77	194.6	379.41	632.14
QTD:	650.74 *	1,741.77 *	194.6 *	379.41 *	632.14 *
YTD 2022:	5,235.75 *	10,876.87 *	1,163.9 *	2,240.34 *	3,735.05 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2022	26.47	70.08	7.2	15.17	25.33
11/02/2022	21.56	60.86	6.4	13.12	21.89
11/03/2022	19.62	62.58	7.0	13.52	22.51
11/04/2022	15.69	50.79	5.8	11.08	18.50
11/05/2022	13.16	44.02	5.2	9.75	16.21
11/06/2022	19.72	56.35	6.2	12.05	20.11
11/07/2022	17.63	53.66	5.8	11.70	19.47
11/08/2022	27.14	58.90	6.4	12.68	21.09
11/09/2022	25.67	53.16	6.2	11.68	19.45
11/10/2022	18.39	55.07	6.0	11.89	19.84
11/11/2022	21.86	59.89	6.5	13.07	21.74
11/12/2022	25.72	70.28	7.2	15.23	25.40
11/13/2022	20.73	65.28	7.0	14.07	23.46
11/14/2022	20.04	67.86	7.1	14.65	24.47
11/15/2022	18.58	66.48	7.3	14.42	24.03
11/16/2022	22.64	64.22	6.8	13.97	23.28
11/17/2022	23.48	66.61	7.1	14.41	24.02
11/18/2022	20.75	76.06	8.2	16.41	27.36
11/19/2022	18.80	63.69	6.9	13.81	23.00
11/20/2022	26.29	70.33	7.7	15.24	25.39
11/21/2022	25.58	63.27	6.7	13.78	22.96
11/22/2022	24.88	62.83	6.8	13.59	22.63
11/23/2022	23.01	57.46	6.1	12.51	20.84
11/24/2022	29.72	65.08	7.0	14.19	23.63
11/25/2022	28.61	59.88	6.5	12.95	21.60
11/26/2022	26.86	63.30	6.7	13.69	22.82
11/27/2022	24.94	59.29	6.4	12.90	21.55
11/28/2022	28.47	61.04	6.5	13.19	21.99
11/29/2022	17.43	65.32	8.1	15.04	25.05
11/30/2022	18.23	58.95	6.4	12.81	21.35
Monthly Avg/Sum*:	671.67 *	1,852.59 *	201.2 *	402.57 *	670.97 *
Daily Min:	13.16	44.02	5.2	9.75	16.21
Daily Max:	29.72	76.06	8.2	16.41	27.36
Oct 2022 - Nov 2022	1,322.41	3,594.36	395.8	781.98	1,303.11
QTD:	1,322.41 *	3,594.36 *	395.8 *	781.98 *	1,303.11 *
YTD 2022:	5,907.42 *	12,729.46 *	1,365.1 *	2,642.91 *	4,406.02 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2022	23.58	68.73	7.3	14.87	24.73
12/02/2022	23.04	74.38	8.3	16.06	26.79
12/03/2022	22.65	69.27	7.3	15.04	25.04
12/04/2022	26.90	65.43	7.2	14.04	23.40
12/05/2022	16.97	53.64	6.2	11.89	19.82
12/06/2022	57.84	37.67	2.7	5.71	9.53
12/07/2022	26.74	64.86	7.0	14.03	23.39
12/08/2022	22.86	72.76	7.7	15.82	26.32
12/09/2022	20.99	61.37	6.6	13.33	22.21
12/10/2022	20.76	60.77	6.7	13.17	22.01
12/11/2022	17.61	50.73	5.5	11.07	18.45
12/12/2022	22.80	49.73	6.4	12.44	20.72
12/13/2022	32.01	61.34	6.7	13.43	22.38
12/14/2022	20.94	59.61	6.7	12.85	21.41
12/15/2022	18.28	64.78	7.2	13.83	23.04
12/16/2022	9.74	39.11	4.9	8.60	14.25
12/17/2022	21.22	56.91	6.0	12.47	20.76
12/18/2022	24.62	63.12	6.9	13.77	23.00
12/19/2022	22.12	76.79	8.6	16.80	27.97
12/20/2022	25.06	61.40	6.8	13.25	22.08
12/21/2022	34.76	71.00	7.2	15.30	25.57
12/22/2022	30.53	68.80	7.4	14.81	24.72
12/23/2022	32.98	69.22	7.0	14.87	24.81
12/24/2022	26.53	60.58	6.7	13.02	21.71
12/25/2022	13.01	40.88	4.9	8.93	14.88
12/26/2022	21.46	53.57	5.9	11.65	19.41
12/27/2022	12.04	37.04	4.8	8.08	13.50
12/28/2022	7.52	0.11	0.0	0.00	0.00
12/29/2022	0.00	0.00	0.0	0.00	0.00
12/30/2022	0.00	0.00	0.0	0.00	0.00
12/31/2022	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	655.56 *	1,613.60 *	176.6 *	349.13 *	581.90 *
Daily Min:	7.52	0.11	0.0	0.00	0.00
Daily Max:	57.84	76.79	8.6	16.80	27.97
Oct 2022 - Dec 2022	1,977.97	5,207.96	572.4	1,131.11	1,885.01
QTD:	1,977.97 *	5,207.96 *	572.4 *	1,131.11 *	1,885.01 *
YTD 2022:	6,562.98 *	14,343.06 *	1,541.7 *	2,992.04 *	4,987.92 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2022	12.70	49.34	5.9	11.01	18.33
10/02/2022	25.01	56.91	6.0	11.95	19.92
10/03/2022	31.30	58.19	6.8	13.46	22.44
10/04/2022	61.26	70.42	7.2	15.28	25.48
10/05/2022	46.97	70.59	7.2	15.10	25.16
10/06/2022	35.21	63.70	6.7	13.76	22.90
10/07/2022	47.95	70.30	7.2	15.17	25.31
10/08/2022	53.64	61.76	6.2	13.12	21.88
10/09/2022	0.00	0.00	0.0	0.00	0.00
10/10/2022	0.00	0.00	0.0	0.00	0.00
10/11/2022	0.00	0.00	0.0	0.00	0.00
10/12/2022	0.00	0.00	0.0	0.00	0.00
10/13/2022	0.00	0.00	0.0	0.00	0.00
10/14/2022	0.00	0.00	0.0	0.00	0.00
10/15/2022	0.00	0.00	0.0	0.00	0.00
10/16/2022	0.00	0.00	0.0	0.00	0.00
10/17/2022	0.00	0.00	0.0	0.00	0.00
10/18/2022	24.64	35.81	3.1	6.00	9.99
10/19/2022	19.18	55.39	6.2	12.18	20.30
10/20/2022	15.25	53.21	6.0	11.73	19.55
10/21/2022	17.19	52.75	5.8	11.68	19.49
10/22/2022	18.68	69.32	7.5	15.04	25.06
10/23/2022	22.23	64.55	6.8	13.80	23.01
10/24/2022	26.06	64.35	6.9	14.00	23.33
10/25/2022	21.40	60.67	6.6	13.27	22.15
10/26/2022	18.72	52.71	5.8	11.65	19.44
10/27/2022	26.51	59.68	6.5	13.05	21.74
10/28/2022	29.15	69.30	7.7	14.99	24.97
10/29/2022	21.24	56.12	5.8	11.94	19.90
10/30/2022	20.10	55.98	6.3	11.90	19.84
10/31/2022	22.04	53.20	6.0	11.99	19.99
Monthly Avg/Sum*:	616.43 *	1,304.25 *	140.2 *	282.07 *	470.18 *
Daily Min:	12.70	35.81	3.1	6.00	9.99
Daily Max:	61.26	70.59	7.7	15.28	25.48
Oct 2022 - Oct 2022	616.43	1,304.25	140.2	282.07	470.18
QTD:	616.43 *	1,304.25 *	140.2 *	282.07 *	470.18 *
YTD 2022:	6,676.01 *	11,346.51 *	1,162.0 *	2,316.99 *	3,861.64 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2022	30.85	74.45	7.9	16.13	26.88
11/02/2022	27.46	64.65	7.0	14.06	23.46
11/03/2022	27.15	66.71	7.2	14.48	24.16
11/04/2022	21.05	56.25	6.2	11.92	19.88
11/05/2022	17.13	50.06	5.3	10.44	17.41
11/06/2022	25.10	65.73	6.3	12.98	21.60
11/07/2022	26.49	60.08	6.1	12.56	20.94
11/08/2022	8.91	0.25	0.0	0.00	0.01
11/09/2022	29.12	16.27	0.7	1.30	2.18
11/10/2022	22.15	57.95	6.4	12.79	21.28
11/11/2022	26.10	64.42	7.1	13.97	23.28
11/12/2022	30.36	75.28	8.0	16.31	27.16
11/13/2022	27.09	70.01	7.8	15.14	25.24
11/14/2022	26.49	72.43	8.1	15.72	26.19
11/15/2022	24.75	70.55	8.0	15.37	25.66
11/16/2022	28.43	68.16	7.7	15.00	24.99
11/17/2022	30.16	71.30	7.6	15.45	25.76
11/18/2022	28.13	80.04	9.0	17.45	29.07
11/19/2022	26.13	67.68	7.5	14.73	24.54
11/20/2022	34.95	74.67	7.9	16.25	27.13
11/21/2022	32.23	67.12	7.1	14.74	24.56
11/22/2022	32.55	67.38	7.0	14.58	24.29
11/23/2022	29.85	61.22	6.5	13.43	22.41
11/24/2022	35.98	69.69	7.1	15.18	25.33
11/25/2022	34.62	64.19	6.5	13.89	23.15
11/26/2022	34.25	68.01	6.9	14.62	24.42
11/27/2022	31.47	63.22	6.6	13.87	23.07
11/28/2022	34.83	65.31	6.9	14.14	23.57
11/29/2022	68.70	69.12	6.7	13.09	21.86
11/30/2022	25.22	62.81	6.6	13.79	22.97
Monthly Avg/Sum*:	877.70 *	1,885.01 *	199.7 *	403.38 *	672.45 *
Daily Min:	8.91	0.25	0.0	0.00	0.01
Daily Max:	68.70	80.04	9.0	17.45	29.07
Oct 2022 - Nov 2022	1,494.13	3,189.26	339.9	685.45	1,142.63
QTD:	1,494.13 *	3,189.26 *	339.9 *	685.45 *	1,142.63 *
YTD 2022:	7,553.71 *	13,231.52 *	1,361.7 *	2,720.37 *	4,534.09 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2022	26.15	72.98	8.0	15.87	26.46
12/02/2022	25.69	79.67	8.8	17.16	28.59
12/03/2022	34.95	64.05	6.4	12.78	21.30
12/04/2022	0.00	0.00	0.0	0.00	0.00
12/05/2022	29.32	36.56	1.9	3.86	6.43
12/06/2022	16.73	52.96	5.8	11.75	19.57
12/07/2022	27.84	69.39	7.4	15.10	25.14
12/08/2022	24.96	77.53	8.6	16.86	28.13
12/09/2022	23.58	65.46	7.5	14.25	23.79
12/10/2022	22.46	64.77	6.8	14.22	23.69
12/11/2022	18.50	54.43	6.0	11.95	19.87
12/12/2022	26.37	35.45	3.9	7.63	12.70
12/13/2022	0.00	0.00	0.0	0.00	0.00
12/14/2022	0.00	0.00	0.0	0.00	0.00
12/15/2022	0.00	0.00	0.0	0.00	0.00
12/16/2022	0.00	0.00	0.0	0.00	0.00
12/17/2022	52.88	64.36	6.1	11.96	19.95
12/18/2022	26.63	67.46	7.5	14.76	24.60
12/19/2022	24.41	82.64	9.6	17.90	29.79
12/20/2022	27.75	65.40	6.9	14.22	23.76
12/21/2022	37.04	75.39	7.9	16.45	27.35
12/22/2022	32.51	73.21	7.5	15.90	26.52
12/23/2022	33.88	72.72	7.7	15.93	26.55
12/24/2022	29.54	64.90	6.7	14.03	23.39
12/25/2022	14.42	43.39	4.9	9.63	16.07
12/26/2022	23.53	57.02	6.0	12.53	20.90
12/27/2022	9.23	40.17	4.8	8.72	14.56
12/28/2022	10.40	40.70	4.8	8.93	14.95
12/29/2022	9.78	40.71	4.8	8.88	14.87
12/30/2022	8.88	40.65	4.8	8.92	14.79
12/31/2022	72.44	42.70	3.9	7.53	12.53
Monthly Avg/Sum*:	689.87 *	1,544.67 *	165.0 *	327.72 *	546.25 *
Daily Min:	8.88	35.45	1.9	3.86	6.43
Daily Max:	72.44	82.64	9.6	17.90	29.79
Oct 2022 - Dec 2022	2,184.00	4,733.93	504.9	1,013.17	1,688.88
QTD:	2,184.00 *	4,733.93 *	504.9 *	1,013.17 *	1,688.88 *
YTD 2022:	8,243.58 *	14,776.19 *	1,526.7 *	3,048.09 *	5,080.34 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2022	23.99	94.97	10.63	21.25	35.40
10/02/2022	38.90	110.10	11.54	23.10	38.51
10/03/2022	48.06	113.38	13.02	26.00	43.38
10/04/2022	85.68	137.90	15.11	30.20	50.34
10/05/2022	68.63	141.28	15.16	30.31	50.56
10/06/2022	52.28	125.69	13.62	27.26	45.42
10/07/2022	71.36	141.34	15.29	30.58	51.00
10/08/2022	73.95	123.81	13.30	26.62	44.33
10/09/2022	35.57	64.88	6.96	13.96	23.26
10/10/2022	27.67	59.52	6.55	13.14	21.90
10/11/2022	17.92	47.24	5.17	10.36	17.25
10/12/2022	15.66	46.66	5.01	10.22	16.98
10/13/2022	16.66	47.21	5.17	10.48	17.41
10/14/2022	26.11	54.89	5.95	11.99	19.93
10/15/2022	15.42	45.23	4.92	9.95	16.56
10/16/2022	27.92	53.05	5.80	11.75	19.52
10/17/2022	32.37	63.74	6.95	13.90	23.19
10/18/2022	50.34	102.68	10.26	20.59	34.26
10/19/2022	75.01	97.70	10.21	20.36	33.92
10/20/2022	29.13	103.49	11.33	22.70	37.88
10/21/2022	32.32	102.93	11.32	22.61	37.71
10/22/2022	34.84	134.28	14.55	29.09	48.52
10/23/2022	40.33	124.08	13.31	26.65	44.41
10/24/2022	46.76	124.44	13.56	27.05	45.09
10/25/2022	37.75	117.15	12.77	25.54	42.60
10/26/2022	32.94	101.99	11.27	22.50	37.52
10/27/2022	48.24	115.96	12.65	25.26	42.06
10/28/2022	50.59	134.17	14.50	29.00	48.37
10/29/2022	37.35	106.67	11.50	23.03	38.37
10/30/2022	35.20	105.48	11.44	22.91	38.15
10/31/2022	38.22	104.11	11.54	23.12	38.52
Monthly Avg/Sum*:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
Daily Min:	15.42	45.23	4.92	9.95	16.56
Daily Max:	85.68	141.34	15.29	30.58	51.00
Oct 2022 - Oct 2022	1,267.17	3,046.02	330.36	661.48	1,102.32
QTD:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
YTD 2022:	11,980.84 *	22,223.38 *	2,278.01 *	4,557.33 *	7,596.69 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2022	57.32	144.53	15.65	31.30	52.21
11/02/2022	49.02	125.51	13.60	27.18	45.35
11/03/2022	46.77	129.29	13.99	28.00	46.67
11/04/2022	36.74	107.04	11.51	23.00	38.38
11/05/2022	30.29	94.08	10.08	20.19	33.62
11/06/2022	44.82	122.08	12.51	25.03	41.71
11/07/2022	44.12	113.74	12.13	24.26	40.41
11/08/2022	36.05	59.15	6.32	12.68	21.10
11/09/2022	54.79	69.43	6.44	12.98	21.63
11/10/2022	40.54	113.02	12.35	24.68	41.12
11/11/2022	47.96	124.31	13.53	27.04	45.02
11/12/2022	56.08	145.56	15.78	31.54	52.56
11/13/2022	47.82	135.29	14.62	29.21	48.70
11/14/2022	46.53	140.29	15.22	30.37	50.66
11/15/2022	43.33	137.03	14.91	29.79	49.69
11/16/2022	51.07	132.38	14.47	28.97	48.27
11/17/2022	53.64	137.91	14.98	29.86	49.78
11/18/2022	48.88	156.10	16.93	33.86	56.43
11/19/2022	44.93	131.37	14.24	28.54	47.54
11/20/2022	61.24	145.00	15.75	31.49	52.52
11/21/2022	57.81	130.39	14.27	28.52	47.52
11/22/2022	57.43	130.21	14.11	28.17	46.92
11/23/2022	52.86	118.68	12.97	25.94	43.25
11/24/2022	65.70	134.77	14.70	29.37	48.96
11/25/2022	63.23	124.07	13.44	26.84	44.75
11/26/2022	61.11	131.31	14.16	28.31	47.24
11/27/2022	56.41	122.51	13.40	26.77	44.62
11/28/2022	63.30	126.35	13.69	27.33	45.56
11/29/2022	86.13	134.44	14.09	28.13	46.91
11/30/2022	43.45	121.76	13.26	26.60	44.32
Monthly Avg/Sum*:	1,549.37 *	3,737.60 *	403.10 *	805.95 *	1,343.42 *
Daily Min:	30.29	59.15	6.32	12.68	21.10
Daily Max:	86.13	156.10	16.93	33.86	56.43
Oct 2022 - Nov 2022	2,816.54	6,783.62	733.46	1,467.43	2,445.74
QTD:	2,816.54 *	6,783.62 *	733.46 *	1,467.43 *	2,445.74 *
YTD 2022:	13,530.21 *	25,960.98 *	2,681.11 *	5,363.28 *	8,940.11 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2022	49.73	141.71	15.37	30.74	51.19
12/02/2022	48.73	154.05	16.60	33.22	55.38
12/03/2022	57.60	133.32	13.90	27.82	46.34
12/04/2022	26.90	65.43	7.03	14.04	23.40
12/05/2022	46.29	90.20	7.88	15.75	26.25
12/06/2022	74.57	90.63	8.75	17.46	29.10
12/07/2022	54.58	134.25	14.54	29.13	48.53
12/08/2022	47.82	150.29	16.33	32.68	54.45
12/09/2022	44.57	126.83	13.77	27.58	46.00
12/10/2022	43.22	125.54	13.72	27.39	45.70
12/11/2022	36.11	105.16	11.50	23.02	38.32
12/12/2022	49.17	85.18	10.04	20.07	33.42
12/13/2022	32.01	61.34	6.71	13.43	22.38
12/14/2022	20.94	59.61	6.44	12.85	21.41
12/15/2022	18.28	64.78	6.96	13.83	23.04
12/16/2022	9.74	39.11	4.25	8.60	14.25
12/17/2022	74.10	121.27	12.22	24.43	40.71
12/18/2022	51.25	130.58	14.25	28.53	47.60
12/19/2022	46.53	159.43	17.31	34.70	57.76
12/20/2022	52.81	126.80	13.75	27.47	45.84
12/21/2022	71.80	146.39	15.88	31.75	52.92
12/22/2022	63.04	142.01	15.40	30.71	51.24
12/23/2022	66.86	141.94	15.41	30.80	51.36
12/24/2022	56.07	125.48	13.57	27.05	45.10
12/25/2022	27.43	84.27	9.30	18.56	30.95
12/26/2022	44.99	110.59	12.10	24.18	40.31
12/27/2022	21.27	77.21	8.44	16.80	28.06
12/28/2022	17.92	40.81	4.57	8.93	14.95
12/29/2022	9.78	40.71	4.54	8.88	14.87
12/30/2022	8.88	40.65	4.40	8.92	14.79
12/31/2022	72.44	42.70	3.74	7.53	12.53
Monthly Avg/Sum*:	1,345.43 *	3,158.27 *	338.67 *	676.85 *	1,128.15 *
Daily Min:	8.88	39.11	3.74	7.53	12.53
Daily Max:	74.57	159.43	17.31	34.70	57.76
Oct 2022 - Dec 2022	4,161.97	9,941.89	1,072.13	2,144.28	3,573.89
QTD:	4,161.97 *	9,941.89 *	1,072.13 *	2,144.28 *	3,573.89 *
YTD 2022:	14,875.64 *	29,119.25 *	3,019.78 *	6,040.13 *	10,068.26 *

ATTACHMENT 18

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NO _x	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM ₁₀	16,300	13,692	17,789	17,569	32.67
SO _x	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2022	11.29	45.63	5.4	10.24	17.07
10/02/2022	13.89	53.19	5.9	11.15	18.59
10/03/2022	16.76	55.19	6.6	12.54	20.94
10/04/2022	24.42	67.48	7.2	14.92	24.86
10/05/2022	21.66	70.69	7.2	15.21	25.40
10/06/2022	17.07	61.99	6.7	13.50	22.52
10/07/2022	23.41	71.04	7.2	15.41	25.69
10/08/2022	20.31	62.05	6.5	13.50	22.45
10/09/2022	35.57	64.88	7.2	13.96	23.26
10/10/2022	27.67	59.52	6.7	13.14	21.90
10/11/2022	17.92	47.24	5.6	10.36	17.25
10/12/2022	15.66	46.66	5.6	10.22	16.98
10/13/2022	16.66	47.21	5.6	10.48	17.41
10/14/2022	26.11	54.89	6.3	11.99	19.93
10/15/2022	15.42	45.23	5.5	9.95	16.56
10/16/2022	27.92	53.05	6.2	11.75	19.52
10/17/2022	32.37	63.74	7.2	13.90	23.19
10/18/2022	25.70	66.87	7.3	14.59	24.27
10/19/2022	55.83	42.31	4.2	8.18	13.62
10/20/2022	13.88	50.28	5.7	10.97	18.33
10/21/2022	15.13	50.18	5.8	10.93	18.22
10/22/2022	16.16	64.96	7.4	14.05	23.46
10/23/2022	18.10	59.53	6.6	12.85	21.40
10/24/2022	20.70	60.09	6.7	13.05	21.76
10/25/2022	16.35	56.48	6.1	12.27	20.45
10/26/2022	14.22	49.28	5.7	10.85	18.08
10/27/2022	21.73	56.28	6.2	12.21	20.32
10/28/2022	21.44	64.87	6.9	14.01	23.40
10/29/2022	16.11	50.55	5.4	11.09	18.47
10/30/2022	15.10	49.50	6.2	11.01	18.31
10/31/2022	16.18	50.91	5.8	11.13	18.53
Monthly Avg/Sum*:	650.74 *	1,741.77 *	194.6 *	379.41 *	632.14 *
Daily Min:	11.29	42.31	4.2	8.18	13.62
Daily Max:	55.83	71.04	7.4	15.41	25.69
Oct 2022 - Oct 2022	650.74	1,741.77	194.6	379.41	632.14
QTD:	650.74 *	1,741.77 *	194.6 *	379.41 *	632.14 *
YTD 2022:	5,235.75 *	10,876.87 *	1,163.9 *	2,240.34 *	3,735.05 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2022	26.47	70.08	7.2	15.17	25.33
11/02/2022	21.56	60.86	6.4	13.12	21.89
11/03/2022	19.62	62.58	7.0	13.52	22.51
11/04/2022	15.69	50.79	5.8	11.08	18.50
11/05/2022	13.16	44.02	5.2	9.75	16.21
11/06/2022	19.72	56.35	6.2	12.05	20.11
11/07/2022	17.63	53.66	5.8	11.70	19.47
11/08/2022	27.14	58.90	6.4	12.68	21.09
11/09/2022	25.67	53.16	6.2	11.68	19.45
11/10/2022	18.39	55.07	6.0	11.89	19.84
11/11/2022	21.86	59.89	6.5	13.07	21.74
11/12/2022	25.72	70.28	7.2	15.23	25.40
11/13/2022	20.73	65.28	7.0	14.07	23.46
11/14/2022	20.04	67.86	7.1	14.65	24.47
11/15/2022	18.58	66.48	7.3	14.42	24.03
11/16/2022	22.64	64.22	6.8	13.97	23.28
11/17/2022	23.48	66.61	7.1	14.41	24.02
11/18/2022	20.75	76.06	8.2	16.41	27.36
11/19/2022	18.80	63.69	6.9	13.81	23.00
11/20/2022	26.29	70.33	7.7	15.24	25.39
11/21/2022	25.58	63.27	6.7	13.78	22.96
11/22/2022	24.88	62.83	6.8	13.59	22.63
11/23/2022	23.01	57.46	6.1	12.51	20.84
11/24/2022	29.72	65.08	7.0	14.19	23.63
11/25/2022	28.61	59.88	6.5	12.95	21.60
11/26/2022	26.86	63.30	6.7	13.69	22.82
11/27/2022	24.94	59.29	6.4	12.90	21.55
11/28/2022	28.47	61.04	6.5	13.19	21.99
11/29/2022	17.43	65.32	8.1	15.04	25.05
11/30/2022	18.23	58.95	6.4	12.81	21.35
Monthly Avg/Sum*:	671.67 *	1,852.59 *	201.2 *	402.57 *	670.97 *
Daily Min:	13.16	44.02	5.2	9.75	16.21
Daily Max:	29.72	76.06	8.2	16.41	27.36
Oct 2022 - Nov 2022	1,322.41	3,594.36	395.8	781.98	1,303.11
QTD:	1,322.41 *	3,594.36 *	395.8 *	781.98 *	1,303.11 *
YTD 2022:	5,907.42 *	12,729.46 *	1,365.1 *	2,642.91 *	4,406.02 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:27 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2022	23.58	68.73	7.3	14.87	24.73
12/02/2022	23.04	74.38	8.3	16.06	26.79
12/03/2022	22.65	69.27	7.3	15.04	25.04
12/04/2022	26.90	65.43	7.2	14.04	23.40
12/05/2022	16.97	53.64	6.2	11.89	19.82
12/06/2022	57.84	37.67	2.7	5.71	9.53
12/07/2022	26.74	64.86	7.0	14.03	23.39
12/08/2022	22.86	72.76	7.7	15.82	26.32
12/09/2022	20.99	61.37	6.6	13.33	22.21
12/10/2022	20.76	60.77	6.7	13.17	22.01
12/11/2022	17.61	50.73	5.5	11.07	18.45
12/12/2022	22.80	49.73	6.4	12.44	20.72
12/13/2022	32.01	61.34	6.7	13.43	22.38
12/14/2022	20.94	59.61	6.7	12.85	21.41
12/15/2022	18.28	64.78	7.2	13.83	23.04
12/16/2022	9.74	39.11	4.9	8.60	14.25
12/17/2022	21.22	56.91	6.0	12.47	20.76
12/18/2022	24.62	63.12	6.9	13.77	23.00
12/19/2022	22.12	76.79	8.6	16.80	27.97
12/20/2022	25.06	61.40	6.8	13.25	22.08
12/21/2022	34.76	71.00	7.2	15.30	25.57
12/22/2022	30.53	68.80	7.4	14.81	24.72
12/23/2022	32.98	69.22	7.0	14.87	24.81
12/24/2022	26.53	60.58	6.7	13.02	21.71
12/25/2022	13.01	40.88	4.9	8.93	14.88
12/26/2022	21.46	53.57	5.9	11.65	19.41
12/27/2022	12.04	37.04	4.8	8.08	13.50
12/28/2022	7.52	0.11	0.0	0.00	0.00
12/29/2022	0.00	0.00	0.0	0.00	0.00
12/30/2022	0.00	0.00	0.0	0.00	0.00
12/31/2022	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	655.56 *	1,613.60 *	176.6 *	349.13 *	581.90 *
Daily Min:	7.52	0.11	0.0	0.00	0.00
Daily Max:	57.84	76.79	8.6	16.80	27.97
Oct 2022 - Dec 2022	1,977.97	5,207.96	572.4	1,131.11	1,885.01
QTD:	1,977.97 *	5,207.96 *	572.4 *	1,131.11 *	1,885.01 *
YTD 2022:	6,562.98 *	14,343.06 *	1,541.7 *	2,992.04 *	4,987.92 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2022	12.70	49.34	5.9	11.01	18.33
10/02/2022	25.01	56.91	6.0	11.95	19.92
10/03/2022	31.30	58.19	6.8	13.46	22.44
10/04/2022	61.26	70.42	7.2	15.28	25.48
10/05/2022	46.97	70.59	7.2	15.10	25.16
10/06/2022	35.21	63.70	6.7	13.76	22.90
10/07/2022	47.95	70.30	7.2	15.17	25.31
10/08/2022	53.64	61.76	6.2	13.12	21.88
10/09/2022	0.00	0.00	0.0	0.00	0.00
10/10/2022	0.00	0.00	0.0	0.00	0.00
10/11/2022	0.00	0.00	0.0	0.00	0.00
10/12/2022	0.00	0.00	0.0	0.00	0.00
10/13/2022	0.00	0.00	0.0	0.00	0.00
10/14/2022	0.00	0.00	0.0	0.00	0.00
10/15/2022	0.00	0.00	0.0	0.00	0.00
10/16/2022	0.00	0.00	0.0	0.00	0.00
10/17/2022	0.00	0.00	0.0	0.00	0.00
10/18/2022	24.64	35.81	3.1	6.00	9.99
10/19/2022	19.18	55.39	6.2	12.18	20.30
10/20/2022	15.25	53.21	6.0	11.73	19.55
10/21/2022	17.19	52.75	5.8	11.68	19.49
10/22/2022	18.68	69.32	7.5	15.04	25.06
10/23/2022	22.23	64.55	6.8	13.80	23.01
10/24/2022	26.06	64.35	6.9	14.00	23.33
10/25/2022	21.40	60.67	6.6	13.27	22.15
10/26/2022	18.72	52.71	5.8	11.65	19.44
10/27/2022	26.51	59.68	6.5	13.05	21.74
10/28/2022	29.15	69.30	7.7	14.99	24.97
10/29/2022	21.24	56.12	5.8	11.94	19.90
10/30/2022	20.10	55.98	6.3	11.90	19.84
10/31/2022	22.04	53.20	6.0	11.99	19.99
Monthly Avg/Sum*:	616.43 *	1,304.25 *	140.2 *	282.07 *	470.18 *
Daily Min:	12.70	35.81	3.1	6.00	9.99
Daily Max:	61.26	70.59	7.7	15.28	25.48
Oct 2022 - Oct 2022	616.43	1,304.25	140.2	282.07	470.18
QTD:	616.43 *	1,304.25 *	140.2 *	282.07 *	470.18 *
YTD 2022:	6,676.01 *	11,346.51 *	1,162.0 *	2,316.99 *	3,861.64 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2022	30.85	74.45	7.9	16.13	26.88
11/02/2022	27.46	64.65	7.0	14.06	23.46
11/03/2022	27.15	66.71	7.2	14.48	24.16
11/04/2022	21.05	56.25	6.2	11.92	19.88
11/05/2022	17.13	50.06	5.3	10.44	17.41
11/06/2022	25.10	65.73	6.3	12.98	21.60
11/07/2022	26.49	60.08	6.1	12.56	20.94
11/08/2022	8.91	0.25	0.0	0.00	0.01
11/09/2022	29.12	16.27	0.7	1.30	2.18
11/10/2022	22.15	57.95	6.4	12.79	21.28
11/11/2022	26.10	64.42	7.1	13.97	23.28
11/12/2022	30.36	75.28	8.0	16.31	27.16
11/13/2022	27.09	70.01	7.8	15.14	25.24
11/14/2022	26.49	72.43	8.1	15.72	26.19
11/15/2022	24.75	70.55	8.0	15.37	25.66
11/16/2022	28.43	68.16	7.7	15.00	24.99
11/17/2022	30.16	71.30	7.6	15.45	25.76
11/18/2022	28.13	80.04	9.0	17.45	29.07
11/19/2022	26.13	67.68	7.5	14.73	24.54
11/20/2022	34.95	74.67	7.9	16.25	27.13
11/21/2022	32.23	67.12	7.1	14.74	24.56
11/22/2022	32.55	67.38	7.0	14.58	24.29
11/23/2022	29.85	61.22	6.5	13.43	22.41
11/24/2022	35.98	69.69	7.1	15.18	25.33
11/25/2022	34.62	64.19	6.5	13.89	23.15
11/26/2022	34.25	68.01	6.9	14.62	24.42
11/27/2022	31.47	63.22	6.6	13.87	23.07
11/28/2022	34.83	65.31	6.9	14.14	23.57
11/29/2022	68.70	69.12	6.7	13.09	21.86
11/30/2022	25.22	62.81	6.6	13.79	22.97
Monthly Avg/Sum*:	877.70 *	1,885.01 *	199.7 *	403.38 *	672.45 *
Daily Min:	8.91	0.25	0.0	0.00	0.01
Daily Max:	68.70	80.04	9.0	17.45	29.07
Oct 2022 - Nov 2022	1,494.13	3,189.26	339.9	685.45	1,142.63
QTD:	1,494.13 *	3,189.26 *	339.9 *	685.45 *	1,142.63 *
YTD 2022:	7,553.71 *	13,231.52 *	1,361.7 *	2,720.37 *	4,534.09 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 15:25 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2022	26.15	72.98	8.0	15.87	26.46
12/02/2022	25.69	79.67	8.8	17.16	28.59
12/03/2022	34.95	64.05	6.4	12.78	21.30
12/04/2022	0.00	0.00	0.0	0.00	0.00
12/05/2022	29.32	36.56	1.9	3.86	6.43
12/06/2022	16.73	52.96	5.8	11.75	19.57
12/07/2022	27.84	69.39	7.4	15.10	25.14
12/08/2022	24.96	77.53	8.6	16.86	28.13
12/09/2022	23.58	65.46	7.5	14.25	23.79
12/10/2022	22.46	64.77	6.8	14.22	23.69
12/11/2022	18.50	54.43	6.0	11.95	19.87
12/12/2022	26.37	35.45	3.9	7.63	12.70
12/13/2022	0.00	0.00	0.0	0.00	0.00
12/14/2022	0.00	0.00	0.0	0.00	0.00
12/15/2022	0.00	0.00	0.0	0.00	0.00
12/16/2022	0.00	0.00	0.0	0.00	0.00
12/17/2022	52.88	64.36	6.1	11.96	19.95
12/18/2022	26.63	67.46	7.5	14.76	24.60
12/19/2022	24.41	82.64	9.6	17.90	29.79
12/20/2022	27.75	65.40	6.9	14.22	23.76
12/21/2022	37.04	75.39	7.9	16.45	27.35
12/22/2022	32.51	73.21	7.5	15.90	26.52
12/23/2022	33.88	72.72	7.7	15.93	26.55
12/24/2022	29.54	64.90	6.7	14.03	23.39
12/25/2022	14.42	43.39	4.9	9.63	16.07
12/26/2022	23.53	57.02	6.0	12.53	20.90
12/27/2022	9.23	40.17	4.8	8.72	14.56
12/28/2022	10.40	40.70	4.8	8.93	14.95
12/29/2022	9.78	40.71	4.8	8.88	14.87
12/30/2022	8.88	40.65	4.8	8.92	14.79
12/31/2022	72.44	42.70	3.9	7.53	12.53
Monthly Avg/Sum*:	689.87 *	1,544.67 *	165.0 *	327.72 *	546.25 *
Daily Min:	8.88	35.45	1.9	3.86	6.43
Daily Max:	72.44	82.64	9.6	17.90	29.79
Oct 2022 - Dec 2022	2,184.00	4,733.93	504.9	1,013.17	1,688.88
QTD:	2,184.00 *	4,733.93 *	504.9 *	1,013.17 *	1,688.88 *
YTD 2022:	8,243.58 *	14,776.19 *	1,526.7 *	3,048.09 *	5,080.34 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2022	23.99	94.97	10.63	21.25	35.40
10/02/2022	38.90	110.10	11.54	23.10	38.51
10/03/2022	48.06	113.38	13.02	26.00	43.38
10/04/2022	85.68	137.90	15.11	30.20	50.34
10/05/2022	68.63	141.28	15.16	30.31	50.56
10/06/2022	52.28	125.69	13.62	27.26	45.42
10/07/2022	71.36	141.34	15.29	30.58	51.00
10/08/2022	73.95	123.81	13.30	26.62	44.33
10/09/2022	35.57	64.88	6.96	13.96	23.26
10/10/2022	27.67	59.52	6.55	13.14	21.90
10/11/2022	17.92	47.24	5.17	10.36	17.25
10/12/2022	15.66	46.66	5.01	10.22	16.98
10/13/2022	16.66	47.21	5.17	10.48	17.41
10/14/2022	26.11	54.89	5.95	11.99	19.93
10/15/2022	15.42	45.23	4.92	9.95	16.56
10/16/2022	27.92	53.05	5.80	11.75	19.52
10/17/2022	32.37	63.74	6.95	13.90	23.19
10/18/2022	50.34	102.68	10.26	20.59	34.26
10/19/2022	75.01	97.70	10.21	20.36	33.92
10/20/2022	29.13	103.49	11.33	22.70	37.88
10/21/2022	32.32	102.93	11.32	22.61	37.71
10/22/2022	34.84	134.28	14.55	29.09	48.52
10/23/2022	40.33	124.08	13.31	26.65	44.41
10/24/2022	46.76	124.44	13.56	27.05	45.09
10/25/2022	37.75	117.15	12.77	25.54	42.60
10/26/2022	32.94	101.99	11.27	22.50	37.52
10/27/2022	48.24	115.96	12.65	25.26	42.06
10/28/2022	50.59	134.17	14.50	29.00	48.37
10/29/2022	37.35	106.67	11.50	23.03	38.37
10/30/2022	35.20	105.48	11.44	22.91	38.15
10/31/2022	38.22	104.11	11.54	23.12	38.52
Monthly Avg/Sum*:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
Daily Min:	15.42	45.23	4.92	9.95	16.56
Daily Max:	85.68	141.34	15.29	30.58	51.00
Oct 2022 - Oct 2022	1,267.17	3,046.02	330.36	661.48	1,102.32
QTD:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
YTD 2022:	11,980.84 *	22,223.38 *	2,278.01 *	4,557.33 *	7,596.69 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2022	57.32	144.53	15.65	31.30	52.21
11/02/2022	49.02	125.51	13.60	27.18	45.35
11/03/2022	46.77	129.29	13.99	28.00	46.67
11/04/2022	36.74	107.04	11.51	23.00	38.38
11/05/2022	30.29	94.08	10.08	20.19	33.62
11/06/2022	44.82	122.08	12.51	25.03	41.71
11/07/2022	44.12	113.74	12.13	24.26	40.41
11/08/2022	36.05	59.15	6.32	12.68	21.10
11/09/2022	54.79	69.43	6.44	12.98	21.63
11/10/2022	40.54	113.02	12.35	24.68	41.12
11/11/2022	47.96	124.31	13.53	27.04	45.02
11/12/2022	56.08	145.56	15.78	31.54	52.56
11/13/2022	47.82	135.29	14.62	29.21	48.70
11/14/2022	46.53	140.29	15.22	30.37	50.66
11/15/2022	43.33	137.03	14.91	29.79	49.69
11/16/2022	51.07	132.38	14.47	28.97	48.27
11/17/2022	53.64	137.91	14.98	29.86	49.78
11/18/2022	48.88	156.10	16.93	33.86	56.43
11/19/2022	44.93	131.37	14.24	28.54	47.54
11/20/2022	61.24	145.00	15.75	31.49	52.52
11/21/2022	57.81	130.39	14.27	28.52	47.52
11/22/2022	57.43	130.21	14.11	28.17	46.92
11/23/2022	52.86	118.68	12.97	25.94	43.25
11/24/2022	65.70	134.77	14.70	29.37	48.96
11/25/2022	63.23	124.07	13.44	26.84	44.75
11/26/2022	61.11	131.31	14.16	28.31	47.24
11/27/2022	56.41	122.51	13.40	26.77	44.62
11/28/2022	63.30	126.35	13.69	27.33	45.56
11/29/2022	86.13	134.44	14.09	28.13	46.91
11/30/2022	43.45	121.76	13.26	26.60	44.32
Monthly Avg/Sum*:	1,549.37 *	3,737.60 *	403.10 *	805.95 *	1,343.42 *
Daily Min:	30.29	59.15	6.32	12.68	21.10
Daily Max:	86.13	156.10	16.93	33.86	56.43
Oct 2022 - Nov 2022	2,816.54	6,783.62	733.46	1,467.43	2,445.74
QTD:	2,816.54 *	6,783.62 *	733.46 *	1,467.43 *	2,445.74 *
YTD 2022:	13,530.21 *	25,960.98 *	2,681.11 *	5,363.28 *	8,940.11 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 **To:** 12/31/2022 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2022	49.73	141.71	15.37	30.74	51.19
12/02/2022	48.73	154.05	16.60	33.22	55.38
12/03/2022	57.60	133.32	13.90	27.82	46.34
12/04/2022	26.90	65.43	7.03	14.04	23.40
12/05/2022	46.29	90.20	7.88	15.75	26.25
12/06/2022	74.57	90.63	8.75	17.46	29.10
12/07/2022	54.58	134.25	14.54	29.13	48.53
12/08/2022	47.82	150.29	16.33	32.68	54.45
12/09/2022	44.57	126.83	13.77	27.58	46.00
12/10/2022	43.22	125.54	13.72	27.39	45.70
12/11/2022	36.11	105.16	11.50	23.02	38.32
12/12/2022	49.17	85.18	10.04	20.07	33.42
12/13/2022	32.01	61.34	6.71	13.43	22.38
12/14/2022	20.94	59.61	6.44	12.85	21.41
12/15/2022	18.28	64.78	6.96	13.83	23.04
12/16/2022	9.74	39.11	4.25	8.60	14.25
12/17/2022	74.10	121.27	12.22	24.43	40.71
12/18/2022	51.25	130.58	14.25	28.53	47.60
12/19/2022	46.53	159.43	17.31	34.70	57.76
12/20/2022	52.81	126.80	13.75	27.47	45.84
12/21/2022	71.80	146.39	15.88	31.75	52.92
12/22/2022	63.04	142.01	15.40	30.71	51.24
12/23/2022	66.86	141.94	15.41	30.80	51.36
12/24/2022	56.07	125.48	13.57	27.05	45.10
12/25/2022	27.43	84.27	9.30	18.56	30.95
12/26/2022	44.99	110.59	12.10	24.18	40.31
12/27/2022	21.27	77.21	8.44	16.80	28.06
12/28/2022	17.92	40.81	4.57	8.93	14.95
12/29/2022	9.78	40.71	4.54	8.88	14.87
12/30/2022	8.88	40.65	4.40	8.92	14.79
12/31/2022	72.44	42.70	3.74	7.53	12.53
Monthly Avg/Sum*:	1,345.43 *	3,158.27 *	338.67 *	676.85 *	1,128.15 *
Daily Min:	8.88	39.11	3.74	7.53	12.53
Daily Max:	74.57	159.43	17.31	34.70	57.76
Oct 2022 - Dec 2022	4,161.97	9,941.89	1,072.13	2,144.28	3,573.89
QTD:	4,161.97 *	9,941.89 *	1,072.13 *	2,144.28 *	3,573.89 *
YTD 2022:	14,875.64 *	29,119.25 *	3,019.78 *	6,040.13 *	10,068.26 *

ATTACHMENT 19

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2022	23.99	94.97	10.63	21.25	35.40
10/02/2022	38.90	110.10	11.54	23.10	38.51
10/03/2022	48.06	113.38	13.02	26.00	43.38
10/04/2022	85.68	137.90	15.11	30.20	50.34
10/05/2022	68.63	141.28	15.16	30.31	50.56
10/06/2022	52.28	125.69	13.62	27.26	45.42
10/07/2022	71.36	141.34	15.29	30.58	51.00
10/08/2022	73.95	123.81	13.30	26.62	44.33
10/09/2022	35.57	64.88	6.96	13.96	23.26
10/10/2022	27.67	59.52	6.55	13.14	21.90
10/11/2022	17.92	47.24	5.17	10.36	17.25
10/12/2022	15.66	46.66	5.01	10.22	16.98
10/13/2022	16.66	47.21	5.17	10.48	17.41
10/14/2022	26.11	54.89	5.95	11.99	19.93
10/15/2022	15.42	45.23	4.92	9.95	16.56
10/16/2022	27.92	53.05	5.80	11.75	19.52
10/17/2022	32.37	63.74	6.95	13.90	23.19
10/18/2022	50.34	102.68	10.26	20.59	34.26
10/19/2022	75.01	97.70	10.21	20.36	33.92
10/20/2022	29.13	103.49	11.33	22.70	37.88
10/21/2022	32.32	102.93	11.32	22.61	37.71
10/22/2022	34.84	134.28	14.55	29.09	48.52
10/23/2022	40.33	124.08	13.31	26.65	44.41
10/24/2022	46.76	124.44	13.56	27.05	45.09
10/25/2022	37.75	117.15	12.77	25.54	42.60
10/26/2022	32.94	101.99	11.27	22.50	37.52
10/27/2022	48.24	115.96	12.65	25.26	42.06
10/28/2022	50.59	134.17	14.50	29.00	48.37
10/29/2022	37.35	106.67	11.50	23.03	38.37
10/30/2022	35.20	105.48	11.44	22.91	38.15
10/31/2022	38.22	104.11	11.54	23.12	38.52
Monthly Avg/Sum*:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
Daily Min:	15.42	45.23	4.92	9.95	16.56
Daily Max:	85.68	141.34	15.29	30.58	51.00
Oct 2022 - Oct 2022	1,267.17	3,046.02	330.36	661.48	1,102.32
QTD:	1,267.17 *	3,046.02 *	330.36 *	661.48 *	1,102.32 *
YTD 2022:	11,980.84 *	22,223.38 *	2,278.01 *	4,557.33 *	7,596.69 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2022	57.32	144.53	15.65	31.30	52.21
11/02/2022	49.02	125.51	13.60	27.18	45.35
11/03/2022	46.77	129.29	13.99	28.00	46.67
11/04/2022	36.74	107.04	11.51	23.00	38.38
11/05/2022	30.29	94.08	10.08	20.19	33.62
11/06/2022	44.82	122.08	12.51	25.03	41.71
11/07/2022	44.12	113.74	12.13	24.26	40.41
11/08/2022	36.05	59.15	6.32	12.68	21.10
11/09/2022	54.79	69.43	6.44	12.98	21.63
11/10/2022	40.54	113.02	12.35	24.68	41.12
11/11/2022	47.96	124.31	13.53	27.04	45.02
11/12/2022	56.08	145.56	15.78	31.54	52.56
11/13/2022	47.82	135.29	14.62	29.21	48.70
11/14/2022	46.53	140.29	15.22	30.37	50.66
11/15/2022	43.33	137.03	14.91	29.79	49.69
11/16/2022	51.07	132.38	14.47	28.97	48.27
11/17/2022	53.64	137.91	14.98	29.86	49.78
11/18/2022	48.88	156.10	16.93	33.86	56.43
11/19/2022	44.93	131.37	14.24	28.54	47.54
11/20/2022	61.24	145.00	15.75	31.49	52.52
11/21/2022	57.81	130.39	14.27	28.52	47.52
11/22/2022	57.43	130.21	14.11	28.17	46.92
11/23/2022	52.86	118.68	12.97	25.94	43.25
11/24/2022	65.70	134.77	14.70	29.37	48.96
11/25/2022	63.23	124.07	13.44	26.84	44.75
11/26/2022	61.11	131.31	14.16	28.31	47.24
11/27/2022	56.41	122.51	13.40	26.77	44.62
11/28/2022	63.30	126.35	13.69	27.33	45.56
11/29/2022	86.13	134.44	14.09	28.13	46.91
11/30/2022	43.45	121.76	13.26	26.60	44.32
Monthly Avg/Sum*:	1,549.37 *	3,737.60 *	403.10 *	805.95 *	1,343.42 *
Daily Min:	30.29	59.15	6.32	12.68	21.10
Daily Max:	86.13	156.10	16.93	33.86	56.43
Oct 2022 - Nov 2022	2,816.54	6,783.62	733.46	1,467.43	2,445.74
QTD:	2,816.54 *	6,783.62 *	733.46 *	1,467.43 *	2,445.74 *
YTD 2022:	13,530.21 *	25,960.98 *	2,681.11 *	5,363.28 *	8,940.11 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2022	49.73	141.71	15.37	30.74	51.19
12/02/2022	48.73	154.05	16.60	33.22	55.38
12/03/2022	57.60	133.32	13.90	27.82	46.34
12/04/2022	26.90	65.43	7.03	14.04	23.40
12/05/2022	46.29	90.20	7.88	15.75	26.25
12/06/2022	74.57	90.63	8.75	17.46	29.10
12/07/2022	54.58	134.25	14.54	29.13	48.53
12/08/2022	47.82	150.29	16.33	32.68	54.45
12/09/2022	44.57	126.83	13.77	27.58	46.00
12/10/2022	43.22	125.54	13.72	27.39	45.70
12/11/2022	36.11	105.16	11.50	23.02	38.32
12/12/2022	49.17	85.18	10.04	20.07	33.42
12/13/2022	32.01	61.34	6.71	13.43	22.38
12/14/2022	20.94	59.61	6.44	12.85	21.41
12/15/2022	18.28	64.78	6.96	13.83	23.04
12/16/2022	9.74	39.11	4.25	8.60	14.25
12/17/2022	74.10	121.27	12.22	24.43	40.71
12/18/2022	51.25	130.58	14.25	28.53	47.60
12/19/2022	46.53	159.43	17.31	34.70	57.76
12/20/2022	52.81	126.80	13.75	27.47	45.84
12/21/2022	71.80	146.39	15.88	31.75	52.92
12/22/2022	63.04	142.01	15.40	30.71	51.24
12/23/2022	66.86	141.94	15.41	30.80	51.36
12/24/2022	56.07	125.48	13.57	27.05	45.10
12/25/2022	27.43	84.27	9.30	18.56	30.95
12/26/2022	44.99	110.59	12.10	24.18	40.31
12/27/2022	21.27	77.21	8.44	16.80	28.06
12/28/2022	17.92	40.81	4.57	8.93	14.95
12/29/2022	9.78	40.71	4.54	8.88	14.87
12/30/2022	8.88	40.65	4.40	8.92	14.79
12/31/2022	72.44	42.70	3.74	7.53	12.53
Monthly Avg/Sum*:	1,345.43 *	3,158.27 *	338.67 *	676.85 *	1,128.15 *
Daily Min:	8.88	39.11	3.74	7.53	12.53
Daily Max:	74.57	159.43	17.31	34.70	57.76
Oct 2022 - Dec 2022	4,161.97	9,941.89	1,072.13	2,144.28	3,573.89
QTD:	4,161.97 *	9,941.89 *	1,072.13 *	2,144.28 *	3,573.89 *
YTD 2022:	14,875.64 *	29,119.25 *	3,019.78 *	6,040.13 *	10,068.26 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2022 00:00 To: 12/31/2022 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/03/2023 14:48 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2022	0.6338	6.9447	1.5229	13.9715	0.3310	2.9119	0.1656	1.4563	0.5515	4.8538
Nov 2022	0.7748	7.3343	1.8689	14.5482	0.4031	3.0270	0.2017	1.5140	0.6720	5.0462
Dec 2022	0.6728	7.4389	1.5792	14.5596	0.3385	3.0207	0.1697	1.5116	0.5644	5.0359
Sum/Avg	7.4389		14.5596		3.0207		1.5116		5.0359	
Limit Value										

Replace the dates with the ones you need

10/1/2022 0:00
12/31/2022 0:00

1D

TOWER AVG.

519-AIT-9504-1

3616

10/1/22 0:00	3612.3
10/2/22 0:00	3521.1
10/3/22 0:00	3409.4
10/4/22 0:00	3684.5
10/5/22 0:00	3579.2
10/6/22 0:00	3854.2
10/7/22 0:00	3507.0
10/8/22 0:00	3716.3
10/9/22 0:00	3625.6
10/10/22 0:00	3919.1
10/11/22 0:00	3222.0
10/12/22 0:00	3257.6
10/13/22 0:00	3074.8
10/14/22 0:00	3256.8
10/15/22 0:00	3183.6
10/16/22 0:00	3061.0
10/17/22 0:00	3052.0
10/18/22 0:00	3309.1
10/19/22 0:00	3092.8
10/20/22 0:00	3077.0
10/21/22 0:00	3414.9
10/22/22 0:00	3291.7
10/23/22 0:00	2977.2
10/24/22 0:00	3612.5
10/25/22 0:00	4006.5
10/26/22 0:00	3979.6
10/27/22 0:00	4516.5
10/28/22 0:00	4223.7
10/29/22 0:00	4025.8
10/30/22 0:00	4549.8
10/31/22 0:00	4386.8
11/1/22 0:00	4088.6
11/2/22 0:00	4037.1
11/3/22 0:00	4166.6
11/4/22 0:00	3025.4
11/5/22 0:00	3614.6
11/6/22 0:00	3584.3
11/7/22 0:00	3502.3
11/8/22 0:00	3857.5
11/9/22 0:00	3668.2
11/10/22 0:00	3601.2
11/11/22 0:00	3567.6
11/12/22 0:00	3638.5
11/13/22 0:00	4138.6
11/14/22 0:00	3451.2
11/15/22 0:00	3886.8
11/16/22 0:00	3187.5
11/17/22 0:00	3687.7
11/18/22 0:00	3441.3

11/19/22 0:00	4438.7
11/20/22 0:00	2920.6
11/21/22 0:00	3560.4
11/22/22 0:00	3782.7
11/23/22 0:00	3623.0
11/24/22 0:00	4080.3
11/25/22 0:00	3755.8
11/26/22 0:00	3901.7
11/27/22 0:00	4677.4
11/28/22 0:00	4126.2
11/29/22 0:00	4104.8
11/30/22 0:00	4160.3
12/1/22 0:00	3517.8
12/2/22 0:00	4034.3
12/3/22 0:00	3875.8
12/4/22 0:00	4494.5
12/5/22 0:00	4016.5
12/6/22 0:00	4166.0
12/7/22 0:00	3303.6
12/8/22 0:00	3822.8
12/9/22 0:00	4045.6
12/10/22 0:00	3703.9
12/11/22 0:00	4040.8
12/12/22 0:00	3826.3
12/13/22 0:00	3614.9
12/14/22 0:00	4240.4
12/15/22 0:00	2907.6
12/16/22 0:00	3074.3
12/17/22 0:00	2526.0
12/18/22 0:00	2504.3
12/19/22 0:00	3263.3
12/20/22 0:00	3096.1
12/21/22 0:00	3134.2
12/22/22 0:00	3395.9
12/23/22 0:00	3274.5
12/24/22 0:00	3009.7
12/25/22 0:00	3854.9
12/26/22 0:00	3115.3
12/27/22 0:00	3287.3
12/28/22 0:00	2955.0
12/29/22 0:00	3020.2

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3616	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00231424	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	7.47

92	Days in quarter

PM-10 pounds this quarter	687	4Q22

fill only these

ATTACHMENT 20

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification: The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was last reported with the 2Q21 QAQR.

ATTACHMENT 21

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 22

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2022 0:00
12/31/2022 0:00

1D

TOWER AVG.

519-AIT-9504-1

3616

10/1/22 0:00	3612.3
10/2/22 0:00	3521.1
10/3/22 0:00	3409.4
10/4/22 0:00	3684.5
10/5/22 0:00	3579.2
10/6/22 0:00	3854.2
10/7/22 0:00	3507.0
10/8/22 0:00	3716.3
10/9/22 0:00	3625.6
10/10/22 0:00	3919.1
10/11/22 0:00	3222.0
10/12/22 0:00	3257.6
10/13/22 0:00	3074.8
10/14/22 0:00	3256.8
10/15/22 0:00	3183.6
10/16/22 0:00	3061.0
10/17/22 0:00	3052.0
10/18/22 0:00	3309.1
10/19/22 0:00	3092.8
10/20/22 0:00	3077.0
10/21/22 0:00	3414.9
10/22/22 0:00	3291.7
10/23/22 0:00	2977.2
10/24/22 0:00	3612.5
10/25/22 0:00	4006.5
10/26/22 0:00	3979.6
10/27/22 0:00	4516.5
10/28/22 0:00	4223.7
10/29/22 0:00	4025.8
10/30/22 0:00	4549.8
10/31/22 0:00	4386.8
11/1/22 0:00	4088.6
11/2/22 0:00	4037.1
11/3/22 0:00	4166.6
11/4/22 0:00	3025.4
11/5/22 0:00	3614.6
11/6/22 0:00	3584.3
11/7/22 0:00	3502.3
11/8/22 0:00	3857.5
11/9/22 0:00	3668.2
11/10/22 0:00	3601.2
11/11/22 0:00	3567.6
11/12/22 0:00	3638.5
11/13/22 0:00	4138.6
11/14/22 0:00	3451.2
11/15/22 0:00	3886.8
11/16/22 0:00	3187.5
11/17/22 0:00	3687.7
11/18/22 0:00	3441.3

11/19/22 0:00	4438.7
11/20/22 0:00	2920.6
11/21/22 0:00	3560.4
11/22/22 0:00	3782.7
11/23/22 0:00	3623.0
11/24/22 0:00	4080.3
11/25/22 0:00	3755.8
11/26/22 0:00	3901.7
11/27/22 0:00	4677.4
11/28/22 0:00	4126.2
11/29/22 0:00	4104.8
11/30/22 0:00	4160.3
12/1/22 0:00	3517.8
12/2/22 0:00	4034.3
12/3/22 0:00	3875.8
12/4/22 0:00	4494.5
12/5/22 0:00	4016.5
12/6/22 0:00	4166.0
12/7/22 0:00	3303.6
12/8/22 0:00	3822.8
12/9/22 0:00	4045.6
12/10/22 0:00	3703.9
12/11/22 0:00	4040.8
12/12/22 0:00	3826.3
12/13/22 0:00	3614.9
12/14/22 0:00	4240.4
12/15/22 0:00	2907.6
12/16/22 0:00	3074.3
12/17/22 0:00	2526.0
12/18/22 0:00	2504.3
12/19/22 0:00	3263.3
12/20/22 0:00	3096.1
12/21/22 0:00	3134.2
12/22/22 0:00	3395.9
12/23/22 0:00	3274.5
12/24/22 0:00	3009.7
12/25/22 0:00	3854.9
12/26/22 0:00	3115.3
12/27/22 0:00	3287.3
12/28/22 0:00	2955.0
12/29/22 0:00	3020.2

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3616	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00231424	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	7.47

92	Days in quarter

PM-10 pounds this quarter	687	4Q22

fill only these

ATTACHMENT 23

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $\text{PM-10} = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow down water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2022 0:00
12/31/2022 0:00

1D

TOWER AVG.

519-AIT-9504-1

3616

10/1/22 0:00	3612.3
10/2/22 0:00	3521.1
10/3/22 0:00	3409.4
10/4/22 0:00	3684.5
10/5/22 0:00	3579.2
10/6/22 0:00	3854.2
10/7/22 0:00	3507.0
10/8/22 0:00	3716.3
10/9/22 0:00	3625.6
10/10/22 0:00	3919.1
10/11/22 0:00	3222.0
10/12/22 0:00	3257.6
10/13/22 0:00	3074.8
10/14/22 0:00	3256.8
10/15/22 0:00	3183.6
10/16/22 0:00	3061.0
10/17/22 0:00	3052.0
10/18/22 0:00	3309.1
10/19/22 0:00	3092.8
10/20/22 0:00	3077.0
10/21/22 0:00	3414.9
10/22/22 0:00	3291.7
10/23/22 0:00	2977.2
10/24/22 0:00	3612.5
10/25/22 0:00	4006.5
10/26/22 0:00	3979.6
10/27/22 0:00	4516.5
10/28/22 0:00	4223.7
10/29/22 0:00	4025.8
10/30/22 0:00	4549.8
10/31/22 0:00	4386.8
11/1/22 0:00	4088.6
11/2/22 0:00	4037.1
11/3/22 0:00	4166.6
11/4/22 0:00	3025.4
11/5/22 0:00	3614.6
11/6/22 0:00	3584.3
11/7/22 0:00	3502.3
11/8/22 0:00	3857.5
11/9/22 0:00	3668.2
11/10/22 0:00	3601.2
11/11/22 0:00	3567.6
11/12/22 0:00	3638.5
11/13/22 0:00	4138.6
11/14/22 0:00	3451.2
11/15/22 0:00	3886.8
11/16/22 0:00	3187.5
11/17/22 0:00	3687.7
11/18/22 0:00	3441.3

11/19/22 0:00	4438.7
11/20/22 0:00	2920.6
11/21/22 0:00	3560.4
11/22/22 0:00	3782.7
11/23/22 0:00	3623.0
11/24/22 0:00	4080.3
11/25/22 0:00	3755.8
11/26/22 0:00	3901.7
11/27/22 0:00	4677.4
11/28/22 0:00	4126.2
11/29/22 0:00	4104.8
11/30/22 0:00	4160.3
12/1/22 0:00	3517.8
12/2/22 0:00	4034.3
12/3/22 0:00	3875.8
12/4/22 0:00	4494.5
12/5/22 0:00	4016.5
12/6/22 0:00	4166.0
12/7/22 0:00	3303.6
12/8/22 0:00	3822.8
12/9/22 0:00	4045.6
12/10/22 0:00	3703.9
12/11/22 0:00	4040.8
12/12/22 0:00	3826.3
12/13/22 0:00	3614.9
12/14/22 0:00	4240.4
12/15/22 0:00	2907.6
12/16/22 0:00	3074.3
12/17/22 0:00	2526.0
12/18/22 0:00	2504.3
12/19/22 0:00	3263.3
12/20/22 0:00	3096.1
12/21/22 0:00	3134.2
12/22/22 0:00	3395.9
12/23/22 0:00	3274.5
12/24/22 0:00	3009.7
12/25/22 0:00	3854.9
12/26/22 0:00	3115.3
12/27/22 0:00	3287.3
12/28/22 0:00	2955.0
12/29/22 0:00	3020.2

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3616	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00231424	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	7.47

92	Days in quarter

PM-10 pounds this quarter	687	4Q22

fill only these

ATTACHMENT 24

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

[illegible]

ATTACHMENT 25

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

24

Date	Time Start	Reason	Time Stop	Initials	Total Hours	YTD Hours
8/2/21	1519	Weekly Test Run	1542	2KR	212.1	12.8
8-21-21	1131	Weekly test Run	1201	JM	212.6	12.8
9-2-21	0902	Weekly Test Run	0932	LH	213.1	13.3
9-12-2021	1628	WEEKLY TEST RUN	1658	KAB	213.6	13.8
9-19-21	1150	Weekly Test Run	1220	DWN	214.1	14.8 *
9-25-21	1239	Weekly Test Run	1309	JM	214.6	15.3
10-3-21	1410	Weekly Test Run	1440	KRO	215.1	15.8
10-11-2021	1640	WEEKLY TEST RUN	1710	KAB	215.6	16.3
10-16-21	1307	Weekly test Run	1330	JM	216.1	16.8
10-24-21	1553	WEEKLY TEST RUN	1623	RL	216.6	17.3
10-31-21	1351	Weekly test Run	1421	KRO	217.1	17.8
11-7-2021	1354	WEEKLY TEST RUN	1424	KAB	217.6	18.3
11-14-2021	1444	WEEKLY TEST RUN	1514	KAB	218.1	18.8
11-21-21	1203	Weekly Test Run	1233	DE	218.6	19.3
11-24-21	09:46	Fill Diesel TANK	09:48	LH	80 gallons	
11-28-21	1347	Weekly Test Run	1417	DE	219.1	19.8
12/5/2021	1445	WEEKLY TEST RUN	1515	KAB	219.6	20.3
12-12-21	1150	Weekly Test Run	1220	DWN	220.1	20.8
12-19-21	1553	WEEKLY TEST RUN	1623	RL	220.6	21.3
12-26-21	1514	Weekly Test Run	1544	LH	221.1	21.8
1-2-2022	1547	WEEKLY TEST RUN	1617	KAB	221.6	22.3 KAB
2022 Starting Hours 221.1						
1-2-22	1547	Weekly Test Run	1617	KAB	221.6	0.5
1/10/22	0330	Weekly Test Run	0400	DE	222.1	1.0
1/16/22	1318	Weekly Test Run	1348	2KR	222.6	1.5
1/23/22	1223	Weekly test Run	1253	KOB	223.1	2.0
1-25-22	1610	Weekly Test Run	1640	LH	223.6	2.5
2-5-22	1415	Weekly test Run	1445	JM	224.1	3
2-14-22	1705	Weekly Test Run	1735	2KR	224.6	3.5
2-21-2022	1430	WEEKLY TEST RUN	1500	KAB	225.1	4.0
2-27-2022	1405	WEEKLY TEST RUN	1435	KAB	225.6	4.5
3-5-22	1454	Weekly test Run	1524	JM	226.1	5.0
3-11-22	0915	DIESEL FUEL DELIVERY	48 GALS	AB		
3/13/22	1213	WEEKLY TEST RUN	1243	DE	226.6	5.5
3/20/22	1310	WEEKLY TEST RUN	1340	DE	227.1	6.0
3-27-2022	1520	WEEKLY TEST RUN	1550	KAB	227.6	6.5

2020:199.3

YTD Hours

25

DATE	START	REASON	STOP	TOTAL HRS	YTD	INITIALS
4-3-22	1500	Weekly Test Run	1530	228.1	7.0	DWN
4-30-22	0855	Weekly test Run	0925	230.4	9.0	JM
5-8-22	1444	Weekly Test Run	1512	230.6	9.5	2KR
5-15-22	14:55	WEEKLY TEST RUN	15:25	231.1	10.0	EO
5-22-2022	1311	WEEKLY TEST RUN	1341	231.6	10.5	KAB
5-28-22	1510	Weekly test Run	1540	232.1	11	JM
6-5-22	1440	WEEKLY TEST RUN	1510	232.6	11.5	RL
6-12-22	16:20	WEEKLY Test Run	16:50	233.1	12.0	LH
6-20-22	1200	WEEKLY TEST RUN	1230	233.6	12.5	RL
6-25-22	1042	Weekly test Run	1112	234.1	13	JM
7/3/22	1326	WEEKLY TEST RUN	1356	234.6	13.5	DE
7/10/22	1046	WEEKLY TEST RUN	1110	235.1	14.0	DE
7/17/2022	1342	WEEKLY TEST RUN	1412	235.6	14.5	KAB
7-21-22	1139	Weekly test Run	1209	236.1	15	JM
7-31-22	1320	WEEKLY TEST RUN	1350	236.6	15.5	RL
8/7/22	1317	WEEKLY TEST RUN	1347	237.1	16.0	DE
8-14-2022	1338	WEEKLY TEST RUN	1408	237.6	16.5	KAB
8-21-22	1609	Weekly Test Run	1639	238.1	17.0	CYC
8-28-22	1454	Weekly Test Run	1524	238.6	17.5	2KR
9-6-22	0949	Weekly Test Run	1019	239.1	18.0	LH
9-11-22	13:33	Weekly test Run	1403	239.6	18.5	DE
9-17-22	10:52	Weekly test Run	11:22	240.1	19	JM
9-25-22	11:55	Weekly Test Run	12:25	240.6	19.5	2KR
9/30/22	Diesel Delivery		52 gals			LH
10/7/22	1310	Weekly Test Run	1340	241.1	20.0	DE
10/13/22	10:31	Test After Repairs	10:36	24.2	20.1	LH
10/19/22	1256	Weekly Test Run	1326	24.7	20.6	KAB
10-15-22	1730	Weekly test Run	1800	242.2	21.1	JM
10-24-22	1540	Weekly Test Run	1610	242.7	21.6	JM
10-30-2022	1545	WEEKLY TEST RUN	1615	243.2	22.1	KAB
11-6-22	1310	WEEKLY TEST RUN	1340	243.7	22.6	RL
11-12-22	1134	Weekly test Run	1204	244.2	23.1	JM
11-19-22	1544	Weekly Test Run	1614	244.7	23.6	CYC
11-27-22	1653	Weekly Test Run	1723	245.2	24.1	CYC
12/6/22	10500	ANNUAL TEST	1400	246.5	25.4	JM
12-10-22	1450	Weekly test Run	1526	247	25.9	JM

DATE	TIME START	Reason	TIME STOP	Total Hrs	YTD Hrs	initials
12-17-22	1406	Weekly Test Run	1436	247.5	26.9	Amf
12-25-22	0152	WEEKLY TEST RUN	0222	248.0	26.9	AS
12-31-22	1614	Weekly Test Run	1644	248.5	27.4	AS

ATTACHMENT 26

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

ATTACHMENT 27

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1535	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	HAB	1449	1519	BI-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	010
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730
2023					130	0

ATTACHMENT 28

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 29

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

ATTACHMENT 30

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1535	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	HAB	1449	1519	BI-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	010
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730
2023					130	0

ATTACHMENT 31

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

[illegible]

ATTACHMENT 32

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

ATTACHMENT 33

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1535	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	HAB	1449	1519	BI-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	010
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730
2023					130	0

ATTACHMENT 34

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 35

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 4Q22 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.