

DOCKETED	
Docket Number:	22-SPPE-02
Project Title:	San Jose Data Center 04
TN #:	249562
Document Title:	NOP Comments from City of San Jose Environmental Services Department
Description:	CEC staff was made aware of the comment on March 22, 2023. On April 7, 2023 CEC staff received the original email to docket.
Filer:	Lisa Worrall
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	4/7/2023 3:45:43 PM
Docketed Date:	4/7/2023

From: Van Der Zweep, Cassandra <Cassandra.VanDerZweep@sanjoseca.gov>
Sent: Friday, April 7, 2023 3:24 PM
To: Worrall, Lisa@Energy <Lisa.Worrall@energy.ca.gov>
Subject: Fw: Request for Comments NOP EIR

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Lisa,

Please see the requested email. It is from the City's ESD Water Resources Division.

Thanks,

Cassandra van der Zweep

Supervising Planner | Planning, Building & Code Enforcement
City of San José | 200 East Santa Clara Street
Email: cassandra.vanderzweep@sanjoseca.gov | Phone: (408)-535-7659

From: Begiebing, Maria <Maria.Begiebing@sanjoseca.gov>
Sent: Thursday, March 9, 2023 3:50 PM
To: Van Der Zweep, Cassandra <Cassandra.VanDerZweep@sanjoseca.gov>
Subject: Re: Request for Comments NOP EIR

Hi Cassandra,

I have another utility I am waiting to hear back from, sorry for delay, but I did receive comments from our Water Resources. (Comment below)

The South Bay Water Recycling recycled water system was designed and built as an inland discharge of treated wastewater, without infrastructure redundancy or reliability features as typically associated with drinking water systems. Due to the lack of infrastructure redundancy, South Bay Water Recycling is considered an interruptible utility. While efforts are made to provide a consistent and reliable water supply, South Bay Water Recycling may still experience periodic water service disruptions.

The proposed project is no longer considering a looped recycled water system, nor onsite groundwater wells, as a redundant water supply. Please note, service disruptions, including scheduled or emergency operations and maintenance, may lead to the loss of recycled water service to the site

Maria Begiebing
Supervising Environmental Services Specialist

City of San José
Environmental Services Department
Sustainability & Policy (SuPo)
200 East Santa Clara Street- 10th Floor
San José, CA 95113
Tel: 408.975.2516