

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	249868
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2023
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	4/26/2023 8:17:04 AM
Docketed Date:	4/26/2023



Quarterly Operational Report

**Roseville Energy Park
(03-AFC-01C)**

First Quarter 2023

Submitted to:

California Energy Commission

List of Attachments

Attachment 1: AQ15 – SCR Installed before commissioning in 2007

Attachment 2: AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

Attachment 3: AQ21 – Startups and Shutdowns

Attachment 4: AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

Attachment 5: AQ33 – All hourly, daily, and quarterly Sox AQ-SC6

Attachment 6: AQ34 – Start Up and Shut downs

Attachment 7: AQ36 – Breakdown condition

Attachment 8: AQ37 – Violations of Emissions

Attachment 9: AQ40 – CEMS quality assurance test failures

Attachment 10: AQ41 – Excess Emissions

Attachment 11: AQ42 – Running 12 month summary

Attachment 12: AQ47 – All nuisance violations

N/A for this report period

Attachment 13: AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

Attachment 14: AQ51 – Ammonia slip exceedances

Attachment 15: AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

Attachment 16: AQ57 – Emission exceedance rates during startup and shutdown – CO, NOX, PM-10, SOX, and VOC

Attachment 17: AQ59 – Emission limit exceedances – NOX, CO, VOC, PM-10, SO2

Attachment 18: AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NO_x, CO, VOCs, PM₁₀, SO₂

Attachment 19: AQ63 – Total facility emission exceedances – NO_x, CO, VOC, PM-10, SO₂

Attachment 20: AQ68 – Annual water sample analysis of cooling tower water

Attachment 21: AQ69 – Nuisance complaints

N/A for this report period

Attachment 22: AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

Attachment 23: AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow down water* design drift rate

Attachment 24: AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

Attachment 25: AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

Attachment 26: AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

Attachment 27: AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

Attachment 28: AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

Attachment 29: AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

Attachment 30: AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Attachment 31: AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

Attachment 32: AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

Attachment 33: AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

Attachment 34: AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

Attachment 35: AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period

ATTACHMENT 1

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

ATTACHMENT 2

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ20 ROSEVILLE ENERGY PARK

1Q23

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	JAN	FEB	MAR
1	1052.25	1043.59	1039.93
2	1052.25	1042.77	1038.03
3	1051.09	1044.58	1039.19
4	1049.69	1045.47	1042.25
5	1047.09	1048.44	1045.02
6	1048.14	1055.42	1042.23
7	1050.08	1053.26	1041.67
8	1050.16	1052.81	1042.92
9	1051.21	1048.03	1046.29
10	1050.27	1044.12	1046.84
11	1051.13	1038.82	1048.01
12	1051.47	1040.69	1051.94
13	1052.40	1,042.33	1051.93
14	1052.71	1038.85	1051.61
15	1053.49	1041.12	1051.96
16	1051.38	1043.25	1052.17
17	1048.67	1041.11	1049.74
18	1047.46	1040.88	1047.22
19	1048.49	1039.51	1047.24
20	1047.29	1040.29	1047.81
21	1048.21	1045.43	1046.41
22	1046.61	1046.79	1044.26
23	1048.98	1041.81	1046.39
24	1048.22	1037.09	1046.67
25	1046.11	1037.09	1047.21
26	1042.84	1037.09	1046.38
27	1045.18	1032.67	1044.67
28	1046.80	1042.39	1047.29
29	1049.69	N/A	1046.61
30	1045.55	N/A	1046.41
31	1048.15	N/A	1044.07

odeline/operations/gas_quality/p01_2_weeks.shtml



California Gas Transmission

Pipe Ranger

Go

Log in

About CGT

Products

Tools & Services

Operating Data

Reference/Library

Current Pipeline Status

Forecasts

Historical Archives

Gas Quality/Heating Values

Gas System Sulfur Survey Results

Note: Starting Q4 2022, we began breaking sulfur data down monthly. Data will still be updated on a quarterly basis just with additional granularity.

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2022				
Fourth Quarter	4.2	0.25	0.8	0.05

ATTACHMENT 3

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.47	8.89	14.83
01/02/2023	70.30	107.48	10.90	21.70	36.20
01/03/2023	43.16	158.77	17.15	34.27	57.16
01/04/2023	38.26	76.13	8.09	16.23	27.01
01/05/2023	70.05	62.66	5.86	11.58	19.33
01/06/2023	72.64	70.54	6.51	12.99	21.60
01/07/2023	11.01	41.31	4.50	8.90	14.85
01/08/2023	80.03	72.15	6.89	13.75	22.95
01/09/2023	97.02	81.86	7.88	15.71	26.15
01/10/2023	87.97	77.46	7.47	14.85	24.78
01/11/2023	80.37	71.25	6.96	13.78	22.99
01/12/2023	87.61	71.86	6.88	13.71	22.82
01/13/2023	10.90	41.32	4.55	8.91	14.91
01/14/2023	75.93	69.03	6.51	12.98	21.64
01/15/2023	91.63	75.97	7.42	14.68	24.52
01/16/2023	88.48	78.04	7.60	15.11	25.24
01/17/2023	81.23	76.97	7.38	14.75	24.53
01/18/2023	49.14	78.98	8.55	16.98	28.35
01/19/2023	21.19	46.72	5.30	10.47	17.49
01/20/2023	40.39	62.03	6.78	13.41	22.37
01/21/2023	22.86	59.46	6.41	12.76	21.27
01/22/2023	22.45	50.42	5.46	10.98	18.25
01/23/2023	75.82	95.38	9.25	18.54	30.88
01/24/2023	51.26	82.90	8.97	17.89	29.81
01/25/2023	13.09	41.63	4.56	8.99	15.02
01/26/2023	12.89	41.93	4.56	8.97	14.97
01/27/2023	90.68	65.49	6.08	12.15	20.23
01/28/2023	9.30	37.73	4.14	8.41	13.96
01/29/2023	92.90	62.63	5.49	11.15	18.46
01/30/2023	25.25	66.19	7.20	14.42	24.05
01/31/2023	29.56	64.58	7.04	14.11	23.50
Monthly Avg/Sum*:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
Daily Min:	8.02	37.73	4.14	8.41	13.96
Daily Max:	97.02	158.77	17.15	34.27	57.16
Jan 2023 - Jan 2023	1,651.39	2,129.79	216.81	432.02	720.12
QTD:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
YTD 2023:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.47	11.07	18.41
02/02/2023	8.96	37.94	4.18	8.37	13.99
02/03/2023	53.12	85.39	8.16	16.36	27.29
02/04/2023	108.11	77.99	7.53	14.98	24.95
02/05/2023	87.96	64.19	5.88	11.66	19.40
02/06/2023	84.25	78.56	7.67	15.20	25.38
02/07/2023	74.29	84.12	8.26	16.41	27.37
02/08/2023	102.79	114.57	11.51	22.94	38.30
02/09/2023	110.14	113.63	11.41	22.87	38.08
02/10/2023	71.93	81.12	7.82	15.48	25.86
02/11/2023	108.40	113.45	11.78	23.52	39.21
02/12/2023	106.28	114.76	11.68	23.35	38.89
02/13/2023	35.31	43.33	4.73	9.32	15.55
02/14/2023	68.07	90.12	8.73	17.38	28.96
02/15/2023	139.40	125.21	12.48	24.83	41.34
02/16/2023	113.23	113.19	11.51	23.10	38.43
02/17/2023	51.56	57.29	6.20	12.35	20.58
02/18/2023	14.71	41.46	4.56	8.89	14.89
02/19/2023	16.33	41.56	4.53	8.95	14.93
02/20/2023	93.55	78.91	7.60	15.18	25.29
02/21/2023	10.53	37.94	4.21	8.38	13.95
02/22/2023	74.47	82.53	7.57	15.25	25.37
02/23/2023	63.79	104.53	11.25	22.55	37.54
02/24/2023	33.93	63.80	6.90	13.85	23.09
02/25/2023	11.76	44.64	4.97	9.78	16.39
02/26/2023	8.81	37.99	4.12	8.40	13.93
02/27/2023	78.18	72.19	6.64	13.38	22.27
02/28/2023	82.98	77.32	7.24	14.49	24.11
Monthly Avg/Sum*:	1,832.18 *	2,127.93 *	214.59 *	428.29 *	713.75 *
Daily Min:	8.81	37.94	4.12	8.37	13.93
Daily Max:	139.40	125.21	12.48	24.83	41.34
Jan 2023 - Feb 2023	3,483.57	4,257.72	431.40	860.31	1,433.87
QTD:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *
YTD 2023:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2023	51.98	74.11	8.06	16.05	26.78
03/02/2023	9.67	39.23	4.23	8.55	14.17
03/03/2023	85.29	81.61	7.53	15.10	25.14
03/04/2023	75.09	72.57	6.69	13.45	22.36
03/05/2023	75.04	85.77	8.07	16.09	26.83
03/06/2023	126.20	101.89	9.55	19.18	31.92
03/07/2023	116.20	108.24	10.82	21.73	36.18
03/08/2023	89.84	114.83	11.61	23.23	38.72
03/09/2023	76.00	143.12	15.31	30.58	50.99
03/10/2023	95.18	68.88	6.07	12.24	20.39
03/11/2023	56.34	76.68	7.11	14.40	23.97
03/12/2023	72.36	115.27	11.61	23.25	38.76
03/13/2023	59.09	69.55	7.01	14.14	23.54
03/14/2023	87.90	112.41	11.25	22.52	37.54
03/15/2023	68.63	71.50	6.18	12.49	20.80
03/16/2023	58.11	51.83	4.30	8.72	14.48
03/17/2023	184.98	110.06	9.98	19.98	33.29
03/18/2023	89.16	76.17	6.91	13.89	23.14
03/19/2023	69.83	87.09	8.17	16.41	27.35
03/20/2023	100.82	74.36	5.92	11.91	19.84
03/21/2023	50.51	34.49	2.45	4.94	8.23
03/22/2023	82.62	85.32	8.05	16.02	26.77
03/23/2023	82.43	80.88	7.78	15.50	25.79
03/24/2023	12.46	43.27	4.80	9.57	15.84
03/25/2023	25.39	43.01	4.63	9.10	15.18
03/26/2023	0.00	0.00	0.00	0.00	0.00
03/27/2023	0.00	0.00	0.00	0.00	0.00
03/28/2023	0.00	0.00	0.00	0.00	0.00
03/29/2023	0.00	0.00	0.00	0.00	0.00
03/30/2023	0.00	0.00	0.00	0.00	0.00
03/31/2023	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	1,901.12 *	2,022.14 *	194.09 *	389.04 *	648.00 *
Daily Min:	9.67	34.49	2.45	4.94	8.23
Daily Max:	184.98	143.12	15.31	30.58	50.99
Jan 2023 - Mar 2023	5,384.69	6,279.86	625.49	1,249.35	2,081.87
QTD:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *
YTD 2023:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023	0.0	0.0	0.0	0.0
01/02/2023	52.8	10.3	0.0	0.0
01/03/2023	0.0	0.0	0.0	0.0
01/04/2023	19.0	0.7	0.0	0.0
01/05/2023	60.4	11.6	0.0	0.0
01/06/2023	63.3	13.3	0.0	0.0
01/07/2023	5.2	0.0	0.0	0.0
01/08/2023	61.8	11.3	0.0	0.0
01/09/2023	56.5	10.6	0.0	0.0
01/10/2023	60.2	10.0	0.0	0.0
01/11/2023	61.1	10.0	0.0	0.0
01/12/2023	64.4	11.0	0.0	0.0
01/13/2023	-1.3	0.0	0.0	0.0
01/14/2023	57.1	12.7	0.0	0.0
01/15/2023	60.1	10.7	0.0	0.0
01/16/2023	56.8	11.0	0.0	0.0
01/17/2023	47.6	9.8	0.0	0.0
01/18/2023	13.4	0.6	0.0	0.0
01/19/2023	0.0	0.0	0.0	0.0
01/20/2023	0.0	0.0	0.0	0.0
01/21/2023	0.0	0.0	0.0	0.0
01/22/2023	0.0	0.0	0.0	0.0
01/23/2023	41.9	12.2	0.0	0.0
01/24/2023	19.8	0.6	0.0	0.0
01/25/2023	0.1	0.0	0.0	0.0
01/26/2023	0.8	0.0	0.0	0.0
01/27/2023	45.1	10.3	13.0	0.8
01/28/2023	0.0	0.0	0.0	0.0
01/29/2023	0.0	0.0	63.8	13.6
01/30/2023	0.0	0.0	0.0	0.0
01/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	841.3 *	156.7 *	76.8 *	14.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	64.4	13.3	63.8	13.6
Jan 2023 - Jan 2023	841.3	156.7	76.8	14.4
QTD:	846.1 *	156.7 *	76.8 *	14.4 *
YTD 2023:	846.1 *	156.7 *	76.8 *	14.4 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023	0.0	0.0	0.0	0.0
02/02/2023	0.0	0.0	0.0	0.0
02/03/2023	0.0	0.0	26.3	12.1
02/04/2023	82.8	11.2	0.0	0.0
02/05/2023	61.0	11.1	0.0	0.0
02/06/2023	51.2	10.1	0.0	0.0
02/07/2023	49.7	9.9	0.0	0.0
02/08/2023	0.0	0.0	54.8	9.3
02/09/2023	0.0	0.0	56.6	9.7
02/10/2023	0.0	0.0	48.5	12.4
02/11/2023	51.7	6.8	0.0	0.0
02/12/2023	0.0	0.0	50.3	8.3
02/13/2023	20.2	0.7	0.0	0.0
02/14/2023	43.5	11.3	0.0	0.0
02/15/2023	55.8	7.7	31.2	5.8
02/16/2023	69.9	8.1	0.0	0.0
02/17/2023	12.0	0.6	0.0	0.0
02/18/2023	0.5	0.0	0.0	0.0
02/19/2023	11.4	0.0	0.0	0.0
02/20/2023	58.9	11.4	12.3	0.8
02/21/2023	0.0	0.0	0.0	0.0
02/22/2023	0.0	0.0	49.5	14.1
02/23/2023	0.0	0.0	13.1	0.7
02/24/2023	0.0	0.0	0.0	0.0
02/25/2023	0.0	0.0	0.0	0.0
02/26/2023	0.0	0.0	0.0	0.0
02/27/2023	0.0	0.0	45.8	13.1
02/28/2023	0.0	0.0	57.1	12.8
Monthly Avg/Sum*:	556.7 *	88.9 *	445.5 *	99.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	82.8	11.4	57.1	14.1
Jan 2023 - Feb 2023	1,398.0	245.6	522.3	113.5
QTD:	1,414.7 *	245.6 *	522.3 *	113.5 *
YTD 2023:	1,414.7 *	245.6 *	522.3 *	113.5 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023	0.0	0.0	12.0	0.7
03/02/2023	0.0	0.0	0.0	0.0
03/03/2023	0.0	0.0	53.5	13.9
03/04/2023	0.0	0.0	37.6	13.1
03/05/2023	0.0	0.0	49.1	13.0
03/06/2023	0.0	0.0	69.8	16.1
03/07/2023	0.0	0.0	59.5	10.5
03/08/2023	0.0	0.0	31.6	8.5
03/09/2023	0.0	0.0	10.5	0.7
03/10/2023	0.0	0.0	59.9	13.8
03/11/2023	0.0	0.0	45.1	12.6
03/12/2023	0.0	0.0	40.3	9.6
03/13/2023	0.0	0.0	21.7	1.6
03/14/2023	0.0	0.0	57.5	10.4
03/15/2023	0.0	0.0	36.5	13.7
03/16/2023	0.0	0.0	48.2	13.6
03/17/2023	67.1	8.5	73.3	12.5
03/18/2023	0.0	0.0	52.0	12.9
03/19/2023	0.0	0.0	49.4	12.8
03/20/2023	12.5	2.2	47.9	17.9
03/21/2023	0.0	0.0	41.6	14.3
03/22/2023	60.9	14.0	0.0	0.0
03/23/2023	79.0	12.0	0.0	0.0
03/24/2023	0.0	0.0	0.0	0.0
03/25/2023	0.0	0.0	12.0	1.6
03/26/2023	0.0	0.0	0.0	0.0
03/27/2023	0.0	0.0	0.0	0.0
03/28/2023	0.0	0.0	0.0	0.0
03/29/2023	0.0	0.0	0.0	0.0
03/30/2023	0.0	0.0	0.0	0.0
03/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	219.5 *	36.7 *	909.0 *	223.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	79.0	14.0	73.3	17.9
Jan 2023 - Mar 2023	1,617.5	282.3	1,431.3	337.3
QTD:	1,634.2 *	282.3 *	1,431.3 *	337.3 *
YTD 2023:	1,634.2 *	282.3 *	1,431.3 *	337.3 *

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2023 00:00	01/02/2023 11:00	36
01/04/2023 10:00	01/05/2023 14:00	29
01/05/2023 20:00	01/06/2023 15:00	20
01/06/2023 22:00	01/08/2023 15:00	42
01/08/2023 23:00	01/09/2023 12:00	14
01/09/2023 22:00	01/10/2023 14:00	17
01/11/2023 00:00	01/11/2023 14:00	15
01/11/2023 22:00	01/12/2023 14:00	17
01/12/2023 23:00	01/14/2023 13:00	39
01/14/2023 21:00	01/15/2023 13:00	17
01/15/2023 23:00	01/16/2023 14:00	16
01/16/2023 23:00	01/17/2023 16:00	18
01/18/2023 10:00	01/23/2023 15:00	126
01/24/2023 11:00	01/27/2023 15:00	77
02/04/2023 01:00	02/04/2023 15:00	15
02/05/2023 00:00	02/05/2023 16:00	17
02/05/2023 23:00	02/06/2023 14:00	16
02/07/2023 00:00	02/07/2023 14:00	15
02/11/2023 09:00	02/11/2023 15:00	7
02/13/2023 01:00	02/14/2023 14:00	38
02/15/2023 09:00	02/15/2023 15:00	7
02/16/2023 09:00	02/16/2023 15:00	7
02/17/2023 05:00	02/20/2023 14:00	82
03/16/2023 16:00	03/17/2023 00:00	9
03/20/2023 21:00	03/22/2023 15:00	43
03/23/2023 00:00	03/23/2023 13:00	14
03/24/2023 00:00	03/31/2023 08:00	177

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 08:00 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,145.00 Hour(s)
Total Offline:	930.00 Hour(s)
Offline Percentage:	43.36 %
Total Online:	1,215.00 Hour(s)
Online Percentage:	56.64 %

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/02/2023 12:10	01/02/2023 13:09	Cold Startup	60
2	01/04/2023 08:53	01/04/2023 09:00	Shutdown	8
3	01/05/2023 15:30	01/05/2023 16:34	Cold Startup	65
4	01/05/2023 19:07	01/05/2023 19:14	Shutdown	8
5	01/06/2023 16:02	01/06/2023 16:58	Cold Startup	57
6	01/06/2023 21:23	01/06/2023 21:30	Shutdown	8
7	01/08/2023 16:05	01/08/2023 16:58	Cold Startup	54
8	01/08/2023 22:08	01/08/2023 22:15	Shutdown	8
9	01/09/2023 13:54	01/09/2023 14:41	Cold Startup	48
10	01/09/2023 21:46	01/09/2023 21:55	Shutdown	10
11	01/10/2023 15:56	01/10/2023 16:44	Cold Startup	49
12	01/10/2023 23:07	01/10/2023 23:14	Shutdown	8
13	01/11/2023 15:02	01/11/2023 15:48	Cold Startup	47
14	01/11/2023 21:00	01/11/2023 21:07	Shutdown	8
15	01/12/2023 15:48	01/12/2023 16:50	Cold Startup	63
16	01/12/2023 22:08	01/12/2023 22:15	Shutdown	8
17	01/14/2023 14:54	01/14/2023 16:01	Cold Startup	68
18	01/14/2023 20:08	01/14/2023 20:14	Shutdown	7
19	01/15/2023 14:59	01/15/2023 15:53	Cold Startup	55
20	01/15/2023 22:06	01/15/2023 22:13	Shutdown	8
21	01/16/2023 15:00	01/16/2023 15:55	Cold Startup	56
22	01/16/2023 22:53	01/16/2023 22:59	Shutdown	7

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	01/17/2023 17:00	01/17/2023 18:06	cold Startup	67
24	01/18/2023 09:06	01/18/2023 09:13	Shutdown	8
25	01/23/2023 16:10	01/23/2023 17:17	cold Startup	68
26	01/24/2023 10:09	01/24/2023 10:16	Shutdown	8
27	01/27/2023 16:22	01/27/2023 17:21	cold Startup	60
28	02/04/2023 00:08	02/04/2023 00:15	Shutdown	8
29	02/04/2023 16:08	02/04/2023 17:02	cold Startup	55
30	02/04/2023 23:06	02/04/2023 23:13	Shutdown	8
31	02/05/2023 17:57	02/05/2023 18:56	cold Startup	60
32	02/05/2023 22:22	02/05/2023 22:29	Shutdown	8
33	02/06/2023 15:54	02/06/2023 16:49	cold Startup	56
34	02/06/2023 23:24	02/06/2023 23:31	Shutdown	8
35	02/07/2023 15:51	02/07/2023 16:45	cold Startup	55
36	02/11/2023 08:38	02/11/2023 08:45	Shutdown	8
37	02/11/2023 16:01	02/11/2023 16:39	cold Startup	39
38	02/13/2023 00:37	02/13/2023 00:44	Shutdown	8
39	02/14/2023 15:34	02/14/2023 16:29	cold Startup	56
40	02/15/2023 08:36	02/15/2023 08:43	Shutdown	8
41	02/15/2023 16:16	02/15/2023 17:01	cold Startup	46
42	02/16/2023 08:53	02/16/2023 08:59	Shutdown	7
43	02/16/2023 16:13	02/16/2023 16:54	cold Startup	42
44	02/17/2023 03:53	02/17/2023 04:00	Shutdown	8
45	02/20/2023 15:58	02/20/2023 17:09	cold Startup	72
46	03/16/2023 15:17	03/16/2023 15:17	Shutdown	1

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 08:00 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
47	03/17/2023 01:50	03/17/2023 02:51	Cold Startup	62
48	03/20/2023 20:14	03/20/2023 20:30	Shutdown	17
49	03/22/2023 16:08	03/22/2023 17:18	Cold Startup	71
50	03/22/2023 23:44	03/22/2023 23:52	Shutdown	9
51	03/23/2023 14:59	03/23/2023 15:55	Cold Startup	57
52	03/23/2023 22:55	03/23/2023 23:03	Shutdown	9

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	26	1488	2.09
Warm Startup	0		0.00
Shutdown	26	211	0.30
Total Process Events:	52	1699	2.38

Total Report Time:	2,144.00 Hour(s)
Total Operating Time:	1,187.52 Hour(s)
Total Startup Time:	1,488 Minute(s)
Total Shutdown Time:	211 Minute(s)
Total Startup/Shutdown Time:	1,699 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.38 %

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/27/2023 21:00	01/29/2023 08:00	36
01/29/2023 13:00	02/03/2023 15:00	123
02/08/2023 09:00	02/08/2023 14:00	6
02/09/2023 09:00	02/09/2023 15:00	7
02/10/2023 00:00	02/10/2023 14:00	15
02/12/2023 09:00	02/12/2023 14:00	6
02/21/2023 00:00	02/22/2023 15:00	40
02/23/2023 14:00	02/27/2023 16:00	99
02/28/2023 00:00	02/28/2023 15:00	16
03/01/2023 09:00	03/03/2023 14:00	54
03/04/2023 00:00	03/04/2023 15:00	16
03/04/2023 23:00	03/05/2023 14:00	16
03/06/2023 02:00	03/06/2023 12:00	11
03/07/2023 09:00	03/07/2023 15:00	7
03/08/2023 12:00	03/08/2023 17:00	6
03/10/2023 00:00	03/10/2023 14:00	15
03/10/2023 21:00	03/11/2023 15:00	19
03/12/2023 08:00	03/12/2023 14:00	7
03/13/2023 01:00	03/13/2023 15:00	15
03/13/2023 23:00	03/14/2023 08:00	10
03/15/2023 00:00	03/15/2023 15:00	16
03/15/2023 22:00	03/16/2023 14:00	17
03/17/2023 09:00	03/17/2023 15:00	7
03/18/2023 00:00	03/18/2023 14:00	15
03/18/2023 22:00	03/19/2023 14:00	17
03/20/2023 02:00	03/20/2023 15:00	14
03/20/2023 21:00	03/21/2023 10:00	14
03/26/2023 00:00	03/31/2023 08:00	129

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 08:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,145.00 Hour(s)
Total Offline:	753.00 Hour(s)
Offline Percentage:	35.10 %
Total Online:	1,392.00 Hour(s)
Online Percentage:	64.90 %

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/27/2023 20:28	01/27/2023 20:35	Shutdown	8
2	01/29/2023 09:14	01/29/2023 10:09	Cold Startup	56
3	01/29/2023 12:37	01/29/2023 12:44	Shutdown	8
4	02/03/2023 16:09	02/03/2023 17:02	Cold Startup	54
5	02/08/2023 08:15	02/08/2023 08:22	Shutdown	8
6	02/08/2023 15:57	02/08/2023 16:37	Cold Startup	41
7	02/09/2023 08:12	02/09/2023 08:19	Shutdown	8
8	02/09/2023 16:05	02/09/2023 16:45	Cold Startup	41
9	02/09/2023 23:52	02/09/2023 23:59	Shutdown	8
10	02/10/2023 15:54	02/10/2023 16:56	Cold Startup	63
11	02/12/2023 08:26	02/12/2023 08:34	Shutdown	9
12	02/12/2023 15:30	02/12/2023 16:03	Warm Startup	34
13	02/15/2023 06:53	02/15/2023 06:53	Shutdown	1
14	02/15/2023 07:29	02/15/2023 08:05	Warm Startup	37
15	02/20/2023 23:09	02/20/2023 23:16	Shutdown	8
16	02/22/2023 16:09	02/22/2023 17:11	Cold Startup	63
17	02/23/2023 13:08	02/23/2023 13:15	Shutdown	8
18	02/27/2023 17:27	02/27/2023 18:20	Cold Startup	54
19	02/27/2023 23:09	02/27/2023 23:17	Shutdown	9
20	02/28/2023 16:54	02/28/2023 17:47	Cold Startup	54
21	03/01/2023 08:12	03/01/2023 08:19	Shutdown	8
22	03/03/2023 15:10	03/03/2023 16:12	Cold Startup	63

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/03/2023 22:53	03/03/2023 23:00	Shutdown	8
24	03/04/2023 16:57	03/04/2023 17:45	Cold Startup	49
25	03/04/2023 22:52	03/04/2023 22:59	Shutdown	8
26	03/05/2023 15:54	03/05/2023 16:42	Cold Startup	49
27	03/06/2023 01:38	03/06/2023 01:45	Shutdown	8
28	03/06/2023 13:10	03/06/2023 14:17	Cold Startup	68
29	03/07/2023 08:09	03/07/2023 08:16	Shutdown	8
30	03/07/2023 16:48	03/07/2023 17:39	Cold Startup	52
31	03/08/2023 11:14	03/08/2023 11:21	Shutdown	8
32	03/08/2023 18:18	03/08/2023 18:55	Cold Startup	38
33	03/09/2023 23:08	03/09/2023 23:15	Shutdown	8
34	03/10/2023 15:49	03/10/2023 16:48	Cold Startup	60
35	03/10/2023 20:44	03/10/2023 20:52	Shutdown	9
36	03/11/2023 16:59	03/11/2023 17:59	Cold Startup	61
37	03/12/2023 07:11	03/12/2023 07:19	Shutdown	9
38	03/12/2023 15:07	03/12/2023 15:55	Cold Startup	49
39	03/13/2023 00:08	03/13/2023 00:15	Shutdown	8
40	03/13/2023 16:47	03/13/2023 17:37	Cold Startup	51
41	03/13/2023 16:55	03/13/2023 16:57	Shutdown	3
42	03/13/2023 22:52	03/13/2023 22:59	Shutdown	8
43	03/14/2023 09:09	03/14/2023 09:47	Cold Startup	39
44	03/14/2023 23:09	03/14/2023 23:16	Shutdown	8
45	03/15/2023 16:47	03/15/2023 17:34	Cold Startup	48
46	03/15/2023 21:45	03/15/2023 21:54	Shutdown	10

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 08:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
47	03/16/2023 15:45	03/16/2023 16:46	Cold Startup	62
48	03/17/2023 08:22	03/17/2023 08:30	Shutdown	9
49	03/17/2023 16:39	03/17/2023 17:30	Cold Startup	52
50	03/17/2023 22:53	03/17/2023 23:01	Shutdown	9
51	03/18/2023 15:55	03/18/2023 16:46	Cold Startup	52
52	03/18/2023 21:45	03/18/2023 21:53	Shutdown	9
53	03/19/2023 15:42	03/19/2023 16:42	Cold Startup	61
54	03/20/2023 01:08	03/20/2023 01:16	Shutdown	9
55	03/20/2023 16:31	03/20/2023 17:39	Cold Startup	69
56	03/20/2023 20:19	03/20/2023 20:35	Shutdown	17
57	03/21/2023 11:32	03/21/2023 12:36	Cold Startup	65
58	03/25/2023 22:55	03/25/2023 23:06	Shutdown	12

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	26	1414	1.73
Warm Startup	2	71	0.09
Shutdown	30	251	0.31
Total Process Events:	58	1736	2.12

Total Report Time:	2,144.98 Hour(s)
Total Operating Time:	1,361.78 Hour(s)
Total Startup Time:	1,485 Minute(s)
Total Shutdown Time:	251 Minute(s)
Total Startup/Shutdown Time:	1,736 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.12 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 12:05	0			0			0			0			0			0		
01/02/23 12:06	0			0			0			0			0			0		
01/02/23 12:07	0			0			0			0			0			0		
01/02/23 12:08	0			0			0			0			0			0		
01/02/23 12:09	5160.1			0			0			0.07			0			0		
01/02/23 12:10	20024.2			5.9			0			0.28			0			1		
01/02/23 12:11	31114.5			5.9			0			0.43			0			1		
01/02/23 12:12	40048.3			82.6			5.9			7.78			0.92			1		
01/02/23 12:13	46671.7			1050.8			11.21			115.49			2.03			1		
01/02/23 12:14	59456.3			973.2			13.19			136.37			3.04			1		
01/02/23 12:15	73627.3			582.6			17.11			101.07			4.89			1		
01/02/23 12:16	111981.2			406.8			21.45			107.28			9.31			1		
01/02/23 12:17	141247.3			296.5			24.34			98.62			13.32			1		
01/02/23 12:18	142479.5			191.2			46.81			64.14			25.85			1		
01/02/23 12:19	151259.4			1646.8			37.8			586.5			22.15			1		
01/02/23 12:20	167740.8			1911.2			38.08			755.11			24.76			1		
01/02/23 12:21	185916.6			1752			41.63			767.09			30			1		
01/02/23 12:22	210792.7			678.4			50.22			336.8			41.04			1		
01/02/23 12:23	231279			97.9			56.56			53.3			50.7			1		
01/02/23 12:24	253844.6			8.1			57.3			4.81			56.36			1		
01/02/23 12:25	271481.3			2.5			55.89			1.59			58.81			1		
01/02/23 12:26	290504.3			2.2			31.78			1.5			35.78			1		
01/02/23 12:27	309450.2			2			20.02			1.43			24.01			1		
01/02/23 12:28	309450.2			2			14.02			1.43			16.82			1		
01/02/23 12:29	310990.5			2			10.35			1.44			12.47			1		
01/02/23 12:30	309989.3			1.9			8.29			1.37			9.96			1		
01/02/23 12:31	309219.1			1.7			6.93			1.25			8.3			1		
01/02/23 12:32	309758.3			1.6			5.99			1.14			7.19			1		
01/02/23 12:33	309681.2			1.5			5.21			1.08			6.25			1		
01/02/23 12:34	308063.9			1.3			4.77			0.94			5.7			1		
01/02/23 12:35	307524.8			1.2			4.25			0.88			5.07			1		
01/02/23 12:36	306677.6			1.1			4.16			0.81			4.95			1		
01/02/23 12:37	304829.2			1			4.08			0.75			4.82			1		
01/02/23 12:38	304752.2			1.1			3.96			0.76			4.68			1		
01/02/23 12:39	306985.7			1			3.79			0.7			4.51			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 12:40	307216.7			1			3.7			0.7			4.4			1		
01/02/23 12:41	306369.5			1			3.7			0.7			4.39			1		
01/02/23 12:42	306061.5			0.9			3.79			0.63			4.49			1		
01/02/23 12:43	315534.4			0.9			3.79			0.65			4.63			1		
01/02/23 12:44	316843.7			0.9			3.79			0.66			4.65			1		
01/02/23 12:45	318846.1			0.9			3.73			0.65			4.61			1		
01/02/23 12:46	316150.6			0.9			3.9			0.65			4.78			1		
01/02/23 12:47	296742.5			0.9			3.99			0.61			4.59			1		
01/02/23 12:48	278489.8			0.9			3.7			0.58			3.99			1		
01/02/23 12:49	274870			0.8			4.54			0.53			4.84			1		
01/02/23 12:50	274099.8			0.7			5.25			0.48			5.58			1		
01/02/23 12:51	274947			0.6			5.35			0.42			5.7			1		
01/02/23 12:52	277411.5			0.6			5.53			0.42			5.95			1		
01/02/23 12:53	290889.3			0.6			5.63			0.44			6.34			1		
01/02/23 12:54	310528.4			0.6			5.54			0.46			6.66			1		
01/02/23 12:55	328935.2			0.6			4.65			0.48			5.93			1		
01/02/23 12:56	333248.1			0.7			4.58			0.55			5.91			1		
01/02/23 12:57	328242.1			0.8			4.49			0.61			5.71			1		
01/02/23 12:58	315996.5			0.8			4.08			0.58			4.99			1		
01/02/23 12:59	294663.1			0.9			2.86			0.6			3.27			1		
01/02/23 13:00	276025.3			0.8			2.03			0.52			2.17			1		
01/02/23 13:01	269632.9			0.7			2.63			0.46			2.75			1		
01/02/23 13:02	272944.6			0.6			3.6			0.41			3.8			1		
01/02/23 13:03	286345.4			0.6			3.69			0.37			4.09			1		
01/02/23 13:04	304983.3			0.5			3.18			0.39			3.75			1		
01/02/23 13:05	326162.7			0.6			2.23			0.48			2.82			1		
01/02/23 13:06	335019.5			0.7			1.85			0.56			2.4			1		
01/02/23 13:07	332015.8			0.8			1.23			0.62			1.59			1		
01/02/23 13:08	334480.4			0.8			1.13			0.62			1.46			1		
01/02/23 13:09	352887.2			0.8			1.14			0.66			1.57			1		
01/02/23 13:10	363900.5			0.8			1.06			0.68			1.49			0		
01/02/23 13:11	373989.6			0.7			0.91			0.64			1.32			0		
01/02/23 13:12	377532.3			0.7			0.8			0.64			1.18			0		
01/02/23 13:13	390162.9			0.7			0.72			0.66			1.08			0		
01/02/23 13:14	401792.3			0.7			0.72			0.68			1.11			0		

CT1 SUSD EVENT 2

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 8:48	266552.3			0.6			1.4			0.35			1.45			0		
01/04/23 8:49	267322.4			0.6			1.31			0.35			1.36			0		
01/04/23 8:50	267630.5			0.6			1.31			0.35			1.36			0		
01/04/23 8:51	267168.4			0.6			1.31			0.35			1.36			0		
01/04/23 8:52	267707.5			0.6			1.4			0.35			1.46			0		
01/04/23 8:53	263394.6			0.6			1.4			0.35			1.43			1		
01/04/23 8:54	242061.2			0.6			1.5			0.32			1.41			1		
01/04/23 8:55	221652			0.5			4.33			0.26			3.72			1		
01/04/23 8:56	196467.8			0.4			8.58			0.2			6.53			1		
01/04/23 8:57	174210.1			5.2			10.97			2.13			7.41			1		
01/04/23 8:58	156573.5			332.7			14.08			122.65			8.54			1		
01/04/23 8:59	137781.6			1279.4			15.88			414.98			8.48			1		
01/04/23 9:00	21333.4			1853.5			17.87			92.94			1.47			1		
01/04/23 9:01	15788.3			0			14.75			153.83			0.9			0		
01/04/23 9:02	16635.4			0			2.95			17.22			0.19			0		
01/04/23 9:03	16404.4			0			5.9			7.77			0.38			0		
01/04/23 9:04	16404.4			0			5.9			6.63			0.38			0		
01/04/23 9:05	16789.5			0			5.9			6.55			0.38			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:25	8856.8			0			0			0.25			0			0		
01/05/23 15:26	9550			0			0			0.26			0			0		
01/05/23 15:27	7547.6			0			0			0.21			0			0		
01/05/23 15:28	10012.1			0			0			0.28			0			0		
01/05/23 15:29	11090.3			0			0			0.31			0			0		
01/05/23 15:30	18560.8			11.8			0			0.52			0			1		
01/05/23 15:31	25877.4			11.8			0			0.72			0			1		
01/05/23 15:32	36120.5			35.4			13.77			3.01			1.93			1		
01/05/23 15:33	47518.9			938.1			11.01			105			2.03			1		
01/05/23 15:34	60688.6			744.4			15.41			106.31			3.62			1		
01/05/23 15:35	80481.7			440.5			19.95			83.52			6.22			1		
01/05/23 15:36	121223.1			311.4			23.09			88.88			10.84			1		
01/05/23 15:37	144250.9			216.9			37.22			73.72			20.81			1		
01/05/23 15:38	150797.3			287.3			49.41			101.98			28.87			1		
01/05/23 15:39	164737.2			1709.8			45.81			663.27			29.25			1		
01/05/23 15:40	184607.3			1694.9			52.44			736.81			37.52			1		
01/05/23 15:41	207404			812.2			57.27			396.7			46.04			1		
01/05/23 15:42	229430.6			96.2			57.59			51.98			51.21			1		
01/05/23 15:43	249377.7			9			52.98			5.3			51.2			1		
01/05/23 15:44	276641.4			2.2			48.78			1.44			52.29			1		
01/05/23 15:45	294663.1			1.9			26.07			1.32			29.78			1		
01/05/23 15:46	295433.3			1.8			15.7			1.27			17.98			1		
01/05/23 15:47	297512.7			1.9			12.4			1.32			14.3			1		
01/05/23 15:48	311837.7			1.9			10.6			1.38			12.82			1		
01/05/23 15:49	313224			1.7			8.38			1.26			10.17			1		
01/05/23 15:50	311529.6			1.6			7.18			1.19			8.67			1		
01/05/23 15:51	310143.3			1.5			6.41			1.12			7.71			1		
01/05/23 15:52	310143.3			1.4			5.99			1.01			7.2			1		
01/05/23 15:53	309142.1			1.3			5.55			0.95			6.65			1		
01/05/23 15:54	306600.6			1.2			5.21			0.88			6.19			1		
01/05/23 15:55	306677.6			1.1			5.12			0.81			6.08			1		
01/05/23 15:56	306985.7			1.1			5.11			0.76			6.08			1		
01/05/23 15:57	305599.4			1.1			5.02			0.76			5.94			1		
01/05/23 15:58	306677.6			1			4.93			0.7			5.86			1		
01/05/23 15:59	306754.6			1			4.84			0.7			5.76			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 16:00	307678.8			1			4.84			0.7			5.78			1		
01/05/23 16:01	306677.6			1			4.84			0.7			5.76			1		
01/05/23 16:02	305291.3			1			4.93			0.7			5.84			1		
01/05/23 16:03	303982			0.9			4.93			0.63			5.81			1		
01/05/23 16:04	303828			0.9			4.84			0.63			5.7			1		
01/05/23 16:05	303211.9			0.9			4.84			0.63			5.69			1		
01/05/23 16:06	303828			0.8			4.84			0.57			5.7			1		
01/05/23 16:07	304444.1			0.8			4.93			0.57			5.82			1		
01/05/23 16:08	306523.6			0.8			4.93			0.57			5.86			1		
01/05/23 16:09	304598.2			0.8			5.02			0.57			5.92			1		
01/05/23 16:10	285498.2			0.8			5.2			0.53			5.75			1		
01/05/23 16:11	277873.6			0.8			5.45			0.53			5.87			1		
01/05/23 16:12	275871.2			0.7			6.63			0.47			7.08			1		
01/05/23 16:13	276025.3			0.6			6.81			0.41			7.28			1		
01/05/23 16:14	277488.6			0.6			7.47			0.42			8.03			1		
01/05/23 16:15	272482.5			0.6			7.17			0.41			7.57			1		
01/05/23 16:16	271019.2			0.6			4.43			0.41			4.65			1		
01/05/23 16:17	270172			0.6			3.13			0.41			3.28			1		
01/05/23 16:18	273098.6			0.6			3.5			0.42			3.71			1		
01/05/23 16:19	274793			0.6			4.43			0.36			4.71			1		
01/05/23 16:20	273868.8			0.6			5.07			0.36			5.38			1		
01/05/23 16:21	273868.8			0.6			4.06			0.42			4.31			1		
01/05/23 16:22	274716			0.6			2.77			0.42			2.94			1		
01/05/23 16:23	281185.3			0.6			2.3			0.43			2.51			1		
01/05/23 16:24	286576.4			0.6			2.3			0.44			2.56			1		
01/05/23 16:25	287577.6			0.6			2.36			0.43			2.63			1		
01/05/23 16:26	285960.3			0.6			2.45			0.43			2.72			1		
01/05/23 16:27	283110.7			0.6			2.54			0.42			2.79			1		
01/05/23 16:28	292660.7			0.6			2.72			0.44			3.09			1		
01/05/23 16:29	314071.1			0.6			2.81			0.47			3.42			1		
01/05/23 16:30	333017.1			0.7			2.23			0.56			2.88			1		
01/05/23 16:31	343029.1			0.7			1.85			0.57			2.46			1		
01/05/23 16:32	341334.8			0.8			1.32			0.64			1.75			1		
01/05/23 16:33	345185.6			0.8			1.23			0.64			1.65			1		
01/05/23 16:34	356198.9			0.8			1.23			0.66			1.7			1		
01/05/23 16:35	357970.3			0.8			1.32			0.67			1.83			0		
01/05/23 16:36	357739.2			0.8			1.32			0.67			1.83			0		
01/05/23 16:37	357970.3			0.8			1.5			0.67			2.08			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 16:38	362822.3			0.8			1.59			0.68			2.23			0		
01/05/23 16:39	385233.9			0.8			1.5			0.72			2.24			0		

CT1 SUSD EVENT 4

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 19:02	268169.6			0.6			1.5			0.35			1.56			0		
01/05/23 19:03	268554.7			0.6			1.5			0.36			1.56			0		
01/05/23 19:04	268169.6			0.6			1.4			0.35			1.46			0		
01/05/23 19:05	267938.6			0.6			1.4			0.35			1.46			0		
01/05/23 19:06	267861.6			0.6			1.31			0.35			1.36			0		
01/05/23 19:07	266860.3			0.6			1.31			0.35			1.36			1		
01/05/23 19:08	251611.2			0.6			1.4			0.33			1.37			1		
01/05/23 19:09	230354.8			0.6			2.57			0.31			2.29			1		
01/05/23 19:10	207250			0.5			7.76			0.25			6.23			1		
01/05/23 19:11	183144			2.8			10.55			1.22			7.49			1		
01/05/23 19:12	163736			123.6			13.98			47.69			8.87			1		
01/05/23 19:13	145252.1			700.4			15.97			239.55			8.99			1		
01/05/23 19:14	80635.7			1618.2			18.36			307.18			5.73			1		
01/05/23 19:15	21025.4			0			21.91			129.01			1.78			0		
01/05/23 19:16	20871.3			0			5.9			62.47			0.48			0		
01/05/23 19:17	20563.3			0			5.9			13.12			0.47			0		
01/05/23 19:18	20409.2			0			5.9			8.8			0.47			0		
01/05/23 19:19	20255.2			0			5.9			8.44			0.46			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 15:57	22950.8			0			0			0.32			0			0		
01/06/23 15:58	22796.7			0			0			0.32			0			0		
01/06/23 15:59	22796.7			0			0			0.32			0			0		
01/06/23 16:00	22719.7			0			0			0.32			0			0		
01/06/23 16:01	24337			0			0			0.34			0			0		
01/06/23 16:02	28418.9			5.9			0			0.39			0			1		
01/06/23 16:03	36967.7			47.2			0			4.11			0			1		
01/06/23 16:04	45439.4			5.9			16.96			0.63			2.99			1		
01/06/23 16:05	58224.1			845.4			13.88			115.82			3.13			1		
01/06/23 16:06	68621.2			513.3			19.47			82.96			5.18			1		
01/06/23 16:07	94113.5			329.3			24.4			72.98			8.9			1		
01/06/23 16:08	136395.3			225.9			33.43			72.57			17.67			1		
01/06/23 16:09	143711.8			158			50.99			53.49			28.4			1		
01/06/23 16:10	155187.2			851.3			55.13			311.17			33.16			1		
01/06/23 16:11	170975.5			1805.2			54.14			726.96			35.88			1		
01/06/23 16:12	192308.9			1551.4			57.25			702.53			42.66			1		
01/06/23 16:13	214412.5			457.5			55.21			231.05			45.88			1		
01/06/23 16:14	235360.8			54			55.23			29.92			50.38			1		
01/06/23 16:15	259774.9			3.6			50.21			2.18			50.55			1		
01/06/23 16:16	274793			1.9			41.3			1.25			43.99			1		
01/06/23 16:17	277873.6			1.8			17.61			1.16			18.96			1		
01/06/23 16:18	276564.3			1.6			14.43			1.06			15.47			1		
01/06/23 16:19	276564.3			1.6			13.52			1.06			14.49			1		
01/06/23 16:20	276487.3			1.5			12.44			1			13.33			1		
01/06/23 16:21	275563.2			1.5			11.89			0.94			12.7			1		
01/06/23 16:22	275255.1			1.3			10.8			0.82			11.52			1		
01/06/23 16:23	275024			1.2			10.53			0.76			11.22			1		
01/06/23 16:24	274947			1.1			10.26			0.71			10.93			1		
01/06/23 16:25	274407.9			1			9.98			0.65			10.62			1		
01/06/23 16:26	274099.8			0.9			9.71			0.59			10.32			1		
01/06/23 16:27	274484.9			0.9			9.62			0.59			10.24			1		
01/06/23 16:28	273637.8			0.8			9.53			0.53			10.11			1		
01/06/23 16:29	272944.6			0.8			9.59			0.53			10.14			1		
01/06/23 16:30	273945.8			0.7			9.59			0.48			10.18			1		
01/06/23 16:31	291813.5			0.7			9.59			0.51			10.84			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 16:32	302056.7			0.7			8.08			0.52			9.46			1		
01/06/23 16:33	302826.8			0.7			6.53			0.51			7.66			1		
01/06/23 16:34	303442.9			0.8			6.44			0.57			7.57			1		
01/06/23 16:35	303442.9			0.8			6.26			0.57			7.36			1		
01/06/23 16:36	293045.8			0.8			6.17			0.56			7.01			1		
01/06/23 16:37	275717.2			0.8			6.08			0.52			6.5			1		
01/06/23 16:38	272867.6			0.7			7.38			0.47			7.8			1		
01/06/23 16:39	271712.3			0.6			8.57			0.41			9.03			1		
01/06/23 16:40	271481.3			0.6			8.76			0.41			9.21			1		
01/06/23 16:41	270942.2			0.6			8.94			0.35			9.39			1		
01/06/23 16:42	270942.2			0.6			9.13			0.35			9.58			1		
01/06/23 16:43	271943.4			0.6			9.59			0.35			10.11			1		
01/06/23 16:44	288655.9			0.6			9.93			0.38			11.11			1		
01/06/23 16:45	309989.3			0.6			8.94			0.4			10.74			1		
01/06/23 16:46	328704.2			0.6			7.15			0.48			9.11			1		
01/06/23 16:47	335250.5			0.7			7.04			0.56			9.15			1		
01/06/23 16:48	339255.3			0.8			6.08			0.63			7.99			1		
01/06/23 16:49	356044.8			0.8			5.72			0.66			7.9			1		
01/06/23 16:50	366596			0.8			4.56			0.69			6.48			1		
01/06/23 16:51	376608.1			0.7			4.18			0.64			6.09			1		
01/06/23 16:52	379919.8			0.7			4.99			0.65			7.35			1		
01/06/23 16:53	388622.6			0.7			5.18			0.65			7.81			1		
01/06/23 16:54	406952.4			0.7			3.99			0.7			6.3			1		
01/06/23 16:55	423741.9			0.7			2.4			0.74			3.94			1		
01/06/23 16:56	419891.1			0.6			1.75			0.64			2.85			1		
01/06/23 16:57	425205.2			0.6			1.54			0.64			2.54			1		
01/06/23 16:58	416579.4			0.7			1.36			0.71			2.2			1		
01/06/23 16:59	417118.5			0.7			1.18			0.71			1.91			0		
01/06/23 17:00	408954.8			0.7			0.98			0.69			1.56			0		
01/06/23 17:01	410341.1			0.7			0.8			0.69			1.28			0		
01/06/23 17:02	416348.3			0.7			0.73			0.71			1.17			0		
01/06/23 17:03	402716.5			0.7			0.64			0.69			0.99			0		

CT1 SUSD EVENT 6

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 21:18	269786.9			0.6			1.69			0.36			1.76			0		
01/06/23 21:19	269941			0.6			1.59			0.36			1.67			0		
01/06/23 21:20	268323.7			0.6			1.59			0.36			1.66			0		
01/06/23 21:21	268631.7			0.6			1.5			0.36			1.56			0		
01/06/23 21:22	269093.8			0.6			1.5			0.36			1.56			0		
01/06/23 21:23	270018			0.6			1.5			0.36			1.57			1		
01/06/23 21:24	259081.7			0.6			1.5			0.34			1.5			1		
01/06/23 21:25	237286.2			0.6			1.78			0.31			1.64			1		
01/06/23 21:26	215105.6			0.5			5.9			0.26			4.92			1		
01/06/23 21:27	190152.4			1.6			9.91			0.7			7.3			1		
01/06/23 21:28	168665			1.8			11.17			0.7			7.3			1		
01/06/23 21:29	151952.5			468.2			15.03			167.59			8.85			1		
01/06/23 21:30	104125.6			1398.6			17.06			342.82			6.88			1		
01/06/23 21:31	23104.8			0			18.33			119.79			1.64			0		
01/06/23 21:32	23104.8			0			5.9			230.75			0.53			0		
01/06/23 21:33	23104.8			0			2.95			10.75			0.26			0		
01/06/23 21:34	23181.8			0			5.9			9.67			0.53			0		
01/06/23 21:35	22719.7			0			5.9			8.84			0.52			0		

CT1 SUSD EVENT 7

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 16:00	23027.8			0			0			0.64			0			0		
01/08/23 16:01	22950.8			0			0			0.64			0			0		
01/08/23 16:02	23181.8			0			0			0.64			0			0		
01/08/23 16:03	23027.8			0			0			0.64			0			0		
01/08/23 16:04	22950.8			0			0			0.64			0			0		
01/08/23 16:05	25723.3			11.8			0			0.72			0			1		
01/08/23 16:06	32500.7			11.8			0			0.9			0			1		
01/08/23 16:07	40587.4			43.3			9.83			4.14			1.55			1		
01/08/23 16:08	52293.8			890.5			12.22			109.63			2.48			1		
01/08/23 16:09	63153.1			725.4			15.08			107.81			3.69			1		
01/08/23 16:10	79326.5			422.3			19.1			78.93			5.88			1		
01/08/23 16:11	118912.7			280.4			22.57			78.51			10.4			1		
01/08/23 16:12	143403.7			190.6			35.17			64.39			19.55			1		
01/08/23 16:13	149179.9			226.4			47.38			79.52			27.39			1		
01/08/23 16:14	162888.8			1670.2			43.45			640.82			27.43			1		
01/08/23 16:15	181680.7			1702.2			48.02			728.13			33.81			1		
01/08/23 16:16	202398			1017.8			55.61			485.03			43.61			1		
01/08/23 16:17	225348.7			131			57.95			69.52			50.62			1		
01/08/23 16:18	245526.9			13.1			55.46			7.57			52.77			1		
01/08/23 16:19	269864			2.2			52.26			1.41			54.65			1		
01/08/23 16:20	276179.3			1.9			28.34			1.26			30.33			1		
01/08/23 16:21	275178.1			1.8			15.61			1.18			16.65			1		
01/08/23 16:22	286268.4			1.7			14.39			1.15			15.97			1		
01/08/23 16:23	303674			1.6			13.03			1.13			15.34			1		
01/08/23 16:24	309142.1			1.6			8.94			1.14			10.71			1		
01/08/23 16:25	309758.3			1.6			7.38			1.14			8.85			1		
01/08/23 16:26	307293.7			1.5			6.68			1.07			7.96			1		
01/08/23 16:27	307216.7			1.4			5.9			1			7.02			1		
01/08/23 16:28	304906.2			1.3			5.47			0.93			6.46			1		
01/08/23 16:29	305907.4			1.2			5.11			0.89			6.05			1		
01/08/23 16:30	302980.8			1.1			5.02			0.82			5.89			1		
01/08/23 16:31	303211.9			1.1			5.02			0.75			5.9			1		
01/08/23 16:32	303211.9			1.1			4.84			0.75			5.69			1		
01/08/23 16:33	304521.2			1			4.67			0.69			5.51			1		
01/08/23 16:34	304598.2			1			4.67			0.69			5.51			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 16:35	304829.2			1			4.67			0.7			5.51			1		
01/08/23 16:36	304290.1			0.9			4.67			0.63			5.5			1		
01/08/23 16:37	305214.3			0.9			4.67			0.63			5.52			1		
01/08/23 16:38	303597			0.9			4.67			0.63			5.49			1		
01/08/23 16:39	304906.2			0.9			4.74			0.64			5.6			1		
01/08/23 16:40	297897.8			0.8			4.83			0.56			5.57			1		
01/08/23 16:41	278720.8			0.8			4.83			0.53			5.21			1		
01/08/23 16:42	270942.2			0.8			5.26			0.52			5.53			1		
01/08/23 16:43	271481.3			0.7			6.64			0.47			6.98			1		
01/08/23 16:44	273483.7			0.6			7.01			0.42			7.43			1		
01/08/23 16:45	273945.8			0.6			7.38			0.42			7.83			1		
01/08/23 16:46	272251.5			0.6			7.38			0.41			7.78			1		
01/08/23 16:47	270634.1			0.6			7.38			0.41			7.74			1		
01/08/23 16:48	279953.1			0.6			7.47			0.43			8.1			1		
01/08/23 16:49	301440.5			0.6			7.47			0.46			8.72			1		
01/08/23 16:50	321002.6			0.6			6.17			0.48			7.68			1		
01/08/23 16:51	329705.4			0.7			5.81			0.55			7.43			1		
01/08/23 16:52	324160.2			0.8			5.37			0.6			6.75			1		
01/08/23 16:53	333633.2			0.8			5.02			0.62			6.49			1		
01/08/23 16:54	350730.8			0.9			3.7			0.73			5.03			1		
01/08/23 16:55	361744			0.8			1.97			0.69			2.76			1		
01/08/23 16:56	372218.2			0.8			1.18			0.72			1.7			1		
01/08/23 16:57	376762.1			0.7			1.18			0.64			1.72			1		
01/08/23 16:58	375683.9			0.7			1.16			0.63			1.69			1		
01/08/23 16:59	357431.1			0.8			1.16			0.68			1.61			0		
01/08/23 17:00	343491.3			0.8			1.21			0.63			1.62			0		
01/08/23 17:01	339948.5			0.9			1.3			0.69			1.71			0		
01/08/23 17:02	339871.5			0.9			1.23			0.7			1.62			0		
01/08/23 17:03	342721.1			0.9			1.14			0.71			1.52			0		

CT1 SUSD EVENT 8

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 22:03	265936.2			0.6			1.29			0.35			1.33			0		
01/08/23 22:04	266398.3			0.6			1.29			0.35			1.33			0		
01/08/23 22:05	266706.3			0.6			1.2			0.35			1.24			0		
01/08/23 22:06	266244.2			0.6			1.29			0.35			1.33			0		
01/08/23 22:07	265705.1			0.6			1.29			0.35			1.33			0		
01/08/23 22:08	262162.4			0.6			1.29			0.34			1.31			1		
01/08/23 22:09	241984.2			0.6			1.48			0.32			1.38			1		
01/08/23 22:10	220342.7			0.6			4.35			0.3			3.72			1		
01/08/23 22:11	196852.8			0.5			9.44			0.25			7.2			1		
01/08/23 22:12	173517			4.6			13.33			1.88			8.96			1		
01/08/23 22:13	155264.2			261.5			16.09			95.58			9.68			1		
01/08/23 22:14	137627.5			1027.8			18.15			333.14			9.68			1		
01/08/23 22:15	32500.7			1843.8			20.13			141.15			2.54			1		
01/08/23 22:16	24876.2			0			18.54			247.31			1.79			0		
01/08/23 22:17	24876.2			0			5.9			21.8			0.57			0		
01/08/23 22:18	24799.1			0			11.8			11.38			1.13			0		
01/08/23 22:19	24876.2			0			5.9			10.38			0.57			0		
01/08/23 22:20	24953.2			0			5.9			9.69			0.57			0		

CT1 SUSD EVENT 9

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 13:49	23952			0			0			0			0			0		
01/09/23 13:50	23720.9			0			0			0			0			0		
01/09/23 13:51	23952			0			0			0			0			0		
01/09/23 13:52	24029			0			0			0			0			0		
01/09/23 13:53	23797.9			0			0			0			0			0		
01/09/23 13:54	30190.3			0			0			0			0			1		
01/09/23 13:55	35504.4			0			0			0			0			1		
01/09/23 13:56	44746.3			33.7			16.01			3.55			2.78			1		
01/09/23 13:57	56837.8			1133.8			12.84			151.78			2.83			1		
01/09/23 13:58	67080.9			754.9			19.56			119.3			5.09			1		
01/09/23 13:59	90493.8			428.3			24.4			91.27			8.56			1		
01/09/23 14:00	133391.7			304.7			34.37			95.71			17.77			1		
01/09/23 14:01	144867			194.7			49.31			66.42			27.68			1		
01/09/23 14:02	154648.1			934			52.38			340.16			31.4			1		
01/09/23 14:03	171206.5			1810.5			48.55			729.88			32.21			1		
01/09/23 14:04	189998.4			1667.5			51.7			746.17			38.08			1		
01/09/23 14:05	214951.6			524.7			50.63			265.55			42.17			1		
01/09/23 14:06	234205.6			52.4			50.27			28.88			45.63			1		
01/09/23 14:07	259081.7			3.4			45.78			2.07			45.97			1		
01/09/23 14:08	284959.1			1.7			36.5			1.14			40.31			1		
01/09/23 14:09	293122.8			1.6			16.7			1.13			18.98			1		
01/09/23 14:10	294971.2			1.6			12.48			1.13			14.27			1		
01/09/23 14:11	292891.8			1.7			10.35			1.18			11.74			1		
01/09/23 14:12	293353.8			1.6			8.85			1.14			10.06			1		
01/09/23 14:13	293353.8			1.5			8.16			1.02			9.27			1		
01/09/23 14:14	292814.7			1.3			7.49			0.91			8.49			1		
01/09/23 14:15	296742.5			1.1			7.31			0.8			8.41			1		
01/09/23 14:16	307139.7			1.1			6.6			0.76			7.86			1		
01/09/23 14:17	307293.7			1			6.25			0.7			7.45			1		
01/09/23 14:18	308063.9			1			5.81			0.69			6.94			1		
01/09/23 14:19	306369.5			1			5.73			0.69			6.8			1		
01/09/23 14:20	304983.3			0.9			5.81			0.63			6.87			1		
01/09/23 14:21	304213.1			0.9			5.64			0.63			6.64			1		
01/09/23 14:22	304983.3			0.8			5.55			0.57			6.56			1		
01/09/23 14:23	304444.1			0.8			5.46			0.57			6.44			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 14:24	306831.6			0.8			5.46			0.57			6.49			1		
01/09/23 14:25	305984.5			0.8			5.46			0.57			6.47			1		
01/09/23 14:26	305291.3			0.8			5.46			0.57			6.46			1		
01/09/23 14:27	303674			0.7			5.55			0.5			6.53			1		
01/09/23 14:28	304136.1			0.7			5.55			0.5			6.54			1		
01/09/23 14:29	303134.9			0.7			5.55			0.5			6.52			1		
01/09/23 14:30	303828			0.7			5.55			0.5			6.53			1		
01/09/23 14:31	300516.3			0.7			5.64			0.5			6.56			1		
01/09/23 14:32	284651			0.7			5.72			0.48			6.31			1		
01/09/23 14:33	277334.5			0.6			5.99			0.41			6.44			1		
01/09/23 14:34	274022.8			0.6			7.08			0.41			7.52			1		
01/09/23 14:35	269478.9			0.6			7.56			0.35			7.9			1		
01/09/23 14:36	269247.8			0.5			6.64			0.29			6.93			1		
01/09/23 14:37	270172			0.5			3.23			0.29			3.38			1		
01/09/23 14:38	269401.9			0.5			2.03			0.29			2.12			1		
01/09/23 14:39	268708.7			0.5			1.75			0.29			1.82			1		
01/09/23 14:40	268323.7			0.5			1.75			0.29			1.82			1		
01/09/23 14:41	269170.8			0.5			1.75			0.29			1.83			1		
01/09/23 14:42	269555.9			0.5			1.84			0.29			1.93			0		
01/09/23 14:43	268400.7			0.5			1.94			0.29			2.01			0		
01/09/23 14:44	273791.8			0.5			1.94			0.3			2.05			0		
01/09/23 14:45	275255.1			0.5			1.94			0.3			2.07			0		
01/09/23 14:46	275563.2			0.5			1.84			0.3			1.97			0		

CT1 SUSD EVENT 10

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 21:41	339486.4			0.9			1.45			0.68			1.91			0		
01/09/23 21:42	336174.7			0.9			1.45			0.68			1.89			0		
01/09/23 21:43	333248.1			0.9			1.3			0.68			1.68			0		
01/09/23 21:44	314764.3			0.8			1.21			0.58			1.48			0		
01/09/23 21:45	297281.7			0.9			1.56			0.61			1.8			0		
01/09/23 21:46	295125.2			0.8			1.76			0.55			2.01			1		
01/09/23 21:47	285344.2			0.8			1.61			0.54			1.78			1		
01/09/23 21:48	264780.9			0.7			1.43			0.45			1.47			1		
01/09/23 21:49	241753.1			0.6			2.09			0.36			1.96			1		
01/09/23 21:50	221112.9			0.6			5.32			0.3			4.56			1		
01/09/23 21:51	196236.7			0.4			16.09			0.2			12.24			1		
01/09/23 21:52	173902.1			5.7			19.59			2.32			13.2			1		
01/09/23 21:53	155264.2			329.6			22.93			120.48			13.79			1		
01/09/23 21:54	136857.4			1369.3			25.26			441.36			13.4			1		
01/09/23 21:55	8009.7			1870.8			26.03			35.18			0.81			1		
01/09/23 21:56	0			0			24.34			0			0			0		
01/09/23 21:57	0			0			5.9			0			0			0		
01/09/23 21:58	0			0			5.9			0			0			0		
01/09/23 21:59	0			0			5.9			0			0			0		
01/09/23 22:00	0			0			2.95			0			0			0		

CT1 SUSD EVENT 11

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 15:51	13554.8			0			0			0			0			0		
01/10/23 15:52	13862.9			0			0			0			0			0		
01/10/23 15:53	14093.9			0			0			0			0			0		
01/10/23 15:54	16481.4			0			0			0			0			0		
01/10/23 15:55	20024.2			0			0			0			0			0		
01/10/23 15:56	30883.4			0			0			0			0			1		
01/10/23 15:57	39586.2			47.2			8.85			4.4			1.36			1		
01/10/23 15:58	47980.9			1045.3			14.75			118.16			2.74			1		
01/10/23 15:59	57453.9			997.1			15.08			134.81			3.35			1		
01/10/23 16:00	71855.9			592.1			21.83			100.19			6.08			1		
01/10/23 16:01	104356.6			398.3			25.21			97.88			10.2			1		
01/10/23 16:02	142017.5			279			37.61			93.31			20.7			1		
01/10/23 16:03	150566.2			167.4			54.67			59.34			31.9			1		
01/10/23 16:04	165738.4			1531.7			51.13			597.95			32.85			1		
01/10/23 16:05	184376.2			1750			52.28			759.96			37.36			1		
01/10/23 16:06	205863.7			967.7			52.67			469.21			42.03			1		
01/10/23 16:07	229584.6			110.7			52.97			59.84			47.13			1		
01/10/23 16:08	248915.6			8.9			50.09			5.22			48.33			1		
01/10/23 16:09	274561.9			1.9			48.04			1.23			51.11			1		
01/10/23 16:10	297974.8			1.6			26.74			1.14			30.88			1		
01/10/23 16:11	307832.8			1.6			15.53			1.13			18.53			1		
01/10/23 16:12	308063.9			1.6			11.38			1.16			13.59			1		
01/10/23 16:13	309219.1			1.7			10.35			1.25			12.4			1		
01/10/23 16:14	309681.2			1.5			9.32			1.12			11.19			1		
01/10/23 16:15	309065.1			1.4			8.29			1			9.93			1		
01/10/23 16:16	308680			1.3			7.78			0.93			9.31			1		
01/10/23 16:17	306138.5			1.1			7.72			0.81			9.16			1		
01/10/23 16:18	304059.1			1			6.85			0.75			8.08			1		
01/10/23 16:19	302441.7			1.4	X		6.67	X		1	X		7.82	X		1		
01/10/23 16:20	303982			0.9	X		6.51	X		0.66	X		7.67	X		1		
01/10/23 16:21	304059.1			0.9	X		6.43	X		0.63	X		7.58	X		1		
01/10/23 16:22	303982			0.9	X		6.43	X		0.63	X		7.57	X		1		
01/10/23 16:23	304983.3			0.8	X		6.43	X		0.57	X		7.6	X		1		
01/10/23 16:24	303674			0.8	X		6.43	X		0.57	X		7.57	X		1		
01/10/23 16:25	302056.7			0.8	X		6.43	X		0.56	X		7.53	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 16:26	302518.8			0.7	X		6.43	X		0.5	X		7.54	X		1		
01/10/23 16:27	301286.5			0.7			6.34			0.5			7.4			1		
01/10/23 16:28	300824.4			0.7			6.25			0.5			7.29			1		
01/10/23 16:29	301671.6			0.7			6.16			0.5			7.21			1		
01/10/23 16:30	302056.7			0.7			6.26			0.51			7.33			1		
01/10/23 16:31	303597			0.6			6.35			0.45			7.47			1		
01/10/23 16:32	304213.1			0.6			6.34			0.44			7.47			1		
01/10/23 16:33	306446.6			0.6			6.43			0.44			7.64			1		
01/10/23 16:34	307139.7			0.6			6.52			0.45			7.76			1		
01/10/23 16:35	290812.3			0.6			6.69			0.42			7.54			1		
01/10/23 16:36	287885.7			0.6			6.62			0.42			7.38			1		
01/10/23 16:37	281955.5			0.6			7.26			0.42			7.93			1		
01/10/23 16:38	277103.5			0.5			6.26			0.36			6.73			1		
01/10/23 16:39	272174.4			0.5			3.36			0.35			3.54			1		
01/10/23 16:40	269401.9			0.5			2.21			0.29			2.31			1		
01/10/23 16:41	269941			0.5			2.03			0.29			2.12			1		
01/10/23 16:42	270095			0.5			1.84			0.29			1.93			1		
01/10/23 16:43	269401.9			0.5			1.48			0.29			1.54			1		
01/10/23 16:44	268708.7			0.5			1.29			0.29			1.34			1		
01/10/23 16:45	269016.8			0.5			1.11			0.29			1.15			0		
01/10/23 16:46	270018			0.4			1.01			0.23			1.06			0		
01/10/23 16:47	270403.1			0.4			0.92			0.23			0.97			0		
01/10/23 16:48	282725.6			0.4			0.83			0.25			0.91			0		
01/10/23 16:49	302903.8			0.4			0.82			0.26			0.96			0		

CT1 SUSD EVENT 12

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 23:02	267784.5			0.4			1.78			0.24			1.85			0		
01/10/23 23:03	268092.6			0.4			1.69			0.24			1.75			0		
01/10/23 23:04	268708.7			0.4			1.5			0.24			1.56			0		
01/10/23 23:05	268323.7			0.4			1.4			0.24			1.46			0		
01/10/23 23:06	267168.4			0.4			1.31			0.24			1.36			0		
01/10/23 23:07	268477.7			0.4			1.31			0.24			1.36			1		
01/10/23 23:08	256771.3			0.4			1.31			0.23			1.3			1		
01/10/23 23:09	234436.6			0.4			1.81			0.21			1.64			1		
01/10/23 23:10	212487.1			0.3			6.31			0.16			5.2			1		
01/10/23 23:11	187919			2			9.57			0.89			6.97			1		
01/10/23 23:12	167971.8			96.9			12.3			38.33			8.01			1		
01/10/23 23:13	149873.1			830.9			14.39			293.31			8.36			1		
01/10/23 23:14	91726			1677.4			16.9			362.33			6.01			1		
01/10/23 23:15	24414.1			0			18.83			137.39			1.78			0		
01/10/23 23:16	24260			0			5.9			207.62			0.55			0		
01/10/23 23:17	24337			0			2.95			8.28			0.28			0		
01/10/23 23:18	24106			0			2.95			4.7			0.28			0		
01/10/23 23:19	24260			0			2.95			4.71			0.28			0		

CT1 SUSD EVENT 13

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 14:57	20024.2			0			0			-0.28			0			0		
01/11/23 14:58	20178.2			0			0			0			0			0		
01/11/23 14:59	20024.2			0			0			0			0			0		
01/11/23 15:00	20178.2			0			0			0			0			0		
01/11/23 15:01	20024.2			0			0			0			0			0		
01/11/23 15:02	26416.5			0			0			0			0			1		
01/11/23 15:03	32038.6			0			0			0			0			1		
01/11/23 15:04	42897.9			37.4			18.68			3.77			3.1			1		
01/11/23 15:05	53295.1			1136.5			12.91			142.72			2.67			1		
01/11/23 15:06	64693.4			745			18.94			113.56			4.75			1		
01/11/23 15:07	85179.7			454.3			24.44			91.12			8.07			1		
01/11/23 15:08	127615.5			323.2			31.04			97.17			15.36			1		
01/11/23 15:09	143634.8			211.5			43.7			71.54			24.33			1		
01/11/23 15:10	151567.4			581.5			52.92			207.62			31.09			1		
01/11/23 15:11	169743.2			1877.3			48.63			750.51			32			1		
01/11/23 15:12	188612.1			1674.3			50.39			743.59			36.83			1		
01/11/23 15:13	211639.9			818.2			49.65			407.71			40.71			1		
01/11/23 15:14	234744.7			68.5			49.71			37.88			45.22			1		
01/11/23 15:15	255308			4.8			46.75			2.87			46.26			1		
01/11/23 15:16	281724.4			1.9			41.4			1.24			45.21			1		
01/11/23 15:17	304829.2			1.7			18.92			1.21			22.35			1		
01/11/23 15:18	315611.5			1.6			12.31			1.21			15.06			1		
01/11/23 15:19	316304.6			1.7			8.85			1.26			10.85			1		
01/11/23 15:20	315303.4			1.7			7.87			1.27			9.61			1		
01/11/23 15:21	315534.4			1.5			7.1			1.14			8.68			1		
01/11/23 15:22	314918.3			1.4			6.33			1.01			7.72			1		
01/11/23 15:23	314610.3			1.2			6.07			0.9			7.41			1		
01/11/23 15:24	314379.2			1.1			5.73			0.83			6.98			1		
01/11/23 15:25	313301			1			5.29			0.77			6.43			1		
01/11/23 15:26	313301			1			5.21			0.7			6.32			1		
01/11/23 15:27	312068.7			1			5.21			0.7			6.3			1		
01/11/23 15:28	313069.9			0.9			5.12			0.64			6.21			1		
01/11/23 15:29	312145.8			0.8			5.11			0.58			6.18			1		
01/11/23 15:30	312299.8			0.8			5.11			0.58			6.18			1		
01/11/23 15:31	311144.5			0.8			5.11			0.58			6.16			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 15:32	310913.5			0.8			5.11			0.58			6.15			1		
01/11/23 15:33	311452.6			0.8			5.11			0.58			6.16			1		
01/11/23 15:34	309758.3			0.7			5.11			0.51			6.13			1		
01/11/23 15:35	310682.4			0.7			5.11			0.52			6.15			1		
01/11/23 15:36	309604.2			0.7			5.11			0.51			6.13			1		
01/11/23 15:37	311144.5			0.7			5.11			0.52			6.16			1		
01/11/23 15:38	310143.3			0.7			5.2			0.51			6.25			1		
01/11/23 15:39	311067.5			0.7			5.37			0.52			6.47			1		
01/11/23 15:40	298976			0.6			5.37			0.43			6.22			1		
01/11/23 15:41	291197.4			0.6			5.54			0.43			6.25			1		
01/11/23 15:42	286961.5			0.6			5.63			0.42			6.26			1		
01/11/23 15:43	287346.6			0.5			6.26			0.37			6.97			1		
01/11/23 15:44	289734.1			0.5			4.18			0.37			4.69			1		
01/11/23 15:45	281416.4			0.5			2.09			0.36			2.28			1		
01/11/23 15:46	276487.3			0.5			1.36			0.35			1.46			1		
01/11/23 15:47	273868.8			0.5			1.29			0.3			1.37			1		
01/11/23 15:48	273637.8			0.5			1.2			0.3			1.27			1		
01/11/23 15:49	273098.6			0.5			1.11			0.3			1.17			0		
01/11/23 15:50	271019.2			0.5			1.11			0.29			1.16			0		
01/11/23 15:51	271173.3			0.5			1.01			0.29			1.07			0		
01/11/23 15:52	271250.3			0.4			1.01			0.24			1.07			0		
01/11/23 15:53	285575.2			0.4			1.01			0.25			1.12			0		

CT1 SUSD EVENT 14

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 20:55	291351.4			0.7			1.74			0.48			1.96			0		
01/11/23 20:56	279799			0.7			1.67			0.46			1.81			0		
01/11/23 20:57	282648.6			0.6			1.63			0.42			1.79			0		
01/11/23 20:58	275332.1			0.5			1.63			0.29			1.74			0		
01/11/23 20:59	269555.9			0.5			1.54			0.29			1.61			0		
01/11/23 21:00	266552.3			0.5			1.48			0.29			1.52			1		
01/11/23 21:01	248145.5			0.5			1.38			0.27			1.33			1		
01/11/23 21:02	227890.3			0.4			2.66			0.2			2.35			1		
01/11/23 21:03	204323.4			0.3			8.38			0.15			6.64			1		
01/11/23 21:04	180448.4			3.1			11.57			1.33			8.09			1		
01/11/23 21:05	161964.6			190.1			15.52			72.5			9.74			1		
01/11/23 21:06	144096.9			1091.1			18			370.25			10.05			1		
01/11/23 21:07	62537			1715.8			20.16			252.71			4.89			1		
01/11/23 21:08	23258.8			0			21.86			151.77			1.97			0		
01/11/23 21:09	23412.9			0			5.9			69.85			0.53			0		
01/11/23 21:10	23412.9			0			2.95			6.01			0.27			0		
01/11/23 21:11	23566.9			0			2.95			4.75			0.27			0		
01/11/23 21:12	23566.9			0			2.95			4.59			0.27			0		

CT1 SUSD EVENT 15

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 15:43	28341.9			0			0			0			0			0		
01/12/23 15:44	28110.8			0			0			0			0			0		
01/12/23 15:45	28264.9			0			0			0			0			0		
01/12/23 15:46	28264.9			0			0			0			0			0		
01/12/23 15:47	28110.8			0			0			0			0			0		
01/12/23 15:48	31884.6			0			0			0			0			1		
01/12/23 15:49	35196.3			0			0			0			0			1		
01/12/23 15:50	42512.8			47.2			14.75			4.72			2.43			1		
01/12/23 15:51	52293.8			1050.7			14.07			129.35			2.85			1		
01/12/23 15:52	62691			878.8			17.37			129.63			4.22			1		
01/12/23 15:53	75937.8			481.8			22.76			86.18			6.7			1		
01/12/23 15:54	111288.1			295.3			25.4			77.39			10.96			1		
01/12/23 15:55	143326.7			187.4			40.17			63.27			22.31			1		
01/12/23 15:56	143557.8			132.1			56.53			44.65			31.44			1		
01/12/23 15:57	155649.3			1610.9			48.27			590.28			29.11			1		
01/12/23 15:58	174595.2			1829			51.02			752.1			34.53			1		
01/12/23 15:59	196159.7			1356.7			51.28			626.82			39			1		
01/12/23 16:00	219264.5			195.5			52.03			100.96			44.22			1		
01/12/23 16:01	239750.7			15.9			49.73			8.97			46.2			1		
01/12/23 16:02	264010.8			2.3			45.48			1.4			46.53			1		
01/12/23 16:03	289426			1.9			29.4			1.27			32.98			1		
01/12/23 16:04	306600.6			1.7			14.75			1.23			17.52			1		
01/12/23 16:05	308680			1.6			10.09			1.18			12.07			1		
01/12/23 16:06	309527.2			1.7			8.47			1.25			10.15			1		
01/12/23 16:07	309065.1			1.6			7.72			1.14			9.25			1		
01/12/23 16:08	307524.8			1.4			7.2			1.01			8.58			1		
01/12/23 16:09	308988.1			1.3			6.51			0.95			7.79			1		
01/12/23 16:10	305984.5			1.1			6.34			0.82			7.52			1		
01/12/23 16:11	304906.2			1.1			5.81			0.76			6.87			1		
01/12/23 16:12	302056.7			1			5.64			0.69			6.6			1		
01/12/23 16:13	300978.4			0.9			5.46			0.62			6.37			1		
01/12/23 16:14	302749.8			0.9			5.36			0.64			6.29			1		
01/12/23 16:15	302826.8			0.8			5.27			0.57			6.19			1		
01/12/23 16:16	304367.1			0.8			5.27			0.58			6.22			1		
01/12/23 16:17	302826.8			0.8			5.27			0.57			6.19			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 16:18	303751			0.7			5.27			0.51			6.21			1		
01/12/23 16:19	302210.7			0.7			5.27			0.51			6.18			1		
01/12/23 16:20	301209.5			0.7			5.27			0.51			6.16			1		
01/12/23 16:21	299438.1			0.7			5.18			0.5			6.02			1		
01/12/23 16:22	301440.5			0.7			5.1			0.51			5.95			1		
01/12/23 16:23	299130			0.6			5.1			0.44			5.91			1		
01/12/23 16:24	301055.4			0.6			5.18			0.44			6.05			1		
01/12/23 16:25	302056.7			0.6			5.18			0.45			6.07			1		
01/12/23 16:26	303442.9			0.6			5.27			0.45			6.2			1		
01/12/23 16:27	302518.8			0.6			5.45			0.45			6.39			1		
01/12/23 16:28	292660.7			0.6			5.54			0.43			6.29			1		
01/12/23 16:29	279182.9			0.6			5.63			0.41			6.09			1		
01/12/23 16:30	276795.4			0.6			5.81			0.36			6.23			1		
01/12/23 16:31	272328.5			0.6			4.61			0.35			4.87			1		
01/12/23 16:32	269786.9			0.5			2.4			0.29			2.51			1		
01/12/23 16:33	269401.9			0.5			2.25			0.3			2.35			1		
01/12/23 16:34	269478.9			0.5			2.9			0.3			3.03			1		
01/12/23 16:35	269324.8			0.4			3.56			0.24			3.71			1		
01/12/23 16:36	269864			0.4			4.12			0.24			4.31			1		
01/12/23 16:37	268939.8			0.4			3.75			0.24			3.9			1		
01/12/23 16:38	268862.8			0.4			2.72			0.24			2.83			1		
01/12/23 16:39	269324.8			0.4			2.53			0.24			2.64			1		
01/12/23 16:40	269247.8			0.4			2.34			0.24			2.44			1		
01/12/23 16:41	269247.8			0.4			2.15			0.24			2.25			1		
01/12/23 16:42	268939.8			0.4			2.15			0.24			2.24			1		
01/12/23 16:43	270249			0.4			2.25			0.24			2.35			1		
01/12/23 16:44	281416.4			0.4			2.25			0.25			2.45			1		
01/12/23 16:45	283110.7			0.4			2.21			0.25			2.43			1		
01/12/23 16:46	283033.7			0.5			2.12			0.31			2.33			1		
01/12/23 16:47	281108.3			0.5			1.84			0.31			2.01			1		
01/12/23 16:48	280107.1			0.5			1.75			0.3			1.9			1		
01/12/23 16:49	279953.1			0.5			1.75			0.3			1.9			1		
01/12/23 16:50	280415.2			0.5			1.75			0.3			1.9			1		
01/12/23 16:51	280492.2			0.5			1.84			0.3			2			0		
01/12/23 16:52	280261.1			0.5			1.84			0.3			2			0		
01/12/23 16:53	281647.4			0.5			1.84			0.31			2.01			0		
01/12/23 16:54	282802.7			0.5			1.75			0.31			1.92			0		
01/12/23 16:55	282802.7			0.5			1.75			0.31			1.92			0		

CT1 SUSD EVENT 16

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 22:03	268015.6			0.5			1.12			0.3			1.17			0		
01/12/23 22:04	268323.7			0.5			1.22			0.3			1.27			0		
01/12/23 22:05	268015.6			0.5			1.31			0.3			1.36			0		
01/12/23 22:06	268631.7			0.5			1.31			0.3			1.36			0		
01/12/23 22:07	268554.7			0.5			1.4			0.3			1.46			0		
01/12/23 22:08	264241.8			0.5			1.5			0.29			1.53			1		
01/12/23 22:09	243678.5			0.5			1.59			0.27			1.5			1		
01/12/23 22:10	223962.5			0.4			3.97			0.2			3.44			1		
01/12/23 22:11	198778.2			0.3			9.87			0.15			7.6			1		
01/12/23 22:12	175981.5			3			13.45			1.22			9.17			1		
01/12/23 22:13	159038			248.1			16.49			92.9			10.17			1		
01/12/23 22:14	139475.9			1255.5			18.46			412.28			9.97			1		
01/12/23 22:15	50214.4			1825.4			20.82			215.74			4.05			1		
01/12/23 22:16	31961.6			0			20.42			220.37			2.53			0		
01/12/23 22:17	31961.6			0			5.9			48.59			0.73			0		
01/12/23 22:18	31807.6			0			2.95			7.3			0.36			0		
01/12/23 22:19	31807.6			0			2.95			6.19			0.36			0		
01/12/23 22:20	31730.6			0			2.95			5.96			0.36			0		

CT1 SUSD EVENT 17

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 14:49	18329.8			0			0			0			0			0		
01/14/23 14:50	18329.8			0			0			0			0			0		
01/14/23 14:51	18252.8			0			0			0			0			0		
01/14/23 14:52	18329.8			0			0			0			0			0		
01/14/23 14:53	18945.9			0			0			0			0			0		
01/14/23 14:54	29959.2			0			0			0			0			1		
01/14/23 14:55	34580.2			23.6			0			1.92			0			1		
01/14/23 14:56	43206			64.9			13.11			6.61			2.2			1		
01/14/23 14:57	55913.6			1105.4			12.15			145.49			2.63			1		
01/14/23 14:58	70700.7			653.1			16.82			108.77			4.61			1		
01/14/23 14:59	98888.5			439.3			19.85			102.26			7.6			1		
01/14/23 15:00	134392.9			302.6			22.13			95.79			11.53			1		
01/14/23 15:01	143480.8			190.4			42.52			64.32			23.64			1		
01/14/23 15:02	152645.7			1385.6			40.94			498.12			24.22			1		
01/14/23 15:03	169512.2			1888.9			45.29			753.88			29.75			1		
01/14/23 15:04	191230.7			1689.4			54.03			760.88			40.05			1		
01/14/23 15:05	214027.4			434.3			59			218.91			48.95			1		
01/14/23 15:06	234128.6			45.5			59.25			25.07			53.76			1		
01/14/23 15:07	256386.2			3.6			72.8			2.15			72.34			1		
01/14/23 15:08	285883.3			2			74.3			1.35			82.31			1		
01/14/23 15:09	304983.3			1.8			34.76			1.3			41.09			1		
01/14/23 15:10	313378			1.8			14.16			1.31			17.2			1		
01/14/23 15:11	312453.8			1.9			11.21			1.36			13.57			1		
01/14/23 15:12	311606.6			1.8			9.78			1.3			11.81			1		
01/14/23 15:13	309296.2			1.7			8.38			1.25			10.05			1		
01/14/23 15:14	310143.3			1.5			7.27			1.12			8.74			1		
01/14/23 15:15	307216.7			1.4			6.5			0.99			7.74			1		
01/14/23 15:16	307370.8			1.3			6.07			0.93			7.23			1		
01/14/23 15:17	305522.4			1.1			5.55			0.81			6.57			1		
01/14/23 15:18	305291.3			1			5.47			0.75			6.47			1		
01/14/23 15:19	302980.8			1			5.29			0.68			6.21			1		
01/14/23 15:20	303288.9			1			5.12			0.68			6.02			1		
01/14/23 15:21	302672.8			0.9			5.02			0.63			5.89			1		
01/14/23 15:22	302749.8			0.9			4.93			0.63			5.79			1		
01/14/23 15:23	301825.6			0.9			4.84			0.63			5.67			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 15:24	302749.8			0.8			4.84			0.57			5.68			1		
01/14/23 15:25	302980.8			0.8			4.84			0.57			5.69			1		
01/14/23 15:26	301517.5			0.8			4.84			0.56			5.66			1		
01/14/23 15:27	301286.5			0.8			4.84			0.56			5.66			1		
01/14/23 15:28	301825.6			0.8			4.76			0.56			5.56			1		
01/14/23 15:29	298976			0.7			4.76			0.5			5.51			1		
01/14/23 15:30	300593.3			0.7			4.76			0.5			5.54			1		
01/14/23 15:31	302672.8			0.7			4.76			0.5			5.58			1		
01/14/23 15:32	303365.9			0.7			4.84			0.5			5.69			1		
01/14/23 15:33	303905			0.7			4.93			0.5			5.81			1		
01/14/23 15:34	288501.8			0.7			5.2			0.48			5.81			1		
01/14/23 15:35	284959.1			0.7			5.01			0.48			5.53			1		
01/14/23 15:36	279799			0.6			5.63			0.42			6.1			1		
01/14/23 15:37	274099.8			0.5			6.17			0.35			6.56			1		
01/14/23 15:38	268477.7			0.5			6.9			0.34			7.18			1		
01/14/23 15:39	266860.3			0.5			7.84			0.29			8.1			1		
01/14/23 15:40	268015.6			0.5			5.44			0.29			5.65			1		
01/14/23 15:41	268092.6			0.5			2.77			0.29			2.87			1		
01/14/23 15:42	267168.4			0.5			2.67			0.29			2.77			1		
01/14/23 15:43	268015.6			0.5			3.5			0.29			3.64			1		
01/14/23 15:44	267784.5			0.5			4.15			0.29			4.31			1		
01/14/23 15:45	267245.4			0.5			4.7			0.29			4.87			1		
01/14/23 15:46	268477.7			0.5			3.69			0.29			3.84			1		
01/14/23 15:47	269864			0.5			2.86			0.29			2.99			1		
01/14/23 15:48	269555.9			0.5			2.58			0.29			2.7			1		
01/14/23 15:49	267399.5			0.5			2.4			0.29			2.48			1		
01/14/23 15:50	267014.4			0.5			2.3			0.29			2.38			1		
01/14/23 15:51	266475.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:52	266629.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:53	266398.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:54	267630.5			0.5			2.3			0.29			2.39			1		
01/14/23 15:55	266706.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:56	266552.3			0.5			2.21			0.29			2.29			1		
01/14/23 15:57	266244.2			0.5			2.12			0.29			2.19			1		
01/14/23 15:58	275563.2			0.5			1.94			0.3			2.07			1		
01/14/23 15:59	289580.1			0.5			1.84			0.31			2.07			1		
01/14/23 16:00	290350.2			0.5			1.63			0.31			1.84			1		
01/14/23 16:01	286268.4			0.5			1.34			0.36			1.49			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 16:02	286037.3			0.5			1.16			0.36			1.29			0		
01/14/23 16:03	296126.4			0.5			1.18			0.38			1.35			0		
01/14/23 16:04	313917.1			0.5			1.25			0.4			1.52			0		
01/14/23 16:05	333171.1			0.5			1.41			0.41			1.82			0		
01/14/23 16:06	337098.9			0.6			1.5			0.49			1.96			0		

CT1 SUSD EVENT 18

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 20:03	287423.6			0.5			1.34			0.36			1.49			0		
01/14/23 20:04	270018			0.5			1.43			0.34			1.5			0		
01/14/23 20:05	265628.1			0.5			2			0.34			2.06			0		
01/14/23 20:06	265243			0.5			2.3			0.29			2.37			0		
01/14/23 20:07	265243			0.5			1.66			0.29			1.71			0		
01/14/23 20:08	258157.5			0.4			1.48			0.22			1.48			1		
01/14/23 20:09	236670.1			0.4			1.59			0.21			1.46			1		
01/14/23 20:10	214643.5			0.3			5.2			0.15			4.33			1		
01/14/23 20:11	190383.5			1			9.83			0.44			7.26			1		
01/14/23 20:12	168202.9			9.5			12.17			3.75			7.93			1		
01/14/23 20:13	151490.4			489.7			16.05			174.73			9.43			1		
01/14/23 20:14	110826			1564.7			18.32			408.41			7.87			1		
01/14/23 20:15	3080.6			0			20.47			14.32			0.24			0		
01/14/23 20:16	0			0			11.8			0			0			0		
01/14/23 20:17	2079.4			0			5.9			1.1			0.05			0		
01/14/23 20:18	2926.6			0			2.95			0.57			0.03			0		
01/14/23 20:19	0			0			2.95			0			0			0		

CT1 SUSD EVENT 19

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 14:54	0			0			0			0			0			0		
01/15/23 14:55	0			0			0			0			0			0		
01/15/23 14:56	0			0			0			0			0			0		
01/15/23 14:57	0			0			0			0			0			0		
01/15/23 14:58	2156.4			0			0			0			0			0		
01/15/23 14:59	13400.8			0			0			0			0			1		
01/15/23 15:00	28187.8			29.5			2.95			1.96			0.32			1		
01/15/23 15:01	40433.4			1003			14.75			95.42			2.31			1		
01/15/23 15:02	53064			1039.7			12.78			129.87			2.63			1		
01/15/23 15:03	66233.7			648.7			19.18			101.21			4.92			1		
01/15/23 15:04	94960.7			433.9			23.87			97.03			8.78			1		
01/15/23 15:05	135856.2			305.8			33.43			97.82			17.6			1		
01/15/23 15:06	141863.4			198.6			48.42			66.32			26.61			1		
01/15/23 15:07	150412.2			1239.4			49.52			438.89			28.86			1		
01/15/23 15:08	167509.7			1878.3			49.11			740.83			31.88			1		
01/15/23 15:09	188535.1			1726			51.98			766.14			37.98			1		
01/15/23 15:10	211100.8			686.9			51.7			341.52			42.3			1		
01/15/23 15:11	232896.3			60.1			50.21			32.98			45.32			1		
01/15/23 15:12	255385			5.2			46.75			3.14			46.27			1		
01/15/23 15:13	280261.1			2.1			41.82			1.37			45.42			1		
01/15/23 15:14	304290.1			1.8			18.81			1.26			22.18			1		
01/15/23 15:15	312992.9			1.8			13.51			1.32			16.39			1		
01/15/23 15:16	315072.3			1.9			10.03			1.38			12.25			1		
01/15/23 15:17	313146.9			1.9			8.43			1.37			10.23			1		
01/15/23 15:18	311914.7			1.7			7.84			1.24			9.47			1		
01/15/23 15:19	310374.4			1.5			7.01			1.12			8.43			1		
01/15/23 15:20	308911.1			1.4			6.58			1			7.88			1		
01/15/23 15:21	308757			1.2			6.07			0.87			7.26			1		
01/15/23 15:22	306908.7			1.1			6.07			0.82			7.22			1		
01/15/23 15:23	305830.4			1			5.9			0.75			6.99			1		
01/15/23 15:24	306831.6			1			5.73			0.75			6.81			1		
01/15/23 15:25	306138.5			1			5.55			0.69			6.59			1		
01/15/23 15:26	304906.2			0.9			5.47			0.62			6.46			1		
01/15/23 15:27	305753.4			0.9			5.47			0.62			6.48			1		
01/15/23 15:28	305368.3			0.9			5.47			0.62			6.47			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 15:29	304213.1			0.8			5.46			0.57			6.44			1		
01/15/23 15:30	303597			0.8			5.46			0.57			6.42			1		
01/15/23 15:31	303288.9			0.8			5.46			0.57			6.42			1		
01/15/23 15:32	301517.5			0.8			5.46			0.56			6.38			1		
01/15/23 15:33	301825.6			0.7			5.37			0.5			6.28			1		
01/15/23 15:34	303674			0.7			5.46			0.5			6.43			1		
01/15/23 15:35	303597			0.7			5.46			0.5			6.42			1		
01/15/23 15:36	304059.1			0.7			5.64			0.5			6.64			1		
01/15/23 15:37	305137.3			0.7			5.72			0.51			6.77			1		
01/15/23 15:38	304675.2			0.7			5.81			0.51			6.86			1		
01/15/23 15:39	306061.5			0.7			5.9			0.51			7			1		
01/15/23 15:40	305368.3			0.7			5.99			0.51			7.09			1		
01/15/23 15:41	303211.9			0.7			6.16			0.5			7.24			1		
01/15/23 15:42	303751			0.7			5.28			0.5			6.22			1		
01/15/23 15:43	305830.4			0.7			3.26			0.51			3.86			1		
01/15/23 15:44	297512.7			0.7			2.64			0.49			3.05			1		
01/15/23 15:45	292583.7			0.7			3.17			0.49			3.59			1		
01/15/23 15:46	288193.8			0.7			3.49			0.49			3.89			1		
01/15/23 15:47	284266			0.6			4.29			0.42			4.73			1		
01/15/23 15:48	277642.6			0.6			4.18			0.42			4.49			1		
01/15/23 15:49	274561.9			0.5			2.63			0.35			2.8			1		
01/15/23 15:50	271481.3			0.5			1.72			0.35			1.81			1		
01/15/23 15:51	271096.2			0.6			1.57			0.35			1.65			1		
01/15/23 15:52	268939.8			0.5			1.38			0.29			1.44			1		
01/15/23 15:53	278104.7			0.5			1.2			0.3			1.29			1		
01/15/23 15:54	299053			0.5			1.01			0.32			1.18			0		
01/15/23 15:55	320001.4			0.5			0.89			0.4			1.11			0		
01/15/23 15:56	329243.3			0.6			0.7			0.48			0.9			0		
01/15/23 15:57	324622.3			0.7			0.61			0.53			0.76			0		
01/15/23 15:58	332169.9			0.7			0.61			0.54			0.78			0		

CT1 SUSD EVENT 20

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 22:01	266244.2			0.5			2.12			0.29			2.19			0		
01/15/23 22:02	267476.5			0.4			1.57			0.23			1.62			0		
01/15/23 22:03	266783.3			0.4			1.48			0.23			1.53			0		
01/15/23 22:04	266321.2			0.4			1.38			0.23			1.43			0		
01/15/23 22:05	266629.3			0.4			1.38			0.23			1.43			0		
01/15/23 22:06	260160			0.4			1.38			0.23			1.39			1		
01/15/23 22:07	236362			0.4			1.59			0.21			1.46			1		
01/15/23 22:08	215798.8			0.4			5.1			0.2			4.26			1		
01/15/23 22:09	190768.6			0.3			9.18			0.15			6.79			1		
01/15/23 22:10	169204.1			8.3			10.48			3.31			6.87			1		
01/15/23 22:11	150797.3			496.4			13.72			176.24			8.02			1		
01/15/23 22:12	132082.4			1558.2			16.15			484.49			8.26			1		
01/15/23 22:13	0			1943.2			17.88			0			0			1		
01/15/23 22:14	0			0			16.52			0			0			0		
01/15/23 22:15	0			0			2.95			0			0			0		
01/15/23 22:16	0			0			2.95			0			0			0		
01/15/23 22:17	0			0			2.95			0			0			0		
01/15/23 22:18	0			0			2.95			0			0			0		

CT1 SUSD EVENT 21

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 14:55	16019.3			0			0			-0.22			0			0		
01/16/23 14:56	16173.4			0			0			-0.22			0			0		
01/16/23 14:57	15942.3			0			0			0			0			0		
01/16/23 14:58	16096.3			0			0			0			0			0		
01/16/23 14:59	15788.3			0			0			0			0			0		
01/16/23 15:00	22950.8			0			0			0			0			1		
01/16/23 15:01	29574.1			-5.9			0			-0.41			0			1		
01/16/23 15:02	39124.1			34.2			16.52			3.16			2.51			1		
01/16/23 15:03	51754.7			1086.7			12.54			132.33			2.51			1		
01/16/23 15:04	63076.1			758.3			18.32			112.71			4.48			1		
01/16/23 15:05	83716.4			468.3			23.6			92.36			7.66			1		
01/16/23 15:06	126845.3			323.2			25.65			96.52			12.61			1		
01/16/23 15:07	143403.7			210.7			46.98			71.15			26.12			1		
01/16/23 15:08	149565			786.9			53.84			277.08			31.2			1		
01/16/23 15:09	164737.2			1934.3			50.06			750.37			31.96			1		
01/16/23 15:10	182835.9			1772.3			51.79			762.9			36.69			1		
01/16/23 15:11	205863.7			956.2			51.92			463.64			41.43			1		
01/16/23 15:12	229507.6			81.4			51.3			44.01			45.63			1		
01/16/23 15:13	247298.3			6.6			47.78			3.84			45.8			1		
01/16/23 15:14	276872.4			2			43.83			1.31			47.03			1		
01/16/23 15:15	298359.9			1.7			21.7			1.2			25.09			1		
01/16/23 15:16	307909.8			1.6			15.36			1.2			18.33			1		
01/16/23 15:17	307986.9			1.8			10.79			1.28			12.88			1		
01/16/23 15:18	308911.1			1.8			9.06			1.31			10.85			1		
01/16/23 15:19	304598.2			1.6			8.21			1.17			9.69			1		
01/16/23 15:20	305984.5			1.5			7.29			1.06			8.64			1		
01/16/23 15:21	307986.9			1.3			6.85			0.94			8.18			1		
01/16/23 15:22	306677.6			1.1			6.68			0.81			7.94			1		
01/16/23 15:23	305368.3			1			6.25			0.75			7.39			1		
01/16/23 15:24	302903.8			1.1			5.9			0.75			6.93			1		
01/16/23 15:25	303828			1			5.81			0.69			6.84			1		
01/16/23 15:26	303519.9			0.9			5.64			0.63			6.63			1		
01/16/23 15:27	302518.8			0.9			5.55			0.63			6.51			1		
01/16/23 15:28	303674			0.8			5.46			0.57			6.43			1		
01/16/23 15:29	302364.7			0.8			5.37			0.56			6.29			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 15:30	303288.9			0.8			5.37			0.57			6.31			1		
01/16/23 15:31	300901.4			0.8			5.37			0.56			6.26			1		
01/16/23 15:32	300670.3			0.7			5.54			0.51			6.46			1		
01/16/23 15:33	302133.7			0.7			5.45			0.51			6.38			1		
01/16/23 15:34	301748.6			0.7			5.45			0.51			6.38			1		
01/16/23 15:35	302749.8			0.7			5.54			0.51			6.5			1		
01/16/23 15:36	301594.6			0.7			5.63			0.51			6.58			1		
01/16/23 15:37	303828			0.6			5.81			0.45			6.84			1		
01/16/23 15:38	307524.8			0.6			5.9			0.45			7.03			1		
01/16/23 15:39	291197.4			0.6			5.9			0.42			6.66			1		
01/16/23 15:40	285113.1			0.7			5.99			0.48			6.62			1		
01/16/23 15:41	280415.2			0.6			6.72			0.42			7.3			1		
01/16/23 15:42	275255.1			0.6			6.99			0.41			7.46			1		
01/16/23 15:43	270865.2			0.6			8.11			0.35			8.52			1		
01/16/23 15:44	269786.9			0.5			5.62			0.29			5.88			1		
01/16/23 15:45	268708.7			0.5			3.13			0.29			3.26			1		
01/16/23 15:46	269941			0.5			3.23			0.29			3.38			1		
01/16/23 15:47	268554.7			0.5			4.15			0.29			4.32			1		
01/16/23 15:48	268862.8			0.5			4.98			0.29			5.19			1		
01/16/23 15:49	268246.6			0.5			4.7			0.29			4.89			1		
01/16/23 15:50	269170.8			0.4			3.13			0.23			3.27			1		
01/16/23 15:51	268785.8			0.4			2.21			0.23			2.31			1		
01/16/23 15:52	268785.8			0.5			2.03			0.29			2.11			1		
01/16/23 15:53	269093.8			0.5			1.75			0.29			1.83			1		
01/16/23 15:54	268785.8			0.4			1.48			0.23			1.54			1		
01/16/23 15:55	269093.8			0.5			1.2			0.29			1.25			1		
01/16/23 15:56	268323.7			0.5			1.01			0.29			1.05			0		
01/16/23 15:57	268939.8			0.5			0.92			0.29			0.96			0		
01/16/23 15:58	268015.6			0.5			0.83			0.29			0.86			0		
01/16/23 15:59	268708.7			0.5			0.83			0.29			0.86			0		
01/16/23 16:00	267476.5			0.5			0.83			0.29			0.86			0		

CT1 SUSD EVENT 22

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 22:48	265551.1			0.5			1.69			0.29			1.74			0		
01/16/23 22:49	266244.2			0.4			1.5			0.23			1.55			0		
01/16/23 22:50	267091.4			0.4			1.4			0.24			1.45			0		
01/16/23 22:51	267553.5			0.4			1.4			0.24			1.46			0		
01/16/23 22:52	266937.4			0.4			1.5			0.24			1.55			0		
01/16/23 22:53	259620.8			0.4			1.5			0.23			1.51			1		
01/16/23 22:54	236593.1			0.4			1.78			0.21			1.63			1		
01/16/23 22:55	215105.6			0.4			6.3			0.2			5.25			1		
01/16/23 22:56	191615.7			0.8			10.38			0.35			7.71			1		
01/16/23 22:57	168819			10			14.38			3.96			9.41			1		
01/16/23 22:58	150335.2			597.9			16.86			211.72			9.82			1		
01/16/23 22:59	100659.9			1647.7			19.14			390.59			7.47			1		
01/16/23 23:00	0			0			21.36			0			0			0		
01/16/23 23:01	0			0			29.5			0			0			0		
01/16/23 23:02	0			0			2.95			0			0			0		
01/16/23 23:03	0			0			2.95			0			0			0		
01/16/23 23:04	0			0			2.95			0			0			0		

CT1 SUSD EVENT 23

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 16:55	13400.8			0			0			-0.19			0			0		
01/17/23 16:56	14170.9			0			0			-0.2			0			0		
01/17/23 16:57	14016.9			0			0			-0.19			0			0		
01/17/23 16:58	13862.9			0			0			0			0			0		
01/17/23 16:59	13708.8			0			0			0			0			0		
01/17/23 17:00	19100			0			0			0			0			1		
01/17/23 17:01	26031.4			0			0			0			0			1		
01/17/23 17:02	36197.5			37.4			11.8			3.19			1.66			1		
01/17/23 17:03	48366			1094.6			11.41			124.72			2.14			1		
01/17/23 17:04	59764.4			907.3			16.06			127.75			3.72			1		
01/17/23 17:05	75398.6			515			21.35			91.42			6.24			1		
01/17/23 17:06	115678			377.3			25.21			102.79			11.3			1		
01/17/23 17:07	142941.6			256.3			40.12			86.29			22.23			1		
01/17/23 17:08	145945.3			260.2			54.43			89.4			30.78			1		
01/17/23 17:09	162811.8			1883.4			48.68			722.18			30.72			1		
01/17/23 17:10	180833.5			1783.7			50.4			759.4			35.32			1		
01/17/23 17:11	203938.3			1290.8			49.41			619.76			39.05			1		
01/17/23 17:12	226966.1			181.2			50.95			96.84			44.83			1		
01/17/23 17:13	245449.9			15.7			46.96			9.07			44.67			1		
01/17/23 17:14	273098.6			2.3			44.2			1.45			46.78			1		
01/17/23 17:15	296588.5			1.7			27.08			1.22			31.13			1		
01/17/23 17:16	316458.6			1.7			15.32			1.25			18.79			1		
01/17/23 17:17	322542.9			1.7			11.04			1.28			13.8			1		
01/17/23 17:18	321926.8			1.8			9.69			1.34			12.09			1		
01/17/23 17:19	319077.2			1.7			8.34			1.27			10.32			1		
01/17/23 17:20	320386.4			1.5			7.7			1.16			9.56			1		
01/17/23 17:21	321541.7			1.4			6.93			1.04			8.63			1		
01/17/23 17:22	321079.6			1.2			6.84			0.91			8.51			1		
01/17/23 17:23	319308.2			1.1			6.58			0.84			8.15			1		
01/17/23 17:24	318538.1			1			6.51			0.78			8.03			1		
01/17/23 17:25	318384			1			6.33			0.78			7.81			1		
01/17/23 17:26	314995.3			1			6.07			0.71			7.41			1		
01/17/23 17:27	314841.3			0.9			5.9			0.64			7.2			1		
01/17/23 17:28	315534.4			0.9			5.81			0.64			7.11			1		
01/17/23 17:29	312530.8			0.9			5.73			0.64			6.94			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 17:30	313840.1			0.9			5.72			0.65			6.96			1		
01/17/23 17:31	316304.6			0.8			5.64			0.59			6.91			1		
01/17/23 17:32	315457.4			0.8			5.64			0.59			6.89			1		
01/17/23 17:33	313917.1			0.8			5.72			0.59			6.96			1		
01/17/23 17:34	316535.7			0.8			5.72			0.59			7.02			1		
01/17/23 17:35	317613.9			0.7			5.81			0.53			7.15			1		
01/17/23 17:36	317228.8			1.2	X		5.9	X		0.86	X		7.25	X		1		
01/17/23 17:37	317151.8			0.8	X		6.61	X		0.61	X		8.13	X		1		
01/17/23 17:38	317074.8			0.8	X		6.25	X		0.59	X		7.68	X		1		
01/17/23 17:39	318153			0.7	X		6.34	X		0.53	X		7.82	X		1		
01/17/23 17:40	319154.2			0.7	X		6.34	X		0.53	X		7.84	X		1		
01/17/23 17:41	304136.1			0.7	X		6.43	X		0.5	X		7.58	X		1		
01/17/23 17:42	300670.3			0.7	X		6.25	X		0.5	X		7.29	X		1		
01/17/23 17:43	294971.2			0.7	X		5.1	X		0.5	X		5.82	X		1		
01/17/23 17:44	289811.1			0.6			3.67			0.43			4.12			1		
01/17/23 17:45	282263.5			0.5			2.9			0.36			3.18			1		
01/17/23 17:46	280954.3			0.5			3.54			0.36			3.86			1		
01/17/23 17:47	279259.9			0.6			4.43			0.36			4.79			1		
01/17/23 17:48	274716			0.5			3.78			0.3			4.02			1		
01/17/23 17:49	273098.6			0.5			2.86			0.3			3.02			1		
01/17/23 17:50	273021.6			0.5			2.67			0.3			2.83			1		
01/17/23 17:51	273483.7			0.5			2.49			0.3			2.64			1		
01/17/23 17:52	273098.6			0.5			2.4			0.3			2.54			1		
01/17/23 17:53	280415.2			0.5			2.4			0.3			2.6			1		
01/17/23 17:54	289503			0.5			2.49			0.31			2.79			1		
01/17/23 17:55	289195			0.5			2.36			0.31			2.64			1		
01/17/23 17:56	286345.4			0.5			2.18			0.37			2.42			1		
01/17/23 17:57	286191.3			0.5			1.91			0.37			2.11			1		
01/17/23 17:58	286037.3			0.5			1.91			0.37			2.11			1		
01/17/23 17:59	286268.4			0.5			1.91			0.31			2.12			1		
01/17/23 18:00	285652.3			0.5			2			0.31			2.21			1		
01/17/23 18:01	285883.3			0.5			2			0.31			2.21			1		
01/17/23 18:02	285729.3			0.5			2			0.31			2.21			1		
01/17/23 18:03	286268.4			0.5			1.91			0.31			2.12			1		
01/17/23 18:04	286114.3			0.5			1.91			0.31			2.11			1		
01/17/23 18:05	286884.5			0.5			1.82			0.31			2.02			1		
01/17/23 18:06	285806.3			0.5			1.72			0.31			1.91			1		
01/17/23 18:07	286037.3			0.5			1.63			0.31			1.81			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 18:08	286191.3			0.5			1.54			0.31			1.71			0		
01/17/23 18:09	286345.4			0.5			1.54			0.31			1.71			0		
01/17/23 18:10	284034.9			0.5			1.54			0.3			1.7			0		
01/17/23 18:11	283264.8			0.5			1.54			0.3			1.69			0		

CT1 SUSD EVENT 24

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 9:01	267861.6			0.5			1.71			0.3			1.78			0		
01/18/23 9:02	268015.6			0.4			1.71			0.24			1.78			0		
01/18/23 9:03	267476.5			0.4			1.62			0.24			1.68			0		
01/18/23 9:04	267861.6			0.4			1.52			0.24			1.58			0		
01/18/23 9:05	268092.6			0.4			1.43			0.24			1.48			0		
01/18/23 9:06	268400.7			0.4			1.43			0.24			1.49			1		
01/18/23 9:07	258465.6			0.4			1.43			0.23			1.43			1		
01/18/23 9:08	237440.3			0.4			1.93			0.22			1.78			1		
01/18/23 9:09	213873.4			0.3			5.9			0.16			4.89			1		
01/18/23 9:10	190614.5			2.4			8.96			1.07			6.62			1		
01/18/23 9:11	169358.1			94.1			11.17			37.56			7.33			1		
01/18/23 9:12	150412.2			757.1			13.53			268.1			7.88			1		
01/18/23 9:13	109285.7			1650.4			15.15			424.85			6.42			1		
01/18/23 9:14	0			0			17.5			0			0			0		
01/18/23 9:15	0			0			8.85			0			0			0		
01/18/23 9:16	0			0			2.95			0			0			0		
01/18/23 9:17	0			0			5.9			0			0			0		
01/18/23 9:18	0			0			5.9			0			0			0		

CT1 SUSD EVENT 25

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 16:05	9627			0			0			0			0			0		
01/23/23 16:06	5314.1			0			0			0			0			0		
01/23/23 16:07	7547.6			0			0			0			0			0		
01/23/23 16:08	6700.4			0			0			0			0			0		
01/23/23 16:09	17097.5			0			0			0			0			0		
01/23/23 16:10	26493.5			0			0			0			0			1		
01/23/23 16:11	36120.5			0			0			0			0			1		
01/23/23 16:12	42666.8			88.5			5.9			8.89			0.98			1		
01/23/23 16:13	51908.8			1044.3			9.83			127.63			1.98			1		
01/23/23 16:14	61843.8			917.3			13.54			133.67			3.25			1		
01/23/23 16:15	77786.1			512.7			18.29			93.88			5.51			1		
01/23/23 16:16	115832			344.1			23.33			93.89			10.48			1		
01/23/23 16:17	143326.7			231.8			35.89			78.25			19.94			1		
01/23/23 16:18	151721.5			171.5			51.72			61.27			30.41			1		
01/23/23 16:19	168279.9			1733.7			40.75			686.9			26.57			1		
01/23/23 16:20	188304			1770			46.02			784.89			33.59			1		
01/23/23 16:21	211716.9			736.6			56.2			367.21			46.11			1		
01/23/23 16:22	234051.5			72			56.95			39.65			51.65			1		
01/23/23 16:23	256463.2			5.7			57.61			3.42			57.26			1		
01/23/23 16:24	281570.4			2.1			57.84			1.4			63.12			1		
01/23/23 16:25	295510.3			1.9			33.4			1.32			38.26			1		
01/23/23 16:26	295818.3			1.9			24.04			1.35			27.56			1		
01/23/23 16:27	295202.2			2.1			18.31			1.45			20.95			1		
01/23/23 16:28	299669.2			2			14.4			1.41			16.73			1		
01/23/23 16:29	316843.7			1.8			12.15			1.38			14.92			1		
01/23/23 16:30	322619.9			1.7			9.86			1.27			12.33			1		
01/23/23 16:31	322773.9			1.6			8.42			1.19			10.53			1		
01/23/23 16:32	322465.9			1.6			7.38			1.19			9.22			1		
01/23/23 16:33	320771.5			1.4			6.85			1.05			8.52			1		
01/23/23 16:34	319385.3			1.3			6.07			0.98			7.52			1		
01/23/23 16:35	318769.1			1.1			5.81			0.85			7.18			1		
01/23/23 16:36	317844.9			1.1			5.46			0.79			6.73			1		
01/23/23 16:37	316997.8			1			5.2			0.72			6.38			1		
01/23/23 16:38	317382.8			0.9			5.2			0.66			6.39			1		
01/23/23 16:39	317536.8			0.8			5.11			0.59			6.29			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 16:40	317921.9			0.9			5.11			0.66			6.29			1		
01/23/23 16:41	318692.1			0.8			5.11			0.59			6.31			1		
01/23/23 16:42	318461			0.8			5.11			0.59			6.3			1		
01/23/23 16:43	317767.9			0.8			5.11			0.59			6.29			1		
01/23/23 16:44	314995.3			0.8			5.11			0.59			6.24			1		
01/23/23 16:45	314533.2			0.8			5.2			0.59			6.33			1		
01/23/23 16:46	315611.5			0.8			5.11			0.59			6.25			1		
01/23/23 16:47	316843.7			0.7			5.11			0.53			6.27			1		
01/23/23 16:48	318307			0.7			5.27			0.54			6.51			1		
01/23/23 16:49	318230			0.7			5.28			0.53			6.52			1		
01/23/23 16:50	317844.9			0.7			5.46			0.53			6.73			1		
01/23/23 16:51	318153			0.7			5.64			0.53			6.95			1		
01/23/23 16:52	316997.8			0.7			5.81			0.53			7.14			1		
01/23/23 16:53	317536.8			0.7			5.9			0.53			7.26			1		
01/23/23 16:54	319077.2			0.7			6.08			0.53			7.51			1		
01/23/23 16:55	321618.7			0.7			6.08			0.53			7.57			1		
01/23/23 16:56	308294.9			0.7			6.43			0.51			7.68			1		
01/23/23 16:57	302364.7			0.6			5.55			0.44			6.5			1		
01/23/23 16:58	306292.5			0.6			2.95			0.45			3.5			1		
01/23/23 16:59	327163.8			0.6			2.45			0.49			3.11			1		
01/23/23 17:00	342952.1			0.6			3.31			0.51			4.4			1		
01/23/23 17:01	336713.8			0.6			3.04			0.5			3.97			1		
01/23/23 17:02	330167.5			0.6			3.17			0.48			4.06			1		
01/23/23 17:03	328319.1			0.6			3.87			0.48			4.93			1		
01/23/23 17:04	327009.8			0.7			3.96			0.54			5.02			1		
01/23/23 17:05	326008.6			0.7			2.73			0.54			3.45			1		
01/23/23 17:06	326162.7			0.7			2.29			0.54			2.89			1		
01/23/23 17:07	325854.6			0.7			2.11			0.54			2.67			1		
01/23/23 17:08	325700.5			0.6			2.03			0.47			2.56			1		
01/23/23 17:09	325546.5			0.6			2.2			0.47			2.78			1		
01/23/23 17:10	325777.6			0.6			2.38			0.47			3			1		
01/23/23 17:11	325623.5			0.6			2.64			0.47			3.33			1		
01/23/23 17:12	325469.5			0.6			2.73			0.47			3.44			1		
01/23/23 17:13	325700.5			0.7			2.55			0.54			3.22			1		
01/23/23 17:14	326316.7			0.7			2.03			0.54			2.56			1		
01/23/23 17:15	324699.3			0.6			1.76			0.47			2.22			1		
01/23/23 17:16	324083.2			0.6			1.67			0.47			2.1			1		
01/23/23 17:17	324006.2			0.6			1.67			0.47			2.1			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 17:18	333633.2			0.6			1.67			0.48			2.16			0		
01/23/23 17:19	352579.1			0.6			1.67			0.51			2.29			0		
01/23/23 17:20	368906.5			0.6			1.43			0.54			2.04			0		
01/23/23 17:21	393089.5			0.5			1			0.5			1.52			0		
01/23/23 17:22	409879			0.6			1.11			0.53			1.76			0		

CT1 SUSD EVENT 26

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 10:04	269786.9			0.4			1.43			0.24			1.49			0		
01/24/23 10:05	269941			0.4			1.43			0.24			1.49			0		
01/24/23 10:06	270634.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:07	270326.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:08	270326.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:09	268246.6			0.4			1.43			0.24			1.48			1		
01/24/23 10:10	250224.9			0.4			1.43			0.22			1.38			1		
01/24/23 10:11	229199.5			0.4			3.25			0.21			2.88			1		
01/24/23 10:12	206248.8			0.3			6.76			0.16			5.4			1		
01/24/23 10:13	182219.8			3.7			8.85			1.57			6.25			1		
01/24/23 10:14	163350.9			224.6			10.62			86.37			6.72			1		
01/24/23 10:15	145483.2			1190.9			12.25			407.86			6.91			1		
01/24/23 10:16	50060.4			1733.1			13.49			204.45			2.62			1		
01/24/23 10:17	20871.3			0			16.86			144.26			1.37			0		
01/24/23 10:18	21102.4			0			5.9			52.04			0.48			0		
01/24/23 10:19	21179.4			0			5.9			9.72			0.48			0		
01/24/23 10:20	21487.5			0			5.9			7.46			0.49			0		
01/24/23 10:21	21718.5			0			5.9			7.53			0.5			0		

CT1 SUSD EVENT 27

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 16:17	12784.7			0			0			0.35			0			0		
01/27/23 16:18	12630.6			0			0			0.35			0			0		
01/27/23 16:19	12168.5			0			0			0.34			0			0		
01/27/23 16:20	16558.4			0			0			0.46			0			0		
01/27/23 16:21	23643.9			0			0			0.66			0			0		
01/27/23 16:22	37275.7			11.8			0			1.04			0			1		
01/27/23 16:23	42897.9			76.7			0			7.74			0			1		
01/27/23 16:24	50060.4			1048.9			12.46			123.73			2.42			1		
01/27/23 16:25	60765.6			1000.6			12.49			143.12			2.94			1		
01/27/23 16:26	72626.1			586.5			17.11			100.3			4.82			1		
01/27/23 16:27	102893.3			374.7			20.92			90.74			8.34			1		
01/27/23 16:28	141016.3			254.4			23.6			84.52			12.9			1		
01/27/23 16:29	149179.9			167			44.56			58.66			25.75			1		
01/27/23 16:30	163967			1325.7			38.62			511.9			24.54			1		
01/27/23 16:31	182912.9			1773.2			40.46			763.68			28.68			1		
01/27/23 16:32	203707.3			1315.7			51.74			631.14			40.85			1		
01/27/23 16:33	226658			164.4			61.15			87.73			53.7			1		
01/27/23 16:34	247375.3			11.8			60.65			6.87			58.14			1		
01/27/23 16:35	275024			2.1			56.64			1.39			60.37			1		
01/27/23 16:36	300824.4			1.8			33.66			1.3			39.25			1		
01/27/23 16:37	314456.2			1.8			18.4			1.3			22.43			1		
01/27/23 16:38	316843.7			1.8			12.66			1.34			15.54			1		
01/27/23 16:39	316843.7			1.9			10.52			1.4			12.91			1		
01/27/23 16:40	319539.3			1.7			8.81			1.29			10.91			1		
01/27/23 16:41	320694.5			1.6			7.18			1.23			8.93			1		
01/27/23 16:42	320771.5			1.5			6.33			1.1			7.87			1		
01/27/23 16:43	319693.3			1.4			5.56			1.03			6.89			1		
01/27/23 16:44	317921.9			1.3			4.95			0.97			6.09			1		
01/27/23 16:45	317690.9			1.2			4.69			0.91			5.77			1		
01/27/23 16:46	316612.7			1.1			4.16			0.84			5.11			1		
01/27/23 16:47	316689.7			1			4.08			0.78			5.01			1		
01/27/23 16:48	323929.2			1			3.99			0.73			5.01			1		
01/27/23 16:49	342952.1			1			3.9			0.77			5.19			1		
01/27/23 16:50	354196.5			0.9			3.17			0.73			4.35			1		
01/27/23 16:51	377840.4			0.9			2.59			0.8			3.8			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 16:52	396709.3			0.8			2.54			0.76			3.91			1		
01/27/23 16:53	420738.3			0.7			2.27			0.72			3.7			1		
01/27/23 16:54	443458			0.7			2.21			0.77			3.8			1		
01/27/23 16:55	450466.4			0.7			2.67			0.78			4.67			1		
01/27/23 16:56	446769.7			0.7			3.18			0.76			5.5			1		
01/27/23 16:57	447154.8			0.7			3.18			0.76			5.51			1		
01/27/23 16:58	445460.4			0.8			3.18			0.86			5.48			1		
01/27/23 16:59	430827.3			0.7			3.18			0.74			5.3			1		
01/27/23 17:00	410726.2			0.7			3.27			0.7			5.2			1		
01/27/23 17:01	392627.4			0.8			3.75			0.74			5.71			1		
01/27/23 17:02	384694.8			0.8			3.79			0.72			5.65			1		
01/27/23 17:03	390162.9			0.9			3.7			0.81			5.59			1		
01/27/23 17:04	399173.8			0.8			3.49			0.76			5.39			1		
01/27/23 17:05	404025.8			0.7			3.36			0.69			5.26			1		
01/27/23 17:06	400406			0.7			3.22			0.67			4.99			1		
01/27/23 17:07	401022.2			0.7			3.4			0.68			5.28			1		
01/27/23 17:08	396093.2			0.7			3.4			0.67			5.21			1		
01/27/23 17:09	398095.6			0.7			2.5			0.67			3.86			1		
01/27/23 17:10	396940.3			0.7			2.15			0.67			3.3			1		
01/27/23 17:11	399866.9			0.7			2.06			0.67			3.19			1		
01/27/23 17:12	399327.8			0.8			2.15			0.76			3.32			1		
01/27/23 17:13	402408.5			0.7			2.41			0.68			3.76			1		
01/27/23 17:14	419120.9			0.7			2.59			0.71			4.21			1		
01/27/23 17:15	441609.6			0.7			2.27			0.76			3.88			1		
01/27/23 17:16	455241.4			0.6			2.03			0.69			3.58			1		
01/27/23 17:17	450312.4			0.7			2.63			0.77			4.59			1		
01/27/23 17:18	450697.5			0.7			2.18			0.77			3.8			1		
01/27/23 17:19	452622.9			0.7			1.45			0.78			2.56			1		
01/27/23 17:20	452083.8			0.7			1.45			0.8			2.62			1		
01/27/23 17:21	451852.7			1.3			1.41			1.46			2.57			1		
01/27/23 17:22	452314.8			2			2.08			2.21			3.8			0		
01/27/23 17:23	451852.7			2.2			2.17			2.41			3.96			0		
01/27/23 17:24	451775.7			1.8			2.17			2.03			3.97			0		
01/27/23 17:25	452853.9			1.5			1.97			1.72			3.61			0		
01/27/23 17:26	451544.7			1.5			1.71			1.62			3.14			0		

CT1 SUSD EVENT 28

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 0:03	286884.5			0.8			1.43			0.54			1.59			0		
02/04/23 0:04	270788.2			0.8			1.52			0.51			1.59			0		
02/04/23 0:05	269247.8			0.8			1.94			0.52			2.01			0		
02/04/23 0:06	268400.7			0.7			2.25			0.47			2.33			0		
02/04/23 0:07	268323.7			0.7			1.97			0.41			2.04			0		
02/04/23 0:08	267630.5			0.7			1.4			0.41			1.45			1		
02/04/23 0:09	249377.7			0.7			1.31			0.38			1.26			1		
02/04/23 0:10	228583.4			0.7			2.61			0.36			2.31			1		
02/04/23 0:11	204477.4			0.6			7.38			0.3			5.83			1		
02/04/23 0:12	181141.6			3.1			10.53			1.33			7.37			1		
02/04/23 0:13	162426.7			221.8			13.9			84.62			8.72			1		
02/04/23 0:14	144559			1118.2			15.93			379.46			8.9			1		
02/04/23 0:15	47133.8			1758.4			18.54			194.44			3.37			1		
02/04/23 0:16	15172.1			0			23.97			100.55			1.4			0		
02/04/23 0:17	15403.2			0			5.9			41.4			0.35			0		
02/04/23 0:18	15942.3			0			5.9			3.97			0.36			0		
02/04/23 0:19	16635.4			0			5.9			6.47			0.38			0		
02/04/23 0:20	16789.5			0			5.9			6.51			0.38			0		

CT1 SUSD EVENT 29

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 16:03	20486.2			0			0			0.28			0			0		
02/04/23 16:04	20178.2			0			0			0.28			0			0		
02/04/23 16:05	20178.2			0			0			0.28			0			0		
02/04/23 16:06	19870.1			0			0			0.27			0			0		
02/04/23 16:07	19947.1			0			0			0.28			0			0		
02/04/23 16:08	22565.7			5.9			0			0.31			0			1		
02/04/23 16:09	30652.4			5.9			0			0.43			0			1		
02/04/23 16:10	38662			31.5			13.77			2.86			2.06			1		
02/04/23 16:11	50984.6			1149.7			13.06			137.68			2.57			1		
02/04/23 16:12	61843.8			908.6			17.04			132			4.08			1		
02/04/23 16:13	76630.9			511.1			22.48			91.98			6.66			1		
02/04/23 16:14	115909			374.4			25.48			101.91			11.41			1		
02/04/23 16:15	142864.6			246.4			39.41			82.67			21.76			1		
02/04/23 16:16	149796.1			187.7			53.1			65.99			30.73			1		
02/04/23 16:17	162811.8			1808.1			47.56			691.28			29.92			1		
02/04/23 16:18	180371.4			1785.2			48.72			756.05			33.96			1		
02/04/23 16:19	202475			1300.5			48.09			618.33			37.63			1		
02/04/23 16:20	225810.8			191.6			48.68			101.61			42.48			1		
02/04/23 16:21	245141.8			18.5			45.9			10.67			43.49			1		
02/04/23 16:22	272174.4			2.5			42.69			1.58			44.91			1		
02/04/23 16:23	294124			1.9			29.11			1.29			33.08			1		
02/04/23 16:24	312222.8			1.8			13.91			1.29			16.79			1		
02/04/23 16:25	310913.5			1.8			9.86			1.29			11.85			1		
02/04/23 16:26	309065.1			1.8			8.21			1.3			9.8			1		
02/04/23 16:27	307601.8			1.7			7.27			1.24			8.64			1		
02/04/23 16:28	308757			1.6			6.51			1.13			7.76			1		
02/04/23 16:29	309681.2			1.4			6.07			1.01			7.27			1		
02/04/23 16:30	310143.3			1.2			5.99			0.88			7.17			1		
02/04/23 16:31	310528.4			1.1			5.81			0.82			6.98			1		
02/04/23 16:32	308294.9			1.1			5.55			0.82			6.62			1		
02/04/23 16:33	306292.5			1			5.29			0.75			6.26			1		
02/04/23 16:34	306369.5			1.1			5.2			0.76			6.15			1		
02/04/23 16:35	304983.3			1			5.02			0.69			5.92			1		
02/04/23 16:36	304829.2			1			4.93			0.69			5.81			1		
02/04/23 16:37	304675.2			0.9			4.93			0.63			5.81			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 16:38	305137.3			0.8			4.93			0.57			5.82			1		
02/04/23 16:39	304675.2			0.9			4.93			0.63			5.81			1		
02/04/23 16:40	303982			0.8			4.93			0.57			5.79			1		
02/04/23 16:41	304444.1			0.8			4.84			0.57			5.7			1		
02/04/23 16:42	304906.2			0.8			4.84			0.57			5.71			1		
02/04/23 16:43	304752.2			0.8			4.84			0.57			5.7			1		
02/04/23 16:44	303982			0.8			4.93			0.57			5.79			1		
02/04/23 16:45	305368.3			0.8			5.02			0.57			5.92			1		
02/04/23 16:46	305753.4			0.8			5.11			0.57			6.03			1		
02/04/23 16:47	304367.1			0.7			5.2			0.5			6.11			1		
02/04/23 16:48	306600.6			0.7			5.28			0.51			6.26			1		
02/04/23 16:49	306908.7			0.7			5.37			0.51			6.37			1		
02/04/23 16:50	305599.4			0.7			5.46			0.51			6.45			1		
02/04/23 16:51	305291.3			0.7			5.2			0.5			6.13			1		
02/04/23 16:52	289195			0.7			3.26			0.48			3.64			1		
02/04/23 16:53	282186.5			0.7			2.15			0.47			2.34			1		
02/04/23 16:54	281185.3			0.6			2.81			0.42			3.06			1		
02/04/23 16:55	275717.2			0.6			3.45			0.41			3.67			1		
02/04/23 16:56	270788.2			0.5			4.18			0.35			4.37			1		
02/04/23 16:57	270480.1			0.6			3.87			0.35			4.05			1		
02/04/23 16:58	270634.1			0.6			2.67			0.35			2.8			1		
02/04/23 16:59	270403.1			0.6			1.94			0.35			2.02			1		
02/04/23 17:00	271481.3			0.5			1.84			0.29			1.93			1		
02/04/23 17:01	271866.4			0.5			1.84			0.29			1.94			1		
02/04/23 17:02	271327.3			0.5			1.94			0.29			2.03			1		
02/04/23 17:03	271943.4			0.5			2.03			0.29			2.13			0		
02/04/23 17:04	271250.3			0.6			2.12			0.35			2.22			0		
02/04/23 17:05	270865.2			0.6			2.12			0.35			2.22			0		
02/04/23 17:06	270403.1			0.6			2.12			0.35			2.22			0		
02/04/23 17:07	270018			0.6			2.03			0.35			2.12			0		

CT1 SUSD EVENT 30

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 23:01	296049.4			0.5			1.52			0.37			1.74			0		
02/04/23 23:02	296357.5			0.5			1.52			0.37			1.74			0		
02/04/23 23:03	287038.5			0.5			1.43			0.36			1.59			0		
02/04/23 23:04	271558.3			0.5			1.43			0.34			1.5			0		
02/04/23 23:05	268708.7			0.6			1.84			0.35			1.91			0		
02/04/23 23:06	264241.8			0.5			2.12			0.29			2.17			1		
02/04/23 23:07	243293.5			0.4			1.97			0.21			1.85			1		
02/04/23 23:08	222576.2			0.3			4.52			0.15			3.89			1		
02/04/23 23:09	197623			0.3			9.98			0.15			7.62			1		
02/04/23 23:10	175673.4			5.2			14.99			2.14			10.17			1		
02/04/23 23:11	156727.5			346.8			18.1			127.61			10.96			1		
02/04/23 23:12	138628.8			1352.3			20.27			440.14			10.86			1		
02/04/23 23:13	25492.3			1836.1			22.91			109.74			2.25			1		
02/04/23 23:14	24953.2			0			23.6			269.61			2.28			0		
02/04/23 23:15	24568.1			0			2.95			26.24			0.28			0		
02/04/23 23:16	24491.1			0			2.95			5.26			0.28			0		
02/04/23 23:17	24645.1			0			5.9			9.58			0.56			0		
02/04/23 23:18	24722.1			0			5.9			8.89			0.56			0		

CT1 SUSD EVENT 31

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 17:52	17636.7			0			0			0			0			0		
02/05/23 17:53	17559.6			0			0			0			0			0		
02/05/23 17:54	17251.6			0			0			0			0			0		
02/05/23 17:55	17251.6			0			0			0			0			0		
02/05/23 17:56	17482.6			0			0			0			0			0		
02/05/23 17:57	22257.6			0			0			0			0			1		
02/05/23 17:58	30575.3			0			0			0			0			1		
02/05/23 17:59	38431			27.5			17.7			2.48			2.63			1		
02/05/23 18:00	53218			1137.9			12.98			142.13			2.67			1		
02/05/23 18:01	60919.6			848.9			18.36			121.43			4.32			1		
02/05/23 18:02	81559.9			478.7			23.6			91.73			7.44			1		
02/05/23 18:03	120530			358			25.75			101.3			11.99			1		
02/05/23 18:04	143326.7			244.5			42.48			82.31			23.54			1		
02/05/23 18:05	147562.6			336.5			55.76			116.6			31.8			1		
02/05/23 18:06	160347.3			1908.5			50.7			718.56			31.42			1		
02/05/23 18:07	177829.9			1807			53.1			754.36			36.48			1		
02/05/23 18:08	199856.5			1492.7			52.95			700.68			40.9			1		
02/05/23 18:09	222422.1			257.1			53.92			134.28			46.35			1		
02/05/23 18:10	242061.2			28.2			50.57			16.01			47.3			1		
02/05/23 18:11	266013.2			3			49.49			1.84			50.87			1		
02/05/23 18:12	291813.5			1.9			37.6			1.3			42.4			1		
02/05/23 18:13	308294.9			1.7			16.88			1.25			20.11			1		
02/05/23 18:14	311144.5			1.7			12.74			1.25			15.32			1		
02/05/23 18:15	311144.5			1.8			10			1.31			12.03			1		
02/05/23 18:16	311067.5			1.7			8.89			1.25			10.69			1		
02/05/23 18:17	310913.5			1.6			8.07			1.14			9.69			1		
02/05/23 18:18	309989.3			1.4			7.64			1.01			9.15			1		
02/05/23 18:19	308140.9			1.2			6.94			0.88			8.26			1		
02/05/23 18:20	307601.8			1.1			6.77			0.81			8.05			1		
02/05/23 18:21	306908.7			1.1			6.69			0.76			7.94			1		
02/05/23 18:22	306831.6			1.5	X		6.3	X		1.06	X		7.47	X		1		
02/05/23 18:23	306061.5			0.9	X		6.51	X		0.66	X		7.7	X		1		
02/05/23 18:24	305753.4			0.9	X		5.99	X		0.63	X		7.07	X		1		
02/05/23 18:25	305368.3			0.8	X		5.99	X		0.57	X		7.07	X		1		
02/05/23 18:26	303828			0.8	X		5.99	X		0.57	X		7.03	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 18:27	303211.9			0.8	X		5.9	X		0.56	X		6.91	X		1		
02/05/23 18:28	302980.8			0.8	X		5.99	X		0.57	X		7.01	X		1		
02/05/23 18:29	304136.1			0.7	X		5.9	X		0.51	X		6.93	X		1		
02/05/23 18:30	305137.3			0.7			5.9			0.51			6.96			1		
02/05/23 18:31	304444.1			0.7			5.9			0.51			6.94			1		
02/05/23 18:32	304290.1			0.7			5.9			0.51			6.94			1		
02/05/23 18:33	303905			0.7			5.99			0.51			7.03			1		
02/05/23 18:34	304367.1			0.6			6.08			0.45			7.15			1		
02/05/23 18:35	304444.1			0.6			6.17			0.45			7.26			1		
02/05/23 18:36	305753.4			0.6			6.17			0.45			7.29			1		
02/05/23 18:37	306600.6			0.6			6.26			0.45			7.41			1		
02/05/23 18:38	306369.5			0.6			6.35			0.45			7.52			1		
02/05/23 18:39	293970			0.6			6.53			0.43			7.41			1		
02/05/23 18:40	281108.3			0.6			6.62			0.41			7.19			1		
02/05/23 18:41	280492.2			0.5			7.9			0.36			8.56			1		
02/05/23 18:42	275563.2			0.6			8.48			0.36			9.03			1		
02/05/23 18:43	276102.3			0.5			8.67			0.3			9.25			1		
02/05/23 18:44	280107.1			0.5			9.86			0.3			10.68			1		
02/05/23 18:45	273252.7			0.5			5.35			0.3			5.65			1		
02/05/23 18:46	272790.6			0.5			2.86			0.3			3.01			1		
02/05/23 18:47	273175.7			0.5			3.13			0.3			3.31			1		
02/05/23 18:48	271635.3			0.5			3.96			0.29			4.16			1		
02/05/23 18:49	272482.5			0.5			4.98			0.29			5.24			1		
02/05/23 18:50	274484.9			0.5			4.61			0.3			4.89			1		
02/05/23 18:51	274330.9			0.5			3.13			0.3			3.32			1		
02/05/23 18:52	275178.1			0.5			2.3			0.3			2.45			1		
02/05/23 18:53	282879.7			0.5			2.03			0.31			2.22			1		
02/05/23 18:54	304213.1			0.5			1.38			0.33			1.63			1		
02/05/23 18:55	320463.5			0.5			1.18			0.34			1.46			1		
02/05/23 18:56	324853.4			0.5			0.97			0.4			1.22			1		
02/05/23 18:57	320848.5			0.7			0.87			0.52			1.08			0		
02/05/23 18:58	319462.3			0.7			0.78			0.52			0.96			0		
02/05/23 18:59	317690.9			0.7			0.79			0.53			0.97			0		
02/05/23 19:00	317690.9			0.7			0.7			0.53			0.87			0		
02/05/23 19:01	318076			0.7			0.7			0.53			0.87			0		

CT1 SUSD EVENT 32

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 22:17	267707.5			0.4			1.69			0.24			1.74			0		
02/05/23 22:18	267014.4			0.4			1.59			0.23			1.64			0		
02/05/23 22:19	266475.3			0.4			1.62			0.24			1.67			0		
02/05/23 22:20	267784.5			0.5			1.62			0.3			1.67			0		
02/05/23 22:21	267553.5			0.5			1.52			0.3			1.57			0		
02/05/23 22:22	266629.3			0.4			1.5			0.23			1.54			1		
02/05/23 22:23	258080.5			0.4			1.5			0.23			1.49			1		
02/05/23 22:24	236208			0.4			1.81			0.21			1.65			1		
02/05/23 22:25	213950.4			0.4			5.59			0.2			4.63			1		
02/05/23 22:26	188381.1			1.6			8.68			0.69			6.32			1		
02/05/23 22:27	168202.9			72			10.82			28.44			7.03			1		
02/05/23 22:28	150489.2			636.2			12.78			224.87			7.44			1		
02/05/23 22:29	90339.7			1620.3			14.51			343.83			5.07			1		
02/05/23 22:30	0			0			16.18			0			0			0		
02/05/23 22:31	0			0			11.8			0			0			0		
02/05/23 22:32	0			0			2.95			0			0			0		
02/05/23 22:33	0			0			5.9			0			0			0		
02/05/23 22:34	0			0			5.9			0			0			0		

CT1 SUSD EVENT 33

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 15:49	21564.5			0			0			0			0			0		
02/06/23 15:50	21333.4			0			0			0			0			0		
02/06/23 15:51	21487.5			0			0			0			0			0		
02/06/23 15:52	21641.5			0			0			0			0			0		
02/06/23 15:53	21718.5			0			0			0			0			0		
02/06/23 15:54	26647.5			0			0			0			0			1		
02/06/23 15:55	31422.5			0			0			0			0			1		
02/06/23 15:56	40125.3			31.5			19.67			2.97			3.05			1		
02/06/23 15:57	51523.7			1034.1			12.98			125			2.58			1		
02/06/23 15:58	63307.1			811.6			19.01			120.63			4.65			1		
02/06/23 15:59	79480.5			452.3			23.88			84.45			7.34			1		
02/06/23 16:00	122301.4			323.7			22.8			92.96			10.77			1		
02/06/23 16:01	143865.8			214.1			41.77			72.3			23.22			1		
02/06/23 16:02	149257			184.4			55.76			64.65			32.17			1		
02/06/23 16:03	167586.8			1725.3			48.99			678.94			31.73			1		
02/06/23 16:04	187919			1694.6			51.46			747.66			37.37			1		
02/06/23 16:05	209868.5			842.8			52.07			415.43			42.24			1		
02/06/23 16:06	232511.2			81.6			51.3			44.54			46.1			1		
02/06/23 16:07	254691.8			5.6			48.13			3.32			47.37			1		
02/06/23 16:08	279722			1.9			43.83			1.25			47.37			1		
02/06/23 16:09	303134.9			1.6			21.03			1.15			24.64			1		
02/06/23 16:10	314764.3			1.6			12.93			1.15			15.73			1		
02/06/23 16:11	315611.5			1.6			8.98			1.2			10.95			1		
02/06/23 16:12	316073.6			1.6			7.7			1.21			9.4			1		
02/06/23 16:13	313146.9			1.6			6.94			1.15			8.4			1		
02/06/23 16:14	311221.5			1.4			6.07			1.01			7.31			1		
02/06/23 16:15	311221.5			1.2			5.55			0.89			6.68			1		
02/06/23 16:16	310451.4			1.1			5.2			0.83			6.23			1		
02/06/23 16:17	308063.9			1.1			4.84			0.76			5.77			1		
02/06/23 16:18	307370.8			1			4.76			0.7			5.65			1		
02/06/23 16:19	305984.5			0.9			4.67			0.63			5.52			1		
02/06/23 16:20	305907.4			0.9			4.56			0.64			5.39			1		
02/06/23 16:21	307755.8			0.8			4.38			0.58			5.21			1		
02/06/23 16:22	307986.9			0.8			4.38			0.58			5.21			1		
02/06/23 16:23	307139.7			0.8			4.38			0.58			5.2			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 16:24	306754.6			0.8			4.47			0.58			5.3			1		
02/06/23 16:25	307216.7			0.7			4.47			0.52			5.31			1		
02/06/23 16:26	304444.1			0.7			4.47			0.51			5.26			1		
02/06/23 16:27	303905			0.7			4.47			0.51			5.25			1		
02/06/23 16:28	303905			0.7			4.47			0.51			5.25			1		
02/06/23 16:29	304752.2			0.6			4.47			0.45			5.26			1		
02/06/23 16:30	306600.6			0.6			4.47			0.45			5.3			1		
02/06/23 16:31	306831.6			0.6			4.56			0.45			5.41			1		
02/06/23 16:32	290042.2			0.6			4.74			0.43			5.31			1		
02/06/23 16:33	278489.8			0.6			4.99			0.42			5.37			1		
02/06/23 16:34	276949.4			0.6			6.27			0.36			6.71			1		
02/06/23 16:35	271481.3			0.6			6.64			0.35			6.96			1		
02/06/23 16:36	270788.2			0.5			4.59			0.3			4.8			1		
02/06/23 16:37	270865.2			0.5			2.9			0.3			3.04			1		
02/06/23 16:38	270095			0.5			2.25			0.3			2.35			1		
02/06/23 16:39	268862.8			0.5			2.34			0.3			2.43			1		
02/06/23 16:40	270634.1			0.5			2.62			0.3			2.74			1		
02/06/23 16:41	270249			0.5			3.28			0.3			3.42			1		
02/06/23 16:42	269709.9			0.5			3.37			0.3			3.51			1		
02/06/23 16:43	270634.1			0.5			2.72			0.3			2.84			1		
02/06/23 16:44	271019.2			0.5			2.34			0.3			2.45			1		
02/06/23 16:45	274716			0.4			2.15			0.24			2.29			1		
02/06/23 16:46	271943.4			0.5			1.97			0.3			2.07			1		
02/06/23 16:47	270711.2			0.5			1.87			0.3			1.96			1		
02/06/23 16:48	269941			0.5			1.69			0.3			1.76			1		
02/06/23 16:49	269247.8			0.5			1.59			0.3			1.66			1		
02/06/23 16:50	269941			0.4			1.59			0.24			1.66			0		
02/06/23 16:51	270095			0.4			1.59			0.24			1.66			0		
02/06/23 16:52	269632.9			0.4			1.59			0.24			1.66			0		
02/06/23 16:53	285575.2			0.4			1.5			0.25			1.65			0		
02/06/23 16:54	305214.3			0.4			1.5			0.27			1.77			0		

CT1 SUSD EVENT 34

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 23:19	271327.3			0.4			1.78			0.24			1.87			0		
02/06/23 23:20	271096.2			0.4			1.59			0.24			1.67			0		
02/06/23 23:21	272944.6			0.4			1.5			0.24			1.58			0		
02/06/23 23:22	273714.8			0.4			1.4			0.24			1.49			0		
02/06/23 23:23	272713.6			0.5			1.38			0.3			1.46			0		
02/06/23 23:24	267553.5			0.5			1.38			0.29			1.43			1		
02/06/23 23:25	244756.8			0.5			1.59			0.27			1.51			1		
02/06/23 23:26	223346.3			0.4			4.62			0.21			3.99			1		
02/06/23 23:27	198932.3			0.3			9.65			0.15			7.42			1		
02/06/23 23:28	176366.6			4.8			13.12			1.99			8.94			1		
02/06/23 23:29	157574.7			326.5			15.55			120.82			9.47			1		
02/06/23 23:30	139244.9			1263.7			17.7			413.27			9.53			1		
02/06/23 23:31	10089.1			1792.7			19.96			42.54			0.78			1		
02/06/23 23:32	0			0			19.67			0			0			0		
02/06/23 23:33	0			0			2.95			0			0			0		
02/06/23 23:34	0			0			5.9			0			0			0		
02/06/23 23:35	0			0			5.9			0			0			0		
02/06/23 23:36	0			0			5.9			0			0			0		

CT1 SUSD EVENT 35

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 15:46	20640.3			0			0			0.29			0			0		
02/07/23 15:47	20486.2			0			0			0.28			0			0		
02/07/23 15:48	20486.2			0			0			0.57			0			0		
02/07/23 15:49	20486.2			0			0			0.57			0			0		
02/07/23 15:50	20486.2			0			0			0.57			0			0		
02/07/23 15:51	22411.6			11.8			0			0.62			0			1		
02/07/23 15:52	30113.2			11.8			0			0.83			0			1		
02/07/23 15:53	37737.8			38.4			8.85			3.4			1.29			1		
02/07/23 15:54	46748.7			1094			15.73			119.99			2.84			1		
02/07/23 15:55	62460			939.7			17.04			137.78			4.11			1		
02/07/23 15:56	72703.1			566.1			23.6			96.69			6.63			1		
02/07/23 15:57	107591.3			380			25.21			96.04			10.48			1		
02/07/23 15:58	143711.8			253.9			40.81			85.72			22.67			1		
02/07/23 15:59	146253.3			156.7			55.85			53.82			31.56			1		
02/07/23 16:00	159577.1			1493.3			51.63			559.55			31.84			1		
02/07/23 16:01	178831.1			1793.6			51.36			753.2			35.5			1		
02/07/23 16:02	198470.2			1529.2			52.63			712.67			40.37			1		
02/07/23 16:03	222114.1			273			51.73			142.41			44.4			1		
02/07/23 16:04	245141.8			24.8			49.25			14.28			46.66			1		
02/07/23 16:05	262855.5			2.8			45.56			1.75			46.28			1		
02/07/23 16:06	289965.1			1.9			33.9			1.29			37.99			1		
02/07/23 16:07	308449			1.8			15.02			1.3			17.9			1		
02/07/23 16:08	313686.1			1.8			10.77			1.32			13.06			1		
02/07/23 16:09	316689.7			1.8			8.38			1.34			10.26			1		
02/07/23 16:10	315303.4			1.7			7.35			1.27			8.96			1		
02/07/23 16:11	315688.5			1.6			6.77			1.16			8.26			1		
02/07/23 16:12	314764.3			1.4			6.25			1.03			7.6			1		
02/07/23 16:13	314533.2			1.3			5.81			0.96			7.07			1		
02/07/23 16:14	311298.6			1.1			5.47			0.82			6.58			1		
02/07/23 16:15	304829.2			1.1			5.38			0.81			6.34			1		
02/07/23 16:16	308140.9			1.1			4.76			0.76			5.66			1		
02/07/23 16:17	307601.8			1			4.76			0.7			5.65			1		
02/07/23 16:18	308294.9			1			4.84			0.7			5.77			1		
02/07/23 16:19	304367.1			0.9			4.84			0.63			5.7			1		
02/07/23 16:20	304059.1			0.9			4.84			0.63			5.69			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 16:21	303905			0.9			4.83			0.64			5.67			1		
02/07/23 16:22	303674			0.8			4.83			0.57			5.66			1		
02/07/23 16:23	303674			0.8			4.74			0.57			5.56			1		
02/07/23 16:24	303905			0.8			4.74			0.57			5.56			1		
02/07/23 16:25	303211.9			0.8			4.74			0.57			5.55			1		
02/07/23 16:26	303597			0.7			4.74			0.51			5.56			1		
02/07/23 16:27	303905			0.7			4.83			0.51			5.67			1		
02/07/23 16:28	304136.1			0.7			4.83			0.51			5.67			1		
02/07/23 16:29	288963.9			0.7			5.01			0.49			5.59			1		
02/07/23 16:30	284034.9			0.7			5.36			0.48			5.89			1		
02/07/23 16:31	278643.8			0.7			6.35			0.48			6.84			1		
02/07/23 16:32	274484.9			0.6			6.91			0.42			7.33			1		
02/07/23 16:33	271250.3			0.6			7.65			0.35			8.02			1		
02/07/23 16:34	270942.2			0.6			4.89			0.35			5.12			1		
02/07/23 16:35	271404.3			0.6			3			0.36			3.14			1		
02/07/23 16:36	270480.1			0.6			3.28			0.36			3.43			1		
02/07/23 16:37	269941			0.6			4.21			0.36			4.4			1		
02/07/23 16:38	270788.2			0.6			5.15			0.36			5.39			1		
02/07/23 16:39	270865.2			0.6			4.68			0.36			4.9			1		
02/07/23 16:40	269941			0.6			3.18			0.36			3.32			1		
02/07/23 16:41	270172			0.6			2.25			0.36			2.35			1		
02/07/23 16:42	270634.1			0.6			2.06			0.36			2.15			1		
02/07/23 16:43	271019.2			0.6			1.59			0.36			1.67			1		
02/07/23 16:44	289195			0.6			1.22			0.38			1.36			1		
02/07/23 16:45	307909.8			0.6			1.2			0.4			1.43			1		
02/07/23 16:46	325238.4			0.6			1			0.49			1.26			0		
02/07/23 16:47	326393.7			0.7			0.7			0.54			0.89			0		
02/07/23 16:48	331168.7			0.8			0.62			0.62			0.79			0		
02/07/23 16:49	341796.9			0.8			0.62			0.64			0.81			0		
02/07/23 16:50	360973.9			0.8			0.54			0.68			0.75			0		

CT1 SUSD EVENT 36

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 8:33	271943.4			0.6			1.78			0.36			1.87			0		
02/11/23 8:34	272713.6			0.6			1.69			0.36			1.78			0		
02/11/23 8:35	269555.9			0.6			1.69			0.36			1.76			0		
02/11/23 8:36	270711.2			0.6			1.59			0.36			1.67			0		
02/11/23 8:37	270326.1			0.5			1.59			0.3			1.66			0		
02/11/23 8:38	267322.4			0.5			1.59			0.29			1.64			1		
02/11/23 8:39	248222.5			0.5			1.59			0.27			1.53			1		
02/11/23 8:40	227582.2			0.5			3.84			0.26			3.37			1		
02/11/23 8:41	202012.9			0.4			8.58			0.2			6.7			1		
02/11/23 8:42	179832.3			4			10.97			1.69			7.62			1		
02/11/23 8:43	161117.4			260.6			13.11			98.6			8.16			1		
02/11/23 8:44	141940.4			1336.7			15.88			445.54			8.71			1		
02/11/23 8:45	29574.1			1783.7			17.7			123.77			2.02			1		
02/11/23 8:46	11860.5			0			22.53			96.76			1.03			0		
02/11/23 8:47	10320.1			0			2.95			15.83			0.12			0		
02/11/23 8:48	12707.6			0			2.95			2.81			0.14			0		
02/11/23 8:49	13015.7			0			2.95			2.53			0.15			0		
02/11/23 8:50	10859.3			0			2.95			2.03			0.12			0		

CT1 SUSD EVENT 37

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 15:56	19716.1			0			0			0.27			0			0		
02/11/23 15:57	19870.1			0			0			0.27			0			0		
02/11/23 15:58	19562.1			0			0			0.27			0			0		
02/11/23 15:59	19716.1			0			0			0.27			0			0		
02/11/23 16:00	19639.1			0			0			0			0			0		
02/11/23 16:01	25723.3			0			0			0			0			1		
02/11/23 16:02	31730.6			0			0			0			0			1		
02/11/23 16:03	43283			26.6			5.9			2.7			0.99			1		
02/11/23 16:04	53911.2			1028.4			5.16			130.3			1.08			1		
02/11/23 16:05	64462.4			640.9			8.07			96.99			2.01			1		
02/11/23 16:06	85025.6			353.4			10.4			70.57			3.42			1		
02/11/23 16:07	129001.8			222.4			13.85			67.36			6.9			1		
02/11/23 16:08	144327.9			160.6			19.01			54.43			10.6			1		
02/11/23 16:09	157343.6			629.3			28.39			232.42			17.26			1		
02/11/23 16:10	176982.7			1853.5			28.63			770.45			19.59			1		
02/11/23 16:11	197700			1367.3			30.41			634.77			23.23			1		
02/11/23 16:12	220342.7			225.3			33.48			116.55			28.5			1		
02/11/23 16:13	240828.9			21.2			34.44			11.98			32.05			1		
02/11/23 16:14	266090.2			2.2			35.07			1.37			36.06			1		
02/11/23 16:15	291967.6			1.5			24.9			1.03			28.1			1		
02/11/23 16:16	304213.1			1.3			12.34			0.96			14.5			1		
02/11/23 16:17	311914.7			1.4			9.15			1			11.03			1		
02/11/23 16:18	313146.9			1.4			7.61			1.01			9.21			1		
02/11/23 16:19	313224			1.3			7.01			0.94			8.49			1		
02/11/23 16:20	309835.3			1.2			6.68			0.88			8			1		
02/11/23 16:21	308140.9			1.1			6.51			0.82			7.75			1		
02/11/23 16:22	307601.8			1			5.99			0.75			7.12			1		
02/11/23 16:23	307755.8			1			5.81			0.69			6.91			1		
02/11/23 16:24	307755.8			0.9			5.9			0.64			7.02			1		
02/11/23 16:25	307986.9			0.9			5.81			0.64			6.92			1		
02/11/23 16:26	306600.6			0.8			5.72			0.57			6.78			1		
02/11/23 16:27	306369.5			0.8			5.72			0.57			6.78			1		
02/11/23 16:28	306677.6			0.8			5.81			0.57			6.89			1		
02/11/23 16:29	306831.6			0.8			5.9			0.57			7			1		
02/11/23 16:30	300131.3			0.8			5.99			0.56			6.94			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 16:31	288886.9			0.8			5.99			0.54			6.68			1		
02/11/23 16:32	286191.3			0.7			6.44			0.49			7.13			1		
02/11/23 16:33	278566.8			0.7			6.72			0.47			7.23			1		
02/11/23 16:34	273791.8			0.6			3.72			0.41			3.94			1		
02/11/23 16:35	271404.3			0.6			2.49			0.41			2.61			1		
02/11/23 16:36	271327.3			0.6			1.84			0.35			1.93			1		
02/11/23 16:37	272097.4			0.6			1.57			0.35			1.65			1		
02/11/23 16:38	270711.2			0.6			1.48			0.35			1.54			1		
02/11/23 16:39	271327.3			0.6			1.29			0.35			1.35			1		
02/11/23 16:40	271327.3			0.6			1.11			0.35			1.16			0		
02/11/23 16:41	270788.2			0.6			0.92			0.35			0.96			0		
02/11/23 16:42	271712.3			0.5			0.83			0.29			0.87			0		
02/11/23 16:43	270480.1			0.5			0.83			0.29			0.87			0		
02/11/23 16:44	271866.4			0.6			0.74			0.35			0.77			0		

CT1 SUSD EVENT 38

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/13/23 0:32	269478.9			0.6			1.66			0.35			1.73			0		
02/13/23 0:33	268785.8			0.6			1.66			0.35			1.72			0		
02/13/23 0:34	269401.9			0.6			1.57			0.35			1.63			0		
02/13/23 0:35	268323.7			0.6			1.48			0.35			1.53			0		
02/13/23 0:36	269709.9			0.6			1.48			0.35			1.54			0		
02/13/23 0:37	265089			0.6			1.48			0.34			1.51			1		
02/13/23 0:38	245372.9			0.6			1.48			0.32			1.4			1		
02/13/23 0:39	224424.5			0.6			3.58			0.31			3.1			1		
02/13/23 0:40	199240.3			0.5			9.06			0.25			6.98			1		
02/13/23 0:41	176905.7			2.7			11.22			1.11			7.67			1		
02/13/23 0:42	159192			220.9			14.68			82.59			9.03			1		
02/13/23 0:43	139475.9			1166.9			16.52			382.14			8.9			1		
02/13/23 0:44	30883.4			1802			18.71			130.69			2.23			1		
02/13/23 0:45	20024.2			0			19.06			134.56			1.47			0		
02/13/23 0:46	19100			0			2.95			29.98			0.22			0		
02/13/23 0:47	20178.2			0			2.95			4.34			0.23			0		
02/13/23 0:48	19947.1			0			2.95			3.59			0.23			0		
02/13/23 0:49	19562.1			0			2.95			3.52			0.22			0		

CT1 SUSD EVENT 39

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 15:29	0			0			0			0			0			0		
02/14/23 15:30	0			0			0			0			0			0		
02/14/23 15:31	0			0			0			0			0			0		
02/14/23 15:32	0			0			0			0			0			0		
02/14/23 15:33	19254			0			0			0			0			0		
02/14/23 15:34	29035			0.1			0			0			0			1		
02/14/23 15:35	37583.8			0.1			0			0			0			1		
02/14/23 15:36	45901.5			51.6			16.23			5.56			2.88			1		
02/14/23 15:37	55143.4			1148.9			11.8			148.65			2.51			1		
02/14/23 15:38	66849.9			739.5			16.39			116.03			4.23			1		
02/14/23 15:39	90955.9			467.9			20.36			99.91			7.15			1		
02/14/23 15:40	134084.8			332.5			23.33			104.66			12.09			1		
02/14/23 15:41	143942.9			215.4			41.75			72.79			23.23			1		
02/14/23 15:42	158113.8			727.5			47.57			270.18			29.07			1		
02/14/23 15:43	174133.1			1900.7			49.52			777.32			33.33			1		
02/14/23 15:44	196390.7			1624.6			58.68			749.13			44.53			1		
02/14/23 15:45	220573.8			391.8			64.06			202.94			54.61			1		
02/14/23 15:46	239057.6			50.2			65.28			28.19			60.31			1		
02/14/23 15:47	265474.1			3.2			59.56			2.01			61.1			1		
02/14/23 15:48	290735.3			1.8			47.91			1.25			53.83			1		
02/14/23 15:49	297820.8			1.7			21.39			1.16			24.61			1		
02/14/23 15:50	296973.6			1.6			17.01			1.15			19.52			1		
02/14/23 15:51	296742.5			1.8			13.62			1.27			15.62			1		
02/14/23 15:52	295510.3			1.8			12.15			1.22			13.88			1		
02/14/23 15:53	297897.8			1.7			10.66			1.17			12.27			1		
02/14/23 15:54	310759.4			1.5			8.89			1.09			10.68			1		
02/14/23 15:55	312222.8			1.4			7.31			1.03			8.82			1		
02/14/23 15:56	311991.7			1.3			6.52			0.97			7.86			1		
02/14/23 15:57	310143.3			1.2			6.08			0.9			7.28			1		
02/14/23 15:58	314764.3			1.1			5.64			0.85			6.86			1		
02/14/23 15:59	319000.2			1.1			5.37			0.79			6.62			1		
02/14/23 16:00	321772.7			1.1			5.46			0.8			6.79			1		
02/14/23 16:01	323082			1.1			5.55			0.8			6.93			1		
02/14/23 16:02	321849.8			1			5.64			0.73			7.01			1		
02/14/23 16:03	320155.4			1			5.64			0.73			6.97			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 16:04	320232.4			1			5.64			0.73			6.97			1		
02/14/23 16:05	320001.4			1			5.64			0.73			6.97			1		
02/14/23 16:06	317998.9			0.9			5.55			0.66			6.82			1		
02/14/23 16:07	318230			0.9			5.55			0.66			6.82			1		
02/14/23 16:08	327009.8			0.9			5.46			0.68			6.9			1		
02/14/23 16:09	338639.2			0.9			5.37			0.7			7.03			1		
02/14/23 16:10	345647.7			0.8			4.47			0.65			5.97			1		
02/14/23 16:11	340718.7			0.8			4.02			0.64			5.3			1		
02/14/23 16:12	337330			0.8			4.58			0.63			5.97			1		
02/14/23 16:13	334018.3			0.8			4.67			0.62			6.02			1		
02/14/23 16:14	352194			0.8			4.76			0.66			6.47			1		
02/14/23 16:15	367597.3			0.8			3.84			0.69			5.46			1		
02/14/23 16:16	385079.9			0.7			3.5			0.67			5.21			1		
02/14/23 16:17	385387.9			0.6			4.15			0.58			6.18			1		
02/14/23 16:18	391934.3			0.6			3.63			0.58			5.5			1		
02/14/23 16:19	408723.8			0.7			2.18			0.7			3.44			1		
02/14/23 16:20	424435			0.7			1.48			0.73			2.42			1		
02/14/23 16:21	430596.3			0.7			1.5			0.66			2.49			1		
02/14/23 16:22	429441.1			0.6			2.21			0.65			3.67			1		
02/14/23 16:23	437065.7			0.6			2.58			0.66			4.36			1		
02/14/23 16:24	453701.1			0.6			2.77			0.69			4.85			1		
02/14/23 16:25	453778.1			0.6			3.04			0.69			5.33			1		
02/14/23 16:26	453239			0.6			2.45			0.68			4.29			1		
02/14/23 16:27	451775.7			0.7			1.54			0.77			2.69			1		
02/14/23 16:28	453701.1			0.7			1.45			0.78			2.57			1		
02/14/23 16:29	452160.8			0.9			1.54			0.99			2.78			1		
02/14/23 16:30	452853.9			1.5			1.76			1.65			3.19			0		
02/14/23 16:31	453162			1.9			2.26			2.1			4.08			0		
02/14/23 16:32	453932.1			1.8			2.26			2.01			4.09			0		
02/14/23 16:33	453162			1.6			1.91			1.82			3.46			0		
02/14/23 16:34	454086.2			1.6			1.39			1.72			2.51			0		

CT1 SUSD EVENT 40

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 8:31	270172			0.6			1.52			0.36			1.59			0		
02/15/23 8:32	270095			0.4			1.71			0.24			1.79			0		
02/15/23 8:33	269478.9			0.4			1.84			0.24			1.91			0		
02/15/23 8:34	269478.9			0.4			1.84			0.24			1.91			0		
02/15/23 8:35	269401.9			0.4			1.74			0.24			1.81			0		
02/15/23 8:36	267861.6			0.4			1.62			0.24			1.67			1		
02/15/23 8:37	248145.5			0.4			1.64			0.23			1.58			1		
02/15/23 8:38	228044.3			0.4			3.7			0.21			3.26			1		
02/15/23 8:39	204169.3			0.3			7.21			0.16			5.69			1		
02/15/23 8:40	180833.5			4.8			9.68			2.05			6.76			1		
02/15/23 8:41	162426.7			331.3			11.93			126.38			7.49			1		
02/15/23 8:42	143865.8			1323.9			13.77			447.18			7.65			1		
02/15/23 8:43	36197.5			1751.3			15.51			148.97			2.17			1		
02/15/23 8:44	0			0			16.91			0			0			0		
02/15/23 8:45	0			0			2.95			0			0			0		
02/15/23 8:46	0			0			5.9			0			0			0		
02/15/23 8:47	0			0			5.9			0			0			0		
02/15/23 8:48	0			0			5.9			0			0			0		

CT1 SUSD EVENT 41

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 16:11	22257.6			0			0			0			0			0		
02/15/23 16:12	22180.6			0			0			0			0			0		
02/15/23 16:13	22334.6			0			0			0			0			0		
02/15/23 16:14	22411.6			0			0			0			0			0		
02/15/23 16:15	22411.6			0			0			0			0			0		
02/15/23 16:16	25569.3			0			0			0			0			1		
02/15/23 16:17	30960.4			0			0			0			0			1		
02/15/23 16:18	40125.3			38.4			8.85			3.61			1.37			1		
02/15/23 16:19	50214.4			976.9			5.06			115.24			0.98			1		
02/15/23 16:20	61304.7			842			7.29			121.19			1.73			1		
02/15/23 16:21	75783.7			441.3			9.44			78.54			2.76			1		
02/15/23 16:22	111365.1			273.6			12.92			71.55			5.56			1		
02/15/23 16:23	144713			182.9			18.93			62.15			10.59			1		
02/15/23 16:24	148640.8			135.7			19.27			47.36			11.07			1		
02/15/23 16:25	163350.9			1682.6			28.76			645.57			18.16			1		
02/15/23 16:26	181526.6			1808			31.76			770.58			22.27			1		
02/15/23 16:27	203630.2			1157.8			32.22			553.57			25.36			1		
02/15/23 16:28	227274.1			140.4			34.73			74.92			30.5			1		
02/15/23 16:29	246682.2			12			37.21			6.98			35.47			1		
02/15/23 16:30	273406.7			2			37.59			1.26			39.71			1		
02/15/23 16:31	297666.7			1.5			23.9			1.03			27.49			1		
02/15/23 16:32	314379.2			1.3			12.96			0.99			15.75			1		
02/15/23 16:33	314841.3			1.4			8.98			1.01			10.92			1		
02/15/23 16:34	315765.5			1.4			8.24			1.03			10.06			1		
02/15/23 16:35	314841.3			1.3			7.38			0.96			8.97			1		
02/15/23 16:36	313146.9			1.2			7.2			0.89			8.72			1		
02/15/23 16:37	312145.8			1.1			6.6			0.84			7.97			1		
02/15/23 16:38	311683.6			1.1			6.43			0.77			7.74			1		
02/15/23 16:39	310836.5			1			6.34			0.71			7.62			1		
02/15/23 16:40	311067.5			0.9			6.16			0.64			7.41			1		
02/15/23 16:41	310374.4			0.9			6.17			0.65			7.4			1		
02/15/23 16:42	310528.4			0.8			6.08			0.59			7.29			1		
02/15/23 16:43	309912.3			0.8			6.08			0.59			7.28			1		
02/15/23 16:44	310297.3			0.7			6.17			0.52			7.4			1		
02/15/23 16:45	311221.5			0.7			6.17			0.52			7.42			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 16:46	311529.6			0.7			6.26			0.52			7.53			1		
02/15/23 16:47	311452.6			0.7			6.35			0.52			7.64			1		
02/15/23 16:48	311760.7			0.7			6.44			0.52			7.75			1		
02/15/23 16:49	314610.3			0.7			6.53			0.53			7.93			1		
02/15/23 16:50	299361.1			0.7			6.53			0.5			7.55			1		
02/15/23 16:51	289580.1			0.7			4.02			0.49			4.5			1		
02/15/23 16:52	285190.2			0.6			2.72			0.43			3			1		
02/15/23 16:53	280184.1			0.6			3.13			0.36			3.39			1		
02/15/23 16:54	274176.9			0.6			4.43			0.36			4.69			1		
02/15/23 16:55	272944.6			0.6			5.71			0.36			6.03			1		
02/15/23 16:56	272328.5			0.5			4.12			0.3			4.34			1		
02/15/23 16:57	271943.4			0.5			2.81			0.3			2.95			1		
02/15/23 16:58	272482.5			0.5			2.25			0.3			2.37			1		
02/15/23 16:59	271712.3			0.5			1.69			0.3			1.77			1		
02/15/23 17:00	272328.5			0.5			1.59			0.3			1.68			1		
02/15/23 17:01	271558.3			0.5			1.5			0.3			1.57			1		
02/15/23 17:02	272097.4			0.5			1.4			0.3			1.48			0		
02/15/23 17:03	278566.8			0.4			1.4			0.25			1.51			0		
02/15/23 17:04	295818.3			0.5			1.31			0.33			1.5			0		
02/15/23 17:05	300285.3			0.5			1.29			0.33			1.5			0		
02/15/23 17:06	295125.2			0.5			1.09			0.38			1.24			0		

CT1 SUSD EVENT 42

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 8:48	270403.1			0.5			1.62			0.3			1.69			0		
02/16/23 8:49	270018			0.5			1.62			0.3			1.69			0		
02/16/23 8:50	269941			0.5			1.71			0.3			1.79			0		
02/16/23 8:51	270326.1			0.5			1.71			0.3			1.79			0		
02/16/23 8:52	270172			0.5			1.71			0.3			1.79			0		
02/16/23 8:53	262470.4			0.5			1.71			0.29			1.74			1		
02/16/23 8:54	239904.8			0.5			1.93			0.27			1.79			1		
02/16/23 8:55	219649.5			0.4			6			0.21			5.09			1		
02/16/23 8:56	193849.2			0.8			9.8			0.35			7.34			1		
02/16/23 8:57	172900.9			9.2			11.55			3.74			7.72			1		
02/16/23 8:58	155110.2			603.2			15.31			219.69			9.18			1		
02/16/23 8:59	112289.3			1601.6			17.54			422.33			7.61			1		
02/16/23 9:00	4158.9			0			19.41			19.4			0.31			0		
02/16/23 9:01	1925.4			0			15.73			26.98			0.12			0		
02/16/23 9:02	1155.2			0			2.95			0.58			0.01			0		
02/16/23 9:03	7393.5			0			5.9			2.99			0.17			0		
02/16/23 9:04	4621			0			5.9			1.71			0.1			0		

CT1 SUSD EVENT 43

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 16:08	25338.3			0			0			0			0			0		
02/16/23 16:09	25184.2			0			0			0			0			0		
02/16/23 16:10	25030.2			0			0			0			0			0		
02/16/23 16:11	25107.2			0			0			0			0			0		
02/16/23 16:12	25646.3			0			0			0			0			0		
02/16/23 16:13	32577.8			0.1			0			0			0			1		
02/16/23 16:14	38970.1			0.3			0			0			0			1		
02/16/23 16:15	45131.4			36.7			6.56			3.89			1.14			1		
02/16/23 16:16	59841.4			944			6.27			132.7			1.45			1		
02/16/23 16:17	69160.3			512.4			9.01			83.15			2.41			1		
02/16/23 16:18	94190.5			280.7			11.52			62.07			4.19			1		
02/16/23 16:19	141401.3			189.3			16.16			62.85			8.83			1		
02/16/23 16:20	143788.8			133.2			19.81			44.95			11			1		
02/16/23 16:21	141093.3			921.7			29.68			305.35			16.18			1		
02/16/23 16:22	156573.5			1987			31.21			730.32			18.88			1		
02/16/23 16:23	174980.3			1924.9			36.88			791.09			24.94			1		
02/16/23 16:24	194003.2			1664.8			36.2			758.34			27.14			1		
02/16/23 16:25	217262.1			385.4			38.42			196.6			32.26			1		
02/16/23 16:26	239596.7			39.8			39.42			22.38			36.49			1		
02/16/23 16:27	263317.6			3.2			40.85			1.96			41.56			1		
02/16/23 16:28	289580.1			1.9			33.23			1.27			37.19			1		
02/16/23 16:29	309296.2			1.7			14.84			1.21			17.74			1		
02/16/23 16:30	313146.9			1.6			10.93			1.15			13.23			1		
02/16/23 16:31	313455			1.6			8.5			1.15			10.3			1		
02/16/23 16:32	313301			1.5			8.16			1.09			9.88			1		
02/16/23 16:33	313224			1.3			7.38			0.96			8.93			1		
02/16/23 16:34	311452.6			1.2			7.22			0.9			8.69			1		
02/16/23 16:35	309989.3			1.1			7.04			0.77			8.44			1		
02/16/23 16:36	306908.7			1.1			6.78			0.76			8.04			1		
02/16/23 16:37	307062.7			1			6.52			0.7			7.73			1		
02/16/23 16:38	309604.2			0.8			6.44			0.58			7.7			1		
02/16/23 16:39	311529.6			0.9			6.35			0.65			7.64			1		
02/16/23 16:40	311606.6			0.8			6.44			0.59			7.75			1		
02/16/23 16:41	310297.3			0.8			6.53			0.59			7.83			1		
02/16/23 16:42	307755.8			0.8			6.7			0.58			7.97			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 16:43	306908.7			0.8			6.7			0.58			7.95			1		
02/16/23 16:44	306369.5			0.7			6.62			0.51			7.83			1		
02/16/23 16:45	290658.3			0.7			6.62			0.49			7.43			1		
02/16/23 16:46	289734.1			0.7			7.08			0.49			7.93			1		
02/16/23 16:47	282725.6			0.6			6.17			0.42			6.74			1		
02/16/23 16:48	277334.5			0.6			3.04			0.42			3.26			1		
02/16/23 16:49	274176.9			0.6			2.21			0.36			2.34			1		
02/16/23 16:50	274484.9			0.6			2.06			0.36			2.19			1		
02/16/23 16:51	273175.7			0.6			1.78			0.36			1.88			1		
02/16/23 16:52	273791.8			0.5			1.5			0.3			1.59			1		
02/16/23 16:53	273637.8			0.5			1.31			0.3			1.39			1		
02/16/23 16:54	273175.7			0.5			1.22			0.3			1.29			1		
02/16/23 16:55	273791.8			0.5			1.03			0.3			1.09			0		
02/16/23 16:56	272790.6			0.5			0.94			0.3			0.99			0		
02/16/23 16:57	273175.7			0.5			0.94			0.3			0.99			0		
02/16/23 16:58	274484.9			0.5			0.84			0.3			0.89			0		
02/16/23 16:59	290196.2			0.5			0.84			0.32			0.95			0		

CT1 SUSD EVENT 44

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 3:48	269632.9			0.7			1.71			0.42			1.78			0		
02/17/23 3:49	269478.9			0.7			1.71			0.42			1.78			0		
02/17/23 3:50	270172			0.7			1.62			0.42			1.69			0		
02/17/23 3:51	269170.8			0.7			1.62			0.42			1.68			0		
02/17/23 3:52	269555.9			0.7			1.52			0.42			1.59			0		
02/17/23 3:53	261931.3			0.7			1.52			0.41			1.54			1		
02/17/23 3:54	238672.5			0.7			1.81			0.37			1.67			1		
02/17/23 3:55	217185			0.6			5.49			0.31			4.61			1		
02/17/23 3:56	193233.1			1.7			8.46			0.76			6.32			1		
02/17/23 3:57	169974.3			10.9			10.57			4.37			6.94			1		
02/17/23 3:58	153877.9			615.6			12.5			222.4			7.43			1		
02/17/23 3:59	126691.3			1570.5			13.82			467.21			6.77			1		
02/17/23 4:00	0			1870.1			15.73			0			0			1		
02/17/23 4:01	0			0			12.78			0			0			0		
02/17/23 4:02	0			0			2.95			0			0			0		
02/17/23 4:03	0			0			5.9			0			0			0		
02/17/23 4:04	0			0			5.9			0			0			0		
02/17/23 4:05	0			0			5.9			0			0			0		

CT1 SUSD EVENT 45

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 15:53	30190.3			0			0			1.26			0			0		
02/20/23 15:54	30267.3			0			0			1.26			0			0		
02/20/23 15:55	30344.3			0			0			1.26			0			0		
02/20/23 15:56	30344.3			0			0			1.26			0			0		
02/20/23 15:57	30498.3			0			0			1.27			0			0		
02/20/23 15:58	39817.3			17.7			0			1.66			0			1		
02/20/23 15:59	42666.8			35.4			0			3.55			0			1		
02/20/23 16:00	51446.7			67.4			12.64			8.15			2.52			1		
02/20/23 16:01	62305.9			1040.6			12.91			152.34			3.11			1		
02/20/23 16:02	73242.2			578.5			16.52			99.45			4.67			1		
02/20/23 16:03	101661.1			363.9			21.19			86.84			8.32			1		
02/20/23 16:04	139938			235			23.35			77.23			12.63			1		
02/20/23 16:05	148332.8			152.4			43.94			53.08			25.19			1		
02/20/23 16:06	152029.5			1099.7			41.84			392.64			24.58			1		
02/20/23 16:07	161348.5			1829			37.31			693.14			23.27			1		
02/20/23 16:08	180448.4			1776.7			40.63			752.88			28.33			1		
02/20/23 16:09	202321			1257.9			54.76			597.51			42.81			1		
02/20/23 16:10	223423.3			201.8			66.82			105.9			57.7			1		
02/20/23 16:11	244371.7			18.2			64.78			10.43			61.17			1		
02/20/23 16:12	272174.4			2.7			59.76			1.75			62.86			1		
02/20/23 16:13	295972.4			2.2			36.38			1.5			41.62			1		
02/20/23 16:14	313609			2.1			18.06			1.51			21.89			1		
02/20/23 16:15	315996.5			2.1			12.31			1.52			15.04			1		
02/20/23 16:16	315534.4			2.1			10.18			1.52			12.41			1		
02/20/23 16:17	316689.7			1.9			8.5			1.42			10.41			1		
02/20/23 16:18	315072.3			1.7			7.11			1.28			8.66			1		
02/20/23 16:19	310759.4			1.6			6.25			1.2			7.5			1		
02/20/23 16:20	310605.4			1.6			5.55			1.16			6.66			1		
02/20/23 16:21	311683.6			1.4			4.84			1.03			5.83			1		
02/20/23 16:22	309912.3			1.3			4.67			0.96			5.59			1		
02/20/23 16:23	309912.3			1.2			4.49			0.9			5.38			1		
02/20/23 16:24	311375.6			1.2			4.38			0.85			5.27			1		
02/20/23 16:25	311837.7			1.1			4.2			0.79			5.06			1		
02/20/23 16:26	308063.9			1.1			4.11			0.78			4.9			1		
02/20/23 16:27	305830.4			1.1			4.11			0.77			4.86			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 16:28	305368.3			1			3.93			0.71			4.64			1		
02/20/23 16:29	305522.4			1			3.84			0.71			4.54			1		
02/20/23 16:30	305753.4			1			3.84			0.71			4.54			1		
02/20/23 16:31	306369.5			0.9			3.84			0.64			4.55			1		
02/20/23 16:32	305830.4			0.9			3.75			0.64			4.44			1		
02/20/23 16:33	305753.4			0.9			3.75			0.64			4.44			1		
02/20/23 16:34	307139.7			0.9			3.75			0.64			4.46			1		
02/20/23 16:35	308217.9			0.9			3.84			0.65			4.58			1		
02/20/23 16:36	309450.2			0.9			3.93			0.65			4.7			1		
02/20/23 16:37	298282.9			0.9			4.02			0.63			4.64			1		
02/20/23 16:38	280877.3			0.8			4.11			0.53			4.46			1		
02/20/23 16:39	279413.9			0.8			4.61			0.54			4.98			1		
02/20/23 16:40	276949.4			0.7			5.16			0.48			5.52			1		
02/20/23 16:41	272328.5			0.6			5.35			0.41			5.63			1		
02/20/23 16:42	272482.5			0.7			6.27			0.42			6.61			1		
02/20/23 16:43	272251.5			0.7			6.46			0.42			6.8			1		
02/20/23 16:44	272328.5			0.7			5.53			0.42			5.82			1		
02/20/23 16:45	274330.9			0.6			3.75			0.36			3.97			1		
02/20/23 16:46	273406.7			0.6			3.28			0.36			3.46			1		
02/20/23 16:47	275101.1			0.6			4.03			0.36			4.28			1		
02/20/23 16:48	274253.9			0.6			4.68			0.36			4.96			1		
02/20/23 16:49	276102.3			0.6			4.78			0.36			5.1			1		
02/20/23 16:50	276333.3			0.6			3.47			0.36			3.7			1		
02/20/23 16:51	275255.1			0.7			2.9			0.42			3.09			1		
02/20/23 16:52	276256.3			0.7			2.72			0.43			2.9			1		
02/20/23 16:53	285806.3			0.7			2.62			0.44			2.9			1		
02/20/23 16:54	306677.6			0.6			2.58			0.4			3.06			1		
02/20/23 16:55	329320.3			0.6			2.54			0.49			3.23			1		
02/20/23 16:56	335327.5			0.7			2.41			0.56			3.13			1		
02/20/23 16:57	331707.8			0.8			2.29			0.62			2.94			1		
02/20/23 16:58	332477.9			0.8			2.29			0.62			2.94			1		
02/20/23 16:59	355505.7			0.8			2.29			0.66			3.15			1		
02/20/23 17:00	369291.6			0.8			2.32			0.7			3.32			1		
02/20/23 17:01	380998			0.8			2.09			0.73			3.07			1		
02/20/23 17:02	383462.5			0.7			1.94			0.66			2.87			1		
02/20/23 17:03	390702			0.7			2			0.67			3.01			1		
02/20/23 17:04	406875.4			0.7			2.18			0.69			3.43			1		
02/20/23 17:05	415886.3			0.7			2.12			0.72			3.41			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 17:06	416964.5			0.7			1.94			0.72			3.12			1		
02/20/23 17:07	418812.8			0.7			1.75			0.73			2.83			1		
02/20/23 17:08	428670.9			0.7			1.66			0.74			2.75			1		
02/20/23 17:09	444998.3			0.7			1.38			0.77			2.38			1		
02/20/23 17:10	445383.4			0.7			1.2			0.77			2.06			0		
02/20/23 17:11	444074.1			0.7			1.09			0.76			1.87			0		
02/20/23 17:12	444228.1			0.7			1.2			0.77			2.06			0		
02/20/23 17:13	443380.9			0.7			1.2			0.77			2.05			0		
02/20/23 17:14	443535			0.7			1.2			0.77			2.05			0		

CT1 SUSD EVENT 46

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 15:12	280107.1			0.4			1.62			0.25			1.74			0		
03/16/23 15:13	280800.3			0.4			1.62			0.25			1.75			0		
03/16/23 15:14	276641.4			0.4			1.5			0.24			1.59			0		
03/16/23 15:15	272559.5			0.5			1.43			0.3			1.5			0		
03/16/23 15:16	273483.7			0.5			1.43			0.3			1.5			0		
03/16/23 15:17	170898.4			0.4			1.52			0.15			1			1		
03/16/23 15:18	33656			0			1.69			0.12			0.22			0		
03/16/23 15:19	33656			0			0			0			0			0		
03/16/23 15:20	33656			0			0			0			0			0		
03/16/23 15:21	33347.9			0			0			0			0			0		
03/16/23 15:22	33501.9			0			0			0			0			0		

CT1 SUSD EVENT 47

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 1:45	0			0			0			0			0			0		
03/17/23 1:46	1001.2			0			0			0			0			0		
03/17/23 1:47	0			0			0			0			0			0		
03/17/23 1:48	0			0			0			0			0			0		
03/17/23 1:49	1078.2			0			0			0			0			0		
03/17/23 1:50	15865.3			0			0			0			0			1		
03/17/23 1:51	26108.4			0			0			0			0			1		
03/17/23 1:52	37044.7			82.6			17.7			7.14			2.52			1		
03/17/23 1:53	48212			1328			8.17			149.52			1.51			1		
03/17/23 1:54	60226.5			1016.3			12.17			142.86			2.82			1		
03/17/23 1:55	76707.9			574.2			16.46			102.82			4.85			1		
03/17/23 1:56	118373.5			421.6			22.42			116.54			10.2			1		
03/17/23 1:57	142479.5			291.4			24.88			96.93			13.62			1		
03/17/23 1:58	139013.8			281.8			47			91.46			25.1			1		
03/17/23 1:59	139938			1983.4			39.33			648.2			21.16			1		
03/17/23 2:00	155341.2			2146.4			41.71			778.34			24.89			1		
03/17/23 2:01	174518.2			2007.9			44.73			818.02			29.99			1		
03/17/23 2:02	195466.5			1729			40.32			789.17			30.28			1		
03/17/23 2:03	219110.4			440.8			39.29			225.45			33.07			1		
03/17/23 2:04	240289.8			43.4			38.48			24.32			35.52			1		
03/17/23 2:05	263856.7			4.4			37.1			2.73			37.62			1		
03/17/23 2:06	288809.9			2.6			28.26			1.74			31.36			1		
03/17/23 2:07	310066.3			2.2			12.27			1.63			14.62			1		
03/17/23 2:08	326162.7			2.1			8.42			1.59			10.55			1		
03/17/23 2:09	333941.3			2.1			6.25			1.62			8.02			1		
03/17/23 2:10	334018.3			1.9			5.73			1.47			7.35			1		
03/17/23 2:11	330398.5			1.7			5.22			1.32			6.62			1		
03/17/23 2:12	329397.3			1.6			4.51			1.2			5.71			1		
03/17/23 2:13	328319.1			1.4			4.43			1.06			5.58			1		
03/17/23 2:14	326932.8			1.3			4.25			0.99			5.34			1		
03/17/23 2:15	326162.7			1.2			4.08			0.93			5.11			1		
03/17/23 2:16	325623.5			1.1			4.05			0.87			5.07			1		
03/17/23 2:17	325623.5			1.1			3.96			0.87			4.96			1		
03/17/23 2:18	326316.7			1.1			3.87			0.81			4.86			1		
03/17/23 2:19	326624.8			1.1			3.79			0.81			4.75			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 2:20	326855.8			1			3.79			0.74			4.76			1		
03/17/23 2:21	325854.6			1			3.79			0.74			4.74			1		
03/17/23 2:22	322851			1			3.87			0.73			4.81			1		
03/17/23 2:23	306831.6			0.9			3.87			0.63			4.57			1		
03/17/23 2:24	290889.3			0.9			3.84			0.61			4.3			1		
03/17/23 2:25	288963.9			0.8			3.99			0.55			4.43			1		
03/17/23 2:26	288578.8			0.7			4.43			0.5			4.91			1		
03/17/23 2:27	288809.9			0.6			4.43			0.44			4.91			1		
03/17/23 2:28	288655.9			0.6			4.52			0.43			5.01			1		
03/17/23 2:29	288424.8			0.6			4.7			0.43			5.21			1		
03/17/23 2:30	288424.8			0.6			4.79			0.43			5.31			1		
03/17/23 2:31	288347.8			0.6			4.89			0.43			5.41			1		
03/17/23 2:32	288424.8			0.6			4.89			0.43			5.41			1		
03/17/23 2:33	287731.7			0.6			3.6			0.43			3.97			1		
03/17/23 2:34	288193.8			0.6			2.86			0.43			3.16			1		
03/17/23 2:35	287962.7			0.6			2.67			0.43			2.96			1		
03/17/23 2:36	287962.7			0.6			2.86			0.43			3.16			1		
03/17/23 2:37	288116.8			0.6			3.32			0.43			3.67			1		
03/17/23 2:38	288270.8			0.6			3.41			0.43			3.78			1		
03/17/23 2:39	287885.7			0.6			2.86			0.43			3.16			1		
03/17/23 2:40	287577.6			0.6			2.4			0.37			2.65			1		
03/17/23 2:41	287500.6			0.6			2.21			0.37			2.44			1		
03/17/23 2:42	287346.6			0.6			2.12			0.37			2.34			1		
03/17/23 2:43	287577.6			0.6			2.12			0.37			2.34			1		
03/17/23 2:44	291582.5			0.6			2.12			0.38			2.38			1		
03/17/23 2:45	311683.6			0.6			2.21			0.4			2.65			1		
03/17/23 2:46	330321.5			0.6			2.09			0.49			2.65			1		
03/17/23 2:47	343645.3			0.6			1.97			0.5			2.6			1		
03/17/23 2:48	349267.4			0.7			1.45			0.59			1.95			1		
03/17/23 2:49	362976.3			0.7			1.36			0.62			1.9			1		
03/17/23 2:50	379919.8			0.7			1.27			0.64			1.86			1		
03/17/23 2:51	387467.3			0.7			1.31			0.59			1.95			1		
03/17/23 2:52	388776.6			0.6			1.38			0.59			2.07			0		
03/17/23 2:53	396940.3			0.6			1.54			0.59			2.35			0		
03/17/23 2:54	415039.1			0.6			1.75			0.63			2.79			0		
03/17/23 2:55	426591.5			0.7			1.87			0.65			3.07			0		
03/17/23 2:56	429364			0.7			1.87			0.66			3.09			0		

CT1 SUSD EVENT 48

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 20:09	448387			0.1			1.64			0.1			3.97			0		
03/20/23 20:10	447770.9			0.1			1.7			0.14			2.93			0		
03/20/23 20:11	448541			0.3			0.91			0.29			1.56			0		
03/20/23 20:12	450158.3			0.7			0.65			0.78			1.12			0		
03/20/23 20:13	449542.2			1.1			0.83			1.16			1.43			0		
03/20/23 20:14	448695.1			1			1.48			1.06			2.54			1		
03/20/23 20:15	447616.8			0.7			1.57			0.77			2.7			1		
03/20/23 20:16	431289.4			0.6			1.57			0.65			2.6			1		
03/20/23 20:17	409648			0.6			2.12			0.53			3.34			1		
03/20/23 20:18	387390.3			0.5			2.45			0.49			3.65			1		
03/20/23 20:19	365209.8			0.6			2.86			0.53			4.01			1		
03/20/23 20:20	341180.8			0.7			3.17			0.56			4.16			1		
03/20/23 20:21	316304.6			0.7			3.26			0.52			3.96			1		
03/20/23 20:22	296434.5			0.7			3.26			0.49			3.71			1		
03/20/23 20:23	274947			0.7			3.4			0.46			3.59			1		
03/20/23 20:24	251919.3			0.6			4.43			0.33			4.28			1		
03/20/23 20:25	230893.9			0.5			6.67			0.26			5.92			1		
03/20/23 20:26	207018.9			0.3			21.49			0.15			17.09			1		
03/20/23 20:27	183452			2.5			26.26			1.09			18.51			1		
03/20/23 20:28	163350.9			102.7			30.02			39.16			18.85			1		
03/20/23 20:29	145791.2			658.5			34.64			224.21			19.41			1		
03/20/23 20:30	83408.3			1685.2			34.22			328.19			10.97			1		
03/20/23 20:31	24799.1			0			34.6			150.88			3.3			0		
03/20/23 20:32	24260			0			0.5			0			0			0		
03/20/23 20:33	24106			0			0.2			0			0			0		
03/20/23 20:34	23720.9			0			0.2			0			0			0		
03/20/23 20:35	23489.9			0			0.1			0			0			0		

CT1 SUSD EVENT 49

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 16:03	26570.5			0			0			0			0			0		
03/22/23 16:04	26493.5			0			0			0			0			0		
03/22/23 16:05	26647.5			0			0			0			0			0		
03/22/23 16:06	26493.5			0			0			0			0			0		
03/22/23 16:07	26955.6			0			0			0			0			0		
03/22/23 16:08	34195.1			0			0			0			0			1		
03/22/23 16:09	39201.1			0.3			0			0			0			1		
03/22/23 16:10	48366			73.8			17.7			8.32			3.29			1		
03/22/23 16:11	59225.3			1250.4			12.59			172.98			2.87			1		
03/22/23 16:12	71393.8			793			17.7			132.25			4.86			1		
03/22/23 16:13	97656.3			461.4			20.95			105.24			7.86			1		
03/22/23 16:14	138320.7			306.3			23.06			98.93			12.26			1		
03/22/23 16:15	148563.8			195.1			45.23			67.66			25.81			1		
03/22/23 16:16	158575.9			1148			48.53			425.05			29.57			1		
03/22/23 16:17	175673.4			1898.5			48.27			778.57			32.58			1		
03/22/23 16:18	196544.8			1740.3			57.36			798.61			43.32			1		
03/22/23 16:19	219033.4			386.8			63.03			197.76			53.03			1		
03/22/23 16:20	240058.8			48.4			63.87			27.1			58.92			1		
03/22/23 16:21	263779.7			3.2			58.32			1.96			59.1			1		
03/22/23 16:22	289040.9			1.9			45.34			1.26			50.36			1		
03/22/23 16:23	310528.4			1.7			21.35			1.22			25.48			1		
03/22/23 16:24	315688.5			1.6			16.23			1.22			19.68			1		
03/22/23 16:25	315688.5			1.8			13.01			1.34			15.79			1		
03/22/23 16:26	313455			1.7			12.23			1.27			14.73			1		
03/22/23 16:27	312222.8			1.7			11.18			1.22			13.41			1		
03/22/23 16:28	311760.7			1.5			10.48			1.09			12.55			1		
03/22/23 16:29	310066.3			1.3			9.69			0.96			11.54			1		
03/22/23 16:30	309142.1			1.3			8.67			0.9			10.3			1		
03/22/23 16:31	309142.1			1.1			8.05			0.77			9.56			1		
03/22/23 16:32	309065.1			1			7.96			0.71			9.45			1		
03/22/23 16:33	310220.3			0.9			7.78			0.65			9.27			1		
03/22/23 16:34	309373.2			0.9			7.6			0.65			9.03			1		
03/22/23 16:35	307755.8			0.9			7.51			0.64			8.88			1		
03/22/23 16:36	306831.6			0.9			7.51			0.64			8.85			1		
03/22/23 16:37	306985.7			0.8			7.44			0.59			8.78			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 16:38	307447.8			0.8			7.35			0.59			8.69			1		
03/22/23 16:39	306446.6			0.8			7.26			0.58			8.55			1		
03/22/23 16:40	305676.4			0.7			7.26			0.52			8.53			1		
03/22/23 16:41	306523.6			0.7			7.26			0.52			8.55			1		
03/22/23 16:42	307139.7			0.7			7.17			0.52			8.46			1		
03/22/23 16:43	315688.5			0.7			7.17			0.54			8.7			1		
03/22/23 16:44	328396.1			0.7			7.35			0.56			9.28			1		
03/22/23 16:45	329166.3			0.7			7.6			0.55			9.61			1		
03/22/23 16:46	329089.3			0.7			7.33			0.55			9.27			1		
03/22/23 16:47	328781.2			0.7			7.33			0.55			9.26			1		
03/22/23 16:48	327857			0.7			7.42			0.55			9.35			1		
03/22/23 16:49	313301			0.7			7.51			0.52			9.04			1		
03/22/23 16:50	307986.9			0.7			7.6			0.51			8.99			1		
03/22/23 16:51	301748.6			0.7			7.17			0.51			8.31			1		
03/22/23 16:52	297589.7			0.6			5.36			0.44			6.12			1		
03/22/23 16:53	295356.3			0.6			4.33			0.45			4.92			1		
03/22/23 16:54	295433.3			0.6			4.61			0.38			5.23			1		
03/22/23 16:55	292968.8			0.6			5.35			0.38			6.02			1		
03/22/23 16:56	289195			0.6			5.53			0.37			6.15			1		
03/22/23 16:57	289195			0.6			3.6			0.37			3.99			1		
03/22/23 16:58	288501.8			0.6			2.3			0.37			2.55			1		
03/22/23 16:59	288039.8			0.6			2.21			0.37			2.45			1		
03/22/23 17:00	288270.8			0.6			2.62			0.38			2.9			1		
03/22/23 17:01	288424.8			0.6			3.28			0.38			3.63			1		
03/22/23 17:02	288424.8			0.6			3.47			0.38			3.84			1		
03/22/23 17:03	288578.8			0.6			3.65			0.38			4.05			1		
03/22/23 17:04	288116.8			0.5			2.9			0.31			3.21			1		
03/22/23 17:05	288270.8			0.5			2.62			0.32			2.9			1		
03/22/23 17:06	288655.9			0.6			2.43			0.38			2.7			1		
03/22/23 17:07	288655.9			0.6			2.15			0.38			2.39			1		
03/22/23 17:08	288501.8			0.6			2.06			0.38			2.28			1		
03/22/23 17:09	288424.8			0.5			1.97			0.32			2.18			1		
03/22/23 17:10	288501.8			0.5			1.87			0.32			2.08			1		
03/22/23 17:11	288270.8			0.5			1.87			0.32			2.07			1		
03/22/23 17:12	288193.8			0.5			1.97			0.32			2.18			1		
03/22/23 17:13	294740.1			0.6			1.97			0.39			2.23			1		
03/22/23 17:14	315303.4			0.6			1.97			0.41			2.38			1		
03/22/23 17:15	334018.3			0.5			1.82			0.42			2.33			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 17:16	351654.9			0.6			1.72			0.52			2.33			1		
03/22/23 17:17	368290.4			0.6			1.18			0.55			1.67			1		
03/22/23 17:18	388314.5			0.6			1.01			0.59			1.51			1		
03/22/23 17:19	410110.1			0.6			1.03			0.54			1.62			0		
03/22/23 17:20	433676.9			0.6			1.12			0.57			1.87			0		
03/22/23 17:21	449234.2			0.5			1.33			0.5			2.3			0		
03/22/23 17:22	448001.9			0.5			2.15			0.49			3.71			0		
03/22/23 17:23	446923.7			0.6			2.03			0.58			3.48			0		

CT1 SUSD EVENT 50

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 23:39	286807.5			0.6			1.4			0.38			1.55			0		
03/22/23 23:40	287423.6			0.6			1.48			0.37			1.63			0		
03/22/23 23:41	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:42	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:43	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:44	287500.6			0.6			1.5			0.38			1.66			1		
03/22/23 23:45	279028.9			0.6			1.59			0.37			1.71			1		
03/22/23 23:46	256848.3			0.6			1.59			0.34			1.57			1		
03/22/23 23:47	234282.6			0.5			2.85			0.26			2.57			1		
03/22/23 23:48	210407.6			0.4			8.11			0.21			6.56			1		
03/22/23 23:49	185762.5			2.2			15.96			0.95			11.39			1		
03/22/23 23:50	166816.6			96.8			18.88			37.69			12.1			1		
03/22/23 23:51	148948.9			735.4			21.54			255.83			12.33			1		
03/22/23 23:52	93574.4			1757.9			23.77			384.05			8.55			1		
03/22/23 23:53	24260			0			23.6			130.33			2.2			0		
03/22/23 23:54	24183			0			0.4			0			0			0		
03/22/23 23:55	24414.1			0			0.2			0			0			0		
03/22/23 23:56	24491.1			0			0.1			0			0			0		
03/22/23 23:57	24645.1			0			0.1			0			0			0		

CT1 SUSD EVENT 51

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 14:54	26108.4			0			0			0			0			0		
03/23/23 14:55	26108.4			0			0			0			0			0		
03/23/23 14:56	26185.4			0			0			0			0			0		
03/23/23 14:57	26570.5			0			0			0			0			0		
03/23/23 14:58	26647.5			0			0			0			0			0		
03/23/23 14:59	30960.4			0			0			0			0			1		
03/23/23 15:00	35273.3			0			0			0			0			1		
03/23/23 15:01	43822.1			112.1			53.1			11.47			8.94			1		
03/23/23 15:02	54219.2			1254.4			13.62			158.93			2.84			1		
03/23/23 15:03	64847.4			945.8			18.44			143.13			4.59			1		
03/23/23 15:04	80558.7			509.3			23.91			95.76			7.4			1		
03/23/23 15:05	120607			338.8			26.69			95.41			12.37			1		
03/23/23 15:06	144405			215.8			42.53			72.76			23.6			1		
03/23/23 15:07	148794.9			241.7			57.98			83.97			33.15			1		
03/23/23 15:08	160116.2			1900.9			49.48			710.62			30.44			1		
03/23/23 15:09	178369			1866.5			50.6			777.14			34.67			1		
03/23/23 15:10	200395.6			1485			51.35			694.76			39.53			1		
03/23/23 15:11	223192.3			228.3			52.12			118.96			44.7			1		
03/23/23 15:12	243678.5			20.8			49.71			11.86			46.55			1		
03/23/23 15:13	269401.9			2.4			48.09			1.54			49.78			1		
03/23/23 15:14	290658.3			1.8			31.43			1.24			35.11			1		
03/23/23 15:15	307062.7			1.8			16.13			1.26			19.04			1		
03/23/23 15:16	314456.2			1.8			11.8			1.29			14.26			1		
03/23/23 15:17	314764.3			1.8			8.72			1.29			10.54			1		
03/23/23 15:18	312376.8			1.6			8.1			1.16			9.72			1		
03/23/23 15:19	310836.5			1.4			7.31			1.02			8.73			1		
03/23/23 15:20	310451.4			1.3			6.7			0.91			8			1		
03/23/23 15:21	309373.2			1.2			6.53			0.84			7.76			1		
03/23/23 15:22	309758.3			1.1			6.35			0.78			7.55			1		
03/23/23 15:23	309681.2			1			5.99			0.72			7.13			1		
03/23/23 15:24	308371.9			0.9			5.9			0.65			6.99			1		
03/23/23 15:25	307293.7			0.9			5.99			0.65			7.07			1		
03/23/23 15:26	306446.6			0.8			5.9			0.58			6.95			1		
03/23/23 15:27	307601.8			0.8			5.81			0.59			6.87			1		
03/23/23 15:28	307601.8			0.7			5.72			0.52			6.76			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 15:29	306754.6			0.7			5.72			0.52			6.74			1		
03/23/23 15:30	304521.2			0.7			5.72			0.52			6.69			1		
03/23/23 15:31	297743.8			0.7			5.81			0.51			6.64			1		
03/23/23 15:32	291659.5			0.6			5.72			0.44			6.41			1		
03/23/23 15:33	291043.3			0.6			6.18			0.44			6.91			1		
03/23/23 15:34	290427.2			0.6			6.56			0.38			7.32			1		
03/23/23 15:35	290273.2			0.6			6.56			0.38			7.31			1		
03/23/23 15:36	289657.1			0.6			6.65			0.38			7.4			1		
03/23/23 15:37	289349			0.6			6.74			0.38			7.5			1		
03/23/23 15:38	289811.1			0.6			6.74			0.38			7.51			1		
03/23/23 15:39	289503			0.6			6.84			0.38			7.6			1		
03/23/23 15:40	289734.1			0.6			6.93			0.38			7.72			1		
03/23/23 15:41	289811.1			0.6			6.37			0.38			7.09			1		
03/23/23 15:42	290119.2			0.6			5.06			0.38			5.64			1		
03/23/23 15:43	289734.1			0.6			4.03			0.38			4.48			1		
03/23/23 15:44	289811.1			0.6			3.75			0.38			4.17			1		
03/23/23 15:45	289118			0.6			3.18			0.38			3.54			1		
03/23/23 15:46	289195			0.6			3.09			0.38			3.43			1		
03/23/23 15:47	288963.9			0.6			3			0.38			3.33			1		
03/23/23 15:48	288732.9			0.6			2.81			0.38			3.12			1		
03/23/23 15:49	288963.9			0.6			2.62			0.38			2.91			1		
03/23/23 15:50	289118			0.6			2.34			0.38			2.6			1		
03/23/23 15:51	289118			0.6			2.06			0.38			2.29			1		
03/23/23 15:52	289040.9			0.6			1.78			0.38			1.98			1		
03/23/23 15:53	288732.9			0.5			1.5			0.32			1.66			1		
03/23/23 15:54	288963.9			0.6			1.31			0.38			1.46			1		
03/23/23 15:55	289426			0.6			1.22			0.38			1.35			1		
03/23/23 15:56	288809.9			0.6			1.12			0.38			1.25			0		
03/23/23 15:57	289195			0.6			1.12			0.38			1.25			0		
03/23/23 15:58	289272			0.6			1.03			0.38			1.14			0		
03/23/23 15:59	288809.9			0.6			1.12			0.38			1.25			0		
03/23/23 16:00	287962.7			0.6			1.12			0.38			1.24			0		

CT1 SUSD EVENT 52

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 22:50	293045.8			0.6			2.53			0.38			2.85			0		
03/23/23 22:51	306600.6			0.6			2.34			0.4			2.76			0		
03/23/23 22:52	307601.8			0.6			1.57			0.4			1.85			0		
03/23/23 22:53	306369.5			0.6			1.45			0.45			1.71			0		
03/23/23 22:54	300824.4			0.6			1.45			0.45			1.68			0		
03/23/23 22:55	299130			0.6			1.57			0.45			1.8			1		
03/23/23 22:56	283033.7			0.6			1.75			0.43			1.9			1		
03/23/23 22:57	261161.2			0.6			2.4			0.39			2.41			1		
03/23/23 22:58	238672.5			0.6			4.38			0.32			4.01			1		
03/23/23 22:59	216414.9			0.4			8.28			0.21			6.89			1		
03/23/23 23:00	191384.7			1.5			19.97			0.66			14.68			1		
03/23/23 23:01	170975.5			12.3			23.09			4.91			15.16			1		
03/23/23 23:02	153492.8			569.6			25.9			204.12			15.28			1		
03/23/23 23:03	106590.1			1630.7			27.37			405.91			11.21			1		
03/23/23 23:04	22950.8			0			26.24			113.01			2.31			0		
03/23/23 23:05	22950.8			0			70.8			1011.33			6.23			0		
03/23/23 23:06	22950.8			0			0.2			0			0			0		
03/23/23 23:07	22642.7			0			0.1			0			0			0		
03/23/23 23:08	22642.7			0			0.1			0			0			0		

CT2 SUSD EVENT 1

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 20:23	288347.8			0.8			1.33			0.52			1.49			0		
01/27/23 20:24	287500.6			0.8			1.33			0.52			1.48			0		
01/27/23 20:25	287577.6			0.8			1.33			0.52			1.48			0		
01/27/23 20:26	289426			0.8			1.33			0.52			1.49			0		
01/27/23 20:27	287962.7			0.8			1.33			0.52			1.49			0		
01/27/23 20:28	284959.1			0.8			1.43			0.51			1.58			1		
01/27/23 20:29	265012			0.8			1.43			0.48			1.47			1		
01/27/23 20:30	245912			0.8			3.3			0.46			3.15			1		
01/27/23 20:31	217801.2			0.8			8.63			0.39			7.28			1		
01/27/23 20:32	193233.1			4.6			11.68			2.08			8.75			1		
01/27/23 20:33	170898.4			332.2			14.27			133.7			9.45			1		
01/27/23 20:34	152722.7			1154.4			17.7			415.26			10.48			1		
01/27/23 20:35	50830.5			1894.4			22.88			226.87			4.51			1		
01/27/23 20:36	0			0			29.5			0			0			0		
01/27/23 20:37	0			0			0.2			0			0			0		
01/27/23 20:38	0			0			0.1			0			0			0		
01/27/23 20:39	0			0			0.1			0			0			0		
01/27/23 20:40	0			0			0.1			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:09	0			0			0			0			0			0		
01/29/23 9:10	0			0			0			0			0			0		
01/29/23 9:11	0			0			0			0			0			0		
01/29/23 9:12	0			0			0			0			0			0		
01/29/23 9:13	0			0			0			0			0			0		
01/29/23 9:14	6392.3			0.2			0			0			0			1		
01/29/23 9:15	20640.3			0.2			0			0			0			1		
01/29/23 9:16	36428.6			50.2			29.5			4.3			4.16			1		
01/29/23 9:17	50214.4			1393.8			14.07			164.73			2.74			1		
01/29/23 9:18	58686.2			1094.1			18.44			151.11			4.19			1		
01/29/23 9:19	73473.2			685.3			22.05			118.59			6.28			1		
01/29/23 9:20	106975.2			535.1			25.96			134.76			10.76			1		
01/29/23 9:21	151413.4			406			35.4			144.78			20.77			1		
01/29/23 9:22	157959.8			248.9			50.36			92.58			30.83			1		
01/29/23 9:23	170436.3			1426.1			49.29			572.37			32.56			1		
01/29/23 9:24	191538.7			1873.5			53.46			845.05			39.68			1		
01/29/23 9:25	213642.3			1068.2			59.8			537.3			49.5			1		
01/29/23 9:26	237286.2			311.7			60.83			174.16			55.93			1		
01/29/23 9:27	261315.2			35.2			56.05			21.63			56.76			1		
01/29/23 9:28	287731.7			3.5			55.22			2.34			61.57			1		
01/29/23 9:29	314610.3			2.1			39.67			1.58			48.38			1		
01/29/23 9:30	337330			1.9			19.64			1.54			25.67			1		
01/29/23 9:31	341488.8			1.9			14.4			1.53			19.06			1		
01/29/23 9:32	341488.8			2			11.89			1.6			15.73			1		
01/29/23 9:33	343953.3			2			10.59			1.62			14.11			1		
01/29/23 9:34	351038.8			1.9			10.06			1.58			13.69			1		
01/29/23 9:35	349960.6			1.8			9.46			1.5			12.83			1		
01/29/23 9:36	348420.3			1.7			8.85			1.42			11.95			1		
01/29/23 9:37	347342			1.6			8.5			1.35			11.45			1		
01/29/23 9:38	344569.5			1.5			8.19			1.21			10.94			1		
01/29/23 9:39	344415.4			1.4			7.84			1.14			10.46			1		
01/29/23 9:40	345416.6			1.3			7.57			1.07			10.14			1		
01/29/23 9:41	344492.4			1.3			7.4			1.07			9.88			1		
01/29/23 9:42	344338.4			1.2			7.31			1			9.75			1		
01/29/23 9:43	354889.6			1.2			7.31			1.03			10.05			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:44	373450.4			1.2			7.22			1.08			10.45			1		
01/29/23 9:45	386081.1			1.3			5.99			1.14			8.96			1		
01/29/23 9:46	397017.3			1.2			4.27			1.1			6.56			1		
01/29/23 9:47	411650.4			1.1			4.36			1.06			6.95			1		
01/29/23 9:48	418735.8			1			4.63			0.98			7.51			1		
01/29/23 9:49	436911.6			1			4.63			1.03			7.84			1		
01/29/23 9:50	444536.2			1			4.43			1.06			7.62			1		
01/29/23 9:51	443149.9			0.9			4.7			0.96			8.07			1		
01/29/23 9:52	439992.3			0.9			5.07			0.96			8.65			1		
01/29/23 9:53	441532.6			0.9			5.17			0.94			8.85			1		
01/29/23 9:54	460478.5			1			5.07			1.1			9.05			1		
01/29/23 9:55	461325.7			1			4.7			1.1			8.41			1		
01/29/23 9:56	456781.7			0.9			4.98			0.99			8.81			1		
01/29/23 9:57	455626.5			0.9			3.96			0.99			7			1		
01/29/23 9:58	458707.1			0.9			2.3			1			4.1			1		
01/29/23 9:59	475034.5			0.9			2.12			1.03			3.9			1		
01/29/23 10:00	473648.2			0.9			2.12			1.03			3.89			1		
01/29/23 10:01	476420.8			0.8			2.77			0.93			5.11			1		
01/29/23 10:02	477576			0.8			3.13			0.93			5.8			1		
01/29/23 10:03	478269.2			0.9			3.32			1.04			6.15			1		
01/29/23 10:04	493133.3			0.9			3.04			1.07			5.81			1		
01/29/23 10:05	489436.5			0.8			3.04			0.96			5.77			1		
01/29/23 10:06	487434.1			0.9			2.49			1.06			4.71			1		
01/29/23 10:07	489898.6			1.2			1.82			1.39			3.51			1		
01/29/23 10:08	489898.6			2.2			1.79			2.58			3.4			1		
01/29/23 10:09	480117.6			3.1			1.97			3.54			3.66			1		
01/29/23 10:10	471029.7			3			2.15			3.37			3.92			0		
01/29/23 10:11	468257.1			2.5			2.23			2.76			4.06			0		
01/29/23 10:12	471029.7			2.3			2.27			2.52			4.14			0		
01/29/23 10:13	488127.2			1.9			2.12			2.23			4.01			0		
01/29/23 10:14	491361.9			1.4			2.21			1.6			4.21			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 12:32	320925.6			1			1.27			0.75			1.58			0		
01/29/23 12:33	308449			1			1.36			0.73			1.63			0		
01/29/23 12:34	289888.1			1			1.48			0.69			1.66			0		
01/29/23 12:35	288809.9			0.9			2.25			0.64			2.52			0		
01/29/23 12:36	290350.2			0.9			2.28			0.59			2.57			0		
01/29/23 12:37	288963.9			0.8			2			0.52			2.24			1		
01/29/23 12:38	274561.9			0.7			1.62			0.43			1.72			1		
01/29/23 12:39	253074.5			0.7			1.97			0.41			1.93			1		
01/29/23 12:40	228506.4			0.6			6.01			0.34			5.32			1		
01/29/23 12:41	200472.6			2.9			9.6			1.37			7.46			1		
01/29/23 12:42	176135.5			184.5			12.32			76.52			8.41			1		
01/29/23 12:43	156419.4			909.9			14.16			335.26			8.59			1		
01/29/23 12:44	94652.6			1791.5			20.65			399.42			7.58			1		
01/29/23 12:45	0			0			28.16			0			0			0		
01/29/23 12:46	0			0			0.2			0			0			0		
01/29/23 12:47	0			0			0.1			0			0			0		
01/29/23 12:48	0			0			0.1			0			0			0		
01/29/23 12:49	0			0			0.1			0			0			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 16:04	6854.4			0			0			0			0			0		
02/03/23 16:05	5160.1			0			0			0			0			0		
02/03/23 16:06	6623.4			0			0			0			0			0		
02/03/23 16:07	5314.1			0			0			0			0			0		
02/03/23 16:08	16635.4			0			0			0			0			0		
02/03/23 16:09	1155.2			0.3			0			0			0			1		
02/03/23 16:10	20255.2			0.3			0			0			0			1		
02/03/23 16:11	36351.5			106.2			17.7			9.06			2.48			1		
02/03/23 16:12	47518.9			1432.2			11.31			159.66			2.07			1		
02/03/23 16:13	59841.4			1014.8			15.96			142.66			3.69			1		
02/03/23 16:14	72780.1			680.1			21.43			116.15			6.02			1		
02/03/23 16:15	108207.4			491.4			24.72			124.84			10.34			1		
02/03/23 16:16	148794.9			364			22.57			127.19			12.98			1		
02/03/23 16:17	173131.9			231.9			45.98			94.28			30.76			1		
02/03/23 16:18	224116.5			1079.3			46.65			568.01			40.4			1		
02/03/23 16:19	254768.8			317.6			58.02			190.04			57.13			1		
02/03/23 16:20	275871.2			14.3			53.1			9.29			56.61			1		
02/03/23 16:21	304521.2			2.3			47.92			1.63			56.39			1		
02/03/23 16:22	322619.9			2.1			22.76			1.56			28.37			1		
02/03/23 16:23	321541.7			2.1			18.57			1.57			23.07			1		
02/03/23 16:24	321926.8			2.3			18.13			1.71			22.56			1		
02/03/23 16:25	335096.5			2.4			17.96			1.87			23.26			1		
02/03/23 16:26	336713.8			2.1			15.23			1.67			19.82			1		
02/03/23 16:27	332169.9			1.9			12.49			1.49			16.04			1		
02/03/23 16:28	334480.4			1.8			11.18			1.38			14.46			1		
02/03/23 16:29	332863			1.7			9.86			1.31			12.69			1		
02/03/23 16:30	332246.9			1.7			9.16			1.31			11.76			1		
02/03/23 16:31	332940.1			1.6			8.76			1.26			11.27			1		
02/03/23 16:32	332786			1.5			8.13			1.19			10.46			1		
02/03/23 16:33	332323.9			1.4			7.51			1.12			9.64			1		
02/03/23 16:34	332477.9			1.3			7.33			1.05			9.42			1		
02/03/23 16:35	332786			1.3			7.24			1.05			9.31			1		
02/03/23 16:36	333017.1			1.3			6.97			0.98			8.97			1		
02/03/23 16:37	332092.9			1.3			6.88			0.98			8.83			1		
02/03/23 16:38	332632			1.2			6.79			0.91			8.73			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 16:39	330013.4			1.2			6.7			0.9			8.55			1		
02/03/23 16:40	327240.9			1.2			6.7			0.89			8.48			1		
02/03/23 16:41	329012.2			1.2			6.72			0.91			8.54			1		
02/03/23 16:42	329551.3			1.1			6.72			0.84			8.55			1		
02/03/23 16:43	330860.6			1.1			6.81			0.85			8.71			1		
02/03/23 16:44	329089.3			1.1			6.81			0.84			8.66			1		
02/03/23 16:45	311298.6			1.1			6.99			0.8			8.41			1		
02/03/23 16:46	295818.3			1			7.62			0.69			8.72			1		
02/03/23 16:47	292198.6			1			10.77			0.71			12.16			1		
02/03/23 16:48	292814.7			0.9			11.61			0.64			13.14			1		
02/03/23 16:49	291736.5			0.8			12.36			0.58			13.94			1		
02/03/23 16:50	290812.3			0.7			13.11			0.51			14.74			1		
02/03/23 16:51	291736.5			0.7			13.39			0.51			15.1			1		
02/03/23 16:52	292660.7			0.7			13.58			0.51			15.36			1		
02/03/23 16:53	292429.7			0.7			13.11			0.51			14.82			1		
02/03/23 16:54	291274.4			0.7			8.33			0.51			9.38			1		
02/03/23 16:55	292198.6			0.7			4.78			0.51			5.39			1		
02/03/23 16:56	292891.8			0.7			3.47			0.52			3.92			1		
02/03/23 16:57	291274.4			0.7			2.53			0.51			2.85			1		
02/03/23 16:58	290658.3			0.7			2.25			0.51			2.52			1		
02/03/23 16:59	295202.2			0.7			1.87			0.52			2.14			1		
02/03/23 17:00	294663.1			0.8			1.52			0.53			1.73			1		
02/03/23 17:01	296434.5			0.7			1.31			0.52			1.5			1		
02/03/23 17:02	296742.5			0.7			1.03			0.52			1.18			1		
02/03/23 17:03	295972.4			0.7			0.94			0.52			1.07			0		
02/03/23 17:04	297204.6			0.7			0.84			0.52			0.97			0		
02/03/23 17:05	295433.3			0.7			0.84			0.52			0.96			0		
02/03/23 17:06	294278			0.8			0.75			0.58			0.85			0		
02/03/23 17:07	293122.8			0.8			0.75			0.58			0.85			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 8:10	287038.5			1.1			2.13			0.72			2.36			0		
02/08/23 8:11	288963.9			0.9			2.22			0.59			2.48			0		
02/08/23 8:12	290273.2			0.8			1.97			0.54			2.21			0		
02/08/23 8:13	291582.5			0.8			1.74			0.53			1.96			0		
02/08/23 8:14	291351.4			0.8			1.64			0.53			1.85			0		
02/08/23 8:15	291967.6			0.8			1.55			0.53			1.75			1		
02/08/23 8:16	276872.4			0.8			1.45			0.5			1.55			1		
02/08/23 8:17	252304.3			0.8			2.8			0.47			2.73			1		
02/08/23 8:18	227813.3			0.8			7.08			0.4			6.23			1		
02/08/23 8:19	203476.2			4.6			10.15			2.2			7.98			1		
02/08/23 8:20	178369			272.1			12.59			113.94			8.68			1		
02/08/23 8:21	159885.2			1073			14.52			402.81			8.97			1		
02/08/23 8:22	104125.6			1716.4			20.73			419.56			8.34			1		
02/08/23 8:23	0			0			27.45			0			0			0		
02/08/23 8:24	0			0			17.7			0			0			0		
02/08/23 8:25	0			0			0.2			0			0			0		
02/08/23 8:26	0			0			0.1			0			0			0		
02/08/23 8:27	0			0			0.1			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 15:52	0			0			0			0			0			0		
02/08/23 15:53	0			0			0			0			0			0		
02/08/23 15:54	0			0			0			0			0			0		
02/08/23 15:55	0			0			0			0			0			0		
02/08/23 15:56	0			0			0			0			0			0		
02/08/23 15:57	7701.6			0.2			0			0			0			1		
02/08/23 15:58	24799.1			0.5			0			0			0			1		
02/08/23 15:59	37044.7			44.7			10.11			3.89			1.45			1		
02/08/23 16:00	51369.7			1185.1			7.47			142.99			1.48			1		
02/08/23 16:01	62382.9			750.6			11.14			109.89			2.69			1		
02/08/23 16:02	75398.6			473.8			14.46			83.89			4.21			1		
02/08/23 16:03	117680.4			363.6			18.82			100.42			8.56			1		
02/08/23 16:04	153492.8			240.4			22.62			86.65			13.41			1		
02/08/23 16:05	162426.7			200.2			37.37			76.37			23.46			1		
02/08/23 16:06	179139.2			1668.8			36.69			701.9			25.4			1		
02/08/23 16:07	201011.7			1456.8			39.61			687.74			30.78			1		
02/08/23 16:08	226427			536.9			40.56			285.43			35.49			1		
02/08/23 16:09	248684.6			68.2			42.71			39.85			41.05			1		
02/08/23 16:10	268939.8			5.2			44.42			3.29			46.17			1		
02/08/23 16:11	297435.7			1.9			41.72			1.32			47.95			1		
02/08/23 16:12	322928			1.6			19.25			1.25			24.02			1		
02/08/23 16:13	338408.2			1.5			12.68			1.19			16.58			1		
02/08/23 16:14	342259			1.6			9.46			1.26			12.51			1		
02/08/23 16:15	340102.5			1.6			9.16			1.27			12.04			1		
02/08/23 16:16	335250.5			1.5			8.81			1.18			11.41			1		
02/08/23 16:17	336097.7			1.4			8.54			1.11			11.1			1		
02/08/23 16:18	336174.7			1.3			8.28			1.04			10.75			1		
02/08/23 16:19	335173.5			1.3			8.31			0.98			10.77			1		
02/08/23 16:20	338870.3			1.2			8.22			0.92			10.77			1		
02/08/23 16:21	332400.9			1.2			8.31			0.91			10.68			1		
02/08/23 16:22	314841.3			1.1			8.31			0.79			10.12			1		
02/08/23 16:23	310759.4			1.1			8.62			0.79			10.36			1		
02/08/23 16:24	305522.4			1			9.96			0.73			11.76			1		
02/08/23 16:25	300516.3			0.9			10.97			0.65			12.74			1		
02/08/23 16:26	295356.3			0.9			9.83			0.65			11.22			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 16:27	292198.6			0.9			5.24			0.64			5.92			1		
02/08/23 16:28	292583.7			0.8			4.4			0.58			4.98			1		
02/08/23 16:29	291736.5			0.8			5.53			0.58			6.23			1		
02/08/23 16:30	291505.5			0.8			6.65			0.58			7.49			1		
02/08/23 16:31	292891.8			0.7			6.18			0.52			7			1		
02/08/23 16:32	291043.3			0.7			4.03			0.51			4.53			1		
02/08/23 16:33	291120.4			0.8			2.66			0.52			3			1		
02/08/23 16:34	290273.2			0.8			2			0.52			2.24			1		
02/08/23 16:35	290812.3			0.9			1.62			0.58			1.82			1		
02/08/23 16:36	292506.7			0.9			1.43			0.59			1.61			1		
02/08/23 16:37	290427.2			0.9			1.33			0.58			1.5			1		
02/08/23 16:38	291890.5			0.8			1.24			0.52			1.4			0		
02/08/23 16:39	290504.3			0.8			1.14			0.52			1.28			0		
02/08/23 16:40	290735.3			0.8			1.14			0.52			1.28			0		
02/08/23 16:41	290889.3			0.8			1.05			0.52			1.18			0		
02/08/23 16:42	289965.1			0.8			1.05			0.52			1.17			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 8:07	290966.3			0.8			1.45			0.53			1.63			0		
02/09/23 8:08	290427.2			0.8			1.45			0.53			1.63			0		
02/09/23 8:09	288809.9			0.8			1.45			0.52			1.62			0		
02/09/23 8:10	291505.5			0.8			1.45			0.53			1.63			0		
02/09/23 8:11	292968.8			0.7			1.55			0.47			1.75			0		
02/09/23 8:12	285190.2			0.8			1.43			0.51			1.57			1		
02/09/23 8:13	264010.8			0.8			1.55			0.48			1.58			1		
02/09/23 8:14	239827.7			0.8			4.37			0.46			4.05			1		
02/09/23 8:15	213257.2			1.2			8.13			0.61			6.7			1		
02/09/23 8:16	189998.4			9.6			10.69			4.28			7.85			1		
02/09/23 8:17	169743.2			535.2			13.2			213.37			8.66			1		
02/09/23 8:18	148178.7			1397.7			16.58			486.19			9.49			1		
02/09/23 8:19	24799.1			1938			21.02			112.79			2.01			1		
02/09/23 8:20	0			0			26.13			0			0			0		
02/09/23 8:21	0			0			0.1			0			0			0		
02/09/23 8:22	0			0			0.1			0			0			0		
02/09/23 8:23	0			0			0.1			0			0			0		
02/09/23 8:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 16:00	0			0			0			0			0			0		
02/09/23 16:01	0			0			0			0			0			0		
02/09/23 16:02	0			0			0			0			0			0		
02/09/23 16:03	0			0			0			0			0			0		
02/09/23 16:04	0			0			0			0			0			0		
02/09/23 16:05	10397.2			0.2			0			0			0			1		
02/09/23 16:06	23489.9			0.2			0			0			0			1		
02/09/23 16:07	37044.7			50.2			9.83			4.37			1.41			1		
02/09/23 16:08	49367.2			1196.5			6.69			138.74			1.28			1		
02/09/23 16:09	60996.6			761.1			10.16			109.04			2.4			1		
02/09/23 16:10	76476.9			467.6			13.28			83.94			3.92			1		
02/09/23 16:11	116063.1			342.2			17.7			93.22			7.94			1		
02/09/23 16:12	151875.5			216.6			20.06			77.25			11.77			1		
02/09/23 16:13	170744.4			196.5			35.6			78.77			23.49			1		
02/09/23 16:14	185608.5			1327.3			34.71			578.49			24.89			1		
02/09/23 16:15	209945.5			928.2			36.49			457.5			29.6			1		
02/09/23 16:16	233589.4			254			39.47			139.29			35.63			1		
02/09/23 16:17	257156.3			23.1			41.67			13.96			41.42			1		
02/09/23 16:18	284497			2.1			43.42			1.41			47.73			1		
02/09/23 16:19	307216.7			1.5			30.01			1.1			35.63			1		
02/09/23 16:20	333479.2			1.5			14.84			1.15			19.13			1		
02/09/23 16:21	342875.1			1.5			10.21			1.21			13.54			1		
02/09/23 16:22	336405.8			1.5			8.76			1.17			11.39			1		
02/09/23 16:23	339255.3			1.5			8.81			1.19			11.55			1		
02/09/23 16:24	334095.3			1.4			8.19			1.11			10.57			1		
02/09/23 16:25	333171.1			1.3			8.13			1.05			10.47			1		
02/09/23 16:26	335789.6			1.3			7.87			0.99			10.21			1		
02/09/23 16:27	336559.8			1.2			7.87			0.92			10.23			1		
02/09/23 16:28	332940.1			1.2			7.87			0.91			10.12			1		
02/09/23 16:29	327548.9			1.2			7.96			0.89			10.07			1		
02/09/23 16:30	307832.8			1.1			7.99			0.79			9.5			1		
02/09/23 16:31	299669.2			1.1			8.39			0.78			9.72			1		
02/09/23 16:32	292891.8			0.9			11.33			0.64			12.82			1		
02/09/23 16:33	295664.3			0.8			11.99			0.59			13.69			1		
02/09/23 16:34	292506.7			0.8			11.89			0.58			13.44			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 16:35	292737.7			0.8			7.68			0.58			8.69			1		
02/09/23 16:36	292121.6			0.8			4.31			0.58			4.86			1		
02/09/23 16:37	293122.8			0.9			4.57			0.59			5.17			1		
02/09/23 16:38	293430.8			0.9			5.71			0.59			6.47			1		
02/09/23 16:39	291197.4			0.8			6.57			0.52			7.39			1		
02/09/23 16:40	292429.7			0.8			5.71			0.52			6.45			1		
02/09/23 16:41	291505.5			0.8			3.62			0.52			4.07			1		
02/09/23 16:42	292583.7			0.8			2.47			0.52			2.8			1		
02/09/23 16:43	292044.6			0.8			1.81			0.52			2.04			1		
02/09/23 16:44	291197.4			0.8			1.52			0.52			1.71			1		
02/09/23 16:45	291351.4			0.8			1.24			0.52			1.39			1		
02/09/23 16:46	291274.4			0.8			1.05			0.52			1.18			0		
02/09/23 16:47	291428.4			0.8			0.86			0.52			0.96			0		
02/09/23 16:48	290581.3			0.8			0.86			0.52			0.96			0		
02/09/23 16:49	291428.4			0.8			0.76			0.52			0.86			0		
02/09/23 16:50	290889.3			0.8			0.76			0.52			0.86			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 23:47	318615.1			0.9			1.09			0.68			1.34			0		
02/09/23 23:48	304290.1			0.9			1.2			0.66			1.41			0		
02/09/23 23:49	290427.2			0.9			1.38			0.63			1.55			0		
02/09/23 23:50	289118			0.9			1.78			0.64			1.99			0		
02/09/23 23:51	288886.9			0.9			2.09			0.58			2.34			0		
02/09/23 23:52	289811.1			0.8			1.9			0.52			2.13			1		
02/09/23 23:53	279645			0.8			1.62			0.5			1.75			1		
02/09/23 23:54	258619.6			0.8			1.74			0.47			1.74			1		
02/09/23 23:55	234975.7			0.7			5.28			0.4			4.79			1		
02/09/23 23:56	209329.4			2.4			9.53			1.17			7.71			1		
02/09/23 23:57	183991.2			87			12.3			37.58			8.75			1		
02/09/23 23:58	163273.9			687.1			14.82			263.48			9.35			1		
02/09/23 23:59	131928.4			1556.3			19.83			482.14			10.11			1		
02/10/23 0:00	0			0			26.35			0			0			0		
02/10/23 0:01	0			0			35.4			0			0			0		
02/10/23 0:02	0			0			0.1			0			0			0		
02/10/23 0:03	0			0			0.1			0			0			0		
02/10/23 0:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/10/23 15:49	0			0			0			0			0			0		
02/10/23 15:50	0			0			0			0			0			0		
02/10/23 15:51	0			0			0			0			0			0		
02/10/23 15:52	0			0			0			0			0			0		
02/10/23 15:53	0			0			0			0			0			0		
02/10/23 15:54	0			0.2			0			0			0			1		
02/10/23 15:55	17174.6			0.2			0			0			0			1		
02/10/23 15:56	33116.9			153.4			53.1			11.92			6.79			1		
02/10/23 15:57	43822.1			1360.4			17.21			140.08			2.92			1		
02/10/23 15:58	57222.9			1070.9			21.02			143.82			4.65			1		
02/10/23 15:59	68313.2			664.2			25.77			106.61			6.81			1		
02/10/23 16:00	96501			501.5			28.62			113.61			10.67			1		
02/10/23 16:01	145406.2			355.3			39.15			121.3			22			1		
02/10/23 16:02	152029.5			225.3			51.84			80.42			30.46			1		
02/10/23 16:03	163042.8			1010			53.1			386.62			33.45			1		
02/10/23 16:04	182065.8			1964.3			53.65			839.84			37.75			1		
02/10/23 16:05	201396.8			1347.8			53.26			637.5			41.46			1		
02/10/23 16:06	227813.3			470.4			53.4			251.65			47.01			1		
02/10/23 16:07	252073.3			55.2			52.33			32.64			50.97			1		
02/10/23 16:08	278489.8			5.4			50.55			3.56			54.4			1		
02/10/23 16:09	307062.7			2.3			41.71			1.64			49.5			1		
02/10/23 16:10	332246.9			2.1			18.54			1.61			23.81			1		
02/10/23 16:11	344030.3			2			12.42			1.64			16.51			1		
02/10/23 16:12	337869.1			2.1			9.8			1.65			12.8			1		
02/10/23 16:13	344569.5			1.9			9.16			1.57			12.2			1		
02/10/23 16:14	338331.2			1.8			8.89			1.4			11.63			1		
02/10/23 16:15	344030.3			1.6			8.28			1.28			11.01			1		
02/10/23 16:16	334249.3			1.5			8.05			1.19			10.39			1		
02/10/23 16:17	341488.8			1.4			7.69			1.15			10.14			1		
02/10/23 16:18	337484			1.3			7.42			1.06			9.68			1		
02/10/23 16:19	341334.8			1.3			7.24			1.07			9.55			1		
02/10/23 16:20	334480.4			1.3			7.15			1.05			9.24			1		
02/10/23 16:21	339717.5			1.3			7.15			1			9.39			1		
02/10/23 16:22	332709			1.2			7.15			0.91			9.19			1		
02/10/23 16:23	337407			1.2			7.24			0.92			9.44			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/10/23 16:24	333633.2			1.1			7.44			0.85			9.6			1		
02/10/23 16:25	338331.2			1.1			7.53			0.87			9.85			1		
02/10/23 16:26	331938.8			1.1			7.62			0.85			9.78			1		
02/10/23 16:27	335866.7			1.1			7.81			0.86			10.13			1		
02/10/23 16:28	335327.5			1.1			7.81			0.86			10.12			1		
02/10/23 16:29	336020.7			1			7.99			0.79			10.37			1		
02/10/23 16:30	334172.3			1			7.99			0.78			10.31			1		
02/10/23 16:31	335250.5			1.1			7.99			0.86			10.35			1		
02/10/23 16:32	326162.7			1			5.81			0.76			7.32			1		
02/10/23 16:33	305753.4			1			3.36			0.72			3.97			1		
02/10/23 16:34	292198.6			1			3.96			0.7			4.48			1		
02/10/23 16:35	291197.4			1			6.66			0.65			7.5			1		
02/10/23 16:36	290350.2			0.9			5.9			0.58			6.62			1		
02/10/23 16:37	291274.4			0.9			3.43			0.59			3.86			1		
02/10/23 16:38	290966.3			0.8			3.24			0.52			3.64			1		
02/10/23 16:39	291736.5			0.8			3.9			0.52			4.4			1		
02/10/23 16:40	290735.3			0.8			4.57			0.52			5.13			1		
02/10/23 16:41	290350.2			0.8			5.23			0.52			5.87			1		
02/10/23 16:42	290966.3			0.8			4.76			0.52			5.35			1		
02/10/23 16:43	295279.3			0.8			3.62			0.53			4.13			1		
02/10/23 16:44	299592.1			0.8			2.76			0.54			3.2			1		
02/10/23 16:45	302133.7			0.8			2.57			0.54			3			1		
02/10/23 16:46	299361.1			0.7			2.25			0.53			2.6			1		
02/10/23 16:47	299284.1			0.8			2.34			0.59			2.71			1		
02/10/23 16:48	298359.9			0.8			2.62			0.59			3.02			1		
02/10/23 16:49	297204.6			0.8			2.81			0.59			3.23			1		
02/10/23 16:50	297974.8			0.7			3			0.52			3.45			1		
02/10/23 16:51	299438.1			0.8			2.9			0.59			3.36			1		
02/10/23 16:52	297666.7			0.8			2.34			0.59			2.69			1		
02/10/23 16:53	314225.2			0.8			2.06			0.62			2.5			1		
02/10/23 16:54	331938.8			0.8			1.87			0.66			2.4			1		
02/10/23 16:55	354350.5			0.8			1.48			0.69			2.02			1		
02/10/23 16:56	357662.2			0.9			1.25			0.75			1.73			1		
02/10/23 16:57	356429.9			1			1.34			0.82			1.85			0		
02/10/23 16:58	360588.8			1.1			1.25			0.91			1.74			0		
02/10/23 16:59	363438.4			1.1			1.61			0.92			2.26			0		
02/10/23 17:00	356044.8			1.1			1.52			0.9			2.09			0		
02/10/23 17:01	351269.8			1.1			1.43			0.88			1.94			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 8:21	291274.4			1			2.09			0.65			2.36			0		
02/12/23 8:22	293353.8			1			2.03			0.67			2.3			0		
02/12/23 8:23	294971.2			0.9			1.71			0.59			1.95			0		
02/12/23 8:24	295048.2			0.9			1.33			0.59			1.52			0		
02/12/23 8:25	294894.2			0.9			1.24			0.59			1.41			0		
02/12/23 8:26	295895.4			0.9			1.24			0.6			1.41			1		
02/12/23 8:27	281262.3			0.9			1.24			0.57			1.34			1		
02/12/23 8:28	258311.6			0.9			1.64			0.53			1.64			1		
02/12/23 8:29	234898.7			0.9			5.18			0.51			4.7			1		
02/12/23 8:30	207404			2.2			9.42			1.05			7.55			1		
02/12/23 8:31	182835.9			121.7			12.31			52.26			8.7			1		
02/12/23 8:32	164275.1			733.8			13.96			283			8.86			1		
02/12/23 8:33	132159.4			1625			19.05			504.17			9.73			1		
02/12/23 8:34	0			2089.8			24.82			0			0			1		
02/12/23 8:35	0			0			35.4			0			0			0		
02/12/23 8:36	0			0			0.1			0			0			0		
02/12/23 8:37	0			0			0.1			0			0			0		
02/12/23 8:38	0			0			0.1			0			0			0		
02/12/23 8:39	0			0			0.1			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:25	0			0			0			0			0			0		
02/12/23 15:26	0			0			0			0			0			0		
02/12/23 15:27	0			0			0			0			0			0		
02/12/23 15:28	0			0			0			0			0			0		
02/12/23 15:29	0			0			0			0			0			0		
02/12/23 15:30	5622.2			0.2			0			0			0			1		
02/12/23 15:31	20486.2			0.2			0			0			0			1		
02/12/23 15:32	34657.2			92.4			11.8			7.53			1.58			1		
02/12/23 15:33	48135			1008.9			6.74			114.05			1.25			1		
02/12/23 15:34	59764.4			666			10.41			93.47			2.4			1		
02/12/23 15:35	71855.9			373.2			12.69			62.98			3.52			1		
02/12/23 15:36	109131.6			259.6			16.58			66.54			6.99			1		
02/12/23 15:37	149257			177.5			20.9			62.22			12.06			1		
02/12/23 15:38	150489.2			136.5			35.99			48.24			20.94			1		
02/12/23 15:39	169897.2			1609.7			35.97			642.12			23.61			1		
02/12/23 15:40	188766.1			1547.7			39.39			685.97			28.73			1		
02/12/23 15:41	213257.2			625.6			41.77			313.24			34.42			1		
02/12/23 15:42	239904.8			103.9			43.58			58.55			40.41			1		
02/12/23 15:43	261700.3			7.5			46.12			4.59			46.64			1		
02/12/23 15:44	288501.8			1.8			45.27			1.24			50.46			1		
02/12/23 15:45	315919.5			1.6			23.5			1.17			28.69			1		
02/12/23 15:46	334557.4			1.5			13.32			1.19			17.22			1		
02/12/23 15:47	336097.7			1.6			9.77			1.25			12.7			1		
02/12/23 15:48	336944.9			1.6			9.25			1.25			12.04			1		
02/12/23 15:49	334865.4			1.5			9.03			1.2			11.68			1		
02/12/23 15:50	337252.9			1.4			8.94			1.13			11.65			1		
02/12/23 15:51	332940.1			1.3			8.67			1.05			11.16			1		
02/12/23 15:52	331707.8			1.3			8.62			0.99			11.05			1		
02/12/23 15:53	321002.6			1.2			8.44			0.89			10.47			1		
02/12/23 15:54	311914.7			1.2			8.26			0.86			9.96			1		
02/12/23 15:55	304598.2			1.1			8.57			0.79			10.09			1		
02/12/23 15:56	298590.9			1			9.18			0.72			10.59			1		
02/12/23 15:57	293738.9			1			10.3			0.71			11.69			1		
02/12/23 15:58	293122.8			1			6.19			0.66			7.01			1		
02/12/23 15:59	290504.3			0.9			3.24			0.58			3.63			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 16:00	293584.9			0.9			2.28			0.59			2.59			1		
02/12/23 16:01	290658.3			0.9			1.71			0.58			1.92			1		
02/12/23 16:02	291813.5			0.9			1.52			0.59			1.72			1		
02/12/23 16:03	289657.1			0.9			1.33			0.58			1.49			1		
02/12/23 16:04	290350.2			0.9			1.24			0.58			1.39			0		
02/12/23 16:05	290119.2			0.9			1.24			0.58			1.39			0		
02/12/23 16:06	289349			0.9			1.24			0.58			1.38			0		
02/12/23 16:07	290581.3			0.9			1.24			0.58			1.39			0		
02/12/23 16:08	291351.4			0.9			1.24			0.59			1.39			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 6:48	508459.4			0.7			1.42			1			3.49			0		
02/15/23 6:49	514774.8			0.7			1.4			1.14			3.57			0		
02/15/23 6:50	509768.7			0.6			1.49			0.99			3.8			0		
02/15/23 6:51	510230.8			0.6			1.55			0.86			3.91			0		
02/15/23 6:52	506842.1			0.6			1.56			0.87			3.92			0		
02/15/23 6:53	216414.9			0.6			1.49			0.4			1.73			1		
02/15/23 6:54	0			0			1.86			0			0			0		
02/15/23 6:55	0			0			0			0			0			0		
02/15/23 6:56	0			0			0			0			0			0		
02/15/23 6:57	0			0			0			0			0			0		
02/15/23 6:58	0			0			0			0			0			0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 7:24	0			0			0			0			0			0		
02/15/23 7:25	0			0			0			0			0			0		
02/15/23 7:26	0			0			0			0			0			0		
02/15/23 7:27	0			0			0			0			0			0		
02/15/23 7:28	0			0			0			0			0			0		
02/15/23 7:29	10320.1			0.3			0			0			0			1		
02/15/23 7:30	25723.3			0.2			0			0			0			1		
02/15/23 7:31	37660.8			39.3			0.98			3.48			0.14			1		
02/15/23 7:32	48982.2			303			0.84			34.86			0.16			1		
02/15/23 7:33	63769.2			262.2			1.11			39.26			0.27			1		
02/15/23 7:34	81636.9			227.5			1.64			43.59			0.52			1		
02/15/23 7:35	127846.5			213.6			4.04			64.13			1.99			1		
02/15/23 7:36	156419.4			188.5			9.75			69.26			5.89			1		
02/15/23 7:37	184299.2			428.2			17.7			185.27			12.6			1		
02/15/23 7:38	186455.7			1298.3			25.34			568.47			18.26			1		
02/15/23 7:39	208636.3			1074			28.22			526.24			22.76			1		
02/15/23 7:40	230277.8			467.7			32.89			252.95			29.28			1		
02/15/23 7:41	254922.9			90.4			34.86			54.1			34.34			1		
02/15/23 7:42	276641.4			7.6			32.99			4.93			35.27			1		
02/15/23 7:43	309758.3			1.7			29.83			1.27			35.7			1		
02/15/23 7:44	333633.2			1.5			11.41			1.16			14.71			1		
02/15/23 7:45	354658.6			1.3			6.88			1.12			9.43			1		
02/15/23 7:46	370831.9			1.4			5.21			1.21			7.46			1		
02/15/23 7:47	391703.3			1.5			5.64			1.34			8.54			1		
02/15/23 7:48	408800.8			1.5			5.12			1.42			8.09			1		
02/15/23 7:49	429595.1			1.4			4.58			1.42			7.6			1		
02/15/23 7:50	455549.5			1.3			4.47			1.43			7.87			1		
02/15/23 7:51	476497.8			1.2			4.47			1.3			8.23			1		
02/15/23 7:52	482967.2			1.1			4.81			1.24			8.98			1		
02/15/23 7:53	494211.5			1.1			5.54			1.26			10.57			1		
02/15/23 7:54	495597.8			1			4.36			1.16			8.34			1		
02/15/23 7:55	500449.8			1.1			2.54			1.28			4.92			1		
02/15/23 7:56	493826.4			1			2.45			1.16			4.68			1		
02/15/23 7:57	500988.9			1			3			1.17			5.8			1		
02/15/23 7:58	498216.3			1			3.45			1.17			6.64			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 7:59	493826.4			1			3.9			1.16			7.45			1		
02/15/23 8:00	473879.3			1			3.9			1.11			7.15			1		
02/15/23 8:01	447000.7			1			2.77			1.03			4.79			1		
02/15/23 8:02	430134.2			1.1			2.11			1.07			3.51			1		
02/15/23 8:03	433985			1.1			1.67			1.08			2.81			1		
02/15/23 8:04	444921.3			1.1			1.7			1.12			2.92			1		
02/15/23 8:05	448926.1			1.1			1.72			1.15			2.99			1		
02/15/23 8:06	447924.9			1			1.97			1.03			3.4			0		
02/15/23 8:07	444228.1			1			2.23			1.03			3.84			0		
02/15/23 8:08	452237.8			1.1			2.5			1.14			4.37			0		
02/15/23 8:09	469643.4			1			2.54			1.1			4.61			0		
02/15/23 8:10	475573.6			1			2.18			1.12			4			0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 23:04	289118			1			1.33			0.65			1.49			0		
02/20/23 23:05	286114.3			1			1.33			0.64			1.47			0		
02/20/23 23:06	288193.8			1			1.33			0.64			1.48			0		
02/20/23 23:07	287962.7			1			1.43			0.64			1.59			0		
02/20/23 23:08	288193.8			1			1.43			0.64			1.59			0		
02/20/23 23:09	287808.7			1			1.43			0.64			1.59			1		
02/20/23 23:10	271250.3			1			1.43			0.61			1.5			1		
02/20/23 23:11	248376.5			1			2.13			0.56			2.04			1		
02/20/23 23:12	225887.8			0.9			6.95			0.5			6.07			1		
02/20/23 23:13	199240.3			3			10.76			1.41			8.28			1		
02/20/23 23:14	175750.5			147.1			13.47			60.73			9.15			1		
02/20/23 23:15	156881.5			852.3			16.23			314.01			9.84			1		
02/20/23 23:16	89492.6			1697			20.57			356.7			7.11			1		
02/20/23 23:17	0			0			25.57			0			0			0		
02/20/23 23:18	0			0			11.8			0			0			0		
02/20/23 23:19	0			0			0.1			0			0			0		
02/20/23 23:20	0			0			0.1			0			0			0		
02/20/23 23:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 16:04	0			0			0			0			0			0		
02/22/23 16:05	0			0			0			0			0			0		
02/22/23 16:06	0			0			0			0			0			0		
02/22/23 16:07	0			0			0			0			0			0		
02/22/23 16:08	0			0			0			0			0			0		
02/22/23 16:09	8009.7			0.3			0			0			0			1		
02/22/23 16:10	22488.7			0.3			0			0			0			1		
02/22/23 16:11	34965.3			64.9			26.55			5.33			3.59			1		
02/22/23 16:12	49290.2			1478.9			15.24			171.15			2.9			1		
02/22/23 16:13	60457.5			1069			18.44			151.71			4.31			1		
02/22/23 16:14	74474.4			681			22.05			119.05			6.34			1		
02/22/23 16:15	111596.1			532.8			25.96			139.65			11.2			1		
02/22/23 16:16	155649.3			384.5			34.12			140.56			20.52			1		
02/22/23 16:17	155110.2			249.9			49.52			91.02			29.68			1		
02/22/23 16:18	172823.8			1417.7			48.15			575.36			32.16			1		
02/22/23 16:19	192925			1881.2			53.28			852.31			39.73			1		
02/22/23 16:20	217955.2			217955.2			58.53			503.32			49.29			1		
02/22/23 16:21	243216.4			253.3			59.82			144.64			56.22			1		
02/22/23 16:22	264472.8			22.7			58.26			14.12			59.54			1		
02/22/23 16:23	290658.3			3.1			55.44			2.13			62.27			1		
02/22/23 16:24	319539.3			2.2			36.8			1.65			45.44			1		
02/22/23 16:25	340795.7			2			19.7			1.6			25.94			1		
02/22/23 16:26	345647.7			2.1			15.01			1.69			20.05			1		
02/22/23 16:27	350037.6			2.2			12.48			1.83			16.89			1		
02/22/23 16:28	351500.9			2.3			11.54			1.86			15.67			1		
02/22/23 16:29	350576.7			2.2			10.59			1.79			14.34			1		
02/22/23 16:30	350037.6			2.1			9.63			1.71			13.03			1		
02/22/23 16:31	346957			1.9			8.94			1.56			11.98			1		
02/22/23 16:32	346494.8			1.7			8.59			1.41			11.5			1		
02/22/23 16:33	344492.4			1.6			8.24			1.33			10.97			1		
02/22/23 16:34	342875.1			1.6			8.01			1.28			10.62			1		
02/22/23 16:35	342336			1.5			7.75			1.2			10.25			1		
02/22/23 16:36	343722.3			1.4			7.57			1.14			10.06			1		
02/22/23 16:37	345647.7			1.4			7.49			1.14			10			1		
02/22/23 16:38	346648.9			1.4			7.49			1.15			10.03			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 16:39	343491.3			1.3			7.57			1.07			10.05			1		
02/22/23 16:40	344415.4			1.3			7.66			1.07			10.2			1		
02/22/23 16:41	343722.3			1.3			7.66			1.07			10.18			1		
02/22/23 16:42	341950.9			1.3			7.75			1.06			10.24			1		
02/22/23 16:43	350576.7			1.2			7.75			1.02			10.5			1		
02/22/23 16:44	362437.2			1.2			7.75			1.05			10.85			1		
02/22/23 16:45	363746.4			1.2			7.49			1.05			10.52			1		
02/22/23 16:46	346957			1.3			7.69			1.02			10.31			1		
02/22/23 16:47	342027.9			1.2			8.1			0.99			10.71			1		
02/22/23 16:48	356275.9			1.2			7.84			1.03			10.79			1		
02/22/23 16:49	382461.3			1.3			7.96			1.12			11.76			1		
02/22/23 16:50	393012.5			1.3			6.44			1.16			9.78			1		
02/22/23 16:51	398480.6			1.2			5.17			1.1			7.97			1		
02/22/23 16:52	409879			1.1			5.81			1.05			9.2			1		
02/22/23 16:53	409648			1.1			6.08			1.05			9.63			1		
02/22/23 16:54	427823.7			1.1			5.72			1.09			9.45			1		
02/22/23 16:55	420969.3			1.1			5.36			1.08			8.71			1		
02/22/23 16:56	425590.3			1.1			3.81			1.09			6.27			1		
02/22/23 16:57	427438.7			1.1			2.9			1.09			4.8			1		
02/22/23 16:58	413267.7			1.1			3.18			1.06			5.07			1		
02/22/23 16:59	403178.6			1.1			3.81			1.03			5.94			1		
02/22/23 17:00	386158.1			1.1			4.02			0.97			6			1		
02/22/23 17:01	373219.4			1.1			3.08			1			4.45			1		
02/22/23 17:02	365979.9			1.2			2.11			1.06			2.99			1		
02/22/23 17:03	363669.4			1.2			1.85			1.05			2.6			1		
02/22/23 17:04	348882.3			1.2			2.03			1.01			2.73			1		
02/22/23 17:05	346571.9			1.2			3.08			1			4.13			1		
02/22/23 17:06	350114.6			1.2			2.99			1.01			4.05			1		
02/22/23 17:07	353657.3			1.2			2.2			1.02			3.01			1		
02/22/23 17:08	358740.4			1.2			2.03			1.04			2.81			1		
02/22/23 17:09	383539.5			1.2			1.85			1.11			2.74			1		
02/22/23 17:10	391626.2			1.2			1.61			1.07			2.44			1		
02/22/23 17:11	386466.2			1.2			1.43			1.05			2.14			1		
02/22/23 17:12	384232.7			1.2			1.52			1.05			2.26			0		
02/22/23 17:13	383847.6			1.2			1.61			1.05			2.39			0		
02/22/23 17:14	402716.5			1.2			1.7			1.1			2.64			0		
02/22/23 17:15	426129.4			1.1			1.63			1.09			2.69			0		
02/22/23 17:16	421508.4			1.1			1.72			1.08			2.81			0		

CT2 SUSD EVENT 17

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 13:03	289118			0.8			1.26			0.53			1.4			0		
02/23/23 13:04	289888.1			0.8			1.26			0.53			1.41			0		
02/23/23 13:05	290196.2			0.8			1.26			0.53			1.41			0		
02/23/23 13:06	292814.7			0.9			1.24			0.59			1.4			0		
02/23/23 13:07	292198.6			0.9			1.33			0.59			1.5			0		
02/23/23 13:08	284805.1			0.9			1.33			0.57			1.47			1		
02/23/23 13:09	261700.3			0.8			1.45			0.48			1.47			1		
02/23/23 13:10	240674.9			0.8			4.37			0.46			4.07			1		
02/23/23 13:11	212641.1			1.8			8.57			0.89			7.05			1		
02/23/23 13:12	187533.9			11.2			11.67			4.92			8.46			1		
02/23/23 13:13	167894.8			565			13.63			222.72			8.84			1		
02/23/23 13:14	146792.4			1444.7			17.06			498.02			9.68			1		
02/23/23 13:15	11783.4			2013.2			21.76			55.88			0.99			1		
02/23/23 13:16	0			0			23.6			0			0			0		
02/23/23 13:17	0			0			0.1			0			0			0		
02/23/23 13:18	0			0			0.1			0			0			0		
02/23/23 13:19	0			0			0.1			0			0			0		
02/23/23 13:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 17:22	0			0			0			0			0			0		
02/27/23 17:23	0			0			0			0			0			0		
02/27/23 17:24	0			0			0			0			0			0		
02/27/23 17:25	0			0			0			0			0			0		
02/27/23 17:26	43591			0			0			0			0			0		
02/27/23 17:27	5699.2			0.3			0			0			0			1		
02/27/23 17:28	23104.8			0.3			0			0			0			1		
02/27/23 17:29	36274.5			59			17.7			5.02			2.48			1		
02/27/23 17:30	49136.2			1437.8			13.16			165.75			2.5			1		
02/27/23 17:31	61535.8			1126.9			18.07			162.96			4.3			1		
02/27/23 17:32	75321.6			703.3			20.81			124.38			6.06			1		
02/27/23 17:33	110672			548.7			23.6			142.6			10.09			1		
02/27/23 17:34	153415.8			403.3			24.11			145.24			14.29			1		
02/27/23 17:35	175134.3			268			43.62			110.21			29.52			1		
02/27/23 17:36	203322.2			1163.4			41.3			555.48			32.45			1		
02/27/23 17:37	232665.3			703.6			50.38			384.46			45.3			1		
02/27/23 17:38	257387.4			106.6			54.41			64.42			54.12			1		
02/27/23 17:39	278720.8			7.3			55.07			4.77			59.32			1		
02/27/23 17:40	303288.9			1.9			52.47			1.35			61.5			1		
02/27/23 17:41	308988.1			1.7			27.22			1.24			32.5			1		
02/27/23 17:42	328473.1			1.6			22.33			1.26			28.35			1		
02/27/23 17:43	349036.4			1.7			19.99			1.37			26.96			1		
02/27/23 17:44	358894.4			1.8			15.22			1.51			21.11			1		
02/27/23 17:45	353657.3			1.8			13.85			1.49			18.93			1		
02/27/23 17:46	350961.8			1.8			12.23			1.48			16.59			1		
02/27/23 17:47	350191.6			1.8			10.6			1.48			14.35			1		
02/27/23 17:48	348959.4			1.7			9.54			1.42			12.87			1		
02/27/23 17:49	348805.3			1.6			8.94			1.35			12.05			1		
02/27/23 17:50	347111			1.6			8.16			1.27			10.94			1		
02/27/23 17:51	345878.7			1.5			7.72			1.2			10.32			1		
02/27/23 17:52	344184.4			1.4			7.4			1.14			9.84			1		
02/27/23 17:53	347419.1			1.3			7.13			1.08			9.58			1		
02/27/23 17:54	345185.6			1.3			7.04			1.07			9.4			1		
02/27/23 17:55	346032.8			1.3			7.13			1.07			9.54			1		
02/27/23 17:56	347419.1			1.3			7.22			1.08			9.69			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 17:57	345339.6			1.2			7.22			1			9.64			1		
02/27/23 17:58	347419.1			1.2			7.31			1.01			9.81			1		
02/27/23 17:59	364593.6			1.2			7.31			1.06			10.3			1		
02/27/23 18:00	391164.1			1.2			6.43			1.13			9.72			1		
02/27/23 18:01	402177.4			1.2			4.72			1.11			7.34			1		
02/27/23 18:02	378225.4			1.1			5.26			0.97			7.7			1		
02/27/23 18:03	371602.1			1.1			6.08			1			8.73			1		
02/27/23 18:04	382615.3			1.1			6.25			1.03			9.25			1		
02/27/23 18:05	396324.2			1.3			5.54			1.16			8.49			1		
02/27/23 18:06	414808			1.2			5.08			1.15			8.15			1		
02/27/23 18:07	408338.7			1.1			5.54			1.04			8.74			1		
02/27/23 18:08	411727.4			1			5.63			0.97			8.95			1		
02/27/23 18:09	408338.7			1			5.72			0.96			9.02			1		
02/27/23 18:10	418581.8			1.1			5.17			1.07			8.37			1		
02/27/23 18:11	400868.1			1.1			3.18			1.03			4.92			1		
02/27/23 18:12	414885			1.1			2.41			1.05			3.87			1		
02/27/23 18:13	400560.1			1.1			2.59			1.01			4.01			1		
02/27/23 18:14	383231.5			1.1			3.31			0.97			4.9			1		
02/27/23 18:15	367828.3			1.1			4.05			0.91			5.76			1		
02/27/23 18:16	370754.9			1.1			2.99			1			4.29			1		
02/27/23 18:17	370908.9			1.1			1.85			1			2.65			1		
02/27/23 18:18	375915			1.1			1.76			1.01			2.56			1		
02/27/23 18:19	389700.8			1.1			1.94			1.05			2.92			1		
02/27/23 18:20	390933.1			1.2			2.15			1.07			3.24			1		
02/27/23 18:21	390162.9			1.2			2.5			1.06			3.77			0		
02/27/23 18:22	393474.6			1.1			2.82			1.06			4.29			0		
02/27/23 18:23	390933.1			1.1			2.73			1.05			4.12			0		
02/27/23 18:24	409339.9			1.2			2.15			1.12			3.39			0		
02/27/23 18:25	424820.1			1.1			1.82			1.09			2.98			0		

CT2 SUSD EVENT 19

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 23:04	293430.8			0.7			1.45			0.47			1.65			0		
02/27/23 23:05	291813.5			0.8			1.43			0.52			1.61			0		
02/27/23 23:06	294740.1			0.8			1.33			0.53			1.52			0		
02/27/23 23:07	293276.8			0.8			1.33			0.52			1.51			0		
02/27/23 23:08	294432.1			0.8			1.24			0.53			1.41			0		
02/27/23 23:09	293738.9			0.9			1.24			0.59			1.4			1		
02/27/23 23:10	280646.2			0.9			1.33			0.56			1.44			1		
02/27/23 23:11	256001.1			0.9			1.84			0.52			1.82			1		
02/27/23 23:12	233435.4			0.8			6.01			0.46			5.42			1		
02/27/23 23:13	208636.3			2.7			9.53			1.33			7.69			1		
02/27/23 23:14	184530.3			128.3			12.44			55.58			8.87			1		
02/27/23 23:15	163813			736.5			14.25			283.23			9.02			1		
02/27/23 23:16	134392.9			1574			18.52			496.79			9.62			1		
02/27/23 23:17	0			1958			23.98			0			0			1		
02/27/23 23:18	0			0			47.2			0			0			0		
02/27/23 23:19	0			0			0.1			0			0			0		
02/27/23 23:20	0			0			0.1			0			0			0		
02/27/23 23:21	0			0			0.1			0			0			0		
02/27/23 23:22	0			0			0.1			0			0			0		

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 16:49	0			0			0			0			0			0		
02/28/23 16:50	0			0			0			0			0			0		
02/28/23 16:51	0			0			0			0			0			0		
02/28/23 16:52	0			0			0			0			0			0		
02/28/23 16:53	0			0			0			0			0			0		
02/28/23 16:54	9550			0.3			0			0			0			1		
02/28/23 16:55	27263.7			1.2			0			0			0			1		
02/28/23 16:56	41434.6			1374.7			18.44			133.86			2.95			1		
02/28/23 16:57	53911.2			1373.9			14.95			174.07			3.12			1		
02/28/23 16:58	65001.5			903.4			19.67			137.91			4.94			1		
02/28/23 16:59	83793.4			618.3			25.37			121.66			8.22			1		
02/28/23 17:00	129925.9			509.4			27.53			155.41			13.83			1		
02/28/23 17:01	155495.3			359.2			44.84			131.14			26.94			1		
02/28/23 17:02	157728.7			422.7			55.38			156.6			33.77			1		
02/28/23 17:03	169435.1			1892.2			53.29			752.66			34.89			1		
02/28/23 17:04	189228.3			1857.6			56.14			825.4			41.05			1		
02/28/23 17:05	211562.9			1120.2			56.61			556.42			46.28			1		
02/28/23 17:06	237440.3			375.2			56.33			209.22			51.69			1		
02/28/23 17:07	259466.8			48.2			53.6			29.37			53.75			1		
02/28/23 17:08	286114.3			4.2			50.87			2.84			56.24			1		
02/28/23 17:09	310836.5			2.2			38.04			1.63			45.7			1		
02/28/23 17:10	335789.6			2.1			17.98			1.67			23.32			1		
02/28/23 17:11	351346.9			2.1			13.97			1.72			18.97			1		
02/28/23 17:12	353195.3			2.2			11.12			1.84			15.17			1		
02/28/23 17:13	351269.8			2.2			10.18			1.83			13.81			1		
02/28/23 17:14	351963			2.1			9.32			1.7			12.68			1		
02/28/23 17:15	349344.4			1.9			8.72			1.54			11.78			1		
02/28/23 17:16	349190.4			1.7			8.5			1.42			11.47			1		
02/28/23 17:17	347650.1			1.6			7.98			1.27			10.72			1		
02/28/23 17:18	346186.8			1.5			7.81			1.2			10.45			1		
02/28/23 17:19	344338.4			1.5			7.64			1.19			10.16			1		
02/28/23 17:20	343799.3			1.4			7.49			1.14			9.94			1		
02/28/23 17:21	343029.1			1.3			7.31			1.06			9.69			1		
02/28/23 17:22	343645.3			1.3			7.22			1.07			9.59			1		
02/28/23 17:23	344723.5			1.2			7.22			1			9.62			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 17:24	345185.6			1.2			7.22			1			9.63			1		
02/28/23 17:25	345185.6			1.2			7.4			1			9.87			1		
02/28/23 17:26	343722.3			1.2			7.49			1			9.94			1		
02/28/23 17:27	344107.4			1.2			7.49			1			9.95			1		
02/28/23 17:28	343876.3			1.2			7.57			1			10.06			1		
02/28/23 17:29	343106.2			1.2			7.66			0.99			10.16			1		
02/28/23 17:30	345185.6			1.1			7.66			0.93			10.22			1		
02/28/23 17:31	347650.1			1.1			7.75			0.93			10.41			1		
02/28/23 17:32	336328.8			1.1			8.01			0.9			10.42			1		
02/28/23 17:33	328627.2			1.1			7.93			0.88			10.06			1		
02/28/23 17:34	325931.6			1.2			8.05			0.89			10.13			1		
02/28/23 17:35	319693.3			1.1			8.22			0.81			10.16			1		
02/28/23 17:36	312607.8			1.1			6.54			0.8			7.89			1		
02/28/23 17:37	306523.6			1			3.72			0.72			4.41			1		
02/28/23 17:38	301363.5			1			3.69			0.72			4.29			1		
02/28/23 17:39	295510.3			0.9			4.79			0.64			5.47			1		
02/28/23 17:40	292660.7			0.9			6.09			0.64			6.88			1		
02/28/23 17:41	292429.7			0.8			5.53			0.58			6.25			1		
02/28/23 17:42	292121.6			0.8			3.65			0.58			4.12			1		
02/28/23 17:43	303519.9			0.8			2.66			0.54			3.13			1		
02/28/23 17:44	326701.8			0.8			2.15			0.65			2.72			1		
02/28/23 17:45	349113.4			0.8			1.27			0.67			1.71			1		
02/28/23 17:46	364208.5			0.9			1.07			0.76			1.51			1		
02/28/23 17:47	358355.3			1.1			1.06			0.89			1.46			1		
02/28/23 17:48	362591.2			1.1			1.14			0.97			1.6			0		
02/28/23 17:49	381614.2			1.1			1.14			1.03			1.69			0		
02/28/23 17:50	399943.9			1.2			1.07			1.09			1.66			0		
02/28/23 17:51	413267.7			1.1			0.91			1.06			1.45			0		
02/28/23 17:52	416271.3			1			0.91			0.98			1.46			0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/01/23 8:07	290273.2			0.8			1.35			0.53			1.52			0		
03/01/23 8:08	290581.3			0.8			1.45			0.53			1.63			0		
03/01/23 8:09	290273.2			0.8			1.45			0.53			1.63			0		
03/01/23 8:10	291120.4			0.8			1.45			0.53			1.63			0		
03/01/23 8:11	291043.3			0.8			1.45			0.53			1.63			0		
03/01/23 8:12	282186.5			0.8			1.45			0.51			1.58			1		
03/01/23 8:13	259081.7			0.8			1.87			0.48			1.87			1		
03/01/23 8:14	236208			0.7			5.69			0.41			5.19			1		
03/01/23 8:15	209252.4			2.5			8.74			1.23			7.06			1		
03/01/23 8:16	186147.6			104.3			11.54			45.59			8.31			1		
03/01/23 8:17	166893.6			585.4			13.81			229.45			8.91			1		
03/01/23 8:18	144636			1301			15.9			441.77			8.88			1		
03/01/23 8:19	0			1757.1			22.46			0			0			1		
03/01/23 8:20	0			0			36.88			0			0			0		
03/01/23 8:21	0			0			0.1			0			0			0		
03/01/23 8:22	0			0			0.1			0			0			0		
03/01/23 8:23	0			0			0.1			0			0			0		
03/01/23 8:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:05	0			0			0			0			0			0		
03/03/23 15:06	0			0			0			0			0			0		
03/03/23 15:07	0			0			0			0			0			0		
03/03/23 15:08	0			0			0			0			0			0		
03/03/23 15:09	0			0			0			0			0			0		
03/03/23 15:10	6392.3			0.4			0			0			0			1		
03/03/23 15:11	23027.8			0.4			0			0			0			1		
03/03/23 15:12	36582.6			73.8			23.6			6.34			3.34			1		
03/03/23 15:13	48520.1			1275.8			14.07			145.36			2.64			1		
03/03/23 15:14	60611.6			921.1			17.7			131.13			4.15			1		
03/03/23 15:15	74397.4			601.2			21.74			104.97			6.25			1		
03/03/23 15:16	109516.7			460.2			24.72			118.36			10.47			1		
03/03/23 15:17	151952.5			327.3			34.63			116.79			20.34			1		
03/03/23 15:18	159808.1			206.3			49.44			77.4			30.52			1		
03/03/23 15:19	171591.6			1259.1			43.14			507.32			28.61			1		
03/03/23 15:20	191769.8			1556.2			48.59			700.88			36.01			1		
03/03/23 15:21	215105.6			859.8			58.69			434.41			48.8			1		
03/03/23 15:22	240520.9			221.6			63.94			125.15			59.43			1		
03/03/23 15:23	261623.3			20.8			63.18			12.76			63.87			1		
03/03/23 15:24	288039.8			3			60.89			2.03			67.79			1		
03/03/23 15:25	314841.3			2.1			37.4			1.55			45.51			1		
03/03/23 15:26	338023.1			1.9			20			1.54			26.13			1		
03/03/23 15:27	344646.5			2			14.23			1.61			18.95			1		
03/03/23 15:28	344646.5			2.1			12.23			1.69			16.29			1		
03/03/23 15:29	349036.4			2			11.02			1.64			14.86			1		
03/03/23 15:30	350499.7			1.9			9.63			1.57			13.05			1		
03/03/23 15:31	349575.5			1.8			9.28			1.5			12.54			1		
03/03/23 15:32	347111			1.8			8.37			1.44			11.22			1		
03/03/23 15:33	352887.2			1.7			7.57			1.39			10.33			1		
03/03/23 15:34	346879.9			1.6			7.49			1.29			10.03			1		
03/03/23 15:35	346186.8			1.5			6.69			1.22			8.95			1		
03/03/23 15:36	344261.4			1.4			6.52			1.14			8.67			1		
03/03/23 15:37	342952.1			1.4			6.43			1.13			8.52			1		
03/03/23 15:38	341257.8			1.3			6.44			1.07			8.49			1		
03/03/23 15:39	343029.1			1.3			6.26			1.08			8.29			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:40	343645.3			1.3			6.35			1.08			8.43			1		
03/03/23 15:41	342952.1			1.3			6.35			1.01			8.41			1		
03/03/23 15:42	343183.2			1.3			6.44			1.01			8.54			1		
03/03/23 15:43	342490			1.2			6.53			0.93			8.64			1		
03/03/23 15:44	342104.9			1.2			6.53			0.93			8.63			1		
03/03/23 15:45	343029.1			1.2			6.62			0.94			8.77			1		
03/03/23 15:46	342336			1.2			6.62			0.93			8.75			1		
03/03/23 15:47	341642.8			1.2			6.7			0.93			8.85			1		
03/03/23 15:48	343722.3			1.2			6.88			0.94			9.14			1		
03/03/23 15:49	343491.3			1.2			7.15			0.94			9.49			1		
03/03/23 15:50	336559.8			1.2			7.24			0.92			9.42			1		
03/03/23 15:51	322311.8			1.2			7.24			0.88			9.02			1		
03/03/23 15:52	317690.9			1.2			7.26			0.88			8.92			1		
03/03/23 15:53	310682.4			1.1			7.01			0.81			8.41			1		
03/03/23 15:54	304675.2			1			4.61			0.73			5.43			1		
03/03/23 15:55	296511.5			1			3.56			0.72			4.08			1		
03/03/23 15:56	291736.5			0.9			4.31			0.64			4.86			1		
03/03/23 15:57	291505.5			1			5.52			0.65			6.22			1		
03/03/23 15:58	290735.3			0.9			4.76			0.58			5.35			1		
03/03/23 15:59	290812.3			0.9			3.24			0.58			3.64			1		
03/03/23 16:00	290504.3			0.9			2.85			0.58			3.2			1		
03/03/23 16:01	293199.8			0.9			2.66			0.59			3.02			1		
03/03/23 16:02	293584.9			0.9			2.85			0.59			3.24			1		
03/03/23 16:03	292891.8			0.9			3.14			0.59			3.55			1		
03/03/23 16:04	293892.9			0.9			3.24			0.59			3.67			1		
03/03/23 16:05	292044.6			0.8			3.09			0.58			3.49			1		
03/03/23 16:06	290889.3			0.9			2.95			0.58			3.32			1		
03/03/23 16:07	291274.4			0.9			2.66			0.59			3			1		
03/03/23 16:08	290812.3			0.9			2.38			0.58			2.67			1		
03/03/23 16:09	291428.4			0.9			2.09			0.59			2.36			1		
03/03/23 16:10	291043.3			0.9			1.9			0.59			2.14			1		
03/03/23 16:11	293122.8			0.9			1.81			0.59			2.05			1		
03/03/23 16:12	293430.8			0.9			1.71			0.59			1.94			1		
03/03/23 16:13	294355			0.9			1.71			0.59			1.95			0		
03/03/23 16:14	295048.2			0.9			1.62			0.59			1.84			0		
03/03/23 16:15	292968.8			0.9			1.62			0.59			1.83			0		
03/03/23 16:16	292814.7			0.9			1.62			0.59			1.83			0		
03/03/23 16:17	290042.2			0.9			1.62			0.58			1.81			0		

CT2 SUSD EVENT 23

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 22:48	289811.1			0.8			1.52			0.52			1.71			0		
03/03/23 22:49	289888.1			0.8			1.43			0.52			1.6			0		
03/03/23 22:50	289965.1			0.8			1.33			0.52			1.49			0		
03/03/23 22:51	289272			0.9			1.33			0.58			1.49			0		
03/03/23 22:52	289195			0.9			1.33			0.58			1.49			0		
03/03/23 22:53	282494.6			0.9			1.33			0.57			1.45			1		
03/03/23 22:54	260160			0.9			1.52			0.52			1.53			1		
03/03/23 22:55	236593.1			0.8			4.98			0.45			4.56			1		
03/03/23 22:56	209945.5			1.6			9.02			0.77			7.31			1		
03/03/23 22:57	185300.4			9.4			12.18			4.1			8.72			1		
03/03/23 22:58	165892.4			511.8			14.47			199.32			9.27			1		
03/03/23 22:59	145945.3			1246.8			18.82			427.29			10.61			1		
03/03/23 23:00	12476.6			1727			24.71			50.64			1.19			1		
03/03/23 23:01	0			0			36.58			0			0			0		
03/03/23 23:02	0			0			0.2			0			0			0		
03/03/23 23:03	0			0			0.2			0			0			0		
03/03/23 23:04	0			0			0.1			0			0			0		
03/03/23 23:05	0			0			0.1			0			0			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 16:52	0			0			0			0			0			0		
03/04/23 16:53	0			0			0			0			0			0		
03/04/23 16:54	0			0			0			0			0			0		
03/04/23 16:55	0			0			0			0			0			0		
03/04/23 16:56	0			0			0			0			0			0		
03/04/23 16:57	17867.7			0.3			0			0			0			1		
03/04/23 16:58	29112			1.2			0.1			0			0			1		
03/04/23 16:59	42743.9			1282.3			18.36			128.59			3.03			1		
03/04/23 17:00	54450.3			1182.4			17.7			151.12			3.72			1		
03/04/23 17:01	66310.8			743.4			23.93			115.82			6.14			1		
03/04/23 17:02	88953.4			523.6			27.44			109.36			9.43			1		
03/04/23 17:03	136780.4			423.4			36.8			136			19.46			1		
03/04/23 17:04	161502.5			284.3			50.15			107.82			31.3			1		
03/04/23 17:05	196005.7			557			59.18			256.35			44.83			1		
03/04/23 17:06	221960			784.4			62.35			408.75			53.47			1		
03/04/23 17:07	246990.2			148.3			60.34			86.01			57.6			1		
03/04/23 17:08	269478.9			10.6			57.82			6.72			60.22			1		
03/04/23 17:09	296434.5			1.8			54.07			1.27			61.94			1		
03/04/23 17:10	320848.5			1.6			27.93			1.19			34.63			1		
03/04/23 17:11	339640.4			1.5			17.79			1.21			23.35			1		
03/04/23 17:12	341950.9			1.7			13			1.37			17.17			1		
03/04/23 17:13	342182			1.9			11.71			1.53			15.49			1		
03/04/23 17:14	338870.3			1.8			10.5			1.45			13.75			1		
03/04/23 17:15	338100.1			1.8			9.54			1.45			12.47			1		
03/04/23 17:16	337175.9			1.7			8.89			1.32			11.59			1		
03/04/23 17:17	336482.8			1.6			8.72			1.25			11.34			1		
03/04/23 17:18	336636.8			1.4			8.01			1.11			10.42			1		
03/04/23 17:19	335943.7			1.3			7.66			1.04			9.95			1		
03/04/23 17:20	336790.8			1.3			7.69			1.06			10.01			1		
03/04/23 17:21	333941.3			1.3			7.6			1.05			9.81			1		
03/04/23 17:22	333710.2			1.3			7.51			1.05			9.68			1		
03/04/23 17:23	333017.1			1.3			7.33			0.98			9.43			1		
03/04/23 17:24	333325.1			1.3			7.42			0.98			9.56			1		
03/04/23 17:25	332555			1.3			7.42			0.98			9.54			1		
03/04/23 17:26	330475.5			1.3			7.33			0.97			9.36			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 17:27	331245.7			1.3			7.24			0.97			9.27			1		
03/04/23 17:28	330552.6			1.2			7.24			0.9			9.25			1		
03/04/23 17:29	314071.1			1.2			7.33			0.86			8.9			1		
03/04/23 17:30	302210.7			1.2			8.08			0.84			9.43			1		
03/04/23 17:31	293276.8			1.1			10.05			0.76			11.39			1		
03/04/23 17:32	292352.6			1			11.71			0.71			13.23			1		
03/04/23 17:33	291505.5			0.9			12.36			0.64			13.93			1		
03/04/23 17:34	290273.2			0.9			12.83			0.64			14.39			1		
03/04/23 17:35	288732.9			0.9			13.2			0.63			14.73			1		
03/04/23 17:36	290889.3			0.9			13.49			0.64			15.16			1		
03/04/23 17:37	291659.5			0.9			13.39			0.64			15.1			1		
03/04/23 17:38	291197.4			0.9			8.9			0.64			10.01			1		
03/04/23 17:39	290889.3			0.8			5.06			0.58			5.68			1		
03/04/23 17:40	290735.3			0.8			3.28			0.58			3.68			1		
03/04/23 17:41	290504.3			0.8			2.43			0.57			2.73			1		
03/04/23 17:42	291043.3			0.9			2			0.59			2.25			1		
03/04/23 17:43	290504.3			0.9			1.71			0.58			1.92			1		
03/04/23 17:44	290119.2			0.9			1.43			0.58			1.6			1		
03/04/23 17:45	290735.3			0.9			1.24			0.58			1.39			1		
03/04/23 17:46	290581.3			0.9			1.14			0.58			1.28			0		
03/04/23 17:47	289811.1			0.9			1.05			0.58			1.17			0		
03/04/23 17:48	290350.2			0.9			0.95			0.58			1.07			0		
03/04/23 17:49	290504.3			0.9			0.86			0.58			0.96			0		
03/04/23 17:50	290504.3			0.9			0.86			0.58			0.96			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 22:47	288809.9			0.9			1.71			0.58			1.91			0		
03/04/23 22:48	287808.7			0.8			1.62			0.51			1.8			0		
03/04/23 22:49	288270.8			0.8			1.52			0.52			1.7			0		
03/04/23 22:50	287038.5			0.8			1.43			0.51			1.58			0		
03/04/23 22:51	287500.6			0.8			1.43			0.51			1.59			0		
03/04/23 22:52	284959.1			0.8			1.33			0.51			1.47			1		
03/04/23 22:53	263086.6			0.8			1.43			0.47			1.45			1		
03/04/23 22:54	240443.9			0.8			3.8			0.45			3.53			1		
03/04/23 22:55	213257.2			0.8			7.87			0.38			6.48			1		
03/04/23 22:56	189151.2			6.1			10.96			2.73			8.01			1		
03/04/23 22:57	169666.2			368			13.58			146.63			8.91			1		
03/04/23 22:58	149719			1179.5			18.02			414.79			10.43			1		
03/04/23 22:59	38199.9			1740			22.88			156.18			3.38			1		
03/04/23 23:00	0			0			27.35			0			0			0		
03/04/23 23:01	0			0			5.9			0			0			0		
03/04/23 23:02	0			0			0.1			0			0			0		
03/04/23 23:03	0			0			0.1			0			0			0		
03/04/23 23:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 15:49	0			0			0			0			0			0		
03/05/23 15:50	0			0			0			0			0			0		
03/05/23 15:51	0			0			0			0			0			0		
03/05/23 15:52	0			0			0			0			0			0		
03/05/23 15:53	0			0			0			0			0			0		
03/05/23 15:54	5006			0.3			0			0			0			1		
03/05/23 15:55	21872.5			0.4			0			0			0			1		
03/05/23 15:56	36120.5			159.3			47.2			13.51			6.59			1		
03/05/23 15:57	48212			1290.7			16.79			146.2			3.13			1		
03/05/23 15:58	59995.4			957.6			23.23			134.84			5.38			1		
03/05/23 15:59	73550.3			597.5			27.33			103.25			7.77			1		
03/05/23 16:00	109439.7			482.6			29.21			124.02			12.35			1		
03/05/23 16:01	153107.8			332.7			42.58			119.61			25.19			1		
03/05/23 16:02	177675.8			206.3			58.59			86.08			40.24			1		
03/05/23 16:03	183298			954.5			60.43			410.89			42.81			1		
03/05/23 16:04	171514.6			902.1			56.67			363.27			37.56			1		
03/05/23 16:05	183837.1			1399.4			52.61			603.97			37.37			1		
03/05/23 16:06	206325.8			1115.6			51.82			540.39			41.31			1		
03/05/23 16:07	232203.2			416.3			52.81			227.01			47.39			1		
03/05/23 16:08	255230.9			55.2			51.82			33.05			51.1			1		
03/05/23 16:09	280107.1			5.4			52.52			3.58			56.85			1		
03/05/23 16:10	307832.8			2.5			42.67			1.83			50.76			1		
03/05/23 16:11	331245.7			2.3			19.03			1.78			24.36			1		
03/05/23 16:12	345185.6			2.1			13.56			1.71			18.09			1		
03/05/23 16:13	351500.9			2.2			10.93			1.79			14.85			1		
03/05/23 16:14	350422.7			2.1			10.24			1.71			13.86			1		
03/05/23 16:15	348805.3			2			9.46			1.63			12.75			1		
03/05/23 16:16	347496.1			1.8			8.85			1.49			11.88			1		
03/05/23 16:17	346494.8			1.7			8.63			1.36			11.56			1		
03/05/23 16:18	345955.8			1.6			8.37			1.29			11.18			1		
03/05/23 16:19	344954.5			1.5			8.19			1.21			10.92			1		
03/05/23 16:20	342798.1			1.4			8.01			1.13			10.62			1		
03/05/23 16:21	343106.2			1.4			7.84			1.14			10.39			1		
03/05/23 16:22	341180.8			1.4			7.87			1.15			10.37			1		
03/05/23 16:23	341411.8			1.3			7.87			1.07			10.38			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 16:24	338947.3			1.3			7.87			1.07			10.31			1		
03/05/23 16:25	339563.4			1.3			7.87			1			10.32			1		
03/05/23 16:26	341950.9			1.3			7.78			1			10.28			1		
03/05/23 16:27	341565.8			1.2			7.87			0.93			10.38			1		
03/05/23 16:28	341642.8			1.2			8.05			0.93			10.62			1		
03/05/23 16:29	341257.8			1.3			8.13			1			10.73			1		
03/05/23 16:30	340949.7			1.2			8.22			0.93			10.84			1		
03/05/23 16:31	341488.8			1.2			8.31			0.93			10.97			1		
03/05/23 16:32	323929.2			1.2			8.31			0.88			10.41			1		
03/05/23 16:33	315842.5			1.2			8.62			0.88			10.52			1		
03/05/23 16:34	314533.2			1.1			9.22			0.82			11.2			1		
03/05/23 16:35	304059.1			1			7.01			0.72			8.23			1		
03/05/23 16:36	299669.2			1			3.5			0.71			4.06			1		
03/05/23 16:37	294201			1			2.62			0.71			2.98			1		
03/05/23 16:38	291736.5			0.9			2.34			0.64			2.64			1		
03/05/23 16:39	291659.5			1			2			0.65			2.25			1		
03/05/23 16:40	292506.7			0.9			1.71			0.59			1.94			1		
03/05/23 16:41	291274.4			0.9			1.52			0.59			1.71			1		
03/05/23 16:42	292198.6			0.9			1.33			0.59			1.5			1		
03/05/23 16:43	298667.9			0.9			1.14			0.6			1.32			0		
03/05/23 16:44	320001.4			0.9			1.05			0.64			1.29			0		
03/05/23 16:45	342104.9			0.8			0.83			0.67			1.1			0		
03/05/23 16:46	357123.1			0.9			0.64			0.76			0.88			0		
03/05/23 16:47	357277.1			1.1			0.54			0.9			0.74			0		

CT2 SUSD EVENT 27

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 1:33	289426			0.8			1.74			0.53			1.95			0		
03/06/23 1:34	288578.8			0.8			1.55			0.52			1.73			0		
03/06/23 1:35	289580.1			0.8			1.45			0.53			1.62			0		
03/06/23 1:36	289734.1			0.8			1.45			0.53			1.62			0		
03/06/23 1:37	288732.9			0.8			1.35			0.52			1.51			0		
03/06/23 1:38	281262.3			0.8			1.35			0.51			1.47			1		
03/06/23 1:39	259081.7			0.8			1.77			0.48			1.77			1		
03/06/23 1:40	235976.9			0.8			5.16			0.47			4.71			1		
03/06/23 1:41	208790.3			3.1			7.94			1.5			6.41			1		
03/06/23 1:42	185300.4			117.6			10.39			51.18			7.44			1		
03/06/23 1:43	166046.4			701.5			12.81			273.55			8.22			1		
03/06/23 1:44	146869.5			1427.6			16.23			492.46			9.21			1		
03/06/23 1:45	0			1841.4			22.65			0			0			1		
03/06/23 1:46	0			0			28.03			0			0			0		
03/06/23 1:47	0			0			0.1			0			0			0		
03/06/23 1:48	0			0			0.1			0			0			0		
03/06/23 1:49	0			0			0.1			0			0			0		
03/06/23 1:50	0			0			0.1			0			0			0		

CT2 SUSD EVENT 28

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 13:05	0			0			0			0			0			0		
03/06/23 13:06	0			0			0			0			0			0		
03/06/23 13:07	0			0			0			0			0			0		
03/06/23 13:08	0			0			0			0			0			0		
03/06/23 13:09	0			0			0			0			0			0		
03/06/23 13:10	11167.3			0.3			0			0			0			1		
03/06/23 13:11	24799.1			0.4			0			0			0			1		
03/06/23 13:12	38970.1			51.1			21.63			4.65			3.24			1		
03/06/23 13:13	51369.7			1215.4			15.73			145.83			3.11			1		
03/06/23 13:14	63153.1			876			22.56			129.22			5.48			1		
03/06/23 13:15	77632.1			591.9			27.33			107.31			8.15			1		
03/06/23 13:16	119528.8			470.9			24.72			131.44			11.36			1		
03/06/23 13:17	155880.3			333.6			43.76			121.42			26.21			1		
03/06/23 13:18	171129.5			246			55.85			98.31			36.73			1		
03/06/23 13:19	171668.6			1331.3			53.82			533.71			35.51			1		
03/06/23 13:20	173440			1465.5			50.81			593.43			33.86			1		
03/06/23 13:21	188843.2			1638.3			49.56			722.47			35.97			1		
03/06/23 13:22	213642.3			1064.2			49.43			530.76			40.57			1		
03/06/23 13:23	237902.3			301.6			49.73			167.5			45.45			1		
03/06/23 13:24	259774.9			48.7			48.2			29.54			48.11			1		
03/06/23 13:25	285113.1			5.2			48.33			3.47			52.96			1		
03/06/23 13:26	311837.7			2.7			36.33			1.96			43.53			1		
03/06/23 13:27	336174.7			2.3			17.23			1.84			22.26			1		
03/06/23 13:28	353426.3			2.2			12.15			1.79			16.49			1		
03/06/23 13:29	356198.9			2.3			10.24			1.88			14.01			1		
03/06/23 13:30	356506.9			2.2			9.89			1.81			13.55			1		
03/06/23 13:31	355582.8			2			8.94			1.66			12.21			1		
03/06/23 13:32	354273.5			1.8			8.85	X		1.51			12.05	X		1		
03/06/23 13:33	353041.2			1.6			8.59			1.36			11.65			1		
03/06/23 13:34	352733.2			1.6			7.98			1.29			10.82			1		
03/06/23 13:35	350730.8			1.6			7.93			1.3			10.68			1		
03/06/23 13:36	351192.8			1.4			7.84			1.16			10.58			1		
03/06/23 13:37	350653.7			1.4			7.75			1.15			10.44			1		
03/06/23 13:38	351269.8			1.3			7.75			1.08			10.46			1		
03/06/23 13:39	351192.8			1.3			7.75			1.08			10.46			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 13:40	348728.3			1.3			7.75			1.08			10.38			1		
03/06/23 13:41	348882.3			1.2			7.75			1			10.39			1		
03/06/23 13:42	337869.1			1.2			7.75			0.97			10.06			1		
03/06/23 13:43	315688.5			1.3			7.6			0.92			9.22			1		
03/06/23 13:44	308449			1.2			8.17			0.85			9.68			1		
03/06/23 13:45	304598.2			1.1			10.23			0.79			11.98			1		
03/06/23 13:46	304136.1			1			10.97			0.72			12.82			1		
03/06/23 13:47	304290.1			1			11.8			0.73			13.8			1		
03/06/23 13:48	302133.7			1			11.99			0.73			13.92			1		
03/06/23 13:49	301209.5			0.9			12.17			0.66			14.09			1		
03/06/23 13:50	302518.8			0.9			12.55			0.66			14.59			1		
03/06/23 13:51	301902.6			0.9			12.74			0.66			14.78			1		
03/06/23 13:52	301440.5			0.9			12.92			0.66			14.97			1		
03/06/23 13:53	301286.5			0.9			13.11			0.66			15.18			1		
03/06/23 13:54	299207.1			0.9			13.3			0.65			15.29			1		
03/06/23 13:55	298745			0.9			13.49			0.65			15.48			1		
03/06/23 13:56	298822			0.9			13.77			0.65			15.81			1		
03/06/23 13:57	299130			0.9			13.95			0.65			16.04			1		
03/06/23 13:58	307293.7			0.8			14.14			0.6			16.7			1		
03/06/23 13:59	317305.8			0.9			12.27			0.69			14.96			1		
03/06/23 14:00	318846.1			0.9			5.44			0.69			6.66			1		
03/06/23 14:01	315149.3			0.9			3.69			0.68			4.47			1		
03/06/23 14:02	314379.2			1			4.43			0.74			5.35			1		
03/06/23 14:03	312838.9			1			5.35			0.74			6.43			1		
03/06/23 14:04	311760.7			0.9			6.08			0.67			7.29			1		
03/06/23 14:05	308911.1			0.9			5.07			0.66			6.02			1		
03/06/23 14:06	308757			0.9			3.23			0.66			3.83			1		
03/06/23 14:07	308449			0.9			2.77			0.66			3.28			1		
03/06/23 14:08	308526			0.9			2.58			0.66			3.06			1		
03/06/23 14:09	307986.9			0.9			2.86			0.66			3.38			1		
03/06/23 14:10	308911.1			0.9			3.41			0.66			4.05			1		
03/06/23 14:11	308911.1			0.9			3.41			0.66			4.05			1		
03/06/23 14:12	308294.9			0.9			3.04			0.66			3.6			1		
03/06/23 14:13	318153			0.9			2.4			0.68			2.93			1		
03/06/23 14:14	341026.7			0.9			2.12			0.73			2.78			1		
03/06/23 14:15	362514.2			0.9			1.45			0.77			2.02			1		
03/06/23 14:16	382384.3			1			1.43			0.88			2.1			1		
03/06/23 14:17	401099.2			1.1			1.43			1			2.2			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 14:18	424204			1.1			1.18			1.08			1.92			0		
03/06/23 14:19	446538.6			1			1.11			1.06			1.9			0		
03/06/23 14:20	472107.9			1			1.2			1.12			2.17			0		
03/06/23 14:21	492286.1			1			1.31			1.18			2.48			0		
03/06/23 14:22	495289.7			0.9			1.84			1.07			3.51			0		

CT2 SUSD EVENT 29

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 8:04	290581.3			0.8			1.26			0.52			1.4			0		
03/07/23 8:05	292891.8			0.8			1.26			0.53			1.42			0		
03/07/23 8:06	292814.7			0.8			1.26			0.53			1.41			0		
03/07/23 8:07	292121.6			0.8			1.35			0.53			1.52			0		
03/07/23 8:08	291274.4			0.8			1.35			0.53			1.52			0		
03/07/23 8:09	285498.2			0.8			1.35			0.52			1.49			1		
03/07/23 8:10	265705.1			0.8			1.45			0.48			1.48			1		
03/07/23 8:11	238903.5			0.8			3.87			0.45			3.55			1		
03/07/23 8:12	217416.1			1.6			7.57			0.79			6.32			1		
03/07/23 8:13	190460.5			9			10.2			3.99			7.46			1		
03/07/23 8:14	171591.6			504.9			12.5			202.29			8.24			1		
03/07/23 8:15	149565			1287.5			15.31			449.59			8.8			1		
03/07/23 8:16	0			1838			21.2			0			0			1		
03/07/23 8:17	0			0			18.88			0			0			0		
03/07/23 8:18	0			0			0.1			0			0			0		
03/07/23 8:19	0			0			0.1			0			0			0		
03/07/23 8:20	0			0			0.1			0			0			0		
03/07/23 8:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 30

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 16:43	0			0			0			0			0			0		
03/07/23 16:44	0			0			0			0			0			0		
03/07/23 16:45	0			0			0			0			0			0		
03/07/23 16:46	0			0			0			0			0			0		
03/07/23 16:47	0			0			0			0			0			0		
03/07/23 16:48	3542.7			0.3			0			0			0			1		
03/07/23 16:49	24029			0.3			0			0			0			1		
03/07/23 16:50	37352.7			41.3			10.62			3.61			1.53			1		
03/07/23 16:51	49521.3			1259.2			7.16			145.45			1.36			1		
03/07/23 16:52	61381.7			856.5			11.11			122.71			2.62			1		
03/07/23 16:53	74551.5			549.3			14.28			95.67			4.09			1		
03/07/23 16:54	111904.2			422.3			17.14			110.31			7.37			1		
03/07/23 16:55	155264.2			298.6			22.57			108.21			13.46			1		
03/07/23 16:56	151875.5			196.3			36.82			69.61			21.49			1		
03/07/23 16:57	172900.9			1517.8			35.78			612.59			23.77			1		
03/07/23 16:58	181295.6			1799.1			38.98			761.56			27.15			1		
03/07/23 16:59	211793.9			1211.8			40.15			599.2			32.68			1		
03/07/23 17:00	233127.3			404.9			41.44			220.45			37.13			1		
03/07/23 17:01	252920.5			53			43.61			31.28			42.38			1		
03/07/23 17:02	280107.1			5			43.91			3.27			47.27			1		
03/07/23 17:03	316920.7			2.2			37.88			1.61			46.13			1		
03/07/23 17:04	338870.3			1.9			17.61			1.48			22.92			1		
03/07/23 17:05	340795.7			1.8			12.86			1.4			16.84			1		
03/07/23 17:06	337252.9			1.8			10.24			1.43			13.27			1		
03/07/23 17:07	337561			1.7			9.63			1.37			12.49			1		
03/07/23 17:08	337946.1			1.6			9.2			1.3			11.94			1		
03/07/23 17:09	340333.6			1.6			8.89			1.26			11.63			1		
03/07/23 17:10	341103.8			1.5			8.81			1.19			11.54			1		
03/07/23 17:11	332786			1.4			8.63			1.09			11.04			1		
03/07/23 17:12	336482.8			1.3			8.67			1.05			11.21			1		
03/07/23 17:13	334942.5			1.3			8.85			0.98			11.39			1		
03/07/23 17:14	311452.6			1.3			8.94			0.91			10.7			1		
03/07/23 17:15	300593.3			1.2			10.35			0.83			11.95			1		
03/07/23 17:16	296280.4			1.1			13			0.77			14.8			1		
03/07/23 17:17	295587.3			1			14.42			0.71			16.38			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 17:18	295741.3			0.9			14.61			0.65			16.6			1		
03/07/23 17:19	294663.1			1			10.09			0.65			11.42			1		
03/07/23 17:20	294894.2			0.9			5.33			0.59			6.04			1		
03/07/23 17:21	295818.3			0.9			3.71			0.59			4.22			1		
03/07/23 17:22	295895.4			0.9			3.81			0.59			4.33			1		
03/07/23 17:23	294894.2			0.9			4.66			0.59			5.28			1		
03/07/23 17:24	293199.8			0.9			5.14			0.59			5.79			1		
03/07/23 17:25	293584.9			0.9			4.76			0.59			5.37			1		
03/07/23 17:26	293584.9			0.9			3.62			0.59			4.08			1		
03/07/23 17:27	295048.2			0.9			2.85			0.59			3.24			1		
03/07/23 17:28	293970			0.9			2.66			0.59			3.01			1		
03/07/23 17:29	293970			0.9			2.57			0.59			2.9			1		
03/07/23 17:30	293970			0.9			2.57			0.59			2.9			1		
03/07/23 17:31	293815.9			0.9			2.57			0.59			2.9			1		
03/07/23 17:32	293276.8			0.9			2.57			0.59			2.9			1		
03/07/23 17:33	292121.6			0.8			2.47			0.52			2.78			1		
03/07/23 17:34	292506.7			0.8			2.38			0.52			2.67			1		
03/07/23 17:35	293507.9			0.8			2.28			0.52			2.58			1		
03/07/23 17:36	292506.7			0.8			2.09			0.52			2.35			1		
03/07/23 17:37	293199.8			0.8			2			0.52			2.25			1		
03/07/23 17:38	294124			0.8			1.9			0.52			2.15			1		
03/07/23 17:39	293430.8			0.8			1.81			0.52			2.04			1		
03/07/23 17:40	292275.6			0.8			1.71			0.52			1.92			0		
03/07/23 17:41	292968.8			0.8			1.71			0.52			1.93			0		
03/07/23 17:42	292583.7			0.8			1.62			0.52			1.82			0		
03/07/23 17:43	295510.3			0.8			1.62			0.53			1.84			0		
03/07/23 17:44	300824.4			0.8			1.62			0.53			1.87			0		

CT2 SUSD EVENT 31

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 11:09	292121.6			0.9			1.52			0.58			1.71			0		
03/08/23 11:10	293199.8			0.9			1.62			0.59			1.82			0		
03/08/23 11:11	293584.9			0.9			1.62			0.59			1.82			0		
03/08/23 11:12	294817.2			0.9			1.62			0.59			1.83			0		
03/08/23 11:13	291890.5			0.8			1.59			0.57			1.79			0		
03/08/23 11:14	282417.6			0.9			1.59			0.62			1.73			1		
03/08/23 11:15	261777.3			0.9			1.84			0.53			1.85			1		
03/08/23 11:16	239673.7			0.9			5.7			0.51			5.25			1		
03/08/23 11:17	212333			0.9			10.35			0.44			8.45			1		
03/08/23 11:18	189151.2			9.1			13.64			4.02			9.92			1		
03/08/23 11:19	167894.8			472.1			17			185.06			10.96			1		
03/08/23 11:20	147793.7			1219.9			20.57			420.79			11.68			1		
03/08/23 11:21	12399.6			1791.9			25.08			51.74			1.19			1		
03/08/23 11:22	0			0			24.44			0			0			0		
03/08/23 11:23	0			0			0.2			0			0			0		
03/08/23 11:24	0			0			0.1			0			0			0		
03/08/23 11:25	0			0			0.1			0			0			0		
03/08/23 11:26	0			0			0.1			0			0			0		

CT2 SUSD EVENT 32

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 18:13	0			0			0			0			0			0		
03/08/23 18:14	0			0			0			0			0			0		
03/08/23 18:15	0			0			0			0			0			0		
03/08/23 18:16	0			0			0			0			0			0		
03/08/23 18:17	0			0			0			0			0			0		
03/08/23 18:18	12630.6			0.1			0			0			0			1		
03/08/23 18:19	27571.7			1.1			0			0			0			1		
03/08/23 18:20	40895.5			1097.4			9.18			104.89			1.44			1		
03/08/23 18:21	52216.8			1132			9.44			138.1			1.9			1		
03/08/23 18:22	64539.4			697.8			12.78			105.13			3.17			1		
03/08/23 18:23	84563.5			471.7			16.82			93.13			5.46			1		
03/08/23 18:24	131389.3			371.4			21.91			113.9			11.06			1		
03/08/23 18:25	163813			239.3			33.51			91.55			21.1			1		
03/08/23 18:26	204862.5			423.7			41.11			202.66			32.36			1		
03/08/23 18:27	234590.7			594			45.65			325.38			41.15			1		
03/08/23 18:28	260082.9			55.2			47.33			33.49			47.3			1		
03/08/23 18:29	286499.4			2.6			46.86			1.75			51.58			1		
03/08/23 18:30	309450.2			1.2			35.91			0.88			42.7			1		
03/08/23 18:31	334942.5			1.1			16.86			0.88			21.69			1		
03/08/23 18:32	348959.4			1.2			12.67			0.99			16.99			1		
03/08/23 18:33	357816.2			1.4			10.59			1.16			14.55			1		
03/08/23 18:34	352502.1			1.5			10.33			1.21			13.99			1		
03/08/23 18:35	350037.6			1.4			9.8			1.13			13.19			1		
03/08/23 18:36	348420.3			1.3			9.2			1.06			12.31			1		
03/08/23 18:37	349267.4			1.2			8.98			1.01			12.05			1		
03/08/23 18:38	348420.3			1.2			8.98	X		1			12.02	X		1		
03/08/23 18:39	348497.3			1.1			8.98	X		0.93			12.03	X		1		
03/08/23 18:40	348574.3			1.1			8.89	X		0.93			11.91	X		1		
03/08/23 18:41	338485.2			1.1			8.89	X		0.83			11.57	X		1		
03/08/23 18:42	330475.5			1.1			8.76			0.83			11.12			1		
03/08/23 18:43	325931.6			1.1			8.58			0.82			10.75			1		
03/08/23 18:44	319539.3			1			8.8			0.74			10.81			1		
03/08/23 18:45	312530.8			0.8			8.99			0.6			10.79			1		
03/08/23 18:46	306215.5			0.9			10.69			0.66			12.58			1		
03/08/23 18:47	300516.3			0.8			11.25			0.58			12.99			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 18:48	297281.7			0.8			6.46			0.59			7.38			1		
03/08/23 18:49	294201			0.7			3.65			0.51			4.13			1		
03/08/23 18:50	294355			0.7			2.72			0.51			3.07			1		
03/08/23 18:51	293353.8			0.7			2.15			0.51			2.43			1		
03/08/23 18:52	294278			0.7			1.97			0.51			2.22			1		
03/08/23 18:53	293353.8			0.7			1.78			0.51			2.01			1		
03/08/23 18:54	292814.7			0.7			1.69			0.51			1.9			1		
03/08/23 18:55	290273.2			0.7			1.69			0.51			1.88			1		
03/08/23 18:56	292891.8			0.8			1.71			0.52			1.93			0		
03/08/23 18:57	291428.4			0.8			1.71			0.52			1.92			0		
03/08/23 18:58	300747.4			0.8			1.71			0.53			1.98			0		
03/08/23 18:59	307755.8			0.7			1.69			0.54			1.99			0		
03/08/23 19:00	308140.9			0.7			1.4			0.54			1.66			0		

CT2 SUSD EVENT 33

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:03	287423.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:04	287577.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:05	287500.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:06	288732.9			0.7			1.31			0.44			1.45			0		
03/09/23 23:07	288270.8			0.7			1.31			0.44			1.45			0		
03/09/23 23:08	281647.4			0.7			1.4			0.49			1.52			1		
03/09/23 23:09	260005.9			0.8			1.52			0.46			1.52			1		
03/09/23 23:10	237363.2			0.7			4.7			0.39			4.29			1		
03/09/23 23:11	208636.3			0.7			9.61			0.32			7.71			1		
03/09/23 23:12	186609.7			8.2			12.29			3.59			8.81			1		
03/09/23 23:13	165122.3			477.8			14.96			184.16			9.49			1		
03/09/23 23:14	144482			1298.6			19.93			438.08			11.07			1		
03/09/23 23:15	0			1935.4			25.69			0			0			1		
03/09/23 23:16	0			0			53.1			0			0			0		
03/09/23 23:17	0			0			0.1			0			0			0		
03/09/23 23:18	0			0			0.1			0			0			0		
03/09/23 23:19	0			0			0.1			0			0			0		
03/09/23 23:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 34

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 15:44	0			0			0			0			0			0		
03/10/23 15:45	0			0			0			0			0			0		
03/10/23 15:46	0			0			0			0			0			0		
03/10/23 15:47	0			0			0			0			0			0		
03/10/23 15:48	0			0			0			0			0			0		
03/10/23 15:49	3696.8			0.1			0			0			0			1		
03/10/23 15:50	22488.7			0.1			0			0			0			1		
03/10/23 15:51	35504.4			49.2			31.47			4.07			4.29			1		
03/10/23 15:52	48366			1238.2			15.59			139.69			2.9			1		
03/10/23 15:53	59918.4			898.9			22.91			125.76			5.27			1		
03/10/23 15:54	73704.3			554.9			26.26			95.52			7.44			1		
03/10/23 15:55	113136.5			440.8			32.03			116.44			13.92			1		
03/10/23 15:56	150797.3			292.1			42.53			102.83			24.65			1		
03/10/23 15:57	154186			215.5			57.23			77.58			33.9			1		
03/10/23 15:58	161887.6			1538.2			52.18			581.57			32.47			1		
03/10/23 15:59	179909.3			1825.6			52.74			766.64			36.45			1		
03/10/23 16:00	202398			1257.7			55.39			594.31			43.08			1		
03/10/23 16:01	227505.2			405.7			53.68			215.48			46.92			1		
03/10/23 16:02	250764			55.2			53.74			32.28			51.77			1		
03/10/23 16:03	274407.9			4.5			52.76			2.91			55.63			1		
03/10/23 16:04	302672.8			2.3			40.58			1.61			47.19			1		
03/10/23 16:05	325546.5			2			19.01			1.49			23.78			1		
03/10/23 16:06	336482.8			1.9			13.12			1.52			16.96			1		
03/10/23 16:07	337638			2			10.5			1.57			13.62			1		
03/10/23 16:08	335866.7			1.9			9.72			1.5			12.54			1		
03/10/23 16:09	333556.2			1.8			9.16			1.37			11.74			1		
03/10/23 16:10	334326.3			1.6			8.54			1.24			10.97			1		
03/10/23 16:11	331476.8			1.4			8.28			1.09			10.54			1		
03/10/23 16:12	331476.8			1.3			7.87			1.04			10.02			1		
03/10/23 16:13	330013.4			1.3			7.78			1.03			9.86			1		
03/10/23 16:14	329551.3			1.3			7.6			0.96			9.62			1		
03/10/23 16:15	328165.1			1.3			7.51			0.96			9.47			1		
03/10/23 16:16	326624.8			1.2			7.33			0.89			9.2			1		
03/10/23 16:17	326393.7			1.2			7.35			0.9			9.22			1		
03/10/23 16:18	325084.4			1.1			7.35			0.83			9.18			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 16:19	328473.1			1.1			7.35			0.84			9.28			1		
03/10/23 16:20	327625.9			1			7.26			0.76			9.14			1		
03/10/23 16:21	325700.5			1			7.35			0.76			9.2			1		
03/10/23 16:22	324930.4			1			7.26			0.76			9.07			1		
03/10/23 16:23	326316.7			1			7.26			0.76			9.11			1		
03/10/23 16:24	315072.3			1			7.35			0.73			8.9			1		
03/10/23 16:25	303288.9			1			7.81			0.71			9.1			1		
03/10/23 16:26	300593.3			0.9			9.13			0.65			10.54			1		
03/10/23 16:27	294894.2			0.8			10.4			0.58			11.78			1		
03/10/23 16:28	290812.3			0.8			11.33			0.57			12.66			1		
03/10/23 16:29	288963.9			0.7			12.27			0.51			13.62			1		
03/10/23 16:30	290196.2			0.8			8.66			0.52			9.66			1		
03/10/23 16:31	290427.2			0.8			4.38			0.52			4.88			1		
03/10/23 16:32	289888.1			0.8			3.52			0.52			3.92			1		
03/10/23 16:33	289503			0.8			4.38			0.51			4.87			1		
03/10/23 16:34	290119.2			0.7			5.33			0.45			5.94			1		
03/10/23 16:35	289272			0.7			5.9			0.45			6.56			1		
03/10/23 16:36	289349			0.7			4.95			0.45			5.5			1		
03/10/23 16:37	289118			0.7			3.52			0.45			3.91			1		
03/10/23 16:38	289349			0.8			2.95			0.51			3.28			1		
03/10/23 16:39	289349			0.7			2.76			0.45			3.07			1		
03/10/23 16:40	287731.7			0.7			2.95			0.45			3.26			1		
03/10/23 16:41	288655.9			0.7			3.33			0.45			3.69			1		
03/10/23 16:42	289195			0.7			3.52			0.45			3.91			1		
03/10/23 16:43	290350.2			0.7			3.33			0.45			3.72			1		
03/10/23 16:44	307139.7			0.7			2.66			0.48			3.14			1		
03/10/23 16:45	328550.1			0.7			1.97			0.5			2.48			1		
03/10/23 16:46	347342			0.7			1.38			0.6			1.85			1		
03/10/23 16:47	349652.5			0.8			1.34			0.66			1.8			1		
03/10/23 16:48	353349.3			0.9			1.43			0.74			1.94			1		
03/10/23 16:49	371140			1			1.52			0.85			2.17			0		
03/10/23 16:50	391164.1			1			1.34			0.9			2.02			0		
03/10/23 16:51	402177.4			0.9			1.18			0.85			1.82			0		
03/10/23 16:52	401407.3			0.9			1.2			0.86			1.85			0		
03/10/23 16:53	409493.9			0.8			1.27			0.78			2			0		

CT2 SUSD EVENT 35

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 20:39	348112.2			1			1.32			0.79			1.77			0		
03/10/23 20:40	325546.5			1			1.41			0.74			1.76			0		
03/10/23 20:41	311067.5			1			1.61			0.71			1.92			0		
03/10/23 20:42	313224			0.9			1.57			0.67			1.89			0		
03/10/23 20:43	305214.3			0.8			1.48			0.59			1.73			0		
03/10/23 20:44	289888.1			0.8			1.38			0.56			1.54			1		
03/10/23 20:45	275717.2			0.8			1.5			0.54			1.59			1		
03/10/23 20:46	253613.6			0.8			2.28			0.45			2.23			1		
03/10/23 20:47	230893.9			0.6			7.25			0.33			6.43			1		
03/10/23 20:48	203861.3			1.5			15.54			0.7			12.17			1		
03/10/23 20:49	180679.5			10.5			19.71			4.45			13.68			1		
03/10/23 20:50	161117.4			610.4			23.46			229.56			14.52			1		
03/10/23 20:51	139784			1425.8			28.84			465.35			15.49			1		
03/10/23 20:52	0			1896.2			32.93			0			0			1		
03/10/23 20:53	0			0			35.4			0			0			0		
03/10/23 20:54	0			0			0.2			0			0			0		
03/10/23 20:55	0			0			0.2			0			0			0		
03/10/23 20:56	0			0			0.1			0			0			0		
03/10/23 20:57	0			0			0.1			0			0			0		

CT2 SUSD EVENT 36

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 16:54	0			0			0			0			0			0		
03/11/23 16:55	0			0			0			0			0			0		
03/11/23 16:56	0			0			0			0			0			0		
03/11/23 16:57	0			0			0			0			0			0		
03/11/23 16:58	0			0			0			0			0			0		
03/11/23 16:59	4081.8			0.1			0			0			0			1		
03/11/23 17:00	22796.7			0			0			0			0			1		
03/11/23 17:01	36120.5			62.9			29.5			5.31			4.1			1		
03/11/23 17:02	49213.2			1338			14.33			153.65			2.71			1		
03/11/23 17:03	60765.6			971.4			20.13			137.86			4.7			1		
03/11/23 17:04	75090.6			640.9			25.46			112.34			7.34			1		
03/11/23 17:05	114214.7			491.4			27.25			131			11.96			1		
03/11/23 17:06	152337.6			367.1			39.5			130.57			23.13			1		
03/11/23 17:07	158884			257.4			54.73			95.46			33.41			1		
03/11/23 17:08	174518.2			1520			51.63			619.24			34.61			1		
03/11/23 17:09	193618.2			1643.2			55.36			742.61			41.17			1		
03/11/23 17:10	218032.2			826.6			54.16			420.76			45.37			1		
03/11/23 17:11	241445.1			195.9			54.17			110.42			50.25			1		
03/11/23 17:12	265243			17.3			52.26			10.74			53.25			1		
03/11/23 17:13	291813.5			2.5			51.71			1.68			57.98			1		
03/11/23 17:14	317228.8			1.9			28.12			1.38			34.28			1		
03/11/23 17:15	338100.1			1.8			16.98			1.41			22.06			1		
03/11/23 17:16	340256.6			1.9			12.49			1.52			16.34			1		
03/11/23 17:17	337946.1			2			10.93			1.57			14.2			1		
03/11/23 17:18	336482.8			1.9			10.06			1.5			13.01			1		
03/11/23 17:19	333787.2			1.7			9.2			1.35			11.79			1		
03/11/23 17:20	334865.4			1.6			8.89			1.24			11.44			1		
03/11/23 17:21	332709			1.4			8.72			1.09			11.14			1		
03/11/23 17:22	330937.6			1.3			8.37			1.02			10.64			1		
03/11/23 17:23	330167.5			1.2			8.1			0.95			10.28			1		
03/11/23 17:24	329936.4			1.2			8.05			0.9			10.2			1		
03/11/23 17:25	329012.2			1.2			8.05			0.89			10.17			1		
03/11/23 17:26	330475.5			1.1			7.96			0.83			10.1			1		
03/11/23 17:27	331938.8			1.1			7.96			0.83			10.15			1		
03/11/23 17:28	330321.5			1.1			7.87			0.83			9.98			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 17:29	328935.2			1.1			7.87			0.82			9.94			1		
03/11/23 17:30	329012.2			1			7.78			0.76			9.83			1		
03/11/23 17:31	329397.3			1			7.78			0.76			9.84			1		
03/11/23 17:32	328473.1			1			7.69			0.75			9.7			1		
03/11/23 17:33	328011			1			7.78			0.75			9.8			1		
03/11/23 17:34	330937.6			1			7.9			0.77			10.04			1		
03/11/23 17:35	330475.5			1			7.87			0.76			9.99			1		
03/11/23 17:36	333864.3			1			7.87			0.77			10.09			1		
03/11/23 17:37	329936.4			1			8.05			0.76			10.2			1		
03/11/23 17:38	313686.1			1			8.22			0.72			9.91			1		
03/11/23 17:39	310374.4			0.9			8.71			0.66			10.39			1		
03/11/23 17:40	302364.7			0.8			9.22			0.59			10.71			1		
03/11/23 17:41	297127.6			0.8			4.33			0.58			4.95			1		
03/11/23 17:42	292352.6			0.7			3.13			0.5			3.52			1		
03/11/23 17:43	290273.2			0.7			4.31			0.51			4.81			1		
03/11/23 17:44	290196.2			0.7			5.71			0.44			6.37			1		
03/11/23 17:45	289118			0.7			5.53			0.44			6.14			1		
03/11/23 17:46	287577.6			0.7			3.84			0.44			4.24			1		
03/11/23 17:47	288886.9			0.7			2.72			0.44			3.01			1		
03/11/23 17:48	290350.2			0.7			2.43			0.44			2.72			1		
03/11/23 17:49	289349			0.7			2.34			0.44			2.6			1		
03/11/23 17:50	289118			0.7			2.43			0.44			2.71			1		
03/11/23 17:51	289272			0.7			2.62			0.44			2.91			1		
03/11/23 17:52	289118			0.7			2.62			0.44			2.91			1		
03/11/23 17:53	288963.9			0.7			2.62			0.44			2.91			1		
03/11/23 17:54	289040.9			0.7			2.53			0.44			2.81			1		
03/11/23 17:55	289580.1			0.7			2.34			0.44			2.6			1		
03/11/23 17:56	290504.3			0.7			2.15			0.44			2.4			1		
03/11/23 17:57	290119.2			0.7			1.97			0.44			2.19			1		
03/11/23 17:58	291043.3			0.7			1.78			0.45			1.99			1		
03/11/23 17:59	290119.2			0.7			1.69			0.44			1.88			1		
03/11/23 18:00	290273.2			0.7			1.59			0.44			1.78			0		
03/11/23 18:01	288809.9			0.7			1.59			0.44			1.77			0		
03/11/23 18:02	289272			0.7			1.59			0.44			1.77			0		
03/11/23 18:03	289272			1.1	X		1.64	X		0.77	X		1.82	X		0		
03/11/23 18:04	289503			0.6	X		1.61	X		0.43	X		1.79	X		0		

CT2 SUSD EVENT 37

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 7:06	286268.4			0.7			1.4			0.44			1.55			0		
03/12/23 7:07	285960.3			0.6			1.43			0.38			1.57			0		
03/12/23 7:08	287346.6			0.6			1.43			0.38			1.58			0		
03/12/23 7:09	286961.5			0.6			1.43			0.38			1.57			0		
03/12/23 7:10	287654.7			0.6			1.43			0.38			1.58			0		
03/12/23 7:11	286422.4			0.6			1.43			0.38			1.57			1		
03/12/23 7:12	278027.7			0.6			1.43			0.37			1.52			1		
03/12/23 7:13	253459.6			0.6			1.81			0.34			1.76			1		
03/12/23 7:14	230277.8			0.5			6.21			0.28			5.5			1		
03/12/23 7:15	203630.2			1.8			10.02			0.85			7.84			1		
03/12/23 7:16	181603.7			2.1			14.37			0.87			10.02			1		
03/12/23 7:17	159654.1			602.8			17.27			224.67			10.59			1		
03/12/23 7:18	141709.4			1322.4			21.8			437.52			11.87			1		
03/12/23 7:19	10859.3			1777.4			26.65			44.96			1.11			1		
03/12/23 7:20	0			0			29.5			0			0			0		
03/12/23 7:21	0			0			0.1			0			0			0		
03/12/23 7:22	0			0			0.1			0			0			0		
03/12/23 7:23	0			0			0.1			0			0			0		
03/12/23 7:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 38

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 15:02	0			0			0			0			0			0		
03/12/23 15:03	0			0			0			0			0			0		
03/12/23 15:04	0			0			0			0			0			0		
03/12/23 15:05	0			0			0			0			0			0		
03/12/23 15:06	1848.4			0			0			0			0			0		
03/12/23 15:07	9704			0			0			0			0			1		
03/12/23 15:08	27109.6			0.9			0			0			0			1		
03/12/23 15:09	41357.6			1168.9			9.83			112.77			1.56			1		
03/12/23 15:10	52601.9			1142			10.33			140.34			2.09			1		
03/12/23 15:11	64308.3			698.4			13.66			104.9			3.38			1		
03/12/23 15:12	81791			488.8			17.7			93.33			5.56			1		
03/12/23 15:13	130388			359.1			20.92			109.32			10.48			1		
03/12/23 15:14	151336.4			246.2			33.36			86.97			19.39			1		
03/12/23 15:15	179062.1			562.8			38.45			235.33			26.46			1		
03/12/23 15:16	218879.4			1314			43.9			671.49			36.92			1		
03/12/23 15:17	246297.1			218.2			46.51			125.46			44.02			1		
03/12/23 15:18	269324.8			11.2			45.93			7.06			47.53			1		
03/12/23 15:19	294971.2			1.7			42.99			1.16			48.73			1		
03/12/23 15:20	320232.4			1.4			20.8			1.01			25.59			1		
03/12/23 15:21	331553.8			1.3			13.3			1.02			16.94			1		
03/12/23 15:22	334018.3			1.4			10.06			1.08			12.92			1		
03/12/23 15:23	335866.7			1.4			9.2			1.09			11.87			1		
03/12/23 15:24	336713.8			1.3			8.85			1.02			11.45			1		
03/12/23 15:25	335866.7			1.2			8.63			0.97			11.14			1		
03/12/23 15:26	336405.8			1.1			8.54			0.9			11.04			1		
03/12/23 15:27	335250.5			1.1			8.28			0.9			10.66			1		
03/12/23 15:28	333479.2			1.1			8.01			0.82			10.27			1		
03/12/23 15:29	330860.6			1			7.93			0.75			10.08			1		
03/12/23 15:30	319077.2			1			8.05			0.73			9.86			1		
03/12/23 15:31	309835.3			1			8.31			0.71			9.9			1		
03/12/23 15:32	304829.2			0.9			9.53			0.65			11.16			1		
03/12/23 15:33	298436.9			0.8			10.51			0.58			12.05			1		
03/12/23 15:34	294047			0.8			11.34			0.57			12.81			1		
03/12/23 15:35	293122.8			0.7			11.98			0.5			13.5			1		
03/12/23 15:36	291120.4			0.7			8.33			0.45			9.32			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 15:37	289657.1			0.6			4.12			0.38			4.59			1		
03/12/23 15:38	290889.3			0.6			3.18			0.38			3.56			1		
03/12/23 15:39	290812.3			0.6			4.03			0.38			4.5			1		
03/12/23 15:40	288270.8			0.7			4.96			0.44			5.5			1		
03/12/23 15:41	289349			0.6			5.81			0.38			6.46			1		
03/12/23 15:42	289580.1			0.6			4.87			0.38			5.42			1		
03/12/23 15:43	290812.3			0.6			3.28			0.38			3.66			1		
03/12/23 15:44	291274.4			0.6			2.53			0.38			2.83			1		
03/12/23 15:45	290504.3			0.6			2.53			0.38			2.82			1		
03/12/23 15:46	290273.2			0.6			2.72			0.38			3.03			1		
03/12/23 15:47	290889.3			0.6			3.09			0.38			3.45			1		
03/12/23 15:48	291582.5			0.6			3.28			0.38			3.67			1		
03/12/23 15:49	288732.9			0.6			3.28			0.38			3.64			1		
03/12/23 15:50	286268.4			0.6			3			0.38			3.3			1		
03/12/23 15:51	290812.3			0.6			2.95			0.39			3.3			1		
03/12/23 15:52	295125.2			0.6			2.34			0.39			2.65			1		
03/12/23 15:53	298513.9			0.6			1.78			0.39			2.04			1		
03/12/23 15:54	320309.4			0.6			1.5			0.42			1.84			1		
03/12/23 15:55	341334.8			0.6			1.38			0.44			1.81			1		
03/12/23 15:56	352271.1			0.6			1.16			0.51			1.57			0		
03/12/23 15:57	351192.8			0.8			1.23			0.65			1.66			0		
03/12/23 15:58	333094.1			0.9			1.32			0.68			1.69			0		
03/12/23 15:59	309758.3			0.9			1.34			0.65			1.6			0		
03/12/23 16:00	296665.5			0.9			1.27			0.63			1.45			0		

CT2 SUSD EVENT 39

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 0:03	286037.3			0.6			1.5			0.38			1.65			0		
03/13/23 0:04	287192.6			0.6			1.31			0.38			1.45			0		
03/13/23 0:05	288039.8			0.6			1.22			0.38			1.35			0		
03/13/23 0:06	286884.5			0.6			1.22			0.38			1.34			0		
03/13/23 0:07	285960.3			0.6			1.22			0.38			1.34			0		
03/13/23 0:08	287192.6			0.6			1.22			0.38			1.34			1		
03/13/23 0:09	270018			0.6			1.24			0.36			1.28			1		
03/13/23 0:10	248761.6			0.6			2.13			0.34			2.03			1		
03/13/23 0:11	223654.4			0.5			7.16			0.28			6.16			1		
03/13/23 0:12	197700			3.4			10.87			1.55			8.26			1		
03/13/23 0:13	174749.2			171.9			13.64			70.14			9.16			1		
03/13/23 0:14	154879.1			764.8			16.82			276.48			10			1		
03/13/23 0:15	88029.3			1530.5			21.24			314.5			7.18			1		
03/13/23 0:16	0			0			26.55			0			0			0		
03/13/23 0:17	0			0			11.8			0			0			0		
03/13/23 0:18	0			0			0.1			0			0			0		
03/13/23 0:19	0			0			0.1			0			0			0		
03/13/23 0:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 40

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 16:42	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:43	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:44	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:45	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:46	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:47	0			0	X		0	X		0	X		0	X		1		
03/13/23 16:48	15942.3			0.1	X		0	X		0	X		0	X		1		
03/13/23 16:49	31268.5			761.1	X		35.4	X		55.54	X		4.25	X		1		
03/13/23 16:50	44284.2			230.6	X		16.63	X		23.85	X		2.83	X		1		
03/13/23 16:51	56375.7			158.6	X		19.18	X		20.87	X		4.15	X		1		
03/13/23 16:52	67389			133.5	X		24.22	X		21.01	X		6.27	X		1		
03/13/23 16:53	95422.8			120.8	X		27.53	X		26.91	X		10.09	X		1		
03/13/23 16:54	142325.5			110.3	X		35.91	X		36.67	X		19.65	X		1		
03/13/23 16:55	151875.5			90.6	X		51.84	X		32.13	X		30.25	X		1		
03/13/23 16:56	157882.8			79.3	X		51.81	X		29.23	X		31.44	X		1		
03/13/23 16:57	169127.1			76.9	X		50.95	X		30.36	X		33.11	X		1		
03/13/23 16:58	188073			126.9	X		47.5	X		55.71	X		34.33	X		1		
03/13/23 16:59	211562.9			97.6	X		49.92	X		48.21	X		40.59	X		1		
03/13/23 17:00	239442.7			81.8	X		48.53	X		45.74	X		44.64	X		1		
03/13/23 17:01	262008.3			22.9	X		51.78	X		14	X		52.13	X		1		
03/13/23 17:02	288809.9			2.7	X		46.13	X		1.81	X		51.18	X		1		
03/13/23 17:03	312299.8			2	X		23.99	X		1.48	X		28.78	X		1		
03/13/23 17:04	334788.4			1.9	X		14.48	X		1.47	X		18.63	X		1		
03/13/23 17:05	338639.2			1.9	X		10.41	X		1.51	X		13.55	X		1		
03/13/23 17:06	336790.8			1.8	X		9.72	X		1.43	X		12.58	X		1		
03/13/23 17:07	337792.1			1.7	X		8.85	X		1.37	X		11.49	X		1		
03/13/23 17:08	336328.8			1.5			8.54			1.18			11.04			1		
03/13/23 17:09	336405.8			1.4			7.93			1.11			10.25			1		
03/13/23 17:10	336174.7			1.3			7.75			1.04			10.01			1		
03/13/23 17:11	327625.9			1.2			7.4			0.94			9.31			1		
03/13/23 17:12	326624.8			1.2			7.06			0.89			8.86			1		
03/13/23 17:13	327703			1.1			6.97			0.82			8.78			1		
03/13/23 17:14	328473.1			1.1			6.97			0.82			8.8			1		
03/13/23 17:15	327625.9			1			6.97			0.75			8.78			1		
03/13/23 17:16	326239.7			1			6.88			0.75			8.63			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 17:17	324776.3			1			6.99			0.76			8.72			1		
03/13/23 17:18	321310.6			1			6.9			0.75			8.52			1		
03/13/23 17:19	321079.6			0.9			6.9			0.68			8.51			1		
03/13/23 17:20	303211.9			0.9			6.99			0.64			8.14			1		
03/13/23 17:21	291659.5			0.8			7.84			0.56			8.78			1		
03/13/23 17:22	289349			0.7			10.49			0.51			11.66			1		
03/13/23 17:23	289040.9			0.7			10.86			0.44			12.07			1		
03/13/23 17:24	288886.9			0.7			11.24			0.44			12.47			1		
03/13/23 17:25	289888.1			0.7			11.61			0.44			12.94			1		
03/13/23 17:26	288886.9			0.7			11.8			0.44			13.1			1		
03/13/23 17:27	289272			0.7			11.99			0.44			13.32			1		
03/13/23 17:28	289965.1			0.6			10.68			0.38			11.89			1		
03/13/23 17:29	288039.8			0.6			5.62			0.38			6.22			1		
03/13/23 17:30	289349			0.6			3.84			0.38			4.27			1		
03/13/23 17:31	288732.9			0.6			4.68			0.38			5.19			1		
03/13/23 17:32	289657.1			0.6			5.71			0.39			6.35			1		
03/13/23 17:33	288578.8			0.7			5.52			0.45			6.12			1		
03/13/23 17:34	288347.8			0.6			4			0.38			4.43			1		
03/13/23 17:35	289040.9			0.6			2.57			0.39			2.85			1		
03/13/23 17:36	289426			0.6			2			0.39			2.22			1		
03/13/23 17:37	288809.9			0.6			1.62			0.38			1.8			1		
03/13/23 17:38	287808.7			0.6			1.33			0.38			1.47			0		
03/13/23 17:39	287500.6			0.6			1.05			0.38			1.16			0		
03/13/23 17:40	287654.7			0.6			0.95			0.38			1.05			0		
03/13/23 17:41	287885.7			0.6			0.86			0.38			0.95			0		
03/13/23 17:42	287962.7			0.6			0.76			0.38			0.84			0		

CT2 SUSD EVENT 41

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 16:50	44284.2			230.6	X		16.63	X		23.85	X		2.83	X		1		
03/13/23 16:51	56375.7			158.6	X		19.18	X		20.87	X		4.15	X		1		
03/13/23 16:52	67389			133.5	X		24.22	X		21.01	X		6.27	X		1		
03/13/23 16:53	95422.8			120.8	X		27.53	X		26.91	X		10.09	X		1		
03/13/23 16:54	142325.5			110.3	X		35.91	X		36.67	X		19.65	X		1		
03/13/23 16:55	151875.5			90.6	X		51.84	X		32.13	X		30.25	X		1		
03/13/23 16:56	157882.8			79.3	X		51.81	X		29.23	X		31.44	X		1		
03/13/23 16:57	169127.1			76.9	X		50.95	X		30.36	X		33.11	X		1		
03/13/23 16:58	188073			126.9	X		47.5	X		55.71	X		34.33	X		1		
03/13/23 16:59	211562.9			97.6	X		49.92	X		48.21	X		40.59	X		1		
03/13/23 17:00	239442.7			81.8	X		48.53	X		45.74	X		44.64	X		1		
03/13/23 17:01	262008.3			22.9	X		51.78	X		14	X		52.13	X		1		
03/13/23 17:02	288809.9			2.7	X		46.13	X		1.81	X		51.18	X		1		

CT2 SUSD EVENT 42

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 22:47	314456.2			0.9			1.54			0.67			1.86			0		
03/13/23 22:48	311298.6			0.8			1.45			0.59			1.74			0		
03/13/23 22:49	290658.3			0.7			1.36			0.49			1.52			0		
03/13/23 22:50	286191.3			0.7			1.69			0.44			1.85			0		
03/13/23 22:51	285190.2			0.7			2			0.44			2.19			0		
03/13/23 22:52	279568			0.6			1.81			0.37			1.94			1		
03/13/23 22:53	256771.3			0.6			1.62			0.34			1.6			1		
03/13/23 22:54	234975.7			0.5			4.4			0.27			3.97			1		
03/13/23 22:55	208020.1			0.4			9.8			0.22			7.83			1		
03/13/23 22:56	183837.1			7.6			13.52			3.27			9.55			1		
03/13/23 22:57	164506.1			432.1			16.72			165.98			10.57			1		
03/13/23 22:58	142864.6			1214.3			21.85			405			11.99			1		
03/13/23 22:59	13862.9			1779			26.92			57.74			1.44			1		
03/13/23 23:00	0			0			26.97			0			0			0		
03/13/23 23:01	0			0			0.2			0			0			0		
03/13/23 23:02	0			0			0.1			0			0			0		
03/13/23 23:03	0			0			0.1			0			0			0		
03/13/23 23:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 43

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 9:04	0			0			0			0			0			0		
03/14/23 9:05	0			0			0			0			0			0		
03/14/23 9:06	0			0			0			0			0			0		
03/14/23 9:07	0			0			0			0			0			0		
03/14/23 9:08	0			0			0			0			0			0		
03/14/23 9:09	13400.8			0			0			0			0			1		
03/14/23 9:10	28264.9			1.4			0.1			0			0			1		
03/14/23 9:11	41973.7			1240.8			12.98			121.65			2.09			1		
03/14/23 9:12	53911.2			1212.8			12.91			152.57			2.67			1		
03/14/23 9:13	65001.5			764.2			17.39			115.98			4.34			1		
03/14/23 9:14	86797			553.4			21.54			112.11			7.18			1		
03/14/23 9:15	134932			422.1			23.87			132.95			12.37			1		
03/14/23 9:16	152029.5			276.4			39.33			98.14			22.98			1		
03/14/23 9:17	157959.8			601.6			41.85			221.94			25.41			1		
03/14/23 9:18	172284.7			1819.6			43.88			731.94			29.05			1		
03/14/23 9:19	193079			1452.9			45.35			655.01			33.64			1		
03/14/23 9:20	215875.8			693.2			45.23			349.43			37.53			1		
03/14/23 9:21	242600.3			151.7			45.86			85.89			42.74			1		
03/14/23 9:22	265551.1			11.6			46.73			7.17			47.68			1		
03/14/23 9:23	292429.7			2.3			44.3			1.54			49.78			1		
03/14/23 9:24	317305.8			1.8			21.28			1.36			25.95			1		
03/14/23 9:25	332786			1.6			13.91			1.23			17.79			1		
03/14/23 9:26	336251.8			1.6			10.41			1.29			13.45			1		
03/14/23 9:27	335096.5			1.6			9.63			1.29			12.4			1		
03/14/23 9:28	333479.2			1.6			9.2			1.22			11.78			1		
03/14/23 9:29	332400.9			1.5			8.94			1.14			11.41			1		
03/14/23 9:30	331784.8			1.3			8.98			1.02			11.45			1		
03/14/23 9:31	330706.6			1.2			8.54			0.95			10.85			1		
03/14/23 9:32	331784.8			1.1			8.54			0.89			10.89			1		
03/14/23 9:33	331245.7			1.1			8.45			0.82			10.76			1		
03/14/23 9:34	330013.4			1.1			8.54			0.81			10.83			1		
03/14/23 9:35	329705.4			1			8.67			0.76			10.99			1		
03/14/23 9:36	331399.7			1			8.67			0.76			11.04			1		
03/14/23 9:37	334095.3			1			8.76			0.77			11.25			1		
03/14/23 9:38	327086.8			0.9			8.85			0.68			11.12			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 9:39	311375.6			0.9			9.03			0.65			10.8			1		
03/14/23 9:40	308140.9			0.9			9.08			0.65			10.75			1		
03/14/23 9:41	304213.1			0.8			9.98			0.58			11.67			1		
03/14/23 9:42	297127.6			0.8			6.27			0.58			7.16			1		
03/14/23 9:43	298822			0.7			3.13			0.51			3.6			1		
03/14/23 9:44	299900.2			0.6			2.12			0.45			2.44			1		
03/14/23 9:45	293430.8			0.6			1.48			0.44			1.66			1		
03/14/23 9:46	290966.3			0.6			1.29			0.44			1.44			1		
03/14/23 9:47	289657.1			0.7			1.12			0.44			1.25			1		
03/14/23 9:48	290427.2			0.7			0.94			0.44			1.05			0		
03/14/23 9:49	288655.9			0.7			0.84			0.44			0.93			0		
03/14/23 9:50	288809.9			0.7			0.75			0.44			0.83			0		
03/14/23 9:51	287346.6			0.6			0.75			0.38			0.83			0		
03/14/23 9:52	287577.6			0.6			0.66			0.38			0.72			0		

CT2 SUSD EVENT 44

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 23:04	376223			0.9			1.14			0.77			1.65			0		
03/14/23 23:05	357970.3			0.9			1.23			0.74			1.7			0		
03/14/23 23:06	334249.3			1			1.39			0.74			1.78			0		
03/14/23 23:07	312453.8			1			1.76			0.71			2.11			0		
03/14/23 23:08	291813.5			0.9			1.63			0.62			1.83			0		
03/14/23 23:09	282263.5			0.8			1.75			0.55			1.9			1		
03/14/23 23:10	259158.8			0.7			2.09			0.4			2.08			1		
03/14/23 23:11	238441.5			0.5			6.41			0.28			5.87			1		
03/14/23 23:12	211100.8			0.4			13.8			0.22			11.2			1		
03/14/23 23:13	188073			8			18.19			3.51			13.15			1		
03/14/23 23:14	168433.9			386			21.27			151.8			13.77			1		
03/14/23 23:15	147023.5			1117.3			26.55			383.4			14.99			1		
03/14/23 23:16	24799.1			1801.1			30.93			104.42			2.95			1		
03/14/23 23:17	0			0			41.89			0			0			0		
03/14/23 23:18	0			0			0.2			0			0			0		
03/14/23 23:19	0			0			0.1			0			0			0		
03/14/23 23:20	0			0			0.1			0			0			0		
03/14/23 23:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 45

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 16:42	0			0			0			0			0			0		
03/15/23 16:43	0			0			0			0			0			0		
03/15/23 16:44	0			0			0			0			0			0		
03/15/23 16:45	0			0			0			0			0			0		
03/15/23 16:46	0			0			0			0			0			0		
03/15/23 16:47	8394.7			0			0			0			0			1		
03/15/23 16:48	21872.5			0			0			0			0			1		
03/15/23 16:49	34657.2			50.2			41.3			4.06			5.51			1		
03/15/23 16:50	47903.9			1224			18.15			137			3.34			1		
03/15/23 16:51	59225.3			887.8			22.91			122.81			5.21			1		
03/15/23 16:52	71547.8			584.1			27.95			97.54			7.68			1		
03/15/23 16:53	105280.8			429.3			32.03			105.51			12.96			1		
03/15/23 16:54	148332.8			284.7			43.87			98.6			25			1		
03/15/23 16:55	162734.8			180.1			57.98			68.4			36.25			1		
03/15/23 16:56	197931			1009.6			58.63			466.47			44.58			1		
03/15/23 16:57	225579.8			518			61.42			272.83			53.24			1		
03/15/23 16:58	249531.8			55.2			61.05			32.14			58.55			1		
03/15/23 16:59	273945.8			3.2			57.07			2.03			60.07			1		
03/15/23 17:00	301209.5			1.4			47.2			1.02			54.63			1		
03/15/23 17:01	323852.2			1.3			22.17			1.01			27.59			1		
03/15/23 17:02	332246.9			1.4			15.15			1.09			19.33			1		
03/15/23 17:03	333864.3			1.6			11.63			1.28			14.91			1		
03/15/23 17:04	336020.7			1.7			11.01			1.31			14.21			1		
03/15/23 17:05	336559.8			1.6			10.3			1.25			13.32			1		
03/15/23 17:06	335712.6			1.5			9.86			1.17			12.72			1		
03/15/23 17:07	332400.9			1.3			9.16			1.03			11.7			1		
03/15/23 17:08	332169.9			1.3			8.94			0.97			11.41			1		
03/15/23 17:09	329474.3			1.2			8.67			0.89			10.98			1		
03/15/23 17:10	328396.1			1.1			8.49			0.82			10.72			1		
03/15/23 17:11	328935.2			1			8.31			0.76			10.51			1		
03/15/23 17:12	330475.5			1			8.26			0.77			10.49			1		
03/15/23 17:13	330321.5			1			8.26			0.77			10.48			1		
03/15/23 17:14	329012.2			1			8.17			0.77			10.33			1		
03/15/23 17:15	327317.9			0.9			8.17			0.69			10.27			1		
03/15/23 17:16	326932.8			0.9			8.08			0.69			10.15			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 17:17	327317.9			0.9			8.08			0.69			10.16			1		
03/15/23 17:18	328473.1			0.9			7.99			0.7			10.08			1		
03/15/23 17:19	327471.9			0.9			7.99			0.69			10.05			1		
03/15/23 17:20	320848.5			0.9			8.08			0.68			9.96			1		
03/15/23 17:21	306985.7			0.9			8.17			0.65			9.64			1		
03/15/23 17:22	300285.3			0.8			8.94			0.58			10.32			1		
03/15/23 17:23	296511.5			0.8			10.49			0.58			11.95			1		
03/15/23 17:24	290658.3			0.7			11.61			0.51			12.97			1		
03/15/23 17:25	289040.9			0.8			12.66			0.51			14.06			1		
03/15/23 17:26	289195			0.7			13.51			0.45			15.01			1		
03/15/23 17:27	289195			0.6			13.13			0.39			14.59			1		
03/15/23 17:28	288193.8			0.6			7.42			0.38			8.22			1		
03/15/23 17:29	288809.9			0.6			4			0.38			4.43			1		
03/15/23 17:30	289426			0.7			2.66			0.45			2.96			1		
03/15/23 17:31	288347.8			0.6			1.9			0.38			2.11			1		
03/15/23 17:32	289040.9			0.6			1.71			0.39			1.9			1		
03/15/23 17:33	287269.6			0.6			1.33			0.38			1.47			1		
03/15/23 17:34	289118			0.6			1.14			0.39			1.27			1		
03/15/23 17:35	288193.8			0.6			1.05			0.38			1.16			0		
03/15/23 17:36	289272			0.6			1.05			0.39			1.16			0		
03/15/23 17:37	287577.6			0.6			0.95			0.38			1.05			0		
03/15/23 17:38	287808.7			0.6			0.95			0.38			1.05			0		
03/15/23 17:39	286884.5			0.6			0.95			0.38			1.05			0		

CT2 SUSD EVENT 46

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 21:40	382769.4			0.8			1.67			0.71			2.46			0		
03/15/23 21:41	376608.1			0.9			1.59			0.77			2.29			0		
03/15/23 21:42	376762.1			1			1.32			0.85			1.91			0		
03/15/23 21:43	373989.6			1			1.14			0.85			1.65			0		
03/15/23 21:44	351192.8			0.9			1.14			0.72			1.54			0		
03/15/23 21:45	329551.3			0.9			1.41			0.68			1.78			1		
03/15/23 21:46	306908.7			1			1.61			0.7			1.9			1		
03/15/23 21:47	283341.8			0.9			1.91			0.6			2.08			1		
03/15/23 21:48	259543.8			0.7			3.47			0.45			3.46			1		
03/15/23 21:49	235283.8			0.6			7.53			0.34			6.81			1		
03/15/23 21:50	211408.8			0.6			22.04			0.27			17.9			1		
03/15/23 21:51	186378.7			7.4			26.43			3.21			18.93			1		
03/15/23 21:52	166277.5			445			31.47			172.74			20.1			1		
03/15/23 21:53	146792.4			1189.2			35.4			407.57			19.97			1		
03/15/23 21:54	39817.3			1792.3			37.43			166.5			5.72			1		
03/15/23 21:55	0			0			43.07			0			0			0		
03/15/23 21:56	0			0			0.3			0			0			0		
03/15/23 21:57	0			0			0.2			0			0			0		
03/15/23 21:58	0			0			0.2			0			0			0		
03/15/23 21:59	0			0			0.1			0			0			0		

CT2 SUSD EVENT 47

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 15:40	0			0			0			0			0			0		
03/16/23 15:41	0			0			0			0			0			0		
03/16/23 15:42	0			0			0			0			0			0		
03/16/23 15:43	0			0			0			0			0			0		
03/16/23 15:44	0			0			0			0			0			0		
03/16/23 15:45	16866.5			0			0			0			0			1		
03/16/23 15:46	26878.6			1.1			0.1			0			0			1		
03/16/23 15:47	40972.5			1198.4			21.63			114.54			3.4			1		
03/16/23 15:48	53449.1			1080.1			19.54			134.67			4.01			1		
03/16/23 15:49	66079.7			678.5			25.46			104.65			6.46			1		
03/16/23 15:50	85025.6			489.1			28.62			97.11			9.35			1		
03/16/23 15:51	133006.6			366.1			36.47			113.65			18.64			1		
03/16/23 15:52	152183.6			232.8			51.97			82.71			30.38			1		
03/16/23 15:53	145868.3			550.6			58.05			187.46			32.53			1		
03/16/23 15:54	156111.4			1874.1			53.29			682.97			31.96			1		
03/16/23 15:55	186301.6			1844			61.09			802.03			43.73			1		
03/16/23 15:56	210715.7			780.7			62.11			384.1			50.29			1		
03/16/23 15:57	234205.6			234.9			60.83			128.44			54.74			1		
03/16/23 15:58	256540.2			23.6			58.75			14.14			57.92			1		
03/16/23 15:59	283957.9			3			56.38			1.96			61.52			1		
03/16/23 16:00	306061.5			2.2			36.5			1.57			42.92			1		
03/16/23 16:01	316535.7			2			18.97			1.48			23.08			1		
03/16/23 16:02	338254.2			2			14.53			1.6			18.88			1		
03/16/23 16:03	358586.4			2			11.89			1.7			16.38			1		
03/16/23 16:04	370908.9			1.8			10.85			1.58			15.46			1		
03/16/23 16:05	373989.6			1.7			8.72			1.46			12.53			1		
03/16/23 16:06	373219.4			1.5			8.37			1.3			12			1		
03/16/23 16:07	373065.4			1.4			8.01			1.23			11.49			1		
03/16/23 16:08	371294			1.3			7.66			1.15			10.93			1		
03/16/23 16:09	372834.3			1.2			7.49			1.07			10.72			1		
03/16/23 16:10	371448			1.3			7.33			1.09			10.46			1		
03/16/23 16:11	372064.2			1.2			7.24			1.01			10.35			1		
03/16/23 16:12	371525.1			1.2			7.15			1.01			10.21			1		
03/16/23 16:13	370292.8			1.1			7.06			0.93			10.05			1		
03/16/23 16:14	369445.6			1.1			6.97			0.93			9.9			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 16:15	370677.9			1.1			7.06			0.93			10.06			1		
03/16/23 16:16	368444.4			1.1			7.06			0.92			10			1		
03/16/23 16:17	369599.7			1			6.97			0.85			9.9			1		
03/16/23 16:18	367212.2			1			7.06			0.84			9.96			1		
03/16/23 16:19	368521.4			1			6.97			0.85			9.87			1		
03/16/23 16:20	365902.9			1			7.06			0.84			9.93			1		
03/16/23 16:21	368059.3			1			7.06			0.85			9.99			1		
03/16/23 16:22	367751.3			1			7.15			0.84			10.11			1		
03/16/23 16:23	367289.2			1			7.15			0.84			10.09			1		
03/16/23 16:24	368059.3			0.9			5.99			0.77			8.47			1		
03/16/23 16:25	367058.1			0.9			3.4			0.77			4.79			1		
03/16/23 16:26	366596			0.9			2.77			0.77			3.9			1		
03/16/23 16:27	352271.1			0.9			3.13			0.74			4.23			1		
03/16/23 16:28	362360.2			0.9			3.93			0.76			5.48			1		
03/16/23 16:29	377763.3			0.9			3.93			0.79			5.71			1		
03/16/23 16:30	394706.8			0.9			3.09			0.84			4.68			1		
03/16/23 16:31	400868.1			0.8			3.04			0.78			4.69			1		
03/16/23 16:32	404256.8			0.8			3.41			0.78			5.3			1		
03/16/23 16:33	403948.8			0.8			3.5			0.78			5.44			1		
03/16/23 16:34	400175			0.8			3.6			0.78			5.53			1		
03/16/23 16:35	398095.6			0.8			3.09			0.76			4.72			1		
03/16/23 16:36	400252			0.8			2.45			0.76			3.77			1		
03/16/23 16:37	400329			0.8			2.27			0.76			3.49			1		
03/16/23 16:38	398634.7			0.8			2.27			0.76			3.48			1		
03/16/23 16:39	399250.8			0.8			2.45			0.76			3.76			1		
03/16/23 16:40	399558.9			0.8			2.63			0.76			4.04			1		
03/16/23 16:41	399327.8			0.8			2.54			0.76			3.9			1		
03/16/23 16:42	396555.3			0.8			2.36			0.76			3.6			1		
03/16/23 16:43	397864.5			0.8			2.09			0.76			3.19			1		
03/16/23 16:44	400406			0.8			1.91			0.76			2.93			1		
03/16/23 16:45	402408.5			0.8			1.72			0.77			2.67			1		
03/16/23 16:46	399712.9			0.8			1.82			0.76			2.79			1		
03/16/23 16:47	397864.5			0.8			1.91			0.76			2.91			0		
03/16/23 16:48	397402.4			0.8			1.91			0.76			2.91			0		
03/16/23 16:49	399789.9			0.8			1.82			0.76			2.79			0		
03/16/23 16:50	404102.8			0.8			1.63			0.77			2.54			0		
03/16/23 16:51	401561.3			0.8			1.63			0.77			2.52			0		

CT2 SUSD EVENT 48

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 8:17	307601.8			0.7			1.48			0.53			1.74			0		
03/17/23 8:18	307601.8			0.7			1.38			0.53			1.63			0		
03/17/23 8:19	307678.8			0.7			1.38			0.53			1.63			0		
03/17/23 8:20	308834.1			0.7			1.29			0.53			1.53			0		
03/17/23 8:21	307755.8			0.7			1.29			0.53			1.53			0		
03/17/23 8:22	299592.1			0.7			1.38			0.52			1.59			1		
03/17/23 8:23	276410.3			0.7			1.38			0.48			1.47			1		
03/17/23 8:24	253382.5			0.7			2.61			0.4			2.54			1		
03/17/23 8:25	230200.7			0.6			8.32			0.34			7.36			1		
03/17/23 8:26	202706			2			14.23			0.93			11.08			1		
03/17/23 8:27	180910.5			129.7			17.44			54.77			12.13			1		
03/17/23 8:28	160963.4			740.3			20.65			278.23			12.77			1		
03/17/23 8:29	129001.8			1514.8			24.61			456.06			12.19			1		
03/17/23 8:30	0			1864.6			28.36			0			0			1		
03/17/23 8:31	0			0			50.15			0			0			0		
03/17/23 8:32	0			0			0.2			0			0			0		
03/17/23 8:33	0			0			0.2			0			0			0		
03/17/23 8:34	0			0			0.1			0			0			0		
03/17/23 8:35	0			0			0.1			0			0			0		

CT2 SUSD EVENT 49

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 16:34	0			0			0			0			0			0		
03/17/23 16:35	0			0			0			0			0			0		
03/17/23 16:36	0			0			0			0			0			0		
03/17/23 16:37	0			0			0			0			0			0		
03/17/23 16:38	0			0			0			0			0			0		
03/17/23 16:39	1925.4			0			0			0			0			1		
03/17/23 16:40	15865.3			0			0			0			0			1		
03/17/23 16:41	31114.5			64.9			29.5			4.71			3.52			1		
03/17/23 16:42	44438.2			1099.2			9.08			114.17			1.55			1		
03/17/23 16:43	56375.7			917.6			12.49			120.78			2.71			1		
03/17/23 16:44	67928.1			572			16.46			90.78			4.3			1		
03/17/23 16:45	97271.2			391.6			19.67			88.98			7.35			1		
03/17/23 16:46	145483.2			249.1			23.09			84.58			12.9			1		
03/17/23 16:47	154648.1			164.4			39.27			59.35			23.33			1		
03/17/23 16:48	161810.6			950.1			40.75			358.99			25.34			1		
03/17/23 16:49	162195.6			1551.7			40.95			587.7			25.53			1		
03/17/23 16:50	178677.1			1664			40.95			694.29			28.12			1		
03/17/23 16:51	199702.4			982.4			43.37			458.08			33.28			1		
03/17/23 16:52	225348.7			312.6			45.76			164.42			39.62			1		
03/17/23 16:53	250764			39.5			47.45			23.15			45.71			1		
03/17/23 16:54	276795.4			3.3			49.81			2.13			52.98			1		
03/17/23 16:55	302364.7			1.8			36.82			1.29			42.79			1		
03/17/23 16:56	326008.6			1.7			17.33			1.26			21.71			1		
03/17/23 16:57	336636.8			1.6			11.8			1.25			15.26			1		
03/17/23 16:58	335404.6			1.6			10.48			1.24			13.5			1		
03/17/23 16:59	335404.6			1.6			10.04			1.24			12.94			1		
03/17/23 17:00	334095.3			1.4			9.77			1.1			12.55			1		
03/17/23 17:01	334095.3			1.3			9.57			1.05			12.28			1		
03/17/23 17:02	333479.2			1.3			9.3			0.97			11.91			1		
03/17/23 17:03	333094.1			1.2			9.12			0.9			11.67			1		
03/17/23 17:04	336020.7			1.2			9.03			0.91			11.66			1		
03/17/23 17:05	322003.8			1.1			9.03			0.81			11.17			1		
03/17/23 17:06	312992.9			1.1			9.26			0.8			11.13			1		
03/17/23 17:07	310297.3			1			9.59			0.73			11.43			1		
03/17/23 17:08	311375.6			0.9			9.77			0.67			11.69			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 17:09	309142.1			0.8			10.05			0.6			11.93			1		
03/17/23 17:10	309373.2			0.8			10.14			0.6			12.06			1		
03/17/23 17:11	308988.1			0.8			6.08			0.6			7.22			1		
03/17/23 17:12	310220.3			0.8			3.32			0.6			3.96			1		
03/17/23 17:13	310682.4			0.8			3.69			0.6			4.4			1		
03/17/23 17:14	309450.2			0.8			4.43			0.6			5.26			1		
03/17/23 17:15	308988.1			0.8			5.35			0.6			6.35			1		
03/17/23 17:16	309835.3			0.8			5.44			0.6			6.48			1		
03/17/23 17:17	308526			0.8			3.87			0.6			4.59			1		
03/17/23 17:18	309065.1			0.7			2.86			0.53			3.39			1		
03/17/23 17:19	309296.2			0.7			2.72			0.54			3.23			1		
03/17/23 17:20	307293.7			0.7			2.77			0.53			3.27			1		
03/17/23 17:21	308294.9			0.7			3.09			0.54			3.66			1		
03/17/23 17:22	308603			0.7			3.37			0.54			4			1		
03/17/23 17:23	308757			0.7			3.56			0.54			4.22			1		
03/17/23 17:24	309296.2			0.7			2.9			0.54			3.45			1		
03/17/23 17:25	308757			0.8			2.43			0.61			2.89			1		
03/17/23 17:26	308526			0.8			2.25			0.61			2.66			1		
03/17/23 17:27	306677.6			0.8			2.06			0.6			2.43			1		
03/17/23 17:28	307139.7			0.8			1.97			0.6			2.32			1		
03/17/23 17:29	311452.6			0.8			1.97			0.61			2.35			1		
03/17/23 17:30	332940.1			0.8			1.97			0.66			2.52			1		
03/17/23 17:31	353811.4			0.8			1.84			0.69			2.51			0		
03/17/23 17:32	369060.5			0.9			1.88			0.77			2.66			0		
03/17/23 17:33	377455.3			0.9			1.72			0.8			2.5			0		
03/17/23 17:34	396863.3			1			1.45			0.93			2.21			0		
03/17/23 17:35	411419.3			0.9			1.38			0.89			2.19			0		

CT2 SUSD EVENT 50

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 22:48	306908.7			0.7			1.48			0.53			1.74			0		
03/17/23 22:49	306754.6			0.7			1.38			0.53			1.63			0		
03/17/23 22:50	307447.8			0.7			1.38			0.53			1.63			0		
03/17/23 22:51	307062.7			0.7			1.38			0.53			1.63			0		
03/17/23 22:52	308063.9			0.7			1.38			0.53			1.64			0		
03/17/23 22:53	304598.2			0.7			1.38			0.52			1.62			1		
03/17/23 22:54	284188.9			0.7			1.38			0.49			1.51			1		
03/17/23 22:55	258773.7			0.8			2.19			0.46			2.18			1		
03/17/23 22:56	237209.2			0.7			6.51			0.39			5.93			1		
03/17/23 22:57	210715.7			1			14.81			0.49			11.99			1		
03/17/23 22:58	186147.6			8.9			19.83			3.87			14.19			1		
03/17/23 22:59	165815.4			460.1			23.6			178.16			15.04			1		
03/17/23 23:00	145945.3			1185.3			27.43			403.81			15.38			1		
03/17/23 23:01	34503.2			1768.2			31.9			142.49			4.23			1		
03/17/23 23:02	0			0			35.4			0			0			0		
03/17/23 23:03	0			0			0.2			0			0			0		
03/17/23 23:04	0			0			0.2			0			0			0		
03/17/23 23:05	0			0			0.1			0			0			0		
03/17/23 23:06	0			0			0.1			0			0			0		

CT2 SUSD EVENT 51

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 15:50	0			0			0			0			0			0		
03/18/23 15:51	0			0			0			0			0			0		
03/18/23 15:52	0			0			0			0			0			0		
03/18/23 15:53	0			0			0			0			0			0		
03/18/23 15:54	0			0			0			0			0			0		
03/18/23 15:55	8779.8			0.1			0			0			0			1		
03/18/23 15:56	24876.2			0.1			0			0			0			1		
03/18/23 15:57	38276.9			75.5			29.5			6.75			4.34			1		
03/18/23 15:58	50214.4			1221.7			17.7			143.3			3.42			1		
03/18/23 15:59	61920.8			808			24.58			116.84			5.85			1		
03/18/23 16:00	76399.8			532.2			27.73			94.94			8.14			1		
03/18/23 16:01	118835.6			407.1			32.72			113			14.95			1		
03/18/23 16:02	152106.5			270.7			45.78			96.16			26.77			1		
03/18/23 16:03	155572.3			250.8			55.95			91.13			33.46			1		
03/18/23 16:04	168433.9			1625.1			52.73			639.14			34.13			1		
03/18/23 16:05	188612.1			1598.7			53.62			703.93			38.86			1		
03/18/23 16:06	211023.8			810.3			54.5			399.23			44.19			1		
03/18/23 16:07	236516			171			53.5			94.41			48.62			1		
03/18/23 16:08	260853.1			14.2			52.5			8.65			52.62			1		
03/18/23 16:09	287731.7			2.5			52.99			1.69			58.58			1		
03/18/23 16:10	310528.4			2.1			27.93			1.5			33.32			1		
03/18/23 16:11	317998.9			1.9			16			1.39			19.55			1		
03/18/23 16:12	316997.8			1.9			12.33			1.43			15.01			1		
03/18/23 16:13	328627.2			2			11.35			1.51			14.34			1		
03/18/23 16:14	332632			1.8			9.92			1.39			12.68			1		
03/18/23 16:15	332323.9			1.6			8.98			1.23			11.47			1		
03/18/23 16:16	331168.7			1.4			8.81			1.09			11.21			1		
03/18/23 16:17	328858.2			1.3			8.4			1.03			10.62			1		
03/18/23 16:18	328550.1			1.3			8.31			0.96			10.5			1		
03/18/23 16:19	327317.9			1.2			8.05			0.89			10.12			1		
03/18/23 16:20	328088			1.2			7.87			0.89			9.92			1		
03/18/23 16:21	326162.7			1.1			7.78			0.82			9.75			1		
03/18/23 16:22	325854.6			1.1			7.9			0.83			9.89			1		
03/18/23 16:23	327009.8			1			7.72			0.76			9.7			1		
03/18/23 16:24	327163.8			1			7.72			0.76			9.7			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 16:25	328935.2			1			7.62			0.77			9.64			1		
03/18/23 16:26	328011			1			7.72			0.76			9.72			1		
03/18/23 16:27	326162.7			1			7.72			0.76			9.67			1		
03/18/23 16:28	325854.6			1			7.62			0.76			9.55			1		
03/18/23 16:29	325161.4			0.9			7.62			0.69			9.52			1		
03/18/23 16:30	326393.7			0.9			7.62			0.69			9.56			1		
03/18/23 16:31	325315.5			0.9			7.72			0.69			9.64			1		
03/18/23 16:32	313917.1			0.9			7.81			0.67			9.42			1		
03/18/23 16:33	308988.1			0.8			8.2			0.6			9.74			1		
03/18/23 16:34	309681.2			0.8			8.67			0.6			10.31			1		
03/18/23 16:35	309373.2			0.8			7.93			0.6			9.43			1		
03/18/23 16:36	308294.9			0.8			3.23			0.6			3.82			1		
03/18/23 16:37	309296.2			0.7			2.3			0.53			2.74			1		
03/18/23 16:38	308371.9			0.7			2.86			0.53			3.39			1		
03/18/23 16:39	307909.8			0.7			3.41			0.53			4.04			1		
03/18/23 16:40	310451.4			0.7			3.69			0.53			4.4			1		
03/18/23 16:41	309296.2			0.7			3.13			0.53			3.73			1		
03/18/23 16:42	308140.9			0.7			2.49			0.53			2.95			1		
03/18/23 16:43	311991.7			0.7			2.12			0.54			2.54			1		
03/18/23 16:44	330937.6			0.7			1.57			0.57			1.99			1		
03/18/23 16:45	351809			0.7			1.38			0.61			1.87			1		
03/18/23 16:46	368290.4			0.8			1.25			0.69			1.77			1		
03/18/23 16:47	368675.5			0.9			0.98			0.77			1.39			0		
03/18/23 16:48	370831.9			1			0.8			0.85			1.15			0		
03/18/23 16:49	388930.7			1			0.8			0.89			1.2			0		
03/18/23 16:50	408569.7			0.9			0.82			0.87			1.28			0		
03/18/23 16:51	418658.8			0.8			0.74			0.81			1.19			0		

CT2 SUSD EVENT 52

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 21:40	309835.3			1			1.61			0.71			1.92			0		
03/18/23 21:41	304906.2			0.9			1.57			0.66			1.84			0		
03/18/23 21:42	304598.2			0.8			1.48			0.59			1.73			0		
03/18/23 21:43	305214.3			0.8			1.4			0.6			1.65			0		
03/18/23 21:44	305753.4			0.7			1.31			0.53			1.54			0		
03/18/23 21:45	296434.5			0.7			1.31			0.52			1.49			1		
03/18/23 21:46	275332.1			0.7			1.31			0.48			1.39			1		
03/18/23 21:47	249223.7			0.8			2.38			0.44			2.28			1		
03/18/23 21:48	227351.2			0.6			6.42			0.33			5.61			1		
03/18/23 21:49	198470.2			1.5			17.13			0.68			13.07			1		
03/18/23 21:50	178137.9			10.3			21.21			4.28			14.52			1		
03/18/23 21:51	157805.7			510.7			25.47			188.17			15.45			1		
03/18/23 21:52	127461.4			1298.2			29.66			386.19			14.52			1		
03/18/23 21:53	0			1791.9			34.07			0			0			1		
03/18/23 21:54	0			0			64.9			0			0			0		
03/18/23 21:55	0			0			0.2			0			0			0		
03/18/23 21:56	0			0			0.2			0			0			0		
03/18/23 21:57	0			0			0.1			0			0			0		
03/18/23 21:58	0			0			0.1			0			0			0		

CT2 SUSD EVENT 53

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 15:37	0			0			0			0			0			0		
03/19/23 15:38	0			0			0			0			0			0		
03/19/23 15:39	0			0			0			0			0			0		
03/19/23 15:40	0			0			0			0			0			0		
03/19/23 15:41	0			0			0			0			0			0		
03/19/23 15:42	19100			0			0			0			0			1		
03/19/23 15:43	31422.5			82.6			35.4			6.06			4.28			1		
03/19/23 15:44	45131.4			1388.1			17.7			146.35			3.07			1		
03/19/23 15:45	57068.8			1152			19.91			153.43			4.36			1		
03/19/23 15:46	68082.1			734.4			24.53			116.72			6.42			1		
03/19/23 15:47	96038.9			519.5			26.69			116.52			9.85			1		
03/19/23 15:48	142710.6			413			37.01			137.56			20.29			1		
03/19/23 15:49	152414.6			282.5			49.82			100.56			29.18			1		
03/19/23 15:50	159346			852.9			51.44			317.31			31.5			1		
03/19/23 15:51	175442.4			1820			52.55			745.53			35.43			1		
03/19/23 15:52	194850.4			1480.4			54.45			673.37			40.76			1		
03/19/23 15:53	217724.2			647.2			51.92			329.02			43.44			1		
03/19/23 15:54	245989			138.1			53.36			79.3			50.44			1		
03/19/23 15:55	269941			10.5			51.48			6.63			53.39			1		
03/19/23 15:56	297127.6			2.2			48.25			1.53			55.09			1		
03/19/23 15:57	321156.6			1.9			22.27			1.43			27.48			1		
03/19/23 15:58	336405.8			1.8			15.41			1.45			19.92			1		
03/19/23 15:59	337330			2			11.63			1.57			15.07			1		
03/19/23 16:00	336328.8			2			10.5			1.57			13.57			1		
03/19/23 16:01	335173.5			1.8			9.89			1.43			12.74			1		
03/19/23 16:02	333402.2			1.7			9.25			1.3			11.84			1		
03/19/23 16:03	331476.8			1.5			9.07			1.16			11.55			1		
03/19/23 16:04	332169.9			1.3			8.89	X		1.02			11.35	X		1		
03/19/23 16:05	329628.4			1.2			8.63			0.95			10.93			1		
03/19/23 16:06	328396.1			1.1			8.37			0.88			10.56			1		
03/19/23 16:07	326547.7			1.2			8.31			0.89			10.43			1		
03/19/23 16:08	329474.3			1.1			8.22			0.83			10.41			1		
03/19/23 16:09	328165.1			1.1			8.22			0.82			10.37			1		
03/19/23 16:10	331553.8			1.1			8.22			0.83			10.48			1		
03/19/23 16:11	331091.7			1.1			8.22			0.83			10.46			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 16:12	329320.3			1			8.13			0.76			10.29			1		
03/19/23 16:13	327780			1			8.13			0.75			10.25			1		
03/19/23 16:14	328242.1			1			8.05			0.75			10.15			1		
03/19/23 16:15	327703			1			8.05			0.75			10.13			1		
03/19/23 16:16	330244.5			0.9			8.05			0.69			10.21			1		
03/19/23 16:17	326085.6			0.9			8.13			0.68			10.19			1		
03/19/23 16:18	315380.4			0.9			8.22			0.66			9.96			1		
03/19/23 16:19	312145.8			0.9			8.71			0.66			10.45			1		
03/19/23 16:20	310605.4			0.8			9.26			0.59			11.05			1		
03/19/23 16:21	309835.3			0.8			9.86			0.6			11.74			1		
03/19/23 16:22	309989.3			0.8			9.86			0.6			11.75			1		
03/19/23 16:23	310220.3			0.8			8.57			0.6			10.22			1		
03/19/23 16:24	309527.2			0.7			4.15			0.53			4.93			1		
03/19/23 16:25	309758.3			0.7			3.13			0.53			3.73			1		
03/19/23 16:26	309681.2			0.7			3.87			0.53			4.61			1		
03/19/23 16:27	309681.2			0.7			4.61			0.53			5.48			1		
03/19/23 16:28	310682.4			0.6			5.25			0.47			6.27			1		
03/19/23 16:29	308757			0.6			4.89			0.47			5.8			1		
03/19/23 16:30	308834.1			0.6			3.6			0.47			4.27			1		
03/19/23 16:31	308911.1			0.6			2.77			0.47			3.28			1		
03/19/23 16:32	309912.3			0.7			2.67			0.53			3.18			1		
03/19/23 16:33	308217.9			0.7			2.86			0.53			3.38			1		
03/19/23 16:34	309065.1			0.7			3.04			0.53			3.61			1		
03/19/23 16:35	309065.1			0.7			3.23			0.53			3.83			1		
03/19/23 16:36	308603			0.7			3.23			0.53			3.83			1		
03/19/23 16:37	307755.8			0.7			2.86			0.53			3.38			1		
03/19/23 16:38	312992.9			0.7			2.21			0.54			2.66			1		
03/19/23 16:39	333864.3			0.7			2.03			0.57			2.6			1		
03/19/23 16:40	355274.7			0.7			1.72			0.6			2.35			1		
03/19/23 16:41	363361.3			0.7			1.7			0.61			2.37			1		
03/19/23 16:42	358432.3			0.8			1.61			0.67			2.22			1		
03/19/23 16:43	364747.7			0.9			1.43			0.76			2			0		
03/19/23 16:44	384001.6			0.9			1.52			0.8			2.24			0		
03/19/23 16:45	404718.9			0.9			1.45			0.86			2.26			0		
03/19/23 16:46	413575.8			0.8			1.36			0.79			2.16			0		
03/19/23 16:47	416194.3			0.7			1.45			0.71			2.32			0		

CT2 SUSD EVENT 54

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 1:03	307139.7			0.7			1.38			0.53			1.63			0		
03/20/23 1:04	307524.8			0.7			1.38			0.53			1.63			0		
03/20/23 1:05	307678.8			0.7			1.48			0.53			1.74			0		
03/20/23 1:06	306831.6			0.7			1.48			0.53			1.74			0		
03/20/23 1:07	307216.7			0.7			1.48			0.53			1.74			0		
03/20/23 1:08	302133.7			0.7			1.48			0.52			1.71			1		
03/20/23 1:09	281801.4			0.7			1.57			0.49			1.7			1		
03/20/23 1:10	256925.3			0.7			2.34			0.45			2.31			1		
03/20/23 1:11	234436.6			0.6			6.61			0.33			5.96			1		
03/20/23 1:12	207635.1			1.9			15.7			0.92			12.52			1		
03/20/23 1:13	183144			14.1			19.96			6.01			14.04			1		
03/20/23 1:14	163736			482.7			23.6			184.54			14.85			1		
03/20/23 1:15	141247.3			1222.1			27.27			402.96			14.8			1		
03/20/23 1:16	0			1732.6			31.71			0			0			1		
03/20/23 1:17	0			0			41.3			0			0			0		
03/20/23 1:18	0			0			0.2			0			0			0		
03/20/23 1:19	0			0			0.1			0			0			0		
03/20/23 1:20	0			0			0.1			0			0			0		
03/20/23 1:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 55

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 16:26	0			0			0			0			0			0		
03/20/23 16:27	0			0			0			0			0			0		
03/20/23 16:28	0			0			0			0			0			0		
03/20/23 16:29	0			0			0			0			0			0		
03/20/23 16:30	0			0			0			0			0			0		
03/20/23 16:31	14633			0			0			0			0			1		
03/20/23 16:32	20178.2			0			0			0			0			1		
03/20/23 16:33	32731.8			88.5			53.1			6.76			6.67			1		
03/20/23 16:34	45824.5			1334.4			18.19			142.78			3.2			1		
03/20/23 16:35	57530.9			985.6			21.52			132.38			4.76			1		
03/20/23 16:36	69391.4			639.1			27.64			103.57			7.37			1		
03/20/23 16:37	98272.4			473.7			27.25			108.68			10.29			1		
03/20/23 16:38	144636			348.4			39.25			117.67			21.82			1		
03/20/23 16:39	166123.5			219.8			56.68			85.26			36.19			1		
03/20/23 16:40	189305.3			745.4			58.46			329.52			42.54			1		
03/20/23 16:41	211485.9			679.6			56.13			335.57			45.61			1		
03/20/23 16:42	237440.3			200.3			58.45			111.03			53.32			1		
03/20/23 16:43	260930.1			19.6			55.03			11.95			55.16			1		
03/20/23 16:44	286499.4			1.7			56.27			1.17			61.94			1		
03/20/23 16:45	294663.1			1.3			32.9			0.89			37.25			1		
03/20/23 16:46	314148.2			1.3			19.01			0.96			22.95			1		
03/20/23 16:47	335481.6			1.3			16.36			1.05			21.09			1		
03/20/23 16:48	337021.9			1.5			11.89			1.16			15.39			1		
03/20/23 16:49	336944.9			1.6			10.67			1.23			13.82			1		
03/20/23 16:50	335481.6			1.5			10.21			1.17			13.17			1		
03/20/23 16:51	333479.2			1.4			9.33			1.1			11.96			1		
03/20/23 16:52	333171.1			1.3			9.25			1.03			11.84			1		
03/20/23 16:53	329705.4			1.2			8.63			0.95			10.93			1		
03/20/23 16:54	329705.4			1.2			8.67			0.89			10.99			1		
03/20/23 16:55	328550.1			1.1			8.49			0.82			10.72			1		
03/20/23 16:56	327317.9			1.1			8.4			0.82			10.57			1		
03/20/23 16:57	327240.9			1.1			8.31			0.82			10.45			1		
03/20/23 16:58	326008.6			1			8.22			0.75			10.3			1		
03/20/23 16:59	327934			1			8.26			0.76			10.41			1		
03/20/23 17:00	328473.1			0.9			8.26			0.7			10.43			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 17:01	327009.8			0.9			8.26			0.69			10.38			1		
03/20/23 17:02	328011			0.9			8.17			0.7			10.3			1		
03/20/23 17:03	322388.9			0.9			8.08			0.68			10.01			1		
03/20/23 17:04	311298.6			0.9			8.08			0.66			9.66			1		
03/20/23 17:05	311067.5			0.9			8.76			0.67			10.47			1		
03/20/23 17:06	310759.4			0.8			9.4	X		0.6			11.23	X		1		
03/20/23 17:07	310682.4			0.8			9.31			0.6			11.11			1		
03/20/23 17:08	310066.3			0.7			9.5			0.53			11.31			1		
03/20/23 17:09	309835.3			0.7			9.59			0.53			11.42			1		
03/20/23 17:10	310220.3			0.7			9.77			0.53			11.65			1		
03/20/23 17:11	310682.4			0.7			9.86			0.53			11.77			1		
03/20/23 17:12	309604.2			0.7			9.77			0.53			11.62			1		
03/20/23 17:13	310759.4			0.7			5.53			0.54			6.6			1		
03/20/23 17:14	326701.8			0.7			3.32			0.56			4.17			1		
03/20/23 17:15	349036.4			0.7			3.5			0.6			4.7			1		
03/20/23 17:16	364054.5			0.8			4.11			0.68			5.75			1		
03/20/23 17:17	361667			0.9			3.84			0.75			5.34			1		
03/20/23 17:18	365671.8			0.9			4.02			0.76			5.65			1		
03/20/23 17:19	382846.4			1			4.11			0.88			6.05			1		
03/20/23 17:20	403178.6			1			3.54			0.94			5.48			1		
03/20/23 17:21	415578.2			0.9			3.23			0.89			5.15			1		
03/20/23 17:22	417965.7			0.8			3.5			0.81			5.63			1		
03/20/23 17:23	428670.9			0.7			3.96			0.74			6.53			1		
03/20/23 17:24	449003.1			0.8			3.13			0.87			5.41			1		
03/20/23 17:25	462943			0.7			2.34			0.81			4.16			1		
03/20/23 17:26	466100.7			0.7			2.53			0.82			4.53			1		
03/20/23 17:27	469258.3			0.7			2.9			0.82			5.23			1		
03/20/23 17:28	471722.8			0.7			3.09			0.83			5.6			1		
03/20/23 17:29	475034.5			0.7			2.9			0.83			5.3			1		
03/20/23 17:30	473417.2			0.7			2.53			0.83			4.6			1		
03/20/23 17:31	471953.9			0.7			2.15			0.83			3.91			1		
03/20/23 17:32	475881.7			0.7			1.87			0.83			3.42			1		
03/20/23 17:33	477576			0.7			1.97			0.84			3.61			1		
03/20/23 17:34	476420.8			0.7			2.49			0.82			4.56			1		
03/20/23 17:35	477191			0.7			2.49			0.82			4.56			1		
03/20/23 17:36	477113.9			0.7			1.75			0.83			3.25			1		
03/20/23 17:37	477268			0.9			1.48			1.06			2.79			1		
03/20/23 17:38	476574.8			1.8			1.34			2.06			2.54			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 17:39	477576			2.5			1.23			2.85			2.34			1		
03/20/23 17:40	478269.2			2.2			1.32			2.55			2.51			0		
03/20/23 17:41	476728.9			1.8			1.32			2.03			2.5			0		
03/20/23 17:42	477499			1.6			1.32			1.82			2.5			0		
03/20/23 17:43	477576			1.6			1.41			1.82			2.67			0		
03/20/23 17:44	478192.2			1.6			1.41			1.82			2.67			0		

CT2 SUSD EVENT 56

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 20:14	483275.2			0.9			1.01			1.04			1.88			0		
03/20/23 20:15	483660.3			0.7			1.2			0.83			2.23			0		
03/20/23 20:16	481426.8			0.7			1.29			0.83			2.39			0		
03/20/23 20:17	481503.8			0.7			1.11			0.83			2.05			0		
03/20/23 20:18	482582.1			0.7			1.01			0.83			1.88			0		
03/20/23 20:19	481580.9			0.7			1.01			0.83			1.88			1		
03/20/23 20:20	478654.3			0.7			1.2			0.82			2.2			1		
03/20/23 20:21	459939.4			0.7			1.94			0.79			3.42			1		
03/20/23 20:22	435987.4			0.7			2.4			0.75			4.02			1		
03/20/23 20:23	412035.4			0.7			3.13			0.69			4.95			1		
03/20/23 20:24	390394			0.8			3.67			0.73			5.5			1		
03/20/23 20:25	365132.7			0.9			4.05			0.75			5.68			1		
03/20/23 20:26	340641.7			1			4.43			0.76			5.79			1		
03/20/23 20:27	316612.7			1			4.84			0.72			5.89			1		
03/20/23 20:28	292814.7			0.9			5.18			0.61			5.83			1		
03/20/23 20:29	270634.1			0.7			6.82			0.47			7.09			1		
03/20/23 20:30	243986.6			0.7			8.8			0.39			8.25			1		
03/20/23 20:31	223269.3			0.5			29.39			0.28			25.22			1		
03/20/23 20:32	195466.5			3.1			37.05			1.4			27.83			1		
03/20/23 20:33	174518.2			174.1			41.17			70.93			27.6			1		
03/20/23 20:34	153569.8			773.8			46.59			277.49			27.5			1		
03/20/23 20:35	112443.3			1487.5			44.84			390.57			19.38			1		
03/20/23 20:36	0			0			49.56			0			0			0		
03/20/23 20:37	0			0			64.9			0			0			0		
03/20/23 20:38	0			0			0.3			0			0			0		
03/20/23 20:39	0			0			0.3			0			0			0		
03/20/23 20:40	0			0			0.2			0			0			0		

CT2 SUSD EVENT 57

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 11:27	0			0			0			0			0			0		
03/21/23 11:28	0			0			0			0			0			0		
03/21/23 11:29	0			0			0			0			0			0		
03/21/23 11:30	0			0			0			0			0			0		
03/21/23 11:31	0			0			0			0			0			0		
03/21/23 11:32	1925.4			0			0			0			0			1		
03/21/23 11:33	20332.2			0			0			0			0			1		
03/21/23 11:34	32731.8			47.2			32.45			3.6			4.08			1		
03/21/23 11:35	46132.6			1340.2			16.79			144.3			2.98			1		
03/21/23 11:36	57762			1058.5			21.17			142.64			4.7			1		
03/21/23 11:37	71778.9			707.4			26.71			118.6			7.37			1		
03/21/23 11:38	103201.4			514.4			28.1			123.9			11.14			1		
03/21/23 11:39	147177.5			394			38.22			135.39			21.61			1		
03/21/23 11:40	161348.5			258.1			55.21			97.24			34.23			1		
03/21/23 11:41	168356.9			988.9			53.28			388.7			34.47			1		
03/21/23 11:42	185454.5			1493.5			53.61			646.58			38.19			1		
03/21/23 11:43	206710.9			953.2			54.81			460.01			43.53			1		
03/21/23 11:44	232588.2			305.4			57.03			165.85			50.97			1		
03/21/23 11:45	257849.5			35.9			56.54			21.6			56.01			1		
03/21/23 11:46	283880.9			3			55.29			1.96			60.31			1		
03/21/23 11:47	309219.1			1.9			38.4			1.37			45.62			1		
03/21/23 11:48	332863			1.8			19.79			1.41			25.31			1		
03/21/23 11:49	350499.7			1.8			14.62			1.47			19.69			1		
03/21/23 11:50	353272.3			2			13.34			1.62			18.11			1		
03/21/23 11:51	357123.1			2			12.74			1.64			17.48			1		
03/21/23 11:52	370369.8			1.8			11.8			1.55			16.79			1		
03/21/23 11:53	361050.9			1.6			9.54			1.39			13.24			1		
03/21/23 11:54	355659.8			1.5			10.24			1.22			13.99			1		
03/21/23 11:55	356815			1.4			10.77			1.14			14.77			1		
03/21/23 11:56	361744			1.4			10.41			1.17			14.47			1		
03/21/23 11:57	365517.8			1.3			9.98			1.11			14.01			1		
03/21/23 11:58	368290.4			1.2			9.95			1.06			14.08			1		
03/21/23 11:59	371063			1.2			8.54			1.07			12.18			1		
03/21/23 12:00	376069			1.1			7.93			1.01			11.45			1		
03/21/23 12:01	379149.6			1.1			7.75			0.94			11.29			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 12:02	381614.2			1.1			7.75			0.94			11.36			1		
03/21/23 12:03	385696			1.1			7.57			0.95			11.22			1		
03/21/23 12:04	389700.8			1.1			7.42			0.98			11.11			1		
03/21/23 12:05	391395.2			1			7.06			0.9			10.62			1		
03/21/23 12:06	394783.9			1			6.97			0.91			10.58			1		
03/21/23 12:07	398326.6			0.9			6.88			0.83			10.54			1		
03/21/23 12:08	401946.3			0.9			6.97			0.84			10.77			1		
03/21/23 12:09	402870.6			0.9			7.06			0.84			10.93			1		
03/21/23 12:10	405797.2			0.8			7.06			0.76			11.01			1		
03/21/23 12:11	411188.3			0.8			7.06			0.77			11.16			1		
03/21/23 12:12	413498.8			0.9			4.47			0.86			7.1			1		
03/21/23 12:13	418504.8			0.9			2.36			0.89			3.8			1		
03/21/23 12:14	420122.1			0.9			2.27			0.89			3.66			1		
03/21/23 12:15	425359.2			0.8			2.81			0.81			4.6			1		
03/21/23 12:16	426591.5			0.8			3.36			0.81			5.5			1		
03/21/23 12:17	431289.4			0.8			3.9			0.82			6.47			1		
03/21/23 12:18	433522.9			0.8			4.08			0.83			6.8			1		
03/21/23 12:19	438374.9			0.8			4.27			0.84			7.19			1		
03/21/23 12:20	441455.6			0.8			3.54			0.84			6			1		
03/21/23 12:21	445845.5			0.8			2.54			0.85			4.35			1		
03/21/23 12:22	447539.8			0.8			2.36			0.85			4.06			1		
03/21/23 12:23	450928.5			0.8			2.45			0.86			4.25			1		
03/21/23 12:24	453162			0.8			3			0.86			5.22			1		
03/21/23 12:25	459785.3			0.8			3.18			0.88			5.61			1		
03/21/23 12:26	460632.5			0.8			3			0.88			5.3			1		
03/21/23 12:27	467641			0.8			2.3			0.91			4.14			1		
03/21/23 12:28	468488.2			0.8			2.03			0.91			3.65			1		
03/21/23 12:29	472801.1			0.8			1.84			0.92			3.35			1		
03/21/23 12:30	477345			0.8			1.84			0.92			3.38			1		
03/21/23 12:31	480271.6			0.8			2.21			0.93			4.08			1		
03/21/23 12:32	476651.8			0.8			2.54			0.91			4.65			1		
03/21/23 12:33	457089.8			0.8			2			0.87			3.51			1		
03/21/23 12:34	435987.4			0.8			1.45			0.83			2.43			1		
03/21/23 12:35	409108.8			0.8			1.43			0.77			2.25			1		
03/21/23 12:36	403024.6			0.9			1.5			0.83			2.32			1		
03/21/23 12:37	396401.2			1			1.41			0.9			2.15			0		
03/21/23 12:38	395169			1			1.34			0.91			2.04			0		
03/21/23 12:39	396709.3			1			1.34			0.91			2.04			0		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 12:40	400175			1			1.43			0.92			2.2			0		
03/21/23 12:41	398711.7			0.9			1.52			0.83			2.33			0		

CT2 SUSD EVENT 58

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 22:50	402023.4			0.8			1			0.77			1.54			0		
03/25/23 22:51	405566.1			0.8			1			0.77			1.56			0		
03/25/23 22:52	402485.5			0.8			1.09			0.77			1.68			0		
03/25/23 22:53	400406			0.8			1.07			0.75			1.65			0		
03/25/23 22:54	400098			0.8			1.25			0.75			1.92			0		
03/25/23 22:55	393628.6			0.8			1.25			0.74			1.89			1		
03/25/23 22:56	375683.9			0.8			1.34			0.71			1.94			1		
03/25/23 22:57	353272.3			0.9			1.5			0.73			2.03			1		
03/25/23 22:58	328011			0.9			2.11			0.67			2.66			1		
03/25/23 22:59	304521.2			0.9			2.41			0.64			2.82			1		
03/25/23 23:00	280569.2			0.9			3.13			0.6			3.38			1		
03/25/23 23:01	256078.1			0.8			5.51			0.46			5.42			1		
03/25/23 23:02	234667.7			0.6			10.33			0.35			9.31			1		
03/25/23 23:03	207558			2.5			21.86			1.23			17.44			1		
03/25/23 23:04	183529.1			115.9			24.37			49.68			17.18			1		
03/25/23 23:05	166046.4			647.5			27.44			251.05			17.51			1		
03/25/23 23:06	123456.6			1417.3			28.66			408.64			13.6			1		
03/25/23 23:07	0			0			31.4			0			0			0		
03/25/23 23:08	0			0			47.2			0			0			0		
03/25/23 23:09	0			0			0.2			0			0			0		
03/25/23 23:10	0			0			0.1			0			0			0		
03/25/23 23:11	0			0			0.1			0			0			0		

ATTACHMENT 4

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:54 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2023	0.8256	7.5859	1.0650	14.2128	0.2163	2.9308	0.1084	1.4667	0.3601	4.8854
Feb 2023	0.9164	7.5652	1.0643	14.3537	0.2142	2.9600	0.1074	1.4819	0.3569	4.9340
Mar 2023	0.9505	8.1089	1.0109	14.8234	0.1947	3.0447	0.0971	1.5240	0.3242	5.0748
Sum/Avg	8.1089		14.8234		3.0447		1.5240		5.0748	
Limit Value										

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
01/01/23 0:00	0			0			8.02			40.92								
01/02/23 0:00	56.95			45.89			13.35			61.59								
01/03/23 0:00	21.5			76.62			21.66			82.15								
01/04/23 0:00	24.58			24.68			13.68			51.45								
01/05/23 0:00	57.48			18.57			12.57			44.09								
01/06/23 0:00	57.39			24.3			15.25			46.24								
01/07/23 0:00	0			0			11.01			41.31								
01/08/23 0:00	64.32			25.12			15.71			47.03								
01/09/23 0:00	79.81			31.33			17.21			50.53								
01/10/23 0:00	70.81			28.6			17.16			48.86								
01/11/23 0:00	64.59			23.74			15.78			47.51								
01/12/23 0:00	71.9			24.54			15.71			47.32								
01/13/23 0:00	0			0			10.9			41.32								
01/14/23 0:00	61.07			23.27			14.86			45.76								
01/15/23 0:00	74.99			26.95			16.64			49.02								
01/16/23 0:00	71.17			29			17.31			49.04								
01/17/23 0:00	62.55			27.66			18.68			49.31								
01/18/23 0:00	27.47			26.3			21.67			52.68								
01/19/23 0:00	0			0			21.19			46.72								
01/20/23 0:00	0			0			40.39			62.03								
01/21/23 0:00	0			0			22.86			59.46								
01/22/23 0:00	0			0			22.45			50.42								
01/23/23 0:00	45.51			32.42			30.31			62.96								
01/24/23 0:00	28.15			28.52			23.11			54.38								
01/25/23 0:00	0			0			13.09			41.63								
01/26/23 0:00	0			0			12.89			41.93								
01/27/23 0:00	52.26			24.65			38.42			40.84								
01/28/23 0:00	9.3			37.73			0			0								
01/29/23 0:00	10.01			41.55			82.89			21.08								
01/30/23 0:00	25.25			66.19			0			0								
01/31/23 0:00	29.56			64.58			0			0								
02/01/23 0:00	19.34			50.2			0			0								
02/02/23 0:00	8.96			37.94			0			0								
02/03/23 0:00	18.33			53			34.79			32.39								
02/04/23 0:00	88.9			28.42			19.21			49.57								

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 0:00	72.85			19.97			15.11			44.22								
02/06/23 0:00	66.07			28.38			18.18			50.18								
02/07/23 0:00	54.39			31.54			19.9			52.58								
02/08/23 0:00	19.59			58.04			83.2			56.53								
02/09/23 0:00	16.98			57.78			93.16			55.85								
02/10/23 0:00	15.54			47.51			56.39			33.61								
02/11/23 0:00	78.77			51.25			29.63			62.2								
02/12/23 0:00	18.67			58.19			87.61			56.57								
02/13/23 0:00	21.08			1.97			14.23			41.36								
02/14/23 0:00	48.02			35.19			20.05			54.93								
02/15/23 0:00	78.97			56.55			60.43			68.66								
02/16/23 0:00	84.71			51.67			28.52			61.52								
02/17/23 0:00	32.4			11.48			19.16			45.81								
02/18/23 0:00	0			0			14.71			41.46								
02/19/23 0:00	0			0			16.33			41.56								
02/20/23 0:00	55.98			29.43			37.57			49.48								
02/21/23 0:00	10.53			37.94			0			0								
02/22/23 0:00	13.81			47.37			60.66			35.16								
02/23/23 0:00	20.19			61.35			43.6			43.18								
02/24/23 0:00	33.93			63.8			0			0								
02/25/23 0:00	11.76			44.64			0			0								
02/26/23 0:00	8.81			37.99			0			0								
02/27/23 0:00	13.34			44.7			64.84			27.49								
02/28/23 0:00	15.61			46.23			67.37			31.09								
03/01/23 0:00	15.98			48.98			36			25.13								
03/02/23 0:00	9.67			39.23			0			0								
03/03/23 0:00	17.71			49.06			67.58			32.55								
03/04/23 0:00	13			45.07			62.09			27.5								
03/05/23 0:00	13.8			49.68			61.24			36.09								
03/06/23 0:00	20.36			52.61			105.84			49.28								
03/07/23 0:00	21.62			55.27			94.58			52.97								
03/08/23 0:00	22.39			57.71			67.45			57.12								
03/09/23 0:00	23.79			69.25			52.21			73.87								
03/10/23 0:00	9.44			42.96			85.74			25.92								
03/11/23 0:00	9.07			46.22			47.27			30.46								
03/12/23 0:00	11.68			58.61			60.68			56.66								
03/13/23 0:00	8.96			47.05			50.13			22.5								
03/14/23 0:00	10.54			59.12			77.36			53.29								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
03/15/23 0:00	8.47			43.3			60.16			28.2								
03/16/23 0:00	4.36			24.48			53.75			27.35								
03/17/23 0:00	80.03			57.91			104.95			52.15								
03/18/23 0:00	11.23			46.72			77.93			29.45								
03/19/23 0:00	12.23			50.34			57.6			36.75								
03/20/23 0:00	28.92			42.52			71.9			31.84								
03/21/23 0:00	0			0			50.51			34.49								
03/22/23 0:00	67.43			32.81			15.19			52.51								
03/23/23 0:00	64.93			29.97			17.5			50.91								
03/24/23 0:00	0			0			12.46			43.27								
03/25/23 0:00	0			0			25.39			43.01								
03/26/23 0:00	0			0			0			0								
03/27/23 0:00	0			0			0			0								
03/28/23 0:00	0			0			0			0								
03/29/23 0:00	0			0			0			0								
03/30/23 0:00	0			0			0			0								
03/31/23 0:00	0			0			0			0								
04/01/23 0:00	0	X		0	X		0	X		0	X							

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/01/23 0:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 1:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 2:00	0	X		0	X		0	X	1	0.5			1.3			14.6		1
01/01/23 3:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 4:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 5:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 6:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 7:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 8:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 9:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 10:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 11:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 12:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 13:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 14:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 15:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 16:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/01/23 17:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 18:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 19:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 20:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/01/23 21:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/01/23 22:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/01/23 23:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/02/23 0:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/02/23 1:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/02/23 2:00	0	X		0	X		0	X	1	0.5			1.4			14.6		1
01/02/23 3:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/02/23 4:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/02/23 5:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/02/23 6:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/02/23 7:00	0	X		0	X		0	X	1	0.7			1.4			14.4		1
01/02/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/02/23 9:00	0	X		0	X		0	X	1	0.6			1.5			14.6		1
01/02/23 10:00	0	X		0	X		0	X	1	0.6			1.2			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 11:00	0	X		0	X		0	X	1	0.6			1.3			14.5		1
01/02/23 12:00	0			0			15.5		1	0.7			1.4			14.4		1
01/02/23 13:00	0.8			1.4			13.9		1	0.9			1.3			14.1		1
01/02/23 14:00	0.4			1.5			12.5		1	0.4			1.5			12.7		1
01/02/23 15:00	0.4			1.5			12.6		1	0.4			1.5			12.8		1
01/02/23 16:00	0.4			1.5			12.6		1	0.4			1.5			12.8		1
01/02/23 17:00	0.4			1.5			12.6		1	0.4			1.5			12.8		1
01/02/23 18:00	0.4			1.5			12.7		1	0.4			1.5			12.8		1
01/02/23 19:00	0.4			1.5			12.7		1	0.4			1.5			12.9		1
01/02/23 20:00	0.4			1.5			12.8		1	0.4			1.5			12.9		1
01/02/23 21:00	0.5			1.5			12.9		1	0.5			1.5			13		1
01/02/23 22:00	0.7			1.5			13.1		1	0.6			1.5			13.2		1
01/02/23 23:00	0.7			1.5			13.2		1	0.7			1.5			13.3		1
01/03/23 0:00	0.6			1.5			13		1	0.6			1.5			13.1		1
01/03/23 1:00	0.6			1.5			13.1		1	0.6			1.5			13.2		1
01/03/23 2:00	0.6			1.5			13.1		1	0.6			1.5			13.2		1
01/03/23 3:00	0.6			1.5			13		1	0.6			1.5			13.1		1
01/03/23 4:00	0.5			1.5			12.9		1	0.5			1.5			13.1		1
01/03/23 5:00	0.5			1.5			12.9		1	0.5			1.5			13		1
01/03/23 6:00	0.3			1.5			12.5		1	0.3			1.5			12.7		1
01/03/23 7:00	0.5			1.5			12.8		1	0.4			1.5			13		1
01/03/23 8:00	1			1.5			13.6		1	1			1.5			13.7		1
01/03/23 9:00	1.1			1.5			13.5		1	1			1.5			13.7		1
01/03/23 10:00	1.4			1.5			13.8		1	1.2			1.5			14		1
01/03/23 11:00	1.3			1.5			13.9		1	1.1			1.5			14		1
01/03/23 12:00	1.2			1.5			13.7		1	1			1.5			13.9		1
01/03/23 13:00	1.2			1.5			13.8		1	1.1			1.5			13.9		1
01/03/23 14:00	1.1			1.5			13.6		1	1			1.5			13.7		1
01/03/23 15:00	0.4			1.5			12.7		1	0.4			1.5			12.8		1
01/03/23 16:00	0.5			1.5			12.9		1	0.4			1.5			13		1
01/03/23 17:00	0.5			1.5			12.9		1	0.4			1.5			13		1
01/03/23 18:00	0.5			1.5			12.8		1	0.4			1.5			13		1
01/03/23 19:00	0.5			1.5			12.9		1	0.5			1.5			13.1		1
01/03/23 20:00	0.5			1.5			12.7		1	0.4			1.5			12.9		1
01/03/23 21:00	0.4			1.5			12.7		1	0.4			1.5			12.9		1
01/03/23 22:00	0.4			1.5			12.9		1	0.4			1.5			13		1
01/03/23 23:00	0.8			1.5			13.3		1	0.8			1.5			13.5		1
01/04/23 0:00	1			1.5			14.3		1	0.9			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 1:00	0.8			1.5			14.3		1	0.7			1.5			14.4		1
01/04/23 2:00	0.7			1.6			14.3		1	0.7			1.7			14.4		1
01/04/23 3:00	0.8			1.5			14.3		1	0.7			1.5			14.4		1
01/04/23 4:00	0.8			1.5			14.3		1	0.7			1.5			14.4		1
01/04/23 5:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
01/04/23 6:00	0.7			1.5			14.3		1	0.7			1.5			14.4		1
01/04/23 7:00	1.4			1.5			13.9		1	1.3			1.5			14		1
01/04/23 8:00	1			1.5			14.3		1	0.9			1.4			14.3		1
01/04/23 9:00	0			0			17.5		1	0.6			1.3			14.5		1
01/04/23 10:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 11:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 12:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 13:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 14:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 15:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/04/23 16:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/04/23 17:00	0	X		0	X		0	X	1	0.5			1.5			14.7		1
01/04/23 18:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 19:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 20:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 21:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 22:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/04/23 23:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 0:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 1:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 2:00	0	X		0	X		0	X	1	0.5			1.4			14.6		1
01/05/23 3:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 4:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 5:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 6:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 7:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 8:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 9:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 10:00	0	X		0	X		0	X	1	0.5			1.5			14.6		1
01/05/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:00	0			0			16.2		1	1.1			1.3			14.4		1
01/05/23 16:00	1			1.6			14.3		1	1			1.4			14.4		1
01/05/23 17:00	1.1			1.5			13.7		1	1.1			1.5			13.8		1
01/05/23 18:00	1.2			1.5			14		1	1.2			1.5			14.1		1
01/05/23 19:00	0.6			1.4			15.1		1	0.7			1.3			14.5		1
01/05/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/05/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 2:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/06/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/06/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 15:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/06/23 16:00	0.7			1.2			15.4		1	0.8			1.4			14.4		1
01/06/23 17:00	1			1.2			14.1		1	1.4			1.5			14.3		1
01/06/23 18:00	1.1			1.5			13.8		1	1.1			1.5			13.9		1
01/06/23 19:00	1.1			1.5			13.8		1	1.2			1.5			13.9		1
01/06/23 20:00	0.9			1.5			14.2		1	0.9			1.5			14.3		1
01/06/23 21:00	0.6			1.6			14.8		1	0.8			1.3			14.5		1
01/06/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/06/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 2:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
01/07/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/07/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/07/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 19:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/07/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/07/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
01/08/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/08/23 15:00	0	X		0	X		0	X	1	0.8			1.3			14.6		1
01/08/23 16:00	0.8			1.2			15.4		1	0.8			1.4			14.4		1
01/08/23 17:00	1			1.4			14		1	1.1			1.4			14.1		1
01/08/23 18:00	1.1			1.5			13.7		1	1.1			1.5			13.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 19:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
01/08/23 20:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
01/08/23 21:00	1			1.5			14		1	1.1			1.5			14.1		1
01/08/23 22:00	0.6			1.3			15.1		1	0.8			1.3			14.5		1
01/08/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 2:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/09/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/09/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/09/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/09/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/09/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/09/23 13:00	0			0			19.8		1	0.7			1.4			14.5		1
01/09/23 14:00	0.5			1.6			14.7		1	0.8			1.5			14.4		1
01/09/23 15:00	0.9			1.5			14.1		1	1.1			1.4			14.2		1
01/09/23 16:00	0.6			1.5			13.3		1	1			1.5			13.5		1
01/09/23 17:00	0.6			1.5			13.4		1	1			1.5			13.5		1
01/09/23 18:00	0.8			1.5			13.5		1	1			1.5			13.6		1
01/09/23 19:00	0.9			1.5			13.5		1	1.1			1.5			13.6		1
01/09/23 20:00	0.9			1.5			13.5		1	1.1			1.5			13.6		1
01/09/23 21:00	1			1.5			14.3		1	1.1			1.4			14.2		1
01/09/23 22:00	0	X		0	X		0	X	1	0.8			1.4			14.4		1
01/09/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
01/10/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/10/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 2:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/10/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/10/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/10/23 15:00	0			0			20.1		1	0.7			1.3			14.5		1
01/10/23 16:00	0.5			0.7			14.9		1	0.8			1.4			14.4		1
01/10/23 17:00	1			1.5			13.9		1	1.2			1.4			14		1
01/10/23 18:00	1			1.5			13.6		1	1.1			1.5			13.7		1
01/10/23 19:00	0.9			1.5			13.6		1	1.1			1.5			13.7		1
01/10/23 20:00	1			1.5			13.7		1	1.1			1.5			13.8		1
01/10/23 21:00	1.1			1.5			13.9		1	1.2			1.5			14		1
01/10/23 22:00	1			1.5			14.1		1	1.2			1.5			14.1		1
01/10/23 23:00	0.4			1.6			15.1		1	0.7			1.3			14.5		1
01/11/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 2:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/11/23 14:00	0	X		0	X		0	X	1	0.7			1.3			14.6		1
01/11/23 15:00	0.5			0.9			15.3		1	0.8			1.5			14.4		1
01/11/23 16:00	0.9			1.5			13.9		1	1.1			1.4			14		1
01/11/23 17:00	1			1.5			13.7		1	1.1			1.5			13.8		1
01/11/23 18:00	1			1.5			13.8		1	1.2			1.5			13.9		1
01/11/23 19:00	1			1.5			13.8		1	1.2			1.5			14		1
01/11/23 20:00	0.9			1.5			14		1	1.1			1.5			14.1		1
01/11/23 21:00	0			0			15.7		1	0.8			1.3			14.5		1
01/11/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
01/12/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/12/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/12/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/12/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/12/23 15:00	0			0			18.9		1	0.7			1.4			14.6		1
01/12/23 16:00	0.5			1.7			14.5		1	0.7			1.5			14.5		1
01/12/23 17:00	0.9			1.5			14		1	1			1.5			14.1		1
01/12/23 18:00	1.2			1.5			13.7		1	1.2			1.5			13.9		1
01/12/23 19:00	1.1			1.5			13.8		1	1.2			1.5			13.9		1
01/12/23 20:00	1.1			1.5			13.7		1	1.2			1.5			13.9		1
01/12/23 21:00	1			1.5			14		1	1.1			1.5			14.2		1
01/12/23 22:00	0.5			1.2			15.2		1	0.8			1.3			14.5		1
01/12/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 2:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
01/13/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/13/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/13/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 19:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/13/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 2:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/14/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 9:00	0	X		0	X		0	X	1	0.7			1.3			14.6		1
01/14/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/14/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 14:00	0			0			19.7		1	0.8			1.3			14.5		1
01/14/23 15:00	0			0			14.7		1	0.7			1.5			14.5		1
01/14/23 16:00	0.8			1.5			13.9		1	1.1			1.4			14		1
01/14/23 17:00	1.1			1.5			13.7		1	1.1			1.5			13.9		1
01/14/23 18:00	1			1.5			13.7		1	1.1			1.5			13.8		1
01/14/23 19:00	0.9			1.5			14		1	1.2			1.5			14.1		1
01/14/23 20:00	0.6			1.6			14.9		1	0.8			1.3			14.5		1
01/14/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/14/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/15/23 14:00	0			0			20.8		1	0.7			1.4			14.5		1
01/15/23 15:00	0.6			0.7			15		1	0.8			1.5			14.4		1
01/15/23 16:00	0.8			1.4			14.2		1	1.1			1.4			14.4		1
01/15/23 17:00	0.9			1.5			13.5		1	1.1			1.5			13.7		1
01/15/23 18:00	0.9			1.5			13.5		1	1.1			1.5			13.7		1
01/15/23 19:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
01/15/23 20:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
01/15/23 21:00	0.8			1.4			14.1		1	1			1.4			14.3		1
01/15/23 22:00	0.5			1.7			15.3		1	0.8			1.3			14.5		1
01/15/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 2:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/16/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
01/16/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/16/23 14:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/16/23 15:00	0.5			0.9			15.3		1	0.8			1.4			14.5		1
01/16/23 16:00	0.7			1.3			14.2		1	0.9			1.4			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 17:00	1			1.5			13.8		1	1.2			1.5			13.9		1
01/16/23 18:00	1.1			1.5			13.8		1	1.2			1.5			13.9		1
01/16/23 19:00	1.1			1.5			13.8		1	1.2			1.5			13.9		1
01/16/23 20:00	1.1			1.5			13.8		1	1.2			1.5			13.9		1
01/16/23 21:00	1.2			1.5			13.8		1	1.2			1.5			14		1
01/16/23 22:00	0.9			1.5			14.3		1	1			1.5			14.3		1
01/16/23 23:00	0	X		0	X		0	X	1	0.8			1.3			14.5		1
01/17/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 1:00	0	X		0	X		0	X	1	1			1.5			14.6		1
01/17/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
01/17/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 7:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
01/17/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/17/23 16:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/17/23 17:00	0			0			15.4		1	0.8			1.5			14.4		1
01/17/23 18:00	0.9			1.5			14		1	1.1			1.4			14.2		1
01/17/23 19:00	1.2			1.5			13.9		1	1.2			1.5			14		1
01/17/23 20:00	1.3			1.5			13.9		1	1.3			1.5			14.1		1
01/17/23 21:00	1.3			1.5			13.9		1	1.4			1.5			14.1		1
01/17/23 22:00	1.4			1.5			14		1	1.4			1.5			14.1		1
01/17/23 23:00	1.5			1.5			14		1	1.5			1.5			14.1		1
01/18/23 0:00	1.3			1.5			13.9		1	1.3			1.5			14.1		1
01/18/23 1:00	1.2			1.5			13.9		1	1.3			1.5			14		1
01/18/23 2:00	1.2			1.5			13.9		1	1.3			1.5			14.1		1
01/18/23 3:00	1.2			1.5			13.9		1	1.3			1.5			14.1		1
01/18/23 4:00	1.3			1.5			14		1	1.3			1.5			14.1		1
01/18/23 5:00	1.3			1.5			14		1	1.4			1.5			14.1		1
01/18/23 6:00	1.2			1.5			13.9		1	1.4			1.5			14.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 7:00	1.3			1.5			14		1	1.5			1.5			14.2		1
01/18/23 8:00	1.1			1.5			14.1		1	1.3			1.5			14.3		1
01/18/23 9:00	0.5			1.6			15.2		1	0.8			1.3			14.6		1
01/18/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/18/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 19:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/18/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/18/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/19/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.7		1
01/19/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 4:00	0	X		0	X		0	X	1	0.6			1.5			14.7		1
01/19/23 5:00	0	X		0	X		0	X	1	0.6			1.5			14.7		1
01/19/23 6:00	0	X		0	X		0	X	1	0.6			1.5			14.7		1
01/19/23 7:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
01/19/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 9:00	0	X		0	X		0	X	1	0.7			1.1			14.7		1
01/19/23 10:00	0	X		0	X		0	X	1	0.7			1.3			14.7		1
01/19/23 11:00	0	X		0	X		0	X	1	0.7			0.6			14.7		1
01/19/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/19/23 17:00	0	X		0	X		0	X	1	1			1.4			14.5		1
01/19/23 18:00	0	X		0	X		0	X	1	1.9			1.5			14.3		1
01/19/23 19:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/19/23 20:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/19/23 21:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/19/23 22:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/19/23 23:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 0:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 1:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 2:00	0	X		0	X		0	X	1	1.8			1.6			14.2		1
01/20/23 3:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 4:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 5:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 6:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 7:00	0	X		0	X		0	X	1	1.7			1.5			14.2		1
01/20/23 8:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/20/23 9:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/20/23 10:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
01/20/23 11:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
01/20/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
01/20/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/20/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/20/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/20/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/20/23 17:00	0	X		0	X		0	X	1	1.3			1.4			14.4		1
01/20/23 18:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
01/20/23 19:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/20/23 20:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
01/20/23 21:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
01/20/23 22:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
01/20/23 23:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
01/21/23 0:00	0	X		0	X		0	X	1	1.3			1.5			14.3		1
01/21/23 1:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 2:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 3:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 4:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 5:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 6:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 7:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 8:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
01/21/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/21/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/21/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/21/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/21/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/21/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/21/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/21/23 16:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
01/21/23 17:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
01/21/23 18:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
01/21/23 19:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
01/21/23 20:00	0	X		0	X		0	X	1	1			1.5			14.4		1
01/21/23 21:00	0	X		0	X		0	X	1	2.3			1.5			14.2		1
01/21/23 22:00	0	X		0	X		0	X	1	1.6			1.5			14.3		1
01/21/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/22/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/22/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/22/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
01/22/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/22/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/22/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/22/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/22/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/22/23 16:00	0	X		0	X		0	X	1	1			1.3			14.5		1
01/22/23 17:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/22/23 18:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/22/23 19:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
01/22/23 20:00	0	X		0	X		0	X	1	1.5			1.5			14.1		1
01/22/23 21:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
01/22/23 22:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/22/23 23:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 0:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 1:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 2:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 3:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 4:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 5:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
01/23/23 6:00	0	X		0	X		0	X	1	1.5			1.5			14.1		1
01/23/23 7:00	0	X		0	X		0	X	1	1.3			1.5			14		1
01/23/23 8:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
01/23/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/23/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/23/23 16:00	0			0			15.4		1	1			1.3			14.4		1
01/23/23 17:00	1.1			1.5			14.2		1	1.4			1.4			14.3		1
01/23/23 18:00	0.8			1.5			13.6		1	1.2			1.5			13.7		1
01/23/23 19:00	0.5			1.5			13.1		1	0.7			1.5			13.2		1
01/23/23 20:00	0.6			1.5			13.2		1	0.9			1.5			13.3		1
01/23/23 21:00	0.8			1.5			13.5		1	1			1.5			13.5		1
01/23/23 22:00	0.9			1.5			13.6		1	1			1.5			13.5		1
01/23/23 23:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
01/24/23 0:00	0.8			1.5			14.4		1	1.1			1.5			14.4		1
01/24/23 1:00	0.7			1.5			14.4		1	1			1.5			14.4		1
01/24/23 2:00	0.7			1.5			14.3		1	1			1.5			14.4		1
01/24/23 3:00	0.7			1.5			14.3		1	1			1.5			14.4		1
01/24/23 4:00	0.7			1.5			14.3		1	1			1.5			14.4		1
01/24/23 5:00	0.9			1.5			13.7		1	1.3			1.5			13.8		1
01/24/23 6:00	0.6			1.5			13.1		1	0.9			1.5			13.1		1
01/24/23 7:00	1.4			1.5			14		1	1.8			1.5			14.1		1
01/24/23 8:00	1.5			1.5			14.1		1	2			1.5			14.2		1
01/24/23 9:00	0.6			1.5			14.4		1	1.2			1.5			14.4		1
01/24/23 10:00	0.4			1.4			15.2		1	0.8			1.2			14.6		1
01/24/23 11:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/24/23 12:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
01/24/23 13:00	0	X		0	X		0	X	1	0.7			1.4			14.7		1
01/24/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/24/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/24/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/24/23 18:00	0	X		0	X		0	X	1	0.9			1.4			14.5		1
01/24/23 19:00	0	X		0	X		0	X	1	0.9			1.4			14.5		1
01/24/23 20:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/24/23 21:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/24/23 22:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/24/23 23:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/25/23 0:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/25/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/25/23 2:00	0	X		0	X		0	X	1	0.8			1.3			14.7		1
01/25/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/25/23 4:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
01/25/23 5:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
01/25/23 6:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/25/23 7:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/25/23 8:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/25/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
01/25/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/25/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/25/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/25/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/25/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/25/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 19:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/25/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/26/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/26/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 2:00	0	X		0	X		0	X	1	0.8			1.8			14.7		1
01/26/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/26/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 6:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 7:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 15:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 16:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 17:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 18:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 19:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 20:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 21:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/26/23 22:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/26/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/27/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/27/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 2:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 6:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 7:00	0	X		0	X		0	X	1	0.8			1.4			14.6		1
01/27/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
01/27/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
01/27/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
01/27/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/27/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/27/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
01/27/23 15:00	0	X		0	X		0	X	1	1			1.4			14.6		1
01/27/23 16:00	0			0			15.7		1	1.6			1.5			14.4		1
01/27/23 17:00	1.3			1.6			14.1		1	1.5			1.5			14.2		1
01/27/23 18:00	1.1			1.5			13.8		1	1.3			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 19:00	1			1.5			14		1	1.2			1.5			14.2		1
01/27/23 20:00	0.7			1.5			14.3		1	1			1.5			14.7		1
01/27/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/27/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/27/23 23:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 0:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
01/28/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 2:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
01/28/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 4:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 5:00	0.8			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 6:00	0.7			1.5			14.4		1	0	X		0	X		0	X	1
01/28/23 7:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
01/28/23 8:00	0.6			1.3			14.5		1	0	X		0	X		0	X	1
01/28/23 9:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
01/28/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 14:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 16:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 17:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 19:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/28/23 23:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 1:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 2:00	0.5			1.4			14.4		1	0	X		0	X		0	X	1
01/29/23 3:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 4:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 5:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 6:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 7:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 8:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:00	0.7			1.5			14.3		1	0			0			15.7		1
01/29/23 10:00	0.9			1.5			14.2		1	1.2			1.4			14.4		1
01/29/23 11:00	1			1.5			13.9		1	1.2			1.3			14.1		1
01/29/23 12:00	0.7			1.4			14.3		1	1			1.5			14.6		1
01/29/23 13:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 14:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 15:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 16:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 17:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 18:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 19:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 20:00	0.5			1.5			14.4		1	0	X		0	X		0	X	1
01/29/23 21:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 22:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/29/23 23:00	0.4			1.5			14.5		1	0	X		0	X		0	X	1
01/30/23 0:00	0.4			1.5			14.5		1	0	X		0	X		0	X	1
01/30/23 1:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
01/30/23 2:00	0.9			1.3			14.3		1	0	X		0	X		0	X	1
01/30/23 3:00	1.4			1.6			14		1	0	X		0	X		0	X	1
01/30/23 4:00	1.4			1.5			14		1	0	X		0	X		0	X	1
01/30/23 5:00	1.2			1.5			13.8		1	0	X		0	X		0	X	1
01/30/23 6:00	0.9			1.5			13.5		1	0	X		0	X		0	X	1
01/30/23 7:00	0.1			1.5			12		1	0	X		0	X		0	X	1
01/30/23 8:00	0.2			1.5			12.3		1	0	X		0	X		0	X	1
01/30/23 9:00	1			1.5			13.9		1	0	X		0	X		0	X	1
01/30/23 10:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 11:00	1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 12:00	0.9			1.5			14		1	0	X		0	X		0	X	1
01/30/23 13:00	0.9			1.5			14		1	0	X		0	X		0	X	1
01/30/23 14:00	0.9			1.5			14		1	0	X		0	X		0	X	1
01/30/23 15:00	0.9			1.5			14		1	0	X		0	X		0	X	1
01/30/23 16:00	0.9			1.5			14		1	0	X		0	X		0	X	1
01/30/23 17:00	1.1			1.5			14		1	0	X		0	X		0	X	1
01/30/23 18:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 19:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 20:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 21:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/30/23 22:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/30/23 23:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 0:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 1:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 2:00	1.1			1.6			14.1		1	0	X		0	X		0	X	1
01/31/23 3:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 4:00	1.2			1.5			14		1	0	X		0	X		0	X	1
01/31/23 5:00	1.2			1.5			14		1	0	X		0	X		0	X	1
01/31/23 6:00	1.2			1.5			14		1	0	X		0	X		0	X	1
01/31/23 7:00	1.2			1.5			13.9		1	0	X		0	X		0	X	1
01/31/23 8:00	1.2			1.5			14		1	0	X		0	X		0	X	1
01/31/23 9:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 10:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 11:00	1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 12:00	1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 13:00	0.8			1.5			14.2		1	0	X		0	X		0	X	1
01/31/23 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
01/31/23 15:00	0.8			1.4			14.4		1	0	X		0	X		0	X	1
01/31/23 16:00	1.2			1.5			14		1	0	X		0	X		0	X	1
01/31/23 17:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 18:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 19:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 20:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 21:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 22:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
01/31/23 23:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 0:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 1:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 2:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 3:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 4:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 5:00	1.3			1.5			14		1	0	X		0	X		0	X	1
02/01/23 6:00	1.2			1.5			14		1	0	X		0	X		0	X	1
02/01/23 7:00	1.2			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 8:00	1.3			1.5			14		1	0	X		0	X		0	X	1
02/01/23 9:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/01/23 10:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/01/23 11:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 12:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/01/23 13:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 14:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 15:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 16:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 17:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 18:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 19:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/01/23 20:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/01/23 21:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/01/23 22:00	0.8			1.5			14.6		1	0	X		0	X		0	X	1
02/01/23 23:00	0.8			1.5			14.6		1	0	X		0	X		0	X	1
02/02/23 0:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/02/23 1:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 2:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 3:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 4:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 5:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 8:00	0.8			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 9:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 12:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 13:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 15:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 16:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
02/02/23 17:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 18:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 19:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 22:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/02/23 23:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 2:00	0.5			1.6			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 3:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 4:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
02/03/23 5:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
02/03/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 7:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1
02/03/23 8:00	0.6			1.6			14.4		1	0	X		0	X		0	X	1
02/03/23 9:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 10:00	0.5			1.5			14.5		1	0	X		0	X		0	X	1
02/03/23 11:00	0.9			1.4			14.3		1	0	X		0	X		0	X	1
02/03/23 12:00	1.2			1.5			14		1	0	X		0	X		0	X	1
02/03/23 13:00	1.2			1.5			14		1	0	X		0	X		0	X	1
02/03/23 14:00	1.1			1.5			14		1	0	X		0	X		0	X	1
02/03/23 15:00	1			1.5			14.1		1	0	X		0	X		0	X	1
02/03/23 16:00	0.6			1.5			14.4		1	0			0			15.5		1
02/03/23 17:00	0.9			1.5			14.2		1	1.3			1.1			14.3		1
02/03/23 18:00	0.9			1.5			13.6		1	1.2			1.6			13.8		1
02/03/23 19:00	0.8			1.5			13.5		1	1.1			1.5			13.6		1
02/03/23 20:00	0.9			1.5			13.5		1	1.1			1.5			13.6		1
02/03/23 21:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
02/03/23 22:00	1.2			1.5			13.8		1	1.3			1.5			14		1
02/03/23 23:00	1.1			1.5			14.1		1	1.4			1.5			14.2		1
02/04/23 0:00	0.8			1.7			15.1		1	0.9			1.3			14.5		1
02/04/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 2:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
02/04/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 4:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/04/23 5:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/04/23 6:00	0	X		0	X		0	X	1	0.9			1.5			14.5		1
02/04/23 7:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/04/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/04/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/04/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/04/23 15:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
02/04/23 16:00	0			0			15.4		1	1.1			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 17:00	1			1.5			14.1		1	1.3			1.3			14.2		1
02/04/23 18:00	1			1.5			13.6		1	1.1			1.5			13.7		1
02/04/23 19:00	0.8			1.5			13.5		1	1.1			1.5			13.6		1
02/04/23 20:00	0.7			1.5			13.4		1	1			1.5			13.5		1
02/04/23 21:00	0.7			1.5			13.3		1	1			1.5			13.5		1
02/04/23 22:00	0.8			1.5			13.9		1	1.1			1.5			14		1
02/04/23 23:00	0.5			1.5			15.2		1	0.8			1.3			14.5		1
02/05/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 2:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/05/23 17:00	0			0			20.7		1	0.8			1.4			14.6		1
02/05/23 18:00	0.7			0.8			15.1		1	0.9			1.5			14.4		1
02/05/23 19:00	0.7			1.4			14.2		1	1			1.5			14.3		1
02/05/23 20:00	1.2			1.5			13.9		1	1.3			1.5			14.1		1
02/05/23 21:00	1.1			1.5			14.1		1	1.3			1.5			14.2		1
02/05/23 22:00	0.4			1.7			14.9		1	0.9			1.4			14.6		1
02/05/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/06/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/06/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/06/23 2:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/06/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 7:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
02/06/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
02/06/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
02/06/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/06/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/06/23 15:00	0			0			19.9		1	0.8			1.4			14.6		1
02/06/23 16:00	0.5			1.4			14.8		1	0.9			1.5			14.5		1
02/06/23 17:00	0.8			1.5			13.9		1	1.2			1.4			14		1
02/06/23 18:00	0.7			1.5			13.5		1	1.1			1.5			13.6		1
02/06/23 19:00	0.8			1.5			13.5		1	1.1			1.5			13.6		1
02/06/23 20:00	0.5			1.5			13.1		1	0.8			1.5			13.2		1
02/06/23 21:00	0.9			1.5			13.7		1	1.2			1.5			13.8		1
02/06/23 22:00	1			1.5			14.1		1	1.2			1.5			14.2		1
02/06/23 23:00	0.6			1.5			14.7		1	1			1.3			14.5		1
02/07/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 2:00	0	X		0	X		0	X	1	0.8			1.6			14.6		1
02/07/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 6:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/07/23 7:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/07/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/07/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
02/07/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/07/23 15:00	0			0			19.5		1	1			1.4			14.5		1
02/07/23 16:00	0.7			0.6			14.6		1	1			1.4			14.5		1
02/07/23 17:00	1			1.5			13.9		1	1.3			1.5			14		1
02/07/23 18:00	0.6			1.5			13.2		1	1			1.5			13.4		1
02/07/23 19:00	0.7			1.5			13.2		1	0.9			1.5			13.4		1
02/07/23 20:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 21:00	0.8			1.5			13.3		1	1			1.5			13.4		1
02/07/23 22:00	0.9			1.5			13.5		1	1.1			1.5			13.6		1
02/07/23 23:00	1.2			1.5			13.7		1	1.4			1.5			13.8		1
02/08/23 0:00	1			1.5			14.3		1	1.3			1.5			14.4		1
02/08/23 1:00	0.8			1.5			14.3		1	1.2			1.5			14.4		1
02/08/23 2:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
02/08/23 3:00	0.9			1.5			14.2		1	1.2			1.5			14.3		1
02/08/23 4:00	0.9			1.5			14.3		1	1.1			1.5			14.4		1
02/08/23 5:00	1.1			1.5			14.2		1	1.4			1.5			14.3		1
02/08/23 6:00	1			1.5			13.4		1	1.4			1.5			13.6		1
02/08/23 7:00	1.2			1.5			13.8		1	1.3			1.5			14.1		1
02/08/23 8:00	0.7			1.7			14.4		1	1.1			1.6			14.9		1
02/08/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 14:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/08/23 15:00	0.7			1.5			14.5		1	0			0			20.7		1
02/08/23 16:00	0.7			1.4			14.4		1	0.9			0.9			15.1		1
02/08/23 17:00	1			1.5			13.8		1	1.3			1.5			13.9		1
02/08/23 18:00	0.4			1.5			13		1	0.7			1.5			13.1		1
02/08/23 19:00	0.6			1.5			13.2		1	0.9			1.5			13.3		1
02/08/23 20:00	1.2			1.5			13.5		1	1.3			1.5			13.6		1
02/08/23 21:00	0.7			1.5			13		1	0.9			1.5			13.1		1
02/08/23 22:00	0.8			1.5			13.3		1	1			1.5			13.4		1
02/08/23 23:00	1.2			1.5			13.9		1	1.3			1.5			14		1
02/09/23 0:00	0.8			1.5			14.4		1	1			1.5			14.5		1
02/09/23 1:00	0.8			1.5			14.4		1	1			1.5			14.4		1
02/09/23 2:00	0.8			1.6			14.4		1	0.9			1.4			14.5		1
02/09/23 3:00	0.8			1.5			14.3		1	1			1.5			14.5		1
02/09/23 4:00	0.9			1.5			14.3		1	1.3			1.5			14.4		1
02/09/23 5:00	0.8			1.5			13.3		1	1.2			1.5			13.5		1
02/09/23 6:00	0.6			1.5			13		1	0.8			1.5			13.2		1
02/09/23 7:00	1.1			1.5			14		1	1.2			1.5			14.1		1
02/09/23 8:00	0.7			1.4			14.5		1	0.8			1.4			15.3		1
02/09/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/09/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/09/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/09/23 13:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/09/23 14:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/09/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/09/23 16:00	0.6			1.5			14.5		1	0.8			0.7			15.6		1
02/09/23 17:00	1			1.5			14.1		1	1.3			1.2			14.2		1
02/09/23 18:00	0.4			1.5			12.9		1	0.7			1.5			13.1		1
02/09/23 19:00	0.7			1.5			13.3		1	1			1.5			13.5		1
02/09/23 20:00	0.6			1.5			13.1		1	0.8			1.5			13.2		1
02/09/23 21:00	0.6			1.5			13		1	0.8			1.5			13.2		1
02/09/23 22:00	0.8			1.5			13.3		1	1			1.5			13.5		1
02/09/23 23:00	1			1.5			14.2		1	1.2			1.4			14.4		1
02/10/23 0:00	0.7			1.4			14.4		1	0	X		0	X		0	X	1
02/10/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 2:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
02/10/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 6:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/10/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/10/23 15:00	0.6			1.5			14.5		1	0			0			20.1		1
02/10/23 16:00	0.6			1.5			14.4		1	1.1			1.4			14.9		1
02/10/23 17:00	0.8			1.5			13.9		1	1.1			1.5			14.1		1
02/10/23 18:00	1.1			1.5			13.8		1	1.2			1.5			14		1
02/10/23 19:00	1.1			1.5			13.9		1	1.2			1.5			14		1
02/10/23 20:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
02/10/23 21:00	1			1.5			13.6		1	1.2			1.5			13.8		1
02/10/23 22:00	1			1.5			13.6		1	1.2			1.5			13.7		1
02/10/23 23:00	1.2			1.5			13.8		1	1.3			1.5			14		1
02/11/23 0:00	1.1			1.5			13.7		1	1.2			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 1:00	1.2			1.5			13.8		1	1.3			1.5			14		1
02/11/23 2:00	1.3			1.5			13.9		1	1.3			1.4			14.1		1
02/11/23 3:00	1.3			1.5			13.9		1	1.3			1.5			14.1		1
02/11/23 4:00	1.3			1.5			13.9		1	1.3			1.5			14.1		1
02/11/23 5:00	1.2			1.5			13.8		1	1.3			1.5			14		1
02/11/23 6:00	1.3			1.5			13.9		1	1.4			1.5			14		1
02/11/23 7:00	1.3			1.5			14		1	1.4			1.5			14.1		1
02/11/23 8:00	0.9			1.6			14.6		1	1.1			1.4			14.5		1
02/11/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.5		1
02/11/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/11/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/11/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/11/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/11/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/11/23 15:00	0	X		0	X		0	X	1	0.9			1.4			14.6		1
02/11/23 16:00	0.6			0.7			15.3		1	0.9			1.4			14.5		1
02/11/23 17:00	0.9			1.5			13.8		1	1.3			1.5			14.1		1
02/11/23 18:00	1			1.5			13.6		1	1.2			1.5			13.8		1
02/11/23 19:00	1			1.5			13.7		1	1.2			1.5			13.8		1
02/11/23 20:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
02/11/23 21:00	0.9			1.5			13.5		1	1.1			1.5			13.7		1
02/11/23 22:00	0.9			1.5			13.5		1	1.1			1.5			13.7		1
02/11/23 23:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
02/12/23 0:00	1.1			1.5			13.5		1	1.3			1.5			13.6		1
02/12/23 1:00	1			1.5			13.5		1	1.3			1.5			13.7		1
02/12/23 2:00	1.1			1.5			13.6		1	1.3			1.5			13.8		1
02/12/23 3:00	1			1.5			13.5		1	1.2			1.5			13.6		1
02/12/23 4:00	0.9			1.5			13.4		1	1.1			1.5			13.6		1
02/12/23 5:00	0.9			1.5			13.5		1	1.2			1.5			13.6		1
02/12/23 6:00	1			1.5			13.6		1	1.2			1.5			13.7		1
02/12/23 7:00	1			1.5			14		1	1.2			1.5			14.1		1
02/12/23 8:00	0.8			1.4			14.3		1	1.1			1.2			14.8		1
02/12/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/12/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/12/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/12/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/12/23 13:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
02/12/23 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:00	0.6			1.4			14.5		1	0			0			16.4		1
02/12/23 16:00	0.6			1.5			14.5		1	1			1.4			14.6		1
02/12/23 17:00	0.7			1.5			13.4		1	0.9			1.5			13.5		1
02/12/23 18:00	0.9			1.5			13.7		1	1.2			1.5			13.8		1
02/12/23 19:00	0.7			1.5			13.4		1	1			1.5			13.5		1
02/12/23 20:00	0.6			1.5			13.3		1	0.9			1.5			13.4		1
02/12/23 21:00	0.9			1.5			13.8		1	1.1			1.5			13.9		1
02/12/23 22:00	0.8			1.4			14.3		1	1			1.4			14.4		1
02/12/23 23:00	0.7			1.4			14.4		1	0.9			1.4			14.5		1
02/13/23 0:00	0.7			1.5			14.6		1	1			1.2			14.5		1
02/13/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 2:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 6:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 7:00	0	X		0	X		0	X	1	0.9			1.4			14.5		1
02/13/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/13/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/13/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 15:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 16:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 17:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 18:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 19:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/13/23 20:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/13/23 21:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/13/23 22:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/13/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/14/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/14/23 1:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/14/23 2:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/14/23 3:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/14/23 4:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 6:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
02/14/23 8:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/14/23 14:00	0	X		0	X		0	X	1	0.9			1.3			14.6		1
02/14/23 15:00	0			0			16.5		1	1.2			1.4			14.5		1
02/14/23 16:00	1.4			1.6			14.2		1	1.5			1.5			14.3		1
02/14/23 17:00	0.5			1.5			12.9		1	0.8			1.5			13.1		1
02/14/23 18:00	0.4			1.5			12.8		1	0.7			1.5			13		1
02/14/23 19:00	0.6			1.5			13.2		1	1			1.5			13.4		1
02/14/23 20:00	0.5			1.5			13		1	0.8			1.5			13.2		1
02/14/23 21:00	0.8			1.5			13.4		1	1.1			1.5			13.5		1
02/14/23 22:00	1.1			1.5			13.8		1	1.3			1.5			13.9		1
02/14/23 23:00	0.9			1.5			13.5		1	1.2			1.5			13.7		1
02/15/23 0:00	1.1			1.5			13.6		1	1.2			1.5			13.8		1
02/15/23 1:00	1.1			1.5			13.6		1	1.2			1.5			13.8		1
02/15/23 2:00	1.1			1.5			13.7		1	1.3			1.5			13.8		1
02/15/23 3:00	0.9			1.5			13.5		1	1.2			1.5			13.6		1
02/15/23 4:00	0.6			1.5			13.2		1	1			1.5			13.3		1
02/15/23 5:00	0.6			1.5			13.2		1	0.9			1.5			13.3		1
02/15/23 6:00	0.5			1.5			13		1	0.9			1.5			13.2		1
02/15/23 7:00	0.4			1.5			12.5		1	0			0			16.3		1
02/15/23 8:00	0.7			1.4			14.6		1	1			1.2			14.4		1
02/15/23 9:00	0	X		0	X		0	X	1	0.9			1.4			14.6		1
02/15/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/15/23 11:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/15/23 12:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/15/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/15/23 14:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/15/23 15:00	0	X		0	X		0	X	1	0.8			1.4			14.7		1
02/15/23 16:00	0			0			15.7		1	0.9			1.5			14.5		1
02/15/23 17:00	0.9			1.4			14.2		1	1.4			1.3			14.3		1
02/15/23 18:00	0.4			1.5			12.9		1	0.7			1.5			13		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 19:00	0.4			1.5			12.9		1	0.7			1.5			13		1
02/15/23 20:00	0.4			1.5			12.9		1	0.7			1.5			13.1		1
02/15/23 21:00	0.4			1.5			12.8		1	0.7			1.5			13		1
02/15/23 22:00	0.4			1.5			12.9		1	0.7			1.5			13.1		1
02/15/23 23:00	0.7			1.5			13.3		1	1			1.5			13.4		1
02/16/23 0:00	0.8			1.5			14.4		1	1			1.5			14.5		1
02/16/23 1:00	0.7			1.5			14.4		1	1			1.5			14.4		1
02/16/23 2:00	0.7			1.5			14.4		1	1			1.5			14.4		1
02/16/23 3:00	0.8			1.5			14.4		1	1			1.5			14.4		1
02/16/23 4:00	0.7			1.5			14.4		1	1			1.5			14.4		1
02/16/23 5:00	0.7			1.5			14.3		1	1			1.5			14.5		1
02/16/23 6:00	0.9			1.5			14.3		1	1.3			1.5			14.5		1
02/16/23 7:00	1.1			1.5			13.8		1	1.4			1.5			14		1
02/16/23 8:00	0.9			1.6			14.4		1	1.1			1.5			14.4		1
02/16/23 9:00	0	X		0	X		0	X	1	1			1.4			14.6		1
02/16/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/16/23 11:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/16/23 12:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/16/23 13:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/16/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/16/23 15:00	0	X		0	X		0	X	1	0.9			1.4			14.6		1
02/16/23 16:00	0.5			0.9			15.7		1	1			1.5			14.6		1
02/16/23 17:00	1			1.3			14.2		1	1.4			1.4			14.3		1
02/16/23 18:00	1.1			1.5			14		1	1.6			1.5			14.1		1
02/16/23 19:00	1.1			1.5			13.8		1	1.4			1.5			13.9		1
02/16/23 20:00	1.2			1.5			13.6		1	1.5			1.5			13.8		1
02/16/23 21:00	1			1.5			13.6		1	1.2			1.5			13.7		1
02/16/23 22:00	0.9			1.5			13.5		1	1.2			1.5			13.6		1
02/16/23 23:00	1.1			1.5			13.7		1	1.3			1.5			13.9		1
02/17/23 0:00	1			1.5			13.6		1	1.3			1.5			13.8		1
02/17/23 1:00	1.2			1.5			13.9		1	1.5			1.5			14.1		1
02/17/23 2:00	1.2			1.5			13.9		1	1.5			1.5			14.1		1
02/17/23 3:00	0.9			1.5			14.7		1	1.2			1.5			14.6		1
02/17/23 4:00	0			0			17.6		1	1			1.3			14.6		1
02/17/23 5:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 6:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 7:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 8:00	0	X		0	X		0	X	1	0.8			1.4			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 9:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/17/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/17/23 11:00	0	X		0	X		0	X	1	0.8			1.4			14.6		1
02/17/23 12:00	0	X		0	X		0	X	1	1.1			1.5			14.4		1
02/17/23 13:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/17/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 15:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 16:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 17:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/17/23 18:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/17/23 19:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/17/23 20:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/17/23 21:00	0	X		0	X		0	X	1	1			1.5			14.6		1
02/17/23 22:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/17/23 23:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 0:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 1:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 2:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 3:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 4:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 5:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
02/18/23 6:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 7:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 8:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 10:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
02/18/23 11:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 12:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 13:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 15:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 16:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/18/23 17:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 18:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 19:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 20:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 21:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/18/23 22:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/18/23 23:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 0:00	0	X		0	X		0	X	1	1			1.5			14.7		1
02/19/23 1:00	0	X		0	X		0	X	1	1.2			1.5			14.7		1
02/19/23 2:00	0	X		0	X		0	X	1	1.2			1.6			14.7		1
02/19/23 3:00	0	X		0	X		0	X	1	1.1			1.5			14.7		1
02/19/23 4:00	0	X		0	X		0	X	1	1.1			1.5			14.7		1
02/19/23 5:00	0	X		0	X		0	X	1	1			1.5			14.7		1
02/19/23 6:00	0	X		0	X		0	X	1	1			1.5			14.7		1
02/19/23 7:00	0	X		0	X		0	X	1	1			1.5			14.7		1
02/19/23 8:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 10:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 11:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 12:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 13:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 15:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 16:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 17:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/19/23 18:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 19:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 20:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 21:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 22:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/19/23 23:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 0:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 1:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 2:00	0	X		0	X		0	X	1	0.9			1.6			14.6		1
02/20/23 3:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 4:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 5:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 6:00	0	X		0	X		0	X	1	1			1.5			14.6		1
02/20/23 7:00	0	X		0	X		0	X	1	1.1			1.4			14.5		1
02/20/23 8:00	0	X		0	X		0	X	1	1			1.5			14.6		1
02/20/23 9:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 10:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
02/20/23 11:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/20/23 12:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 13:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/20/23 14:00	0	X		0	X		0	X	1	0.9			1.5			14.7		1
02/20/23 15:00	0			0			20.8		1	1.1			1.4			14.6		1
02/20/23 16:00	0			0			15.1		1	1			1.4			14.5		1
02/20/23 17:00	1			1.4			14.1		1	1.1			1.4			13.8		1
02/20/23 18:00	0.8			1.5			13.3		1	1			1.5			13.5		1
02/20/23 19:00	0.8			1.5			13.3		1	1.1			1.5			13.5		1
02/20/23 20:00	0.8			1.5			13.4		1	1.1			1.5			13.5		1
02/20/23 21:00	1			1.5			13.6		1	1.3			1.5			13.7		1
02/20/23 22:00	1.2			1.5			14		1	1.4			1.5			14.1		1
02/20/23 23:00	0.8			1.4			14.4		1	1			1.4			15.2		1
02/21/23 0:00	0.8			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 1:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 2:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 3:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 4:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 5:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 6:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 7:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 8:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 12:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 16:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 17:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 19:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/21/23 23:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/22/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 1:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/22/23 2:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 6:00	0.7			1.4			14.4		1	0	X		0	X		0	X	1
02/22/23 7:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/22/23 16:00	0.8			1.5			14.3		1	0			0			15.5		1
02/22/23 17:00	1.1			1.5			14.1		1	1.5			1.6			14.2		1
02/22/23 18:00	0.7			1.5			13.3		1	1.1			1.5			13.5		1
02/22/23 19:00	0.8			1.5			13.4		1	1.1			1.5			13.5		1
02/22/23 20:00	0.8			1.5			13.4		1	1.2			1.5			13.5		1
02/22/23 21:00	0.9			1.5			13.5		1	1.2			1.5			13.6		1
02/22/23 22:00	0.8			1.5			14.3		1	1.1			1.5			14.4		1
02/22/23 23:00	0.8			1.5			14.2		1	1.1			1.5			14.3		1
02/23/23 0:00	0.8			1.5			13.6		1	1.3			1.5			13.7		1
02/23/23 1:00	0.4			1.5			12.9		1	0.7			1.5			13		1
02/23/23 2:00	0.6			1.5			13.1		1	0.9			1.5			13.2		1
02/23/23 3:00	0.5			1.5			13		1	0.8			1.5			13.1		1
02/23/23 4:00	0.5			1.5			13		1	0.8			1.5			13.1		1
02/23/23 5:00	0.6			1.5			13.1		1	0.9			1.5			13.2		1
02/23/23 6:00	0.4			1.5			12.8		1	0.7			1.5			13		1
02/23/23 7:00	1.2			1.5			13.9		1	1.5			1.3			14		1
02/23/23 8:00	1.2			1.5			13.8		1	1.5			1.5			14		1
02/23/23 9:00	1.2			1.5			13.9		1	1.5			1.5			14		1
02/23/23 10:00	1.2			1.5			13.9		1	1.5			1.5			14		1
02/23/23 11:00	1.2			1.5			13.8		1	1.4			1.5			14		1
02/23/23 12:00	1			1.5			14.1		1	1.3			1.5			14.2		1
02/23/23 13:00	0.6			1.4			14.4		1	0.8			1.3			15.4		1
02/23/23 14:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/23/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/23/23 16:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 17:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/23/23 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/23/23 19:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1
02/23/23 20:00	0.8			1.5			14.3		1	0	X		0	X		0	X	1
02/23/23 21:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/23/23 22:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/23/23 23:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 0:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 1:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 2:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 3:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 4:00	1.3			1.5			14		1	0	X		0	X		0	X	1
02/24/23 5:00	1.1			1.5			13.6		1	0	X		0	X		0	X	1
02/24/23 6:00	0.7			1.5			13.2		1	0	X		0	X		0	X	1
02/24/23 7:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 8:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 9:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 10:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 11:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 12:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 13:00	1.4			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 14:00	1.3			1.5			14.1		1	0	X		0	X		0	X	1
02/24/23 15:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 16:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 17:00	1.3			1.5			14		1	0	X		0	X		0	X	1
02/24/23 18:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 19:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 20:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 21:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 22:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/24/23 23:00	1.4			1.5			14		1	0	X		0	X		0	X	1
02/25/23 0:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1
02/25/23 1:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/25/23 2:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/25/23 3:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/25/23 4:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/25/23 5:00	0.7			1.5			14.3		1	0	X		0	X		0	X	1
02/25/23 6:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/25/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 8:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/25/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 11:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/25/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 16:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 17:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 19:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/25/23 23:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 2:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/26/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 4:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/26/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 16:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 17:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 18:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 19:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 20:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/26/23 21:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/26/23 23:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/27/23 0:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/27/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 2:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
02/27/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 14:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/27/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/27/23 16:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1
02/27/23 17:00	0.9			1.5			14.3		1	0			0			16		1
02/27/23 18:00	0.9			1.5			14.1		1	1.4			1.7			14.3		1
02/27/23 19:00	1			1.5			13.5		1	1.2			1.5			13.6		1
02/27/23 20:00	1			1.5			13.5		1	1.2			1.4			13.6		1
02/27/23 21:00	1.1			1.5			13.6		1	1.3			1.5			13.7		1
02/27/23 22:00	1.1			1.5			14		1	1.3			1.4			14.2		1
02/27/23 23:00	0.7			1.4			14.4		1	0.8			1.4			15.3		1
02/28/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 2:00	0.6			1.6			14.5		1	0	X		0	X		0	X	1
02/28/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
02/28/23 10:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 11:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/28/23 12:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/28/23 13:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/28/23 14:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/28/23 15:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
02/28/23 16:00	0.8			1.4			14.4		1	0			0			19.9		1
02/28/23 17:00	0.9			1.4			14.2		1	1			1.1			14.8		1
02/28/23 18:00	1.2			1.5			14		1	1.7			1.5			14.1		1
02/28/23 19:00	1.2			1.5			13.8		1	1.3			1.4			13.9		1
02/28/23 20:00	1.2			1.5			13.8		1	1.4			1.5			14		1
02/28/23 21:00	1.2			1.5			13.8		1	1.3			1.4			14		1
02/28/23 22:00	1.2			1.5			13.9		1	1.4			1.5			14		1
02/28/23 23:00	1.2			1.5			13.9		1	1.4			1.5			14		1
03/01/23 0:00	1.1			1.5			13.9		1	1.4			1.5			14		1
03/01/23 1:00	1.1			1.5			13.9		1	1.4			1.5			14		1
03/01/23 2:00	1.2			1.6			13.9		1	1.4			1.4			14		1
03/01/23 3:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
03/01/23 4:00	1.2			1.5			13.8		1	1.3			1.4			13.9		1
03/01/23 5:00	1.2			1.5			13.8		1	1.4			1.4			13.9		1
03/01/23 6:00	0.8			1.5			13.2		1	1.4			1.5			13.8		1
03/01/23 7:00	1			1.5			14		1	1.3			1.5			14.2		1
03/01/23 8:00	0.6			1.4			14.4		1	0.8			1.4			15.3		1
03/01/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/01/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/01/23 11:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 12:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 13:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 14:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/01/23 15:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/01/23 16:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/01/23 17:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 18:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 19:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 20:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/01/23 21:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 22:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/01/23 23:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 0:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/02/23 1:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 2:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 3:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 4:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 5:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 6:00	0.7			1.4			14.5		1	0	X		0	X		0	X	1
03/02/23 7:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 8:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 9:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 10:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/02/23 11:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 12:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 13:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 14:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 15:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 16:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 17:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 18:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 19:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 20:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 21:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 22:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/02/23 23:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 0:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 1:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 2:00	0.6			1.6			14.7		1	0	X		0	X		0	X	1
03/03/23 3:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/03/23 4:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/03/23 5:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 6:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 7:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 8:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/03/23 9:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/03/23 10:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/03/23 11:00	0.7			1.4			14.6		1	0	X		0	X		0	X	1
03/03/23 12:00	1.4			1.5			14.3		1	0	X		0	X		0	X	1
03/03/23 13:00	1.2			1.5			14.2		1	0	X		0	X		0	X	1
03/03/23 14:00	1.1			1.5			14.1		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:00	1			1.5			14.3		1	0			0			15.6		1
03/03/23 16:00	0.7			1.4			14.6		1	1			1.5			14.6		1
03/03/23 17:00	1			1.5			14.3		1	1.4			1.4			14.2		1
03/03/23 18:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
03/03/23 19:00	1.1			1.5			13.8		1	1.2			1.5			13.8		1
03/03/23 20:00	1			1.5			13.7		1	1.2			1.5			13.6		1
03/03/23 21:00	1			1.5			13.9		1	1.2			1.5			13.8		1
03/03/23 22:00	0.8			1.5			14.5		1	1.1			1.5			14.6		1
03/03/23 23:00	0.7			1.4			14.6		1	0			0			17.7		1
03/04/23 0:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 1:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 2:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 3:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 4:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 5:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 6:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 7:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 8:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 9:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 10:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 11:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 12:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 13:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 14:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 15:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/04/23 16:00	0.7			1.4			14.6		1	0			0			20.6		1
03/04/23 17:00	0.7			1.5			14.6		1	0.9			0.8			15		1
03/04/23 18:00	1			1.4			14.1		1	1.3			1.2			14.1		1
03/04/23 19:00	0.7			1.5			13.3		1	1			1.5			13.4		1
03/04/23 20:00	0.9			1.5			13.6		1	1.2			1.5			13.6		1
03/04/23 21:00	0.9			1.5			13.6		1	1.2			1.5			13.6		1
03/04/23 22:00	0.9			1.5			14.3		1	1.2			1.5			14.5		1
03/04/23 23:00	0.7			1.4			14.6		1	0	X		0	X		0	X	1
03/05/23 0:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 1:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/05/23 2:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 3:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 4:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 5:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 6:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 7:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 8:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 9:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 10:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 11:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/05/23 12:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/05/23 13:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/05/23 14:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/05/23 15:00	0.7			1.4			14.6		1	0			0			20.1		1
03/05/23 16:00	0.8			1.4			14.5		1	1			0.5			14.9		1
03/05/23 17:00	0.9			1.5			13.9		1	1.2			1.4			13.9		1
03/05/23 18:00	0.6			1.5			13.3		1	0.9			1.5			13.3		1
03/05/23 19:00	0.6			1.5			13.2		1	0.8			1.5			13.2		1
03/05/23 20:00	0.6			1.5			13.2		1	0.8			1.5			13.2		1
03/05/23 21:00	0.7			1.5			13.4		1	1			1.5			13.3		1
03/05/23 22:00	0.9			1.5			13.6		1	1.1			1.5			13.6		1
03/05/23 23:00	1.2			1.5			14		1	1.3			1.5			13.9		1
03/06/23 0:00	0.9			1.5			14.4		1	1.2			1.5			14.4		1
03/06/23 1:00	0.8			1.4			14.4		1	1.1			1.5			14.7		1
03/06/23 2:00	0.6			1.6			14.7		1	0	X		0	X		0	X	1
03/06/23 3:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 4:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 5:00	0.7			1.4			14.6		1	0	X		0	X		0	X	1
03/06/23 6:00	0.8			1.5			14.4		1	0	X		0	X		0	X	1
03/06/23 7:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 8:00	0.7			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 9:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 10:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/06/23 11:00	0.7			1.5			14.6		1	0	X		0	X		0	X	1
03/06/23 12:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/06/23 13:00	0.8			1.5			14.5		1	0			0			15.7		1
03/06/23 14:00	1			1.4			14.3		1	1.4			1.5			14.2		1
03/06/23 15:00	1.2			1.5			14		1	1.3			1.3			14		1
03/06/23 16:00	1.2			1.5			14		1	1.3			1.3			14		1
03/06/23 17:00	1.2			1.5			14		1	1.3			1.5			14		1
03/06/23 18:00	1.2			1.5			14		1	1.4			1.5			14		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 19:00	1.1			1.5			14.1		1	1.4			1.5			14.1		1
03/06/23 20:00	1.1			1.5			14.1		1	1.5			1.5			14.1		1
03/06/23 21:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/06/23 22:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/06/23 23:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/07/23 0:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/07/23 1:00	1.1			1.5			14		1	1.4			1.5			14.1		1
03/07/23 2:00	1.1			1.5			14		1	1.4			1.5			14.1		1
03/07/23 3:00	1.1			1.5			14		1	1.4			1.5			14.1		1
03/07/23 4:00	1.2			1.5			14		1	1.4			1.5			14		1
03/07/23 5:00	1.1			1.5			13.7		1	1.2			1.5			13.7		1
03/07/23 6:00	0.6			1.5			13.1		1	0.8			1.5			13.1		1
03/07/23 7:00	1.3			1.5			14.1		1	1.4			1.5			14.2		1
03/07/23 8:00	0.7			1.4			14.6		1	0.8			1.3			15.4		1
03/07/23 9:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/07/23 10:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 11:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 12:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 13:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 14:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 15:00	0.6			1.5			14.7		1	0	X		0	X		0	X	1
03/07/23 16:00	0.6			1.5			14.6		1	0			0			19		1
03/07/23 17:00	0.6			1.5			14.6		1	0.8			1.5			14.7		1
03/07/23 18:00	1			1.4			14.3		1	1.3			1.4			14.3		1
03/07/23 19:00	1.1			1.5			14.1		1	1.4			1.5			14.1		1
03/07/23 20:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/07/23 21:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/07/23 22:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/07/23 23:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 0:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 1:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 2:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 3:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 4:00	1.2			1.5			14.1		1	1.5			1.5			14.1		1
03/08/23 5:00	1.2			1.5			14.1		1	1.4			1.5			14.1		1
03/08/23 6:00	1.1			1.5			14.1		1	1.4			1.5			14		1
03/08/23 7:00	1.2			1.5			13.9		1	1.4			1.5			13.9		1
03/08/23 8:00	1.2			1.5			13.9		1	1.4			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 9:00	1.1			1.5			14		1	1.4			1.5			14		1
03/08/23 10:00	0.9			1.5			14.2		1	1.3			1.5			14		1
03/08/23 11:00	0.5			1.4			14.6		1	0.9			1.4			15.2		1
03/08/23 12:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/08/23 13:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/08/23 14:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/08/23 15:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/08/23 16:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/08/23 17:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/08/23 18:00	0.6			1.5			14.5		1	0.8			1.7			15.6		1
03/08/23 19:00	0.7			1.4			14.4		1	1			1.4			14.4		1
03/08/23 20:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/08/23 21:00	1.1			1.5			14		1	1.2			1.5			14		1
03/08/23 22:00	1.1			1.5			14		1	1.2			1.5			14		1
03/08/23 23:00	1			1.5			14		1	1.2			1.5			14		1
03/09/23 0:00	1			1.5			14		1	1.2			1.5			14		1
03/09/23 1:00	1			1.5			14		1	1.2			1.5			14		1
03/09/23 2:00	1			1.5			14		1	1.2			1.5			14		1
03/09/23 3:00	1.1			1.5			14		1	1.2			1.5			14		1
03/09/23 4:00	1.1			1.5			14		1	1.2			1.5			14		1
03/09/23 5:00	0.9			1.5			13.8		1	1.1			1.5			13.8		1
03/09/23 6:00	1			1.5			14		1	1.2			1.5			13.9		1
03/09/23 7:00	1			1.5			14		1	1.2			1.5			14		1
03/09/23 8:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 9:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 10:00	1			1.5			13.9		1	1.1			1.5			13.9		1
03/09/23 11:00	0.6			1.5			13.4		1	0.9			1.5			13.4		1
03/09/23 12:00	0.5			1.5			13.2		1	0.7			1.5			13.2		1
03/09/23 13:00	0.2			1.5			12.7		1	0.4			1.5			12.7		1
03/09/23 14:00	0.3			1.5			12.9		1	0.5			1.5			12.9		1
03/09/23 15:00	0.5			1.5			13.3		1	0.8			1.5			13.3		1
03/09/23 16:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 17:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 18:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 19:00	1			1.5			13.9		1	1.2			1.5			13.9		1
03/09/23 20:00	1			1.5			13.8		1	1.2			1.5			13.9		1
03/09/23 21:00	1			1.5			13.8		1	1.2			1.5			13.9		1
03/09/23 22:00	0.9			1.5			14.1		1	1.1			1.5			14.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:00	0.5			1.4			14.5		1	0.7			1.3			15.3		1
03/10/23 0:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 1:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 2:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 4:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 5:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 6:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 7:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 8:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 9:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 10:00	0.5			1.4			14.5		1	0	X		0	X		0	X	1
03/10/23 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 12:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 13:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 14:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 15:00	0.5			1.5			14.6		1	0			0			19.1		1
03/10/23 16:00	0.5			1.4			14.5		1	0.9			1.5			14.6		1
03/10/23 17:00	0.7			1.5			14		1	1			1.6			14.1		1
03/10/23 18:00	0.8			1.5			13.7		1	1.1			1.5			13.7		1
03/10/23 19:00	1			1.5			13.8		1	1.1			1.5			13.8		1
03/10/23 20:00	0.9			1.4			14.3		1	1.1			1.5			14.5		1
03/10/23 21:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
03/10/23 22:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/10/23 23:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 0:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 1:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 2:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 4:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 5:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 6:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 7:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 8:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 9:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 10:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 14:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 15:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/11/23 16:00	0.5			1.5			14.6		1	0			0			20.9		1
03/11/23 17:00	0.7			1.5			14.5		1	0			0			15.3		1
03/11/23 18:00	0.4			1.5			14.7		1	0.7			1.5			14.6		1
03/11/23 19:00	0.7			1.4			13.8		1	0.9			1.5			13.5		1
03/11/23 20:00	0.7			1.5			13.5		1	0.9			1.5			13.5		1
03/11/23 21:00	0.4			1.5			13.1		1	0.6			1.5			13.1		1
03/11/23 22:00	0.3			1.5			12.8		1	0.4			1.5			12.8		1
03/11/23 23:00	0.3			1.5			12.8		1	0.4			1.5			12.8		1
03/12/23 0:00	0.5			1.5			13.3		1	0.7			1.5			13.3		1
03/12/23 1:00	0.7			1.5			14.5		1	0.9			1.5			14.4		1
03/12/23 2:00	0.6			1.6			14.5		1	0.8			1.5			14.4		1
03/12/23 3:00	1			1.5			14.2		1	1.6			1.5			14.2		1
03/12/23 4:00	0.4			1.5			13.1		1	0.6			1.5			13.1		1
03/12/23 5:00	0.4			1.5			13.1		1	0.6			1.5			13.1		1
03/12/23 6:00	0.8			1.5			14.1		1	1			1.5			14		1
03/12/23 7:00	0.5			1.4			14.6		1	0.7			1.4			15.2		1
03/12/23 8:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 9:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 10:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 12:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 13:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/12/23 14:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
03/12/23 15:00	0.6			1.5			14.5		1	0.8			1.3			15.4		1
03/12/23 16:00	0.7			1.4			14.3		1	0.8			1.4			14.3		1
03/12/23 17:00	0.3			1.5			12.9		1	0.5			1.5			12.9		1
03/12/23 18:00	0.2			1.5			12.8		1	0.4			1.5			12.8		1
03/12/23 19:00	0.3			1.5			13		1	0.4			1.5			13		1
03/12/23 20:00	0.2			1.5			12.8		1	0.4			1.5			12.9		1
03/12/23 21:00	0.3			1.5			12.9		1	0.4			1.5			12.9		1
03/12/23 22:00	0.5			1.5			13.2		1	0.6			1.5			13.2		1
03/12/23 23:00	0.7			1.5			14.4		1	0.8			1.5			14.3		1
03/13/23 0:00	0.5			1.5			14.6		1	0.6			1.5			15.2		1
03/13/23 1:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 2:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 4:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
03/13/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/13/23 6:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
03/13/23 7:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 8:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 9:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 10:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 11:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/13/23 12:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/13/23 13:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/13/23 14:00	0.5			1.5			14.7		1	0	X		0	X		0	X	1
03/13/23 15:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/13/23 16:00	0.5			1.4			14.6		1	0	X		0	X		0	X	0
03/13/23 17:00	0.5			1.4			14.6		1	0.7			0.5			14.5		1
03/13/23 18:00	0.8			1.5			13.9		1	0.8			0.9			13.6		1
03/13/23 19:00	0.4			1.5			13.2		1	0.6			1.5			13.3		1
03/13/23 20:00	0.3			1.5			12.9		1	0.4			1.5			12.9		1
03/13/23 21:00	0.4			1.5			13.1		1	0.6			1.5			13.2		1
03/13/23 22:00	0.7			1.5			14.3		1	0.9			1.5			14.5		1
03/13/23 23:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 0:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 1:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 2:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
03/14/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 4:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 5:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 6:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/14/23 7:00	0.6			1.4			14.5		1	0	X		0	X		0	X	1
03/14/23 8:00	0.8			1.5			14.4		1	0	X		0	X		0	X	1
03/14/23 9:00	0.6			1.5			14.4		1	0.7			0.6			15.5		1
03/14/23 10:00	0.7			1.5			13.8		1	0.8			1.3			13.8		1
03/14/23 11:00	0.4			1.5			13.2		1	0.6			1.5			13.2		1
03/14/23 12:00	0.4			1.5			13		1	0.5			1.5			13.1		1
03/14/23 13:00	0.2			1.5			12.7		1	0.3			1.5			12.7		1
03/14/23 14:00	0.3			1.5			13		1	0.4			1.5			13		1
03/14/23 15:00	0.6			1.5			13.5		1	0.8			1.5			13.5		1
03/14/23 16:00	0.4			1.5			13.1		1	0.6			1.5			13.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 17:00	0.3			1.5			12.9		1	0.5			1.5			13		1
03/14/23 18:00	0.2			1.5			12.8		1	0.4			1.5			12.9		1
03/14/23 19:00	0.2			1.5			12.8		1	0.4			1.5			12.8		1
03/14/23 20:00	0.2			1.5			12.9		1	0.4			1.5			12.9		1
03/14/23 21:00	0.6			1.5			13.4		1	0.8			1.5			13.5		1
03/14/23 22:00	0.7			1.5			14.1		1	0.9			1.5			14		1
03/14/23 23:00	0.6			1.5			14.5		1	0.9			1.4			15		1
03/15/23 0:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 1:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 2:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
03/15/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 4:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 5:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 6:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 7:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 8:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 9:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 10:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 11:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 12:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/15/23 13:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/15/23 14:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/15/23 15:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/15/23 16:00	0.5			1.5			14.6		1	0			0			18.6		1
03/15/23 17:00	0.5			1.4			14.6		1	0.7			0.9			14.5		1
03/15/23 18:00	0.8			1.5			14.1		1	1.2			1.5			13.9		1
03/15/23 19:00	0.5			1.5			13.4		1	0.7			1.5			13.4		1
03/15/23 20:00	0.4			1.5			13.1		1	0.5			1.5			13.2		1
03/15/23 21:00	0.8			1.4			14.3		1	1			1.5			14.5		1
03/15/23 22:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/15/23 23:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 0:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 1:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 2:00	0.5			1.4			14.6		1	0	X		0	X		0	X	1
03/16/23 3:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 4:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 5:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 6:00	0.6			1.6			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 7:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 8:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 9:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 10:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 11:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 12:00	0.4			1.5			14.6		1	0	X		0	X		0	X	1
03/16/23 13:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/16/23 14:00	0.4			1.5			14.7		1	0	X		0	X		0	X	1
03/16/23 15:00	0.4			1.5			14.7		1	0			0			18.3		1
03/16/23 16:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
03/16/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/16/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/16/23 19:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/16/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/16/23 21:00	0	X		0	X		0	X	1	0.8			1.4			14.4		1
03/16/23 22:00	0	X		0	X		0	X	1	0.9			1.5			14.4		1
03/16/23 23:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
03/17/23 0:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
03/17/23 1:00	0			0			19.4		1	0.8			1.5			14.5		1
03/17/23 2:00	0.6			1.7			14.7		1	0.8			1.2			14.4		1
03/17/23 3:00	0.7			1.5			13.7		1	0.8			1.5			13.6		1
03/17/23 4:00	0.4			1.5			13		1	0.5			1.5			13		1
03/17/23 5:00	0.4			1.5			12.9		1	0.5			1.5			12.9		1
03/17/23 6:00	0.5			1.5			13.2		1	0.7			1.5			13.2		1
03/17/23 7:00	1			1.4			14.2		1	1.2			1.5			14.2		1
03/17/23 8:00	0.6			1.4			14.4		1	0.9			1.3			14.8		1
03/17/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/17/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/17/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/17/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/17/23 13:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/17/23 14:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/17/23 15:00	0.5			1.5			14.6		1	0	X		0	X		0	X	1
03/17/23 16:00	0.7			1.5			14.6		1	0			0			17.5		1
03/17/23 17:00	0.7			1.5			14.5		1	1.1			1.7			14.4		1
03/17/23 18:00	0.6			1.5			13.5		1	0.9			1.3			13.6		1
03/17/23 19:00	0.3			1.5			13.1		1	0.5			1.4			13.1		1
03/17/23 20:00	0.6			1.5			13.5		1	0.8			1.5			13.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 21:00	0.5			1.5			13.2		1	0.7			1.5			13.2		1
03/17/23 22:00	0.8			1.5			14.3		1	1			1.5			14.4		1
03/17/23 23:00	0.7			1.5			14.5		1	0			0			17.5		1
03/18/23 0:00	0.8			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 1:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 2:00	0.6			1.6			14.5		1	0	X		0	X		0	X	1
03/18/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 5:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 12:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/18/23 13:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/18/23 14:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/18/23 15:00	0.7			1.5			14.6		1	0			0			20.1		1
03/18/23 16:00	0.6			1.5			14.5		1	0.8			1.1			14.9		1
03/18/23 17:00	0.8			1.5			13.8		1	1			1.5			13.9		1
03/18/23 18:00	0.2			1.5			12.7		1	0.4			1.5			12.8		1
03/18/23 19:00	0.5			1.5			13.3		1	0.8			1.5			13.4		1
03/18/23 20:00	0.6			1.5			13.4		1	0.8			1.5			13.4		1
03/18/23 21:00	0.8			1.5			14.3		1	0.9			1.4			14.5		1
03/18/23 22:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/18/23 23:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 0:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 1:00	0.6			1.5			14.6		1	0	X		0	X		0	X	1
03/19/23 2:00	0.6			1.6			14.5		1	0	X		0	X		0	X	1
03/19/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 4:00	0.7			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 5:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 7:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/19/23 15:00	0.6			1.5			14.4		1	0			0			17.5		1
03/19/23 16:00	0.6			1.5			14.5		1	0.9			1.7			14.4		1
03/19/23 17:00	0.8			1.5			13.4		1	1.1			1.5			13.7		1
03/19/23 18:00	0.4			1.5			13		1	0.5			1.5			13		1
03/19/23 19:00	0.5			1.5			13.3		1	0.7			1.5			13.2		1
03/19/23 20:00	0.5			1.5			13.2		1	0.6			1.5			13.2		1
03/19/23 21:00	0.7			1.5			13.6		1	0.9			1.5			13.6		1
03/19/23 22:00	0.8			1.5			13.7		1	1			1.5			13.7		1
03/19/23 23:00	0.8			1.5			13.6		1	0.9			1.5			13.6		1
03/20/23 0:00	0.9			1.5			14.1		1	1.1			1.5			14.1		1
03/20/23 1:00	0.6			1.4			14.5		1	0.7			1.4			15.2		1
03/20/23 2:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 3:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 4:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 5:00	0.6			1.5			14.4		1	0	X		0	X		0	X	1
03/20/23 6:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 7:00	0.6			1.4			14.4		1	0	X		0	X		0	X	1
03/20/23 8:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 9:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 10:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 11:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 12:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 13:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 14:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 15:00	0.6			1.5			14.5		1	0	X		0	X		0	X	1
03/20/23 16:00	0.7			1.5			14.5		1	0			0			16.3		1
03/20/23 17:00	0.9			1.5			14.4		1	1.7			1.5			14.4		1
03/20/23 18:00	0.5			1.5			13.2		1	0.6			1.5			13.1		1
03/20/23 19:00	0.4			1.5			13.1		1	0.6			1.5			13.2		1
03/20/23 20:00	0.3			1.3			14		1	0.6			1.3			14.1		1
03/20/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/23 11:00	0	X		0	X		0	X	1	0			0			16.4		1
03/21/23 12:00	0	X		0	X		0	X	1	0.9			1.5			14.3		1
03/21/23 13:00	0	X		0	X		0	X	1	0.9			1.5			14.3		1
03/21/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 19:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/21/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/21/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/22/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/22/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.5		1
03/22/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/22/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/22/23 6:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
03/22/23 7:00	0	X		0	X		0	X	1	0.7			1.3			14.5		1
03/22/23 8:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/22/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 12:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/22/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/22/23 16:00	0			0			15.5		1	0.7			1.5			14.4		1
03/22/23 17:00	0.6			1.5			13.8		1	0.7			1.4			13.8		1
03/22/23 18:00	0.3			1.5			12.8		1	0.4			1.5			12.9		1
03/22/23 19:00	0.3			1.5			12.9		1	0.4			1.5			12.9		1
03/22/23 20:00	0.4			1.5			13.1		1	0.6			1.5			13.1		1
03/22/23 21:00	0.7			1.5			13.6		1	0.9			1.5			13.6		1
03/22/23 22:00	0.9			1.5			14.1		1	1			1.5			14.1		1
03/22/23 23:00	0.6			1.4			14.6		1	0.7			1.4			14.4		1
03/23/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 2:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/23/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/23/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.4		1
03/23/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/23/23 9:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/23/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/23/23 11:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/23/23 12:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/23/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/23/23 14:00	0			0			21		1	0.7			1.5			14.5		1
03/23/23 15:00	0.6			1.1			15.4		1	0.7			1.5			14.5		1
03/23/23 16:00	0.6			1.4			14.5		1	0.9			1.5			14.4		1
03/23/23 17:00	1			1.5			13.9		1	1			1.5			13.9		1
03/23/23 18:00	1			1.5			13.9		1	1			1.5			13.9		1
03/23/23 19:00	1			1.5			14		1	1.1			1.5			14		1
03/23/23 20:00	1			1.5			14		1	1.1			1.5			14		1
03/23/23 21:00	1			1.5			14		1	1.1			1.5			14		1
03/23/23 22:00	0.9			1.6			14.4		1	1			1.4			14.3		1
03/23/23 23:00	0			0			16.5		1	0.7			1.4			14.4		1
03/24/23 0:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 1:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 2:00	0	X		0	X		0	X	1	0.7			1.4			14.5		1
03/24/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/24/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 8:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 9:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 10:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/24/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/24/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/24/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 19:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/24/23 20:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/24/23 21:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/24/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/24/23 23:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 0:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/25/23 1:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/25/23 2:00	0	X		0	X		0	X	1	0.7			1.6			14.5		1
03/25/23 3:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 4:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 5:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 6:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 7:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 8:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/25/23 9:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/25/23 10:00	0	X		0	X		0	X	1	0.6			1.5			14.5		1
03/25/23 11:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 12:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/25/23 13:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/25/23 14:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/25/23 15:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/25/23 16:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
03/25/23 17:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 18:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 19:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
03/25/23 20:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 21:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 22:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
03/25/23 23:00	0	X		0	X		0	X	1	0			0			15.9		1
03/26/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/27/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/28/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/30/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/23 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
04/01/23 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
04/01/23 8:00	0	X		0	X		0	X	0	0	X		0	X		0	X	0

ATTACHMENT 5

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:54 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2023	0.8256	7.5859	1.0650	14.2128	0.2163	2.9308	0.1084	1.4667	0.3601	4.8854
Feb 2023	0.9164	7.5652	1.0643	14.3537	0.2142	2.9600	0.1074	1.4819	0.3569	4.9340
Mar 2023	0.9505	8.1089	1.0109	14.8234	0.1947	3.0447	0.0971	1.5240	0.3242	5.0748
Sum/Avg	8.1089		14.8234		3.0447		1.5240		5.0748	
Limit Value										

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/01/23 0:00	0			4.8														
01/02/23 0:00	4.3			7														
01/03/23 0:00	8.8			8.9														
01/04/23 0:00	2.6			5.7														
01/05/23 0:00	0.9			5.1														
01/06/23 0:00	1.4			5.2														
01/07/23 0:00	0			4.8														
01/08/23 0:00	1.7			5.3														
01/09/23 0:00	2.2			5.5														
01/10/23 0:00	2			5.4														
01/11/23 0:00	1.7			5.3														
01/12/23 0:00	1.7			5.3														
01/13/23 0:00	0			4.8														
01/14/23 0:00	1.4			5.2														
01/15/23 0:00	1.9			5.4														
01/16/23 0:00	2.1			5.4														
01/17/23 0:00	2			5.4														
01/18/23 0:00	2.7			5.7														
01/19/23 0:00	0			5.5														
01/20/23 0:00	0			6.7														
01/21/23 0:00	0			6.4														
01/22/23 0:00	0			5.6														
01/23/23 0:00	2.2			6.8														
01/24/23 0:00	3			6														
01/25/23 0:00	0			4.8														
01/26/23 0:00	0			4.8														
01/27/23 0:00	1.8			4.5														
01/28/23 0:00	4.8			0														
01/29/23 0:00	5.1			0.9														
01/30/23 0:00	7.1			0														
01/31/23 0:00	7			0														
02/01/23 0:00	5.8			0														
02/02/23 0:00	4.8			0														
02/03/23 0:00	5.9			2.4														
02/04/23 0:00	1.9			5.6														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 0:00	1.1			5														
02/06/23 0:00	2.1			5.7														
02/07/23 0:00	2.3			6														
02/08/23 0:00	6.5			5.4														
02/09/23 0:00	6.5			5.5														
02/10/23 0:00	5.5			2.3														
02/11/23 0:00	4.8			6.3														
02/12/23 0:00	6.1			5.3														
02/13/23 0:00	0.1			4.8														
02/14/23 0:00	2.8			6.3														
02/15/23 0:00	5.7			7.2														
02/16/23 0:00	4.7			6.6														
02/17/23 0:00	1.1			5.1														
02/18/23 0:00	0			4.8														
02/19/23 0:00	0			4.8														
02/20/23 0:00	2.2			5.5														
02/21/23 0:00	4.8			0														
02/22/23 0:00	5.5			2.6														
02/23/23 0:00	7.1			4.5														
02/24/23 0:00	7.2			0														
02/25/23 0:00	5.4			0														
02/26/23 0:00	4.8			0														
02/27/23 0:00	5.4			1.8														
02/28/23 0:00	5.4			2														
03/01/23 0:00	5.6			2.6														
03/02/23 0:00	4.8			0														
03/03/23 0:00	5.6			2														
03/04/23 0:00	5.2			2														
03/05/23 0:00	5.7			2.8														
03/06/23 0:00	6			3.6														
03/07/23 0:00	6.3			4.5														
03/08/23 0:00	6.3			4.9														
03/09/23 0:00	7.3			7.4														
03/10/23 0:00	5.2			1.3														
03/11/23 0:00	5.5			2.2														
03/12/23 0:00	6.6			5.5														
03/13/23 0:00	5.4			2														
03/14/23 0:00	6.6			5														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod												
03/15/23 0:00	5.2			1.5														
03/16/23 0:00	3.1			1.6														
03/17/23 0:00	5.5			4.5														
03/18/23 0:00	5.3			1.8														
03/19/23 0:00	5.5			2.6														
03/20/23 0:00	4.4			1.7														
03/21/23 0:00	0			2.6														
03/22/23 0:00	2.3			5.8														
03/23/23 0:00	2.1			5.4														
03/24/23 0:00	0			4.8														
03/25/23 0:00	0			4.6														
03/26/23 0:00	0			0														
03/27/23 0:00	0			0														
03/28/23 0:00	0			0														
03/29/23 0:00	0			0														
03/30/23 0:00	0			0														
03/31/23 0:00	0			0														
04/01/23 0:00	0	X		0	X													

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/01/23 0:00	0	X		0.18774			0.19											
01/01/23 1:00	0	X		0.18642			0.19											
01/01/23 2:00	0	X		0.18678			0.19											
01/01/23 3:00	0	X		0.18648			0.19											
01/01/23 4:00	0	X		0.18564			0.19											
01/01/23 5:00	0	X		0.18522			0.19											
01/01/23 6:00	0	X		0.18516			0.19											
01/01/23 7:00	0	X		0.18522			0.19											
01/01/23 8:00	0	X		0.18492			0.18											
01/01/23 9:00	0	X		0.1848			0.18											
01/01/23 10:00	0	X		0.18444			0.18											
01/01/23 11:00	0	X		0.18354			0.18											
01/01/23 12:00	0	X		0.18324			0.18											
01/01/23 13:00	0	X		0.18354			0.18											
01/01/23 14:00	0	X		0.18372			0.18											
01/01/23 15:00	0	X		0.18426			0.18											
01/01/23 16:00	0	X		0.18474			0.18											
01/01/23 17:00	0	X		0.1854			0.19											
01/01/23 18:00	0	X		0.18606			0.19											
01/01/23 19:00	0	X		0.18648			0.19											
01/01/23 20:00	0	X		0.18744			0.19											
01/01/23 21:00	0	X		0.18726			0.19											
01/01/23 22:00	0	X		0.18684			0.19											
01/01/23 23:00	0	X		0.18654			0.19											
01/02/23 0:00	0	X		0.1872			0.19											
01/02/23 1:00	0	X		0.18726			0.19											
01/02/23 2:00	0	X		0.18732			0.19											
01/02/23 3:00	0	X		0.18702			0.19											
01/02/23 4:00	0	X		0.1866			0.19											
01/02/23 5:00	0	X		0.1872			0.19											
01/02/23 6:00	0	X		0.18966			0.19											
01/02/23 7:00	0	X		0.2979			0.3											
01/02/23 8:00	0	X		0.2124			0.21											
01/02/23 9:00	0	X		0.18642			0.19											
01/02/23 10:00	0	X		0.21552			0.22											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/02/23 11:00	0	X		0.22074			0.22											
01/02/23 12:00	0.15786			0.24366			0.37											
01/02/23 13:00	0.27756			0.29808			0.58											
01/02/23 14:00	0.372			0.3945			0.77											
01/02/23 15:00	0.3681			0.39024			0.76											
01/02/23 16:00	0.36678			0.39			0.76											
01/02/23 17:00	0.36642			0.39006			0.76											
01/02/23 18:00	0.36624			0.38934			0.76											
01/02/23 19:00	0.3645			0.38688			0.75											
01/02/23 20:00	0.36324			0.3846			0.75											
01/02/23 21:00	0.35922			0.38124			0.74											
01/02/23 22:00	0.3501			0.37194			0.72											
01/02/23 23:00	0.34476			0.36642			0.71											
01/03/23 0:00	0.35268			0.3738			0.73											
01/03/23 1:00	0.34998			0.37164			0.72											
01/03/23 2:00	0.3501			0.37176			0.72											
01/03/23 3:00	0.3522			0.3747			0.73											
01/03/23 4:00	0.35742			0.37938			0.74											
01/03/23 5:00	0.36054			0.3825			0.74											
01/03/23 6:00	0.3783			0.40026			0.78											
01/03/23 7:00	0.3624			0.38544			0.75											
01/03/23 8:00	0.32352			0.34638			0.67											
01/03/23 9:00	0.32706			0.34884			0.68											
01/03/23 10:00	0.31014			0.33216			0.64											
01/03/23 11:00	0.30666			0.32862			0.64											
01/03/23 12:00	0.31536			0.33756			0.65											
01/03/23 13:00	0.3132			0.33564			0.65											
01/03/23 14:00	0.3228			0.345			0.67											
01/03/23 15:00	0.36984			0.39138			0.76											
01/03/23 16:00	0.35976			0.38166			0.74											
01/03/23 17:00	0.35862			0.38028			0.74											
01/03/23 18:00	0.35922			0.38052			0.74											
01/03/23 19:00	0.35526			0.37722			0.73											
01/03/23 20:00	0.3654			0.38676			0.75											
01/03/23 21:00	0.36396			0.38592			0.75											
01/03/23 22:00	0.35904			0.38034			0.74											
01/03/23 23:00	0.33468			0.35646			0.69											
01/04/23 0:00	0.28782			0.30888			0.6											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/04/23 1:00	0.28848			0.31092			0.6											
01/04/23 2:00	0.28836			0.31104			0.6											
01/04/23 3:00	0.28866			0.31116			0.6											
01/04/23 4:00	0.28818			0.3108			0.6											
01/04/23 5:00	0.28782			0.3108			0.6											
01/04/23 6:00	0.2886			0.31086			0.6											
01/04/23 7:00	0.30546			0.32772			0.63											
01/04/23 8:00	0.23232			0.25884			0.49											
01/04/23 9:00	0.01344			0.20184			0.2											
01/04/23 10:00	0	X		0.18432			0.18											
01/04/23 11:00	0	X		0.18612			0.19											
01/04/23 12:00	0	X		0.1875			0.19											
01/04/23 13:00	0	X		0.18672			0.19											
01/04/23 14:00	0	X		0.18504			0.19											
01/04/23 15:00	0	X		0.18462			0.18											
01/04/23 16:00	0	X		0.18342			0.18											
01/04/23 17:00	0	X		0.1821			0.18											
01/04/23 18:00	0	X		0.18348			0.18											
01/04/23 19:00	0	X		0.1854			0.19											
01/04/23 20:00	0	X		0.18432			0.18											
01/04/23 21:00	0	X		0.18432			0.18											
01/04/23 22:00	0	X		0.18366			0.18											
01/04/23 23:00	0	X		0.18318			0.18											
01/05/23 0:00	0	X		0.18612			0.19											
01/05/23 1:00	0	X		0.18624			0.19											
01/05/23 2:00	0	X		0.18732			0.19											
01/05/23 3:00	0	X		0.18738			0.19											
01/05/23 4:00	0	X		0.1872			0.19											
01/05/23 5:00	0	X		0.186			0.19											
01/05/23 6:00	0	X		0.18618			0.19											
01/05/23 7:00	0	X		0.18624			0.19											
01/05/23 8:00	0	X		0.1866			0.19											
01/05/23 9:00	0	X		0.1863			0.19											
01/05/23 10:00	0	X		0.18552			0.19											
01/05/23 11:00	0	X		0.18594			0.19											
01/05/23 12:00	0	X		0.18738			0.19											
01/05/23 13:00	0	X		0.18786			0.19											
01/05/23 14:00	0	X		0.18786			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/05/23 15:00	0.13866			0.25794			0.33											
01/05/23 16:00	0.22128			0.237			0.46											
01/05/23 17:00	0.31452			0.33618			0.65											
01/05/23 18:00	0.27312			0.29238			0.57											
01/05/23 19:00	0.14328			0.2088			0.24											
01/05/23 20:00	0	X		0.18762			0.19											
01/05/23 21:00	0	X		0.18816			0.19											
01/05/23 22:00	0	X		0.18786			0.19											
01/05/23 23:00	0	X		0.18774			0.19											
01/06/23 0:00	0	X		0.18804			0.19											
01/06/23 1:00	0	X		0.18768			0.19											
01/06/23 2:00	0	X		0.18834			0.19											
01/06/23 3:00	0	X		0.18888			0.19											
01/06/23 4:00	0	X		0.18888			0.19											
01/06/23 5:00	0	X		0.18858			0.19											
01/06/23 6:00	0	X		0.18828			0.19											
01/06/23 7:00	0	X		0.18786			0.19											
01/06/23 8:00	0	X		0.1881			0.19											
01/06/23 9:00	0	X		0.18792			0.19											
01/06/23 10:00	0	X		0.18762			0.19											
01/06/23 11:00	0	X		0.18732			0.19											
01/06/23 12:00	0	X		0.18756			0.19											
01/06/23 13:00	0	X		0.18756			0.19											
01/06/23 14:00	0	X		0.18762			0.19											
01/06/23 15:00	0	X		0.22074			0.22											
01/06/23 16:00	0.17028			0.2433			0.41											
01/06/23 17:00	0.28368			0.30318			0.59											
01/06/23 18:00	0.30942			0.33138			0.64											
01/06/23 19:00	0.30882			0.33132			0.64											
01/06/23 20:00	0.23376			0.2517			0.49											
01/06/23 21:00	0.16176			0.20604			0.29											
01/06/23 22:00	0	X		0.18714			0.19											
01/06/23 23:00	0	X		0.18774			0.19											
01/07/23 0:00	0	X		0.18798			0.19											
01/07/23 1:00	0	X		0.1881			0.19											
01/07/23 2:00	0	X		0.18708			0.19											
01/07/23 3:00	0	X		0.18684			0.19											
01/07/23 4:00	0	X		0.18552			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/07/23 5:00	0	X		0.18582			0.19											
01/07/23 6:00	0	X		0.18636			0.19											
01/07/23 7:00	0	X		0.18732			0.19											
01/07/23 8:00	0	X		0.18654			0.19											
01/07/23 9:00	0	X		0.18546			0.19											
01/07/23 10:00	0	X		0.18534			0.19											
01/07/23 11:00	0	X		0.18576			0.19											
01/07/23 12:00	0	X		0.18678			0.19											
01/07/23 13:00	0	X		0.18636			0.19											
01/07/23 14:00	0	X		0.18702			0.19											
01/07/23 15:00	0	X		0.18636			0.19											
01/07/23 16:00	0	X		0.18642			0.19											
01/07/23 17:00	0	X		0.18606			0.19											
01/07/23 18:00	0	X		0.18498			0.18											
01/07/23 19:00	0	X		0.1842			0.18											
01/07/23 20:00	0	X		0.18342			0.18											
01/07/23 21:00	0	X		0.18318			0.18											
01/07/23 22:00	0	X		0.18402			0.18											
01/07/23 23:00	0	X		0.18378			0.18											
01/08/23 0:00	0	X		0.18288			0.18											
01/08/23 1:00	0	X		0.1839			0.18											
01/08/23 2:00	0	X		0.18492			0.18											
01/08/23 3:00	0	X		0.1848			0.18											
01/08/23 4:00	0	X		0.18474			0.18											
01/08/23 5:00	0	X		0.18504			0.19											
01/08/23 6:00	0	X		0.18582			0.19											
01/08/23 7:00	0	X		0.18768			0.19											
01/08/23 8:00	0	X		0.18816			0.19											
01/08/23 9:00	0	X		0.18834			0.19											
01/08/23 10:00	0	X		0.18762			0.19											
01/08/23 11:00	0	X		0.18594			0.19											
01/08/23 12:00	0	X		0.18588			0.19											
01/08/23 13:00	0	X		0.18606			0.19											
01/08/23 14:00	0	X		0.18618			0.19											
01/08/23 15:00	0	X		0.21846			0.22											
01/08/23 16:00	0.16428			0.2358			0.39											
01/08/23 17:00	0.27156			0.2919			0.56											
01/08/23 18:00	0.31296			0.33564			0.65											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 19:00	0.3099			0.3321			0.64											
01/08/23 20:00	0.3123			0.33462			0.65											
01/08/23 21:00	0.26982			0.29076			0.56											
01/08/23 22:00	0.14004			0.19296			0.23											
01/08/23 23:00	0	X		0.18528			0.19											
01/09/23 0:00	0	X		0.18618			0.19											
01/09/23 1:00	0	X		0.1857			0.19											
01/09/23 2:00	0	X		0.18528			0.19											
01/09/23 3:00	0	X		0.18456			0.18											
01/09/23 4:00	0	X		0.18348			0.18											
01/09/23 5:00	0	X		0.18378			0.18											
01/09/23 6:00	0	X		0.18534			0.19											
01/09/23 7:00	0	X		0.18564			0.19											
01/09/23 8:00	0	X		0.18678			0.19											
01/09/23 9:00	0	X		0.1872			0.19											
01/09/23 10:00	0	X		0.18732			0.19											
01/09/23 11:00	0	X		0.18816			0.19											
01/09/23 12:00	0	X		0.18858			0.19											
01/09/23 13:00	0.0342			0.2199			0.22											
01/09/23 14:00	0.17586			0.20994			0.39											
01/09/23 15:00	0.27978			0.3009			0.58											
01/09/23 16:00	0.3249			0.34638			0.67											
01/09/23 17:00	0.32688			0.34806			0.67											
01/09/23 18:00	0.32304			0.3438			0.67											
01/09/23 19:00	0.3222			0.3429			0.67											
01/09/23 20:00	0.3219			0.34308			0.66											
01/09/23 21:00	0.2448			0.2781			0.51											
01/09/23 22:00	0	X		0.20844			0.21											
01/09/23 23:00	0	X		0.1869			0.19											
01/10/23 0:00	0	X		0.18672			0.19											
01/10/23 1:00	0	X		0.18666			0.19											
01/10/23 2:00	0	X		0.18546			0.19											
01/10/23 3:00	0	X		0.18546			0.19											
01/10/23 4:00	0	X		0.18642			0.19											
01/10/23 5:00	0	X		0.1863			0.19											
01/10/23 6:00	0	X		0.18528			0.19											
01/10/23 7:00	0	X		0.18468			0.18											
01/10/23 8:00	0	X		0.18504			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/10/23 9:00	0	X		0.18456			0.18											
01/10/23 10:00	0	X		0.18582			0.19											
01/10/23 11:00	0	X		0.18654			0.19											
01/10/23 12:00	0	X		0.18666			0.19											
01/10/23 13:00	0	X		0.18702			0.19											
01/10/23 14:00	0	X		0.18732			0.19											
01/10/23 15:00	0.02778			0.21912			0.22											
01/10/23 16:00	0.17946			0.21762			0.4											
01/10/23 17:00	0.29334			0.31452			0.61											
01/10/23 18:00	0.31896			0.34278			0.66											
01/10/23 19:00	0.31956			0.34296			0.66											
01/10/23 20:00	0.31464			0.3384			0.65											
01/10/23 21:00	0.30726			0.33084			0.64											
01/10/23 22:00	0.27054			0.2925			0.56											
01/10/23 23:00	0.14502			0.20184			0.24											
01/11/23 0:00	0	X		0.18552			0.19											
01/11/23 1:00	0	X		0.18672			0.19											
01/11/23 2:00	0	X		0.1881			0.19											
01/11/23 3:00	0	X		0.18708			0.19											
01/11/23 4:00	0	X		0.18666			0.19											
01/11/23 5:00	0	X		0.18684			0.19											
01/11/23 6:00	0	X		0.18732			0.19											
01/11/23 7:00	0	X		0.18696			0.19											
01/11/23 8:00	0	X		0.18672			0.19											
01/11/23 9:00	0	X		0.18726			0.19											
01/11/23 10:00	0	X		0.18738			0.19											
01/11/23 11:00	0	X		0.18732			0.19											
01/11/23 12:00	0	X		0.1863			0.19											
01/11/23 13:00	0	X		0.18492			0.18											
01/11/23 14:00	0	X		0.21648			0.22											
01/11/23 15:00	0.16488			0.22566			0.39											
01/11/23 16:00	0.27936			0.3			0.58											
01/11/23 17:00	0.3177			0.34098			0.66											
01/11/23 18:00	0.30954			0.33312			0.64											
01/11/23 19:00	0.30762			0.33054			0.64											
01/11/23 20:00	0.27036			0.29076			0.56											
01/11/23 21:00	0.11802			0.2232			0.24											
01/11/23 22:00	0	X		0.1866			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/11/23 23:00	0	X		0.18684			0.19											
01/12/23 0:00	0	X		0.18828			0.19											
01/12/23 1:00	0	X		0.18864			0.19											
01/12/23 2:00	0	X		0.18828			0.19											
01/12/23 3:00	0	X		0.18822			0.19											
01/12/23 4:00	0	X		0.18876			0.19											
01/12/23 5:00	0	X		0.18888			0.19											
01/12/23 6:00	0	X		0.1884			0.19											
01/12/23 7:00	0	X		0.18762			0.19											
01/12/23 8:00	0	X		0.1851			0.19											
01/12/23 9:00	0	X		0.18576			0.19											
01/12/23 10:00	0	X		0.18576			0.19											
01/12/23 11:00	0	X		0.18552			0.19											
01/12/23 12:00	0	X		0.1851			0.19											
01/12/23 13:00	0	X		0.18468			0.18											
01/12/23 14:00	0	X		0.1851			0.19											
01/12/23 15:00	0.06444			0.21066			0.22											
01/12/23 16:00	0.1806			0.1962			0.38											
01/12/23 17:00	0.26106			0.27942			0.54											
01/12/23 18:00	0.31008			0.33024			0.64											
01/12/23 19:00	0.30924			0.33006			0.64											
01/12/23 20:00	0.3099			0.33012			0.64											
01/12/23 21:00	0.2649			0.2835			0.55											
01/12/23 22:00	0.14202			0.20508			0.24											
01/12/23 23:00	0	X		0.1869			0.19											
01/13/23 0:00	0	X		0.18504			0.19											
01/13/23 1:00	0	X		0.1851			0.19											
01/13/23 2:00	0	X		0.1851			0.19											
01/13/23 3:00	0	X		0.18522			0.19											
01/13/23 4:00	0	X		0.18528			0.19											
01/13/23 5:00	0	X		0.18516			0.19											
01/13/23 6:00	0	X		0.18552			0.19											
01/13/23 7:00	0	X		0.18582			0.19											
01/13/23 8:00	0	X		0.18528			0.19											
01/13/23 9:00	0	X		0.18498			0.18											
01/13/23 10:00	0	X		0.18714			0.19											
01/13/23 11:00	0	X		0.18684			0.19											
01/13/23 12:00	0	X		0.18672			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/13/23 13:00	0	X		0.18606			0.19											
01/13/23 14:00	0	X		0.18594			0.19											
01/13/23 15:00	0	X		0.18588			0.19											
01/13/23 16:00	0	X		0.18576			0.19											
01/13/23 17:00	0	X		0.18588			0.19											
01/13/23 18:00	0	X		0.186			0.19											
01/13/23 19:00	0	X		0.18684			0.19											
01/13/23 20:00	0	X		0.1875			0.19											
01/13/23 21:00	0	X		0.1878			0.19											
01/13/23 22:00	0	X		0.18774			0.19											
01/13/23 23:00	0	X		0.18732			0.19											
01/14/23 0:00	0	X		0.18678			0.19											
01/14/23 1:00	0	X		0.18648			0.19											
01/14/23 2:00	0	X		0.18588			0.19											
01/14/23 3:00	0	X		0.18516			0.19											
01/14/23 4:00	0	X		0.18474			0.18											
01/14/23 5:00	0	X		0.18462			0.18											
01/14/23 6:00	0	X		0.1845			0.18											
01/14/23 7:00	0	X		0.18378			0.18											
01/14/23 8:00	0	X		0.183			0.18											
01/14/23 9:00	0	X		0.2142			0.21											
01/14/23 10:00	0	X		0.21084			0.21											
01/14/23 11:00	0	X		0.1863			0.19											
01/14/23 12:00	0	X		0.1866			0.19											
01/14/23 13:00	0	X		0.18726			0.19											
01/14/23 14:00	0.03504			0.23412			0.24											
01/14/23 15:00	0.17298			0.20556			0.38											
01/14/23 16:00	0.27294			0.29322			0.57											
01/14/23 17:00	0.31038			0.33108			0.64											
01/14/23 18:00	0.31218			0.33366			0.65											
01/14/23 19:00	0.27528			0.29706			0.57											
01/14/23 20:00	0.15018			0.2025			0.24											
01/14/23 21:00	0	X		0.1866			0.19											
01/14/23 22:00	0	X		0.18678			0.19											
01/14/23 23:00	0	X		0.18666			0.19											
01/15/23 0:00	0	X		0.18702			0.19											
01/15/23 1:00	0	X		0.18732			0.19											
01/15/23 2:00	0	X		0.1869			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/15/23 3:00	0	X		0.18648			0.19											
01/15/23 4:00	0	X		0.18654			0.19											
01/15/23 5:00	0	X		0.18684			0.19											
01/15/23 6:00	0	X		0.18642			0.19											
01/15/23 7:00	0	X		0.18654			0.19											
01/15/23 8:00	0	X		0.1866			0.19											
01/15/23 9:00	0	X		0.18684			0.19											
01/15/23 10:00	0	X		0.18648			0.19											
01/15/23 11:00	0	X		0.18594			0.19											
01/15/23 12:00	0	X		0.18576			0.19											
01/15/23 13:00	0	X		0.18654			0.19											
01/15/23 14:00	0.00846			0.23844			0.24											
01/15/23 15:00	0.16824			0.22338			0.39											
01/15/23 16:00	0.2793			0.30078			0.58											
01/15/23 17:00	0.31962			0.34098			0.66											
01/15/23 18:00	0.31986			0.34092			0.66											
01/15/23 19:00	0.31158			0.33342			0.65											
01/15/23 20:00	0.312			0.33516			0.65											
01/15/23 21:00	0.23976			0.25812			0.5											
01/15/23 22:00	0.13326			0.21168			0.24											
01/15/23 23:00	0	X		0.18732			0.19											
01/16/23 0:00	0	X		0.18726			0.19											
01/16/23 1:00	0	X		0.18744			0.19											
01/16/23 2:00	0	X		0.18696			0.19											
01/16/23 3:00	0	X		0.18636			0.19											
01/16/23 4:00	0	X		0.186			0.19											
01/16/23 5:00	0	X		0.186			0.19											
01/16/23 6:00	0	X		0.18594			0.19											
01/16/23 7:00	0	X		0.1863			0.19											
01/16/23 8:00	0	X		0.18672			0.19											
01/16/23 9:00	0	X		0.1875			0.19											
01/16/23 10:00	0	X		0.1878			0.19											
01/16/23 11:00	0	X		0.18732			0.19											
01/16/23 12:00	0	X		0.18726			0.19											
01/16/23 13:00	0	X		0.18474			0.18											
01/16/23 14:00	0	X		0.19686			0.2											
01/16/23 15:00	0.15798			0.21708			0.38											
01/16/23 16:00	0.22752			0.24426			0.47											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 17:00	0.31086			0.33252			0.64											
01/16/23 18:00	0.31056			0.3321			0.64											
01/16/23 19:00	0.31026			0.33216			0.64											
01/16/23 20:00	0.30918			0.3318			0.64											
01/16/23 21:00	0.30834			0.33096			0.64											
01/16/23 22:00	0.2367			0.26502			0.5											
01/16/23 23:00	0	X		0.20358			0.2											
01/17/23 0:00	0	X		0.18732			0.19											
01/17/23 1:00	0	X		0.18732			0.19											
01/17/23 2:00	0	X		0.18774			0.19											
01/17/23 3:00	0	X		0.18792			0.19											
01/17/23 4:00	0	X		0.18816			0.19											
01/17/23 5:00	0	X		0.18804			0.19											
01/17/23 6:00	0	X		0.19242			0.19											
01/17/23 7:00	0	X		0.19938			0.2											
01/17/23 8:00	0	X		0.1881			0.19											
01/17/23 9:00	0	X		0.1878			0.19											
01/17/23 10:00	0	X		0.18792			0.19											
01/17/23 11:00	0	X		0.1881			0.19											
01/17/23 12:00	0	X		0.18798			0.19											
01/17/23 13:00	0	X		0.18846			0.19											
01/17/23 14:00	0	X		0.1881			0.19											
01/17/23 15:00	0	X		0.18804			0.19											
01/17/23 16:00	0	X		0.2205			0.22											
01/17/23 17:00	0.16416			0.22758			0.39											
01/17/23 18:00	0.26526			0.28452			0.55											
01/17/23 19:00	0.30702			0.32832			0.64											
01/17/23 20:00	0.30726			0.32826			0.64											
01/17/23 21:00	0.30636			0.32844			0.63											
01/17/23 22:00	0.30552			0.3282			0.63											
01/17/23 23:00	0.30522			0.32712			0.63											
01/18/23 0:00	0.30756			0.32964			0.64											
01/18/23 1:00	0.3081			0.33072			0.64											
01/18/23 2:00	0.30798			0.3303			0.64											
01/18/23 3:00	0.30762			0.33036			0.64											
01/18/23 4:00	0.30684			0.32946			0.64											
01/18/23 5:00	0.3057			0.32886			0.63											
01/18/23 6:00	0.3087			0.33192			0.64											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/18/23 7:00	0.30264			0.32664			0.63											
01/18/23 8:00	0.27198			0.29244			0.56											
01/18/23 9:00	0.14448			0.20466			0.24											
01/18/23 10:00	0	X		0.18558			0.19											
01/18/23 11:00	0	X		0.18582			0.19											
01/18/23 12:00	0	X		0.18594			0.19											
01/18/23 13:00	0	X		0.1857			0.19											
01/18/23 14:00	0	X		0.18564			0.19											
01/18/23 15:00	0	X		0.18612			0.19											
01/18/23 16:00	0	X		0.18558			0.19											
01/18/23 17:00	0	X		0.1851			0.19											
01/18/23 18:00	0	X		0.18516			0.19											
01/18/23 19:00	0	X		0.18522			0.19											
01/18/23 20:00	0	X		0.18498			0.18											
01/18/23 21:00	0	X		0.18504			0.19											
01/18/23 22:00	0	X		0.18522			0.19											
01/18/23 23:00	0	X		0.18582			0.19											
01/19/23 0:00	0	X		0.18546			0.19											
01/19/23 1:00	0	X		0.18594			0.19											
01/19/23 2:00	0	X		0.18594			0.19											
01/19/23 3:00	0	X		0.18588			0.19											
01/19/23 4:00	0	X		0.18582			0.19											
01/19/23 5:00	0	X		0.18594			0.19											
01/19/23 6:00	0	X		0.18606			0.19											
01/19/23 7:00	0	X		0.18612			0.19											
01/19/23 8:00	0	X		0.18654			0.19											
01/19/23 9:00	0	X		0.18654			0.19											
01/19/23 10:00	0	X		0.18618			0.19											
01/19/23 11:00	0	X		0.18648			0.19											
01/19/23 12:00	0	X		0.18558			0.19											
01/19/23 13:00	0	X		0.18594			0.19											
01/19/23 14:00	0	X		0.18528			0.19											
01/19/23 15:00	0	X		0.18564			0.19											
01/19/23 16:00	0	X		0.18564			0.19											
01/19/23 17:00	0	X		0.258			0.26											
01/19/23 18:00	0	X		0.30432			0.3											
01/19/23 19:00	0	X		0.3042			0.3											
01/19/23 20:00	0	X		0.30438			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/19/23 21:00	0	X		0.30474			0.3											
01/19/23 22:00	0	X		0.30468			0.3											
01/19/23 23:00	0	X		0.3069			0.31											
01/20/23 0:00	0	X		0.30696			0.31											
01/20/23 1:00	0	X		0.30732			0.31											
01/20/23 2:00	0	X		0.30774			0.31											
01/20/23 3:00	0	X		0.3066			0.31											
01/20/23 4:00	0	X		0.3075			0.31											
01/20/23 5:00	0	X		0.3072			0.31											
01/20/23 6:00	0	X		0.30678			0.31											
01/20/23 7:00	0	X		0.30768			0.31											
01/20/23 8:00	0	X		0.30708			0.31											
01/20/23 9:00	0	X		0.30648			0.31											
01/20/23 10:00	0	X		0.3066			0.31											
01/20/23 11:00	0	X		0.2997			0.3											
01/20/23 12:00	0	X		0.20826			0.21											
01/20/23 13:00	0	X		0.18684			0.19											
01/20/23 14:00	0	X		0.1869			0.19											
01/20/23 15:00	0	X		0.1872			0.19											
01/20/23 16:00	0	X		0.18708			0.19											
01/20/23 17:00	0	X		0.2562			0.26											
01/20/23 18:00	0	X		0.30438			0.3											
01/20/23 19:00	0	X		0.30384			0.3											
01/20/23 20:00	0	X		0.30582			0.31											
01/20/23 21:00	0	X		0.30576			0.31											
01/20/23 22:00	0	X		0.30582			0.31											
01/20/23 23:00	0	X		0.30564			0.31											
01/21/23 0:00	0	X		0.3084			0.31											
01/21/23 1:00	0	X		0.30918			0.31											
01/21/23 2:00	0	X		0.30912			0.31											
01/21/23 3:00	0	X		0.30954			0.31											
01/21/23 4:00	0	X		0.30924			0.31											
01/21/23 5:00	0	X		0.30978			0.31											
01/21/23 6:00	0	X		0.30924			0.31											
01/21/23 7:00	0	X		0.31044			0.31											
01/21/23 8:00	0	X		0.3042			0.3											
01/21/23 9:00	0	X		0.20634			0.21											
01/21/23 10:00	0	X		0.18702			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/21/23 11:00	0	X		0.1869			0.19											
01/21/23 12:00	0	X		0.18708			0.19											
01/21/23 13:00	0	X		0.1869			0.19											
01/21/23 14:00	0	X		0.18684			0.19											
01/21/23 15:00	0	X		0.18666			0.19											
01/21/23 16:00	0	X		0.25788			0.26											
01/21/23 17:00	0	X		0.31194			0.31											
01/21/23 18:00	0	X		0.31182			0.31											
01/21/23 19:00	0	X		0.31248			0.31											
01/21/23 20:00	0	X		0.31266			0.31											
01/21/23 21:00	0	X		0.31578			0.32											
01/21/23 22:00	0	X		0.27456			0.27											
01/21/23 23:00	0	X		0.18732			0.19											
01/22/23 0:00	0	X		0.18768			0.19											
01/22/23 1:00	0	X		0.18792			0.19											
01/22/23 2:00	0	X		0.18822			0.19											
01/22/23 3:00	0	X		0.1881			0.19											
01/22/23 4:00	0	X		0.1884			0.19											
01/22/23 5:00	0	X		0.18858			0.19											
01/22/23 6:00	0	X		0.18846			0.19											
01/22/23 7:00	0	X		0.18744			0.19											
01/22/23 8:00	0	X		0.18606			0.19											
01/22/23 9:00	0	X		0.18594			0.19											
01/22/23 10:00	0	X		0.18498			0.18											
01/22/23 11:00	0	X		0.18432			0.18											
01/22/23 12:00	0	X		0.18282			0.18											
01/22/23 13:00	0	X		0.1827			0.18											
01/22/23 14:00	0	X		0.18264			0.18											
01/22/23 15:00	0	X		0.18252			0.18											
01/22/23 16:00	0	X		0.25368			0.25											
01/22/23 17:00	0	X		0.31872			0.32											
01/22/23 18:00	0	X		0.32052			0.32											
01/22/23 19:00	0	X		0.32166			0.32											
01/22/23 20:00	0	X		0.32352			0.32											
01/22/23 21:00	0	X		0.321			0.32											
01/22/23 22:00	0	X		0.31794			0.32											
01/22/23 23:00	0	X		0.31488			0.31											
01/23/23 0:00	0	X		0.31506			0.32											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/23/23 1:00	0	X		0.31782			0.32											
01/23/23 2:00	0	X		0.31848			0.32											
01/23/23 3:00	0	X		0.31758			0.32											
01/23/23 4:00	0	X		0.31878			0.32											
01/23/23 5:00	0	X		0.31716			0.32											
01/23/23 6:00	0	X		0.3261			0.33											
01/23/23 7:00	0	X		0.33162			0.33											
01/23/23 8:00	0	X		0.31278			0.31											
01/23/23 9:00	0	X		0.2112			0.21											
01/23/23 10:00	0	X		0.18348			0.18											
01/23/23 11:00	0	X		0.18294			0.18											
01/23/23 12:00	0	X		0.18282			0.18											
01/23/23 13:00	0	X		0.1827			0.18											
01/23/23 14:00	0	X		0.18258			0.18											
01/23/23 15:00	0	X		0.21594			0.22											
01/23/23 16:00	0.16506			0.24798			0.38											
01/23/23 17:00	0.25962			0.27504			0.53											
01/23/23 18:00	0.32418			0.34476			0.67											
01/23/23 19:00	0.3498			0.37248			0.72											
01/23/23 20:00	0.34206			0.36588			0.71											
01/23/23 21:00	0.32622			0.35724			0.68											
01/23/23 22:00	0.32832			0.3579			0.69											
01/23/23 23:00	0.3159			0.33768			0.65											
01/24/23 0:00	0.28872			0.31164			0.6											
01/24/23 1:00	0.28956			0.31212			0.6											
01/24/23 2:00	0.28818			0.31086			0.6											
01/24/23 3:00	0.28812			0.31104			0.6											
01/24/23 4:00	0.28806			0.31116			0.6											
01/24/23 5:00	0.3168			0.34134			0.66											
01/24/23 6:00	0.35676			0.38232			0.74											
01/24/23 7:00	0.30882			0.32862			0.64											
01/24/23 8:00	0.30432			0.32376			0.63											
01/24/23 9:00	0.23532			0.25266			0.49											
01/24/23 10:00	0.1458			0.20442			0.25											
01/24/23 11:00	0	X		0.18756			0.19											
01/24/23 12:00	0	X		0.18762			0.19											
01/24/23 13:00	0	X		0.18696			0.19											
01/24/23 14:00	0	X		0.1872			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/24/23 15:00	0	X		0.18768			0.19											
01/24/23 16:00	0	X		0.1869			0.19											
01/24/23 17:00	0	X		0.18894			0.19											
01/24/23 18:00	0	X		0.2595			0.26											
01/24/23 19:00	0	X		0.21402			0.21											
01/24/23 20:00	0	X		0.18894			0.19											
01/24/23 21:00	0	X		0.18918			0.19											
01/24/23 22:00	0	X		0.18936			0.19											
01/24/23 23:00	0	X		0.18948			0.19											
01/25/23 0:00	0	X		0.18912			0.19											
01/25/23 1:00	0	X		0.18756			0.19											
01/25/23 2:00	0	X		0.18732			0.19											
01/25/23 3:00	0	X		0.18726			0.19											
01/25/23 4:00	0	X		0.18702			0.19											
01/25/23 5:00	0	X		0.18708			0.19											
01/25/23 6:00	0	X		0.19116			0.19											
01/25/23 7:00	0	X		0.18954			0.19											
01/25/23 8:00	0	X		0.19176			0.19											
01/25/23 9:00	0	X		0.19074			0.19											
01/25/23 10:00	0	X		0.1899			0.19											
01/25/23 11:00	0	X		0.1875			0.19											
01/25/23 12:00	0	X		0.18624			0.19											
01/25/23 13:00	0	X		0.1881			0.19											
01/25/23 14:00	0	X		0.18582			0.19											
01/25/23 15:00	0	X		0.18576			0.19											
01/25/23 16:00	0	X		0.18624			0.19											
01/25/23 17:00	0	X		0.18816			0.19											
01/25/23 18:00	0	X		0.18702			0.19											
01/25/23 19:00	0	X		0.18666			0.19											
01/25/23 20:00	0	X		0.18678			0.19											
01/25/23 21:00	0	X		0.18696			0.19											
01/25/23 22:00	0	X		0.18702			0.19											
01/25/23 23:00	0	X		0.18762			0.19											
01/26/23 0:00	0	X		0.18942			0.19											
01/26/23 1:00	0	X		0.18768			0.19											
01/26/23 2:00	0	X		0.1869			0.19											
01/26/23 3:00	0	X		0.18954			0.19											
01/26/23 4:00	0	X		0.19002			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/26/23 5:00	0	X		0.18948			0.19											
01/26/23 6:00	0	X		0.18774			0.19											
01/26/23 7:00	0	X		0.18948			0.19											
01/26/23 8:00	0	X		0.18726			0.19											
01/26/23 9:00	0	X		0.18816			0.19											
01/26/23 10:00	0	X		0.18804			0.19											
01/26/23 11:00	0	X		0.18588			0.19											
01/26/23 12:00	0	X		0.18522			0.19											
01/26/23 13:00	0	X		0.18504			0.19											
01/26/23 14:00	0	X		0.18522			0.19											
01/26/23 15:00	0	X		0.18534			0.19											
01/26/23 16:00	0	X		0.18534			0.19											
01/26/23 17:00	0	X		0.18558			0.19											
01/26/23 18:00	0	X		0.1854			0.19											
01/26/23 19:00	0	X		0.1857			0.19											
01/26/23 20:00	0	X		0.18546			0.19											
01/26/23 21:00	0	X		0.18552			0.19											
01/26/23 22:00	0	X		0.18564			0.19											
01/26/23 23:00	0	X		0.18546			0.19											
01/27/23 0:00	0	X		0.18576			0.19											
01/27/23 1:00	0	X		0.18738			0.19											
01/27/23 2:00	0	X		0.18942			0.19											
01/27/23 3:00	0	X		0.18948			0.19											
01/27/23 4:00	0	X		0.18948			0.19											
01/27/23 5:00	0	X		0.18936			0.19											
01/27/23 6:00	0	X		0.1893			0.19											
01/27/23 7:00	0	X		0.19332			0.19											
01/27/23 8:00	0	X		0.18912			0.19											
01/27/23 9:00	0	X		0.18858			0.19											
01/27/23 10:00	0	X		0.18714			0.19											
01/27/23 11:00	0	X		0.18504			0.19											
01/27/23 12:00	0	X		0.18516			0.19											
01/27/23 13:00	0	X		0.18474			0.18											
01/27/23 14:00	0	X		0.18462			0.18											
01/27/23 15:00	0	X		0.21654			0.22											
01/27/23 16:00	0.17664			0.27342			0.38											
01/27/23 17:00	0.28554			0.30558			0.59											
01/27/23 18:00	0.31026			0.33162			0.64											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/27/23 19:00	0.28344			0.30468			0.59											
01/27/23 20:00	0.19566			0.1875			0.31											
01/27/23 21:00	0.17358			0	X		0.17											
01/27/23 22:00	0.17418			0	X		0.17											
01/27/23 23:00	0.17508			0	X		0.18											
01/28/23 0:00	0.17472			0	X		0.17											
01/28/23 1:00	0.17436			0	X		0.17											
01/28/23 2:00	0.1746			0	X		0.17											
01/28/23 3:00	0.1746			0	X		0.17											
01/28/23 4:00	0.17448			0	X		0.17											
01/28/23 5:00	0.1746			0	X		0.17											
01/28/23 6:00	0.17946			0	X		0.18											
01/28/23 7:00	0.17418			0	X		0.17											
01/28/23 8:00	0.17454			0	X		0.17											
01/28/23 9:00	0.17484			0	X		0.17											
01/28/23 10:00	0.17472			0	X		0.17											
01/28/23 11:00	0.1749			0	X		0.17											
01/28/23 12:00	0.17508			0	X		0.18											
01/28/23 13:00	0.17358			0	X		0.17											
01/28/23 14:00	0.1752			0	X		0.18											
01/28/23 15:00	0.1755			0	X		0.18											
01/28/23 16:00	0.1755			0	X		0.18											
01/28/23 17:00	0.17502			0	X		0.18											
01/28/23 18:00	0.17442			0	X		0.17											
01/28/23 19:00	0.17274			0	X		0.17											
01/28/23 20:00	0.17292			0	X		0.17											
01/28/23 21:00	0.17424			0	X		0.17											
01/28/23 22:00	0.1746			0	X		0.17											
01/28/23 23:00	0.17442			0	X		0.17											
01/29/23 0:00	0.17394			0	X		0.17											
01/29/23 1:00	0.1743			0	X		0.17											
01/29/23 2:00	0.1746			0	X		0.17											
01/29/23 3:00	0.17442			0	X		0.17											
01/29/23 4:00	0.17454			0	X		0.17											
01/29/23 5:00	0.17496			0	X		0.17											
01/29/23 6:00	0.17466			0	X		0.17											
01/29/23 7:00	0.17484			0	X		0.17											
01/29/23 8:00	0.20424			0	X		0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/29/23 9:00	0.25296			0.19404			0.4											
01/29/23 10:00	0.28878			0.30996			0.6											
01/29/23 11:00	0.30378			0.32538			0.63											
01/29/23 12:00	0.22884			0.22788			0.4											
01/29/23 13:00	0.17514			0	X		0.18											
01/29/23 14:00	0.17496			0	X		0.17											
01/29/23 15:00	0.17514			0	X		0.18											
01/29/23 16:00	0.1779			0	X		0.18											
01/29/23 17:00	0.17478			0	X		0.17											
01/29/23 18:00	0.17478			0	X		0.17											
01/29/23 19:00	0.17442			0	X		0.17											
01/29/23 20:00	0.17496			0	X		0.17											
01/29/23 21:00	0.17472			0	X		0.17											
01/29/23 22:00	0.17466			0	X		0.17											
01/29/23 23:00	0.1737			0	X		0.17											
01/30/23 0:00	0.17478			0	X		0.17											
01/30/23 1:00	0.17586			0	X		0.18											
01/30/23 2:00	0.246			0	X		0.25											
01/30/23 3:00	0.30534			0	X		0.31											
01/30/23 4:00	0.30456			0	X		0.3											
01/30/23 5:00	0.32058			0	X		0.32											
01/30/23 6:00	0.33876			0	X		0.34											
01/30/23 7:00	0.41376			0	X		0.41											
01/30/23 8:00	0.39312			0	X		0.39											
01/30/23 9:00	0.31326			0	X		0.31											
01/30/23 10:00	0.30102			0	X		0.3											
01/30/23 11:00	0.30156			0	X		0.3											
01/30/23 12:00	0.3033			0	X		0.3											
01/30/23 13:00	0.30384			0	X		0.3											
01/30/23 14:00	0.30576			0	X		0.31											
01/30/23 15:00	0.30528			0	X		0.31											
01/30/23 16:00	0.30468			0	X		0.3											
01/30/23 17:00	0.30228			0	X		0.3											
01/30/23 18:00	0.2982			0	X		0.3											
01/30/23 19:00	0.29736			0	X		0.3											
01/30/23 20:00	0.29928			0	X		0.3											
01/30/23 21:00	0.30066			0	X		0.3											
01/30/23 22:00	0.30108			0	X		0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
01/30/23 23:00	0.30216			0	X		0.3											
01/31/23 0:00	0.3024			0	X		0.3											
01/31/23 1:00	0.30366			0	X		0.3											
01/31/23 2:00	0.30432			0	X		0.3											
01/31/23 3:00	0.30426			0	X		0.3											
01/31/23 4:00	0.306			0	X		0.31											
01/31/23 5:00	0.30702			0	X		0.31											
01/31/23 6:00	0.31056			0	X		0.31											
01/31/23 7:00	0.31548			0	X		0.32											
01/31/23 8:00	0.30672			0	X		0.31											
01/31/23 9:00	0.30378			0	X		0.3											
01/31/23 10:00	0.30252			0	X		0.3											
01/31/23 11:00	0.3024			0	X		0.3											
01/31/23 12:00	0.30006			0	X		0.3											
01/31/23 13:00	0.26784			0	X		0.27											
01/31/23 14:00	0.17298			0	X		0.17											
01/31/23 15:00	0.2406			0	X		0.24											
01/31/23 16:00	0.3015			0	X		0.3											
01/31/23 17:00	0.29928			0	X		0.3											
01/31/23 18:00	0.29796			0	X		0.3											
01/31/23 19:00	0.2982			0	X		0.3											
01/31/23 20:00	0.29886			0	X		0.3											
01/31/23 21:00	0.30012			0	X		0.3											
01/31/23 22:00	0.30186			0	X		0.3											
01/31/23 23:00	0.30252			0	X		0.3											
02/01/23 0:00	0.30198			0	X		0.3											
02/01/23 1:00	0.30294			0	X		0.3											
02/01/23 2:00	0.30288			0	X		0.3											
02/01/23 3:00	0.30336			0	X		0.3											
02/01/23 4:00	0.30438			0	X		0.3											
02/01/23 5:00	0.30474			0	X		0.3											
02/01/23 6:00	0.30486			0	X		0.3											
02/01/23 7:00	0.30408			0	X		0.3											
02/01/23 8:00	0.30456			0	X		0.3											
02/01/23 9:00	0.30276			0	X		0.3											
02/01/23 10:00	0.21816			0	X		0.22											
02/01/23 11:00	0.17742			0	X		0.18											
02/01/23 12:00	0.17784			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/01/23 13:00	0.17778			0	X		0.18											
02/01/23 14:00	0.17598			0	X		0.18											
02/01/23 15:00	0.1743			0	X		0.17											
02/01/23 16:00	0.17376			0	X		0.17											
02/01/23 17:00	0.17394			0	X		0.17											
02/01/23 18:00	0.17376			0	X		0.17											
02/01/23 19:00	0.17298			0	X		0.17											
02/01/23 20:00	0.17274			0	X		0.17											
02/01/23 21:00	0.17244			0	X		0.17											
02/01/23 22:00	0.17202			0	X		0.17											
02/01/23 23:00	0.17196			0	X		0.17											
02/02/23 0:00	0.17226			0	X		0.17											
02/02/23 1:00	0.17652			0	X		0.18											
02/02/23 2:00	0.17592			0	X		0.18											
02/02/23 3:00	0.17586			0	X		0.18											
02/02/23 4:00	0.17568			0	X		0.18											
02/02/23 5:00	0.17598			0	X		0.18											
02/02/23 6:00	0.17682			0	X		0.18											
02/02/23 7:00	0.17634			0	X		0.18											
02/02/23 8:00	0.1761			0	X		0.18											
02/02/23 9:00	0.17616			0	X		0.18											
02/02/23 10:00	0.17574			0	X		0.18											
02/02/23 11:00	0.17382			0	X		0.17											
02/02/23 12:00	0.1737			0	X		0.17											
02/02/23 13:00	0.17352			0	X		0.17											
02/02/23 14:00	0.17322			0	X		0.17											
02/02/23 15:00	0.17286			0	X		0.17											
02/02/23 16:00	0.1728			0	X		0.17											
02/02/23 17:00	0.17316			0	X		0.17											
02/02/23 18:00	0.1731			0	X		0.17											
02/02/23 19:00	0.17202			0	X		0.17											
02/02/23 20:00	0.17214			0	X		0.17											
02/02/23 21:00	0.17442			0	X		0.17											
02/02/23 22:00	0.17358			0	X		0.17											
02/02/23 23:00	0.1731			0	X		0.17											
02/03/23 0:00	0.17268			0	X		0.17											
02/03/23 1:00	0.17466			0	X		0.17											
02/03/23 2:00	0.17412			0	X		0.17											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 3:00	0.1725			0	X		0.17											
02/03/23 4:00	0.17172			0	X		0.17											
02/03/23 5:00	0.17208			0	X		0.17											
02/03/23 6:00	0.17244			0	X		0.17											
02/03/23 7:00	0.20106			0	X		0.2											
02/03/23 8:00	0.19644			0	X		0.2											
02/03/23 9:00	0.17226			0	X		0.17											
02/03/23 10:00	0.17514			0	X		0.18											
02/03/23 11:00	0.24018			0	X		0.24											
02/03/23 12:00	0.30078			0	X		0.3											
02/03/23 13:00	0.30066			0	X		0.3											
02/03/23 14:00	0.30054			0	X		0.3											
02/03/23 15:00	0.29454			0	X		0.29											
02/03/23 16:00	0.21852			0.16956			0.36											
02/03/23 17:00	0.25974			0.279			0.54											
02/03/23 18:00	0.32118			0.34218			0.66											
02/03/23 19:00	0.33078			0.35154			0.68											
02/03/23 20:00	0.33042			0.35052			0.68											
02/03/23 21:00	0.31434			0.3348			0.65											
02/03/23 22:00	0.3117			0.3324			0.64											
02/03/23 23:00	0.27822			0.29982			0.58											
02/04/23 0:00	0.14706			0.20226			0.24											
02/04/23 1:00	0	X		0.18768			0.19											
02/04/23 2:00	0	X		0.18762			0.19											
02/04/23 3:00	0	X		0.18672			0.19											
02/04/23 4:00	0	X		0.1893			0.19											
02/04/23 5:00	0	X		0.18702			0.19											
02/04/23 6:00	0	X		0.18906			0.19											
02/04/23 7:00	0	X		0.1872			0.19											
02/04/23 8:00	0	X		0.18648			0.19											
02/04/23 9:00	0	X		0.18798			0.19											
02/04/23 10:00	0	X		0.18582			0.19											
02/04/23 11:00	0	X		0.18516			0.19											
02/04/23 12:00	0	X		0.1857			0.19											
02/04/23 13:00	0	X		0.1854			0.19											
02/04/23 14:00	0	X		0.1854			0.19											
02/04/23 15:00	0	X		0.21324			0.21											
02/04/23 16:00	0.15822			0.23994			0.38											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/04/23 17:00	0.25914			0.27846			0.54											
02/04/23 18:00	0.32094			0.34254			0.66											
02/04/23 19:00	0.32496			0.34626			0.67											
02/04/23 20:00	0.33012			0.35172			0.68											
02/04/23 21:00	0.3294			0.35112			0.68											
02/04/23 22:00	0.27276			0.29292			0.57											
02/04/23 23:00	0.1413			0.2034			0.24											
02/05/23 0:00	0	X		0.18822			0.19											
02/05/23 1:00	0	X		0.18726			0.19											
02/05/23 2:00	0	X		0.18738			0.19											
02/05/23 3:00	0	X		0.18852			0.19											
02/05/23 4:00	0	X		0.18882			0.19											
02/05/23 5:00	0	X		0.18876			0.19											
02/05/23 6:00	0	X		0.189			0.19											
02/05/23 7:00	0	X		0.18924			0.19											
02/05/23 8:00	0	X		0.189			0.19											
02/05/23 9:00	0	X		0.18852			0.19											
02/05/23 10:00	0	X		0.18726			0.19											
02/05/23 11:00	0	X		0.18744			0.19											
02/05/23 12:00	0	X		0.18744			0.19											
02/05/23 13:00	0	X		0.18702			0.19											
02/05/23 14:00	0	X		0.18696			0.19											
02/05/23 15:00	0	X		0.18666			0.19											
02/05/23 16:00	0	X		0.1869			0.19											
02/05/23 17:00	0.01914			0.22002			0.22											
02/05/23 18:00	0.16998			0.2172			0.39											
02/05/23 19:00	0.19788			0.21276			0.41											
02/05/23 20:00	0.28254			0.30354			0.59											
02/05/23 21:00	0.27378			0.29508			0.57											
02/05/23 22:00	0.15624			0.20058			0.28											
02/05/23 23:00	0	X		0.18684			0.19											
02/06/23 0:00	0	X		0.18714			0.19											
02/06/23 1:00	0	X		0.18678			0.19											
02/06/23 2:00	0	X		0.18756			0.19											
02/06/23 3:00	0	X		0.18636			0.19											
02/06/23 4:00	0	X		0.1857			0.19											
02/06/23 5:00	0	X		0.1854			0.19											
02/06/23 6:00	0	X		0.1857			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/06/23 7:00	0	X		0.18588			0.19											
02/06/23 8:00	0	X		0.18612			0.19											
02/06/23 9:00	0	X		0.18666			0.19											
02/06/23 10:00	0	X		0.18624			0.19											
02/06/23 11:00	0	X		0.18594			0.19											
02/06/23 12:00	0	X		0.18576			0.19											
02/06/23 13:00	0	X		0.1854			0.19											
02/06/23 14:00	0	X		0.18594			0.19											
02/06/23 15:00	0.03066			0.21906			0.22											
02/06/23 16:00	0.17622			0.20922			0.39											
02/06/23 17:00	0.29778			0.31884			0.62											
02/06/23 18:00	0.32934			0.35136			0.68											
02/06/23 19:00	0.32904			0.35094			0.68											
02/06/23 20:00	0.34878			0.37056			0.72											
02/06/23 21:00	0.3198			0.34152			0.66											
02/06/23 22:00	0.26598			0.28608			0.55											
02/06/23 23:00	0.17142			0.20946			0.3											
02/07/23 0:00	0	X		0.18774			0.19											
02/07/23 1:00	0	X		0.18708			0.19											
02/07/23 2:00	0	X		0.18714			0.19											
02/07/23 3:00	0	X		0.18762			0.19											
02/07/23 4:00	0	X		0.1872			0.19											
02/07/23 5:00	0	X		0.1872			0.19											
02/07/23 6:00	0	X		0.18762			0.19											
02/07/23 7:00	0	X		0.19044			0.19											
02/07/23 8:00	0	X		0.1872			0.19											
02/07/23 9:00	0	X		0.1866			0.19											
02/07/23 10:00	0	X		0.18672			0.19											
02/07/23 11:00	0	X		0.18684			0.19											
02/07/23 12:00	0	X		0.18672			0.19											
02/07/23 13:00	0	X		0.18696			0.19											
02/07/23 14:00	0	X		0.18702			0.19											
02/07/23 15:00	0.04686			0.22014			0.23											
02/07/23 16:00	0.19308			0.22344			0.42											
02/07/23 17:00	0.3003			0.32142			0.62											
02/07/23 18:00	0.336			0.35676			0.69											
02/07/23 19:00	0.3405			0.3621			0.7											
02/07/23 20:00	0.34794			0.36912			0.72											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/07/23 21:00	0.339			0.36108			0.7											
02/07/23 22:00	0.32898			0.3507			0.68											
02/07/23 23:00	0.31608			0.33798			0.65											
02/08/23 0:00	0.27882			0.30072			0.58											
02/08/23 1:00	0.2787			0.3006			0.58											
02/08/23 2:00	0.27204			0.29376			0.57											
02/08/23 3:00	0.26892			0.29016			0.56											
02/08/23 4:00	0.27402			0.2958			0.57											
02/08/23 5:00	0.28476			0.30708			0.59											
02/08/23 6:00	0.33582			0.35784			0.69											
02/08/23 7:00	0.29268			0.31248			0.61											
02/08/23 8:00	0.19962			0.18978			0.27											
02/08/23 9:00	0.17532			0	X		0.18											
02/08/23 10:00	0.17514			0	X		0.18											
02/08/23 11:00	0.17574			0	X		0.18											
02/08/23 12:00	0.17646			0	X		0.18											
02/08/23 13:00	0.17634			0	X		0.18											
02/08/23 14:00	0.17616			0	X		0.18											
02/08/23 15:00	0.20628			0.01458			0.21											
02/08/23 16:00	0.21036			0.19206			0.4											
02/08/23 17:00	0.30366			0.32856			0.63											
02/08/23 18:00	0.35286			0.37398			0.73											
02/08/23 19:00	0.34026			0.36186			0.7											
02/08/23 20:00	0.32994			0.3519			0.68											
02/08/23 21:00	0.35526			0.37662			0.73											
02/08/23 22:00	0.33726			0.35922			0.7											
02/08/23 23:00	0.30486			0.32706			0.63											
02/09/23 0:00	0.28836			0.3114			0.6											
02/09/23 1:00	0.28026			0.30312			0.58											
02/09/23 2:00	0.28854			0.31206			0.6											
02/09/23 3:00	0.28788			0.3114			0.6											
02/09/23 4:00	0.28134			0.30354			0.58											
02/09/23 5:00	0.34032			0.36252			0.7											
02/09/23 6:00	0.35562			0.37662			0.73											
02/09/23 7:00	0.27324			0.29394			0.57											
02/09/23 8:00	0.18864			0.15798			0.24											
02/09/23 9:00	0.1749			0	X		0.17											
02/09/23 10:00	0.17616			0	X		0.18											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 11:00	0.17646			0	X		0.18											
02/09/23 12:00	0.17532			0	X		0.18											
02/09/23 13:00	0.174			0	X		0.17											
02/09/23 14:00	0.17394			0	X		0.17											
02/09/23 15:00	0.18438			0	X		0.18											
02/09/23 16:00	0.20748			0.16386			0.36											
02/09/23 17:00	0.27954			0.2997			0.58											
02/09/23 18:00	0.35304			0.3738			0.73											
02/09/23 19:00	0.33252			0.35388			0.69											
02/09/23 20:00	0.34668			0.36762			0.71											
02/09/23 21:00	0.3504			0.37056			0.72											
02/09/23 22:00	0.33432			0.35574			0.69											
02/09/23 23:00	0.24288			0.25254			0.5											
02/10/23 0:00	0.18636			0	X		0.19											
02/10/23 1:00	0.17544			0	X		0.18											
02/10/23 2:00	0.17544			0	X		0.18											
02/10/23 3:00	0.17538			0	X		0.18											
02/10/23 4:00	0.17586			0	X		0.18											
02/10/23 5:00	0.1755			0	X		0.18											
02/10/23 6:00	0.17862			0	X		0.18											
02/10/23 7:00	0.17562			0	X		0.18											
02/10/23 8:00	0.17574			0	X		0.18											
02/10/23 9:00	0.17592			0	X		0.18											
02/10/23 10:00	0.17634			0	X		0.18											
02/10/23 11:00	0.17634			0	X		0.18											
02/10/23 12:00	0.17676			0	X		0.18											
02/10/23 13:00	0.17706			0	X		0.18											
02/10/23 14:00	0.17718			0	X		0.18											
02/10/23 15:00	0.20664			0.02304			0.21											
02/10/23 16:00	0.19866			0.1899			0.39											
02/10/23 17:00	0.27882			0.29826			0.58											
02/10/23 18:00	0.31044			0.33156			0.64											
02/10/23 19:00	0.31062			0.3321			0.64											
02/10/23 20:00	0.31896			0.34044			0.66											
02/10/23 21:00	0.32154			0.34368			0.67											
02/10/23 22:00	0.32286			0.34536			0.67											
02/10/23 23:00	0.31104			0.3348			0.65											
02/11/23 0:00	0.31758			0.34134			0.66											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 1:00	0.31134			0.33516			0.65								
02/11/23 2:00	0.3072			0.3297			0.64								
02/11/23 3:00	0.3072			0.32988			0.64								
02/11/23 4:00	0.30684			0.32898			0.64								
02/11/23 5:00	0.31098			0.33282			0.64								
02/11/23 6:00	0.31152			0.33288			0.64								
02/11/23 7:00	0.29118			0.31356			0.6								
02/11/23 8:00	0.1785			0.22812			0.37								
02/11/23 9:00	0	X		0.19614			0.2								
02/11/23 10:00	0	X		0.18696			0.19								
02/11/23 11:00	0	X		0.18708			0.19								
02/11/23 12:00	0	X		0.18738			0.19								
02/11/23 13:00	0	X		0.18756			0.19								
02/11/23 14:00	0	X		0.18768			0.19								
02/11/23 15:00	0	X		0.22026			0.22								
02/11/23 16:00	0.16434			0.2244			0.39								
02/11/23 17:00	0.27618			0.29628			0.57								
02/11/23 18:00	0.31686			0.3393			0.66								
02/11/23 19:00	0.31428			0.33768			0.65								
02/11/23 20:00	0.31584			0.33924			0.66								
02/11/23 21:00	0.32598			0.34848			0.67								
02/11/23 22:00	0.32766			0.34962			0.68								
02/11/23 23:00	0.31578			0.33768			0.65								
02/12/23 0:00	0.33054			0.35184			0.68								
02/12/23 1:00	0.3285			0.3495			0.68								
02/12/23 2:00	0.32232			0.34386			0.67								
02/12/23 3:00	0.3306			0.35238			0.68								
02/12/23 4:00	0.33126			0.35352			0.68								
02/12/23 5:00	0.32964			0.35166			0.68								
02/12/23 6:00	0.32448			0.34614			0.67								
02/12/23 7:00	0.27072			0.291			0.56								
02/12/23 8:00	0.20514			0.19578			0.32								
02/12/23 9:00	0.17484			0	X		0.17								
02/12/23 10:00	0.1752			0	X		0.18								
02/12/23 11:00	0.17562			0	X		0.18								
02/12/23 12:00	0.1758			0	X		0.18								
02/12/23 13:00	0.17514			0	X		0.18								
02/12/23 14:00	0.17334			0	X		0.17								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/12/23 15:00	0.23358			0.14238			0.3											
02/12/23 16:00	0.23568			0.25344			0.49											
02/12/23 17:00	0.3267			0.34374			0.67											
02/12/23 18:00	0.3135			0.33264			0.65											
02/12/23 19:00	0.32802			0.34758			0.68											
02/12/23 20:00	0.33414			0.35412			0.69											
02/12/23 21:00	0.30198			0.3234			0.63											
02/12/23 22:00	0.23082			0.2481			0.48											
02/12/23 23:00	0.19932			0.21438			0.41											
02/13/23 0:00	0.17562			0.21858			0.35											
02/13/23 1:00	0	X		0.1869			0.19											
02/13/23 2:00	0	X		0.18744			0.19											
02/13/23 3:00	0	X		0.1875			0.19											
02/13/23 4:00	0	X		0.1875			0.19											
02/13/23 5:00	0	X		0.18804			0.19											
02/13/23 6:00	0	X		0.18846			0.19											
02/13/23 7:00	0	X		0.19548			0.2											
02/13/23 8:00	0	X		0.18798			0.19											
02/13/23 9:00	0	X		0.18774			0.19											
02/13/23 10:00	0	X		0.1875			0.19											
02/13/23 11:00	0	X		0.18798			0.19											
02/13/23 12:00	0	X		0.18768			0.19											
02/13/23 13:00	0	X		0.18642			0.19											
02/13/23 14:00	0	X		0.18534			0.19											
02/13/23 15:00	0	X		0.1854			0.19											
02/13/23 16:00	0	X		0.18558			0.19											
02/13/23 17:00	0	X		0.18552			0.19											
02/13/23 18:00	0	X		0.18546			0.19											
02/13/23 19:00	0	X		0.18576			0.19											
02/13/23 20:00	0	X		0.18594			0.19											
02/13/23 21:00	0	X		0.18654			0.19											
02/13/23 22:00	0	X		0.18702			0.19											
02/13/23 23:00	0	X		0.1872			0.19											
02/14/23 0:00	0	X		0.18762			0.19											
02/14/23 1:00	0	X		0.1881			0.19											
02/14/23 2:00	0	X		0.18816			0.19											
02/14/23 3:00	0	X		0.1884			0.19											
02/14/23 4:00	0	X		0.18822			0.19											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 5:00	0	X		0.18822			0.19											
02/14/23 6:00	0	X		0.18672			0.19											
02/14/23 7:00	0	X		0.18666			0.19											
02/14/23 8:00	0	X		0.1863			0.19											
02/14/23 9:00	0	X		0.186			0.19											
02/14/23 10:00	0	X		0.18594			0.19											
02/14/23 11:00	0	X		0.18606			0.19											
02/14/23 12:00	0	X		0.18714			0.19											
02/14/23 13:00	0	X		0.18768			0.19											
02/14/23 14:00	0	X		0.20184			0.2											
02/14/23 15:00	0.13344			0.28326			0.34											
02/14/23 16:00	0.26292			0.28326			0.55											
02/14/23 17:00	0.35604			0.3774			0.73											
02/14/23 18:00	0.3639			0.38556			0.75											
02/14/23 19:00	0.34362			0.36636			0.71											
02/14/23 20:00	0.35676			0.37974			0.74											
02/14/23 21:00	0.33732			0.36048			0.7											
02/14/23 22:00	0.3183			0.34128			0.66											
02/14/23 23:00	0.33258			0.35544			0.69											
02/15/23 0:00	0.32922			0.35148			0.68											
02/15/23 1:00	0.32754			0.34944			0.68											
02/15/23 2:00	0.32694			0.34902			0.68											
02/15/23 3:00	0.33378			0.35616			0.69											
02/15/23 4:00	0.35094			0.3744			0.73											
02/15/23 5:00	0.3528			0.37584			0.73											
02/15/23 6:00	0.3639			0.37902			0.71											
02/15/23 7:00	0.35838			0.19056			0.46											
02/15/23 8:00	0.2082			0.24444			0.4											
02/15/23 9:00	0	X		0.20544			0.21											
02/15/23 10:00	0	X		0.18684			0.19											
02/15/23 11:00	0	X		0.18618			0.19											
02/15/23 12:00	0	X		0.18552			0.19											
02/15/23 13:00	0	X		0.18552			0.19											
02/15/23 14:00	0	X		0.18564			0.19											
02/15/23 15:00	0	X		0.1968			0.2											
02/15/23 16:00	0.15294			0.25008			0.36											
02/15/23 17:00	0.26496			0.28512			0.55											
02/15/23 18:00	0.36228			0.3828			0.75											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/15/23 19:00	0.3621			0.38436			0.75											
02/15/23 20:00	0.36138			0.38406			0.75											
02/15/23 21:00	0.36432			0.38712			0.75											
02/15/23 22:00	0.36168			0.38346			0.75											
02/15/23 23:00	0.33864			0.36042			0.7											
02/16/23 0:00	0.28908			0.31134			0.6											
02/16/23 1:00	0.28938			0.31194			0.6											
02/16/23 2:00	0.29022			0.31272			0.6											
02/16/23 3:00	0.29004			0.31296			0.6											
02/16/23 4:00	0.28956			0.3126			0.6											
02/16/23 5:00	0.28932			0.3126			0.6											
02/16/23 6:00	0.28848			0.3117			0.6											
02/16/23 7:00	0.30978			0.3324			0.64											
02/16/23 8:00	0.22824			0.25596			0.48											
02/16/23 9:00	0	X		0.2082			0.21											
02/16/23 10:00	0	X		0.1881			0.19											
02/16/23 11:00	0	X		0.18816			0.19											
02/16/23 12:00	0	X		0.1902			0.19											
02/16/23 13:00	0	X		0.18864			0.19											
02/16/23 14:00	0	X		0.18852			0.19											
02/16/23 15:00	0	X		0.19998			0.2											
02/16/23 16:00	0.15306			0.24354			0.36											
02/16/23 17:00	0.23886			0.25686			0.5											
02/16/23 18:00	0.30192			0.32298			0.62											
02/16/23 19:00	0.31578			0.33828			0.65											
02/16/23 20:00	0.32478			0.34788			0.67											
02/16/23 21:00	0.32802			0.35076			0.68											
02/16/23 22:00	0.3336			0.35628			0.69											
02/16/23 23:00	0.31878			0.34128			0.66											
02/17/23 0:00	0.32142			0.34446			0.67											
02/17/23 1:00	0.30618			0.32868			0.63											
02/17/23 2:00	0.30606			0.32904			0.64											
02/17/23 3:00	0.1989			0.22428			0.42											
02/17/23 4:00	0.0006			0.20388			0.2											
02/17/23 5:00	0	X		0.18822			0.19											
02/17/23 6:00	0	X		0.18696			0.19											
02/17/23 7:00	0	X		0.18618			0.19											
02/17/23 8:00	0	X		0.1854			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/17/23 9:00	0	X		0.18522			0.19											
02/17/23 10:00	0	X		0.18594			0.19											
02/17/23 11:00	0	X		0.1938			0.19											
02/17/23 12:00	0	X		0.22386			0.22											
02/17/23 13:00	0	X		0.18858			0.19											
02/17/23 14:00	0	X		0.18804			0.19											
02/17/23 15:00	0	X		0.18648			0.19											
02/17/23 16:00	0	X		0.1872			0.19											
02/17/23 17:00	0	X		0.18714			0.19											
02/17/23 18:00	0	X		0.18816			0.19											
02/17/23 19:00	0	X		0.18816			0.19											
02/17/23 20:00	0	X		0.18834			0.19											
02/17/23 21:00	0	X		0.1884			0.19											
02/17/23 22:00	0	X		0.1884			0.19											
02/17/23 23:00	0	X		0.18822			0.19											
02/18/23 0:00	0	X		0.18786			0.19											
02/18/23 1:00	0	X		0.18654			0.19											
02/18/23 2:00	0	X		0.18654			0.19											
02/18/23 3:00	0	X		0.18666			0.19											
02/18/23 4:00	0	X		0.1869			0.19											
02/18/23 5:00	0	X		0.1866			0.19											
02/18/23 6:00	0	X		0.18612			0.19											
02/18/23 7:00	0	X		0.18642			0.19											
02/18/23 8:00	0	X		0.18618			0.19											
02/18/23 9:00	0	X		0.1866			0.19											
02/18/23 10:00	0	X		0.1863			0.19											
02/18/23 11:00	0	X		0.1863			0.19											
02/18/23 12:00	0	X		0.18618			0.19											
02/18/23 13:00	0	X		0.18612			0.19											
02/18/23 14:00	0	X		0.186			0.19											
02/18/23 15:00	0	X		0.18594			0.19											
02/18/23 16:00	0	X		0.18654			0.19											
02/18/23 17:00	0	X		0.18624			0.19											
02/18/23 18:00	0	X		0.18624			0.19											
02/18/23 19:00	0	X		0.18636			0.19											
02/18/23 20:00	0	X		0.18636			0.19											
02/18/23 21:00	0	X		0.18588			0.19											
02/18/23 22:00	0	X		0.1857			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/18/23 23:00	0	X		0.18594			0.19											
02/19/23 0:00	0	X		0.18582			0.19											
02/19/23 1:00	0	X		0.186			0.19											
02/19/23 2:00	0	X		0.18594			0.19											
02/19/23 3:00	0	X		0.18636			0.19											
02/19/23 4:00	0	X		0.1866			0.19											
02/19/23 5:00	0	X		0.18684			0.19											
02/19/23 6:00	0	X		0.18762			0.19											
02/19/23 7:00	0	X		0.18774			0.19											
02/19/23 8:00	0	X		0.1878			0.19											
02/19/23 9:00	0	X		0.18762			0.19											
02/19/23 10:00	0	X		0.18774			0.19											
02/19/23 11:00	0	X		0.18732			0.19											
02/19/23 12:00	0	X		0.18708			0.19											
02/19/23 13:00	0	X		0.18636			0.19											
02/19/23 14:00	0	X		0.18444			0.18											
02/19/23 15:00	0	X		0.1863			0.19											
02/19/23 16:00	0	X		0.18438			0.18											
02/19/23 17:00	0	X		0.18456			0.18											
02/19/23 18:00	0	X		0.18768			0.19											
02/19/23 19:00	0	X		0.18684			0.19											
02/19/23 20:00	0	X		0.18612			0.19											
02/19/23 21:00	0	X		0.18618			0.19											
02/19/23 22:00	0	X		0.18678			0.19											
02/19/23 23:00	0	X		0.18762			0.19											
02/20/23 0:00	0	X		0.18792			0.19											
02/20/23 1:00	0	X		0.18846			0.19											
02/20/23 2:00	0	X		0.18822			0.19											
02/20/23 3:00	0	X		0.1881			0.19											
02/20/23 4:00	0	X		0.18828			0.19											
02/20/23 5:00	0	X		0.18846			0.19											
02/20/23 6:00	0	X		0.1887			0.19											
02/20/23 7:00	0	X		0.20934			0.21											
02/20/23 8:00	0	X		0.1884			0.19											
02/20/23 9:00	0	X		0.18894			0.19											
02/20/23 10:00	0	X		0.189			0.19											
02/20/23 11:00	0	X		0.18678			0.19											
02/20/23 12:00	0	X		0.18756			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/20/23 13:00	0	X		0.1863			0.19											
02/20/23 14:00	0	X		0.18612			0.19											
02/20/23 15:00	0.02598			0.21792			0.22											
02/20/23 16:00	0.16926			0.21858			0.39											
02/20/23 17:00	0.30276			0.32154			0.62											
02/20/23 18:00	0.3318			0.35082			0.68											
02/20/23 19:00	0.3324			0.35304			0.69											
02/20/23 20:00	0.33066			0.35172			0.68											
02/20/23 21:00	0.31962			0.33984			0.66											
02/20/23 22:00	0.27012			0.2898			0.56											
02/20/23 23:00	0.19098			0.15708			0.23											
02/21/23 0:00	0.17532			0		X	0.18											
02/21/23 1:00	0.1752			0		X	0.18											
02/21/23 2:00	0.17544			0		X	0.18											
02/21/23 3:00	0.1752			0		X	0.18											
02/21/23 4:00	0.17496			0		X	0.17											
02/21/23 5:00	0.17514			0		X	0.18											
02/21/23 6:00	0.17502			0		X	0.18											
02/21/23 7:00	0.17484			0		X	0.17											
02/21/23 8:00	0.17556			0		X	0.18											
02/21/23 9:00	0.17508			0		X	0.18											
02/21/23 10:00	0.17532			0		X	0.18											
02/21/23 11:00	0.17574			0		X	0.18											
02/21/23 12:00	0.17616			0		X	0.18											
02/21/23 13:00	0.17628			0		X	0.18											
02/21/23 14:00	0.17562			0		X	0.18											
02/21/23 15:00	0.1743			0		X	0.17											
02/21/23 16:00	0.1728			0		X	0.17											
02/21/23 17:00	0.17148			0		X	0.17											
02/21/23 18:00	0.17142			0		X	0.17											
02/21/23 19:00	0.17364			0		X	0.17											
02/21/23 20:00	0.17352			0		X	0.17											
02/21/23 21:00	0.17388			0		X	0.17											
02/21/23 22:00	0.1743			0		X	0.17											
02/21/23 23:00	0.1746			0		X	0.17											
02/22/23 0:00	0.17418			0		X	0.17											
02/22/23 1:00	0.17436			0		X	0.17											
02/22/23 2:00	0.17424			0		X	0.17											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/22/23 3:00	0.17376			0	X		0.17											
02/22/23 4:00	0.17388			0	X		0.17											
02/22/23 5:00	0.17304			0	X		0.17											
02/22/23 6:00	0.18012			0	X		0.18											
02/22/23 7:00	0.1734			0	X		0.17											
02/22/23 8:00	0.17304			0	X		0.17											
02/22/23 9:00	0.17352			0	X		0.17											
02/22/23 10:00	0.17442			0	X		0.17											
02/22/23 11:00	0.1749			0	X		0.17											
02/22/23 12:00	0.17514			0	X		0.18											
02/22/23 13:00	0.17472			0	X		0.17											
02/22/23 14:00	0.1746			0	X		0.17											
02/22/23 15:00	0.20436			0	X		0.2											
02/22/23 16:00	0.237			0.18792			0.4											
02/22/23 17:00	0.26826			0.29004			0.56											
02/22/23 18:00	0.33396			0.35538			0.69											
02/22/23 19:00	0.33372			0.35562			0.69											
02/22/23 20:00	0.33186			0.35514			0.69											
02/22/23 21:00	0.32376			0.34734			0.67											
02/22/23 22:00	0.27006			0.29196			0.56											
02/22/23 23:00	0.25782			0.27882			0.54											
02/23/23 0:00	0.3186			0.34182			0.66											
02/23/23 1:00	0.3606			0.38388			0.74											
02/23/23 2:00	0.3507			0.3738			0.72											
02/23/23 3:00	0.35772			0.38106			0.74											
02/23/23 4:00	0.35328			0.37614			0.73											
02/23/23 5:00	0.35232			0.3753			0.73											
02/23/23 6:00	0.36132			0.38442			0.75											
02/23/23 7:00	0.30984			0.3333			0.64											
02/23/23 8:00	0.31086			0.33426			0.65											
02/23/23 9:00	0.30744			0.3306			0.64											
02/23/23 10:00	0.30834			0.33042			0.64											
02/23/23 11:00	0.31116			0.33336			0.64											
02/23/23 12:00	0.2682			0.2886			0.56											
02/23/23 13:00	0.1956			0.1509			0.24											
02/23/23 14:00	0.17532			0	X		0.18											
02/23/23 15:00	0.17454			0	X		0.17											
02/23/23 16:00	0.17412			0	X		0.17											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 17:00	0.17394			0	X		0.17											
02/23/23 18:00	0.1737			0	X		0.17											
02/23/23 19:00	0.18474			0	X		0.18											
02/23/23 20:00	0.28422			0	X		0.28											
02/23/23 21:00	0.28926			0	X		0.29											
02/23/23 22:00	0.2841			0	X		0.28											
02/23/23 23:00	0.2823			0	X		0.28											
02/24/23 0:00	0.28422			0	X		0.28											
02/24/23 1:00	0.2868			0	X		0.29											
02/24/23 2:00	0.28266			0	X		0.28											
02/24/23 3:00	0.28344			0	X		0.28											
02/24/23 4:00	0.28704			0	X		0.29											
02/24/23 5:00	0.3168			0	X		0.32											
02/24/23 6:00	0.3408			0	X		0.34											
02/24/23 7:00	0.2847			0	X		0.28											
02/24/23 8:00	0.28308			0	X		0.28											
02/24/23 9:00	0.28524			0	X		0.29											
02/24/23 10:00	0.29118			0	X		0.29											
02/24/23 11:00	0.28974			0	X		0.29											
02/24/23 12:00	0.28536			0	X		0.29											
02/24/23 13:00	0.28386			0	X		0.28											
02/24/23 14:00	0.28422			0	X		0.28											
02/24/23 15:00	0.28404			0	X		0.28											
02/24/23 16:00	0.28428			0	X		0.28											
02/24/23 17:00	0.28488			0	X		0.28											
02/24/23 18:00	0.2853			0	X		0.29											
02/24/23 19:00	0.28572			0	X		0.29											
02/24/23 20:00	0.28332			0	X		0.28											
02/24/23 21:00	0.28326			0	X		0.28											
02/24/23 22:00	0.28224			0	X		0.28											
02/24/23 23:00	0.28098			0	X		0.28											
02/25/23 0:00	0.28524			0	X		0.29											
02/25/23 1:00	0.28956			0	X		0.29											
02/25/23 2:00	0.28956			0	X		0.29											
02/25/23 3:00	0.28932			0	X		0.29											
02/25/23 4:00	0.29154			0	X		0.29											
02/25/23 5:00	0.288			0	X		0.29											
02/25/23 6:00	0.18234			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/25/23 7:00	0.17592			0	X		0.18											
02/25/23 8:00	0.17586			0	X		0.18											
02/25/23 9:00	0.17598			0	X		0.18											
02/25/23 10:00	0.1758			0	X		0.18											
02/25/23 11:00	0.17622			0	X		0.18											
02/25/23 12:00	0.17592			0	X		0.18											
02/25/23 13:00	0.17568			0	X		0.18											
02/25/23 14:00	0.17604			0	X		0.18											
02/25/23 15:00	0.17598			0	X		0.18											
02/25/23 16:00	0.1761			0	X		0.18											
02/25/23 17:00	0.17598			0	X		0.18											
02/25/23 18:00	0.1758			0	X		0.18											
02/25/23 19:00	0.17604			0	X		0.18											
02/25/23 20:00	0.1761			0	X		0.18											
02/25/23 21:00	0.17472			0	X		0.17											
02/25/23 22:00	0.1752			0	X		0.18											
02/25/23 23:00	0.17544			0	X		0.18											
02/26/23 0:00	0.17508			0	X		0.18											
02/26/23 1:00	0.1752			0	X		0.18											
02/26/23 2:00	0.17556			0	X		0.18											
02/26/23 3:00	0.17496			0	X		0.17											
02/26/23 4:00	0.1746			0	X		0.17											
02/26/23 5:00	0.17436			0	X		0.17											
02/26/23 6:00	0.17442			0	X		0.17											
02/26/23 7:00	0.17472			0	X		0.17											
02/26/23 8:00	0.17448			0	X		0.17											
02/26/23 9:00	0.17412			0	X		0.17											
02/26/23 10:00	0.17406			0	X		0.17											
02/26/23 11:00	0.174			0	X		0.17											
02/26/23 12:00	0.17412			0	X		0.17											
02/26/23 13:00	0.17406			0	X		0.17											
02/26/23 14:00	0.17424			0	X		0.17											
02/26/23 15:00	0.17424			0	X		0.17											
02/26/23 16:00	0.17472			0	X		0.17											
02/26/23 17:00	0.1743			0	X		0.17											
02/26/23 18:00	0.1737			0	X		0.17											
02/26/23 19:00	0.174			0	X		0.17											
02/26/23 20:00	0.17454			0	X		0.17											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
02/26/23 21:00	0.1752			0	X		0.18											
02/26/23 22:00	0.17412			0	X		0.17											
02/26/23 23:00	0.17496			0	X		0.17											
02/27/23 0:00	0.17592			0	X		0.18											
02/27/23 1:00	0.17598			0	X		0.18											
02/27/23 2:00	0.17514			0	X		0.18											
02/27/23 3:00	0.17448			0	X		0.17											
02/27/23 4:00	0.17436			0	X		0.17											
02/27/23 5:00	0.17436			0	X		0.17											
02/27/23 6:00	0.1737			0	X		0.17											
02/27/23 7:00	0.17334			0	X		0.17											
02/27/23 8:00	0.17256			0	X		0.17											
02/27/23 9:00	0.17148			0	X		0.17											
02/27/23 10:00	0.17208			0	X		0.17											
02/27/23 11:00	0.17232			0	X		0.17											
02/27/23 12:00	0.17244			0	X		0.17											
02/27/23 13:00	0.17352			0	X		0.17											
02/27/23 14:00	0.174			0	X		0.17											
02/27/23 15:00	0.17358			0	X		0.17											
02/27/23 16:00	0.18426			0	X		0.18											
02/27/23 17:00	0.25512			0.16296			0.34											
02/27/23 18:00	0.26178			0.28284			0.54											
02/27/23 19:00	0.32928			0.35196			0.68											
02/27/23 20:00	0.3282			0.35154			0.68											
02/27/23 21:00	0.32268			0.34632			0.67											
02/27/23 22:00	0.26868			0.28992			0.56											
02/27/23 23:00	0.19752			0.15318			0.24											
02/28/23 0:00	0.17508			0	X		0.18											
02/28/23 1:00	0.17502			0	X		0.18											
02/28/23 2:00	0.17514			0	X		0.18											
02/28/23 3:00	0.1752			0	X		0.18											
02/28/23 4:00	0.17502			0	X		0.18											
02/28/23 5:00	0.17448			0	X		0.17											
02/28/23 6:00	0.17388			0	X		0.17											
02/28/23 7:00	0.17352			0	X		0.17											
02/28/23 8:00	0.17358			0	X		0.17											
02/28/23 9:00	0.1737			0	X		0.17											
02/28/23 10:00	0.17478			0	X		0.17											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 11:00	0.17508			0	X		0.18											
02/28/23 12:00	0.17466			0	X		0.17											
02/28/23 13:00	0.17502			0	X		0.18											
02/28/23 14:00	0.17562			0	X		0.18											
02/28/23 15:00	0.17664			0	X		0.18											
02/28/23 16:00	0.20586			0.02946			0.21											
02/28/23 17:00	0.21348			0.20862			0.42											
02/28/23 18:00	0.28986			0.3126			0.6											
02/28/23 19:00	0.3111			0.3327			0.64											
02/28/23 20:00	0.31008			0.33198			0.64											
02/28/23 21:00	0.31032			0.33198			0.64											
02/28/23 22:00	0.30912			0.33096			0.64											
02/28/23 23:00	0.30816			0.3312			0.64											
03/01/23 0:00	0.30882			0.33258			0.64											
03/01/23 1:00	0.30978			0.33342			0.64											
03/01/23 2:00	0.31026			0.33414			0.64											
03/01/23 3:00	0.31158			0.33552			0.65											
03/01/23 4:00	0.3129			0.33624			0.65											
03/01/23 5:00	0.31542			0.33906			0.65											
03/01/23 6:00	0.3438			0.36738			0.71											
03/01/23 7:00	0.27114			0.29328			0.56											
03/01/23 8:00	0.18978			0.15648			0.24											
03/01/23 9:00	0.17448			0	X		0.17											
03/01/23 10:00	0.17538			0	X		0.18											
03/01/23 11:00	0.17538			0	X		0.18											
03/01/23 12:00	0.1755			0	X		0.18											
03/01/23 13:00	0.17556			0	X		0.18											
03/01/23 14:00	0.17562			0	X		0.18											
03/01/23 15:00	0.17574			0	X		0.18											
03/01/23 16:00	0.17574			0	X		0.18											
03/01/23 17:00	0.1764			0	X		0.18											
03/01/23 18:00	0.17682			0	X		0.18											
03/01/23 19:00	0.17598			0	X		0.18											
03/01/23 20:00	0.17448			0	X		0.17											
03/01/23 21:00	0.1758			0	X		0.18											
03/01/23 22:00	0.17676			0	X		0.18											
03/01/23 23:00	0.17676			0	X		0.18											
03/02/23 0:00	0.1767			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/02/23 1:00	0.17652			0	X		0.18											
03/02/23 2:00	0.17838			0	X		0.18											
03/02/23 3:00	0.17844			0	X		0.18											
03/02/23 4:00	0.1782			0	X		0.18											
03/02/23 5:00	0.17856			0	X		0.18											
03/02/23 6:00	0.21258			0	X		0.21											
03/02/23 7:00	0.1779			0	X		0.18											
03/02/23 8:00	0.17784			0	X		0.18											
03/02/23 9:00	0.17784			0	X		0.18											
03/02/23 10:00	0.17676			0	X		0.18											
03/02/23 11:00	0.17454			0	X		0.17											
03/02/23 12:00	0.17724			0	X		0.18											
03/02/23 13:00	0.17442			0	X		0.17											
03/02/23 14:00	0.17406			0	X		0.17											
03/02/23 15:00	0.17406			0	X		0.17											
03/02/23 16:00	0.17376			0	X		0.17											
03/02/23 17:00	0.17322			0	X		0.17											
03/02/23 18:00	0.17328			0	X		0.17											
03/02/23 19:00	0.17358			0	X		0.17											
03/02/23 20:00	0.17334			0	X		0.17											
03/02/23 21:00	0.17382			0	X		0.17											
03/02/23 22:00	0.17352			0	X		0.17											
03/02/23 23:00	0.17388			0	X		0.17											
03/03/23 0:00	0.17376			0	X		0.17											
03/03/23 1:00	0.17382			0	X		0.17											
03/03/23 2:00	0.17382			0	X		0.17											
03/03/23 3:00	0.17508			0	X		0.18											
03/03/23 4:00	0.1773			0	X		0.18											
03/03/23 5:00	0.17424			0	X		0.17											
03/03/23 6:00	0.17394			0	X		0.17											
03/03/23 7:00	0.17454			0	X		0.17											
03/03/23 8:00	0.17466			0	X		0.17											
03/03/23 9:00	0.17448			0	X		0.17											
03/03/23 10:00	0.17532			0	X		0.18											
03/03/23 11:00	0.18954			0	X		0.19											
03/03/23 12:00	0.27864			0	X		0.28											
03/03/23 13:00	0.29484			0	X		0.29											
03/03/23 14:00	0.30096			0	X		0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/03/23 15:00	0.23484			0.17214			0.38											
03/03/23 16:00	0.18762			0.20124			0.39											
03/03/23 17:00	0.2604			0.27918			0.54											
03/03/23 18:00	0.31224			0.33306			0.65											
03/03/23 19:00	0.318			0.33924			0.66											
03/03/23 20:00	0.32454			0.34656			0.67											
03/03/23 21:00	0.30438			0.32604			0.63											
03/03/23 22:00	0.22668			0.23484			0.46											
03/03/23 23:00	0.19098			0.00786			0.19											
03/04/23 0:00	0.17568			0	X		0.18											
03/04/23 1:00	0.17532			0	X		0.18											
03/04/23 2:00	0.17526			0	X		0.18											
03/04/23 3:00	0.17466			0	X		0.17											
03/04/23 4:00	0.17448			0	X		0.17											
03/04/23 5:00	0.17466			0	X		0.17											
03/04/23 6:00	0.17478			0	X		0.17											
03/04/23 7:00	0.1749			0	X		0.17											
03/04/23 8:00	0.17442			0	X		0.17											
03/04/23 9:00	0.174			0	X		0.17											
03/04/23 10:00	0.17436			0	X		0.17											
03/04/23 11:00	0.17406			0	X		0.17											
03/04/23 12:00	0.17394			0	X		0.17											
03/04/23 13:00	0.17496			0	X		0.17											
03/04/23 14:00	0.1755			0	X		0.18											
03/04/23 15:00	0.17532			0	X		0.18											
03/04/23 16:00	0.2052			0.01884			0.21											
03/04/23 17:00	0.19452			0.18			0.37											
03/04/23 18:00	0.28782			0.30834			0.6											
03/04/23 19:00	0.34248			0.36414			0.71											
03/04/23 20:00	0.3285			0.35088			0.68											
03/04/23 21:00	0.3282			0.351			0.68											
03/04/23 22:00	0.24378			0.2508			0.49											
03/04/23 23:00	0.18408			0	X		0.18											
03/05/23 0:00	0.17262			0	X		0.17											
03/05/23 1:00	0.17136			0	X		0.17											
03/05/23 2:00	0.17316			0	X		0.17											
03/05/23 3:00	0.1755			0	X		0.18											
03/05/23 4:00	0.17628			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/05/23 5:00	0.17694			0	X		0.18											
03/05/23 6:00	0.17676			0	X		0.18											
03/05/23 7:00	0.17634			0	X		0.18											
03/05/23 8:00	0.17376			0	X		0.17											
03/05/23 9:00	0.17562			0	X		0.18											
03/05/23 10:00	0.177			0	X		0.18											
03/05/23 11:00	0.17616			0	X		0.18											
03/05/23 12:00	0.17454			0	X		0.17											
03/05/23 13:00	0.1737			0	X		0.17											
03/05/23 14:00	0.17328			0	X		0.17											
03/05/23 15:00	0.2031			0.02568			0.21											
03/05/23 16:00	0.21312			0.20256			0.42											
03/05/23 17:00	0.28344			0.30438			0.59											
03/05/23 18:00	0.34698			0.36816			0.72											
03/05/23 19:00	0.3501			0.37296			0.72											
03/05/23 20:00	0.3519			0.37434			0.73											
03/05/23 21:00	0.3426			0.36564			0.71											
03/05/23 22:00	0.3321			0.35532			0.69											
03/05/23 23:00	0.3123			0.33582			0.65											
03/06/23 0:00	0.27168			0.29382			0.57											
03/06/23 1:00	0.21846			0.2181			0.39											
03/06/23 2:00	0.17286			0	X		0.17											
03/06/23 3:00	0.17376			0	X		0.17											
03/06/23 4:00	0.17418			0	X		0.17											
03/06/23 5:00	0.19032			0	X		0.19											
03/06/23 6:00	0.25218			0	X		0.25											
03/06/23 7:00	0.17454			0	X		0.17											
03/06/23 8:00	0.17328			0	X		0.17											
03/06/23 9:00	0.174			0	X		0.17											
03/06/23 10:00	0.17442			0	X		0.17											
03/06/23 11:00	0.174			0	X		0.17											
03/06/23 12:00	0.1791			0	X		0.18											
03/06/23 13:00	0.22554			0.16686			0.36											
03/06/23 14:00	0.2631			0.2832			0.55											
03/06/23 15:00	0.30924			0.33096			0.64											
03/06/23 16:00	0.30918			0.3309			0.64											
03/06/23 17:00	0.30864			0.33048			0.64											
03/06/23 18:00	0.30624			0.32826			0.63											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/06/23 19:00	0.30384			0.32706			0.63											
03/06/23 20:00	0.30318			0.32646			0.63											
03/06/23 21:00	0.30306			0.32634			0.63											
03/06/23 22:00	0.3033			0.32658			0.63											
03/06/23 23:00	0.3033			0.3264			0.63											
03/07/23 0:00	0.30324			0.3264			0.63											
03/07/23 1:00	0.30444			0.32868			0.63											
03/07/23 2:00	0.30456			0.32808			0.63											
03/07/23 3:00	0.30516			0.32844			0.63											
03/07/23 4:00	0.30918			0.33246			0.64											
03/07/23 5:00	0.32574			0.34854			0.67											
03/07/23 6:00	0.35142			0.37398			0.73											
03/07/23 7:00	0.26664			0.288			0.55											
03/07/23 8:00	0.1893			0.15246			0.23											
03/07/23 9:00	0.17424			0	X		0.17											
03/07/23 10:00	0.17484			0	X		0.17											
03/07/23 11:00	0.17478			0	X		0.17											
03/07/23 12:00	0.17502			0	X		0.18											
03/07/23 13:00	0.1749			0	X		0.17											
03/07/23 14:00	0.17472			0	X		0.17											
03/07/23 15:00	0.17466			0	X		0.17											
03/07/23 16:00	0.20478			0.06444			0.22											
03/07/23 17:00	0.17922			0.18912			0.37											
03/07/23 18:00	0.2604			0.27984			0.54											
03/07/23 19:00	0.3048			0.32664			0.63											
03/07/23 20:00	0.3033			0.3264			0.63											
03/07/23 21:00	0.30336			0.32664			0.63											
03/07/23 22:00	0.30336			0.32676			0.63											
03/07/23 23:00	0.30318			0.32634			0.63											
03/08/23 0:00	0.3033			0.32634			0.63											
03/08/23 1:00	0.30342			0.32646			0.63											
03/08/23 2:00	0.3036			0.32658			0.63											
03/08/23 3:00	0.30336			0.32658			0.63											
03/08/23 4:00	0.30312			0.32718			0.63											
03/08/23 5:00	0.30402			0.32772			0.63											
03/08/23 6:00	0.30594			0.32922			0.64											
03/08/23 7:00	0.30996			0.33366			0.64											
03/08/23 8:00	0.31152			0.33486			0.65											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/08/23 9:00	0.30846			0.33144			0.64											
03/08/23 10:00	0.2712			0.2922			0.56											
03/08/23 11:00	0.18786			0.15954			0.25											
03/08/23 12:00	0.17592			0	X		0.18											
03/08/23 13:00	0.1752			0	X		0.18											
03/08/23 14:00	0.17484			0	X		0.17											
03/08/23 15:00	0.17466			0	X		0.17											
03/08/23 16:00	0.17412			0	X		0.17											
03/08/23 17:00	0.18456			0	X		0.18											
03/08/23 18:00	0.23238			0.16596			0.35											
03/08/23 19:00	0.22932			0.24756			0.48											
03/08/23 20:00	0.3138			0.33486			0.65											
03/08/23 21:00	0.30918			0.33192			0.64											
03/08/23 22:00	0.30834			0.33216			0.64											
03/08/23 23:00	0.30894			0.3324			0.64											
03/09/23 0:00	0.30924			0.33234			0.64											
03/09/23 1:00	0.3093			0.3324			0.64											
03/09/23 2:00	0.30918			0.33228			0.64											
03/09/23 3:00	0.30906			0.33228			0.64											
03/09/23 4:00	0.30804			0.33186			0.64											
03/09/23 5:00	0.31752			0.34134			0.66											
03/09/23 6:00	0.31008			0.33408			0.64											
03/09/23 7:00	0.3093			0.3324			0.64											
03/09/23 8:00	0.31104			0.3324			0.64											
03/09/23 9:00	0.31158			0.33372			0.65											
03/09/23 10:00	0.3138			0.33576			0.65											
03/09/23 11:00	0.3339			0.35604			0.69											
03/09/23 12:00	0.34704			0.36858			0.72											
03/09/23 13:00	0.36702			0.38892			0.76											
03/09/23 14:00	0.35796			0.37992			0.74											
03/09/23 15:00	0.33738			0.35952			0.7											
03/09/23 16:00	0.30714			0.3291			0.64											
03/09/23 17:00	0.3063			0.32832			0.63											
03/09/23 18:00	0.30696			0.32838			0.64											
03/09/23 19:00	0.30756			0.32898			0.64											
03/09/23 20:00	0.3081			0.3294			0.64											
03/09/23 21:00	0.3081			0.32952			0.64											
03/09/23 22:00	0.26862			0.2889			0.56											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/09/23 23:00	0.19026			0.14802			0.23											
03/10/23 0:00	0.17016			0	X		0.17											
03/10/23 1:00	0.17184			0	X		0.17											
03/10/23 2:00	0.17142			0	X		0.17											
03/10/23 3:00	0.17106			0	X		0.17											
03/10/23 4:00	0.17178			0	X		0.17											
03/10/23 5:00	0.17382			0	X		0.17											
03/10/23 6:00	0.17328			0	X		0.17											
03/10/23 7:00	0.17352			0	X		0.17											
03/10/23 8:00	0.17424			0	X		0.17											
03/10/23 9:00	0.17382			0	X		0.17											
03/10/23 10:00	0.2088			0	X		0.21											
03/10/23 11:00	0.17718			0	X		0.18											
03/10/23 12:00	0.17448			0	X		0.17											
03/10/23 13:00	0.17484			0	X		0.17											
03/10/23 14:00	0.17466			0	X		0.17											
03/10/23 15:00	0.20418			0.05712			0.21											
03/10/23 16:00	0.19584			0.20358			0.4											
03/10/23 17:00	0.27294			0.29238			0.57											
03/10/23 18:00	0.31482			0.33624			0.65											
03/10/23 19:00	0.3093			0.3315			0.64											
03/10/23 20:00	0.25158			0.2538			0.47											
03/10/23 21:00	0.18786			0	X		0.19											
03/10/23 22:00	0.17442			0	X		0.17											
03/10/23 23:00	0.17442			0	X		0.17											
03/11/23 0:00	0.17412			0	X		0.17											
03/11/23 1:00	0.174			0	X		0.17											
03/11/23 2:00	0.17382			0	X		0.17											
03/11/23 3:00	0.17382			0	X		0.17											
03/11/23 4:00	0.17406			0	X		0.17											
03/11/23 5:00	0.17442			0	X		0.17											
03/11/23 6:00	0.17436			0	X		0.17											
03/11/23 7:00	0.1746			0	X		0.17											
03/11/23 8:00	0.17406			0	X		0.17											
03/11/23 9:00	0.17394			0	X		0.17											
03/11/23 10:00	0.17406			0	X		0.17											
03/11/23 11:00	0.17442			0	X		0.17											
03/11/23 12:00	0.1743			0	X		0.17											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/11/23 13:00	0.174			0	X		0.17											
03/11/23 14:00	0.174			0	X		0.17											
03/11/23 15:00	0.1731			0	X		0.17											
03/11/23 16:00	0.18306			0.00258			0.18											
03/11/23 17:00	0.20004			0.17154			0.37											
03/11/23 18:00	0.16842			0.1812			0.35											
03/11/23 19:00	0.30516			0.32568			0.63											
03/11/23 20:00	0.32628			0.34722			0.67											
03/11/23 21:00	0.34668			0.36756			0.71											
03/11/23 22:00	0.36024			0.38088			0.74											
03/11/23 23:00	0.35964			0.37908			0.74											
03/12/23 0:00	0.33582			0.35634			0.69											
03/12/23 1:00	0.28122			0.3027			0.58											
03/12/23 2:00	0.28086			0.30264			0.58											
03/12/23 3:00	0.28308			0.30588			0.59											
03/12/23 4:00	0.3441			0.36534			0.71											
03/12/23 5:00	0.34374			0.36522			0.71											
03/12/23 6:00	0.27402			0.29526			0.57											
03/12/23 7:00	0.1872			0.15474			0.24											
03/12/23 8:00	0.1731			0	X		0.17											
03/12/23 9:00	0.17898			0	X		0.18											
03/12/23 10:00	0.17658			0	X		0.18											
03/12/23 11:00	0.1782			0	X		0.18											
03/12/23 12:00	0.17394			0	X		0.17											
03/12/23 13:00	0.1734			0	X		0.17											
03/12/23 14:00	0.20202			0	X		0.2											
03/12/23 15:00	0.21042			0.16716			0.36											
03/12/23 16:00	0.22692			0.2439			0.47											
03/12/23 17:00	0.35172			0.37308			0.72											
03/12/23 18:00	0.35886			0.37968			0.74											
03/12/23 19:00	0.35136			0.37188			0.72											
03/12/23 20:00	0.35784			0.3777			0.74											
03/12/23 21:00	0.35562			0.37602			0.73											
03/12/23 22:00	0.33804			0.35874			0.7											
03/12/23 23:00	0.24624			0.26574			0.51											
03/13/23 0:00	0.18426			0.1542			0.23											
03/13/23 1:00	0.17466			0	X		0.17											
03/13/23 2:00	0.1755			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/13/23 3:00	0.17412			0	X		0.17											
03/13/23 4:00	0.21024			0	X		0.21											
03/13/23 5:00	0.23466			0	X		0.23											
03/13/23 6:00	0.2643			0	X		0.26											
03/13/23 7:00	0.1731			0	X		0.17											
03/13/23 8:00	0.1734			0	X		0.17											
03/13/23 9:00	0.1734			0	X		0.17											
03/13/23 10:00	0.17358			0	X		0.17											
03/13/23 11:00	0.17382			0	X		0.17											
03/13/23 12:00	0.17376			0	X		0.17											
03/13/23 13:00	0.17424			0	X		0.17											
03/13/23 14:00	0.17424			0	X		0.17											
03/13/23 15:00	0.17382			0	X		0.17											
03/13/23 16:00	0.20172			0.06408			0.22											
03/13/23 17:00	0.1944			0.2061			0.4											
03/13/23 18:00	0.29658			0.3156			0.61											
03/13/23 19:00	0.33648			0.35598			0.69											
03/13/23 20:00	0.354			0.37356			0.73											
03/13/23 21:00	0.33894			0.35946			0.7											
03/13/23 22:00	0.24834			0.25506			0.5											
03/13/23 23:00	0.18408			0	X		0.18											
03/14/23 0:00	0.17346			0	X		0.17											
03/14/23 1:00	0.17088			0	X		0.17											
03/14/23 2:00	0.17238			0	X		0.17											
03/14/23 3:00	0.17268			0	X		0.17											
03/14/23 4:00	0.17238			0	X		0.17											
03/14/23 5:00	0.17232			0	X		0.17											
03/14/23 6:00	0.17184			0	X		0.17											
03/14/23 7:00	0.22146			0	X		0.22											
03/14/23 8:00	0.27102			0	X		0.27											
03/14/23 9:00	0.21684			0.1671			0.36											
03/14/23 10:00	0.29334			0.31398			0.61											
03/14/23 11:00	0.33408			0.3531			0.69											
03/14/23 12:00	0.33948			0.35766			0.7											
03/14/23 13:00	0.35472			0.37386			0.73											
03/14/23 14:00	0.34062			0.35916			0.7											
03/14/23 15:00	0.32034			0.33876			0.66											
03/14/23 16:00	0.3393			0.3588			0.7											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 17:00	0.3486			0.36894			0.72											
03/14/23 18:00	0.35574			0.37626			0.73											
03/14/23 19:00	0.36024			0.3813			0.74											
03/14/23 20:00	0.35514			0.37668			0.73											
03/14/23 21:00	0.32904			0.35118			0.68											
03/14/23 22:00	0.27972			0.30162			0.58											
03/14/23 23:00	0.19332			0.17376			0.24											
03/15/23 0:00	0.1728			0	X		0.17											
03/15/23 1:00	0.17304			0	X		0.17											
03/15/23 2:00	0.17346			0	X		0.17											
03/15/23 3:00	0.17358			0	X		0.17											
03/15/23 4:00	0.1734			0	X		0.17											
03/15/23 5:00	0.17346			0	X		0.17											
03/15/23 6:00	0.17694			0	X		0.18											
03/15/23 7:00	0.17358			0	X		0.17											
03/15/23 8:00	0.17364			0	X		0.17											
03/15/23 9:00	0.17346			0	X		0.17											
03/15/23 10:00	0.17322			0	X		0.17											
03/15/23 11:00	0.1728			0	X		0.17											
03/15/23 12:00	0.17328			0	X		0.17											
03/15/23 13:00	0.17364			0	X		0.17											
03/15/23 14:00	0.17382			0	X		0.17											
03/15/23 15:00	0.17388			0	X		0.17											
03/15/23 16:00	0.2013			0.07734			0.22											
03/15/23 17:00	0.192			0.20706			0.4											
03/15/23 18:00	0.28692			0.3069			0.59											
03/15/23 19:00	0.33222			0.35256			0.68											
03/15/23 20:00	0.34356			0.36402			0.71											
03/15/23 21:00	0.25602			0.2601			0.5											
03/15/23 22:00	0.1779			0	X		0.18											
03/15/23 23:00	0.17322			0	X		0.17											
03/16/23 0:00	0.1737			0	X		0.17											
03/16/23 1:00	0.17328			0	X		0.17											
03/16/23 2:00	0.17268			0	X		0.17											
03/16/23 3:00	0.1728			0	X		0.17											
03/16/23 4:00	0.17292			0	X		0.17											
03/16/23 5:00	0.17256			0	X		0.17											
03/16/23 6:00	0.17994			0	X		0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/16/23 7:00	0.1734			0	X		0.17											
03/16/23 8:00	0.1737			0	X		0.17											
03/16/23 9:00	0.17394			0	X		0.17											
03/16/23 10:00	0.1743			0	X		0.17											
03/16/23 11:00	0.17484			0	X		0.17											
03/16/23 12:00	0.1743			0	X		0.17											
03/16/23 13:00	0.17268			0	X		0.17											
03/16/23 14:00	0.17178			0	X		0.17											
03/16/23 15:00	0.16872			0.08544			0.07											
03/16/23 16:00	0	X		0.23748			0.24											
03/16/23 17:00	0	X		0.19542			0.2											
03/16/23 18:00	0	X		0.19398			0.19											
03/16/23 19:00	0	X		0.195			0.2											
03/16/23 20:00	0	X		0.19548			0.2											
03/16/23 21:00	0	X		0.22344			0.22											
03/16/23 22:00	0	X		0.22308			0.22											
03/16/23 23:00	0	X		0.1992			0.2											
03/17/23 0:00	0	X		0.19788			0.2											
03/17/23 1:00	0.05034			0.22866			0.24											
03/17/23 2:00	0.19752			0.22482			0.42											
03/17/23 3:00	0.29946			0.32556			0.63											
03/17/23 4:00	0.35634			0.37854			0.73											
03/17/23 5:00	0.36252			0.38502			0.75											
03/17/23 6:00	0.34536			0.36804			0.71											
03/17/23 7:00	0.25392			0.27246			0.53											
03/17/23 8:00	0.20274			0.18408			0.3											
03/17/23 9:00	0.18384			0	X		0.18											
03/17/23 10:00	0.18468			0	X		0.18											
03/17/23 11:00	0.18522			0	X		0.19											
03/17/23 12:00	0.18468			0	X		0.18											
03/17/23 13:00	0.18456			0	X		0.18											
03/17/23 14:00	0.18342			0	X		0.18											
03/17/23 15:00	0.18402			0	X		0.18											
03/17/23 16:00	0.22668			0.11046			0.27											
03/17/23 17:00	0.21966			0.23718			0.46											
03/17/23 18:00	0.32802			0.34746			0.68											
03/17/23 19:00	0.34566			0.366			0.71											
03/17/23 20:00	0.33024			0.3501			0.68											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/17/23 21:00	0.34044			0.36084			0.7											
03/17/23 22:00	0.24324			0.25434			0.5											
03/17/23 23:00	0.19464			0.05646			0.2											
03/18/23 0:00	0.18354			0	X		0.18											
03/18/23 1:00	0.18402			0	X		0.18											
03/18/23 2:00	0.1845			0	X		0.18											
03/18/23 3:00	0.18396			0	X		0.18											
03/18/23 4:00	0.18366			0	X		0.18											
03/18/23 5:00	0.1842			0	X		0.18											
03/18/23 6:00	0.18384			0	X		0.18											
03/18/23 7:00	0.1839			0	X		0.18											
03/18/23 8:00	0.18396			0	X		0.18											
03/18/23 9:00	0.18666			0	X		0.19											
03/18/23 10:00	0.186			0	X		0.19											
03/18/23 11:00	0.18552			0	X		0.19											
03/18/23 12:00	0.1845			0	X		0.18											
03/18/23 13:00	0.18378			0	X		0.18											
03/18/23 14:00	0.18378			0	X		0.18											
03/18/23 15:00	0.21018			0.02304			0.21											
03/18/23 16:00	0.21234			0.20208			0.41											
03/18/23 17:00	0.30336			0.32322			0.63											
03/18/23 18:00	0.35952			0.3777			0.74											
03/18/23 19:00	0.3315			0.35064			0.68											
03/18/23 20:00	0.32586			0.34512			0.67											
03/18/23 21:00	0.2469			0.24444			0.47											
03/18/23 22:00	0.18654			0	X		0.19											
03/18/23 23:00	0.18246			0	X		0.18											
03/19/23 0:00	0.18282			0	X		0.18											
03/19/23 1:00	0.1818			0	X		0.18											
03/19/23 2:00	0.1833			0	X		0.18											
03/19/23 3:00	0.18408			0	X		0.18											
03/19/23 4:00	0.18414			0	X		0.18											
03/19/23 5:00	0.18432			0	X		0.18											
03/19/23 6:00	0.1845			0	X		0.18											
03/19/23 7:00	0.18438			0	X		0.18											
03/19/23 8:00	0.18372			0	X		0.18											
03/19/23 9:00	0.18228			0	X		0.18											
03/19/23 10:00	0.1812			0	X		0.18											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 11:00	0.1821			0	X		0.18											
03/19/23 12:00	0.19662			0	X		0.2											
03/19/23 13:00	0.18378			0	X		0.18											
03/19/23 14:00	0.18426			0	X		0.18											
03/19/23 15:00	0.23166			0.1101			0.26											
03/19/23 16:00	0.20616			0.22404			0.43											
03/19/23 17:00	0.32718			0.34884			0.68											
03/19/23 18:00	0.3459			0.36702			0.71											
03/19/23 19:00	0.33462			0.35604			0.69											
03/19/23 20:00	0.3378			0.35904			0.7											
03/19/23 21:00	0.32214			0.34332			0.67											
03/19/23 22:00	0.31374			0.33516			0.65											
03/19/23 23:00	0.3171			0.33834			0.66											
03/20/23 0:00	0.26484			0.28488			0.55											
03/20/23 1:00	0.19566			0.15564			0.24											
03/20/23 2:00	0.1845			0	X		0.18											
03/20/23 3:00	0.18486			0	X		0.18											
03/20/23 4:00	0.1851			0	X		0.19											
03/20/23 5:00	0.20256			0	X		0.2											
03/20/23 6:00	0.18528			0	X		0.19											
03/20/23 7:00	0.20562			0	X		0.21											
03/20/23 8:00	0.1986			0	X		0.2											
03/20/23 9:00	0.18408			0	X		0.18											
03/20/23 10:00	0.18426			0	X		0.18											
03/20/23 11:00	0.18444			0	X		0.18											
03/20/23 12:00	0.18438			0	X		0.18											
03/20/23 13:00	0.18474			0	X		0.18											
03/20/23 14:00	0.18438			0	X		0.18											
03/20/23 15:00	0.1845			0	X		0.18											
03/20/23 16:00	0.23952			0.14568			0.31											
03/20/23 17:00	0.24636			0.26574			0.51											
03/20/23 18:00	0.34464			0.36456			0.71											
03/20/23 19:00	0.34302			0.3636			0.71											
03/20/23 20:00	0.2391			0.26106			0.28											
03/20/23 21:00	0	X		0	X		0											
03/20/23 22:00	0	X		0	X		0											
03/20/23 23:00	0	X		0	X		0											
03/21/23 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/21/23 1:00	0	X		0	X		0											
03/21/23 2:00	0	X		0	X		0											
03/21/23 3:00	0	X		0	X		0											
03/21/23 4:00	0	X		0	X		0											
03/21/23 5:00	0	X		0	X		0											
03/21/23 6:00	0	X		0	X		0											
03/21/23 7:00	0	X		0	X		0											
03/21/23 8:00	0	X		0	X		0											
03/21/23 9:00	0	X		0	X		0											
03/21/23 10:00	0	X		0	X		0											
03/21/23 11:00	0	X		0.1473			0.07											
03/21/23 12:00	0	X		0.26076			0.26											
03/21/23 13:00	0	X		0.20292			0.2											
03/21/23 14:00	0	X		0.1935			0.19											
03/21/23 15:00	0	X		0.19242			0.19											
03/21/23 16:00	0	X		0.19188			0.19											
03/21/23 17:00	0	X		0.19314			0.19											
03/21/23 18:00	0	X		0.19302			0.19											
03/21/23 19:00	0	X		0.1923			0.19											
03/21/23 20:00	0	X		0.19308			0.19											
03/21/23 21:00	0	X		0.19356			0.19											
03/21/23 22:00	0	X		0.19566			0.2											
03/21/23 23:00	0	X		0.19746			0.2											
03/22/23 0:00	0	X		0.19788			0.2											
03/22/23 1:00	0	X		0.19572			0.2											
03/22/23 2:00	0	X		0.19542			0.2											
03/22/23 3:00	0	X		0.1953			0.2											
03/22/23 4:00	0	X		0.19524			0.2											
03/22/23 5:00	0	X		0.20052			0.2											
03/22/23 6:00	0	X		0.25074			0.25											
03/22/23 7:00	0	X		0.1944			0.19											
03/22/23 8:00	0	X		0.19458			0.19											
03/22/23 9:00	0	X		0.19614			0.2											
03/22/23 10:00	0	X		0.19692			0.2											
03/22/23 11:00	0	X		0.19746			0.2											
03/22/23 12:00	0	X		0.1962			0.2											
03/22/23 13:00	0	X		0.19656			0.2											
03/22/23 14:00	0	X		0.19872			0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/22/23 15:00	0	X		0.22686			0.23											
03/22/23 16:00	0.16356			0.23682			0.38											
03/22/23 17:00	0.27186			0.29088			0.56											
03/22/23 18:00	0.36102			0.38112			0.74											
03/22/23 19:00	0.35784			0.378			0.74											
03/22/23 20:00	0.34962			0.37068			0.72											
03/22/23 21:00	0.32526			0.3465			0.67											
03/22/23 22:00	0.27588			0.29676			0.57											
03/22/23 23:00	0.20124			0.23412			0.41											
03/23/23 0:00	0	X		0.20526			0.21											
03/23/23 1:00	0	X		0.19968			0.2											
03/23/23 2:00	0	X		0.19986			0.2											
03/23/23 3:00	0	X		0.19962			0.2											
03/23/23 4:00	0	X		0.19878			0.2											
03/23/23 5:00	0	X		0.1965			0.2											
03/23/23 6:00	0	X		0.19698			0.2											
03/23/23 7:00	0	X		0.19926			0.2											
03/23/23 8:00	0	X		0.19806			0.2											
03/23/23 9:00	0	X		0.19602			0.2											
03/23/23 10:00	0	X		0.19608			0.2											
03/23/23 11:00	0	X		0.19572			0.2											
03/23/23 12:00	0	X		0.19548			0.2											
03/23/23 13:00	0	X		0.19572			0.2											
03/23/23 14:00	0.01938			0.21936			0.22											
03/23/23 15:00	0.16278			0.21768			0.38											
03/23/23 16:00	0.22872			0.24462			0.47											
03/23/23 17:00	0.30876			0.32952			0.64											
03/23/23 18:00	0.3084			0.32946			0.64											
03/23/23 19:00	0.30672			0.32838			0.64											
03/23/23 20:00	0.30552			0.32802			0.63											
03/23/23 21:00	0.30456			0.3276			0.63											
03/23/23 22:00	0.24			0.25938			0.5											
03/23/23 23:00	0.09738			0.21144			0.22											
03/24/23 0:00	0	X		0.19842			0.2											
03/24/23 1:00	0	X		0.19836			0.2											
03/24/23 2:00	0	X		0.1986			0.2											
03/24/23 3:00	0	X		0.19836			0.2											
03/24/23 4:00	0	X		0.19842			0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/24/23 5:00	0	X		0.19818			0.2											
03/24/23 6:00	0	X		0.1983			0.2											
03/24/23 7:00	0	X		0.19764			0.2											
03/24/23 8:00	0	X		0.1974			0.2											
03/24/23 9:00	0	X		0.19746			0.2											
03/24/23 10:00	0	X		0.1974			0.2											
03/24/23 11:00	0	X		0.198			0.2											
03/24/23 12:00	0	X		0.19788			0.2											
03/24/23 13:00	0	X		0.19818			0.2											
03/24/23 14:00	0	X		0.19818			0.2											
03/24/23 15:00	0	X		0.19788			0.2											
03/24/23 16:00	0	X		0.19764			0.2											
03/24/23 17:00	0	X		0.19812			0.2											
03/24/23 18:00	0	X		0.19818			0.2											
03/24/23 19:00	0	X		0.19818			0.2											
03/24/23 20:00	0	X		0.1983			0.2											
03/24/23 21:00	0	X		0.19932			0.2											
03/24/23 22:00	0	X		0.19896			0.2											
03/24/23 23:00	0	X		0.19848			0.2											
03/25/23 0:00	0	X		0.19776			0.2											
03/25/23 1:00	0	X		0.19746			0.2											
03/25/23 2:00	0	X		0.19728			0.2											
03/25/23 3:00	0	X		0.19758			0.2											
03/25/23 4:00	0	X		0.19776			0.2											
03/25/23 5:00	0	X		0.1974			0.2											
03/25/23 6:00	0	X		0.19752			0.2											
03/25/23 7:00	0	X		0.19716			0.2											
03/25/23 8:00	0	X		0.19674			0.2											
03/25/23 9:00	0	X		0.19632			0.2											
03/25/23 10:00	0	X		0.19638			0.2											
03/25/23 11:00	0	X		0.19644			0.2											
03/25/23 12:00	0	X		0.19614			0.2											
03/25/23 13:00	0	X		0.19548			0.2											
03/25/23 14:00	0	X		0.19542			0.2											
03/25/23 15:00	0	X		0.19548			0.2											
03/25/23 16:00	0	X		0.1962			0.2											
03/25/23 17:00	0	X		0.19716			0.2											
03/25/23 18:00	0	X		0.19818			0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/25/23 19:00	0	X		0.19836			0.2											
03/25/23 20:00	0	X		0.19824			0.2											
03/25/23 21:00	0	X		0.1983			0.2											
03/25/23 22:00	0	X		0.207			0.21											
03/25/23 23:00	0	X		0.12978			0.02											
03/26/23 0:00	0	X		0	X		0											
03/26/23 1:00	0	X		0	X		0											
03/26/23 2:00	0	X		0	X		0											
03/26/23 3:00	0	X		0	X		0											
03/26/23 4:00	0	X		0	X		0											
03/26/23 5:00	0	X		0	X		0											
03/26/23 6:00	0	X		0	X		0											
03/26/23 7:00	0	X		0	X		0											
03/26/23 8:00	0	X		0	X		0											
03/26/23 9:00	0	X		0	X		0											
03/26/23 10:00	0	X		0	X		0											
03/26/23 11:00	0	X		0	X		0											
03/26/23 12:00	0	X		0	X		0											
03/26/23 13:00	0	X		0	X		0											
03/26/23 14:00	0	X		0	X		0											
03/26/23 15:00	0	X		0	X		0											
03/26/23 16:00	0	X		0	X		0											
03/26/23 17:00	0	X		0	X		0											
03/26/23 18:00	0	X		0	X		0											
03/26/23 19:00	0	X		0	X		0											
03/26/23 20:00	0	X		0	X		0											
03/26/23 21:00	0	X		0	X		0											
03/26/23 22:00	0	X		0	X		0											
03/26/23 23:00	0	X		0	X		0											
03/27/23 0:00	0	X		0	X		0											
03/27/23 1:00	0	X		0	X		0											
03/27/23 2:00	0	X		0	X		0											
03/27/23 3:00	0	X		0	X		0											
03/27/23 4:00	0	X		0	X		0											
03/27/23 5:00	0	X		0	X		0											
03/27/23 6:00	0	X		0	X		0											
03/27/23 7:00	0	X		0	X		0											
03/27/23 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/27/23 9:00	0	X		0	X		0											
03/27/23 10:00	0	X		0	X		0											
03/27/23 11:00	0	X		0	X		0											
03/27/23 12:00	0	X		0	X		0											
03/27/23 13:00	0	X		0	X		0											
03/27/23 14:00	0	X		0	X		0											
03/27/23 15:00	0	X		0	X		0											
03/27/23 16:00	0	X		0	X		0											
03/27/23 17:00	0	X		0	X		0											
03/27/23 18:00	0	X		0	X		0											
03/27/23 19:00	0	X		0	X		0											
03/27/23 20:00	0	X		0	X		0											
03/27/23 21:00	0	X		0	X		0											
03/27/23 22:00	0	X		0	X		0											
03/27/23 23:00	0	X		0	X		0											
03/28/23 0:00	0	X		0	X		0											
03/28/23 1:00	0	X		0	X		0											
03/28/23 2:00	0	X		0	X		0											
03/28/23 3:00	0	X		0	X		0											
03/28/23 4:00	0	X		0	X		0											
03/28/23 5:00	0	X		0	X		0											
03/28/23 6:00	0	X		0	X		0											
03/28/23 7:00	0	X		0	X		0											
03/28/23 8:00	0	X		0	X		0											
03/28/23 9:00	0	X		0	X		0											
03/28/23 10:00	0	X		0	X		0											
03/28/23 11:00	0	X		0	X		0											
03/28/23 12:00	0	X		0	X		0											
03/28/23 13:00	0	X		0	X		0											
03/28/23 14:00	0	X		0	X		0											
03/28/23 15:00	0	X		0	X		0											
03/28/23 16:00	0	X		0	X		0											
03/28/23 17:00	0	X		0	X		0											
03/28/23 18:00	0	X		0	X		0											
03/28/23 19:00	0	X		0	X		0											
03/28/23 20:00	0	X		0	X		0											
03/28/23 21:00	0	X		0	X		0											
03/28/23 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/28/23 23:00	0	X		0	X		0											
03/29/23 0:00	0	X		0	X		0											
03/29/23 1:00	0	X		0	X		0											
03/29/23 2:00	0	X		0	X		0											
03/29/23 3:00	0	X		0	X		0											
03/29/23 4:00	0	X		0	X		0											
03/29/23 5:00	0	X		0	X		0											
03/29/23 6:00	0	X		0	X		0											
03/29/23 7:00	0	X		0	X		0											
03/29/23 8:00	0	X		0	X		0											
03/29/23 9:00	0	X		0	X		0											
03/29/23 10:00	0	X		0	X		0											
03/29/23 11:00	0	X		0	X		0											
03/29/23 12:00	0	X		0	X		0											
03/29/23 13:00	0	X		0	X		0											
03/29/23 14:00	0	X		0	X		0											
03/29/23 15:00	0	X		0	X		0											
03/29/23 16:00	0	X		0	X		0											
03/29/23 17:00	0	X		0	X		0											
03/29/23 18:00	0	X		0	X		0											
03/29/23 19:00	0	X		0	X		0											
03/29/23 20:00	0	X		0	X		0											
03/29/23 21:00	0	X		0	X		0											
03/29/23 22:00	0	X		0	X		0											
03/29/23 23:00	0	X		0	X		0											
03/30/23 0:00	0	X		0	X		0											
03/30/23 1:00	0	X		0	X		0											
03/30/23 2:00	0	X		0	X		0											
03/30/23 3:00	0	X		0	X		0											
03/30/23 4:00	0	X		0	X		0											
03/30/23 5:00	0	X		0	X		0											
03/30/23 6:00	0	X		0	X		0											
03/30/23 7:00	0	X		0	X		0											
03/30/23 8:00	0	X		0	X		0											
03/30/23 9:00	0	X		0	X		0											
03/30/23 10:00	0	X		0	X		0											
03/30/23 11:00	0	X		0	X		0											
03/30/23 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
03/30/23 13:00	0	X		0	X		0											
03/30/23 14:00	0	X		0	X		0											
03/30/23 15:00	0	X		0	X		0											
03/30/23 16:00	0	X		0	X		0											
03/30/23 17:00	0	X		0	X		0											
03/30/23 18:00	0	X		0	X		0											
03/30/23 19:00	0	X		0	X		0											
03/30/23 20:00	0	X		0	X		0											
03/30/23 21:00	0	X		0	X		0											
03/30/23 22:00	0	X		0	X		0											
03/30/23 23:00	0	X		0	X		0											
03/31/23 0:00	0	X		0	X		0											
03/31/23 1:00	0	X		0	X		0											
03/31/23 2:00	0	X		0	X		0											
03/31/23 3:00	0	X		0	X		0											
03/31/23 4:00	0	X		0	X		0											
03/31/23 5:00	0	X		0	X		0											
03/31/23 6:00	0	X		0	X		0											
03/31/23 7:00	0	X		0	X		0											
03/31/23 8:00	0	X		0	X		0											
03/31/23 9:00	0	X		0	X		0											
03/31/23 10:00	0	X		0	X		0											
03/31/23 11:00	0	X		0	X		0											
03/31/23 12:00	0	X		0	X		0											
03/31/23 13:00	0	X		0	X		0											
03/31/23 14:00	0	X		0	X		0											
03/31/23 15:00	0	X		0	X		0											
03/31/23 16:00	0	X		0	X		0											
03/31/23 17:00	0	X		0	X		0											
03/31/23 18:00	0	X		0	X		0											
03/31/23 19:00	0	X		0	X		0											
03/31/23 20:00	0	X		0	X		0											
03/31/23 21:00	0	X		0	X		0											
03/31/23 22:00	0	X		0	X		0											
03/31/23 23:00	0	X		0	X		0											
04/01/23 0:00	0	X		0	X		0											
04/01/23 1:00	0	X		0	X		0											
04/01/23 2:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
04/01/23 3:00	0	X		0	X		0											
04/01/23 4:00	0	X		0	X		0											
04/01/23 5:00	0	X		0	X		0											
04/01/23 6:00	0	X		0	X		0											
04/01/23 7:00	0	X		0	X		0											
04/01/23 8:00	0	X		0	X		0	X										

ATTACHMENT 6

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

CEMs Log

Date/Time	Operator	Description
03/19/23 19:29	Operator (DWN)	CHANGED UNIT 2 NOX INLET BOTTLE. NOX 25.25 PPM. EB0112912. EXP. 1/30/26
03/19/23 19:26	Operator (DWN)	CHANGED UNIT 1 NOX INLET BOTTLE. NOX 25.18 PPM. EB0094060. EXP. 1/30/26
03/09/23 6:11	Operator (ME)	03/07/2023 SPANNED LOW NOX ON CT1 CEMS TO CORRECT >1x PART 75 ALERT
03/08/23 17:42	Operator (CC)	CHANGED CEMS 1 HIGH NOX/ CO BOTTLE, CYL# EB0099943, EXP DATE 02-14-31
03/06/23 8:41	Operator (LH)	UPDATED GCV TO 104300 FOR MARCH
03/06/23 8:33	Operator (DWN)	CHANGED UNIT 2 O2 BOTTLE. 18.03% BOTTLE # CC21634. EXP 10-25-30
03/03/23 10:41	Operator (DWN)	CHANGED UNIT 1 O2 BOTTLE. 18.06%. BOTTLE #213608054. EXP 12-14-27
02/16/23 0:02	Operator (RC)	CHANGED UNIT 2 HIGH NOX/ CO 181/182 PPM, CYL# CC113751, EXP DATE 11/4/30
02/14/23 3:52	Operator (LH)	SWAPPED UNIT 2 LOW 30 PPM NOX/CO BOTTLE CYLINDER# CC347209 11/29/25
02/13/23 12:15	Operator (JB)	CHANGED UNIT 2 LOW (9) PPM BOTTLE. CC283832 NOX 9.001 / CO 9.031 EXP 12/21/25
02/08/23 15:18	Operator (RG)	RE-TEST ON HIGH RANGE LINEARITY/CGA FOR CT1
02/05/23 12:21	Operator (DWN)	CHANGED UNIT 1 LOW (9) PPM BOTTLE. EB0144535. NOX 8.412 / CO 8.650. EXP 12/1/23
02/03/23 14:06	Operator (DWN)	UPDATED GCV FOR EACH UNIT FOR FEBRUARY TO 104,900
01/30/23 6:08	Operator (LHR)	CHANGED UNIT 1 HI NOX/CO DAILY CALIBRATION CYLINDER CC44599 EXP 11/4/2030
01/24/23 5:06	Operator (LH)	SWAPPED UNIT 1 O2 BOTTLE CYCLINDER ID XC033877B EXP 6/1/24
01/20/23 23:55	Operator (LH)	SWAPPED UNIT 2 O2 BOTTLE ID#214503056 EXP 12/14/27
01/17/23 21:35	Operator (LH)	UNIT 2 LOW CO/NOX 30PPM BOTTLE SWAPPED ID#CC727813 EXP. 9/13/25
01/11/23 13:31	Operator (LHR)	CHANGED UNIT 2 HI NOX/CO DAILY CALIBRATION CYLINDER CC178958 EXP 11/4/2030
01/03/23 4:42	Operator (LHR)	UPDATED GCV VALUES FOR JANUARY TO 105,200

Cylinder Gas Audit

04/01/2023

Page 1

Facility:	ROSEVILLE ENERGY	Instrument	CT2_CODualRg_P_Instr
Unit/Stack:	CT2	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Test Date:	01/19/2023
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/19/2023	08:34	L	200	49.700	51.900	24.9 %
01/19/2023	08:39	M	200	109.100	119.200	54.6 %
01/19/2023	08:51	L	200	49.700	51.900	24.9 %
01/19/2023	08:57	M	200	109.100	118.300	54.6 %
01/19/2023	09:09	L	200	49.700	51.900	24.9 %
01/19/2023	09:14	M	200	109.100	118.900	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.700	51.900	Std	4.4
M	109.100	118.800	Std	8.9

Cylinder Gas Audit

04/01/2023

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scal CO / Low

Test Date: 01/19/2023
Test **Pass**

Instrument CT2_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/19/2023	12:48	L	10	2.400	2.300	24.0 %
01/19/2023	12:53	M	10	5.700	5.600	57.0 %
01/19/2023	13:00	L	10	2.400	2.300	24.0 %
01/19/2023	13:05	M	10	5.700	5.600	57.0 %
01/19/2023	13:12	L	10	2.400	2.300	24.0 %
01/19/2023	13:17	M	10	5.700	5.600	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

04/01/2023

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scal CO / High

Test Date: 01/24/2023
Test **Pass**

Instrument CT1_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/24/2023	08:31	L	200	49.800	46.000	24.9 %
01/24/2023	08:36	M	200	109.200	108.200	54.6 %
01/24/2023	08:48	L	200	49.800	46.100	24.9 %
01/24/2023	08:53	M	200	109.200	108.100	54.6 %
01/24/2023	09:05	L	200	49.800	46.100	24.9 %
01/24/2023	09:10	M	200	109.200	108.100	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.800	46.067	Std	7.5
M	109.200	108.133	Std	1.0

Cylinder Gas Audit

04/01/2023

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/30/2023	14:40	L	10	2.400	2.100	24.0 %
01/30/2023	14:45	M	10	5.700	5.500	57.0 %
01/30/2023	14:52	L	10	2.400	2.100	24.0 %
01/30/2023	14:57	M	10	5.700	5.500	57.0 %
01/30/2023	15:04	L	10	2.400	2.100	24.0 %
01/30/2023	15:09	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.100	Std	12.5
M	5.700	5.500	Std	3.5

Cylinder Gas Audit

04/01/2023

Page 5

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
02/08/2023	07:38	L	200	49.800	47.100	24.9 %
02/08/2023	07:43	M	200	109.200	111.100	54.6 %
02/08/2023	07:56	L	200	49.800	46.900	24.9 %
02/08/2023	08:01	M	200	109.200	110.600	54.6 %
02/08/2023	08:13	L	200	49.800	46.900	24.9 %
02/08/2023	08:18	M	200	109.200	110.800	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.800	46.967	Std	5.7
M	109.200	110.833	Std	1.5

Roseville Energy Park

Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

3/14/23 Taylor Sullivan

Edited the CT2_Startup_Cold tag to 1 for 3/13 16:51 – 17:37 and recalculated dependencies. EDR check.

2/16/23 Adam Jensen

Testing access. No changes made.

2/7/23 Taylor Sullivan

EDR check

1/13,16,24/2023 Taylor Sullivan

Q4 EDRs

Linearity Report

04/01/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	01/19/2023	Scale:	High
Performance	5 %	Test No.:	125	Highest	2.1
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2023	0834	L	200.0	51.6	50.3		25.8 %
01/19/2023	0839	M	200.0	111.3	110.1		55.7 %
01/19/2023	0844	H	200.0	180.4	180.0		90.2 %
01/19/2023	0851	L	200.0	51.6	50.6		25.8 %
01/19/2023	0857	M	200.0	111.3	110.4		55.7 %
01/19/2023	0902	H	200.0	180.4	180.3		90.2 %
01/19/2023	0909	L	200.0	51.6	50.7		25.8 %
01/19/2023	0914	M	200.0	111.3	110.6		55.7 %
01/19/2023	0919	H	200.0	180.4	180.2		90.2 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.600	50.533	No	2.1
M	111.300	110.367	No	0.8
H	180.400	180.167	No	0.1

Linearity Report

04/01/2023

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	01/19/2023	Scale:	High
Performance	5 %	Test No.:	126	Highest	0.7
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2023	1041	L	21.0	5.0	5.1		23.8 %
01/19/2023	1046	M	21.0	11.2	11.2		53.3 %
01/19/2023	1051	H	21.0	18.0	18.0		85.7 %
01/19/2023	1058	L	21.0	5.0	5.0		23.8 %
01/19/2023	1103	M	21.0	11.2	11.2		53.3 %
01/19/2023	1108	H	21.0	18.0	18.0		85.7 %
01/19/2023	1115	L	21.0	5.0	5.0		23.8 %
01/19/2023	1120	M	21.0	11.2	11.2		53.3 %
01/19/2023	1125	H	21.0	18.0	18.0		85.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	0.7
M	11.200	11.200	No	0.0
H	18.000	18.000	No	0.0

Linearity Report

04/01/2023

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	01/24/2023	Scale:	High
Performance	5 %	Test No.:	122	Highest	5.0
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/24/2023	0831	L	200.0	51.3	49.9		25.7 %
01/24/2023	0836	M	200.0	105.0	109.7		52.5 %
01/24/2023	0841	H	200.0	180.0	180.8		90.0 %
01/24/2023	0848	L	200.0	51.3	50.6		25.7 %
01/24/2023	0853	M	200.0	105.0	110.4		52.5 %
01/24/2023	0858	H	200.0	180.0	181.0		90.0 %
01/24/2023	0905	L	200.0	51.3	50.6		25.7 %
01/24/2023	0910	M	200.0	105.0	110.5		52.5 %
01/24/2023	0915	H	200.0	180.0	180.8		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	50.367	No	1.8
M	105.000	110.200	No	5.0
H	180.000	180.867	No	0.5

Linearity Report

04/01/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	01/30/2023	Scale:	High
Performance	5 %	Test No.:	123	Highest	1.1
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/30/2023	1035	L	21.0	5.5	5.5		26.2 %
01/30/2023	1040	M	21.0	11.1	11.0		52.9 %
01/30/2023	1046	H	21.0	18.0	17.8		85.7 %
01/30/2023	1053	L	21.0	5.5	5.5		26.2 %
01/30/2023	1058	M	21.0	11.1	11.0		52.9 %
01/30/2023	1103	H	21.0	18.0	17.8		85.7 %
01/30/2023	1110	L	21.0	5.5	5.5		26.2 %
01/30/2023	1115	M	21.0	11.1	11.0		52.9 %
01/30/2023	1120	H	21.0	18.0	17.8		85.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	11.100	11.000	No	0.9
H	18.000	17.800	No	1.1

Linearity Report

04/01/2023

Page 5

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	02/08/2023	Scale:	High
Performance	5 %	Test No.:	124	Highest	0.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/08/2023	0738	L	200.0	51.3	50.7		25.7 %
02/08/2023	0743	M	200.0	111.6	111.9		55.8 %
02/08/2023	0749	H	200.0	181.6	182.3		90.8 %
02/08/2023	0756	L	200.0	51.3	51.3		25.7 %
02/08/2023	0801	M	200.0	111.6	112.3		55.8 %
02/08/2023	0806	H	200.0	181.6	182.2		90.8 %
02/08/2023	0813	L	200.0	51.3	51.3		25.7 %
02/08/2023	0818	M	200.0	111.6	112.4		55.8 %
02/08/2023	0823	H	200.0	181.6	182.3		90.8 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	51.100	No	0.4
M	111.600	112.200	No	0.5
H	181.600	182.267	No	0.4

AQ34 3HR AVG LOAD

Date/Time	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/01/23 0:00	1			0			32											
01/01/23 1:00	1			0			32											
01/01/23 2:00	1			0			32											
01/01/23 3:00	1			0			32											
01/01/23 4:00	1			0			32											
01/01/23 5:00	1			0			32											
01/01/23 6:00	1			0			32											
01/01/23 7:00	1			0			32											
01/01/23 8:00	1			0			32											
01/01/23 9:00	1			0			32											
01/01/23 10:00	1			0			32											
01/01/23 11:00	1			0			32											
01/01/23 12:00	1			0			31											
01/01/23 13:00	1			0			31											
01/01/23 14:00	1			0			31											
01/01/23 15:00	1			0			31											
01/01/23 16:00	1			0			31											
01/01/23 17:00	1			0			31											
01/01/23 18:00	1			0			31											
01/01/23 19:00	1			0			31											
01/01/23 20:00	1			0			31											
01/01/23 21:00	1			0			32											
01/01/23 22:00	1			0			32											
01/01/23 23:00	1			0			32											
01/02/23 0:00	1			0			32											
01/02/23 1:00	1			0			32											
01/02/23 2:00	1			0			32											
01/02/23 3:00	1			0			32											
01/02/23 4:00	1			0			32											
01/02/23 5:00	1			0			32											
01/02/23 6:00	1			0			32											
01/02/23 7:00	1			0			41											
01/02/23 8:00	1			0			43											
01/02/23 9:00	1			0			43											
01/02/23 10:00	1			0			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 11:00	1			0			37											
01/02/23 12:00	1			8			41											
01/02/23 13:00	1			29			49											
01/02/23 14:00	1			55			62											
01/02/23 15:00	1			72			74											
01/02/23 16:00	1			77			79											
01/02/23 17:00	1			77			79											
01/02/23 18:00	1			77			79											
01/02/23 19:00	1			77			79											
01/02/23 20:00	1			77			79											
01/02/23 21:00	1			77			78											
01/02/23 22:00	1			76			77											
01/02/23 23:00	1			75			77											
01/03/23 0:00	1			75			76											
01/03/23 1:00	1			75			77											
01/03/23 2:00	1			75			77											
01/03/23 3:00	1			75			77											
01/03/23 4:00	1			75			77											
01/03/23 5:00	1			76			78											
01/03/23 6:00	1			77			79											
01/03/23 7:00	1			78			79											
01/03/23 8:00	1			76			78											
01/03/23 9:00	1			73			75											
01/03/23 10:00	1			71			72											
01/03/23 11:00	1			70			71											
01/03/23 12:00	1			69			71											
01/03/23 13:00	1			69			71											
01/03/23 14:00	1			70			71											
01/03/23 15:00	1			73			74											
01/03/23 16:00	1			75			77											
01/03/23 17:00	1			77			79											
01/03/23 18:00	1			77			78											
01/03/23 19:00	1			76			78											
01/03/23 20:00	1			77			78											
01/03/23 21:00	1			77			79											
01/03/23 22:00	1			77			79											
01/03/23 23:00	1			76			77											
01/04/23 0:00	1			72			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 1:00	1			68			69											
01/04/23 2:00	1			65			66											
01/04/23 3:00	1			65			66											
01/04/23 4:00	1			65			66											
01/04/23 5:00	1			65			66											
01/04/23 6:00	1			65			66											
01/04/23 7:00	1			66			67											
01/04/23 8:00	1			61			63											
01/04/23 9:00	1			39			53											
01/04/23 10:00	1			17			40											
01/04/23 11:00	1			0			33											
01/04/23 12:00	1			0			31											
01/04/23 13:00	1			0			31											
01/04/23 14:00	1			0			31											
01/04/23 15:00	1			0			31											
01/04/23 16:00	1			0			31											
01/04/23 17:00	1			0			31											
01/04/23 18:00	1			0			32											
01/04/23 19:00	1			0			32											
01/04/23 20:00	1			0			32											
01/04/23 21:00	1			0			32											
01/04/23 22:00	1			0			32											
01/04/23 23:00	1			0			32											
01/05/23 0:00	1			0			32											
01/05/23 1:00	1			0			32											
01/05/23 2:00	1			0			32											
01/05/23 3:00	1			0			32											
01/05/23 4:00	1			0			32											
01/05/23 5:00	1			0			32											
01/05/23 6:00	1			0			32											
01/05/23 7:00	1			0			32											
01/05/23 8:00	1			0			32											
01/05/23 9:00	1			0			32											
01/05/23 10:00	1			0			32											
01/05/23 11:00	1			0			32											
01/05/23 12:00	1			0			32											
01/05/23 13:00	1			0			32											
01/05/23 14:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:00	1			6			37											
01/05/23 16:00	1			20			41											
01/05/23 17:00	1			43			54											
01/05/23 18:00	1			58			59											
01/05/23 19:00	1			49			57											
01/05/23 20:00	1			26			44											
01/05/23 21:00	1			6			34											
01/05/23 22:00	1			0			31											
01/05/23 23:00	1			0			31											
01/06/23 0:00	1			0			32											
01/06/23 1:00	1			0			32											
01/06/23 2:00	1			0			32											
01/06/23 3:00	1			0			32											
01/06/23 4:00	1			0			32											
01/06/23 5:00	1			0			32											
01/06/23 6:00	1			0			32											
01/06/23 7:00	1			0			32											
01/06/23 8:00	1			0			32											
01/06/23 9:00	1			0			32											
01/06/23 10:00	1			0			32											
01/06/23 11:00	1			0			32											
01/06/23 12:00	1			0			32											
01/06/23 13:00	1			0			32											
01/06/23 14:00	1			0			32											
01/06/23 15:00	1			0			35											
01/06/23 16:00	1			10			39											
01/06/23 17:00	1			31			50											
01/06/23 18:00	1			54			60											
01/06/23 19:00	1			67			68											
01/06/23 20:00	1			62			64											
01/06/23 21:00	1			48			53											
01/06/23 22:00	1			26			40											
01/06/23 23:00	1			9			33											
01/07/23 0:00	1			0			31											
01/07/23 1:00	1			0			31											
01/07/23 2:00	1			0			31											
01/07/23 3:00	1			0			31											
01/07/23 4:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/07/23 5:00	1			0			31											
01/07/23 6:00	1			0			31											
01/07/23 7:00	1			0			31											
01/07/23 8:00	1			0			31											
01/07/23 9:00	1			0			31											
01/07/23 10:00	1			0			31											
01/07/23 11:00	1			0			31											
01/07/23 12:00	1			0			32											
01/07/23 13:00	1			0			32											
01/07/23 14:00	1			0			32											
01/07/23 15:00	1			0			32											
01/07/23 16:00	1			0			31											
01/07/23 17:00	1			0			31											
01/07/23 18:00	1			0			32											
01/07/23 19:00	1			0			32											
01/07/23 20:00	1			0			32											
01/07/23 21:00	1			0			32											
01/07/23 22:00	1			0			32											
01/07/23 23:00	1			0			32											
01/08/23 0:00	1			0			32											
01/08/23 1:00	1			0			32											
01/08/23 2:00	1			0			32											
01/08/23 3:00	1			0			32											
01/08/23 4:00	1			0			32											
01/08/23 5:00	1			0			32											
01/08/23 6:00	1			0			32											
01/08/23 7:00	1			0			32											
01/08/23 8:00	1			0			32											
01/08/23 9:00	1			0			32											
01/08/23 10:00	1			0			32											
01/08/23 11:00	1			0			32											
01/08/23 12:00	1			0			32											
01/08/23 13:00	1			0			32											
01/08/23 14:00	1			0			31											
01/08/23 15:00	1			0			34											
01/08/23 16:00	1			9			38											
01/08/23 17:00	1			29			48											
01/08/23 18:00	1			52			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 19:00	1			66			68											
01/08/23 20:00	1			69			71											
01/08/23 21:00	1			66			68											
01/08/23 22:00	1			49			56											
01/08/23 23:00	1			26			43											
01/09/23 0:00	1			6			33											
01/09/23 1:00	1			0			32											
01/09/23 2:00	1			0			32											
01/09/23 3:00	1			0			32											
01/09/23 4:00	1			0			32											
01/09/23 5:00	1			0			32											
01/09/23 6:00	1			0			32											
01/09/23 7:00	1			0			32											
01/09/23 8:00	1			0			32											
01/09/23 9:00	1			0			32											
01/09/23 10:00	1			0			32											
01/09/23 11:00	1			0			32											
01/09/23 12:00	1			0			32											
01/09/23 13:00	1			0			35											
01/09/23 14:00	1			10			36											
01/09/23 15:00	1			31			47											
01/09/23 16:00	1			54			57											
01/09/23 17:00	1			68			70											
01/09/23 18:00	1			71			72											
01/09/23 19:00	1			71			72											
01/09/23 20:00	1			71			72											
01/09/23 21:00	1			65			68											
01/09/23 22:00	1			42			56											
01/09/23 23:00	1			18			43											
01/10/23 0:00	1			0			34											
01/10/23 1:00	1			0			32											
01/10/23 2:00	1			0			32											
01/10/23 3:00	1			0			32											
01/10/23 4:00	1			0			32											
01/10/23 5:00	1			0			32											
01/10/23 6:00	1			0			32											
01/10/23 7:00	1			0			32											
01/10/23 8:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 9:00	1			0			31											
01/10/23 10:00	1			0			31											
01/10/23 11:00	1			0			31											
01/10/23 12:00	1			0			31											
01/10/23 13:00	1			0			32											
01/10/23 14:00	1			0			32											
01/10/23 15:00	1			0			35											
01/10/23 16:00	1			10			37											
01/10/23 17:00	1			32			48											
01/10/23 18:00	1			55			59											
01/10/23 19:00	1			68			70											
01/10/23 20:00	1			70			72											
01/10/23 21:00	1			69			71											
01/10/23 22:00	1			66			68											
01/10/23 23:00	1			49			57											
01/11/23 0:00	1			27			44											
01/11/23 1:00	1			6			34											
01/11/23 2:00	1			0			32											
01/11/23 3:00	1			0			32											
01/11/23 4:00	1			0			32											
01/11/23 5:00	1			0			32											
01/11/23 6:00	1			0			32											
01/11/23 7:00	1			0			32											
01/11/23 8:00	1			0			32											
01/11/23 9:00	1			0			32											
01/11/23 10:00	1			0			32											
01/11/23 11:00	1			0			32											
01/11/23 12:00	1			0			31											
01/11/23 13:00	1			0			31											
01/11/23 14:00	1			0			34											
01/11/23 15:00	1			9			37											
01/11/23 16:00	1			29			47											
01/11/23 17:00	1			52			58											
01/11/23 18:00	1			67			68											
01/11/23 19:00	1			69			71											
01/11/23 20:00	1			66			68											
01/11/23 21:00	1			47			58											
01/11/23 22:00	1			24			45											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 23:00	1			4			35											
01/12/23 0:00	1			0			31											
01/12/23 1:00	1			0			31											
01/12/23 2:00	1			0			31											
01/12/23 3:00	1			0			31											
01/12/23 4:00	1			0			31											
01/12/23 5:00	1			0			31											
01/12/23 6:00	1			0			32											
01/12/23 7:00	1			0			32											
01/12/23 8:00	1			0			32											
01/12/23 9:00	1			0			32											
01/12/23 10:00	1			0			32											
01/12/23 11:00	1			0			32											
01/12/23 12:00	1			0			32											
01/12/23 13:00	1			0			32											
01/12/23 14:00	1			0			32											
01/12/23 15:00	1			1			34											
01/12/23 16:00	1			11			34											
01/12/23 17:00	1			30			43											
01/12/23 18:00	1			53			54											
01/12/23 19:00	1			65			66											
01/12/23 20:00	1			68			70											
01/12/23 21:00	1			65			67											
01/12/23 22:00	1			48			56											
01/12/23 23:00	1			26			43											
01/13/23 0:00	1			6			33											
01/13/23 1:00	1			0			31											
01/13/23 2:00	1			0			32											
01/13/23 3:00	1			0			32											
01/13/23 4:00	1			0			32											
01/13/23 5:00	1			0			32											
01/13/23 6:00	1			0			32											
01/13/23 7:00	1			0			32											
01/13/23 8:00	1			0			32											
01/13/23 9:00	1			0			31											
01/13/23 10:00	1			0			31											
01/13/23 11:00	1			0			31											
01/13/23 12:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/13/23 13:00	1			0			32											
01/13/23 14:00	1			0			32											
01/13/23 15:00	1			0			32											
01/13/23 16:00	1			0			32											
01/13/23 17:00	1			0			32											
01/13/23 18:00	1			0			31											
01/13/23 19:00	1			0			31											
01/13/23 20:00	1			0			32											
01/13/23 21:00	1			0			32											
01/13/23 22:00	1			0			32											
01/13/23 23:00	1			0			32											
01/14/23 0:00	1			0			32											
01/14/23 1:00	1			0			32											
01/14/23 2:00	1			0			32											
01/14/23 3:00	1			0			32											
01/14/23 4:00	1			0			32											
01/14/23 5:00	1			0			32											
01/14/23 6:00	1			0			32											
01/14/23 7:00	1			0			32											
01/14/23 8:00	1			0			32											
01/14/23 9:00	1			0			35											
01/14/23 10:00	1			0			37											
01/14/23 11:00	1			0			36											
01/14/23 12:00	1			0			33											
01/14/23 13:00	1			0			31											
01/14/23 14:00	1			0			35											
01/14/23 15:00	1			9			37											
01/14/23 16:00	1			29			47											
01/14/23 17:00	1			52			56											
01/14/23 18:00	1			66			67											
01/14/23 19:00	1			67			68											
01/14/23 20:00	1			50			57											
01/14/23 21:00	1			27			44											
01/14/23 22:00	1			7			33											
01/14/23 23:00	1			0			31											
01/15/23 0:00	1			0			31											
01/15/23 1:00	1			0			32											
01/15/23 2:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 3:00	1			0			32											
01/15/23 4:00	1			0			32											
01/15/23 5:00	1			0			32											
01/15/23 6:00	1			0			32											
01/15/23 7:00	1			0			32											
01/15/23 8:00	1			0			32											
01/15/23 9:00	1			0			32											
01/15/23 10:00	1			0			32											
01/15/23 11:00	1			0			32											
01/15/23 12:00	1			0			32											
01/15/23 13:00	1			0			32											
01/15/23 14:00	1			0			36											
01/15/23 15:00	1			9			38											
01/15/23 16:00	1			30			49											
01/15/23 17:00	1			53			58											
01/15/23 18:00	1			67			69											
01/15/23 19:00	1			69			71											
01/15/23 20:00	1			68			70											
01/15/23 21:00	1			63			65											
01/15/23 22:00	1			46			54											
01/15/23 23:00	1			23			42											
01/16/23 0:00	1			5			34											
01/16/23 1:00	1			0			31											
01/16/23 2:00	1			0			31											
01/16/23 3:00	1			0			31											
01/16/23 4:00	1			0			31											
01/16/23 5:00	1			0			31											
01/16/23 6:00	1			0			32											
01/16/23 7:00	1			0			32											
01/16/23 8:00	1			0			31											
01/16/23 9:00	1			0			31											
01/16/23 10:00	1			0			31											
01/16/23 11:00	1			0			31											
01/16/23 12:00	1			0			32											
01/16/23 13:00	1			0			32											
01/16/23 14:00	1			0			33											
01/16/23 15:00	1			8			34											
01/16/23 16:00	1			25			41											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 17:00	1			47			52											
01/16/23 18:00	1			62			63											
01/16/23 19:00	1			68			70											
01/16/23 20:00	1			68			70											
01/16/23 21:00	1			68			70											
01/16/23 22:00	1			63			65											
01/16/23 23:00	1			40			54											
01/17/23 0:00	1			17			41											
01/17/23 1:00	1			0			33											
01/17/23 2:00	1			0			31											
01/17/23 3:00	1			0			31											
01/17/23 4:00	1			0			31											
01/17/23 5:00	1			0			32											
01/17/23 6:00	1			0			32											
01/17/23 7:00	1			0			33											
01/17/23 8:00	1			0			33											
01/17/23 9:00	1			0			33											
01/17/23 10:00	1			0			31											
01/17/23 11:00	1			0			31											
01/17/23 12:00	1			0			31											
01/17/23 13:00	1			0			32											
01/17/23 14:00	1			0			32											
01/17/23 15:00	1			0			32											
01/17/23 16:00	1			0			34											
01/17/23 17:00	1			9			37											
01/17/23 18:00	1			28			46											
01/17/23 19:00	1			51			56											
01/17/23 20:00	1			65			66											
01/17/23 21:00	1			69			70											
01/17/23 22:00	1			68			70											
01/17/23 23:00	1			68			70											
01/18/23 0:00	1			68			70											
01/18/23 1:00	1			68			70											
01/18/23 2:00	1			68			70											
01/18/23 3:00	1			68			70											
01/18/23 4:00	1			68			70											
01/18/23 5:00	1			68			70											
01/18/23 6:00	1			68			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 7:00	1			68			70											
01/18/23 8:00	1			66			67											
01/18/23 9:00	1			49			57											
01/18/23 10:00	1			26			44											
01/18/23 11:00	1			6			33											
01/18/23 12:00	1			0			31											
01/18/23 13:00	1			0			31											
01/18/23 14:00	1			0			31											
01/18/23 15:00	1			0			31											
01/18/23 16:00	1			0			31											
01/18/23 17:00	1			0			31											
01/18/23 18:00	1			0			31											
01/18/23 19:00	1			0			31											
01/18/23 20:00	1			0			31											
01/18/23 21:00	1			0			31											
01/18/23 22:00	1			0			31											
01/18/23 23:00	1			0			31											
01/19/23 0:00	1			0			31											
01/19/23 1:00	1			0			31											
01/19/23 2:00	1			0			31											
01/19/23 3:00	1			0			31											
01/19/23 4:00	1			0			31											
01/19/23 5:00	1			0			31											
01/19/23 6:00	1			0			31											
01/19/23 7:00	1			0			31											
01/19/23 8:00	1			0			31											
01/19/23 9:00	1			0			31											
01/19/23 10:00	1			0			31											
01/19/23 11:00	1			0			31											
01/19/23 12:00	1			0			31											
01/19/23 13:00	1			0			31											
01/19/23 14:00	1			0			31											
01/19/23 15:00	1			0			31											
01/19/23 16:00	1			0			31											
01/19/23 17:00	1			0			37											
01/19/23 18:00	1			0			48											
01/19/23 19:00	1			0			58											
01/19/23 20:00	1			0			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/19/23 21:00	1			0			63											
01/19/23 22:00	1			0			63											
01/19/23 23:00	1			0			63											
01/20/23 0:00	1			0			63											
01/20/23 1:00	1			0			63											
01/20/23 2:00	1			0			63											
01/20/23 3:00	1			0			63											
01/20/23 4:00	1			0			63											
01/20/23 5:00	1			0			63											
01/20/23 6:00	1			0			63											
01/20/23 7:00	1			0			63											
01/20/23 8:00	1			0			63											
01/20/23 9:00	1			0			63											
01/20/23 10:00	1			0			63											
01/20/23 11:00	1			0			62											
01/20/23 12:00	1			0			54											
01/20/23 13:00	1			0			43											
01/20/23 14:00	1			0			33											
01/20/23 15:00	1			0			31											
01/20/23 16:00	1			0			31											
01/20/23 17:00	1			0			37											
01/20/23 18:00	1			0			48											
01/20/23 19:00	1			0			59											
01/20/23 20:00	1			0			63											
01/20/23 21:00	1			0			63											
01/20/23 22:00	1			0			63											
01/20/23 23:00	1			0			63											
01/21/23 0:00	1			0			63											
01/21/23 1:00	1			0			62											
01/21/23 2:00	1			0			62											
01/21/23 3:00	1			0			62											
01/21/23 4:00	1			0			62											
01/21/23 5:00	1			0			62											
01/21/23 6:00	1			0			62											
01/21/23 7:00	1			0			62											
01/21/23 8:00	1			0			62											
01/21/23 9:00	1			0			53											
01/21/23 10:00	1			0			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/21/23 11:00	1			0			33											
01/21/23 12:00	1			0			31											
01/21/23 13:00	1			0			31											
01/21/23 14:00	1			0			31											
01/21/23 15:00	1			0			31											
01/21/23 16:00	1			0			37											
01/21/23 17:00	1			0			48											
01/21/23 18:00	1			0			58											
01/21/23 19:00	1			0			63											
01/21/23 20:00	1			0			63											
01/21/23 21:00	1			0			64											
01/21/23 22:00	1			0			61											
01/21/23 23:00	1			0			50											
01/22/23 0:00	1			0			39											
01/22/23 1:00	1			0			31											
01/22/23 2:00	1			0			31											
01/22/23 3:00	1			0			31											
01/22/23 4:00	1			0			31											
01/22/23 5:00	1			0			32											
01/22/23 6:00	1			0			32											
01/22/23 7:00	1			0			32											
01/22/23 8:00	1			0			31											
01/22/23 9:00	1			0			31											
01/22/23 10:00	1			0			31											
01/22/23 11:00	1			0			31											
01/22/23 12:00	1			0			31											
01/22/23 13:00	1			0			31											
01/22/23 14:00	1			0			31											
01/22/23 15:00	1			0			31											
01/22/23 16:00	1			0			37											
01/22/23 17:00	1			0			48											
01/22/23 18:00	1			0			60											
01/22/23 19:00	1			0			65											
01/22/23 20:00	1			0			65											
01/22/23 21:00	1			0			65											
01/22/23 22:00	1			0			65											
01/22/23 23:00	1			0			65											
01/23/23 0:00	1			0			65											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 1:00	1			0			65											
01/23/23 2:00	1			0			65											
01/23/23 3:00	1			0			65											
01/23/23 4:00	1			0			65											
01/23/23 5:00	1			0			65											
01/23/23 6:00	1			0			65											
01/23/23 7:00	1			0			66											
01/23/23 8:00	1			0			66											
01/23/23 9:00	1			0			57											
01/23/23 10:00	1			0			45											
01/23/23 11:00	1			0			33											
01/23/23 12:00	1			0			31											
01/23/23 13:00	1			0			31											
01/23/23 14:00	1			0			31											
01/23/23 15:00	1			0			34											
01/23/23 16:00	1			8			38											
01/23/23 17:00	1			27			47											
01/23/23 18:00	1			50			58											
01/23/23 19:00	1			67			69											
01/23/23 20:00	1			73			75											
01/23/23 21:00	1			74			76											
01/23/23 22:00	1			73			75											
01/23/23 23:00	1			71			74											
01/24/23 0:00	1			69			71											
01/24/23 1:00	1			67			68											
01/24/23 2:00	1			65			66											
01/24/23 3:00	1			65			66											
01/24/23 4:00	1			65			66											
01/24/23 5:00	1			67			68											
01/24/23 6:00	1			71			73											
01/24/23 7:00	1			72			74											
01/24/23 8:00	1			72			73											
01/24/23 9:00	1			63			64											
01/24/23 10:00	1			46			53											
01/24/23 11:00	1			23			40											
01/24/23 12:00	1			6			33											
01/24/23 13:00	1			0			31											
01/24/23 14:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 15:00	1			0			31											
01/24/23 16:00	1			0			32											
01/24/23 17:00	1			0			32											
01/24/23 18:00	1			0			38											
01/24/23 19:00	1			0			40											
01/24/23 20:00	1			0			40											
01/24/23 21:00	1			0			34											
01/24/23 22:00	1			0			32											
01/24/23 23:00	1			0			32											
01/25/23 0:00	1			0			32											
01/25/23 1:00	1			0			32											
01/25/23 2:00	1			0			31											
01/25/23 3:00	1			0			31											
01/25/23 4:00	1			0			31											
01/25/23 5:00	1			0			31											
01/25/23 6:00	1			0			31											
01/25/23 7:00	1			0			31											
01/25/23 8:00	1			0			31											
01/25/23 9:00	1			0			31											
01/25/23 10:00	1			0			31											
01/25/23 11:00	1			0			31											
01/25/23 12:00	1			0			31											
01/25/23 13:00	1			0			31											
01/25/23 14:00	1			0			31											
01/25/23 15:00	1			0			31											
01/25/23 16:00	1			0			31											
01/25/23 17:00	1			0			31											
01/25/23 18:00	1			0			31											
01/25/23 19:00	1			0			31											
01/25/23 20:00	1			0			31											
01/25/23 21:00	1			0			31											
01/25/23 22:00	1			0			31											
01/25/23 23:00	1			0			31											
01/26/23 0:00	1			0			31											
01/26/23 1:00	1			0			31											
01/26/23 2:00	1			0			31											
01/26/23 3:00	1			0			31											
01/26/23 4:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/26/23 5:00	1			0			31											
01/26/23 6:00	1			0			31											
01/26/23 7:00	1			0			31											
01/26/23 8:00	1			0			31											
01/26/23 9:00	1			0			31											
01/26/23 10:00	1			0			31											
01/26/23 11:00	1			0			31											
01/26/23 12:00	1			0			31											
01/26/23 13:00	1			0			31											
01/26/23 14:00	1			0			31											
01/26/23 15:00	1			0			31											
01/26/23 16:00	1			0			31											
01/26/23 17:00	1			0			31											
01/26/23 18:00	1			0			31											
01/26/23 19:00	1			0			31											
01/26/23 20:00	1			0			31											
01/26/23 21:00	1			0			31											
01/26/23 22:00	1			0			31											
01/26/23 23:00	1			0			31											
01/27/23 0:00	1			0			31											
01/27/23 1:00	1			0			31											
01/27/23 2:00	1			0			31											
01/27/23 3:00	1			0			31											
01/27/23 4:00	1			0			31											
01/27/23 5:00	1			0			31											
01/27/23 6:00	1			0			31											
01/27/23 7:00	1			0			31											
01/27/23 8:00	1			0			31											
01/27/23 9:00	1			0			31											
01/27/23 10:00	1			0			31											
01/27/23 11:00	1			0			31											
01/27/23 12:00	1			0			31											
01/27/23 13:00	1			0			31											
01/27/23 14:00	1			0			31											
01/27/23 15:00	1			0			34											
01/27/23 16:00	1			9			40											
01/27/23 17:00	1			30			51											
01/27/23 18:00	1			53			61											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 19:00	1			65			66											
01/27/23 20:00	1			57			56											
01/27/23 21:00	1			45			32											
01/27/23 22:00	1			34			11											
01/27/23 23:00	1			31			0											
01/28/23 0:00	1			31			0											
01/28/23 1:00	1			31			0											
01/28/23 2:00	1			31			0											
01/28/23 3:00	1			31			0											
01/28/23 4:00	1			31			0											
01/28/23 5:00	1			31			0											
01/28/23 6:00	1			32			0											
01/28/23 7:00	1			32			0											
01/28/23 8:00	1			32			0											
01/28/23 9:00	1			31			0											
01/28/23 10:00	1			31			0											
01/28/23 11:00	1			31			0											
01/28/23 12:00	1			31			0											
01/28/23 13:00	1			31			0											
01/28/23 14:00	1			31			0											
01/28/23 15:00	1			31			0											
01/28/23 16:00	1			31			0											
01/28/23 17:00	1			31			0											
01/28/23 18:00	1			31			0											
01/28/23 19:00	1			31			0											
01/28/23 20:00	1			31			0											
01/28/23 21:00	1			31			0											
01/28/23 22:00	1			31			0											
01/28/23 23:00	1			31			0											
01/29/23 0:00	1			31			0											
01/29/23 1:00	1			31			0											
01/29/23 2:00	1			31			0											
01/29/23 3:00	1			31			0											
01/29/23 4:00	1			31			0											
01/29/23 5:00	1			31			0											
01/29/23 6:00	1			31			0											
01/29/23 7:00	1			31			0											
01/29/23 8:00	1			34			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:00	1			40			10											
01/29/23 10:00	1			51			32											
01/29/23 11:00	1			60			55											
01/29/23 12:00	1			60			59											
01/29/23 13:00	1			49			37											
01/29/23 14:00	1			37			14											
01/29/23 15:00	1			32			0											
01/29/23 16:00	1			32			0											
01/29/23 17:00	1			32			0											
01/29/23 18:00	1			31			0											
01/29/23 19:00	1			31			0											
01/29/23 20:00	1			31			0											
01/29/23 21:00	1			31			0											
01/29/23 22:00	1			31			0											
01/29/23 23:00	1			31			0											
01/30/23 0:00	1			31			0											
01/30/23 1:00	1			31			0											
01/30/23 2:00	1			38			0											
01/30/23 3:00	1			49			0											
01/30/23 4:00	1			61			0											
01/30/23 5:00	1			67			0											
01/30/23 6:00	1			68			0											
01/30/23 7:00	1			74			0											
01/30/23 8:00	1			78			0											
01/30/23 9:00	1			77			0											
01/30/23 10:00	1			72			0											
01/30/23 11:00	1			66			0											
01/30/23 12:00	1			65			0											
01/30/23 13:00	1			65			0											
01/30/23 14:00	1			65			0											
01/30/23 15:00	1			65			0											
01/30/23 16:00	1			65			0											
01/30/23 17:00	1			65			0											
01/30/23 18:00	1			65			0											
01/30/23 19:00	1			65			0											
01/30/23 20:00	1			65			0											
01/30/23 21:00	1			66			0											
01/30/23 22:00	1			66			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/30/23 23:00	1			66			0											
01/31/23 0:00	1			66			0											
01/31/23 1:00	1			66			0											
01/31/23 2:00	1			66			0											
01/31/23 3:00	1			66			0											
01/31/23 4:00	1			66			0											
01/31/23 5:00	1			67			0											
01/31/23 6:00	1			67			0											
01/31/23 7:00	1			68			0											
01/31/23 8:00	1			68			0											
01/31/23 9:00	1			67			0											
01/31/23 10:00	1			66			0											
01/31/23 11:00	1			65			0											
01/31/23 12:00	1			65			0											
01/31/23 13:00	1			62			0											
01/31/23 14:00	1			51			0											
01/31/23 15:00	1			46			0											
01/31/23 16:00	1			49			0											
01/31/23 17:00	1			60			0											
01/31/23 18:00	1			65			0											
01/31/23 19:00	1			65			0											
01/31/23 20:00	1			65			0											
01/31/23 21:00	1			65			0											
01/31/23 22:00	1			66			0											
01/31/23 23:00	1			66			0											
02/01/23 0:00	1			66			0											
02/01/23 1:00	1			66			0											
02/01/23 2:00	1			66			0											
02/01/23 3:00	1			66			0											
02/01/23 4:00	1			66			0											
02/01/23 5:00	1			66			0											
02/01/23 6:00	1			66			0											
02/01/23 7:00	1			66			0											
02/01/23 8:00	1			66			0											
02/01/23 9:00	1			66			0											
02/01/23 10:00	1			58			0											
02/01/23 11:00	1			47			0											
02/01/23 12:00	1			35			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/01/23 13:00	1			31			0											
02/01/23 14:00	1			31			0											
02/01/23 15:00	1			31			0											
02/01/23 16:00	1			31			0											
02/01/23 17:00	1			31			0											
02/01/23 18:00	1			31			0											
02/01/23 19:00	1			31			0											
02/01/23 20:00	1			31			0											
02/01/23 21:00	1			31			0											
02/01/23 22:00	1			31			0											
02/01/23 23:00	1			31			0											
02/02/23 0:00	1			31			0											
02/02/23 1:00	1			31			0											
02/02/23 2:00	1			31			0											
02/02/23 3:00	1			31			0											
02/02/23 4:00	1			31			0											
02/02/23 5:00	1			31			0											
02/02/23 6:00	1			31			0											
02/02/23 7:00	1			31			0											
02/02/23 8:00	1			31			0											
02/02/23 9:00	1			31			0											
02/02/23 10:00	1			31			0											
02/02/23 11:00	1			31			0											
02/02/23 12:00	1			31			0											
02/02/23 13:00	1			31			0											
02/02/23 14:00	1			31			0											
02/02/23 15:00	1			31			0											
02/02/23 16:00	1			31			0											
02/02/23 17:00	1			31			0											
02/02/23 18:00	1			31			0											
02/02/23 19:00	1			31			0											
02/02/23 20:00	1			31			0											
02/02/23 21:00	1			31			0											
02/02/23 22:00	1			31			0											
02/02/23 23:00	1			31			0											
02/03/23 0:00	1			31			0											
02/03/23 1:00	1			31			0											
02/03/23 2:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 3:00	1			31			0											
02/03/23 4:00	1			31			0											
02/03/23 5:00	1			31			0											
02/03/23 6:00	1			31			0											
02/03/23 7:00	1			33			0											
02/03/23 8:00	1			35			0											
02/03/23 9:00	1			35			0											
02/03/23 10:00	1			33			0											
02/03/23 11:00	1			38			0											
02/03/23 12:00	1			49			0											
02/03/23 13:00	1			60			0											
02/03/23 14:00	1			65			0											
02/03/23 15:00	1			65			0											
02/03/23 16:00	1			57			8											
02/03/23 17:00	1			54			28											
02/03/23 18:00	1			56			52											
02/03/23 19:00	1			66			68											
02/03/23 20:00	1			71			73											
02/03/23 21:00	1			71			72											
02/03/23 22:00	1			70			72											
02/03/23 23:00	1			67			69											
02/04/23 0:00	1			50			57											
02/04/23 1:00	1			27			44											
02/04/23 2:00	1			7			33											
02/04/23 3:00	1			0			31											
02/04/23 4:00	1			0			31											
02/04/23 5:00	1			0			31											
02/04/23 6:00	1			0			31											
02/04/23 7:00	1			0			31											
02/04/23 8:00	1			0			31											
02/04/23 9:00	1			0			31											
02/04/23 10:00	1			0			31											
02/04/23 11:00	1			0			31											
02/04/23 12:00	1			0			31											
02/04/23 13:00	1			0			31											
02/04/23 14:00	1			0			31											
02/04/23 15:00	1			0			33											
02/04/23 16:00	1			8			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 17:00	1			27			46											
02/04/23 18:00	1			50			57											
02/04/23 19:00	1			66			67											
02/04/23 20:00	1			70			72											
02/04/23 21:00	1			71			73											
02/04/23 22:00	1			68			70											
02/04/23 23:00	1			50			57											
02/05/23 0:00	1			27			43											
02/05/23 1:00	1			6			33											
02/05/23 2:00	1			0			31											
02/05/23 3:00	1			0			31											
02/05/23 4:00	1			0			32											
02/05/23 5:00	1			0			32											
02/05/23 6:00	1			0			32											
02/05/23 7:00	1			0			32											
02/05/23 8:00	1			0			32											
02/05/23 9:00	1			0			32											
02/05/23 10:00	1			0			32											
02/05/23 11:00	1			0			32											
02/05/23 12:00	1			0			32											
02/05/23 13:00	1			0			32											
02/05/23 14:00	1			0			32											
02/05/23 15:00	1			0			32											
02/05/23 16:00	1			0			32											
02/05/23 17:00	1			0			34											
02/05/23 18:00	1			9			36											
02/05/23 19:00	1			23			40											
02/05/23 20:00	1			44			48											
02/05/23 21:00	1			55			57											
02/05/23 22:00	1			50			56											
02/05/23 23:00	1			29			45											
02/06/23 0:00	1			8			34											
02/06/23 1:00	1			0			32											
02/06/23 2:00	1			0			32											
02/06/23 3:00	1			0			32											
02/06/23 4:00	1			0			31											
02/06/23 5:00	1			0			31											
02/06/23 6:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 7:00	1			0			31											
02/06/23 8:00	1			0			31											
02/06/23 9:00	1			0			31											
02/06/23 10:00	1			0			31											
02/06/23 11:00	1			0			31											
02/06/23 12:00	1			0			31											
02/06/23 13:00	1			0			31											
02/06/23 14:00	1			0			31											
02/06/23 15:00	1			0			34											
02/06/23 16:00	1			10			36											
02/06/23 17:00	1			32			48											
02/06/23 18:00	1			56			59											
02/06/23 19:00	1			70			72											
02/06/23 20:00	1			73			75											
02/06/23 21:00	1			73			75											
02/06/23 22:00	1			69			70											
02/06/23 23:00	1			53			58											
02/07/23 0:00	1			30			44											
02/07/23 1:00	1			10			34											
02/07/23 2:00	1			0			32											
02/07/23 3:00	1			0			32											
02/07/23 4:00	1			0			32											
02/07/23 5:00	1			0			32											
02/07/23 6:00	1			0			32											
02/07/23 7:00	1			0			32											
02/07/23 8:00	1			0			32											
02/07/23 9:00	1			0			32											
02/07/23 10:00	1			0			31											
02/07/23 11:00	1			0			31											
02/07/23 12:00	1			0			31											
02/07/23 13:00	1			0			31											
02/07/23 14:00	1			0			31											
02/07/23 15:00	1			0			34											
02/07/23 16:00	1			12			37											
02/07/23 17:00	1			34			50											
02/07/23 18:00	1			58			61											
02/07/23 19:00	1			71			73											
02/07/23 20:00	1			74			76											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 21:00	1			74			76											
02/07/23 22:00	1			74			76											
02/07/23 23:00	1			72			74											
02/08/23 0:00	1			69			70											
02/08/23 1:00	1			66			67											
02/08/23 2:00	1			62			64											
02/08/23 3:00	1			61			63											
02/08/23 4:00	1			61			63											
02/08/23 5:00	1			62			64											
02/08/23 6:00	1			67			68											
02/08/23 7:00	1			68			70											
02/08/23 8:00	1			60			57											
02/08/23 9:00	1			46			32											
02/08/23 10:00	1			35			10											
02/08/23 11:00	1			32			0											
02/08/23 12:00	1			32			0											
02/08/23 13:00	1			32			0											
02/08/23 14:00	1			32			0											
02/08/23 15:00	1			34			0											
02/08/23 16:00	1			37			11											
02/08/23 17:00	1			49			34											
02/08/23 18:00	1			61			60											
02/08/23 19:00	1			72			74											
02/08/23 20:00	1			74			75											
02/08/23 21:00	1			74			76											
02/08/23 22:00	1			74			76											
02/08/23 23:00	1			73			75											
02/09/23 0:00	1			69			71											
02/09/23 1:00	1			66			67											
02/09/23 2:00	1			64			65											
02/09/23 3:00	1			64			65											
02/09/23 4:00	1			64			66											
02/09/23 5:00	1			67			69											
02/09/23 6:00	1			71			73											
02/09/23 7:00	1			70			72											
02/09/23 8:00	1			58			54											
02/09/23 9:00	1			43			28											
02/09/23 10:00	1			34			7											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 11:00	1			32			0											
02/09/23 12:00	1			32			0											
02/09/23 13:00	1			32			0											
02/09/23 14:00	1			32			0											
02/09/23 15:00	1			33			0											
02/09/23 16:00	1			36			8											
02/09/23 17:00	1			46			29											
02/09/23 18:00	1			59			55											
02/09/23 19:00	1			70			71											
02/09/23 20:00	1			74			75											
02/09/23 21:00	1			74			75											
02/09/23 22:00	1			74			75											
02/09/23 23:00	1			67			67											
02/10/23 0:00	1			54			42											
02/10/23 1:00	1			40			17											
02/10/23 2:00	1			33			0											
02/10/23 3:00	1			32			0											
02/10/23 4:00	1			32			0											
02/10/23 5:00	1			32			0											
02/10/23 6:00	1			32			0											
02/10/23 7:00	1			32			0											
02/10/23 8:00	1			32			0											
02/10/23 9:00	1			32			0											
02/10/23 10:00	1			32			0											
02/10/23 11:00	1			32			0											
02/10/23 12:00	1			32			0											
02/10/23 13:00	1			32			0											
02/10/23 14:00	1			32			0											
02/10/23 15:00	1			34			0											
02/10/23 16:00	1			35			10											
02/10/23 17:00	1			45			31											
02/10/23 18:00	1			55			54											
02/10/23 19:00	1			66			67											
02/10/23 20:00	1			69			71											
02/10/23 21:00	1			70			71											
02/10/23 22:00	1			70			72											
02/10/23 23:00	1			70			72											
02/11/23 0:00	1			70			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 1:00	1			69			71											
02/11/23 2:00	1			69			71											
02/11/23 3:00	1			68			70											
02/11/23 4:00	1			68			70											
02/11/23 5:00	1			68			70											
02/11/23 6:00	1			69			70											
02/11/23 7:00	1			68			69											
02/11/23 8:00	1			56			61											
02/11/23 9:00	1			33			49											
02/11/23 10:00	1			11			37											
02/11/23 11:00	1			0			32											
02/11/23 12:00	1			0			31											
02/11/23 13:00	1			0			32											
02/11/23 14:00	1			0			32											
02/11/23 15:00	1			0			35											
02/11/23 16:00	1			9			38											
02/11/23 17:00	1			30			48											
02/11/23 18:00	1			53			58											
02/11/23 19:00	1			66			68											
02/11/23 20:00	1			69			71											
02/11/23 21:00	1			70			72											
02/11/23 22:00	1			70			72											
02/11/23 23:00	1			71			72											
02/12/23 0:00	1			71			72											
02/12/23 1:00	1			71			72											
02/12/23 2:00	1			72			73											
02/12/23 3:00	1			72			73											
02/12/23 4:00	1			71			73											
02/12/23 5:00	1			71			73											
02/12/23 6:00	1			71			73											
02/12/23 7:00	1			68			69											
02/12/23 8:00	1			58			56											
02/12/23 9:00	1			44			32											
02/12/23 10:00	1			34			11											
02/12/23 11:00	1			31			0											
02/12/23 12:00	1			31			0											
02/12/23 13:00	1			31			0											
02/12/23 14:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:00	1			36			6											
02/12/23 16:00	1			43			23											
02/12/23 17:00	1			56			47											
02/12/23 18:00	1			63			64											
02/12/23 19:00	1			70			71											
02/12/23 20:00	1			71			72											
02/12/23 21:00	1			70			72											
02/12/23 22:00	1			63			65											
02/12/23 23:00	1			53			54											
02/13/23 0:00	1			41			45											
02/13/23 1:00	1			24			39											
02/13/23 2:00	1			11			36											
02/13/23 3:00	1			0			32											
02/13/23 4:00	1			0			32											
02/13/23 5:00	1			0			32											
02/13/23 6:00	1			0			32											
02/13/23 7:00	1			0			33											
02/13/23 8:00	1			0			33											
02/13/23 9:00	1			0			33											
02/13/23 10:00	1			0			32											
02/13/23 11:00	1			0			32											
02/13/23 12:00	1			0			32											
02/13/23 13:00	1			0			32											
02/13/23 14:00	1			0			32											
02/13/23 15:00	1			0			32											
02/13/23 16:00	1			0			32											
02/13/23 17:00	1			0			32											
02/13/23 18:00	1			0			32											
02/13/23 19:00	1			0			32											
02/13/23 20:00	1			0			31											
02/13/23 21:00	1			0			32											
02/13/23 22:00	1			0			31											
02/13/23 23:00	1			0			32											
02/14/23 0:00	1			0			31											
02/14/23 1:00	1			0			32											
02/14/23 2:00	1			0			32											
02/14/23 3:00	1			0			32											
02/14/23 4:00	1			0			32											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 5:00	1			0			32											
02/14/23 6:00	1			0			32											
02/14/23 7:00	1			0			32											
02/14/23 8:00	1			0			32											
02/14/23 9:00	1			0			32											
02/14/23 10:00	1			0			32											
02/14/23 11:00	1			0			32											
02/14/23 12:00	1			0			32											
02/14/23 13:00	1			0			32											
02/14/23 14:00	1			0			33											
02/14/23 15:00	1			5			40											
02/14/23 16:00	1			24			49											
02/14/23 17:00	1			49			62											
02/14/23 18:00	1			69			71											
02/14/23 19:00	1			74			76											
02/14/23 20:00	1			75			77											
02/14/23 21:00	1			73			75											
02/14/23 22:00	1			72			74											
02/14/23 23:00	1			71			73											
02/15/23 0:00	1			71			72											
02/15/23 1:00	1			72			73											
02/15/23 2:00	1			72			73											
02/15/23 3:00	1			72			74											
02/15/23 4:00	1			73			75											
02/15/23 5:00	1			75			76											
02/15/23 6:00	1			76			77											
02/15/23 7:00	1			76			61											
02/15/23 8:00	1			64			52											
02/15/23 9:00	1			38			38											
02/15/23 10:00	1			13			39											
02/15/23 11:00	1			0			33											
02/15/23 12:00	1			0			31											
02/15/23 13:00	1			0			31											
02/15/23 14:00	1			0			31											
02/15/23 15:00	1			0			32											
02/15/23 16:00	1			7			36											
02/15/23 17:00	1			27			46											
02/15/23 18:00	1			52			61											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 19:00	1			71			72											
02/15/23 20:00	1			77			79											
02/15/23 21:00	1			77			79											
02/15/23 22:00	1			77			79											
02/15/23 23:00	1			76			78											
02/16/23 0:00	1			72			73											
02/16/23 1:00	1			68			69											
02/16/23 2:00	1			64			66											
02/16/23 3:00	1			64			66											
02/16/23 4:00	1			64			66											
02/16/23 5:00	1			64			66											
02/16/23 6:00	1			64			66											
02/16/23 7:00	1			66			68											
02/16/23 8:00	1			61			63											
02/16/23 9:00	1			39			54											
02/16/23 10:00	1			16			40											
02/16/23 11:00	1			0			33											
02/16/23 12:00	1			0			31											
02/16/23 13:00	1			0			31											
02/16/23 14:00	1			0			31											
02/16/23 15:00	1			0			32											
02/16/23 16:00	1			7			36											
02/16/23 17:00	1			24			44											
02/16/23 18:00	1			47			55											
02/16/23 19:00	1			63			64											
02/16/23 20:00	1			70			71											
02/16/23 21:00	1			71			72											
02/16/23 22:00	1			72			73											
02/16/23 23:00	1			71			73											
02/17/23 0:00	1			70			72											
02/17/23 1:00	1			69			71											
02/17/23 2:00	1			69			71											
02/17/23 3:00	1			59			61											
02/17/23 4:00	1			36			50											
02/17/23 5:00	1			14			37											
02/17/23 6:00	1			0			33											
02/17/23 7:00	1			0			31											
02/17/23 8:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 9:00	1			0			31											
02/17/23 10:00	1			0			31											
02/17/23 11:00	1			0			31											
02/17/23 12:00	1			0			31											
02/17/23 13:00	1			0			32											
02/17/23 14:00	1			0			32											
02/17/23 15:00	1			0			32											
02/17/23 16:00	1			0			31											
02/17/23 17:00	1			0			31											
02/17/23 18:00	1			0			31											
02/17/23 19:00	1			0			31											
02/17/23 20:00	1			0			31											
02/17/23 21:00	1			0			31											
02/17/23 22:00	1			0			31											
02/17/23 23:00	1			0			32											
02/18/23 0:00	1			0			31											
02/18/23 1:00	1			0			31											
02/18/23 2:00	1			0			31											
02/18/23 3:00	1			0			31											
02/18/23 4:00	1			0			31											
02/18/23 5:00	1			0			31											
02/18/23 6:00	1			0			31											
02/18/23 7:00	1			0			31											
02/18/23 8:00	1			0			31											
02/18/23 9:00	1			0			31											
02/18/23 10:00	1			0			31											
02/18/23 11:00	1			0			31											
02/18/23 12:00	1			0			31											
02/18/23 13:00	1			0			31											
02/18/23 14:00	1			0			31											
02/18/23 15:00	1			0			31											
02/18/23 16:00	1			0			31											
02/18/23 17:00	1			0			31											
02/18/23 18:00	1			0			31											
02/18/23 19:00	1			0			31											
02/18/23 20:00	1			0			31											
02/18/23 21:00	1			0			31											
02/18/23 22:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/18/23 23:00	1			0			31											
02/19/23 0:00	1			0			31											
02/19/23 1:00	1			0			31											
02/19/23 2:00	1			0			31											
02/19/23 3:00	1			0			31											
02/19/23 4:00	1			0			31											
02/19/23 5:00	1			0			31											
02/19/23 6:00	1			0			31											
02/19/23 7:00	1			0			31											
02/19/23 8:00	1			0			31											
02/19/23 9:00	1			0			31											
02/19/23 10:00	1			0			31											
02/19/23 11:00	1			0			31											
02/19/23 12:00	1			0			31											
02/19/23 13:00	1			0			31											
02/19/23 14:00	1			0			31											
02/19/23 15:00	1			0			31											
02/19/23 16:00	1			0			31											
02/19/23 17:00	1			0			31											
02/19/23 18:00	1			0			31											
02/19/23 19:00	1			0			31											
02/19/23 20:00	1			0			31											
02/19/23 21:00	1			0			31											
02/19/23 22:00	1			0			31											
02/19/23 23:00	1			0			31											
02/20/23 0:00	1			0			31											
02/20/23 1:00	1			0			31											
02/20/23 2:00	1			0			31											
02/20/23 3:00	1			0			31											
02/20/23 4:00	1			0			31											
02/20/23 5:00	1			0			31											
02/20/23 6:00	1			0			31											
02/20/23 7:00	1			0			33											
02/20/23 8:00	1			0			33											
02/20/23 9:00	1			0			33											
02/20/23 10:00	1			0			31											
02/20/23 11:00	1			0			31											
02/20/23 12:00	1			0			31											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 13:00	1			0			31											
02/20/23 14:00	1			0			31											
02/20/23 15:00	1			0			34											
02/20/23 16:00	1			9			36											
02/20/23 17:00	1			31			48											
02/20/23 18:00	1			55			59											
02/20/23 19:00	1			70			72											
02/20/23 20:00	1			72			74											
02/20/23 21:00	1			71			73											
02/20/23 22:00	1			68			69											
02/20/23 23:00	1			56			51											
02/21/23 0:00	1			44			27											
02/21/23 1:00	1			34			7											
02/21/23 2:00	1			32			0											
02/21/23 3:00	1			32			0											
02/21/23 4:00	1			32			0											
02/21/23 5:00	1			32			0											
02/21/23 6:00	1			32			0											
02/21/23 7:00	1			32			0											
02/21/23 8:00	1			32			0											
02/21/23 9:00	1			32			0											
02/21/23 10:00	1			32			0											
02/21/23 11:00	1			32			0											
02/21/23 12:00	1			32			0											
02/21/23 13:00	1			32			0											
02/21/23 14:00	1			32			0											
02/21/23 15:00	1			32			0											
02/21/23 16:00	1			32			0											
02/21/23 17:00	1			31			0											
02/21/23 18:00	1			31			0											
02/21/23 19:00	1			31			0											
02/21/23 20:00	1			31			0											
02/21/23 21:00	1			31			0											
02/21/23 22:00	1			31			0											
02/21/23 23:00	1			31			0											
02/22/23 0:00	1			31			0											
02/22/23 1:00	1			31			0											
02/22/23 2:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 3:00	1			31			0											
02/22/23 4:00	1			31			0											
02/22/23 5:00	1			31			0											
02/22/23 6:00	1			32			0											
02/22/23 7:00	1			32			0											
02/22/23 8:00	1			32			0											
02/22/23 9:00	1			31			0											
02/22/23 10:00	1			31			0											
02/22/23 11:00	1			31			0											
02/22/23 12:00	1			31			0											
02/22/23 13:00	1			31			0											
02/22/23 14:00	1			31			0											
02/22/23 15:00	1			34			0											
02/22/23 16:00	1			39			10											
02/22/23 17:00	1			48			30											
02/22/23 18:00	1			59			54											
02/22/23 19:00	1			68			69											
02/22/23 20:00	1			72			73											
02/22/23 21:00	1			72			73											
02/22/23 22:00	1			68			69											
02/22/23 23:00	1			63			64											
02/23/23 0:00	1			62			64											
02/23/23 1:00	1			68			69											
02/23/23 2:00	1			73			75											
02/23/23 3:00	1			75			77											
02/23/23 4:00	1			75			77											
02/23/23 5:00	1			75			77											
02/23/23 6:00	1			75			77											
02/23/23 7:00	1			73			75											
02/23/23 8:00	1			71			73											
02/23/23 9:00	1			69			70											
02/23/23 10:00	1			68			70											
02/23/23 11:00	1			68			70											
02/23/23 12:00	1			66			67											
02/23/23 13:00	1			56			50											
02/23/23 14:00	1			43			27											
02/23/23 15:00	1			34			6											
02/23/23 16:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 17:00	1			31			0											
02/23/23 18:00	1			31			0											
02/23/23 19:00	1			32			0											
02/23/23 20:00	1			42			0											
02/23/23 21:00	1			52			0											
02/23/23 22:00	1			62			0											
02/23/23 23:00	1			63			0											
02/24/23 0:00	1			63			0											
02/24/23 1:00	1			63			0											
02/24/23 2:00	1			63			0											
02/24/23 3:00	1			63			0											
02/24/23 4:00	1			63			0											
02/24/23 5:00	1			65			0											
02/24/23 6:00	1			67			0											
02/24/23 7:00	1			67			0											
02/24/23 8:00	1			66			0											
02/24/23 9:00	1			63			0											
02/24/23 10:00	1			63			0											
02/24/23 11:00	1			63			0											
02/24/23 12:00	1			63			0											
02/24/23 13:00	1			63			0											
02/24/23 14:00	1			63			0											
02/24/23 15:00	1			63			0											
02/24/23 16:00	1			63			0											
02/24/23 17:00	1			63			0											
02/24/23 18:00	1			63			0											
02/24/23 19:00	1			63			0											
02/24/23 20:00	1			63			0											
02/24/23 21:00	1			62			0											
02/24/23 22:00	1			62			0											
02/24/23 23:00	1			62			0											
02/25/23 0:00	1			62			0											
02/25/23 1:00	1			62			0											
02/25/23 2:00	1			62			0											
02/25/23 3:00	1			62			0											
02/25/23 4:00	1			62			0											
02/25/23 5:00	1			62			0											
02/25/23 6:00	1			52			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/25/23 7:00	1			42			0											
02/25/23 8:00	1			32			0											
02/25/23 9:00	1			31			0											
02/25/23 10:00	1			31			0											
02/25/23 11:00	1			31			0											
02/25/23 12:00	1			31			0											
02/25/23 13:00	1			31			0											
02/25/23 14:00	1			31			0											
02/25/23 15:00	1			31			0											
02/25/23 16:00	1			31			0											
02/25/23 17:00	1			31			0											
02/25/23 18:00	1			31			0											
02/25/23 19:00	1			31			0											
02/25/23 20:00	1			31			0											
02/25/23 21:00	1			31			0											
02/25/23 22:00	1			31			0											
02/25/23 23:00	1			31			0											
02/26/23 0:00	1			31			0											
02/26/23 1:00	1			31			0											
02/26/23 2:00	1			31			0											
02/26/23 3:00	1			31			0											
02/26/23 4:00	1			31			0											
02/26/23 5:00	1			31			0											
02/26/23 6:00	1			31			0											
02/26/23 7:00	1			31			0											
02/26/23 8:00	1			31			0											
02/26/23 9:00	1			31			0											
02/26/23 10:00	1			31			0											
02/26/23 11:00	1			31			0											
02/26/23 12:00	1			31			0											
02/26/23 13:00	1			31			0											
02/26/23 14:00	1			31			0											
02/26/23 15:00	1			31			0											
02/26/23 16:00	1			31			0											
02/26/23 17:00	1			31			0											
02/26/23 18:00	1			31			0											
02/26/23 19:00	1			31			0											
02/26/23 20:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/26/23 21:00	1			31			0											
02/26/23 22:00	1			31			0											
02/26/23 23:00	1			31			0											
02/27/23 0:00	1			31			0											
02/27/23 1:00	1			31			0											
02/27/23 2:00	1			31			0											
02/27/23 3:00	1			31			0											
02/27/23 4:00	1			31			0											
02/27/23 5:00	1			31			0											
02/27/23 6:00	1			31			0											
02/27/23 7:00	1			31			0											
02/27/23 8:00	1			31			0											
02/27/23 9:00	1			31			0											
02/27/23 10:00	1			31			0											
02/27/23 11:00	1			31			0											
02/27/23 12:00	1			31			0											
02/27/23 13:00	1			31			0											
02/27/23 14:00	1			31			0											
02/27/23 15:00	1			31			0											
02/27/23 16:00	1			32			0											
02/27/23 17:00	1			38			7											
02/27/23 18:00	1			47			27											
02/27/23 19:00	1			60			51											
02/27/23 20:00	1			67			68											
02/27/23 21:00	1			72			73											
02/27/23 22:00	1			68			69											
02/27/23 23:00	1			57			51											
02/28/23 0:00	1			43			27											
02/28/23 1:00	1			34			6											
02/28/23 2:00	1			31			0											
02/28/23 3:00	1			31			0											
02/28/23 4:00	1			31			0											
02/28/23 5:00	1			31			0											
02/28/23 6:00	1			31			0											
02/28/23 7:00	1			31			0											
02/28/23 8:00	1			31			0											
02/28/23 9:00	1			31			0											
02/28/23 10:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 11:00	1			32			0											
02/28/23 12:00	1			32			0											
02/28/23 13:00	1			32			0											
02/28/23 14:00	1			32			0											
02/28/23 15:00	1			32			0											
02/28/23 16:00	1			35			0											
02/28/23 17:00	1			37			12											
02/28/23 18:00	1			48			34											
02/28/23 19:00	1			58			57											
02/28/23 20:00	1			67			69											
02/28/23 21:00	1			69			70											
02/28/23 22:00	1			69			70											
02/28/23 23:00	1			69			70											
03/01/23 0:00	1			68			70											
03/01/23 1:00	1			68			70											
03/01/23 2:00	1			68			70											
03/01/23 3:00	1			68			70											
03/01/23 4:00	1			69			70											
03/01/23 5:00	1			69			70											
03/01/23 6:00	1			70			72											
03/01/23 7:00	1			68			69											
03/01/23 8:00	1			57			53											
03/01/23 9:00	1			43			28											
03/01/23 10:00	1			33			7											
03/01/23 11:00	1			31			0											
03/01/23 12:00	1			31			0											
03/01/23 13:00	1			31			0											
03/01/23 14:00	1			31			0											
03/01/23 15:00	1			31			0											
03/01/23 16:00	1			31			0											
03/01/23 17:00	1			31			0											
03/01/23 18:00	1			31			0											
03/01/23 19:00	1			31			0											
03/01/23 20:00	1			31			0											
03/01/23 21:00	1			31			0											
03/01/23 22:00	1			31			0											
03/01/23 23:00	1			31			0											
03/02/23 0:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/02/23 1:00	1			31			0											
03/02/23 2:00	1			31			0											
03/02/23 3:00	1			31			0											
03/02/23 4:00	1			31			0											
03/02/23 5:00	1			31			0											
03/02/23 6:00	1			34			0											
03/02/23 7:00	1			34			0											
03/02/23 8:00	1			34			0											
03/02/23 9:00	1			31			0											
03/02/23 10:00	1			31			0											
03/02/23 11:00	1			31			0											
03/02/23 12:00	1			31			0											
03/02/23 13:00	1			31			0											
03/02/23 14:00	1			31			0											
03/02/23 15:00	1			31			0											
03/02/23 16:00	1			31			0											
03/02/23 17:00	1			31			0											
03/02/23 18:00	1			31			0											
03/02/23 19:00	1			31			0											
03/02/23 20:00	1			31			0											
03/02/23 21:00	1			31			0											
03/02/23 22:00	1			31			0											
03/02/23 23:00	1			31			0											
03/03/23 0:00	1			31			0											
03/03/23 1:00	1			31			0											
03/03/23 2:00	1			31			0											
03/03/23 3:00	1			31			0											
03/03/23 4:00	1			31			0											
03/03/23 5:00	1			31			0											
03/03/23 6:00	1			31			0											
03/03/23 7:00	1			31			0											
03/03/23 8:00	1			31			0											
03/03/23 9:00	1			31			0											
03/03/23 10:00	1			31			0											
03/03/23 11:00	1			32			0											
03/03/23 12:00	1			42			0											
03/03/23 13:00	1			53			0											
03/03/23 14:00	1			63			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:00	1			58			8											
03/03/23 16:00	1			49			21											
03/03/23 17:00	1			46			41											
03/03/23 18:00	1			54			56											
03/03/23 19:00	1			65			67											
03/03/23 20:00	1			69			71											
03/03/23 21:00	1			69			71											
03/03/23 22:00	1			62			63											
03/03/23 23:00	1			51			39											
03/04/23 0:00	1			39			16											
03/04/23 1:00	1			33			0											
03/04/23 2:00	1			32			0											
03/04/23 3:00	1			32			0											
03/04/23 4:00	1			32			0											
03/04/23 5:00	1			32			0											
03/04/23 6:00	1			32			0											
03/04/23 7:00	1			32			0											
03/04/23 8:00	1			32			0											
03/04/23 9:00	1			31			0											
03/04/23 10:00	1			31			0											
03/04/23 11:00	1			31			0											
03/04/23 12:00	1			32			0											
03/04/23 13:00	1			32			0											
03/04/23 14:00	1			32			0											
03/04/23 15:00	1			32			0											
03/04/23 16:00	1			35			0											
03/04/23 17:00	1			36			9											
03/04/23 18:00	1			46			31											
03/04/23 19:00	1			58			56											
03/04/23 20:00	1			70			71											
03/04/23 21:00	1			73			74											
03/04/23 22:00	1			66			66											
03/04/23 23:00	1			54			42											
03/05/23 0:00	1			40			17											
03/05/23 1:00	1			33			0											
03/05/23 2:00	1			31			0											
03/05/23 3:00	1			31			0											
03/05/23 4:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 5:00	1			31			0											
03/05/23 6:00	1			31			0											
03/05/23 7:00	1			31			0											
03/05/23 8:00	1			31			0											
03/05/23 9:00	1			31			0											
03/05/23 10:00	1			31			0											
03/05/23 11:00	1			31			0											
03/05/23 12:00	1			31			0											
03/05/23 13:00	1			31			0											
03/05/23 14:00	1			31			0											
03/05/23 15:00	1			34			0											
03/05/23 16:00	1			37			11											
03/05/23 17:00	1			47			33											
03/05/23 18:00	1			59			58											
03/05/23 19:00	1			71			72											
03/05/23 20:00	1			75			77											
03/05/23 21:00	1			75			77											
03/05/23 22:00	1			74			76											
03/05/23 23:00	1			72			74											
03/06/23 0:00	1			67			69											
03/06/23 1:00	1			59			58											
03/06/23 2:00	1			46			34											
03/06/23 3:00	1			36			14											
03/06/23 4:00	1			31			0											
03/06/23 5:00	1			33			0											
03/06/23 6:00	1			40			0											
03/06/23 7:00	1			40			0											
03/06/23 8:00	1			38			0											
03/06/23 9:00	1			31			0											
03/06/23 10:00	1			31			0											
03/06/23 11:00	1			31			0											
03/06/23 12:00	1			31			0											
03/06/23 13:00	1			35			8											
03/06/23 14:00	1			44			28											
03/06/23 15:00	1			56			51											
03/06/23 16:00	1			65			66											
03/06/23 17:00	1			68			70											
03/06/23 18:00	1			68			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 19:00	1			68			70											
03/06/23 20:00	1			68			70											
03/06/23 21:00	1			68			70											
03/06/23 22:00	1			68			70											
03/06/23 23:00	1			68			70											
03/07/23 0:00	1			68			70											
03/07/23 1:00	1			68			70											
03/07/23 2:00	1			68			70											
03/07/23 3:00	1			68			70											
03/07/23 4:00	1			68			70											
03/07/23 5:00	1			69			71											
03/07/23 6:00	1			72			74											
03/07/23 7:00	1			68			70											
03/07/23 8:00	1			57			52											
03/07/23 9:00	1			42			27											
03/07/23 10:00	1			33			6											
03/07/23 11:00	1			31			0											
03/07/23 12:00	1			31			0											
03/07/23 13:00	1			31			0											
03/07/23 14:00	1			31			0											
03/07/23 15:00	1			31			0											
03/07/23 16:00	1			34			1											
03/07/23 17:00	1			34			12											
03/07/23 18:00	1			43			31											
03/07/23 19:00	1			53			54											
03/07/23 20:00	1			65			66											
03/07/23 21:00	1			68			70											
03/07/23 22:00	1			68			70											
03/07/23 23:00	1			68			70											
03/08/23 0:00	1			68			70											
03/08/23 1:00	1			68			70											
03/08/23 2:00	1			68			70											
03/08/23 3:00	1			68			70											
03/08/23 4:00	1			68			70											
03/08/23 5:00	1			68			70											
03/08/23 6:00	1			68			70											
03/08/23 7:00	1			68			70											
03/08/23 8:00	1			69			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 9:00	1			69			70											
03/08/23 10:00	1			66			68											
03/08/23 11:00	1			55			51											
03/08/23 12:00	1			43			28											
03/08/23 13:00	1			33			7											
03/08/23 14:00	1			32			0											
03/08/23 15:00	1			32			0											
03/08/23 16:00	1			32			0											
03/08/23 17:00	1			33			0											
03/08/23 18:00	1			38			8											
03/08/23 19:00	1			43			25											
03/08/23 20:00	1			55			48											
03/08/23 21:00	1			62			64											
03/08/23 22:00	1			68			70											
03/08/23 23:00	1			68			70											
03/09/23 0:00	1			68			70											
03/09/23 1:00	1			68			70											
03/09/23 2:00	1			68			70											
03/09/23 3:00	1			68			70											
03/09/23 4:00	1			68			70											
03/09/23 5:00	1			68			70											
03/09/23 6:00	1			68			70											
03/09/23 7:00	1			68			70											
03/09/23 8:00	1			68			70											
03/09/23 9:00	1			68			70											
03/09/23 10:00	1			68			70											
03/09/23 11:00	1			69			71											
03/09/23 12:00	1			71			73											
03/09/23 13:00	1			74			76											
03/09/23 14:00	1			75			77											
03/09/23 15:00	1			75			77											
03/09/23 16:00	1			72			74											
03/09/23 17:00	1			70			71											
03/09/23 18:00	1			69			70											
03/09/23 19:00	1			68			70											
03/09/23 20:00	1			69			70											
03/09/23 21:00	1			69			70											
03/09/23 22:00	1			66			67											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:00	1			56			50											
03/10/23 0:00	1			43			27											
03/10/23 1:00	1			33			6											
03/10/23 2:00	1			31			0											
03/10/23 3:00	1			31			0											
03/10/23 4:00	1			31			0											
03/10/23 5:00	1			31			0											
03/10/23 6:00	1			31			0											
03/10/23 7:00	1			31			0											
03/10/23 8:00	1			31			0											
03/10/23 9:00	1			31			0											
03/10/23 10:00	1			34			0											
03/10/23 11:00	1			35			0											
03/10/23 12:00	1			35			0											
03/10/23 13:00	1			31			0											
03/10/23 14:00	1			31			0											
03/10/23 15:00	1			34			0											
03/10/23 16:00	1			36			12											
03/10/23 17:00	1			46			33											
03/10/23 18:00	1			56			56											
03/10/23 19:00	1			66			68											
03/10/23 20:00	1			65			64											
03/10/23 21:00	1			54			41											
03/10/23 22:00	1			42			17											
03/10/23 23:00	1			33			0											
03/11/23 0:00	1			32			0											
03/11/23 1:00	1			32			0											
03/11/23 2:00	1			32			0											
03/11/23 3:00	1			31			0											
03/11/23 4:00	1			31			0											
03/11/23 5:00	1			32			0											
03/11/23 6:00	1			32			0											
03/11/23 7:00	1			32			0											
03/11/23 8:00	1			32			0											
03/11/23 9:00	1			32			0											
03/11/23 10:00	1			31			0											
03/11/23 11:00	1			31			0											
03/11/23 12:00	1			31			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 13:00	1			31			0											
03/11/23 14:00	1			32			0											
03/11/23 15:00	1			32			0											
03/11/23 16:00	1			33			0											
03/11/23 17:00	1			34			9											
03/11/23 18:00	1			35			20											
03/11/23 19:00	1			46			43											
03/11/23 20:00	1			58			59											
03/11/23 21:00	1			72			73											
03/11/23 22:00	1			75			76											
03/11/23 23:00	1			76			78											
03/12/23 0:00	1			76			77											
03/12/23 1:00	1			72			73											
03/12/23 2:00	1			67			69											
03/12/23 3:00	1			64			66											
03/12/23 4:00	1			68			69											
03/12/23 5:00	1			71			73											
03/12/23 6:00	1			71			72											
03/12/23 7:00	1			58			54											
03/12/23 8:00	1			44			28											
03/12/23 9:00	1			34			7											
03/12/23 10:00	1			32			0											
03/12/23 11:00	1			33			0											
03/12/23 12:00	1			32			0											
03/12/23 13:00	1			32			0											
03/12/23 14:00	1			34			0											
03/12/23 15:00	1			38			9											
03/12/23 16:00	1			43			25											
03/12/23 17:00	1			55			51											
03/12/23 18:00	1			67			68											
03/12/23 19:00	1			76			77											
03/12/23 20:00	1			76			78											
03/12/23 21:00	1			76			77											
03/12/23 22:00	1			75			77											
03/12/23 23:00	1			68			69											
03/13/23 0:00	1			55			50											
03/13/23 1:00	1			41			25											
03/13/23 2:00	1			33			7											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 3:00	1			32			0											
03/13/23 4:00	1			35			0											
03/13/23 5:00	1			41			0											
03/13/23 6:00	1			49			0											
03/13/23 7:00	1			46			0											
03/13/23 8:00	1			40			0											
03/13/23 9:00	1			32			0											
03/13/23 10:00	1			32			0											
03/13/23 11:00	1			32			0											
03/13/23 12:00	1			32			0											
03/13/23 13:00	1			32			0											
03/13/23 14:00	1			32			0											
03/13/23 15:00	1			32			0											
03/13/23 16:00	1			34			1											
03/13/23 17:00	1			36			13											
03/13/23 18:00	1			48			36											
03/13/23 19:00	1			59			60											
03/13/23 20:00	1			72			73											
03/13/23 21:00	1			74			75											
03/13/23 22:00	1			69			69											
03/13/23 23:00	1			55			43											
03/14/23 0:00	1			41			18											
03/14/23 1:00	1			32			0											
03/14/23 2:00	1			31			0											
03/14/23 3:00	1			31			0											
03/14/23 4:00	1			32			0											
03/14/23 5:00	1			32			0											
03/14/23 6:00	1			32			0											
03/14/23 7:00	1			37			0											
03/14/23 8:00	1			46			0											
03/14/23 9:00	1			49			8											
03/14/23 10:00	1			56			31											
03/14/23 11:00	1			60			55											
03/14/23 12:00	1			70			71											
03/14/23 13:00	1			73			75											
03/14/23 14:00	1			74			75											
03/14/23 15:00	1			73			74											
03/14/23 16:00	1			72			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 17:00	1			73			74											
03/14/23 18:00	1			75			76											
03/14/23 19:00	1			76			78											
03/14/23 20:00	1			76			78											
03/14/23 21:00	1			75			77											
03/14/23 22:00	1			71			73											
03/14/23 23:00	1			58			55											
03/15/23 0:00	1			45			30											
03/15/23 1:00	1			34			8											
03/15/23 2:00	1			32			0											
03/15/23 3:00	1			32			0											
03/15/23 4:00	1			32			0											
03/15/23 5:00	1			32			0											
03/15/23 6:00	1			32			0											
03/15/23 7:00	1			32			0											
03/15/23 8:00	1			32			0											
03/15/23 9:00	1			32			0											
03/15/23 10:00	1			32			0											
03/15/23 11:00	1			32			0											
03/15/23 12:00	1			32			0											
03/15/23 13:00	1			32			0											
03/15/23 14:00	1			32			0											
03/15/23 15:00	1			32			0											
03/15/23 16:00	1			34			2											
03/15/23 17:00	1			35			14											
03/15/23 18:00	1			46			36											
03/15/23 19:00	1			58			59											
03/15/23 20:00	1			70			72											
03/15/23 21:00	1			68			68											
03/15/23 22:00	1			55			44											
03/15/23 23:00	1			41			18											
03/16/23 0:00	1			32			0											
03/16/23 1:00	1			32			0											
03/16/23 2:00	1			32			0											
03/16/23 3:00	1			32			0											
03/16/23 4:00	1			32			0											
03/16/23 5:00	1			32			0											
03/16/23 6:00	1			33			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 7:00	1			33			0											
03/16/23 8:00	1			33			0											
03/16/23 9:00	1			32			0											
03/16/23 10:00	1			32			0											
03/16/23 11:00	1			32			0											
03/16/23 12:00	1			32			0											
03/16/23 13:00	1			32			0											
03/16/23 14:00	1			31			0											
03/16/23 15:00	1			30			1											
03/16/23 16:00	1			20			12											
03/16/23 17:00	1			9			23											
03/16/23 18:00	1			0			33											
03/16/23 19:00	1			0			34											
03/16/23 20:00	1			0			35											
03/16/23 21:00	1			0			37											
03/16/23 22:00	1			0			40											
03/16/23 23:00	1			0			40											
03/17/23 0:00	1			0			37											
03/17/23 1:00	1			0			37											
03/17/23 2:00	1			13			40											
03/17/23 3:00	1			35			51											
03/17/23 4:00	1			60			63											
03/17/23 5:00	1			74			76											
03/17/23 6:00	1			76			78											
03/17/23 7:00	1			68			69											
03/17/23 8:00	1			56			53											
03/17/23 9:00	1			43			27											
03/17/23 10:00	1			37			10											
03/17/23 11:00	1			35			0											
03/17/23 12:00	1			35			0											
03/17/23 13:00	1			35			0											
03/17/23 14:00	1			35			0											
03/17/23 15:00	1			35			0											
03/17/23 16:00	1			38			4											
03/17/23 17:00	1			42			19											
03/17/23 18:00	1			54			43											
03/17/23 19:00	1			64			65											
03/17/23 20:00	1			72			74											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 21:00	1			73			75											
03/17/23 22:00	1			67			67											
03/17/23 23:00	1			55			43											
03/18/23 0:00	1			42			18											
03/18/23 1:00	1			35			0											
03/18/23 2:00	1			34			0											
03/18/23 3:00	1			34			0											
03/18/23 4:00	1			34			0											
03/18/23 5:00	1			34			0											
03/18/23 6:00	1			34			0											
03/18/23 7:00	1			34			0											
03/18/23 8:00	1			34			0											
03/18/23 9:00	1			34			0											
03/18/23 10:00	1			35			0											
03/18/23 11:00	1			35			0											
03/18/23 12:00	1			35			0											
03/18/23 13:00	1			35			0											
03/18/23 14:00	1			35			0											
03/18/23 15:00	1			37			0											
03/18/23 16:00	1			39			11											
03/18/23 17:00	1			50			34											
03/18/23 18:00	1			61			60											
03/18/23 19:00	1			72			73											
03/18/23 20:00	1			73			74											
03/18/23 21:00	1			66			65											
03/18/23 22:00	1			54			41											
03/18/23 23:00	1			42			17											
03/19/23 0:00	1			35			0											
03/19/23 1:00	1			35			0											
03/19/23 2:00	1			34			0											
03/19/23 3:00	1			34			0											
03/19/23 4:00	1			34			0											
03/19/23 5:00	1			34			0											
03/19/23 6:00	1			34			0											
03/19/23 7:00	1			34			0											
03/19/23 8:00	1			34			0											
03/19/23 9:00	1			34			0											
03/19/23 10:00	1			34			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 11:00	1			35			0											
03/19/23 12:00	1			36			0											
03/19/23 13:00	1			36			0											
03/19/23 14:00	1			36			0											
03/19/23 15:00	1			39			3											
03/19/23 16:00	1			40			17											
03/19/23 17:00	1			52			41											
03/19/23 18:00	1			61			63											
03/19/23 19:00	1			72			74											
03/19/23 20:00	1			73			75											
03/19/23 21:00	1			72			74											
03/19/23 22:00	1			71			73											
03/19/23 23:00	1			70			72											
03/20/23 0:00	1			66			68											
03/20/23 1:00	1			56			51											
03/20/23 2:00	1			45			27											
03/20/23 3:00	1			36			7											
03/20/23 4:00	1			35			0											
03/20/23 5:00	1			37			0											
03/20/23 6:00	1			37			0											
03/20/23 7:00	1			39			0											
03/20/23 8:00	1			38			0											
03/20/23 9:00	1			38			0											
03/20/23 10:00	1			36			0											
03/20/23 11:00	1			34			0											
03/20/23 12:00	1			34			0											
03/20/23 13:00	1			34			0											
03/20/23 14:00	1			34			0											
03/20/23 15:00	1			34			0											
03/20/23 16:00	1			38			6											
03/20/23 17:00	1			45			24											
03/20/23 18:00	1			58			49											
03/20/23 19:00	1			67			69											
03/20/23 20:00	1			64			65											
03/20/23 21:00	0			39			40											
03/20/23 22:00	0			14			15											
03/20/23 23:00	0			0			0											
03/21/23 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 1:00	0			0			0											
03/21/23 2:00	0			0			0											
03/21/23 3:00	0			0			0											
03/21/23 4:00	0			0			0											
03/21/23 5:00	0			0			0											
03/21/23 6:00	0			0			0											
03/21/23 7:00	0			0			0											
03/21/23 8:00	0			0			0											
03/21/23 9:00	0			0			0											
03/21/23 10:00	0			0			0											
03/21/23 11:00	1			0			5											
03/21/23 12:00	1			0			17											
03/21/23 13:00	1			0			29											
03/21/23 14:00	1			0			36											
03/21/23 15:00	1			0			35											
03/21/23 16:00	1			0			35											
03/21/23 17:00	1			0			34											
03/21/23 18:00	1			0			34											
03/21/23 19:00	1			0			34											
03/21/23 20:00	1			0			34											
03/21/23 21:00	1			0			34											
03/21/23 22:00	1			0			34											
03/21/23 23:00	1			0			34											
03/22/23 0:00	1			0			34											
03/22/23 1:00	1			0			34											
03/22/23 2:00	1			0			34											
03/22/23 3:00	1			0			34											
03/22/23 4:00	1			0			34											
03/22/23 5:00	1			0			34											
03/22/23 6:00	1			0			39											
03/22/23 7:00	1			0			39											
03/22/23 8:00	1			0			39											
03/22/23 9:00	1			0			34											
03/22/23 10:00	1			0			34											
03/22/23 11:00	1			0			34											
03/22/23 12:00	1			0			35											
03/22/23 13:00	1			0			35											
03/22/23 14:00	1			0			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 15:00	1			0			37											
03/22/23 16:00	1			8			39											
03/22/23 17:00	1			28			48											
03/22/23 18:00	1			54			60											
03/22/23 19:00	1			71			72											
03/22/23 20:00	1			76			78											
03/22/23 21:00	1			74			76											
03/22/23 22:00	1			70			71											
03/22/23 23:00	1			58			61											
03/23/23 0:00	1			34			49											
03/23/23 1:00	1			13			39											
03/23/23 2:00	1			0			35											
03/23/23 3:00	1			0			35											
03/23/23 4:00	1			0			35											
03/23/23 5:00	1			0			34											
03/23/23 6:00	1			0			34											
03/23/23 7:00	1			0			34											
03/23/23 8:00	1			0			34											
03/23/23 9:00	1			0			34											
03/23/23 10:00	1			0			34											
03/23/23 11:00	1			0			34											
03/23/23 12:00	1			0			34											
03/23/23 13:00	1			0			34											
03/23/23 14:00	1			0			36											
03/23/23 15:00	1			9			38											
03/23/23 16:00	1			26			43											
03/23/23 17:00	1			48			53											
03/23/23 18:00	1			62			64											
03/23/23 19:00	1			68			70											
03/23/23 20:00	1			68			70											
03/23/23 21:00	1			68			70											
03/23/23 22:00	1			63			65											
03/23/23 23:00	1			42			54											
03/24/23 0:00	1			20			43											
03/24/23 1:00	1			2			36											
03/24/23 2:00	1			0			35											
03/24/23 3:00	1			0			35											
03/24/23 4:00	1			0			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/24/23 5:00	1			0			35											
03/24/23 6:00	1			0			35											
03/24/23 7:00	1			0			35											
03/24/23 8:00	1			0			34											
03/24/23 9:00	1			0			34											
03/24/23 10:00	1			0			34											
03/24/23 11:00	1			0			34											
03/24/23 12:00	1			0			35											
03/24/23 13:00	1			0			35											
03/24/23 14:00	1			0			35											
03/24/23 15:00	1			0			35											
03/24/23 16:00	1			0			35											
03/24/23 17:00	1			0			34											
03/24/23 18:00	1			0			34											
03/24/23 19:00	1			0			34											
03/24/23 20:00	1			0			34											
03/24/23 21:00	1			0			34											
03/24/23 22:00	1			0			35											
03/24/23 23:00	1			0			35											
03/25/23 0:00	1			0			35											
03/25/23 1:00	1			0			34											
03/25/23 2:00	1			0			34											
03/25/23 3:00	1			0			34											
03/25/23 4:00	1			0			34											
03/25/23 5:00	1			0			34											
03/25/23 6:00	1			0			34											
03/25/23 7:00	1			0			34											
03/25/23 8:00	1			0			34											
03/25/23 9:00	1			0			34											
03/25/23 10:00	1			0			34											
03/25/23 11:00	1			0			34											
03/25/23 12:00	1			0			34											
03/25/23 13:00	1			0			34											
03/25/23 14:00	1			0			34											
03/25/23 15:00	1			0			34											
03/25/23 16:00	1			0			34											
03/25/23 17:00	1			0			34											
03/25/23 18:00	1			0			34											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 19:00	1			0			35											
03/25/23 20:00	1			0			34											
03/25/23 21:00	1			0			34											
03/25/23 22:00	1			0			34											
03/25/23 23:00	1			0			26											
03/26/23 0:00	0			0			14											
03/26/23 1:00	0			0			3											
03/26/23 2:00	0			0			0											
03/26/23 3:00	0			0			0											
03/26/23 4:00	0			0			0											
03/26/23 5:00	0			0			0											
03/26/23 6:00	0			0			0											
03/26/23 7:00	0			0			0											
03/26/23 8:00	0			0			0											
03/26/23 9:00	0			0			0											
03/26/23 10:00	0			0			0											
03/26/23 11:00	0			0			0											
03/26/23 12:00	0			0			0											
03/26/23 13:00	0			0			0											
03/26/23 14:00	0			0			0											
03/26/23 15:00	0			0			0											
03/26/23 16:00	0			0			0											
03/26/23 17:00	0			0			0											
03/26/23 18:00	0			0			0											
03/26/23 19:00	0			0			0											
03/26/23 20:00	0			0			0											
03/26/23 21:00	0			0			0											
03/26/23 22:00	0			0			0											
03/26/23 23:00	0			0			0											
03/27/23 0:00	0			0			0											
03/27/23 1:00	0			0			0											
03/27/23 2:00	0			0			0											
03/27/23 3:00	0			0			0											
03/27/23 4:00	0			0			0											
03/27/23 5:00	0			0			0											
03/27/23 6:00	0			0			0											
03/27/23 7:00	0			0			0											
03/27/23 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/27/23 9:00	0			0			0											
03/27/23 10:00	0			0			0											
03/27/23 11:00	0			0			0											
03/27/23 12:00	0			0			0											
03/27/23 13:00	0			0			0											
03/27/23 14:00	0			0			0											
03/27/23 15:00	0			0			0											
03/27/23 16:00	0			0			0											
03/27/23 17:00	0			0			0											
03/27/23 18:00	0			0			0											
03/27/23 19:00	0			0			0											
03/27/23 20:00	0			0			0											
03/27/23 21:00	0			0			0											
03/27/23 22:00	0			0			0											
03/27/23 23:00	0			0			0											
03/28/23 0:00	0			0			0											
03/28/23 1:00	0			0			0											
03/28/23 2:00	0			0			0											
03/28/23 3:00	0			0			0											
03/28/23 4:00	0			0			0											
03/28/23 5:00	0			0			0											
03/28/23 6:00	0			0			0											
03/28/23 7:00	0			0			0											
03/28/23 8:00	0			0			0											
03/28/23 9:00	0			0			0											
03/28/23 10:00	0			0			0											
03/28/23 11:00	0			0			0											
03/28/23 12:00	0			0			0											
03/28/23 13:00	0			0			0											
03/28/23 14:00	0			0			0											
03/28/23 15:00	0			0			0											
03/28/23 16:00	0			0			0											
03/28/23 17:00	0			0			0											
03/28/23 18:00	0			0			0											
03/28/23 19:00	0			0			0											
03/28/23 20:00	0			0			0											
03/28/23 21:00	0			0			0											
03/28/23 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/28/23 23:00	0			0			0											
03/29/23 0:00	0			0			0											
03/29/23 1:00	0			0			0											
03/29/23 2:00	0			0			0											
03/29/23 3:00	0			0			0											
03/29/23 4:00	0			0			0											
03/29/23 5:00	0			0			0											
03/29/23 6:00	0			0			0											
03/29/23 7:00	0			0			0											
03/29/23 8:00	0			0			0											
03/29/23 9:00	0			0			0											
03/29/23 10:00	0			0			0											
03/29/23 11:00	0			0			0											
03/29/23 12:00	0			0			0											
03/29/23 13:00	0			0			0											
03/29/23 14:00	0			0			0											
03/29/23 15:00	0			0			0											
03/29/23 16:00	0			0			0											
03/29/23 17:00	0			0			0											
03/29/23 18:00	0			0			0											
03/29/23 19:00	0			0			0											
03/29/23 20:00	0			0			0											
03/29/23 21:00	0			0			0											
03/29/23 22:00	0			0			0											
03/29/23 23:00	0			0			0											
03/30/23 0:00	0			0			0											
03/30/23 1:00	0			0			0											
03/30/23 2:00	0			0			0											
03/30/23 3:00	0			0			0											
03/30/23 4:00	0			0			0											
03/30/23 5:00	0			0			0											
03/30/23 6:00	0			0			0											
03/30/23 7:00	0			0			0											
03/30/23 8:00	0			0			0											
03/30/23 9:00	0			0			0											
03/30/23 10:00	0			0			0											
03/30/23 11:00	0			0			0											
03/30/23 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/30/23 13:00	0			0			0											
03/30/23 14:00	0			0			0											
03/30/23 15:00	0			0			0											
03/30/23 16:00	0			0			0											
03/30/23 17:00	0			0			0											
03/30/23 18:00	0			0			0											
03/30/23 19:00	0			0			0											
03/30/23 20:00	0			0			0											
03/30/23 21:00	0			0			0											
03/30/23 22:00	0			0			0											
03/30/23 23:00	0			0			0											
03/31/23 0:00	0			0			0											
03/31/23 1:00	0			0			0											
03/31/23 2:00	0			0			0											
03/31/23 3:00	0			0			0											
03/31/23 4:00	0			0			0											
03/31/23 5:00	0			0			0											
03/31/23 6:00	0			0			0											
03/31/23 7:00	0			0			0											
03/31/23 8:00	0			0			0											
03/31/23 9:00	0			0			0											
03/31/23 10:00	0			0			0											
03/31/23 11:00	0			0			0											
03/31/23 12:00	0			0			0											
03/31/23 13:00	0			0			0											
03/31/23 14:00	0			0			0											
03/31/23 15:00	0			0			0											
03/31/23 16:00	0			0			0											
03/31/23 17:00	0			0			0											
03/31/23 18:00	0			0			0											
03/31/23 19:00	0			0			0											
03/31/23 20:00	0			0			0											
03/31/23 21:00	0			0			0											
03/31/23 22:00	0			0			0											
03/31/23 23:00	0			0			0											
04/01/23 0:00	0			0			0											
04/01/23 1:00	0			0			0											
04/01/23 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
04/01/23 3:00	0			0			0											
04/01/23 4:00	0			0			0											
04/01/23 5:00	0			0			0											
04/01/23 6:00	0			0			0											
04/01/23 7:00	0			0			0											
04/01/23 8:00	0	X		0	X		0	X										

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/01/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/01/23 02:25	200.0	182.0	181.7	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/01/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/01/23 02:20	30.0	23.4	23.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/01/23 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	01/01/23 03:24	200.0	185.0	186.7	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/01/23 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	01/01/23 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/01/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/01/23 03:24	200.0	182.0	182.5	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/01/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/01/23 03:19	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/01/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/01/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/02/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 02:25	200.0	182.0	181.7	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/02/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 02:19	30.0	23.4	23.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/02/23 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	01/02/23 03:25	200.0	185.0	186.5	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/02/23 03:15	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	01/02/23 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/02/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 03:25	200.0	182.0	182.7	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/02/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 03:20	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/02/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/02/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/02/23 14:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/02/23 14:25	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/02/23 14:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/02/23 14:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/02/23 14:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 14:25	200.0	181.3	177.5	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/02/23 14:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/02/23 14:20	10.0	8.5	8.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/02/23 14:15	21.0	18.2	18.0	R-A		0.2
	Zero	01/02/23 14:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 02:25	200.0	181.3	178.0	R-A /Span * 100		1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 02:19	30.0	24.3	24.9	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 02:25	200.0	182.0	183.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 02:20	30.0	23.4	23.7	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	01/03/23 03:24	200.0	185.0	186.3	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	01/03/23 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 03:24	200.0	182.0	182.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 03:19	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/03/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/03/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/03/23 03:25	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/03/23 03:20	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/03/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 03:25	200.0	181.3	178.4	R-A /Span * 100		1.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/03/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/03/23 03:20	10.0	8.5	8.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/03/23 03:15	21.0	18.2	18.0	R-A		0.2
	Zero	01/03/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 02:25	200.0	181.3	177.0	R-A /Span * 100		2.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 02:20	30.0	24.3	24.6	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 02:25	200.0	182.0	182.9	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 02:19	30.0	23.4	23.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/04/23 03:25	200.0	180.0	180.1	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/04/23 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 03:25	200.0	181.3	178.3	R-A /Span * 100		1.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 03:20	10.0	8.5	8.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/04/23 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	01/04/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	01/04/23 03:25	200.0	185.0	185.7	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 03:15	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	01/04/23 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/04/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 03:25	200.0	182.0	181.9	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/04/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/04/23 03:20	10.0	8.9	8.0	R-A		0.9
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/04/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/04/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/05/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/05/23 02:25	200.0	182.0	180.9	R-A /Span * 100		0.6

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/05/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	01/05/23 02:19	30.0	23.4		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/05/23 03:14	200.0	-0.1		R-A /Span * 100	0.1
	High	01/05/23 03:25	200.0	185.0		R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/05/23 03:14	10.0	-0.2		R-A /Span * 100	2.0
	High	01/05/23 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/05/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/05/23 03:25	200.0	182.0		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/05/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/05/23 03:19	10.0	8.9		R-A	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/05/23 03:14	21.0	18.0		R-A	0.0
	Zero	01/05/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Warning	
	Zero	01/05/23 17:15	200.0	0.0		R-A /Span * 100	0.1
	High	01/05/23 17:25	200.0	180.0	>2x	R-A /Span * 100	12.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/05/23 17:15	10.0	0.0		R-A /Span * 100	2.0
	High	01/05/23 17:20	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/05/23 17:15	200.0	0.0		R-A /Span * 100	0.0
	High	01/05/23 17:25	200.0	181.3		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/05/23 17:15	10.0	0.0		R-A /Span * 100	0.0
	High	01/05/23 17:20	10.0	8.5		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/05/23 17:15	21.0	18.2		R-A	0.2
	Zero	01/05/23 17:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/06/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	01/06/23 02:25	200.0	182.0		R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/06/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 02:20	30.0	23.4	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/06/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 03:25	200.0	185.0	183.2	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/06/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/06/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 03:25	200.0	182.0	181.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/06/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 03:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/06/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/06/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Warning	
	Zero	01/06/23 18:06	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/06/23 18:17	200.0	180.0	155.6	>2x R-A /Span * 100		12.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/06/23 18:06	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/06/23 18:12	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/06/23 18:06	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 18:17	200.0	181.3	179.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/06/23 18:06	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/06/23 18:12	10.0	8.5	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/06/23 18:06	21.0	18.2	18.0	R-A		0.2
	Zero	01/06/23 18:12	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/07/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 02:24	200.0	182.0	183.1	R-A /Span * 100		0.6

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/07/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 02:19	30.0	23.4	23.6	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/07/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 03:24	200.0	185.0	184.9	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/07/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/07/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 03:24	200.0	182.0	182.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/07/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/07/23 03:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/07/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/07/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/08/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 02:24	200.0	182.0	182.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/08/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 02:19	30.0	23.4	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/08/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 03:24	200.0	185.0	185.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/08/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/08/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 03:24	200.0	182.0	182.1	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/08/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/08/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/08/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Warning	
	Zero	01/08/23 18:10	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/08/23 18:20	200.0	180.0	156.3	>2x R-A /Span * 100		11.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/08/23 18:10	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/08/23 18:15	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/08/23 18:10	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 18:20	200.0	181.3	179.7	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/08/23 18:10	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/08/23 18:15	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/08/23 18:10	21.0	18.2	18.0	R-A		0.2
	Zero	01/08/23 18:15	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/09/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 02:25	200.0	182.0	182.3	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/09/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 02:19	30.0	23.4	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 03:24	200.0	185.0	186.3	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 03:24	200.0	182.0	181.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/09/23 03:14	21.0	18.0	R-A		0.0
	Zero	01/09/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/09/23 16:10	200.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 16:20	200.0	179.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/09/23 16:10	10.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 16:15	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/09/23 16:10	200.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 16:20	200.0	180.2	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/09/23 16:10	10.0	0.0	R-A /Span * 100		0.0
	High	01/09/23 16:15	10.0	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/09/23 16:10	21.0	18.0	R-A		0.2
	Zero	01/09/23 16:15	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/10/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 02:25	200.0	183.2	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/10/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 02:20	30.0	23.6	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 03:25	200.0	186.5	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 03:25	200.0	182.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 03:19	10.0	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/10/23 03:14	21.0	18.0	R-A		0.0
	Zero	01/10/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/10/23 18:00	200.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 18:11	200.0	179.3	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/10/23 18:00	10.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 18:06	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/10/23 18:00	200.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 18:11	200.0	180.0	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/10/23 18:00	10.0	0.0	R-A /Span * 100		0.0
	High	01/10/23 18:06	10.0	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/10/23 18:00	21.0	18.0	R-A		0.2
	Zero	01/10/23 18:06	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/11/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 02:25	200.0	182.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/11/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 02:20	30.0	23.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/11/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 03:25	200.0	184.3	R-A /Span * 100		1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/11/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/11/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 03:25	200.0	182.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/11/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 03:20	10.0	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/11/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/11/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/11/23 18:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 18:25	200.0	180.0	178.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/11/23 18:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 18:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/11/23 18:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 18:25	200.0	181.3	179.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/11/23 18:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/11/23 18:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/11/23 18:15	21.0	18.2	18.0	R-A		0.2
	Zero	01/11/23 18:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/12/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 02:25	200.0	180.4	179.6	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/12/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 02:20	30.0	23.4	23.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 03:25	200.0	181.4	186.7	R-A /Span * 100		2.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 03:25	200.0	180.4	179.7	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/12/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/12/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/12/23 18:29	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 18:39	200.0	180.0	178.5	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/12/23 18:29	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/12/23 18:33	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/12/23 18:29	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 18:39	200.0	181.3	179.1	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/12/23 18:29	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/12/23 18:33	10.0	8.5	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/12/23 18:29	21.0	18.2	18.0	R-A		0.2
	Zero	01/12/23 18:33	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/13/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 02:25	200.0	180.4	181.5	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/13/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 02:19	30.0	23.4	23.6	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/13/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 03:25	200.0	181.4	187.1	R-A /Span * 100		2.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/13/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/13/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 03:25	200.0	180.4	180.1	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/13/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/13/23 03:19	10.0	8.9	9.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/13/23 03:14	21.0	18.0	R-A		0.0
	Zero	01/13/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/14/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 02:25	200.0	180.4	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/14/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 02:19	30.0	23.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/14/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 03:25	200.0	181.4	R-A /Span * 100		3.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/14/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 03:25	200.0	180.4	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 03:19	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/14/23 03:14	21.0	18.0	R-A		0.0
	Zero	01/14/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/14/23 16:58	200.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 17:09	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/14/23 16:58	10.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 17:03	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/14/23 16:58	200.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 17:09	200.0	181.3	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/14/23 16:58	10.0	0.0	R-A /Span * 100		0.0
	High	01/14/23 17:03	10.0	8.5	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/14/23 16:58	21.0	18.2	18.0	R-A	0.2
	Zero	01/14/23 17:03	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/15/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 02:25	200.0	180.4	180.5	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/15/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 02:20	30.0	23.4	23.4	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/15/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 03:25	200.0	181.4	188.1	R-A /Span * 100	3.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/15/23 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	01/15/23 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/15/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 03:25	200.0	180.4	179.9	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/15/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 03:19	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/15/23 03:14	21.0	18.0	18.1	R-A	0.1
	Zero	01/15/23 03:19	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/15/23 17:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 17:22	200.0	180.0	180.4	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/15/23 17:12	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	01/15/23 17:17	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/15/23 17:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 17:22	200.0	181.3	180.2	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/15/23 17:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/15/23 17:17	10.0	8.5	8.5	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/15/23 17:12	21.0	18.2	18.0	R-A	0.2
	Zero	01/15/23 17:17	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/16/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 02:25	200.0	180.4	180.7	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/16/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 02:20	30.0	23.4	23.4	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/16/23 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	01/16/23 03:25	200.0	181.4	188.9	R-A /Span * 100	3.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/16/23 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	01/16/23 03:20	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/16/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 03:25	200.0	180.4	179.4	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/16/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/16/23 03:15	21.0	18.0	18.0	R-A	0.0
	Zero	01/16/23 03:20	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/16/23 17:26	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 17:37	200.0	180.0	179.7	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/16/23 17:26	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 17:31	10.0	8.7	8.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/16/23 17:26	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 17:37	200.0	181.3	179.8	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/16/23 17:26	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/16/23 17:31	10.0	8.5	8.5	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/16/23 17:26	21.0	18.2	18.0	R-A	0.2
	Zero	01/16/23 17:31	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/17/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 02:24	200.0	180.4	180.6	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/17/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 02:19	30.0	23.4	23.4	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/17/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 03:25	200.0	181.4	187.1	R-A /Span * 100	2.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/17/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 03:20	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/17/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 03:25	200.0	180.4	180.2	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/17/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 03:20	10.0	8.9	9.0	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/17/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	01/17/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/17/23 19:05	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 19:15	200.0	180.0	179.3	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/17/23 19:05	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 19:10	10.0	8.7	8.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/17/23 19:05	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 19:15	200.0	181.3	179.3	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/17/23 19:05	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/17/23 19:10	10.0	8.5	8.4	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/17/23 19:05	21.0	18.2	18.0	R-A		0.2
	Zero	01/17/23 19:10	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/18/23 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/18/23 02:25	200.0	181.3	180.6	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/18/23 02:15	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	01/18/23 02:20	30.0	24.3	23.9	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/18/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 02:25	200.0	180.4	181.4	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/18/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 02:20	30.0	24.6	25.3	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:24	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:24	200.0	181.3	179.9	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:19	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/18/23 03:14	21.0	18.2	18.0	R-A		0.2
	Zero	01/18/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:25	200.0	181.4	186.4	R-A /Span * 100		2.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/18/23 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/18/23 03:25	200.0	180.4		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/18/23 03:20	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/18/23 03:14	21.0	18.0		R-A	0.0
	Zero	01/18/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/19/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 02:25	200.0	180.4		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/19/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 02:19	30.0	24.6		R-A /Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/19/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 03:25	200.0	181.4		R-A /Span * 100	2.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/19/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/19/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 03:25	200.0	180.4		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/19/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/19/23 03:19	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/19/23 03:14	21.0	18.0		R-A	0.1
	Zero	01/19/23 03:19	21.0	0.0		R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/20/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	01/20/23 02:25	200.0	180.4		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/20/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	01/20/23 02:20	30.0	24.6		R-A /Span * 100	2.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/20/23 03:24	200.0	181.4	186.1	R-A /Span * 100		2.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/20/23 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/20/23 03:24	200.0	180.4	180.5	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/20/23 03:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/20/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/20/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/21/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/21/23 02:25	200.0	180.4	181.9	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/21/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/21/23 02:20	30.0	24.6	25.3	R-A /Span * 100		2.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/21/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/21/23 03:25	200.0	181.4	185.3	R-A /Span * 100		2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/21/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/21/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/21/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/21/23 03:25	200.0	180.4	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/21/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/21/23 03:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/21/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/21/23 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/22/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/22/23 02:24	200.0	180.4	180.6	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/22/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/22/23 02:19	30.0	24.6	25.1	R-A /Span * 100		1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/22/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/22/23 03:25	200.0	181.4	185.6	R-A /Span * 100		2.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/22/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/22/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/22/23 03:25	200.0	180.4	180.1	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/22/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/22/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	01/22/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/23/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/23/23 02:25	200.0	180.4	181.9	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/23/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/23/23 02:20	30.0	24.6	25.4	>1x Alert R-A /Span * 100		2.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/23/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/23/23 03:25	200.0	181.4	187.1	R-A /Span * 100		2.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/23/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/23/23 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/23/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/23/23 03:25	200.0	180.4	180.5	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/23/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	01/23/23 03:20	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/23/23 03:15	21.0	18.0		R-A	0.0
	Zero	01/23/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/23/23 18:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/23/23 18:24	200.0	180.0		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/23/23 18:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/23/23 18:20	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/23/23 18:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/23/23 18:24	200.0	181.3		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/23/23 18:14	10.0	0.0		R-A /Span * 100	0.0
	High	01/23/23 18:20	10.0	8.7		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/23/23 18:14	21.0	18.2		R-A	0.1
	Zero	01/23/23 18:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/24/23 02:15	200.0	0.0		R-A /Span * 100	0.1
	High	01/24/23 02:25	200.0	181.3		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/24/23 02:15	30.0	0.0		R-A /Span * 100	0.3
	High	01/24/23 02:20	30.0	24.3		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/24/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/24/23 02:25	200.0	180.4		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/24/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	01/24/23 02:19	30.0	24.6		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/24/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	01/24/23 03:24	200.0	180.0		R-A /Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/24/23 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/23 03:24	200.0	181.3	180.5	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/23 03:19	10.0	8.5	8.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/24/23 03:14	21.0	18.2	18.1	R-A		0.1
	Zero	01/24/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/24/23 03:25	200.0	181.4	186.1	R-A /Span * 100		2.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	01/24/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/23 03:25	200.0	180.4	180.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/23 03:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/24/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	01/24/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/25/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/25/23 02:25	200.0	180.4	179.2	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/25/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/25/23 02:20	30.0	24.6	24.4	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/25/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/25/23 03:24	200.0	181.4	186.5	R-A /Span * 100		2.6

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/25/23 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	01/25/23 03:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/25/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/25/23 03:24	200.0	180.4	179.8	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/25/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/25/23 03:19	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/25/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	01/25/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/26/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/26/23 02:25	200.0	180.4	178.9	R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/26/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/26/23 02:19	30.0	24.6	24.4	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/26/23 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	01/26/23 03:24	200.0	181.4	186.3	R-A /Span * 100	2.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/26/23 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	01/26/23 03:19	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/26/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/26/23 03:24	200.0	180.4	179.8	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/26/23 03:19	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/26/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	01/26/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/27/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/27/23 02:25	200.0	180.4	178.9	R-A /Span * 100	0.8

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/27/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	01/27/23 02:19	30.0	24.6	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/27/23 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	01/27/23 03:25	200.0	181.4	R-A /Span * 100		2.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/27/23 03:14	10.0	0.2	R-A /Span * 100		2.0
	High	01/27/23 03:20	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/27/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	01/27/23 03:25	200.0	180.4	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/27/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	01/27/23 03:20	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/27/23 03:14	21.0	18.0	R-A		0.0
	Zero	01/27/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/27/23 18:25	200.0	0.0	R-A /Span * 100		0.1
	High	01/27/23 18:36	200.0	180.0	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/27/23 18:25	10.0	0.0	R-A /Span * 100		1.0
	High	01/27/23 18:31	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/27/23 18:25	200.0	0.0	R-A /Span * 100		0.0
	High	01/27/23 18:36	200.0	181.3	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/27/23 18:25	10.0	0.0	R-A /Span * 100		0.0
	High	01/27/23 18:31	10.0	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/27/23 18:25	21.0	18.0	R-A		0.2
	Zero	01/27/23 18:31	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/28/23 02:14	200.0	0.0	R-A /Span * 100		0.1
	High	01/28/23 02:25	200.0	181.3	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/28/23 02:14	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	01/28/23 02:19	30.0	24.3	24.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/28/23 03:24	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/28/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	01/28/23 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/28/23 03:24	200.0	181.3	180.9	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/28/23 03:20	10.0	8.5	8.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/28/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	01/28/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/29/23 02:15	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	01/29/23 02:25	200.0	181.3	182.2	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/29/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	01/29/23 02:19	30.0	24.3	24.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/29/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/29/23 03:25	200.0	180.0	180.8	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/29/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	01/29/23 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/29/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/29/23 03:25	200.0	181.3	180.8	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/29/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/29/23 03:20	10.0	8.5	8.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/29/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	01/29/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/29/23 11:18	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	01/29/23 11:29	200.0	181.4	188.3	R-A /Span * 100		3.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/29/23 11:18	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	01/29/23 11:24	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/29/23 11:18	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/29/23 11:29	200.0	180.4	180.5	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/29/23 11:18	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/29/23 11:24	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/29/23 11:18	21.0	18.0	18.0	R-A		0.0
	Zero	01/29/23 11:24	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/30/23 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	01/30/23 02:25	200.0	181.3	183.5	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/30/23 02:14	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	01/30/23 02:20	30.0	24.3	24.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/30/23 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	01/30/23 03:24	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/30/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	01/30/23 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/30/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/30/23 03:24	200.0	181.3	180.6	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/30/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/30/23 03:19	10.0	8.5	8.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/30/23 03:14	21.0	18.0	17.8	R-A	0.2
	Zero	01/30/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/31/23 02:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	01/31/23 02:25	200.0	181.6	180.8	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/31/23 02:15	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	01/31/23 02:20	30.0	24.3	24.3	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/31/23 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	01/31/23 03:25	200.0	181.4	180.1	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/31/23 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	01/31/23 03:20	10.0	8.7	8.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	01/31/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/31/23 03:25	200.0	181.6	177.9	R-A /Span * 100	1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	01/31/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	01/31/23 03:20	10.0	8.5	8.5	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	01/31/23 03:15	21.0	18.0	17.8	R-A	0.2
	Zero	01/31/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/01/23 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	02/01/23 02:25	200.0	181.6	180.9	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/01/23 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	02/01/23 02:19	30.0	24.3	24.1	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/01/23 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	02/01/23 03:25	200.0	181.4	180.7	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/01/23 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	02/01/23 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/01/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/01/23 03:25	200.0	181.6	177.4	R-A /Span * 100		2.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/01/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/01/23 03:20	10.0	8.5	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/01/23 03:15	21.0	18.0	17.8	R-A		0.2
	Zero	02/01/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/02/23 02:15	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	02/02/23 02:25	200.0	181.6	179.8	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/02/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/02/23 02:20	30.0	24.3	24.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/02/23 03:24	200.0	181.4	179.6	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/02/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/02/23 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/02/23 03:24	200.0	181.6	177.8	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/02/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/02/23 03:20	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/02/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/02/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/03/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/03/23 02:25	200.0	181.6	179.7	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/03/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/03/23 02:20	30.0	24.3	24.1	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/03/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/03/23 03:25	200.0	181.4	179.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/03/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	02/03/23 03:19	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/03/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/03/23 03:25	200.0	181.6	177.7	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/03/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/03/23 03:19	10.0	8.5	8.5	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/03/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/03/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/03/23 18:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/03/23 18:24	200.0	181.4	187.4	R-A /Span * 100		3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/03/23 18:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	02/03/23 18:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/03/23 18:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/03/23 18:24	200.0	180.4	180.6	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/03/23 18:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/03/23 18:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/03/23 18:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/03/23 18:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/04/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 02:25	200.0	180.4	182.3	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/04/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 02:20	30.0	24.6	25.1	R-A /Span * 100		1.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/04/23 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/04/23 03:25	200.0	181.4	186.8	R-A /Span * 100		2.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/04/23 03:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/04/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/04/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 03:25	200.0	180.4	180.9	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/04/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 03:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/04/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	02/04/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/04/23 18:13	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 18:23	200.0	181.4	180.4	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/04/23 18:13	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	02/04/23 18:18	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/04/23 18:13	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 18:23	200.0	181.6	176.7	R-A /Span * 100		2.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/04/23 18:13	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/04/23 18:18	10.0	8.5	8.3	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/04/23 18:13	21.0	18.0	17.8	R-A		0.2
	Zero	02/04/23 18:18	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/05/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 02:24	200.0	180.4	179.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/05/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 02:20	30.0	24.6	24.5	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/05/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/05/23 03:24	200.0	181.4	187.9	R-A /Span * 100		3.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/05/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/05/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 03:24	200.0	180.4	180.4	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/05/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/05/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/05/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/05/23 20:01	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 20:11	200.0	181.4	179.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/05/23 20:01	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	02/05/23 20:06	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/05/23 20:01	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 20:11	200.0	181.6	176.7	R-A /Span * 100		2.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/05/23 20:01	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/05/23 20:06	10.0	8.4	8.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/05/23 20:01	21.0	18.0	17.8	R-A		0.2
	Zero	02/05/23 20:06	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/06/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/06/23 02:25	200.0	180.4	178.9	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/06/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/06/23 02:19	30.0	24.6	24.4	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/06/23 03:15	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	02/06/23 03:25	200.0	181.4	185.8	R-A /Span * 100	2.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/06/23 03:15	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	02/06/23 03:20	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/06/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/06/23 03:25	200.0	180.4	180.7	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/06/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/06/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/06/23 03:15	21.0	18.0	18.0	R-A	0.0
	Zero	02/06/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/06/23 18:26	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/06/23 18:37	200.0	181.4	179.4	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/06/23 18:26	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	02/06/23 18:32	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/06/23 18:26	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/06/23 18:37	200.0	181.6	176.4	>1x Alert R-A /Span * 100	2.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/06/23 18:26	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/06/23 18:32	10.0	8.4	8.3	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/06/23 18:26	21.0	18.0	17.8	R-A	0.2
	Zero	02/06/23 18:32	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/07/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/07/23 02:24	200.0	180.4	178.9	R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/07/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/07/23 02:19	30.0	24.6	24.4	R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/07/23 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/07/23 03:25	200.0	181.4	186.8	R-A /Span * 100		2.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/07/23 03:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/07/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 03:25	200.0	180.4	180.7	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 03:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/07/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	02/07/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/07/23 18:40	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 18:50	200.0	181.4	182.6	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/07/23 18:40	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 18:45	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/07/23 18:40	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 18:50	200.0	181.6	180.1	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/07/23 18:40	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/07/23 18:45	10.0	8.4	8.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/07/23 18:40	21.0	18.0	17.8	R-A		0.2
	Zero	02/07/23 18:45	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/08/23 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/08/23 02:25	200.0	181.6	181.1	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/08/23 02:15	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/08/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/08/23 02:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	02/08/23 02:25	200.0	180.4	179.5	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/08/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 02:19	30.0	24.6	24.5	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/08/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 03:25	200.0	181.4	183.2	R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/08/23 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	02/08/23 03:19	10.0	8.7	8.8	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/08/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 03:25	200.0	181.6	180.9	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/08/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 03:19	10.0	8.4	8.4	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/08/23 03:15	21.0	18.0	17.8	R-A	0.2
	Zero	02/08/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/08/23 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	02/08/23 03:25	200.0	181.4	186.3	R-A /Span * 100	2.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/08/23 03:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	02/08/23 03:19	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 03:25	200.0	180.4	180.5	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/08/23 03:19	10.0	8.9	9.0	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/08/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	02/08/23 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/09/23 02:24	200.0	181.6	181.1	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/09/23 02:20	30.0	24.3	24.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	02/09/23 02:24	200.0	180.4	180.1	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 02:19	30.0	24.6	24.7	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:25	200.0	181.4	183.6	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:25	200.0	181.6	180.9	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:19	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/09/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/09/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/09/23 03:24	200.0	181.4	187.1	R-A /Span * 100		2.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/09/23 03:20	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:24	200.0	180.4	180.4	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/09/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/09/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/09/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/10/23 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/10/23 02:25	200.0	181.6	180.9	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/10/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/10/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/10/23 03:25	200.0	181.4	183.8	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/10/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	02/10/23 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/10/23 03:25	200.0	181.6	181.4	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/10/23 03:19	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/10/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/10/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/10/23 17:58	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/10/23 18:09	200.0	181.4	187.4	R-A /Span * 100		3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/10/23 17:58	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/10/23 18:03	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/10/23 17:58	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/10/23 18:09	200.0	180.4	180.1	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/10/23 17:58	10.0	0.0	R-A /Span * 100		0.0
	High	02/10/23 18:03	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/10/23 17:58	21.0	18.0	R-A		0.0
	Zero	02/10/23 18:03	21.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/11/23 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	02/11/23 02:25	200.0	181.6	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/11/23 02:14	30.0	0.1	R-A /Span * 100		0.3
	High	02/11/23 02:20	30.0	24.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/11/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 02:25	200.0	180.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/11/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 02:19	30.0	24.6	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/11/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:25	200.0	181.4	R-A /Span * 100		1.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/11/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:20	10.0	8.7	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/11/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:25	200.0	181.6	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/11/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:20	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/11/23 03:15	21.0	18.0	R-A		0.2
	Zero	02/11/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/11/23 03:14	200.0	0.3	R-A /Span * 100		0.2
	High	02/11/23 03:25	200.0	181.4	R-A /Span * 100		3.2

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/11/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/11/23 03:19	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:25	200.0	180.4	180.4	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/11/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/11/23 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/11/23 17:17	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 17:28	200.0	181.4	184.4	R-A /Span * 100		1.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/11/23 17:17	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 17:23	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/11/23 17:17	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 17:28	200.0	181.6	181.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/11/23 17:17	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/11/23 17:23	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/11/23 17:17	21.0	18.0	17.8	R-A		0.2
	Zero	02/11/23 17:23	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/12/23 02:24	200.0	181.6	182.1	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/12/23 02:19	30.0	24.3	24.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 02:24	200.0	180.4	179.7	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 02:19	30.0	24.6	24.5	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 03:24	200.0	181.4	184.2	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	02/12/23 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 03:24	200.0	181.6	181.3	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 03:19	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/12/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/12/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/12/23 03:25	200.0	181.4	188.1	R-A /Span * 100		3.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/12/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 03:25	200.0	180.4	180.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/12/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/12/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/12/23 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/13/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/13/23 02:25	200.0	180.4	179.4	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/13/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/13/23 02:20	30.0	24.6	24.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/13/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/13/23 03:25	200.0	181.4	188.5	R-A /Span * 100		3.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/13/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/13/23 03:20	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/13/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/13/23 03:25	200.0	180.4	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/13/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/13/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/13/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/13/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/14/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 02:25	200.0	180.4	179.3	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/14/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 02:20	30.0	24.6	24.4	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/14/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/14/23 03:25	200.0	181.4	187.9	R-A /Span * 100		3.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/14/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/14/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/14/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 03:25	200.0	180.4	180.6	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/14/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/14/23 03:14	21.0	18.0	R-A		0.0
	Zero	02/14/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/14/23 17:10	200.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 17:20	200.0	181.4	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/14/23 17:10	10.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 17:15	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/14/23 17:10	200.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 17:20	200.0	181.6	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/14/23 17:10	10.0	0.0	R-A /Span * 100		0.0
	High	02/14/23 17:15	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/14/23 17:10	21.0	17.8	R-A		0.2
	Zero	02/14/23 17:15	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 02:15	200.0	0.0	R-A /Span * 100		0.1
	High	02/15/23 02:24	200.0	181.6	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 02:15	30.0	0.0	R-A /Span * 100		0.3
	High	02/15/23 02:19	30.0	24.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 02:25	200.0	180.4	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 02:19	30.0	23.0	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:25	200.0	181.4	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:19	10.0	8.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:25	200.0	181.6	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:19	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/15/23 03:14	21.0	17.8	R-A		0.2
	Zero	02/15/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	200.0	0.3	R-A /Span * 100		0.2
	High	02/15/23 03:25	200.0	181.4	R-A /Span * 100		2.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	10.0	0.3	R-A /Span * 100		3.0
	High	02/15/23 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:25	200.0	180.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	02/15/23 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/15/23 03:14	21.0	18.0	R-A		0.0
	Zero	02/15/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/16/23 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	02/16/23 02:25	200.0	181.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/16/23 02:14	30.0	0.1	R-A /Span * 100		0.3
	High	02/16/23 02:19	30.0	24.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/16/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 02:25	200.0	181.0	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/16/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 02:19	30.0	23.0	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:24	200.0	181.4	181.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:19	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:24	200.0	181.6	180.5	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:19	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/16/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/16/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/16/23 03:25	200.0	182.0	187.2	R-A /Span * 100		2.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/16/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:25	200.0	181.0	180.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/16/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/16/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/16/23 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/17/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/17/23 02:25	200.0	181.6	181.3	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/17/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/17/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/17/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 02:25	200.0	181.0	178.8	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/17/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 02:20	30.0	23.0	22.2	>1x Alert R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 03:25	200.0	181.4	182.5	R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 03:25	200.0	181.6	180.3	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	02/17/23 03:20	10.0	8.4	8.3	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/17/23 03:14	21.0	18.0	17.8	R-A	0.2
	Zero	02/17/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	02/17/23 03:24	200.0	182.0	188.2	R-A /Span * 100	3.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	02/17/23 03:20	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/17/23 03:24	200.0	181.0	180.2	R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/17/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/17/23 03:20	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/17/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	02/17/23 03:20	21.0	0.0	0.1	R-A	0.1

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/17/23 09:39	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/17/23 09:48	200.0	181.0	180.6	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/17/23 09:39	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/17/23 09:44	30.0	23.0	23.4	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/18/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/18/23 02:25	200.0	181.0	181.2	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/18/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/18/23 02:20	30.0	23.0	23.5	R-A /Span * 100		1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/18/23 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/18/23 03:25	200.0	182.0	188.9	R-A /Span * 100		3.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/18/23 03:15	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	02/18/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/18/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/18/23 03:25	200.0	181.0	180.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/18/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/18/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/18/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	02/18/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/19/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/19/23 02:25	200.0	181.0	180.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/19/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/19/23 02:19	30.0	23.0	23.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/19/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/19/23 03:24	200.0	182.0	189.0	R-A /Span * 100		3.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/19/23 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/19/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/19/23 03:24	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/19/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/19/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/19/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/20/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/20/23 02:24	200.0	181.0	180.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/20/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/20/23 02:19	30.0	23.0	23.4	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/20/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/20/23 03:24	200.0	182.0	188.5	R-A /Span * 100		3.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/20/23 03:14	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	02/20/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/20/23 03:24	200.0	181.0	179.8	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/20/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/20/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	02/20/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/20/23 17:47	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/20/23 17:57	200.0	181.4	183.6	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/20/23 17:47	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	02/20/23 17:52	10.0	8.7	8.8	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/20/23 17:47	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/20/23 17:57	200.0	181.6	180.3	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/20/23 17:47	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/20/23 17:52	10.0	8.4	8.4	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/20/23 17:47	21.0	18.0	17.8	R-A	0.2
	Zero	02/20/23 17:52	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/21/23 02:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	02/21/23 02:25	200.0	181.6	180.9	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/21/23 02:15	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	02/21/23 02:20	30.0	24.3	24.2	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/21/23 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	02/21/23 03:25	200.0	181.4	184.3	R-A /Span * 100	1.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/21/23 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	02/21/23 03:20	10.0	8.7	8.8	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/21/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/21/23 03:25	200.0	181.6	181.8	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/21/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	02/21/23 03:20	10.0	8.4	8.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/21/23 03:15	21.0	18.0	17.8	R-A	0.2
	Zero	02/21/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/22/23 02:15	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	02/22/23 02:24	200.0	181.6	183.0	R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/22/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/22/23 02:19	30.0	24.3	24.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 03:25	200.0	181.4	186.4	R-A /Span * 100		2.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 03:25	200.0	181.6	182.5	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 03:19	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/22/23 03:15	21.0	18.0	17.8	R-A		0.2
	Zero	02/22/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/22/23 18:13	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	02/22/23 18:23	200.0	182.0	190.8	R-A /Span * 100		4.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/22/23 18:13	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	02/22/23 18:18	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/22/23 18:13	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 18:23	200.0	181.0	180.1	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/22/23 18:13	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/22/23 18:18	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/22/23 18:13	21.0	18.0	18.0	R-A		0.0
	Zero	02/22/23 18:18	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/23/23 02:24	200.0	181.6	182.5	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	02/23/23 02:20	30.0	24.3	24.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 02:25	200.0	181.0	183.7	R-A /Span * 100		1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 02:19	30.0	23.0	24.1	>1x Alert R-A /Span * 100		3.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:25	200.0	181.4	186.5	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:19	10.0	8.7	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:25	200.0	181.6	182.1	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:19	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/23/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/23/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	02/23/23 03:25	200.0	182.0	190.3	R-A /Span * 100		4.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	02/23/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:25	200.0	181.0	180.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/23/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/23/23 03:14	21.0	18.0	R-A		0.0
	Zero	02/23/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/24/23 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	02/24/23 02:25	200.0	181.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/24/23 02:14	30.0	0.1	R-A /Span * 100		0.3
	High	02/24/23 02:20	30.0	24.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/24/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/24/23 03:25	200.0	181.4	R-A /Span * 100		2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/24/23 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	02/24/23 03:19	10.0	8.7	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/24/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/24/23 03:25	200.0	181.6	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/24/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	02/24/23 03:19	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	02/24/23 03:14	21.0	18.0	R-A		0.2
	Zero	02/24/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/25/23 02:15	200.0	0.1	R-A /Span * 100		0.1
	High	02/25/23 02:25	200.0	181.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/25/23 02:15	30.0	0.1	R-A /Span * 100		0.3
	High	02/25/23 02:20	30.0	24.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	02/25/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	02/25/23 03:25	200.0	181.4	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	02/25/23 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	02/25/23 03:20	10.0	8.7	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/25/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/25/23 03:25	200.0	181.6	181.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/25/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/25/23 03:20	10.0	8.4	8.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/25/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/25/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/26/23 02:15	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	02/26/23 02:25	200.0	181.6	181.6	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/26/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/26/23 02:20	30.0	24.3	24.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/26/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/23 03:24	200.0	181.4	186.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/23 03:19	10.0	8.7	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/26/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/23 03:24	200.0	181.6	181.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/23 03:19	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/26/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/26/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/23 02:15	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	02/27/23 02:25	200.0	181.6	181.6	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/23 02:15	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/27/23 02:20	30.0	24.3	24.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/27/23 03:24	200.0	181.4	186.5	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	02/27/23 03:20	10.0	8.7	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/23 03:24	200.0	181.6	182.2	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/23 03:20	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/27/23 03:15	21.0	18.0	17.8	R-A		0.2
	Zero	02/27/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/23 19:32	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/27/23 19:42	200.0	182.0	189.2	R-A /Span * 100		3.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/23 19:32	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/27/23 19:36	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/23 19:32	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/23 19:42	200.0	181.0	180.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/23 19:32	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/23 19:36	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/27/23 19:32	21.0	18.0	18.0	R-A		0.0
	Zero	02/27/23 19:36	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/28/23 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	02/28/23 02:25	200.0	181.6	181.4	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/28/23 02:14	30.0	0.0	0.2	R-A /Span * 100		0.7
	High	02/28/23 02:19	30.0	24.3	24.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/28/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/28/23 03:25	200.0	181.4	186.1	R-A /Span * 100		2.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/28/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	02/28/23 03:20	10.0	8.7	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/28/23 03:25	200.0	181.6	182.1	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/28/23 03:20	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/28/23 03:14	21.0	18.0	17.8	R-A		0.2
	Zero	02/28/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/28/23 19:45	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	02/28/23 19:55	200.0	182.0	190.7	R-A /Span * 100		4.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/28/23 19:45	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	02/28/23 19:51	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/28/23 19:45	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/28/23 19:55	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/28/23 19:45	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/28/23 19:51	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/28/23 19:45	21.0	18.0	18.0	R-A		0.0
	Zero	02/28/23 19:51	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/01/23 02:25	200.0	181.6	181.9	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	03/01/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 02:24	200.0	181.0	178.7	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 02:19	30.0	23.0	22.5	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/01/23 03:25	200.0	181.4	185.4	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/01/23 03:20	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 03:25	200.0	181.6	181.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 03:20	10.0	8.4	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/01/23 03:15	21.0	18.0	17.8	R-A		0.2
	Zero	03/01/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	03/01/23 03:25	200.0	182.0	190.6	R-A /Span * 100		4.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	03/01/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 03:25	200.0	181.0	180.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/23 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/01/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	03/01/23 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/02/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/02/23 02:24	200.0	181.6	180.6	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/02/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/02/23 02:20	30.0	24.3	24.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/02/23 03:25	200.0	181.4	180.3	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/02/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/02/23 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/02/23 03:25	200.0	181.6	180.6	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/02/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/02/23 03:20	10.0	8.4	8.2	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/02/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	03/02/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/03/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 02:25	200.0	181.6	179.6	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/03/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/03/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/03/23 03:25	200.0	181.4	180.4	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/03/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/03/23 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/03/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 03:25	200.0	181.6	180.2	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/03/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 03:20	10.0	8.4	8.2	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/03/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	03/03/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/03/23 16:34	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	03/03/23 16:45	200.0	182.0	181.7	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/03/23 16:34	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	03/03/23 16:40	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/03/23 16:34	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 16:45	200.0	181.0	180.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/03/23 16:34	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/03/23 16:40	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/03/23 16:34	21.0	18.0	18.0	R-A		0.0
	Zero	03/03/23 16:40	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/04/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 02:24	200.0	181.6	179.8	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/04/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/04/23 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/04/23 03:25	200.0	181.4	181.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/04/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	03/04/23 03:20	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 03:25	200.0	181.6	180.6	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 03:20	10.0	8.4	8.2	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/04/23 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	03/04/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/04/23 19:01	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	03/04/23 19:11	200.0	182.0	181.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/04/23 19:01	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	03/04/23 19:06	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/04/23 19:01	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 19:11	200.0	181.0	180.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/04/23 19:01	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/04/23 19:06	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/04/23 19:01	21.0	18.0	18.0	R-A		0.0
	Zero	03/04/23 19:06	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/05/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/05/23 02:25	200.0	181.6	179.9	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/05/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/05/23 02:20	30.0	24.3	24.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/05/23 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/05/23 03:24	200.0	181.4	181.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/05/23 03:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/05/23 03:19	10.0	8.7	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/05/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/05/23 03:24	200.0	181.6	180.7	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/05/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/05/23 03:19	10.0	8.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/05/23 03:15	21.0	18.1		R-A	0.0
	Zero	03/05/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/05/23 18:51	200.0	0.4		R-A /Span * 100	0.2
	High	03/05/23 19:01	200.0	181.3		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/05/23 18:51	10.0	0.4		R-A /Span * 100	4.0
	High	03/05/23 18:56	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/05/23 18:51	200.0	0.0		R-A /Span * 100	0.0
	High	03/05/23 19:01	200.0	181.0		R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/05/23 18:51	10.0	0.0		R-A /Span * 100	0.0
	High	03/05/23 18:56	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/05/23 18:51	21.0	18.0		R-A	0.0
	Zero	03/05/23 18:56	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/06/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/06/23 02:25	200.0	181.6		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/06/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	03/06/23 02:20	30.0	24.3		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/06/23 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	03/06/23 03:25	200.0	181.4		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/06/23 03:14	10.0	0.2		R-A /Span * 100	2.0
	High	03/06/23 03:20	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/06/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/06/23 03:25	200.0	181.6		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/06/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/06/23 03:20	10.0	8.4	8.2	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/06/23 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	03/06/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/06/23 15:02	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/06/23 15:12	200.0	182.0	181.3	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/06/23 15:02	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/06/23 15:07	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/06/23 15:02	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/06/23 15:12	200.0	181.0	179.6	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/06/23 15:02	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/06/23 15:07	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/06/23 15:02	21.0	18.0	18.0	R-A		0.0
	Zero	03/06/23 15:07	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/07/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/07/23 02:24	200.0	181.6	179.4	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/07/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/07/23 02:19	30.0	24.3	24.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/07/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/07/23 02:24	200.0	181.0	178.2	R-A /Span * 100		1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/07/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/07/23 02:20	30.0	23.0	22.7	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/07/23 03:25	200.0	181.4	180.6	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	03/07/23 03:20	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/07/23 03:25	200.0	181.6	179.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/07/23 03:20	10.0	8.4	8.1	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/07/23 03:15	21.0	18.1	18.1	R-A	0.0
	Zero	03/07/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	03/07/23 03:25	200.0	182.0	180.3	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	03/07/23 03:20	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/07/23 03:25	200.0	181.0	179.7	R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/07/23 03:20	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/07/23 03:15	21.0	18.0	18.0	R-A	0.0
	Zero	03/07/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/08/23 02:25	200.0	181.6	180.8	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/08/23 02:20	30.0	24.3	24.3	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/08/23 02:25	200.0	181.0	178.6	R-A /Span * 100	1.2

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	03/08/23 02:20	30.0	23.0	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 03:14	200.0	0.3	R-A /Span * 100		0.2
	High	03/08/23 03:25	200.0	181.4	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 03:14	10.0	0.2	R-A /Span * 100		2.0
	High	03/08/23 03:19	10.0	8.7	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/08/23 03:25	200.0	181.6	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/08/23 03:19	10.0	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/08/23 03:14	21.0	18.1	R-A		0.0
	Zero	03/08/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 03:15	200.0	0.3	R-A /Span * 100		0.2
	High	03/08/23 03:25	200.0	182.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 03:15	10.0	0.3	R-A /Span * 100		3.0
	High	03/08/23 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	03/08/23 03:25	200.0	181.0	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	03/08/23 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/08/23 03:15	21.0	18.0	R-A		0.0
	Zero	03/08/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/09/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 02:25	200.0	181.9	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 02:20	30.0	24.3	24.9	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/09/23 02:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/09/23 02:25	200.0	181.0	176.5	R-A /Span * 100		2.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 02:15	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	03/09/23 02:19	30.0	23.0	22.4	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:24	200.0	178.7	180.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:24	200.0	181.9	182.9	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:20	10.0	8.4	8.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/09/23 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	03/09/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/09/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:25	200.0	182.0	182.2	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/09/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:25	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/09/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/09/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/09/23 03:15	21.0	18.0	R-A		0.0
	Zero	03/09/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/10/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 02:25	200.0	182.3	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/10/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 02:19	30.0	24.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 03:25	200.0	182.1	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 03:19	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 03:25	200.0	183.7	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 03:19	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/10/23 03:14	21.0	18.1	R-A		0.0
	Zero	03/10/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/10/23 17:53	200.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 18:04	200.0	182.9	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/10/23 17:53	10.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 17:58	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/10/23 17:53	200.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 18:04	200.0	179.7	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/10/23 17:53	10.0	0.0	R-A /Span * 100		0.0
	High	03/10/23 17:58	10.0	8.9	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/10/23 17:53	21.0	18.0	R-A		0.0
	Zero	03/10/23 17:58	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/11/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 02:24	200.0	184.2	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/11/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 02:19	30.0	24.8	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/11/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 03:24	200.0	180.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/11/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 03:19	10.0	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/11/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 03:24	200.0	183.4	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/11/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 03:19	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/11/23 03:14	21.0	18.1	R-A		0.0
	Zero	03/11/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/11/23 19:04	200.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 19:14	200.0	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/11/23 19:04	10.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 19:09	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/11/23 19:04	200.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 19:14	200.0	179.2	R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/11/23 19:04	10.0	0.0	R-A /Span * 100		0.0
	High	03/11/23 19:09	10.0	8.9	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/11/23 19:04	21.0	18.0	R-A		0.0
	Zero	03/11/23 19:09	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	03/12/23 02:24	200.0	183.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 02:20	30.0	24.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	03/12/23 02:25	200.0	175.0	>1x Alert R-A /Span * 100		3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 02:14	30.0	0.1	R-A /Span * 100		0.3
	High	03/12/23 02:19	30.0	22.1	>1x Alert R-A /Span * 100		3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:25	200.0	180.4	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:19	10.0	8.7	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:25	200.0	183.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:19	10.0	8.4	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/12/23 03:14	21.0	18.1	R-A		0.0
	Zero	03/12/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:25	200.0	181.8	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	03/12/23 03:20	10.0	9.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/12/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/12/23 03:25	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/12/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/12/23 03:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/12/23 03:15	21.0	18.0		R-A	0.0
	Zero	03/12/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 02:25	200.0	181.9		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 02:20	30.0	24.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 03:25	200.0	178.7		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 03:20	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 03:25	200.0	181.9		R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 03:20	10.0	8.4		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/13/23 03:15	21.0	18.1		R-A	0.0
	Zero	03/13/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/23 18:10	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 18:20	200.0	182.0		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/23 18:10	10.0	0.0		R-A /Span * 100	1.0
	High	03/13/23 18:15	10.0	9.0		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/23 18:10	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 18:20	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/23 18:10	10.0	0.0		R-A /Span * 100	0.0
	High	03/13/23 18:15	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/13/23 18:10	21.0	18.0		R-A	0.0
	Zero	03/13/23 18:15	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/14/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 02:24	200.0	181.9		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/14/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 02:19	30.0	24.3		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/14/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 03:25	200.0	178.7		R-A /Span * 100	1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/14/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 03:20	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/14/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 03:25	200.0	181.9		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/14/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 03:20	10.0	8.4		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/14/23 03:15	21.0	18.1		R-A	0.0
	Zero	03/14/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/14/23 11:49	200.0	0.0		R-A /Span * 100	0.0
	High	03/14/23 11:59	200.0	182.0		R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/14/23 11:49	10.0	0.0		R-A /Span * 100	1.0
	High	03/14/23 11:54	10.0	9.0		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/14/23 11:49	200.0	0.0	R-A /Span * 100		0.0
	High	03/14/23 11:59	200.0	181.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/14/23 11:49	10.0	0.0	R-A /Span * 100		0.0
	High	03/14/23 11:54	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/14/23 11:49	21.0	18.0	R-A		0.0
	Zero	03/14/23 11:54	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/15/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 02:25	200.0	181.9	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/15/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 02:20	30.0	24.3	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 03:25	200.0	178.7	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 03:19	10.0	8.7	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 03:25	200.0	181.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	03/15/23 03:19	10.0	8.4	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/15/23 03:14	21.0	18.1	R-A		0.0
	Zero	03/15/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/15/23 17:57	200.0	-0.1	R-A /Span * 100		0.1
	High	03/15/23 18:07	200.0	182.0	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/15/23 17:57	10.0	-0.1	R-A /Span * 100		1.0
	High	03/15/23 18:01	10.0	9.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/15/23 17:57	200.0	0.0		R-A /Span * 100	0.0
	High	03/15/23 18:07	200.0	181.0		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/15/23 17:57	10.0	0.0		R-A /Span * 100	0.0
	High	03/15/23 18:01	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/15/23 17:57	21.0	18.0		R-A	0.0
	Zero	03/15/23 18:01	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/16/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 02:24	200.0	181.9		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/16/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 02:19	30.0	24.3		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/16/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 03:25	200.0	178.7		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/16/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 03:20	10.0	8.7		R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/16/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 03:25	200.0	181.9		R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/16/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 03:20	10.0	8.4		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/16/23 03:14	21.0	18.1		R-A	0.0
	Zero	03/16/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/16/23 18:10	200.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 18:20	200.0	182.0		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/16/23 18:10	10.0	0.0		R-A /Span * 100	1.0
	High	03/16/23 18:15	10.0	9.0		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/16/23 18:10	200.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 18:20	200.0	181.0		R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/16/23 18:10	10.0	0.0		R-A /Span * 100	0.0
	High	03/16/23 18:15	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/16/23 18:10	21.0	18.0		R-A	0.0
	Zero	03/16/23 18:15	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/17/23 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	03/17/23 02:25	200.0	181.9		R-A /Span * 100	1.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/17/23 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	03/17/23 02:20	30.0	24.3	>1x Alert	R-A /Span * 100	3.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/17/23 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	03/17/23 02:25	200.0	181.0	>1x Alert	R-A /Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/17/23 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	03/17/23 02:20	30.0	23.0	>1x Alert	R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/17/23 03:24	200.0	182.0		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/17/23 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/17/23 03:24	200.0	181.0		R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/17/23 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/17/23 03:14	21.0	18.0		R-A	0.0
	Zero	03/17/23 03:19	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 03:25	200.0	178.7	178.1	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 03:25	200.0	181.9	183.0	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/17/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 03:20	10.0	8.4	8.6	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/17/23 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	03/17/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/17/23 18:25	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 18:36	200.0	182.0	182.6	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/17/23 18:25	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 18:31	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/17/23 18:25	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 18:36	200.0	181.0	179.3	R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/17/23 18:25	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/17/23 18:31	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/17/23 18:25	21.0	18.0	18.0	R-A		0.0
	Zero	03/17/23 18:31	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/18/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/18/23 02:25	200.0	181.9	183.6	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/18/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/18/23 02:19	30.0	24.3	24.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 03:24	200.0	178.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 03:19	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 03:24	200.0	181.9		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 03:19	10.0	8.4		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/18/23 03:14	21.0	18.1		R-A	0.0
	Zero	03/18/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/18/23 17:31	200.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 17:41	200.0	182.0		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/18/23 17:31	10.0	0.0		R-A /Span * 100	1.0
	High	03/18/23 17:37	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/18/23 17:31	200.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 17:41	200.0	181.0		R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/18/23 17:31	10.0	0.0		R-A /Span * 100	0.0
	High	03/18/23 17:37	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/18/23 17:31	21.0	18.0		R-A	0.0
	Zero	03/18/23 17:37	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/19/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/19/23 02:24	200.0	181.9		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/19/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/19/23 02:19	30.0	24.3		R-A /Span * 100	1.3

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 03:25	200.0	178.7	179.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 03:19	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 03:25	200.0	181.9	183.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 03:19	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/19/23 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	03/19/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/23 17:45	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	03/19/23 17:56	200.0	182.0	182.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/23 17:45	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	03/19/23 17:51	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/23 17:45	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 17:56	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/23 17:45	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/23 17:51	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/19/23 17:45	21.0	18.0	18.0	R-A		0.0
	Zero	03/19/23 17:51	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/20/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 02:24	200.0	181.9	182.9	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/20/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 02:19	30.0	25.2	24.4	>1x Alert R-A /Span * 100		2.7

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:58 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/20/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 03:24	200.0	178.7	179.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/20/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 03:20	10.0	8.7	8.6	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/20/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 03:24	200.0	181.9	183.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/20/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 03:20	10.0	8.4	8.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/20/23 03:15	21.0	18.1	18.1	R-A		0.0
	Zero	03/20/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/20/23 18:16	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 18:26	200.0	182.0	182.6	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/20/23 18:16	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	03/20/23 18:21	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/20/23 18:16	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 18:26	200.0	181.0	179.6	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/20/23 18:16	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/20/23 18:21	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/20/23 18:16	21.0	18.0	18.0	R-A		0.0
	Zero	03/20/23 18:21	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/21/23 13:51	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/21/23 14:02	200.0	182.0	184.7	R-A /Span * 100		1.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/21/23 13:51	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/21/23 13:56	10.0	9.0	9.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/21/23 13:51	200.0	0.0		R-A /Span * 100	0.0
	High	03/21/23 14:02	200.0	181.0	179.3	R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/21/23 13:51	10.0	0.0		R-A /Span * 100	0.0
	High	03/21/23 13:56	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/21/23 13:51	21.0	18.0		R-A	0.0
	Zero	03/21/23 13:56	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/23 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	03/22/23 02:24	200.0	181.0	174.9	>1x Alert R-A /Span * 100	3.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/23 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	03/22/23 02:20	30.0	25.3	24.4	>1x Alert R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/23 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	03/22/23 03:24	200.0	182.0	183.1	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/23 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	03/22/23 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/22/23 03:24	200.0	181.0	179.4	R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/22/23 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/22/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	03/22/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/23 18:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/22/23 18:22	200.0	178.7	180.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/23 18:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	03/22/23 18:17	10.0	8.7	8.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/23 18:12	200.0	0.0		R-A /Span * 100	0.0
	High	03/22/23 18:22	200.0	181.9		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/23 18:12	10.0	0.0		R-A /Span * 100	0.0
	High	03/22/23 18:17	10.0	8.4		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/22/23 18:12	21.0	18.1		R-A	0.0
	Zero	03/22/23 18:17	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 02:24	200.0	181.0		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 02:20	30.0	25.3		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 03:24	200.0	182.0		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/23 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	03/23/23 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 03:24	200.0	181.0		R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 03:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/23/23 03:14	21.0	18.0		R-A	0.0
	Zero	03/23/23 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/23 16:55	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 17:05	200.0	178.7		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/23 16:55	10.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 17:00	10.0	8.7		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/23 16:55	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 17:05	200.0	181.9		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/23 16:55	10.0	0.0		R-A /Span * 100	0.0
	High	03/23/23 17:00	10.0	8.4		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/23/23 16:55	21.0	18.1		R-A	0.0
	Zero	03/23/23 17:00	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/24/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/24/23 02:24	200.0	181.0		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/24/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	03/24/23 02:19	30.0	25.3		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/24/23 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	03/24/23 03:24	200.0	182.0		R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/24/23 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	03/24/23 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/24/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/24/23 03:24	200.0	181.0		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/24/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/24/23 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/24/23 03:14	21.0	18.0		R-A	0.0
	Zero	03/24/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/25/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 02:25	200.0	181.0		R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/25/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 02:20	30.0	25.3		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2023 08:58

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	03/25/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 03:25	200.0	182.0		R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	03/25/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 03:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	03/25/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 03:25	200.0	181.0		R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	03/25/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/25/23 03:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	03/25/23 03:14	21.0	18.0		R-A	0.0
	Zero	03/25/23 03:20	21.0	0.0		R-A	0.0

Monthly Summary Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:59 Location: Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Jan 23	246.77	246.77	147.99	147.99	648.12	648.12	148.12	148.12
Feb 23	458.94	705.71	178.85	326.84	410.48	1,058.60	138.20	286.32
Mar 23	481.83	1,187.54	156.53	483.37	303.18	1,361.78	153.54	439.86
Sum/Avg	1,187.54		483.37		1,361.78		439.86	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:54 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2023	0.8256	7.5859	1.0650	14.2128	0.2163	2.9308	0.1084	1.4667	0.3601	4.8854
Feb 2023	0.9164	7.5652	1.0643	14.3537	0.2142	2.9600	0.1074	1.4819	0.3569	4.9340
Mar 2023	0.9505	8.1089	1.0109	14.8234	0.1947	3.0447	0.0971	1.5240	0.3242	5.0748
Sum/Avg	8.1089		14.8234		3.0447		1.5240		5.0748	
Limit Value										

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/01/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/02/2023 12:00	2,500.6	0.0	2,500.6	105,200.0	263.1	0.00	0.0	0.0
01/02/2023 13:00	4,244.7	324.1	4,397.0	105,200.0	462.6	0.61	0.3	1.0
01/02/2023 14:00	4,576.7	1,317.2	5,893.9	105,200.0	620.0	0.74	0.4	1.2
01/02/2023 15:00	4,561.2	1,270.7	5,831.9	105,200.0	613.5	0.74	0.4	1.2
01/02/2023 16:00	4,544.5	1,266.6	5,811.1	105,200.0	611.3	0.73	0.4	1.2
01/02/2023 17:00	4,546.7	1,258.2	5,804.9	105,200.0	610.7	0.73	0.4	1.2
01/02/2023 18:00	4,560.5	1,241.8	5,802.3	105,200.0	610.4	0.73	0.4	1.2
01/02/2023 19:00	4,579.0	1,195.8	5,774.8	105,200.0	607.5	0.73	0.4	1.2
01/02/2023 20:00	4,597.7	1,157.4	5,755.1	105,200.0	605.4	0.73	0.4	1.2
01/02/2023 21:00	4,612.2	1,078.7	5,690.9	105,200.0	598.7	0.72	0.4	1.2
01/02/2023 22:00	4,614.0	932.9	5,546.9	105,200.0	583.5	0.70	0.4	1.2
01/02/2023 23:00	4,608.5	853.6	5,462.1	105,200.0	574.6	0.69	0.3	1.1
Average/Sum#:	4,378.9	991.4	5,356.0	105,200.0	563.4	0.71	0.4	1.2
Minimum:	2,500.6	0.0	2,500.6	105,200.0	263.1	0.61	0.3	1.0
Maximum:	4,614.0	1,317.2	5,893.9	105,200.0	620.0	0.74	0.4	1.2
%SI	50.00	50.00	50.00	0.00	50.00	54.17	54.17	54.17

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2023 00:00	4,606.4	981.1	5,587.5	105,200.0	587.8	0.71	0.4	1.2
01/03/2023 01:00	4,603.2	941.1	5,544.3	105,200.0	583.3	0.70	0.3	1.2
01/03/2023 02:00	4,605.5	941.1	5,546.6	105,200.0	583.5	0.70	0.4	1.2
01/03/2023 03:00	4,603.3	976.3	5,579.6	105,200.0	587.0	0.70	0.4	1.2
01/03/2023 04:00	4,602.4	1,060.4	5,662.8	105,200.0	595.7	0.71	0.4	1.2
01/03/2023 05:00	4,602.7	1,109.3	5,712.0	105,200.0	600.9	0.72	0.4	1.2
01/03/2023 06:00	4,612.8	1,380.4	5,993.2	105,200.0	630.5	0.76	0.4	1.3
01/03/2023 07:00	4,611.0	1,130.2	5,741.2	105,200.0	604.0	0.72	0.4	1.2
01/03/2023 08:00	4,620.6	504.5	5,125.1	105,200.0	539.2	0.65	0.3	1.1
01/03/2023 09:00	4,615.6	565.5	5,181.1	105,200.0	545.1	0.65	0.3	1.1
01/03/2023 10:00	4,605.7	308.1	4,913.8	105,200.0	516.9	0.62	0.3	1.0
01/03/2023 11:00	4,579.9	278.8	4,858.7	105,200.0	511.1	0.61	0.3	1.0
01/03/2023 12:00	4,585.1	411.3	4,996.4	105,200.0	525.6	0.63	0.3	1.1
01/03/2023 13:00	4,586.0	375.7	4,961.7	105,200.0	522.0	0.63	0.3	1.0
01/03/2023 14:00	4,584.8	529.0	5,113.8	105,200.0	538.0	0.65	0.3	1.1
01/03/2023 15:00	4,594.5	1,264.6	5,859.1	105,200.0	616.4	0.74	0.4	1.2
01/03/2023 16:00	4,584.3	1,114.9	5,699.2	105,200.0	599.6	0.72	0.4	1.2
01/03/2023 17:00	4,568.2	1,113.2	5,681.4	105,200.0	597.7	0.72	0.4	1.2
01/03/2023 18:00	4,577.1	1,113.7	5,690.8	105,200.0	598.7	0.72	0.4	1.2
01/03/2023 19:00	4,578.6	1,049.5	5,628.1	105,200.0	592.1	0.71	0.4	1.2
01/03/2023 20:00	4,578.9	1,209.9	5,788.8	105,200.0	609.0	0.73	0.4	1.2
01/03/2023 21:00	4,571.6	1,194.2	5,765.8	105,200.0	606.6	0.73	0.4	1.2
01/03/2023 22:00	4,586.0	1,102.2	5,688.2	105,200.0	598.4	0.72	0.4	1.2
01/03/2023 23:00	4,588.0	714.5	5,302.5	105,200.0	557.8	0.67	0.3	1.1
Average/Sum#:	4,593.8	890.4	5,484.2	105,200.0	577.0	0.69	0.4	1.2
Minimum:	4,568.2	278.8	4,858.7	105,200.0	511.1	0.61	0.3	1.0
Maximum:	4,620.6	1,380.4	5,993.2	105,200.0	630.5	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2023 00:00	4,558.1	14.0	4,559.8	105,200.0	479.7	0.58	0.3	1.0
01/04/2023 01:00	4,570.8	0.0	4,570.8	105,200.0	480.8	0.58	0.3	1.0
01/04/2023 02:00	4,568.2	0.0	4,568.2	105,200.0	480.6	0.58	0.3	1.0
01/04/2023 03:00	4,573.1	0.0	4,573.1	105,200.0	481.1	0.58	0.3	1.0
01/04/2023 04:00	4,565.6	0.0	4,565.6	105,200.0	480.3	0.58	0.3	1.0
01/04/2023 05:00	4,560.2	0.0	4,560.2	105,200.0	479.7	0.58	0.3	1.0
01/04/2023 06:00	4,571.9	0.0	4,571.9	105,200.0	481.0	0.58	0.3	1.0
01/04/2023 07:00	4,574.1	265.0	4,839.1	105,200.0	509.1	0.61	0.3	1.0
01/04/2023 08:00	3,662.3	67.2	3,680.4	105,200.0	387.2	0.50	0.2	0.8
01/04/2023 09:00	213.3	0.0	213.3	105,200.0	22.4	0.00	0.0	0.0
01/04/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/04/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	4,041.8	34.6	4,070.2	105,200.0	428.2	0.57	0.3	1.0
Minimum:	213.3	0.0	213.3	105,200.0	22.4	0.50	0.2	0.8
Maximum:	4,574.1	265.0	4,839.1	105,200.0	509.1	0.61	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 15:00	2,196.9	0.0	2,196.9	105,200.0	231.1	0.00	0.0	0.0
01/05/2023 16:00	3,497.6	45.9	3,505.9	105,200.0	368.8	0.55	0.3	0.9
01/05/2023 17:00	4,524.0	459.3	4,983.3	105,200.0	524.2	0.63	0.3	1.0
01/05/2023 18:00	4,212.6	197.0	4,326.9	105,200.0	455.2	0.56	0.3	0.9
01/05/2023 19:00	2,269.8	0.0	2,269.8	105,200.0	238.8	0.34	0.2	0.6
01/05/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/05/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,340.2	140.4	3,456.6	105,200.0	363.6	0.52	0.3	0.9
Minimum:	2,196.9	0.0	2,196.9	105,200.0	231.1	0.34	0.2	0.6
Maximum:	4,524.0	459.3	4,983.3	105,200.0	524.2	0.63	0.3	1.0
%SI	79.17	79.17	79.17	0.00	79.17	83.33	83.33	83.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 16:00	2,697.9	0.0	2,697.9	105,200.0	283.8	0.53	0.3	0.9
01/06/2023 17:00	4,413.5	146.1	4,493.9	105,200.0	472.8	0.58	0.3	1.0
01/06/2023 18:00	4,533.0	369.0	4,902.0	105,200.0	515.7	0.62	0.3	1.0
01/06/2023 19:00	4,531.8	360.4	4,892.2	105,200.0	514.7	0.62	0.3	1.0
01/06/2023 20:00	3,685.4	80.1	3,703.8	105,200.0	389.6	0.48	0.2	0.8
01/06/2023 21:00	2,562.7	0.0	2,562.7	105,200.0	269.6	0.35	0.2	0.6
01/06/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/06/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,737.4	159.3	3,875.4	105,200.0	407.7	0.53	0.3	0.9
Minimum:	2,562.7	0.0	2,562.7	105,200.0	269.6	0.35	0.2	0.6
Maximum:	4,533.0	369.0	4,902.0	105,200.0	515.7	0.62	0.3	1.0
%SI	75.00	75.00	75.00	0.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/07/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/08/2023 16:00	2,602.5	0.0	2,602.5	105,200.0	273.8	0.45	0.2	0.8
01/08/2023 17:00	4,181.0	243.1	4,302.6	105,200.0	452.6	0.56	0.3	0.9
01/08/2023 18:00	4,457.1	501.1	4,958.2	105,200.0	521.6	0.63	0.3	1.0
01/08/2023 19:00	4,465.8	443.6	4,909.4	105,200.0	516.5	0.62	0.3	1.0
01/08/2023 20:00	4,463.7	483.9	4,947.6	105,200.0	520.5	0.62	0.3	1.0
01/08/2023 21:00	4,163.5	214.3	4,274.9	105,200.0	449.7	0.55	0.3	0.9
01/08/2023 22:00	2,218.6	0.0	2,218.6	105,200.0	233.4	0.34	0.2	0.6
01/08/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,793.2	269.4	4,030.5	105,200.0	424.0	0.54	0.3	0.9
Minimum:	2,218.6	0.0	2,218.6	105,200.0	233.4	0.34	0.2	0.6
Maximum:	4,465.8	501.1	4,958.2	105,200.0	521.6	0.63	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 13:00	541.4	0.0	541.4	105,200.0	57.0	0.00	0.0	0.0
01/09/2023 14:00	2,786.1	0.0	2,786.1	105,200.0	293.1	0.37	0.2	0.6
01/09/2023 15:00	4,341.7	193.5	4,432.6	105,200.0	466.3	0.57	0.3	1.0
01/09/2023 16:00	4,430.0	717.4	5,147.4	105,200.0	541.5	0.65	0.3	1.1
01/09/2023 17:00	4,447.0	731.3	5,178.3	105,200.0	544.8	0.65	0.3	1.1
01/09/2023 18:00	4,463.9	654.0	5,117.9	105,200.0	538.4	0.65	0.3	1.1
01/09/2023 19:00	4,475.9	628.8	5,104.7	105,200.0	537.0	0.64	0.3	1.1
01/09/2023 20:00	4,481.8	618.2	5,100.0	105,200.0	536.5	0.64	0.3	1.1
01/09/2023 21:00	3,826.7	138.4	3,878.8	105,200.0	408.0	0.56	0.3	0.9
01/09/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/09/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,754.9	409.1	4,143.0	105,200.0	435.8	0.59	0.3	1.0
Minimum:	541.4	0.0	541.4	105,200.0	57.0	0.37	0.2	0.6
Maximum:	4,481.8	731.3	5,178.3	105,200.0	544.8	0.65	0.3	1.1
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/10/2023 15:00	439.8	0.0	439.8	105,200.0	46.3	0.00	0.0	0.0
01/10/2023 16:00	2,843.0	0.0	2,843.0	105,200.0	299.1	0.41	0.2	0.7
01/10/2023 17:00	4,391.1	341.1	4,646.9	105,200.0	488.9	0.60	0.3	1.0
01/10/2023 18:00	4,516.6	536.2	5,052.8	105,200.0	531.6	0.64	0.3	1.1
01/10/2023 19:00	4,520.7	541.8	5,062.5	105,200.0	532.6	0.64	0.3	1.1
01/10/2023 20:00	4,520.9	464.3	4,985.2	105,200.0	524.4	0.63	0.3	1.0
01/10/2023 21:00	4,528.0	340.2	4,868.2	105,200.0	512.1	0.61	0.3	1.0
01/10/2023 22:00	4,197.8	166.5	4,286.0	105,200.0	450.9	0.55	0.3	0.9
01/10/2023 23:00	2,297.5	0.0	2,297.5	105,200.0	241.7	0.34	0.2	0.6
Average/Sum#:	3,583.9	265.6	3,831.3	105,200.0	403.1	0.55	0.3	0.9
Minimum:	439.8	0.0	439.8	105,200.0	46.3	0.34	0.2	0.6
Maximum:	4,528.0	541.8	5,062.5	105,200.0	532.6	0.64	0.3	1.1
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 15:00	2,611.7	0.0	2,611.7	105,200.0	274.8	0.38	0.2	0.6
01/11/2023 16:00	4,222.5	323.2	4,426.1	105,200.0	465.6	0.57	0.3	1.0
01/11/2023 17:00	4,535.0	498.1	5,033.1	105,200.0	529.5	0.64	0.3	1.1
01/11/2023 18:00	4,537.3	366.7	4,904.0	105,200.0	515.9	0.62	0.3	1.0
01/11/2023 19:00	4,534.5	339.5	4,874.0	105,200.0	512.7	0.62	0.3	1.0
01/11/2023 20:00	4,198.4	163.0	4,283.2	105,200.0	450.6	0.55	0.3	0.9
01/11/2023 21:00	1,869.9	0.0	1,869.9	105,200.0	196.7	0.00	0.0	0.0
01/11/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/11/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,787.0	241.5	4,000.3	105,200.0	420.8	0.56	0.3	0.9
Minimum:	1,869.9	0.0	1,869.9	105,200.0	196.7	0.38	0.2	0.6
Maximum:	4,537.3	498.1	5,033.1	105,200.0	529.5	0.64	0.3	1.1
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/12/2023 15:00	1,020.9	0.0	1,020.9	105,200.0	107.4	0.00	0.0	0.0
01/12/2023 16:00	2,861.5	0.0	2,861.5	105,200.0	301.0	0.36	0.2	0.6
01/12/2023 17:00	3,980.8	267.2	4,135.8	105,200.0	435.1	0.54	0.3	0.9
01/12/2023 18:00	4,488.7	423.9	4,912.6	105,200.0	516.8	0.62	0.3	1.0
01/12/2023 19:00	4,486.5	412.3	4,898.8	105,200.0	515.4	0.62	0.3	1.0
01/12/2023 20:00	4,472.9	437.1	4,910.0	105,200.0	516.5	0.62	0.3	1.0
01/12/2023 21:00	4,086.4	212.0	4,196.6	105,200.0	441.5	0.54	0.3	0.9
01/12/2023 22:00	2,250.2	0.0	2,250.2	105,200.0	236.7	0.34	0.2	0.6
01/12/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,456.0	219.1	3,648.3	105,200.0	383.8	0.52	0.3	0.9
Minimum:	1,020.9	0.0	1,020.9	105,200.0	107.4	0.34	0.2	0.6
Maximum:	4,488.7	437.1	4,912.6	105,200.0	516.8	0.62	0.3	1.0
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/13/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 14:00	555.4	0.0	555.4	105,200.0	58.4	0.00	0.0	0.0
01/14/2023 15:00	2,740.9	0.0	2,740.9	105,200.0	288.3	0.00	0.0	0.0
01/14/2023 16:00	4,116.8	329.4	4,324.3	105,200.0	454.9	0.57	0.3	0.9
01/14/2023 17:00	4,464.1	453.5	4,917.6	105,200.0	517.3	0.62	0.3	1.0
01/14/2023 18:00	4,465.3	480.5	4,945.8	105,200.0	520.3	0.62	0.3	1.0
01/14/2023 19:00	4,250.0	209.9	4,361.2	105,200.0	458.8	0.56	0.3	0.9
01/14/2023 20:00	2,379.1	0.0	2,379.1	105,200.0	250.3	0.35	0.2	0.6
01/14/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/14/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,281.7	210.5	3,460.6	105,200.0	364.0	0.54	0.3	0.9
Minimum:	555.4	0.0	555.4	105,200.0	58.4	0.35	0.2	0.6
Maximum:	4,465.3	480.5	4,945.8	105,200.0	520.3	0.62	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/15/2023 14:00	134.0	0.0	134.0	105,200.0	14.1	0.00	0.0	0.0
01/15/2023 15:00	2,665.5	0.0	2,665.5	105,200.0	280.4	0.41	0.2	0.7
01/15/2023 16:00	4,399.8	99.9	4,424.8	105,200.0	465.5	0.57	0.3	0.9
01/15/2023 17:00	4,473.6	590.3	5,063.9	105,200.0	532.7	0.64	0.3	1.1
01/15/2023 18:00	4,476.7	590.8	5,067.5	105,200.0	533.1	0.64	0.3	1.1
01/15/2023 19:00	4,469.9	466.0	4,935.9	105,200.0	519.3	0.62	0.3	1.0
01/15/2023 20:00	4,487.0	455.8	4,942.8	105,200.0	520.0	0.62	0.3	1.0
01/15/2023 21:00	3,770.7	101.6	3,798.1	105,200.0	399.6	0.49	0.2	0.8
01/15/2023 22:00	2,111.2	0.0	2,111.2	105,200.0	222.1	0.34	0.2	0.6
01/15/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,443.2	256.0	3,682.6	105,200.0	387.4	0.54	0.3	0.9
Minimum:	134.0	0.0	134.0	105,200.0	14.1	0.34	0.2	0.6
Maximum:	4,487.0	590.8	5,067.5	105,200.0	533.1	0.64	0.3	1.1
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/16/2023 15:00	2,503.1	0.0	2,503.1	105,200.0	263.3	0.34	0.2	0.6
01/16/2023 16:00	3,558.1	139.7	3,604.2	105,200.0	379.2	0.47	0.2	0.8
01/16/2023 17:00	4,493.3	431.9	4,925.2	105,200.0	518.1	0.62	0.3	1.0
01/16/2023 18:00	4,515.5	404.7	4,920.2	105,200.0	517.6	0.62	0.3	1.0
01/16/2023 19:00	4,516.4	399.2	4,915.6	105,200.0	517.1	0.62	0.3	1.0
01/16/2023 20:00	4,524.5	373.7	4,898.2	105,200.0	515.3	0.62	0.3	1.0
01/16/2023 21:00	4,536.3	349.1	4,885.4	105,200.0	513.9	0.62	0.3	1.0
01/16/2023 22:00	3,728.7	80.4	3,750.4	105,200.0	394.5	0.51	0.3	0.9
01/16/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	4,047.0	272.3	4,300.3	105,200.0	452.4	0.55	0.3	0.9
Minimum:	2,503.1	0.0	2,503.1	105,200.0	263.3	0.34	0.2	0.6
Maximum:	4,536.3	431.9	4,925.2	105,200.0	518.1	0.62	0.3	1.0
%SI	66.67	66.67	66.67	0.00	66.67	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/17/2023 17:00	2,600.4	0.0	2,600.4	105,200.0	273.6	0.00	0.0	0.0
01/17/2023 18:00	4,063.0	240.6	4,202.5	105,200.0	442.1	0.57	0.3	0.9
01/17/2023 19:00	4,583.0	281.1	4,864.1	105,200.0	511.7	0.61	0.3	1.0
01/17/2023 20:00	4,603.3	265.0	4,868.3	105,200.0	512.1	0.61	0.3	1.0
01/17/2023 21:00	4,607.4	245.9	4,853.3	105,200.0	510.6	0.61	0.3	1.0
01/17/2023 22:00	4,611.0	229.4	4,840.4	105,200.0	509.2	0.61	0.3	1.0
01/17/2023 23:00	4,630.8	205.2	4,836.0	105,200.0	508.7	0.61	0.3	1.0
Average/Sum#:	4,242.7	209.6	4,437.9	105,200.0	466.9	0.60	0.3	1.0
Minimum:	2,600.4	0.0	2,600.4	105,200.0	273.6	0.57	0.3	0.9
Maximum:	4,630.8	281.1	4,868.3	105,200.0	512.1	0.61	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2023 00:00	4,628.2	244.8	4,873.0	105,200.0	512.6	0.62	0.3	1.0
01/18/2023 01:00	4,623.2	258.3	4,881.5	105,200.0	513.5	0.62	0.3	1.0
01/18/2023 02:00	4,630.0	248.9	4,878.9	105,200.0	513.3	0.62	0.3	1.0
01/18/2023 03:00	4,627.3	246.1	4,873.4	105,200.0	512.7	0.62	0.3	1.0
01/18/2023 04:00	4,637.4	223.5	4,860.9	105,200.0	511.4	0.61	0.3	1.0
01/18/2023 05:00	4,648.4	194.6	4,843.0	105,200.0	509.5	0.61	0.3	1.0
01/18/2023 06:00	4,649.8	241.2	4,891.0	105,200.0	514.5	0.62	0.3	1.0
01/18/2023 07:00	4,645.0	149.9	4,794.9	105,200.0	504.4	0.60	0.3	1.0
01/18/2023 08:00	4,272.7	69.0	4,308.6	105,200.0	453.3	0.55	0.3	0.9
01/18/2023 09:00	2,289.0	0.0	2,289.0	105,200.0	240.8	0.34	0.2	0.6
01/18/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/18/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	4,365.1	187.6	4,549.4	105,200.0	478.6	0.58	0.3	1.0
Minimum:	2,289.0	0.0	2,289.0	105,200.0	240.8	0.34	0.2	0.6
Maximum:	4,649.8	258.3	4,891.0	105,200.0	514.5	0.62	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/19/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/20/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/21/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/22/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/23/2023 16:00	2,614.9	0.0	2,614.9	105,200.0	275.1	0.00	0.0	0.0
01/23/2023 17:00	4,077.5	66.6	4,112.8	105,200.0	432.7	0.57	0.3	1.0
01/23/2023 18:00	4,532.6	603.4	5,136.0	105,200.0	540.3	0.65	0.3	1.1
01/23/2023 19:00	4,544.1	997.7	5,541.8	105,200.0	583.0	0.70	0.3	1.2
01/23/2023 20:00	4,568.8	850.1	5,418.9	105,200.0	570.1	0.69	0.3	1.1
01/23/2023 21:00	4,592.9	639.4	5,168.4	105,200.0	543.7	0.66	0.3	1.1
01/23/2023 22:00	4,626.4	593.3	5,201.9	105,200.0	547.2	0.66	0.3	1.1
01/23/2023 23:00	4,633.5	371.2	5,004.7	105,200.0	526.5	0.63	0.3	1.1
Average/Sum#:	4,273.8	515.2	4,774.9	105,200.0	502.3	0.65	0.3	1.1
Minimum:	2,614.9	0.0	2,614.9	105,200.0	275.1	0.57	0.3	1.0
Maximum:	4,633.5	997.7	5,541.8	105,200.0	583.0	0.70	0.3	1.2
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2023 00:00	4,574.4	0.9	4,574.4	105,200.0	481.2	0.58	0.3	1.0
01/24/2023 01:00	4,587.6	0.0	4,587.6	105,200.0	482.6	0.58	0.3	1.0
01/24/2023 02:00	4,565.8	0.0	4,565.8	105,200.0	480.3	0.58	0.3	1.0
01/24/2023 03:00	4,564.9	0.0	4,564.9	105,200.0	480.2	0.58	0.3	1.0
01/24/2023 04:00	4,564.0	0.0	4,564.0	105,200.0	480.1	0.58	0.3	1.0
01/24/2023 05:00	4,646.0	517.9	5,018.9	105,200.0	528.0	0.65	0.3	1.1
01/24/2023 06:00	4,669.5	982.7	5,652.2	105,200.0	594.6	0.71	0.4	1.2
01/24/2023 07:00	4,701.4	212.5	4,892.7	105,200.0	514.7	0.62	0.3	1.0
01/24/2023 08:00	4,692.6	128.6	4,821.2	105,200.0	507.2	0.61	0.3	1.0
01/24/2023 09:00	3,718.7	33.8	3,727.8	105,200.0	392.2	0.47	0.2	0.8
01/24/2023 10:00	2,309.8	0.0	2,309.8	105,200.0	243.0	0.34	0.2	0.6
01/24/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/24/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	4,326.8	170.6	4,479.9	105,200.0	471.3	0.57	0.3	1.0
Minimum:	2,309.8	0.0	2,309.8	105,200.0	243.0	0.34	0.2	0.6
Maximum:	4,701.4	982.7	5,652.2	105,200.0	594.6	0.71	0.4	1.2
%SI	54.17	54.17	54.17	0.00	54.17	54.17	54.17	54.17

From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/25/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/26/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
01/27/2023 16:00	2,798.8	0.0	2,798.8	105,200.0	294.4	0.00	0.0	0.0
01/27/2023 17:00	4,389.5	197.2	4,523.6	105,200.0	475.9	0.61	0.3	1.0
01/27/2023 18:00	4,533.9	381.4	4,915.3	105,200.0	517.1	0.62	0.3	1.0
01/27/2023 19:00	4,400.8	172.8	4,490.7	105,200.0	472.4	0.58	0.3	1.0
01/27/2023 20:00	3,099.8	0.0	3,099.8	105,200.0	326.1	0.39	0.2	0.7
01/27/2023 21:00	2,750.2	0.0	2,750.2	105,200.0	289.3	0.35	0.2	0.6
01/27/2023 22:00	2,759.4	0.0	2,759.4	105,200.0	290.3	0.35	0.2	0.6
01/27/2023 23:00	2,773.8	0.0	2,773.8	105,200.0	291.8	0.35	0.2	0.6
Average/Sum#:	3,438.3	93.9	3,514.0	105,200.0	369.7	0.46	0.2	0.8
Minimum:	2,750.2	0.0	2,750.2	105,200.0	289.3	0.35	0.2	0.6
Maximum:	4,533.9	381.4	4,915.3	105,200.0	517.1	0.62	0.3	1.0
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2023 00:00	2,768.3	0.0	2,768.3	105,200.0	291.2	0.35	0.2	0.6
01/28/2023 01:00	2,762.2	0.0	2,762.2	105,200.0	290.6	0.35	0.2	0.6
01/28/2023 02:00	2,765.7	0.0	2,765.7	105,200.0	291.0	0.35	0.2	0.6
01/28/2023 03:00	2,766.5	0.0	2,766.5	105,200.0	291.0	0.35	0.2	0.6
01/28/2023 04:00	2,764.2	0.0	2,764.2	105,200.0	290.8	0.35	0.2	0.6
01/28/2023 05:00	2,766.4	0.0	2,766.4	105,200.0	291.0	0.35	0.2	0.6
01/28/2023 06:00	2,843.6	0.0	2,843.6	105,200.0	299.1	0.36	0.2	0.6
01/28/2023 07:00	2,759.8	0.0	2,759.8	105,200.0	290.3	0.35	0.2	0.6
01/28/2023 08:00	2,765.4	0.0	2,765.4	105,200.0	290.9	0.35	0.2	0.6
01/28/2023 09:00	2,770.0	0.0	2,770.0	105,200.0	291.4	0.35	0.2	0.6
01/28/2023 10:00	2,768.1	0.0	2,768.1	105,200.0	291.2	0.35	0.2	0.6
01/28/2023 11:00	2,770.9	0.0	2,770.9	105,200.0	291.5	0.35	0.2	0.6
01/28/2023 12:00	2,773.5	0.0	2,773.5	105,200.0	291.8	0.35	0.2	0.6
01/28/2023 13:00	2,750.2	0.0	2,750.2	105,200.0	289.3	0.35	0.2	0.6
01/28/2023 14:00	2,775.4	0.0	2,775.4	105,200.0	292.0	0.35	0.2	0.6
01/28/2023 15:00	2,780.1	0.0	2,780.1	105,200.0	292.5	0.35	0.2	0.6
01/28/2023 16:00	2,780.0	0.0	2,780.0	105,200.0	292.5	0.35	0.2	0.6
01/28/2023 17:00	2,772.5	0.0	2,772.5	105,200.0	291.7	0.35	0.2	0.6
01/28/2023 18:00	2,763.0	0.0	2,763.0	105,200.0	290.7	0.35	0.2	0.6
01/28/2023 19:00	2,736.6	0.0	2,736.6	105,200.0	287.9	0.35	0.2	0.6
01/28/2023 20:00	2,739.8	0.0	2,739.8	105,200.0	288.2	0.35	0.2	0.6
01/28/2023 21:00	2,760.7	0.0	2,760.7	105,200.0	290.4	0.35	0.2	0.6
01/28/2023 22:00	2,765.9	0.0	2,765.9	105,200.0	291.0	0.35	0.2	0.6
01/28/2023 23:00	2,763.5	0.0	2,763.5	105,200.0	290.7	0.35	0.2	0.6
Average/Sum#:	2,768.0	0.0	2,768.0	105,200.0	291.2	0.35	0.2	0.6
Minimum:	2,736.6	0.0	2,736.6	105,200.0	287.9	0.35	0.2	0.6
Maximum:	2,843.6	0.0	2,843.6	105,200.0	299.1	0.36	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2023 00:00	2,755.5	0.0	2,755.5	105,200.0	289.9	0.35	0.2	0.6
01/29/2023 01:00	2,761.4	0.0	2,761.4	105,200.0	290.5	0.35	0.2	0.6
01/29/2023 02:00	2,766.4	0.0	2,766.4	105,200.0	291.0	0.35	0.2	0.6
01/29/2023 03:00	2,763.0	0.0	2,763.0	105,200.0	290.7	0.35	0.2	0.6
01/29/2023 04:00	2,765.3	0.0	2,765.3	105,200.0	290.9	0.35	0.2	0.6
01/29/2023 05:00	2,771.5	0.0	2,771.5	105,200.0	291.6	0.35	0.2	0.6
01/29/2023 06:00	2,767.4	0.0	2,767.4	105,200.0	291.1	0.35	0.2	0.6
01/29/2023 07:00	2,769.9	0.0	2,769.9	105,200.0	291.4	0.35	0.2	0.6
01/29/2023 08:00	3,235.8	0.0	3,235.8	105,200.0	340.4	0.41	0.2	0.7
01/29/2023 09:00	4,007.9	0.0	4,007.9	105,200.0	421.6	0.51	0.3	0.8
01/29/2023 10:00	4,539.4	111.2	4,575.0	105,200.0	481.3	0.59	0.3	1.0
01/29/2023 11:00	4,548.5	343.6	4,813.1	105,200.0	506.3	0.62	0.3	1.0
01/29/2023 12:00	3,625.8	0.0	3,625.8	105,200.0	381.4	0.46	0.2	0.8
01/29/2023 13:00	2,774.6	0.0	2,774.6	105,200.0	291.9	0.35	0.2	0.6
01/29/2023 14:00	2,772.2	0.0	2,772.2	105,200.0	291.6	0.35	0.2	0.6
01/29/2023 15:00	2,775.0	0.0	2,775.0	105,200.0	291.9	0.35	0.2	0.6
01/29/2023 16:00	2,818.7	0.0	2,818.7	105,200.0	296.5	0.36	0.2	0.6
01/29/2023 17:00	2,769.4	0.0	2,769.4	105,200.0	291.3	0.35	0.2	0.6
01/29/2023 18:00	2,768.8	0.0	2,768.8	105,200.0	291.3	0.35	0.2	0.6
01/29/2023 19:00	2,763.0	0.0	2,763.0	105,200.0	290.7	0.35	0.2	0.6
01/29/2023 20:00	2,772.0	0.0	2,772.0	105,200.0	291.6	0.35	0.2	0.6
01/29/2023 21:00	2,768.3	0.0	2,768.3	105,200.0	291.2	0.35	0.2	0.6
01/29/2023 22:00	2,767.2	0.0	2,767.2	105,200.0	291.1	0.35	0.2	0.6
01/29/2023 23:00	2,751.9	0.0	2,751.9	105,200.0	289.5	0.35	0.2	0.6
Average/Sum#:	3,024.1	19.0	3,036.6	105,200.0	319.4	0.39	0.2	0.7
Minimum:	2,751.9	0.0	2,751.9	105,200.0	289.5	0.35	0.2	0.6
Maximum:	4,548.5	343.6	4,813.1	105,200.0	506.3	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2023 00:00	2,769.4	0.0	2,769.4	105,200.0	291.3	0.35	0.2	0.6
01/30/2023 01:00	2,785.9	0.0	2,785.9	105,200.0	293.1	0.35	0.2	0.6
01/30/2023 02:00	3,870.3	67.7	3,897.4	105,200.0	410.0	0.50	0.2	0.8
01/30/2023 03:00	4,680.4	157.5	4,837.9	105,200.0	508.9	0.61	0.3	1.0
01/30/2023 04:00	4,694.0	131.3	4,825.3	105,200.0	507.6	0.61	0.3	1.0
01/30/2023 05:00	4,705.9	373.0	5,078.9	105,200.0	534.3	0.64	0.3	1.1
01/30/2023 06:00	4,717.1	649.4	5,366.5	105,200.0	564.6	0.68	0.3	1.1
01/30/2023 07:00	4,718.8	1,836.7	6,555.5	105,200.0	689.6	0.83	0.4	1.4
01/30/2023 08:00	4,699.6	1,528.5	6,228.1	105,200.0	655.2	0.79	0.4	1.3
01/30/2023 09:00	4,661.0	301.9	4,962.9	105,200.0	522.1	0.63	0.3	1.0
01/30/2023 10:00	4,634.4	134.5	4,768.9	105,200.0	501.7	0.60	0.3	1.0
01/30/2023 11:00	4,607.0	170.6	4,777.6	105,200.0	502.6	0.60	0.3	1.0
01/30/2023 12:00	4,581.2	223.7	4,804.9	105,200.0	505.5	0.61	0.3	1.0
01/30/2023 13:00	4,558.4	254.9	4,813.3	105,200.0	506.4	0.61	0.3	1.0
01/30/2023 14:00	4,541.3	302.7	4,844.0	105,200.0	509.6	0.61	0.3	1.0
01/30/2023 15:00	4,532.5	304.3	4,836.8	105,200.0	508.8	0.61	0.3	1.0
01/30/2023 16:00	4,531.2	296.0	4,827.2	105,200.0	507.8	0.61	0.3	1.0
01/30/2023 17:00	4,559.1	229.6	4,788.7	105,200.0	503.8	0.60	0.3	1.0
01/30/2023 18:00	4,570.1	154.0	4,724.1	105,200.0	497.0	0.60	0.3	1.0
01/30/2023 19:00	4,583.8	127.3	4,711.1	105,200.0	495.6	0.59	0.3	1.0
01/30/2023 20:00	4,615.1	125.9	4,741.0	105,200.0	498.8	0.60	0.3	1.0
01/30/2023 21:00	4,639.8	123.8	4,763.6	105,200.0	501.1	0.60	0.3	1.0
01/30/2023 22:00	4,646.1	124.1	4,770.2	105,200.0	501.8	0.60	0.3	1.0
01/30/2023 23:00	4,657.6	129.8	4,787.4	105,200.0	503.6	0.60	0.3	1.0
Average/Sum#:	4,440.0	322.8	4,761.1	105,200.0	500.9	0.60	0.3	1.0
Minimum:	2,769.4	0.0	2,769.4	105,200.0	291.3	0.35	0.2	0.6
Maximum:	4,718.8	1,836.7	6,555.5	105,200.0	689.6	0.83	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2023 00:00	4,662.8	128.5	4,791.3	105,200.0	504.0	0.60	0.3	1.0
01/31/2023 01:00	4,681.3	129.5	4,810.8	105,200.0	506.1	0.61	0.3	1.0
01/31/2023 02:00	4,692.1	129.2	4,821.3	105,200.0	507.2	0.61	0.3	1.0
01/31/2023 03:00	4,692.3	128.1	4,820.4	105,200.0	507.1	0.61	0.3	1.0
01/31/2023 04:00	4,718.3	129.5	4,847.8	105,200.0	510.0	0.61	0.3	1.0
01/31/2023 05:00	4,730.5	133.7	4,864.2	105,200.0	511.7	0.61	0.3	1.0
01/31/2023 06:00	4,743.8	176.0	4,919.8	105,200.0	517.6	0.62	0.3	1.0
01/31/2023 07:00	4,749.4	248.3	4,997.7	105,200.0	525.8	0.63	0.3	1.1
01/31/2023 08:00	4,734.4	124.7	4,859.1	105,200.0	511.2	0.61	0.3	1.0
01/31/2023 09:00	4,690.6	122.3	4,812.9	105,200.0	506.3	0.61	0.3	1.0
01/31/2023 10:00	4,656.5	136.1	4,792.6	105,200.0	504.2	0.60	0.3	1.0
01/31/2023 11:00	4,617.4	173.1	4,790.5	105,200.0	504.0	0.60	0.3	1.0
01/31/2023 12:00	4,597.3	156.2	4,753.5	105,200.0	500.1	0.60	0.3	1.0
01/31/2023 13:00	4,178.3	125.5	4,243.6	105,200.0	446.4	0.54	0.3	0.9
01/31/2023 14:00	2,740.2	0.0	2,740.2	105,200.0	288.3	0.35	0.2	0.6
01/31/2023 15:00	3,790.5	67.8	3,812.2	105,200.0	401.0	0.49	0.2	0.8
01/31/2023 16:00	4,550.9	225.4	4,776.3	105,200.0	502.5	0.60	0.3	1.0
01/31/2023 17:00	4,557.6	184.2	4,741.8	105,200.0	498.8	0.60	0.3	1.0
01/31/2023 18:00	4,576.0	144.2	4,720.2	105,200.0	496.6	0.60	0.3	1.0
01/31/2023 19:00	4,599.0	125.6	4,724.6	105,200.0	497.0	0.60	0.3	1.0
01/31/2023 20:00	4,611.4	123.3	4,734.7	105,200.0	498.1	0.60	0.3	1.0
01/31/2023 21:00	4,628.2	126.5	4,754.7	105,200.0	500.2	0.60	0.3	1.0
01/31/2023 22:00	4,652.6	129.6	4,782.2	105,200.0	503.1	0.60	0.3	1.0
01/31/2023 23:00	4,665.0	128.0	4,793.0	105,200.0	504.2	0.61	0.3	1.0
Average/Sum#:	4,521.5	137.3	4,654.4	105,200.0	489.6	0.59	0.3	1.0
Minimum:	2,740.2	0.0	2,740.2	105,200.0	288.3	0.35	0.2	0.6
Maximum:	4,749.4	248.3	4,997.7	105,200.0	525.8	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023 00:00	4,670.0	127.9	4,797.9	104,900.0	503.3	0.60	0.3	1.0
02/01/2023 01:00	4,683.5	129.9	4,813.4	104,900.0	504.9	0.61	0.3	1.0
02/01/2023 02:00	4,684.0	128.1	4,812.1	104,900.0	504.8	0.61	0.3	1.0
02/01/2023 03:00	4,689.4	130.2	4,819.6	104,900.0	505.6	0.61	0.3	1.0
02/01/2023 04:00	4,704.9	130.7	4,835.6	104,900.0	507.3	0.61	0.3	1.0
02/01/2023 05:00	4,711.6	130.1	4,841.7	104,900.0	507.9	0.61	0.3	1.0
02/01/2023 06:00	4,715.1	128.2	4,843.3	104,900.0	508.1	0.61	0.3	1.0
02/01/2023 07:00	4,701.0	130.4	4,831.4	104,900.0	506.8	0.61	0.3	1.0
02/01/2023 08:00	4,711.2	128.0	4,839.2	104,900.0	507.6	0.61	0.3	1.0
02/01/2023 09:00	4,687.1	123.5	4,810.6	104,900.0	504.6	0.61	0.3	1.0
02/01/2023 10:00	3,465.1	11.5	3,466.3	104,900.0	363.6	0.44	0.2	0.7
02/01/2023 11:00	2,818.9	0.0	2,818.9	104,900.0	295.7	0.35	0.2	0.6
02/01/2023 12:00	2,825.8	0.0	2,825.8	104,900.0	296.4	0.36	0.2	0.6
02/01/2023 13:00	2,824.5	0.0	2,824.5	104,900.0	296.3	0.36	0.2	0.6
02/01/2023 14:00	2,795.6	0.0	2,795.6	104,900.0	293.3	0.35	0.2	0.6
02/01/2023 15:00	2,768.9	0.0	2,768.9	104,900.0	290.5	0.35	0.2	0.6
02/01/2023 16:00	2,761.1	0.0	2,761.1	104,900.0	289.6	0.35	0.2	0.6
02/01/2023 17:00	2,763.7	0.0	2,763.7	104,900.0	289.9	0.35	0.2	0.6
02/01/2023 18:00	2,761.0	0.0	2,761.0	104,900.0	289.6	0.35	0.2	0.6
02/01/2023 19:00	2,748.7	0.0	2,748.7	104,900.0	288.3	0.35	0.2	0.6
02/01/2023 20:00	2,744.6	0.0	2,744.6	104,900.0	287.9	0.34	0.2	0.6
02/01/2023 21:00	2,740.0	0.0	2,740.0	104,900.0	287.4	0.34	0.2	0.6
02/01/2023 22:00	2,733.3	0.0	2,733.3	104,900.0	286.7	0.34	0.2	0.6
02/01/2023 23:00	2,732.6	0.0	2,732.6	104,900.0	286.6	0.34	0.2	0.6
Average/Sum#:	3,601.7	54.1	3,655.4	104,900.0	383.4	0.46	0.2	0.8
Minimum:	2,732.6	0.0	2,732.6	104,900.0	286.6	0.34	0.2	0.6
Maximum:	4,715.1	130.7	4,843.3	104,900.0	508.1	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2023 00:00	2,737.2	0.0	2,737.2	104,900.0	287.1	0.34	0.2	0.6
02/02/2023 01:00	2,804.3	0.0	2,804.3	104,900.0	294.2	0.35	0.2	0.6
02/02/2023 02:00	2,794.6	0.0	2,794.6	104,900.0	293.2	0.35	0.2	0.6
02/02/2023 03:00	2,794.2	0.0	2,794.2	104,900.0	293.1	0.35	0.2	0.6
02/02/2023 04:00	2,791.6	0.0	2,791.6	104,900.0	292.8	0.35	0.2	0.6
02/02/2023 05:00	2,795.7	0.0	2,795.7	104,900.0	293.3	0.35	0.2	0.6
02/02/2023 06:00	2,808.9	0.0	2,808.9	104,900.0	294.7	0.35	0.2	0.6
02/02/2023 07:00	2,801.6	0.0	2,801.6	104,900.0	293.9	0.35	0.2	0.6
02/02/2023 08:00	2,797.8	0.0	2,797.8	104,900.0	293.5	0.35	0.2	0.6
02/02/2023 09:00	2,799.1	0.0	2,799.1	104,900.0	293.6	0.35	0.2	0.6
02/02/2023 10:00	2,792.6	0.0	2,792.6	104,900.0	292.9	0.35	0.2	0.6
02/02/2023 11:00	2,762.0	0.0	2,762.0	104,900.0	289.7	0.35	0.2	0.6
02/02/2023 12:00	2,760.1	0.0	2,760.1	104,900.0	289.5	0.35	0.2	0.6
02/02/2023 13:00	2,757.0	0.0	2,757.0	104,900.0	289.2	0.35	0.2	0.6
02/02/2023 14:00	2,752.2	0.0	2,752.2	104,900.0	288.7	0.35	0.2	0.6
02/02/2023 15:00	2,746.0	0.0	2,746.0	104,900.0	288.1	0.35	0.2	0.6
02/02/2023 16:00	2,745.9	0.0	2,745.9	104,900.0	288.0	0.35	0.2	0.6
02/02/2023 17:00	2,751.2	0.0	2,751.2	104,900.0	288.6	0.35	0.2	0.6
02/02/2023 18:00	2,750.7	0.0	2,750.7	104,900.0	288.5	0.35	0.2	0.6
02/02/2023 19:00	2,733.3	0.0	2,733.3	104,900.0	286.7	0.34	0.2	0.6
02/02/2023 20:00	2,735.1	0.0	2,735.1	104,900.0	286.9	0.34	0.2	0.6
02/02/2023 21:00	2,771.1	0.0	2,771.1	104,900.0	290.7	0.35	0.2	0.6
02/02/2023 22:00	2,757.7	0.0	2,757.7	104,900.0	289.3	0.35	0.2	0.6
02/02/2023 23:00	2,750.1	0.0	2,750.1	104,900.0	288.5	0.35	0.2	0.6
Average/Sum#:	2,770.4	0.0	2,770.4	104,900.0	290.6	0.35	0.2	0.6
Minimum:	2,733.3	0.0	2,733.3	104,900.0	286.7	0.34	0.2	0.6
Maximum:	2,808.9	0.0	2,808.9	104,900.0	294.7	0.35	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2023 00:00	2,743.5	0.0	2,743.5	104,900.0	287.8	0.35	0.2	0.6
02/03/2023 01:00	2,775.4	0.0	2,775.4	104,900.0	291.1	0.35	0.2	0.6
02/03/2023 02:00	2,766.7	0.0	2,766.7	104,900.0	290.2	0.35	0.2	0.6
02/03/2023 03:00	2,740.4	0.0	2,740.4	104,900.0	287.5	0.35	0.2	0.6
02/03/2023 04:00	2,728.7	0.0	2,728.7	104,900.0	286.2	0.34	0.2	0.6
02/03/2023 05:00	2,734.5	0.0	2,734.5	104,900.0	286.8	0.34	0.2	0.6
02/03/2023 06:00	2,739.5	0.0	2,739.5	104,900.0	287.4	0.34	0.2	0.6
02/03/2023 07:00	3,194.0	0.0	3,194.0	104,900.0	335.1	0.40	0.2	0.7
02/03/2023 08:00	3,121.2	0.0	3,121.2	104,900.0	327.4	0.39	0.2	0.7
02/03/2023 09:00	2,736.6	0.0	2,736.6	104,900.0	287.1	0.34	0.2	0.6
02/03/2023 10:00	2,782.2	0.0	2,782.2	104,900.0	291.9	0.35	0.2	0.6
02/03/2023 11:00	3,792.9	65.3	3,815.8	104,900.0	400.3	0.49	0.2	0.8
02/03/2023 12:00	4,569.0	209.4	4,778.4	104,900.0	501.3	0.60	0.3	1.0
02/03/2023 13:00	4,560.8	216.2	4,777.0	104,900.0	501.1	0.60	0.3	1.0
02/03/2023 14:00	4,560.7	214.1	4,774.8	104,900.0	500.9	0.60	0.3	1.0
02/03/2023 15:00	4,536.1	186.5	4,679.7	104,900.0	490.9	0.59	0.3	1.0
02/03/2023 16:00	3,471.6	0.0	3,471.6	104,900.0	364.2	0.44	0.2	0.7
02/03/2023 17:00	4,052.1	158.3	4,126.5	104,900.0	432.9	0.53	0.3	0.9
02/03/2023 18:00	4,558.6	544.8	5,103.4	104,900.0	535.3	0.64	0.3	1.1
02/03/2023 19:00	4,585.1	670.2	5,255.3	104,900.0	551.3	0.66	0.3	1.1
02/03/2023 20:00	4,607.0	642.7	5,249.7	104,900.0	550.7	0.66	0.3	1.1
02/03/2023 21:00	4,615.8	378.7	4,994.5	104,900.0	523.9	0.63	0.3	1.0
02/03/2023 22:00	4,618.7	333.5	4,952.2	104,900.0	519.5	0.62	0.3	1.0
02/03/2023 23:00	4,347.3	140.2	4,420.2	104,900.0	463.7	0.57	0.3	0.9
Average/Sum#:	3,664.1	156.7	3,810.9	104,900.0	399.8	0.48	0.2	0.8
Minimum:	2,728.7	0.0	2,728.7	104,900.0	286.2	0.34	0.2	0.6
Maximum:	4,618.7	670.2	5,255.3	104,900.0	551.3	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2023 00:00	2,336.7	0.0	2,336.7	104,900.0	245.1	0.35	0.2	0.6
02/04/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/04/2023 16:00	2,513.4	0.0	2,513.4	104,900.0	263.7	0.00	0.0	0.0
02/04/2023 17:00	4,030.0	182.1	4,117.4	104,900.0	431.9	0.54	0.3	0.9
02/04/2023 18:00	4,513.8	585.0	5,098.8	104,900.0	534.9	0.64	0.3	1.1
02/04/2023 19:00	4,513.0	650.1	5,163.1	104,900.0	541.6	0.65	0.3	1.1
02/04/2023 20:00	4,507.5	737.8	5,245.3	104,900.0	550.2	0.66	0.3	1.1
02/04/2023 21:00	4,496.5	736.8	5,233.3	104,900.0	549.0	0.66	0.3	1.1
02/04/2023 22:00	4,221.1	239.1	4,333.5	104,900.0	454.6	0.56	0.3	0.9
02/04/2023 23:00	2,244.9	0.0	2,244.9	104,900.0	235.5	0.36	0.2	0.6
Average/Sum#:	3,708.5	347.9	4,031.8	104,900.0	422.9	0.55	0.3	0.9
Minimum:	2,244.9	0.0	2,244.9	104,900.0	235.5	0.35	0.2	0.6
Maximum:	4,513.8	737.8	5,245.3	104,900.0	550.2	0.66	0.3	1.1
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/05/2023 17:00	304.2	0.0	304.2	104,900.0	31.9	0.00	0.0	0.0
02/05/2023 18:00	2,700.2	0.0	2,700.2	104,900.0	283.3	0.40	0.2	0.7
02/05/2023 19:00	3,144.3	0.0	3,144.3	104,900.0	329.8	0.40	0.2	0.7
02/05/2023 20:00	4,325.1	227.5	4,488.9	104,900.0	470.9	0.57	0.3	1.0
02/05/2023 21:00	4,294.6	105.7	4,349.6	104,900.0	456.3	0.55	0.3	0.9
02/05/2023 22:00	2,482.8	0.0	2,482.8	104,900.0	260.4	0.34	0.2	0.6
02/05/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,875.2	55.5	2,911.7	104,900.0	305.4	0.45	0.2	0.8
Minimum:	304.2	0.0	304.2	104,900.0	31.9	0.34	0.2	0.6
Maximum:	4,325.1	227.5	4,488.9	104,900.0	470.9	0.57	0.3	1.0
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/06/2023 15:00	487.5	0.0	487.5	104,900.0	51.1	0.00	0.0	0.0
02/06/2023 16:00	2,799.6	0.0	2,799.6	104,900.0	293.7	0.38	0.2	0.6
02/06/2023 17:00	4,437.9	406.9	4,730.9	104,900.0	496.3	0.61	0.3	1.0
02/06/2023 18:00	4,549.5	682.8	5,232.3	104,900.0	548.9	0.66	0.3	1.1
02/06/2023 19:00	4,561.0	666.4	5,227.4	104,900.0	548.4	0.66	0.3	1.1
02/06/2023 20:00	4,578.3	963.3	5,541.6	104,900.0	581.3	0.70	0.3	1.2
02/06/2023 21:00	4,590.8	490.6	5,081.4	104,900.0	533.0	0.64	0.3	1.1
02/06/2023 22:00	4,176.8	104.7	4,226.0	104,900.0	443.3	0.54	0.3	0.9
02/06/2023 23:00	2,723.5	0.0	2,723.5	104,900.0	285.7	0.38	0.2	0.6
Average/Sum#:	3,656.1	368.3	4,005.6	104,900.0	420.2	0.57	0.3	1.0
Minimum:	487.5	0.0	487.5	104,900.0	51.1	0.38	0.2	0.6
Maximum:	4,590.8	963.3	5,541.6	104,900.0	581.3	0.70	0.3	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/07/2023 15:00	744.1	0.0	744.1	104,900.0	78.1	0.00	0.0	0.0
02/07/2023 16:00	3,067.8	0.0	3,067.8	104,900.0	321.8	0.48	0.2	0.8
02/07/2023 17:00	4,485.4	391.4	4,771.1	104,900.0	500.5	0.61	0.3	1.0
02/07/2023 18:00	4,558.0	780.4	5,338.4	104,900.0	560.0	0.67	0.3	1.1
02/07/2023 19:00	4,564.9	845.4	5,410.3	104,900.0	567.5	0.68	0.3	1.1
02/07/2023 20:00	4,585.3	942.4	5,527.7	104,900.0	579.9	0.70	0.3	1.2
02/07/2023 21:00	4,593.9	792.2	5,386.1	104,900.0	565.0	0.68	0.3	1.1
02/07/2023 22:00	4,605.5	621.5	5,227.0	104,900.0	548.3	0.66	0.3	1.1
02/07/2023 23:00	4,615.6	406.5	5,022.1	104,900.0	526.8	0.63	0.3	1.1
Average/Sum#:	3,980.1	531.1	4,499.4	104,900.0	472.0	0.64	0.3	1.1
Minimum:	744.1	0.0	744.1	104,900.0	78.1	0.48	0.2	0.8
Maximum:	4,615.6	942.4	5,527.7	104,900.0	579.9	0.70	0.3	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2023 00:00	4,427.0	18.4	4,429.8	104,900.0	464.7	0.56	0.3	0.9
02/08/2023 01:00	4,427.7	0.0	4,427.7	104,900.0	464.5	0.56	0.3	0.9
02/08/2023 02:00	4,322.4	0.0	4,322.4	104,900.0	453.4	0.54	0.3	0.9
02/08/2023 03:00	4,272.8	0.0	4,272.8	104,900.0	448.2	0.54	0.3	0.9
02/08/2023 04:00	4,354.1	0.0	4,354.1	104,900.0	456.7	0.55	0.3	0.9
02/08/2023 05:00	4,517.9	28.8	4,524.5	104,900.0	474.6	0.57	0.3	1.0
02/08/2023 06:00	4,677.8	657.3	5,335.1	104,900.0	559.7	0.67	0.3	1.1
02/08/2023 07:00	4,522.2	207.1	4,650.6	104,900.0	487.8	0.60	0.3	1.0
02/08/2023 08:00	3,171.3	0.0	3,171.3	104,900.0	332.7	0.40	0.2	0.7
02/08/2023 09:00	2,785.2	0.0	2,785.2	104,900.0	292.2	0.35	0.2	0.6
02/08/2023 10:00	2,783.1	0.0	2,783.1	104,900.0	291.9	0.35	0.2	0.6
02/08/2023 11:00	2,792.2	0.0	2,792.2	104,900.0	292.9	0.35	0.2	0.6
02/08/2023 12:00	2,803.3	0.0	2,803.3	104,900.0	294.1	0.35	0.2	0.6
02/08/2023 13:00	2,802.0	0.0	2,802.0	104,900.0	293.9	0.35	0.2	0.6
02/08/2023 14:00	2,798.7	0.0	2,798.7	104,900.0	293.6	0.35	0.2	0.6
02/08/2023 15:00	3,277.5	0.0	3,277.5	104,900.0	343.8	0.41	0.2	0.7
02/08/2023 16:00	3,342.4	0.0	3,342.4	104,900.0	350.6	0.42	0.2	0.7
02/08/2023 17:00	4,487.3	433.0	4,825.0	104,900.0	506.1	0.62	0.3	1.0
02/08/2023 18:00	4,538.7	1,067.6	5,606.3	104,900.0	588.1	0.71	0.4	1.2
02/08/2023 19:00	4,551.4	855.0	5,406.4	104,900.0	567.1	0.68	0.3	1.1
02/08/2023 20:00	4,575.5	667.1	5,242.6	104,900.0	549.9	0.66	0.3	1.1
02/08/2023 21:00	4,585.5	1,058.9	5,644.4	104,900.0	592.1	0.71	0.4	1.2
02/08/2023 22:00	4,591.9	766.2	5,358.1	104,900.0	562.1	0.68	0.3	1.1
02/08/2023 23:00	4,587.2	332.8	4,843.5	104,900.0	508.1	0.62	0.3	1.0
Average/Sum#:	3,916.5	253.8	4,158.3	104,900.0	436.2	0.53	0.3	0.9
Minimum:	2,783.1	0.0	2,783.1	104,900.0	291.9	0.35	0.2	0.6
Maximum:	4,677.8	1,067.6	5,644.4	104,900.0	592.1	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2023 00:00	4,581.2	0.0	4,581.2	104,900.0	480.6	0.58	0.3	1.0
02/09/2023 01:00	4,452.8	0.0	4,452.8	104,900.0	467.1	0.56	0.3	0.9
02/09/2023 02:00	4,584.1	0.0	4,584.1	104,900.0	480.9	0.58	0.3	1.0
02/09/2023 03:00	4,574.2	0.0	4,574.2	104,900.0	479.8	0.58	0.3	1.0
02/09/2023 04:00	4,469.2	6.6	4,469.7	104,900.0	468.9	0.56	0.3	0.9
02/09/2023 05:00	4,645.8	784.9	5,407.2	104,900.0	567.2	0.68	0.3	1.1
02/09/2023 06:00	4,665.8	984.5	5,650.3	104,900.0	592.7	0.71	0.4	1.2
02/09/2023 07:00	4,223.0	222.8	4,341.1	104,900.0	455.4	0.56	0.3	0.9
02/09/2023 08:00	2,997.3	0.0	2,997.3	104,900.0	314.4	0.38	0.2	0.6
02/09/2023 09:00	2,778.5	0.0	2,778.5	104,900.0	291.5	0.35	0.2	0.6
02/09/2023 10:00	2,798.4	0.0	2,798.4	104,900.0	293.6	0.35	0.2	0.6
02/09/2023 11:00	2,803.6	0.0	2,803.6	104,900.0	294.1	0.35	0.2	0.6
02/09/2023 12:00	2,785.1	0.0	2,785.1	104,900.0	292.2	0.35	0.2	0.6
02/09/2023 13:00	2,764.8	0.0	2,764.8	104,900.0	290.0	0.35	0.2	0.6
02/09/2023 14:00	2,763.7	0.0	2,763.7	104,900.0	289.9	0.35	0.2	0.6
02/09/2023 15:00	2,929.6	0.0	2,929.6	104,900.0	307.3	0.37	0.2	0.6
02/09/2023 16:00	3,296.6	0.0	3,296.6	104,900.0	345.8	0.41	0.2	0.7
02/09/2023 17:00	4,289.0	241.4	4,441.1	104,900.0	465.9	0.57	0.3	1.0
02/09/2023 18:00	4,524.9	1,084.2	5,609.1	104,900.0	588.4	0.71	0.4	1.2
02/09/2023 19:00	4,521.3	762.1	5,283.4	104,900.0	554.2	0.66	0.3	1.1
02/09/2023 20:00	4,561.6	946.9	5,508.5	104,900.0	577.8	0.69	0.3	1.2
02/09/2023 21:00	4,576.9	989.9	5,566.8	104,900.0	584.0	0.70	0.4	1.2
02/09/2023 22:00	4,570.5	741.0	5,311.5	104,900.0	557.2	0.67	0.3	1.1
02/09/2023 23:00	3,842.1	62.2	3,858.9	104,900.0	404.8	0.49	0.2	0.8
Average/Sum#:	3,875.0	284.4	4,148.2	104,900.0	435.2	0.52	0.3	0.9
Minimum:	2,763.7	0.0	2,763.7	104,900.0	289.9	0.35	0.2	0.6
Maximum:	4,665.8	1,084.2	5,650.3	104,900.0	592.7	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2023 00:00	2,960.8	0.0	2,960.8	104,900.0	310.6	0.37	0.2	0.6
02/10/2023 01:00	2,787.6	0.0	2,787.6	104,900.0	292.4	0.35	0.2	0.6
02/10/2023 02:00	2,787.3	0.0	2,787.3	104,900.0	292.4	0.35	0.2	0.6
02/10/2023 03:00	2,786.7	0.0	2,786.7	104,900.0	292.3	0.35	0.2	0.6
02/10/2023 04:00	2,793.7	0.0	2,793.7	104,900.0	293.1	0.35	0.2	0.6
02/10/2023 05:00	2,788.5	0.0	2,788.5	104,900.0	292.5	0.35	0.2	0.6
02/10/2023 06:00	2,838.0	0.0	2,838.0	104,900.0	297.7	0.36	0.2	0.6
02/10/2023 07:00	2,790.4	0.0	2,790.4	104,900.0	292.7	0.35	0.2	0.6
02/10/2023 08:00	2,792.1	0.0	2,792.1	104,900.0	292.9	0.35	0.2	0.6
02/10/2023 09:00	2,794.7	0.0	2,794.7	104,900.0	293.2	0.35	0.2	0.6
02/10/2023 10:00	2,802.0	0.0	2,802.0	104,900.0	293.9	0.35	0.2	0.6
02/10/2023 11:00	2,801.3	0.0	2,801.3	104,900.0	293.9	0.35	0.2	0.6
02/10/2023 12:00	2,808.3	0.0	2,808.3	104,900.0	294.6	0.35	0.2	0.6
02/10/2023 13:00	2,813.6	0.0	2,813.6	104,900.0	295.1	0.35	0.2	0.6
02/10/2023 14:00	2,814.9	0.0	2,814.9	104,900.0	295.3	0.35	0.2	0.6
02/10/2023 15:00	3,282.9	0.0	3,282.9	104,900.0	344.4	0.41	0.2	0.7
02/10/2023 16:00	3,155.9	0.0	3,155.9	104,900.0	331.1	0.40	0.2	0.7
02/10/2023 17:00	4,221.5	359.4	4,430.0	104,900.0	464.7	0.58	0.3	1.0
02/10/2023 18:00	4,558.9	373.4	4,932.3	104,900.0	517.4	0.62	0.3	1.0
02/10/2023 19:00	4,574.8	360.4	4,935.2	104,900.0	517.7	0.62	0.3	1.0
02/10/2023 20:00	4,580.3	487.1	5,067.4	104,900.0	531.6	0.64	0.3	1.1
02/10/2023 21:00	4,575.3	533.1	5,108.4	104,900.0	535.9	0.64	0.3	1.1
02/10/2023 22:00	4,595.4	534.5	5,129.9	104,900.0	538.1	0.65	0.3	1.1
02/10/2023 23:00	4,593.6	348.1	4,941.7	104,900.0	518.4	0.62	0.3	1.0
Average/Sum#:	3,345.8	124.8	3,464.3	104,900.0	363.4	0.44	0.2	0.7
Minimum:	2,786.7	0.0	2,786.7	104,900.0	292.3	0.35	0.2	0.6
Maximum:	4,595.4	534.5	5,129.9	104,900.0	538.1	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2023 00:00	4,602.0	444.2	5,046.2	104,900.0	529.3	0.64	0.3	1.1
02/11/2023 01:00	4,600.9	345.4	4,946.3	104,900.0	518.9	0.62	0.3	1.0
02/11/2023 02:00	4,616.3	264.2	4,880.5	104,900.0	512.0	0.61	0.3	1.0
02/11/2023 03:00	4,611.7	269.3	4,881.0	104,900.0	512.0	0.61	0.3	1.0
02/11/2023 04:00	4,632.1	242.6	4,874.7	104,900.0	511.4	0.61	0.3	1.0
02/11/2023 05:00	4,638.6	302.6	4,941.2	104,900.0	518.3	0.62	0.3	1.0
02/11/2023 06:00	4,655.6	294.1	4,949.7	104,900.0	519.2	0.62	0.3	1.0
02/11/2023 07:00	4,511.1	157.4	4,626.0	104,900.0	485.3	0.59	0.3	1.0
02/11/2023 08:00	2,835.6	0.0	2,835.6	104,900.0	297.5	0.38	0.2	0.6
02/11/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/11/2023 16:00	2,611.2	0.0	2,611.2	104,900.0	273.9	0.39	0.2	0.6
02/11/2023 17:00	4,186.3	310.9	4,388.4	104,900.0	460.3	0.57	0.3	0.9
02/11/2023 18:00	4,504.6	530.1	5,034.7	104,900.0	528.1	0.63	0.3	1.1
02/11/2023 19:00	4,519.6	474.2	4,993.8	104,900.0	523.8	0.63	0.3	1.0
02/11/2023 20:00	4,533.2	484.5	5,017.7	104,900.0	526.4	0.63	0.3	1.1
02/11/2023 21:00	4,561.5	618.0	5,179.5	104,900.0	543.3	0.65	0.3	1.1
02/11/2023 22:00	4,590.4	615.7	5,206.1	104,900.0	546.1	0.65	0.3	1.1
02/11/2023 23:00	4,604.0	412.9	5,016.9	104,900.0	526.3	0.63	0.3	1.1
Average/Sum#:	4,342.0	339.2	4,672.3	104,900.0	490.1	0.59	0.3	1.0
Minimum:	2,611.2	0.0	2,611.2	104,900.0	273.9	0.38	0.2	0.6
Maximum:	4,655.6	618.0	5,206.1	104,900.0	546.1	0.65	0.3	1.1
%SI	29.17	29.17	29.17	0.00	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2023 00:00	4,621.4	630.0	5,251.4	104,900.0	550.9	0.66	0.3	1.1
02/12/2023 01:00	4,627.7	591.2	5,218.9	104,900.0	547.5	0.66	0.3	1.1
02/12/2023 02:00	4,641.5	479.4	5,120.9	104,900.0	537.2	0.65	0.3	1.1
02/12/2023 03:00	4,623.6	629.4	5,253.0	104,900.0	551.0	0.66	0.3	1.1
02/12/2023 04:00	4,609.7	653.2	5,262.9	104,900.0	552.1	0.66	0.3	1.1
02/12/2023 05:00	4,618.9	618.0	5,236.9	104,900.0	549.4	0.66	0.3	1.1
02/12/2023 06:00	4,620.5	534.7	5,155.2	104,900.0	540.8	0.65	0.3	1.1
02/12/2023 07:00	4,213.3	196.4	4,301.7	104,900.0	451.2	0.56	0.3	0.9
02/12/2023 08:00	3,259.4	0.0	3,259.4	104,900.0	341.9	0.41	0.2	0.7
02/12/2023 09:00	2,778.2	0.0	2,778.2	104,900.0	291.4	0.35	0.2	0.6
02/12/2023 10:00	2,783.2	0.0	2,783.2	104,900.0	292.0	0.35	0.2	0.6
02/12/2023 11:00	2,790.0	0.0	2,790.0	104,900.0	292.7	0.35	0.2	0.6
02/12/2023 12:00	2,793.6	0.0	2,793.6	104,900.0	293.0	0.35	0.2	0.6
02/12/2023 13:00	2,782.4	0.0	2,782.4	104,900.0	291.9	0.35	0.2	0.6
02/12/2023 14:00	2,754.3	0.0	2,754.3	104,900.0	288.9	0.35	0.2	0.6
02/12/2023 15:00	3,711.1	0.0	3,711.1	104,900.0	389.3	0.47	0.2	0.8
02/12/2023 16:00	3,743.5	16.9	3,744.7	104,900.0	392.8	0.47	0.2	0.8
02/12/2023 17:00	4,403.3	787.6	5,190.9	104,900.0	544.5	0.65	0.3	1.1
02/12/2023 18:00	4,439.4	541.7	4,981.1	104,900.0	522.5	0.63	0.3	1.0
02/12/2023 19:00	4,459.6	752.4	5,212.0	104,900.0	546.7	0.66	0.3	1.1
02/12/2023 20:00	4,488.1	820.4	5,308.5	104,900.0	556.9	0.67	0.3	1.1
02/12/2023 21:00	4,462.7	446.6	4,797.7	104,900.0	503.3	0.62	0.3	1.0
02/12/2023 22:00	3,667.3	0.0	3,667.3	104,900.0	384.7	0.46	0.2	0.8
02/12/2023 23:00	3,167.1	0.0	3,167.1	104,900.0	332.2	0.40	0.2	0.7
Average/Sum#:	3,877.5	320.7	4,188.4	104,900.0	439.4	0.53	0.3	0.9
Minimum:	2,754.3	0.0	2,754.3	104,900.0	288.9	0.35	0.2	0.6
Maximum:	4,641.5	820.4	5,308.5	104,900.0	556.9	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2023 00:00	2,790.0	0.0	2,790.0	104,900.0	292.7	0.38	0.2	0.6
02/13/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/13/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,790.0	0.0	2,790.0	104,900.0	292.7	0.38	0.2	0.6
Minimum:	2,790.0	0.0	2,790.0	104,900.0	292.7	0.38	0.2	0.6
Maximum:	2,790.0	0.0	2,790.0	104,900.0	292.7	0.38	0.2	0.6
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/14/2023 15:00	2,119.9	0.0	2,119.9	104,900.0	222.4	0.00	0.0	0.0
02/14/2023 16:00	4,156.2	39.4	4,177.1	104,900.0	438.2	0.58	0.3	1.0
02/14/2023 17:00	4,575.9	1,080.9	5,656.8	104,900.0	593.4	0.71	0.4	1.2
02/14/2023 18:00	4,602.9	1,179.0	5,781.9	104,900.0	606.5	0.73	0.4	1.2
02/14/2023 19:00	4,631.1	828.5	5,459.6	104,900.0	572.7	0.69	0.3	1.1
02/14/2023 20:00	4,644.0	1,024.5	5,668.5	104,900.0	594.6	0.71	0.4	1.2
02/14/2023 21:00	4,670.5	689.2	5,359.7	104,900.0	562.2	0.67	0.3	1.1
02/14/2023 22:00	4,677.7	379.7	5,057.4	104,900.0	530.5	0.64	0.3	1.1
02/14/2023 23:00	4,694.6	589.6	5,284.2	104,900.0	554.3	0.67	0.3	1.1
Average/Sum#:	4,308.1	645.6	4,951.7	104,900.0	519.4	0.68	0.3	1.1
Minimum:	2,119.9	0.0	2,119.9	104,900.0	222.4	0.58	0.3	1.0
Maximum:	4,694.6	1,179.0	5,781.9	104,900.0	606.5	0.73	0.4	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2023 00:00	4,710.5	520.1	5,230.6	104,900.0	548.7	0.66	0.3	1.1
02/15/2023 01:00	4,717.4	486.4	5,203.8	104,900.0	545.9	0.65	0.3	1.1
02/15/2023 02:00	4,725.9	468.6	5,194.5	104,900.0	544.9	0.65	0.3	1.1
02/15/2023 03:00	4,728.8	574.3	5,303.1	104,900.0	556.3	0.67	0.3	1.1
02/15/2023 04:00	4,728.5	847.4	5,575.9	104,900.0	584.9	0.70	0.4	1.2
02/15/2023 05:00	4,732.4	872.9	5,605.3	104,900.0	588.0	0.71	0.4	1.2
02/15/2023 06:00	4,744.4	1,037.0	5,781.4	104,900.0	606.5	0.73	0.4	1.2
02/15/2023 07:00	4,637.9	1,353.6	5,693.7	104,900.0	597.3	0.75	0.4	1.3
02/15/2023 08:00	3,307.5	0.0	3,307.5	104,900.0	347.0	0.46	0.2	0.8
02/15/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/15/2023 16:00	2,430.1	0.0	2,430.1	104,900.0	254.9	0.00	0.0	0.0
02/15/2023 17:00	4,139.2	127.7	4,209.4	104,900.0	441.6	0.54	0.3	0.9
02/15/2023 18:00	4,574.2	1,181.5	5,755.7	104,900.0	603.8	0.72	0.4	1.2
02/15/2023 19:00	4,577.3	1,175.7	5,753.0	104,900.0	603.5	0.72	0.4	1.2
02/15/2023 20:00	4,608.6	1,132.7	5,741.3	104,900.0	602.3	0.72	0.4	1.2
02/15/2023 21:00	4,605.0	1,183.0	5,788.0	104,900.0	607.2	0.73	0.4	1.2
02/15/2023 22:00	4,609.1	1,137.8	5,746.9	104,900.0	602.8	0.72	0.4	1.2
02/15/2023 23:00	4,609.4	771.2	5,380.6	104,900.0	564.4	0.68	0.3	1.1
Average/Sum#:	4,422.7	757.1	5,158.9	104,900.0	541.2	0.68	0.4	1.1
Minimum:	2,430.1	0.0	2,430.1	104,900.0	254.9	0.46	0.2	0.8
Maximum:	4,744.4	1,353.6	5,788.0	104,900.0	607.2	0.75	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2023 00:00	4,593.2	0.4	4,593.2	104,900.0	481.8	0.58	0.3	1.0
02/16/2023 01:00	4,597.5	0.0	4,597.5	104,900.0	482.3	0.58	0.3	1.0
02/16/2023 02:00	4,611.4	0.0	4,611.4	104,900.0	483.7	0.58	0.3	1.0
02/16/2023 03:00	4,608.1	0.0	4,608.1	104,900.0	483.4	0.58	0.3	1.0
02/16/2023 04:00	4,600.1	0.0	4,600.1	104,900.0	482.6	0.58	0.3	1.0
02/16/2023 05:00	4,597.0	0.0	4,597.0	104,900.0	482.2	0.58	0.3	1.0
02/16/2023 06:00	4,582.7	4.9	4,583.3	104,900.0	480.8	0.58	0.3	1.0
02/16/2023 07:00	4,594.6	334.4	4,922.3	104,900.0	516.3	0.62	0.3	1.0
02/16/2023 08:00	3,610.2	58.6	3,626.0	104,900.0	380.4	0.49	0.2	0.8
02/16/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/16/2023 16:00	2,432.1	0.0	2,432.1	104,900.0	255.1	0.35	0.2	0.6
02/16/2023 17:00	3,791.6	12.5	3,795.1	104,900.0	398.1	0.48	0.2	0.8
02/16/2023 18:00	4,603.1	248.3	4,796.8	104,900.0	503.2	0.61	0.3	1.0
02/16/2023 19:00	4,609.6	407.2	5,016.8	104,900.0	526.3	0.63	0.3	1.1
02/16/2023 20:00	4,606.4	553.9	5,160.3	104,900.0	541.3	0.65	0.3	1.1
02/16/2023 21:00	4,611.6	599.9	5,211.5	104,900.0	546.7	0.66	0.3	1.1
02/16/2023 22:00	4,614.7	685.2	5,299.9	104,900.0	556.0	0.67	0.3	1.1
02/16/2023 23:00	4,610.9	454.3	5,065.2	104,900.0	531.3	0.64	0.3	1.1
Average/Sum#:	4,369.1	197.6	4,559.8	104,900.0	478.3	0.58	0.3	1.0
Minimum:	2,432.1	0.0	2,432.1	104,900.0	255.1	0.35	0.2	0.6
Maximum:	4,614.7	685.2	5,299.9	104,900.0	556.0	0.67	0.3	1.1
%SI	29.17	29.17	29.17	0.00	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2023 00:00	4,605.0	501.3	5,106.3	104,900.0	535.7	0.64	0.3	1.1
02/17/2023 01:00	4,603.3	261.0	4,864.3	104,900.0	510.3	0.61	0.3	1.0
02/17/2023 02:00	4,596.1	266.8	4,862.9	104,900.0	510.1	0.61	0.3	1.0
02/17/2023 03:00	3,160.4	1.1	3,160.4	104,900.0	331.5	0.42	0.2	0.7
02/17/2023 04:00	0.0	0.0	9.1	104,900.0	1.0	0.00	0.0	0.0
02/17/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/17/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,393.0	206.0	3,600.6	104,900.0	377.7	0.57	0.3	1.0
Minimum:	0.0	0.0	9.1	104,900.0	1.0	0.42	0.2	0.7
Maximum:	4,605.0	501.3	5,106.3	104,900.0	535.7	0.64	0.3	1.1
%SI	79.17	79.17	79.17	0.00	79.17	83.33	83.33	83.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/18/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/19/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
02/20/2023 15:00	412.4	0.0	412.4	104,900.0	43.3	0.00	0.0	0.0
02/20/2023 16:00	2,689.7	0.0	2,689.7	104,900.0	282.1	0.00	0.0	0.0
02/20/2023 17:00	4,391.0	581.9	4,810.0	104,900.0	504.6	0.65	0.3	1.1
02/20/2023 18:00	4,479.3	792.6	5,271.9	104,900.0	553.0	0.66	0.3	1.1
02/20/2023 19:00	4,484.9	796.7	5,281.6	104,900.0	554.0	0.66	0.3	1.1
02/20/2023 20:00	4,498.4	755.0	5,253.4	104,900.0	551.1	0.66	0.3	1.1
02/20/2023 21:00	4,520.0	557.9	5,077.9	104,900.0	532.7	0.64	0.3	1.1
02/20/2023 22:00	4,187.7	195.7	4,291.4	104,900.0	450.2	0.55	0.3	0.9
02/20/2023 23:00	3,033.9	0.0	3,033.9	104,900.0	318.3	0.38	0.2	0.6
Average/Sum#:	3,633.0	408.9	4,013.6	104,900.0	421.0	0.60	0.3	1.0
Minimum:	412.4	0.0	412.4	104,900.0	43.3	0.38	0.2	0.6
Maximum:	4,520.0	796.7	5,281.6	104,900.0	554.0	0.66	0.3	1.1
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2023 00:00	2,785.7	0.0	2,785.7	104,900.0	292.2	0.35	0.2	0.6
02/21/2023 01:00	2,784.0	0.0	2,784.0	104,900.0	292.0	0.35	0.2	0.6
02/21/2023 02:00	2,787.2	0.0	2,787.2	104,900.0	292.4	0.35	0.2	0.6
02/21/2023 03:00	2,783.8	0.0	2,783.8	104,900.0	292.0	0.35	0.2	0.6
02/21/2023 04:00	2,779.4	0.0	2,779.4	104,900.0	291.6	0.35	0.2	0.6
02/21/2023 05:00	2,783.0	0.0	2,783.0	104,900.0	291.9	0.35	0.2	0.6
02/21/2023 06:00	2,780.4	0.0	2,780.4	104,900.0	291.7	0.35	0.2	0.6
02/21/2023 07:00	2,778.3	0.0	2,778.3	104,900.0	291.4	0.35	0.2	0.6
02/21/2023 08:00	2,789.0	0.0	2,789.0	104,900.0	292.6	0.35	0.2	0.6
02/21/2023 09:00	2,781.4	0.0	2,781.4	104,900.0	291.8	0.35	0.2	0.6
02/21/2023 10:00	2,785.8	0.0	2,785.8	104,900.0	292.2	0.35	0.2	0.6
02/21/2023 11:00	2,792.0	0.0	2,792.0	104,900.0	292.9	0.35	0.2	0.6
02/21/2023 12:00	2,798.6	0.0	2,798.6	104,900.0	293.6	0.35	0.2	0.6
02/21/2023 13:00	2,801.0	0.0	2,801.0	104,900.0	293.8	0.35	0.2	0.6
02/21/2023 14:00	2,790.1	0.0	2,790.1	104,900.0	292.7	0.35	0.2	0.6
02/21/2023 15:00	2,769.6	0.0	2,769.6	104,900.0	290.5	0.35	0.2	0.6
02/21/2023 16:00	2,745.4	0.0	2,745.4	104,900.0	288.0	0.35	0.2	0.6
02/21/2023 17:00	2,724.2	0.0	2,724.2	104,900.0	285.8	0.34	0.2	0.6
02/21/2023 18:00	2,723.3	0.0	2,723.3	104,900.0	285.7	0.34	0.2	0.6
02/21/2023 19:00	2,758.6	0.0	2,758.6	104,900.0	289.4	0.35	0.2	0.6
02/21/2023 20:00	2,757.0	0.0	2,757.0	104,900.0	289.2	0.35	0.2	0.6
02/21/2023 21:00	2,762.2	0.0	2,762.2	104,900.0	289.8	0.35	0.2	0.6
02/21/2023 22:00	2,769.4	0.0	2,769.4	104,900.0	290.5	0.35	0.2	0.6
02/21/2023 23:00	2,773.6	0.0	2,773.6	104,900.0	291.0	0.35	0.2	0.6
Average/Sum#:	2,774.3	0.0	2,774.3	104,900.0	291.0	0.35	0.2	0.6
Minimum:	2,723.3	0.0	2,723.3	104,900.0	285.7	0.34	0.2	0.6
Maximum:	2,801.0	0.0	2,801.0	104,900.0	293.8	0.35	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2023 00:00	2,767.5	0.0	2,767.5	104,900.0	290.3	0.35	0.2	0.6
02/22/2023 01:00	2,770.5	0.0	2,770.5	104,900.0	290.6	0.35	0.2	0.6
02/22/2023 02:00	2,768.4	0.0	2,768.4	104,900.0	290.4	0.35	0.2	0.6
02/22/2023 03:00	2,761.0	0.0	2,761.0	104,900.0	289.6	0.35	0.2	0.6
02/22/2023 04:00	2,762.3	0.0	2,762.3	104,900.0	289.8	0.35	0.2	0.6
02/22/2023 05:00	2,749.6	0.0	2,749.6	104,900.0	288.4	0.35	0.2	0.6
02/22/2023 06:00	2,862.1	0.0	2,862.1	104,900.0	300.2	0.36	0.2	0.6
02/22/2023 07:00	2,755.4	0.0	2,755.4	104,900.0	289.0	0.35	0.2	0.6
02/22/2023 08:00	2,749.6	0.0	2,749.6	104,900.0	288.4	0.35	0.2	0.6
02/22/2023 09:00	2,756.5	0.0	2,756.5	104,900.0	289.2	0.35	0.2	0.6
02/22/2023 10:00	2,771.4	0.0	2,771.4	104,900.0	290.7	0.35	0.2	0.6
02/22/2023 11:00	2,779.2	0.0	2,779.2	104,900.0	291.5	0.35	0.2	0.6
02/22/2023 12:00	2,782.5	0.0	2,782.5	104,900.0	291.9	0.35	0.2	0.6
02/22/2023 13:00	2,776.1	0.0	2,776.1	104,900.0	291.2	0.35	0.2	0.6
02/22/2023 14:00	2,773.9	0.0	2,773.9	104,900.0	291.0	0.35	0.2	0.6
02/22/2023 15:00	3,246.5	0.0	3,246.5	104,900.0	340.6	0.41	0.2	0.7
02/22/2023 16:00	3,765.4	0.0	3,765.4	104,900.0	395.0	0.47	0.2	0.8
02/22/2023 17:00	4,192.2	149.1	4,262.3	104,900.0	447.1	0.55	0.3	0.9
02/22/2023 18:00	4,568.0	738.2	5,306.2	104,900.0	556.6	0.67	0.3	1.1
02/22/2023 19:00	4,596.9	705.1	5,302.0	104,900.0	556.2	0.67	0.3	1.1
02/22/2023 20:00	4,593.9	679.1	5,273.0	104,900.0	553.1	0.66	0.3	1.1
02/22/2023 21:00	4,590.7	553.0	5,143.7	104,900.0	539.6	0.65	0.3	1.1
02/22/2023 22:00	4,290.9	0.9	4,290.9	104,900.0	450.1	0.54	0.3	0.9
02/22/2023 23:00	4,096.4	0.0	4,096.4	104,900.0	429.7	0.52	0.3	0.9
Average/Sum#:	3,313.6	117.7	3,428.0	104,900.0	359.6	0.43	0.2	0.7
Minimum:	2,749.6	0.0	2,749.6	104,900.0	288.4	0.35	0.2	0.6
Maximum:	4,596.9	738.2	5,306.2	104,900.0	556.6	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2023 00:00	4,592.6	601.2	5,061.5	104,900.0	531.0	0.65	0.3	1.1
02/23/2023 01:00	4,607.8	1,121.7	5,729.5	104,900.0	601.0	0.72	0.4	1.2
02/23/2023 02:00	4,610.4	961.4	5,571.8	104,900.0	584.5	0.70	0.4	1.2
02/23/2023 03:00	4,607.5	1,075.8	5,683.3	104,900.0	596.2	0.72	0.4	1.2
02/23/2023 04:00	4,608.2	1,004.6	5,612.8	104,900.0	588.8	0.71	0.4	1.2
02/23/2023 05:00	4,602.8	994.5	5,597.3	104,900.0	587.2	0.70	0.4	1.2
02/23/2023 06:00	4,604.2	1,136.2	5,740.4	104,900.0	602.2	0.72	0.4	1.2
02/23/2023 07:00	4,611.3	311.7	4,923.0	104,900.0	516.4	0.62	0.3	1.0
02/23/2023 08:00	4,620.0	318.7	4,938.7	104,900.0	518.1	0.62	0.3	1.0
02/23/2023 09:00	4,627.2	257.4	4,884.6	104,900.0	512.4	0.61	0.3	1.0
02/23/2023 10:00	4,624.7	274.5	4,899.2	104,900.0	513.9	0.62	0.3	1.0
02/23/2023 11:00	4,616.2	327.1	4,943.3	104,900.0	518.6	0.62	0.3	1.0
02/23/2023 12:00	4,188.6	140.4	4,261.6	104,900.0	447.0	0.55	0.3	0.9
02/23/2023 13:00	3,107.3	0.0	3,107.3	104,900.0	326.0	0.39	0.2	0.7
02/23/2023 14:00	2,785.2	0.0	2,785.2	104,900.0	292.2	0.35	0.2	0.6
02/23/2023 15:00	2,772.9	0.0	2,772.9	104,900.0	290.9	0.35	0.2	0.6
02/23/2023 16:00	2,766.8	0.0	2,766.8	104,900.0	290.2	0.35	0.2	0.6
02/23/2023 17:00	2,764.0	0.0	2,764.0	104,900.0	289.9	0.35	0.2	0.6
02/23/2023 18:00	2,760.2	0.0	2,760.2	104,900.0	289.5	0.35	0.2	0.6
02/23/2023 19:00	2,935.6	0.0	2,935.6	104,900.0	307.9	0.37	0.2	0.6
02/23/2023 20:00	4,516.1	0.2	4,516.1	104,900.0	473.7	0.57	0.3	0.9
02/23/2023 21:00	4,596.2	0.0	4,596.2	104,900.0	482.1	0.58	0.3	1.0
02/23/2023 22:00	4,502.5	14.2	4,514.1	104,900.0	473.5	0.57	0.3	0.9
02/23/2023 23:00	4,470.0	15.8	4,485.3	104,900.0	470.5	0.56	0.3	0.9
Average/Sum#:	4,062.4	356.5	4,410.4	104,900.0	462.7	0.56	0.3	0.9
Minimum:	2,760.2	0.0	2,760.2	104,900.0	289.5	0.35	0.2	0.6
Maximum:	4,627.2	1,136.2	5,740.4	104,900.0	602.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2023 00:00	4,499.7	16.1	4,515.8	104,900.0	473.7	0.57	0.3	0.9
02/24/2023 01:00	4,547.7	8.6	4,556.3	104,900.0	478.0	0.57	0.3	1.0
02/24/2023 02:00	4,478.6	12.7	4,491.3	104,900.0	471.1	0.57	0.3	0.9
02/24/2023 03:00	4,490.9	12.4	4,503.3	104,900.0	472.4	0.57	0.3	0.9
02/24/2023 04:00	4,545.8	14.7	4,560.5	104,900.0	478.4	0.57	0.3	1.0
02/24/2023 05:00	4,604.6	428.5	5,033.1	104,900.0	528.0	0.63	0.3	1.1
02/24/2023 06:00	4,631.0	784.0	5,415.0	104,900.0	568.0	0.68	0.3	1.1
02/24/2023 07:00	4,503.0	19.9	4,522.9	104,900.0	474.5	0.57	0.3	0.9
02/24/2023 08:00	4,485.9	11.3	4,497.2	104,900.0	471.8	0.57	0.3	0.9
02/24/2023 09:00	4,505.0	27.2	4,532.2	104,900.0	475.4	0.57	0.3	1.0
02/24/2023 10:00	4,561.7	65.0	4,626.7	104,900.0	485.3	0.58	0.3	1.0
02/24/2023 11:00	4,553.5	50.6	4,603.1	104,900.0	482.9	0.58	0.3	1.0
02/24/2023 12:00	4,520.7	13.4	4,533.7	104,900.0	475.6	0.57	0.3	1.0
02/24/2023 13:00	4,499.3	10.6	4,509.6	104,900.0	473.1	0.57	0.3	0.9
02/24/2023 14:00	4,503.8	12.0	4,515.6	104,900.0	473.7	0.57	0.3	0.9
02/24/2023 15:00	4,497.8	14.7	4,512.5	104,900.0	473.4	0.57	0.3	0.9
02/24/2023 16:00	4,502.6	14.5	4,517.1	104,900.0	473.8	0.57	0.3	0.9
02/24/2023 17:00	4,513.5	13.0	4,526.5	104,900.0	474.8	0.57	0.3	0.9
02/24/2023 18:00	4,518.8	14.0	4,532.8	104,900.0	475.5	0.57	0.3	1.0
02/24/2023 19:00	4,523.0	16.5	4,539.5	104,900.0	476.2	0.57	0.3	1.0
02/24/2023 20:00	4,501.6	0.0	4,501.6	104,900.0	472.2	0.57	0.3	0.9
02/24/2023 21:00	4,500.5	0.1	4,500.6	104,900.0	472.1	0.57	0.3	0.9
02/24/2023 22:00	4,484.2	0.0	4,484.2	104,900.0	470.4	0.56	0.3	0.9
02/24/2023 23:00	4,464.6	0.0	4,464.6	104,900.0	468.3	0.56	0.3	0.9
Average/Sum#:	4,518.2	65.0	4,583.2	104,900.0	480.8	0.58	0.3	1.0
Minimum:	4,464.6	0.0	4,464.6	104,900.0	468.3	0.56	0.3	0.9
Maximum:	4,631.0	784.0	5,415.0	104,900.0	568.0	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2023 00:00	4,532.2	0.4	4,532.4	104,900.0	475.4	0.57	0.3	1.0
02/25/2023 01:00	4,600.1	0.0	4,600.1	104,900.0	482.6	0.58	0.3	1.0
02/25/2023 02:00	4,600.6	0.0	4,600.6	104,900.0	482.6	0.58	0.3	1.0
02/25/2023 03:00	4,596.7	0.0	4,596.7	104,900.0	482.2	0.58	0.3	1.0
02/25/2023 04:00	4,631.8	0.0	4,631.8	104,900.0	485.9	0.58	0.3	1.0
02/25/2023 05:00	4,576.1	0.0	4,576.1	104,900.0	480.0	0.57	0.3	1.0
02/25/2023 06:00	2,896.8	0.0	2,896.8	104,900.0	303.9	0.37	0.2	0.6
02/25/2023 07:00	2,795.2	0.0	2,795.2	104,900.0	293.2	0.35	0.2	0.6
02/25/2023 08:00	2,794.2	0.0	2,794.2	104,900.0	293.1	0.35	0.2	0.6
02/25/2023 09:00	2,796.2	0.0	2,796.2	104,900.0	293.3	0.35	0.2	0.6
02/25/2023 10:00	2,793.5	0.0	2,793.5	104,900.0	293.0	0.35	0.2	0.6
02/25/2023 11:00	2,799.6	0.0	2,799.6	104,900.0	293.7	0.35	0.2	0.6
02/25/2023 12:00	2,795.4	0.0	2,795.4	104,900.0	293.2	0.35	0.2	0.6
02/25/2023 13:00	2,791.0	0.0	2,791.0	104,900.0	292.8	0.35	0.2	0.6
02/25/2023 14:00	2,796.8	0.0	2,796.8	104,900.0	293.4	0.35	0.2	0.6
02/25/2023 15:00	2,796.4	0.0	2,796.4	104,900.0	293.3	0.35	0.2	0.6
02/25/2023 16:00	2,797.8	0.0	2,797.8	104,900.0	293.5	0.35	0.2	0.6
02/25/2023 17:00	2,796.4	0.0	2,796.4	104,900.0	293.3	0.35	0.2	0.6
02/25/2023 18:00	2,793.4	0.0	2,793.4	104,900.0	293.0	0.35	0.2	0.6
02/25/2023 19:00	2,797.4	0.0	2,797.4	104,900.0	293.4	0.35	0.2	0.6
02/25/2023 20:00	2,798.3	0.0	2,798.3	104,900.0	293.5	0.35	0.2	0.6
02/25/2023 21:00	2,775.7	0.0	2,775.7	104,900.0	291.2	0.35	0.2	0.6
02/25/2023 22:00	2,783.2	0.0	2,783.2	104,900.0	292.0	0.35	0.2	0.6
02/25/2023 23:00	2,787.6	0.0	2,787.6	104,900.0	292.4	0.35	0.2	0.6
Average/Sum#:	3,246.8	0.0	3,246.8	104,900.0	340.6	0.41	0.2	0.7
Minimum:	2,775.7	0.0	2,775.7	104,900.0	291.2	0.35	0.2	0.6
Maximum:	4,631.8	0.4	4,631.8	104,900.0	485.9	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2023 00:00	2,781.8	0.0	2,781.8	104,900.0	291.8	0.35	0.2	0.6
02/26/2023 01:00	2,783.8	0.0	2,783.8	104,900.0	292.0	0.35	0.2	0.6
02/26/2023 02:00	2,789.4	0.0	2,789.4	104,900.0	292.6	0.35	0.2	0.6
02/26/2023 03:00	2,780.0	0.0	2,780.0	104,900.0	291.6	0.35	0.2	0.6
02/26/2023 04:00	2,773.8	0.0	2,773.8	104,900.0	291.0	0.35	0.2	0.6
02/26/2023 05:00	2,770.4	0.0	2,770.4	104,900.0	290.6	0.35	0.2	0.6
02/26/2023 06:00	2,771.4	0.0	2,771.4	104,900.0	290.7	0.35	0.2	0.6
02/26/2023 07:00	2,775.7	0.0	2,775.7	104,900.0	291.2	0.35	0.2	0.6
02/26/2023 08:00	2,772.4	0.0	2,772.4	104,900.0	290.8	0.35	0.2	0.6
02/26/2023 09:00	2,766.9	0.0	2,766.9	104,900.0	290.2	0.35	0.2	0.6
02/26/2023 10:00	2,765.7	0.0	2,765.7	104,900.0	290.1	0.35	0.2	0.6
02/26/2023 11:00	2,764.6	0.0	2,764.6	104,900.0	290.0	0.35	0.2	0.6
02/26/2023 12:00	2,766.6	0.0	2,766.6	104,900.0	290.2	0.35	0.2	0.6
02/26/2023 13:00	2,765.2	0.0	2,765.2	104,900.0	290.1	0.35	0.2	0.6
02/26/2023 14:00	2,768.6	0.0	2,768.6	104,900.0	290.4	0.35	0.2	0.6
02/26/2023 15:00	2,768.7	0.0	2,768.7	104,900.0	290.4	0.35	0.2	0.6
02/26/2023 16:00	2,776.3	0.0	2,776.3	104,900.0	291.2	0.35	0.2	0.6
02/26/2023 17:00	2,769.6	0.0	2,769.6	104,900.0	290.5	0.35	0.2	0.6
02/26/2023 18:00	2,759.5	0.0	2,759.5	104,900.0	289.5	0.35	0.2	0.6
02/26/2023 19:00	2,764.4	0.0	2,764.4	104,900.0	290.0	0.35	0.2	0.6
02/26/2023 20:00	2,773.1	0.0	2,773.1	104,900.0	290.9	0.35	0.2	0.6
02/26/2023 21:00	2,784.0	0.0	2,784.0	104,900.0	292.0	0.35	0.2	0.6
02/26/2023 22:00	2,766.1	0.0	2,766.1	104,900.0	290.2	0.35	0.2	0.6
02/26/2023 23:00	2,779.6	0.0	2,779.6	104,900.0	291.6	0.35	0.2	0.6
Average/Sum#:	2,772.4	0.0	2,772.4	104,900.0	290.8	0.35	0.2	0.6
Minimum:	2,759.5	0.0	2,759.5	104,900.0	289.5	0.35	0.2	0.6
Maximum:	2,789.4	0.0	2,789.4	104,900.0	292.6	0.35	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2023 00:00	2,795.4	0.0	2,795.4	104,900.0	293.2	0.35	0.2	0.6
02/27/2023 01:00	2,795.7	0.0	2,795.7	104,900.0	293.3	0.35	0.2	0.6
02/27/2023 02:00	2,782.8	0.0	2,782.8	104,900.0	291.9	0.35	0.2	0.6
02/27/2023 03:00	2,772.0	0.0	2,772.0	104,900.0	290.8	0.35	0.2	0.6
02/27/2023 04:00	2,770.7	0.0	2,770.7	104,900.0	290.6	0.35	0.2	0.6
02/27/2023 05:00	2,769.8	0.0	2,769.8	104,900.0	290.6	0.35	0.2	0.6
02/27/2023 06:00	2,760.2	0.0	2,760.2	104,900.0	289.5	0.35	0.2	0.6
02/27/2023 07:00	2,753.7	0.0	2,753.7	104,900.0	288.9	0.35	0.2	0.6
02/27/2023 08:00	2,741.4	0.0	2,741.4	104,900.0	287.6	0.34	0.2	0.6
02/27/2023 09:00	2,724.5	0.0	2,724.5	104,900.0	285.8	0.34	0.2	0.6
02/27/2023 10:00	2,733.7	0.0	2,733.7	104,900.0	286.8	0.34	0.2	0.6
02/27/2023 11:00	2,737.6	0.0	2,737.6	104,900.0	287.2	0.34	0.2	0.6
02/27/2023 12:00	2,739.8	0.0	2,739.8	104,900.0	287.4	0.35	0.2	0.6
02/27/2023 13:00	2,756.7	0.0	2,756.7	104,900.0	289.2	0.35	0.2	0.6
02/27/2023 14:00	2,764.4	0.0	2,764.4	104,900.0	290.0	0.35	0.2	0.6
02/27/2023 15:00	2,758.3	0.0	2,758.3	104,900.0	289.3	0.35	0.2	0.6
02/27/2023 16:00	2,927.2	0.0	2,927.2	104,900.0	307.1	0.37	0.2	0.6
02/27/2023 17:00	4,053.7	0.1	4,053.7	104,900.0	425.2	0.51	0.3	0.8
02/27/2023 18:00	4,133.4	102.9	4,159.1	104,900.0	436.3	0.53	0.3	0.9
02/27/2023 19:00	4,605.4	626.3	5,231.7	104,900.0	548.8	0.66	0.3	1.1
02/27/2023 20:00	4,606.8	607.4	5,214.2	104,900.0	547.0	0.66	0.3	1.1
02/27/2023 21:00	4,611.0	516.0	5,127.0	104,900.0	537.8	0.64	0.3	1.1
02/27/2023 22:00	4,189.0	152.9	4,268.5	104,900.0	447.8	0.55	0.3	0.9
02/27/2023 23:00	3,138.3	0.0	3,138.3	104,900.0	329.2	0.39	0.2	0.7
Average/Sum#:	3,184.2	83.6	3,261.5	104,900.0	342.1	0.41	0.2	0.7
Minimum:	2,724.5	0.0	2,724.5	104,900.0	285.8	0.34	0.2	0.6
Maximum:	4,611.0	626.3	5,231.7	104,900.0	548.8	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2023 00:00	2,781.4	0.0	2,781.4	104,900.0	291.8	0.35	0.2	0.6
02/28/2023 01:00	2,780.8	0.0	2,780.8	104,900.0	291.7	0.35	0.2	0.6
02/28/2023 02:00	2,782.8	0.0	2,782.8	104,900.0	291.9	0.35	0.2	0.6
02/28/2023 03:00	2,783.8	0.0	2,783.8	104,900.0	292.0	0.35	0.2	0.6
02/28/2023 04:00	2,781.1	0.0	2,781.1	104,900.0	291.7	0.35	0.2	0.6
02/28/2023 05:00	2,771.9	0.0	2,771.9	104,900.0	290.8	0.35	0.2	0.6
02/28/2023 06:00	2,762.8	0.0	2,762.8	104,900.0	289.8	0.35	0.2	0.6
02/28/2023 07:00	2,757.0	0.0	2,757.0	104,900.0	289.2	0.35	0.2	0.6
02/28/2023 08:00	2,758.3	0.0	2,758.3	104,900.0	289.3	0.35	0.2	0.6
02/28/2023 09:00	2,759.9	0.0	2,759.9	104,900.0	289.5	0.35	0.2	0.6
02/28/2023 10:00	2,777.4	0.0	2,777.4	104,900.0	291.3	0.35	0.2	0.6
02/28/2023 11:00	2,782.0	0.0	2,782.0	104,900.0	291.8	0.35	0.2	0.6
02/28/2023 12:00	2,774.9	0.0	2,774.9	104,900.0	291.1	0.35	0.2	0.6
02/28/2023 13:00	2,780.5	0.0	2,780.5	104,900.0	291.7	0.35	0.2	0.6
02/28/2023 14:00	2,790.3	0.0	2,790.3	104,900.0	292.7	0.35	0.2	0.6
02/28/2023 15:00	2,806.3	0.0	2,806.3	104,900.0	294.4	0.35	0.2	0.6
02/28/2023 16:00	3,270.0	2.9	3,270.3	104,900.0	343.1	0.41	0.2	0.7
02/28/2023 17:00	3,391.5	1.1	3,391.6	104,900.0	355.8	0.43	0.2	0.7
02/28/2023 18:00	4,471.4	190.9	4,605.0	104,900.0	483.1	0.59	0.3	1.0
02/28/2023 19:00	4,604.7	337.8	4,942.5	104,900.0	518.5	0.62	0.3	1.0
02/28/2023 20:00	4,598.9	327.5	4,926.4	104,900.0	516.8	0.62	0.3	1.0
02/28/2023 21:00	4,594.3	336.0	4,930.3	104,900.0	517.2	0.62	0.3	1.0
02/28/2023 22:00	4,623.8	287.2	4,911.0	104,900.0	515.2	0.62	0.3	1.0
02/28/2023 23:00	4,621.4	274.7	4,896.1	104,900.0	513.6	0.62	0.3	1.0
Average/Sum#:	3,275.3	73.3	3,346.0	104,900.0	351.0	0.42	0.2	0.7
Minimum:	2,757.0	0.0	2,757.0	104,900.0	289.2	0.35	0.2	0.6
Maximum:	4,623.8	337.8	4,942.5	104,900.0	518.5	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023 00:00	4,614.2	292.4	4,906.6	104,900.0	514.7	0.62	0.3	1.0
03/01/2023 01:00	4,609.2	312.5	4,921.7	104,900.0	516.3	0.62	0.3	1.0
03/01/2023 02:00	4,610.5	318.7	4,929.2	104,900.0	517.1	0.62	0.3	1.0
03/01/2023 03:00	4,608.6	342.2	4,950.8	104,900.0	519.3	0.62	0.3	1.0
03/01/2023 04:00	4,606.9	364.6	4,971.5	104,900.0	521.5	0.63	0.3	1.0
03/01/2023 05:00	4,611.1	400.5	5,011.6	104,900.0	525.7	0.63	0.3	1.1
03/01/2023 06:00	4,606.2	855.9	5,462.1	104,900.0	573.0	0.69	0.3	1.1
03/01/2023 07:00	4,187.7	226.9	4,308.0	104,900.0	451.9	0.56	0.3	0.9
03/01/2023 08:00	3,015.6	0.0	3,015.6	104,900.0	316.3	0.38	0.2	0.6
03/01/2023 09:00	2,772.2	0.0	2,772.2	104,900.0	290.8	0.35	0.2	0.6
03/01/2023 10:00	2,786.7	0.0	2,786.7	104,900.0	292.3	0.35	0.2	0.6
03/01/2023 11:00	2,786.2	0.0	2,786.2	104,900.0	292.3	0.35	0.2	0.6
03/01/2023 12:00	2,788.3	0.0	2,788.3	104,900.0	292.5	0.35	0.2	0.6
03/01/2023 13:00	2,789.1	0.0	2,789.1	104,900.0	292.6	0.35	0.2	0.6
03/01/2023 14:00	2,789.8	0.0	2,789.8	104,900.0	292.7	0.35	0.2	0.6
03/01/2023 15:00	2,791.8	0.0	2,791.8	104,900.0	292.9	0.35	0.2	0.6
03/01/2023 16:00	2,792.6	0.0	2,792.6	104,900.0	292.9	0.35	0.2	0.6
03/01/2023 17:00	2,802.4	0.0	2,802.4	104,900.0	294.0	0.35	0.2	0.6
03/01/2023 18:00	2,809.4	0.0	2,809.4	104,900.0	294.7	0.35	0.2	0.6
03/01/2023 19:00	2,795.7	0.0	2,795.7	104,900.0	293.3	0.35	0.2	0.6
03/01/2023 20:00	2,771.9	0.0	2,771.9	104,900.0	290.8	0.35	0.2	0.6
03/01/2023 21:00	2,792.8	0.0	2,792.8	104,900.0	293.0	0.35	0.2	0.6
03/01/2023 22:00	2,808.1	0.0	2,808.1	104,900.0	294.6	0.35	0.2	0.6
03/01/2023 23:00	2,808.7	0.0	2,808.7	104,900.0	294.6	0.35	0.2	0.6
Average/Sum#:	3,389.8	129.7	3,515.1	104,900.0	368.7	0.44	0.2	0.7
Minimum:	2,771.9	0.0	2,771.9	104,900.0	290.8	0.35	0.2	0.6
Maximum:	4,614.2	855.9	5,462.1	104,900.0	573.0	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2023 00:00	2,807.9	0.0	2,807.9	104,900.0	294.5	0.35	0.2	0.6
03/02/2023 01:00	2,804.5	0.0	2,804.5	104,900.0	294.2	0.35	0.2	0.6
03/02/2023 02:00	2,834.6	0.0	2,834.6	104,900.0	297.3	0.36	0.2	0.6
03/02/2023 03:00	2,835.3	0.0	2,835.3	104,900.0	297.4	0.36	0.2	0.6
03/02/2023 04:00	2,830.8	0.0	2,830.8	104,900.0	297.0	0.36	0.2	0.6
03/02/2023 05:00	2,837.1	0.0	2,837.1	104,900.0	297.6	0.36	0.2	0.6
03/02/2023 06:00	3,377.5	0.0	3,377.5	104,900.0	354.3	0.43	0.2	0.7
03/02/2023 07:00	2,826.2	0.0	2,826.2	104,900.0	296.5	0.36	0.2	0.6
03/02/2023 08:00	2,826.0	0.0	2,826.0	104,900.0	296.4	0.36	0.2	0.6
03/02/2023 09:00	2,825.7	0.0	2,825.7	104,900.0	296.4	0.36	0.2	0.6
03/02/2023 10:00	2,808.6	0.0	2,808.6	104,900.0	294.6	0.35	0.2	0.6
03/02/2023 11:00	2,772.7	0.0	2,772.7	104,900.0	290.9	0.35	0.2	0.6
03/02/2023 12:00	2,816.1	0.0	2,816.1	104,900.0	295.4	0.35	0.2	0.6
03/02/2023 13:00	2,771.1	0.0	2,771.1	104,900.0	290.7	0.35	0.2	0.6
03/02/2023 14:00	2,765.3	0.0	2,765.3	104,900.0	290.1	0.35	0.2	0.6
03/02/2023 15:00	2,765.3	0.0	2,765.3	104,900.0	290.1	0.35	0.2	0.6
03/02/2023 16:00	2,760.7	0.0	2,760.7	104,900.0	289.6	0.35	0.2	0.6
03/02/2023 17:00	2,752.0	0.0	2,752.0	104,900.0	288.7	0.35	0.2	0.6
03/02/2023 18:00	2,753.1	0.0	2,753.1	104,900.0	288.8	0.35	0.2	0.6
03/02/2023 19:00	2,758.3	0.0	2,758.3	104,900.0	289.3	0.35	0.2	0.6
03/02/2023 20:00	2,753.8	0.0	2,753.8	104,900.0	288.9	0.35	0.2	0.6
03/02/2023 21:00	2,761.3	0.0	2,761.3	104,900.0	289.7	0.35	0.2	0.6
03/02/2023 22:00	2,756.6	0.0	2,756.6	104,900.0	289.2	0.35	0.2	0.6
03/02/2023 23:00	2,762.4	0.0	2,762.4	104,900.0	289.8	0.35	0.2	0.6
Average/Sum#:	2,815.1	0.0	2,815.1	104,900.0	295.3	0.36	0.2	0.6
Minimum:	2,752.0	0.0	2,752.0	104,900.0	288.7	0.35	0.2	0.6
Maximum:	3,377.5	0.0	3,377.5	104,900.0	354.3	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2023 00:00	2,760.8	0.0	2,760.8	104,900.0	289.6	0.35	0.2	0.6
03/03/2023 01:00	2,761.9	0.0	2,761.9	104,900.0	289.7	0.35	0.2	0.6
03/03/2023 02:00	2,762.1	0.0	2,762.1	104,900.0	289.7	0.35	0.2	0.6
03/03/2023 03:00	2,782.0	0.0	2,782.0	104,900.0	291.8	0.35	0.2	0.6
03/03/2023 04:00	2,816.8	0.0	2,816.8	104,900.0	295.5	0.35	0.2	0.6
03/03/2023 05:00	2,768.8	0.0	2,768.8	104,900.0	290.4	0.35	0.2	0.6
03/03/2023 06:00	2,763.8	0.0	2,763.8	104,900.0	289.9	0.35	0.2	0.6
03/03/2023 07:00	2,773.5	0.0	2,773.5	104,900.0	290.9	0.35	0.2	0.6
03/03/2023 08:00	2,775.4	0.0	2,775.4	104,900.0	291.1	0.35	0.2	0.6
03/03/2023 09:00	2,772.4	0.0	2,772.4	104,900.0	290.8	0.35	0.2	0.6
03/03/2023 10:00	2,785.5	0.0	2,785.5	104,900.0	292.2	0.35	0.2	0.6
03/03/2023 11:00	3,011.3	0.0	3,011.3	104,900.0	315.9	0.38	0.2	0.6
03/03/2023 12:00	4,415.6	12.5	4,427.5	104,900.0	464.4	0.56	0.3	0.9
03/03/2023 13:00	4,496.2	188.3	4,684.5	104,900.0	491.4	0.59	0.3	1.0
03/03/2023 14:00	4,515.1	266.6	4,781.7	104,900.0	501.6	0.60	0.3	1.0
03/03/2023 15:00	3,683.1	125.2	3,730.7	104,900.0	391.4	0.48	0.2	0.8
03/03/2023 16:00	2,980.6	0.0	2,980.6	104,900.0	312.7	0.37	0.2	0.6
03/03/2023 17:00	4,061.0	158.7	4,137.2	104,900.0	434.0	0.53	0.3	0.9
03/03/2023 18:00	4,519.1	441.7	4,960.8	104,900.0	520.4	0.62	0.3	1.0
03/03/2023 19:00	4,519.6	532.5	5,052.1	104,900.0	530.0	0.64	0.3	1.1
03/03/2023 20:00	4,526.6	630.0	5,156.6	104,900.0	540.9	0.65	0.3	1.1
03/03/2023 21:00	4,524.3	426.4	4,835.6	104,900.0	507.3	0.62	0.3	1.0
03/03/2023 22:00	3,601.3	0.0	3,601.3	104,900.0	377.8	0.45	0.2	0.8
03/03/2023 23:00	3,034.5	0.0	3,034.5	104,900.0	318.3	0.38	0.2	0.6
Average/Sum#:	3,433.8	115.9	3,538.2	104,900.0	371.2	0.45	0.2	0.8
Minimum:	2,760.8	0.0	2,760.8	104,900.0	289.6	0.35	0.2	0.6
Maximum:	4,526.6	630.0	5,156.6	104,900.0	540.9	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2023 00:00	2,791.0	0.0	2,791.0	104,900.0	292.8	0.35	0.2	0.6
03/04/2023 01:00	2,785.2	0.0	2,785.2	104,900.0	292.2	0.35	0.2	0.6
03/04/2023 02:00	2,784.5	0.0	2,784.5	104,900.0	292.1	0.35	0.2	0.6
03/04/2023 03:00	2,775.2	0.0	2,775.2	104,900.0	291.1	0.35	0.2	0.6
03/04/2023 04:00	2,772.6	0.0	2,772.6	104,900.0	290.8	0.35	0.2	0.6
03/04/2023 05:00	2,774.6	0.0	2,774.6	104,900.0	291.1	0.35	0.2	0.6
03/04/2023 06:00	2,776.6	0.0	2,776.6	104,900.0	291.3	0.35	0.2	0.6
03/04/2023 07:00	2,778.7	0.0	2,778.7	104,900.0	291.5	0.35	0.2	0.6
03/04/2023 08:00	2,771.6	0.0	2,771.6	104,900.0	290.7	0.35	0.2	0.6
03/04/2023 09:00	2,764.2	0.0	2,764.2	104,900.0	290.0	0.35	0.2	0.6
03/04/2023 10:00	2,770.2	0.0	2,770.2	104,900.0	290.6	0.35	0.2	0.6
03/04/2023 11:00	2,765.7	0.0	2,765.7	104,900.0	290.1	0.35	0.2	0.6
03/04/2023 12:00	2,764.0	0.0	2,764.0	104,900.0	289.9	0.35	0.2	0.6
03/04/2023 13:00	2,779.9	0.0	2,779.9	104,900.0	291.6	0.35	0.2	0.6
03/04/2023 14:00	2,788.6	0.0	2,788.6	104,900.0	292.5	0.35	0.2	0.6
03/04/2023 15:00	2,785.1	0.0	2,785.1	104,900.0	292.2	0.35	0.2	0.6
03/04/2023 16:00	3,260.2	0.0	3,260.2	104,900.0	342.0	0.41	0.2	0.7
03/04/2023 17:00	3,090.8	0.0	3,090.8	104,900.0	324.2	0.39	0.2	0.6
03/04/2023 18:00	4,361.4	316.3	4,573.3	104,900.0	479.7	0.59	0.3	1.0
03/04/2023 19:00	4,577.8	863.4	5,441.2	104,900.0	570.8	0.69	0.3	1.1
03/04/2023 20:00	4,565.5	653.8	5,219.3	104,900.0	547.5	0.66	0.3	1.1
03/04/2023 21:00	4,555.5	659.4	5,214.9	104,900.0	547.0	0.66	0.3	1.1
03/04/2023 22:00	3,849.1	89.9	3,873.4	104,900.0	406.3	0.50	0.2	0.8
03/04/2023 23:00	2,924.8	0.0	2,924.8	104,900.0	306.8	0.37	0.2	0.6
Average/Sum#:	3,150.5	107.6	3,251.1	104,900.0	341.0	0.41	0.2	0.7
Minimum:	2,764.0	0.0	2,764.0	104,900.0	289.9	0.35	0.2	0.6
Maximum:	4,577.8	863.4	5,441.2	104,900.0	570.8	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2023 00:00	2,743.0	0.0	2,743.0	104,900.0	287.7	0.35	0.2	0.6
03/05/2023 01:00	2,722.9	0.0	2,722.9	104,900.0	285.6	0.34	0.2	0.6
03/05/2023 02:00	2,751.0	0.0	2,751.0	104,900.0	288.6	0.35	0.2	0.6
03/05/2023 03:00	2,788.2	0.0	2,788.2	104,900.0	292.5	0.35	0.2	0.6
03/05/2023 04:00	2,800.5	0.0	2,800.5	104,900.0	293.8	0.35	0.2	0.6
03/05/2023 05:00	2,811.6	0.0	2,811.6	104,900.0	294.9	0.35	0.2	0.6
03/05/2023 06:00	2,808.4	0.0	2,808.4	104,900.0	294.6	0.35	0.2	0.6
03/05/2023 07:00	2,801.3	0.0	2,801.3	104,900.0	293.9	0.35	0.2	0.6
03/05/2023 08:00	2,760.6	0.0	2,760.6	104,900.0	289.6	0.35	0.2	0.6
03/05/2023 09:00	2,790.0	0.0	2,790.0	104,900.0	292.7	0.35	0.2	0.6
03/05/2023 10:00	2,812.5	0.0	2,812.5	104,900.0	295.0	0.35	0.2	0.6
03/05/2023 11:00	2,799.3	0.0	2,799.3	104,900.0	293.6	0.35	0.2	0.6
03/05/2023 12:00	2,773.1	0.0	2,773.1	104,900.0	290.9	0.35	0.2	0.6
03/05/2023 13:00	2,760.0	0.0	2,760.0	104,900.0	289.5	0.35	0.2	0.6
03/05/2023 14:00	2,753.2	0.0	2,753.2	104,900.0	288.8	0.35	0.2	0.6
03/05/2023 15:00	3,226.5	0.0	3,226.5	104,900.0	338.5	0.41	0.2	0.7
03/05/2023 16:00	3,386.4	0.0	3,386.4	104,900.0	355.2	0.43	0.2	0.7
03/05/2023 17:00	4,260.2	405.3	4,503.4	104,900.0	472.4	0.59	0.3	1.0
03/05/2023 18:00	4,611.2	901.2	5,512.4	104,900.0	578.3	0.70	0.3	1.2
03/05/2023 19:00	4,609.6	952.4	5,562.0	104,900.0	583.5	0.70	0.4	1.2
03/05/2023 20:00	4,614.7	976.2	5,590.9	104,900.0	586.5	0.70	0.4	1.2
03/05/2023 21:00	4,607.0	836.5	5,443.5	104,900.0	571.0	0.69	0.3	1.1
03/05/2023 22:00	4,602.1	674.8	5,276.9	104,900.0	553.5	0.66	0.3	1.1
03/05/2023 23:00	4,599.6	362.6	4,962.2	104,900.0	520.5	0.62	0.3	1.0
Average/Sum#:	3,341.4	212.9	3,547.5	104,900.0	372.1	0.45	0.2	0.8
Minimum:	2,722.9	0.0	2,722.9	104,900.0	285.6	0.34	0.2	0.6
Maximum:	4,614.7	976.2	5,590.9	104,900.0	586.5	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2023 00:00	4,316.3	0.5	4,316.3	104,900.0	452.8	0.54	0.3	0.9
03/06/2023 01:00	3,470.9	0.0	3,470.9	104,900.0	364.1	0.44	0.2	0.7
03/06/2023 02:00	2,746.2	0.0	2,746.2	104,900.0	288.1	0.35	0.2	0.6
03/06/2023 03:00	2,761.1	0.0	2,761.1	104,900.0	289.6	0.35	0.2	0.6
03/06/2023 04:00	2,767.0	0.0	2,767.0	104,900.0	290.3	0.35	0.2	0.6
03/06/2023 05:00	3,023.4	0.0	3,023.4	104,900.0	317.2	0.38	0.2	0.6
03/06/2023 06:00	4,006.7	0.0	4,006.7	104,900.0	420.3	0.50	0.3	0.8
03/06/2023 07:00	2,773.5	0.0	2,773.5	104,900.0	290.9	0.35	0.2	0.6
03/06/2023 08:00	2,769.4	0.0	2,769.4	104,300.0	288.8	0.35	0.2	0.6
03/06/2023 09:00	2,780.8	0.0	2,780.8	104,300.0	290.0	0.35	0.2	0.6
03/06/2023 10:00	2,787.5	0.0	2,787.5	104,300.0	290.7	0.35	0.2	0.6
03/06/2023 11:00	2,780.3	0.0	2,780.3	104,300.0	290.0	0.35	0.2	0.6
03/06/2023 12:00	2,861.6	0.0	2,861.6	104,300.0	298.5	0.36	0.2	0.6
03/06/2023 13:00	3,603.9	0.0	3,603.9	104,300.0	375.9	0.45	0.2	0.8
03/06/2023 14:00	4,095.0	187.8	4,203.9	104,300.0	438.5	0.54	0.3	0.9
03/06/2023 15:00	4,595.1	346.2	4,941.3	104,300.0	515.4	0.62	0.3	1.0
03/06/2023 16:00	4,592.5	347.8	4,940.3	104,300.0	515.3	0.62	0.3	1.0
03/06/2023 17:00	4,587.3	344.6	4,931.9	104,300.0	514.4	0.62	0.3	1.0
03/06/2023 18:00	4,599.8	294.0	4,893.8	104,300.0	510.4	0.61	0.3	1.0
03/06/2023 19:00	4,590.0	265.2	4,855.2	104,300.0	506.4	0.61	0.3	1.0
03/06/2023 20:00	4,600.3	244.2	4,844.5	104,300.0	505.3	0.61	0.3	1.0
03/06/2023 21:00	4,601.0	241.6	4,842.6	104,300.0	505.1	0.61	0.3	1.0
03/06/2023 22:00	4,605.1	241.7	4,846.8	104,300.0	505.5	0.61	0.3	1.0
03/06/2023 23:00	4,607.4	239.0	4,846.4	104,300.0	505.5	0.61	0.3	1.0
Average/Sum#:	3,705.1	114.7	3,816.5	104,500.0	398.7	0.48	0.3	0.8
Minimum:	2,746.2	0.0	2,746.2	104,300.0	288.1	0.35	0.2	0.6
Maximum:	4,607.4	347.8	4,941.3	104,900.0	515.4	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2023 00:00	4,602.7	243.4	4,846.1	104,300.0	505.4	0.61	0.3	1.0
03/07/2023 01:00	4,582.4	282.8	4,865.2	104,300.0	507.4	0.61	0.3	1.0
03/07/2023 02:00	4,590.0	276.8	4,866.8	104,300.0	507.6	0.61	0.3	1.0
03/07/2023 03:00	4,597.7	278.2	4,875.9	104,300.0	508.6	0.61	0.3	1.0
03/07/2023 04:00	4,595.5	344.6	4,940.1	104,300.0	515.3	0.62	0.3	1.0
03/07/2023 05:00	4,600.7	604.7	5,205.4	104,300.0	542.9	0.65	0.3	1.1
03/07/2023 06:00	4,602.8	1,013.1	5,615.9	104,300.0	585.7	0.70	0.4	1.2
03/07/2023 07:00	4,186.7	140.3	4,261.1	104,300.0	444.4	0.54	0.3	0.9
03/07/2023 08:00	3,025.1	0.0	3,025.1	104,300.0	315.5	0.38	0.2	0.6
03/07/2023 09:00	2,784.0	0.0	2,784.0	104,300.0	290.4	0.35	0.2	0.6
03/07/2023 10:00	2,793.7	0.0	2,793.7	104,300.0	291.4	0.35	0.2	0.6
03/07/2023 11:00	2,793.2	0.0	2,793.2	104,300.0	291.3	0.35	0.2	0.6
03/07/2023 12:00	2,796.6	0.0	2,796.6	104,300.0	291.7	0.35	0.2	0.6
03/07/2023 13:00	2,794.6	0.0	2,794.6	104,300.0	291.5	0.35	0.2	0.6
03/07/2023 14:00	2,792.4	0.0	2,792.4	104,300.0	291.2	0.35	0.2	0.6
03/07/2023 15:00	2,791.0	0.0	2,791.0	104,300.0	291.1	0.35	0.2	0.6
03/07/2023 16:00	3,272.0	0.0	3,272.0	104,300.0	341.3	0.41	0.2	0.7
03/07/2023 17:00	2,863.6	0.0	2,863.6	104,300.0	298.7	0.36	0.2	0.6
03/07/2023 18:00	4,073.6	150.9	4,161.1	104,300.0	434.0	0.53	0.3	0.9
03/07/2023 19:00	4,602.3	267.9	4,870.2	104,300.0	508.0	0.61	0.3	1.0
03/07/2023 20:00	4,608.8	238.2	4,847.0	104,300.0	505.5	0.61	0.3	1.0
03/07/2023 21:00	4,604.2	243.0	4,847.2	104,300.0	505.6	0.61	0.3	1.0
03/07/2023 22:00	4,603.5	244.4	4,847.9	104,300.0	505.6	0.61	0.3	1.0
03/07/2023 23:00	4,602.6	242.0	4,844.6	104,300.0	505.3	0.61	0.3	1.0
Average/Sum#:	3,840.0	190.4	4,025.0	104,300.0	419.8	0.51	0.3	0.8
Minimum:	2,784.0	0.0	2,784.0	104,300.0	290.4	0.35	0.2	0.6
Maximum:	4,608.8	1,013.1	5,615.9	104,300.0	585.7	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2023 00:00	4,605.3	241.1	4,846.4	104,300.0	505.5	0.61	0.3	1.0
03/08/2023 01:00	4,604.1	244.8	4,848.9	104,300.0	505.7	0.61	0.3	1.0
03/08/2023 02:00	4,602.5	249.2	4,851.7	104,300.0	506.0	0.61	0.3	1.0
03/08/2023 03:00	4,603.0	244.9	4,847.9	104,300.0	505.6	0.61	0.3	1.0
03/08/2023 04:00	4,593.5	250.2	4,843.7	104,300.0	505.2	0.61	0.3	1.0
03/08/2023 05:00	4,597.1	260.6	4,857.7	104,300.0	506.7	0.61	0.3	1.0
03/08/2023 06:00	4,606.6	281.8	4,888.4	104,300.0	509.9	0.61	0.3	1.0
03/08/2023 07:00	4,600.1	353.2	4,953.3	104,300.0	516.6	0.62	0.3	1.0
03/08/2023 08:00	4,610.1	368.3	4,978.4	104,300.0	519.2	0.62	0.3	1.0
03/08/2023 09:00	4,601.4	327.8	4,929.2	104,300.0	514.1	0.61	0.3	1.0
03/08/2023 10:00	4,250.5	157.7	4,334.1	104,300.0	452.0	0.55	0.3	0.9
03/08/2023 11:00	3,001.6	0.0	3,001.6	104,300.0	313.1	0.38	0.2	0.6
03/08/2023 12:00	2,811.4	0.0	2,811.4	104,300.0	293.2	0.35	0.2	0.6
03/08/2023 13:00	2,799.4	0.0	2,799.4	104,300.0	292.0	0.35	0.2	0.6
03/08/2023 14:00	2,793.5	0.0	2,793.5	104,300.0	291.4	0.35	0.2	0.6
03/08/2023 15:00	2,790.7	0.0	2,790.7	104,300.0	291.1	0.35	0.2	0.6
03/08/2023 16:00	2,782.7	0.0	2,782.7	104,300.0	290.2	0.35	0.2	0.6
03/08/2023 17:00	2,949.4	0.0	2,949.4	104,300.0	307.6	0.37	0.2	0.6
03/08/2023 18:00	3,713.5	0.0	3,713.5	104,300.0	387.3	0.47	0.2	0.8
03/08/2023 19:00	3,615.7	148.1	3,664.6	104,300.0	382.2	0.47	0.2	0.8
03/08/2023 20:00	4,582.3	431.9	5,014.2	104,300.0	523.0	0.63	0.3	1.0
03/08/2023 21:00	4,587.0	353.2	4,940.2	104,300.0	515.3	0.62	0.3	1.0
03/08/2023 22:00	4,584.8	342.7	4,927.5	104,300.0	513.9	0.62	0.3	1.0
03/08/2023 23:00	4,585.1	351.6	4,936.7	104,300.0	514.9	0.62	0.3	1.0
Average/Sum#:	3,994.6	192.0	4,179.4	104,300.0	435.9	0.53	0.3	0.9
Minimum:	2,782.7	0.0	2,782.7	104,300.0	290.2	0.35	0.2	0.6
Maximum:	4,610.1	431.9	5,014.2	104,300.0	523.0	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2023 00:00	4,590.6	350.5	4,941.1	104,300.0	515.4	0.62	0.3	1.0
03/09/2023 01:00	4,589.9	352.4	4,942.3	104,300.0	515.5	0.62	0.3	1.0
03/09/2023 02:00	4,590.1	350.5	4,940.6	104,300.0	515.3	0.62	0.3	1.0
03/09/2023 03:00	4,587.7	351.1	4,938.8	104,300.0	515.1	0.62	0.3	1.0
03/09/2023 04:00	4,586.1	336.2	4,922.3	104,300.0	513.4	0.62	0.3	1.0
03/09/2023 05:00	4,585.3	488.5	5,073.8	104,300.0	529.2	0.64	0.3	1.1
03/09/2023 06:00	4,589.5	365.2	4,954.7	104,300.0	516.8	0.62	0.3	1.0
03/09/2023 07:00	4,594.2	348.7	4,942.9	104,300.0	515.5	0.62	0.3	1.0
03/09/2023 08:00	4,596.9	373.7	4,970.6	104,300.0	518.4	0.62	0.3	1.0
03/09/2023 09:00	4,557.5	421.4	4,978.9	104,300.0	519.3	0.62	0.3	1.0
03/09/2023 10:00	4,544.4	470.0	5,014.4	104,300.0	523.0	0.63	0.3	1.0
03/09/2023 11:00	4,536.0	799.9	5,335.9	104,300.0	556.5	0.67	0.3	1.1
03/09/2023 12:00	4,527.1	1,018.7	5,545.8	104,300.0	578.4	0.69	0.3	1.2
03/09/2023 13:00	4,518.5	1,346.4	5,864.9	104,300.0	611.7	0.73	0.4	1.2
03/09/2023 14:00	4,538.3	1,181.6	5,719.9	104,300.0	596.6	0.71	0.4	1.2
03/09/2023 15:00	4,533.9	856.8	5,390.7	104,300.0	562.3	0.67	0.3	1.1
03/09/2023 16:00	4,543.5	364.1	4,907.6	104,300.0	511.9	0.61	0.3	1.0
03/09/2023 17:00	4,535.3	359.4	4,894.7	104,300.0	510.5	0.61	0.3	1.0
03/09/2023 18:00	4,529.7	375.2	4,904.9	104,300.0	511.6	0.61	0.3	1.0
03/09/2023 19:00	4,517.7	397.0	4,914.7	104,300.0	512.6	0.62	0.3	1.0
03/09/2023 20:00	4,505.1	418.0	4,923.1	104,300.0	513.5	0.62	0.3	1.0
03/09/2023 21:00	4,503.2	419.8	4,923.0	104,300.0	513.5	0.62	0.3	1.0
03/09/2023 22:00	4,185.2	207.1	4,292.9	104,300.0	447.7	0.55	0.3	0.9
03/09/2023 23:00	3,040.1	0.0	3,040.1	104,300.0	317.1	0.38	0.2	0.6
Average/Sum#:	4,476.1	498.0	4,969.9	104,300.0	518.4	0.62	0.3	1.0
Minimum:	3,040.1	0.0	3,040.1	104,300.0	317.1	0.38	0.2	0.6
Maximum:	4,596.9	1,346.4	5,864.9	104,300.0	611.7	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2023 00:00	2,719.5	0.0	2,719.5	104,300.0	283.6	0.34	0.2	0.6
03/10/2023 01:00	2,745.6	0.0	2,745.6	104,300.0	286.4	0.34	0.2	0.6
03/10/2023 02:00	2,739.6	0.0	2,739.6	104,300.0	285.7	0.34	0.2	0.6
03/10/2023 03:00	2,733.1	0.0	2,733.1	104,300.0	285.1	0.34	0.2	0.6
03/10/2023 04:00	2,744.9	0.0	2,744.9	104,300.0	286.3	0.34	0.2	0.6
03/10/2023 05:00	2,777.2	0.0	2,777.2	104,300.0	289.7	0.35	0.2	0.6
03/10/2023 06:00	2,768.5	0.0	2,768.5	104,300.0	288.8	0.35	0.2	0.6
03/10/2023 07:00	2,772.5	0.0	2,772.5	104,300.0	289.2	0.35	0.2	0.6
03/10/2023 08:00	2,784.5	0.0	2,784.5	104,300.0	290.4	0.35	0.2	0.6
03/10/2023 09:00	2,777.2	0.0	2,777.2	104,300.0	289.7	0.35	0.2	0.6
03/10/2023 10:00	3,336.2	0.0	3,336.2	104,300.0	348.0	0.42	0.2	0.7
03/10/2023 11:00	2,831.5	0.0	2,831.5	104,300.0	295.3	0.35	0.2	0.6
03/10/2023 12:00	2,787.9	0.0	2,787.9	104,300.0	290.8	0.35	0.2	0.6
03/10/2023 13:00	2,793.8	0.0	2,793.8	104,300.0	291.4	0.35	0.2	0.6
03/10/2023 14:00	2,791.4	0.0	2,791.4	104,300.0	291.1	0.35	0.2	0.6
03/10/2023 15:00	3,262.9	0.0	3,262.9	104,300.0	340.3	0.41	0.2	0.7
03/10/2023 16:00	3,129.1	0.0	3,129.1	104,300.0	326.4	0.39	0.2	0.7
03/10/2023 17:00	4,146.1	414.4	4,361.6	104,300.0	454.9	0.57	0.3	1.0
03/10/2023 18:00	4,446.0	584.3	5,030.3	104,300.0	524.7	0.63	0.3	1.1
03/10/2023 19:00	4,463.1	479.0	4,942.1	104,300.0	515.5	0.62	0.3	1.0
03/10/2023 20:00	3,987.9	108.8	4,020.5	104,300.0	419.3	0.51	0.3	0.9
03/10/2023 21:00	3,002.2	0.0	3,002.2	104,300.0	313.1	0.38	0.2	0.6
03/10/2023 22:00	2,787.6	0.0	2,787.6	104,300.0	290.7	0.35	0.2	0.6
03/10/2023 23:00	2,787.0	0.0	2,787.0	104,300.0	290.7	0.35	0.2	0.6
Average/Sum#:	3,088.1	66.1	3,142.8	104,300.0	327.8	0.40	0.2	0.7
Minimum:	2,719.5	0.0	2,719.5	104,300.0	283.6	0.34	0.2	0.6
Maximum:	4,463.1	584.3	5,030.3	104,300.0	524.7	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2023 00:00	2,782.7	0.0	2,782.7	104,300.0	290.2	0.35	0.2	0.6
03/11/2023 01:00	2,780.8	0.0	2,780.8	104,300.0	290.0	0.35	0.2	0.6
03/11/2023 02:00	2,777.7	0.0	2,777.7	104,300.0	289.7	0.35	0.2	0.6
03/11/2023 03:00	2,777.9	0.0	2,777.9	104,300.0	289.7	0.35	0.2	0.6
03/11/2023 04:00	2,781.2	0.0	2,781.2	104,300.0	290.1	0.35	0.2	0.6
03/11/2023 05:00	2,786.7	0.0	2,786.7	104,300.0	290.7	0.35	0.2	0.6
03/11/2023 06:00	2,786.5	0.0	2,786.5	104,300.0	290.6	0.35	0.2	0.6
03/11/2023 07:00	2,790.3	0.0	2,790.3	104,300.0	291.0	0.35	0.2	0.6
03/11/2023 08:00	2,781.1	0.0	2,781.1	104,300.0	290.1	0.35	0.2	0.6
03/11/2023 09:00	2,779.8	0.0	2,779.8	104,300.0	289.9	0.35	0.2	0.6
03/11/2023 10:00	2,781.8	0.0	2,781.8	104,300.0	290.1	0.35	0.2	0.6
03/11/2023 11:00	2,787.3	0.0	2,787.3	104,300.0	290.7	0.35	0.2	0.6
03/11/2023 12:00	2,785.3	0.0	2,785.3	104,300.0	290.5	0.35	0.2	0.6
03/11/2023 13:00	2,780.1	0.0	2,780.1	104,300.0	290.0	0.35	0.2	0.6
03/11/2023 14:00	2,780.0	0.0	2,780.0	104,300.0	290.0	0.35	0.2	0.6
03/11/2023 15:00	2,765.7	0.0	2,765.7	104,300.0	288.5	0.35	0.2	0.6
03/11/2023 16:00	2,925.4	0.0	2,925.4	104,300.0	305.1	0.37	0.2	0.6
03/11/2023 17:00	3,196.9	0.4	3,196.9	104,300.0	333.4	0.40	0.2	0.7
03/11/2023 18:00	2,691.6	0.0	2,691.6	104,300.0	280.7	0.34	0.2	0.6
03/11/2023 19:00	4,408.2	564.0	4,876.3	104,300.0	508.6	0.62	0.3	1.0
03/11/2023 20:00	4,516.0	697.6	5,213.6	104,300.0	543.8	0.66	0.3	1.1
03/11/2023 21:00	4,495.2	1,044.7	5,539.9	104,300.0	577.8	0.69	0.3	1.2
03/11/2023 22:00	4,487.0	1,269.6	5,756.6	104,300.0	600.4	0.72	0.4	1.2
03/11/2023 23:00	4,507.4	1,239.9	5,747.3	104,300.0	599.4	0.72	0.4	1.2
Average/Sum#:	3,155.5	200.7	3,352.2	104,300.0	349.6	0.42	0.2	0.7
Minimum:	2,691.6	0.0	2,691.6	104,300.0	280.7	0.34	0.2	0.6
Maximum:	4,516.0	1,269.6	5,756.6	104,300.0	600.4	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2023 00:00	4,511.7	854.6	5,366.3	104,300.0	559.7	0.67	0.3	1.1
03/12/2023 01:00	4,493.9	2.0	4,493.9	104,300.0	468.7	0.56	0.3	0.9
03/12/2023 02:00	4,487.7	0.0	4,487.7	104,300.0	468.1	0.56	0.3	0.9
03/12/2023 03:00	4,481.0	128.4	4,523.4	104,300.0	471.8	0.58	0.3	1.0
03/12/2023 04:00	4,489.2	1,009.7	5,498.9	104,300.0	573.5	0.69	0.3	1.1
03/12/2023 05:00	4,481.8	1,011.3	5,493.1	104,300.0	572.9	0.69	0.3	1.1
03/12/2023 06:00	4,247.6	248.2	4,379.1	104,300.0	456.7	0.56	0.3	0.9
03/12/2023 07:00	2,991.7	0.0	2,991.7	104,300.0	312.0	0.37	0.2	0.6
03/12/2023 08:00	2,765.7	0.0	2,765.7	104,300.0	288.5	0.35	0.2	0.6
03/12/2023 09:00	2,859.9	0.0	2,859.9	104,300.0	298.3	0.36	0.2	0.6
03/12/2023 10:00	2,821.9	0.0	2,821.9	104,300.0	294.3	0.35	0.2	0.6
03/12/2023 11:00	2,847.9	0.0	2,847.9	104,300.0	297.0	0.36	0.2	0.6
03/12/2023 12:00	2,779.2	0.0	2,779.2	104,300.0	289.9	0.35	0.2	0.6
03/12/2023 13:00	2,770.4	0.0	2,770.4	104,300.0	289.0	0.35	0.2	0.6
03/12/2023 14:00	3,228.3	0.0	3,228.3	104,300.0	336.7	0.40	0.2	0.7
03/12/2023 15:00	3,362.1	0.0	3,362.1	104,300.0	350.7	0.42	0.2	0.7
03/12/2023 16:00	3,572.5	168.6	3,626.5	104,300.0	378.2	0.47	0.2	0.8
03/12/2023 17:00	4,452.5	1,167.5	5,620.0	104,300.0	586.2	0.70	0.4	1.2
03/12/2023 18:00	4,481.7	1,252.4	5,734.1	104,300.0	598.1	0.72	0.4	1.2
03/12/2023 19:00	4,489.4	1,124.8	5,614.2	104,300.0	585.6	0.70	0.4	1.2
03/12/2023 20:00	4,489.3	1,228.6	5,717.9	104,300.0	596.4	0.71	0.4	1.2
03/12/2023 21:00	4,486.8	1,195.7	5,682.5	104,300.0	592.7	0.71	0.4	1.2
03/12/2023 22:00	4,484.7	916.6	5,401.3	104,300.0	563.4	0.68	0.3	1.1
03/12/2023 23:00	3,934.9	1.4	3,934.9	104,300.0	410.4	0.49	0.2	0.8
Average/Sum#:	3,833.8	429.6	4,250.0	104,300.0	443.3	0.53	0.3	0.9
Minimum:	2,765.7	0.0	2,765.7	104,300.0	288.5	0.35	0.2	0.6
Maximum:	4,511.7	1,252.4	5,734.1	104,300.0	598.1	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2023 00:00	2,944.5	0.0	2,944.5	104,300.0	307.1	0.37	0.2	0.6
03/13/2023 01:00	2,791.2	0.0	2,791.2	104,300.0	291.1	0.35	0.2	0.6
03/13/2023 02:00	2,804.8	0.0	2,804.8	104,300.0	292.5	0.35	0.2	0.6
03/13/2023 03:00	2,782.7	0.0	2,782.7	104,300.0	290.2	0.35	0.2	0.6
03/13/2023 04:00	3,359.7	0.0	3,359.7	104,300.0	350.4	0.42	0.2	0.7
03/13/2023 05:00	3,749.5	0.0	3,749.5	104,300.0	391.1	0.47	0.2	0.8
03/13/2023 06:00	4,223.4	0.0	4,223.4	104,300.0	440.5	0.53	0.3	0.9
03/13/2023 07:00	2,765.6	0.0	2,765.6	104,300.0	288.5	0.35	0.2	0.6
03/13/2023 08:00	2,771.2	0.0	2,771.2	104,300.0	289.0	0.35	0.2	0.6
03/13/2023 09:00	2,770.4	0.0	2,770.4	104,300.0	289.0	0.35	0.2	0.6
03/13/2023 10:00	2,773.3	0.0	2,773.3	104,300.0	289.3	0.35	0.2	0.6
03/13/2023 11:00	2,777.3	0.0	2,777.3	104,300.0	289.7	0.35	0.2	0.6
03/13/2023 12:00	2,776.4	0.0	2,776.4	104,300.0	289.6	0.35	0.2	0.6
03/13/2023 13:00	2,784.6	0.0	2,784.6	104,300.0	290.4	0.35	0.2	0.6
03/13/2023 14:00	2,784.2	0.0	2,784.2	104,300.0	290.4	0.35	0.2	0.6
03/13/2023 15:00	2,777.9	0.0	2,777.9	104,300.0	289.7	0.35	0.2	0.6
03/13/2023 16:00	3,223.8	0.0	3,223.8	104,300.0	336.2	0.40	0.2	0.7
03/13/2023 17:00	3,106.7	0.0	3,106.7	104,300.0	324.0	0.39	0.2	0.6
03/13/2023 18:00	4,439.7	460.5	4,739.0	104,300.0	494.3	0.61	0.3	1.0
03/13/2023 19:00	4,453.6	923.6	5,377.2	104,300.0	560.8	0.67	0.3	1.1
03/13/2023 20:00	4,450.2	1,206.5	5,656.7	104,300.0	590.0	0.71	0.4	1.2
03/13/2023 21:00	4,437.3	978.6	5,415.9	104,300.0	564.9	0.68	0.3	1.1
03/13/2023 22:00	3,939.5	106.2	3,968.2	104,300.0	413.9	0.51	0.3	0.8
03/13/2023 23:00	2,941.5	0.0	2,941.5	104,300.0	306.8	0.37	0.2	0.6
Average/Sum#:	3,276.2	153.1	3,419.4	104,300.0	356.6	0.43	0.2	0.7
Minimum:	2,765.6	0.0	2,765.6	104,300.0	288.5	0.35	0.2	0.6
Maximum:	4,453.6	1,206.5	5,656.7	104,300.0	590.0	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2023 00:00	2,771.8	0.0	2,771.8	104,300.0	289.1	0.35	0.2	0.6
03/14/2023 01:00	2,730.6	0.0	2,730.6	104,300.0	284.8	0.34	0.2	0.6
03/14/2023 02:00	2,754.5	0.0	2,754.5	104,300.0	287.3	0.35	0.2	0.6
03/14/2023 03:00	2,759.1	0.0	2,759.1	104,300.0	287.8	0.35	0.2	0.6
03/14/2023 04:00	2,754.7	0.0	2,754.7	104,300.0	287.3	0.34	0.2	0.6
03/14/2023 05:00	2,753.8	0.0	2,753.8	104,300.0	287.2	0.34	0.2	0.6
03/14/2023 06:00	2,745.8	0.0	2,745.8	104,300.0	286.4	0.34	0.2	0.6
03/14/2023 07:00	3,538.5	0.0	3,538.5	104,300.0	369.1	0.44	0.2	0.7
03/14/2023 08:00	4,330.1	1.9	4,330.3	104,300.0	451.7	0.54	0.3	0.9
03/14/2023 09:00	3,465.3	0.0	3,465.3	104,300.0	361.4	0.43	0.2	0.7
03/14/2023 10:00	4,330.7	496.0	4,687.8	104,300.0	488.9	0.60	0.3	1.0
03/14/2023 11:00	4,394.7	944.0	5,338.7	104,300.0	556.8	0.67	0.3	1.1
03/14/2023 12:00	4,380.7	1,043.9	5,424.6	104,300.0	565.8	0.68	0.3	1.1
03/14/2023 13:00	4,369.1	1,299.3	5,668.4	104,300.0	591.2	0.71	0.4	1.2
03/14/2023 14:00	4,359.1	1,083.8	5,442.9	104,300.0	567.7	0.68	0.3	1.1
03/14/2023 15:00	4,368.1	750.6	5,118.7	104,300.0	533.9	0.64	0.3	1.1
03/14/2023 16:00	4,409.8	1,011.7	5,421.5	104,300.0	565.5	0.68	0.3	1.1
03/14/2023 17:00	4,438.0	1,132.2	5,570.2	104,300.0	581.0	0.70	0.3	1.2
03/14/2023 18:00	4,466.6	1,218.2	5,684.8	104,300.0	592.9	0.71	0.4	1.2
03/14/2023 19:00	4,481.3	1,275.5	5,756.8	104,300.0	600.4	0.72	0.4	1.2
03/14/2023 20:00	4,490.2	1,185.0	5,675.2	104,300.0	591.9	0.71	0.4	1.2
03/14/2023 21:00	4,498.9	759.1	5,258.0	104,300.0	548.4	0.66	0.3	1.1
03/14/2023 22:00	4,339.7	250.4	4,469.9	104,300.0	466.2	0.57	0.3	1.0
03/14/2023 23:00	3,089.2	0.0	3,089.2	104,300.0	322.2	0.39	0.2	0.6
Average/Sum#:	3,792.5	518.8	4,300.5	104,300.0	448.5	0.54	0.3	0.9
Minimum:	2,730.6	0.0	2,730.6	104,300.0	284.8	0.34	0.2	0.6
Maximum:	4,498.9	1,299.3	5,756.8	104,300.0	600.4	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2023 00:00	2,761.7	0.0	2,761.7	104,300.0	288.0	0.35	0.2	0.6
03/15/2023 01:00	2,765.4	0.0	2,765.4	104,300.0	288.4	0.35	0.2	0.6
03/15/2023 02:00	2,771.4	0.0	2,771.4	104,300.0	289.1	0.35	0.2	0.6
03/15/2023 03:00	2,774.0	0.0	2,774.0	104,300.0	289.3	0.35	0.2	0.6
03/15/2023 04:00	2,770.5	0.0	2,770.5	104,300.0	289.0	0.35	0.2	0.6
03/15/2023 05:00	2,771.5	0.0	2,771.5	104,300.0	289.1	0.35	0.2	0.6
03/15/2023 06:00	2,827.8	0.0	2,827.8	104,300.0	294.9	0.35	0.2	0.6
03/15/2023 07:00	2,773.8	0.0	2,773.8	104,300.0	289.3	0.35	0.2	0.6
03/15/2023 08:00	2,775.1	0.0	2,775.1	104,300.0	289.4	0.35	0.2	0.6
03/15/2023 09:00	2,772.2	0.0	2,772.2	104,300.0	289.1	0.35	0.2	0.6
03/15/2023 10:00	2,767.9	0.0	2,767.9	104,300.0	288.7	0.35	0.2	0.6
03/15/2023 11:00	2,760.9	0.0	2,760.9	104,300.0	288.0	0.35	0.2	0.6
03/15/2023 12:00	2,769.3	0.0	2,769.3	104,300.0	288.8	0.35	0.2	0.6
03/15/2023 13:00	2,774.7	0.0	2,774.7	104,300.0	289.4	0.35	0.2	0.6
03/15/2023 14:00	2,778.0	0.0	2,778.0	104,300.0	289.7	0.35	0.2	0.6
03/15/2023 15:00	2,778.1	0.0	2,778.1	104,300.0	289.8	0.35	0.2	0.6
03/15/2023 16:00	3,216.3	0.0	3,216.3	104,300.0	335.5	0.40	0.2	0.7
03/15/2023 17:00	3,068.5	0.0	3,068.5	104,300.0	320.0	0.38	0.2	0.6
03/15/2023 18:00	4,348.8	327.6	4,584.7	104,300.0	478.2	0.59	0.3	1.0
03/15/2023 19:00	4,479.8	828.8	5,308.6	104,300.0	553.7	0.66	0.3	1.1
03/15/2023 20:00	4,500.1	989.8	5,489.9	104,300.0	572.6	0.69	0.3	1.1
03/15/2023 21:00	4,065.9	89.9	4,091.1	104,300.0	426.7	0.52	0.3	0.9
03/15/2023 22:00	2,842.6	0.0	2,842.6	104,300.0	296.5	0.36	0.2	0.6
03/15/2023 23:00	2,767.7	0.0	2,767.7	104,300.0	288.7	0.35	0.2	0.6
Average/Sum#:	3,070.1	93.2	3,156.7	104,300.0	329.2	0.40	0.2	0.7
Minimum:	2,760.9	0.0	2,760.9	104,300.0	288.0	0.35	0.2	0.6
Maximum:	4,500.1	989.8	5,489.9	104,300.0	572.6	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2023 00:00	2,775.5	0.0	2,775.5	104,300.0	289.5	0.35	0.2	0.6
03/16/2023 01:00	2,768.5	0.0	2,768.5	104,300.0	288.8	0.35	0.2	0.6
03/16/2023 02:00	2,759.5	0.0	2,759.5	104,300.0	287.8	0.35	0.2	0.6
03/16/2023 03:00	2,761.7	0.0	2,761.7	104,300.0	288.0	0.35	0.2	0.6
03/16/2023 04:00	2,763.0	0.0	2,763.0	104,300.0	288.2	0.35	0.2	0.6
03/16/2023 05:00	2,757.6	0.0	2,757.6	104,300.0	287.6	0.35	0.2	0.6
03/16/2023 06:00	2,874.9	0.0	2,874.9	104,300.0	299.9	0.36	0.2	0.6
03/16/2023 07:00	2,771.0	0.0	2,771.0	104,300.0	289.0	0.35	0.2	0.6
03/16/2023 08:00	2,775.8	0.0	2,775.8	104,300.0	289.5	0.35	0.2	0.6
03/16/2023 09:00	2,779.4	0.0	2,779.4	104,300.0	289.9	0.35	0.2	0.6
03/16/2023 10:00	2,785.2	0.0	2,785.2	104,300.0	290.5	0.35	0.2	0.6
03/16/2023 11:00	2,793.8	0.0	2,793.8	104,300.0	291.4	0.35	0.2	0.6
03/16/2023 12:00	2,785.4	0.0	2,785.4	104,300.0	290.5	0.35	0.2	0.6
03/16/2023 13:00	2,759.1	0.0	2,759.1	104,300.0	287.8	0.35	0.2	0.6
03/16/2023 14:00	2,744.9	0.0	2,744.9	104,300.0	286.3	0.34	0.2	0.6
03/16/2023 15:00	2,696.2	0.0	2,696.2	104,300.0	281.2	0.34	0.2	0.6
03/16/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/16/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,772.0	0.0	2,772.0	104,300.0	289.1	0.35	0.2	0.6
Minimum:	2,696.2	0.0	2,696.2	104,300.0	281.2	0.34	0.2	0.6
Maximum:	2,874.9	0.0	2,874.9	104,300.0	299.9	0.36	0.2	0.6
%SI	33.33	33.33	33.33	0.00	33.33	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/17/2023 01:00	804.0	0.0	804.0	104,300.0	83.9	0.00	0.0	0.0
03/17/2023 02:00	3,156.7	0.0	3,156.7	104,300.0	329.2	0.53	0.3	0.9
03/17/2023 03:00	4,495.8	413.3	4,785.1	104,300.0	499.1	0.62	0.3	1.0
03/17/2023 04:00	4,584.6	1,109.2	5,693.8	104,300.0	593.9	0.71	0.4	1.2
03/17/2023 05:00	4,585.1	1,207.7	5,792.8	104,300.0	604.2	0.72	0.4	1.2
03/17/2023 06:00	4,585.0	933.6	5,518.6	104,300.0	575.6	0.69	0.3	1.2
03/17/2023 07:00	3,959.5	171.5	4,057.3	104,300.0	423.2	0.52	0.3	0.9
03/17/2023 08:00	3,240.0	0.0	3,240.0	104,300.0	337.9	0.41	0.2	0.7
03/17/2023 09:00	2,938.1	0.0	2,938.1	104,300.0	306.4	0.37	0.2	0.6
03/17/2023 10:00	2,951.0	0.0	2,951.0	104,300.0	307.8	0.37	0.2	0.6
03/17/2023 11:00	2,959.4	0.0	2,959.4	104,300.0	308.7	0.37	0.2	0.6
03/17/2023 12:00	2,950.7	0.0	2,950.7	104,300.0	307.8	0.37	0.2	0.6
03/17/2023 13:00	2,949.0	0.0	2,949.0	104,300.0	307.6	0.37	0.2	0.6
03/17/2023 14:00	2,930.8	0.0	2,930.8	104,300.0	305.7	0.37	0.2	0.6
03/17/2023 15:00	2,940.6	0.0	2,940.6	104,300.0	306.7	0.37	0.2	0.6
03/17/2023 16:00	3,622.0	0.3	3,622.0	104,300.0	377.8	0.45	0.2	0.8
03/17/2023 17:00	3,502.0	42.5	3,510.5	104,300.0	366.1	0.44	0.2	0.7
03/17/2023 18:00	4,429.6	811.7	5,241.3	104,300.0	546.7	0.66	0.3	1.1
03/17/2023 19:00	4,440.6	1,083.0	5,523.6	104,300.0	576.1	0.69	0.3	1.2
03/17/2023 20:00	4,463.8	813.3	5,277.1	104,300.0	550.4	0.66	0.3	1.1
03/17/2023 21:00	4,484.3	955.3	5,439.6	104,300.0	567.4	0.68	0.3	1.1
03/17/2023 22:00	3,861.2	93.3	3,886.4	104,300.0	405.4	0.50	0.2	0.8
03/17/2023 23:00	3,110.2	0.0	3,110.2	104,300.0	324.4	0.39	0.2	0.6
Average/Sum#:	3,562.8	331.9	3,881.7	104,300.0	404.9	0.51	0.3	0.9
Minimum:	804.0	0.0	804.0	104,300.0	83.9	0.37	0.2	0.6
Maximum:	4,585.1	1,207.7	5,792.8	104,300.0	604.2	0.72	0.4	1.2
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2023 00:00	2,933.1	0.0	2,933.1	104,300.0	305.9	0.37	0.2	0.6
03/18/2023 01:00	2,940.9	0.0	2,940.9	104,300.0	306.7	0.37	0.2	0.6
03/18/2023 02:00	2,948.2	0.0	2,948.2	104,300.0	307.5	0.37	0.2	0.6
03/18/2023 03:00	2,939.6	0.0	2,939.6	104,300.0	306.6	0.37	0.2	0.6
03/18/2023 04:00	2,934.8	0.0	2,934.8	104,300.0	306.1	0.37	0.2	0.6
03/18/2023 05:00	2,943.9	0.0	2,943.9	104,300.0	307.0	0.37	0.2	0.6
03/18/2023 06:00	2,938.1	0.0	2,938.1	104,300.0	306.4	0.37	0.2	0.6
03/18/2023 07:00	2,938.4	0.0	2,938.4	104,300.0	306.5	0.37	0.2	0.6
03/18/2023 08:00	2,940.0	0.0	2,940.0	104,300.0	306.6	0.37	0.2	0.6
03/18/2023 09:00	2,983.2	0.0	2,983.2	104,300.0	311.1	0.37	0.2	0.6
03/18/2023 10:00	2,972.4	0.0	2,972.4	104,300.0	310.0	0.37	0.2	0.6
03/18/2023 11:00	2,964.5	0.0	2,964.5	104,300.0	309.2	0.37	0.2	0.6
03/18/2023 12:00	2,948.7	0.0	2,948.7	104,300.0	307.5	0.37	0.2	0.6
03/18/2023 13:00	2,937.0	0.0	2,937.0	104,300.0	306.3	0.37	0.2	0.6
03/18/2023 14:00	2,937.0	0.0	2,937.0	104,300.0	306.3	0.37	0.2	0.6
03/18/2023 15:00	3,358.4	0.1	3,358.4	104,300.0	350.3	0.42	0.2	0.7
03/18/2023 16:00	3,393.4	0.0	3,393.4	104,300.0	353.9	0.43	0.2	0.7
03/18/2023 17:00	4,398.1	562.2	4,847.9	104,300.0	505.6	0.62	0.3	1.0
03/18/2023 18:00	4,443.4	1,301.9	5,745.3	104,300.0	599.2	0.72	0.4	1.2
03/18/2023 19:00	4,445.9	851.4	5,297.3	104,300.0	552.5	0.66	0.3	1.1
03/18/2023 20:00	4,408.7	798.8	5,207.5	104,300.0	543.1	0.65	0.3	1.1
03/18/2023 21:00	3,916.4	126.7	3,945.5	104,300.0	411.5	0.51	0.3	0.8
03/18/2023 22:00	2,981.0	0.0	2,981.0	104,300.0	310.9	0.37	0.2	0.6
03/18/2023 23:00	2,916.0	0.0	2,916.0	104,300.0	304.1	0.36	0.2	0.6
Average/Sum#:	3,269.2	151.7	3,412.2	104,300.0	355.9	0.43	0.2	0.7
Minimum:	2,916.0	0.0	2,916.0	104,300.0	304.1	0.36	0.2	0.6
Maximum:	4,445.9	1,301.9	5,745.3	104,300.0	599.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2023 00:00	2,921.4	0.0	2,921.4	104,300.0	304.7	0.37	0.2	0.6
03/19/2023 01:00	2,904.9	0.0	2,904.9	104,300.0	303.0	0.36	0.2	0.6
03/19/2023 02:00	2,928.9	0.0	2,928.9	104,300.0	305.5	0.37	0.2	0.6
03/19/2023 03:00	2,941.4	0.0	2,941.4	104,300.0	306.8	0.37	0.2	0.6
03/19/2023 04:00	2,942.0	0.0	2,942.0	104,300.0	306.9	0.37	0.2	0.6
03/19/2023 05:00	2,945.8	0.0	2,945.8	104,300.0	307.2	0.37	0.2	0.6
03/19/2023 06:00	2,947.8	0.0	2,947.8	104,300.0	307.5	0.37	0.2	0.6
03/19/2023 07:00	2,946.7	0.0	2,946.7	104,300.0	307.3	0.37	0.2	0.6
03/19/2023 08:00	2,935.6	0.0	2,935.6	104,300.0	306.2	0.37	0.2	0.6
03/19/2023 09:00	2,912.4	0.0	2,912.4	104,300.0	303.8	0.36	0.2	0.6
03/19/2023 10:00	2,895.9	0.0	2,895.9	104,300.0	302.0	0.36	0.2	0.6
03/19/2023 11:00	2,909.6	0.0	2,909.6	104,300.0	303.5	0.36	0.2	0.6
03/19/2023 12:00	3,142.1	0.0	3,142.1	104,300.0	327.7	0.39	0.2	0.7
03/19/2023 13:00	2,936.9	0.0	2,936.9	104,300.0	306.3	0.37	0.2	0.6
03/19/2023 14:00	2,944.0	0.0	2,944.0	104,300.0	307.1	0.37	0.2	0.6
03/19/2023 15:00	3,702.0	0.0	3,702.0	104,300.0	386.1	0.46	0.2	0.8
03/19/2023 16:00	3,293.8	7.1	3,294.2	104,300.0	343.6	0.41	0.2	0.7
03/19/2023 17:00	4,455.2	773.3	5,228.5	104,300.0	545.3	0.66	0.3	1.1
03/19/2023 18:00	4,455.5	1,071.4	5,526.9	104,300.0	576.5	0.69	0.3	1.2
03/19/2023 19:00	4,458.5	888.6	5,347.1	104,300.0	557.7	0.67	0.3	1.1
03/19/2023 20:00	4,466.1	931.8	5,397.9	104,300.0	563.0	0.68	0.3	1.1
03/19/2023 21:00	4,501.3	646.8	5,148.1	104,300.0	536.9	0.64	0.3	1.1
03/19/2023 22:00	4,481.0	532.7	5,013.7	104,300.0	522.9	0.63	0.3	1.0
03/19/2023 23:00	4,475.7	591.6	5,067.3	104,300.0	528.5	0.63	0.3	1.1
Average/Sum#:	3,435.2	226.8	3,661.7	104,300.0	381.9	0.46	0.2	0.8
Minimum:	2,895.9	0.0	2,895.9	104,300.0	302.0	0.36	0.2	0.6
Maximum:	4,501.3	1,071.4	5,526.9	104,300.0	576.5	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2023 00:00	4,115.7	219.0	4,231.8	104,300.0	441.4	0.54	0.3	0.9
03/20/2023 01:00	3,126.5	0.0	3,126.5	104,300.0	326.1	0.39	0.2	0.7
03/20/2023 02:00	2,948.4	0.0	2,948.4	104,300.0	307.5	0.37	0.2	0.6
03/20/2023 03:00	2,953.9	0.0	2,953.9	104,300.0	308.1	0.37	0.2	0.6
03/20/2023 04:00	2,957.6	0.0	2,957.6	104,300.0	308.5	0.37	0.2	0.6
03/20/2023 05:00	3,237.2	0.0	3,237.2	104,300.0	337.6	0.41	0.2	0.7
03/20/2023 06:00	2,960.4	0.0	2,960.4	104,300.0	308.8	0.37	0.2	0.6
03/20/2023 07:00	3,286.1	0.0	3,286.1	104,300.0	342.7	0.41	0.2	0.7
03/20/2023 08:00	3,173.4	0.0	3,173.4	104,300.0	331.0	0.40	0.2	0.7
03/20/2023 09:00	2,941.8	0.0	2,941.8	104,300.0	306.8	0.37	0.2	0.6
03/20/2023 10:00	2,944.1	0.0	2,944.1	104,300.0	307.1	0.37	0.2	0.6
03/20/2023 11:00	2,947.2	0.0	2,947.2	104,300.0	307.4	0.37	0.2	0.6
03/20/2023 12:00	2,946.0	0.0	2,946.0	104,300.0	307.3	0.37	0.2	0.6
03/20/2023 13:00	2,952.1	0.0	2,952.1	104,300.0	307.9	0.37	0.2	0.6
03/20/2023 14:00	2,945.9	0.0	2,945.9	104,300.0	307.3	0.37	0.2	0.6
03/20/2023 15:00	2,948.4	0.0	2,948.4	104,300.0	307.5	0.37	0.2	0.6
03/20/2023 16:00	3,827.5	0.3	3,827.5	104,300.0	399.2	0.48	0.2	0.8
03/20/2023 17:00	3,918.3	49.3	3,937.0	104,300.0	410.6	0.50	0.2	0.8
03/20/2023 18:00	4,480.1	1,027.1	5,507.2	104,300.0	574.4	0.69	0.3	1.1
03/20/2023 19:00	4,488.9	992.1	5,481.0	104,300.0	571.7	0.69	0.3	1.1
03/20/2023 20:00	3,636.0	563.9	3,820.4	104,300.0	398.5	0.72	0.4	1.2
03/20/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/20/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/20/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,320.7	135.8	3,432.1	104,300.0	358.0	0.44	0.2	0.7
Minimum:	2,941.8	0.0	2,941.8	104,300.0	306.8	0.37	0.2	0.6
Maximum:	4,488.9	1,027.1	5,507.2	104,300.0	574.4	0.72	0.4	1.2
%SI	12.50	12.50	12.50	0.00	12.50	12.50	12.50	12.50

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/21/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/22/2023 16:00	2,613.3	0.0	2,613.3	104,300.0	272.6	0.00	0.0	0.0
03/22/2023 17:00	4,032.1	537.8	4,344.0	104,300.0	453.1	0.66	0.3	1.1
03/22/2023 18:00	4,535.2	1,233.8	5,769.0	104,300.0	601.7	0.72	0.4	1.2
03/22/2023 19:00	4,533.0	1,185.6	5,718.6	104,300.0	596.4	0.71	0.4	1.2
03/22/2023 20:00	4,540.7	1,045.9	5,586.6	104,300.0	582.7	0.70	0.3	1.2
03/22/2023 21:00	4,551.8	645.3	5,197.1	104,300.0	542.1	0.65	0.3	1.1
03/22/2023 22:00	4,306.5	195.5	4,408.2	104,300.0	459.8	0.56	0.3	0.9
03/22/2023 23:00	3,215.8	0.0	3,215.8	104,300.0	335.4	0.43	0.2	0.7
Average/Sum#:	4,041.1	605.5	4,606.6	104,300.0	480.5	0.63	0.3	1.1
Minimum:	2,613.3	0.0	2,613.3	104,300.0	272.6	0.43	0.2	0.7
Maximum:	4,551.8	1,233.8	5,769.0	104,300.0	601.7	0.72	0.4	1.2
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/23/2023 14:00	309.6	0.0	309.6	104,300.0	32.3	0.00	0.0	0.0
03/23/2023 15:00	2,601.6	0.0	2,601.6	104,300.0	271.3	0.36	0.2	0.6
03/23/2023 16:00	3,621.3	118.4	3,654.5	104,300.0	381.2	0.47	0.2	0.8
03/23/2023 17:00	4,514.3	419.3	4,933.6	104,300.0	514.6	0.62	0.3	1.0
03/23/2023 18:00	4,538.3	389.8	4,928.1	104,300.0	514.0	0.62	0.3	1.0
03/23/2023 19:00	4,558.7	342.7	4,901.4	104,300.0	511.2	0.61	0.3	1.0
03/23/2023 20:00	4,562.4	319.4	4,881.8	104,300.0	509.2	0.61	0.3	1.0
03/23/2023 21:00	4,570.2	296.1	4,866.3	104,300.0	507.6	0.61	0.3	1.0
03/23/2023 22:00	3,817.0	66.1	3,835.5	104,300.0	400.0	0.50	0.3	0.8
03/23/2023 23:00	1,556.1	0.0	1,556.1	104,300.0	162.3	0.00	0.0	0.0
Average/Sum#:	3,465.0	195.2	3,646.9	104,300.0	380.4	0.55	0.3	0.9
Minimum:	309.6	0.0	309.6	104,300.0	32.3	0.36	0.2	0.6
Maximum:	4,570.2	419.3	4,933.6	104,300.0	514.6	0.62	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/24/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/25/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/26/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/27/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/28/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:00 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/29/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:01 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/30/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:01 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
03/31/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023 00:00	2,973.9	0.0	2,973.9	105,200.0	312.9	0.4	0.2	0.6
01/01/2023 01:00	2,953.1	0.0	2,953.1	105,200.0	310.7	0.4	0.2	0.6
01/01/2023 02:00	2,959.5	0.0	2,959.5	105,200.0	311.3	0.4	0.2	0.6
01/01/2023 03:00	2,954.8	0.0	2,954.8	105,200.0	310.8	0.4	0.2	0.6
01/01/2023 04:00	2,940.9	0.0	2,940.9	105,200.0	309.4	0.4	0.2	0.6
01/01/2023 05:00	2,934.7	0.0	2,934.7	105,200.0	308.7	0.4	0.2	0.6
01/01/2023 06:00	2,933.7	0.0	2,933.7	105,200.0	308.6	0.4	0.2	0.6
01/01/2023 07:00	2,934.8	0.0	2,934.8	105,200.0	308.7	0.4	0.2	0.6
01/01/2023 08:00	2,929.7	0.0	2,929.7	105,200.0	308.2	0.4	0.2	0.6
01/01/2023 09:00	2,928.1	0.0	2,928.1	105,200.0	308.0	0.4	0.2	0.6
01/01/2023 10:00	2,921.7	0.0	2,921.7	105,200.0	307.4	0.4	0.2	0.6
01/01/2023 11:00	2,908.1	0.0	2,908.1	105,200.0	305.9	0.4	0.2	0.6
01/01/2023 12:00	2,903.5	0.0	2,903.5	105,200.0	305.4	0.4	0.2	0.6
01/01/2023 13:00	2,907.6	0.0	2,907.6	105,200.0	305.9	0.4	0.2	0.6
01/01/2023 14:00	2,910.4	0.0	2,910.4	105,200.0	306.2	0.4	0.2	0.6
01/01/2023 15:00	2,919.6	0.0	2,919.6	105,200.0	307.1	0.4	0.2	0.6
01/01/2023 16:00	2,926.5	0.0	2,926.5	105,200.0	307.9	0.4	0.2	0.6
01/01/2023 17:00	2,937.4	0.0	2,937.4	105,200.0	309.0	0.4	0.2	0.6
01/01/2023 18:00	2,948.0	0.0	2,948.0	105,200.0	310.1	0.4	0.2	0.6
01/01/2023 19:00	2,954.3	0.0	2,954.3	105,200.0	310.8	0.4	0.2	0.6
01/01/2023 20:00	2,969.7	0.0	2,969.7	105,200.0	312.4	0.4	0.2	0.6
01/01/2023 21:00	2,966.4	0.0	2,966.4	105,200.0	312.1	0.4	0.2	0.6
01/01/2023 22:00	2,959.8	0.0	2,959.8	105,200.0	311.4	0.4	0.2	0.6
01/01/2023 23:00	2,955.6	0.0	2,955.6	105,200.0	310.9	0.4	0.2	0.6
Average/Sum#:	2,938.8	0.0	2,938.8	105,200.0	309.2	0.4	0.2	0.6
Minimum:	2,903.5	0.0	2,903.5	105,200.0	305.4	0.4	0.2	0.6
Maximum:	2,973.9	0.0	2,973.9	105,200.0	312.9	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2023 00:00	2,966.2	0.0	2,966.2	105,200.0	312.0	0.4	0.2	0.6
01/02/2023 01:00	2,966.8	0.0	2,966.8	105,200.0	312.1	0.4	0.2	0.6
01/02/2023 02:00	2,968.0	0.0	2,968.0	105,200.0	312.2	0.4	0.2	0.6
01/02/2023 03:00	2,962.5	0.0	2,962.5	105,200.0	311.7	0.4	0.2	0.6
01/02/2023 04:00	2,956.7	0.0	2,956.7	105,200.0	311.0	0.4	0.2	0.6
01/02/2023 05:00	2,965.6	0.0	2,965.6	105,200.0	312.0	0.4	0.2	0.6
01/02/2023 06:00	3,005.1	0.0	3,005.1	105,200.0	316.1	0.4	0.2	0.6
01/02/2023 07:00	4,719.3	0.0	4,719.3	105,200.0	496.5	0.6	0.3	1.0
01/02/2023 08:00	3,365.0	0.0	3,365.0	105,200.0	354.0	0.4	0.2	0.7
01/02/2023 09:00	2,953.4	0.0	2,953.4	105,200.0	310.7	0.4	0.2	0.6
01/02/2023 10:00	3,414.6	0.0	3,414.6	105,200.0	359.2	0.4	0.2	0.7
01/02/2023 11:00	3,496.7	0.0	3,496.7	105,200.0	367.9	0.4	0.2	0.7
01/02/2023 12:00	3,859.8	0.0	3,859.8	105,200.0	406.1	0.5	0.2	0.8
01/02/2023 13:00	4,572.5	319.4	4,722.6	105,200.0	496.8	0.6	0.3	1.0
01/02/2023 14:00	4,943.6	1,306.2	6,249.8	105,200.0	657.5	0.8	0.4	1.3
01/02/2023 15:00	4,923.5	1,259.3	6,182.8	105,200.0	650.4	0.8	0.4	1.3
01/02/2023 16:00	4,923.3	1,255.6	6,178.9	105,200.0	650.0	0.8	0.4	1.3
01/02/2023 17:00	4,932.7	1,246.9	6,179.6	105,200.0	650.1	0.8	0.4	1.3
01/02/2023 18:00	4,937.6	1,230.8	6,168.4	105,200.0	648.9	0.8	0.4	1.3
01/02/2023 19:00	4,944.0	1,184.9	6,128.9	105,200.0	644.8	0.8	0.4	1.3
01/02/2023 20:00	4,945.6	1,147.2	6,092.8	105,200.0	641.0	0.8	0.4	1.3
01/02/2023 21:00	4,970.3	1,069.4	6,039.7	105,200.0	635.4	0.8	0.4	1.3
01/02/2023 22:00	4,968.2	924.6	5,892.8	105,200.0	619.9	0.7	0.4	1.2
01/02/2023 23:00	4,958.9	846.2	5,805.1	105,200.0	610.7	0.7	0.4	1.2
Average/Sum#:	4,025.8	491.3	4,510.0	105,200.0	474.5	0.6	0.3	0.9
Minimum:	2,953.4	0.0	2,953.4	105,200.0	310.7	0.4	0.2	0.6
Maximum:	4,970.3	1,306.2	6,249.8	105,200.0	657.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2023 00:00	4,948.8	972.8	5,921.6	105,200.0	623.0	0.7	0.4	1.2
01/03/2023 01:00	4,955.4	932.6	5,888.0	105,200.0	619.4	0.7	0.4	1.2
01/03/2023 02:00	4,956.5	933.0	5,889.5	105,200.0	619.6	0.7	0.4	1.2
01/03/2023 03:00	4,968.5	967.5	5,936.0	105,200.0	624.5	0.7	0.4	1.2
01/03/2023 04:00	4,959.0	1,051.1	6,010.1	105,200.0	632.3	0.8	0.4	1.3
01/03/2023 05:00	4,960.5	1,099.5	6,060.0	105,200.0	637.5	0.8	0.4	1.3
01/03/2023 06:00	4,972.3	1,368.5	6,340.8	105,200.0	667.1	0.8	0.4	1.3
01/03/2023 07:00	4,986.4	1,119.8	6,106.2	105,200.0	642.4	0.8	0.4	1.3
01/03/2023 08:00	4,986.9	500.4	5,487.3	105,200.0	577.3	0.7	0.3	1.2
01/03/2023 09:00	4,965.7	560.7	5,526.4	105,200.0	581.4	0.7	0.3	1.2
01/03/2023 10:00	4,956.2	305.7	5,261.9	105,200.0	553.6	0.7	0.3	1.1
01/03/2023 11:00	4,930.7	276.0	5,206.7	105,200.0	547.7	0.7	0.3	1.1
01/03/2023 12:00	4,939.6	408.0	5,347.6	105,200.0	562.6	0.7	0.3	1.1
01/03/2023 13:00	4,945.4	372.3	5,317.7	105,200.0	559.4	0.7	0.3	1.1
01/03/2023 14:00	4,941.4	524.1	5,465.5	105,200.0	575.0	0.7	0.3	1.1
01/03/2023 15:00	4,946.7	1,253.5	6,200.2	105,200.0	652.3	0.8	0.4	1.3
01/03/2023 16:00	4,941.9	1,105.1	6,047.0	105,200.0	636.1	0.8	0.4	1.3
01/03/2023 17:00	4,921.4	1,103.2	6,024.6	105,200.0	633.8	0.8	0.4	1.3
01/03/2023 18:00	4,924.1	1,104.1	6,028.2	105,200.0	634.2	0.8	0.4	1.3
01/03/2023 19:00	4,936.3	1,039.8	5,976.1	105,200.0	628.7	0.8	0.4	1.3
01/03/2023 20:00	4,928.1	1,199.5	6,127.6	105,200.0	644.6	0.8	0.4	1.3
01/03/2023 21:00	4,930.0	1,183.6	6,113.6	105,200.0	643.2	0.8	0.4	1.3
01/03/2023 22:00	4,933.7	1,091.7	6,025.4	105,200.0	633.9	0.8	0.4	1.3
01/03/2023 23:00	4,939.1	707.8	5,646.9	105,200.0	594.1	0.7	0.4	1.2
Average/Sum#:	4,948.9	882.5	5,831.5	105,200.0	613.5	0.8	0.4	1.2
Minimum:	4,921.4	276.0	5,206.7	105,200.0	547.7	0.7	0.3	1.1
Maximum:	4,986.9	1,368.5	6,340.8	105,200.0	667.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2023 00:00	4,893.6	0.2	4,893.6	105,200.0	514.8	0.6	0.3	1.0
01/04/2023 01:00	4,925.4	0.0	4,925.4	105,200.0	518.2	0.6	0.3	1.0
01/04/2023 02:00	4,927.3	0.0	4,927.3	105,200.0	518.4	0.6	0.3	1.0
01/04/2023 03:00	4,929.3	0.0	4,929.3	105,200.0	518.6	0.6	0.3	1.0
01/04/2023 04:00	4,924.2	0.0	4,924.2	105,200.0	518.0	0.6	0.3	1.0
01/04/2023 05:00	4,923.8	0.0	4,923.8	105,200.0	518.0	0.6	0.3	1.0
01/04/2023 06:00	4,925.1	0.0	4,925.1	105,200.0	518.1	0.6	0.3	1.0
01/04/2023 07:00	4,939.7	257.4	5,192.0	105,200.0	546.2	0.7	0.3	1.1
01/04/2023 08:00	4,082.5	66.5	4,100.5	105,200.0	431.4	0.5	0.3	0.9
01/04/2023 09:00	3,197.3	0.0	3,197.3	105,200.0	336.4	0.4	0.2	0.7
01/04/2023 10:00	2,920.3	0.0	2,920.3	105,200.0	307.2	0.4	0.2	0.6
01/04/2023 11:00	2,948.2	0.0	2,948.2	105,200.0	310.2	0.4	0.2	0.6
01/04/2023 12:00	2,970.2	0.0	2,970.2	105,200.0	312.5	0.4	0.2	0.6
01/04/2023 13:00	2,957.7	0.0	2,957.7	105,200.0	311.2	0.4	0.2	0.6
01/04/2023 14:00	2,931.2	0.0	2,931.2	105,200.0	308.4	0.4	0.2	0.6
01/04/2023 15:00	2,925.0	0.0	2,925.0	105,200.0	307.7	0.4	0.2	0.6
01/04/2023 16:00	2,905.5	0.0	2,905.5	105,200.0	305.7	0.4	0.2	0.6
01/04/2023 17:00	2,884.8	0.0	2,884.8	105,200.0	303.5	0.4	0.2	0.6
01/04/2023 18:00	2,906.9	0.0	2,906.9	105,200.0	305.8	0.4	0.2	0.6
01/04/2023 19:00	2,937.0	0.0	2,937.0	105,200.0	309.0	0.4	0.2	0.6
01/04/2023 20:00	2,920.1	0.0	2,920.1	105,200.0	307.2	0.4	0.2	0.6
01/04/2023 21:00	2,920.4	0.0	2,920.4	105,200.0	307.2	0.4	0.2	0.6
01/04/2023 22:00	2,909.4	0.0	2,909.4	105,200.0	306.1	0.4	0.2	0.6
01/04/2023 23:00	2,902.5	0.0	2,902.5	105,200.0	305.3	0.4	0.2	0.6
Average/Sum#:	3,650.3	13.5	3,661.6	105,200.0	385.2	0.5	0.2	0.8
Minimum:	2,884.8	0.0	2,884.8	105,200.0	303.5	0.4	0.2	0.6
Maximum:	4,939.7	257.4	5,192.0	105,200.0	546.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2023 00:00	2,949.1	0.0	2,949.1	105,200.0	310.2	0.4	0.2	0.6
01/05/2023 01:00	2,951.0	0.0	2,951.0	105,200.0	310.4	0.4	0.2	0.6
01/05/2023 02:00	2,968.0	0.0	2,968.0	105,200.0	312.2	0.4	0.2	0.6
01/05/2023 03:00	2,968.8	0.0	2,968.8	105,200.0	312.3	0.4	0.2	0.6
01/05/2023 04:00	2,965.9	0.0	2,965.9	105,200.0	312.0	0.4	0.2	0.6
01/05/2023 05:00	2,946.9	0.0	2,946.9	105,200.0	310.0	0.4	0.2	0.6
01/05/2023 06:00	2,949.6	0.0	2,949.6	105,200.0	310.3	0.4	0.2	0.6
01/05/2023 07:00	2,950.5	0.0	2,950.5	105,200.0	310.4	0.4	0.2	0.6
01/05/2023 08:00	2,956.2	0.0	2,956.2	105,200.0	311.0	0.4	0.2	0.6
01/05/2023 09:00	2,951.5	0.0	2,951.5	105,200.0	310.5	0.4	0.2	0.6
01/05/2023 10:00	2,938.8	0.0	2,938.8	105,200.0	309.2	0.4	0.2	0.6
01/05/2023 11:00	2,945.7	0.0	2,945.7	105,200.0	309.9	0.4	0.2	0.6
01/05/2023 12:00	2,968.9	0.0	2,968.9	105,200.0	312.3	0.4	0.2	0.6
01/05/2023 13:00	2,976.6	0.0	2,976.6	105,200.0	313.1	0.4	0.2	0.6
01/05/2023 14:00	2,976.1	0.0	2,976.1	105,200.0	313.1	0.4	0.2	0.6
01/05/2023 15:00	4,086.5	1.8	4,086.8	105,200.0	429.9	0.5	0.3	0.9
01/05/2023 16:00	3,746.3	44.2	3,754.3	105,200.0	395.0	0.5	0.2	0.8
01/05/2023 17:00	4,871.0	455.5	5,326.5	105,200.0	560.3	0.7	0.3	1.1
01/05/2023 18:00	4,518.8	189.0	4,632.2	105,200.0	487.3	0.6	0.3	1.0
01/05/2023 19:00	3,308.0	0.0	3,308.0	105,200.0	348.0	0.4	0.2	0.7
01/05/2023 20:00	2,972.7	0.0	2,972.7	105,200.0	312.7	0.4	0.2	0.6
01/05/2023 21:00	2,981.0	0.0	2,981.0	105,200.0	313.6	0.4	0.2	0.6
01/05/2023 22:00	2,975.9	0.0	2,975.9	105,200.0	313.1	0.4	0.2	0.6
01/05/2023 23:00	2,974.5	0.0	2,974.5	105,200.0	312.9	0.4	0.2	0.6
Average/Sum#:	3,199.9	28.8	3,224.0	105,200.0	339.2	0.4	0.2	0.7
Minimum:	2,938.8	0.0	2,938.8	105,200.0	309.2	0.4	0.2	0.6
Maximum:	4,871.0	455.5	5,326.5	105,200.0	560.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2023 00:00	2,979.2	0.0	2,979.2	105,200.0	313.4	0.4	0.2	0.6
01/06/2023 01:00	2,973.7	0.0	2,973.7	105,200.0	312.8	0.4	0.2	0.6
01/06/2023 02:00	2,983.6	0.0	2,983.6	105,200.0	313.9	0.4	0.2	0.6
01/06/2023 03:00	2,992.0	0.0	2,992.0	105,200.0	314.8	0.4	0.2	0.6
01/06/2023 04:00	2,992.6	0.0	2,992.6	105,200.0	314.8	0.4	0.2	0.6
01/06/2023 05:00	2,987.9	0.0	2,987.9	105,200.0	314.3	0.4	0.2	0.6
01/06/2023 06:00	2,983.2	0.0	2,983.2	105,200.0	313.8	0.4	0.2	0.6
01/06/2023 07:00	2,975.9	0.0	2,975.9	105,200.0	313.1	0.4	0.2	0.6
01/06/2023 08:00	2,980.3	0.0	2,980.3	105,200.0	313.5	0.4	0.2	0.6
01/06/2023 09:00	2,977.1	0.0	2,977.1	105,200.0	313.2	0.4	0.2	0.6
01/06/2023 10:00	2,972.1	0.0	2,972.1	105,200.0	312.7	0.4	0.2	0.6
01/06/2023 11:00	2,967.6	0.0	2,967.6	105,200.0	312.2	0.4	0.2	0.6
01/06/2023 12:00	2,971.5	0.0	2,971.5	105,200.0	312.6	0.4	0.2	0.6
01/06/2023 13:00	2,971.1	0.0	2,971.1	105,200.0	312.6	0.4	0.2	0.6
01/06/2023 14:00	2,972.6	0.0	2,972.6	105,200.0	312.7	0.4	0.2	0.6
01/06/2023 15:00	3,497.3	0.0	3,497.3	105,200.0	367.9	0.4	0.2	0.7
01/06/2023 16:00	3,854.9	0.0	3,854.9	105,200.0	405.5	0.5	0.2	0.8
01/06/2023 17:00	4,738.2	114.0	4,803.2	105,200.0	505.3	0.6	0.3	1.0
01/06/2023 18:00	4,884.2	365.8	5,250.0	105,200.0	552.3	0.7	0.3	1.1
01/06/2023 19:00	4,891.5	357.4	5,248.9	105,200.0	552.2	0.7	0.3	1.1
01/06/2023 20:00	3,969.0	80.3	3,987.5	105,200.0	419.5	0.5	0.3	0.9
01/06/2023 21:00	3,263.9	0.0	3,263.9	105,200.0	343.4	0.4	0.2	0.7
01/06/2023 22:00	2,964.9	0.0	2,964.9	105,200.0	311.9	0.4	0.2	0.6
01/06/2023 23:00	2,974.7	0.0	2,974.7	105,200.0	312.9	0.4	0.2	0.6
Average/Sum#:	3,321.6	38.2	3,355.2	105,200.0	353.0	0.4	0.2	0.7
Minimum:	2,964.9	0.0	2,964.9	105,200.0	311.9	0.4	0.2	0.6
Maximum:	4,891.5	365.8	5,250.0	105,200.0	552.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2023 00:00	2,977.8	0.0	2,977.8	105,200.0	313.3	0.4	0.2	0.6
01/07/2023 01:00	2,979.7	0.0	2,979.7	105,200.0	313.5	0.4	0.2	0.6
01/07/2023 02:00	2,963.8	0.0	2,963.8	105,200.0	311.8	0.4	0.2	0.6
01/07/2023 03:00	2,959.7	0.0	2,959.7	105,200.0	311.4	0.4	0.2	0.6
01/07/2023 04:00	2,939.5	0.0	2,939.5	105,200.0	309.2	0.4	0.2	0.6
01/07/2023 05:00	2,943.7	0.0	2,943.7	105,200.0	309.7	0.4	0.2	0.6
01/07/2023 06:00	2,952.6	0.0	2,952.6	105,200.0	310.6	0.4	0.2	0.6
01/07/2023 07:00	2,967.8	0.0	2,967.8	105,200.0	312.2	0.4	0.2	0.6
01/07/2023 08:00	2,955.2	0.0	2,955.2	105,200.0	310.9	0.4	0.2	0.6
01/07/2023 09:00	2,938.1	0.0	2,938.1	105,200.0	309.1	0.4	0.2	0.6
01/07/2023 10:00	2,936.3	0.0	2,936.3	105,200.0	308.9	0.4	0.2	0.6
01/07/2023 11:00	2,943.0	0.0	2,943.0	105,200.0	309.6	0.4	0.2	0.6
01/07/2023 12:00	2,958.9	0.0	2,958.9	105,200.0	311.3	0.4	0.2	0.6
01/07/2023 13:00	2,952.7	0.0	2,952.7	105,200.0	310.6	0.4	0.2	0.6
01/07/2023 14:00	2,962.8	0.0	2,962.8	105,200.0	311.7	0.4	0.2	0.6
01/07/2023 15:00	2,952.9	0.0	2,952.9	105,200.0	310.6	0.4	0.2	0.6
01/07/2023 16:00	2,953.3	0.0	2,953.3	105,200.0	310.7	0.4	0.2	0.6
01/07/2023 17:00	2,947.7	0.0	2,947.7	105,200.0	310.1	0.4	0.2	0.6
01/07/2023 18:00	2,930.2	0.0	2,930.2	105,200.0	308.3	0.4	0.2	0.6
01/07/2023 19:00	2,918.0	0.0	2,918.0	105,200.0	307.0	0.4	0.2	0.6
01/07/2023 20:00	2,906.2	0.0	2,906.2	105,200.0	305.7	0.4	0.2	0.6
01/07/2023 21:00	2,902.4	0.0	2,902.4	105,200.0	305.3	0.4	0.2	0.6
01/07/2023 22:00	2,915.2	0.0	2,915.2	105,200.0	306.7	0.4	0.2	0.6
01/07/2023 23:00	2,911.9	0.0	2,911.9	105,200.0	306.3	0.4	0.2	0.6
Average/Sum#:	2,944.6	0.0	2,944.6	105,200.0	309.8	0.4	0.2	0.6
Minimum:	2,902.4	0.0	2,902.4	105,200.0	305.3	0.4	0.2	0.6
Maximum:	2,979.7	0.0	2,979.7	105,200.0	313.5	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2023 00:00	2,897.5	0.0	2,897.5	105,200.0	304.8	0.4	0.2	0.6
01/08/2023 01:00	2,913.8	0.0	2,913.8	105,200.0	306.5	0.4	0.2	0.6
01/08/2023 02:00	2,929.2	0.0	2,929.2	105,200.0	308.2	0.4	0.2	0.6
01/08/2023 03:00	2,927.3	0.0	2,927.3	105,200.0	308.0	0.4	0.2	0.6
01/08/2023 04:00	2,926.9	0.0	2,926.9	105,200.0	307.9	0.4	0.2	0.6
01/08/2023 05:00	2,931.7	0.0	2,931.7	105,200.0	308.4	0.4	0.2	0.6
01/08/2023 06:00	2,943.7	0.0	2,943.7	105,200.0	309.7	0.4	0.2	0.6
01/08/2023 07:00	2,973.8	0.0	2,973.8	105,200.0	312.8	0.4	0.2	0.6
01/08/2023 08:00	2,981.0	0.0	2,981.0	105,200.0	313.6	0.4	0.2	0.6
01/08/2023 09:00	2,984.3	0.0	2,984.3	105,200.0	313.9	0.4	0.2	0.6
01/08/2023 10:00	2,972.3	0.0	2,972.3	105,200.0	312.7	0.4	0.2	0.6
01/08/2023 11:00	2,946.2	0.0	2,946.2	105,200.0	309.9	0.4	0.2	0.6
01/08/2023 12:00	2,944.6	0.0	2,944.6	105,200.0	309.8	0.4	0.2	0.6
01/08/2023 13:00	2,947.8	0.0	2,947.8	105,200.0	310.1	0.4	0.2	0.6
01/08/2023 14:00	2,949.4	0.0	2,949.4	105,200.0	310.3	0.4	0.2	0.6
01/08/2023 15:00	3,460.9	0.2	3,460.9	105,200.0	364.1	0.4	0.2	0.7
01/08/2023 16:00	3,735.9	0.0	3,735.9	105,200.0	393.0	0.5	0.2	0.8
01/08/2023 17:00	4,500.8	237.8	4,624.5	105,200.0	486.5	0.6	0.3	1.0
01/08/2023 18:00	4,820.4	497.2	5,317.6	105,200.0	559.4	0.7	0.3	1.1
01/08/2023 19:00	4,822.0	439.7	5,261.7	105,200.0	553.5	0.7	0.3	1.1
01/08/2023 20:00	4,821.6	480.1	5,301.7	105,200.0	557.7	0.7	0.3	1.1
01/08/2023 21:00	4,495.6	212.8	4,606.3	105,200.0	484.6	0.6	0.3	1.0
01/08/2023 22:00	3,057.1	0.0	3,057.1	105,200.0	321.6	0.4	0.2	0.6
01/08/2023 23:00	2,935.7	0.0	2,935.7	105,200.0	308.8	0.4	0.2	0.6
Average/Sum#:	3,367.5	77.8	3,436.3	105,200.0	361.5	0.5	0.2	0.7
Minimum:	2,897.5	0.0	2,897.5	105,200.0	304.8	0.4	0.2	0.6
Maximum:	4,822.0	497.2	5,317.6	105,200.0	559.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2023 00:00	2,949.8	0.0	2,949.8	105,200.0	310.3	0.4	0.2	0.6
01/09/2023 01:00	2,941.6	0.0	2,941.6	105,200.0	309.5	0.4	0.2	0.6
01/09/2023 02:00	2,934.9	0.0	2,934.9	105,200.0	308.8	0.4	0.2	0.6
01/09/2023 03:00	2,923.9	0.0	2,923.9	105,200.0	307.6	0.4	0.2	0.6
01/09/2023 04:00	2,907.1	0.0	2,907.1	105,200.0	305.8	0.4	0.2	0.6
01/09/2023 05:00	2,911.8	0.0	2,911.8	105,200.0	306.3	0.4	0.2	0.6
01/09/2023 06:00	2,935.9	0.0	2,935.9	105,200.0	308.9	0.4	0.2	0.6
01/09/2023 07:00	2,941.0	0.0	2,941.0	105,200.0	309.4	0.4	0.2	0.6
01/09/2023 08:00	2,958.9	0.0	2,958.9	105,200.0	311.3	0.4	0.2	0.6
01/09/2023 09:00	2,966.0	0.0	2,966.0	105,200.0	312.0	0.4	0.2	0.6
01/09/2023 10:00	2,967.6	0.0	2,967.6	105,200.0	312.2	0.4	0.2	0.6
01/09/2023 11:00	2,980.9	0.0	2,980.9	105,200.0	313.6	0.4	0.2	0.6
01/09/2023 12:00	2,987.8	0.0	2,987.8	105,200.0	314.3	0.4	0.2	0.6
01/09/2023 13:00	3,483.4	0.0	3,483.4	105,200.0	366.5	0.4	0.2	0.7
01/09/2023 14:00	3,326.5	0.0	3,326.5	105,200.0	349.9	0.4	0.2	0.7
01/09/2023 15:00	4,675.8	189.9	4,767.0	105,200.0	501.5	0.6	0.3	1.0
01/09/2023 16:00	4,776.4	711.4	5,487.8	105,200.0	577.3	0.7	0.3	1.2
01/09/2023 17:00	4,789.5	724.7	5,514.2	105,200.0	580.1	0.7	0.3	1.2
01/09/2023 18:00	4,799.4	647.6	5,447.0	105,200.0	573.0	0.7	0.3	1.1
01/09/2023 19:00	4,808.6	623.5	5,432.1	105,200.0	571.5	0.7	0.3	1.1
01/09/2023 20:00	4,822.4	613.2	5,435.6	105,200.0	571.8	0.7	0.3	1.1
01/09/2023 21:00	4,360.6	128.4	4,405.5	105,200.0	463.5	0.6	0.3	0.9
01/09/2023 22:00	3,302.1	0.0	3,302.1	105,200.0	347.4	0.4	0.2	0.7
01/09/2023 23:00	2,961.4	0.0	2,961.4	105,200.0	311.5	0.4	0.2	0.6
Average/Sum#:	3,517.2	151.6	3,661.2	105,200.0	385.2	0.5	0.2	0.8
Minimum:	2,907.1	0.0	2,907.1	105,200.0	305.8	0.4	0.2	0.6
Maximum:	4,822.4	724.7	5,514.2	105,200.0	580.1	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2023 00:00	2,957.8	0.0	2,957.8	105,200.0	311.2	0.4	0.2	0.6
01/10/2023 01:00	2,957.2	0.0	2,957.2	105,200.0	311.1	0.4	0.2	0.6
01/10/2023 02:00	2,938.2	0.0	2,938.2	105,200.0	309.1	0.4	0.2	0.6
01/10/2023 03:00	2,938.0	0.0	2,938.0	105,200.0	309.1	0.4	0.2	0.6
01/10/2023 04:00	2,953.4	0.0	2,953.4	105,200.0	310.7	0.4	0.2	0.6
01/10/2023 05:00	2,951.5	0.0	2,951.5	105,200.0	310.5	0.4	0.2	0.6
01/10/2023 06:00	2,935.3	0.0	2,935.3	105,200.0	308.8	0.4	0.2	0.6
01/10/2023 07:00	2,926.2	0.0	2,926.2	105,200.0	307.8	0.4	0.2	0.6
01/10/2023 08:00	2,931.5	0.0	2,931.5	105,200.0	308.4	0.4	0.2	0.6
01/10/2023 09:00	2,923.5	0.0	2,923.5	105,200.0	307.6	0.4	0.2	0.6
01/10/2023 10:00	2,943.8	0.0	2,943.8	105,200.0	309.7	0.4	0.2	0.6
01/10/2023 11:00	2,955.7	0.0	2,955.7	105,200.0	310.9	0.4	0.2	0.6
01/10/2023 12:00	2,956.9	0.0	2,956.9	105,200.0	311.1	0.4	0.2	0.6
01/10/2023 13:00	2,962.9	0.0	2,962.9	105,200.0	311.7	0.4	0.2	0.6
01/10/2023 14:00	2,967.9	0.0	2,967.9	105,200.0	312.2	0.4	0.2	0.6
01/10/2023 15:00	3,471.5	0.0	3,471.5	105,200.0	365.2	0.4	0.2	0.7
01/10/2023 16:00	3,447.4	0.0	3,447.4	105,200.0	362.7	0.4	0.2	0.7
01/10/2023 17:00	4,748.2	313.2	4,983.1	105,200.0	524.2	0.6	0.3	1.1
01/10/2023 18:00	4,898.8	531.4	5,430.2	105,200.0	571.3	0.7	0.3	1.1
01/10/2023 19:00	4,895.9	537.6	5,433.5	105,200.0	571.6	0.7	0.3	1.1
01/10/2023 20:00	4,901.2	460.4	5,361.6	105,200.0	564.0	0.7	0.3	1.1
01/10/2023 21:00	4,904.3	337.6	5,241.9	105,200.0	551.4	0.7	0.3	1.1
01/10/2023 22:00	4,542.7	166.3	4,634.2	105,200.0	487.5	0.6	0.3	1.0
01/10/2023 23:00	3,197.3	0.0	3,197.3	105,200.0	336.4	0.4	0.2	0.7
Average/Sum#:	3,467.0	97.8	3,558.4	105,200.0	374.3	0.5	0.2	0.7
Minimum:	2,923.5	0.0	2,923.5	105,200.0	307.6	0.4	0.2	0.6
Maximum:	4,904.3	537.6	5,433.5	105,200.0	571.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2023 00:00	2,939.2	0.0	2,939.2	105,200.0	309.2	0.4	0.2	0.6
01/11/2023 01:00	2,957.7	0.0	2,957.7	105,200.0	311.2	0.4	0.2	0.6
01/11/2023 02:00	2,979.7	0.0	2,979.7	105,200.0	313.5	0.4	0.2	0.6
01/11/2023 03:00	2,964.0	0.0	2,964.0	105,200.0	311.8	0.4	0.2	0.6
01/11/2023 04:00	2,957.6	0.0	2,957.6	105,200.0	311.1	0.4	0.2	0.6
01/11/2023 05:00	2,960.4	0.0	2,960.4	105,200.0	311.4	0.4	0.2	0.6
01/11/2023 06:00	2,967.9	0.0	2,967.9	105,200.0	312.2	0.4	0.2	0.6
01/11/2023 07:00	2,962.2	0.0	2,962.2	105,200.0	311.6	0.4	0.2	0.6
01/11/2023 08:00	2,958.6	0.0	2,958.6	105,200.0	311.2	0.4	0.2	0.6
01/11/2023 09:00	2,967.0	0.0	2,967.0	105,200.0	312.1	0.4	0.2	0.6
01/11/2023 10:00	2,969.0	0.0	2,969.0	105,200.0	312.3	0.4	0.2	0.6
01/11/2023 11:00	2,967.6	0.0	2,967.6	105,200.0	312.2	0.4	0.2	0.6
01/11/2023 12:00	2,951.8	0.0	2,951.8	105,200.0	310.5	0.4	0.2	0.6
01/11/2023 13:00	2,929.4	0.0	2,929.4	105,200.0	308.2	0.4	0.2	0.6
01/11/2023 14:00	3,430.1	0.0	3,430.1	105,200.0	360.8	0.4	0.2	0.7
01/11/2023 15:00	3,575.3	0.0	3,575.3	105,200.0	376.1	0.5	0.2	0.8
01/11/2023 16:00	4,554.0	316.0	4,753.1	105,200.0	500.0	0.6	0.3	1.0
01/11/2023 17:00	4,908.3	493.5	5,401.8	105,200.0	568.3	0.7	0.3	1.1
01/11/2023 18:00	4,913.8	363.6	5,277.4	105,200.0	555.2	0.7	0.3	1.1
01/11/2023 19:00	4,899.9	336.9	5,236.8	105,200.0	550.9	0.7	0.3	1.1
01/11/2023 20:00	4,521.8	162.4	4,606.2	105,200.0	484.6	0.6	0.3	1.0
01/11/2023 21:00	3,536.2	0.0	3,536.2	105,200.0	372.0	0.4	0.2	0.7
01/11/2023 22:00	2,956.4	0.0	2,956.4	105,200.0	311.0	0.4	0.2	0.6
01/11/2023 23:00	2,960.2	0.0	2,960.2	105,200.0	311.4	0.4	0.2	0.6
Average/Sum#:	3,403.7	69.7	3,465.2	105,200.0	364.5	0.5	0.2	0.7
Minimum:	2,929.4	0.0	2,929.4	105,200.0	308.2	0.4	0.2	0.6
Maximum:	4,913.8	493.5	5,401.8	105,200.0	568.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2023 00:00	2,983.0	0.0	2,983.0	105,200.0	313.8	0.4	0.2	0.6
01/12/2023 01:00	2,988.4	0.0	2,988.4	105,200.0	314.4	0.4	0.2	0.6
01/12/2023 02:00	2,983.3	0.0	2,983.3	105,200.0	313.8	0.4	0.2	0.6
01/12/2023 03:00	2,982.0	0.0	2,982.0	105,200.0	313.7	0.4	0.2	0.6
01/12/2023 04:00	2,990.7	0.0	2,990.7	105,200.0	314.6	0.4	0.2	0.6
01/12/2023 05:00	2,992.3	0.0	2,992.3	105,200.0	314.8	0.4	0.2	0.6
01/12/2023 06:00	2,984.6	0.0	2,984.6	105,200.0	314.0	0.4	0.2	0.6
01/12/2023 07:00	2,972.4	0.0	2,972.4	105,200.0	312.7	0.4	0.2	0.6
01/12/2023 08:00	2,932.8	0.0	2,932.8	105,200.0	308.5	0.4	0.2	0.6
01/12/2023 09:00	2,942.5	0.0	2,942.5	105,200.0	309.6	0.4	0.2	0.6
01/12/2023 10:00	2,943.3	0.0	2,943.3	105,200.0	309.6	0.4	0.2	0.6
01/12/2023 11:00	2,939.6	0.0	2,939.6	105,200.0	309.2	0.4	0.2	0.6
01/12/2023 12:00	2,932.9	0.0	2,932.9	105,200.0	308.5	0.4	0.2	0.6
01/12/2023 13:00	2,926.2	0.0	2,926.2	105,200.0	307.8	0.4	0.2	0.6
01/12/2023 14:00	2,932.3	0.0	2,932.3	105,200.0	308.5	0.4	0.2	0.6
01/12/2023 15:00	3,337.5	0.0	3,337.5	105,200.0	351.1	0.4	0.2	0.7
01/12/2023 16:00	3,108.2	0.0	3,108.2	105,200.0	327.0	0.4	0.2	0.7
01/12/2023 17:00	4,268.4	263.5	4,426.5	105,200.0	465.7	0.6	0.3	1.0
01/12/2023 18:00	4,811.4	420.3	5,231.7	105,200.0	550.4	0.7	0.3	1.1
01/12/2023 19:00	4,819.7	409.0	5,228.7	105,200.0	550.1	0.7	0.3	1.1
01/12/2023 20:00	4,796.9	433.5	5,230.4	105,200.0	550.2	0.7	0.3	1.1
01/12/2023 21:00	4,382.2	210.2	4,491.5	105,200.0	472.5	0.6	0.3	1.0
01/12/2023 22:00	3,249.4	0.0	3,249.4	105,200.0	341.8	0.4	0.2	0.7
01/12/2023 23:00	2,961.1	0.0	2,961.1	105,200.0	311.5	0.4	0.2	0.6
Average/Sum#:	3,340.0	72.4	3,403.8	105,200.0	358.1	0.5	0.2	0.7
Minimum:	2,926.2	0.0	2,926.2	105,200.0	307.8	0.4	0.2	0.6
Maximum:	4,819.7	433.5	5,231.7	105,200.0	550.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2023 00:00	2,931.4	0.0	2,931.4	105,200.0	308.4	0.4	0.2	0.6
01/13/2023 01:00	2,932.6	0.0	2,932.6	105,200.0	308.5	0.4	0.2	0.6
01/13/2023 02:00	2,932.5	0.0	2,932.5	105,200.0	308.5	0.4	0.2	0.6
01/13/2023 03:00	2,934.4	0.0	2,934.4	105,200.0	308.7	0.4	0.2	0.6
01/13/2023 04:00	2,935.1	0.0	2,935.1	105,200.0	308.8	0.4	0.2	0.6
01/13/2023 05:00	2,933.4	0.0	2,933.4	105,200.0	308.6	0.4	0.2	0.6
01/13/2023 06:00	2,938.7	0.0	2,938.7	105,200.0	309.2	0.4	0.2	0.6
01/13/2023 07:00	2,944.0	0.0	2,944.0	105,200.0	309.7	0.4	0.2	0.6
01/13/2023 08:00	2,935.7	0.0	2,935.7	105,200.0	308.8	0.4	0.2	0.6
01/13/2023 09:00	2,931.0	0.0	2,931.0	105,200.0	308.3	0.4	0.2	0.6
01/13/2023 10:00	2,964.8	0.0	2,964.8	105,200.0	311.9	0.4	0.2	0.6
01/13/2023 11:00	2,959.7	0.0	2,959.7	105,200.0	311.4	0.4	0.2	0.6
01/13/2023 12:00	2,957.9	0.0	2,957.9	105,200.0	311.2	0.4	0.2	0.6
01/13/2023 13:00	2,947.3	0.0	2,947.3	105,200.0	310.1	0.4	0.2	0.6
01/13/2023 14:00	2,945.5	0.0	2,945.5	105,200.0	309.9	0.4	0.2	0.6
01/13/2023 15:00	2,944.6	0.0	2,944.6	105,200.0	309.8	0.4	0.2	0.6
01/13/2023 16:00	2,943.4	0.0	2,943.4	105,200.0	309.6	0.4	0.2	0.6
01/13/2023 17:00	2,945.3	0.0	2,945.3	105,200.0	309.8	0.4	0.2	0.6
01/13/2023 18:00	2,947.0	0.0	2,947.0	105,200.0	310.0	0.4	0.2	0.6
01/13/2023 19:00	2,959.9	0.0	2,959.9	105,200.0	311.4	0.4	0.2	0.6
01/13/2023 20:00	2,970.5	0.0	2,970.5	105,200.0	312.5	0.4	0.2	0.6
01/13/2023 21:00	2,975.6	0.0	2,975.6	105,200.0	313.0	0.4	0.2	0.6
01/13/2023 22:00	2,974.6	0.0	2,974.6	105,200.0	312.9	0.4	0.2	0.6
01/13/2023 23:00	2,968.0	0.0	2,968.0	105,200.0	312.2	0.4	0.2	0.6
Average/Sum#:	2,948.0	0.0	2,948.0	105,200.0	310.1	0.4	0.2	0.6
Minimum:	2,931.0	0.0	2,931.0	105,200.0	308.3	0.4	0.2	0.6
Maximum:	2,975.6	0.0	2,975.6	105,200.0	313.0	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2023 00:00	2,959.1	0.0	2,959.1	105,200.0	311.3	0.4	0.2	0.6
01/14/2023 01:00	2,954.5	0.0	2,954.5	105,200.0	310.8	0.4	0.2	0.6
01/14/2023 02:00	2,945.3	0.0	2,945.3	105,200.0	309.8	0.4	0.2	0.6
01/14/2023 03:00	2,933.9	0.0	2,933.9	105,200.0	308.6	0.4	0.2	0.6
01/14/2023 04:00	2,926.6	0.0	2,926.6	105,200.0	307.9	0.4	0.2	0.6
01/14/2023 05:00	2,924.5	0.0	2,924.5	105,200.0	307.7	0.4	0.2	0.6
01/14/2023 06:00	2,922.8	0.0	2,922.8	105,200.0	307.5	0.4	0.2	0.6
01/14/2023 07:00	2,911.5	0.0	2,911.5	105,200.0	306.3	0.4	0.2	0.6
01/14/2023 08:00	2,899.0	0.0	2,899.0	105,200.0	305.0	0.4	0.2	0.6
01/14/2023 09:00	3,393.2	0.0	3,393.2	105,200.0	357.0	0.4	0.2	0.7
01/14/2023 10:00	3,340.2	0.0	3,340.2	105,200.0	351.4	0.4	0.2	0.7
01/14/2023 11:00	2,951.9	0.0	2,951.9	105,200.0	310.5	0.4	0.2	0.6
01/14/2023 12:00	2,956.6	0.0	2,956.6	105,200.0	311.0	0.4	0.2	0.6
01/14/2023 13:00	2,966.8	0.0	2,966.8	105,200.0	312.1	0.4	0.2	0.6
01/14/2023 14:00	3,709.2	0.0	3,709.2	105,200.0	390.2	0.5	0.2	0.8
01/14/2023 15:00	3,256.6	0.0	3,256.6	105,200.0	342.6	0.4	0.2	0.7
01/14/2023 16:00	4,433.8	325.3	4,645.2	105,200.0	488.7	0.6	0.3	1.0
01/14/2023 17:00	4,795.6	449.9	5,245.5	105,200.0	551.8	0.7	0.3	1.1
01/14/2023 18:00	4,809.3	476.4	5,285.7	105,200.0	556.1	0.7	0.3	1.1
01/14/2023 19:00	4,591.0	208.8	4,705.8	105,200.0	495.1	0.6	0.3	1.0
01/14/2023 20:00	3,207.7	0.0	3,207.7	105,200.0	337.5	0.4	0.2	0.7
01/14/2023 21:00	2,956.4	0.0	2,956.4	105,200.0	311.0	0.4	0.2	0.6
01/14/2023 22:00	2,959.5	0.0	2,959.5	105,200.0	311.3	0.4	0.2	0.6
01/14/2023 23:00	2,957.2	0.0	2,957.2	105,200.0	311.1	0.4	0.2	0.6
Average/Sum#:	3,319.3	60.9	3,371.4	105,200.0	354.7	0.4	0.2	0.7
Minimum:	2,899.0	0.0	2,899.0	105,200.0	305.0	0.4	0.2	0.6
Maximum:	4,809.3	476.4	5,285.7	105,200.0	556.1	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2023 00:00	2,962.5	0.0	2,962.5	105,200.0	311.7	0.4	0.2	0.6
01/15/2023 01:00	2,968.0	0.0	2,968.0	105,200.0	312.2	0.4	0.2	0.6
01/15/2023 02:00	2,960.7	0.0	2,960.7	105,200.0	311.5	0.4	0.2	0.6
01/15/2023 03:00	2,953.9	0.0	2,953.9	105,200.0	310.8	0.4	0.2	0.6
01/15/2023 04:00	2,954.9	0.0	2,954.9	105,200.0	310.9	0.4	0.2	0.6
01/15/2023 05:00	2,959.9	0.0	2,959.9	105,200.0	311.4	0.4	0.2	0.6
01/15/2023 06:00	2,953.5	0.0	2,953.5	105,200.0	310.7	0.4	0.2	0.6
01/15/2023 07:00	2,955.0	0.0	2,955.0	105,200.0	310.9	0.4	0.2	0.6
01/15/2023 08:00	2,956.5	0.0	2,956.5	105,200.0	311.0	0.4	0.2	0.6
01/15/2023 09:00	2,960.5	0.0	2,960.5	105,200.0	311.4	0.4	0.2	0.6
01/15/2023 10:00	2,954.3	0.0	2,954.3	105,200.0	310.8	0.4	0.2	0.6
01/15/2023 11:00	2,946.1	0.0	2,946.1	105,200.0	309.9	0.4	0.2	0.6
01/15/2023 12:00	2,942.9	0.0	2,942.9	105,200.0	309.6	0.4	0.2	0.6
01/15/2023 13:00	2,955.1	0.0	2,955.1	105,200.0	310.9	0.4	0.2	0.6
01/15/2023 14:00	3,777.4	0.0	3,777.4	105,200.0	397.4	0.5	0.2	0.8
01/15/2023 15:00	3,538.6	0.0	3,538.6	105,200.0	372.3	0.4	0.2	0.7
01/15/2023 16:00	4,743.3	88.5	4,765.4	105,200.0	501.3	0.6	0.3	1.0
01/15/2023 17:00	4,816.7	585.1	5,401.8	105,200.0	568.3	0.7	0.3	1.1
01/15/2023 18:00	4,815.9	585.5	5,401.4	105,200.0	568.2	0.7	0.3	1.1
01/15/2023 19:00	4,820.6	461.7	5,282.3	105,200.0	555.7	0.7	0.3	1.1
01/15/2023 20:00	4,857.3	452.2	5,309.5	105,200.0	558.6	0.7	0.3	1.1
01/15/2023 21:00	4,062.1	100.9	4,089.3	105,200.0	430.2	0.5	0.3	0.9
01/15/2023 22:00	3,353.6	0.0	3,353.6	105,200.0	352.8	0.4	0.2	0.7
01/15/2023 23:00	2,967.6	0.0	2,967.6	105,200.0	312.2	0.4	0.2	0.6
Average/Sum#:	3,464.0	94.7	3,552.9	105,200.0	373.8	0.5	0.2	0.7
Minimum:	2,942.9	0.0	2,942.9	105,200.0	309.6	0.4	0.2	0.6
Maximum:	4,857.3	585.5	5,401.8	105,200.0	568.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2023 00:00	2,966.8	0.0	2,966.8	105,200.0	312.1	0.4	0.2	0.6
01/16/2023 01:00	2,969.8	0.0	2,969.8	105,200.0	312.4	0.4	0.2	0.6
01/16/2023 02:00	2,962.2	0.0	2,962.2	105,200.0	311.6	0.4	0.2	0.6
01/16/2023 03:00	2,952.9	0.0	2,952.9	105,200.0	310.6	0.4	0.2	0.6
01/16/2023 04:00	2,946.5	0.0	2,946.5	105,200.0	310.0	0.4	0.2	0.6
01/16/2023 05:00	2,946.3	0.0	2,946.3	105,200.0	310.0	0.4	0.2	0.6
01/16/2023 06:00	2,946.1	0.0	2,946.1	105,200.0	309.9	0.4	0.2	0.6
01/16/2023 07:00	2,951.4	0.0	2,951.4	105,200.0	310.5	0.4	0.2	0.6
01/16/2023 08:00	2,957.7	0.0	2,957.7	105,200.0	311.2	0.4	0.2	0.6
01/16/2023 09:00	2,970.2	0.0	2,970.2	105,200.0	312.5	0.4	0.2	0.6
01/16/2023 10:00	2,975.2	0.0	2,975.2	105,200.0	313.0	0.4	0.2	0.6
01/16/2023 11:00	2,967.8	0.0	2,967.8	105,200.0	312.2	0.4	0.2	0.6
01/16/2023 12:00	2,967.1	0.0	2,967.1	105,200.0	312.1	0.4	0.2	0.6
01/16/2023 13:00	2,927.0	0.0	2,927.0	105,200.0	307.9	0.4	0.2	0.6
01/16/2023 14:00	3,118.7	0.0	3,118.7	105,200.0	328.1	0.4	0.2	0.7
01/16/2023 15:00	3,439.0	0.0	3,439.0	105,200.0	361.8	0.4	0.2	0.7
01/16/2023 16:00	3,821.2	137.6	3,869.4	105,200.0	407.1	0.5	0.2	0.8
01/16/2023 17:00	4,839.9	428.3	5,268.2	105,200.0	554.2	0.7	0.3	1.1
01/16/2023 18:00	4,860.5	401.1	5,261.6	105,200.0	553.5	0.7	0.3	1.1
01/16/2023 19:00	4,866.7	395.9	5,262.6	105,200.0	553.6	0.7	0.3	1.1
01/16/2023 20:00	4,886.3	370.5	5,256.8	105,200.0	553.0	0.7	0.3	1.1
01/16/2023 21:00	4,897.7	346.0	5,243.7	105,200.0	551.6	0.7	0.3	1.1
01/16/2023 22:00	4,176.6	80.8	4,198.4	105,200.0	441.7	0.5	0.3	0.9
01/16/2023 23:00	3,225.6	0.0	3,225.6	105,200.0	339.3	0.4	0.2	0.7
Average/Sum#:	3,480.8	90.0	3,564.6	105,200.0	375.0	0.5	0.2	0.7
Minimum:	2,927.0	0.0	2,927.0	105,200.0	307.9	0.4	0.2	0.6
Maximum:	4,897.7	428.3	5,268.2	105,200.0	554.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2023 00:00	2,967.8	0.0	2,967.8	105,200.0	312.2	0.4	0.2	0.6
01/17/2023 01:00	2,967.7	0.0	2,967.7	105,200.0	312.2	0.4	0.2	0.6
01/17/2023 02:00	2,974.7	0.0	2,974.7	105,200.0	312.9	0.4	0.2	0.6
01/17/2023 03:00	2,977.0	0.0	2,977.0	105,200.0	313.2	0.4	0.2	0.6
01/17/2023 04:00	2,981.3	0.0	2,981.3	105,200.0	313.6	0.4	0.2	0.6
01/17/2023 05:00	2,979.2	0.0	2,979.2	105,200.0	313.4	0.4	0.2	0.6
01/17/2023 06:00	3,048.4	0.0	3,048.4	105,200.0	320.7	0.4	0.2	0.6
01/17/2023 07:00	3,159.0	0.0	3,159.0	105,200.0	332.3	0.4	0.2	0.7
01/17/2023 08:00	2,979.9	0.0	2,979.9	105,200.0	313.5	0.4	0.2	0.6
01/17/2023 09:00	2,974.9	0.0	2,974.9	105,200.0	313.0	0.4	0.2	0.6
01/17/2023 10:00	2,977.0	0.0	2,977.0	105,200.0	313.2	0.4	0.2	0.6
01/17/2023 11:00	2,980.5	0.0	2,980.5	105,200.0	313.5	0.4	0.2	0.6
01/17/2023 12:00	2,978.1	0.0	2,978.1	105,200.0	313.3	0.4	0.2	0.6
01/17/2023 13:00	2,985.4	0.0	2,985.4	105,200.0	314.1	0.4	0.2	0.6
01/17/2023 14:00	2,980.5	0.0	2,980.5	105,200.0	313.5	0.4	0.2	0.6
01/17/2023 15:00	2,979.2	0.0	2,979.2	105,200.0	313.4	0.4	0.2	0.6
01/17/2023 16:00	3,493.2	0.0	3,493.2	105,200.0	367.5	0.4	0.2	0.7
01/17/2023 17:00	3,605.3	0.0	3,605.3	105,200.0	379.3	0.5	0.2	0.8
01/17/2023 18:00	4,365.9	235.6	4,507.3	105,200.0	474.2	0.6	0.3	1.0
01/17/2023 19:00	4,923.1	278.7	5,201.8	105,200.0	547.2	0.7	0.3	1.1
01/17/2023 20:00	4,937.6	263.2	5,200.8	105,200.0	547.1	0.7	0.3	1.1
01/17/2023 21:00	4,959.6	243.8	5,203.4	105,200.0	547.4	0.7	0.3	1.1
01/17/2023 22:00	4,971.8	227.8	5,199.6	105,200.0	547.0	0.7	0.3	1.1
01/17/2023 23:00	4,979.4	203.3	5,182.7	105,200.0	545.2	0.7	0.3	1.1
Average/Sum#:	3,505.3	60.5	3,561.9	105,200.0	374.7	0.5	0.2	0.7
Minimum:	2,967.7	0.0	2,967.7	105,200.0	312.2	0.4	0.2	0.6
Maximum:	4,979.4	278.7	5,203.4	105,200.0	547.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2023 00:00	4,980.6	242.3	5,222.9	105,200.0	549.4	0.7	0.3	1.1
01/18/2023 01:00	4,983.7	256.0	5,239.7	105,200.0	551.2	0.7	0.3	1.1
01/18/2023 02:00	4,985.5	247.0	5,232.5	105,200.0	550.5	0.7	0.3	1.1
01/18/2023 03:00	4,989.4	244.1	5,233.5	105,200.0	550.6	0.7	0.3	1.1
01/18/2023 04:00	4,997.8	221.8	5,219.6	105,200.0	549.1	0.7	0.3	1.1
01/18/2023 05:00	5,017.1	192.8	5,209.9	105,200.0	548.1	0.7	0.3	1.1
01/18/2023 06:00	5,020.3	238.2	5,258.5	105,200.0	553.2	0.7	0.3	1.1
01/18/2023 07:00	5,025.0	150.2	5,175.2	105,200.0	544.4	0.7	0.3	1.1
01/18/2023 08:00	4,599.6	64.4	4,633.1	105,200.0	487.4	0.6	0.3	1.0
01/18/2023 09:00	3,242.5	0.0	3,242.5	105,200.0	341.1	0.4	0.2	0.7
01/18/2023 10:00	2,939.9	0.0	2,939.9	105,200.0	309.3	0.4	0.2	0.6
01/18/2023 11:00	2,944.3	0.0	2,944.3	105,200.0	309.7	0.4	0.2	0.6
01/18/2023 12:00	2,945.4	0.0	2,945.4	105,200.0	309.9	0.4	0.2	0.6
01/18/2023 13:00	2,941.9	0.0	2,941.9	105,200.0	309.5	0.4	0.2	0.6
01/18/2023 14:00	2,941.3	0.0	2,941.3	105,200.0	309.4	0.4	0.2	0.6
01/18/2023 15:00	2,948.7	0.0	2,948.7	105,200.0	310.2	0.4	0.2	0.6
01/18/2023 16:00	2,940.2	0.0	2,940.2	105,200.0	309.3	0.4	0.2	0.6
01/18/2023 17:00	2,932.9	0.0	2,932.9	105,200.0	308.5	0.4	0.2	0.6
01/18/2023 18:00	2,933.5	0.0	2,933.5	105,200.0	308.6	0.4	0.2	0.6
01/18/2023 19:00	2,934.2	0.0	2,934.2	105,200.0	308.7	0.4	0.2	0.6
01/18/2023 20:00	2,930.8	0.0	2,930.8	105,200.0	308.3	0.4	0.2	0.6
01/18/2023 21:00	2,931.3	0.0	2,931.3	105,200.0	308.4	0.4	0.2	0.6
01/18/2023 22:00	2,934.4	0.0	2,934.4	105,200.0	308.7	0.4	0.2	0.6
01/18/2023 23:00	2,943.7	0.0	2,943.7	105,200.0	309.7	0.4	0.2	0.6
Average/Sum#:	3,707.7	77.4	3,783.7	105,200.0	398.1	0.5	0.2	0.8
Minimum:	2,930.8	0.0	2,930.8	105,200.0	308.3	0.4	0.2	0.6
Maximum:	5,025.0	256.0	5,258.5	105,200.0	553.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2023 00:00	2,938.6	0.0	2,938.6	105,200.0	309.1	0.4	0.2	0.6
01/19/2023 01:00	2,945.8	0.0	2,945.8	105,200.0	309.9	0.4	0.2	0.6
01/19/2023 02:00	2,945.8	0.0	2,945.8	105,200.0	309.9	0.4	0.2	0.6
01/19/2023 03:00	2,944.8	0.0	2,944.8	105,200.0	309.8	0.4	0.2	0.6
01/19/2023 04:00	2,944.0	0.0	2,944.0	105,200.0	309.7	0.4	0.2	0.6
01/19/2023 05:00	2,945.5	0.0	2,945.5	105,200.0	309.9	0.4	0.2	0.6
01/19/2023 06:00	2,947.5	0.0	2,947.5	105,200.0	310.1	0.4	0.2	0.6
01/19/2023 07:00	2,949.1	0.0	2,949.1	105,200.0	310.2	0.4	0.2	0.6
01/19/2023 08:00	2,955.0	0.0	2,955.0	105,200.0	310.9	0.4	0.2	0.6
01/19/2023 09:00	2,955.0	0.0	2,955.0	105,200.0	310.9	0.4	0.2	0.6
01/19/2023 10:00	2,949.3	0.0	2,949.3	105,200.0	310.3	0.4	0.2	0.6
01/19/2023 11:00	2,954.3	0.0	2,954.3	105,200.0	310.8	0.4	0.2	0.6
01/19/2023 12:00	2,940.3	0.0	2,940.3	105,200.0	309.3	0.4	0.2	0.6
01/19/2023 13:00	2,945.7	0.0	2,945.7	105,200.0	309.9	0.4	0.2	0.6
01/19/2023 14:00	2,935.4	0.0	2,935.4	105,200.0	308.8	0.4	0.2	0.6
01/19/2023 15:00	2,941.4	0.0	2,941.4	105,200.0	309.4	0.4	0.2	0.6
01/19/2023 16:00	2,941.0	0.0	2,941.0	105,200.0	309.4	0.4	0.2	0.6
01/19/2023 17:00	4,087.1	0.5	4,087.2	105,200.0	430.0	0.5	0.3	0.9
01/19/2023 18:00	4,813.5	7.7	4,821.2	105,200.0	507.2	0.6	0.3	1.0
01/19/2023 19:00	4,810.1	8.9	4,819.0	105,200.0	507.0	0.6	0.3	1.0
01/19/2023 20:00	4,812.5	9.4	4,821.9	105,200.0	507.3	0.6	0.3	1.0
01/19/2023 21:00	4,819.0	9.6	4,828.4	105,200.0	507.9	0.6	0.3	1.0
01/19/2023 22:00	4,816.9	9.9	4,826.8	105,200.0	507.8	0.6	0.3	1.0
01/19/2023 23:00	4,853.2	9.4	4,862.6	105,200.0	511.5	0.6	0.3	1.0
Average/Sum#:	3,462.1	2.3	3,464.4	105,200.0	364.5	0.5	0.2	0.7
Minimum:	2,935.4	0.0	2,935.4	105,200.0	308.8	0.4	0.2	0.6
Maximum:	4,853.2	9.9	4,862.6	105,200.0	511.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2023 00:00	4,855.1	7.9	4,863.0	105,200.0	511.6	0.6	0.3	1.0
01/20/2023 01:00	4,859.1	10.3	4,869.1	105,200.0	512.2	0.6	0.3	1.0
01/20/2023 02:00	4,865.2	10.0	4,875.2	105,200.0	512.9	0.6	0.3	1.0
01/20/2023 03:00	4,848.1	9.8	4,857.7	105,200.0	511.0	0.6	0.3	1.0
01/20/2023 04:00	4,862.4	9.3	4,871.4	105,200.0	512.5	0.6	0.3	1.0
01/20/2023 05:00	4,857.4	9.7	4,866.9	105,200.0	512.0	0.6	0.3	1.0
01/20/2023 06:00	4,851.1	9.5	4,859.9	105,200.0	511.3	0.6	0.3	1.0
01/20/2023 07:00	4,864.3	10.9	4,874.7	105,200.0	512.8	0.6	0.3	1.0
01/20/2023 08:00	4,854.8	10.3	4,864.9	105,200.0	511.8	0.6	0.3	1.0
01/20/2023 09:00	4,847.6	8.0	4,855.4	105,200.0	510.8	0.6	0.3	1.0
01/20/2023 10:00	4,847.7	9.8	4,857.5	105,200.0	511.0	0.6	0.3	1.0
01/20/2023 11:00	4,740.7	9.7	4,748.5	105,200.0	499.5	0.6	0.3	1.0
01/20/2023 12:00	3,299.0	0.0	3,299.0	105,200.0	347.1	0.4	0.2	0.7
01/20/2023 13:00	2,960.2	0.0	2,960.2	105,200.0	311.4	0.4	0.2	0.6
01/20/2023 14:00	2,960.9	0.0	2,960.9	105,200.0	311.5	0.4	0.2	0.6
01/20/2023 15:00	2,966.2	0.0	2,966.2	105,200.0	312.0	0.4	0.2	0.6
01/20/2023 16:00	2,963.9	0.0	2,963.9	105,200.0	311.8	0.4	0.2	0.6
01/20/2023 17:00	4,056.3	5.8	4,058.8	105,200.0	427.0	0.5	0.3	0.9
01/20/2023 18:00	4,812.6	9.8	4,822.2	105,200.0	507.3	0.6	0.3	1.0
01/20/2023 19:00	4,805.5	8.1	4,813.6	105,200.0	506.4	0.6	0.3	1.0
01/20/2023 20:00	4,836.7	8.9	4,845.3	105,200.0	509.7	0.6	0.3	1.0
01/20/2023 21:00	4,834.0	10.1	4,844.1	105,200.0	509.6	0.6	0.3	1.0
01/20/2023 22:00	4,836.5	8.6	4,845.1	105,200.0	509.7	0.6	0.3	1.0
01/20/2023 23:00	4,831.4	10.5	4,841.9	105,200.0	509.4	0.6	0.3	1.0
Average/Sum#:	4,429.9	7.4	4,436.9	105,200.0	466.8	0.6	0.3	0.9
Minimum:	2,960.2	0.0	2,960.2	105,200.0	311.4	0.4	0.2	0.6
Maximum:	4,865.2	10.9	4,875.2	105,200.0	512.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2023 00:00	4,884.9	4.2	4,886.2	105,200.0	514.0	0.6	0.3	1.0
01/21/2023 01:00	4,898.5	0.0	4,898.5	105,200.0	515.3	0.6	0.3	1.0
01/21/2023 02:00	4,897.5	0.0	4,897.5	105,200.0	515.2	0.6	0.3	1.0
01/21/2023 03:00	4,903.6	0.0	4,903.6	105,200.0	515.9	0.6	0.3	1.0
01/21/2023 04:00	4,898.8	0.0	4,898.8	105,200.0	515.4	0.6	0.3	1.0
01/21/2023 05:00	4,908.0	0.0	4,908.0	105,200.0	516.3	0.6	0.3	1.0
01/21/2023 06:00	4,898.8	0.0	4,898.8	105,200.0	515.4	0.6	0.3	1.0
01/21/2023 07:00	4,917.8	0.0	4,917.8	105,200.0	517.4	0.6	0.3	1.0
01/21/2023 08:00	4,819.4	0.1	4,819.4	105,200.0	507.0	0.6	0.3	1.0
01/21/2023 09:00	3,268.8	0.0	3,268.8	105,200.0	343.9	0.4	0.2	0.7
01/21/2023 10:00	2,962.9	0.0	2,962.9	105,200.0	311.7	0.4	0.2	0.6
01/21/2023 11:00	2,961.5	0.0	2,961.5	105,200.0	311.5	0.4	0.2	0.6
01/21/2023 12:00	2,963.8	0.0	2,963.8	105,200.0	311.8	0.4	0.2	0.6
01/21/2023 13:00	2,960.6	0.0	2,960.6	105,200.0	311.5	0.4	0.2	0.6
01/21/2023 14:00	2,959.8	0.0	2,959.8	105,200.0	311.4	0.4	0.2	0.6
01/21/2023 15:00	2,956.8	0.0	2,956.8	105,200.0	311.1	0.4	0.2	0.6
01/21/2023 16:00	4,085.7	0.0	4,085.7	105,200.0	429.8	0.5	0.3	0.9
01/21/2023 17:00	4,941.7	0.0	4,941.7	105,200.0	519.9	0.6	0.3	1.0
01/21/2023 18:00	4,940.1	0.0	4,940.1	105,200.0	519.7	0.6	0.3	1.0
01/21/2023 19:00	4,950.7	0.0	4,950.7	105,200.0	520.8	0.6	0.3	1.0
01/21/2023 20:00	4,953.3	0.5	4,953.3	105,200.0	521.1	0.6	0.3	1.0
01/21/2023 21:00	4,989.3	13.9	5,003.2	105,200.0	526.3	0.6	0.3	1.1
01/21/2023 22:00	4,348.0	4.4	4,350.2	105,200.0	457.6	0.5	0.3	0.9
01/21/2023 23:00	2,967.7	0.0	2,967.7	105,200.0	312.2	0.4	0.2	0.6
Average/Sum#:	4,218.3	1.0	4,219.0	105,200.0	443.8	0.5	0.3	0.9
Minimum:	2,956.8	0.0	2,956.8	105,200.0	311.1	0.4	0.2	0.6
Maximum:	4,989.3	13.9	5,003.2	105,200.0	526.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2023 00:00	2,973.8	0.0	2,973.8	105,200.0	312.8	0.4	0.2	0.6
01/22/2023 01:00	2,977.5	0.0	2,977.5	105,200.0	313.2	0.4	0.2	0.6
01/22/2023 02:00	2,981.6	0.0	2,981.6	105,200.0	313.7	0.4	0.2	0.6
01/22/2023 03:00	2,979.6	0.0	2,979.6	105,200.0	313.5	0.4	0.2	0.6
01/22/2023 04:00	2,984.6	0.0	2,984.6	105,200.0	314.0	0.4	0.2	0.6
01/22/2023 05:00	2,988.1	0.0	2,988.1	105,200.0	314.3	0.4	0.2	0.6
01/22/2023 06:00	2,986.1	0.0	2,986.1	105,200.0	314.1	0.4	0.2	0.6
01/22/2023 07:00	2,969.9	0.0	2,969.9	105,200.0	312.4	0.4	0.2	0.6
01/22/2023 08:00	2,948.0	0.0	2,948.0	105,200.0	310.1	0.4	0.2	0.6
01/22/2023 09:00	2,945.6	0.0	2,945.6	105,200.0	309.9	0.4	0.2	0.6
01/22/2023 10:00	2,930.7	0.0	2,930.7	105,200.0	308.3	0.4	0.2	0.6
01/22/2023 11:00	2,920.0	0.0	2,920.0	105,200.0	307.2	0.4	0.2	0.6
01/22/2023 12:00	2,896.0	0.0	2,896.0	105,200.0	304.7	0.4	0.2	0.6
01/22/2023 13:00	2,894.9	0.0	2,894.9	105,200.0	304.5	0.4	0.2	0.6
01/22/2023 14:00	2,893.4	0.0	2,893.4	105,200.0	304.4	0.4	0.2	0.6
01/22/2023 15:00	2,891.9	0.0	2,891.9	105,200.0	304.2	0.4	0.2	0.6
01/22/2023 16:00	4,017.3	10.0	4,018.6	105,200.0	422.8	0.5	0.3	0.8
01/22/2023 17:00	4,916.6	132.7	5,049.3	105,200.0	531.2	0.6	0.3	1.1
01/22/2023 18:00	4,946.5	131.7	5,078.2	105,200.0	534.2	0.6	0.3	1.1
01/22/2023 19:00	4,946.4	149.7	5,096.1	105,200.0	536.1	0.6	0.3	1.1
01/22/2023 20:00	4,930.4	194.8	5,125.2	105,200.0	539.2	0.6	0.3	1.1
01/22/2023 21:00	4,935.1	150.8	5,085.9	105,200.0	535.0	0.6	0.3	1.1
01/22/2023 22:00	4,946.6	90.9	5,037.5	105,200.0	529.9	0.6	0.3	1.1
01/22/2023 23:00	4,970.6	18.3	4,988.9	105,200.0	524.8	0.6	0.3	1.1
Average/Sum#:	3,573.8	36.6	3,610.1	105,200.0	379.8	0.5	0.2	0.8
Minimum:	2,891.9	0.0	2,891.9	105,200.0	304.2	0.4	0.2	0.6
Maximum:	4,970.6	194.8	5,125.2	105,200.0	539.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2023 00:00	4,983.3	8.4	4,991.7	105,200.0	525.1	0.6	0.3	1.1
01/23/2023 01:00	4,983.2	51.5	5,034.7	105,200.0	529.7	0.6	0.3	1.1
01/23/2023 02:00	4,991.9	53.7	5,045.6	105,200.0	530.8	0.6	0.3	1.1
01/23/2023 03:00	4,985.5	46.3	5,031.8	105,200.0	529.3	0.6	0.3	1.1
01/23/2023 04:00	4,990.8	59.3	5,050.1	105,200.0	531.3	0.6	0.3	1.1
01/23/2023 05:00	5,002.4	22.2	5,024.6	105,200.0	528.6	0.6	0.3	1.1
01/23/2023 06:00	5,000.5	165.5	5,166.0	105,200.0	543.5	0.7	0.3	1.1
01/23/2023 07:00	5,001.0	252.6	5,253.6	105,200.0	552.7	0.7	0.3	1.1
01/23/2023 08:00	4,946.7	9.0	4,955.7	105,200.0	521.3	0.6	0.3	1.0
01/23/2023 09:00	3,345.7	1.6	3,345.9	105,200.0	352.0	0.4	0.2	0.7
01/23/2023 10:00	2,907.1	0.0	2,907.1	105,200.0	305.8	0.4	0.2	0.6
01/23/2023 11:00	2,898.3	0.0	2,898.3	105,200.0	304.9	0.4	0.2	0.6
01/23/2023 12:00	2,896.2	0.0	2,896.2	105,200.0	304.7	0.4	0.2	0.6
01/23/2023 13:00	2,894.7	0.0	2,894.7	105,200.0	304.5	0.4	0.2	0.6
01/23/2023 14:00	2,892.9	0.0	2,892.9	105,200.0	304.3	0.4	0.2	0.6
01/23/2023 15:00	3,420.9	0.0	3,420.9	105,200.0	359.9	0.4	0.2	0.7
01/23/2023 16:00	3,928.5	0.0	3,928.5	105,200.0	413.3	0.5	0.2	0.8
01/23/2023 17:00	4,351.4	11.1	4,357.5	105,200.0	458.4	0.6	0.3	0.9
01/23/2023 18:00	4,882.7	579.1	5,461.8	105,200.0	574.6	0.7	0.3	1.1
01/23/2023 19:00	4,912.2	988.8	5,901.0	105,200.0	620.8	0.7	0.4	1.2
01/23/2023 20:00	4,954.4	842.4	5,796.8	105,200.0	609.8	0.7	0.4	1.2
01/23/2023 21:00	4,958.6	701.5	5,660.1	105,200.0	595.4	0.7	0.4	1.2
01/23/2023 22:00	4,982.1	688.4	5,670.5	105,200.0	596.5	0.7	0.4	1.2
01/23/2023 23:00	4,983.2	366.8	5,350.0	105,200.0	562.8	0.7	0.3	1.1
Average/Sum#:	4,337.3	202.0	4,539.0	105,200.0	477.5	0.6	0.3	1.0
Minimum:	2,892.9	0.0	2,892.9	105,200.0	304.3	0.4	0.2	0.6
Maximum:	5,002.4	988.8	5,901.0	105,200.0	620.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2023 00:00	4,937.3	0.7	4,937.3	105,200.0	519.4	0.6	0.3	1.0
01/24/2023 01:00	4,944.6	0.0	4,944.6	105,200.0	520.2	0.6	0.3	1.0
01/24/2023 02:00	4,925.3	0.0	4,925.3	105,200.0	518.1	0.6	0.3	1.0
01/24/2023 03:00	4,928.1	0.0	4,928.1	105,200.0	518.4	0.6	0.3	1.0
01/24/2023 04:00	4,929.5	0.0	4,929.5	105,200.0	518.6	0.6	0.3	1.0
01/24/2023 05:00	5,037.0	507.8	5,407.7	105,200.0	568.9	0.7	0.3	1.2
01/24/2023 06:00	5,082.9	974.4	6,057.3	105,200.0	637.2	0.8	0.4	1.3
01/24/2023 07:00	5,064.7	157.4	5,206.4	105,200.0	547.7	0.7	0.3	1.1
01/24/2023 08:00	5,070.1	58.9	5,129.0	105,200.0	539.6	0.6	0.3	1.1
01/24/2023 09:00	3,997.3	21.3	4,003.1	105,200.0	421.1	0.5	0.3	0.8
01/24/2023 10:00	3,238.4	0.0	3,238.4	105,200.0	340.7	0.4	0.2	0.7
01/24/2023 11:00	2,971.3	0.0	2,971.3	105,200.0	312.6	0.4	0.2	0.6
01/24/2023 12:00	2,972.7	0.0	2,972.7	105,200.0	312.7	0.4	0.2	0.6
01/24/2023 13:00	2,961.9	0.0	2,961.9	105,200.0	311.6	0.4	0.2	0.6
01/24/2023 14:00	2,965.6	0.0	2,965.6	105,200.0	312.0	0.4	0.2	0.6
01/24/2023 15:00	2,973.8	0.0	2,973.8	105,200.0	312.8	0.4	0.2	0.6
01/24/2023 16:00	2,961.0	0.0	2,961.0	105,200.0	311.5	0.4	0.2	0.6
01/24/2023 17:00	2,993.0	0.0	2,993.0	105,200.0	314.9	0.4	0.2	0.6
01/24/2023 18:00	4,111.3	0.0	4,111.3	105,200.0	432.5	0.5	0.3	0.9
01/24/2023 19:00	3,390.3	0.0	3,390.3	105,200.0	356.7	0.4	0.2	0.7
01/24/2023 20:00	2,993.4	0.0	2,993.4	105,200.0	314.9	0.4	0.2	0.6
01/24/2023 21:00	2,996.8	0.0	2,996.8	105,200.0	315.3	0.4	0.2	0.6
01/24/2023 22:00	2,999.7	0.0	2,999.7	105,200.0	315.6	0.4	0.2	0.6
01/24/2023 23:00	3,002.1	0.0	3,002.1	105,200.0	315.8	0.4	0.2	0.6
Average/Sum#:	3,852.0	71.7	3,916.7	105,200.0	412.0	0.5	0.3	0.8
Minimum:	2,961.0	0.0	2,961.0	105,200.0	311.5	0.4	0.2	0.6
Maximum:	5,082.9	974.4	6,057.3	105,200.0	637.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2023 00:00	2,995.9	0.0	2,995.9	105,200.0	315.2	0.4	0.2	0.6
01/25/2023 01:00	2,971.1	0.0	2,971.1	105,200.0	312.6	0.4	0.2	0.6
01/25/2023 02:00	2,967.3	0.0	2,967.3	105,200.0	312.2	0.4	0.2	0.6
01/25/2023 03:00	2,966.3	0.0	2,966.3	105,200.0	312.1	0.4	0.2	0.6
01/25/2023 04:00	2,962.5	0.0	2,962.5	105,200.0	311.7	0.4	0.2	0.6
01/25/2023 05:00	2,964.0	0.0	2,964.0	105,200.0	311.8	0.4	0.2	0.6
01/25/2023 06:00	3,028.7	0.0	3,028.7	105,200.0	318.6	0.4	0.2	0.6
01/25/2023 07:00	3,002.6	0.0	3,002.6	105,200.0	315.9	0.4	0.2	0.6
01/25/2023 08:00	3,037.8	0.0	3,037.8	105,200.0	319.6	0.4	0.2	0.6
01/25/2023 09:00	3,022.2	0.0	3,022.2	105,200.0	317.9	0.4	0.2	0.6
01/25/2023 10:00	3,008.5	0.0	3,008.5	105,200.0	316.5	0.4	0.2	0.6
01/25/2023 11:00	2,970.9	0.0	2,970.9	105,200.0	312.5	0.4	0.2	0.6
01/25/2023 12:00	2,950.3	0.0	2,950.3	105,200.0	310.4	0.4	0.2	0.6
01/25/2023 13:00	2,980.0	0.0	2,980.0	105,200.0	313.5	0.4	0.2	0.6
01/25/2023 14:00	2,943.5	0.0	2,943.5	105,200.0	309.7	0.4	0.2	0.6
01/25/2023 15:00	2,942.5	0.0	2,942.5	105,200.0	309.6	0.4	0.2	0.6
01/25/2023 16:00	2,950.7	0.0	2,950.7	105,200.0	310.4	0.4	0.2	0.6
01/25/2023 17:00	2,981.3	0.0	2,981.3	105,200.0	313.6	0.4	0.2	0.6
01/25/2023 18:00	2,963.4	0.0	2,963.4	105,200.0	311.7	0.4	0.2	0.6
01/25/2023 19:00	2,957.4	0.0	2,957.4	105,200.0	311.1	0.4	0.2	0.6
01/25/2023 20:00	2,959.4	0.0	2,959.4	105,200.0	311.3	0.4	0.2	0.6
01/25/2023 21:00	2,962.3	0.0	2,962.3	105,200.0	311.6	0.4	0.2	0.6
01/25/2023 22:00	2,962.5	0.0	2,962.5	105,200.0	311.7	0.4	0.2	0.6
01/25/2023 23:00	2,972.2	0.0	2,972.2	105,200.0	312.7	0.4	0.2	0.6
Average/Sum#:	2,976.0	0.0	2,976.0	105,200.0	313.1	0.4	0.2	0.6
Minimum:	2,942.5	0.0	2,942.5	105,200.0	309.6	0.4	0.2	0.6
Maximum:	3,037.8	0.0	3,037.8	105,200.0	319.6	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2023 00:00	3,001.0	0.0	3,001.0	105,200.0	315.7	0.4	0.2	0.6
01/26/2023 01:00	2,973.8	0.0	2,973.8	105,200.0	312.8	0.4	0.2	0.6
01/26/2023 02:00	2,960.9	0.0	2,960.9	105,200.0	311.5	0.4	0.2	0.6
01/26/2023 03:00	3,002.9	0.0	3,002.9	105,200.0	315.9	0.4	0.2	0.6
01/26/2023 04:00	3,010.1	0.0	3,010.1	105,200.0	316.7	0.4	0.2	0.6
01/26/2023 05:00	3,002.1	0.0	3,002.1	105,200.0	315.8	0.4	0.2	0.6
01/26/2023 06:00	2,974.7	0.0	2,974.7	105,200.0	312.9	0.4	0.2	0.6
01/26/2023 07:00	3,001.5	0.0	3,001.5	105,200.0	315.8	0.4	0.2	0.6
01/26/2023 08:00	2,966.8	0.0	2,966.8	105,200.0	312.1	0.4	0.2	0.6
01/26/2023 09:00	2,980.7	0.0	2,980.7	105,200.0	313.6	0.4	0.2	0.6
01/26/2023 10:00	2,979.3	0.0	2,979.3	105,200.0	313.4	0.4	0.2	0.6
01/26/2023 11:00	2,945.0	0.0	2,945.0	105,200.0	309.8	0.4	0.2	0.6
01/26/2023 12:00	2,934.1	0.0	2,934.1	105,200.0	308.7	0.4	0.2	0.6
01/26/2023 13:00	2,931.5	0.0	2,931.5	105,200.0	308.4	0.4	0.2	0.6
01/26/2023 14:00	2,934.0	0.0	2,934.0	105,200.0	308.7	0.4	0.2	0.6
01/26/2023 15:00	2,936.1	0.0	2,936.1	105,200.0	308.9	0.4	0.2	0.6
01/26/2023 16:00	2,936.6	0.0	2,936.6	105,200.0	308.9	0.4	0.2	0.6
01/26/2023 17:00	2,940.4	0.0	2,940.4	105,200.0	309.3	0.4	0.2	0.6
01/26/2023 18:00	2,937.2	0.0	2,937.2	105,200.0	309.0	0.4	0.2	0.6
01/26/2023 19:00	2,941.8	0.0	2,941.8	105,200.0	309.5	0.4	0.2	0.6
01/26/2023 20:00	2,938.0	0.0	2,938.0	105,200.0	309.1	0.4	0.2	0.6
01/26/2023 21:00	2,938.9	0.0	2,938.9	105,200.0	309.2	0.4	0.2	0.6
01/26/2023 22:00	2,941.2	0.0	2,941.2	105,200.0	309.4	0.4	0.2	0.6
01/26/2023 23:00	2,938.2	0.0	2,938.2	105,200.0	309.1	0.4	0.2	0.6
Average/Sum#:	2,960.3	0.0	2,960.3	105,200.0	311.4	0.4	0.2	0.6
Minimum:	2,931.5	0.0	2,931.5	105,200.0	308.4	0.4	0.2	0.6
Maximum:	3,010.1	0.0	3,010.1	105,200.0	316.7	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2023 00:00	2,943.2	0.0	2,943.2	105,200.0	309.6	0.4	0.2	0.6
01/27/2023 01:00	2,968.6	0.0	2,968.6	105,200.0	312.3	0.4	0.2	0.6
01/27/2023 02:00	3,001.2	0.0	3,001.2	105,200.0	315.7	0.4	0.2	0.6
01/27/2023 03:00	3,001.7	0.0	3,001.7	105,200.0	315.8	0.4	0.2	0.6
01/27/2023 04:00	3,002.3	0.0	3,002.3	105,200.0	315.8	0.4	0.2	0.6
01/27/2023 05:00	2,999.9	0.0	2,999.9	105,200.0	315.6	0.4	0.2	0.6
01/27/2023 06:00	2,999.3	0.0	2,999.3	105,200.0	315.5	0.4	0.2	0.6
01/27/2023 07:00	3,063.1	0.0	3,063.1	105,200.0	322.2	0.4	0.2	0.6
01/27/2023 08:00	2,996.6	0.0	2,996.6	105,200.0	315.2	0.4	0.2	0.6
01/27/2023 09:00	2,987.7	0.0	2,987.7	105,200.0	314.3	0.4	0.2	0.6
01/27/2023 10:00	2,964.5	0.0	2,964.5	105,200.0	311.9	0.4	0.2	0.6
01/27/2023 11:00	2,931.5	0.0	2,931.5	105,200.0	308.4	0.4	0.2	0.6
01/27/2023 12:00	2,933.6	0.0	2,933.6	105,200.0	308.6	0.4	0.2	0.6
01/27/2023 13:00	2,927.0	0.0	2,927.0	105,200.0	307.9	0.4	0.2	0.6
01/27/2023 14:00	2,925.0	0.0	2,925.0	105,200.0	307.7	0.4	0.2	0.6
01/27/2023 15:00	3,430.7	0.7	3,430.8	105,200.0	360.9	0.4	0.2	0.7
01/27/2023 16:00	4,329.7	4.6	4,332.1	105,200.0	455.7	0.5	0.3	0.9
01/27/2023 17:00	4,716.5	184.0	4,841.6	105,200.0	509.3	0.6	0.3	1.0
01/27/2023 18:00	4,875.7	378.0	5,253.7	105,200.0	552.7	0.7	0.3	1.1
01/27/2023 19:00	4,737.2	171.9	4,826.6	105,200.0	507.8	0.6	0.3	1.0
01/27/2023 20:00	2,971.0	0.0	2,971.0	105,200.0	312.5	0.4	0.2	0.7
01/27/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/27/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/27/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,319.3	35.2	3,347.7	105,200.0	352.2	0.4	0.2	0.7
Minimum:	2,925.0	0.0	2,925.0	105,200.0	307.7	0.4	0.2	0.6
Maximum:	4,875.7	378.0	5,253.7	105,200.0	552.7	0.7	0.3	1.1
%SI	12.50	12.50	12.50	0.00	12.50	12.50	12.50	12.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/28/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 09:00	3,073.7	0.0	3,073.7	105,200.0	323.4	0.0	0.0	0.0
01/29/2023 10:00	4,877.1	100.8	4,910.4	105,200.0	516.6	0.6	0.3	1.1
01/29/2023 11:00	4,892.8	340.9	5,155.3	105,200.0	542.3	0.7	0.3	1.1
01/29/2023 12:00	3,610.2	0.0	3,610.2	105,200.0	379.8	0.5	0.2	0.8
01/29/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/29/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,113.5	110.4	4,187.4	105,200.0	440.5	0.6	0.3	1.0
Minimum:	3,073.7	0.0	3,073.7	105,200.0	323.4	0.5	0.2	0.8
Maximum:	4,892.8	340.9	5,155.3	105,200.0	542.3	0.7	0.3	1.1
%SI	83.33	83.33	83.33	0.00	83.33	87.50	87.50	87.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/30/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2023 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
01/31/2023 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/01/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/02/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/03/2023 16:00	2,693.9	0.0	2,693.9	104,900.0	282.6	0.0	0.0	0.0
02/03/2023 17:00	4,363.6	144.0	4,432.7	104,900.0	465.0	0.6	0.3	1.0
02/03/2023 18:00	4,896.3	539.9	5,436.2	104,900.0	570.3	0.7	0.3	1.1
02/03/2023 19:00	4,921.0	664.5	5,585.5	104,900.0	585.9	0.7	0.4	1.2
02/03/2023 20:00	4,931.5	637.6	5,569.1	104,900.0	584.2	0.7	0.4	1.2
02/03/2023 21:00	4,943.7	375.8	5,319.5	104,900.0	558.0	0.7	0.3	1.1
02/03/2023 22:00	4,950.0	331.3	5,281.3	104,900.0	554.0	0.7	0.3	1.1
02/03/2023 23:00	4,691.0	139.0	4,763.3	104,900.0	499.7	0.6	0.3	1.0
Average/Sum#:	4,548.9	354.0	4,885.2	104,900.0	512.5	0.7	0.3	1.1
Minimum:	2,693.9	0.0	2,693.9	104,900.0	282.6	0.6	0.3	1.0
Maximum:	4,950.0	664.5	5,585.5	104,900.0	585.9	0.7	0.4	1.2
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2023 00:00	3,214.0	0.0	3,214.0	104,900.0	337.1	0.4	0.2	0.7
02/04/2023 01:00	2,982.3	0.0	2,982.3	104,900.0	312.8	0.4	0.2	0.6
02/04/2023 02:00	2,980.5	0.0	2,980.5	104,900.0	312.7	0.4	0.2	0.6
02/04/2023 03:00	2,966.8	0.0	2,966.8	104,900.0	311.2	0.4	0.2	0.6
02/04/2023 04:00	3,007.2	0.0	3,007.2	104,900.0	315.5	0.4	0.2	0.6
02/04/2023 05:00	2,971.8	0.0	2,971.8	104,900.0	311.7	0.4	0.2	0.6
02/04/2023 06:00	3,003.8	0.0	3,003.8	104,900.0	315.1	0.4	0.2	0.6
02/04/2023 07:00	2,973.8	0.0	2,973.8	104,900.0	312.0	0.4	0.2	0.6
02/04/2023 08:00	2,962.8	0.0	2,962.8	104,900.0	310.8	0.4	0.2	0.6
02/04/2023 09:00	2,986.9	0.0	2,986.9	104,900.0	313.3	0.4	0.2	0.6
02/04/2023 10:00	2,952.8	0.0	2,952.8	104,900.0	309.7	0.4	0.2	0.6
02/04/2023 11:00	2,942.1	0.0	2,942.1	104,900.0	308.6	0.4	0.2	0.6
02/04/2023 12:00	2,950.5	0.0	2,950.5	104,900.0	309.5	0.4	0.2	0.6
02/04/2023 13:00	2,946.1	0.0	2,946.1	104,900.0	309.0	0.4	0.2	0.6
02/04/2023 14:00	2,946.1	0.0	2,946.1	104,900.0	309.0	0.4	0.2	0.6
02/04/2023 15:00	3,388.1	0.0	3,388.1	104,900.0	355.4	0.4	0.2	0.7
02/04/2023 16:00	3,811.9	1.2	3,811.9	104,900.0	399.9	0.5	0.2	0.8
02/04/2023 17:00	4,338.2	178.5	4,423.9	104,900.0	464.1	0.6	0.3	0.9
02/04/2023 18:00	4,862.3	580.3	5,442.6	104,900.0	570.9	0.7	0.3	1.1
02/04/2023 19:00	4,856.4	645.2	5,501.6	104,900.0	577.1	0.7	0.3	1.2
02/04/2023 20:00	4,856.7	731.1	5,587.8	104,900.0	586.2	0.7	0.4	1.2
02/04/2023 21:00	4,847.7	731.0	5,578.7	104,900.0	585.2	0.7	0.4	1.2
02/04/2023 22:00	4,541.4	238.5	4,653.5	104,900.0	488.2	0.6	0.3	1.0
02/04/2023 23:00	3,232.0	0.0	3,232.0	104,900.0	339.0	0.4	0.2	0.7
Average/Sum#:	3,480.1	129.4	3,600.3	104,900.0	377.7	0.5	0.2	0.7
Minimum:	2,942.1	0.0	2,942.1	104,900.0	308.6	0.4	0.2	0.6
Maximum:	4,862.3	731.1	5,587.8	104,900.0	586.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2023 00:00	2,990.0	0.0	2,990.0	104,900.0	313.7	0.4	0.2	0.6
02/05/2023 01:00	2,975.3	0.0	2,975.3	104,900.0	312.1	0.4	0.2	0.6
02/05/2023 02:00	2,977.3	0.0	2,977.3	104,900.0	312.3	0.4	0.2	0.6
02/05/2023 03:00	2,995.0	0.0	2,995.0	104,900.0	314.2	0.4	0.2	0.6
02/05/2023 04:00	3,000.2	0.0	3,000.2	104,900.0	314.7	0.4	0.2	0.6
02/05/2023 05:00	2,999.3	0.0	2,999.3	104,900.0	314.6	0.4	0.2	0.6
02/05/2023 06:00	3,003.2	0.0	3,003.2	104,900.0	315.0	0.4	0.2	0.6
02/05/2023 07:00	3,007.0	0.0	3,007.0	104,900.0	315.4	0.4	0.2	0.6
02/05/2023 08:00	3,002.6	0.0	3,002.6	104,900.0	315.0	0.4	0.2	0.6
02/05/2023 09:00	2,995.3	0.0	2,995.3	104,900.0	314.2	0.4	0.2	0.6
02/05/2023 10:00	2,975.1	0.0	2,975.1	104,900.0	312.1	0.4	0.2	0.6
02/05/2023 11:00	2,977.7	0.0	2,977.7	104,900.0	312.4	0.4	0.2	0.6
02/05/2023 12:00	2,977.8	0.0	2,977.8	104,900.0	312.4	0.4	0.2	0.6
02/05/2023 13:00	2,971.6	0.0	2,971.6	104,900.0	311.7	0.4	0.2	0.6
02/05/2023 14:00	2,970.4	0.0	2,970.4	104,900.0	311.6	0.4	0.2	0.6
02/05/2023 15:00	2,966.1	0.0	2,966.1	104,900.0	311.1	0.4	0.2	0.6
02/05/2023 16:00	2,969.7	0.0	2,969.7	104,900.0	311.5	0.4	0.2	0.6
02/05/2023 17:00	3,495.3	0.0	3,495.3	104,900.0	366.7	0.4	0.2	0.7
02/05/2023 18:00	3,450.7	0.0	3,450.7	104,900.0	362.0	0.4	0.2	0.7
02/05/2023 19:00	3,380.5	0.0	3,380.5	104,900.0	354.6	0.4	0.2	0.7
02/05/2023 20:00	4,664.7	216.4	4,822.7	104,900.0	505.9	0.6	0.3	1.0
02/05/2023 21:00	4,635.0	103.1	4,688.6	104,900.0	491.8	0.6	0.3	1.0
02/05/2023 22:00	3,186.4	0.0	3,186.4	104,900.0	334.3	0.4	0.2	0.7
02/05/2023 23:00	2,968.5	0.0	2,968.5	104,900.0	311.4	0.4	0.2	0.6
Average/Sum#:	3,188.9	13.3	3,197.8	104,900.0	335.4	0.4	0.2	0.7
Minimum:	2,966.1	0.0	2,966.1	104,900.0	311.1	0.4	0.2	0.6
Maximum:	4,664.7	216.4	4,822.7	104,900.0	505.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2023 00:00	2,973.2	0.0	2,973.2	104,900.0	311.9	0.4	0.2	0.6
02/06/2023 01:00	2,967.3	0.0	2,967.3	104,900.0	311.3	0.4	0.2	0.6
02/06/2023 02:00	2,980.3	0.0	2,980.3	104,900.0	312.6	0.4	0.2	0.6
02/06/2023 03:00	2,960.8	0.0	2,960.8	104,900.0	310.6	0.4	0.2	0.6
02/06/2023 04:00	2,950.7	0.0	2,950.7	104,900.0	309.5	0.4	0.2	0.6
02/06/2023 05:00	2,946.1	0.0	2,946.1	104,900.0	309.0	0.4	0.2	0.6
02/06/2023 06:00	2,950.8	0.0	2,950.8	104,900.0	309.5	0.4	0.2	0.6
02/06/2023 07:00	2,953.6	0.0	2,953.6	104,900.0	309.8	0.4	0.2	0.6
02/06/2023 08:00	2,956.8	0.0	2,956.8	104,900.0	310.2	0.4	0.2	0.6
02/06/2023 09:00	2,965.4	0.0	2,965.4	104,900.0	311.1	0.4	0.2	0.6
02/06/2023 10:00	2,958.8	0.0	2,958.8	104,900.0	310.4	0.4	0.2	0.6
02/06/2023 11:00	2,954.1	0.0	2,954.1	104,900.0	309.9	0.4	0.2	0.6
02/06/2023 12:00	2,951.8	0.0	2,951.8	104,900.0	309.6	0.4	0.2	0.6
02/06/2023 13:00	2,945.5	0.0	2,945.5	104,900.0	309.0	0.4	0.2	0.6
02/06/2023 14:00	2,954.7	0.0	2,954.7	104,900.0	309.9	0.4	0.2	0.6
02/06/2023 15:00	3,480.3	0.0	3,480.3	104,900.0	365.1	0.4	0.2	0.7
02/06/2023 16:00	3,323.7	0.0	3,323.7	104,900.0	348.7	0.4	0.2	0.7
02/06/2023 17:00	4,780.6	390.2	5,065.4	104,900.0	531.4	0.7	0.3	1.1
02/06/2023 18:00	4,906.6	676.2	5,582.8	104,900.0	585.6	0.7	0.4	1.2
02/06/2023 19:00	4,914.9	660.5	5,575.4	104,900.0	584.9	0.7	0.4	1.2
02/06/2023 20:00	4,932.7	955.2	5,887.9	104,900.0	617.6	0.7	0.4	1.2
02/06/2023 21:00	4,939.0	487.0	5,426.0	104,900.0	569.2	0.7	0.3	1.1
02/06/2023 22:00	4,496.5	104.3	4,545.5	104,900.0	476.8	0.6	0.3	1.0
02/06/2023 23:00	3,327.5	0.0	3,327.5	104,900.0	349.1	0.4	0.2	0.7
Average/Sum#:	3,478.0	136.4	3,607.7	104,900.0	378.4	0.5	0.2	0.7
Minimum:	2,945.5	0.0	2,945.5	104,900.0	309.0	0.4	0.2	0.6
Maximum:	4,939.0	955.2	5,887.9	104,900.0	617.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2023 00:00	2,982.5	0.0	2,982.5	104,900.0	312.9	0.4	0.2	0.6
02/07/2023 01:00	2,972.5	0.0	2,972.5	104,900.0	311.8	0.4	0.2	0.6
02/07/2023 02:00	2,973.5	0.0	2,973.5	104,900.0	311.9	0.4	0.2	0.6
02/07/2023 03:00	2,981.1	0.0	2,981.1	104,900.0	312.7	0.4	0.2	0.6
02/07/2023 04:00	2,973.8	0.0	2,973.8	104,900.0	312.0	0.4	0.2	0.6
02/07/2023 05:00	2,973.9	0.0	2,973.9	104,900.0	312.0	0.4	0.2	0.6
02/07/2023 06:00	2,981.0	0.0	2,981.0	104,900.0	312.7	0.4	0.2	0.6
02/07/2023 07:00	3,026.0	0.0	3,026.0	104,900.0	317.4	0.4	0.2	0.6
02/07/2023 08:00	2,974.5	0.0	2,974.5	104,900.0	312.0	0.4	0.2	0.6
02/07/2023 09:00	2,964.5	0.0	2,964.5	104,900.0	311.0	0.4	0.2	0.6
02/07/2023 10:00	2,966.3	0.0	2,966.3	104,900.0	311.2	0.4	0.2	0.6
02/07/2023 11:00	2,968.5	0.0	2,968.5	104,900.0	311.4	0.4	0.2	0.6
02/07/2023 12:00	2,966.4	0.0	2,966.4	104,900.0	311.2	0.4	0.2	0.6
02/07/2023 13:00	2,970.2	0.0	2,970.2	104,900.0	311.6	0.4	0.2	0.6
02/07/2023 14:00	2,971.1	0.0	2,971.1	104,900.0	311.7	0.4	0.2	0.6
02/07/2023 15:00	3,495.3	14.8	3,497.5	104,900.0	366.9	0.4	0.2	0.7
02/07/2023 16:00	3,549.9	2.5	3,550.0	104,900.0	372.4	0.4	0.2	0.7
02/07/2023 17:00	4,836.3	369.8	5,106.3	104,900.0	535.7	0.7	0.3	1.1
02/07/2023 18:00	4,894.4	774.0	5,668.4	104,900.0	594.6	0.7	0.4	1.2
02/07/2023 19:00	4,914.8	838.3	5,753.1	104,900.0	603.5	0.7	0.4	1.2
02/07/2023 20:00	4,930.5	934.5	5,865.0	104,900.0	615.2	0.7	0.4	1.2
02/07/2023 21:00	4,952.0	785.1	5,737.1	104,900.0	601.8	0.7	0.4	1.2
02/07/2023 22:00	4,955.7	616.5	5,572.2	104,900.0	584.5	0.7	0.4	1.2
02/07/2023 23:00	4,967.4	402.3	5,369.7	104,900.0	563.3	0.7	0.3	1.1
Average/Sum#:	3,589.3	197.4	3,781.9	104,900.0	396.7	0.5	0.3	0.8
Minimum:	2,964.5	0.0	2,964.5	104,900.0	311.0	0.4	0.2	0.6
Maximum:	4,967.4	934.5	5,865.0	104,900.0	615.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2023 00:00	4,777.6	4.9	4,778.3	104,900.0	501.2	0.6	0.3	1.0
02/08/2023 01:00	4,776.0	0.8	4,776.0	104,900.0	501.0	0.6	0.3	1.0
02/08/2023 02:00	4,667.0	0.0	4,667.0	104,900.0	489.6	0.6	0.3	1.0
02/08/2023 03:00	4,610.4	0.0	4,610.4	104,900.0	483.6	0.6	0.3	1.0
02/08/2023 04:00	4,700.1	0.0	4,700.1	104,900.0	493.0	0.6	0.3	1.0
02/08/2023 05:00	4,873.1	23.9	4,878.6	104,900.0	511.8	0.6	0.3	1.0
02/08/2023 06:00	5,050.5	634.5	5,685.0	104,900.0	596.4	0.7	0.4	1.2
02/08/2023 07:00	4,857.4	195.0	4,964.7	104,900.0	520.8	0.6	0.3	1.1
02/08/2023 08:00	3,015.2	0.0	3,015.2	104,900.0	316.3	0.4	0.2	0.7
02/08/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/08/2023 15:00	231.8	0.0	231.8	104,900.0	24.3	0.0	0.0	0.0
02/08/2023 16:00	3,051.3	0.0	3,051.3	104,900.0	320.1	0.5	0.2	0.8
02/08/2023 17:00	4,830.5	432.5	5,219.8	104,900.0	547.6	0.7	0.3	1.1
02/08/2023 18:00	4,883.6	1,058.1	5,941.7	104,900.0	623.3	0.7	0.4	1.2
02/08/2023 19:00	4,901.6	847.7	5,749.3	104,900.0	603.1	0.7	0.4	1.2
02/08/2023 20:00	4,929.9	661.1	5,591.0	104,900.0	586.5	0.7	0.4	1.2
02/08/2023 21:00	4,933.4	1,050.5	5,983.9	104,900.0	627.7	0.8	0.4	1.3
02/08/2023 22:00	4,948.5	759.1	5,707.6	104,900.0	598.7	0.7	0.4	1.2
02/08/2023 23:00	4,942.3	329.5	5,196.0	104,900.0	545.1	0.7	0.3	1.1
Average/Sum#:	4,387.8	333.2	4,708.2	104,900.0	493.9	0.6	0.3	1.1
Minimum:	231.8	0.0	231.8	104,900.0	24.3	0.4	0.2	0.7
Maximum:	5,050.5	1,058.1	5,983.9	104,900.0	627.7	0.8	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2023 00:00	4,947.6	0.0	4,947.6	104,900.0	519.0	0.6	0.3	1.0
02/09/2023 01:00	4,816.2	0.0	4,816.2	104,900.0	505.2	0.6	0.3	1.0
02/09/2023 02:00	4,958.4	0.0	4,958.4	104,900.0	520.1	0.6	0.3	1.0
02/09/2023 03:00	4,947.5	0.0	4,947.5	104,900.0	519.0	0.6	0.3	1.0
02/09/2023 04:00	4,822.9	1.5	4,823.0	104,900.0	505.9	0.6	0.3	1.0
02/09/2023 05:00	4,997.9	777.0	5,759.4	104,900.0	604.2	0.7	0.4	1.2
02/09/2023 06:00	5,007.6	976.4	5,984.0	104,900.0	627.7	0.8	0.4	1.3
02/09/2023 07:00	4,549.0	220.9	4,670.5	104,900.0	489.9	0.6	0.3	1.0
02/09/2023 08:00	2,509.9	0.0	2,509.9	104,900.0	263.3	0.4	0.2	0.6
02/09/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/09/2023 16:00	2,603.6	0.0	2,603.6	104,900.0	273.1	0.4	0.2	0.6
02/09/2023 17:00	4,607.4	237.8	4,762.0	104,900.0	499.5	0.6	0.3	1.0
02/09/2023 18:00	4,863.6	1,075.3	5,938.9	104,900.0	623.0	0.7	0.4	1.2
02/09/2023 19:00	4,867.2	755.6	5,622.8	104,900.0	589.8	0.7	0.4	1.2
02/09/2023 20:00	4,902.0	938.6	5,840.6	104,900.0	612.7	0.7	0.4	1.2
02/09/2023 21:00	4,906.2	981.3	5,887.5	104,900.0	617.6	0.7	0.4	1.2
02/09/2023 22:00	4,917.6	734.2	5,651.8	104,900.0	592.9	0.7	0.4	1.2
02/09/2023 23:00	3,993.5	68.8	4,012.1	104,900.0	420.9	0.5	0.3	0.9
Average/Sum#:	4,542.2	398.1	4,925.6	104,900.0	516.7	0.6	0.3	1.0
Minimum:	2,509.9	0.0	2,509.9	104,900.0	263.3	0.4	0.2	0.6
Maximum:	5,007.6	1,075.3	5,984.0	104,900.0	627.7	0.8	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/10/2023 15:00	366.1	0.0	366.1	104,900.0	38.4	0.0	0.0	0.0
02/10/2023 16:00	3,017.2	0.0	3,017.2	104,900.0	316.5	0.5	0.2	0.8
02/10/2023 17:00	4,538.7	350.7	4,738.6	104,900.0	497.1	0.6	0.3	1.0
02/10/2023 18:00	4,898.3	369.6	5,267.9	104,900.0	552.6	0.7	0.3	1.1
02/10/2023 19:00	4,919.5	357.1	5,276.6	104,900.0	553.5	0.7	0.3	1.1
02/10/2023 20:00	4,926.3	483.0	5,409.3	104,900.0	567.4	0.7	0.3	1.1
02/10/2023 21:00	4,932.4	528.4	5,460.8	104,900.0	572.8	0.7	0.3	1.1
02/10/2023 22:00	4,957.2	530.0	5,487.2	104,900.0	575.6	0.7	0.3	1.2
02/10/2023 23:00	4,974.3	345.3	5,319.6	104,900.0	558.0	0.7	0.3	1.1
Average/Sum#:	4,170.0	329.3	4,482.6	104,900.0	470.2	0.7	0.3	1.1
Minimum:	366.1	0.0	366.1	104,900.0	38.4	0.5	0.2	0.8
Maximum:	4,974.3	530.0	5,487.2	104,900.0	575.6	0.7	0.3	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2023 00:00	4,982.3	440.7	5,423.0	104,900.0	568.9	0.7	0.3	1.1
02/11/2023 01:00	4,981.6	343.2	5,324.8	104,900.0	558.6	0.7	0.3	1.1
02/11/2023 02:00	4,976.8	261.9	5,238.7	104,900.0	549.5	0.7	0.3	1.1
02/11/2023 03:00	4,974.2	266.8	5,241.0	104,900.0	549.8	0.7	0.3	1.1
02/11/2023 04:00	4,985.4	241.2	5,226.6	104,900.0	548.3	0.7	0.3	1.1
02/11/2023 05:00	4,988.1	299.5	5,287.6	104,900.0	554.7	0.7	0.3	1.1
02/11/2023 06:00	4,996.8	291.9	5,288.7	104,900.0	554.8	0.7	0.3	1.1
02/11/2023 07:00	4,867.2	157.1	4,981.9	104,900.0	522.6	0.6	0.3	1.1
02/11/2023 08:00	3,624.0	0.4	3,624.0	104,900.0	380.2	0.5	0.2	0.8
02/11/2023 09:00	3,116.2	0.0	3,116.2	104,900.0	326.9	0.4	0.2	0.7
02/11/2023 10:00	2,970.7	0.0	2,970.7	104,900.0	311.6	0.4	0.2	0.6
02/11/2023 11:00	2,972.7	0.0	2,972.7	104,900.0	311.8	0.4	0.2	0.6
02/11/2023 12:00	2,977.3	0.0	2,977.3	104,900.0	312.3	0.4	0.2	0.6
02/11/2023 13:00	2,980.2	0.0	2,980.2	104,900.0	312.6	0.4	0.2	0.6
02/11/2023 14:00	2,981.9	0.0	2,981.9	104,900.0	312.8	0.4	0.2	0.6
02/11/2023 15:00	3,499.1	1.5	3,499.2	104,900.0	367.1	0.4	0.2	0.7
02/11/2023 16:00	3,565.2	0.0	3,565.2	104,900.0	374.0	0.4	0.2	0.7
02/11/2023 17:00	4,509.9	303.3	4,707.0	104,900.0	493.8	0.6	0.3	1.0
02/11/2023 18:00	4,865.6	525.2	5,390.8	104,900.0	565.5	0.7	0.3	1.1
02/11/2023 19:00	4,894.6	470.4	5,365.0	104,900.0	562.8	0.7	0.3	1.1
02/11/2023 20:00	4,909.4	480.6	5,390.0	104,900.0	565.4	0.7	0.3	1.1
02/11/2023 21:00	4,924.5	612.6	5,537.1	104,900.0	580.8	0.7	0.3	1.2
02/11/2023 22:00	4,944.4	610.4	5,554.8	104,900.0	582.7	0.7	0.3	1.2
02/11/2023 23:00	4,955.7	409.4	5,365.1	104,900.0	562.8	0.7	0.3	1.1
Average/Sum#:	4,268.5	238.2	4,500.4	104,900.0	472.1	0.6	0.3	0.9
Minimum:	2,970.7	0.0	2,970.7	104,900.0	311.6	0.4	0.2	0.6
Maximum:	4,996.8	612.6	5,554.8	104,900.0	582.7	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2023 00:00	4,964.6	625.2	5,589.8	104,900.0	586.4	0.7	0.4	1.2
02/12/2023 01:00	4,967.0	585.7	5,552.7	104,900.0	582.5	0.7	0.3	1.2
02/12/2023 02:00	4,987.3	475.6	5,462.9	104,900.0	573.1	0.7	0.3	1.1
02/12/2023 03:00	4,974.8	624.3	5,599.1	104,900.0	587.3	0.7	0.4	1.2
02/12/2023 04:00	4,969.3	647.7	5,617.0	104,900.0	589.2	0.7	0.4	1.2
02/12/2023 05:00	4,974.2	612.9	5,587.1	104,900.0	586.1	0.7	0.4	1.2
02/12/2023 06:00	4,969.3	529.8	5,499.1	104,900.0	576.9	0.7	0.3	1.2
02/12/2023 07:00	4,531.2	195.3	4,623.0	104,900.0	485.0	0.6	0.3	1.0
02/12/2023 08:00	3,110.5	0.0	3,110.5	104,900.0	326.3	0.4	0.2	0.7
02/12/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/12/2023 15:00	2,261.7	0.0	2,261.7	104,900.0	237.3	0.0	0.0	0.0
02/12/2023 16:00	4,025.7	20.1	4,027.1	104,900.0	422.4	0.5	0.3	0.9
02/12/2023 17:00	4,675.2	786.2	5,461.4	104,900.0	572.9	0.7	0.3	1.1
02/12/2023 18:00	4,748.7	536.2	5,284.9	104,900.0	554.4	0.7	0.3	1.1
02/12/2023 19:00	4,776.6	745.5	5,522.1	104,900.0	579.3	0.7	0.3	1.2
02/12/2023 20:00	4,813.1	813.4	5,626.5	104,900.0	590.2	0.7	0.4	1.2
02/12/2023 21:00	4,805.3	443.4	5,137.9	104,900.0	539.0	0.7	0.3	1.1
02/12/2023 22:00	3,942.0	0.0	3,942.0	104,900.0	413.5	0.5	0.2	0.8
02/12/2023 23:00	3,406.1	0.0	3,406.1	104,900.0	357.3	0.4	0.2	0.7
Average/Sum#:	4,439.0	424.5	4,850.6	104,900.0	508.8	0.6	0.3	1.1
Minimum:	2,261.7	0.0	2,261.7	104,900.0	237.3	0.4	0.2	0.7
Maximum:	4,987.3	813.4	5,626.5	104,900.0	590.2	0.7	0.4	1.2
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2023 00:00	3,473.3	0.0	3,473.3	104,900.0	364.3	0.4	0.2	0.7
02/13/2023 01:00	2,969.1	0.0	2,969.1	104,900.0	311.5	0.4	0.2	0.6
02/13/2023 02:00	2,977.7	0.0	2,977.7	104,900.0	312.4	0.4	0.2	0.6
02/13/2023 03:00	2,978.7	0.0	2,978.7	104,900.0	312.5	0.4	0.2	0.6
02/13/2023 04:00	2,979.3	0.0	2,979.3	104,900.0	312.5	0.4	0.2	0.6
02/13/2023 05:00	2,987.4	0.0	2,987.4	104,900.0	313.4	0.4	0.2	0.6
02/13/2023 06:00	2,994.0	0.0	2,994.0	104,900.0	314.1	0.4	0.2	0.6
02/13/2023 07:00	3,106.2	0.0	3,106.2	104,900.0	325.8	0.4	0.2	0.7
02/13/2023 08:00	2,986.7	0.0	2,986.7	104,900.0	313.3	0.4	0.2	0.6
02/13/2023 09:00	2,982.6	0.0	2,982.6	104,900.0	312.9	0.4	0.2	0.6
02/13/2023 10:00	2,979.4	0.0	2,979.4	104,900.0	312.5	0.4	0.2	0.6
02/13/2023 11:00	2,986.4	0.0	2,986.4	104,900.0	313.3	0.4	0.2	0.6
02/13/2023 12:00	2,981.9	0.0	2,981.9	104,900.0	312.8	0.4	0.2	0.6
02/13/2023 13:00	2,961.4	0.0	2,961.4	104,900.0	310.7	0.4	0.2	0.6
02/13/2023 14:00	2,944.6	0.0	2,944.6	104,900.0	308.9	0.4	0.2	0.6
02/13/2023 15:00	2,945.7	0.0	2,945.7	104,900.0	309.0	0.4	0.2	0.6
02/13/2023 16:00	2,948.7	0.0	2,948.7	104,900.0	309.3	0.4	0.2	0.6
02/13/2023 17:00	2,947.1	0.0	2,947.1	104,900.0	309.2	0.4	0.2	0.6
02/13/2023 18:00	2,946.6	0.0	2,946.6	104,900.0	309.1	0.4	0.2	0.6
02/13/2023 19:00	2,951.6	0.0	2,951.6	104,900.0	309.6	0.4	0.2	0.6
02/13/2023 20:00	2,954.0	0.0	2,954.0	104,900.0	309.9	0.4	0.2	0.6
02/13/2023 21:00	2,963.7	0.0	2,963.7	104,900.0	310.9	0.4	0.2	0.6
02/13/2023 22:00	2,971.3	0.0	2,971.3	104,900.0	311.7	0.4	0.2	0.6
02/13/2023 23:00	2,974.4	0.0	2,974.4	104,900.0	312.0	0.4	0.2	0.6
Average/Sum#:	2,995.5	0.0	2,995.5	104,900.0	314.2	0.4	0.2	0.6
Minimum:	2,944.6	0.0	2,944.6	104,900.0	308.9	0.4	0.2	0.6
Maximum:	3,473.3	0.0	3,473.3	104,900.0	364.3	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2023 00:00	2,981.3	0.0	2,981.3	104,900.0	312.7	0.4	0.2	0.6
02/14/2023 01:00	2,988.3	0.0	2,988.3	104,900.0	313.5	0.4	0.2	0.6
02/14/2023 02:00	2,989.9	0.0	2,989.9	104,900.0	313.6	0.4	0.2	0.6
02/14/2023 03:00	2,993.0	0.0	2,993.0	104,900.0	314.0	0.4	0.2	0.6
02/14/2023 04:00	2,990.3	0.0	2,990.3	104,900.0	313.7	0.4	0.2	0.6
02/14/2023 05:00	2,990.0	0.0	2,990.0	104,900.0	313.7	0.4	0.2	0.6
02/14/2023 06:00	2,967.1	0.0	2,967.1	104,900.0	311.2	0.4	0.2	0.6
02/14/2023 07:00	2,965.3	0.0	2,965.3	104,900.0	311.1	0.4	0.2	0.6
02/14/2023 08:00	2,959.8	0.0	2,959.8	104,900.0	310.5	0.4	0.2	0.6
02/14/2023 09:00	2,955.1	0.0	2,955.1	104,900.0	310.0	0.4	0.2	0.6
02/14/2023 10:00	2,954.6	0.0	2,954.6	104,900.0	309.9	0.4	0.2	0.6
02/14/2023 11:00	2,956.2	0.0	2,956.2	104,900.0	310.1	0.4	0.2	0.6
02/14/2023 12:00	2,973.1	0.0	2,973.1	104,900.0	311.9	0.4	0.2	0.6
02/14/2023 13:00	2,981.6	0.0	2,981.6	104,900.0	312.8	0.4	0.2	0.6
02/14/2023 14:00	3,206.6	0.0	3,206.6	104,900.0	336.4	0.4	0.2	0.7
02/14/2023 15:00	4,498.5	12.0	4,500.9	104,900.0	472.1	0.6	0.3	0.9
02/14/2023 16:00	4,476.4	44.6	4,500.9	104,900.0	472.1	0.6	0.3	0.9
02/14/2023 17:00	4,927.4	1,068.5	5,995.9	104,900.0	629.0	0.8	0.4	1.3
02/14/2023 18:00	4,957.5	1,168.8	6,126.3	104,900.0	642.6	0.8	0.4	1.3
02/14/2023 19:00	5,000.0	820.8	5,820.8	104,900.0	610.6	0.7	0.4	1.2
02/14/2023 20:00	5,017.7	1,016.1	6,033.8	104,900.0	632.9	0.8	0.4	1.3
02/14/2023 21:00	5,043.5	684.3	5,727.8	104,900.0	600.8	0.7	0.4	1.2
02/14/2023 22:00	5,047.6	375.0	5,422.6	104,900.0	568.8	0.7	0.3	1.1
02/14/2023 23:00	5,062.5	584.9	5,647.4	104,900.0	592.4	0.7	0.4	1.2
Average/Sum#:	3,703.5	240.6	3,942.9	104,900.0	413.6	0.5	0.3	0.8
Minimum:	2,954.6	0.0	2,954.6	104,900.0	309.9	0.4	0.2	0.6
Maximum:	5,062.5	1,168.8	6,126.3	104,900.0	642.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2023 00:00	5,069.2	515.2	5,584.4	104,900.0	585.8	0.7	0.4	1.2
02/15/2023 01:00	5,069.1	483.0	5,552.1	104,900.0	582.4	0.7	0.3	1.2
02/15/2023 02:00	5,080.9	464.7	5,545.6	104,900.0	581.7	0.7	0.3	1.2
02/15/2023 03:00	5,089.8	568.8	5,658.6	104,900.0	593.6	0.7	0.4	1.2
02/15/2023 04:00	5,108.4	840.3	5,948.7	104,900.0	624.0	0.7	0.4	1.2
02/15/2023 05:00	5,106.0	865.2	5,971.2	104,900.0	626.4	0.8	0.4	1.3
02/15/2023 06:00	5,055.7	966.1	6,021.8	104,900.0	631.7	0.8	0.4	1.3
02/15/2023 07:00	3,027.3	0.0	3,027.3	104,900.0	317.6	0.0	0.0	0.0
02/15/2023 08:00	3,883.9	0.0	3,883.9	104,900.0	407.4	0.5	0.2	0.8
02/15/2023 09:00	3,263.8	0.0	3,263.8	104,900.0	342.4	0.4	0.2	0.7
02/15/2023 10:00	2,968.9	0.0	2,968.9	104,900.0	311.4	0.4	0.2	0.6
02/15/2023 11:00	2,958.4	0.0	2,958.4	104,900.0	310.3	0.4	0.2	0.6
02/15/2023 12:00	2,947.5	0.0	2,947.5	104,900.0	309.2	0.4	0.2	0.6
02/15/2023 13:00	2,947.8	0.0	2,947.8	104,900.0	309.2	0.4	0.2	0.6
02/15/2023 14:00	2,949.0	0.0	2,949.0	104,900.0	309.4	0.4	0.2	0.6
02/15/2023 15:00	3,126.8	0.0	3,126.8	104,900.0	328.0	0.4	0.2	0.7
02/15/2023 16:00	3,973.6	0.0	3,973.6	104,900.0	416.8	0.5	0.3	0.8
02/15/2023 17:00	4,455.5	131.0	4,530.2	104,900.0	475.2	0.6	0.3	1.0
02/15/2023 18:00	4,910.7	1,171.4	6,082.1	104,900.0	638.0	0.8	0.4	1.3
02/15/2023 19:00	4,941.5	1,165.7	6,107.2	104,900.0	640.6	0.8	0.4	1.3
02/15/2023 20:00	4,980.0	1,121.6	6,101.6	104,900.0	640.1	0.8	0.4	1.3
02/15/2023 21:00	4,977.5	1,172.9	6,150.4	104,900.0	645.2	0.8	0.4	1.3
02/15/2023 22:00	4,964.7	1,127.8	6,092.5	104,900.0	639.1	0.8	0.4	1.3
02/15/2023 23:00	4,959.4	767.3	5,726.7	104,900.0	600.7	0.7	0.4	1.2
Average/Sum#:	4,242.3	473.4	4,713.3	104,900.0	494.4	0.6	0.3	1.0
Minimum:	2,947.5	0.0	2,947.5	104,900.0	309.2	0.4	0.2	0.6
Maximum:	5,108.4	1,172.9	6,150.4	104,900.0	645.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2023 00:00	4,946.5	1.3	4,946.5	104,900.0	518.9	0.6	0.3	1.0
02/16/2023 01:00	4,956.6	0.0	4,956.6	104,900.0	519.9	0.6	0.3	1.0
02/16/2023 02:00	4,968.4	0.0	4,968.4	104,900.0	521.2	0.6	0.3	1.0
02/16/2023 03:00	4,972.2	0.0	4,972.2	104,900.0	521.6	0.6	0.3	1.0
02/16/2023 04:00	4,967.1	0.0	4,967.1	104,900.0	521.0	0.6	0.3	1.0
02/16/2023 05:00	4,966.8	0.0	4,966.8	104,900.0	521.0	0.6	0.3	1.0
02/16/2023 06:00	4,952.1	1.1	4,952.2	104,900.0	519.5	0.6	0.3	1.0
02/16/2023 07:00	4,960.0	328.2	5,281.6	104,900.0	554.0	0.7	0.3	1.1
02/16/2023 08:00	4,050.6	60.3	4,066.9	104,900.0	426.6	0.5	0.3	0.9
02/16/2023 09:00	3,307.5	0.0	3,307.5	104,900.0	347.0	0.4	0.2	0.7
02/16/2023 10:00	2,988.1	0.0	2,988.1	104,900.0	313.5	0.4	0.2	0.6
02/16/2023 11:00	2,989.3	0.0	2,989.3	104,900.0	313.6	0.4	0.2	0.6
02/16/2023 12:00	3,022.1	0.0	3,022.1	104,900.0	317.0	0.4	0.2	0.6
02/16/2023 13:00	2,997.6	0.0	2,997.6	104,900.0	314.4	0.4	0.2	0.6
02/16/2023 14:00	2,995.6	0.0	2,995.6	104,900.0	314.2	0.4	0.2	0.6
02/16/2023 15:00	3,177.4	0.0	3,177.4	104,900.0	333.3	0.4	0.2	0.7
02/16/2023 16:00	3,869.6	0.0	3,869.6	104,900.0	405.9	0.5	0.2	0.8
02/16/2023 17:00	4,078.3	10.0	4,081.3	104,900.0	428.1	0.5	0.3	0.9
02/16/2023 18:00	4,945.2	242.2	5,131.7	104,900.0	538.3	0.7	0.3	1.1
02/16/2023 19:00	4,972.3	402.4	5,374.7	104,900.0	563.8	0.7	0.3	1.1
02/16/2023 20:00	4,978.3	548.7	5,527.0	104,900.0	579.8	0.7	0.3	1.2
02/16/2023 21:00	4,978.3	594.6	5,572.9	104,900.0	584.6	0.7	0.4	1.2
02/16/2023 22:00	4,979.6	681.2	5,660.8	104,900.0	593.8	0.7	0.4	1.2
02/16/2023 23:00	4,973.5	448.7	5,422.2	104,900.0	568.8	0.7	0.3	1.1
Average/Sum#:	4,291.4	138.3	4,424.8	104,900.0	464.2	0.6	0.3	0.9
Minimum:	2,988.1	0.0	2,988.1	104,900.0	313.5	0.4	0.2	0.6
Maximum:	4,979.6	681.2	5,660.8	104,900.0	593.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2023 00:00	4,974.6	498.2	5,472.8	104,900.0	574.1	0.7	0.3	1.1
02/17/2023 01:00	4,963.1	258.8	5,221.9	104,900.0	547.8	0.7	0.3	1.1
02/17/2023 02:00	4,962.5	265.6	5,228.1	104,900.0	548.4	0.7	0.3	1.1
02/17/2023 03:00	3,563.7	2.0	3,563.8	104,900.0	373.8	0.4	0.2	0.7
02/17/2023 04:00	3,239.3	0.0	3,239.3	104,900.0	339.8	0.4	0.2	0.7
02/17/2023 05:00	2,990.4	0.0	2,990.4	104,900.0	313.7	0.4	0.2	0.6
02/17/2023 06:00	2,970.7	0.0	2,970.7	104,900.0	311.6	0.4	0.2	0.6
02/17/2023 07:00	2,958.5	0.0	2,958.5	104,900.0	310.3	0.4	0.2	0.6
02/17/2023 08:00	2,945.6	0.0	2,945.6	104,900.0	309.0	0.4	0.2	0.6
02/17/2023 09:00	2,943.1	0.0	2,943.1	104,900.0	308.7	0.4	0.2	0.6
02/17/2023 10:00	2,953.8	0.0	2,953.8	104,900.0	309.9	0.4	0.2	0.6
02/17/2023 11:00	3,078.8	0.0	3,078.8	104,900.0	323.0	0.4	0.2	0.6
02/17/2023 12:00	3,556.9	0.0	3,556.9	104,900.0	373.1	0.4	0.2	0.7
02/17/2023 13:00	2,996.3	0.0	2,996.3	104,900.0	314.3	0.4	0.2	0.6
02/17/2023 14:00	2,988.0	0.0	2,988.0	104,900.0	313.4	0.4	0.2	0.6
02/17/2023 15:00	2,963.1	0.0	2,963.1	104,900.0	310.8	0.4	0.2	0.6
02/17/2023 16:00	2,974.7	0.0	2,974.7	104,900.0	312.0	0.4	0.2	0.6
02/17/2023 17:00	2,973.1	0.0	2,973.1	104,900.0	311.9	0.4	0.2	0.6
02/17/2023 18:00	2,989.2	0.0	2,989.2	104,900.0	313.6	0.4	0.2	0.6
02/17/2023 19:00	2,989.1	0.0	2,989.1	104,900.0	313.6	0.4	0.2	0.6
02/17/2023 20:00	2,992.3	0.0	2,992.3	104,900.0	313.9	0.4	0.2	0.6
02/17/2023 21:00	2,993.8	0.0	2,993.8	104,900.0	314.0	0.4	0.2	0.6
02/17/2023 22:00	2,992.9	0.0	2,992.9	104,900.0	314.0	0.4	0.2	0.6
02/17/2023 23:00	2,990.3	0.0	2,990.3	104,900.0	313.7	0.4	0.2	0.6
Average/Sum#:	3,289.3	42.7	3,331.9	104,900.0	349.5	0.4	0.2	0.7
Minimum:	2,943.1	0.0	2,943.1	104,900.0	308.7	0.4	0.2	0.6
Maximum:	4,974.6	498.2	5,472.8	104,900.0	574.1	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2023 00:00	2,984.4	0.0	2,984.4	104,900.0	313.1	0.4	0.2	0.6
02/18/2023 01:00	2,964.0	0.0	2,964.0	104,900.0	310.9	0.4	0.2	0.6
02/18/2023 02:00	2,963.4	0.0	2,963.4	104,900.0	310.9	0.4	0.2	0.6
02/18/2023 03:00	2,965.6	0.0	2,965.6	104,900.0	311.1	0.4	0.2	0.6
02/18/2023 04:00	2,969.5	0.0	2,969.5	104,900.0	311.5	0.4	0.2	0.6
02/18/2023 05:00	2,965.1	0.0	2,965.1	104,900.0	311.0	0.4	0.2	0.6
02/18/2023 06:00	2,956.8	0.0	2,956.8	104,900.0	310.2	0.4	0.2	0.6
02/18/2023 07:00	2,962.2	0.0	2,962.2	104,900.0	310.7	0.4	0.2	0.6
02/18/2023 08:00	2,958.4	0.0	2,958.4	104,900.0	310.3	0.4	0.2	0.6
02/18/2023 09:00	2,964.9	0.0	2,964.9	104,900.0	311.0	0.4	0.2	0.6
02/18/2023 10:00	2,960.3	0.0	2,960.3	104,900.0	310.5	0.4	0.2	0.6
02/18/2023 11:00	2,960.1	0.0	2,960.1	104,900.0	310.5	0.4	0.2	0.6
02/18/2023 12:00	2,958.1	0.0	2,958.1	104,900.0	310.3	0.4	0.2	0.6
02/18/2023 13:00	2,957.3	0.0	2,957.3	104,900.0	310.2	0.4	0.2	0.6
02/18/2023 14:00	2,954.9	0.0	2,954.9	104,900.0	310.0	0.4	0.2	0.6
02/18/2023 15:00	2,954.3	0.0	2,954.3	104,900.0	309.9	0.4	0.2	0.6
02/18/2023 16:00	2,964.1	0.0	2,964.1	104,900.0	310.9	0.4	0.2	0.6
02/18/2023 17:00	2,959.3	0.0	2,959.3	104,900.0	310.4	0.4	0.2	0.6
02/18/2023 18:00	2,959.0	0.0	2,959.0	104,900.0	310.4	0.4	0.2	0.6
02/18/2023 19:00	2,961.1	0.0	2,961.1	104,900.0	310.6	0.4	0.2	0.6
02/18/2023 20:00	2,960.8	0.0	2,960.8	104,900.0	310.6	0.4	0.2	0.6
02/18/2023 21:00	2,953.6	0.0	2,953.6	104,900.0	309.8	0.4	0.2	0.6
02/18/2023 22:00	2,950.6	0.0	2,950.6	104,900.0	309.5	0.4	0.2	0.6
02/18/2023 23:00	2,954.3	0.0	2,954.3	104,900.0	309.9	0.4	0.2	0.6
Average/Sum#:	2,960.9	0.0	2,960.9	104,900.0	310.6	0.4	0.2	0.6
Minimum:	2,950.6	0.0	2,950.6	104,900.0	309.5	0.4	0.2	0.6
Maximum:	2,984.4	0.0	2,984.4	104,900.0	313.1	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2023 00:00	2,952.0	0.0	2,952.0	104,900.0	309.7	0.4	0.2	0.6
02/19/2023 01:00	2,955.2	0.0	2,955.2	104,900.0	310.0	0.4	0.2	0.6
02/19/2023 02:00	2,954.7	0.0	2,954.7	104,900.0	309.9	0.4	0.2	0.6
02/19/2023 03:00	2,961.2	0.0	2,961.2	104,900.0	310.6	0.4	0.2	0.6
02/19/2023 04:00	2,965.0	0.0	2,965.0	104,900.0	311.0	0.4	0.2	0.6
02/19/2023 05:00	2,968.9	0.0	2,968.9	104,900.0	311.4	0.4	0.2	0.6
02/19/2023 06:00	2,980.9	0.0	2,980.9	104,900.0	312.7	0.4	0.2	0.6
02/19/2023 07:00	2,983.1	0.0	2,983.1	104,900.0	312.9	0.4	0.2	0.6
02/19/2023 08:00	2,983.7	0.0	2,983.7	104,900.0	313.0	0.4	0.2	0.6
02/19/2023 09:00	2,980.8	0.0	2,980.8	104,900.0	312.7	0.4	0.2	0.6
02/19/2023 10:00	2,983.0	0.0	2,983.0	104,900.0	312.9	0.4	0.2	0.6
02/19/2023 11:00	2,976.3	0.0	2,976.3	104,900.0	312.2	0.4	0.2	0.6
02/19/2023 12:00	2,971.9	0.0	2,971.9	104,900.0	311.8	0.4	0.2	0.6
02/19/2023 13:00	2,961.3	0.0	2,961.3	104,900.0	310.6	0.4	0.2	0.6
02/19/2023 14:00	2,930.4	0.0	2,930.4	104,900.0	307.4	0.4	0.2	0.6
02/19/2023 15:00	2,960.3	0.0	2,960.3	104,900.0	310.5	0.4	0.2	0.6
02/19/2023 16:00	2,929.6	0.0	2,929.6	104,900.0	307.3	0.4	0.2	0.6
02/19/2023 17:00	2,931.9	0.0	2,931.9	104,900.0	307.6	0.4	0.2	0.6
02/19/2023 18:00	2,982.0	0.0	2,982.0	104,900.0	312.8	0.4	0.2	0.6
02/19/2023 19:00	2,968.2	0.0	2,968.2	104,900.0	311.4	0.4	0.2	0.6
02/19/2023 20:00	2,957.3	0.0	2,957.3	104,900.0	310.2	0.4	0.2	0.6
02/19/2023 21:00	2,958.1	0.0	2,958.1	104,900.0	310.3	0.4	0.2	0.6
02/19/2023 22:00	2,968.0	0.0	2,968.0	104,900.0	311.3	0.4	0.2	0.6
02/19/2023 23:00	2,980.8	0.0	2,980.8	104,900.0	312.7	0.4	0.2	0.6
Average/Sum#:	2,964.4	0.0	2,964.4	104,900.0	311.0	0.4	0.2	0.6
Minimum:	2,929.6	0.0	2,929.6	104,900.0	307.3	0.4	0.2	0.6
Maximum:	2,983.7	0.0	2,983.7	104,900.0	313.0	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2023 00:00	2,985.6	0.0	2,985.6	104,900.0	313.2	0.4	0.2	0.6
02/20/2023 01:00	2,994.4	0.0	2,994.4	104,900.0	314.1	0.4	0.2	0.6
02/20/2023 02:00	2,990.7	0.0	2,990.7	104,900.0	313.7	0.4	0.2	0.6
02/20/2023 03:00	2,988.3	0.0	2,988.3	104,900.0	313.5	0.4	0.2	0.6
02/20/2023 04:00	2,991.3	0.0	2,991.3	104,900.0	313.8	0.4	0.2	0.6
02/20/2023 05:00	2,993.9	0.0	2,993.9	104,900.0	314.1	0.4	0.2	0.6
02/20/2023 06:00	2,998.4	0.0	2,998.4	104,900.0	314.5	0.4	0.2	0.6
02/20/2023 07:00	3,326.4	0.0	3,326.4	104,900.0	348.9	0.4	0.2	0.7
02/20/2023 08:00	2,993.6	0.0	2,993.6	104,900.0	314.0	0.4	0.2	0.6
02/20/2023 09:00	3,001.5	0.0	3,001.5	104,900.0	314.9	0.4	0.2	0.6
02/20/2023 10:00	3,002.8	0.0	3,002.8	104,900.0	315.0	0.4	0.2	0.6
02/20/2023 11:00	2,968.0	0.0	2,968.0	104,900.0	311.3	0.4	0.2	0.6
02/20/2023 12:00	2,980.0	0.0	2,980.0	104,900.0	312.6	0.4	0.2	0.6
02/20/2023 13:00	2,960.2	0.0	2,960.2	104,900.0	310.5	0.4	0.2	0.6
02/20/2023 14:00	2,957.3	0.0	2,957.3	104,900.0	310.2	0.4	0.2	0.6
02/20/2023 15:00	3,461.8	2.3	3,461.9	104,900.0	363.2	0.4	0.2	0.7
02/20/2023 16:00	3,473.2	0.0	3,473.2	104,900.0	364.3	0.4	0.2	0.7
02/20/2023 17:00	4,688.0	576.5	5,108.8	104,900.0	535.9	0.7	0.3	1.1
02/20/2023 18:00	4,788.2	785.8	5,574.0	104,900.0	584.7	0.7	0.4	1.2
02/20/2023 19:00	4,819.0	789.9	5,608.9	104,900.0	588.4	0.7	0.4	1.2
02/20/2023 20:00	4,839.5	748.6	5,588.1	104,900.0	586.2	0.7	0.4	1.2
02/20/2023 21:00	4,847.4	552.5	5,399.9	104,900.0	566.4	0.7	0.3	1.1
02/20/2023 22:00	4,496.4	195.9	4,604.1	104,900.0	483.0	0.6	0.3	1.0
02/20/2023 23:00	2,495.3	0.0	2,495.3	104,900.0	261.8	0.4	0.2	0.6
Average/Sum#:	3,460.1	152.1	3,601.9	104,900.0	377.8	0.5	0.2	0.7
Minimum:	2,495.3	0.0	2,495.3	104,900.0	261.8	0.4	0.2	0.6
Maximum:	4,847.4	789.9	5,608.9	104,900.0	588.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/21/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/22/2023 16:00	2,986.0	0.0	2,986.0	104,900.0	313.2	0.0	0.0	0.0
02/22/2023 17:00	4,538.6	145.1	4,608.2	104,900.0	483.4	0.6	0.3	1.0
02/22/2023 18:00	4,913.9	732.1	5,646.0	104,900.0	592.3	0.7	0.4	1.2
02/22/2023 19:00	4,950.7	699.3	5,650.0	104,900.0	592.7	0.7	0.4	1.2
02/22/2023 20:00	4,969.7	672.9	5,642.6	104,900.0	591.9	0.7	0.4	1.2
02/22/2023 21:00	4,967.5	550.8	5,518.3	104,900.0	578.9	0.7	0.3	1.2
02/22/2023 22:00	4,639.0	1.4	4,639.0	104,900.0	486.6	0.6	0.3	1.0
02/22/2023 23:00	4,430.3	0.0	4,430.3	104,900.0	464.7	0.6	0.3	0.9
Average/Sum#:	4,549.5	350.2	4,890.1	104,900.0	513.0	0.7	0.3	1.1
Minimum:	2,986.0	0.0	2,986.0	104,900.0	313.2	0.6	0.3	0.9
Maximum:	4,969.7	732.1	5,650.0	104,900.0	592.7	0.7	0.4	1.2
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2023 00:00	4,968.7	592.9	5,431.2	104,900.0	569.7	0.7	0.4	1.2
02/23/2023 01:00	4,986.2	1,112.6	6,098.8	104,900.0	639.8	0.8	0.4	1.3
02/23/2023 02:00	4,986.1	953.3	5,939.4	104,900.0	623.0	0.7	0.4	1.2
02/23/2023 03:00	4,988.3	1,066.5	6,054.8	104,900.0	635.1	0.8	0.4	1.3
02/23/2023 04:00	4,980.8	995.5	5,976.3	104,900.0	626.9	0.8	0.4	1.3
02/23/2023 05:00	4,977.7	985.2	5,962.9	104,900.0	625.5	0.8	0.4	1.3
02/23/2023 06:00	4,981.3	1,126.4	6,107.7	104,900.0	640.7	0.8	0.4	1.3
02/23/2023 07:00	4,986.6	309.1	5,295.7	104,900.0	555.5	0.7	0.3	1.1
02/23/2023 08:00	4,993.3	317.0	5,310.3	104,900.0	557.1	0.7	0.3	1.1
02/23/2023 09:00	4,996.3	256.0	5,252.3	104,900.0	551.0	0.7	0.3	1.1
02/23/2023 10:00	4,979.1	271.1	5,250.2	104,900.0	550.7	0.7	0.3	1.1
02/23/2023 11:00	4,971.3	325.1	5,296.4	104,900.0	555.6	0.7	0.3	1.1
02/23/2023 12:00	4,512.4	141.0	4,585.7	104,900.0	481.0	0.6	0.3	1.0
02/23/2023 13:00	2,397.7	0.0	2,397.7	104,900.0	251.5	0.4	0.2	0.6
02/23/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/23/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,764.7	603.7	5,354.2	104,900.0	561.7	0.7	0.3	1.1
Minimum:	2,397.7	0.0	2,397.7	104,900.0	251.5	0.4	0.2	0.6
Maximum:	4,996.3	1,126.4	6,107.7	104,900.0	640.7	0.8	0.4	1.3
%SI	41.67	41.67	41.67	0.00	41.67	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/25/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
02/26/2023 00:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 01:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 02:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 03:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 04:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 05:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 06:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 07:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 08:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 09:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 10:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 11:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 12:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 13:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 14:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 15:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 16:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 17:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 18:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 19:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 20:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 21:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 22:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
02/26/2023 23:00	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/27/2023 17:00	2,589.2	0.0	2,589.2	104,900.0	271.6	0.0	0.0	0.0
02/27/2023 18:00	4,466.6	100.9	4,493.8	104,900.0	471.4	0.6	0.3	1.0
02/27/2023 19:00	4,970.6	621.1	5,591.7	104,900.0	586.6	0.7	0.4	1.2
02/27/2023 20:00	4,983.4	602.3	5,585.7	104,900.0	585.9	0.7	0.4	1.2
02/27/2023 21:00	4,989.9	512.6	5,502.5	104,900.0	577.2	0.7	0.3	1.2
02/27/2023 22:00	4,525.7	154.3	4,605.9	104,900.0	483.2	0.6	0.3	1.0
02/27/2023 23:00	2,434.1	0.0	2,434.1	104,900.0	255.3	0.4	0.2	0.6
Average/Sum#:	4,137.1	284.5	4,400.4	104,900.0	461.6	0.6	0.3	1.0
Minimum:	2,434.1	0.0	2,434.1	104,900.0	255.3	0.4	0.2	0.6
Maximum:	4,989.9	621.1	5,591.7	104,900.0	586.6	0.7	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
02/28/2023 16:00	468.3	0.0	468.3	104,900.0	49.1	0.0	0.0	0.0
02/28/2023 17:00	3,314.2	0.0	3,314.2	104,900.0	347.7	0.5	0.3	0.9
02/28/2023 18:00	4,829.1	188.2	4,966.5	104,900.0	521.0	0.6	0.3	1.1
02/28/2023 19:00	4,950.5	335.2	5,285.7	104,900.0	554.5	0.7	0.3	1.1
02/28/2023 20:00	4,949.6	324.9	5,274.5	104,900.0	553.3	0.7	0.3	1.1
02/28/2023 21:00	4,941.8	333.2	5,275.0	104,900.0	553.3	0.7	0.3	1.1
02/28/2023 22:00	4,972.5	285.5	5,258.0	104,900.0	551.6	0.7	0.3	1.1
02/28/2023 23:00	4,989.9	272.5	5,262.4	104,900.0	552.0	0.7	0.3	1.1
Average/Sum#:	4,177.0	217.4	4,388.1	104,900.0	460.3	0.7	0.3	1.1
Minimum:	468.3	0.0	468.3	104,900.0	49.1	0.5	0.3	0.9
Maximum:	4,989.9	335.2	5,285.7	104,900.0	554.5	0.7	0.3	1.1
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023 00:00	4,994.5	289.8	5,284.3	104,900.0	554.3	0.7	0.3	1.1
03/01/2023 01:00	4,987.9	309.8	5,297.7	104,900.0	555.7	0.7	0.3	1.1
03/01/2023 02:00	4,992.9	316.2	5,309.1	104,900.0	556.9	0.7	0.3	1.1
03/01/2023 03:00	4,992.0	339.2	5,331.2	104,900.0	559.2	0.7	0.3	1.1
03/01/2023 04:00	4,980.2	361.8	5,342.0	104,900.0	560.4	0.7	0.3	1.1
03/01/2023 05:00	4,989.5	397.2	5,386.7	104,900.0	565.1	0.7	0.3	1.1
03/01/2023 06:00	4,989.8	847.0	5,836.8	104,900.0	612.3	0.7	0.4	1.2
03/01/2023 07:00	4,533.8	228.1	4,659.3	104,900.0	488.8	0.6	0.3	1.0
03/01/2023 08:00	2,486.0	0.0	2,486.0	104,900.0	260.8	0.4	0.2	0.6
03/01/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/01/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,660.7	343.2	4,992.6	104,900.0	523.7	0.7	0.3	1.0
Minimum:	2,486.0	0.0	2,486.0	104,900.0	260.8	0.4	0.2	0.6
Maximum:	4,994.5	847.0	5,836.8	104,900.0	612.3	0.7	0.4	1.2
%SI	62.50	62.50	62.50	0.00	62.50	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/02/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/03/2023 15:00	2,735.4	0.0	2,735.4	104,900.0	286.9	0.0	0.0	0.0
03/03/2023 16:00	3,197.4	0.0	3,197.4	104,900.0	335.4	0.4	0.2	0.7
03/03/2023 17:00	4,361.0	154.9	4,435.4	104,900.0	465.3	0.6	0.3	0.9
03/03/2023 18:00	4,853.9	437.6	5,291.5	104,900.0	555.1	0.7	0.3	1.1
03/03/2023 19:00	4,862.3	528.0	5,390.3	104,900.0	565.4	0.7	0.3	1.1
03/03/2023 20:00	4,881.0	624.8	5,505.8	104,900.0	577.6	0.7	0.3	1.2
03/03/2023 21:00	4,861.7	424.7	5,180.2	104,900.0	543.4	0.7	0.3	1.1
03/03/2023 22:00	3,731.4	0.0	3,731.4	104,900.0	391.4	0.5	0.2	0.8
03/03/2023 23:00	124.8	0.0	124.8	104,900.0	13.1	0.0	0.0	0.0
Average/Sum#:	3,734.3	241.1	3,954.7	104,900.0	414.8	0.6	0.3	1.0
Minimum:	124.8	0.0	124.8	104,900.0	13.1	0.4	0.2	0.7
Maximum:	4,881.0	624.8	5,505.8	104,900.0	577.6	0.7	0.3	1.2
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/04/2023 16:00	299.1	0.0	299.1	104,900.0	31.4	0.0	0.0	0.0
03/04/2023 17:00	2,859.8	0.0	2,859.8	104,900.0	300.0	0.4	0.2	0.6
03/04/2023 18:00	4,697.6	309.8	4,899.0	104,900.0	513.9	0.6	0.3	1.1
03/04/2023 19:00	4,928.3	856.8	5,785.1	104,900.0	606.9	0.7	0.4	1.2
03/04/2023 20:00	4,926.0	648.4	5,574.4	104,900.0	584.8	0.7	0.4	1.2
03/04/2023 21:00	4,922.8	654.0	5,576.8	104,900.0	585.0	0.7	0.4	1.2
03/04/2023 22:00	3,960.1	91.0	3,984.7	104,900.0	418.0	0.6	0.3	0.9
03/04/2023 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,799.1	365.7	4,139.8	104,900.0	434.3	0.6	0.3	1.0
Minimum:	299.1	0.0	299.1	104,900.0	31.4	0.4	0.2	0.6
Maximum:	4,928.3	856.8	5,785.1	104,900.0	606.9	0.7	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2023 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/05/2023 15:00	407.9	0.0	407.9	104,900.0	42.8	0.0	0.0	0.0
03/05/2023 16:00	3,218.2	0.0	3,218.2	104,900.0	337.6	0.5	0.2	0.8
03/05/2023 17:00	4,584.0	400.6	4,836.4	104,900.0	507.3	0.6	0.3	1.0
03/05/2023 18:00	4,955.8	893.2	5,849.0	104,900.0	613.6	0.7	0.4	1.2
03/05/2023 19:00	4,981.6	944.1	5,925.7	104,900.0	621.6	0.7	0.4	1.2
03/05/2023 20:00	4,979.7	968.1	5,947.8	104,900.0	623.9	0.7	0.4	1.2
03/05/2023 21:00	4,981.1	828.7	5,809.8	104,900.0	609.4	0.7	0.4	1.2
03/05/2023 22:00	4,976.1	669.6	5,645.7	104,900.0	592.2	0.7	0.4	1.2
03/05/2023 23:00	4,973.6	362.3	5,335.9	104,900.0	559.7	0.7	0.3	1.1
Average/Sum#:	4,228.7	563.0	4,775.2	104,900.0	500.9	0.7	0.4	1.1
Minimum:	407.9	0.0	407.9	104,900.0	42.8	0.5	0.2	0.8
Maximum:	4,981.6	968.1	5,947.8	104,900.0	623.9	0.7	0.4	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2023 00:00	4,668.3	1.9	4,668.4	104,900.0	489.7	0.6	0.3	1.0
03/06/2023 01:00	3,464.9	0.0	3,464.9	104,900.0	363.5	0.5	0.2	0.8
03/06/2023 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
03/06/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/06/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/06/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/06/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/06/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/06/2023 13:00	2,666.5	0.0	2,666.5	104,300.0	278.1	0.0	0.0	0.0
03/06/2023 14:00	4,415.3	184.2	4,525.8	104,300.0	472.0	0.6	0.3	1.1
03/06/2023 15:00	4,945.4	343.5	5,288.9	104,300.0	551.6	0.7	0.3	1.1
03/06/2023 16:00	4,943.1	344.8	5,287.9	104,300.0	551.5	0.7	0.3	1.1
03/06/2023 17:00	4,938.9	341.9	5,280.8	104,300.0	550.8	0.7	0.3	1.1
03/06/2023 18:00	4,953.2	292.2	5,245.4	104,300.0	547.1	0.7	0.3	1.1
03/06/2023 19:00	4,962.9	263.5	5,226.4	104,300.0	545.1	0.7	0.3	1.1
03/06/2023 20:00	4,974.1	242.5	5,216.6	104,300.0	544.1	0.7	0.3	1.1
03/06/2023 21:00	4,975.1	239.8	5,214.9	104,300.0	543.9	0.7	0.3	1.1
03/06/2023 22:00	4,979.3	239.5	5,218.8	104,300.0	544.3	0.7	0.3	1.1
03/06/2023 23:00	4,978.1	237.2	5,215.3	104,300.0	544.0	0.7	0.3	1.1
Average/Sum#:	4,605.0	210.1	4,809.3	104,500.0	502.0	0.7	0.3	1.1
Minimum:	2,666.5	0.0	2,666.5	104,300.0	278.1	0.5	0.2	0.8
Maximum:	4,979.3	344.8	5,288.9	104,900.0	551.6	0.7	0.3	1.1
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2023 00:00	4,974.3	241.1	5,215.4	104,300.0	544.0	0.7	0.3	1.1
03/07/2023 01:00	4,971.9	280.0	5,251.9	104,300.0	547.8	0.7	0.3	1.1
03/07/2023 02:00	4,967.6	274.7	5,242.3	104,300.0	546.8	0.7	0.3	1.1
03/07/2023 03:00	4,972.0	275.9	5,247.9	104,300.0	547.4	0.7	0.3	1.1
03/07/2023 04:00	4,971.9	341.0	5,312.9	104,300.0	554.1	0.7	0.3	1.1
03/07/2023 05:00	4,970.6	599.0	5,569.6	104,300.0	580.9	0.7	0.3	1.2
03/07/2023 06:00	4,971.9	1,004.6	5,976.5	104,300.0	623.3	0.7	0.4	1.2
03/07/2023 07:00	4,524.1	141.7	4,665.8	104,300.0	480.0	0.6	0.3	1.0
03/07/2023 08:00	2,436.4	0.0	2,436.4	104,300.0	254.1	0.4	0.2	0.6
03/07/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/07/2023 16:00	1,029.5	0.0	1,029.5	104,300.0	107.4	0.0	0.0	0.0
03/07/2023 17:00	3,021.8	0.0	3,021.8	104,300.0	315.2	0.4	0.2	0.6
03/07/2023 18:00	4,385.8	148.7	4,472.0	104,300.0	466.4	0.6	0.3	0.9
03/07/2023 19:00	4,953.9	266.1	5,220.0	104,300.0	544.4	0.7	0.3	1.1
03/07/2023 20:00	4,979.4	236.5	5,215.9	104,300.0	544.0	0.7	0.3	1.1
03/07/2023 21:00	4,979.1	240.9	5,220.0	104,300.0	544.4	0.7	0.3	1.1
03/07/2023 22:00	4,978.4	242.6	5,221.0	104,300.0	544.6	0.7	0.3	1.1
03/07/2023 23:00	4,975.1	240.1	5,215.2	104,300.0	543.9	0.7	0.3	1.1
Average/Sum#:	4,415.5	266.6	4,674.7	104,300.0	487.6	0.7	0.3	1.0
Minimum:	1,029.5	0.0	1,029.5	104,300.0	107.4	0.4	0.2	0.6
Maximum:	4,979.4	1,004.6	5,976.5	104,300.0	623.3	0.7	0.4	1.2
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2023 00:00	4,975.9	239.3	5,215.2	104,300.0	543.9	0.7	0.3	1.1
03/08/2023 01:00	4,973.7	242.8	5,216.5	104,300.0	544.1	0.7	0.3	1.1
03/08/2023 02:00	4,971.4	247.4	5,218.8	104,300.0	544.3	0.7	0.3	1.1
03/08/2023 03:00	4,975.4	242.8	5,218.2	104,300.0	544.3	0.7	0.3	1.1
03/08/2023 04:00	4,979.8	248.1	5,227.9	104,300.0	545.3	0.7	0.3	1.1
03/08/2023 05:00	4,978.3	258.6	5,236.9	104,300.0	546.2	0.7	0.3	1.1
03/08/2023 06:00	4,982.5	278.6	5,261.1	104,300.0	548.7	0.7	0.3	1.1
03/08/2023 07:00	4,981.5	350.6	5,332.1	104,300.0	556.1	0.7	0.3	1.1
03/08/2023 08:00	4,986.1	364.8	5,350.9	104,300.0	558.1	0.7	0.3	1.1
03/08/2023 09:00	4,969.9	326.0	5,295.9	104,300.0	552.4	0.7	0.3	1.1
03/08/2023 10:00	4,581.6	158.5	4,668.8	104,300.0	487.0	0.6	0.3	1.0
03/08/2023 11:00	2,549.3	0.0	2,549.3	104,300.0	265.9	0.4	0.2	0.6
03/08/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/08/2023 18:00	2,651.7	0.0	2,651.7	104,300.0	276.6	0.4	0.2	0.6
03/08/2023 19:00	3,904.6	146.3	3,955.8	104,300.0	412.6	0.5	0.3	0.8
03/08/2023 20:00	4,922.2	428.8	5,351.0	104,300.0	558.1	0.7	0.3	1.1
03/08/2023 21:00	4,953.1	350.6	5,303.7	104,300.0	553.2	0.7	0.3	1.1
03/08/2023 22:00	4,967.5	340.1	5,307.6	104,300.0	553.6	0.7	0.3	1.1
03/08/2023 23:00	4,962.8	349.0	5,311.8	104,300.0	554.0	0.7	0.3	1.1
Average/Sum#:	4,626.0	254.0	4,870.7	104,300.0	508.0	0.7	0.3	1.0
Minimum:	2,549.3	0.0	2,549.3	104,300.0	265.9	0.4	0.2	0.6
Maximum:	4,986.1	428.8	5,351.0	104,300.0	558.1	0.7	0.3	1.1
%SI	25.00	25.00	25.00	0.00	25.00	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2023 00:00	4,962.7	347.7	5,310.4	104,300.0	553.9	0.7	0.3	1.1
03/09/2023 01:00	4,962.0	349.7	5,311.7	104,300.0	554.0	0.7	0.3	1.1
03/09/2023 02:00	4,961.9	347.7	5,309.6	104,300.0	553.8	0.7	0.3	1.1
03/09/2023 03:00	4,961.4	348.3	5,309.7	104,300.0	553.8	0.7	0.3	1.1
03/09/2023 04:00	4,969.3	333.6	5,302.9	104,300.0	553.1	0.7	0.3	1.1
03/09/2023 05:00	4,970.2	484.6	5,454.8	104,300.0	568.9	0.7	0.3	1.1
03/09/2023 06:00	4,976.0	362.1	5,338.1	104,300.0	556.8	0.7	0.3	1.1
03/09/2023 07:00	4,965.3	346.2	5,311.5	104,300.0	554.0	0.7	0.3	1.1
03/09/2023 08:00	4,941.2	370.6	5,311.8	104,300.0	554.0	0.7	0.3	1.1
03/09/2023 09:00	4,914.3	418.1	5,332.4	104,300.0	556.2	0.7	0.3	1.1
03/09/2023 10:00	4,900.0	465.1	5,365.1	104,300.0	559.6	0.7	0.3	1.1
03/09/2023 11:00	4,895.6	793.8	5,689.4	104,300.0	593.4	0.7	0.4	1.2
03/09/2023 12:00	4,880.6	1,009.3	5,889.9	104,300.0	614.3	0.7	0.4	1.2
03/09/2023 13:00	4,879.8	1,334.6	6,214.4	104,300.0	648.2	0.8	0.4	1.3
03/09/2023 14:00	4,899.5	1,171.3	6,070.8	104,300.0	633.2	0.8	0.4	1.3
03/09/2023 15:00	4,895.5	849.7	5,745.2	104,300.0	599.2	0.7	0.4	1.2
03/09/2023 16:00	4,896.7	361.7	5,258.4	104,300.0	548.5	0.7	0.3	1.1
03/09/2023 17:00	4,890.2	356.5	5,246.7	104,300.0	547.2	0.7	0.3	1.1
03/09/2023 18:00	4,875.5	372.1	5,247.6	104,300.0	547.3	0.7	0.3	1.1
03/09/2023 19:00	4,863.4	393.9	5,257.3	104,300.0	548.3	0.7	0.3	1.1
03/09/2023 20:00	4,848.8	414.8	5,263.6	104,300.0	549.0	0.7	0.3	1.1
03/09/2023 21:00	4,849.4	416.6	5,266.0	104,300.0	549.2	0.7	0.3	1.1
03/09/2023 22:00	4,506.9	206.9	4,616.6	104,300.0	481.5	0.6	0.3	1.0
03/09/2023 23:00	2,365.1	0.0	2,365.1	104,300.0	246.7	0.4	0.2	0.6
Average/Sum#:	4,793.0	494.0	5,282.9	104,300.0	551.0	0.7	0.3	1.1
Minimum:	2,365.1	0.0	2,365.1	104,300.0	246.7	0.4	0.2	0.6
Maximum:	4,976.0	1,334.6	6,214.4	104,300.0	648.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 15:00	912.4	0.0	912.4	104,300.0	95.2	0.0	0.0	0.0
03/10/2023 16:00	3,252.9	0.0	3,252.9	104,300.0	339.3	0.5	0.3	0.8
03/10/2023 17:00	4,460.5	406.9	4,672.1	104,300.0	487.3	0.6	0.3	1.0
03/10/2023 18:00	4,793.5	579.4	5,372.9	104,300.0	560.4	0.7	0.3	1.1
03/10/2023 19:00	4,822.0	475.0	5,297.0	104,300.0	552.5	0.7	0.3	1.1
03/10/2023 20:00	4,009.3	127.2	4,055.6	104,300.0	423.0	0.6	0.3	1.0
03/10/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/10/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,708.4	264.8	3,927.2	104,300.0	409.6	0.6	0.3	1.0
Minimum:	912.4	0.0	912.4	104,300.0	95.2	0.5	0.3	0.8
Maximum:	4,822.0	579.4	5,372.9	104,300.0	560.4	0.7	0.3	1.1
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/11/2023 16:00	40.8	0.0	40.8	104,300.0	4.3	0.0	0.0	0.0
03/11/2023 17:00	2,741.0	0.0	2,741.0	104,300.0	285.9	0.0	0.0	0.0
03/11/2023 18:00	2,895.2	0.0	2,895.2	104,300.0	302.0	0.4	0.2	0.6
03/11/2023 19:00	4,743.6	555.4	5,204.6	104,300.0	542.8	0.7	0.3	1.1
03/11/2023 20:00	4,856.6	692.1	5,548.7	104,300.0	578.7	0.7	0.3	1.2
03/11/2023 21:00	4,838.1	1,035.4	5,873.5	104,300.0	612.6	0.7	0.4	1.2
03/11/2023 22:00	4,827.1	1,258.9	6,086.0	104,300.0	634.8	0.8	0.4	1.3
03/11/2023 23:00	4,828.7	1,229.2	6,057.9	104,300.0	631.8	0.8	0.4	1.3
Average/Sum#:	3,721.4	596.4	4,306.0	104,300.0	449.1	0.7	0.3	1.1
Minimum:	40.8	0.0	40.8	104,300.0	4.3	0.4	0.2	0.6
Maximum:	4,856.6	1,258.9	6,086.0	104,300.0	634.8	0.8	0.4	1.3
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2023 00:00	4,845.0	848.8	5,693.8	104,300.0	593.9	0.7	0.4	1.2
03/12/2023 01:00	4,837.0	3.0	4,837.2	104,300.0	504.5	0.6	0.3	1.0
03/12/2023 02:00	4,836.1	0.0	4,836.1	104,300.0	504.4	0.6	0.3	1.0
03/12/2023 03:00	4,840.9	126.3	4,887.6	104,300.0	509.8	0.6	0.3	1.0
03/12/2023 04:00	4,835.5	1,002.0	5,837.5	104,300.0	608.9	0.7	0.4	1.2
03/12/2023 05:00	4,833.2	1,002.8	5,836.0	104,300.0	608.7	0.7	0.4	1.2
03/12/2023 06:00	4,581.0	249.1	4,718.0	104,300.0	492.1	0.6	0.3	1.0
03/12/2023 07:00	2,472.6	0.0	2,472.6	104,300.0	257.9	0.4	0.2	0.6
03/12/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/12/2023 15:00	2,671.5	0.0	2,671.5	104,300.0	278.6	0.4	0.2	0.7
03/12/2023 16:00	3,842.9	169.8	3,897.2	104,300.0	406.5	0.5	0.3	0.8
03/12/2023 17:00	4,804.2	1,157.9	5,962.1	104,300.0	621.8	0.7	0.4	1.2
03/12/2023 18:00	4,826.0	1,241.4	6,067.4	104,300.0	632.8	0.8	0.4	1.3
03/12/2023 19:00	4,827.6	1,114.7	5,942.3	104,300.0	619.8	0.7	0.4	1.2
03/12/2023 20:00	4,817.4	1,218.4	6,035.8	104,300.0	629.5	0.8	0.4	1.3
03/12/2023 21:00	4,824.1	1,184.7	6,008.8	104,300.0	626.7	0.8	0.4	1.3
03/12/2023 22:00	4,822.5	909.8	5,732.3	104,300.0	597.9	0.7	0.4	1.2
03/12/2023 23:00	4,246.0	1.8	4,246.0	104,300.0	442.9	0.5	0.3	0.9
Average/Sum#:	4,456.7	601.8	5,040.1	104,300.0	525.7	0.6	0.3	1.1
Minimum:	2,472.6	0.0	2,472.6	104,300.0	257.9	0.4	0.2	0.6
Maximum:	4,845.0	1,241.4	6,067.4	104,300.0	632.8	0.8	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2023 00:00	2,463.8	0.0	2,463.8	104,300.0	257.0	0.4	0.2	0.6
03/13/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/13/2023 16:00	1,024.3	0.0	1,024.3	104,300.0	106.8	0.0	0.0	0.0
03/13/2023 17:00	3,293.0	0.0	3,293.0	104,300.0	343.5	0.5	0.2	0.8
03/13/2023 18:00	4,747.1	454.9	5,042.8	104,300.0	526.0	0.7	0.3	1.1
03/13/2023 19:00	4,773.6	915.1	5,688.7	104,300.0	593.3	0.7	0.4	1.2
03/13/2023 20:00	4,774.0	1,195.6	5,969.6	104,300.0	622.6	0.7	0.4	1.2
03/13/2023 21:00	4,773.6	970.7	5,744.3	104,300.0	599.1	0.7	0.4	1.2
03/13/2023 22:00	4,047.4	106.1	4,076.0	104,300.0	425.1	0.6	0.3	0.9
03/13/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,737.1	455.3	4,162.8	104,300.0	434.2	0.6	0.3	1.0
Minimum:	1,024.3	0.0	1,024.3	104,300.0	106.8	0.4	0.2	0.6
Maximum:	4,774.0	1,195.6	5,969.6	104,300.0	622.6	0.7	0.4	1.2
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/14/2023 09:00	2,670.0	0.0	2,670.0	104,300.0	278.5	0.4	0.2	0.7
03/14/2023 10:00	4,655.6	495.3	5,017.2	104,300.0	523.3	0.6	0.3	1.1
03/14/2023 11:00	4,706.5	935.7	5,642.2	104,300.0	588.5	0.7	0.4	1.2
03/14/2023 12:00	4,680.5	1,034.5	5,715.0	104,300.0	596.1	0.7	0.4	1.2
03/14/2023 13:00	4,686.8	1,287.1	5,973.9	104,300.0	623.1	0.7	0.4	1.2
03/14/2023 14:00	4,665.4	1,073.7	5,739.1	104,300.0	598.6	0.7	0.4	1.2
03/14/2023 15:00	4,669.2	744.3	5,413.5	104,300.0	564.6	0.7	0.3	1.1
03/14/2023 16:00	4,731.2	1,001.8	5,733.0	104,300.0	598.0	0.7	0.4	1.2
03/14/2023 17:00	4,773.3	1,122.3	5,895.6	104,300.0	614.9	0.7	0.4	1.2
03/14/2023 18:00	4,805.2	1,207.1	6,012.3	104,300.0	627.1	0.8	0.4	1.3
03/14/2023 19:00	4,828.9	1,264.4	6,093.3	104,300.0	635.5	0.8	0.4	1.3
03/14/2023 20:00	4,844.5	1,175.0	6,019.5	104,300.0	627.8	0.8	0.4	1.3
03/14/2023 21:00	4,859.5	752.1	5,611.6	104,300.0	585.3	0.7	0.4	1.2
03/14/2023 22:00	4,689.9	250.3	4,820.1	104,300.0	502.7	0.6	0.3	1.0
03/14/2023 23:00	2,776.8	0.0	2,776.8	104,300.0	289.6	0.4	0.2	0.7
Average/Sum#:	4,469.6	822.9	5,275.5	104,300.0	550.2	0.7	0.4	1.1
Minimum:	2,670.0	0.0	2,670.0	104,300.0	278.5	0.4	0.2	0.7
Maximum:	4,859.5	1,287.1	6,093.3	104,300.0	635.5	0.8	0.4	1.3
%SI	37.50	37.50	37.50	0.00	37.50	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 16:00	1,236.1	0.0	1,236.1	104,300.0	128.9	0.0	0.0	0.0
03/15/2023 17:00	3,308.4	0.0	3,308.4	104,300.0	345.1	0.4	0.2	0.7
03/15/2023 18:00	4,667.0	325.5	4,904.6	104,300.0	511.5	0.6	0.3	1.0
03/15/2023 19:00	4,811.7	822.0	5,633.7	104,300.0	587.6	0.7	0.4	1.2
03/15/2023 20:00	4,834.4	982.2	5,816.6	104,300.0	606.7	0.7	0.4	1.2
03/15/2023 21:00	4,124.0	99.4	4,156.4	104,300.0	433.5	0.6	0.3	1.0
03/15/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/15/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,830.3	371.5	4,176.0	104,300.0	435.6	0.6	0.3	1.0
Minimum:	1,236.1	0.0	1,236.1	104,300.0	128.9	0.4	0.2	0.7
Maximum:	4,834.4	982.2	5,816.6	104,300.0	606.7	0.7	0.4	1.2
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/16/2023 15:00	1,365.4	0.0	1,365.4	104,300.0	142.4	0.0	0.0	0.0
03/16/2023 16:00	3,795.3	0.0	3,795.3	104,300.0	395.8	0.5	0.2	0.8
03/16/2023 17:00	3,122.6	0.0	3,122.6	104,300.0	325.7	0.4	0.2	0.7
03/16/2023 18:00	3,100.0	0.0	3,100.0	104,300.0	323.3	0.4	0.2	0.6
03/16/2023 19:00	3,115.6	0.0	3,115.6	104,300.0	325.0	0.4	0.2	0.7
03/16/2023 20:00	3,123.7	0.0	3,123.7	104,300.0	325.8	0.4	0.2	0.7
03/16/2023 21:00	3,570.8	0.0	3,570.8	104,300.0	372.4	0.4	0.2	0.7
03/16/2023 22:00	3,564.6	0.0	3,564.6	104,300.0	371.8	0.4	0.2	0.7
03/16/2023 23:00	3,182.9	0.0	3,182.9	104,300.0	332.0	0.4	0.2	0.7
Average/Sum#:	3,104.5	0.0	3,104.5	104,300.0	323.8	0.4	0.2	0.7
Minimum:	1,365.4	0.0	1,365.4	104,300.0	142.4	0.4	0.2	0.6
Maximum:	3,795.3	0.0	3,795.3	104,300.0	395.8	0.5	0.2	0.8
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2023 00:00	3,162.2	0.0	3,162.2	104,300.0	329.8	0.4	0.2	0.7
03/17/2023 01:00	3,653.5	0.0	3,653.5	104,300.0	381.1	0.5	0.2	0.8
03/17/2023 02:00	3,592.9	0.0	3,592.9	104,300.0	374.7	0.5	0.2	0.7
03/17/2023 03:00	4,868.2	418.0	5,202.6	104,300.0	542.6	0.7	0.3	1.1
03/17/2023 04:00	4,949.7	1,099.1	6,048.8	104,300.0	630.9	0.8	0.4	1.3
03/17/2023 05:00	4,956.2	1,195.8	6,152.0	104,300.0	641.7	0.8	0.4	1.3
03/17/2023 06:00	4,955.6	925.6	5,881.2	104,300.0	613.4	0.7	0.4	1.2
03/17/2023 07:00	4,256.7	170.4	4,353.8	104,300.0	454.1	0.6	0.3	0.9
03/17/2023 08:00	2,941.6	0.0	2,941.6	104,300.0	306.8	0.4	0.2	0.7
03/17/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/17/2023 16:00	1,764.8	0.0	1,764.8	104,300.0	184.1	0.0	0.0	0.0
03/17/2023 17:00	3,780.2	46.6	3,790.5	104,300.0	395.3	0.6	0.3	1.0
03/17/2023 18:00	4,749.1	803.0	5,552.1	104,300.0	579.1	0.7	0.3	1.2
03/17/2023 19:00	4,774.7	1,073.8	5,848.5	104,300.0	610.0	0.7	0.4	1.2
03/17/2023 20:00	4,788.7	805.6	5,594.3	104,300.0	583.5	0.7	0.4	1.2
03/17/2023 21:00	4,818.2	948.3	5,766.5	104,300.0	601.4	0.7	0.4	1.2
03/17/2023 22:00	4,039.5	93.5	4,064.7	104,300.0	423.9	0.5	0.3	0.9
03/17/2023 23:00	902.2	0.0	902.2	104,300.0	94.1	0.0	0.0	0.0
Average/Sum#:	3,938.5	445.9	4,369.0	104,300.0	455.7	0.6	0.3	1.0
Minimum:	902.2	0.0	902.2	104,300.0	94.1	0.4	0.2	0.7
Maximum:	4,956.2	1,195.8	6,152.0	104,300.0	641.7	0.8	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 15:00	368.1	0.0	368.1	104,300.0	38.4	0.0	0.0	0.0
03/18/2023 16:00	3,229.6	0.0	3,229.6	104,300.0	336.8	0.5	0.3	0.9
03/18/2023 17:00	4,707.0	558.7	5,165.1	104,300.0	538.7	0.7	0.3	1.1
03/18/2023 18:00	4,744.9	1,290.8	6,035.7	104,300.0	629.5	0.8	0.4	1.3
03/18/2023 19:00	4,758.9	843.9	5,602.8	104,300.0	584.4	0.7	0.4	1.2
03/18/2023 20:00	4,722.6	791.9	5,514.5	104,300.0	575.2	0.7	0.3	1.2
03/18/2023 21:00	3,871.1	137.2	3,906.2	104,300.0	407.4	0.6	0.3	0.9
03/18/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/18/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,771.7	517.5	4,260.3	104,300.0	444.3	0.7	0.3	1.1
Minimum:	368.1	0.0	368.1	104,300.0	38.4	0.5	0.3	0.9
Maximum:	4,758.9	1,290.8	6,035.7	104,300.0	629.5	0.8	0.4	1.3
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/19/2023 15:00	1,759.6	0.0	1,759.6	104,300.0	183.5	0.0	0.0	0.0
03/19/2023 16:00	3,579.2	16.7	3,580.4	104,300.0	373.4	0.6	0.3	0.9
03/19/2023 17:00	4,803.6	770.6	5,574.2	104,300.0	581.4	0.7	0.3	1.2
03/19/2023 18:00	4,803.3	1,061.9	5,865.2	104,300.0	611.7	0.7	0.4	1.2
03/19/2023 19:00	4,807.7	881.2	5,688.9	104,300.0	593.4	0.7	0.4	1.2
03/19/2023 20:00	4,813.8	923.3	5,737.1	104,300.0	598.4	0.7	0.4	1.2
03/19/2023 21:00	4,844.6	641.8	5,486.4	104,300.0	572.2	0.7	0.3	1.1
03/19/2023 22:00	4,827.5	528.4	5,355.9	104,300.0	558.6	0.7	0.3	1.1
03/19/2023 23:00	4,818.8	587.3	5,406.1	104,300.0	563.9	0.7	0.3	1.1
Average/Sum#:	4,339.8	601.2	4,939.3	104,300.0	515.2	0.7	0.3	1.1
Minimum:	1,759.6	0.0	1,759.6	104,300.0	183.5	0.6	0.3	0.9
Maximum:	4,844.6	1,061.9	5,865.2	104,300.0	611.7	0.7	0.4	1.2
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2023 00:00	4,432.2	218.7	4,552.5	104,300.0	474.8	0.6	0.3	1.0
03/20/2023 01:00	2,487.3	0.0	2,487.3	104,300.0	259.4	0.4	0.2	0.6
03/20/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 16:00	2,328.2	0.0	2,328.2	104,300.0	242.8	0.0	0.0	0.0
03/20/2023 17:00	4,225.5	53.1	4,246.7	104,300.0	442.9	0.6	0.3	1.0
03/20/2023 18:00	4,811.8	1,014.1	5,825.9	104,300.0	607.6	0.7	0.4	1.2
03/20/2023 19:00	4,827.1	983.1	5,810.2	104,300.0	606.0	0.7	0.4	1.2
03/20/2023 20:00	4,034.1	485.5	4,171.7	104,300.0	435.1	0.7	0.4	1.2
03/20/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/20/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,878.0	393.5	4,203.2	104,300.0	438.4	0.6	0.3	1.0
Minimum:	2,328.2	0.0	2,328.2	104,300.0	242.8	0.4	0.2	0.6
Maximum:	4,827.1	1,014.1	5,825.9	104,300.0	607.6	0.7	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/21/2023 11:00	2,353.8	0.0	2,353.8	104,300.0	245.5	0.0	0.0	0.0
03/21/2023 12:00	4,167.1	0.0	4,167.1	104,300.0	434.6	0.5	0.2	0.8
03/21/2023 13:00	3,242.6	0.0	3,242.6	104,300.0	338.2	0.4	0.2	0.7
03/21/2023 14:00	3,092.1	0.0	3,092.1	104,300.0	322.5	0.4	0.2	0.6
03/21/2023 15:00	3,075.0	0.0	3,075.0	104,300.0	320.7	0.4	0.2	0.6
03/21/2023 16:00	3,066.4	0.0	3,066.4	104,300.0	319.8	0.4	0.2	0.6
03/21/2023 17:00	3,086.1	0.0	3,086.1	104,300.0	321.9	0.4	0.2	0.6
03/21/2023 18:00	3,084.1	0.0	3,084.1	104,300.0	321.7	0.4	0.2	0.6
03/21/2023 19:00	3,072.8	0.0	3,072.8	104,300.0	320.5	0.4	0.2	0.6
03/21/2023 20:00	3,085.0	0.0	3,085.0	104,300.0	321.8	0.4	0.2	0.6
03/21/2023 21:00	3,093.3	0.0	3,093.3	104,300.0	322.6	0.4	0.2	0.6
03/21/2023 22:00	3,126.5	0.0	3,126.5	104,300.0	326.1	0.4	0.2	0.7
03/21/2023 23:00	3,155.3	0.0	3,155.3	104,300.0	329.1	0.4	0.2	0.7
Average/Sum#:	3,130.8	0.0	3,130.8	104,300.0	326.5	0.4	0.2	0.6
Minimum:	2,353.8	0.0	2,353.8	104,300.0	245.5	0.4	0.2	0.6
Maximum:	4,167.1	0.0	4,167.1	104,300.0	434.6	0.5	0.2	0.8
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2023 00:00	3,161.6	0.0	3,161.6	104,300.0	329.8	0.4	0.2	0.7
03/22/2023 01:00	3,127.1	0.0	3,127.1	104,300.0	326.2	0.4	0.2	0.7
03/22/2023 02:00	3,122.9	0.0	3,122.9	104,300.0	325.7	0.4	0.2	0.7
03/22/2023 03:00	3,121.1	0.0	3,121.1	104,300.0	325.5	0.4	0.2	0.7
03/22/2023 04:00	3,119.5	0.0	3,119.5	104,300.0	325.4	0.4	0.2	0.7
03/22/2023 05:00	3,204.3	0.0	3,204.3	104,300.0	334.2	0.4	0.2	0.7
03/22/2023 06:00	4,007.0	0.0	4,007.0	104,300.0	417.9	0.5	0.3	0.8
03/22/2023 07:00	3,106.2	0.0	3,106.2	104,300.0	324.0	0.4	0.2	0.6
03/22/2023 08:00	3,109.6	0.0	3,109.6	104,300.0	324.3	0.4	0.2	0.6
03/22/2023 09:00	3,134.0	0.0	3,134.0	104,300.0	326.9	0.4	0.2	0.7
03/22/2023 10:00	3,146.3	0.0	3,146.3	104,300.0	328.2	0.4	0.2	0.7
03/22/2023 11:00	3,155.5	0.0	3,155.5	104,300.0	329.1	0.4	0.2	0.7
03/22/2023 12:00	3,135.5	0.0	3,135.5	104,300.0	327.0	0.4	0.2	0.7
03/22/2023 13:00	3,141.0	0.0	3,141.0	104,300.0	327.6	0.4	0.2	0.7
03/22/2023 14:00	3,175.4	0.0	3,175.4	104,300.0	331.2	0.4	0.2	0.7
03/22/2023 15:00	3,625.3	0.0	3,625.3	104,300.0	378.1	0.5	0.2	0.8
03/22/2023 16:00	3,784.2	0.0	3,784.2	104,300.0	394.7	0.5	0.2	0.8
03/22/2023 17:00	4,324.0	539.6	4,647.8	104,300.0	484.8	0.6	0.3	1.0
03/22/2023 18:00	4,866.8	1,222.9	6,089.7	104,300.0	635.2	0.8	0.4	1.3
03/22/2023 19:00	4,865.4	1,175.0	6,040.4	104,300.0	630.0	0.8	0.4	1.3
03/22/2023 20:00	4,885.8	1,037.1	5,922.9	104,300.0	617.8	0.7	0.4	1.2
03/22/2023 21:00	4,896.0	641.0	5,537.0	104,300.0	577.5	0.7	0.3	1.2
03/22/2023 22:00	4,639.9	196.0	4,741.8	104,300.0	494.6	0.6	0.3	1.0
03/22/2023 23:00	3,741.2	0.0	3,741.2	104,300.0	390.2	0.5	0.2	0.8
Average/Sum#:	3,649.8	200.5	3,837.4	104,300.0	400.2	0.5	0.2	0.8
Minimum:	3,106.2	0.0	3,106.2	104,300.0	324.0	0.4	0.2	0.6
Maximum:	4,896.0	1,222.9	6,089.7	104,300.0	635.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2023 00:00	3,280.3	0.0	3,280.3	104,300.0	342.1	0.4	0.2	0.7
03/23/2023 01:00	3,190.7	0.0	3,190.7	104,300.0	332.8	0.4	0.2	0.7
03/23/2023 02:00	3,193.8	0.0	3,193.8	104,300.0	333.1	0.4	0.2	0.7
03/23/2023 03:00	3,189.4	0.0	3,189.4	104,300.0	332.7	0.4	0.2	0.7
03/23/2023 04:00	3,176.2	0.0	3,176.2	104,300.0	331.3	0.4	0.2	0.7
03/23/2023 05:00	3,140.3	0.0	3,140.3	104,300.0	327.5	0.4	0.2	0.7
03/23/2023 06:00	3,147.9	0.0	3,147.9	104,300.0	328.3	0.4	0.2	0.7
03/23/2023 07:00	3,184.4	0.0	3,184.4	104,300.0	332.1	0.4	0.2	0.7
03/23/2023 08:00	3,165.0	0.0	3,165.0	104,300.0	330.1	0.4	0.2	0.7
03/23/2023 09:00	3,132.0	0.0	3,132.0	104,300.0	326.7	0.4	0.2	0.7
03/23/2023 10:00	3,132.8	0.0	3,132.8	104,300.0	326.8	0.4	0.2	0.7
03/23/2023 11:00	3,127.5	0.0	3,127.5	104,300.0	326.2	0.4	0.2	0.7
03/23/2023 12:00	3,123.7	0.0	3,123.7	104,300.0	325.8	0.4	0.2	0.7
03/23/2023 13:00	3,127.4	0.0	3,127.4	104,300.0	326.2	0.4	0.2	0.7
03/23/2023 14:00	3,505.0	0.0	3,505.0	104,300.0	365.6	0.4	0.2	0.7
03/23/2023 15:00	3,478.8	0.0	3,478.8	104,300.0	362.8	0.4	0.2	0.7
03/23/2023 16:00	3,876.4	114.7	3,908.5	104,300.0	407.7	0.5	0.2	0.8
03/23/2023 17:00	4,849.8	416.1	5,265.9	104,300.0	549.2	0.7	0.3	1.1
03/23/2023 18:00	4,877.4	386.8	5,264.2	104,300.0	549.1	0.7	0.3	1.1
03/23/2023 19:00	4,907.5	340.3	5,247.8	104,300.0	547.3	0.7	0.3	1.1
03/23/2023 20:00	4,924.8	317.0	5,241.8	104,300.0	546.7	0.7	0.3	1.1
03/23/2023 21:00	4,941.0	293.9	5,234.9	104,300.0	546.0	0.7	0.3	1.1
03/23/2023 22:00	4,122.5	68.5	4,144.4	104,300.0	432.3	0.5	0.3	0.9
03/23/2023 23:00	3,378.6	0.0	3,378.6	104,300.0	352.4	0.4	0.2	0.7
Average/Sum#:	3,632.2	80.7	3,707.6	104,300.0	386.7	0.5	0.2	0.8
Minimum:	3,123.7	0.0	3,123.7	104,300.0	325.8	0.4	0.2	0.7
Maximum:	4,941.0	416.1	5,265.9	104,300.0	549.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2023 00:00	3,170.8	0.0	3,170.8	104,300.0	330.7	0.4	0.2	0.7
03/24/2023 01:00	3,169.6	0.0	3,169.6	104,300.0	330.6	0.4	0.2	0.7
03/24/2023 02:00	3,173.7	0.0	3,173.7	104,300.0	331.0	0.4	0.2	0.7
03/24/2023 03:00	3,169.7	0.0	3,169.7	104,300.0	330.6	0.4	0.2	0.7
03/24/2023 04:00	3,171.1	0.0	3,171.1	104,300.0	330.7	0.4	0.2	0.7
03/24/2023 05:00	3,166.7	0.0	3,166.7	104,300.0	330.3	0.4	0.2	0.7
03/24/2023 06:00	3,168.7	0.0	3,168.7	104,300.0	330.5	0.4	0.2	0.7
03/24/2023 07:00	3,158.5	0.0	3,158.5	104,300.0	329.4	0.4	0.2	0.7
03/24/2023 08:00	3,154.7	0.0	3,154.7	104,300.0	329.0	0.4	0.2	0.7
03/24/2023 09:00	3,155.5	0.0	3,155.5	104,300.0	329.1	0.4	0.2	0.7
03/24/2023 10:00	3,154.3	0.0	3,154.3	104,300.0	329.0	0.4	0.2	0.7
03/24/2023 11:00	3,163.7	0.0	3,163.7	104,300.0	330.0	0.4	0.2	0.7
03/24/2023 12:00	3,162.5	0.0	3,162.5	104,300.0	329.8	0.4	0.2	0.7
03/24/2023 13:00	3,167.1	0.0	3,167.1	104,300.0	330.3	0.4	0.2	0.7
03/24/2023 14:00	3,166.8	0.0	3,166.8	104,300.0	330.3	0.4	0.2	0.7
03/24/2023 15:00	3,162.3	0.0	3,162.3	104,300.0	329.8	0.4	0.2	0.7
03/24/2023 16:00	3,157.8	0.0	3,157.8	104,300.0	329.4	0.4	0.2	0.7
03/24/2023 17:00	3,165.4	0.0	3,165.4	104,300.0	330.2	0.4	0.2	0.7
03/24/2023 18:00	3,166.6	0.0	3,166.6	104,300.0	330.3	0.4	0.2	0.7
03/24/2023 19:00	3,166.4	0.0	3,166.4	104,300.0	330.3	0.4	0.2	0.7
03/24/2023 20:00	3,168.7	0.0	3,168.7	104,300.0	330.5	0.4	0.2	0.7
03/24/2023 21:00	3,184.9	0.0	3,184.9	104,300.0	332.2	0.4	0.2	0.7
03/24/2023 22:00	3,178.9	0.0	3,178.9	104,300.0	331.6	0.4	0.2	0.7
03/24/2023 23:00	3,171.5	0.0	3,171.5	104,300.0	330.8	0.4	0.2	0.7
Average/Sum#:	3,166.5	0.0	3,166.5	104,300.0	330.3	0.4	0.2	0.7
Minimum:	3,154.3	0.0	3,154.3	104,300.0	329.0	0.4	0.2	0.7
Maximum:	3,184.9	0.0	3,184.9	104,300.0	332.2	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2023 00:00	3,159.9	0.0	3,159.9	104,300.0	329.6	0.4	0.2	0.7
03/25/2023 01:00	3,155.7	0.0	3,155.7	104,300.0	329.1	0.4	0.2	0.7
03/25/2023 02:00	3,152.8	0.0	3,152.8	104,300.0	328.8	0.4	0.2	0.7
03/25/2023 03:00	3,157.2	0.0	3,157.2	104,300.0	329.3	0.4	0.2	0.7
03/25/2023 04:00	3,159.7	0.0	3,159.7	104,300.0	329.6	0.4	0.2	0.7
03/25/2023 05:00	3,154.1	0.0	3,154.1	104,300.0	329.0	0.4	0.2	0.7
03/25/2023 06:00	3,156.4	0.0	3,156.4	104,300.0	329.2	0.4	0.2	0.7
03/25/2023 07:00	3,150.9	0.0	3,150.9	104,300.0	328.6	0.4	0.2	0.7
03/25/2023 08:00	3,144.0	0.0	3,144.0	104,300.0	327.9	0.4	0.2	0.7
03/25/2023 09:00	3,136.9	0.0	3,136.9	104,300.0	327.2	0.4	0.2	0.7
03/25/2023 10:00	3,137.9	0.0	3,137.9	104,300.0	327.3	0.4	0.2	0.7
03/25/2023 11:00	3,139.5	0.0	3,139.5	104,300.0	327.4	0.4	0.2	0.7
03/25/2023 12:00	3,134.5	0.0	3,134.5	104,300.0	326.9	0.4	0.2	0.7
03/25/2023 13:00	3,124.0	0.0	3,124.0	104,300.0	325.8	0.4	0.2	0.7
03/25/2023 14:00	3,122.7	0.0	3,122.7	104,300.0	325.7	0.4	0.2	0.7
03/25/2023 15:00	3,123.9	0.0	3,123.9	104,300.0	325.8	0.4	0.2	0.7
03/25/2023 16:00	3,135.3	0.0	3,135.3	104,300.0	327.0	0.4	0.2	0.7
03/25/2023 17:00	3,150.1	0.0	3,150.1	104,300.0	328.6	0.4	0.2	0.7
03/25/2023 18:00	3,167.1	0.0	3,167.1	104,300.0	330.3	0.4	0.2	0.7
03/25/2023 19:00	3,170.1	0.0	3,170.1	104,300.0	330.6	0.4	0.2	0.7
03/25/2023 20:00	3,168.2	0.0	3,168.2	104,300.0	330.4	0.4	0.2	0.7
03/25/2023 21:00	3,169.1	0.0	3,169.1	104,300.0	330.5	0.4	0.2	0.7
03/25/2023 22:00	3,308.1	0.0	3,308.1	104,300.0	345.0	0.4	0.2	0.7
03/25/2023 23:00	2,074.2	0.0	2,074.2	104,300.0	216.3	0.0	0.0	0.0
Average/Sum#:	3,110.5	0.0	3,110.5	104,300.0	324.4	0.4	0.2	0.7
Minimum:	2,074.2	0.0	2,074.2	104,300.0	216.3	0.4	0.2	0.7
Maximum:	3,308.1	0.0	3,308.1	104,300.0	345.0	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/26/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/27/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/28/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 04/01/2023 09:02 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/29/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag:							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2023 00:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 01:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 02:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 03:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 04:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 05:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 06:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 07:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 08:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 09:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 10:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 11:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 12:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 13:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 14:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 15:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 16:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 17:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 18:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 19:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 20:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 21:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 22:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
03/30/2023 23:00	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:02 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
03/31/2023 00:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 01:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 02:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 03:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 04:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 05:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 06:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 07:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 08:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 09:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 10:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 11:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 12:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 13:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 14:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 15:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 16:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 17:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 18:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 19:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 20:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 21:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 22:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
03/31/2023 23:00	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,300.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:03 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,215.00 Hour(s)
Operating time for CMS: 1,215.00 Hour(s)

Emission Data Summary		
1. Duration of excess emission in reporting period due to:		
a. Startup/shutdown		0
b. Control equipment problems		0
c. Process Problems		0
d. Other known causes		0
e. Unknown causes		0
2. Upset Conditions		0
3. Total Duration (Subtracts Exclusions and Upset Conditions)		0
4. Time of Excess Emission as a percentage of operating time	0.00	
5. Time in compliance as percentage of operating time	100.00	

CMS Performance Summary		
1. CMS downtime in reporting period due to:		
a. Monitor equipment malfunctions		0
b. Non-Monitor equipment malfunctions		0
c. Quality assurance calibration		0
d. Other known causes		0
e. Unknown causes		0
2. Total CMS Downtime		0
3. Total Downtime as a percentage of operating time	0.00	
4. Total Availability as a percentage of operating time	100.00	

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:04 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,215.00 Hour(s)
Operating time for CMS: 1,215.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:04 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,392.00 Hour(s)
Operating time for CMS: 1,392.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.07
4. Total Availability as a percentage of operating time	99.93

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:05 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,392.00 Hour(s)
Operating time for CMS: 1,392.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.07
4. Total Availability as a percentage of operating time	99.93

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:06 Location: Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,215.00 Hour(s)
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,215.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:07 Location: Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,215.00 Hour(s)
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,215.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:08 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,215.00 Hour(s)
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,215.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:09 Location: Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,215.00 Hour(s)
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,215.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Invalid Data

CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:49 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,392.00 Hour(s)
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2023 16:00	03/13/2023 16:59	1		

Total Operating Time:	1,392.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.93 %
Percent Monitor Downtime:	0.07 %

NOx Invalid Data

CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:50 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 1,392.00 Hour(s)
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2023 16:00	03/13/2023 16:59	1		

Total Operating Time:	1,392.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.93 %
Percent Monitor Downtime:	0.07 %

NOx SCR Invalid Data



CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:50 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,392.00 Hour(s)
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2023 16:00	03/13/2023 16:59	1		

Total Operating Time:	1,392.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.93 %
Percent Monitor Downtime:	0.07 %

02 Invalid Data

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:51 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,392.00 Hour(s)
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2023 16:00	03/13/2023 16:59	1		

Total Operating Time:	1,392.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.93 %
Percent Monitor Downtime:	0.07 %

ATTACHMENT 7

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

ATTACHMENT 8

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

ATTACHMENT 9

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

04/01/2023

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 01/19/2023
Test **Pass**

Instrument: CT2_CODualRg_P_Instr
Performance: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/19/2023	08:34	L	200	49.700	51.900	24.9 %
01/19/2023	08:39	M	200	109.100	119.200	54.6 %
01/19/2023	08:51	L	200	49.700	51.900	24.9 %
01/19/2023	08:57	M	200	109.100	118.300	54.6 %
01/19/2023	09:09	L	200	49.700	51.900	24.9 %
01/19/2023	09:14	M	200	109.100	118.900	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.700	51.900	Std	4.4
M	109.100	118.800	Std	8.9

Cylinder Gas Audit

04/01/2023

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scal CO / Low

Test Date: 01/19/2023
Test **Pass**

Instrument CT2_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/19/2023	12:48	L	10	2.400	2.300	24.0 %
01/19/2023	12:53	M	10	5.700	5.600	57.0 %
01/19/2023	13:00	L	10	2.400	2.300	24.0 %
01/19/2023	13:05	M	10	5.700	5.600	57.0 %
01/19/2023	13:12	L	10	2.400	2.300	24.0 %
01/19/2023	13:17	M	10	5.700	5.600	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

04/01/2023

Page 3

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/24/2023	08:31	L	200	49.800	46.000	24.9 %
01/24/2023	08:36	M	200	109.200	108.200	54.6 %
01/24/2023	08:48	L	200	49.800	46.100	24.9 %
01/24/2023	08:53	M	200	109.200	108.100	54.6 %
01/24/2023	09:05	L	200	49.800	46.100	24.9 %
01/24/2023	09:10	M	200	109.200	108.100	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.800	46.067	Std	7.5
M	109.200	108.133	Std	1.0

Cylinder Gas Audit

04/01/2023

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / Low	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
01/30/2023	14:40	L	10	2.400	2.100	24.0 %
01/30/2023	14:45	M	10	5.700	5.500	57.0 %
01/30/2023	14:52	L	10	2.400	2.100	24.0 %
01/30/2023	14:57	M	10	5.700	5.500	57.0 %
01/30/2023	15:04	L	10	2.400	2.100	24.0 %
01/30/2023	15:09	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference	Mean	CEMS Mean	Specification	Results
L	2.400		2.100	Std	12.5
M	5.700		5.500	Std	3.5

Cylinder Gas Audit

04/01/2023

Page 5

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
02/08/2023	07:38	L	200	49.800	47.100	24.9 %
02/08/2023	07:43	M	200	109.200	111.100	54.6 %
02/08/2023	07:56	L	200	49.800	46.900	24.9 %
02/08/2023	08:01	M	200	109.200	110.600	54.6 %
02/08/2023	08:13	L	200	49.800	46.900	24.9 %
02/08/2023	08:18	M	200	109.200	110.800	54.6 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.800	46.967	Std	5.7
M	109.200	110.833	Std	1.5

Roseville Energy Park

Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

3/14/23 Taylor Sullivan

Edited the CT2_Startup_Cold tag to 1 for 3/13 16:51 – 17:37 and recalculated dependencies. EDR check.

2/16/23 Adam Jensen

Testing access. No changes made.

2/7/23 Taylor Sullivan

EDR check

1/13,16,24/2023 Taylor Sullivan

Q4 EDRs

Linearity Report

04/01/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	01/19/2023	Scale:	High
Performance	5 %	Test No.:	125	Highest	2.1
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2023	0834	L	200.0	51.6	50.3		25.8 %
01/19/2023	0839	M	200.0	111.3	110.1		55.7 %
01/19/2023	0844	H	200.0	180.4	180.0		90.2 %
01/19/2023	0851	L	200.0	51.6	50.6		25.8 %
01/19/2023	0857	M	200.0	111.3	110.4		55.7 %
01/19/2023	0902	H	200.0	180.4	180.3		90.2 %
01/19/2023	0909	L	200.0	51.6	50.7		25.8 %
01/19/2023	0914	M	200.0	111.3	110.6		55.7 %
01/19/2023	0919	H	200.0	180.4	180.2		90.2 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.600	50.533	No	2.1
M	111.300	110.367	No	0.8
H	180.400	180.167	No	0.1

Linearity Report

04/01/2023

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	01/19/2023	Scale:	High
Performance	5 %	Test No.:	126	Highest	0.7
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2023	1041	L	21.0	5.0	5.1		23.8 %
01/19/2023	1046	M	21.0	11.2	11.2		53.3 %
01/19/2023	1051	H	21.0	18.0	18.0		85.7 %
01/19/2023	1058	L	21.0	5.0	5.0		23.8 %
01/19/2023	1103	M	21.0	11.2	11.2		53.3 %
01/19/2023	1108	H	21.0	18.0	18.0		85.7 %
01/19/2023	1115	L	21.0	5.0	5.0		23.8 %
01/19/2023	1120	M	21.0	11.2	11.2		53.3 %
01/19/2023	1125	H	21.0	18.0	18.0		85.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	0.7
M	11.200	11.200	No	0.0
H	18.000	18.000	No	0.0

Linearity Report

04/01/2023

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	01/24/2023	Scale:	High
Performance	5 %	Test No.:	122	Highest	5.0
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/24/2023	0831	L	200.0	51.3	49.9		25.7 %
01/24/2023	0836	M	200.0	105.0	109.7		52.5 %
01/24/2023	0841	H	200.0	180.0	180.8		90.0 %
01/24/2023	0848	L	200.0	51.3	50.6		25.7 %
01/24/2023	0853	M	200.0	105.0	110.4		52.5 %
01/24/2023	0858	H	200.0	180.0	181.0		90.0 %
01/24/2023	0905	L	200.0	51.3	50.6		25.7 %
01/24/2023	0910	M	200.0	105.0	110.5		52.5 %
01/24/2023	0915	H	200.0	180.0	180.8		90.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	50.367	No	1.8
M	105.000	110.200	No	5.0
H	180.000	180.867	No	0.5

Linearity Report

04/01/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	01/30/2023	Scale:	High
Performance	5 %	Test No.:	123	Highest	1.1
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/30/2023	1035	L	21.0	5.5	5.5		26.2 %
01/30/2023	1040	M	21.0	11.1	11.0		52.9 %
01/30/2023	1046	H	21.0	18.0	17.8		85.7 %
01/30/2023	1053	L	21.0	5.5	5.5		26.2 %
01/30/2023	1058	M	21.0	11.1	11.0		52.9 %
01/30/2023	1103	H	21.0	18.0	17.8		85.7 %
01/30/2023	1110	L	21.0	5.5	5.5		26.2 %
01/30/2023	1115	M	21.0	11.1	11.0		52.9 %
01/30/2023	1120	H	21.0	18.0	17.8		85.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	11.100	11.000	No	0.9
H	18.000	17.800	No	1.1

Linearity Report

04/01/2023

Page 5

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	02/08/2023	Scale:	High
Performance	5 %	Test No.:	124	Highest	0.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/08/2023	0738	L	200.0	51.3	50.7		25.7 %
02/08/2023	0743	M	200.0	111.6	111.9		55.8 %
02/08/2023	0749	H	200.0	181.6	182.3		90.8 %
02/08/2023	0756	L	200.0	51.3	51.3		25.7 %
02/08/2023	0801	M	200.0	111.6	112.3		55.8 %
02/08/2023	0806	H	200.0	181.6	182.2		90.8 %
02/08/2023	0813	L	200.0	51.3	51.3		25.7 %
02/08/2023	0818	M	200.0	111.6	112.4		55.8 %
02/08/2023	0823	H	200.0	181.6	182.3		90.8 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	51.100	No	0.4
M	111.600	112.200	No	0.5
H	181.600	182.267	No	0.4

ATTACHMENT 10

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:52 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	84.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:53 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	84.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:54 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	84.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:54 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	84.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 09:55 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	84.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:57 Location: Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:58 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSD 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:58 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 09:59 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:00 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:00 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:01 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:02 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:03 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:04 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,215.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 945.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,215.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:05 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:06 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:07 Location: Roseville, CA

Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:08 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:08 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:09 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:09 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:10 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:11 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:12 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,392.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 768.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,392.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 11

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

- a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
- b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
- c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants; and
- d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:31 Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOx, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Jan 23	1.0650	1.0650	0.3601	0.3601
Feb 23	1.0643	2.1293	0.3569	0.7170
Mar 23	1.0109	3.1402	0.3242	1.0412
Sum/Avg	3.1402		1.0412	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:22 Location: Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOX, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOX, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2023	0.5335	3.5412	0.3763	6.9264	246.77	5,674.59	0.2923	4.0112	0.6889	7.2877	648.12	5,689.32
Feb 2023	0.4640	3.5818	0.5464	7.2146	458.94	5,950.36	0.4525	3.9499	0.5177	7.1402	410.48	5,516.23
Mar 2023	0.2428	3.6280	0.5245	7.3365	481.83	6,040.70	0.7079	4.4478	0.4867	7.4882	303.18	5,715.12
Sum/Avg	3.6280		7.3365		6,040.70		4.4478		7.4882		5,715.12	
Limit Value												

ATTACHMENT 12

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 13

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

ATTACHMENT 14

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2023 12:00	0	10.9	16.7	15.5	2.2	667,214.0	0.83	0.83
01/02/2023 13:00	1	1.8	10.6	13.9	26.2	904,993.9	0.17	1.00
01/02/2023 14:00	2	2.2	14.2	12.5	35.9	1,010,765.6	0.00	1.00
01/02/2023 15:00	2	2.1	13.9	12.6	36.4	1,012,219.1	0.00	1.00
01/02/2023 16:00	2	2.1	13.7	12.6	35.9	1,008,589.3	0.00	1.00
01/02/2023 17:00	2	2.1	13.6	12.6	35.6	1,007,599.4	0.00	1.00
01/02/2023 18:00	2	2.1	13.6	12.7	35.8	1,019,386.2	0.00	1.00
01/02/2023 19:00	2	2.1	13.4	12.7	35.7	1,014,543.1	0.00	1.00
01/02/2023 20:00	2	2.1	13.2	12.8	35.7	1,023,517.9	0.00	1.00
01/02/2023 21:00	1	2.1	12.8	12.9	35.0	1,024,843.0	0.00	1.00
01/02/2023 22:00	1	2.0	12.2	13.1	33.3	1,024,434.8	0.00	1.00
01/02/2023 23:00	1	2.0	11.8	13.2	32.7	1,021,910.7	0.00	1.00
Average/Sum#:	2	2.8	13.3	13.1	31.7	978,334.8	1.00 #	11.83 #
Minimum:	1	1.8	10.6	12.5	2.2	667,214.0	0.00	0.00
Maximum:	2	10.9	16.7	15.5	36.4	1,024,843.0	0.83	1.00
%SI	54.17	50.00	50.00	50.00	50.00	50.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2023 00:00	1	2.0	12.3	13.0	33.9	1,018,921.1	0.00	1.00
01/03/2023 01:00	1	2.0	12.1	13.1	33.6	1,024,083.6	0.00	1.00
01/03/2023 02:00	1	2.0	12.4	13.1	33.6	1,024,434.8	0.00	1.00
01/03/2023 03:00	1	2.0	12.3	13.0	33.5	1,017,534.3	0.00	1.00
01/03/2023 04:00	1	2.0	12.6	12.9	34.8	1,019,707.6	0.00	1.00
01/03/2023 05:00	1	2.0	12.9	12.9	35.2	1,028,608.9	0.00	1.00
01/03/2023 06:00	2	2.2	14.1	12.5	38.6	1,027,883.4	0.00	1.00
01/03/2023 07:00	1	2.0	12.8	12.8	35.2	1,021,151.0	0.00	1.00
01/03/2023 08:00	1	1.9	10.4	13.6	29.5	1,011,498.1	0.00	1.00
01/03/2023 09:00	1	1.9	10.7	13.5	29.8	1,008,747.6	0.00	1.00
01/03/2023 10:00	1	1.8	9.7	13.8	28.0	996,979.5	0.00	1.00
01/03/2023 11:00	1	1.8	9.5	13.9	27.2	999,875.4	0.00	1.00
01/03/2023 12:00	1	1.8	9.9	13.7	26.5	999,679.8	0.00	1.00
01/03/2023 13:00	1	1.8	9.8	13.8	26.9	1,006,816.2	0.00	1.00
01/03/2023 14:00	1	1.9	10.3	13.6	27.5	1,009,247.0	0.00	1.00
01/03/2023 15:00	2	2.1	13.2	12.7	35.7	1,029,406.3	0.00	1.00
01/03/2023 16:00	1	2.0	12.7	12.9	35.0	1,026,383.6	0.00	1.00
01/03/2023 17:00	1	2.0	13.0	12.9	34.8	1,023,131.2	0.00	1.00
01/03/2023 18:00	1	2.1	13.4	12.8	35.3	1,012,190.6	0.00	1.00
01/03/2023 19:00	1	2.0	12.8	12.9	34.4	1,013,545.2	0.00	1.00
01/03/2023 20:00	2	2.1	13.5	12.7	36.0	1,017,048.1	0.00	1.00
01/03/2023 21:00	2	2.1	13.1	12.7	35.5	1,013,040.0	0.00	1.00
01/03/2023 22:00	1	2.1	12.6	12.9	34.3	1,024,329.4	0.00	1.00
01/03/2023 23:00	1	1.9	11.4	13.3	32.0	1,005,085.4	0.00	1.00
Average/Sum#:	1	2.0	12.0	13.1	32.8	1,015,805.3	0.00 #	24.00 #
Minimum:	1	1.8	9.5	12.5	26.5	996,979.5	0.00	1.00
Maximum:	2	2.2	14.1	13.9	38.6	1,029,406.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2023 00:00	1	1.7	8.5	14.3	24.9	995,322.5	0.00	1.00
01/04/2023 01:00	1	1.7	8.7	14.3	25.7	997,604.9	0.00	1.00
01/04/2023 02:00	1	1.8	9.0	14.3	24.3	997,189.9	0.00	1.00
01/04/2023 03:00	1	1.7	8.9	14.3	26.1	998,227.4	0.00	1.00
01/04/2023 04:00	1	1.7	8.7	14.3	25.6	996,567.5	0.00	1.00
01/04/2023 05:00	1	1.7	8.7	14.3	25.7	995,322.5	0.00	1.00
01/04/2023 06:00	1	1.7	8.8	14.3	26.1	998,019.9	0.00	1.00
01/04/2023 07:00	1	1.8	9.8	13.9	28.6	995,962.8	0.00	1.00
01/04/2023 08:00	2	2.2	12.5	14.3	25.4	803,395.6	0.12	1.00
01/04/2023 09:00	0	10.3	21.3	17.5	0.0	90,220.9	0.02	0.02
01/04/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.6	10.5	14.6	23.2	886,783.4	0.14 #	9.02 #
Minimum:	1	1.7	8.5	13.9	0.0	90,220.9	0.00	0.00
Maximum:	2	10.3	21.3	17.5	28.6	998,227.4	0.12	1.00
%SI	62.50	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 15:00	0	15.0	18.2	16.2	0.0	673,348.9	0.50	0.50
01/05/2023 16:00	1	3.4	10.9	14.3	16.9	765,217.7	0.58	1.00
01/05/2023 17:00	1	1.8	10.3	13.7	26.2	997,017.0	0.00	1.00
01/05/2023 18:00	1	1.8	9.4	14.0	24.7	903,423.2	0.00	1.00
01/05/2023 19:00	3	4.4	21.7	15.1	19.1	563,825.1	0.13	0.25
01/05/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	5.3	14.1	14.7	17.4	780,566.4	1.21 #	3.75 #
Minimum:	1	1.8	9.4	13.7	0.0	563,825.1	0.00	0.00
Maximum:	3	15.0	21.7	16.2	26.2	997,017.0	0.58	1.00
%SI	83.33	79.17	79.17	79.17	79.17	79.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 16:00	3	12.0	15.9	15.4	5.7	706,623.0	0.95	0.97
01/06/2023 17:00	1	1.3	8.9	14.1	23.1	952,152.7	0.00	1.00
01/06/2023 18:00	1	1.8	10.0	13.8	26.5	994,665.0	0.00	1.00
01/06/2023 19:00	1	1.8	9.8	13.8	25.9	992,736.2	0.00	1.00
01/06/2023 20:00	1	1.7	10.2	14.2	24.8	796,310.1	0.00	1.00
01/06/2023 21:00	2	2.9	17.3	14.8	23.4	605,240.7	0.13	0.52
01/06/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	3.6	12.0	14.4	21.6	841,288.0	1.08 #	5.49 #
Minimum:	1	1.3	8.9	13.8	5.7	605,240.7	0.00	0.00
Maximum:	3	12.0	17.3	15.4	26.5	994,665.0	0.95	1.00
%SI	75.00	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2023 16:00	2	10.6	14.8	15.4	4.7	681,724.4	0.90	0.92
01/08/2023 17:00	1	1.6	9.1	14.0	22.4	898,263.0	0.00	1.00
01/08/2023 18:00	1	1.9	10.1	13.7	24.1	992,071.9	0.00	1.00
01/08/2023 19:00	1	1.8	9.8	13.7	24.7	982,371.8	0.00	1.00
01/08/2023 20:00	1	1.8	9.7	13.7	24.3	989,979.7	0.00	1.00
01/08/2023 21:00	1	1.8	8.8	14.0	23.4	892,507.5	0.00	1.00
01/08/2023 22:00	3	4.7	20.1	15.1	16.5	551,075.3	0.13	0.27
01/08/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.5	11.8	14.2	20.0	855,427.7	1.03 #	6.19 #
Minimum:	1	1.6	8.8	13.7	4.7	551,075.3	0.00	0.00
Maximum:	3	10.6	20.1	15.4	24.7	992,071.9	0.90	1.00
%SI	70.83	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 13:00	0	3.5	5.5	19.8	0.0	709,610.8	0.10	0.10
01/09/2023 14:00	1	9.2	15.6	14.7	11.2	647,384.3	0.70	1.00
01/09/2023 15:00	1	1.8	8.3	14.1	20.9	939,062.6	0.00	1.00
01/09/2023 16:00	1	1.9	10.2	13.3	26.6	975,714.9	0.00	1.00
01/09/2023 17:00	1	1.9	10.2	13.4	27.6	994,749.9	0.00	1.00
01/09/2023 18:00	1	1.9	9.8	13.5	27.2	996,348.8	0.00	1.00
01/09/2023 19:00	1	1.9	9.7	13.5	27.3	993,758.0	0.00	1.00
01/09/2023 20:00	1	1.9	9.6	13.5	27.2	992,832.7	0.00	1.00
01/09/2023 21:00	1	3.1	11.0	14.3	19.9	846,553.3	0.17	0.93
01/09/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.0	10.0	14.5	20.9	899,557.3	0.97 #	8.03 #
Minimum:	1	1.8	5.5	13.3	0.0	647,384.3	0.00	0.00
Maximum:	1	9.2	15.6	19.8	27.6	996,348.8	0.70	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2023 15:00	0	2.0	3.7	20.1	0.0	792,554.4	0.07	0.07
01/10/2023 16:00	2	9.9	15.7	14.9	16.0	682,658.1	0.75	1.00
01/10/2023 17:00	1	1.7	9.3	13.9	20.3	956,445.1	0.00	1.00
01/10/2023 18:00	1	1.9	9.8	13.6	27.8	997,241.1	0.00	1.00
01/10/2023 19:00	1	1.9	9.7	13.6	28.0	999,117.0	0.00	1.00
01/10/2023 20:00	1	1.8	9.7	13.7	28.0	997,397.4	0.00	1.00
01/10/2023 21:00	1	1.8	9.6	13.9	26.9	1,001,831.8	0.00	1.00
01/10/2023 22:00	1	1.7	9.0	14.1	24.7	908,049.2	0.00	1.00
01/10/2023 23:00	4	4.1	22.0	15.1	24.1	570,672.2	0.13	0.25
Average/Sum#:	2	3.0	10.9	14.8	21.8	878,440.7	0.95 #	7.32 #
Minimum:	1	1.7	3.7	13.6	0.0	570,672.2	0.00	0.00
Maximum:	4	9.9	22.0	20.1	28.0	1,001,831.8	0.75	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 15:00	1	8.9	14.9	15.3	12.1	671,996.1	0.78	0.97
01/11/2023 16:00	1	1.8	9.6	13.9	20.3	910,862.8	0.00	1.00
01/11/2023 17:00	1	1.9	10.2	13.7	27.3	1,007,097.5	0.00	1.00
01/11/2023 18:00	1	1.8	9.5	13.8	26.7	995,050.8	0.00	1.00
01/11/2023 19:00	1	1.8	9.6	13.8	26.5	988,878.7	0.00	1.00
01/11/2023 20:00	1	1.7	9.1	14.0	25.4	894,293.7	0.00	1.00
01/11/2023 21:00	0	7.6	27.0	15.7	4.0	518,011.1	0.13	0.13
01/11/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.6	12.8	14.3	20.3	855,170.1	0.91 #	6.10 #
Minimum:	1	1.7	9.1	13.7	4.0	518,011.1	0.00	0.00
Maximum:	1	8.9	27.0	15.7	27.3	1,007,097.5	0.78	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2023 15:00	0	13.7	15.3	18.9	0.0	735,380.9	0.20	0.20
01/12/2023 16:00	2	6.9	14.2	14.5	13.4	644,057.4	0.85	1.00
01/12/2023 17:00	1	1.7	10.1	14.0	21.9	863,531.2	0.00	1.00
01/12/2023 18:00	1	1.8	10.1	13.7	26.1	982,942.4	0.00	1.00
01/12/2023 19:00	1	1.8	10.5	13.8	27.9	994,086.4	0.00	1.00
01/12/2023 20:00	1	1.8	10.8	13.7	28.1	982,371.8	0.00	1.00
01/12/2023 21:00	1	1.7	10.4	14.0	26.9	876,233.1	0.00	1.00
01/12/2023 22:00	1	4.7	20.5	15.2	11.6	568,671.5	0.13	0.27
01/12/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	4.3	12.7	14.7	19.5	830,909.3	1.18 #	6.47 #
Minimum:	1	1.7	10.1	13.7	0.0	568,671.5	0.00	0.00
Maximum:	2	13.7	20.5	18.9	28.1	994,086.4	0.85	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 14:00	0	3.1	5.5	19.7	0.0	666,453.2	0.10	0.10
01/14/2023 15:00	0	10.9	17.1	14.7	11.9	636,782.3	1.00	1.00
01/14/2023 16:00	1	1.8	10.6	13.9	22.7	889,930.2	0.03	1.00
01/14/2023 17:00	1	1.9	11.0	13.7	29.8	983,893.4	0.00	1.00
01/14/2023 18:00	1	1.8	10.7	13.7	28.3	989,599.3	0.00	1.00
01/14/2023 19:00	1	1.8	9.1	14.0	25.0	910,568.0	0.00	1.00
01/14/2023 20:00	3	4.3	19.4	14.9	17.8	571,278.2	0.12	0.25
01/14/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.7	11.9	14.9	19.4	806,929.2	1.25 #	5.35 #
Minimum:	1	1.8	5.5	13.7	0.0	571,278.2	0.00	0.00
Maximum:	3	10.9	19.4	19.7	29.8	989,599.3	1.00	1.00
%SI	79.17	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2023 14:00	0	0.0	0.0	20.8	0.0	1,930,888.4	0.02	0.02
01/15/2023 15:00	2	9.5	14.8	15.0	12.9	650,824.7	0.90	1.00
01/15/2023 16:00	1	1.6	9.0	14.2	21.0	951,443.4	0.00	1.00
01/15/2023 17:00	1	1.9	10.7	13.5	29.8	985,800.5	0.00	1.00
01/15/2023 18:00	1	1.9	10.6	13.5	29.6	986,540.7	0.00	1.00
01/15/2023 19:00	1	1.8	10.1	13.7	28.8	987,697.3	0.00	1.00
01/15/2023 20:00	1	1.8	10.1	13.7	29.1	989,028.7	0.00	1.00
01/15/2023 21:00	2	1.7	9.9	14.1	25.9	804,738.2	0.00	1.00
01/15/2023 22:00	5	4.8	22.4	15.3	21.3	543,123.5	0.13	0.23
01/15/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.8	10.8	14.9	22.0	981,120.6	1.05 #	7.25 #
Minimum:	1	0.0	0.0	13.5	0.0	543,123.5	0.00	0.00
Maximum:	5	9.5	22.4	20.8	29.8	1,930,888.4	0.90	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2023 15:00	5	9.6	16.5	15.3	16.1	643,874.0	0.93	1.00
01/16/2023 16:00	1	1.5	11.9	14.2	20.6	775,053.3	0.00	1.00
01/16/2023 17:00	1	1.8	10.5	13.8	27.3	999,294.0	0.00	1.00
01/16/2023 18:00	1	1.8	10.2	13.8	27.8	998,329.7	0.00	1.00
01/16/2023 19:00	1	1.8	10.2	13.8	28.2	997,365.3	0.00	1.00
01/16/2023 20:00	1	1.8	10.0	13.8	28.5	993,893.5	0.00	1.00
01/16/2023 21:00	1	1.8	10.1	13.8	28.6	991,193.2	0.00	1.00
01/16/2023 22:00	2	2.4	12.4	14.3	24.9	818,542.3	0.12	1.00
01/16/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.8	11.5	14.1	25.3	902,193.2	1.05 #	8.00 #
Minimum:	1	1.5	10.0	13.8	16.1	643,874.0	0.00	0.00
Maximum:	5	9.6	16.5	15.3	28.6	999,294.0	0.93	1.00
%SI	66.67	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2023 17:00	0	10.0	15.7	15.4	9.0	681,226.4	1.00	1.00
01/17/2023 18:00	1	1.8	10.7	14.0	26.3	877,423.9	0.12	1.00
01/17/2023 19:00	1	1.8	10.4	13.9	30.4	1,001,049.2	0.00	1.00
01/17/2023 20:00	1	1.8	10.2	13.9	29.8	1,001,831.8	0.00	1.00
01/17/2023 21:00	1	1.8	10.0	13.9	29.4	998,897.3	0.00	1.00
01/17/2023 22:00	1	1.8	9.8	14.0	29.3	1,010,595.5	0.00	1.00
01/17/2023 23:00	1	1.8	9.8	14.0	29.4	1,009,603.2	0.00	1.00
Average/Sum#:	1	3.0	10.9	14.2	26.2	940,089.6	1.12 #	7.00 #
Minimum:	1	1.8	9.8	13.9	9.0	681,226.4	0.00	0.00
Maximum:	1	10.0	15.7	15.4	30.4	1,010,595.5	1.00	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2023 00:00	1	1.8	9.9	13.9	29.6	1,002,809.9	0.00	1.00
01/18/2023 01:00	1	1.8	9.9	13.9	29.5	1,004,570.6	0.00	1.00
01/18/2023 02:00	1	1.8	10.3	13.9	29.4	1,004,179.3	0.00	1.00
01/18/2023 03:00	1	1.8	10.1	13.9	30.0	1,003,005.5	0.00	1.00
01/18/2023 04:00	1	1.8	9.9	14.0	29.8	1,014,961.8	0.00	1.00
01/18/2023 05:00	1	1.8	9.8	14.0	30.2	1,011,190.9	0.00	1.00
01/18/2023 06:00	1	1.8	10.1	13.9	30.3	1,006,526.9	0.00	1.00
01/18/2023 07:00	1	1.8	9.8	14.0	30.1	1,001,069.1	0.00	1.00
01/18/2023 08:00	2	1.7	9.8	14.1	29.5	912,882.5	0.00	1.00
01/18/2023 09:00	4	4.0	24.8	15.2	25.1	578,521.7	0.13	0.23
01/18/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.0	11.4	14.1	29.4	953,971.8	0.13 #	9.23 #
Minimum:	1	1.7	9.8	13.9	25.1	578,521.7	0.00	0.00
Maximum:	4	4.0	24.8	15.2	30.3	1,014,961.8	0.13	1.00
%SI	58.33	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2023 16:00	0	12.1	17.9	15.4	2.0	684,961.2	0.83	0.83
01/23/2023 17:00	1	2.1	10.5	14.2	25.2	884,402.9	0.30	1.00
01/23/2023 18:00	1	1.9	11.9	13.6	32.5	1,013,561.6	0.00	1.00
01/23/2023 19:00	1	2.0	13.2	13.1	35.3	1,023,556.9	0.00	1.00
01/23/2023 20:00	1	2.0	12.4	13.2	33.8	1,013,907.6	0.00	1.00
01/23/2023 21:00	1	1.9	11.6	13.5	32.5	1,006,156.8	0.00	1.00
01/23/2023 22:00	1	1.9	10.9	13.6	32.7	1,026,505.5	0.00	1.00
01/23/2023 23:00	1	1.8	10.1	13.8	31.2	1,015,495.7	0.00	1.00
Average/Sum#:	1	3.2	12.3	13.8	28.2	958,568.5	1.13 #	7.83 #
Minimum:	1	1.8	10.1	13.1	2.0	684,961.2	0.00	0.00
Maximum:	1	12.1	17.9	15.4	35.3	1,026,505.5	0.83	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2023 00:00	1	1.7	8.5	14.4	25.6	1,013,795.4	0.00	1.00
01/24/2023 01:00	1	1.7	8.6	14.4	26.5	1,016,744.9	0.00	1.00
01/24/2023 02:00	1	1.7	9.2	14.3	26.6	996,567.5	0.00	1.00
01/24/2023 03:00	1	1.7	8.9	14.3	26.9	996,360.0	0.00	1.00
01/24/2023 04:00	1	1.7	8.8	14.3	26.9	996,152.5	0.00	1.00
01/24/2023 05:00	1	1.8	11.0	13.7	33.7	1,004,244.5	0.00	1.00
01/24/2023 06:00	2	2.0	12.9	13.1	38.3	1,043,922.7	0.00	1.00
01/24/2023 07:00	1	1.8	10.1	14.0	32.1	1,021,511.2	0.00	1.00
01/24/2023 08:00	1	1.7	9.8	14.1	31.7	1,021,429.5	0.00	1.00
01/24/2023 09:00	3	1.7	12.1	14.4	35.6	826,289.6	0.00	1.00
01/24/2023 10:00	3	3.4	23.5	15.2	25.2	583,807.2	0.13	0.28
01/24/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	1.9	11.2	14.2	29.9	956,438.6	0.13 #	10.28 #
Minimum:	1	1.7	8.5	13.1	25.2	583,807.2	0.00	0.00
Maximum:	3	3.4	23.5	15.2	38.3	1,043,922.7	0.13	1.00
%SI	54.17	54.17	54.17	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 16:00	0	12.0	16.1	15.7	0.0	775,304.9	0.63	0.63
01/27/2023 17:00	1	2.3	9.8	14.1	23.4	958,395.7	0.37	1.00
01/27/2023 18:00	1	1.8	10.9	13.8	28.8	997,365.3	0.00	1.00
01/27/2023 19:00	1	1.7	10.0	14.0	26.6	937,559.5	0.00	1.00
01/27/2023 20:00	2	1.6	11.8	14.3	27.0	676,620.1	0.00	1.00
01/27/2023 21:00	2	1.6	15.1	14.5	34.2	619,022.6	0.00	1.00
01/27/2023 22:00	2	1.6	14.8	14.5	32.8	621,162.3	0.00	1.00
01/27/2023 23:00	2	1.6	14.7	14.5	32.7	624,371.9	0.00	1.00
Average/Sum#:	2	3.0	12.9	14.4	25.7	776,225.3	1.00 #	7.63 #
Minimum:	1	1.6	9.8	13.8	0.0	619,022.6	0.00	0.00
Maximum:	2	12.0	16.1	15.7	34.2	997,365.3	0.63	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2023 00:00	2	1.6	15.0	14.4	33.9	613,502.1	0.00	1.00
01/28/2023 01:00	3	1.6	15.5	14.5	35.7	621,804.3	0.00	1.00
01/28/2023 02:00	2	1.6	16.2	14.5	36.6	622,660.1	0.00	1.00
01/28/2023 03:00	3	1.7	15.9	14.5	36.1	622,660.1	0.00	1.00
01/28/2023 04:00	3	1.6	15.6	14.5	35.8	622,232.2	0.00	1.00
01/28/2023 05:00	3	1.6	15.7	14.5	36.8	622,660.1	0.00	1.00
01/28/2023 06:00	2	1.6	15.5	14.4	33.8	630,145.9	0.00	1.00
01/28/2023 07:00	3	1.6	16.3	14.5	42.5	621,162.3	0.00	1.00
01/28/2023 08:00	3	1.4	16.4	14.5	40.3	622,446.2	0.00	1.00
01/28/2023 09:00	3	1.5	16.1	14.5	37.4	623,516.0	0.00	1.00
01/28/2023 10:00	2	1.6	14.6	14.5	32.1	623,088.1	0.00	1.00
01/28/2023 11:00	2	1.6	13.8	14.5	29.6	623,730.0	0.00	1.00
01/28/2023 12:00	2	1.6	13.4	14.5	28.5	624,371.9	0.00	1.00
01/28/2023 13:00	2	1.6	13.9	14.5	29.8	619,022.6	0.00	1.00
01/28/2023 14:00	2	1.6	13.5	14.5	28.9	624,799.9	0.00	1.00
01/28/2023 15:00	2	1.6	13.1	14.5	27.1	625,869.7	0.00	1.00
01/28/2023 16:00	2	1.6	13.3	14.5	28.0	625,869.7	0.00	1.00
01/28/2023 17:00	2	1.6	13.4	14.5	29.2	624,158.0	0.00	1.00
01/28/2023 18:00	2	1.6	13.5	14.5	29.7	622,018.2	0.00	1.00
01/28/2023 19:00	2	1.6	14.3	14.5	31.7	616,027.0	0.00	1.00
01/28/2023 20:00	2	1.6	15.0	14.5	33.4	616,668.9	0.00	1.00
01/28/2023 21:00	2	1.6	14.5	14.5	32.1	621,376.3	0.00	1.00
01/28/2023 22:00	2	1.6	14.3	14.5	32.1	622,660.1	0.00	1.00
01/28/2023 23:00	2	1.6	14.4	14.5	32.1	622,018.2	0.00	1.00
Average/Sum#:	2	1.6	14.7	14.5	33.1	622,269.5	0.00 #	24.00 #
Minimum:	2	1.4	13.1	14.4	27.1	613,502.1	0.00	1.00
Maximum:	3	1.7	16.4	14.5	42.5	630,145.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2023 00:00	2	1.6	14.8	14.5	33.4	620,306.5	0.00	1.00
01/29/2023 01:00	2	1.6	14.5	14.4	32.5	612,027.4	0.00	1.00
01/29/2023 02:00	2	1.6	15.0	14.4	33.2	613,080.8	0.00	1.00
01/29/2023 03:00	2	1.7	14.7	14.4	32.3	612,448.7	0.00	1.00
01/29/2023 04:00	2	1.6	14.4	14.4	32.1	612,870.1	0.00	1.00
01/29/2023 05:00	2	1.6	14.1	14.4	31.7	614,344.8	0.00	1.00
01/29/2023 06:00	2	1.6	13.9	14.4	31.2	613,291.4	0.00	1.00
01/29/2023 07:00	2	1.6	14.1	14.5	31.8	623,516.0	0.00	1.00
01/29/2023 08:00	2	1.6	12.3	14.4	25.3	717,157.0	0.00	1.00
01/29/2023 09:00	1	1.7	8.8	14.3	20.7	874,771.7	0.00	1.00
01/29/2023 10:00	1	1.7	9.0	14.2	26.9	983,737.2	0.00	1.00
01/29/2023 11:00	1	1.8	10.7	13.9	28.6	990,485.1	0.00	1.00
01/29/2023 12:00	2	1.6	9.4	14.3	24.2	791,361.3	0.00	1.00
01/29/2023 13:00	2	1.6	14.0	14.4	32.6	614,976.9	0.00	1.00
01/29/2023 14:00	2	1.6	14.2	14.4	31.9	614,344.8	0.00	1.00
01/29/2023 15:00	2	1.6	14.1	14.4	31.9	614,976.9	0.00	1.00
01/29/2023 16:00	2	1.6	13.8	14.4	29.7	624,668.2	0.00	1.00
01/29/2023 17:00	3	1.6	14.5	14.4	34.7	613,712.8	0.00	1.00
01/29/2023 18:00	3	1.6	15.0	14.5	34.6	623,302.1	0.00	1.00
01/29/2023 19:00	3	1.6	15.2	14.5	34.6	622,018.2	0.00	1.00
01/29/2023 20:00	3	1.6	15.3	14.4	34.7	614,344.8	0.00	1.00
01/29/2023 21:00	3	1.6	16.0	14.5	37.2	623,088.1	0.00	1.00
01/29/2023 22:00	3	1.6	16.4	14.5	37.9	622,874.1	0.00	1.00
01/29/2023 23:00	3	1.6	16.8	14.5	39.2	619,450.6	0.00	1.00
Average/Sum#:	2	1.6	13.8	14.4	31.8	670,298.1	0.00 #	24.00 #
Minimum:	1	1.6	8.8	13.9	20.7	612,027.4	0.00	1.00
Maximum:	3	1.8	16.8	14.5	39.2	990,485.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2023 00:00	3	1.6	16.7	14.5	38.3	623,302.1	0.00	1.00
01/30/2023 01:00	3	1.6	16.4	14.5	38.0	627,153.6	0.00	1.00
01/30/2023 02:00	1	1.4	12.0	14.3	28.0	850,703.0	0.00	1.00
01/30/2023 03:00	1	1.8	10.2	14.0	28.7	1,010,000.1	0.00	1.00
01/30/2023 04:00	1	1.8	10.1	14.0	31.3	1,007,420.0	0.00	1.00
01/30/2023 05:00	2	1.8	10.7	13.8	34.3	1,030,540.1	0.00	1.00
01/30/2023 06:00	2	1.9	11.7	13.5	37.5	1,044,833.8	0.00	1.00
01/30/2023 07:00	2	2.3	17.1	12.0	52.4	1,061,073.1	0.00	1.00
01/30/2023 08:00	2	2.2	16.0	12.3	47.1	1,043,310.3	0.00	1.00
01/30/2023 09:00	1	1.8	10.5	13.9	30.8	1,021,395.0	0.00	1.00
01/30/2023 10:00	1	1.7	9.8	14.1	30.4	1,010,353.3	0.00	1.00
01/30/2023 11:00	1	1.7	10.8	14.1	31.5	1,012,165.7	0.00	1.00
01/30/2023 12:00	1	1.7	10.9	14.0	30.7	1,003,252.2	0.00	1.00
01/30/2023 13:00	1	1.8	10.7	14.0	30.3	1,005,038.4	0.00	1.00
01/30/2023 14:00	1	1.8	10.9	14.0	30.1	1,011,389.4	0.00	1.00
01/30/2023 15:00	1	1.8	10.9	14.0	29.1	1,009,801.6	0.00	1.00
01/30/2023 16:00	1	1.8	10.8	14.0	29.1	1,007,817.0	0.00	1.00
01/30/2023 17:00	1	1.8	10.7	14.0	29.5	999,878.3	0.00	1.00
01/30/2023 18:00	1	1.7	10.5	14.1	30.5	1,000,888.1	0.00	1.00
01/30/2023 19:00	1	1.7	10.6	14.1	31.0	998,068.7	0.00	1.00
01/30/2023 20:00	1	1.7	10.7	14.1	31.6	1,004,513.1	0.00	1.00
01/30/2023 21:00	1	1.7	10.8	14.1	32.0	1,009,144.9	0.00	1.00
01/30/2023 22:00	1	1.7	11.0	14.1	32.3	1,010,554.6	0.00	1.00
01/30/2023 23:00	1	1.7	10.7	14.1	32.2	1,014,179.6	0.00	1.00
Average/Sum#:	1	1.8	11.7	13.9	33.2	975,699.0	0.00 #	24.00 #
Minimum:	1	1.4	9.8	12.0	28.0	623,302.1	0.00	1.00
Maximum:	3	2.3	17.1	14.5	52.4	1,061,073.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2023 00:00	1	1.7	10.9	14.1	32.3	1,014,985.1	0.00	1.00
01/31/2023 01:00	1	1.8	10.3	14.1	32.0	1,019,214.2	0.00	1.00
01/31/2023 02:00	1	1.8	10.9	14.1	32.7	1,021,429.5	0.00	1.00
01/31/2023 03:00	1	1.8	10.6	14.1	32.9	1,021,228.1	0.00	1.00
01/31/2023 04:00	1	1.7	10.2	14.0	31.8	1,012,183.2	0.00	1.00
01/31/2023 05:00	1	1.7	9.7	14.0	30.7	1,015,557.2	0.00	1.00
01/31/2023 06:00	1	1.8	10.0	14.0	32.2	1,027,266.8	0.00	1.00
01/31/2023 07:00	1	1.8	10.4	13.9	32.7	1,028,633.3	0.00	1.00
01/31/2023 08:00	1	1.7	9.8	14.0	31.2	1,014,564.8	0.00	1.00
01/31/2023 09:00	1	1.7	9.5	14.1	30.1	1,019,617.0	0.00	1.00
01/31/2023 10:00	1	1.7	9.3	14.1	28.3	1,015,387.9	0.00	1.00
01/31/2023 11:00	1	1.7	9.5	14.1	28.6	1,014,985.1	0.00	1.00
01/31/2023 12:00	1	1.7	9.3	14.1	27.9	1,007,131.1	0.00	1.00
01/31/2023 13:00	2	1.7	9.7	14.2	28.3	912,404.5	0.00	1.00
01/31/2023 14:00	2	1.6	15.9	14.6	34.6	626,674.7	0.00	1.00
01/31/2023 15:00	1	1.6	10.9	14.4	21.8	844,829.5	0.00	1.00
01/31/2023 16:00	1	1.8	10.1	14.0	26.8	997,298.2	0.00	1.00
01/31/2023 17:00	1	1.7	9.7	14.1	27.2	1,004,513.1	0.00	1.00
01/31/2023 18:00	1	1.7	10.0	14.1	28.0	1,000,082.6	0.00	1.00
01/31/2023 19:00	1	1.7	9.8	14.1	28.2	1,000,888.1	0.00	1.00
01/31/2023 20:00	1	1.7	9.6	14.1	27.7	1,003,103.4	0.00	1.00
01/31/2023 21:00	1	1.7	9.3	14.1	28.0	1,007,332.5	0.00	1.00
01/31/2023 22:00	1	1.7	9.5	14.1	29.2	1,013,172.7	0.00	1.00
01/31/2023 23:00	1	1.7	9.6	14.1	28.8	1,015,387.9	0.00	1.00
Average/Sum#:	1	1.7	10.2	14.1	29.7	985,744.6	0.00 #	24.00 #
Minimum:	1	1.6	9.3	13.9	21.8	626,674.7	0.00	1.00
Maximum:	2	1.8	15.9	14.6	34.6	1,028,633.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag: > 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023 00:00	1	1.7	9.6	14.1	28.9	1,013,575.4	0.00	1.00
02/01/2023 01:00	1	1.7	9.3	14.1	29.1	1,016,797.6	0.00	1.00
02/01/2023 02:00	1	1.7	9.8	14.1	28.8	1,016,596.2	0.00	1.00
02/01/2023 03:00	1	1.8	9.6	14.1	28.7	1,018,207.3	0.00	1.00
02/01/2023 04:00	1	1.7	9.4	14.1	29.8	1,021,630.9	0.00	1.00
02/01/2023 05:00	1	1.7	9.4	14.0	29.8	1,008,015.4	0.00	1.00
02/01/2023 06:00	1	1.7	9.3	14.0	29.4	1,008,412.4	0.00	1.00
02/01/2023 07:00	1	1.7	9.3	14.1	29.1	1,020,623.9	0.00	1.00
02/01/2023 08:00	1	1.7	9.3	14.0	29.4	1,007,420.0	0.00	1.00
02/01/2023 09:00	1	1.7	9.1	14.1	28.4	1,016,193.4	0.00	1.00
02/01/2023 10:00	2	1.7	11.5	14.3	29.4	754,428.3	0.00	1.00
02/01/2023 11:00	2	1.6	13.5	14.5	29.0	632,716.9	0.00	1.00
02/01/2023 12:00	2	1.6	13.3	14.5	29.4	634,214.7	0.00	1.00
02/01/2023 13:00	2	1.6	13.1	14.5	28.0	634,000.7	0.00	1.00
02/01/2023 14:00	2	1.6	13.5	14.5	29.1	627,581.5	0.00	1.00
02/01/2023 15:00	2	1.6	13.9	14.5	29.9	621,590.3	0.00	1.00
02/01/2023 16:00	2	1.6	14.2	14.5	31.1	619,664.5	0.00	1.00
02/01/2023 17:00	2	1.6	14.6	14.5	31.4	620,306.5	0.00	1.00
02/01/2023 18:00	2	1.6	15.0	14.5	33.3	619,664.5	0.00	1.00
02/01/2023 19:00	3	1.6	15.5	14.5	35.7	616,882.9	0.00	1.00
02/01/2023 20:00	3	1.6	16.0	14.6	37.8	625,805.2	0.00	1.00
02/01/2023 21:00	3	1.6	16.1	14.6	38.2	624,718.4	0.00	1.00
02/01/2023 22:00	3	1.6	16.4	14.6	39.7	623,196.8	0.00	1.00
02/01/2023 23:00	3	1.6	16.7	14.6	40.5	622,979.4	0.00	1.00
Average/Sum#:	2	1.7	12.4	14.3	31.4	792,717.6	0.00 #	24.00 #
Minimum:	1	1.6	9.1	14.0	28.0	616,882.9	0.00	1.00
Maximum:	3	1.8	16.7	14.6	40.5	1,021,630.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2023 00:00	3	1.6	16.9	14.6	40.7	624,066.3	0.00	1.00
02/02/2023 01:00	2	1.6	15.3	14.5	34.6	629,507.3	0.00	1.00
02/02/2023 02:00	2	1.6	15.9	14.5	36.0	627,367.5	0.00	1.00
02/02/2023 03:00	3	1.6	15.4	14.5	35.7	627,153.6	0.00	1.00
02/02/2023 04:00	3	1.6	15.4	14.5	36.6	626,511.7	0.00	1.00
02/02/2023 05:00	3	1.6	15.8	14.5	37.5	627,581.5	0.00	1.00
02/02/2023 06:00	3	1.6	15.4	14.5	36.6	630,577.1	0.00	1.00
02/02/2023 07:00	3	1.6	15.3	14.5	36.0	628,865.4	0.00	1.00
02/02/2023 08:00	3	1.6	15.2	14.5	36.2	628,009.5	0.00	1.00
02/02/2023 09:00	3	1.6	15.0	14.5	35.3	628,223.4	0.00	1.00
02/02/2023 10:00	2	1.6	14.7	14.5	33.5	626,725.6	0.00	1.00
02/02/2023 11:00	2	1.6	15.4	14.5	34.3	619,878.5	0.00	1.00
02/02/2023 12:00	2	1.6	15.2	14.5	33.0	619,450.6	0.00	1.00
02/02/2023 13:00	2	1.6	14.9	14.5	31.4	618,808.6	0.00	1.00
02/02/2023 14:00	2	1.6	14.6	14.5	31.2	617,738.8	0.00	1.00
02/02/2023 15:00	2	1.6	14.7	14.5	32.0	616,454.9	0.00	1.00
02/02/2023 16:00	2	1.6	14.4	14.6	31.0	626,022.6	0.00	1.00
02/02/2023 17:00	2	1.6	14.9	14.5	32.4	617,524.8	0.00	1.00
02/02/2023 18:00	2	1.6	15.2	14.5	33.9	617,310.8	0.00	1.00
02/02/2023 19:00	3	1.6	15.6	14.5	36.4	613,459.3	0.00	1.00
02/02/2023 20:00	2	1.6	15.4	14.5	34.5	613,887.3	0.00	1.00
02/02/2023 21:00	2	1.6	13.8	14.5	29.8	622,018.2	0.00	1.00
02/02/2023 22:00	3	1.6	15.4	14.5	35.9	619,022.6	0.00	1.00
02/02/2023 23:00	3	1.6	15.9	14.5	37.2	617,310.8	0.00	1.00
Average/Sum#:	2	1.6	15.2	14.5	34.7	622,644.9	0.00 #	24.00 #
Minimum:	2	1.6	13.8	14.5	29.8	613,459.3	0.00	1.00
Maximum:	3	1.6	16.9	14.6	40.7	630,577.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2023 00:00	3	1.6	16.0	14.5	37.3	615,813.0	0.00	1.00
02/03/2023 01:00	2	1.6	14.6	14.5	32.5	622,874.1	0.00	1.00
02/03/2023 02:00	2	1.7	15.8	14.5	33.0	620,948.4	0.00	1.00
02/03/2023 03:00	3	1.6	16.1	14.5	37.1	615,171.1	0.00	1.00
02/03/2023 04:00	3	1.6	16.1	14.6	37.3	622,109.9	0.00	1.00
02/03/2023 05:00	2	1.6	15.7	14.6	35.3	623,414.1	0.00	1.00
02/03/2023 06:00	3	1.6	15.7	14.5	36.0	614,957.1	0.00	1.00
02/03/2023 07:00	1	1.5	12.2	14.4	24.3	705,990.9	0.00	1.00
02/03/2023 08:00	2	1.7	12.9	14.4	31.6	689,768.5	0.00	1.00
02/03/2023 09:00	3	1.6	15.3	14.5	35.2	614,315.2	0.00	1.00
02/03/2023 10:00	2	1.6	14.5	14.5	32.6	624,585.9	0.00	1.00
02/03/2023 11:00	1	1.6	10.3	14.3	20.0	830,576.6	0.00	1.00
02/03/2023 12:00	1	1.8	9.0	14.0	21.7	994,916.6	0.00	1.00
02/03/2023 13:00	1	1.8	9.0	14.0	23.7	994,519.7	0.00	1.00
02/03/2023 14:00	1	1.8	9.0	14.0	23.9	994,122.7	0.00	1.00
02/03/2023 15:00	1	1.7	8.7	14.1	23.4	988,603.6	0.00	1.00
02/03/2023 16:00	2	1.7	9.7	14.4	24.1	767,299.0	0.00	1.00
02/03/2023 17:00	1	1.7	9.3	14.2	21.1	884,811.7	0.00	1.00
02/03/2023 18:00	1	1.9	9.8	13.6	28.5	1,004,182.0	0.00	1.00
02/03/2023 19:00	1	1.9	10.3	13.5	30.0	1,020,221.2	0.00	1.00
02/03/2023 20:00	1	1.9	10.3	13.5	30.1	1,019,110.8	0.00	1.00
02/03/2023 21:00	1	1.8	9.0	13.8	28.1	1,010,480.9	0.00	1.00
02/03/2023 22:00	1	1.8	9.4	13.8	28.6	1,001,994.3	0.00	1.00
02/03/2023 23:00	1	1.7	8.7	14.1	26.1	933,826.6	0.00	1.00
Average/Sum#:	2	1.7	12.0	14.2	29.2	808,942.2	0.00 #	24.00 #
Minimum:	1	1.5	8.7	13.5	20.0	614,315.2	0.00	1.00
Maximum:	3	1.9	16.1	14.6	37.3	1,020,221.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2023 00:00	4	4.3	20.0	15.1	22.3	578,699.9	0.13	0.27
02/04/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2023 16:00	0	10.0	15.1	15.4	6.9	656,576.7	0.87	0.87
02/04/2023 17:00	1	1.8	10.1	14.1	23.3	869,785.9	0.05	1.00
02/04/2023 18:00	1	1.9	10.1	13.6	27.1	1,003,431.6	0.00	1.00
02/04/2023 19:00	1	1.9	10.2	13.5	27.9	1,002,270.6	0.00	1.00
02/04/2023 20:00	1	1.9	10.2	13.4	27.6	1,004,609.7	0.00	1.00
02/04/2023 21:00	1	1.9	10.3	13.3	27.4	989,228.9	0.00	1.00
02/04/2023 22:00	1	1.8	8.7	13.9	23.2	889,343.3	0.00	1.00
02/04/2023 23:00	3	5.8	19.7	15.2	13.9	565,788.5	0.13	0.23
Average/Sum#:	2	3.5	12.7	14.2	22.2	839,970.6	1.18 #	7.37 #
Minimum:	1	1.8	8.7	13.3	6.9	565,788.5	0.00	0.00
Maximum:	4	10.0	20.0	15.4	27.9	1,004,609.7	0.87	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2023 17:00	0	0.3	1.8	20.7	0.0	2,184,231.9	0.05	0.05
02/05/2023 18:00	4	11.2	16.5	15.1	13.8	668,893.0	0.95	1.00
02/05/2023 19:00	1	1.5	11.3	14.2	22.8	674,083.8	0.00	1.00
02/05/2023 20:00	1	1.8	9.7	13.9	25.7	921,231.3	0.00	1.00
02/05/2023 21:00	1	1.7	9.0	14.1	25.6	918,924.0	0.00	1.00
02/05/2023 22:00	4	2.8	20.5	14.9	35.3	594,330.2	0.13	0.50
02/05/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	3.2	11.5	15.5	20.5	993,615.7	1.13 #	4.55 #
Minimum:	1	0.3	1.8	13.9	0.0	594,330.2	0.00	0.00
Maximum:	4	11.2	20.5	20.7	35.3	2,184,231.9	0.95	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2023 15:00	0	3.1	5.4	19.9	0.0	699,775.9	0.10	0.10
02/06/2023 16:00	1	8.5	16.9	14.8	14.4	659,344.2	0.83	1.00
02/06/2023 17:00	1	1.8	9.7	13.9	23.4	970,921.9	0.00	1.00
02/06/2023 18:00	1	1.9	10.8	13.5	29.2	1,015,779.8	0.00	1.00
02/06/2023 19:00	1	1.9	10.6	13.5	30.3	1,014,854.5	0.00	1.00
02/06/2023 20:00	1	2.0	11.9	13.1	33.6	1,020,572.3	0.00	1.00
02/06/2023 21:00	1	1.8	10.1	13.7	29.1	1,013,754.4	0.00	1.00
02/06/2023 22:00	2	1.7	9.4	14.1	28.4	892,743.9	0.00	1.00
02/06/2023 23:00	2	3.2	16.4	14.7	20.2	631,039.6	0.13	0.53
Average/Sum#:	1	2.9	11.2	14.6	23.2	879,865.2	1.06 #	7.63 #
Minimum:	1	1.7	5.4	13.1	0.0	631,039.6	0.00	0.00
Maximum:	2	8.5	16.9	19.9	33.6	1,020,572.3	0.83	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2023 15:00	0	7.9	10.0	19.5	0.0	763,943.2	0.15	0.15
02/07/2023 16:00	0	8.0	15.2	14.6	14.6	699,493.3	0.77	1.00
02/07/2023 17:00	1	1.8	9.9	13.9	24.3	979,138.4	0.00	1.00
02/07/2023 18:00	1	2.0	11.3	13.2	29.3	995,945.0	0.00	1.00
02/07/2023 19:00	1	1.9	11.4	13.2	32.8	1,009,283.6	0.00	1.00
02/07/2023 20:00	1	2.0	11.9	13.1	33.4	1,018,114.4	0.00	1.00
02/07/2023 21:00	1	1.9	11.0	13.3	31.6	1,018,058.9	0.00	1.00
02/07/2023 22:00	1	1.9	10.3	13.5	29.9	1,014,669.4	0.00	1.00
02/07/2023 23:00	1	1.8	10.0	13.7	29.1	1,001,962.2	0.00	1.00
Average/Sum#:	1	3.2	11.2	14.2	25.0	944,512.0	0.92 #	8.15 #
Minimum:	0	1.8	9.9	13.1	0.0	699,493.3	0.00	0.00
Maximum:	1	8.0	15.2	19.5	33.4	1,018,114.4	0.77	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2023 00:00	1	1.7	8.0	14.3	23.8	964,199.3	0.00	1.00
02/08/2023 01:00	1	1.7	8.0	14.3	24.3	963,784.3	0.00	1.00
02/08/2023 02:00	1	1.7	8.5	14.3	24.1	940,753.1	0.00	1.00
02/08/2023 03:00	1	1.7	8.5	14.2	25.5	916,083.6	0.00	1.00
02/08/2023 04:00	1	1.7	8.6	14.3	26.4	947,600.2	0.00	1.00
02/08/2023 05:00	1	1.7	9.0	14.2	28.5	970,043.0	0.00	1.00
02/08/2023 06:00	2	1.9	11.4	13.4	35.6	1,021,955.8	0.00	1.00
02/08/2023 07:00	1	1.8	9.6	13.8	28.3	940,852.4	0.00	1.00
02/08/2023 08:00	3	1.9	12.9	14.4	32.9	700,934.6	0.00	1.00
02/08/2023 09:00	3	1.6	15.2	14.5	36.7	625,227.8	0.00	1.00
02/08/2023 10:00	2	1.6	14.3	14.5	33.0	624,585.9	0.00	1.00
02/08/2023 11:00	2	1.6	13.4	14.5	29.6	626,725.6	0.00	1.00
02/08/2023 12:00	2	1.6	12.8	14.5	27.3	629,293.3	0.00	1.00
02/08/2023 13:00	2	1.6	12.7	14.5	27.3	628,865.4	0.00	1.00
02/08/2023 14:00	2	1.6	12.5	14.5	26.3	628,223.4	0.00	1.00
02/08/2023 15:00	1	1.6	10.6	14.5	20.4	735,637.7	0.00	1.00
02/08/2023 16:00	1	1.6	10.3	14.4	21.5	738,646.4	0.00	1.00
02/08/2023 17:00	1	1.8	9.7	13.8	24.3	976,148.8	0.00	1.00
02/08/2023 18:00	1	2.0	12.3	13.0	32.8	1,019,441.1	0.00	1.00
02/08/2023 19:00	1	2.0	11.2	13.2	31.1	1,008,572.2	0.00	1.00
02/08/2023 20:00	1	1.9	10.2	13.5	30.3	1,017,630.4	0.00	1.00
02/08/2023 21:00	2	2.0	12.1	13.0	34.7	1,026,374.9	0.00	1.00
02/08/2023 22:00	1	1.9	11.0	13.3	31.9	1,012,833.5	0.00	1.00
02/08/2023 23:00	1	1.8	9.4	13.9	28.5	994,006.5	0.00	1.00
Average/Sum#:	1	1.8	10.9	14.0	28.5	860,767.5	0.00 #	24.00 #
Minimum:	1	1.6	8.0	13.0	20.4	624,585.9	0.00	1.00
Maximum:	3	2.0	15.2	14.5	36.7	1,026,374.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2023 00:00	1	1.7	8.1	14.4	25.3	1,012,531.3	0.00	1.00
02/09/2023 01:00	1	1.7	7.6	14.4	24.2	984,089.4	0.00	1.00
02/09/2023 02:00	1	1.7	8.9	14.4	25.3	1,013,163.4	0.00	1.00
02/09/2023 03:00	1	1.7	9.1	14.3	26.5	995,530.0	0.00	1.00
02/09/2023 04:00	1	1.7	8.6	14.3	25.7	972,913.8	0.00	1.00
02/09/2023 05:00	1	1.9	12.2	13.3	35.3	1,022,023.0	0.00	1.00
02/09/2023 06:00	2	2.0	13.1	13.0	37.7	1,027,415.0	0.00	1.00
02/09/2023 07:00	2	1.8	10.7	14.0	31.8	903,820.1	0.00	1.00
02/09/2023 08:00	2	1.6	13.9	14.5	32.3	672,729.7	0.00	1.00
02/09/2023 09:00	2	1.6	14.2	14.5	31.6	623,730.0	0.00	1.00
02/09/2023 10:00	2	1.6	13.1	14.5	28.2	628,223.4	0.00	1.00
02/09/2023 11:00	2	1.6	12.5	14.5	26.1	629,293.3	0.00	1.00
02/09/2023 12:00	2	1.6	12.6	14.5	26.6	625,227.8	0.00	1.00
02/09/2023 13:00	2	1.6	12.8	14.6	26.1	630,370.0	0.00	1.00
02/09/2023 14:00	2	1.6	12.6	14.6	25.7	630,152.6	0.00	1.00
02/09/2023 15:00	1	1.6	11.6	14.5	21.9	657,537.7	0.00	1.00
02/09/2023 16:00	2	1.6	11.0	14.5	24.6	739,917.1	0.00	1.00
02/09/2023 17:00	1	1.7	8.9	14.1	17.8	938,257.1	0.00	1.00
02/09/2023 18:00	1	2.1	12.1	12.9	30.1	1,007,211.6	0.00	1.00
02/09/2023 19:00	1	1.9	10.9	13.3	29.9	998,598.7	0.00	1.00
02/09/2023 20:00	1	2.0	11.8	13.1	32.1	1,014,427.4	0.00	1.00
02/09/2023 21:00	1	2.0	12.0	13.0	33.9	1,012,334.0	0.00	1.00
02/09/2023 22:00	1	1.9	11.4	13.3	30.7	1,004,004.3	0.00	1.00
02/09/2023 23:00	1	1.7	9.6	14.2	25.1	827,377.6	0.00	1.00
Average/Sum#:	1	1.7	11.2	14.0	28.1	857,119.9	0.00 #	24.00 #
Minimum:	1	1.6	7.6	12.9	17.8	623,730.0	0.00	1.00
Maximum:	2	2.1	14.2	14.6	37.7	1,027,415.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2023 00:00	2	1.6	12.3	14.4	28.5	654,374.2	0.00	1.00
02/10/2023 01:00	2	1.6	13.6	14.5	30.3	625,655.8	0.00	1.00
02/10/2023 02:00	2	1.5	14.3	14.5	31.9	625,655.8	0.00	1.00
02/10/2023 03:00	2	1.6	14.2	14.5	31.3	625,441.8	0.00	1.00
02/10/2023 04:00	2	1.6	14.3	14.5	32.6	627,153.6	0.00	1.00
02/10/2023 05:00	2	1.6	14.2	14.5	32.1	625,869.7	0.00	1.00
02/10/2023 06:00	2	1.6	13.9	14.4	31.2	627,196.4	0.00	1.00
02/10/2023 07:00	2	1.6	14.6	14.5	33.4	626,297.7	0.00	1.00
02/10/2023 08:00	2	1.6	13.9	14.5	30.2	626,725.6	0.00	1.00
02/10/2023 09:00	2	1.6	13.4	14.5	28.4	627,367.5	0.00	1.00
02/10/2023 10:00	2	1.6	12.9	14.5	26.7	628,865.4	0.00	1.00
02/10/2023 11:00	2	1.6	12.4	14.5	25.5	628,865.4	0.00	1.00
02/10/2023 12:00	2	1.6	12.5	14.5	25.5	630,363.2	0.00	1.00
02/10/2023 13:00	2	1.6	12.1	14.5	24.2	631,433.0	0.00	1.00
02/10/2023 14:00	1	1.6	11.9	14.5	23.7	631,861.0	0.00	1.00
02/10/2023 15:00	1	1.6	10.3	14.5	19.0	736,921.5	0.00	1.00
02/10/2023 16:00	1	1.6	11.1	14.4	23.2	697,563.7	0.00	1.00
02/10/2023 17:00	1	1.8	8.9	13.9	18.6	909,102.2	0.00	1.00
02/10/2023 18:00	1	1.8	9.6	13.8	25.6	997,943.9	0.00	1.00
02/10/2023 19:00	1	1.8	9.9	13.9	26.4	1,012,787.1	0.00	1.00
02/10/2023 20:00	1	1.8	10.5	13.7	28.5	1,011,091.7	0.00	1.00
02/10/2023 21:00	1	1.9	10.7	13.6	29.3	1,005,307.6	0.00	1.00
02/10/2023 22:00	1	1.8	11.2	13.6	30.3	1,009,434.6	0.00	1.00
02/10/2023 23:00	1	1.8	10.7	13.8	29.6	999,872.7	0.00	1.00
Average/Sum#:	2	1.7	12.2	14.3	27.8	742,631.3	0.00 #	24.00 #
Minimum:	1	1.5	8.9	13.6	18.6	625,441.8	0.00	1.00
Maximum:	2	1.9	14.6	14.5	33.4	1,012,787.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2023 00:00	1	1.8	10.3	13.7	29.2	1,006,717.1	0.00	1.00
02/11/2023 01:00	1	1.8	10.2	13.8	28.7	1,000,837.1	0.00	1.00
02/11/2023 02:00	1	1.7	10.1	13.9	27.9	1,001,636.1	0.00	1.00
02/11/2023 03:00	1	1.8	9.9	13.9	28.1	1,001,636.1	0.00	1.00
02/11/2023 04:00	1	1.8	9.8	13.9	28.8	1,000,462.3	0.00	1.00
02/11/2023 05:00	1	1.8	9.9	13.8	28.6	999,679.8	0.00	1.00
02/11/2023 06:00	1	1.8	9.8	13.9	28.8	1,015,721.6	0.00	1.00
02/11/2023 07:00	1	1.7	9.2	14.0	27.2	963,161.8	0.00	1.00
02/11/2023 08:00	3	2.7	15.7	14.6	28.2	646,672.6	0.13	0.77
02/11/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2023 16:00	2	6.0	15.9	15.3	17.9	669,795.2	0.65	1.00
02/11/2023 17:00	1	1.8	9.8	13.8	17.5	887,811.3	0.00	1.00
02/11/2023 18:00	1	1.9	10.8	13.6	27.4	990,675.4	0.00	1.00
02/11/2023 19:00	1	1.8	10.5	13.7	27.0	996,256.2	0.00	1.00
02/11/2023 20:00	1	1.8	10.5	13.7	27.7	1,001,201.4	0.00	1.00
02/11/2023 21:00	1	1.9	10.6	13.5	29.2	1,005,416.6	0.00	1.00
02/11/2023 22:00	1	1.9	10.6	13.5	30.4	1,010,598.2	0.00	1.00
02/11/2023 23:00	1	1.8	9.8	13.8	29.0	1,015,109.9	0.00	1.00
Average/Sum#:	1	2.1	10.8	13.9	27.2	953,728.7	0.78 #	16.77 #
Minimum:	1	1.7	9.2	13.5	17.5	646,672.6	0.00	0.00
Maximum:	3	6.0	15.9	15.3	30.4	1,015,721.6	0.65	1.00
%SI	29.17	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2023 00:00	1	1.9	10.9	13.5	31.3	1,019,480.9	0.00	1.00
02/12/2023 01:00	1	1.9	11.0	13.5	30.7	1,013,189.0	0.00	1.00
02/12/2023 02:00	1	1.8	11.1	13.6	30.2	1,007,746.3	0.00	1.00
02/12/2023 03:00	1	1.9	11.3	13.5	31.2	1,019,666.0	0.00	1.00
02/12/2023 04:00	1	1.9	11.1	13.4	30.6	1,008,078.9	0.00	1.00
02/12/2023 05:00	1	1.9	11.0	13.5	30.3	1,016,705.1	0.00	1.00
02/12/2023 06:00	1	1.9	10.6	13.6	30.2	1,014,499.6	0.00	1.00
02/12/2023 07:00	2	1.8	9.7	14.0	28.7	895,484.5	0.00	1.00
02/12/2023 08:00	2	1.6	11.1	14.3	24.5	709,403.3	0.00	1.00
02/12/2023 09:00	2	1.6	14.4	14.5	32.6	623,516.0	0.00	1.00
02/12/2023 10:00	2	1.6	13.6	14.5	28.9	624,799.9	0.00	1.00
02/12/2023 11:00	2	1.6	12.9	14.5	26.2	626,297.7	0.00	1.00
02/12/2023 12:00	2	1.6	12.2	14.5	24.3	626,939.6	0.00	1.00
02/12/2023 13:00	1	1.6	11.9	14.6	23.7	634,500.0	0.00	1.00
02/12/2023 14:00	2	1.6	12.1	14.6	24.3	627,978.9	0.00	1.00
02/12/2023 15:00	1	1.6	8.7	14.5	17.3	832,995.2	0.00	1.00
02/12/2023 16:00	1	1.6	9.1	14.5	17.4	840,484.2	0.00	1.00
02/12/2023 17:00	1	1.9	11.3	13.4	27.4	994,202.1	0.00	1.00
02/12/2023 18:00	1	1.9	10.3	13.7	26.9	993,783.7	0.00	1.00
02/12/2023 19:00	1	1.9	11.2	13.4	29.3	998,219.1	0.00	1.00
02/12/2023 20:00	1	2.0	11.5	13.3	30.5	1,003,463.7	0.00	1.00
02/12/2023 21:00	1	1.8	9.7	13.8	27.0	970,748.3	0.00	1.00
02/12/2023 22:00	1	1.6	8.5	14.3	20.8	798,208.4	0.00	1.00
02/12/2023 23:00	2	1.6	10.7	14.4	24.0	699,881.2	0.00	1.00
Average/Sum#:	1	1.8	11.1	14.0	27.0	858,344.7	0.00 #	24.00 #
Minimum:	1	1.6	8.5	13.3	17.3	623,516.0	0.00	1.00
Maximum:	2	2.0	14.4	14.6	32.6	1,019,666.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2023 00:00	2	2.6	14.5	14.6	20.6	636,238.9	0.13	0.75
02/13/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.6	14.5	14.6	20.6	636,238.9	0.13 #	0.75 #
Minimum:	2	2.6	14.5	14.6	20.6	636,238.9	0.00	0.00
Maximum:	2	2.6	14.5	14.6	20.6	636,238.9	0.13	0.75
%SI	95.83	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2023 15:00	0	17.7	21.3	16.5	0.0	692,181.8	0.43	0.43
02/14/2023 16:00	1	3.1	10.5	14.2	20.5	895,644.4	0.50	1.00
02/14/2023 17:00	2	2.1	13.7	12.9	37.5	1,015,770.5	0.00	1.00
02/14/2023 18:00	2	2.1	14.0	12.8	38.5	1,025,377.6	0.00	1.00
02/14/2023 19:00	1	2.0	12.5	13.2	34.7	1,018,531.6	0.00	1.00
02/14/2023 20:00	2	2.0	12.7	13.0	36.0	1,030,708.5	0.00	1.00
02/14/2023 21:00	1	1.9	11.3	13.4	32.8	1,026,520.5	0.00	1.00
02/14/2023 22:00	1	1.8	10.5	13.8	30.6	1,023,210.8	0.00	1.00
02/14/2023 23:00	1	1.9	11.0	13.5	32.9	1,025,772.9	0.00	1.00
Average/Sum#:	1	3.8	13.1	13.7	29.3	972,635.4	0.93 #	8.43 #
Minimum:	1	1.8	10.5	12.8	0.0	692,181.8	0.00	0.00
Maximum:	2	17.7	21.3	16.5	38.5	1,030,708.5	0.50	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2023 00:00	1	1.9	10.5	13.6	32.4	1,029,319.4	0.00	1.00
02/15/2023 01:00	1	1.9	10.5	13.6	32.6	1,024,066.8	0.00	1.00
02/15/2023 02:00	1	1.8	11.1	13.7	32.7	1,036,388.0	0.00	1.00
02/15/2023 03:00	1	1.9	11.2	13.5	34.1	1,029,474.0	0.00	1.00
02/15/2023 04:00	2	2.0	12.1	13.2	36.6	1,040,229.0	0.00	1.00
02/15/2023 05:00	2	2.0	12.2	13.2	36.7	1,045,742.3	0.00	1.00
02/15/2023 06:00	2	2.0	12.9	13.0	38.9	1,051,336.6	0.00	1.00
02/15/2023 07:00	2	2.1	14.0	12.5	42.8	973,758.6	0.00	1.00
02/15/2023 08:00	2	2.4	15.1	14.6	28.7	754,270.3	0.13	0.73
02/15/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2023 16:00	0	8.7	17.8	15.7	11.2	671,281.3	0.73	0.73
02/15/2023 17:00	1	1.6	10.3	14.2	22.7	902,593.7	0.03	1.00
02/15/2023 18:00	2	2.1	13.7	12.9	37.2	1,033,573.1	0.00	1.00
02/15/2023 19:00	2	2.1	13.6	12.9	38.0	1,033,059.5	0.00	1.00
02/15/2023 20:00	2	2.0	13.3	12.9	38.1	1,031,005.4	0.00	1.00
02/15/2023 21:00	2	2.1	13.1	12.8	38.0	1,026,561.1	0.00	1.00
02/15/2023 22:00	2	2.0	12.7	12.9	36.8	1,031,861.3	0.00	1.00
02/15/2023 23:00	1	1.9	11.2	13.3	32.2	1,016,977.8	0.00	1.00
Average/Sum#:	2	2.4	12.7	13.4	33.5	984,205.8	0.89 #	16.46 #
Minimum:	1	1.6	10.3	12.5	11.2	671,281.3	0.00	0.00
Maximum:	2	8.7	17.8	15.7	42.8	1,051,336.6	0.73	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2023 00:00	1	1.7	8.3	14.4	25.0	1,015,059.5	0.00	1.00
02/16/2023 01:00	1	1.7	8.4	14.4	25.8	1,016,112.9	0.00	1.00
02/16/2023 02:00	1	1.6	8.8	14.4	25.6	1,019,062.4	0.00	1.00
02/16/2023 03:00	1	1.7	8.6	14.4	26.2	1,018,430.4	0.00	1.00
02/16/2023 04:00	1	1.7	8.6	14.4	26.3	1,016,744.9	0.00	1.00
02/16/2023 05:00	1	1.7	8.6	14.3	26.5	1,000,509.8	0.00	1.00
02/16/2023 06:00	1	1.7	8.6	14.3	26.6	997,604.9	0.00	1.00
02/16/2023 07:00	1	1.8	9.8	13.8	29.3	995,822.3	0.00	1.00
02/16/2023 08:00	2	2.4	14.1	14.4	29.6	801,429.3	0.12	1.00
02/16/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2023 16:00	4	8.6	18.2	15.7	20.1	671,808.0	0.70	0.78
02/16/2023 17:00	0	1.5	10.1	14.2	16.8	813,683.4	0.00	1.00
02/16/2023 18:00	1	1.8	9.7	14.0	26.8	998,687.5	0.00	1.00
02/16/2023 19:00	1	1.8	10.1	13.8	28.6	1,015,109.9	0.00	1.00
02/16/2023 20:00	1	1.8	10.6	13.6	29.7	1,015,437.6	0.00	1.00
02/16/2023 21:00	1	1.9	10.7	13.6	30.1	1,025,567.5	0.00	1.00
02/16/2023 22:00	1	1.9	10.6	13.5	30.4	1,028,918.9	0.00	1.00
02/16/2023 23:00	1	1.8	9.5	13.7	29.0	1,010,521.1	0.00	1.00
Average/Sum#:	1	2.2	10.2	14.2	26.6	968,265.3	0.82 #	16.78 #
Minimum:	0	1.5	8.3	13.5	16.8	671,808.0	0.00	0.00
Maximum:	4	8.6	18.2	15.7	30.4	1,028,918.9	0.70	1.00
%SI	29.17	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2023 00:00	1	1.8	10.2	13.6	29.1	1,004,932.4	0.00	1.00
02/17/2023 01:00	1	1.8	9.4	13.9	27.7	998,310.4	0.00	1.00
02/17/2023 02:00	1	1.8	9.9	13.9	28.2	997,919.1	0.00	1.00
02/17/2023 03:00	3	2.5	15.6	14.7	33.2	732,200.3	0.12	1.00
02/17/2023 04:00	0	8.8	21.9	17.6	0.0	4,149.8	0.02	0.02
02/17/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	3.3	13.4	14.7	23.6	747,502.4	0.14 #	4.02 #
Minimum:	1	1.8	9.4	13.6	0.0	4,149.8	0.00	0.00
Maximum:	3	8.8	21.9	17.6	33.2	1,004,932.4	0.12	1.00
%SI	83.33	79.17	79.17	79.17	79.17	79.17	0.00	0.00

NH3 Slip Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2023 15:00	0	0.0	1.2	20.8	0.0	5,929,607.6	0.03	0.03
02/20/2023 16:00	0	9.9	15.9	15.1	5.3	666,059.7	1.00	1.00
02/20/2023 17:00	1	1.8	10.9	14.1	29.8	1,016,193.4	0.17	1.00
02/20/2023 18:00	1	1.9	11.6	13.3	29.5	996,436.4	0.00	1.00
02/20/2023 19:00	1	1.9	11.5	13.3	30.7	998,238.3	0.00	1.00
02/20/2023 20:00	1	1.9	11.2	13.4	30.8	1,006,253.0	0.00	1.00
02/20/2023 21:00	1	1.9	10.6	13.6	29.3	999,304.6	0.00	1.00
02/20/2023 22:00	1	1.7	9.5	14.0	27.7	893,499.8	0.00	1.00
02/20/2023 23:00	2	1.5	11.9	14.4	25.1	670,596.6	0.00	1.00
Average/Sum#:	1	2.5	10.5	14.7	23.1	1,464,021.0	1.20 #	8.03 #
Minimum:	1	0.0	1.2	13.3	0.0	666,059.7	0.00	0.00
Maximum:	2	9.9	15.9	20.8	30.8	5,929,607.6	1.00	1.00
%SI	70.83	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2023 00:00	2	1.6	13.4	14.5	29.1	625,227.8	0.00	1.00
02/21/2023 01:00	2	1.6	13.4	14.5	29.1	624,799.9	0.00	1.00
02/21/2023 02:00	2	1.6	14.0	14.5	28.9	625,655.8	0.00	1.00
02/21/2023 03:00	2	1.6	13.7	14.5	29.3	624,799.9	0.00	1.00
02/21/2023 04:00	2	1.6	13.9	14.5	30.2	623,944.0	0.00	1.00
02/21/2023 05:00	2	1.6	13.7	14.5	29.7	624,585.9	0.00	1.00
02/21/2023 06:00	2	1.6	13.7	14.5	29.9	624,158.0	0.00	1.00
02/21/2023 07:00	2	1.6	13.7	14.5	29.7	623,516.0	0.00	1.00
02/21/2023 08:00	2	1.6	13.7	14.5	29.3	626,083.7	0.00	1.00
02/21/2023 09:00	2	1.6	13.5	14.5	28.8	624,371.9	0.00	1.00
02/21/2023 10:00	2	1.6	13.1	14.5	26.6	625,227.8	0.00	1.00
02/21/2023 11:00	2	1.6	12.6	14.5	25.2	626,725.6	0.00	1.00
02/21/2023 12:00	1	1.6	12.1	14.5	23.9	628,223.4	0.00	1.00
02/21/2023 13:00	1	1.6	11.9	14.5	23.6	628,651.4	0.00	1.00
02/21/2023 14:00	2	1.6	12.4	14.5	25.1	626,297.7	0.00	1.00
02/21/2023 15:00	2	1.6	13.4	14.5	28.6	621,590.3	0.00	1.00
02/21/2023 16:00	2	1.6	14.3	14.5	30.4	616,241.0	0.00	1.00
02/21/2023 17:00	2	1.6	15.2	14.5	33.1	611,533.6	0.00	1.00
02/21/2023 18:00	2	1.6	15.6	14.5	34.1	611,319.6	0.00	1.00
02/21/2023 19:00	2	1.6	15.3	14.5	33.6	619,236.6	0.00	1.00
02/21/2023 20:00	2	1.6	15.5	14.5	34.5	618,808.6	0.00	1.00
02/21/2023 21:00	2	1.6	15.8	14.5	35.1	620,092.5	0.00	1.00
02/21/2023 22:00	3	1.6	16.0	14.5	35.9	621,590.3	0.00	1.00
02/21/2023 23:00	3	1.6	16.4	14.4	36.8	613,080.8	0.00	1.00
Average/Sum#:	2	1.6	14.0	14.5	30.0	622,323.4	0.00 #	24.00 #
Minimum:	1	1.6	11.9	14.4	23.6	611,319.6	0.00	1.00
Maximum:	3	1.6	16.4	14.5	36.8	628,651.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2023 00:00	3	1.6	16.3	14.5	37.2	621,162.3	0.00	1.00
02/22/2023 01:00	3	1.6	16.7	14.4	38.0	612,238.0	0.00	1.00
02/22/2023 02:00	3	1.7	17.4	14.5	37.8	621,376.3	0.00	1.00
02/22/2023 03:00	3	1.6	17.1	14.5	39.5	619,664.5	0.00	1.00
02/22/2023 04:00	3	1.6	17.1	14.5	39.5	620,092.5	0.00	1.00
02/22/2023 05:00	3	1.6	17.2	14.5	40.0	617,096.9	0.00	1.00
02/22/2023 06:00	2	1.6	16.1	14.4	35.5	632,463.4	0.00	1.00
02/22/2023 07:00	3	1.7	17.2	14.5	42.3	618,380.7	0.00	1.00
02/22/2023 08:00	3	1.6	17.2	14.5	40.2	617,096.9	0.00	1.00
02/22/2023 09:00	3	1.6	16.4	14.5	37.1	618,808.6	0.00	1.00
02/22/2023 10:00	2	1.6	15.7	14.5	34.8	622,018.2	0.00	1.00
02/22/2023 11:00	2	1.6	15.3	14.5	33.2	623,730.0	0.00	1.00
02/22/2023 12:00	2	1.6	15.1	14.5	32.2	624,585.9	0.00	1.00
02/22/2023 13:00	2	1.6	15.2	14.5	32.2	623,088.1	0.00	1.00
02/22/2023 14:00	2	1.6	15.0	14.5	31.4	622,660.1	0.00	1.00
02/22/2023 15:00	1	1.6	12.8	14.5	25.0	728,790.5	0.00	1.00
02/22/2023 16:00	1	1.7	9.3	14.3	21.0	819,579.7	0.00	1.00
02/22/2023 17:00	1	1.7	9.0	14.1	24.1	900,396.5	0.00	1.00
02/22/2023 18:00	1	1.9	11.0	13.3	31.1	1,002,923.2	0.00	1.00
02/22/2023 19:00	1	1.9	11.1	13.4	32.4	1,015,565.1	0.00	1.00
02/22/2023 20:00	1	1.9	10.8	13.4	31.8	1,009,904.8	0.00	1.00
02/22/2023 21:00	1	1.9	10.1	13.5	29.9	998,569.5	0.00	1.00
02/22/2023 22:00	1	1.7	8.1	14.3	23.7	933,905.9	0.00	1.00
02/22/2023 23:00	1	1.7	8.4	14.2	23.4	878,271.1	0.00	1.00
Average/Sum#:	2	1.7	14.0	14.3	33.1	733,432.0	0.00 #	24.00 #
Minimum:	1	1.6	8.1	13.3	21.0	612,238.0	0.00	1.00
Maximum:	3	1.9	17.4	14.5	42.3	1,015,565.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2023 00:00	1	1.9	11.1	13.6	33.8	996,115.5	0.00	1.00
02/23/2023 01:00	2	2.0	12.7	12.9	36.3	1,028,780.1	0.00	1.00
02/23/2023 02:00	1	2.0	12.3	13.1	34.3	1,026,190.5	0.00	1.00
02/23/2023 03:00	2	2.0	12.7	13.0	36.2	1,033,482.0	0.00	1.00
02/23/2023 04:00	2	2.0	12.2	13.0	34.9	1,020,654.5	0.00	1.00
02/23/2023 05:00	2	2.0	12.1	13.1	35.0	1,030,930.8	0.00	1.00
02/23/2023 06:00	2	2.1	12.8	12.8	36.1	1,018,107.9	0.00	1.00
02/23/2023 07:00	1	1.8	9.8	13.9	28.3	1,010,243.9	0.00	1.00
02/23/2023 08:00	1	1.8	10.0	13.8	29.1	999,294.0	0.00	1.00
02/23/2023 09:00	1	1.8	10.0	13.9	28.9	1,002,418.6	0.00	1.00
02/23/2023 10:00	1	1.8	10.2	13.9	29.2	1,005,353.1	0.00	1.00
02/23/2023 11:00	1	1.8	10.6	13.8	29.8	1,000,258.4	0.00	1.00
02/23/2023 12:00	2	1.8	9.8	14.1	28.4	900,195.1	0.00	1.00
02/23/2023 13:00	2	1.6	13.1	14.4	29.8	686,819.0	0.00	1.00
02/23/2023 14:00	2	1.6	14.7	14.4	33.3	615,608.9	0.00	1.00
02/23/2023 15:00	2	1.6	14.9	14.5	33.8	622,446.2	0.00	1.00
02/23/2023 16:00	2	1.6	14.8	14.5	33.1	620,948.4	0.00	1.00
02/23/2023 17:00	2	1.6	15.2	14.5	34.5	620,306.5	0.00	1.00
02/23/2023 18:00	3	1.6	15.6	14.5	35.3	619,450.6	0.00	1.00
02/23/2023 19:00	2	1.6	14.0	14.4	29.4	648,685.8	0.00	1.00
02/23/2023 20:00	1	1.7	7.9	14.3	19.3	982,873.2	0.00	1.00
02/23/2023 21:00	1	1.7	8.5	14.3	24.4	1,000,302.3	0.00	1.00
02/23/2023 22:00	1	1.7	8.6	14.1	24.5	953,562.4	0.00	1.00
02/23/2023 23:00	1	1.7	8.6	14.1	24.6	947,520.8	0.00	1.00
Average/Sum#:	2	1.8	11.8	13.9	30.9	891,272.9	0.00 #	24.00 #
Minimum:	1	1.6	7.9	12.8	19.3	615,608.9	0.00	1.00
Maximum:	3	2.1	15.6	14.5	36.3	1,033,482.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2023 00:00	1	1.7	8.6	14.1	25.4	953,965.2	0.00	1.00
02/24/2023 01:00	1	1.7	8.8	14.1	26.5	962,624.8	0.00	1.00
02/24/2023 02:00	1	1.8	8.8	14.1	24.0	948,729.2	0.00	1.00
02/24/2023 03:00	1	1.7	8.6	14.1	26.2	951,347.2	0.00	1.00
02/24/2023 04:00	1	1.8	8.6	14.0	26.1	949,467.6	0.00	1.00
02/24/2023 05:00	1	1.9	10.0	13.6	31.5	990,487.8	0.00	1.00
02/24/2023 06:00	1	1.9	11.4	13.2	33.2	1,010,172.8	0.00	1.00
02/24/2023 07:00	1	1.7	8.5	14.0	24.6	941,727.3	0.00	1.00
02/24/2023 08:00	1	1.8	8.1	14.0	24.6	936,368.7	0.00	1.00
02/24/2023 09:00	1	1.7	7.8	14.1	24.8	957,388.8	0.00	1.00
02/24/2023 10:00	1	1.8	7.9	14.0	25.1	963,161.8	0.00	1.00
02/24/2023 11:00	1	1.7	7.9	14.1	23.1	972,492.7	0.00	1.00
02/24/2023 12:00	1	1.7	7.9	14.1	22.7	957,791.5	0.00	1.00
02/24/2023 13:00	1	1.7	8.0	14.1	23.7	952,756.9	0.00	1.00
02/24/2023 14:00	1	1.7	8.1	14.1	24.3	953,965.2	0.00	1.00
02/24/2023 15:00	1	1.7	8.1	14.0	24.5	939,544.2	0.00	1.00
02/24/2023 16:00	1	1.7	8.3	14.0	24.7	940,338.1	0.00	1.00
02/24/2023 17:00	1	1.8	8.5	14.0	25.2	942,322.7	0.00	1.00
02/24/2023 18:00	1	1.7	8.6	14.0	25.4	943,712.0	0.00	1.00
02/24/2023 19:00	1	1.8	8.5	14.0	25.4	945,101.3	0.00	1.00
02/24/2023 20:00	1	1.8	8.8	14.0	27.0	937,162.6	0.00	1.00
02/24/2023 21:00	1	1.8	9.2	14.0	27.9	936,964.1	0.00	1.00
02/24/2023 22:00	1	1.8	9.2	14.0	28.1	933,590.2	0.00	1.00
02/24/2023 23:00	1	1.8	9.4	14.0	27.3	929,422.4	0.00	1.00
Average/Sum#:	1	1.8	8.7	14.0	25.9	952,108.5	0.00 #	24.00 #
Minimum:	1	1.7	7.8	13.2	22.7	929,422.4	0.00	1.00
Maximum:	1	1.9	11.4	14.1	33.2	1,010,172.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2023 00:00	1	1.7	8.6	14.1	25.7	957,388.8	0.00	1.00
02/25/2023 01:00	1	1.7	7.7	14.3	24.7	1,001,339.7	0.00	1.00
02/25/2023 02:00	1	1.6	8.4	14.3	25.3	1,001,339.7	0.00	1.00
02/25/2023 03:00	1	1.7	8.1	14.3	24.7	1,000,509.8	0.00	1.00
02/25/2023 04:00	1	1.7	8.1	14.3	25.1	1,008,186.8	0.00	1.00
02/25/2023 05:00	1	1.7	8.1	14.3	24.9	995,945.0	0.00	1.00
02/25/2023 06:00	3	1.7	14.5	14.4	35.4	640,258.6	0.00	1.00
02/25/2023 07:00	3	1.6	15.8	14.5	36.7	627,367.5	0.00	1.00
02/25/2023 08:00	3	1.6	15.6	14.4	35.9	617,505.1	0.00	1.00
02/25/2023 09:00	3	1.6	15.5	14.5	36.2	627,581.5	0.00	1.00
02/25/2023 10:00	3	1.6	15.6	14.5	36.2	626,939.6	0.00	1.00
02/25/2023 11:00	3	1.6	15.4	14.4	35.3	618,769.1	0.00	1.00
02/25/2023 12:00	2	1.6	15.3	14.5	34.8	627,367.5	0.00	1.00
02/25/2023 13:00	2	1.6	15.0	14.5	33.1	626,511.7	0.00	1.00
02/25/2023 14:00	2	1.6	14.5	14.5	31.6	627,795.5	0.00	1.00
02/25/2023 15:00	2	1.6	14.6	14.5	32.1	627,581.5	0.00	1.00
02/25/2023 16:00	2	1.6	14.6	14.5	32.6	628,009.5	0.00	1.00
02/25/2023 17:00	2	1.6	15.0	14.5	34.2	627,581.5	0.00	1.00
02/25/2023 18:00	2	1.6	15.2	14.5	34.7	626,939.6	0.00	1.00
02/25/2023 19:00	3	1.6	15.3	14.5	35.2	627,795.5	0.00	1.00
02/25/2023 20:00	3	1.6	15.3	14.5	35.2	628,009.5	0.00	1.00
02/25/2023 21:00	3	1.6	15.1	14.5	34.6	623,088.1	0.00	1.00
02/25/2023 22:00	2	1.6	15.2	14.5	34.6	624,799.9	0.00	1.00
02/25/2023 23:00	2	1.6	15.1	14.5	34.0	625,655.8	0.00	1.00
Average/Sum#:	2	1.6	13.4	14.4	32.2	718,511.1	0.00 #	24.00 #
Minimum:	1	1.6	7.7	14.1	24.7	617,505.1	0.00	1.00
Maximum:	3	1.7	15.8	14.5	36.7	1,008,186.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2023 00:00	2	1.6	15.2	14.5	34.7	624,371.9	0.00	1.00
02/26/2023 01:00	2	1.6	15.3	14.5	34.7	624,799.9	0.00	1.00
02/26/2023 02:00	2	1.6	15.6	14.4	34.0	616,451.7	0.00	1.00
02/26/2023 03:00	3	1.7	15.6	14.5	35.5	623,944.0	0.00	1.00
02/26/2023 04:00	3	1.6	15.5	14.4	35.2	613,080.8	0.00	1.00
02/26/2023 05:00	3	1.6	15.6	14.5	35.8	621,804.3	0.00	1.00
02/26/2023 06:00	3	1.6	15.8	14.5	36.2	622,018.2	0.00	1.00
02/26/2023 07:00	3	1.6	15.6	14.5	35.8	623,088.1	0.00	1.00
02/26/2023 08:00	3	1.6	15.7	14.5	36.2	622,232.2	0.00	1.00
02/26/2023 09:00	3	1.6	15.5	14.5	35.3	620,948.4	0.00	1.00
02/26/2023 10:00	3	1.6	15.3	14.5	35.1	620,734.4	0.00	1.00
02/26/2023 11:00	2	1.6	15.4	14.5	34.9	620,520.4	0.00	1.00
02/26/2023 12:00	2	1.6	15.1	14.5	34.0	620,948.4	0.00	1.00
02/26/2023 13:00	2	1.6	15.0	14.5	33.7	620,734.4	0.00	1.00
02/26/2023 14:00	2	1.6	14.9	14.5	34.0	621,376.3	0.00	1.00
02/26/2023 15:00	2	1.6	14.8	14.5	33.6	621,376.3	0.00	1.00
02/26/2023 16:00	2	1.6	14.6	14.5	33.0	623,088.1	0.00	1.00
02/26/2023 17:00	2	1.6	14.8	14.5	33.9	621,590.3	0.00	1.00
02/26/2023 18:00	3	1.6	15.1	14.5	34.5	619,450.6	0.00	1.00
02/26/2023 19:00	3	1.6	15.2	14.5	34.6	620,520.4	0.00	1.00
02/26/2023 20:00	2	1.6	15.2	14.5	34.6	622,446.2	0.00	1.00
02/26/2023 21:00	3	1.6	15.2	14.5	34.7	624,799.9	0.00	1.00
02/26/2023 22:00	2	1.6	15.2	14.5	34.5	620,948.4	0.00	1.00
02/26/2023 23:00	2	1.6	14.9	14.4	33.8	614,344.8	0.00	1.00
Average/Sum#:	2	1.6	15.3	14.5	34.7	621,067.4	0.00 #	24.00 #
Minimum:	2	1.6	14.6	14.4	33.0	613,080.8	0.00	1.00
Maximum:	3	1.7	15.8	14.5	36.2	624,799.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2023 00:00	3	1.6	15.0	14.4	34.6	617,715.7	0.00	1.00
02/27/2023 01:00	3	1.6	15.4	14.5	35.3	627,581.5	0.00	1.00
02/27/2023 02:00	3	1.6	16.2	14.5	37.0	624,585.9	0.00	1.00
02/27/2023 03:00	3	1.6	16.1	14.5	37.1	622,232.2	0.00	1.00
02/27/2023 04:00	3	1.6	16.0	14.5	36.7	621,804.3	0.00	1.00
02/27/2023 05:00	3	1.6	16.0	14.5	36.6	621,804.3	0.00	1.00
02/27/2023 06:00	3	1.6	16.0	14.5	36.4	619,450.6	0.00	1.00
02/27/2023 07:00	3	1.6	16.2	14.5	37.1	618,166.7	0.00	1.00
02/27/2023 08:00	3	1.6	16.2	14.5	36.8	615,385.1	0.00	1.00
02/27/2023 09:00	3	1.6	16.4	14.5	37.8	611,533.6	0.00	1.00
02/27/2023 10:00	3	1.6	16.1	14.5	36.8	613,673.3	0.00	1.00
02/27/2023 11:00	3	1.6	16.2	14.5	36.8	614,529.2	0.00	1.00
02/27/2023 12:00	3	1.6	15.9	14.5	36.1	614,957.1	0.00	1.00
02/27/2023 13:00	3	1.6	15.6	14.5	35.5	618,808.6	0.00	1.00
02/27/2023 14:00	2	1.6	15.1	14.4	34.0	610,974.0	0.00	1.00
02/27/2023 15:00	2	1.6	15.2	14.5	34.4	619,022.6	0.00	1.00
02/27/2023 16:00	2	1.6	13.8	14.4	28.9	647,000.4	0.00	1.00
02/27/2023 17:00	1	1.7	8.6	14.3	19.5	882,241.3	0.00	1.00
02/27/2023 18:00	1	1.7	8.2	14.1	20.5	878,646.9	0.00	1.00
02/27/2023 19:00	1	1.9	10.2	13.5	29.0	1,015,594.7	0.00	1.00
02/27/2023 20:00	1	1.9	10.1	13.5	30.3	1,012,263.7	0.00	1.00
02/27/2023 21:00	1	1.9	9.7	13.6	28.9	1,008,871.8	0.00	1.00
02/27/2023 22:00	2	1.7	9.4	14.0	28.2	888,736.6	0.00	1.00
02/27/2023 23:00	2	1.5	12.7	14.4	30.3	693,560.8	0.00	1.00
Average/Sum#:	2	1.6	14.0	14.3	33.1	704,964.2	0.00 #	24.00 #
Minimum:	1	1.5	8.2	13.5	19.5	610,974.0	0.00	1.00
Maximum:	3	1.9	16.4	14.5	37.8	1,015,594.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2023 00:00	3	1.6	15.4	14.5	36.4	624,371.9	0.00	1.00
02/28/2023 01:00	3	1.6	15.5	14.5	36.1	624,158.0	0.00	1.00
02/28/2023 02:00	3	1.7	16.1	14.5	35.4	624,585.9	0.00	1.00
02/28/2023 03:00	3	1.6	15.8	14.5	36.7	624,799.9	0.00	1.00
02/28/2023 04:00	3	1.6	15.7	14.5	35.6	624,158.0	0.00	1.00
02/28/2023 05:00	3	1.6	15.7	14.5	36.0	622,232.2	0.00	1.00
02/28/2023 06:00	3	1.6	15.7	14.5	36.1	620,092.5	0.00	1.00
02/28/2023 07:00	3	1.6	15.7	14.5	35.8	618,808.6	0.00	1.00
02/28/2023 08:00	3	1.6	15.6	14.5	36.0	619,022.6	0.00	1.00
02/28/2023 09:00	3	1.6	15.6	14.5	35.4	619,450.6	0.00	1.00
02/28/2023 10:00	2	1.6	15.2	14.4	34.3	613,712.8	0.00	1.00
02/28/2023 11:00	2	1.7	14.7	14.4	33.0	614,766.2	0.00	1.00
02/28/2023 12:00	2	1.6	14.6	14.4	32.6	613,291.4	0.00	1.00
02/28/2023 13:00	2	1.6	14.1	14.4	31.1	614,555.5	0.00	1.00
02/28/2023 14:00	2	1.6	13.6	14.4	29.9	616,662.3	0.00	1.00
02/28/2023 15:00	2	1.7	13.3	14.4	29.5	620,243.9	0.00	1.00
02/28/2023 16:00	1	1.6	11.4	14.4	23.1	722,845.4	0.00	1.00
02/28/2023 17:00	1	1.6	9.4	14.2	21.0	727,225.7	0.00	1.00
02/28/2023 18:00	1	1.8	8.5	14.0	22.6	958,795.5	0.00	1.00
02/28/2023 19:00	1	1.8	9.5	13.8	27.1	1,000,065.6	0.00	1.00
02/28/2023 20:00	1	1.8	9.5	13.8	27.6	996,786.7	0.00	1.00
02/28/2023 21:00	1	1.8	9.5	13.8	27.8	997,558.2	0.00	1.00
02/28/2023 22:00	1	1.8	9.5	13.9	28.0	1,007,896.3	0.00	1.00
02/28/2023 23:00	1	1.8	9.3	13.9	27.3	1,004,766.2	0.00	1.00
Average/Sum#:	2	1.7	13.3	14.3	31.4	722,118.8	0.00 #	24.00 #
Minimum:	1	1.6	8.5	13.8	21.0	613,291.4	0.00	1.00
Maximum:	3	1.8	16.1	14.5	36.7	1,007,896.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023 00:00	1	1.8	9.2	13.9	27.0	1,006,918.2	0.00	1.00
03/01/2023 01:00	1	1.8	9.1	13.9	26.6	1,010,048.3	0.00	1.00
03/01/2023 02:00	1	1.8	9.9	13.9	27.3	1,011,613.4	0.00	1.00
03/01/2023 03:00	1	1.8	9.7	13.8	28.6	1,001,608.6	0.00	1.00
03/01/2023 04:00	1	1.8	9.8	13.8	28.7	1,005,851.9	0.00	1.00
03/01/2023 05:00	1	1.8	10.0	13.8	29.3	1,013,952.7	0.00	1.00
03/01/2023 06:00	1	2.0	11.3	13.2	33.0	1,019,065.2	0.00	1.00
03/01/2023 07:00	2	1.8	9.8	14.0	29.9	896,873.7	0.00	1.00
03/01/2023 08:00	2	1.5	13.8	14.4	32.5	666,383.0	0.00	1.00
03/01/2023 09:00	3	1.6	15.9	14.5	37.8	622,232.2	0.00	1.00
03/01/2023 10:00	3	1.6	15.6	14.5	34.3	625,441.8	0.00	1.00
03/01/2023 11:00	2	1.6	14.8	14.6	33.4	635,369.4	0.00	1.00
03/01/2023 12:00	2	1.6	14.4	14.6	31.9	635,804.2	0.00	1.00
03/01/2023 13:00	2	1.6	14.4	14.6	31.2	636,021.5	0.00	1.00
03/01/2023 14:00	2	1.6	14.2	14.7	29.7	646,500.8	0.00	1.00
03/01/2023 15:00	2	1.6	13.8	14.7	29.5	646,942.6	0.00	1.00
03/01/2023 16:00	2	1.6	13.7	14.7	29.6	646,942.6	0.00	1.00
03/01/2023 17:00	2	1.6	13.7	14.6	30.2	639,064.7	0.00	1.00
03/01/2023 18:00	2	1.6	13.9	14.6	31.5	640,586.3	0.00	1.00
03/01/2023 19:00	2	1.6	14.5	14.6	33.3	637,543.1	0.00	1.00
03/01/2023 20:00	3	1.6	15.6	14.7	37.0	642,304.2	0.00	1.00
03/01/2023 21:00	2	1.6	15.5	14.6	35.7	636,891.0	0.00	1.00
03/01/2023 22:00	2	1.6	15.2	14.6	35.0	640,368.9	0.00	1.00
03/01/2023 23:00	2	1.6	15.4	14.6	35.9	640,368.9	0.00	1.00
Average/Sum#:	2	1.7	13.1	14.3	31.6	758,529.1	0.00 #	24.00 #
Minimum:	1	1.5	9.1	13.2	26.6	622,232.2	0.00	1.00
Maximum:	3	2.0	15.9	14.7	37.8	1,019,065.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2023 00:00	2	1.6	15.5	14.6	36.0	640,151.6	0.00	1.00
03/02/2023 01:00	3	1.6	16.0	14.7	37.9	649,814.0	0.00	1.00
03/02/2023 02:00	2	1.6	15.8	14.6	35.1	646,237.9	0.00	1.00
03/02/2023 03:00	3	1.6	15.7	14.6	37.0	646,455.3	0.00	1.00
03/02/2023 04:00	2	1.6	15.6	14.6	36.6	645,585.8	0.00	1.00
03/02/2023 05:00	2	1.6	15.8	14.6	37.3	646,890.0	0.00	1.00
03/02/2023 06:00	2	1.5	12.2	14.5	26.9	758,104.8	0.00	1.00
03/02/2023 07:00	3	1.6	15.9	14.6	41.4	644,498.9	0.00	1.00
03/02/2023 08:00	3	1.6	15.7	14.6	37.4	644,281.6	0.00	1.00
03/02/2023 09:00	2	1.6	14.7	14.6	32.9	644,281.6	0.00	1.00
03/02/2023 10:00	2	1.6	14.3	14.6	32.0	640,368.9	0.00	1.00
03/02/2023 11:00	2	1.6	15.1	14.7	33.9	642,525.1	0.00	1.00
03/02/2023 12:00	2	1.5	14.2	14.7	30.3	652,464.5	0.00	1.00
03/02/2023 13:00	2	1.6	14.7	14.7	31.8	642,083.3	0.00	1.00
03/02/2023 14:00	2	1.6	14.4	14.7	30.9	640,758.1	0.00	1.00
03/02/2023 15:00	2	1.6	13.9	14.7	28.9	640,758.1	0.00	1.00
03/02/2023 16:00	2	1.6	14.0	14.7	29.6	639,653.7	0.00	1.00
03/02/2023 17:00	2	1.6	14.4	14.7	30.8	637,665.8	0.00	1.00
03/02/2023 18:00	2	1.6	14.8	14.7	32.5	637,886.7	0.00	1.00
03/02/2023 19:00	2	1.6	14.8	14.7	32.9	638,991.1	0.00	1.00
03/02/2023 20:00	2	1.6	14.8	14.7	32.9	638,107.6	0.00	1.00
03/02/2023 21:00	2	1.6	15.1	14.7	34.3	639,874.6	0.00	1.00
03/02/2023 22:00	2	1.6	15.2	14.7	34.7	638,770.2	0.00	1.00
03/02/2023 23:00	2	1.6	15.5	14.7	36.2	640,095.5	0.00	1.00
Average/Sum#:	2	1.6	14.9	14.7	33.8	647,346.0	0.00 #	24.00 #
Minimum:	2	1.5	12.2	14.5	26.9	637,665.8	0.00	1.00
Maximum:	3	1.6	16.0	14.7	41.4	758,104.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2023 00:00	2	1.6	15.7	14.7	36.7	639,653.7	0.00	1.00
03/03/2023 01:00	2	1.6	15.7	14.7	36.2	639,874.6	0.00	1.00
03/03/2023 02:00	2	1.6	16.4	14.7	36.0	639,874.6	0.00	1.00
03/03/2023 03:00	2	1.6	15.6	14.6	35.3	634,282.6	0.00	1.00
03/03/2023 04:00	2	1.6	14.5	14.6	32.6	642,325.2	0.00	1.00
03/03/2023 05:00	2	1.6	15.4	14.7	36.3	641,420.7	0.00	1.00
03/03/2023 06:00	3	1.6	16.2	14.7	38.7	640,316.3	0.00	1.00
03/03/2023 07:00	2	1.6	15.8	14.7	37.1	642,525.1	0.00	1.00
03/03/2023 08:00	2	1.6	15.4	14.7	36.3	642,966.8	0.00	1.00
03/03/2023 09:00	2	1.6	14.7	14.6	33.2	632,108.9	0.00	1.00
03/03/2023 10:00	2	1.6	13.9	14.6	30.5	635,152.1	0.00	1.00
03/03/2023 11:00	1	1.5	12.2	14.6	24.8	686,668.5	0.00	1.00
03/03/2023 12:00	0	1.7	7.8	14.3	15.7	963,576.8	0.00	1.00
03/03/2023 13:00	1	1.7	8.6	14.2	22.8	1,004,380.8	0.00	1.00
03/03/2023 14:00	1	1.7	9.1	14.1	24.3	1,010,151.9	0.00	1.00
03/03/2023 15:00	1	1.7	9.7	14.3	24.1	812,110.2	0.00	1.00
03/03/2023 16:00	1	1.5	11.9	14.6	22.2	679,712.7	0.00	1.00
03/03/2023 17:00	1	1.7	8.7	14.3	20.1	900,500.3	0.00	1.00
03/03/2023 18:00	1	1.8	10.4	13.9	26.2	1,018,069.2	0.00	1.00
03/03/2023 19:00	1	1.8	10.7	13.8	28.4	1,022,246.4	0.00	1.00
03/03/2023 20:00	1	1.8	11.2	13.7	29.9	1,028,780.1	0.00	1.00
03/03/2023 21:00	1	1.8	10.2	13.9	28.0	992,441.4	0.00	1.00
03/03/2023 22:00	1	1.6	9.2	14.5	23.9	808,388.3	0.00	1.00
03/03/2023 23:00	2	1.5	11.6	14.6	26.8	691,885.4	0.00	1.00
Average/Sum#:	2	1.6	12.5	14.4	29.4	777,058.9	0.00 #	24.00 #
Minimum:	0	1.5	7.8	13.7	15.7	632,108.9	0.00	1.00
Maximum:	3	1.8	16.4	14.7	38.7	1,028,780.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2023 00:00	2	1.6	13.3	14.6	30.0	636,456.3	0.00	1.00
03/04/2023 01:00	2	1.6	13.7	14.6	31.1	635,152.1	0.00	1.00
03/04/2023 02:00	2	1.6	14.1	14.6	30.5	634,934.7	0.00	1.00
03/04/2023 03:00	2	1.6	14.3	14.6	32.5	632,761.0	0.00	1.00
03/04/2023 04:00	2	1.6	14.2	14.6	32.3	632,108.9	0.00	1.00
03/04/2023 05:00	2	1.6	14.4	14.6	32.6	632,761.0	0.00	1.00
03/04/2023 06:00	2	1.6	14.5	14.6	32.9	633,195.8	0.00	1.00
03/04/2023 07:00	2	1.6	14.7	14.6	33.4	633,630.5	0.00	1.00
03/04/2023 08:00	2	1.6	14.5	14.6	33.0	631,891.5	0.00	1.00
03/04/2023 09:00	2	1.6	14.2	14.6	31.6	630,370.0	0.00	1.00
03/04/2023 10:00	2	1.6	13.9	14.6	30.5	631,674.2	0.00	1.00
03/04/2023 11:00	2	1.6	13.7	14.6	30.6	630,587.3	0.00	1.00
03/04/2023 12:00	2	1.6	13.9	14.6	31.2	630,152.6	0.00	1.00
03/04/2023 13:00	2	1.6	13.6	14.6	30.5	633,847.9	0.00	1.00
03/04/2023 14:00	2	1.6	13.1	14.6	29.4	635,804.2	0.00	1.00
03/04/2023 15:00	2	1.6	13.1	14.6	29.0	635,152.1	0.00	1.00
03/04/2023 16:00	1	1.5	11.5	14.6	23.5	743,401.8	0.00	1.00
03/04/2023 17:00	2	1.6	12.2	14.6	30.4	704,710.1	0.00	1.00
03/04/2023 18:00	1	1.7	9.4	14.1	20.2	966,048.3	0.00	1.00
03/04/2023 19:00	1	2.0	11.4	13.3	30.6	1,028,509.8	0.00	1.00
03/04/2023 20:00	1	1.9	10.4	13.6	29.6	1,027,068.3	0.00	1.00
03/04/2023 21:00	1	1.9	10.4	13.6	29.5	1,026,130.3	0.00	1.00
03/04/2023 22:00	2	1.6	10.2	14.3	28.1	843,026.0	0.00	1.00
03/04/2023 23:00	2	1.5	13.4	14.6	31.9	666,887.9	0.00	1.00
Average/Sum#:	2	1.6	13.0	14.4	30.2	714,010.9	0.00 #	24.00 #
Minimum:	1	1.5	9.4	13.3	20.2	630,152.6	0.00	1.00
Maximum:	2	2.0	14.7	14.6	33.4	1,028,509.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2023 00:00	2	1.6	15.3	14.6	35.0	625,370.5	0.00	1.00
03/05/2023 01:00	2	1.6	15.7	14.7	35.6	630,818.7	0.00	1.00
03/05/2023 02:00	2	1.6	15.5	14.6	34.0	627,326.8	0.00	1.00
03/05/2023 03:00	2	1.6	14.7	14.6	32.8	635,804.2	0.00	1.00
03/05/2023 04:00	2	1.6	14.3	14.6	32.2	638,630.0	0.00	1.00
03/05/2023 05:00	2	1.6	14.2	14.6	32.1	641,021.0	0.00	1.00
03/05/2023 06:00	2	1.6	14.1	14.6	32.0	640,368.9	0.00	1.00
03/05/2023 07:00	2	1.6	14.3	14.6	32.9	638,847.3	0.00	1.00
03/05/2023 08:00	2	1.6	15.3	14.6	35.6	629,500.5	0.00	1.00
03/05/2023 09:00	2	1.6	14.0	14.6	30.9	636,238.9	0.00	1.00
03/05/2023 10:00	2	1.6	13.4	14.6	29.2	641,238.4	0.00	1.00
03/05/2023 11:00	2	1.6	13.6	14.6	29.7	638,195.2	0.00	1.00
03/05/2023 12:00	2	1.6	14.2	14.7	30.5	642,525.1	0.00	1.00
03/05/2023 13:00	2	1.6	14.4	14.7	31.2	639,432.8	0.00	1.00
03/05/2023 14:00	2	1.6	14.5	14.7	31.4	637,886.7	0.00	1.00
03/05/2023 15:00	1	1.5	12.4	14.6	24.5	735,793.9	0.00	1.00
03/05/2023 16:00	1	1.6	9.8	14.5	20.8	760,030.5	0.00	1.00
03/05/2023 17:00	1	1.8	9.6	13.9	22.8	924,165.8	0.00	1.00
03/05/2023 18:00	1	2.0	11.6	13.3	31.7	1,042,023.8	0.00	1.00
03/05/2023 19:00	1	2.0	11.3	13.2	31.8	1,037,739.1	0.00	1.00
03/05/2023 20:00	1	2.0	11.7	13.2	33.4	1,043,074.5	0.00	1.00
03/05/2023 21:00	1	1.9	11.1	13.4	32.2	1,042,588.4	0.00	1.00
03/05/2023 22:00	1	1.9	10.5	13.6	29.6	1,038,323.8	0.00	1.00
03/05/2023 23:00	1	1.8	9.5	14.0	27.8	1,033,022.3	0.00	1.00
Average/Sum#:	2	1.7	13.1	14.3	30.8	758,332.0	0.00 #	24.00 #
Minimum:	1	1.5	9.5	13.2	20.8	625,370.5	0.00	1.00
Maximum:	2	2.0	15.7	14.7	35.6	1,043,074.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2023 00:00	1	1.6	7.7	14.4	22.4	953,962.1	0.00	1.00
03/06/2023 01:00	2	1.5	10.2	14.4	26.7	767,088.3	0.00	1.00
03/06/2023 02:00	3	1.7	16.9	14.7	39.4	636,340.6	0.00	1.00
03/06/2023 03:00	2	1.6	16.4	14.7	38.5	639,653.7	0.00	1.00
03/06/2023 04:00	2	1.6	16.2	14.7	37.6	641,199.8	0.00	1.00
03/06/2023 05:00	2	1.5	13.5	14.6	29.0	689,494.3	0.00	1.00
03/06/2023 06:00	1	1.6	8.4	14.4	18.4	885,490.9	0.00	1.00
03/06/2023 07:00	3	1.6	15.3	14.7	38.7	642,525.1	0.00	1.00
03/06/2023 08:00	2	1.6	15.6	14.7	36.3	637,886.7	0.00	1.00
03/06/2023 09:00	2	1.6	15.6	14.7	35.8	640,537.2	0.00	1.00
03/06/2023 10:00	2	1.6	15.4	14.7	34.8	642,083.3	0.00	1.00
03/06/2023 11:00	2	1.6	15.0	14.6	33.4	630,370.0	0.00	1.00
03/06/2023 12:00	2	1.6	13.9	14.6	28.6	648,846.3	0.00	1.00
03/06/2023 13:00	1	1.6	9.8	14.5	21.4	804,322.9	0.00	1.00
03/06/2023 14:00	1	1.6	9.7	14.3	21.4	909,837.3	0.00	1.00
03/06/2023 15:00	1	1.8	9.7	14.0	25.8	1,022,900.5	0.00	1.00
03/06/2023 16:00	1	1.8	9.8	14.0	27.1	1,022,702.0	0.00	1.00
03/06/2023 17:00	1	1.8	9.9	14.0	28.2	1,020,915.8	0.00	1.00
03/06/2023 18:00	1	1.8	9.8	14.0	29.0	1,012,977.1	0.00	1.00
03/06/2023 19:00	1	1.7	9.3	14.1	27.3	1,019,818.4	0.00	1.00
03/06/2023 20:00	1	1.7	9.2	14.1	27.3	1,017,603.1	0.00	1.00
03/06/2023 21:00	1	1.7	9.8	14.1	27.7	1,017,200.4	0.00	1.00
03/06/2023 22:00	1	1.7	9.9	14.1	28.0	1,018,005.9	0.00	1.00
03/06/2023 23:00	1	1.7	9.9	14.1	28.8	1,018,005.9	0.00	1.00
Average/Sum#:	2	1.7	12.0	14.4	29.7	830,823.7	0.00 #	24.00 #
Minimum:	1	1.5	7.7	14.0	18.4	630,370.0	0.00	1.00
Maximum:	3	1.8	16.9	14.7	39.4	1,022,900.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2023 00:00	1	1.7	9.5	14.1	26.6	1,017,804.5	0.00	1.00
03/07/2023 01:00	1	1.7	9.1	14.0	26.0	1,007,023.1	0.00	1.00
03/07/2023 02:00	1	1.7	9.7	14.0	26.5	1,007,420.0	0.00	1.00
03/07/2023 03:00	1	1.8	9.1	14.0	26.1	1,009,404.7	0.00	1.00
03/07/2023 04:00	1	1.8	9.0	14.0	26.3	1,022,702.0	0.00	1.00
03/07/2023 05:00	1	1.8	9.8	13.7	28.3	1,032,584.0	0.00	1.00
03/07/2023 06:00	1	2.0	11.2	13.1	31.7	1,028,297.3	0.00	1.00
03/07/2023 07:00	1	1.7	9.5	14.1	27.1	894,959.1	0.00	1.00
03/07/2023 08:00	2	1.5	13.3	14.6	32.6	685,799.0	0.00	1.00
03/07/2023 09:00	2	1.6	14.7	14.6	33.9	631,239.4	0.00	1.00
03/07/2023 10:00	2	1.6	14.6	14.7	33.3	643,629.5	0.00	1.00
03/07/2023 11:00	2	1.6	14.6	14.7	32.7	643,408.6	0.00	1.00
03/07/2023 12:00	2	1.6	14.4	14.7	31.0	644,292.1	0.00	1.00
03/07/2023 13:00	2	1.6	14.1	14.7	31.0	643,850.3	0.00	1.00
03/07/2023 14:00	2	1.6	14.0	14.7	30.3	643,187.7	0.00	1.00
03/07/2023 15:00	2	1.6	14.2	14.7	29.8	642,966.8	0.00	1.00
03/07/2023 16:00	1	1.5	11.6	14.6	23.4	741,880.2	0.00	1.00
03/07/2023 17:00	2	1.6	14.0	14.6	33.5	649,281.1	0.00	1.00
03/07/2023 18:00	1	1.6	10.0	14.3	22.1	900,500.3	0.00	1.00
03/07/2023 19:00	1	1.8	9.4	14.1	26.0	1,023,040.6	0.00	1.00
03/07/2023 20:00	1	1.7	9.1	14.1	26.5	1,018,005.9	0.00	1.00
03/07/2023 21:00	1	1.7	9.0	14.1	26.5	1,018,207.3	0.00	1.00
03/07/2023 22:00	1	1.7	8.9	14.1	26.4	1,018,207.3	0.00	1.00
03/07/2023 23:00	1	1.7	9.2	14.1	27.5	1,017,603.1	0.00	1.00
Average/Sum#:	1	1.7	11.3	14.3	28.5	857,720.6	0.00 #	24.00 #
Minimum:	1	1.5	8.9	13.1	22.1	631,239.4	0.00	1.00
Maximum:	2	2.0	14.7	14.7	33.9	1,032,584.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2023 00:00	1	1.7	9.3	14.1	27.4	1,018,005.9	0.00	1.00
03/08/2023 01:00	1	1.7	9.3	14.1	27.6	1,018,408.7	0.00	1.00
03/08/2023 02:00	1	1.8	9.9	14.1	27.5	1,019,012.9	0.00	1.00
03/08/2023 03:00	1	1.7	9.6	14.1	27.8	1,018,207.3	0.00	1.00
03/08/2023 04:00	1	1.7	9.3	14.1	26.9	1,017,401.8	0.00	1.00
03/08/2023 05:00	1	1.7	9.1	14.1	26.8	1,020,422.6	0.00	1.00
03/08/2023 06:00	1	1.7	8.9	14.1	26.6	1,026,866.9	0.00	1.00
03/08/2023 07:00	1	1.8	9.1	13.9	27.0	1,010,635.2	0.00	1.00
03/08/2023 08:00	1	1.8	9.2	13.9	24.2	1,015,721.6	0.00	1.00
03/08/2023 09:00	1	1.8	10.3	14.0	24.9	1,020,320.4	0.00	1.00
03/08/2023 10:00	1	1.7	9.7	14.2	26.5	923,850.5	0.00	1.00
03/08/2023 11:00	2	1.4	13.0	14.6	27.8	680,582.2	0.00	1.00
03/08/2023 12:00	2	1.6	14.1	14.7	29.5	647,605.2	0.00	1.00
03/08/2023 13:00	2	1.6	13.9	14.7	28.9	644,954.7	0.00	1.00
03/08/2023 14:00	2	1.6	13.8	14.7	28.5	643,629.5	0.00	1.00
03/08/2023 15:00	2	1.6	13.8	14.7	28.6	642,966.8	0.00	1.00
03/08/2023 16:00	2	1.6	13.9	14.7	28.9	640,979.0	0.00	1.00
03/08/2023 17:00	1	1.5	12.9	14.6	25.2	668,626.9	0.00	1.00
03/08/2023 18:00	1	1.6	10.2	14.5	25.1	828,715.7	0.00	1.00
03/08/2023 19:00	1	1.6	10.9	14.4	22.3	805,221.5	0.00	1.00
03/08/2023 20:00	1	1.8	10.4	13.9	26.7	1,023,155.6	0.00	1.00
03/08/2023 21:00	1	1.8	10.0	14.0	26.9	1,022,702.0	0.00	1.00
03/08/2023 22:00	1	1.8	9.5	14.0	25.8	1,019,923.5	0.00	1.00
03/08/2023 23:00	1	1.8	9.5	14.0	26.1	1,021,908.1	0.00	1.00
Average/Sum#:	1	1.7	10.8	14.3	26.8	891,659.4	0.00 #	24.00 #
Minimum:	1	1.4	8.9	13.9	22.3	640,979.0	0.00	1.00
Maximum:	2	1.8	14.1	14.7	29.5	1,026,866.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2023 00:00	1	1.8	9.5	14.0	26.7	1,022,900.5	0.00	1.00
03/09/2023 01:00	1	1.8	9.5	14.0	26.3	1,023,098.9	0.00	1.00
03/09/2023 02:00	1	1.7	9.9	14.0	26.5	1,022,702.0	0.00	1.00
03/09/2023 03:00	1	1.8	9.6	14.0	26.4	1,022,305.1	0.00	1.00
03/09/2023 04:00	1	1.8	9.6	14.0	27.0	1,018,931.1	0.00	1.00
03/09/2023 05:00	1	1.8	9.7	13.8	26.9	1,020,703.4	0.00	1.00
03/09/2023 06:00	1	1.8	9.3	14.0	26.0	1,025,679.0	0.00	1.00
03/09/2023 07:00	1	1.8	9.6	14.0	26.5	1,023,098.9	0.00	1.00
03/09/2023 08:00	1	1.8	10.1	13.9	28.1	1,014,156.6	0.00	1.00
03/09/2023 09:00	1	1.8	10.1	13.9	26.7	1,015,917.3	0.00	1.00
03/09/2023 10:00	1	1.8	10.3	13.9	26.6	1,023,155.6	0.00	1.00
03/09/2023 11:00	1	1.9	11.1	13.4	29.1	1,016,112.9	0.00	1.00
03/09/2023 12:00	1	2.0	12.0	13.2	31.6	1,028,668.9	0.00	1.00
03/09/2023 13:00	1	2.1	13.4	12.7	34.9	1,021,557.2	0.00	1.00
03/09/2023 14:00	1	2.0	12.7	12.9	34.3	1,021,248.2	0.00	1.00
03/09/2023 15:00	1	2.0	11.2	13.3	30.1	1,013,193.9	0.00	1.00
03/09/2023 16:00	1	1.8	9.4	13.9	26.5	1,001,440.5	0.00	1.00
03/09/2023 17:00	1	1.8	9.5	13.9	26.2	998,701.6	0.00	1.00
03/09/2023 18:00	1	1.8	9.5	13.9	25.9	1,000,853.6	0.00	1.00
03/09/2023 19:00	1	1.8	9.6	13.9	25.8	1,002,809.9	0.00	1.00
03/09/2023 20:00	1	1.8	9.6	13.8	25.8	990,421.7	0.00	1.00
03/09/2023 21:00	1	1.8	9.5	13.8	25.5	990,421.7	0.00	1.00
03/09/2023 22:00	1	1.7	8.9	14.1	24.4	901,604.8	0.00	1.00
03/09/2023 23:00	2	1.5	11.6	14.5	26.0	678,507.0	0.00	1.00
Average/Sum#:	1	1.8	10.2	13.8	27.5	995,757.9	0.00 #	24.00 #
Minimum:	1	1.5	8.9	12.7	24.4	678,507.0	0.00	1.00
Maximum:	2	2.1	13.4	14.5	34.9	1,028,668.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2023 00:00	2	1.6	13.3	14.6	28.3	616,458.3	0.00	1.00
03/10/2023 01:00	2	1.6	12.6	14.6	26.2	622,544.7	0.00	1.00
03/10/2023 02:00	2	1.6	13.2	14.6	26.7	621,023.1	0.00	1.00
03/10/2023 03:00	2	1.6	12.9	14.6	26.4	619,718.9	0.00	1.00
03/10/2023 04:00	2	1.6	12.4	14.6	25.4	622,327.3	0.00	1.00
03/10/2023 05:00	2	1.6	11.7	14.6	24.0	629,717.8	0.00	1.00
03/10/2023 06:00	2	1.6	12.3	14.6	26.6	627,761.5	0.00	1.00
03/10/2023 07:00	2	1.6	12.8	14.6	27.2	628,631.0	0.00	1.00
03/10/2023 08:00	2	1.6	12.7	14.6	26.8	631,239.4	0.00	1.00
03/10/2023 09:00	2	1.6	12.9	14.6	27.3	629,717.8	0.00	1.00
03/10/2023 10:00	1	1.5	9.3	14.5	17.7	744,624.5	0.00	1.00
03/10/2023 11:00	2	1.6	12.4	14.6	25.4	641,890.5	0.00	1.00
03/10/2023 12:00	2	1.6	12.7	14.6	25.2	632,108.9	0.00	1.00
03/10/2023 13:00	1	1.6	12.4	14.6	24.7	633,413.1	0.00	1.00
03/10/2023 14:00	1	1.6	12.4	14.6	24.7	632,761.0	0.00	1.00
03/10/2023 15:00	1	1.5	10.6	14.6	19.2	739,706.5	0.00	1.00
03/10/2023 16:00	1	1.5	10.1	14.5	20.1	698,406.4	0.00	1.00
03/10/2023 17:00	1	1.8	9.2	14.0	19.8	902,827.8	0.00	1.00
03/10/2023 18:00	1	1.9	10.0	13.7	24.3	997,968.0	0.00	1.00
03/10/2023 19:00	1	1.8	9.7	13.8	26.4	994,279.3	0.00	1.00
03/10/2023 20:00	1	1.6	8.8	14.3	23.7	869,999.5	0.00	1.00
03/10/2023 21:00	2	1.5	11.7	14.5	26.3	669,948.1	0.00	1.00
03/10/2023 22:00	2	1.6	12.9	14.6	28.1	631,891.5	0.00	1.00
03/10/2023 23:00	2	1.6	13.0	14.6	28.5	631,891.5	0.00	1.00
Average/Sum#:	2	1.6	11.8	14.5	25.0	694,619.0	0.00 #	24.00 #
Minimum:	1	1.5	8.8	13.7	17.7	616,458.3	0.00	1.00
Maximum:	2	1.9	13.3	14.6	28.5	997,968.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2023 00:00	2	1.6	13.2	14.6	28.6	630,804.7	0.00	1.00
03/11/2023 01:00	2	1.6	13.4	14.6	29.1	630,370.0	0.00	1.00
03/11/2023 02:00	2	1.6	13.6	14.6	27.9	629,717.8	0.00	1.00
03/11/2023 03:00	2	1.6	13.3	14.6	28.5	629,717.8	0.00	1.00
03/11/2023 04:00	2	1.6	13.4	14.6	28.9	630,587.3	0.00	1.00
03/11/2023 05:00	2	1.6	13.3	14.6	29.2	631,891.5	0.00	1.00
03/11/2023 06:00	2	1.6	13.3	14.6	29.0	631,674.2	0.00	1.00
03/11/2023 07:00	2	1.6	13.3	14.6	28.7	632,543.6	0.00	1.00
03/11/2023 08:00	2	1.6	13.2	14.6	28.7	630,587.3	0.00	1.00
03/11/2023 09:00	2	1.6	13.3	14.6	28.9	630,152.6	0.00	1.00
03/11/2023 10:00	2	1.6	13.0	14.6	28.1	630,587.3	0.00	1.00
03/11/2023 11:00	2	1.6	12.8	14.6	27.2	631,891.5	0.00	1.00
03/11/2023 12:00	2	1.6	12.9	14.6	27.7	631,456.8	0.00	1.00
03/11/2023 13:00	2	1.6	12.9	14.6	27.7	630,370.0	0.00	1.00
03/11/2023 14:00	2	1.6	12.9	14.6	27.8	630,370.0	0.00	1.00
03/11/2023 15:00	2	1.6	13.1	14.6	27.8	627,109.4	0.00	1.00
03/11/2023 16:00	1	1.5	12.0	14.6	23.8	663,192.7	0.00	1.00
03/11/2023 17:00	2	1.6	10.4	14.5	25.1	713,384.5	0.00	1.00
03/11/2023 18:00	2	1.6	15.2	14.7	34.2	619,995.8	0.00	1.00
03/11/2023 19:00	1	1.7	9.7	13.8	20.1	980,970.8	0.00	1.00
03/11/2023 20:00	1	1.9	10.6	13.5	27.1	1,006,341.9	0.00	1.00
03/11/2023 21:00	1	2.0	12.2	13.1	31.0	1,014,427.4	0.00	1.00
03/11/2023 22:00	1	2.1	13.8	12.8	35.2	1,015,064.7	0.00	1.00
03/11/2023 23:00	1	2.1	13.4	12.8	34.7	1,013,374.0	0.00	1.00
Average/Sum#:	2	1.7	12.8	14.3	28.5	713,191.0	0.00 #	24.00 #
Minimum:	1	1.5	9.7	12.8	20.1	619,995.8	0.00	1.00
Maximum:	2	2.1	15.2	14.7	35.2	1,015,064.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2023 00:00	1	2.0	11.8	13.3	30.3	1,008,509.0	0.00	1.00
03/12/2023 01:00	1	1.6	8.3	14.5	23.9	1,002,889.4	0.00	1.00
03/12/2023 02:00	1	1.7	8.8	14.5	24.1	1,001,605.6	0.00	1.00
03/12/2023 03:00	1	1.7	8.5	14.2	24.5	964,320.0	0.00	1.00
03/12/2023 04:00	1	2.0	11.5	13.1	30.8	1,006,878.1	0.00	1.00
03/12/2023 05:00	1	2.0	11.5	13.1	31.6	1,005,824.7	0.00	1.00
03/12/2023 06:00	1	1.7	8.8	14.1	23.8	919,729.6	0.00	1.00
03/12/2023 07:00	2	1.5	11.0	14.6	24.5	678,191.1	0.00	1.00
03/12/2023 08:00	2	1.6	11.9	14.6	24.3	627,109.4	0.00	1.00
03/12/2023 09:00	1	1.6	11.2	14.6	21.4	648,411.6	0.00	1.00
03/12/2023 10:00	1	1.6	11.6	14.6	22.8	639,716.8	0.00	1.00
03/12/2023 11:00	1	1.6	11.2	14.6	23.0	645,585.8	0.00	1.00
03/12/2023 12:00	2	1.6	11.7	14.6	24.8	630,152.6	0.00	1.00
03/12/2023 13:00	2	1.6	11.9	14.6	24.8	628,196.3	0.00	1.00
03/12/2023 14:00	1	1.5	10.5	14.6	20.9	731,881.3	0.00	1.00
03/12/2023 15:00	1	1.6	10.1	14.5	23.0	750,401.8	0.00	1.00
03/12/2023 16:00	1	1.6	9.7	14.3	19.7	784,721.7	0.00	1.00
03/12/2023 17:00	1	2.0	12.1	12.9	29.3	1,003,445.7	0.00	1.00
03/12/2023 18:00	1	2.1	12.7	12.8	32.7	1,011,176.2	0.00	1.00
03/12/2023 19:00	1	2.0	11.9	13.0	31.4	1,015,107.5	0.00	1.00
03/12/2023 20:00	1	2.1	12.4	12.8	32.1	1,008,302.1	0.00	1.00
03/12/2023 21:00	1	2.0	12.2	12.9	31.6	1,014,572.3	0.00	1.00
03/12/2023 22:00	1	2.0	11.0	13.2	29.0	1,001,991.8	0.00	1.00
03/12/2023 23:00	1	1.6	7.2	14.4	18.8	864,633.5	0.00	1.00
Average/Sum#:	1	1.8	10.8	13.9	26.0	858,056.4	0.00 #	24.00 #
Minimum:	1	1.5	7.2	12.8	18.8	627,109.4	0.00	1.00
Maximum:	2	2.1	12.7	14.6	32.7	1,015,107.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2023 00:00	2	1.6	11.3	14.6	25.1	667,540.0	0.00	1.00
03/13/2023 01:00	2	1.6	11.6	14.6	24.0	632,761.0	0.00	1.00
03/13/2023 02:00	2	1.6	12.0	14.6	24.8	635,804.2	0.00	1.00
03/13/2023 03:00	2	1.6	12.5	14.6	27.5	630,804.7	0.00	1.00
03/13/2023 04:00	1	1.5	10.4	14.6	20.3	761,660.8	0.00	1.00
03/13/2023 05:00	1	1.6	8.9	14.5	20.2	836,846.7	0.00	1.00
03/13/2023 06:00	1	1.6	7.6	14.4	19.6	928,048.4	0.00	1.00
03/13/2023 07:00	2	1.6	12.5	14.6	27.4	627,109.4	0.00	1.00
03/13/2023 08:00	2	1.6	12.3	14.6	24.6	628,196.3	0.00	1.00
03/13/2023 09:00	1	1.6	12.0	14.6	23.8	628,196.3	0.00	1.00
03/13/2023 10:00	1	1.6	11.8	14.6	23.2	628,848.4	0.00	1.00
03/13/2023 11:00	1	1.6	11.4	14.6	22.0	629,717.8	0.00	1.00
03/13/2023 12:00	1	1.6	11.2	14.7	21.5	639,653.7	0.00	1.00
03/13/2023 13:00	1	1.6	10.8	14.7	20.3	641,420.7	0.00	1.00
03/13/2023 14:00	1	1.6	10.7	14.7	20.0	641,420.7	0.00	1.00
03/13/2023 15:00	1	1.6	10.7	14.7	20.0	639,874.6	0.00	1.00
03/13/2023 16:00	1	1.5	9.4	14.6	16.5	730,794.4	0.00	1.00
03/13/2023 17:00	1	1.5	9.5	14.6	18.4	704,275.4	0.00	1.00
03/13/2023 18:00	1	1.8	9.1	13.9	21.3	967,009.2	0.00	1.00
03/13/2023 19:00	1	2.0	10.8	13.2	26.9	997,367.8	0.00	1.00
03/13/2023 20:00	1	2.1	12.2	12.9	30.8	1,009,950.5	0.00	1.00
03/13/2023 21:00	1	2.0	11.2	13.1	28.2	991,779.3	0.00	1.00
03/13/2023 22:00	1	1.6	8.3	14.3	21.4	858,795.1	0.00	1.00
03/13/2023 23:00	2	1.6	10.7	14.6	23.4	666,887.9	0.00	1.00
Average/Sum#:	1	1.7	10.8	14.4	23.0	738,531.8	0.00 #	24.00 #
Minimum:	1	1.5	7.6	12.9	16.5	627,109.4	0.00	1.00
Maximum:	2	2.1	12.5	14.7	30.8	1,009,950.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2023 00:00	2	1.6	11.4	14.6	24.8	628,413.6	0.00	1.00
03/14/2023 01:00	2	1.6	12.3	14.6	26.3	619,066.8	0.00	1.00
03/14/2023 02:00	1	1.5	11.8	14.6	24.6	624,501.0	0.00	1.00
03/14/2023 03:00	1	1.6	11.4	14.6	23.8	625,587.8	0.00	1.00
03/14/2023 04:00	2	1.6	11.6	14.6	24.3	624,501.0	0.00	1.00
03/14/2023 05:00	2	1.6	11.5	14.6	24.2	624,283.6	0.00	1.00
03/14/2023 06:00	2	1.6	11.7	14.6	24.5	622,544.7	0.00	1.00
03/14/2023 07:00	1	1.5	8.8	14.5	17.2	789,772.7	0.00	1.00
03/14/2023 08:00	1	1.6	7.5	14.4	19.0	951,644.6	0.00	1.00
03/14/2023 09:00	1	1.6	9.2	14.4	22.3	761,400.0	0.00	1.00
03/14/2023 10:00	1	1.8	9.2	13.8	22.5	942,974.1	0.00	1.00
03/14/2023 11:00	1	2.0	10.8	13.2	26.8	990,253.9	0.00	1.00
03/14/2023 12:00	1	2.0	11.2	13.0	27.6	980,785.2	0.00	1.00
03/14/2023 13:00	1	2.1	12.4	12.7	30.8	987,321.6	0.00	1.00
03/14/2023 14:00	1	2.0	11.3	13.0	26.8	984,078.8	0.00	1.00
03/14/2023 15:00	1	1.9	9.8	13.5	24.0	988,021.2	0.00	1.00
03/14/2023 16:00	1	2.0	11.1	13.1	28.0	992,832.7	0.00	1.00
03/14/2023 17:00	1	2.0	11.7	12.9	30.6	994,544.5	0.00	1.00
03/14/2023 18:00	1	2.1	12.4	12.8	32.8	1,002,384.8	0.00	1.00
03/14/2023 19:00	1	2.1	12.6	12.8	33.8	1,015,064.7	0.00	1.00
03/14/2023 20:00	1	2.0	12.3	12.9	33.2	1,013,202.9	0.00	1.00
03/14/2023 21:00	1	1.9	10.3	13.4	28.9	1,001,323.1	0.00	1.00
03/14/2023 22:00	1	1.7	8.4	14.1	23.0	938,861.2	0.00	1.00
03/14/2023 23:00	2	1.6	10.9	14.5	25.0	689,419.6	0.00	1.00
Average/Sum#:	1	1.8	10.9	13.8	26.0	849,699.3	0.00 #	24.00 #
Minimum:	1	1.5	7.5	12.7	17.2	619,066.8	0.00	1.00
Maximum:	2	2.1	12.6	14.6	33.8	1,015,064.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2023 00:00	2	1.6	13.4	14.6	29.2	626,022.6	0.00	1.00
03/15/2023 01:00	2	1.6	13.5	14.6	29.4	626,892.1	0.00	1.00
03/15/2023 02:00	2	1.5	14.1	14.6	30.2	628,413.6	0.00	1.00
03/15/2023 03:00	2	1.6	13.8	14.6	29.9	628,848.4	0.00	1.00
03/15/2023 04:00	2	1.6	13.8	14.6	30.4	628,196.3	0.00	1.00
03/15/2023 05:00	2	1.6	13.8	14.6	30.3	628,413.6	0.00	1.00
03/15/2023 06:00	2	1.6	13.0	14.6	28.2	641,021.0	0.00	1.00
03/15/2023 07:00	2	1.6	13.5	14.6	30.4	628,848.4	0.00	1.00
03/15/2023 08:00	2	1.6	13.3	14.6	29.3	629,065.7	0.00	1.00
03/15/2023 09:00	2	1.6	13.2	14.6	28.5	628,413.6	0.00	1.00
03/15/2023 10:00	2	1.6	12.9	14.6	27.6	627,544.2	0.00	1.00
03/15/2023 11:00	2	1.6	12.7	14.6	26.4	626,022.6	0.00	1.00
03/15/2023 12:00	2	1.6	12.5	14.7	25.8	637,886.7	0.00	1.00
03/15/2023 13:00	1	1.6	11.9	14.7	23.5	639,212.0	0.00	1.00
03/15/2023 14:00	1	1.6	11.6	14.7	22.6	639,874.6	0.00	1.00
03/15/2023 15:00	1	1.6	11.5	14.7	22.8	640,095.5	0.00	1.00
03/15/2023 16:00	1	1.5	10.0	14.6	17.9	729,272.8	0.00	1.00
03/15/2023 17:00	1	1.5	10.3	14.6	20.3	695,580.6	0.00	1.00
03/15/2023 18:00	1	1.7	9.0	14.1	19.8	963,027.6	0.00	1.00
03/15/2023 19:00	1	1.9	10.8	13.4	27.5	1,011,000.4	0.00	1.00
03/15/2023 20:00	1	2.0	11.6	13.1	29.7	1,005,298.0	0.00	1.00
03/15/2023 21:00	1	1.6	8.1	14.3	20.7	885,353.6	0.00	1.00
03/15/2023 22:00	2	1.6	13.0	14.6	30.4	644,498.9	0.00	1.00
03/15/2023 23:00	2	1.6	13.4	14.6	29.5	627,544.2	0.00	1.00
Average/Sum#:	2	1.6	12.3	14.5	26.7	694,431.1	0.00 #	24.00 #
Minimum:	1	1.5	8.1	13.1	17.9	626,022.6	0.00	1.00
Maximum:	2	2.0	14.1	14.7	30.4	1,011,000.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2023 00:00	2	1.6	13.5	14.6	29.8	629,283.1	0.00	1.00
03/16/2023 01:00	2	1.6	14.3	14.6	32.1	627,761.5	0.00	1.00
03/16/2023 02:00	2	1.5	15.2	14.6	33.0	625,587.8	0.00	1.00
03/16/2023 03:00	2	1.6	14.9	14.6	32.3	626,022.6	0.00	1.00
03/16/2023 04:00	2	1.6	14.9	14.6	32.5	626,457.3	0.00	1.00
03/16/2023 05:00	2	1.6	14.9	14.6	32.4	625,153.1	0.00	1.00
03/16/2023 06:00	2	1.7	13.5	14.5	28.9	641,703.7	0.00	1.00
03/16/2023 07:00	2	1.6	14.3	14.6	31.6	628,196.3	0.00	1.00
03/16/2023 08:00	2	1.6	13.7	14.6	29.8	629,283.1	0.00	1.00
03/16/2023 09:00	2	1.6	12.8	14.6	26.2	630,152.6	0.00	1.00
03/16/2023 10:00	1	1.6	12.2	14.6	24.6	631,456.8	0.00	1.00
03/16/2023 11:00	1	1.6	11.8	14.6	23.0	633,413.1	0.00	1.00
03/16/2023 12:00	1	1.6	11.8	14.6	22.8	631,456.8	0.00	1.00
03/16/2023 13:00	1	1.6	12.2	14.7	24.2	635,678.0	0.00	1.00
03/16/2023 14:00	1	1.6	12.4	14.7	24.3	632,364.8	0.00	1.00
03/16/2023 15:00	1	1.6	12.2	14.7	22.1	621,100.2	0.02	0.30
03/16/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	1.6	13.4	14.6	28.1	629,691.9	0.02 #	15.30 #
Minimum:	1	1.5	11.8	14.5	22.1	621,100.2	0.00	0.00
Maximum:	2	1.7	15.2	14.7	33.0	641,703.7	0.02	1.00
%SI	33.33	33.33	33.33	33.33	33.33	33.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 01:00	0	7.1	11.4	19.4	0.0	765,964.7	0.17	0.17
03/17/2023 02:00	1	6.5	16.1	14.7	10.0	727,120.2	0.87	1.00
03/17/2023 03:00	1	1.9	10.7	13.7	29.6	949,277.4	0.00	1.00
03/17/2023 04:00	1	2.0	13.3	13.0	35.5	1,029,495.1	0.00	1.00
03/17/2023 05:00	1	2.0	13.3	12.9	36.1	1,034,257.8	0.00	1.00
03/17/2023 06:00	1	2.0	11.7	13.2	32.0	1,023,689.2	0.00	1.00
03/17/2023 07:00	2	1.6	10.7	14.2	28.8	864,985.7	0.00	1.00
03/17/2023 08:00	1	1.6	10.3	14.4	21.6	711,890.0	0.00	1.00
03/17/2023 09:00	1	1.6	11.1	14.5	23.4	655,611.9	0.00	1.00
03/17/2023 10:00	1	1.6	10.7	14.5	21.2	658,607.5	0.00	1.00
03/17/2023 11:00	1	1.6	10.4	14.5	20.7	660,533.3	0.00	1.00
03/17/2023 12:00	1	1.6	10.2	14.5	19.9	658,607.5	0.00	1.00
03/17/2023 13:00	1	1.6	10.1	14.6	19.8	668,626.9	0.00	1.00
03/17/2023 14:00	1	1.6	10.3	14.6	19.9	664,496.9	0.00	1.00
03/17/2023 15:00	1	1.6	10.1	14.6	19.2	666,670.6	0.00	1.00
03/17/2023 16:00	1	1.6	8.8	14.6	18.1	821,219.9	0.00	1.00
03/17/2023 17:00	1	1.6	9.4	14.5	20.1	783,353.5	0.00	1.00
03/17/2023 18:00	1	1.9	11.6	13.5	28.3	1,011,708.5	0.00	1.00
03/17/2023 19:00	1	2.0	12.6	13.1	31.7	1,011,442.8	0.00	1.00
03/17/2023 20:00	1	1.9	11.3	13.5	29.7	1,018,555.6	0.00	1.00
03/17/2023 21:00	1	2.0	12.0	13.2	31.9	1,009,105.7	0.00	1.00
03/17/2023 22:00	1	1.6	9.7	14.3	24.8	841,158.6	0.00	1.00
03/17/2023 23:00	2	1.6	11.1	14.5	25.1	694,127.0	0.00	1.00
Average/Sum#:	1	2.2	11.2	14.3	23.8	823,065.5	1.04 #	22.17 #
Minimum:	1	1.6	8.8	12.9	0.0	655,611.9	0.00	0.00
Maximum:	2	7.1	16.1	19.4	36.1	1,034,257.8	0.87	1.00
%SI	8.33	4.17	4.17	4.17	4.17	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2023 00:00	2	1.6	11.9	14.5	26.4	654,542.1	0.00	1.00
03/18/2023 01:00	2	1.6	11.9	14.5	26.2	656,253.8	0.00	1.00
03/18/2023 02:00	2	1.7	12.4	14.5	25.7	657,965.6	0.00	1.00
03/18/2023 03:00	2	1.6	12.3	14.5	27.4	656,039.9	0.00	1.00
03/18/2023 04:00	2	1.6	12.2	14.5	27.2	654,970.0	0.00	1.00
03/18/2023 05:00	2	1.6	12.4	14.5	27.9	656,895.8	0.00	1.00
03/18/2023 06:00	2	1.6	12.5	14.5	28.2	655,611.9	0.00	1.00
03/18/2023 07:00	2	1.6	12.3	14.5	27.1	655,825.9	0.00	1.00
03/18/2023 08:00	1	1.6	11.8	14.5	24.3	656,039.9	0.00	1.00
03/18/2023 09:00	1	1.6	10.8	14.5	21.1	665,668.6	0.00	1.00
03/18/2023 10:00	1	1.6	10.7	14.5	21.2	663,314.9	0.00	1.00
03/18/2023 11:00	1	1.6	10.4	14.5	19.8	661,603.2	0.00	1.00
03/18/2023 12:00	1	1.6	10.3	14.6	19.9	668,409.5	0.00	1.00
03/18/2023 13:00	1	1.6	10.3	14.6	19.7	665,801.1	0.00	1.00
03/18/2023 14:00	1	1.6	10.2	14.6	19.6	665,801.1	0.00	1.00
03/18/2023 15:00	1	1.6	9.2	14.6	17.5	761,443.4	0.00	1.00
03/18/2023 16:00	1	1.6	8.7	14.5	17.2	757,248.9	0.00	1.00
03/18/2023 17:00	1	1.8	9.9	13.8	23.5	975,184.5	0.00	1.00
03/18/2023 18:00	1	2.1	13.4	12.7	32.4	1,000,681.8	0.00	1.00
03/18/2023 19:00	1	1.9	11.3	13.3	28.5	995,535.5	0.00	1.00
03/18/2023 20:00	1	1.9	11.0	13.4	27.8	991,645.8	0.00	1.00
03/18/2023 21:00	1	1.6	8.6	14.3	20.4	853,815.4	0.00	1.00
03/18/2023 22:00	1	1.6	10.3	14.5	21.8	665,240.7	0.00	1.00
03/18/2023 23:00	1	1.6	10.7	14.5	22.3	650,690.6	0.00	1.00
Average/Sum#:	1	1.7	11.1	14.3	23.9	731,092.9	0.00 #	24.00 #
Minimum:	1	1.6	8.6	12.7	17.2	650,690.6	0.00	1.00
Maximum:	2	2.1	13.4	14.6	32.4	1,000,681.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2023 00:00	1	1.6	10.8	14.5	22.3	651,974.4	0.00	1.00
03/19/2023 01:00	1	1.6	10.8	14.6	22.0	658,627.9	0.00	1.00
03/19/2023 02:00	1	1.7	11.3	14.5	22.6	653,686.2	0.00	1.00
03/19/2023 03:00	1	1.6	10.9	14.5	23.3	656,467.8	0.00	1.00
03/19/2023 04:00	1	1.6	10.8	14.5	23.0	656,681.8	0.00	1.00
03/19/2023 05:00	2	1.6	10.8	14.5	23.3	657,323.7	0.00	1.00
03/19/2023 06:00	2	1.6	11.0	14.5	23.6	657,965.6	0.00	1.00
03/19/2023 07:00	1	1.6	10.9	14.5	23.3	657,537.7	0.00	1.00
03/19/2023 08:00	2	1.6	11.1	14.5	24.1	655,184.0	0.00	1.00
03/19/2023 09:00	2	1.6	11.3	14.5	24.3	650,048.6	0.00	1.00
03/19/2023 10:00	2	1.6	11.5	14.5	24.5	646,197.1	0.00	1.00
03/19/2023 11:00	2	1.6	11.3	14.5	23.8	649,406.7	0.00	1.00
03/19/2023 12:00	1	1.6	10.0	14.5	21.3	701,188.1	0.00	1.00
03/19/2023 13:00	1	1.6	10.7	14.5	22.9	655,398.0	0.00	1.00
03/19/2023 14:00	1	1.6	10.4	14.5	22.1	657,109.7	0.00	1.00
03/19/2023 15:00	1	1.6	8.8	14.4	19.6	813,438.1	0.00	1.00
03/19/2023 16:00	1	1.6	9.3	14.5	19.8	735,209.7	0.00	1.00
03/19/2023 17:00	1	1.9	11.2	13.4	28.3	995,662.8	0.00	1.00
03/19/2023 18:00	1	2.0	12.3	13.0	31.8	999,333.1	0.00	1.00
03/19/2023 19:00	1	2.0	11.4	13.3	30.0	1,004,905.2	0.00	1.00
03/19/2023 20:00	1	2.0	11.7	13.2	30.5	1,001,280.4	0.00	1.00
03/19/2023 21:00	1	1.9	10.8	13.6	29.1	1,007,183.5	0.00	1.00
03/19/2023 22:00	1	1.8	10.4	13.7	29.1	994,544.5	0.00	1.00
03/19/2023 23:00	1	1.8	10.5	13.6	29.0	991,425.7	0.00	1.00
Average/Sum#:	1	1.7	10.8	14.2	24.7	766,990.8	0.00 #	24.00 #
Minimum:	1	1.6	8.8	13.0	19.6	646,197.1	0.00	1.00
Maximum:	2	2.0	12.3	14.6	31.8	1,007,183.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2023 00:00	1	1.7	9.3	14.1	25.9	888,917.5	0.00	1.00
03/20/2023 01:00	1	1.6	10.1	14.5	21.8	697,764.5	0.00	1.00
03/20/2023 02:00	1	1.6	11.2	14.5	23.8	657,965.6	0.00	1.00
03/20/2023 03:00	2	1.7	11.1	14.5	23.9	659,249.5	0.00	1.00
03/20/2023 04:00	2	1.6	11.0	14.5	23.9	660,105.3	0.00	1.00
03/20/2023 05:00	1	1.6	9.9	14.4	20.5	711,258.0	0.00	1.00
03/20/2023 06:00	2	1.6	11.2	14.5	25.9	660,747.3	0.00	1.00
03/20/2023 07:00	1	1.5	9.7	14.4	22.0	722,002.7	0.00	1.00
03/20/2023 08:00	1	1.6	10.2	14.5	22.2	708,249.2	0.00	1.00
03/20/2023 09:00	1	1.6	11.0	14.5	23.3	656,467.8	0.00	1.00
03/20/2023 10:00	1	1.6	11.1	14.5	22.8	657,109.7	0.00	1.00
03/20/2023 11:00	1	1.6	11.1	14.5	22.1	657,751.6	0.00	1.00
03/20/2023 12:00	1	1.6	10.9	14.5	22.2	657,537.7	0.00	1.00
03/20/2023 13:00	1	1.6	10.6	14.5	20.8	658,821.5	0.00	1.00
03/20/2023 14:00	1	1.6	10.5	14.5	21.1	657,537.7	0.00	1.00
03/20/2023 15:00	1	1.6	10.4	14.5	20.6	657,965.6	0.00	1.00
03/20/2023 16:00	1	1.6	8.7	14.5	18.3	854,178.5	0.00	1.00
03/20/2023 17:00	1	1.6	8.9	14.4	19.3	865,054.8	0.00	1.00
03/20/2023 18:00	1	2.0	12.2	13.2	30.6	1,021,555.0	0.00	1.00
03/20/2023 19:00	1	2.0	12.1	13.1	32.0	1,003,717.8	0.00	1.00
03/20/2023 20:00	1	5.7	16.1	14.0	16.1	790,892.2	0.28	0.52
03/20/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	1.8	10.8	14.3	22.8	738,326.2	0.28 #	20.52 #
Minimum:	1	1.5	8.7	13.1	16.1	656,467.8	0.00	0.00
Maximum:	2	5.7	16.1	14.5	32.0	1,021,555.0	0.28	1.00
%SI	12.50	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2023 16:00	0	12.5	15.8	15.5	3.9	691,305.7	0.87	0.87
03/22/2023 17:00	1	2.0	11.8	13.8	27.7	873,924.2	0.32	1.00
03/22/2023 18:00	1	2.1	13.9	12.8	35.1	1,017,262.5	0.00	1.00
03/22/2023 19:00	1	2.0	13.5	12.9	35.2	1,020,905.9	0.00	1.00
03/22/2023 20:00	1	2.0	12.7	13.1	33.8	1,023,030.2	0.00	1.00
03/22/2023 21:00	1	1.9	11.1	13.6	29.8	1,016,938.3	0.00	1.00
03/22/2023 22:00	1	1.7	9.4	14.1	26.0	925,972.5	0.00	1.00
03/22/2023 23:00	1	2.6	12.1	14.6	18.6	729,055.5	0.15	0.88
Average/Sum#:	1	3.4	12.5	13.8	26.3	912,299.4	1.34 #	7.75 #
Minimum:	1	1.7	9.4	12.8	3.9	691,305.7	0.00	0.00
Maximum:	1	12.5	15.8	15.5	35.2	1,023,030.2	0.87	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2023 14:00	0	0.0	0.0	21.0	0.0	0.0	0.02	0.02
03/23/2023 15:00	1	9.4	15.8	15.4	11.1	675,499.7	0.93	1.00
03/23/2023 16:00	1	1.5	11.0	14.5	21.8	815,663.4	0.00	1.00
03/23/2023 17:00	1	1.8	10.6	13.9	25.9	1,006,722.6	0.00	1.00
03/23/2023 18:00	1	1.8	10.4	13.9	26.2	1,005,548.8	0.00	1.00
03/23/2023 19:00	1	1.8	10.3	14.0	27.1	1,014,564.8	0.00	1.00
03/23/2023 20:00	1	1.8	10.4	14.0	28.4	1,010,595.5	0.00	1.00
03/23/2023 21:00	1	1.8	10.5	14.0	29.2	1,007,420.0	0.00	1.00
03/23/2023 22:00	1	1.9	11.2	14.4	23.2	842,722.7	0.08	1.00
03/23/2023 23:00	0	17.6	35.6	16.5	0.0	505,130.9	0.07	0.07
Average/Sum#:	1	3.9	12.6	15.2	19.3	788,386.8	1.10 #	8.09 #
Minimum:	1	0.0	0.0	13.9	0.0	0.0	0.00	0.00
Maximum:	1	17.6	35.6	21.0	29.2	1,014,564.8	0.93	1.00
%SI	66.67	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:14 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023 00:00	0	1.6	15.9	14.6	21.4	680,147.4	0.00	1.00
01/01/2023 01:00	0	1.6	16.9	14.6	23.0	675,365.3	0.00	1.00
01/01/2023 02:00	0	1.4	17.4	14.6	23.4	676,669.5	0.00	1.00
01/01/2023 03:00	0	1.6	17.7	14.6	24.1	675,582.7	0.00	1.00
01/01/2023 04:00	0	1.6	18.0	14.6	24.8	672,539.5	0.00	1.00
01/01/2023 05:00	0	1.6	18.2	14.6	25.3	671,017.9	0.00	1.00
01/01/2023 06:00	0	1.6	18.5	14.6	25.7	670,800.6	0.00	1.00
01/01/2023 07:00	0	1.6	18.5	14.6	25.6	671,017.9	0.00	1.00
01/01/2023 08:00	0	1.6	18.5	14.6	25.5	669,931.1	0.00	1.00
01/01/2023 09:00	0	1.6	18.3	14.6	25.5	669,496.4	0.00	1.00
01/01/2023 10:00	0	1.6	18.0	14.6	24.9	668,192.2	0.00	1.00
01/01/2023 11:00	0	1.6	17.7	14.7	24.1	675,656.3	0.00	1.00
01/01/2023 12:00	0	1.6	17.5	14.7	23.6	674,551.9	0.00	1.00
01/01/2023 13:00	0	1.6	17.2	14.7	23.2	675,656.3	0.00	1.00
01/01/2023 14:00	0	1.6	17.1	14.7	22.9	676,318.9	0.00	1.00
01/01/2023 15:00	0	1.6	17.0	14.7	22.8	678,306.8	0.00	1.00
01/01/2023 16:00	0	1.6	17.4	14.7	23.6	680,073.8	0.00	1.00
01/01/2023 17:00	0	1.6	17.7	14.6	24.5	671,670.1	0.00	1.00
01/01/2023 18:00	0	1.6	17.9	14.6	24.6	674,061.1	0.00	1.00
01/01/2023 19:00	0	1.6	18.0	14.6	25.1	675,582.7	0.00	1.00
01/01/2023 20:00	0	1.6	17.9	14.6	24.9	679,060.6	0.00	1.00
01/01/2023 21:00	0	1.6	18.3	14.6	26.0	678,408.5	0.00	1.00
01/01/2023 22:00	0	1.6	18.9	14.6	27.0	676,886.9	0.00	1.00
01/01/2023 23:00	0	1.6	18.7	14.6	26.9	675,800.1	0.00	1.00
Average/Sum#:	0	1.6	17.8	14.6	24.5	674,699.8	0.00 #	24.00 #
Minimum:	0	1.4	15.9	14.6	21.4	668,192.2	0.00	1.00
Maximum:	0	1.6	18.9	14.7	27.0	680,147.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2023 00:00	0	1.6	18.1	14.6	25.6	678,191.1	0.00	1.00
01/02/2023 01:00	0	1.6	18.2	14.6	26.2	678,408.5	0.00	1.00
01/02/2023 02:00	0	1.5	19.0	14.6	27.2	678,625.9	0.00	1.00
01/02/2023 03:00	0	1.6	19.0	14.6	27.1	677,539.0	0.00	1.00
01/02/2023 04:00	0	1.6	19.2	14.6	27.6	676,017.4	0.00	1.00
01/02/2023 05:00	0	1.6	18.7	14.6	26.7	678,191.1	0.00	1.00
01/02/2023 06:00	0	1.6	18.4	14.6	25.5	687,103.3	0.00	1.00
01/02/2023 07:00	0	1.5	8.1	14.4	5.3	1,046,029.5	0.00	1.00
01/02/2023 08:00	1	1.6	15.5	14.5	25.2	757,462.9	0.00	1.00
01/02/2023 09:00	1	1.6	19.0	14.6	27.9	675,365.3	0.00	1.00
01/02/2023 10:00	0	1.3	14.5	14.5	17.5	768,589.4	0.00	1.00
01/02/2023 11:00	0	1.4	13.8	14.5	17.4	787,205.0	0.00	1.00
01/02/2023 12:00	0	1.6	10.7	14.4	14.6	855,574.2	0.00	1.00
01/02/2023 13:00	0	1.5	10.6	14.1	13.3	1,000,485.3	0.00	1.00
01/02/2023 14:00	0	2.1	15.0	12.7	26.1	1,098,044.6	0.00	1.00
01/02/2023 15:00	0	2.1	14.8	12.8	26.2	1,099,597.1	0.00	1.00
01/02/2023 16:00	0	2.1	15.0	12.8	26.7	1,098,920.8	0.00	1.00
01/02/2023 17:00	0	2.1	15.0	12.8	26.5	1,099,089.9	0.00	1.00
01/02/2023 18:00	0	2.1	14.9	12.8	26.3	1,097,061.1	0.00	1.00
01/02/2023 19:00	0	2.0	14.8	12.9	26.0	1,103,756.1	0.00	1.00
01/02/2023 20:00	0	2.0	14.5	12.9	25.6	1,097,251.3	0.00	1.00
01/02/2023 21:00	0	2.0	14.2	13.0	25.2	1,101,433.2	0.00	1.00
01/02/2023 22:00	0	2.0	13.6	13.2	23.7	1,102,475.6	0.00	1.00
01/02/2023 23:00	0	1.9	13.2	13.3	23.2	1,100,404.6	0.00	1.00
Average/Sum#:	0	1.8	15.3	13.9	23.4	901,784.3	0.00 #	24.00 #
Minimum:	0	1.3	8.1	12.7	5.3	675,365.3	0.00	1.00
Maximum:	1	2.1	19.2	14.6	27.9	1,103,756.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2023 00:00	0	2.0	13.8	13.1	23.9	1,093,783.8	0.00	1.00
01/03/2023 01:00	0	2.0	13.5	13.2	23.7	1,101,586.3	0.00	1.00
01/03/2023 02:00	0	2.0	13.8	13.2	23.5	1,101,942.0	0.00	1.00
01/03/2023 03:00	0	2.0	13.8	13.1	23.9	1,096,417.3	0.00	1.00
01/03/2023 04:00	0	2.0	14.1	13.1	24.8	1,110,111.6	0.00	1.00
01/03/2023 05:00	0	2.0	14.3	13.0	25.1	1,105,073.5	0.00	1.00
01/03/2023 06:00	0	2.1	15.4	12.7	28.6	1,114,076.8	0.00	1.00
01/03/2023 07:00	0	2.0	14.5	13.0	25.5	1,113,567.4	0.00	1.00
01/03/2023 08:00	0	1.9	11.7	13.7	20.3	1,098,012.1	0.00	1.00
01/03/2023 09:00	0	1.8	11.7	13.7	20.3	1,105,810.2	0.00	1.00
01/03/2023 10:00	0	1.8	10.6	14.0	18.8	1,098,715.0	0.00	1.00
01/03/2023 11:00	0	1.8	10.1	14.0	18.0	1,087,005.4	0.00	1.00
01/03/2023 12:00	0	1.8	10.7	13.9	18.9	1,100,625.9	0.00	1.00
01/03/2023 13:00	0	1.8	10.5	13.9	18.9	1,094,365.7	0.00	1.00
01/03/2023 14:00	0	1.8	11.1	13.7	19.3	1,093,637.5	0.00	1.00
01/03/2023 15:00	0	2.1	14.5	12.8	26.7	1,102,809.3	0.00	1.00
01/03/2023 16:00	0	2.0	14.1	13.0	25.0	1,102,646.6	0.00	1.00
01/03/2023 17:00	0	2.0	14.0	13.0	24.5	1,098,659.7	0.00	1.00
01/03/2023 18:00	0	2.0	14.1	13.0	24.6	1,099,353.1	0.00	1.00
01/03/2023 19:00	0	2.0	13.7	13.1	23.8	1,103,791.2	0.00	1.00
01/03/2023 20:00	0	2.1	14.4	12.9	25.7	1,103,413.7	0.00	1.00
01/03/2023 21:00	0	2.1	14.4	12.9	25.6	1,101,017.2	0.00	1.00
01/03/2023 22:00	0	2.0	14.0	13.0	24.4	1,098,833.1	0.00	1.00
01/03/2023 23:00	0	1.9	12.4	13.5	21.2	1,099,425.7	0.00	1.00
Average/Sum#:	0	2.0	13.1	13.3	23.1	1,101,028.3	0.00 #	24.00 #
Minimum:	0	1.8	10.1	12.7	18.0	1,087,005.4	0.00	1.00
Maximum:	0	2.1	15.4	14.0	28.6	1,114,076.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2023 00:00	0	1.7	8.7	14.4	14.9	1,084,584.1	0.00	1.00
01/04/2023 01:00	0	1.6	8.8	14.4	15.3	1,091,747.3	0.00	1.00
01/04/2023 02:00	0	1.9	9.0	14.4	14.5	1,092,168.6	0.00	1.00
01/04/2023 03:00	0	1.7	9.0	14.4	15.7	1,092,590.0	0.00	1.00
01/04/2023 04:00	0	1.6	8.9	14.4	15.4	1,091,325.9	0.00	1.00
01/04/2023 05:00	0	1.7	9.0	14.4	16.0	1,091,325.9	0.00	1.00
01/04/2023 06:00	0	1.7	8.9	14.4	15.6	1,091,536.6	0.00	1.00
01/04/2023 07:00	0	1.8	10.0	14.0	17.9	1,084,028.4	0.00	1.00
01/04/2023 08:00	0	1.6	11.9	14.3	19.1	895,105.6	0.00	1.00
01/04/2023 09:00	0	1.4	15.1	14.5	20.4	719,803.7	0.00	1.00
01/04/2023 10:00	0	1.6	17.3	14.6	23.8	667,757.4	0.00	1.00
01/04/2023 11:00	0	1.6	16.5	14.6	22.2	674,278.5	0.00	1.00
01/04/2023 12:00	0	1.6	15.8	14.6	20.9	679,278.0	0.00	1.00
01/04/2023 13:00	0	1.6	15.5	14.6	20.6	676,452.2	0.00	1.00
01/04/2023 14:00	0	1.6	16.0	14.6	21.4	670,365.8	0.00	1.00
01/04/2023 15:00	0	1.6	15.6	14.7	20.8	679,632.1	0.00	1.00
01/04/2023 16:00	0	1.6	16.0	14.7	21.6	675,214.6	0.00	1.00
01/04/2023 17:00	0	1.6	16.2	14.7	21.6	670,355.3	0.00	1.00
01/04/2023 18:00	0	1.6	15.8	14.6	20.7	664,714.2	0.00	1.00
01/04/2023 19:00	0	1.6	15.0	14.6	19.2	671,670.1	0.00	1.00
01/04/2023 20:00	0	1.6	15.7	14.6	21.1	667,757.4	0.00	1.00
01/04/2023 21:00	0	1.6	15.8	14.6	21.1	667,757.4	0.00	1.00
01/04/2023 22:00	0	1.6	16.1	14.6	21.7	665,366.4	0.00	1.00
01/04/2023 23:00	0	1.6	16.4	14.6	21.9	663,627.4	0.00	1.00
Average/Sum#:	0	1.6	13.5	14.5	19.3	822,018.5	0.00 #	24.00 #
Minimum:	0	1.4	8.7	14.0	14.5	663,627.4	0.00	1.00
Maximum:	0	1.9	17.3	14.7	23.8	1,092,590.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2023 00:00	0	1.6	15.8	14.6	20.6	674,278.5	0.00	1.00
01/05/2023 01:00	0	1.6	15.4	14.6	20.6	674,713.2	0.00	1.00
01/05/2023 02:00	0	1.5	15.6	14.6	20.6	678,625.9	0.00	1.00
01/05/2023 03:00	0	1.6	15.7	14.6	20.6	678,843.2	0.00	1.00
01/05/2023 04:00	0	1.6	15.5	14.6	20.5	678,191.1	0.00	1.00
01/05/2023 05:00	0	1.6	15.9	14.6	21.1	673,843.7	0.00	1.00
01/05/2023 06:00	0	1.6	16.1	14.6	21.8	674,495.9	0.00	1.00
01/05/2023 07:00	0	1.6	16.2	14.6	22.0	674,713.2	0.00	1.00
01/05/2023 08:00	0	1.6	15.9	14.6	21.1	676,017.4	0.00	1.00
01/05/2023 09:00	0	1.6	15.9	14.6	21.3	674,930.6	0.00	1.00
01/05/2023 10:00	0	1.6	16.2	14.6	20.3	672,104.8	0.00	1.00
01/05/2023 11:00	1	1.6	16.6	14.6	21.9	673,626.4	0.00	1.00
01/05/2023 12:00	0	1.6	16.2	14.6	22.1	678,843.2	0.00	1.00
01/05/2023 13:00	0	1.6	16.3	14.6	22.6	680,582.2	0.00	1.00
01/05/2023 14:00	0	1.6	16.1	14.6	22.2	680,582.2	0.00	1.00
01/05/2023 15:00	0	1.5	9.5	14.4	8.6	905,716.2	0.00	1.00
01/05/2023 16:00	0	1.5	11.1	14.4	12.8	832,188.7	0.00	1.00
01/05/2023 17:00	0	1.8	11.9	13.8	17.4	1,080,688.0	0.00	1.00
01/05/2023 18:00	0	1.7	10.5	14.1	16.8	981,353.7	0.00	1.00
01/05/2023 19:00	0	1.4	13.8	14.5	19.2	744,624.5	0.00	1.00
01/05/2023 20:00	0	1.6	17.2	14.6	24.9	679,712.7	0.00	1.00
01/05/2023 21:00	0	1.6	17.3	14.6	25.1	681,669.0	0.00	1.00
01/05/2023 22:00	1	1.6	17.7	14.6	25.9	680,582.2	0.00	1.00
01/05/2023 23:00	0	1.6	18.1	14.6	26.1	680,147.4	0.00	1.00
Average/Sum#:	0	1.6	15.3	14.5	20.7	725,461.4	0.00 #	24.00 #
Minimum:	0	1.4	9.5	13.8	8.6	672,104.8	0.00	1.00
Maximum:	1	1.8	18.1	14.6	26.1	1,080,688.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2023 00:00	0	1.6	17.9	14.6	26.3	681,234.3	0.00	1.00
01/06/2023 01:00	0	1.6	17.9	14.6	26.0	679,930.1	0.00	1.00
01/06/2023 02:00	0	1.6	18.1	14.6	25.2	682,321.1	0.00	1.00
01/06/2023 03:00	0	1.6	17.6	14.6	25.2	684,277.5	0.00	1.00
01/06/2023 04:00	0	1.6	17.5	14.6	25.2	684,277.5	0.00	1.00
01/06/2023 05:00	0	1.6	17.5	14.6	25.2	683,190.6	0.00	1.00
01/06/2023 06:00	1	1.6	17.8	14.6	26.0	682,103.8	0.00	1.00
01/06/2023 07:00	0	1.6	18.0	14.6	26.2	680,582.2	0.00	1.00
01/06/2023 08:00	0	1.6	18.0	14.6	26.1	681,451.7	0.00	1.00
01/06/2023 09:00	0	1.6	17.7	14.6	25.6	680,799.6	0.00	1.00
01/06/2023 10:00	0	1.6	17.5	14.7	25.1	690,675.8	0.00	1.00
01/06/2023 11:00	0	1.6	17.3	14.7	24.7	689,571.4	0.00	1.00
01/06/2023 12:00	0	1.6	16.9	14.6	23.8	679,495.3	0.00	1.00
01/06/2023 13:00	0	1.6	16.6	14.6	23.1	679,495.3	0.00	1.00
01/06/2023 14:00	0	1.6	16.6	14.6	23.2	679,712.7	0.00	1.00
01/06/2023 15:00	0	1.5	13.6	14.6	15.6	799,700.4	0.00	1.00
01/06/2023 16:00	0	1.5	10.3	14.4	12.1	854,310.1	0.00	1.00
01/06/2023 17:00	0	1.7	8.9	14.3	12.4	1,048,439.6	0.00	1.00
01/06/2023 18:00	0	1.8	11.5	13.9	18.4	1,080,475.8	0.00	1.00
01/06/2023 19:00	0	1.8	11.5	13.9	18.7	1,080,280.2	0.00	1.00
01/06/2023 20:00	0	1.6	12.3	14.3	19.6	870,414.4	0.00	1.00
01/06/2023 21:00	0	1.4	14.7	14.5	20.5	734,781.8	0.00	1.00
01/06/2023 22:00	0	1.6	17.3	14.6	24.8	677,973.8	0.00	1.00
01/06/2023 23:00	0	1.6	17.3	14.6	24.6	680,147.4	0.00	1.00
Average/Sum#:	0	1.6	15.8	14.5	22.7	752,735.1	0.00 #	24.00 #
Minimum:	0	1.4	8.9	13.9	12.1	677,973.8	0.00	1.00
Maximum:	1	1.8	18.1	14.7	26.3	1,080,475.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2023 00:00	0	1.6	17.1	14.6	24.3	681,016.9	0.00	1.00
01/07/2023 01:00	0	1.6	17.2	14.6	24.5	681,451.7	0.00	1.00
01/07/2023 02:00	1	1.8	18.1	14.6	24.5	677,756.4	0.00	1.00
01/07/2023 03:00	0	1.6	18.0	14.6	26.0	676,886.9	0.00	1.00
01/07/2023 04:00	1	1.6	18.3	14.6	26.8	672,104.8	0.00	1.00
01/07/2023 05:00	0	1.6	17.9	14.6	25.2	673,191.6	0.00	1.00
01/07/2023 06:00	0	1.6	17.6	14.6	25.2	675,148.0	0.00	1.00
01/07/2023 07:00	0	1.6	17.1	14.6	23.7	678,625.9	0.00	1.00
01/07/2023 08:00	0	1.6	17.2	14.6	24.6	675,800.1	0.00	1.00
01/07/2023 09:00	0	1.6	17.7	14.6	24.9	671,887.4	0.00	1.00
01/07/2023 10:00	0	1.6	17.4	14.6	24.6	671,452.7	0.00	1.00
01/07/2023 11:00	0	1.6	16.8	14.7	23.1	683,828.7	0.00	1.00
01/07/2023 12:00	0	1.6	16.0	14.6	22.1	676,669.5	0.00	1.00
01/07/2023 13:00	0	1.6	16.3	14.6	22.9	675,148.0	0.00	1.00
01/07/2023 14:00	0	1.6	16.1	14.6	22.3	677,539.0	0.00	1.00
01/07/2023 15:00	0	1.6	16.1	14.6	22.4	675,148.0	0.00	1.00
01/07/2023 16:00	0	1.6	16.1	14.6	22.2	675,365.3	0.00	1.00
01/07/2023 17:00	0	1.6	16.3	14.6	23.1	674,061.1	0.00	1.00
01/07/2023 18:00	1	1.6	17.4	14.6	25.1	670,148.5	0.00	1.00
01/07/2023 19:00	1	1.6	18.0	14.6	26.2	667,322.7	0.00	1.00
01/07/2023 20:00	1	1.6	18.3	14.6	26.4	664,496.9	0.00	1.00
01/07/2023 21:00	0	1.6	18.0	14.7	25.4	674,331.1	0.00	1.00
01/07/2023 22:00	0	1.6	17.5	14.6	24.6	666,670.6	0.00	1.00
01/07/2023 23:00	0	1.6	17.4	14.6	24.6	665,801.1	0.00	1.00
Average/Sum#:	0	1.6	17.2	14.6	24.4	674,243.9	0.00 #	24.00 #
Minimum:	0	1.6	16.0	14.6	22.1	664,496.9	0.00	1.00
Maximum:	1	1.8	18.3	14.7	26.8	683,828.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2023 00:00	0	1.6	17.6	14.6	25.0	662,540.6	0.00	1.00
01/08/2023 01:00	0	1.6	17.8	14.6	25.3	666,235.8	0.00	1.00
01/08/2023 02:00	0	1.7	17.8	14.6	24.1	669,931.1	0.00	1.00
01/08/2023 03:00	1	1.6	17.7	14.6	25.5	669,496.4	0.00	1.00
01/08/2023 04:00	0	1.6	17.5	14.6	24.6	669,279.0	0.00	1.00
01/08/2023 05:00	0	1.6	17.4	14.6	24.6	670,365.8	0.00	1.00
01/08/2023 06:00	0	1.6	17.2	14.6	24.0	673,191.6	0.00	1.00
01/08/2023 07:00	0	1.6	16.9	14.6	23.6	679,930.1	0.00	1.00
01/08/2023 08:00	0	1.6	16.5	14.6	22.9	681,669.0	0.00	1.00
01/08/2023 09:00	0	1.6	16.3	14.6	22.6	682,321.1	0.00	1.00
01/08/2023 10:00	0	1.6	16.0	14.6	22.5	679,712.7	0.00	1.00
01/08/2023 11:00	0	1.6	16.3	14.6	22.8	673,626.4	0.00	1.00
01/08/2023 12:00	0	1.6	16.2	14.6	22.6	673,409.0	0.00	1.00
01/08/2023 13:00	0	1.6	15.9	14.6	21.8	674,061.1	0.00	1.00
01/08/2023 14:00	0	1.6	15.7	14.6	21.6	674,495.9	0.00	1.00
01/08/2023 15:00	0	1.4	13.1	14.6	15.1	791,440.3	0.00	1.00
01/08/2023 16:00	0	1.5	10.3	14.4	12.6	827,975.1	0.00	1.00
01/08/2023 17:00	0	1.6	9.8	14.1	10.0	979,742.6	0.00	1.00
01/08/2023 18:00	0	1.8	12.2	13.8	18.4	1,078,952.1	0.00	1.00
01/08/2023 19:00	0	1.8	12.0	13.8	18.8	1,067,572.4	0.00	1.00
01/08/2023 20:00	0	1.8	12.3	13.8	18.9	1,075,673.2	0.00	1.00
01/08/2023 21:00	0	1.7	10.7	14.1	17.0	975,916.3	0.00	1.00
01/08/2023 22:00	0	1.4	14.9	14.5	20.3	688,135.8	0.00	1.00
01/08/2023 23:00	0	1.6	16.0	14.6	22.1	671,235.3	0.00	1.00
Average/Sum#:	0	1.6	15.2	14.4	21.1	760,704.5	0.00 #	24.00 #
Minimum:	0	1.4	9.8	13.8	10.0	662,540.6	0.00	1.00
Maximum:	1	1.8	17.8	14.6	25.5	1,078,952.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2023 00:00	0	1.6	15.6	14.6	21.3	674,495.9	0.00	1.00
01/09/2023 01:00	0	1.6	15.7	14.6	21.6	672,756.9	0.00	1.00
01/09/2023 02:00	0	1.7	16.6	14.6	22.6	671,235.3	0.00	1.00
01/09/2023 03:00	1	1.6	16.5	14.6	22.0	668,626.9	0.00	1.00
01/09/2023 04:00	0	1.6	16.5	14.6	22.7	664,714.2	0.00	1.00
01/09/2023 05:00	0	1.6	16.2	14.6	21.8	665,801.1	0.00	1.00
01/09/2023 06:00	0	1.6	15.4	14.6	20.7	671,452.7	0.00	1.00
01/09/2023 07:00	0	1.6	15.3	14.6	20.6	672,539.5	0.00	1.00
01/09/2023 08:00	0	1.6	15.1	14.5	20.4	666,096.6	0.00	1.00
01/09/2023 09:00	0	1.6	14.8	14.5	19.6	667,594.4	0.00	1.00
01/09/2023 10:00	0	1.6	14.8	14.5	20.0	668,022.3	0.00	1.00
01/09/2023 11:00	0	1.6	14.5	14.5	19.1	671,017.9	0.00	1.00
01/09/2023 12:00	0	1.6	14.5	14.5	19.2	672,515.8	0.00	1.00
01/09/2023 13:00	0	1.5	12.2	14.5	13.5	784,209.4	0.00	1.00
01/09/2023 14:00	0	1.6	12.3	14.4	16.4	737,171.7	0.00	1.00
01/09/2023 15:00	0	1.5	9.1	14.2	9.6	1,025,024.4	0.00	1.00
01/09/2023 16:00	0	1.9	11.9	13.5	19.9	1,068,336.1	0.00	1.00
01/09/2023 17:00	0	1.9	11.9	13.5	20.9	1,073,517.7	0.00	1.00
01/09/2023 18:00	0	1.9	11.6	13.6	20.3	1,074,904.3	0.00	1.00
01/09/2023 19:00	0	1.9	11.6	13.6	20.1	1,072,090.5	0.00	1.00
01/09/2023 20:00	0	1.9	11.6	13.6	20.2	1,072,653.2	0.00	1.00
01/09/2023 21:00	0	1.6	9.7	14.2	15.2	947,355.5	0.00	1.00
01/09/2023 22:00	0	1.6	13.5	14.4	18.3	731,904.7	0.00	1.00
01/09/2023 23:00	0	1.6	16.4	14.5	22.9	666,524.5	0.00	1.00
Average/Sum#:	0	1.7	13.9	14.3	19.5	790,023.4	0.00 #	24.00 #
Minimum:	0	1.5	9.1	13.5	9.6	664,714.2	0.00	1.00
Maximum:	1	1.9	16.6	14.6	22.9	1,074,904.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2023 00:00	0	1.6	16.3	14.5	22.8	665,882.6	0.00	1.00
01/10/2023 01:00	0	1.6	16.2	14.6	22.4	676,234.8	0.00	1.00
01/10/2023 02:00	0	1.5	16.2	14.6	22.3	671,887.4	0.00	1.00
01/10/2023 03:00	1	1.7	15.7	14.6	20.4	671,887.4	0.00	1.00
01/10/2023 04:00	0	1.6	16.0	14.5	21.9	664,812.7	0.00	1.00
01/10/2023 05:00	0	1.6	16.0	14.6	22.3	674,930.6	0.00	1.00
01/10/2023 06:00	0	1.6	16.6	14.6	23.3	671,235.3	0.00	1.00
01/10/2023 07:00	0	1.6	16.9	14.6	24.0	669,061.6	0.00	1.00
01/10/2023 08:00	0	1.6	16.9	14.6	23.7	670,365.8	0.00	1.00
01/10/2023 09:00	0	1.6	17.0	14.6	24.0	668,626.9	0.00	1.00
01/10/2023 10:00	0	1.6	16.7	14.6	23.7	673,191.6	0.00	1.00
01/10/2023 11:00	0	1.6	16.5	14.6	22.9	675,800.1	0.00	1.00
01/10/2023 12:00	0	1.6	16.6	14.6	23.2	676,234.8	0.00	1.00
01/10/2023 13:00	0	1.6	16.6	14.6	23.3	677,539.0	0.00	1.00
01/10/2023 14:00	0	1.6	16.4	14.6	23.4	678,625.9	0.00	1.00
01/10/2023 15:00	0	1.4	13.9	14.5	16.5	781,427.8	0.00	1.00
01/10/2023 16:00	0	1.5	12.2	14.4	16.9	764,138.8	0.00	1.00
01/10/2023 17:00	0	1.7	9.8	14.0	12.2	1,040,365.6	0.00	1.00
01/10/2023 18:00	0	1.9	11.2	13.7	19.9	1,086,600.2	0.00	1.00
01/10/2023 19:00	0	1.8	11.3	13.7	20.6	1,087,170.8	0.00	1.00
01/10/2023 20:00	0	1.8	11.0	13.8	20.3	1,087,824.4	0.00	1.00
01/10/2023 21:00	0	1.8	10.5	14.0	19.7	1,094,348.7	0.00	1.00
01/10/2023 22:00	0	1.7	10.0	14.1	18.0	981,756.5	0.00	1.00
01/10/2023 23:00	1	1.4	15.5	14.5	23.6	719,803.7	0.00	1.00
Average/Sum#:	0	1.6	14.7	14.4	21.3	780,406.4	0.00 #	24.00 #
Minimum:	0	1.4	9.8	13.7	12.2	664,812.7	0.00	1.00
Maximum:	1	1.9	17.0	14.6	24.0	1,094,348.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2023 00:00	1	1.6	18.3	14.6	27.0	672,104.8	0.00	1.00
01/11/2023 01:00	0	1.6	17.7	14.6	25.6	676,452.2	0.00	1.00
01/11/2023 02:00	0	1.6	17.6	14.6	24.9	681,451.7	0.00	1.00
01/11/2023 03:00	1	1.6	17.8	14.6	25.5	677,756.4	0.00	1.00
01/11/2023 04:00	1	1.6	17.8	14.6	25.8	676,234.8	0.00	1.00
01/11/2023 05:00	1	1.6	17.7	14.6	25.8	676,886.9	0.00	1.00
01/11/2023 06:00	1	1.6	17.7	14.6	25.9	678,625.9	0.00	1.00
01/11/2023 07:00	1	1.6	17.7	14.6	26.0	677,321.6	0.00	1.00
01/11/2023 08:00	1	1.6	17.7	14.6	26.0	676,452.2	0.00	1.00
01/11/2023 09:00	0	1.6	17.4	14.6	25.2	678,408.5	0.00	1.00
01/11/2023 10:00	0	1.6	17.2	14.6	24.9	678,843.2	0.00	1.00
01/11/2023 11:00	0	1.6	17.1	14.6	24.8	678,625.9	0.00	1.00
01/11/2023 12:00	1	1.6	17.3	14.6	25.4	674,930.6	0.00	1.00
01/11/2023 13:00	1	1.6	17.7	14.6	26.0	669,931.1	0.00	1.00
01/11/2023 14:00	0	1.4	14.6	14.6	17.8	784,267.2	0.00	1.00
01/11/2023 15:00	0	1.6	11.8	14.4	16.7	792,370.0	0.00	1.00
01/11/2023 16:00	0	1.6	10.1	14.0	11.4	992,336.5	0.00	1.00
01/11/2023 17:00	0	1.8	10.9	13.8	19.4	1,096,118.1	0.00	1.00
01/11/2023 18:00	0	1.8	10.3	13.9	19.4	1,086,149.2	0.00	1.00
01/11/2023 19:00	0	1.8	10.0	14.0	19.2	1,093,356.4	0.00	1.00
01/11/2023 20:00	0	1.7	9.7	14.1	19.0	975,916.3	0.00	1.00
01/11/2023 21:00	0	1.4	12.6	14.5	18.0	795,977.9	0.00	1.00
01/11/2023 22:00	1	1.6	16.6	14.6	24.5	676,017.4	0.00	1.00
01/11/2023 23:00	1	1.6	16.5	14.6	24.2	676,886.9	0.00	1.00
Average/Sum#:	0	1.6	15.4	14.5	22.9	768,475.9	0.00 #	24.00 #
Minimum:	0	1.4	9.7	13.8	11.4	669,931.1	0.00	1.00
Maximum:	1	1.8	18.3	14.6	27.0	1,096,118.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2023 00:00	0	1.6	15.9	14.6	23.0	682,103.8	0.00	1.00
01/12/2023 01:00	0	1.6	15.9	14.6	22.9	683,408.0	0.00	1.00
01/12/2023 02:00	0	1.7	16.3	14.6	23.1	682,103.8	0.00	1.00
01/12/2023 03:00	1	1.6	16.4	14.6	23.6	681,886.4	0.00	1.00
01/12/2023 04:00	0	1.6	15.9	14.6	22.9	683,842.7	0.00	1.00
01/12/2023 05:00	0	1.6	15.7	14.6	22.5	684,277.5	0.00	1.00
01/12/2023 06:00	0	1.6	15.5	14.6	22.4	682,538.5	0.00	1.00
01/12/2023 07:00	1	1.6	16.0	14.6	23.7	679,712.7	0.00	1.00
01/12/2023 08:00	1	1.6	17.2	14.6	25.5	670,583.2	0.00	1.00
01/12/2023 09:00	0	1.6	16.7	14.6	24.1	672,974.3	0.00	1.00
01/12/2023 10:00	1	1.6	16.6	14.6	24.6	672,974.3	0.00	1.00
01/12/2023 11:00	0	1.6	16.3	14.6	23.4	672,104.8	0.00	1.00
01/12/2023 12:00	0	1.6	15.9	14.7	22.8	681,399.1	0.00	1.00
01/12/2023 13:00	0	1.6	15.8	14.7	22.8	679,852.9	0.00	1.00
01/12/2023 14:00	0	1.6	15.6	14.7	22.1	681,399.1	0.00	1.00
01/12/2023 15:00	0	1.5	12.9	14.6	15.3	763,182.4	0.00	1.00
01/12/2023 16:00	0	1.6	12.9	14.5	18.4	699,690.3	0.00	1.00
01/12/2023 17:00	0	1.7	11.4	14.1	13.9	937,854.3	0.00	1.00
01/12/2023 18:00	0	1.8	11.7	13.9	18.8	1,076,758.8	0.00	1.00
01/12/2023 19:00	0	1.8	11.8	13.9	19.6	1,076,171.9	0.00	1.00
01/12/2023 20:00	0	1.8	12.0	13.9	19.9	1,076,367.6	0.00	1.00
01/12/2023 21:00	0	1.7	11.3	14.2	20.4	965,750.8	0.00	1.00
01/12/2023 22:00	0	1.4	14.0	14.5	18.8	731,358.2	0.00	1.00
01/12/2023 23:00	1	1.6	15.9	14.6	23.4	677,104.3	0.00	1.00
Average/Sum#:	0	1.6	14.8	14.5	21.6	758,141.7	0.00 #	24.00 #
Minimum:	0	1.4	11.3	13.9	13.9	670,583.2	0.00	1.00
Maximum:	1	1.8	17.2	14.7	25.5	1,076,758.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2023 00:00	0	1.6	16.6	14.6	24.2	670,365.8	0.00	1.00
01/13/2023 01:00	1	1.6	16.5	14.6	24.2	670,583.2	0.00	1.00
01/13/2023 02:00	1	1.8	17.1	14.6	23.6	670,583.2	0.00	1.00
01/13/2023 03:00	1	1.6	16.9	14.6	24.3	671,017.9	0.00	1.00
01/13/2023 04:00	1	1.6	16.7	14.6	24.3	671,235.3	0.00	1.00
01/13/2023 05:00	1	1.6	16.8	14.6	24.5	670,800.6	0.00	1.00
01/13/2023 06:00	1	1.6	16.9	14.6	24.9	672,104.8	0.00	1.00
01/13/2023 07:00	1	1.6	17.0	14.6	25.1	673,191.6	0.00	1.00
01/13/2023 08:00	0	1.6	16.6	14.6	24.0	671,235.3	0.00	1.00
01/13/2023 09:00	0	1.6	16.5	14.7	24.3	680,957.3	0.00	1.00
01/13/2023 10:00	0	1.6	16.1	14.6	23.2	677,973.8	0.00	1.00
01/13/2023 11:00	1	1.6	16.1	14.6	23.5	676,886.9	0.00	1.00
01/13/2023 12:00	1	1.6	16.1	14.6	23.7	676,452.2	0.00	1.00
01/13/2023 13:00	1	1.6	16.4	14.6	24.2	674,061.1	0.00	1.00
01/13/2023 14:00	1	1.6	16.5	14.6	24.6	673,626.4	0.00	1.00
01/13/2023 15:00	1	1.6	16.3	14.6	23.8	673,409.0	0.00	1.00
01/13/2023 16:00	1	1.6	16.2	14.6	23.5	672,974.3	0.00	1.00
01/13/2023 17:00	1	1.6	16.0	14.6	23.6	673,409.0	0.00	1.00
01/13/2023 18:00	1	1.6	16.1	14.6	23.5	673,843.7	0.00	1.00
01/13/2023 19:00	0	1.6	15.8	14.6	23.2	676,886.9	0.00	1.00
01/13/2023 20:00	0	1.6	15.5	14.6	22.1	679,278.0	0.00	1.00
01/13/2023 21:00	0	1.6	15.2	14.6	22.2	680,364.8	0.00	1.00
01/13/2023 22:00	0	1.6	15.3	14.6	22.1	680,147.4	0.00	1.00
01/13/2023 23:00	0	1.6	15.6	14.6	22.9	678,625.9	0.00	1.00
Average/Sum#:	1	1.6	16.3	14.6	23.7	674,583.9	0.00 #	24.00 #
Minimum:	0	1.6	15.2	14.6	22.1	670,365.8	0.00	1.00
Maximum:	1	1.8	17.1	14.7	25.1	680,957.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2023 00:00	0	1.6	15.7	14.6	23.0	676,669.5	0.00	1.00
01/14/2023 01:00	0	1.6	15.9	14.6	23.2	675,582.7	0.00	1.00
01/14/2023 02:00	0	1.5	16.4	14.6	23.7	673,409.0	0.00	1.00
01/14/2023 03:00	0	1.6	16.3	14.6	23.5	670,800.6	0.00	1.00
01/14/2023 04:00	0	1.6	16.3	14.6	23.6	669,279.0	0.00	1.00
01/14/2023 05:00	0	1.6	16.1	14.6	23.3	668,844.3	0.00	1.00
01/14/2023 06:00	1	1.6	16.1	14.6	23.3	668,409.5	0.00	1.00
01/14/2023 07:00	1	1.6	16.2	14.6	23.6	665,801.1	0.00	1.00
01/14/2023 08:00	1	1.6	16.5	14.6	24.2	662,975.3	0.00	1.00
01/14/2023 09:00	0	1.4	13.5	14.6	16.3	776,007.2	0.00	1.00
01/14/2023 10:00	1	1.6	13.4	14.5	20.5	751,899.6	0.00	1.00
01/14/2023 11:00	0	1.6	15.1	14.6	21.5	674,930.6	0.00	1.00
01/14/2023 12:00	0	1.6	14.7	14.6	21.0	676,017.4	0.00	1.00
01/14/2023 13:00	0	1.6	14.6	14.6	20.5	678,408.5	0.00	1.00
01/14/2023 14:00	0	1.4	10.5	14.5	12.0	834,920.9	0.00	1.00
01/14/2023 15:00	1	1.6	13.1	14.5	21.1	733,070.0	0.00	1.00
01/14/2023 16:00	0	1.6	10.7	14.0	12.0	969,909.7	0.00	1.00
01/14/2023 17:00	0	1.8	10.8	13.9	19.7	1,079,497.7	0.00	1.00
01/14/2023 18:00	0	1.8	11.0	13.8	20.2	1,072,587.2	0.00	1.00
01/14/2023 19:00	0	1.7	10.0	14.1	18.6	997,061.8	0.00	1.00
01/14/2023 20:00	1	1.4	14.1	14.5	21.9	722,157.4	0.00	1.00
01/14/2023 21:00	1	1.6	16.5	14.6	24.3	676,017.4	0.00	1.00
01/14/2023 22:00	1	1.6	16.5	14.6	24.3	676,669.5	0.00	1.00
01/14/2023 23:00	1	1.6	16.5	14.6	24.4	676,234.8	0.00	1.00
Average/Sum#:	0	1.6	14.4	14.5	21.2	751,131.7	0.00 #	24.00 #
Minimum:	0	1.4	10.0	13.8	12.0	662,975.3	0.00	1.00
Maximum:	1	1.8	16.5	14.6	24.4	1,079,497.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2023 00:00	1	1.6	16.4	14.6	24.2	677,539.0	0.00	1.00
01/15/2023 01:00	1	1.6	16.6	14.6	24.6	678,625.9	0.00	1.00
01/15/2023 02:00	1	1.7	17.2	14.6	24.3	677,104.3	0.00	1.00
01/15/2023 03:00	1	1.6	17.2	14.6	25.4	675,582.7	0.00	1.00
01/15/2023 04:00	1	1.6	17.1	14.6	25.2	675,800.1	0.00	1.00
01/15/2023 05:00	1	1.6	17.0	14.6	25.0	676,886.9	0.00	1.00
01/15/2023 06:00	1	1.6	17.0	14.6	25.0	675,365.3	0.00	1.00
01/15/2023 07:00	1	1.6	16.9	14.6	25.0	675,800.1	0.00	1.00
01/15/2023 08:00	1	1.6	16.7	14.6	24.5	676,017.4	0.00	1.00
01/15/2023 09:00	1	1.6	16.6	14.6	24.4	676,886.9	0.00	1.00
01/15/2023 10:00	1	1.6	16.6	14.6	24.4	675,582.7	0.00	1.00
01/15/2023 11:00	1	1.6	16.4	14.6	23.8	673,626.4	0.00	1.00
01/15/2023 12:00	1	1.6	16.6	14.6	24.3	672,974.3	0.00	1.00
01/15/2023 13:00	1	1.6	16.3	14.6	23.6	675,800.1	0.00	1.00
01/15/2023 14:00	0	1.5	12.1	14.5	14.9	850,327.0	0.00	1.00
01/15/2023 15:00	0	1.6	11.2	14.4	17.5	784,364.2	0.00	1.00
01/15/2023 16:00	0	1.5	8.8	14.4	12.5	1,056,142.2	0.00	1.00
01/15/2023 17:00	0	1.9	11.7	13.7	20.7	1,080,894.3	0.00	1.00
01/15/2023 18:00	0	1.9	11.4	13.7	21.4	1,080,704.1	0.00	1.00
01/15/2023 19:00	0	1.8	10.9	13.8	20.8	1,071,815.7	0.00	1.00
01/15/2023 20:00	0	1.8	10.9	13.8	21.1	1,077,409.1	0.00	1.00
01/15/2023 21:00	0	1.6	11.2	14.3	19.4	892,615.7	0.00	1.00
01/15/2023 22:00	1	1.4	14.2	14.5	21.4	754,895.2	0.00	1.00
01/15/2023 23:00	1	1.6	16.9	14.6	25.2	678,625.9	0.00	1.00
Average/Sum#:	1	1.6	14.7	14.4	22.4	782,974.4	0.00 #	24.00 #
Minimum:	0	1.4	8.8	13.7	12.5	672,974.3	0.00	1.00
Maximum:	1	1.9	17.2	14.6	25.4	1,080,894.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2023 00:00	1	1.6	16.8	14.6	24.8	678,408.5	0.00	1.00
01/16/2023 01:00	1	1.6	16.8	14.6	25.1	679,060.6	0.00	1.00
01/16/2023 02:00	0	1.5	17.6	14.6	26.1	677,321.6	0.00	1.00
01/16/2023 03:00	0	1.6	17.6	14.6	26.1	675,148.0	0.00	1.00
01/16/2023 04:00	1	1.6	17.6	14.6	25.9	673,843.7	0.00	1.00
01/16/2023 05:00	1	1.6	17.4	14.6	25.6	673,843.7	0.00	1.00
01/16/2023 06:00	1	1.6	17.4	14.5	25.7	663,101.0	0.00	1.00
01/16/2023 07:00	1	1.6	17.3	14.6	25.6	674,930.6	0.00	1.00
01/16/2023 08:00	1	1.6	17.1	14.6	25.0	676,452.2	0.00	1.00
01/16/2023 09:00	1	1.6	17.0	14.6	24.9	679,278.0	0.00	1.00
01/16/2023 10:00	1	1.6	16.9	14.6	25.1	680,364.8	0.00	1.00
01/16/2023 11:00	1	1.6	16.8	14.6	24.5	678,625.9	0.00	1.00
01/16/2023 12:00	1	1.6	17.0	14.6	25.4	678,408.5	0.00	1.00
01/16/2023 13:00	1	1.6	18.0	14.6	26.9	669,279.0	0.00	1.00
01/16/2023 14:00	0	1.5	16.3	14.6	22.1	713,187.5	0.00	1.00
01/16/2023 15:00	1	1.6	13.1	14.5	20.4	774,152.7	0.00	1.00
01/16/2023 16:00	0	1.5	13.5	14.4	16.8	857,681.0	0.00	1.00
01/16/2023 17:00	0	1.8	12.2	13.9	19.1	1,084,192.8	0.00	1.00
01/16/2023 18:00	0	1.8	12.0	13.9	20.3	1,082,823.4	0.00	1.00
01/16/2023 19:00	0	1.8	11.9	13.9	20.7	1,083,019.1	0.00	1.00
01/16/2023 20:00	0	1.8	11.8	13.9	20.9	1,081,845.3	0.00	1.00
01/16/2023 21:00	0	1.8	11.8	14.0	21.1	1,094,745.6	0.00	1.00
01/16/2023 22:00	1	1.6	12.0	14.3	21.3	916,476.9	0.00	1.00
01/16/2023 23:00	1	1.4	15.3	14.5	22.9	726,008.9	0.00	1.00
Average/Sum#:	1	1.6	15.5	14.4	23.4	786,341.6	0.00 #	24.00 #
Minimum:	0	1.4	11.8	13.9	16.8	663,101.0	0.00	1.00
Maximum:	1	1.8	18.0	14.6	26.9	1,094,745.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2023 00:00	1	1.6	17.6	14.6	26.8	678,625.9	0.00	1.00
01/17/2023 01:00	1	1.6	17.5	14.6	26.4	678,625.9	0.00	1.00
01/17/2023 02:00	1	1.7	18.0	14.6	25.9	680,147.4	0.00	1.00
01/17/2023 03:00	1	1.6	18.0	14.6	26.8	680,799.6	0.00	1.00
01/17/2023 04:00	1	1.6	18.0	14.6	27.3	681,669.0	0.00	1.00
01/17/2023 05:00	1	1.6	18.2	14.6	28.0	681,234.3	0.00	1.00
01/17/2023 06:00	1	1.6	18.0	14.6	26.1	697,102.2	0.00	1.00
01/17/2023 07:00	1	1.5	16.5	14.5	26.0	711,030.8	0.00	1.00
01/17/2023 08:00	1	1.6	18.5	14.6	28.3	681,451.7	0.00	1.00
01/17/2023 09:00	1	1.6	18.5	14.6	28.3	680,364.8	0.00	1.00
01/17/2023 10:00	1	1.6	18.0	14.6	27.5	680,799.6	0.00	1.00
01/17/2023 11:00	1	1.6	17.5	14.6	26.1	681,451.7	0.00	1.00
01/17/2023 12:00	1	1.6	17.1	14.6	25.4	681,016.9	0.00	1.00
01/17/2023 13:00	1	1.6	16.7	14.6	24.6	682,755.9	0.00	1.00
01/17/2023 14:00	1	1.6	16.5	14.6	24.5	681,451.7	0.00	1.00
01/17/2023 15:00	1	1.6	16.5	14.6	24.3	681,234.3	0.00	1.00
01/17/2023 16:00	0	1.5	13.8	14.6	18.0	798,830.9	0.00	1.00
01/17/2023 17:00	0	1.6	12.1	14.4	19.0	799,111.8	0.00	1.00
01/17/2023 18:00	0	1.6	11.9	14.2	16.3	969,225.4	0.00	1.00
01/17/2023 19:00	0	1.8	11.2	14.0	19.8	1,086,013.1	0.00	1.00
01/17/2023 20:00	0	1.8	11.1	14.1	20.5	1,101,782.5	0.00	1.00
01/17/2023 21:00	0	1.7	11.1	14.1	20.8	1,102,386.6	0.00	1.00
01/17/2023 22:00	0	1.7	11.1	14.1	21.0	1,101,581.1	0.00	1.00
01/17/2023 23:00	0	1.7	11.0	14.1	21.2	1,097,956.1	0.00	1.00
Average/Sum#:	1	1.6	15.6	14.5	24.1	791,527.1	0.00 #	24.00 #
Minimum:	0	1.5	11.0	14.0	16.3	678,625.9	0.00	1.00
Maximum:	1	1.8	18.5	14.6	28.3	1,102,386.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2023 00:00	0	1.7	11.2	14.1	21.4	1,106,414.3	0.00	1.00
01/18/2023 01:00	0	1.7	11.3	14.0	21.5	1,093,951.8	0.00	1.00
01/18/2023 02:00	0	1.7	11.6	14.1	21.7	1,108,629.6	0.00	1.00
01/18/2023 03:00	0	1.8	11.5	14.1	21.6	1,108,831.0	0.00	1.00
01/18/2023 04:00	0	1.7	11.3	14.1	21.7	1,105,810.2	0.00	1.00
01/18/2023 05:00	0	1.7	11.2	14.1	21.9	1,103,796.3	0.00	1.00
01/18/2023 06:00	0	1.7	11.5	14.1	22.1	1,114,067.0	0.00	1.00
01/18/2023 07:00	0	1.7	10.9	14.2	21.7	1,112,708.4	0.00	1.00
01/18/2023 08:00	0	1.7	10.6	14.3	20.8	1,011,299.2	0.00	1.00
01/18/2023 09:00	1	1.4	16.3	14.6	25.6	741,445.5	0.00	1.00
01/18/2023 10:00	1	1.6	18.7	14.7	28.5	683,166.1	0.00	1.00
01/18/2023 11:00	1	1.6	18.1	14.7	27.7	684,049.6	0.00	1.00
01/18/2023 12:00	1	1.6	17.7	14.7	27.0	684,491.3	0.00	1.00
01/18/2023 13:00	1	1.6	17.5	14.7	26.0	683,607.8	0.00	1.00
01/18/2023 14:00	1	1.6	17.4	14.7	26.1	683,386.9	0.00	1.00
01/18/2023 15:00	1	1.6	17.3	14.7	26.2	685,153.9	0.00	1.00
01/18/2023 16:00	1	1.6	17.6	14.6	26.6	672,322.2	0.00	1.00
01/18/2023 17:00	1	1.6	17.7	14.7	27.0	681,399.1	0.00	1.00
01/18/2023 18:00	1	1.6	17.7	14.7	27.3	681,619.9	0.00	1.00
01/18/2023 19:00	1	1.6	17.6	14.6	26.7	671,017.9	0.00	1.00
01/18/2023 20:00	1	1.6	18.1	14.7	27.6	680,957.3	0.00	1.00
01/18/2023 21:00	1	1.6	18.2	14.7	27.6	681,178.2	0.00	1.00
01/18/2023 22:00	1	1.6	18.5	14.7	28.3	681,840.8	0.00	1.00
01/18/2023 23:00	1	1.6	18.2	14.7	27.6	684,049.6	0.00	1.00
Average/Sum#:	1	1.6	15.3	14.5	25.0	839,383.1	0.00 #	24.00 #
Minimum:	0	1.4	10.6	14.0	20.8	671,017.9	0.00	1.00
Maximum:	1	1.8	18.7	14.7	28.5	1,114,067.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2023 00:00	1	1.6	18.5	14.7	28.1	682,724.3	0.00	1.00
01/19/2023 01:00	1	1.6	18.1	14.6	27.4	673,626.4	0.00	1.00
01/19/2023 02:00	1	1.7	18.8	14.7	27.5	684,491.3	0.00	1.00
01/19/2023 03:00	1	1.6	18.9	14.7	29.1	684,270.4	0.00	1.00
01/19/2023 04:00	1	1.6	19.5	14.7	30.6	684,049.6	0.00	1.00
01/19/2023 05:00	1	1.6	19.5	14.7	30.5	684,491.3	0.00	1.00
01/19/2023 06:00	1	1.6	19.5	14.7	30.4	684,933.1	0.00	1.00
01/19/2023 07:00	1	1.6	19.4	14.7	30.2	685,153.9	0.00	1.00
01/19/2023 08:00	1	1.6	18.9	14.7	23.7	686,700.1	0.00	1.00
01/19/2023 09:00	3	1.1	18.5	14.7	32.6	686,700.1	0.00	1.00
01/19/2023 10:00	0	1.4	19.3	14.7	27.5	685,374.8	0.00	1.00
01/19/2023 11:00	0	0.6	19.2	14.7	42.2	686,479.2	0.00	1.00
01/19/2023 12:00	0	1.6	19.0	14.7	21.9	683,166.1	0.00	1.00
01/19/2023 13:00	0	1.5	18.6	14.7	28.8	684,491.3	0.00	1.00
01/19/2023 14:00	1	1.6	19.0	14.7	28.8	682,061.7	0.00	1.00
01/19/2023 15:00	1	1.6	18.8	14.7	29.0	683,386.9	0.00	1.00
01/19/2023 16:00	1	1.6	19.0	14.7	29.0	683,386.9	0.00	1.00
01/19/2023 17:00	0	1.5	12.0	14.5	12.9	920,082.0	0.00	1.00
01/19/2023 18:00	0	1.7	8.7	14.3	15.4	1,052,381.9	0.00	1.00
01/19/2023 19:00	0	1.7	8.8	14.2	16.8	1,036,265.9	0.00	1.00
01/19/2023 20:00	0	1.7	8.9	14.2	17.7	1,036,879.1	0.00	1.00
01/19/2023 21:00	0	1.7	9.0	14.2	17.8	1,038,105.4	0.00	1.00
01/19/2023 22:00	0	1.7	9.1	14.2	18.2	1,037,901.0	0.00	1.00
01/19/2023 23:00	0	1.7	9.1	14.2	18.5	1,045,463.5	0.00	1.00
Average/Sum#:	1	1.6	16.2	14.6	25.6	783,023.6	0.00 #	24.00 #
Minimum:	0	0.6	8.7	14.2	12.9	673,626.4	0.00	1.00
Maximum:	3	1.7	19.5	14.7	42.2	1,052,381.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2023 00:00	0	1.7	9.2	14.2	18.6	1,045,667.9	0.00	1.00
01/20/2023 01:00	0	1.7	9.2	14.2	18.7	1,046,894.3	0.00	1.00
01/20/2023 02:00	0	1.9	9.4	14.2	17.6	1,048,325.0	0.00	1.00
01/20/2023 03:00	0	1.7	9.4	14.2	18.8	1,044,441.6	0.00	1.00
01/20/2023 04:00	0	1.7	9.4	14.2	18.8	1,047,507.5	0.00	1.00
01/20/2023 05:00	0	1.7	9.4	14.2	18.9	1,046,485.5	0.00	1.00
01/20/2023 06:00	0	1.7	9.4	14.2	19.0	1,045,054.8	0.00	1.00
01/20/2023 07:00	0	1.7	9.4	14.2	19.0	1,048,120.6	0.00	1.00
01/20/2023 08:00	0	1.7	9.5	14.2	18.9	1,046,076.7	0.00	1.00
01/20/2023 09:00	0	1.7	9.3	14.2	18.9	1,044,032.8	0.00	1.00
01/20/2023 10:00	0	1.7	9.2	14.3	18.9	1,060,266.5	0.00	1.00
01/20/2023 11:00	0	1.7	9.0	14.3	18.1	1,036,405.3	0.00	1.00
01/20/2023 12:00	1	1.6	15.2	14.5	25.8	742,698.8	0.00	1.00
01/20/2023 13:00	1	1.6	18.7	14.6	28.7	676,886.9	0.00	1.00
01/20/2023 14:00	1	1.6	18.4	14.7	28.2	688,025.3	0.00	1.00
01/20/2023 15:00	1	1.6	18.0	14.6	27.4	678,191.1	0.00	1.00
01/20/2023 16:00	1	1.6	18.0	14.6	27.5	677,756.4	0.00	1.00
01/20/2023 17:00	0	1.5	11.9	14.4	14.6	899,606.5	0.00	1.00
01/20/2023 18:00	0	1.7	9.0	14.3	16.2	1,052,589.4	0.00	1.00
01/20/2023 19:00	0	1.7	9.0	14.2	17.6	1,035,039.6	0.00	1.00
01/20/2023 20:00	0	1.7	9.0	14.2	18.2	1,041,784.5	0.00	1.00
01/20/2023 21:00	0	1.7	9.2	14.2	18.4	1,041,580.1	0.00	1.00
01/20/2023 22:00	0	1.7	9.1	14.2	18.3	1,041,784.5	0.00	1.00
01/20/2023 23:00	0	1.7	9.1	14.2	18.2	1,041,171.3	0.00	1.00
Average/Sum#:	0	1.7	11.1	14.3	20.1	965,683.0	0.00 #	24.00 #
Minimum:	0	1.5	9.0	14.2	14.6	676,886.9	0.00	1.00
Maximum:	1	1.9	18.7	14.7	28.7	1,060,266.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2023 00:00	0	1.7	8.9	14.3	18.2	1,066,491.1	0.00	1.00
01/21/2023 01:00	0	1.7	8.8	14.4	18.2	1,085,637.5	0.00	1.00
01/21/2023 02:00	0	1.7	9.3	14.4	18.3	1,085,426.8	0.00	1.00
01/21/2023 03:00	0	1.7	9.3	14.4	18.3	1,086,901.6	0.00	1.00
01/21/2023 04:00	0	1.7	9.1	14.4	18.2	1,085,848.2	0.00	1.00
01/21/2023 05:00	0	1.7	8.9	14.4	18.0	1,087,744.3	0.00	1.00
01/21/2023 06:00	0	1.7	9.1	14.4	18.4	1,085,848.2	0.00	1.00
01/21/2023 07:00	0	1.7	9.1	14.4	18.4	1,090,061.8	0.00	1.00
01/21/2023 08:00	0	1.7	9.0	14.4	17.4	1,068,151.0	0.00	1.00
01/21/2023 09:00	1	1.6	17.4	14.6	30.8	747,531.8	0.00	1.00
01/21/2023 10:00	1	1.6	20.0	14.7	31.9	688,467.1	0.00	1.00
01/21/2023 11:00	1	1.6	19.6	14.7	30.5	688,025.3	0.00	1.00
01/21/2023 12:00	1	1.6	18.9	14.7	28.9	688,687.9	0.00	1.00
01/21/2023 13:00	1	1.6	18.8	14.7	28.5	688,025.3	0.00	1.00
01/21/2023 14:00	1	1.6	18.4	14.7	27.9	687,804.4	0.00	1.00
01/21/2023 15:00	1	1.6	18.2	14.6	27.8	676,234.8	0.00	1.00
01/21/2023 16:00	0	1.5	11.7	14.5	13.2	919,654.1	0.00	1.00
01/21/2023 17:00	0	1.7	9.1	14.5	17.0	1,112,443.3	0.00	1.00
01/21/2023 18:00	0	1.6	8.8	14.5	17.2	1,112,015.4	0.00	1.00
01/21/2023 19:00	0	1.6	8.6	14.5	17.3	1,114,369.1	0.00	1.00
01/21/2023 20:00	0	1.6	8.7	14.4	17.7	1,097,857.0	0.00	1.00
01/21/2023 21:00	0	1.7	9.4	14.2	19.6	1,075,713.5	0.00	1.00
01/21/2023 22:00	1	1.7	11.1	14.3	22.1	949,467.6	0.00	1.00
01/21/2023 23:00	1	1.6	19.3	14.6	30.6	678,625.9	0.00	1.00
Average/Sum#:	0	1.6	12.5	14.5	21.9	944,459.7	0.00 #	24.00 #
Minimum:	0	1.5	8.6	14.2	13.2	676,234.8	0.00	1.00
Maximum:	1	1.7	20.0	14.7	31.9	1,114,369.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2023 00:00	1	1.6	19.3	14.6	30.5	679,930.1	0.00	1.00
01/22/2023 01:00	1	1.6	19.3	14.6	30.3	680,799.6	0.00	1.00
01/22/2023 02:00	1	1.7	20.1	14.6	30.4	681,886.4	0.00	1.00
01/22/2023 03:00	0	1.6	19.9	14.6	31.6	681,451.7	0.00	1.00
01/22/2023 04:00	1	1.6	19.3	14.6	29.8	682,538.5	0.00	1.00
01/22/2023 05:00	1	1.6	19.1	14.6	29.3	683,190.6	0.00	1.00
01/22/2023 06:00	1	1.6	19.0	14.6	29.2	682,755.9	0.00	1.00
01/22/2023 07:00	1	1.6	19.8	14.7	31.8	690,013.2	0.00	1.00
01/22/2023 08:00	1	1.6	20.2	14.7	32.2	684,933.1	0.00	1.00
01/22/2023 09:00	1	1.6	20.0	14.7	31.3	684,491.3	0.00	1.00
01/22/2023 10:00	1	1.6	20.4	14.7	32.4	680,957.3	0.00	1.00
01/22/2023 11:00	1	1.6	20.0	14.7	31.1	678,527.7	0.00	1.00
01/22/2023 12:00	1	1.6	20.2	14.7	31.2	673,005.8	0.00	1.00
01/22/2023 13:00	1	1.6	19.9	14.7	30.5	672,564.1	0.00	1.00
01/22/2023 14:00	1	1.6	19.6	14.7	29.8	672,343.2	0.00	1.00
01/22/2023 15:00	1	1.6	19.5	14.7	29.7	671,901.4	0.00	1.00
01/22/2023 16:00	0	1.5	12.3	14.5	14.0	904,676.0	0.00	1.00
01/22/2023 17:00	0	1.7	9.9	14.2	18.3	1,085,728.7	0.00	1.00
01/22/2023 18:00	0	1.7	9.9	14.2	19.6	1,091,860.5	0.00	1.00
01/22/2023 19:00	0	1.7	10.0	14.2	20.5	1,095,743.9	0.00	1.00
01/22/2023 20:00	0	1.7	10.3	14.1	21.0	1,085,873.0	0.00	1.00
01/22/2023 21:00	0	1.7	10.1	14.2	20.7	1,093,495.6	0.00	1.00
01/22/2023 22:00	0	1.7	10.0	14.2	20.6	1,083,071.6	0.00	1.00
01/22/2023 23:00	0	1.7	10.0	14.2	20.3	1,072,647.6	0.00	1.00
Average/Sum#:	1	1.6	16.6	14.5	26.9	808,099.5	0.00 #	24.00 #
Minimum:	0	1.5	9.9	14.1	14.0	671,901.4	0.00	1.00
Maximum:	1	1.7	20.4	14.7	32.4	1,095,743.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2023 00:00	0	1.7	9.9	14.2	20.1	1,073,260.8	0.00	1.00
01/23/2023 01:00	0	1.7	10.0	14.2	20.8	1,082,662.8	0.00	1.00
01/23/2023 02:00	0	1.7	10.3	14.2	20.9	1,084,911.1	0.00	1.00
01/23/2023 03:00	0	1.7	10.1	14.2	20.9	1,081,845.3	0.00	1.00
01/23/2023 04:00	0	1.7	10.0	14.2	20.9	1,085,933.1	0.00	1.00
01/23/2023 05:00	0	1.7	10.0	14.2	20.8	1,080,414.5	0.00	1.00
01/23/2023 06:00	0	1.7	10.6	14.1	21.7	1,094,532.6	0.00	1.00
01/23/2023 07:00	0	1.8	10.8	14.0	21.4	1,096,928.8	0.00	1.00
01/23/2023 08:00	0	1.7	9.5	14.3	19.5	1,081,637.8	0.00	1.00
01/23/2023 09:00	1	1.6	16.5	14.6	29.1	765,138.7	0.00	1.00
01/23/2023 10:00	1	1.6	20.0	14.7	31.1	675,435.4	0.00	1.00
01/23/2023 11:00	1	1.6	19.9	14.7	30.7	673,447.6	0.00	1.00
01/23/2023 12:00	1	1.6	19.5	14.7	29.5	673,005.8	0.00	1.00
01/23/2023 13:00	1	1.6	18.9	14.7	28.5	672,564.1	0.00	1.00
01/23/2023 14:00	1	1.6	18.8	14.7	28.1	672,122.3	0.00	1.00
01/23/2023 15:00	1	1.6	18.1	14.7	26.4	794,928.8	0.00	1.00
01/23/2023 16:00	0	1.4	10.5	14.4	9.6	870,743.2	0.00	1.00
01/23/2023 17:00	0	1.5	8.8	14.3	13.6	951,127.5	0.00	1.00
01/23/2023 18:00	0	1.8	11.4	13.7	22.5	1,092,876.7	0.00	1.00
01/23/2023 19:00	0	2.0	13.6	13.2	26.2	1,104,076.2	0.00	1.00
01/23/2023 20:00	0	1.9	12.8	13.3	25.4	1,098,782.9	0.00	1.00
01/23/2023 21:00	0	1.9	12.2	13.5	25.2	1,101,831.5	0.00	1.00
01/23/2023 22:00	0	1.9	12.2	13.5	24.3	1,103,867.1	0.00	1.00
01/23/2023 23:00	0	1.8	10.9	13.9	22.6	1,101,017.2	0.00	1.00
Average/Sum#:	0	1.7	13.1	14.2	23.3	963,045.5	0.00 #	24.00 #
Minimum:	0	1.4	8.8	13.2	9.6	672,122.3	0.00	1.00
Maximum:	1	2.0	20.0	14.7	31.1	1,104,076.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2023 00:00	0	1.7	8.8	14.4	18.2	1,094,275.4	0.00	1.00
01/24/2023 01:00	0	1.7	8.8	14.4	18.2	1,095,960.9	0.00	1.00
01/24/2023 02:00	0	1.7	8.8	14.4	17.8	1,091,536.6	0.00	1.00
01/24/2023 03:00	0	1.7	8.9	14.4	18.2	1,092,168.6	0.00	1.00
01/24/2023 04:00	0	1.7	8.9	14.4	18.1	1,092,590.0	0.00	1.00
01/24/2023 05:00	0	1.8	11.7	13.8	24.1	1,097,275.4	0.00	1.00
01/24/2023 06:00	0	2.0	14.0	13.1	28.5	1,118,714.4	0.00	1.00
01/24/2023 07:00	0	1.8	10.6	14.1	22.1	1,102,990.8	0.00	1.00
01/24/2023 08:00	0	1.7	10.1	14.2	22.0	1,102,897.6	0.00	1.00
01/24/2023 09:00	1	1.7	13.5	14.4	26.8	887,176.3	0.00	1.00
01/24/2023 10:00	1	1.3	16.0	14.6	25.0	740,576.0	0.00	1.00
01/24/2023 11:00	1	1.5	17.5	14.6	27.7	679,495.3	0.00	1.00
01/24/2023 12:00	1	1.5	16.7	14.6	26.4	679,712.7	0.00	1.00
01/24/2023 13:00	1	1.5	16.6	14.7	26.3	688,246.2	0.00	1.00
01/24/2023 14:00	0	1.6	16.2	14.6	23.9	678,191.1	0.00	1.00
01/24/2023 15:00	1	1.6	15.9	14.6	24.5	679,930.1	0.00	1.00
01/24/2023 16:00	1	1.6	16.3	14.6	24.9	677,104.3	0.00	1.00
01/24/2023 17:00	1	1.6	15.8	14.6	23.9	684,494.8	0.00	1.00
01/24/2023 18:00	0	1.5	10.6	14.5	13.5	925,431.3	0.00	1.00
01/24/2023 19:00	1	1.6	13.3	14.5	23.2	763,240.1	0.00	1.00
01/24/2023 20:00	1	1.6	16.6	14.6	26.0	684,494.8	0.00	1.00
01/24/2023 21:00	1	1.6	16.9	14.6	26.5	685,364.3	0.00	1.00
01/24/2023 22:00	1	1.6	17.1	14.6	26.8	686,016.4	0.00	1.00
01/24/2023 23:00	1	1.6	17.4	14.6	27.5	686,451.1	0.00	1.00
Average/Sum#:	1	1.6	13.6	14.4	23.3	863,097.3	0.00 #	24.00 #
Minimum:	0	1.3	8.8	13.1	13.5	677,104.3	0.00	1.00
Maximum:	1	2.0	17.5	14.7	28.5	1,118,714.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2023 00:00	1	1.6	17.8	14.6	28.8	685,146.9	0.00	1.00
01/25/2023 01:00	1	1.6	18.8	14.7	30.3	690,454.9	0.00	1.00
01/25/2023 02:00	0	1.4	19.4	14.7	31.6	689,571.4	0.00	1.00
01/25/2023 03:00	1	1.6	19.3	14.7	30.6	689,350.6	0.00	1.00
01/25/2023 04:00	1	1.6	19.6	14.7	31.8	688,467.1	0.00	1.00
01/25/2023 05:00	1	1.6	19.8	14.7	32.1	688,687.9	0.00	1.00
01/25/2023 06:00	1	1.6	18.2	14.6	29.3	692,537.5	0.00	1.00
01/25/2023 07:00	1	1.6	18.5	14.6	29.2	686,668.5	0.00	1.00
01/25/2023 08:00	1	1.6	17.9	14.6	28.5	694,711.2	0.00	1.00
01/25/2023 09:00	1	1.6	17.6	14.6	27.8	691,015.9	0.00	1.00
01/25/2023 10:00	1	1.6	17.1	14.6	26.5	687,972.7	0.00	1.00
01/25/2023 11:00	1	1.6	17.5	14.6	27.8	679,278.0	0.00	1.00
01/25/2023 12:00	1	1.6	17.1	14.6	26.2	674,713.2	0.00	1.00
01/25/2023 13:00	1	1.6	15.7	14.6	22.9	681,451.7	0.00	1.00
01/25/2023 14:00	0	1.6	15.9	14.7	23.7	684,049.6	0.00	1.00
01/25/2023 15:00	1	1.6	15.6	14.7	23.6	683,828.7	0.00	1.00
01/25/2023 16:00	0	1.6	15.6	14.7	23.1	685,595.7	0.00	1.00
01/25/2023 17:00	0	1.6	15.2	14.6	22.9	681,669.0	0.00	1.00
01/25/2023 18:00	1	1.6	16.1	14.7	24.7	688,467.1	0.00	1.00
01/25/2023 19:00	1	1.6	16.5	14.7	25.6	687,141.8	0.00	1.00
01/25/2023 20:00	1	1.6	17.0	14.7	26.6	687,583.6	0.00	1.00
01/25/2023 21:00	1	1.6	17.4	14.7	27.6	688,246.2	0.00	1.00
01/25/2023 22:00	1	1.6	17.8	14.7	28.8	688,467.1	0.00	1.00
01/25/2023 23:00	1	1.6	17.6	14.6	27.3	679,712.7	0.00	1.00
Average/Sum#:	1	1.6	17.5	14.7	27.4	686,449.5	0.00 #	24.00 #
Minimum:	0	1.4	15.2	14.6	22.9	674,713.2	0.00	1.00
Maximum:	1	1.6	19.8	14.7	32.1	694,711.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2023 00:00	1	1.6	16.7	14.6	26.0	686,233.8	0.00	1.00
01/26/2023 01:00	1	1.6	18.0	14.6	29.4	679,930.1	0.00	1.00
01/26/2023 02:00	1	1.9	19.1	14.7	28.5	688,025.3	0.00	1.00
01/26/2023 03:00	1	1.6	18.0	14.6	28.1	686,668.5	0.00	1.00
01/26/2023 04:00	1	1.6	17.7	14.6	28.2	688,407.5	0.00	1.00
01/26/2023 05:00	1	1.6	18.3	14.6	29.8	686,451.1	0.00	1.00
01/26/2023 06:00	1	1.6	19.1	14.7	31.2	691,117.6	0.00	1.00
01/26/2023 07:00	1	1.6	18.4	14.6	30.3	686,451.1	0.00	1.00
01/26/2023 08:00	1	1.6	19.2	14.7	32.0	689,350.6	0.00	1.00
01/26/2023 09:00	1	1.6	18.0	14.6	27.7	681,669.0	0.00	1.00
01/26/2023 10:00	1	1.6	17.0	14.6	27.0	681,234.3	0.00	1.00
01/26/2023 11:00	1	1.6	17.4	14.7	27.5	684,270.4	0.00	1.00
01/26/2023 12:00	1	1.6	17.0	14.7	26.5	681,840.8	0.00	1.00
01/26/2023 13:00	1	1.6	16.8	14.7	26.0	681,178.2	0.00	1.00
01/26/2023 14:00	1	1.6	16.5	14.7	25.3	681,840.8	0.00	1.00
01/26/2023 15:00	1	1.6	16.5	14.7	25.6	682,282.6	0.00	1.00
01/26/2023 16:00	1	1.6	16.5	14.7	25.1	682,282.6	0.00	1.00
01/26/2023 17:00	1	1.6	16.7	14.7	26.0	683,166.1	0.00	1.00
01/26/2023 18:00	1	1.6	16.9	14.7	26.1	682,503.4	0.00	1.00
01/26/2023 19:00	1	1.6	17.3	14.6	27.2	672,756.9	0.00	1.00
01/26/2023 20:00	1	1.6	17.6	14.6	27.6	671,887.4	0.00	1.00
01/26/2023 21:00	1	1.6	17.8	14.6	28.1	672,104.8	0.00	1.00
01/26/2023 22:00	1	1.6	17.9	14.7	28.3	683,386.9	0.00	1.00
01/26/2023 23:00	1	1.6	18.4	14.7	30.1	682,724.3	0.00	1.00
Average/Sum#:	1	1.6	17.6	14.7	27.8	682,823.5	0.00 #	24.00 #
Minimum:	1	1.6	16.5	14.6	25.1	671,887.4	0.00	1.00
Maximum:	1	1.9	19.2	14.7	32.0	691,117.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2023 00:00	1	1.6	18.5	14.7	29.7	683,828.7	0.00	1.00
01/27/2023 01:00	1	1.6	17.9	14.6	28.2	678,843.2	0.00	1.00
01/27/2023 02:00	1	1.7	17.8	14.6	26.6	686,233.8	0.00	1.00
01/27/2023 03:00	1	1.6	17.5	14.6	27.2	686,451.1	0.00	1.00
01/27/2023 04:00	1	1.6	17.7	14.6	27.8	686,451.1	0.00	1.00
01/27/2023 05:00	1	1.6	17.8	14.6	28.2	686,016.4	0.00	1.00
01/27/2023 06:00	1	1.6	17.9	14.6	28.0	685,799.0	0.00	1.00
01/27/2023 07:00	1	1.5	17.2	14.6	27.3	700,362.8	0.00	1.00
01/27/2023 08:00	1	1.6	18.2	14.6	29.2	685,146.9	0.00	1.00
01/27/2023 09:00	1	1.6	17.7	14.6	27.8	683,190.6	0.00	1.00
01/27/2023 10:00	1	1.6	17.5	14.6	27.9	677,973.8	0.00	1.00
01/27/2023 11:00	1	1.6	17.7	14.7	27.7	681,178.2	0.00	1.00
01/27/2023 12:00	1	1.6	16.8	14.7	25.7	681,619.9	0.00	1.00
01/27/2023 13:00	1	1.6	16.4	14.7	25.0	680,073.8	0.00	1.00
01/27/2023 14:00	1	1.6	16.1	14.7	24.8	679,632.1	0.00	1.00
01/27/2023 15:00	0	1.4	13.1	14.6	16.5	784,484.5	0.00	1.00
01/27/2023 16:00	0	1.6	8.4	14.4	11.8	960,071.8	0.00	1.00
01/27/2023 17:00	0	1.7	9.1	14.2	15.1	1,040,966.9	0.00	1.00
01/27/2023 18:00	0	1.8	11.2	13.9	19.9	1,081,258.4	0.00	1.00
01/27/2023 19:00	0	1.7	9.9	14.2	18.6	1,037,901.0	0.00	1.00
01/27/2023 20:00	1	2.9	16.3	14.7	17.4	690,234.1	0.13	0.60
01/27/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	1.7	15.7	14.5	24.3	755,129.4	0.13 #	20.60 #
Minimum:	0	1.4	8.4	13.9	11.8	677,973.8	0.00	0.00
Maximum:	1	2.9	18.5	14.7	29.7	1,081,258.4	0.13	1.00
%SI	12.50	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 09:00	0	12.4	16.7	15.7	1.7	851,676.6	0.77	0.77
01/29/2023 10:00	0	1.8	10.3	14.4	21.6	1,088,376.4	0.17	1.00
01/29/2023 11:00	0	1.5	12.3	14.1	21.5	1,092,115.9	0.00	1.00
01/29/2023 12:00	1	2.5	14.8	14.6	17.0	825,567.3	0.13	0.75
01/29/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	4.6	13.5	14.7	15.5	964,434.1	1.07 #	3.52 #
Minimum:	0	1.5	10.3	14.1	1.7	825,567.3	0.00	0.00
Maximum:	1	12.4	16.7	15.7	21.6	1,092,115.9	0.77	1.00
%SI	87.50	83.33	83.33	83.33	83.33	83.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2023 16:00	0	12.0	18.5	15.5	11.0	716,665.4	0.85	0.85
02/03/2023 17:00	0	1.2	12.0	14.3	14.7	964,821.7	0.05	1.00
02/03/2023 18:00	0	1.9	12.3	13.8	23.0	1,099,975.7	0.00	1.00
02/03/2023 19:00	0	1.9	12.9	13.6	23.6	1,099,103.8	0.00	1.00
02/03/2023 20:00	0	1.9	12.8	13.6	24.0	1,095,914.7	0.00	1.00
02/03/2023 21:00	0	1.8	11.7	13.9	22.7	1,091,626.9	0.00	1.00
02/03/2023 22:00	0	1.8	11.7	14.0	22.7	1,099,508.9	0.00	1.00
02/03/2023 23:00	0	1.7	11.0	14.2	20.3	1,021,345.3	0.00	1.00
Average/Sum#:	0	3.0	12.9	14.1	20.3	1,023,620.3	0.90 #	7.85 #
Minimum:	0	1.2	11.0	13.6	11.0	716,665.4	0.00	0.00
Maximum:	0	12.0	18.5	15.5	24.0	1,099,975.7	0.85	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2023 00:00	1	1.4	15.7	14.5	24.7	721,301.5	0.00	1.00
02/04/2023 01:00	1	1.6	18.7	14.6	28.8	679,930.1	0.00	1.00
02/04/2023 02:00	1	1.8	19.1	14.6	28.0	679,712.7	0.00	1.00
02/04/2023 03:00	0	1.6	19.5	14.6	30.6	676,452.2	0.00	1.00
02/04/2023 04:00	1	1.6	18.3	14.6	28.1	685,799.0	0.00	1.00
02/04/2023 05:00	1	1.6	19.0	14.6	29.9	677,539.0	0.00	1.00
02/04/2023 06:00	1	1.6	18.1	14.5	27.7	674,227.5	0.00	1.00
02/04/2023 07:00	1	1.6	18.9	14.6	30.2	678,191.1	0.00	1.00
02/04/2023 08:00	1	1.6	19.0	14.6	29.8	675,582.7	0.00	1.00
02/04/2023 09:00	1	1.6	17.5	14.6	26.8	681,016.9	0.00	1.00
02/04/2023 10:00	1	1.6	17.6	14.6	27.5	673,191.6	0.00	1.00
02/04/2023 11:00	1	1.6	17.3	14.7	26.5	681,619.9	0.00	1.00
02/04/2023 12:00	1	1.6	16.7	14.6	25.4	672,756.9	0.00	1.00
02/04/2023 13:00	1	1.6	16.2	14.7	24.5	682,503.4	0.00	1.00
02/04/2023 14:00	1	1.6	15.9	14.7	24.0	682,503.4	0.00	1.00
02/04/2023 15:00	0	1.5	13.1	14.5	16.5	760,458.5	0.00	1.00
02/04/2023 16:00	0	1.7	10.2	14.4	17.1	842,512.0	0.00	1.00
02/04/2023 17:00	0	1.5	10.8	14.2	14.1	948,581.9	0.00	1.00
02/04/2023 18:00	0	1.9	11.2	13.7	20.8	1,085,839.4	0.00	1.00
02/04/2023 19:00	0	1.9	11.6	13.6	22.6	1,082,595.6	0.00	1.00
02/04/2023 20:00	0	1.9	11.9	13.5	23.0	1,084,806.2	0.00	1.00
02/04/2023 21:00	0	1.9	12.0	13.5	23.0	1,082,955.6	0.00	1.00
02/04/2023 22:00	0	1.7	10.0	14.0	18.6	968,917.4	0.00	1.00
02/04/2023 23:00	1	1.4	13.1	14.5	20.6	725,367.0	0.00	1.00
Average/Sum#:	1	1.6	15.5	14.4	24.5	783,515.1	0.00 #	24.00 #
Minimum:	0	1.4	10.0	13.5	14.1	672,756.9	0.00	1.00
Maximum:	1	1.9	19.5	14.7	30.6	1,085,839.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2023 00:00	1	1.6	15.6	14.6	24.3	681,886.4	0.00	1.00
02/05/2023 01:00	1	1.6	16.2	14.6	25.0	678,408.5	0.00	1.00
02/05/2023 02:00	1	1.7	16.9	14.6	25.4	678,843.2	0.00	1.00
02/05/2023 03:00	1	1.6	16.6	14.6	25.9	682,973.2	0.00	1.00
02/05/2023 04:00	1	1.6	16.3	14.6	24.8	684,060.1	0.00	1.00
02/05/2023 05:00	1	1.6	16.2	14.6	25.2	683,842.7	0.00	1.00
02/05/2023 06:00	1	1.6	16.4	14.6	25.7	684,712.2	0.00	1.00
02/05/2023 07:00	1	1.6	16.9	14.6	26.8	685,581.7	0.00	1.00
02/05/2023 08:00	1	1.6	16.7	14.6	25.9	684,712.2	0.00	1.00
02/05/2023 09:00	1	1.6	16.4	14.6	25.4	682,973.2	0.00	1.00
02/05/2023 10:00	1	1.6	16.1	14.6	24.9	678,408.5	0.00	1.00
02/05/2023 11:00	1	1.6	16.2	14.6	25.3	679,060.6	0.00	1.00
02/05/2023 12:00	1	1.6	16.2	14.6	25.3	679,060.6	0.00	1.00
02/05/2023 13:00	1	1.6	16.3	14.6	25.1	677,539.0	0.00	1.00
02/05/2023 14:00	1	1.6	16.3	14.6	25.3	677,321.6	0.00	1.00
02/05/2023 15:00	1	1.6	16.2	14.6	25.0	676,234.8	0.00	1.00
02/05/2023 16:00	1	1.6	16.3	14.6	25.3	677,104.3	0.00	1.00
02/05/2023 17:00	0	1.5	13.8	14.6	19.2	797,091.9	0.00	1.00
02/05/2023 18:00	1	1.6	12.5	14.4	20.5	762,664.0	0.00	1.00
02/05/2023 19:00	0	1.7	11.4	14.3	15.6	735,754.4	0.00	1.00
02/05/2023 20:00	0	1.7	10.2	14.1	18.5	1,018,811.5	0.00	1.00
02/05/2023 21:00	0	1.7	10.0	14.2	19.3	1,005,198.4	0.00	1.00
02/05/2023 22:00	1	1.5	16.0	14.6	27.4	726,664.4	0.00	1.00
02/05/2023 23:00	1	1.6	17.9	14.6	29.1	676,886.9	0.00	1.00
Average/Sum#:	1	1.6	15.4	14.5	24.2	720,658.1	0.00 #	24.00 #
Minimum:	0	1.5	10.0	14.1	15.6	676,234.8	0.00	1.00
Maximum:	1	1.7	17.9	14.6	29.1	1,018,811.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2023 00:00	1	1.6	18.1	14.6	29.4	677,973.8	0.00	1.00
02/06/2023 01:00	1	1.6	18.6	14.6	30.5	676,669.5	0.00	1.00
02/06/2023 02:00	1	1.6	19.1	14.6	30.1	679,495.3	0.00	1.00
02/06/2023 03:00	1	1.6	19.3	14.7	32.3	686,037.4	0.00	1.00
02/06/2023 04:00	1	1.6	19.4	14.7	31.6	683,607.8	0.00	1.00
02/06/2023 05:00	1	1.6	19.6	14.7	32.4	682,503.4	0.00	1.00
02/06/2023 06:00	1	1.6	19.5	14.7	32.5	683,607.8	0.00	1.00
02/06/2023 07:00	1	1.6	19.5	14.7	32.2	684,270.4	0.00	1.00
02/06/2023 08:00	1	1.6	19.2	14.7	31.6	685,153.9	0.00	1.00
02/06/2023 09:00	1	1.6	19.1	14.7	31.3	687,141.8	0.00	1.00
02/06/2023 10:00	1	1.6	18.9	14.7	30.7	685,595.7	0.00	1.00
02/06/2023 11:00	1	1.6	18.1	14.6	28.7	673,626.4	0.00	1.00
02/06/2023 12:00	1	1.6	17.5	14.7	27.5	683,828.7	0.00	1.00
02/06/2023 13:00	1	1.6	17.2	14.7	27.1	682,503.4	0.00	1.00
02/06/2023 14:00	1	1.6	16.8	14.7	25.9	684,491.3	0.00	1.00
02/06/2023 15:00	0	1.5	13.7	14.6	18.6	793,614.0	0.00	1.00
02/06/2023 16:00	1	1.6	13.0	14.5	20.7	746,122.3	0.00	1.00
02/06/2023 17:00	0	1.7	10.6	14.0	16.2	1,054,655.2	0.00	1.00
02/06/2023 18:00	0	1.9	12.4	13.6	23.7	1,098,541.0	0.00	1.00
02/06/2023 19:00	0	1.9	12.3	13.6	25.2	1,097,227.8	0.00	1.00
02/06/2023 20:00	0	2.0	13.8	13.2	28.0	1,098,385.1	0.00	1.00
02/06/2023 21:00	0	1.8	11.9	13.8	24.5	1,097,854.0	0.00	1.00
02/06/2023 22:00	1	1.7	10.7	14.2	22.4	974,539.6	0.00	1.00
02/06/2023 23:00	1	1.4	13.8	14.5	21.4	746,978.2	0.00	1.00
Average/Sum#:	1	1.6	16.3	14.4	27.3	789,351.0	0.00 #	24.00 #
Minimum:	0	1.4	10.6	13.2	16.2	673,626.4	0.00	1.00
Maximum:	1	2.0	19.6	14.7	32.5	1,098,541.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2023 00:00	1	1.6	17.6	14.6	28.6	680,147.4	0.00	1.00
02/07/2023 01:00	1	1.6	18.0	14.6	29.0	677,756.4	0.00	1.00
02/07/2023 02:00	1	1.7	18.6	14.6	28.7	677,973.8	0.00	1.00
02/07/2023 03:00	1	1.6	18.7	14.6	30.0	679,712.7	0.00	1.00
02/07/2023 04:00	1	1.6	18.9	14.6	31.3	678,191.1	0.00	1.00
02/07/2023 05:00	1	1.6	18.9	14.6	30.8	678,191.1	0.00	1.00
02/07/2023 06:00	1	1.6	19.3	14.7	32.1	690,675.8	0.00	1.00
02/07/2023 07:00	1	1.6	18.6	14.6	30.6	689,929.0	0.00	1.00
02/07/2023 08:00	1	1.6	19.0	14.6	31.1	678,191.1	0.00	1.00
02/07/2023 09:00	1	1.6	18.2	14.6	29.0	676,017.4	0.00	1.00
02/07/2023 10:00	1	1.6	17.4	14.6	27.7	676,452.2	0.00	1.00
02/07/2023 11:00	1	1.6	17.0	14.6	26.8	676,886.9	0.00	1.00
02/07/2023 12:00	1	1.6	16.6	14.6	25.9	676,452.2	0.00	1.00
02/07/2023 13:00	1	1.6	16.2	14.6	25.2	677,321.6	0.00	1.00
02/07/2023 14:00	1	1.6	15.9	14.6	24.7	677,539.0	0.00	1.00
02/07/2023 15:00	0	1.5	13.2	14.5	18.2	785,065.3	0.00	1.00
02/07/2023 16:00	0	1.5	11.7	14.5	17.7	796,833.8	0.00	1.00
02/07/2023 17:00	0	1.8	10.6	14.0	18.6	1,063,189.3	0.00	1.00
02/07/2023 18:00	0	1.9	12.8	13.4	24.8	1,085,679.7	0.00	1.00
02/07/2023 19:00	0	1.9	13.1	13.4	26.5	1,101,930.2	0.00	1.00
02/07/2023 20:00	0	2.0	13.7	13.2	27.8	1,094,116.7	0.00	1.00
02/07/2023 21:00	0	1.9	13.2	13.4	26.9	1,098,826.1	0.00	1.00
02/07/2023 22:00	0	1.9	12.4	13.6	25.4	1,096,477.5	0.00	1.00
02/07/2023 23:00	0	1.8	11.4	13.8	24.2	1,086,474.3	0.00	1.00
Average/Sum#:	1	1.7	15.9	14.3	26.7	808,334.6	0.00 #	24.00 #
Minimum:	0	1.5	10.6	13.2	17.7	676,017.4	0.00	1.00
Maximum:	1	2.0	19.3	14.7	32.1	1,101,930.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2023 00:00	0	1.7	9.0	14.4	17.6	1,055,931.5	0.00	1.00
02/08/2023 01:00	0	1.7	8.8	14.4	17.9	1,055,510.2	0.00	1.00
02/08/2023 02:00	0	1.6	9.1	14.3	17.5	1,015,863.9	0.00	1.00
02/08/2023 03:00	0	1.7	9.0	14.3	17.0	1,003,414.6	0.00	1.00
02/08/2023 04:00	0	1.7	9.2	14.4	18.2	1,038,655.7	0.00	1.00
02/08/2023 05:00	0	1.7	9.7	14.3	20.1	1,061,926.4	0.00	1.00
02/08/2023 06:00	0	1.9	13.0	13.6	27.3	1,118,801.0	0.00	1.00
02/08/2023 07:00	0	1.7	10.8	14.1	21.4	1,048,818.0	0.00	1.00
02/08/2023 08:00	2	3.4	20.8	14.9	24.4	721,914.9	0.13	0.38
02/08/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2023 15:00	0	0.4	2.4	20.7	0.0	1,663,850.6	0.05	0.05
02/08/2023 16:00	0	7.6	18.1	15.1	14.0	755,780.6	0.63	1.00
02/08/2023 17:00	0	1.8	11.4	13.9	20.1	1,071,281.1	0.00	1.00
02/08/2023 18:00	0	2.0	14.1	13.1	28.1	1,094,310.5	0.00	1.00
02/08/2023 19:00	0	1.9	13.3	13.3	26.3	1,086,710.3	0.00	1.00
02/08/2023 20:00	0	1.9	12.3	13.6	25.0	1,100,229.3	0.00	1.00
02/08/2023 21:00	1	2.0	14.1	13.1	28.7	1,102,035.5	0.00	1.00
02/08/2023 22:00	0	1.9	12.9	13.4	26.1	1,093,165.8	0.00	1.00
02/08/2023 23:00	0	1.8	10.9	14.0	22.5	1,081,845.3	0.00	1.00
Average/Sum#:	0	2.1	11.6	14.4	20.7	1,065,002.5	0.81 #	16.43 #
Minimum:	0	0.4	2.4	13.1	0.0	721,914.9	0.00	0.00
Maximum:	2	7.6	20.8	20.7	28.7	1,663,850.6	0.63	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2023 00:00	0	1.7	9.1	14.5	19.2	1,110,517.6	0.00	1.00
02/09/2023 01:00	0	1.7	9.0	14.4	18.2	1,064,358.8	0.00	1.00
02/09/2023 02:00	0	1.5	9.3	14.5	20.1	1,112,871.3	0.00	1.00
02/09/2023 03:00	0	1.7	9.4	14.5	20.2	1,110,517.6	0.00	1.00
02/09/2023 04:00	0	1.7	9.1	14.4	18.2	1,065,833.5	0.00	1.00
02/09/2023 05:00	0	1.9	12.9	13.5	27.1	1,118,116.5	0.00	1.00
02/09/2023 06:00	1	2.0	14.0	13.2	29.3	1,116,347.6	0.00	1.00
02/09/2023 07:00	1	1.7	11.7	14.1	25.2	986,589.7	0.00	1.00
02/09/2023 08:00	1	3.6	25.5	15.3	20.4	643,874.0	0.13	0.33
02/09/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2023 16:00	1	7.9	19.4	15.6	20.7	705,641.1	0.68	0.92
02/09/2023 17:00	0	1.4	10.1	14.2	10.3	1,020,936.5	0.00	1.00
02/09/2023 18:00	0	2.0	14.2	13.1	27.8	1,093,783.8	0.00	1.00
02/09/2023 19:00	0	1.9	12.8	13.5	25.2	1,091,468.2	0.00	1.00
02/09/2023 20:00	0	2.0	13.7	13.2	27.3	1,089,670.5	0.00	1.00
02/09/2023 21:00	1	2.0	13.8	13.2	28.0	1,098,385.1	0.00	1.00
02/09/2023 22:00	0	1.9	12.7	13.5	24.8	1,097,205.0	0.00	1.00
02/09/2023 23:00	1	2.3	13.5	14.4	18.9	886,755.0	0.13	1.00
Average/Sum#:	0	2.3	13.0	14.1	22.4	1,024,286.6	0.94 #	16.25 #
Minimum:	0	1.4	9.0	13.1	10.3	643,874.0	0.00	0.00
Maximum:	1	7.9	25.5	15.6	29.3	1,118,116.5	0.68	1.00
%SI	29.17	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2023 15:00	0	3.1	4.9	20.1	0.0	657,323.7	0.10	0.10
02/10/2023 16:00	-1	10.1	18.5	14.9	10.6	722,371.4	0.95	1.00
02/10/2023 17:00	0	1.8	10.7	14.1	17.6	1,001,089.5	0.00	1.00
02/10/2023 18:00	0	1.8	11.4	14.0	23.0	1,096,730.3	0.00	1.00
02/10/2023 19:00	0	1.8	11.5	14.0	23.3	1,098,516.5	0.00	1.00
02/10/2023 20:00	0	1.8	11.9	13.8	24.4	1,094,382.2	0.00	1.00
02/10/2023 21:00	0	1.8	12.1	13.8	24.6	1,104,797.6	0.00	1.00
02/10/2023 22:00	0	1.8	12.0	13.7	24.6	1,094,778.7	0.00	1.00
02/10/2023 23:00	0	1.8	11.3	14.0	23.3	1,107,447.5	0.00	1.00
Average/Sum#:	0	2.9	11.6	14.7	19.0	997,493.0	1.05 #	8.10 #
Minimum:	-1	1.8	4.9	13.7	0.0	657,323.7	0.00	0.00
Maximum:	0	10.1	18.5	20.1	24.6	1,107,447.5	0.95	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2023 00:00	0	1.8	11.6	13.9	23.9	1,112,950.8	0.00	1.00
02/11/2023 01:00	0	1.8	11.2	14.0	23.2	1,108,638.3	0.00	1.00
02/11/2023 02:00	0	1.7	11.1	14.1	22.8	1,106,615.7	0.00	1.00
02/11/2023 03:00	0	1.7	11.0	14.1	22.5	1,107,219.9	0.00	1.00
02/11/2023 04:00	0	1.7	10.7	14.1	22.5	1,104,199.1	0.00	1.00
02/11/2023 05:00	0	1.7	11.0	14.0	23.2	1,100,898.1	0.00	1.00
02/11/2023 06:00	0	1.8	11.0	14.0	23.4	1,101,096.6	0.00	1.00
02/11/2023 07:00	0	1.7	10.5	14.1	21.0	1,052,442.9	0.00	1.00
02/11/2023 08:00	1	1.5	13.4	14.5	22.3	813,523.7	0.00	1.00
02/11/2023 09:00	1	1.7	16.2	14.5	27.2	699,476.3	0.00	1.00
02/11/2023 10:00	1	1.6	17.6	14.6	28.4	677,321.6	0.00	1.00
02/11/2023 11:00	1	1.6	17.5	14.6	28.0	677,756.4	0.00	1.00
02/11/2023 12:00	1	1.6	17.0	14.6	26.7	678,843.2	0.00	1.00
02/11/2023 13:00	1	1.6	16.6	14.6	25.8	679,495.3	0.00	1.00
02/11/2023 14:00	1	1.6	16.2	14.6	25.2	679,930.1	0.00	1.00
02/11/2023 15:00	0	1.5	13.4	14.6	18.7	797,961.4	0.00	1.00
02/11/2023 16:00	0	1.5	12.1	14.5	19.3	800,257.4	0.00	1.00
02/11/2023 17:00	0	1.7	10.4	14.1	16.1	994,443.8	0.00	1.00
02/11/2023 18:00	0	1.8	11.8	13.8	23.7	1,090,717.6	0.00	1.00
02/11/2023 19:00	0	1.8	11.6	13.8	23.9	1,085,509.9	0.00	1.00
02/11/2023 20:00	0	1.8	11.6	13.8	24.5	1,090,524.7	0.00	1.00
02/11/2023 21:00	0	1.8	12.2	13.7	25.4	1,104,669.0	0.00	1.00
02/11/2023 22:00	0	1.9	12.4	13.7	26.1	1,108,282.8	0.00	1.00
02/11/2023 23:00	0	1.8	11.5	13.9	24.9	1,101,017.2	0.00	1.00
Average/Sum#:	0	1.7	12.9	14.2	23.7	953,074.7	0.00 #	24.00 #
Minimum:	0	1.5	10.4	13.7	16.1	677,321.6	0.00	1.00
Maximum:	1	1.9	17.6	14.6	28.4	1,112,950.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2023 00:00	0	1.9	12.4	13.6	26.5	1,100,041.7	0.00	1.00
02/12/2023 01:00	0	1.9	12.3	13.7	26.1	1,107,902.4	0.00	1.00
02/12/2023 02:00	0	1.8	12.2	13.8	25.2	1,105,376.2	0.00	1.00
02/12/2023 03:00	0	1.8	12.5	13.6	26.2	1,101,730.1	0.00	1.00
02/12/2023 04:00	0	1.9	12.7	13.6	26.5	1,105,294.3	0.00	1.00
02/12/2023 05:00	0	1.9	12.7	13.6	26.3	1,099,478.9	0.00	1.00
02/12/2023 06:00	0	1.8	12.2	13.7	25.8	1,097,251.3	0.00	1.00
02/12/2023 07:00	1	1.7	11.5	14.1	23.8	976,721.8	0.00	1.00
02/12/2023 08:00	1	2.7	17.1	14.8	15.0	732,529.8	0.15	0.58
02/12/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2023 15:00	0	12.7	21.2	16.4	8.2	722,143.1	0.50	0.50
02/12/2023 16:00	0	1.5	11.2	14.6	15.9	918,166.4	0.07	1.00
02/12/2023 17:00	0	1.9	12.9	13.5	23.9	1,060,193.6	0.00	1.00
02/12/2023 18:00	0	1.8	11.6	13.8	22.5	1,069,308.3	0.00	1.00
02/12/2023 19:00	0	1.9	12.5	13.5	24.0	1,072,037.2	0.00	1.00
02/12/2023 20:00	0	1.9	12.9	13.4	24.8	1,077,645.7	0.00	1.00
02/12/2023 21:00	0	1.8	11.2	13.9	21.3	1,054,456.8	0.00	1.00
02/12/2023 22:00	0	1.6	9.3	14.4	14.7	871,164.6	0.00	1.00
02/12/2023 23:00	1	1.6	12.7	14.5	20.6	764,524.0	0.00	1.00
Average/Sum#:	0	2.5	12.8	14.0	22.1	1,001,998.1	0.72 #	17.08 #
Minimum:	0	1.5	9.3	13.4	8.2	722,143.1	0.00	0.00
Maximum:	1	12.7	21.2	16.4	26.5	1,107,902.4	0.50	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2023 00:00	0	1.3	12.5	14.5	17.1	779,502.0	0.00	1.00
02/13/2023 01:00	1	1.6	16.9	14.6	27.8	677,104.3	0.00	1.00
02/13/2023 02:00	1	1.6	17.2	14.6	26.3	679,060.6	0.00	1.00
02/13/2023 03:00	1	1.6	17.3	14.6	27.4	679,278.0	0.00	1.00
02/13/2023 04:00	1	1.6	17.3	14.6	26.9	679,278.0	0.00	1.00
02/13/2023 05:00	1	1.6	17.4	14.6	27.5	681,234.3	0.00	1.00
02/13/2023 06:00	1	1.6	17.5	14.6	27.9	682,755.9	0.00	1.00
02/13/2023 07:00	1	1.5	15.8	14.5	25.1	697,122.6	0.00	1.00
02/13/2023 08:00	1	1.6	17.1	14.6	26.7	681,016.9	0.00	1.00
02/13/2023 09:00	1	1.6	16.5	14.6	25.7	680,147.4	0.00	1.00
02/13/2023 10:00	1	1.6	16.0	14.6	24.7	679,278.0	0.00	1.00
02/13/2023 11:00	1	1.6	15.3	14.6	23.2	681,016.9	0.00	1.00
02/13/2023 12:00	1	1.6	14.9	14.6	22.5	679,930.1	0.00	1.00
02/13/2023 13:00	1	1.6	15.0	14.7	22.9	686,258.3	0.00	1.00
02/13/2023 14:00	1	1.6	15.2	14.7	23.2	682,282.6	0.00	1.00
02/13/2023 15:00	1	1.6	15.1	14.7	22.7	682,503.4	0.00	1.00
02/13/2023 16:00	1	1.6	15.2	14.7	23.2	683,166.1	0.00	1.00
02/13/2023 17:00	1	1.6	15.5	14.7	23.8	682,945.2	0.00	1.00
02/13/2023 18:00	1	1.6	15.7	14.7	24.0	682,724.3	0.00	1.00
02/13/2023 19:00	1	1.6	16.3	14.7	25.9	683,828.7	0.00	1.00
02/13/2023 20:00	1	1.6	17.7	14.7	28.5	684,491.3	0.00	1.00
02/13/2023 21:00	1	1.6	17.9	14.7	28.7	686,700.1	0.00	1.00
02/13/2023 22:00	1	1.6	18.0	14.7	29.0	688,467.1	0.00	1.00
02/13/2023 23:00	1	1.6	18.2	14.6	29.4	678,191.1	0.00	1.00
Average/Sum#:	1	1.6	16.3	14.6	25.4	686,595.1	0.00 #	24.00 #
Minimum:	0	1.3	12.5	14.5	17.1	677,104.3	0.00	1.00
Maximum:	1	1.6	18.2	14.7	29.4	779,502.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2023 00:00	1	1.6	18.2	14.6	29.4	679,712.7	0.00	1.00
02/14/2023 01:00	1	1.6	18.4	14.6	29.6	681,451.7	0.00	1.00
02/14/2023 02:00	1	1.6	18.9	14.6	29.7	681,669.0	0.00	1.00
02/14/2023 03:00	1	1.6	18.9	14.6	30.1	682,538.5	0.00	1.00
02/14/2023 04:00	1	1.6	18.8	14.6	30.4	681,886.4	0.00	1.00
02/14/2023 05:00	1	1.6	19.0	14.7	31.2	692,884.6	0.00	1.00
02/14/2023 06:00	1	1.6	19.4	14.7	32.2	687,362.7	0.00	1.00
02/14/2023 07:00	1	1.6	19.7	14.7	32.7	687,141.8	0.00	1.00
02/14/2023 08:00	1	1.6	19.9	14.7	33.3	685,816.6	0.00	1.00
02/14/2023 09:00	1	1.6	19.9	14.7	33.0	684,712.2	0.00	1.00
02/14/2023 10:00	1	1.6	19.7	14.7	31.9	684,491.3	0.00	1.00
02/14/2023 11:00	1	1.6	19.1	14.7	30.9	684,933.1	0.00	1.00
02/14/2023 12:00	1	1.6	18.3	14.7	29.2	688,908.8	0.00	1.00
02/14/2023 13:00	1	1.6	18.0	14.7	28.7	690,896.7	0.00	1.00
02/14/2023 14:00	1	1.4	15.7	14.6	23.0	731,229.1	0.00	1.00
02/14/2023 15:00	0	1.6	9.6	14.5	14.9	1,010,164.5	0.00	1.00
02/14/2023 16:00	0	1.7	9.8	14.3	17.1	979,553.4	0.00	1.00
02/14/2023 17:00	0	2.0	14.3	13.1	28.8	1,104,317.9	0.00	1.00
02/14/2023 18:00	1	2.0	15.1	13.0	31.0	1,113,914.1	0.00	1.00
02/14/2023 19:00	0	1.9	13.4	13.4	27.5	1,114,894.0	0.00	1.00
02/14/2023 20:00	1	2.0	14.5	13.2	30.3	1,125,595.7	0.00	1.00
02/14/2023 21:00	0	1.9	13.2	13.5	27.7	1,111,824.6	0.00	1.00
02/14/2023 22:00	0	1.8	11.7	13.9	25.5	1,112,755.1	0.00	1.00
02/14/2023 23:00	0	1.8	12.6	13.7	27.1	1,126,732.0	0.00	1.00
Average/Sum#:	1	1.7	16.5	14.3	28.6	838,557.8	0.00 #	24.00 #
Minimum:	0	1.4	9.6	13.0	14.9	679,712.7	0.00	1.00
Maximum:	1	2.0	19.9	14.7	33.3	1,126,732.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2023 00:00	0	1.8	12.3	13.8	26.5	1,129,871.6	0.00	1.00
02/15/2023 01:00	0	1.8	12.2	13.8	26.1	1,123,313.7	0.00	1.00
02/15/2023 02:00	0	1.8	12.4	13.8	26.4	1,121,963.6	0.00	1.00
02/15/2023 03:00	0	1.9	12.8	13.6	27.5	1,113,548.4	0.00	1.00
02/15/2023 04:00	1	1.9	14.0	13.3	29.7	1,124,369.5	0.00	1.00
02/15/2023 05:00	1	1.9	14.2	13.3	30.3	1,128,694.0	0.00	1.00
02/15/2023 06:00	1	2.0	14.6	13.2	31.0	1,123,461.5	0.02	0.90
02/15/2023 07:00	0	7.6	18.0	16.3	7.5	945,498.2	0.52	0.52
02/15/2023 08:00	1	1.4	12.6	14.4	24.9	858,313.1	0.10	1.00
02/15/2023 09:00	1	1.5	16.7	14.6	28.1	744,271.3	0.00	1.00
02/15/2023 10:00	1	1.6	19.2	14.7	31.5	687,804.4	0.00	1.00
02/15/2023 11:00	1	1.6	18.8	14.7	31.0	685,374.8	0.00	1.00
02/15/2023 12:00	1	1.6	18.2	14.7	30.0	682,945.2	0.00	1.00
02/15/2023 13:00	1	1.6	17.9	14.7	28.7	682,945.2	0.00	1.00
02/15/2023 14:00	1	1.6	17.7	14.7	28.3	683,386.9	0.00	1.00
02/15/2023 15:00	1	1.5	16.1	14.7	23.9	724,469.7	0.00	1.00
02/15/2023 16:00	0	1.6	10.8	14.5	18.8	891,837.6	0.00	1.00
02/15/2023 17:00	0	1.5	10.3	14.3	15.1	985,985.6	0.00	1.00
02/15/2023 18:00	0	2.0	14.4	13.0	29.0	1,105,940.2	0.00	1.00
02/15/2023 19:00	1	2.0	14.7	13.0	30.4	1,110,447.2	0.00	1.00
02/15/2023 20:00	1	2.0	14.5	13.1	29.8	1,123,805.8	0.00	1.00
02/15/2023 21:00	1	2.0	14.6	13.0	30.4	1,118,421.0	0.00	1.00
02/15/2023 22:00	1	2.0	14.1	13.1	28.7	1,122,050.2	0.00	1.00
02/15/2023 23:00	0	1.9	12.7	13.4	25.9	1,096,817.6	0.00	1.00
Average/Sum#:	1	2.0	14.7	14.0	26.6	963,147.3	0.64 #	23.42 #
Minimum:	0	1.4	10.3	13.0	7.5	682,945.2	0.00	0.52
Maximum:	1	7.6	19.2	16.3	31.5	1,129,871.6	0.52	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2023 00:00	0	1.6	9.4	14.5	19.6	1,110,303.6	0.00	1.00
02/16/2023 01:00	0	1.7	9.4	14.4	20.3	1,095,328.8	0.00	1.00
02/16/2023 02:00	0	1.7	9.8	14.4	20.2	1,098,067.7	0.00	1.00
02/16/2023 03:00	0	1.6	9.6	14.4	20.2	1,098,910.4	0.00	1.00
02/16/2023 04:00	0	1.7	9.5	14.4	20.3	1,097,646.3	0.00	1.00
02/16/2023 05:00	0	1.6	9.5	14.5	20.6	1,114,797.0	0.00	1.00
02/16/2023 06:00	0	1.7	9.4	14.5	20.3	1,111,587.4	0.00	1.00
02/16/2023 07:00	0	1.7	10.6	14.0	22.8	1,099,508.9	0.00	1.00
02/16/2023 08:00	1	1.6	13.3	14.4	25.8	898,763.8	0.00	1.00
02/16/2023 09:00	1	1.6	16.0	14.6	26.0	754,270.3	0.00	1.00
02/16/2023 10:00	1	1.6	18.4	14.7	29.8	692,442.8	0.00	1.00
02/16/2023 11:00	1	1.6	17.7	14.7	28.2	692,663.7	0.00	1.00
02/16/2023 12:00	1	1.6	16.8	14.7	26.3	700,173.4	0.00	1.00
02/16/2023 13:00	1	1.6	17.0	14.7	27.1	694,430.7	0.00	1.00
02/16/2023 14:00	1	1.6	17.0	14.7	26.9	693,988.9	0.00	1.00
02/16/2023 15:00	0	1.5	15.7	14.6	23.0	724,490.7	0.00	1.00
02/16/2023 16:00	1	1.6	12.1	14.6	21.4	882,300.6	0.00	1.00
02/16/2023 17:00	0	1.6	10.4	14.3	14.5	888,258.5	0.00	1.00
02/16/2023 18:00	0	1.7	10.2	14.1	20.2	1,084,060.5	0.00	1.00
02/16/2023 19:00	0	1.8	11.1	13.9	23.7	1,102,973.5	0.00	1.00
02/16/2023 20:00	0	1.8	11.7	13.8	24.7	1,118,299.0	0.00	1.00
02/16/2023 21:00	0	1.8	11.6	13.7	24.6	1,111,896.5	0.00	1.00
02/16/2023 22:00	0	1.9	12.0	13.6	24.8	1,113,923.6	0.00	1.00
02/16/2023 23:00	0	1.8	10.8	13.9	23.1	1,112,755.1	0.00	1.00
Average/Sum#:	0	1.7	12.5	14.3	23.1	962,160.1	0.00 #	24.00 #
Minimum:	0	1.5	9.4	13.6	14.5	692,442.8	0.00	1.00
Maximum:	1	1.9	18.4	14.7	29.8	1,118,299.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2023 00:00	0	1.8	11.1	13.8	23.3	1,107,305.0	0.00	1.00
02/17/2023 01:00	0	1.7	10.1	14.1	21.8	1,103,192.2	0.00	1.00
02/17/2023 02:00	0	1.7	10.4	14.1	21.7	1,104,400.5	0.00	1.00
02/17/2023 03:00	1	1.5	15.2	14.6	28.8	812,525.1	0.00	1.00
02/17/2023 04:00	1	1.4	16.9	14.6	27.8	738,619.7	0.00	1.00
02/17/2023 05:00	1	1.6	18.6	14.7	30.7	692,884.6	0.00	1.00
02/17/2023 06:00	1	1.6	19.3	14.7	32.7	688,246.2	0.00	1.00
02/17/2023 07:00	1	1.6	19.7	14.7	31.0	685,374.8	0.00	1.00
02/17/2023 08:00	0	1.5	21.3	14.7	33.9	682,503.4	0.00	1.00
02/17/2023 09:00	1	1.6	20.9	14.7	31.9	681,840.8	0.00	1.00
02/17/2023 10:00	1	1.6	20.6	14.7	30.5	684,491.3	0.00	1.00
02/17/2023 11:00	0	1.5	18.3	14.6	25.3	702,101.7	0.00	1.00
02/17/2023 12:00	0	1.6	11.5	14.4	13.7	786,049.6	0.00	1.00
02/17/2023 13:00	0	1.6	17.1	14.6	25.3	683,190.6	0.00	1.00
02/17/2023 14:00	0	1.6	17.0	14.7	24.8	692,221.9	0.00	1.00
02/17/2023 15:00	0	1.6	17.4	14.7	25.7	686,479.2	0.00	1.00
02/17/2023 16:00	0	1.6	17.1	14.7	24.6	689,129.7	0.00	1.00
02/17/2023 17:00	0	1.6	17.3	14.7	25.5	688,908.8	0.00	1.00
02/17/2023 18:00	0	1.6	17.1	14.6	25.0	681,669.0	0.00	1.00
02/17/2023 19:00	1	1.6	17.4	14.6	25.9	681,669.0	0.00	1.00
02/17/2023 20:00	1	1.6	17.7	14.6	26.5	682,321.1	0.00	1.00
02/17/2023 21:00	1	1.6	18.0	14.6	26.7	682,538.5	0.00	1.00
02/17/2023 22:00	1	1.6	18.5	14.6	28.1	682,538.5	0.00	1.00
02/17/2023 23:00	1	1.6	18.8	14.6	28.7	681,886.4	0.00	1.00
Average/Sum#:	1	1.6	17.0	14.6	26.7	750,087.0	0.00 #	24.00 #
Minimum:	0	1.4	10.1	13.8	13.7	681,669.0	0.00	1.00
Maximum:	1	1.8	21.3	14.7	33.9	1,107,305.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2023 00:00	1	1.6	18.8	14.6	28.5	680,582.2	0.00	1.00
02/18/2023 01:00	1	1.6	19.8	14.6	30.4	675,800.1	0.00	1.00
02/18/2023 02:00	1	1.6	20.6	14.6	30.4	675,800.1	0.00	1.00
02/18/2023 03:00	1	1.6	20.5	14.6	31.3	676,234.8	0.00	1.00
02/18/2023 04:00	1	1.6	20.2	14.7	30.8	688,025.3	0.00	1.00
02/18/2023 05:00	1	1.6	20.6	14.7	32.5	686,920.9	0.00	1.00
02/18/2023 06:00	1	1.6	21.1	14.7	34.0	685,153.9	0.00	1.00
02/18/2023 07:00	1	1.6	20.8	14.7	33.1	686,258.3	0.00	1.00
02/18/2023 08:00	1	1.6	20.6	14.7	32.1	685,374.8	0.00	1.00
02/18/2023 09:00	1	1.6	19.9	14.7	30.4	686,920.9	0.00	1.00
02/18/2023 10:00	1	1.6	19.4	14.6	29.2	674,930.6	0.00	1.00
02/18/2023 11:00	1	1.6	18.6	14.6	27.7	674,930.6	0.00	1.00
02/18/2023 12:00	1	1.6	18.0	14.7	26.6	685,374.8	0.00	1.00
02/18/2023 13:00	0	1.6	17.7	14.7	25.8	685,153.9	0.00	1.00
02/18/2023 14:00	0	1.6	17.5	14.7	25.5	684,712.2	0.00	1.00
02/18/2023 15:00	0	1.6	17.4	14.7	25.5	684,491.3	0.00	1.00
02/18/2023 16:00	0	1.6	17.4	14.7	25.5	686,700.1	0.00	1.00
02/18/2023 17:00	1	1.6	17.3	14.6	25.4	674,713.2	0.00	1.00
02/18/2023 18:00	1	1.6	17.6	14.6	25.9	674,713.2	0.00	1.00
02/18/2023 19:00	1	1.6	17.8	14.6	26.3	675,148.0	0.00	1.00
02/18/2023 20:00	1	1.6	18.1	14.6	27.4	675,148.0	0.00	1.00
02/18/2023 21:00	1	1.6	18.6	14.6	28.0	673,409.0	0.00	1.00
02/18/2023 22:00	1	1.6	19.0	14.6	28.8	672,756.9	0.00	1.00
02/18/2023 23:00	1	1.6	19.3	14.7	29.7	684,491.3	0.00	1.00
Average/Sum#:	1	1.6	19.0	14.7	28.8	680,572.7	0.00 #	24.00 #
Minimum:	0	1.6	17.3	14.6	25.4	672,756.9	0.00	1.00
Maximum:	1	1.6	21.1	14.7	34.0	688,025.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2023 00:00	1	1.6	19.7	14.7	30.7	684,049.6	0.00	1.00
02/19/2023 01:00	1	1.6	19.6	14.7	30.5	684,712.2	0.00	1.00
02/19/2023 02:00	1	1.7	20.5	14.7	31.1	684,491.3	0.00	1.00
02/19/2023 03:00	0	1.5	20.4	14.7	32.4	686,037.4	0.00	1.00
02/19/2023 04:00	1	1.6	20.1	14.7	31.3	686,920.9	0.00	1.00
02/19/2023 05:00	1	1.6	19.9	14.7	30.8	687,804.4	0.00	1.00
02/19/2023 06:00	1	1.6	20.0	14.7	31.4	690,675.8	0.00	1.00
02/19/2023 07:00	1	1.6	20.1	14.7	31.7	691,117.6	0.00	1.00
02/19/2023 08:00	1	1.6	19.9	14.6	30.7	680,364.8	0.00	1.00
02/19/2023 09:00	1	1.6	19.3	14.6	29.1	679,712.7	0.00	1.00
02/19/2023 10:00	1	1.6	18.5	14.6	27.8	680,147.4	0.00	1.00
02/19/2023 11:00	1	1.6	18.0	14.6	26.7	678,625.9	0.00	1.00
02/19/2023 12:00	0	1.6	17.6	14.6	25.7	677,756.4	0.00	1.00
02/19/2023 13:00	1	1.6	17.1	14.7	25.3	686,037.4	0.00	1.00
02/19/2023 14:00	0	1.6	17.6	14.7	25.7	678,969.4	0.00	1.00
02/19/2023 15:00	0	1.6	16.7	14.7	23.7	685,816.6	0.00	1.00
02/19/2023 16:00	1	1.6	17.4	14.7	25.8	678,748.6	0.00	1.00
02/19/2023 17:00	0	1.6	17.7	14.7	25.9	679,411.2	0.00	1.00
02/19/2023 18:00	0	1.6	16.6	14.6	24.0	679,930.1	0.00	1.00
02/19/2023 19:00	1	1.6	17.1	14.6	25.1	676,886.9	0.00	1.00
02/19/2023 20:00	1	1.6	17.7	14.6	26.3	674,278.5	0.00	1.00
02/19/2023 21:00	1	1.6	18.1	14.6	27.1	674,495.9	0.00	1.00
02/19/2023 22:00	1	1.6	18.0	14.6	26.8	676,669.5	0.00	1.00
02/19/2023 23:00	1	1.6	17.8	14.6	26.7	679,712.7	0.00	1.00
Average/Sum#:	1	1.6	18.6	14.7	28.0	681,807.2	0.00 #	24.00 #
Minimum:	0	1.5	16.6	14.6	23.7	674,278.5	0.00	1.00
Maximum:	1	1.7	20.5	14.7	32.4	691,117.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2023 00:00	1	1.6	18.0	14.6	27.0	680,799.6	0.00	1.00
02/20/2023 01:00	1	1.6	18.1	14.6	27.5	682,755.9	0.00	1.00
02/20/2023 02:00	1	1.7	18.8	14.6	27.2	681,886.4	0.00	1.00
02/20/2023 03:00	1	1.6	18.6	14.6	27.9	681,451.7	0.00	1.00
02/20/2023 04:00	1	1.6	18.7	14.6	27.9	682,103.8	0.00	1.00
02/20/2023 05:00	1	1.6	18.8	14.6	28.5	682,755.9	0.00	1.00
02/20/2023 06:00	1	1.6	19.1	14.6	29.2	683,625.3	0.00	1.00
02/20/2023 07:00	1	1.5	15.8	14.5	23.4	746,550.3	0.00	1.00
02/20/2023 08:00	1	1.6	18.5	14.6	27.7	682,538.5	0.00	1.00
02/20/2023 09:00	1	1.6	17.5	14.6	25.8	684,494.8	0.00	1.00
02/20/2023 10:00	0	1.6	16.8	14.6	24.7	684,712.2	0.00	1.00
02/20/2023 11:00	1	1.6	17.3	14.7	25.7	687,583.6	0.00	1.00
02/20/2023 12:00	0	1.6	16.8	14.7	24.4	690,454.9	0.00	1.00
02/20/2023 13:00	0	1.6	16.8	14.7	24.2	685,816.6	0.00	1.00
02/20/2023 14:00	0	1.6	16.5	14.7	23.9	685,153.9	0.00	1.00
02/20/2023 15:00	0	1.5	13.7	14.6	17.8	789,484.0	0.00	1.00
02/20/2023 16:00	0	1.6	12.2	14.5	17.6	779,502.0	0.00	1.00
02/20/2023 17:00	0	1.7	11.8	13.8	18.9	1,033,626.1	0.00	1.00
02/20/2023 18:00	0	1.9	13.4	13.5	24.6	1,082,030.3	0.00	1.00
02/20/2023 19:00	0	1.9	13.5	13.5	25.5	1,088,877.4	0.00	1.00
02/20/2023 20:00	0	1.9	13.4	13.5	25.5	1,084,806.2	0.00	1.00
02/20/2023 21:00	0	1.8	12.4	13.7	23.9	1,077,280.5	0.00	1.00
02/20/2023 22:00	0	1.7	11.2	14.1	21.7	972,694.1	0.00	1.00
02/20/2023 23:00	1	4.0	25.3	15.2	17.3	628,974.2	0.13	0.28
Average/Sum#:	1	1.8	16.4	14.4	24.5	785,831.6	0.13 #	23.28 #
Minimum:	0	1.5	11.2	13.5	17.3	628,974.2	0.00	0.28
Maximum:	1	4.0	25.3	15.2	29.2	1,088,877.4	0.13	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2023 16:00	0	12.7	18.1	15.5	1.8	794,266.1	0.85	0.85
02/22/2023 17:00	0	2.0	12.1	14.2	22.6	988,029.5	0.20	1.00
02/22/2023 18:00	0	1.9	15.4	13.5	29.6	1,096,094.7	0.00	1.00
02/22/2023 19:00	0	1.9	15.3	13.5	29.5	1,096,834.9	0.00	1.00
02/22/2023 20:00	0	1.9	15.2	13.5	29.8	1,095,354.4	0.00	1.00
02/22/2023 21:00	0	1.9	14.5	13.6	28.3	1,085,972.3	0.00	1.00
02/22/2023 22:00	0	1.7	10.4	14.4	17.9	1,025,172.2	0.00	1.00
02/22/2023 23:00	0	1.6	10.4	14.3	17.4	964,199.3	0.00	1.00
Average/Sum#:	0	3.2	13.9	14.1	22.1	1,018,240.4	1.05 #	7.85 #
Minimum:	0	1.6	10.4	13.5	1.8	794,266.1	0.00	0.00
Maximum:	0	12.7	18.1	15.5	29.8	1,096,834.9	0.85	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2023 00:00	0	1.8	13.8	13.7	27.6	1,083,557.0	0.00	1.00
02/23/2023 01:00	0	2.0	16.0	13.0	31.0	1,109,060.4	0.00	1.00
02/23/2023 02:00	0	2.0	15.3	13.2	29.3	1,107,988.8	0.00	1.00
02/23/2023 03:00	0	2.0	15.8	13.1	30.2	1,115,027.5	0.00	1.00
02/23/2023 04:00	0	2.0	15.3	13.1	29.2	1,100,631.0	0.00	1.00
02/23/2023 05:00	0	2.0	15.2	13.2	29.3	1,112,435.0	0.00	1.00
02/23/2023 06:00	1	2.1	16.2	13.0	31.4	1,110,620.5	0.00	1.00
02/23/2023 07:00	0	1.5	11.7	14.0	23.4	1,102,485.9	0.00	1.00
02/23/2023 08:00	0	1.8	11.7	14.0	24.3	1,105,661.3	0.00	1.00
02/23/2023 09:00	0	1.8	11.8	14.0	25.1	1,093,554.8	0.00	1.00
02/23/2023 10:00	0	1.7	11.7	14.0	24.9	1,092,959.4	0.00	1.00
02/23/2023 11:00	0	1.8	12.0	14.0	25.6	1,102,684.3	0.00	1.00
02/23/2023 12:00	1	1.7	11.8	14.2	25.2	983,124.1	0.00	1.00
02/23/2023 13:00	1	4.2	25.3	15.4	15.3	626,200.4	0.13	0.27
02/23/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.0	14.5	13.7	26.6	1,060,427.9	0.13 #	13.27 #
Minimum:	0	1.5	11.7	13.0	15.3	626,200.4	0.00	0.00
Maximum:	1	4.2	25.3	15.4	31.4	1,115,027.5	0.13	1.00
%SI	41.67	41.67	41.67	41.67	41.67	41.67	0.00	0.00

NH3 Slip Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2023 17:00	0	14.8	19.7	16.0	0.0	759,052.4	0.55	0.55
02/27/2023 18:00	0	2.9	11.1	14.3	19.0	978,101.0	0.35	1.00
02/27/2023 19:00	0	1.8	14.6	13.6	28.7	1,100,416.9	0.00	1.00
02/27/2023 20:00	0	1.8	14.6	13.6	29.2	1,099,103.8	0.00	1.00
02/27/2023 21:00	0	1.8	13.9	13.7	28.2	1,097,821.9	0.00	1.00
02/27/2023 22:00	0	1.6	12.5	14.2	24.7	987,620.7	0.00	1.00
02/27/2023 23:00	1	4.2	26.7	15.3	18.9	624,310.8	0.15	0.30
Average/Sum#:	0	4.1	16.2	14.4	21.2	949,489.6	1.05 #	5.85 #
Minimum:	0	1.6	11.1	13.6	0.0	624,310.8	0.00	0.00
Maximum:	1	14.8	26.7	16.0	29.2	1,100,416.9	0.55	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2023 16:00	0	3.5	5.4	19.9	0.0	672,387.4	0.10	0.10
02/28/2023 17:00	0	10.6	18.2	14.8	9.8	780,571.9	0.80	1.00
02/28/2023 18:00	0	1.7	11.3	14.1	23.4	1,049,220.7	0.00	1.00
02/28/2023 19:00	0	1.7	12.3	13.9	25.5	1,084,779.7	0.00	1.00
02/28/2023 20:00	0	1.7	12.1	14.0	25.3	1,098,119.6	0.00	1.00
02/28/2023 21:00	0	1.7	12.0	14.0	25.4	1,098,119.6	0.00	1.00
02/28/2023 22:00	0	1.7	12.0	14.0	25.8	1,094,745.6	0.00	1.00
02/28/2023 23:00	0	1.7	12.1	14.0	26.1	1,095,539.5	0.00	1.00
Average/Sum#:	0	3.0	11.9	14.8	20.2	996,685.5	0.90 #	7.10 #
Minimum:	0	1.7	5.4	13.9	0.0	672,387.4	0.00	0.00
Maximum:	0	10.6	18.2	19.9	26.1	1,098,119.6	0.80	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023 00:00	0	1.7	12.3	14.0	26.8	1,100,104.3	0.00	1.00
03/01/2023 01:00	0	1.7	12.3	14.0	26.8	1,102,882.8	0.00	1.00
03/01/2023 02:00	0	1.7	12.3	14.0	26.5	1,105,264.4	0.00	1.00
03/01/2023 03:00	0	1.7	12.2	13.9	26.4	1,093,974.5	0.00	1.00
03/01/2023 04:00	0	1.7	12.5	13.9	26.8	1,096,322.0	0.00	1.00
03/01/2023 05:00	0	1.7	13.3	13.9	26.1	1,105,516.7	0.00	1.00
03/01/2023 06:00	0	1.8	13.0	13.8	28.7	1,180,983.9	0.00	1.00
03/01/2023 07:00	1	1.7	12.5	14.2	27.9	999,066.6	0.00	1.00
03/01/2023 08:00	1	3.7	26.5	15.3	20.9	637,760.5	0.13	0.33
03/01/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	1.9	14.1	14.1	26.3	1,046,875.1	0.13 #	8.33 #
Minimum:	0	1.7	12.2	13.8	20.9	637,760.5	0.00	0.00
Maximum:	1	3.7	26.5	15.3	28.7	1,180,983.9	0.13	1.00
%SI	62.50	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2023 15:00	0	12.5	18.5	15.6	5.8	741,297.8	0.83	0.83
03/03/2023 16:00	0	2.0	16.8	14.6	22.8	729,055.5	0.22	1.00
03/03/2023 17:00	0	1.6	11.4	14.2	17.2	951,034.6	0.00	1.00
03/03/2023 18:00	0	1.8	12.4	13.9	23.9	1,085,953.5	0.00	1.00
03/03/2023 19:00	0	1.8	12.7	13.8	24.7	1,090,524.7	0.00	1.00
03/03/2023 20:00	0	1.9	13.0	13.6	25.3	1,083,533.6	0.00	1.00
03/03/2023 21:00	0	1.8	12.2	13.8	23.0	1,048,091.8	0.00	1.00
03/03/2023 22:00	1	2.3	14.1	14.6	18.7	850,782.1	0.12	1.00
03/03/2023 23:00	0	13.4	29.6	17.7	0.0	56,060.8	0.02	0.02
Average/Sum#:	0	4.3	15.6	14.6	17.9	848,481.6	1.19 #	7.85 #
Minimum:	0	1.6	11.4	13.6	0.0	56,060.8	0.00	0.00
Maximum:	1	13.4	29.6	17.7	25.3	1,090,524.7	0.83	1.00
%SI	70.83	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2023 16:00	0	1.0	2.4	20.6	0.0	1,433,330.9	0.05	0.05
03/04/2023 17:00	2	10.6	21.2	15.0	21.6	696,317.5	0.77	1.00
03/04/2023 18:00	0	1.4	12.1	14.1	13.7	1,034,922.3	0.00	1.00
03/04/2023 19:00	0	1.9	14.6	13.4	28.5	1,108,138.2	0.00	1.00
03/04/2023 20:00	0	1.9	13.7	13.6	26.9	1,097,040.2	0.00	1.00
03/04/2023 21:00	0	1.9	13.6	13.6	26.7	1,097,415.4	0.00	1.00
03/04/2023 22:00	1	2.4	15.3	14.5	21.3	894,405.3	0.13	1.00
03/04/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.0	13.3	15.0	19.8	1,051,652.8	0.95 #	6.05 #
Minimum:	0	1.0	2.4	13.4	0.0	696,317.5	0.00	0.00
Maximum:	2	10.6	21.2	20.6	28.5	1,433,330.9	0.77	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2023 15:00	0	3.4	5.3	20.1	0.0	732,642.0	0.10	0.10
03/05/2023 16:00	0	10.5	19.6	14.9	16.3	770,529.5	0.72	1.00
03/05/2023 17:00	0	1.6	12.4	13.9	16.7	992,441.4	0.00	1.00
03/05/2023 18:00	0	2.0	15.0	13.3	29.7	1,105,630.0	0.00	1.00
03/05/2023 19:00	0	2.0	15.2	13.2	30.4	1,105,499.0	0.00	1.00
03/05/2023 20:00	0	2.0	15.3	13.2	30.4	1,109,589.4	0.00	1.00
03/05/2023 21:00	0	1.9	14.3	13.3	28.6	1,098,062.1	0.00	1.00
03/05/2023 22:00	0	1.9	13.2	13.6	26.4	1,110,922.1	0.00	1.00
03/05/2023 23:00	0	1.8	11.5	13.9	23.5	1,094,952.6	0.00	1.00
Average/Sum#:	0	3.0	13.5	14.4	22.4	1,013,363.1	0.82 #	8.10 #
Minimum:	0	1.6	5.3	13.2	0.0	732,642.0	0.00	0.00
Maximum:	0	10.5	19.6	20.1	30.4	1,110,922.1	0.72	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2023 00:00	0	1.7	9.6	14.4	18.4	1,031,703.3	0.00	1.00
03/06/2023 01:00	1	2.5	16.5	14.7	21.5	802,880.3	0.13	0.77
03/06/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2023 13:00	0	14.8	20.1	15.7	1.8	732,378.7	0.83	0.83
03/06/2023 14:00	0	2.3	12.3	14.2	22.1	964,728.8	0.30	1.00
03/06/2023 15:00	0	1.5	11.5	14.0	24.7	1,094,745.6	0.00	1.00
03/06/2023 16:00	0	1.5	11.5	14.0	23.8	1,094,547.2	0.00	1.00
03/06/2023 17:00	0	1.8	12.1	14.0	23.2	1,093,157.9	0.00	1.00
03/06/2023 18:00	0	1.8	12.3	14.0	23.3	1,085,814.6	0.00	1.00
03/06/2023 19:00	0	1.7	12.2	14.1	23.6	1,097,754.8	0.00	1.00
03/06/2023 20:00	0	1.7	12.1	14.1	23.8	1,095,740.9	0.00	1.00
03/06/2023 21:00	0	1.7	12.1	14.1	23.9	1,095,338.1	0.00	1.00
03/06/2023 22:00	0	1.7	12.2	14.1	23.9	1,096,143.7	0.00	1.00
03/06/2023 23:00	0	1.7	12.2	14.1	24.0	1,095,539.5	0.00	1.00
Average/Sum#:	0	2.8	12.8	14.3	21.4	1,029,267.2	1.26 #	12.60 #
Minimum:	0	1.5	9.6	14.0	1.8	732,378.7	0.00	0.00
Maximum:	1	14.8	20.1	15.7	24.7	1,097,754.8	0.83	1.00
%SI	50.00	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2023 00:00	0	1.7	12.1	14.1	23.5	1,095,539.5	0.00	1.00
03/07/2023 01:00	0	1.7	11.7	14.1	22.0	1,103,192.2	0.00	1.00
03/07/2023 02:00	0	1.7	12.0	14.1	22.4	1,101,178.3	0.00	1.00
03/07/2023 03:00	0	1.7	11.9	14.1	22.6	1,102,386.6	0.00	1.00
03/07/2023 04:00	0	1.7	12.4	14.0	22.8	1,099,707.3	0.00	1.00
03/07/2023 05:00	0	1.9	13.8	13.7	24.4	1,104,859.2	0.00	1.00
03/07/2023 06:00	0	2.0	14.1	13.1	27.6	1,094,310.5	0.00	1.00
03/07/2023 07:00	1	1.7	11.4	14.2	23.9	981,080.2	0.00	1.00
03/07/2023 08:00	1	3.8	25.4	15.4	18.0	632,674.1	0.13	0.28
03/07/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2023 16:00	0	9.0	17.4	19.0	0.0	774,085.2	0.20	0.20
03/07/2023 17:00	0	7.2	21.6	14.7	24.2	696,197.7	0.67	1.00
03/07/2023 18:00	0	1.6	12.7	14.3	20.3	967,726.6	0.00	1.00
03/07/2023 19:00	0	1.8	11.5	14.1	23.8	1,096,345.1	0.00	1.00
03/07/2023 20:00	0	1.7	11.5	14.1	24.4	1,095,539.5	0.00	1.00
03/07/2023 21:00	0	1.7	11.3	14.1	23.9	1,096,345.1	0.00	1.00
03/07/2023 22:00	0	1.7	11.3	14.1	24.0	1,096,747.8	0.00	1.00
03/07/2023 23:00	0	1.7	11.1	14.1	23.6	1,095,338.1	0.00	1.00
Average/Sum#:	0	2.6	13.7	14.4	21.8	1,013,720.8	1.00 #	15.48 #
Minimum:	0	1.6	11.1	13.1	0.0	632,674.1	0.00	0.00
Maximum:	1	9.0	25.4	19.0	27.6	1,104,859.2	0.67	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2023 00:00	0	1.7	11.2	14.1	24.0	1,095,338.1	0.00	1.00
03/08/2023 01:00	0	1.7	11.4	14.1	24.4	1,095,740.9	0.00	1.00
03/08/2023 02:00	0	1.7	11.7	14.1	24.4	1,096,143.7	0.00	1.00
03/08/2023 03:00	0	1.7	11.5	14.1	24.0	1,096,143.7	0.00	1.00
03/08/2023 04:00	0	1.7	11.3	14.1	23.8	1,098,157.5	0.00	1.00
03/08/2023 05:00	0	1.7	11.0	14.1	23.3	1,099,970.0	0.00	1.00
03/08/2023 06:00	0	1.8	10.9	14.0	23.1	1,088,990.1	0.00	1.00
03/08/2023 07:00	0	1.8	11.1	13.9	23.4	1,087,909.9	0.00	1.00
03/08/2023 08:00	0	1.8	11.2	13.9	23.1	1,091,822.5	0.00	1.00
03/08/2023 09:00	0	1.8	11.3	14.0	24.1	1,096,333.4	0.00	1.00
03/08/2023 10:00	0	1.7	12.0	14.0	25.0	966,535.8	0.00	1.00
03/08/2023 11:00	0	4.0	24.1	15.2	16.3	638,824.5	0.13	0.37
03/08/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2023 18:00	1	10.1	20.2	15.6	15.7	714,684.5	0.63	0.70
03/08/2023 19:00	0	1.6	14.4	14.4	21.1	869,268.5	0.00	1.00
03/08/2023 20:00	0	1.8	13.7	13.9	24.9	1,091,822.5	0.00	1.00
03/08/2023 21:00	0	1.8	13.1	14.0	25.1	1,097,921.1	0.00	1.00
03/08/2023 22:00	0	1.8	12.8	14.0	24.6	1,098,715.0	0.00	1.00
03/08/2023 23:00	0	1.8	12.3	14.0	24.1	1,099,508.9	0.00	1.00
Average/Sum#:	0	2.3	13.1	14.2	23.0	1,029,101.7	0.76 #	17.07 #
Minimum:	0	1.6	10.9	13.9	15.7	638,824.5	0.00	0.00
Maximum:	1	10.1	24.1	15.6	25.1	1,099,970.0	0.63	1.00
%SI	25.00	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2023 00:00	0	1.8	12.4	14.0	24.2	1,099,310.4	0.00	1.00
03/09/2023 01:00	0	1.8	12.0	14.0	23.5	1,099,508.9	0.00	1.00
03/09/2023 02:00	0	1.8	12.2	14.0	23.8	1,099,111.9	0.00	1.00
03/09/2023 03:00	0	1.8	12.1	14.0	24.1	1,099,111.9	0.00	1.00
03/09/2023 04:00	0	1.8	12.3	14.0	24.7	1,097,722.6	0.00	1.00
03/09/2023 05:00	0	1.8	12.7	13.8	25.7	1,097,275.4	0.00	1.00
03/09/2023 06:00	0	1.8	11.5	13.9	25.2	1,089,279.3	0.00	1.00
03/09/2023 07:00	0	1.8	11.4	14.0	24.9	1,099,508.9	0.00	1.00
03/09/2023 08:00	0	1.8	11.2	13.9	24.3	1,083,801.6	0.00	1.00
03/09/2023 09:00	0	1.8	11.3	13.9	24.3	1,088,105.5	0.00	1.00
03/09/2023 10:00	0	1.8	11.4	13.9	24.5	1,094,757.0	0.00	1.00
03/09/2023 11:00	0	1.9	12.7	13.4	26.5	1,083,488.6	0.00	1.00
03/09/2023 12:00	1	2.0	13.5	13.2	28.9	1,092,516.1	0.00	1.00
03/09/2023 13:00	1	2.1	15.0	12.7	31.8	1,082,513.3	0.00	1.00
03/09/2023 14:00	1	2.0	14.5	12.9	30.0	1,083,899.4	0.00	1.00
03/09/2023 15:00	0	2.0	12.9	13.3	26.1	1,079,683.0	0.00	1.00
03/09/2023 16:00	0	1.8	10.8	13.9	23.0	1,073,041.8	0.00	1.00
03/09/2023 17:00	0	1.8	10.7	13.9	22.4	1,070,498.6	0.00	1.00
03/09/2023 18:00	0	1.8	10.7	13.9	22.2	1,070,694.2	0.00	1.00
03/09/2023 19:00	0	1.8	10.6	13.9	22.1	1,072,650.6	0.00	1.00
03/09/2023 20:00	0	1.8	10.7	13.9	22.2	1,074,020.0	0.00	1.00
03/09/2023 21:00	0	1.8	10.7	13.9	22.1	1,074,411.2	0.00	1.00
03/09/2023 22:00	1	1.7	10.1	14.1	20.6	969,673.3	0.00	1.00
03/09/2023 23:00	1	4.7	22.7	15.3	14.1	603,280.3	0.13	0.27
Average/Sum#:	0	2.0	12.3	13.8	24.2	1,061,577.7	0.13 #	23.27 #
Minimum:	0	1.7	10.1	12.7	14.1	603,280.3	0.00	0.27
Maximum:	1	4.7	22.7	15.3	31.8	1,099,508.9	0.13	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 15:00	0	12.4	14.7	19.1	0.0	724,273.3	0.18	0.18
03/10/2023 16:00	0	9.0	17.0	14.6	9.5	737,532.8	0.82	1.00
03/10/2023 17:00	0	1.8	11.1	14.1	21.0	981,353.7	0.00	1.00
03/10/2023 18:00	0	1.8	11.8	13.7	23.2	1,065,868.6	0.00	1.00
03/10/2023 19:00	0	1.8	11.4	13.8	23.0	1,065,643.6	0.00	1.00
03/10/2023 20:00	0	3.1	13.8	14.5	16.6	905,103.9	0.15	0.88
03/10/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	5.0	13.3	15.0	15.6	913,296.0	1.15 #	5.06 #
Minimum:	0	1.8	11.1	13.7	0.0	724,273.3	0.00	0.00
Maximum:	0	12.4	17.0	19.1	23.2	1,065,868.6	0.82	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2023 16:00	0	0.0	0.0	20.9	0.0	0.0	0.02	0.02
03/11/2023 17:00	0	10.8	17.9	15.3	12.7	699,140.1	1.00	1.00
03/11/2023 18:00	1	1.6	18.6	14.6	28.6	656,454.2	0.00	1.00
03/11/2023 19:00	0	1.9	11.4	13.5	17.8	1,004,491.3	0.00	1.00
03/11/2023 20:00	0	1.9	12.0	13.5	23.6	1,070,926.9	0.00	1.00
03/11/2023 21:00	1	2.0	13.3	13.1	26.6	1,075,524.8	0.00	1.00
03/11/2023 22:00	1	2.1	14.5	12.8	29.5	1,073,223.0	0.00	1.00
03/11/2023 23:00	1	2.1	14.3	12.8	29.0	1,068,151.0	0.00	1.00
Average/Sum#:	1	2.8	12.8	14.6	21.0	830,988.9	1.02 #	7.02 #
Minimum:	0	0.0	0.0	12.8	0.0	0.0	0.00	0.00
Maximum:	1	10.8	18.6	20.9	29.5	1,075,524.8	1.00	1.00
%SI	75.00	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2023 00:00	0	2.0	12.9	13.3	25.7	1,070,133.1	0.00	1.00
03/12/2023 01:00	0	1.7	9.3	14.4	19.1	1,062,884.0	0.00	1.00
03/12/2023 02:00	0	1.6	9.4	14.4	19.2	1,062,673.3	0.00	1.00
03/12/2023 03:00	0	1.7	9.7	14.2	20.3	1,041,988.9	0.00	1.00
03/12/2023 04:00	1	2.0	13.2	13.1	26.5	1,069,028.9	0.00	1.00
03/12/2023 05:00	1	2.0	13.2	13.1	26.4	1,068,677.7	0.00	1.00
03/12/2023 06:00	0	1.7	10.1	14.0	20.0	976,657.6	0.00	1.00
03/12/2023 07:00	1	4.4	22.2	15.2	18.7	619,604.5	0.15	0.33
03/12/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2023 15:00	0	8.6	17.5	15.4	12.0	693,675.7	0.82	0.88
03/12/2023 16:00	0	1.6	12.4	14.3	18.8	843,440.9	0.00	1.00
03/12/2023 17:00	1	2.1	13.9	12.9	27.6	1,064,385.1	0.00	1.00
03/12/2023 18:00	1	2.1	14.4	12.8	29.0	1,069,841.7	0.00	1.00
03/12/2023 19:00	1	2.0	13.8	13.0	27.5	1,074,391.4	0.00	1.00
03/12/2023 20:00	1	2.1	14.1	12.9	28.5	1,077,565.8	0.00	1.00
03/12/2023 21:00	1	2.1	14.0	12.9	28.2	1,072,772.8	0.00	1.00
03/12/2023 22:00	1	2.0	12.9	13.2	25.9	1,063,349.1	0.00	1.00
03/12/2023 23:00	0	1.7	9.1	14.3	16.4	918,966.8	0.00	1.00
Average/Sum#:	1	2.4	13.1	13.7	22.9	991,178.7	0.97 #	16.21 #
Minimum:	0	1.6	9.1	12.8	12.0	619,604.5	0.00	0.00
Maximum:	1	8.6	22.2	15.4	29.0	1,077,565.8	0.82	1.00
%SI	29.17	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2023 00:00	2	4.2	23.8	15.2	20.1	617,442.2	0.13	0.27
03/13/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2023 16:00	0	0.0	0.0	0.0	0.0	69,978.2	0.22	0.22
03/13/2023 17:00	1	4.8	13.4	14.5	17.2	734,995.7	0.63	1.00
03/13/2023 18:00	0	1.1	11.2	13.6	15.6	986,735.9	0.00	1.00
03/13/2023 19:00	0	2.0	13.1	13.3	25.5	1,069,052.0	0.00	1.00
03/13/2023 20:00	1	2.1	14.3	12.9	28.4	1,065,754.5	0.00	1.00
03/13/2023 21:00	0	2.0	13.4	13.2	26.2	1,065,483.3	0.00	1.00
03/13/2023 22:00	0	2.6	12.8	14.5	17.7	909,597.4	0.13	1.00
03/13/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.7	14.6	13.9	18.8	921,294.4	1.11 #	6.49 #
Minimum:	0	1.1	11.2	12.9	0.0	617,442.2	0.00	0.00
Maximum:	2	4.8	23.8	15.2	28.4	1,069,052.0	0.63	1.00
%SI	70.83	70.83	70.83	70.83	66.67	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2023 09:00	2	9.6	17.5	15.5	18.6	706,267.9	0.65	0.85
03/14/2023 10:00	0	1.6	10.8	13.8	11.8	1,009,323.6	0.00	1.00
03/14/2023 11:00	0	2.0	12.9	13.2	25.0	1,046,631.5	0.00	1.00
03/14/2023 12:00	1	2.0	13.3	13.1	25.9	1,046,556.3	0.00	1.00
03/14/2023 13:00	1	2.1	14.2	12.7	28.6	1,040,595.5	0.00	1.00
03/14/2023 14:00	1	2.0	13.3	13.0	25.6	1,037,642.3	0.00	1.00
03/14/2023 15:00	0	1.9	11.8	13.5	23.1	1,044,833.8	0.00	1.00
03/14/2023 16:00	1	2.0	13.1	13.1	26.1	1,049,892.0	0.00	1.00
03/14/2023 17:00	1	2.0	13.8	13.0	28.0	1,065,897.5	0.00	1.00
03/14/2023 18:00	1	2.1	14.4	12.9	29.6	1,073,457.5	0.00	1.00
03/14/2023 19:00	1	2.1	14.7	12.8	30.5	1,074,406.4	0.00	1.00
03/14/2023 20:00	1	2.0	14.5	12.9	30.0	1,074,655.8	0.00	1.00
03/14/2023 21:00	0	1.9	12.6	13.5	26.1	1,083,140.7	0.00	1.00
03/14/2023 22:00	0	1.7	10.5	14.0	20.2	997,695.1	0.00	1.00
03/14/2023 23:00	1	6.0	20.4	15.0	12.8	672,178.5	0.13	0.28
Average/Sum#:	1	2.7	13.9	13.5	24.1	1,001,545.0	0.78 #	14.13 #
Minimum:	0	1.6	10.5	12.7	11.8	672,178.5	0.00	0.00
Maximum:	2	9.6	20.4	15.5	30.5	1,083,140.7	0.65	1.00
%SI	37.50	37.50	37.50	37.50	37.50	37.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 16:00	0	19.1	22.0	18.6	0.0	767,473.1	0.22	0.22
03/15/2023 17:00	0	7.4	15.4	14.5	15.1	738,419.3	0.58	1.00
03/15/2023 18:00	0	1.8	11.0	13.9	18.4	1,000,658.0	0.00	1.00
03/15/2023 19:00	0	1.9	13.2	13.4	26.3	1,072,898.4	0.00	1.00
03/15/2023 20:00	0	2.0	14.0	13.2	27.6	1,078,999.7	0.00	1.00
03/15/2023 21:00	0	3.6	13.4	14.5	15.5	927,571.0	0.17	0.92
03/15/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	6.0	14.8	14.7	17.2	931,003.3	0.97 #	5.14 #
Minimum:	0	1.8	11.0	13.2	0.0	738,419.3	0.00	0.00
Maximum:	0	19.1	22.0	18.6	27.6	1,078,999.7	0.58	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2023 15:00	0	22.4	24.8	18.3	0.0	750,023.2	0.25	0.25
03/16/2023 16:00	1	5.9	10.8	14.4	10.2	833,874.1	0.78	1.00
03/16/2023 17:00	0	1.6	12.6	14.5	19.2	696,908.6	0.00	1.00
03/16/2023 18:00	0	1.6	12.7	14.6	18.4	702,753.8	0.00	1.00
03/16/2023 19:00	0	1.6	12.6	14.5	18.9	695,410.8	0.00	1.00
03/16/2023 20:00	0	1.6	12.9	14.5	19.2	697,122.6	0.00	1.00
03/16/2023 21:00	0	1.6	10.8	14.4	16.5	784,574.8	0.00	1.00
03/16/2023 22:00	0	1.6	10.8	14.4	16.0	783,310.7	0.00	1.00
03/16/2023 23:00	1	1.6	12.6	14.5	19.6	710,388.9	0.00	1.00
Average/Sum#:	0	4.4	13.4	14.9	15.3	739,374.2	1.03 #	8.25 #
Minimum:	0	1.6	10.8	14.4	0.0	695,410.8	0.00	0.00
Maximum:	1	22.4	24.8	18.3	19.6	833,874.1	0.78	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2023 00:00	1	1.6	12.8	14.5	20.0	705,681.5	0.00	1.00
03/17/2023 01:00	0	1.6	11.6	14.5	17.1	815,449.4	0.00	1.00
03/17/2023 02:00	0	1.4	12.0	14.4	20.0	789,420.5	0.00	1.00
03/17/2023 03:00	0	1.8	11.2	13.6	22.4	1,017,876.3	0.00	1.00
03/17/2023 04:00	1	2.0	14.7	13.0	30.6	1,093,632.7	0.00	1.00
03/17/2023 05:00	1	2.1	15.2	12.9	32.3	1,098,449.5	0.00	1.00
03/17/2023 06:00	1	2.0	14.0	13.2	29.5	1,090,915.5	0.00	1.00
03/17/2023 07:00	1	1.7	12.2	14.2	24.5	928,142.7	0.00	1.00
03/17/2023 08:00	1	3.7	17.4	14.8	14.4	688,753.1	0.15	0.52
03/17/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2023 16:00	0	16.6	23.8	17.5	0.0	741,503.0	0.35	0.35
03/17/2023 17:00	0	4.0	11.5	14.4	16.2	832,820.7	0.52	1.00
03/17/2023 18:00	1	1.6	13.2	13.6	30.7	1,086,347.5	0.00	1.00
03/17/2023 19:00	0	1.9	14.7	13.1	26.8	1,070,960.1	0.00	1.00
03/17/2023 20:00	0	1.9	13.3	13.4	27.0	1,065,412.2	0.00	1.00
03/17/2023 21:00	1	2.0	14.1	13.2	28.5	1,069,573.8	0.00	1.00
03/17/2023 22:00	0	2.4	13.3	14.4	19.1	893,075.4	0.12	1.00
03/17/2023 23:00	0	17.3	30.8	17.5	0.0	379,008.3	0.03	0.03
Average/Sum#:	1	3.9	15.0	14.2	21.1	903,942.5	1.17 #	14.90 #
Minimum:	0	1.4	11.2	12.9	0.0	379,008.3	0.00	0.00
Maximum:	1	17.3	30.8	17.5	32.3	1,098,449.5	0.52	1.00
%SI	37.50	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 15:00	0	2.9	4.3	20.1	0.0	657,323.7	0.08	0.08
03/18/2023 16:00	0	10.2	15.8	14.9	9.1	768,703.6	0.78	1.00
03/18/2023 17:00	0	1.7	11.7	13.9	23.5	1,053,869.9	0.00	1.00
03/18/2023 18:00	1	2.1	15.1	12.8	30.5	1,064,262.5	0.00	1.00
03/18/2023 19:00	0	1.9	13.1	13.4	26.0	1,067,055.5	0.00	1.00
03/18/2023 20:00	0	1.9	13.0	13.4	25.6	1,050,257.2	0.00	1.00
03/18/2023 21:00	0	3.2	14.1	14.5	16.5	871,724.2	0.15	0.90
03/18/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	3.4	12.4	14.7	18.7	933,313.8	1.01 #	5.98 #
Minimum:	0	1.7	4.3	12.8	0.0	657,323.7	0.00	0.00
Maximum:	1	10.2	15.8	20.1	30.5	1,067,055.5	0.78	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2023 15:00	0	20.7	23.2	17.5	0.0	739,086.4	0.30	0.30
03/19/2023 16:00	0	5.4	11.9	14.4	10.7	786,681.6	0.72	1.00
03/19/2023 17:00	0	1.9	12.9	13.7	27.5	1,105,810.2	0.00	1.00
03/19/2023 18:00	0	2.0	14.3	13.0	27.7	1,060,350.5	0.00	1.00
03/19/2023 19:00	0	1.9	13.3	13.2	25.9	1,055,346.0	0.00	1.00
03/19/2023 20:00	0	2.0	13.4	13.2	25.7	1,064,238.4	0.00	1.00
03/19/2023 21:00	0	1.9	12.2	13.6	24.2	1,073,403.6	0.00	1.00
03/19/2023 22:00	0	1.8	11.7	13.7	23.4	1,062,445.1	0.00	1.00
03/19/2023 23:00	0	1.9	11.9	13.6	23.8	1,057,833.4	0.00	1.00
Average/Sum#:	0	4.4	13.9	14.0	21.0	1,000,577.2	1.02 #	8.30 #
Minimum:	0	1.8	11.7	13.0	0.0	739,086.4	0.00	0.00
Maximum:	0	20.7	23.2	17.5	27.7	1,105,810.2	0.72	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2023 00:00	0	1.7	10.7	14.1	20.9	956,180.4	0.00	1.00
03/20/2023 01:00	0	6.2	21.7	15.2	9.5	623,208.2	0.15	0.28
03/20/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 16:00	0	16.5	19.7	16.3	0.0	722,817.9	0.48	0.48
03/20/2023 17:00	0	4.2	10.7	14.4	15.2	933,104.7	0.67	1.00
03/20/2023 18:00	1	2.0	14.0	13.1	28.2	1,066,746.5	0.00	1.00
03/20/2023 19:00	1	2.0	14.1	13.2	28.0	1,077,754.8	0.00	1.00
03/20/2023 20:00	1	6.5	16.8	14.1	13.9	876,230.2	0.28	0.60
03/20/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	5.6	15.4	14.3	16.5	893,720.4	1.58 #	5.36 #
Minimum:	0	1.7	10.7	13.1	0.0	623,208.2	0.00	0.00
Maximum:	1	16.5	21.7	16.3	28.2	1,077,754.8	0.67	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2023 11:00	0	18.1	19.9	16.4	0.0	747,097.1	0.47	0.47
03/21/2023 12:00	0	3.5	9.1	14.3	12.8	901,745.2	0.62	1.00
03/21/2023 13:00	1	1.6	11.8	14.3	18.3	701,726.3	0.00	1.00
03/21/2023 14:00	0	1.6	12.2	14.5	17.9	690,061.5	0.00	1.00
03/21/2023 15:00	0	1.6	12.2	14.5	17.6	686,210.0	0.00	1.00
03/21/2023 16:00	0	1.6	12.3	14.5	17.9	684,284.2	0.00	1.00
03/21/2023 17:00	0	1.6	12.6	14.5	18.7	688,777.7	0.00	1.00
03/21/2023 18:00	0	1.6	13.0	14.5	19.4	688,349.7	0.00	1.00
03/21/2023 19:00	1	1.6	13.7	14.5	21.2	685,782.1	0.00	1.00
03/21/2023 20:00	1	1.6	13.8	14.5	21.2	688,563.7	0.00	1.00
03/21/2023 21:00	1	1.6	13.7	14.5	20.9	690,275.5	0.00	1.00
03/21/2023 22:00	0	1.6	13.0	14.5	19.0	697,764.5	0.00	1.00
03/21/2023 23:00	0	1.7	12.4	14.4	18.6	693,350.1	0.00	1.00
Average/Sum#:	0	3.0	13.1	14.6	17.2	711,076.0	1.09 #	12.47 #
Minimum:	0	1.6	9.1	14.3	0.0	684,284.2	0.00	0.00
Maximum:	1	18.1	19.9	16.4	21.2	901,745.2	0.62	1.00
%SI	50.00	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2023 00:00	1	1.7	12.2	14.4	18.9	694,824.9	0.00	1.00
03/22/2023 01:00	1	1.6	12.9	14.5	19.8	697,978.5	0.00	1.00
03/22/2023 02:00	1	1.8	13.3	14.5	18.9	696,908.6	0.00	1.00
03/22/2023 03:00	1	1.7	13.3	14.4	20.0	685,765.6	0.00	1.00
03/22/2023 04:00	1	1.6	13.2	14.5	20.2	696,266.7	0.00	1.00
03/22/2023 05:00	0	1.6	12.8	14.4	18.1	704,094.8	0.00	1.00
03/22/2023 06:00	0	1.6	8.0	14.5	14.1	894,191.3	0.00	1.00
03/22/2023 07:00	0	1.5	14.0	14.5	22.1	693,271.1	0.00	1.00
03/22/2023 08:00	0	1.6	13.9	14.5	20.7	693,913.0	0.00	1.00
03/22/2023 09:00	0	1.6	12.8	14.5	18.2	699,476.3	0.00	1.00
03/22/2023 10:00	0	1.6	12.5	14.5	18.6	702,257.9	0.00	1.00
03/22/2023 11:00	0	1.6	12.3	14.5	18.3	704,183.7	0.00	1.00
03/22/2023 12:00	0	1.6	12.5	14.5	18.9	699,690.3	0.00	1.00
03/22/2023 13:00	0	1.6	12.3	14.5	18.0	700,974.1	0.00	1.00
03/22/2023 14:00	0	1.6	11.8	14.5	17.4	708,677.1	0.00	1.00
03/22/2023 15:00	0	1.6	10.9	14.5	16.1	809,030.2	0.00	1.00
03/22/2023 16:00	0	1.6	10.7	14.4	18.7	831,556.6	0.00	1.00
03/22/2023 17:00	0	1.7	12.4	13.8	20.2	935,066.1	0.00	1.00
03/22/2023 18:00	1	2.1	14.7	12.9	29.2	1,087,323.0	0.00	1.00
03/22/2023 19:00	1	2.0	14.6	12.9	29.4	1,078,421.7	0.00	1.00
03/22/2023 20:00	1	2.0	14.1	13.1	28.5	1,084,654.3	0.00	1.00
03/22/2023 21:00	0	1.9	12.3	13.6	25.0	1,083,346.0	0.00	1.00
03/22/2023 22:00	0	1.7	10.5	14.1	21.1	996,054.9	0.00	1.00
03/22/2023 23:00	0	1.5	10.7	14.4	15.9	822,076.0	0.00	1.00
Average/Sum#:	0	1.7	12.4	14.2	20.3	808,333.4	0.00 #	24.00 #
Minimum:	0	1.5	8.0	12.9	14.1	685,765.6	0.00	1.00
Maximum:	1	2.1	14.7	14.5	29.4	1,087,323.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2023 00:00	0	1.6	11.7	14.4	18.2	720,738.6	0.00	1.00
03/23/2023 01:00	0	1.6	12.2	14.4	18.5	701,145.3	0.00	1.00
03/23/2023 02:00	0	1.6	12.4	14.4	18.4	701,777.3	0.00	1.00
03/23/2023 03:00	1	1.7	12.3	14.4	18.2	700,934.6	0.00	1.00
03/23/2023 04:00	0	1.6	12.6	14.4	19.2	697,985.1	0.00	1.00
03/23/2023 05:00	0	1.6	13.5	14.5	20.4	700,760.1	0.00	1.00
03/23/2023 06:00	0	1.6	13.5	14.5	20.2	702,471.9	0.00	1.00
03/23/2023 07:00	0	1.7	12.7	14.4	19.3	699,670.5	0.00	1.00
03/23/2023 08:00	1	1.6	13.1	14.5	20.0	706,323.4	0.00	1.00
03/23/2023 09:00	1	1.6	14.1	14.5	21.9	699,048.4	0.00	1.00
03/23/2023 10:00	1	1.6	13.8	14.5	21.0	699,262.3	0.00	1.00
03/23/2023 11:00	0	1.6	13.5	14.5	20.2	697,978.5	0.00	1.00
03/23/2023 12:00	0	1.6	13.2	14.5	19.7	697,122.6	0.00	1.00
03/23/2023 13:00	0	1.6	12.9	14.5	19.2	697,978.5	0.00	1.00
03/23/2023 14:00	0	1.6	11.7	14.5	17.4	782,283.7	0.00	1.00
03/23/2023 15:00	0	1.6	12.2	14.5	20.6	776,292.4	0.00	1.00
03/23/2023 16:00	0	1.6	12.0	14.4	19.0	858,945.1	0.00	1.00
03/23/2023 17:00	0	1.8	12.6	13.9	22.7	1,074,411.2	0.00	1.00
03/23/2023 18:00	0	1.8	12.4	13.9	23.5	1,074,215.6	0.00	1.00
03/23/2023 19:00	0	1.8	12.1	14.0	23.9	1,086,211.5	0.00	1.00
03/23/2023 20:00	0	1.8	12.0	14.0	23.8	1,085,020.7	0.00	1.00
03/23/2023 21:00	0	1.8	11.9	14.0	24.0	1,083,631.5	0.00	1.00
03/23/2023 22:00	0	1.6	11.9	14.3	22.1	896,973.0	0.00	1.00
03/23/2023 23:00	0	1.6	12.3	14.4	18.4	742,438.7	0.00	1.00
Average/Sum#:	0	1.7	12.6	14.3	20.4	803,484.2	0.00 #	24.00 #
Minimum:	0	1.6	11.7	13.9	17.4	697,122.6	0.00	1.00
Maximum:	1	1.8	14.1	14.5	24.0	1,086,211.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2023 00:00	1	1.6	13.8	14.5	21.7	707,607.3	0.00	1.00
03/24/2023 01:00	1	1.6	14.2	14.5	22.4	707,393.3	0.00	1.00
03/24/2023 02:00	1	1.6	15.1	14.5	23.9	708,249.2	0.00	1.00
03/24/2023 03:00	1	1.7	15.5	14.5	24.2	707,393.3	0.00	1.00
03/24/2023 04:00	1	1.6	15.5	14.5	24.8	707,607.3	0.00	1.00
03/24/2023 05:00	1	1.6	15.6	14.5	25.3	706,751.4	0.00	1.00
03/24/2023 06:00	1	1.6	16.1	14.5	26.1	707,179.3	0.00	1.00
03/24/2023 07:00	1	1.6	15.7	14.5	25.2	704,825.6	0.00	1.00
03/24/2023 08:00	1	1.6	15.3	14.5	24.3	703,969.7	0.00	1.00
03/24/2023 09:00	1	1.6	15.1	14.5	24.0	704,183.7	0.00	1.00
03/24/2023 10:00	1	1.6	14.5	14.5	22.7	703,969.7	0.00	1.00
03/24/2023 11:00	0	1.6	13.7	14.5	21.0	706,109.4	0.00	1.00
03/24/2023 12:00	0	1.6	13.5	14.5	20.8	705,681.5	0.00	1.00
03/24/2023 13:00	0	1.6	13.1	14.5	20.0	706,751.4	0.00	1.00
03/24/2023 14:00	0	1.6	13.0	14.6	20.3	717,969.6	0.00	1.00
03/24/2023 15:00	0	1.6	13.0	14.6	20.1	716,882.8	0.00	1.00
03/24/2023 16:00	0	1.6	13.0	14.6	20.2	716,013.3	0.00	1.00
03/24/2023 17:00	0	1.6	13.0	14.5	20.0	706,537.4	0.00	1.00
03/24/2023 18:00	0	1.6	13.2	14.5	20.5	706,751.4	0.00	1.00
03/24/2023 19:00	1	1.6	13.1	14.5	20.3	706,751.4	0.00	1.00
03/24/2023 20:00	0	1.6	13.2	14.5	20.3	707,179.3	0.00	1.00
03/24/2023 21:00	1	1.6	13.2	14.5	20.5	710,816.8	0.00	1.00
03/24/2023 22:00	1	1.6	13.5	14.5	21.3	709,533.0	0.00	1.00
03/24/2023 23:00	1	1.6	14.1	14.5	22.7	707,821.2	0.00	1.00
Average/Sum#:	1	1.6	14.1	14.5	22.2	708,080.3	0.00 #	24.00 #
Minimum:	0	1.6	13.0	14.5	20.0	703,969.7	0.00	1.00
Maximum:	1	1.7	16.1	14.6	26.1	717,969.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2023 00:00	1	1.6	14.7	14.5	23.6	705,253.6	0.00	1.00
03/25/2023 01:00	1	1.6	15.0	14.5	24.3	704,183.7	0.00	1.00
03/25/2023 02:00	1	1.8	15.6	14.5	24.0	703,541.8	0.00	1.00
03/25/2023 03:00	1	1.6	15.7	14.5	25.7	704,611.6	0.00	1.00
03/25/2023 04:00	1	1.6	15.6	14.5	25.2	705,253.6	0.00	1.00
03/25/2023 05:00	1	1.6	15.7	14.5	25.6	703,969.7	0.00	1.00
03/25/2023 06:00	1	1.6	16.0	14.5	26.1	704,397.7	0.00	1.00
03/25/2023 07:00	1	1.6	15.9	14.5	25.9	703,113.8	0.00	1.00
03/25/2023 08:00	1	1.6	15.8	14.5	25.7	701,616.0	0.00	1.00
03/25/2023 09:00	1	1.6	15.5	14.5	25.1	700,118.2	0.00	1.00
03/25/2023 10:00	1	1.6	14.8	14.5	23.0	700,332.2	0.00	1.00
03/25/2023 11:00	1	1.6	14.1	14.5	21.8	700,546.2	0.00	1.00
03/25/2023 12:00	1	1.6	13.8	14.6	21.6	710,579.1	0.00	1.00
03/25/2023 13:00	0	1.6	13.8	14.6	21.1	708,188.0	0.00	1.00
03/25/2023 14:00	0	1.6	13.7	14.6	21.1	707,970.7	0.00	1.00
03/25/2023 15:00	0	1.6	13.7	14.6	21.0	708,188.0	0.00	1.00
03/25/2023 16:00	0	1.6	13.2	14.6	19.9	710,796.5	0.00	1.00
03/25/2023 17:00	0	1.6	12.8	14.5	19.5	703,113.8	0.00	1.00
03/25/2023 18:00	0	1.6	12.8	14.5	19.9	706,751.4	0.00	1.00
03/25/2023 19:00	1	1.6	13.1	14.5	20.4	707,393.3	0.00	1.00
03/25/2023 20:00	0	1.6	13.3	14.5	20.5	706,965.3	0.00	1.00
03/25/2023 21:00	1	1.6	13.9	14.5	22.1	707,179.3	0.00	1.00
03/25/2023 22:00	0	1.6	13.4	14.5	18.1	738,205.3	0.08	1.00
03/25/2023 23:00	0	13.2	34.8	15.9	0.0	592,413.0	0.12	0.12
Average/Sum#:	1	2.1	15.3	14.6	21.7	701,861.7	0.20 #	23.12 #
Minimum:	0	1.6	12.8	14.5	0.0	592,413.0	0.00	0.12
Maximum:	1	13.2	34.8	15.9	26.1	738,205.3	0.12	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

ATTACHMENT 15

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NO_x	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.47	8.89	14.83
01/02/2023	70.30	107.48	10.90	21.70	36.20
01/03/2023	43.16	158.77	17.15	34.27	57.16
01/04/2023	38.26	76.13	8.09	16.23	27.01
01/05/2023	70.05	62.66	5.86	11.58	19.33
01/06/2023	72.64	70.54	6.51	12.99	21.60
01/07/2023	11.01	41.31	4.50	8.90	14.85
01/08/2023	80.03	72.15	6.89	13.75	22.95
01/09/2023	97.02	81.86	7.88	15.71	26.15
01/10/2023	87.97	77.46	7.47	14.85	24.78
01/11/2023	80.37	71.25	6.96	13.78	22.99
01/12/2023	87.61	71.86	6.88	13.71	22.82
01/13/2023	10.90	41.32	4.55	8.91	14.91
01/14/2023	75.93	69.03	6.51	12.98	21.64
01/15/2023	91.63	75.97	7.42	14.68	24.52
01/16/2023	88.48	78.04	7.60	15.11	25.24
01/17/2023	81.23	76.97	7.38	14.75	24.53
01/18/2023	49.14	78.98	8.55	16.98	28.35
01/19/2023	21.19	46.72	5.30	10.47	17.49
01/20/2023	40.39	62.03	6.78	13.41	22.37
01/21/2023	22.86	59.46	6.41	12.76	21.27
01/22/2023	22.45	50.42	5.46	10.98	18.25
01/23/2023	75.82	95.38	9.25	18.54	30.88
01/24/2023	51.26	82.90	8.97	17.89	29.81
01/25/2023	13.09	41.63	4.56	8.99	15.02
01/26/2023	12.89	41.93	4.56	8.97	14.97
01/27/2023	90.68	65.49	6.08	12.15	20.23
01/28/2023	9.30	37.73	4.14	8.41	13.96
01/29/2023	92.90	62.63	5.49	11.15	18.46
01/30/2023	25.25	66.19	7.20	14.42	24.05
01/31/2023	29.56	64.58	7.04	14.11	23.50
Monthly Avg/Sum*:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
Daily Min:	8.02	37.73	4.14	8.41	13.96
Daily Max:	97.02	158.77	17.15	34.27	57.16
Jan 2023 - Jan 2023	1,651.39	2,129.79	216.81	432.02	720.12
QTD:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
YTD 2023:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.47	11.07	18.41
02/02/2023	8.96	37.94	4.18	8.37	13.99
02/03/2023	53.12	85.39	8.16	16.36	27.29
02/04/2023	108.11	77.99	7.53	14.98	24.95
02/05/2023	87.96	64.19	5.88	11.66	19.40
02/06/2023	84.25	78.56	7.67	15.20	25.38
02/07/2023	74.29	84.12	8.26	16.41	27.37
02/08/2023	102.79	114.57	11.51	22.94	38.30
02/09/2023	110.14	113.63	11.41	22.87	38.08
02/10/2023	71.93	81.12	7.82	15.48	25.86
02/11/2023	108.40	113.45	11.78	23.52	39.21
02/12/2023	106.28	114.76	11.68	23.35	38.89
02/13/2023	35.31	43.33	4.73	9.32	15.55
02/14/2023	68.07	90.12	8.73	17.38	28.96
02/15/2023	139.40	125.21	12.48	24.83	41.34
02/16/2023	113.23	113.19	11.51	23.10	38.43
02/17/2023	51.56	57.29	6.20	12.35	20.58
02/18/2023	14.71	41.46	4.56	8.89	14.89
02/19/2023	16.33	41.56	4.53	8.95	14.93
02/20/2023	93.55	78.91	7.60	15.18	25.29
02/21/2023	10.53	37.94	4.21	8.38	13.95
02/22/2023	74.47	82.53	7.57	15.25	25.37
02/23/2023	63.79	104.53	11.25	22.55	37.54
02/24/2023	33.93	63.80	6.90	13.85	23.09
02/25/2023	11.76	44.64	4.97	9.78	16.39
02/26/2023	8.81	37.99	4.12	8.40	13.93
02/27/2023	78.18	72.19	6.64	13.38	22.27
02/28/2023	82.98	77.32	7.24	14.49	24.11
Monthly Avg/Sum*:	1,832.18 *	2,127.93 *	214.59 *	428.29 *	713.75 *
Daily Min:	8.81	37.94	4.12	8.37	13.93
Daily Max:	139.40	125.21	12.48	24.83	41.34
Jan 2023 - Feb 2023	3,483.57	4,257.72	431.40	860.31	1,433.87
QTD:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *
YTD 2023:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2023	51.98	74.11	8.06	16.05	26.78
03/02/2023	9.67	39.23	4.23	8.55	14.17
03/03/2023	85.29	81.61	7.53	15.10	25.14
03/04/2023	75.09	72.57	6.69	13.45	22.36
03/05/2023	75.04	85.77	8.07	16.09	26.83
03/06/2023	126.20	101.89	9.55	19.18	31.92
03/07/2023	116.20	108.24	10.82	21.73	36.18
03/08/2023	89.84	114.83	11.61	23.23	38.72
03/09/2023	76.00	143.12	15.31	30.58	50.99
03/10/2023	95.18	68.88	6.07	12.24	20.39
03/11/2023	56.34	76.68	7.11	14.40	23.97
03/12/2023	72.36	115.27	11.61	23.25	38.76
03/13/2023	59.09	69.55	7.01	14.14	23.54
03/14/2023	87.90	112.41	11.25	22.52	37.54
03/15/2023	68.63	71.50	6.18	12.49	20.80
03/16/2023	58.11	51.83	4.30	8.72	14.48
03/17/2023	184.98	110.06	9.98	19.98	33.29
03/18/2023	89.16	76.17	6.91	13.89	23.14
03/19/2023	69.83	87.09	8.17	16.41	27.35
03/20/2023	100.82	74.36	5.92	11.91	19.84
03/21/2023	50.51	34.49	2.45	4.94	8.23
03/22/2023	82.62	85.32	8.05	16.02	26.77
03/23/2023	82.43	80.88	7.78	15.50	25.79
03/24/2023	12.46	43.27	4.80	9.57	15.84
03/25/2023	25.39	43.01	4.63	9.10	15.18
03/26/2023	0.00	0.00	0.00	0.00	0.00
03/27/2023	0.00	0.00	0.00	0.00	0.00
03/28/2023	0.00	0.00	0.00	0.00	0.00
03/29/2023	0.00	0.00	0.00	0.00	0.00
03/30/2023	0.00	0.00	0.00	0.00	0.00
03/31/2023	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	1,901.12 *	2,022.14 *	194.09 *	389.04 *	648.00 *
Daily Min:	9.67	34.49	2.45	4.94	8.23
Daily Max:	184.98	143.12	15.31	30.58	50.99
Jan 2023 - Mar 2023	5,384.69	6,279.86	625.49	1,249.35	2,081.87
QTD:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *
YTD 2023:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2023	0.0	0.0	0.0	0.0
01/02/2023	52.8	10.3	0.0	0.0
01/03/2023	0.0	0.0	0.0	0.0
01/04/2023	19.0	0.7	0.0	0.0
01/05/2023	60.4	11.6	0.0	0.0
01/06/2023	63.3	13.3	0.0	0.0
01/07/2023	5.2	0.0	0.0	0.0
01/08/2023	61.8	11.3	0.0	0.0
01/09/2023	56.5	10.6	0.0	0.0
01/10/2023	60.2	10.0	0.0	0.0
01/11/2023	61.1	10.0	0.0	0.0
01/12/2023	64.4	11.0	0.0	0.0
01/13/2023	-1.3	0.0	0.0	0.0
01/14/2023	57.1	12.7	0.0	0.0
01/15/2023	60.1	10.7	0.0	0.0
01/16/2023	56.8	11.0	0.0	0.0
01/17/2023	47.6	9.8	0.0	0.0
01/18/2023	13.4	0.6	0.0	0.0
01/19/2023	0.0	0.0	0.0	0.0
01/20/2023	0.0	0.0	0.0	0.0
01/21/2023	0.0	0.0	0.0	0.0
01/22/2023	0.0	0.0	0.0	0.0
01/23/2023	41.9	12.2	0.0	0.0
01/24/2023	19.8	0.6	0.0	0.0
01/25/2023	0.1	0.0	0.0	0.0
01/26/2023	0.8	0.0	0.0	0.0
01/27/2023	45.1	10.3	13.0	0.8
01/28/2023	0.0	0.0	0.0	0.0
01/29/2023	0.0	0.0	63.8	13.6
01/30/2023	0.0	0.0	0.0	0.0
01/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	841.3 *	156.7 *	76.8 *	14.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	64.4	13.3	63.8	13.6
Jan 2023 - Jan 2023	841.3	156.7	76.8	14.4
QTD:	846.1 *	156.7 *	76.8 *	14.4 *
YTD 2023:	846.1 *	156.7 *	76.8 *	14.4 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023	0.0	0.0	0.0	0.0
02/02/2023	0.0	0.0	0.0	0.0
02/03/2023	0.0	0.0	26.3	12.1
02/04/2023	82.8	11.2	0.0	0.0
02/05/2023	61.0	11.1	0.0	0.0
02/06/2023	51.2	10.1	0.0	0.0
02/07/2023	49.7	9.9	0.0	0.0
02/08/2023	0.0	0.0	54.8	9.3
02/09/2023	0.0	0.0	56.6	9.7
02/10/2023	0.0	0.0	48.5	12.4
02/11/2023	51.7	6.8	0.0	0.0
02/12/2023	0.0	0.0	50.3	8.3
02/13/2023	20.2	0.7	0.0	0.0
02/14/2023	43.5	11.3	0.0	0.0
02/15/2023	55.8	7.7	31.2	5.8
02/16/2023	69.9	8.1	0.0	0.0
02/17/2023	12.0	0.6	0.0	0.0
02/18/2023	0.5	0.0	0.0	0.0
02/19/2023	11.4	0.0	0.0	0.0
02/20/2023	58.9	11.4	12.3	0.8
02/21/2023	0.0	0.0	0.0	0.0
02/22/2023	0.0	0.0	49.5	14.1
02/23/2023	0.0	0.0	13.1	0.7
02/24/2023	0.0	0.0	0.0	0.0
02/25/2023	0.0	0.0	0.0	0.0
02/26/2023	0.0	0.0	0.0	0.0
02/27/2023	0.0	0.0	45.8	13.1
02/28/2023	0.0	0.0	57.1	12.8
Monthly Avg/Sum*:	556.7 *	88.9 *	445.5 *	99.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	82.8	11.4	57.1	14.1
Jan 2023 - Feb 2023	1,398.0	245.6	522.3	113.5
QTD:	1,414.7 *	245.6 *	522.3 *	113.5 *
YTD 2023:	1,414.7 *	245.6 *	522.3 *	113.5 *

Monthly Summary By Day Report



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:46 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2023	0.0	0.0	12.0	0.7
03/02/2023	0.0	0.0	0.0	0.0
03/03/2023	0.0	0.0	53.5	13.9
03/04/2023	0.0	0.0	37.6	13.1
03/05/2023	0.0	0.0	49.1	13.0
03/06/2023	0.0	0.0	69.8	16.1
03/07/2023	0.0	0.0	59.5	10.5
03/08/2023	0.0	0.0	31.6	8.5
03/09/2023	0.0	0.0	10.5	0.7
03/10/2023	0.0	0.0	59.9	13.8
03/11/2023	0.0	0.0	45.1	12.6
03/12/2023	0.0	0.0	40.3	9.6
03/13/2023	0.0	0.0	21.7	1.6
03/14/2023	0.0	0.0	57.5	10.4
03/15/2023	0.0	0.0	36.5	13.7
03/16/2023	0.0	0.0	48.2	13.6
03/17/2023	67.1	8.5	73.3	12.5
03/18/2023	0.0	0.0	52.0	12.9
03/19/2023	0.0	0.0	49.4	12.8
03/20/2023	12.5	2.2	47.9	17.9
03/21/2023	0.0	0.0	41.6	14.3
03/22/2023	60.9	14.0	0.0	0.0
03/23/2023	79.0	12.0	0.0	0.0
03/24/2023	0.0	0.0	0.0	0.0
03/25/2023	0.0	0.0	12.0	1.6
03/26/2023	0.0	0.0	0.0	0.0
03/27/2023	0.0	0.0	0.0	0.0
03/28/2023	0.0	0.0	0.0	0.0
03/29/2023	0.0	0.0	0.0	0.0
03/30/2023	0.0	0.0	0.0	0.0
03/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	219.5 *	36.7 *	909.0 *	223.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	79.0	14.0	73.3	17.9
Jan 2023 - Mar 2023	1,617.5	282.3	1,431.3	337.3
QTD:	1,634.2 *	282.3 *	1,431.3 *	337.3 *
YTD 2023:	1,634.2 *	282.3 *	1,431.3 *	337.3 *

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2023 00:00	01/02/2023 11:00	36
01/04/2023 10:00	01/05/2023 14:00	29
01/05/2023 20:00	01/06/2023 15:00	20
01/06/2023 22:00	01/08/2023 15:00	42
01/08/2023 23:00	01/09/2023 12:00	14
01/09/2023 22:00	01/10/2023 14:00	17
01/11/2023 00:00	01/11/2023 14:00	15
01/11/2023 22:00	01/12/2023 14:00	17
01/12/2023 23:00	01/14/2023 13:00	39
01/14/2023 21:00	01/15/2023 13:00	17
01/15/2023 23:00	01/16/2023 14:00	16
01/16/2023 23:00	01/17/2023 16:00	18
01/18/2023 10:00	01/23/2023 15:00	126
01/24/2023 11:00	01/27/2023 15:00	77
02/04/2023 01:00	02/04/2023 15:00	15
02/05/2023 00:00	02/05/2023 16:00	17
02/05/2023 23:00	02/06/2023 14:00	16
02/07/2023 00:00	02/07/2023 14:00	15
02/11/2023 09:00	02/11/2023 15:00	7
02/13/2023 01:00	02/14/2023 14:00	38
02/15/2023 09:00	02/15/2023 15:00	7
02/16/2023 09:00	02/16/2023 15:00	7
02/17/2023 05:00	02/20/2023 14:00	82
03/16/2023 16:00	03/17/2023 00:00	9
03/20/2023 21:00	03/22/2023 15:00	43
03/23/2023 00:00	03/23/2023 13:00	14
03/24/2023 00:00	03/31/2023 08:00	177

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 08:00 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,145.00 Hour(s)
Total Offline:	930.00 Hour(s)
Offline Percentage:	43.36 %
Total Online:	1,215.00 Hour(s)
Online Percentage:	56.64 %

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/02/2023 12:10	01/02/2023 13:09	Cold Startup	60
2	01/04/2023 08:53	01/04/2023 09:00	Shutdown	8
3	01/05/2023 15:30	01/05/2023 16:34	Cold Startup	65
4	01/05/2023 19:07	01/05/2023 19:14	Shutdown	8
5	01/06/2023 16:02	01/06/2023 16:58	Cold Startup	57
6	01/06/2023 21:23	01/06/2023 21:30	Shutdown	8
7	01/08/2023 16:05	01/08/2023 16:58	Cold Startup	54
8	01/08/2023 22:08	01/08/2023 22:15	Shutdown	8
9	01/09/2023 13:54	01/09/2023 14:41	Cold Startup	48
10	01/09/2023 21:46	01/09/2023 21:55	Shutdown	10
11	01/10/2023 15:56	01/10/2023 16:44	Cold Startup	49
12	01/10/2023 23:07	01/10/2023 23:14	Shutdown	8
13	01/11/2023 15:02	01/11/2023 15:48	Cold Startup	47
14	01/11/2023 21:00	01/11/2023 21:07	Shutdown	8
15	01/12/2023 15:48	01/12/2023 16:50	Cold Startup	63
16	01/12/2023 22:08	01/12/2023 22:15	Shutdown	8
17	01/14/2023 14:54	01/14/2023 16:01	Cold Startup	68
18	01/14/2023 20:08	01/14/2023 20:14	Shutdown	7
19	01/15/2023 14:59	01/15/2023 15:53	Cold Startup	55
20	01/15/2023 22:06	01/15/2023 22:13	Shutdown	8
21	01/16/2023 15:00	01/16/2023 15:55	Cold Startup	56
22	01/16/2023 22:53	01/16/2023 22:59	Shutdown	7

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	01/17/2023 17:00	01/17/2023 18:06	cold Startup	67
24	01/18/2023 09:06	01/18/2023 09:13	Shutdown	8
25	01/23/2023 16:10	01/23/2023 17:17	cold Startup	68
26	01/24/2023 10:09	01/24/2023 10:16	Shutdown	8
27	01/27/2023 16:22	01/27/2023 17:21	cold Startup	60
28	02/04/2023 00:08	02/04/2023 00:15	Shutdown	8
29	02/04/2023 16:08	02/04/2023 17:02	cold Startup	55
30	02/04/2023 23:06	02/04/2023 23:13	Shutdown	8
31	02/05/2023 17:57	02/05/2023 18:56	cold Startup	60
32	02/05/2023 22:22	02/05/2023 22:29	Shutdown	8
33	02/06/2023 15:54	02/06/2023 16:49	cold Startup	56
34	02/06/2023 23:24	02/06/2023 23:31	Shutdown	8
35	02/07/2023 15:51	02/07/2023 16:45	cold Startup	55
36	02/11/2023 08:38	02/11/2023 08:45	Shutdown	8
37	02/11/2023 16:01	02/11/2023 16:39	cold Startup	39
38	02/13/2023 00:37	02/13/2023 00:44	Shutdown	8
39	02/14/2023 15:34	02/14/2023 16:29	cold Startup	56
40	02/15/2023 08:36	02/15/2023 08:43	Shutdown	8
41	02/15/2023 16:16	02/15/2023 17:01	cold Startup	46
42	02/16/2023 08:53	02/16/2023 08:59	Shutdown	7
43	02/16/2023 16:13	02/16/2023 16:54	cold Startup	42
44	02/17/2023 03:53	02/17/2023 04:00	Shutdown	8
45	02/20/2023 15:58	02/20/2023 17:09	cold Startup	72
46	03/16/2023 15:17	03/16/2023 15:17	Shutdown	1

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 **To:** 03/31/2023 08:00 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
47	03/17/2023 01:50	03/17/2023 02:51	Cold Startup	62
48	03/20/2023 20:14	03/20/2023 20:30	Shutdown	17
49	03/22/2023 16:08	03/22/2023 17:18	Cold Startup	71
50	03/22/2023 23:44	03/22/2023 23:52	Shutdown	9
51	03/23/2023 14:59	03/23/2023 15:55	Cold Startup	57
52	03/23/2023 22:55	03/23/2023 23:03	Shutdown	9

Startup / Shutdown Events

CT1



From: 01/01/2023 00:00 To: 03/31/2023 08:00 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:32 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	26	1488	2.09
Warm Startup	0		0.00
Shutdown	26	211	0.30
Total Process Events:	52	1699	2.38

Total Report Time:	2,144.00 Hour(s)
Total Operating Time:	1,187.52 Hour(s)
Total Startup Time:	1,488 Minute(s)
Total Shutdown Time:	211 Minute(s)
Total Startup/Shutdown Time:	1,699 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.38 %

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/27/2023 21:00	01/29/2023 08:00	36
01/29/2023 13:00	02/03/2023 15:00	123
02/08/2023 09:00	02/08/2023 14:00	6
02/09/2023 09:00	02/09/2023 15:00	7
02/10/2023 00:00	02/10/2023 14:00	15
02/12/2023 09:00	02/12/2023 14:00	6
02/21/2023 00:00	02/22/2023 15:00	40
02/23/2023 14:00	02/27/2023 16:00	99
02/28/2023 00:00	02/28/2023 15:00	16
03/01/2023 09:00	03/03/2023 14:00	54
03/04/2023 00:00	03/04/2023 15:00	16
03/04/2023 23:00	03/05/2023 14:00	16
03/06/2023 02:00	03/06/2023 12:00	11
03/07/2023 09:00	03/07/2023 15:00	7
03/08/2023 12:00	03/08/2023 17:00	6
03/10/2023 00:00	03/10/2023 14:00	15
03/10/2023 21:00	03/11/2023 15:00	19
03/12/2023 08:00	03/12/2023 14:00	7
03/13/2023 01:00	03/13/2023 15:00	15
03/13/2023 23:00	03/14/2023 08:00	10
03/15/2023 00:00	03/15/2023 15:00	16
03/15/2023 22:00	03/16/2023 14:00	17
03/17/2023 09:00	03/17/2023 15:00	7
03/18/2023 00:00	03/18/2023 14:00	15
03/18/2023 22:00	03/19/2023 14:00	17
03/20/2023 02:00	03/20/2023 15:00	14
03/20/2023 21:00	03/21/2023 10:00	14
03/26/2023 00:00	03/31/2023 08:00	129

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 08:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,145.00 Hour(s)
Total Offline:	753.00 Hour(s)
Offline Percentage:	35.10 %
Total Online:	1,392.00 Hour(s)
Online Percentage:	64.90 %

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/27/2023 20:28	01/27/2023 20:35	Shutdown	8
2	01/29/2023 09:14	01/29/2023 10:09	cold Startup	56
3	01/29/2023 12:37	01/29/2023 12:44	Shutdown	8
4	02/03/2023 16:09	02/03/2023 17:02	cold Startup	54
5	02/08/2023 08:15	02/08/2023 08:22	Shutdown	8
6	02/08/2023 15:57	02/08/2023 16:37	cold Startup	41
7	02/09/2023 08:12	02/09/2023 08:19	Shutdown	8
8	02/09/2023 16:05	02/09/2023 16:45	cold Startup	41
9	02/09/2023 23:52	02/09/2023 23:59	Shutdown	8
10	02/10/2023 15:54	02/10/2023 16:56	cold Startup	63
11	02/12/2023 08:26	02/12/2023 08:34	Shutdown	9
12	02/12/2023 15:30	02/12/2023 16:03	warm Startup	34
13	02/15/2023 06:53	02/15/2023 06:53	Shutdown	1
14	02/15/2023 07:29	02/15/2023 08:05	warm Startup	37
15	02/20/2023 23:09	02/20/2023 23:16	Shutdown	8
16	02/22/2023 16:09	02/22/2023 17:11	cold Startup	63
17	02/23/2023 13:08	02/23/2023 13:15	Shutdown	8
18	02/27/2023 17:27	02/27/2023 18:20	cold Startup	54
19	02/27/2023 23:09	02/27/2023 23:17	Shutdown	9
20	02/28/2023 16:54	02/28/2023 17:47	cold Startup	54
21	03/01/2023 08:12	03/01/2023 08:19	Shutdown	8
22	03/03/2023 15:10	03/03/2023 16:12	cold Startup	63

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/03/2023 22:53	03/03/2023 23:00	Shutdown	8
24	03/04/2023 16:57	03/04/2023 17:45	Cold Startup	49
25	03/04/2023 22:52	03/04/2023 22:59	Shutdown	8
26	03/05/2023 15:54	03/05/2023 16:42	Cold Startup	49
27	03/06/2023 01:38	03/06/2023 01:45	Shutdown	8
28	03/06/2023 13:10	03/06/2023 14:17	Cold Startup	68
29	03/07/2023 08:09	03/07/2023 08:16	Shutdown	8
30	03/07/2023 16:48	03/07/2023 17:39	Cold Startup	52
31	03/08/2023 11:14	03/08/2023 11:21	Shutdown	8
32	03/08/2023 18:18	03/08/2023 18:55	Cold Startup	38
33	03/09/2023 23:08	03/09/2023 23:15	Shutdown	8
34	03/10/2023 15:49	03/10/2023 16:48	Cold Startup	60
35	03/10/2023 20:44	03/10/2023 20:52	Shutdown	9
36	03/11/2023 16:59	03/11/2023 17:59	Cold Startup	61
37	03/12/2023 07:11	03/12/2023 07:19	Shutdown	9
38	03/12/2023 15:07	03/12/2023 15:55	Cold Startup	49
39	03/13/2023 00:08	03/13/2023 00:15	Shutdown	8
40	03/13/2023 16:47	03/13/2023 17:37	Cold Startup	51
41	03/13/2023 16:55	03/13/2023 16:57	Shutdown	3
42	03/13/2023 22:52	03/13/2023 22:59	Shutdown	8
43	03/14/2023 09:09	03/14/2023 09:47	Cold Startup	39
44	03/14/2023 23:09	03/14/2023 23:16	Shutdown	8
45	03/15/2023 16:47	03/15/2023 17:34	Cold Startup	48
46	03/15/2023 21:45	03/15/2023 21:54	Shutdown	10

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 08:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
47	03/16/2023 15:45	03/16/2023 16:46	Cold Startup	62
48	03/17/2023 08:22	03/17/2023 08:30	Shutdown	9
49	03/17/2023 16:39	03/17/2023 17:30	Cold Startup	52
50	03/17/2023 22:53	03/17/2023 23:01	Shutdown	9
51	03/18/2023 15:55	03/18/2023 16:46	Cold Startup	52
52	03/18/2023 21:45	03/18/2023 21:53	Shutdown	9
53	03/19/2023 15:42	03/19/2023 16:42	Cold Startup	61
54	03/20/2023 01:08	03/20/2023 01:16	Shutdown	9
55	03/20/2023 16:31	03/20/2023 17:39	Cold Startup	69
56	03/20/2023 20:19	03/20/2023 20:35	Shutdown	17
57	03/21/2023 11:32	03/21/2023 12:36	Cold Startup	65
58	03/25/2023 22:55	03/25/2023 23:06	Shutdown	12

Startup / Shutdown Events

CT2



From: 01/01/2023 00:00 To: 03/31/2023 08:59 Facility Name: ROSEVILLE ENERGY
Generated: 03/31/2023 09:37 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	26	1414	1.73
Warm Startup	2	71	0.09
Shutdown	30	251	0.31
Total Process Events:	58	1736	2.12

Total Report Time:	2,144.98 Hour(s)
Total Operating Time:	1,361.78 Hour(s)
Total Startup Time:	1,485 Minute(s)
Total Shutdown Time:	251 Minute(s)
Total Startup/Shutdown Time:	1,736 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.12 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 12:05	0			0			0			0			0			0		
01/02/23 12:06	0			0			0			0			0			0		
01/02/23 12:07	0			0			0			0			0			0		
01/02/23 12:08	0			0			0			0			0			0		
01/02/23 12:09	5160.1			0			0			0.07			0			0		
01/02/23 12:10	20024.2			5.9			0			0.28			0			1		
01/02/23 12:11	31114.5			5.9			0			0.43			0			1		
01/02/23 12:12	40048.3			82.6			5.9			7.78			0.92			1		
01/02/23 12:13	46671.7			1050.8			11.21			115.49			2.03			1		
01/02/23 12:14	59456.3			973.2			13.19			136.37			3.04			1		
01/02/23 12:15	73627.3			582.6			17.11			101.07			4.89			1		
01/02/23 12:16	111981.2			406.8			21.45			107.28			9.31			1		
01/02/23 12:17	141247.3			296.5			24.34			98.62			13.32			1		
01/02/23 12:18	142479.5			191.2			46.81			64.14			25.85			1		
01/02/23 12:19	151259.4			1646.8			37.8			586.5			22.15			1		
01/02/23 12:20	167740.8			1911.2			38.08			755.11			24.76			1		
01/02/23 12:21	185916.6			1752			41.63			767.09			30			1		
01/02/23 12:22	210792.7			678.4			50.22			336.8			41.04			1		
01/02/23 12:23	231279			97.9			56.56			53.3			50.7			1		
01/02/23 12:24	253844.6			8.1			57.3			4.81			56.36			1		
01/02/23 12:25	271481.3			2.5			55.89			1.59			58.81			1		
01/02/23 12:26	290504.3			2.2			31.78			1.5			35.78			1		
01/02/23 12:27	309450.2			2			20.02			1.43			24.01			1		
01/02/23 12:28	309450.2			2			14.02			1.43			16.82			1		
01/02/23 12:29	310990.5			2			10.35			1.44			12.47			1		
01/02/23 12:30	309989.3			1.9			8.29			1.37			9.96			1		
01/02/23 12:31	309219.1			1.7			6.93			1.25			8.3			1		
01/02/23 12:32	309758.3			1.6			5.99			1.14			7.19			1		
01/02/23 12:33	309681.2			1.5			5.21			1.08			6.25			1		
01/02/23 12:34	308063.9			1.3			4.77			0.94			5.7			1		
01/02/23 12:35	307524.8			1.2			4.25			0.88			5.07			1		
01/02/23 12:36	306677.6			1.1			4.16			0.81			4.95			1		
01/02/23 12:37	304829.2			1			4.08			0.75			4.82			1		
01/02/23 12:38	304752.2			1.1			3.96			0.76			4.68			1		
01/02/23 12:39	306985.7			1			3.79			0.7			4.51			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 12:40	307216.7			1			3.7			0.7			4.4			1		
01/02/23 12:41	306369.5			1			3.7			0.7			4.39			1		
01/02/23 12:42	306061.5			0.9			3.79			0.63			4.49			1		
01/02/23 12:43	315534.4			0.9			3.79			0.65			4.63			1		
01/02/23 12:44	316843.7			0.9			3.79			0.66			4.65			1		
01/02/23 12:45	318846.1			0.9			3.73			0.65			4.61			1		
01/02/23 12:46	316150.6			0.9			3.9			0.65			4.78			1		
01/02/23 12:47	296742.5			0.9			3.99			0.61			4.59			1		
01/02/23 12:48	278489.8			0.9			3.7			0.58			3.99			1		
01/02/23 12:49	274870			0.8			4.54			0.53			4.84			1		
01/02/23 12:50	274099.8			0.7			5.25			0.48			5.58			1		
01/02/23 12:51	274947			0.6			5.35			0.42			5.7			1		
01/02/23 12:52	277411.5			0.6			5.53			0.42			5.95			1		
01/02/23 12:53	290889.3			0.6			5.63			0.44			6.34			1		
01/02/23 12:54	310528.4			0.6			5.54			0.46			6.66			1		
01/02/23 12:55	328935.2			0.6			4.65			0.48			5.93			1		
01/02/23 12:56	333248.1			0.7			4.58			0.55			5.91			1		
01/02/23 12:57	328242.1			0.8			4.49			0.61			5.71			1		
01/02/23 12:58	315996.5			0.8			4.08			0.58			4.99			1		
01/02/23 12:59	294663.1			0.9			2.86			0.6			3.27			1		
01/02/23 13:00	276025.3			0.8			2.03			0.52			2.17			1		
01/02/23 13:01	269632.9			0.7			2.63			0.46			2.75			1		
01/02/23 13:02	272944.6			0.6			3.6			0.41			3.8			1		
01/02/23 13:03	286345.4			0.6			3.69			0.37			4.09			1		
01/02/23 13:04	304983.3			0.5			3.18			0.39			3.75			1		
01/02/23 13:05	326162.7			0.6			2.23			0.48			2.82			1		
01/02/23 13:06	335019.5			0.7			1.85			0.56			2.4			1		
01/02/23 13:07	332015.8			0.8			1.23			0.62			1.59			1		
01/02/23 13:08	334480.4			0.8			1.13			0.62			1.46			1		
01/02/23 13:09	352887.2			0.8			1.14			0.66			1.57			1		
01/02/23 13:10	363900.5			0.8			1.06			0.68			1.49			0		
01/02/23 13:11	373989.6			0.7			0.91			0.64			1.32			0		
01/02/23 13:12	377532.3			0.7			0.8			0.64			1.18			0		
01/02/23 13:13	390162.9			0.7			0.72			0.66			1.08			0		
01/02/23 13:14	401792.3			0.7			0.72			0.68			1.11			0		

CT1 SUSD EVENT 2

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 8:48	266552.3			0.6			1.4			0.35			1.45			0		
01/04/23 8:49	267322.4			0.6			1.31			0.35			1.36			0		
01/04/23 8:50	267630.5			0.6			1.31			0.35			1.36			0		
01/04/23 8:51	267168.4			0.6			1.31			0.35			1.36			0		
01/04/23 8:52	267707.5			0.6			1.4			0.35			1.46			0		
01/04/23 8:53	263394.6			0.6			1.4			0.35			1.43			1		
01/04/23 8:54	242061.2			0.6			1.5			0.32			1.41			1		
01/04/23 8:55	221652			0.5			4.33			0.26			3.72			1		
01/04/23 8:56	196467.8			0.4			8.58			0.2			6.53			1		
01/04/23 8:57	174210.1			5.2			10.97			2.13			7.41			1		
01/04/23 8:58	156573.5			332.7			14.08			122.65			8.54			1		
01/04/23 8:59	137781.6			1279.4			15.88			414.98			8.48			1		
01/04/23 9:00	21333.4			1853.5			17.87			92.94			1.47			1		
01/04/23 9:01	15788.3			0			14.75			153.83			0.9			0		
01/04/23 9:02	16635.4			0			2.95			17.22			0.19			0		
01/04/23 9:03	16404.4			0			5.9			7.77			0.38			0		
01/04/23 9:04	16404.4			0			5.9			6.63			0.38			0		
01/04/23 9:05	16789.5			0			5.9			6.55			0.38			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:25	8856.8			0			0			0.25			0			0		
01/05/23 15:26	9550			0			0			0.26			0			0		
01/05/23 15:27	7547.6			0			0			0.21			0			0		
01/05/23 15:28	10012.1			0			0			0.28			0			0		
01/05/23 15:29	11090.3			0			0			0.31			0			0		
01/05/23 15:30	18560.8			11.8			0			0.52			0			1		
01/05/23 15:31	25877.4			11.8			0			0.72			0			1		
01/05/23 15:32	36120.5			35.4			13.77			3.01			1.93			1		
01/05/23 15:33	47518.9			938.1			11.01			105			2.03			1		
01/05/23 15:34	60688.6			744.4			15.41			106.31			3.62			1		
01/05/23 15:35	80481.7			440.5			19.95			83.52			6.22			1		
01/05/23 15:36	121223.1			311.4			23.09			88.88			10.84			1		
01/05/23 15:37	144250.9			216.9			37.22			73.72			20.81			1		
01/05/23 15:38	150797.3			287.3			49.41			101.98			28.87			1		
01/05/23 15:39	164737.2			1709.8			45.81			663.27			29.25			1		
01/05/23 15:40	184607.3			1694.9			52.44			736.81			37.52			1		
01/05/23 15:41	207404			812.2			57.27			396.7			46.04			1		
01/05/23 15:42	229430.6			96.2			57.59			51.98			51.21			1		
01/05/23 15:43	249377.7			9			52.98			5.3			51.2			1		
01/05/23 15:44	276641.4			2.2			48.78			1.44			52.29			1		
01/05/23 15:45	294663.1			1.9			26.07			1.32			29.78			1		
01/05/23 15:46	295433.3			1.8			15.7			1.27			17.98			1		
01/05/23 15:47	297512.7			1.9			12.4			1.32			14.3			1		
01/05/23 15:48	311837.7			1.9			10.6			1.38			12.82			1		
01/05/23 15:49	313224			1.7			8.38			1.26			10.17			1		
01/05/23 15:50	311529.6			1.6			7.18			1.19			8.67			1		
01/05/23 15:51	310143.3			1.5			6.41			1.12			7.71			1		
01/05/23 15:52	310143.3			1.4			5.99			1.01			7.2			1		
01/05/23 15:53	309142.1			1.3			5.55			0.95			6.65			1		
01/05/23 15:54	306600.6			1.2			5.21			0.88			6.19			1		
01/05/23 15:55	306677.6			1.1			5.12			0.81			6.08			1		
01/05/23 15:56	306985.7			1.1			5.11			0.76			6.08			1		
01/05/23 15:57	305599.4			1.1			5.02			0.76			5.94			1		
01/05/23 15:58	306677.6			1			4.93			0.7			5.86			1		
01/05/23 15:59	306754.6			1			4.84			0.7			5.76			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 16:00	307678.8			1			4.84			0.7			5.78			1		
01/05/23 16:01	306677.6			1			4.84			0.7			5.76			1		
01/05/23 16:02	305291.3			1			4.93			0.7			5.84			1		
01/05/23 16:03	303982			0.9			4.93			0.63			5.81			1		
01/05/23 16:04	303828			0.9			4.84			0.63			5.7			1		
01/05/23 16:05	303211.9			0.9			4.84			0.63			5.69			1		
01/05/23 16:06	303828			0.8			4.84			0.57			5.7			1		
01/05/23 16:07	304444.1			0.8			4.93			0.57			5.82			1		
01/05/23 16:08	306523.6			0.8			4.93			0.57			5.86			1		
01/05/23 16:09	304598.2			0.8			5.02			0.57			5.92			1		
01/05/23 16:10	285498.2			0.8			5.2			0.53			5.75			1		
01/05/23 16:11	277873.6			0.8			5.45			0.53			5.87			1		
01/05/23 16:12	275871.2			0.7			6.63			0.47			7.08			1		
01/05/23 16:13	276025.3			0.6			6.81			0.41			7.28			1		
01/05/23 16:14	277488.6			0.6			7.47			0.42			8.03			1		
01/05/23 16:15	272482.5			0.6			7.17			0.41			7.57			1		
01/05/23 16:16	271019.2			0.6			4.43			0.41			4.65			1		
01/05/23 16:17	270172			0.6			3.13			0.41			3.28			1		
01/05/23 16:18	273098.6			0.6			3.5			0.42			3.71			1		
01/05/23 16:19	274793			0.6			4.43			0.36			4.71			1		
01/05/23 16:20	273868.8			0.6			5.07			0.36			5.38			1		
01/05/23 16:21	273868.8			0.6			4.06			0.42			4.31			1		
01/05/23 16:22	274716			0.6			2.77			0.42			2.94			1		
01/05/23 16:23	281185.3			0.6			2.3			0.43			2.51			1		
01/05/23 16:24	286576.4			0.6			2.3			0.44			2.56			1		
01/05/23 16:25	287577.6			0.6			2.36			0.43			2.63			1		
01/05/23 16:26	285960.3			0.6			2.45			0.43			2.72			1		
01/05/23 16:27	283110.7			0.6			2.54			0.42			2.79			1		
01/05/23 16:28	292660.7			0.6			2.72			0.44			3.09			1		
01/05/23 16:29	314071.1			0.6			2.81			0.47			3.42			1		
01/05/23 16:30	333017.1			0.7			2.23			0.56			2.88			1		
01/05/23 16:31	343029.1			0.7			1.85			0.57			2.46			1		
01/05/23 16:32	341334.8			0.8			1.32			0.64			1.75			1		
01/05/23 16:33	345185.6			0.8			1.23			0.64			1.65			1		
01/05/23 16:34	356198.9			0.8			1.23			0.66			1.7			1		
01/05/23 16:35	357970.3			0.8			1.32			0.67			1.83			0		
01/05/23 16:36	357739.2			0.8			1.32			0.67			1.83			0		
01/05/23 16:37	357970.3			0.8			1.5			0.67			2.08			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 16:38	362822.3			0.8			1.59			0.68			2.23			0		
01/05/23 16:39	385233.9			0.8			1.5			0.72			2.24			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 19:02	268169.6			0.6			1.5			0.35			1.56			0		
01/05/23 19:03	268554.7			0.6			1.5			0.36			1.56			0		
01/05/23 19:04	268169.6			0.6			1.4			0.35			1.46			0		
01/05/23 19:05	267938.6			0.6			1.4			0.35			1.46			0		
01/05/23 19:06	267861.6			0.6			1.31			0.35			1.36			0		
01/05/23 19:07	266860.3			0.6			1.31			0.35			1.36			1		
01/05/23 19:08	251611.2			0.6			1.4			0.33			1.37			1		
01/05/23 19:09	230354.8			0.6			2.57			0.31			2.29			1		
01/05/23 19:10	207250			0.5			7.76			0.25			6.23			1		
01/05/23 19:11	183144			2.8			10.55			1.22			7.49			1		
01/05/23 19:12	163736			123.6			13.98			47.69			8.87			1		
01/05/23 19:13	145252.1			700.4			15.97			239.55			8.99			1		
01/05/23 19:14	80635.7			1618.2			18.36			307.18			5.73			1		
01/05/23 19:15	21025.4			0			21.91			129.01			1.78			0		
01/05/23 19:16	20871.3			0			5.9			62.47			0.48			0		
01/05/23 19:17	20563.3			0			5.9			13.12			0.47			0		
01/05/23 19:18	20409.2			0			5.9			8.8			0.47			0		
01/05/23 19:19	20255.2			0			5.9			8.44			0.46			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 15:57	22950.8			0			0			0.32			0			0		
01/06/23 15:58	22796.7			0			0			0.32			0			0		
01/06/23 15:59	22796.7			0			0			0.32			0			0		
01/06/23 16:00	22719.7			0			0			0.32			0			0		
01/06/23 16:01	24337			0			0			0.34			0			0		
01/06/23 16:02	28418.9			5.9			0			0.39			0			1		
01/06/23 16:03	36967.7			47.2			0			4.11			0			1		
01/06/23 16:04	45439.4			5.9			16.96			0.63			2.99			1		
01/06/23 16:05	58224.1			845.4			13.88			115.82			3.13			1		
01/06/23 16:06	68621.2			513.3			19.47			82.96			5.18			1		
01/06/23 16:07	94113.5			329.3			24.4			72.98			8.9			1		
01/06/23 16:08	136395.3			225.9			33.43			72.57			17.67			1		
01/06/23 16:09	143711.8			158			50.99			53.49			28.4			1		
01/06/23 16:10	155187.2			851.3			55.13			311.17			33.16			1		
01/06/23 16:11	170975.5			1805.2			54.14			726.96			35.88			1		
01/06/23 16:12	192308.9			1551.4			57.25			702.53			42.66			1		
01/06/23 16:13	214412.5			457.5			55.21			231.05			45.88			1		
01/06/23 16:14	235360.8			54			55.23			29.92			50.38			1		
01/06/23 16:15	259774.9			3.6			50.21			2.18			50.55			1		
01/06/23 16:16	274793			1.9			41.3			1.25			43.99			1		
01/06/23 16:17	277873.6			1.8			17.61			1.16			18.96			1		
01/06/23 16:18	276564.3			1.6			14.43			1.06			15.47			1		
01/06/23 16:19	276564.3			1.6			13.52			1.06			14.49			1		
01/06/23 16:20	276487.3			1.5			12.44			1			13.33			1		
01/06/23 16:21	275563.2			1.5			11.89			0.94			12.7			1		
01/06/23 16:22	275255.1			1.3			10.8			0.82			11.52			1		
01/06/23 16:23	275024			1.2			10.53			0.76			11.22			1		
01/06/23 16:24	274947			1.1			10.26			0.71			10.93			1		
01/06/23 16:25	274407.9			1			9.98			0.65			10.62			1		
01/06/23 16:26	274099.8			0.9			9.71			0.59			10.32			1		
01/06/23 16:27	274484.9			0.9			9.62			0.59			10.24			1		
01/06/23 16:28	273637.8			0.8			9.53			0.53			10.11			1		
01/06/23 16:29	272944.6			0.8			9.59			0.53			10.14			1		
01/06/23 16:30	273945.8			0.7			9.59			0.48			10.18			1		
01/06/23 16:31	291813.5			0.7			9.59			0.51			10.84			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 16:32	302056.7			0.7			8.08			0.52			9.46			1		
01/06/23 16:33	302826.8			0.7			6.53			0.51			7.66			1		
01/06/23 16:34	303442.9			0.8			6.44			0.57			7.57			1		
01/06/23 16:35	303442.9			0.8			6.26			0.57			7.36			1		
01/06/23 16:36	293045.8			0.8			6.17			0.56			7.01			1		
01/06/23 16:37	275717.2			0.8			6.08			0.52			6.5			1		
01/06/23 16:38	272867.6			0.7			7.38			0.47			7.8			1		
01/06/23 16:39	271712.3			0.6			8.57			0.41			9.03			1		
01/06/23 16:40	271481.3			0.6			8.76			0.41			9.21			1		
01/06/23 16:41	270942.2			0.6			8.94			0.35			9.39			1		
01/06/23 16:42	270942.2			0.6			9.13			0.35			9.58			1		
01/06/23 16:43	271943.4			0.6			9.59			0.35			10.11			1		
01/06/23 16:44	288655.9			0.6			9.93			0.38			11.11			1		
01/06/23 16:45	309989.3			0.6			8.94			0.4			10.74			1		
01/06/23 16:46	328704.2			0.6			7.15			0.48			9.11			1		
01/06/23 16:47	335250.5			0.7			7.04			0.56			9.15			1		
01/06/23 16:48	339255.3			0.8			6.08			0.63			7.99			1		
01/06/23 16:49	356044.8			0.8			5.72			0.66			7.9			1		
01/06/23 16:50	366596			0.8			4.56			0.69			6.48			1		
01/06/23 16:51	376608.1			0.7			4.18			0.64			6.09			1		
01/06/23 16:52	379919.8			0.7			4.99			0.65			7.35			1		
01/06/23 16:53	388622.6			0.7			5.18			0.65			7.81			1		
01/06/23 16:54	406952.4			0.7			3.99			0.7			6.3			1		
01/06/23 16:55	423741.9			0.7			2.4			0.74			3.94			1		
01/06/23 16:56	419891.1			0.6			1.75			0.64			2.85			1		
01/06/23 16:57	425205.2			0.6			1.54			0.64			2.54			1		
01/06/23 16:58	416579.4			0.7			1.36			0.71			2.2			1		
01/06/23 16:59	417118.5			0.7			1.18			0.71			1.91			0		
01/06/23 17:00	408954.8			0.7			0.98			0.69			1.56			0		
01/06/23 17:01	410341.1			0.7			0.8			0.69			1.28			0		
01/06/23 17:02	416348.3			0.7			0.73			0.71			1.17			0		
01/06/23 17:03	402716.5			0.7			0.64			0.69			0.99			0		

CT1 SUSD EVENT 6

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/06/23 21:18	269786.9			0.6			1.69			0.36			1.76			0		
01/06/23 21:19	269941			0.6			1.59			0.36			1.67			0		
01/06/23 21:20	268323.7			0.6			1.59			0.36			1.66			0		
01/06/23 21:21	268631.7			0.6			1.5			0.36			1.56			0		
01/06/23 21:22	269093.8			0.6			1.5			0.36			1.56			0		
01/06/23 21:23	270018			0.6			1.5			0.36			1.57			1		
01/06/23 21:24	259081.7			0.6			1.5			0.34			1.5			1		
01/06/23 21:25	237286.2			0.6			1.78			0.31			1.64			1		
01/06/23 21:26	215105.6			0.5			5.9			0.26			4.92			1		
01/06/23 21:27	190152.4			1.6			9.91			0.7			7.3			1		
01/06/23 21:28	168665			1.8			11.17			0.7			7.3			1		
01/06/23 21:29	151952.5			468.2			15.03			167.59			8.85			1		
01/06/23 21:30	104125.6			1398.6			17.06			342.82			6.88			1		
01/06/23 21:31	23104.8			0			18.33			119.79			1.64			0		
01/06/23 21:32	23104.8			0			5.9			230.75			0.53			0		
01/06/23 21:33	23104.8			0			2.95			10.75			0.26			0		
01/06/23 21:34	23181.8			0			5.9			9.67			0.53			0		
01/06/23 21:35	22719.7			0			5.9			8.84			0.52			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 16:00	23027.8			0			0			0.64			0			0		
01/08/23 16:01	22950.8			0			0			0.64			0			0		
01/08/23 16:02	23181.8			0			0			0.64			0			0		
01/08/23 16:03	23027.8			0			0			0.64			0			0		
01/08/23 16:04	22950.8			0			0			0.64			0			0		
01/08/23 16:05	25723.3			11.8			0			0.72			0			1		
01/08/23 16:06	32500.7			11.8			0			0.9			0			1		
01/08/23 16:07	40587.4			43.3			9.83			4.14			1.55			1		
01/08/23 16:08	52293.8			890.5			12.22			109.63			2.48			1		
01/08/23 16:09	63153.1			725.4			15.08			107.81			3.69			1		
01/08/23 16:10	79326.5			422.3			19.1			78.93			5.88			1		
01/08/23 16:11	118912.7			280.4			22.57			78.51			10.4			1		
01/08/23 16:12	143403.7			190.6			35.17			64.39			19.55			1		
01/08/23 16:13	149179.9			226.4			47.38			79.52			27.39			1		
01/08/23 16:14	162888.8			1670.2			43.45			640.82			27.43			1		
01/08/23 16:15	181680.7			1702.2			48.02			728.13			33.81			1		
01/08/23 16:16	202398			1017.8			55.61			485.03			43.61			1		
01/08/23 16:17	225348.7			131			57.95			69.52			50.62			1		
01/08/23 16:18	245526.9			13.1			55.46			7.57			52.77			1		
01/08/23 16:19	269864			2.2			52.26			1.41			54.65			1		
01/08/23 16:20	276179.3			1.9			28.34			1.26			30.33			1		
01/08/23 16:21	275178.1			1.8			15.61			1.18			16.65			1		
01/08/23 16:22	286268.4			1.7			14.39			1.15			15.97			1		
01/08/23 16:23	303674			1.6			13.03			1.13			15.34			1		
01/08/23 16:24	309142.1			1.6			8.94			1.14			10.71			1		
01/08/23 16:25	309758.3			1.6			7.38			1.14			8.85			1		
01/08/23 16:26	307293.7			1.5			6.68			1.07			7.96			1		
01/08/23 16:27	307216.7			1.4			5.9			1			7.02			1		
01/08/23 16:28	304906.2			1.3			5.47			0.93			6.46			1		
01/08/23 16:29	305907.4			1.2			5.11			0.89			6.05			1		
01/08/23 16:30	302980.8			1.1			5.02			0.82			5.89			1		
01/08/23 16:31	303211.9			1.1			5.02			0.75			5.9			1		
01/08/23 16:32	303211.9			1.1			4.84			0.75			5.69			1		
01/08/23 16:33	304521.2			1			4.67			0.69			5.51			1		
01/08/23 16:34	304598.2			1			4.67			0.69			5.51			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 16:35	304829.2			1			4.67			0.7			5.51			1		
01/08/23 16:36	304290.1			0.9			4.67			0.63			5.5			1		
01/08/23 16:37	305214.3			0.9			4.67			0.63			5.52			1		
01/08/23 16:38	303597			0.9			4.67			0.63			5.49			1		
01/08/23 16:39	304906.2			0.9			4.74			0.64			5.6			1		
01/08/23 16:40	297897.8			0.8			4.83			0.56			5.57			1		
01/08/23 16:41	278720.8			0.8			4.83			0.53			5.21			1		
01/08/23 16:42	270942.2			0.8			5.26			0.52			5.53			1		
01/08/23 16:43	271481.3			0.7			6.64			0.47			6.98			1		
01/08/23 16:44	273483.7			0.6			7.01			0.42			7.43			1		
01/08/23 16:45	273945.8			0.6			7.38			0.42			7.83			1		
01/08/23 16:46	272251.5			0.6			7.38			0.41			7.78			1		
01/08/23 16:47	270634.1			0.6			7.38			0.41			7.74			1		
01/08/23 16:48	279953.1			0.6			7.47			0.43			8.1			1		
01/08/23 16:49	301440.5			0.6			7.47			0.46			8.72			1		
01/08/23 16:50	321002.6			0.6			6.17			0.48			7.68			1		
01/08/23 16:51	329705.4			0.7			5.81			0.55			7.43			1		
01/08/23 16:52	324160.2			0.8			5.37			0.6			6.75			1		
01/08/23 16:53	333633.2			0.8			5.02			0.62			6.49			1		
01/08/23 16:54	350730.8			0.9			3.7			0.73			5.03			1		
01/08/23 16:55	361744			0.8			1.97			0.69			2.76			1		
01/08/23 16:56	372218.2			0.8			1.18			0.72			1.7			1		
01/08/23 16:57	376762.1			0.7			1.18			0.64			1.72			1		
01/08/23 16:58	375683.9			0.7			1.16			0.63			1.69			1		
01/08/23 16:59	357431.1			0.8			1.16			0.68			1.61			0		
01/08/23 17:00	343491.3			0.8			1.21			0.63			1.62			0		
01/08/23 17:01	339948.5			0.9			1.3			0.69			1.71			0		
01/08/23 17:02	339871.5			0.9			1.23			0.7			1.62			0		
01/08/23 17:03	342721.1			0.9			1.14			0.71			1.52			0		

CT1 SUSD EVENT 8

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 22:03	265936.2			0.6			1.29			0.35			1.33			0		
01/08/23 22:04	266398.3			0.6			1.29			0.35			1.33			0		
01/08/23 22:05	266706.3			0.6			1.2			0.35			1.24			0		
01/08/23 22:06	266244.2			0.6			1.29			0.35			1.33			0		
01/08/23 22:07	265705.1			0.6			1.29			0.35			1.33			0		
01/08/23 22:08	262162.4			0.6			1.29			0.34			1.31			1		
01/08/23 22:09	241984.2			0.6			1.48			0.32			1.38			1		
01/08/23 22:10	220342.7			0.6			4.35			0.3			3.72			1		
01/08/23 22:11	196852.8			0.5			9.44			0.25			7.2			1		
01/08/23 22:12	173517			4.6			13.33			1.88			8.96			1		
01/08/23 22:13	155264.2			261.5			16.09			95.58			9.68			1		
01/08/23 22:14	137627.5			1027.8			18.15			333.14			9.68			1		
01/08/23 22:15	32500.7			1843.8			20.13			141.15			2.54			1		
01/08/23 22:16	24876.2			0			18.54			247.31			1.79			0		
01/08/23 22:17	24876.2			0			5.9			21.8			0.57			0		
01/08/23 22:18	24799.1			0			11.8			11.38			1.13			0		
01/08/23 22:19	24876.2			0			5.9			10.38			0.57			0		
01/08/23 22:20	24953.2			0			5.9			9.69			0.57			0		

CT1 SUSD EVENT 9

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 13:49	23952			0			0			0			0			0		
01/09/23 13:50	23720.9			0			0			0			0			0		
01/09/23 13:51	23952			0			0			0			0			0		
01/09/23 13:52	24029			0			0			0			0			0		
01/09/23 13:53	23797.9			0			0			0			0			0		
01/09/23 13:54	30190.3			0			0			0			0			1		
01/09/23 13:55	35504.4			0			0			0			0			1		
01/09/23 13:56	44746.3			33.7			16.01			3.55			2.78			1		
01/09/23 13:57	56837.8			1133.8			12.84			151.78			2.83			1		
01/09/23 13:58	67080.9			754.9			19.56			119.3			5.09			1		
01/09/23 13:59	90493.8			428.3			24.4			91.27			8.56			1		
01/09/23 14:00	133391.7			304.7			34.37			95.71			17.77			1		
01/09/23 14:01	144867			194.7			49.31			66.42			27.68			1		
01/09/23 14:02	154648.1			934			52.38			340.16			31.4			1		
01/09/23 14:03	171206.5			1810.5			48.55			729.88			32.21			1		
01/09/23 14:04	189998.4			1667.5			51.7			746.17			38.08			1		
01/09/23 14:05	214951.6			524.7			50.63			265.55			42.17			1		
01/09/23 14:06	234205.6			52.4			50.27			28.88			45.63			1		
01/09/23 14:07	259081.7			3.4			45.78			2.07			45.97			1		
01/09/23 14:08	284959.1			1.7			36.5			1.14			40.31			1		
01/09/23 14:09	293122.8			1.6			16.7			1.13			18.98			1		
01/09/23 14:10	294971.2			1.6			12.48			1.13			14.27			1		
01/09/23 14:11	292891.8			1.7			10.35			1.18			11.74			1		
01/09/23 14:12	293353.8			1.6			8.85			1.14			10.06			1		
01/09/23 14:13	293353.8			1.5			8.16			1.02			9.27			1		
01/09/23 14:14	292814.7			1.3			7.49			0.91			8.49			1		
01/09/23 14:15	296742.5			1.1			7.31			0.8			8.41			1		
01/09/23 14:16	307139.7			1.1			6.6			0.76			7.86			1		
01/09/23 14:17	307293.7			1			6.25			0.7			7.45			1		
01/09/23 14:18	308063.9			1			5.81			0.69			6.94			1		
01/09/23 14:19	306369.5			1			5.73			0.69			6.8			1		
01/09/23 14:20	304983.3			0.9			5.81			0.63			6.87			1		
01/09/23 14:21	304213.1			0.9			5.64			0.63			6.64			1		
01/09/23 14:22	304983.3			0.8			5.55			0.57			6.56			1		
01/09/23 14:23	304444.1			0.8			5.46			0.57			6.44			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 14:24	306831.6			0.8			5.46			0.57			6.49			1		
01/09/23 14:25	305984.5			0.8			5.46			0.57			6.47			1		
01/09/23 14:26	305291.3			0.8			5.46			0.57			6.46			1		
01/09/23 14:27	303674			0.7			5.55			0.5			6.53			1		
01/09/23 14:28	304136.1			0.7			5.55			0.5			6.54			1		
01/09/23 14:29	303134.9			0.7			5.55			0.5			6.52			1		
01/09/23 14:30	303828			0.7			5.55			0.5			6.53			1		
01/09/23 14:31	300516.3			0.7			5.64			0.5			6.56			1		
01/09/23 14:32	284651			0.7			5.72			0.48			6.31			1		
01/09/23 14:33	277334.5			0.6			5.99			0.41			6.44			1		
01/09/23 14:34	274022.8			0.6			7.08			0.41			7.52			1		
01/09/23 14:35	269478.9			0.6			7.56			0.35			7.9			1		
01/09/23 14:36	269247.8			0.5			6.64			0.29			6.93			1		
01/09/23 14:37	270172			0.5			3.23			0.29			3.38			1		
01/09/23 14:38	269401.9			0.5			2.03			0.29			2.12			1		
01/09/23 14:39	268708.7			0.5			1.75			0.29			1.82			1		
01/09/23 14:40	268323.7			0.5			1.75			0.29			1.82			1		
01/09/23 14:41	269170.8			0.5			1.75			0.29			1.83			1		
01/09/23 14:42	269555.9			0.5			1.84			0.29			1.93			0		
01/09/23 14:43	268400.7			0.5			1.94			0.29			2.01			0		
01/09/23 14:44	273791.8			0.5			1.94			0.3			2.05			0		
01/09/23 14:45	275255.1			0.5			1.94			0.3			2.07			0		
01/09/23 14:46	275563.2			0.5			1.84			0.3			1.97			0		

CT1 SUSD EVENT 10

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/09/23 21:41	339486.4			0.9			1.45			0.68			1.91			0		
01/09/23 21:42	336174.7			0.9			1.45			0.68			1.89			0		
01/09/23 21:43	333248.1			0.9			1.3			0.68			1.68			0		
01/09/23 21:44	314764.3			0.8			1.21			0.58			1.48			0		
01/09/23 21:45	297281.7			0.9			1.56			0.61			1.8			0		
01/09/23 21:46	295125.2			0.8			1.76			0.55			2.01			1		
01/09/23 21:47	285344.2			0.8			1.61			0.54			1.78			1		
01/09/23 21:48	264780.9			0.7			1.43			0.45			1.47			1		
01/09/23 21:49	241753.1			0.6			2.09			0.36			1.96			1		
01/09/23 21:50	221112.9			0.6			5.32			0.3			4.56			1		
01/09/23 21:51	196236.7			0.4			16.09			0.2			12.24			1		
01/09/23 21:52	173902.1			5.7			19.59			2.32			13.2			1		
01/09/23 21:53	155264.2			329.6			22.93			120.48			13.79			1		
01/09/23 21:54	136857.4			1369.3			25.26			441.36			13.4			1		
01/09/23 21:55	8009.7			1870.8			26.03			35.18			0.81			1		
01/09/23 21:56	0			0			24.34			0			0			0		
01/09/23 21:57	0			0			5.9			0			0			0		
01/09/23 21:58	0			0			5.9			0			0			0		
01/09/23 21:59	0			0			5.9			0			0			0		
01/09/23 22:00	0			0			2.95			0			0			0		

CT1 SUSD EVENT 11

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 15:51	13554.8			0			0			0			0			0		
01/10/23 15:52	13862.9			0			0			0			0			0		
01/10/23 15:53	14093.9			0			0			0			0			0		
01/10/23 15:54	16481.4			0			0			0			0			0		
01/10/23 15:55	20024.2			0			0			0			0			0		
01/10/23 15:56	30883.4			0			0			0			0			1		
01/10/23 15:57	39586.2			47.2			8.85			4.4			1.36			1		
01/10/23 15:58	47980.9			1045.3			14.75			118.16			2.74			1		
01/10/23 15:59	57453.9			997.1			15.08			134.81			3.35			1		
01/10/23 16:00	71855.9			592.1			21.83			100.19			6.08			1		
01/10/23 16:01	104356.6			398.3			25.21			97.88			10.2			1		
01/10/23 16:02	142017.5			279			37.61			93.31			20.7			1		
01/10/23 16:03	150566.2			167.4			54.67			59.34			31.9			1		
01/10/23 16:04	165738.4			1531.7			51.13			597.95			32.85			1		
01/10/23 16:05	184376.2			1750			52.28			759.96			37.36			1		
01/10/23 16:06	205863.7			967.7			52.67			469.21			42.03			1		
01/10/23 16:07	229584.6			110.7			52.97			59.84			47.13			1		
01/10/23 16:08	248915.6			8.9			50.09			5.22			48.33			1		
01/10/23 16:09	274561.9			1.9			48.04			1.23			51.11			1		
01/10/23 16:10	297974.8			1.6			26.74			1.14			30.88			1		
01/10/23 16:11	307832.8			1.6			15.53			1.13			18.53			1		
01/10/23 16:12	308063.9			1.6			11.38			1.16			13.59			1		
01/10/23 16:13	309219.1			1.7			10.35			1.25			12.4			1		
01/10/23 16:14	309681.2			1.5			9.32			1.12			11.19			1		
01/10/23 16:15	309065.1			1.4			8.29			1			9.93			1		
01/10/23 16:16	308680			1.3			7.78			0.93			9.31			1		
01/10/23 16:17	306138.5			1.1			7.72			0.81			9.16			1		
01/10/23 16:18	304059.1			1			6.85			0.75			8.08			1		
01/10/23 16:19	302441.7			1.4	X		6.67	X		1	X		7.82	X		1		
01/10/23 16:20	303982			0.9	X		6.51	X		0.66	X		7.67	X		1		
01/10/23 16:21	304059.1			0.9	X		6.43	X		0.63	X		7.58	X		1		
01/10/23 16:22	303982			0.9	X		6.43	X		0.63	X		7.57	X		1		
01/10/23 16:23	304983.3			0.8	X		6.43	X		0.57	X		7.6	X		1		
01/10/23 16:24	303674			0.8	X		6.43	X		0.57	X		7.57	X		1		
01/10/23 16:25	302056.7			0.8	X		6.43	X		0.56	X		7.53	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 16:26	302518.8			0.7	X		6.43	X		0.5	X		7.54	X		1		
01/10/23 16:27	301286.5			0.7			6.34			0.5			7.4			1		
01/10/23 16:28	300824.4			0.7			6.25			0.5			7.29			1		
01/10/23 16:29	301671.6			0.7			6.16			0.5			7.21			1		
01/10/23 16:30	302056.7			0.7			6.26			0.51			7.33			1		
01/10/23 16:31	303597			0.6			6.35			0.45			7.47			1		
01/10/23 16:32	304213.1			0.6			6.34			0.44			7.47			1		
01/10/23 16:33	306446.6			0.6			6.43			0.44			7.64			1		
01/10/23 16:34	307139.7			0.6			6.52			0.45			7.76			1		
01/10/23 16:35	290812.3			0.6			6.69			0.42			7.54			1		
01/10/23 16:36	287885.7			0.6			6.62			0.42			7.38			1		
01/10/23 16:37	281955.5			0.6			7.26			0.42			7.93			1		
01/10/23 16:38	277103.5			0.5			6.26			0.36			6.73			1		
01/10/23 16:39	272174.4			0.5			3.36			0.35			3.54			1		
01/10/23 16:40	269401.9			0.5			2.21			0.29			2.31			1		
01/10/23 16:41	269941			0.5			2.03			0.29			2.12			1		
01/10/23 16:42	270095			0.5			1.84			0.29			1.93			1		
01/10/23 16:43	269401.9			0.5			1.48			0.29			1.54			1		
01/10/23 16:44	268708.7			0.5			1.29			0.29			1.34			1		
01/10/23 16:45	269016.8			0.5			1.11			0.29			1.15			0		
01/10/23 16:46	270018			0.4			1.01			0.23			1.06			0		
01/10/23 16:47	270403.1			0.4			0.92			0.23			0.97			0		
01/10/23 16:48	282725.6			0.4			0.83			0.25			0.91			0		
01/10/23 16:49	302903.8			0.4			0.82			0.26			0.96			0		

CT1 SUSD EVENT 12

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 23:02	267784.5			0.4			1.78			0.24			1.85			0		
01/10/23 23:03	268092.6			0.4			1.69			0.24			1.75			0		
01/10/23 23:04	268708.7			0.4			1.5			0.24			1.56			0		
01/10/23 23:05	268323.7			0.4			1.4			0.24			1.46			0		
01/10/23 23:06	267168.4			0.4			1.31			0.24			1.36			0		
01/10/23 23:07	268477.7			0.4			1.31			0.24			1.36			1		
01/10/23 23:08	256771.3			0.4			1.31			0.23			1.3			1		
01/10/23 23:09	234436.6			0.4			1.81			0.21			1.64			1		
01/10/23 23:10	212487.1			0.3			6.31			0.16			5.2			1		
01/10/23 23:11	187919			2			9.57			0.89			6.97			1		
01/10/23 23:12	167971.8			96.9			12.3			38.33			8.01			1		
01/10/23 23:13	149873.1			830.9			14.39			293.31			8.36			1		
01/10/23 23:14	91726			1677.4			16.9			362.33			6.01			1		
01/10/23 23:15	24414.1			0			18.83			137.39			1.78			0		
01/10/23 23:16	24260			0			5.9			207.62			0.55			0		
01/10/23 23:17	24337			0			2.95			8.28			0.28			0		
01/10/23 23:18	24106			0			2.95			4.7			0.28			0		
01/10/23 23:19	24260			0			2.95			4.71			0.28			0		

CT1 SUSD EVENT 13

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 14:57	20024.2			0			0			-0.28			0			0		
01/11/23 14:58	20178.2			0			0			0			0			0		
01/11/23 14:59	20024.2			0			0			0			0			0		
01/11/23 15:00	20178.2			0			0			0			0			0		
01/11/23 15:01	20024.2			0			0			0			0			0		
01/11/23 15:02	26416.5			0			0			0			0			1		
01/11/23 15:03	32038.6			0			0			0			0			1		
01/11/23 15:04	42897.9			37.4			18.68			3.77			3.1			1		
01/11/23 15:05	53295.1			1136.5			12.91			142.72			2.67			1		
01/11/23 15:06	64693.4			745			18.94			113.56			4.75			1		
01/11/23 15:07	85179.7			454.3			24.44			91.12			8.07			1		
01/11/23 15:08	127615.5			323.2			31.04			97.17			15.36			1		
01/11/23 15:09	143634.8			211.5			43.7			71.54			24.33			1		
01/11/23 15:10	151567.4			581.5			52.92			207.62			31.09			1		
01/11/23 15:11	169743.2			1877.3			48.63			750.51			32			1		
01/11/23 15:12	188612.1			1674.3			50.39			743.59			36.83			1		
01/11/23 15:13	211639.9			818.2			49.65			407.71			40.71			1		
01/11/23 15:14	234744.7			68.5			49.71			37.88			45.22			1		
01/11/23 15:15	255308			4.8			46.75			2.87			46.26			1		
01/11/23 15:16	281724.4			1.9			41.4			1.24			45.21			1		
01/11/23 15:17	304829.2			1.7			18.92			1.21			22.35			1		
01/11/23 15:18	315611.5			1.6			12.31			1.21			15.06			1		
01/11/23 15:19	316304.6			1.7			8.85			1.26			10.85			1		
01/11/23 15:20	315303.4			1.7			7.87			1.27			9.61			1		
01/11/23 15:21	315534.4			1.5			7.1			1.14			8.68			1		
01/11/23 15:22	314918.3			1.4			6.33			1.01			7.72			1		
01/11/23 15:23	314610.3			1.2			6.07			0.9			7.41			1		
01/11/23 15:24	314379.2			1.1			5.73			0.83			6.98			1		
01/11/23 15:25	313301			1			5.29			0.77			6.43			1		
01/11/23 15:26	313301			1			5.21			0.7			6.32			1		
01/11/23 15:27	312068.7			1			5.21			0.7			6.3			1		
01/11/23 15:28	313069.9			0.9			5.12			0.64			6.21			1		
01/11/23 15:29	312145.8			0.8			5.11			0.58			6.18			1		
01/11/23 15:30	312299.8			0.8			5.11			0.58			6.18			1		
01/11/23 15:31	311144.5			0.8			5.11			0.58			6.16			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 15:32	310913.5			0.8			5.11			0.58			6.15			1		
01/11/23 15:33	311452.6			0.8			5.11			0.58			6.16			1		
01/11/23 15:34	309758.3			0.7			5.11			0.51			6.13			1		
01/11/23 15:35	310682.4			0.7			5.11			0.52			6.15			1		
01/11/23 15:36	309604.2			0.7			5.11			0.51			6.13			1		
01/11/23 15:37	311144.5			0.7			5.11			0.52			6.16			1		
01/11/23 15:38	310143.3			0.7			5.2			0.51			6.25			1		
01/11/23 15:39	311067.5			0.7			5.37			0.52			6.47			1		
01/11/23 15:40	298976			0.6			5.37			0.43			6.22			1		
01/11/23 15:41	291197.4			0.6			5.54			0.43			6.25			1		
01/11/23 15:42	286961.5			0.6			5.63			0.42			6.26			1		
01/11/23 15:43	287346.6			0.5			6.26			0.37			6.97			1		
01/11/23 15:44	289734.1			0.5			4.18			0.37			4.69			1		
01/11/23 15:45	281416.4			0.5			2.09			0.36			2.28			1		
01/11/23 15:46	276487.3			0.5			1.36			0.35			1.46			1		
01/11/23 15:47	273868.8			0.5			1.29			0.3			1.37			1		
01/11/23 15:48	273637.8			0.5			1.2			0.3			1.27			1		
01/11/23 15:49	273098.6			0.5			1.11			0.3			1.17			0		
01/11/23 15:50	271019.2			0.5			1.11			0.29			1.16			0		
01/11/23 15:51	271173.3			0.5			1.01			0.29			1.07			0		
01/11/23 15:52	271250.3			0.4			1.01			0.24			1.07			0		
01/11/23 15:53	285575.2			0.4			1.01			0.25			1.12			0		

CT1 SUSD EVENT 14

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 20:55	291351.4			0.7			1.74			0.48			1.96			0		
01/11/23 20:56	279799			0.7			1.67			0.46			1.81			0		
01/11/23 20:57	282648.6			0.6			1.63			0.42			1.79			0		
01/11/23 20:58	275332.1			0.5			1.63			0.29			1.74			0		
01/11/23 20:59	269555.9			0.5			1.54			0.29			1.61			0		
01/11/23 21:00	266552.3			0.5			1.48			0.29			1.52			1		
01/11/23 21:01	248145.5			0.5			1.38			0.27			1.33			1		
01/11/23 21:02	227890.3			0.4			2.66			0.2			2.35			1		
01/11/23 21:03	204323.4			0.3			8.38			0.15			6.64			1		
01/11/23 21:04	180448.4			3.1			11.57			1.33			8.09			1		
01/11/23 21:05	161964.6			190.1			15.52			72.5			9.74			1		
01/11/23 21:06	144096.9			1091.1			18			370.25			10.05			1		
01/11/23 21:07	62537			1715.8			20.16			252.71			4.89			1		
01/11/23 21:08	23258.8			0			21.86			151.77			1.97			0		
01/11/23 21:09	23412.9			0			5.9			69.85			0.53			0		
01/11/23 21:10	23412.9			0			2.95			6.01			0.27			0		
01/11/23 21:11	23566.9			0			2.95			4.75			0.27			0		
01/11/23 21:12	23566.9			0			2.95			4.59			0.27			0		

CT1 SUSD EVENT 15

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 15:43	28341.9			0			0			0			0			0		
01/12/23 15:44	28110.8			0			0			0			0			0		
01/12/23 15:45	28264.9			0			0			0			0			0		
01/12/23 15:46	28264.9			0			0			0			0			0		
01/12/23 15:47	28110.8			0			0			0			0			0		
01/12/23 15:48	31884.6			0			0			0			0			1		
01/12/23 15:49	35196.3			0			0			0			0			1		
01/12/23 15:50	42512.8			47.2			14.75			4.72			2.43			1		
01/12/23 15:51	52293.8			1050.7			14.07			129.35			2.85			1		
01/12/23 15:52	62691			878.8			17.37			129.63			4.22			1		
01/12/23 15:53	75937.8			481.8			22.76			86.18			6.7			1		
01/12/23 15:54	111288.1			295.3			25.4			77.39			10.96			1		
01/12/23 15:55	143326.7			187.4			40.17			63.27			22.31			1		
01/12/23 15:56	143557.8			132.1			56.53			44.65			31.44			1		
01/12/23 15:57	155649.3			1610.9			48.27			590.28			29.11			1		
01/12/23 15:58	174595.2			1829			51.02			752.1			34.53			1		
01/12/23 15:59	196159.7			1356.7			51.28			626.82			39			1		
01/12/23 16:00	219264.5			195.5			52.03			100.96			44.22			1		
01/12/23 16:01	239750.7			15.9			49.73			8.97			46.2			1		
01/12/23 16:02	264010.8			2.3			45.48			1.4			46.53			1		
01/12/23 16:03	289426			1.9			29.4			1.27			32.98			1		
01/12/23 16:04	306600.6			1.7			14.75			1.23			17.52			1		
01/12/23 16:05	308680			1.6			10.09			1.18			12.07			1		
01/12/23 16:06	309527.2			1.7			8.47			1.25			10.15			1		
01/12/23 16:07	309065.1			1.6			7.72			1.14			9.25			1		
01/12/23 16:08	307524.8			1.4			7.2			1.01			8.58			1		
01/12/23 16:09	308988.1			1.3			6.51			0.95			7.79			1		
01/12/23 16:10	305984.5			1.1			6.34			0.82			7.52			1		
01/12/23 16:11	304906.2			1.1			5.81			0.76			6.87			1		
01/12/23 16:12	302056.7			1			5.64			0.69			6.6			1		
01/12/23 16:13	300978.4			0.9			5.46			0.62			6.37			1		
01/12/23 16:14	302749.8			0.9			5.36			0.64			6.29			1		
01/12/23 16:15	302826.8			0.8			5.27			0.57			6.19			1		
01/12/23 16:16	304367.1			0.8			5.27			0.58			6.22			1		
01/12/23 16:17	302826.8			0.8			5.27			0.57			6.19			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 16:18	303751			0.7			5.27			0.51			6.21			1		
01/12/23 16:19	302210.7			0.7			5.27			0.51			6.18			1		
01/12/23 16:20	301209.5			0.7			5.27			0.51			6.16			1		
01/12/23 16:21	299438.1			0.7			5.18			0.5			6.02			1		
01/12/23 16:22	301440.5			0.7			5.1			0.51			5.95			1		
01/12/23 16:23	299130			0.6			5.1			0.44			5.91			1		
01/12/23 16:24	301055.4			0.6			5.18			0.44			6.05			1		
01/12/23 16:25	302056.7			0.6			5.18			0.45			6.07			1		
01/12/23 16:26	303442.9			0.6			5.27			0.45			6.2			1		
01/12/23 16:27	302518.8			0.6			5.45			0.45			6.39			1		
01/12/23 16:28	292660.7			0.6			5.54			0.43			6.29			1		
01/12/23 16:29	279182.9			0.6			5.63			0.41			6.09			1		
01/12/23 16:30	276795.4			0.6			5.81			0.36			6.23			1		
01/12/23 16:31	272328.5			0.6			4.61			0.35			4.87			1		
01/12/23 16:32	269786.9			0.5			2.4			0.29			2.51			1		
01/12/23 16:33	269401.9			0.5			2.25			0.3			2.35			1		
01/12/23 16:34	269478.9			0.5			2.9			0.3			3.03			1		
01/12/23 16:35	269324.8			0.4			3.56			0.24			3.71			1		
01/12/23 16:36	269864			0.4			4.12			0.24			4.31			1		
01/12/23 16:37	268939.8			0.4			3.75			0.24			3.9			1		
01/12/23 16:38	268862.8			0.4			2.72			0.24			2.83			1		
01/12/23 16:39	269324.8			0.4			2.53			0.24			2.64			1		
01/12/23 16:40	269247.8			0.4			2.34			0.24			2.44			1		
01/12/23 16:41	269247.8			0.4			2.15			0.24			2.25			1		
01/12/23 16:42	268939.8			0.4			2.15			0.24			2.24			1		
01/12/23 16:43	270249			0.4			2.25			0.24			2.35			1		
01/12/23 16:44	281416.4			0.4			2.25			0.25			2.45			1		
01/12/23 16:45	283110.7			0.4			2.21			0.25			2.43			1		
01/12/23 16:46	283033.7			0.5			2.12			0.31			2.33			1		
01/12/23 16:47	281108.3			0.5			1.84			0.31			2.01			1		
01/12/23 16:48	280107.1			0.5			1.75			0.3			1.9			1		
01/12/23 16:49	279953.1			0.5			1.75			0.3			1.9			1		
01/12/23 16:50	280415.2			0.5			1.75			0.3			1.9			1		
01/12/23 16:51	280492.2			0.5			1.84			0.3			2			0		
01/12/23 16:52	280261.1			0.5			1.84			0.3			2			0		
01/12/23 16:53	281647.4			0.5			1.84			0.31			2.01			0		
01/12/23 16:54	282802.7			0.5			1.75			0.31			1.92			0		
01/12/23 16:55	282802.7			0.5			1.75			0.31			1.92			0		

CT1 SUSD EVENT 16

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/12/23 22:03	268015.6			0.5			1.12			0.3			1.17			0		
01/12/23 22:04	268323.7			0.5			1.22			0.3			1.27			0		
01/12/23 22:05	268015.6			0.5			1.31			0.3			1.36			0		
01/12/23 22:06	268631.7			0.5			1.31			0.3			1.36			0		
01/12/23 22:07	268554.7			0.5			1.4			0.3			1.46			0		
01/12/23 22:08	264241.8			0.5			1.5			0.29			1.53			1		
01/12/23 22:09	243678.5			0.5			1.59			0.27			1.5			1		
01/12/23 22:10	223962.5			0.4			3.97			0.2			3.44			1		
01/12/23 22:11	198778.2			0.3			9.87			0.15			7.6			1		
01/12/23 22:12	175981.5			3			13.45			1.22			9.17			1		
01/12/23 22:13	159038			248.1			16.49			92.9			10.17			1		
01/12/23 22:14	139475.9			1255.5			18.46			412.28			9.97			1		
01/12/23 22:15	50214.4			1825.4			20.82			215.74			4.05			1		
01/12/23 22:16	31961.6			0			20.42			220.37			2.53			0		
01/12/23 22:17	31961.6			0			5.9			48.59			0.73			0		
01/12/23 22:18	31807.6			0			2.95			7.3			0.36			0		
01/12/23 22:19	31807.6			0			2.95			6.19			0.36			0		
01/12/23 22:20	31730.6			0			2.95			5.96			0.36			0		

CT1 SUSD EVENT 17

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 14:49	18329.8			0			0			0			0			0		
01/14/23 14:50	18329.8			0			0			0			0			0		
01/14/23 14:51	18252.8			0			0			0			0			0		
01/14/23 14:52	18329.8			0			0			0			0			0		
01/14/23 14:53	18945.9			0			0			0			0			0		
01/14/23 14:54	29959.2			0			0			0			0			1		
01/14/23 14:55	34580.2			23.6			0			1.92			0			1		
01/14/23 14:56	43206			64.9			13.11			6.61			2.2			1		
01/14/23 14:57	55913.6			1105.4			12.15			145.49			2.63			1		
01/14/23 14:58	70700.7			653.1			16.82			108.77			4.61			1		
01/14/23 14:59	98888.5			439.3			19.85			102.26			7.6			1		
01/14/23 15:00	134392.9			302.6			22.13			95.79			11.53			1		
01/14/23 15:01	143480.8			190.4			42.52			64.32			23.64			1		
01/14/23 15:02	152645.7			1385.6			40.94			498.12			24.22			1		
01/14/23 15:03	169512.2			1888.9			45.29			753.88			29.75			1		
01/14/23 15:04	191230.7			1689.4			54.03			760.88			40.05			1		
01/14/23 15:05	214027.4			434.3			59			218.91			48.95			1		
01/14/23 15:06	234128.6			45.5			59.25			25.07			53.76			1		
01/14/23 15:07	256386.2			3.6			72.8			2.15			72.34			1		
01/14/23 15:08	285883.3			2			74.3			1.35			82.31			1		
01/14/23 15:09	304983.3			1.8			34.76			1.3			41.09			1		
01/14/23 15:10	313378			1.8			14.16			1.31			17.2			1		
01/14/23 15:11	312453.8			1.9			11.21			1.36			13.57			1		
01/14/23 15:12	311606.6			1.8			9.78			1.3			11.81			1		
01/14/23 15:13	309296.2			1.7			8.38			1.25			10.05			1		
01/14/23 15:14	310143.3			1.5			7.27			1.12			8.74			1		
01/14/23 15:15	307216.7			1.4			6.5			0.99			7.74			1		
01/14/23 15:16	307370.8			1.3			6.07			0.93			7.23			1		
01/14/23 15:17	305522.4			1.1			5.55			0.81			6.57			1		
01/14/23 15:18	305291.3			1			5.47			0.75			6.47			1		
01/14/23 15:19	302980.8			1			5.29			0.68			6.21			1		
01/14/23 15:20	303288.9			1			5.12			0.68			6.02			1		
01/14/23 15:21	302672.8			0.9			5.02			0.63			5.89			1		
01/14/23 15:22	302749.8			0.9			4.93			0.63			5.79			1		
01/14/23 15:23	301825.6			0.9			4.84			0.63			5.67			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 15:24	302749.8			0.8			4.84			0.57			5.68			1		
01/14/23 15:25	302980.8			0.8			4.84			0.57			5.69			1		
01/14/23 15:26	301517.5			0.8			4.84			0.56			5.66			1		
01/14/23 15:27	301286.5			0.8			4.84			0.56			5.66			1		
01/14/23 15:28	301825.6			0.8			4.76			0.56			5.56			1		
01/14/23 15:29	298976			0.7			4.76			0.5			5.51			1		
01/14/23 15:30	300593.3			0.7			4.76			0.5			5.54			1		
01/14/23 15:31	302672.8			0.7			4.76			0.5			5.58			1		
01/14/23 15:32	303365.9			0.7			4.84			0.5			5.69			1		
01/14/23 15:33	303905			0.7			4.93			0.5			5.81			1		
01/14/23 15:34	288501.8			0.7			5.2			0.48			5.81			1		
01/14/23 15:35	284959.1			0.7			5.01			0.48			5.53			1		
01/14/23 15:36	279799			0.6			5.63			0.42			6.1			1		
01/14/23 15:37	274099.8			0.5			6.17			0.35			6.56			1		
01/14/23 15:38	268477.7			0.5			6.9			0.34			7.18			1		
01/14/23 15:39	266860.3			0.5			7.84			0.29			8.1			1		
01/14/23 15:40	268015.6			0.5			5.44			0.29			5.65			1		
01/14/23 15:41	268092.6			0.5			2.77			0.29			2.87			1		
01/14/23 15:42	267168.4			0.5			2.67			0.29			2.77			1		
01/14/23 15:43	268015.6			0.5			3.5			0.29			3.64			1		
01/14/23 15:44	267784.5			0.5			4.15			0.29			4.31			1		
01/14/23 15:45	267245.4			0.5			4.7			0.29			4.87			1		
01/14/23 15:46	268477.7			0.5			3.69			0.29			3.84			1		
01/14/23 15:47	269864			0.5			2.86			0.29			2.99			1		
01/14/23 15:48	269555.9			0.5			2.58			0.29			2.7			1		
01/14/23 15:49	267399.5			0.5			2.4			0.29			2.48			1		
01/14/23 15:50	267014.4			0.5			2.3			0.29			2.38			1		
01/14/23 15:51	266475.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:52	266629.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:53	266398.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:54	267630.5			0.5			2.3			0.29			2.39			1		
01/14/23 15:55	266706.3			0.5			2.3			0.29			2.38			1		
01/14/23 15:56	266552.3			0.5			2.21			0.29			2.29			1		
01/14/23 15:57	266244.2			0.5			2.12			0.29			2.19			1		
01/14/23 15:58	275563.2			0.5			1.94			0.3			2.07			1		
01/14/23 15:59	289580.1			0.5			1.84			0.31			2.07			1		
01/14/23 16:00	290350.2			0.5			1.63			0.31			1.84			1		
01/14/23 16:01	286268.4			0.5			1.34			0.36			1.49			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 16:02	286037.3			0.5			1.16			0.36			1.29			0		
01/14/23 16:03	296126.4			0.5			1.18			0.38			1.35			0		
01/14/23 16:04	313917.1			0.5			1.25			0.4			1.52			0		
01/14/23 16:05	333171.1			0.5			1.41			0.41			1.82			0		
01/14/23 16:06	337098.9			0.6			1.5			0.49			1.96			0		

CT1 SUSD EVENT 18

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/14/23 20:03	287423.6			0.5			1.34			0.36			1.49			0		
01/14/23 20:04	270018			0.5			1.43			0.34			1.5			0		
01/14/23 20:05	265628.1			0.5			2			0.34			2.06			0		
01/14/23 20:06	265243			0.5			2.3			0.29			2.37			0		
01/14/23 20:07	265243			0.5			1.66			0.29			1.71			0		
01/14/23 20:08	258157.5			0.4			1.48			0.22			1.48			1		
01/14/23 20:09	236670.1			0.4			1.59			0.21			1.46			1		
01/14/23 20:10	214643.5			0.3			5.2			0.15			4.33			1		
01/14/23 20:11	190383.5			1			9.83			0.44			7.26			1		
01/14/23 20:12	168202.9			9.5			12.17			3.75			7.93			1		
01/14/23 20:13	151490.4			489.7			16.05			174.73			9.43			1		
01/14/23 20:14	110826			1564.7			18.32			408.41			7.87			1		
01/14/23 20:15	3080.6			0			20.47			14.32			0.24			0		
01/14/23 20:16	0			0			11.8			0			0			0		
01/14/23 20:17	2079.4			0			5.9			1.1			0.05			0		
01/14/23 20:18	2926.6			0			2.95			0.57			0.03			0		
01/14/23 20:19	0			0			2.95			0			0			0		

CT1 SUSD EVENT 19

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 14:54	0			0			0			0			0			0		
01/15/23 14:55	0			0			0			0			0			0		
01/15/23 14:56	0			0			0			0			0			0		
01/15/23 14:57	0			0			0			0			0			0		
01/15/23 14:58	2156.4			0			0			0			0			0		
01/15/23 14:59	13400.8			0			0			0			0			1		
01/15/23 15:00	28187.8			29.5			2.95			1.96			0.32			1		
01/15/23 15:01	40433.4			1003			14.75			95.42			2.31			1		
01/15/23 15:02	53064			1039.7			12.78			129.87			2.63			1		
01/15/23 15:03	66233.7			648.7			19.18			101.21			4.92			1		
01/15/23 15:04	94960.7			433.9			23.87			97.03			8.78			1		
01/15/23 15:05	135856.2			305.8			33.43			97.82			17.6			1		
01/15/23 15:06	141863.4			198.6			48.42			66.32			26.61			1		
01/15/23 15:07	150412.2			1239.4			49.52			438.89			28.86			1		
01/15/23 15:08	167509.7			1878.3			49.11			740.83			31.88			1		
01/15/23 15:09	188535.1			1726			51.98			766.14			37.98			1		
01/15/23 15:10	211100.8			686.9			51.7			341.52			42.3			1		
01/15/23 15:11	232896.3			60.1			50.21			32.98			45.32			1		
01/15/23 15:12	255385			5.2			46.75			3.14			46.27			1		
01/15/23 15:13	280261.1			2.1			41.82			1.37			45.42			1		
01/15/23 15:14	304290.1			1.8			18.81			1.26			22.18			1		
01/15/23 15:15	312992.9			1.8			13.51			1.32			16.39			1		
01/15/23 15:16	315072.3			1.9			10.03			1.38			12.25			1		
01/15/23 15:17	313146.9			1.9			8.43			1.37			10.23			1		
01/15/23 15:18	311914.7			1.7			7.84			1.24			9.47			1		
01/15/23 15:19	310374.4			1.5			7.01			1.12			8.43			1		
01/15/23 15:20	308911.1			1.4			6.58			1			7.88			1		
01/15/23 15:21	308757			1.2			6.07			0.87			7.26			1		
01/15/23 15:22	306908.7			1.1			6.07			0.82			7.22			1		
01/15/23 15:23	305830.4			1			5.9			0.75			6.99			1		
01/15/23 15:24	306831.6			1			5.73			0.75			6.81			1		
01/15/23 15:25	306138.5			1			5.55			0.69			6.59			1		
01/15/23 15:26	304906.2			0.9			5.47			0.62			6.46			1		
01/15/23 15:27	305753.4			0.9			5.47			0.62			6.48			1		
01/15/23 15:28	305368.3			0.9			5.47			0.62			6.47			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 15:29	304213.1			0.8			5.46			0.57			6.44			1		
01/15/23 15:30	303597			0.8			5.46			0.57			6.42			1		
01/15/23 15:31	303288.9			0.8			5.46			0.57			6.42			1		
01/15/23 15:32	301517.5			0.8			5.46			0.56			6.38			1		
01/15/23 15:33	301825.6			0.7			5.37			0.5			6.28			1		
01/15/23 15:34	303674			0.7			5.46			0.5			6.43			1		
01/15/23 15:35	303597			0.7			5.46			0.5			6.42			1		
01/15/23 15:36	304059.1			0.7			5.64			0.5			6.64			1		
01/15/23 15:37	305137.3			0.7			5.72			0.51			6.77			1		
01/15/23 15:38	304675.2			0.7			5.81			0.51			6.86			1		
01/15/23 15:39	306061.5			0.7			5.9			0.51			7			1		
01/15/23 15:40	305368.3			0.7			5.99			0.51			7.09			1		
01/15/23 15:41	303211.9			0.7			6.16			0.5			7.24			1		
01/15/23 15:42	303751			0.7			5.28			0.5			6.22			1		
01/15/23 15:43	305830.4			0.7			3.26			0.51			3.86			1		
01/15/23 15:44	297512.7			0.7			2.64			0.49			3.05			1		
01/15/23 15:45	292583.7			0.7			3.17			0.49			3.59			1		
01/15/23 15:46	288193.8			0.7			3.49			0.49			3.89			1		
01/15/23 15:47	284266			0.6			4.29			0.42			4.73			1		
01/15/23 15:48	277642.6			0.6			4.18			0.42			4.49			1		
01/15/23 15:49	274561.9			0.5			2.63			0.35			2.8			1		
01/15/23 15:50	271481.3			0.5			1.72			0.35			1.81			1		
01/15/23 15:51	271096.2			0.6			1.57			0.35			1.65			1		
01/15/23 15:52	268939.8			0.5			1.38			0.29			1.44			1		
01/15/23 15:53	278104.7			0.5			1.2			0.3			1.29			1		
01/15/23 15:54	299053			0.5			1.01			0.32			1.18			0		
01/15/23 15:55	320001.4			0.5			0.89			0.4			1.11			0		
01/15/23 15:56	329243.3			0.6			0.7			0.48			0.9			0		
01/15/23 15:57	324622.3			0.7			0.61			0.53			0.76			0		
01/15/23 15:58	332169.9			0.7			0.61			0.54			0.78			0		

CT1 SUSD EVENT 20

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 22:01	266244.2			0.5			2.12			0.29			2.19			0		
01/15/23 22:02	267476.5			0.4			1.57			0.23			1.62			0		
01/15/23 22:03	266783.3			0.4			1.48			0.23			1.53			0		
01/15/23 22:04	266321.2			0.4			1.38			0.23			1.43			0		
01/15/23 22:05	266629.3			0.4			1.38			0.23			1.43			0		
01/15/23 22:06	260160			0.4			1.38			0.23			1.39			1		
01/15/23 22:07	236362			0.4			1.59			0.21			1.46			1		
01/15/23 22:08	215798.8			0.4			5.1			0.2			4.26			1		
01/15/23 22:09	190768.6			0.3			9.18			0.15			6.79			1		
01/15/23 22:10	169204.1			8.3			10.48			3.31			6.87			1		
01/15/23 22:11	150797.3			496.4			13.72			176.24			8.02			1		
01/15/23 22:12	132082.4			1558.2			16.15			484.49			8.26			1		
01/15/23 22:13	0			1943.2			17.88			0			0			1		
01/15/23 22:14	0			0			16.52			0			0			0		
01/15/23 22:15	0			0			2.95			0			0			0		
01/15/23 22:16	0			0			2.95			0			0			0		
01/15/23 22:17	0			0			2.95			0			0			0		
01/15/23 22:18	0			0			2.95			0			0			0		

CT1 SUSD EVENT 21

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 14:55	16019.3			0			0			-0.22			0			0		
01/16/23 14:56	16173.4			0			0			-0.22			0			0		
01/16/23 14:57	15942.3			0			0			0			0			0		
01/16/23 14:58	16096.3			0			0			0			0			0		
01/16/23 14:59	15788.3			0			0			0			0			0		
01/16/23 15:00	22950.8			0			0			0			0			1		
01/16/23 15:01	29574.1			-5.9			0			-0.41			0			1		
01/16/23 15:02	39124.1			34.2			16.52			3.16			2.51			1		
01/16/23 15:03	51754.7			1086.7			12.54			132.33			2.51			1		
01/16/23 15:04	63076.1			758.3			18.32			112.71			4.48			1		
01/16/23 15:05	83716.4			468.3			23.6			92.36			7.66			1		
01/16/23 15:06	126845.3			323.2			25.65			96.52			12.61			1		
01/16/23 15:07	143403.7			210.7			46.98			71.15			26.12			1		
01/16/23 15:08	149565			786.9			53.84			277.08			31.2			1		
01/16/23 15:09	164737.2			1934.3			50.06			750.37			31.96			1		
01/16/23 15:10	182835.9			1772.3			51.79			762.9			36.69			1		
01/16/23 15:11	205863.7			956.2			51.92			463.64			41.43			1		
01/16/23 15:12	229507.6			81.4			51.3			44.01			45.63			1		
01/16/23 15:13	247298.3			6.6			47.78			3.84			45.8			1		
01/16/23 15:14	276872.4			2			43.83			1.31			47.03			1		
01/16/23 15:15	298359.9			1.7			21.7			1.2			25.09			1		
01/16/23 15:16	307909.8			1.6			15.36			1.2			18.33			1		
01/16/23 15:17	307986.9			1.8			10.79			1.28			12.88			1		
01/16/23 15:18	308911.1			1.8			9.06			1.31			10.85			1		
01/16/23 15:19	304598.2			1.6			8.21			1.17			9.69			1		
01/16/23 15:20	305984.5			1.5			7.29			1.06			8.64			1		
01/16/23 15:21	307986.9			1.3			6.85			0.94			8.18			1		
01/16/23 15:22	306677.6			1.1			6.68			0.81			7.94			1		
01/16/23 15:23	305368.3			1			6.25			0.75			7.39			1		
01/16/23 15:24	302903.8			1.1			5.9			0.75			6.93			1		
01/16/23 15:25	303828			1			5.81			0.69			6.84			1		
01/16/23 15:26	303519.9			0.9			5.64			0.63			6.63			1		
01/16/23 15:27	302518.8			0.9			5.55			0.63			6.51			1		
01/16/23 15:28	303674			0.8			5.46			0.57			6.43			1		
01/16/23 15:29	302364.7			0.8			5.37			0.56			6.29			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 15:30	303288.9			0.8			5.37			0.57			6.31			1		
01/16/23 15:31	300901.4			0.8			5.37			0.56			6.26			1		
01/16/23 15:32	300670.3			0.7			5.54			0.51			6.46			1		
01/16/23 15:33	302133.7			0.7			5.45			0.51			6.38			1		
01/16/23 15:34	301748.6			0.7			5.45			0.51			6.38			1		
01/16/23 15:35	302749.8			0.7			5.54			0.51			6.5			1		
01/16/23 15:36	301594.6			0.7			5.63			0.51			6.58			1		
01/16/23 15:37	303828			0.6			5.81			0.45			6.84			1		
01/16/23 15:38	307524.8			0.6			5.9			0.45			7.03			1		
01/16/23 15:39	291197.4			0.6			5.9			0.42			6.66			1		
01/16/23 15:40	285113.1			0.7			5.99			0.48			6.62			1		
01/16/23 15:41	280415.2			0.6			6.72			0.42			7.3			1		
01/16/23 15:42	275255.1			0.6			6.99			0.41			7.46			1		
01/16/23 15:43	270865.2			0.6			8.11			0.35			8.52			1		
01/16/23 15:44	269786.9			0.5			5.62			0.29			5.88			1		
01/16/23 15:45	268708.7			0.5			3.13			0.29			3.26			1		
01/16/23 15:46	269941			0.5			3.23			0.29			3.38			1		
01/16/23 15:47	268554.7			0.5			4.15			0.29			4.32			1		
01/16/23 15:48	268862.8			0.5			4.98			0.29			5.19			1		
01/16/23 15:49	268246.6			0.5			4.7			0.29			4.89			1		
01/16/23 15:50	269170.8			0.4			3.13			0.23			3.27			1		
01/16/23 15:51	268785.8			0.4			2.21			0.23			2.31			1		
01/16/23 15:52	268785.8			0.5			2.03			0.29			2.11			1		
01/16/23 15:53	269093.8			0.5			1.75			0.29			1.83			1		
01/16/23 15:54	268785.8			0.4			1.48			0.23			1.54			1		
01/16/23 15:55	269093.8			0.5			1.2			0.29			1.25			1		
01/16/23 15:56	268323.7			0.5			1.01			0.29			1.05			0		
01/16/23 15:57	268939.8			0.5			0.92			0.29			0.96			0		
01/16/23 15:58	268015.6			0.5			0.83			0.29			0.86			0		
01/16/23 15:59	268708.7			0.5			0.83			0.29			0.86			0		
01/16/23 16:00	267476.5			0.5			0.83			0.29			0.86			0		

CT1 SUSD EVENT 22

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 22:48	265551.1			0.5			1.69			0.29			1.74			0		
01/16/23 22:49	266244.2			0.4			1.5			0.23			1.55			0		
01/16/23 22:50	267091.4			0.4			1.4			0.24			1.45			0		
01/16/23 22:51	267553.5			0.4			1.4			0.24			1.46			0		
01/16/23 22:52	266937.4			0.4			1.5			0.24			1.55			0		
01/16/23 22:53	259620.8			0.4			1.5			0.23			1.51			1		
01/16/23 22:54	236593.1			0.4			1.78			0.21			1.63			1		
01/16/23 22:55	215105.6			0.4			6.3			0.2			5.25			1		
01/16/23 22:56	191615.7			0.8			10.38			0.35			7.71			1		
01/16/23 22:57	168819			10			14.38			3.96			9.41			1		
01/16/23 22:58	150335.2			597.9			16.86			211.72			9.82			1		
01/16/23 22:59	100659.9			1647.7			19.14			390.59			7.47			1		
01/16/23 23:00	0			0			21.36			0			0			0		
01/16/23 23:01	0			0			29.5			0			0			0		
01/16/23 23:02	0			0			2.95			0			0			0		
01/16/23 23:03	0			0			2.95			0			0			0		
01/16/23 23:04	0			0			2.95			0			0			0		

CT1 SUSD EVENT 23

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 16:55	13400.8			0			0			-0.19			0			0		
01/17/23 16:56	14170.9			0			0			-0.2			0			0		
01/17/23 16:57	14016.9			0			0			-0.19			0			0		
01/17/23 16:58	13862.9			0			0			0			0			0		
01/17/23 16:59	13708.8			0			0			0			0			0		
01/17/23 17:00	19100			0			0			0			0			1		
01/17/23 17:01	26031.4			0			0			0			0			1		
01/17/23 17:02	36197.5			37.4			11.8			3.19			1.66			1		
01/17/23 17:03	48366			1094.6			11.41			124.72			2.14			1		
01/17/23 17:04	59764.4			907.3			16.06			127.75			3.72			1		
01/17/23 17:05	75398.6			515			21.35			91.42			6.24			1		
01/17/23 17:06	115678			377.3			25.21			102.79			11.3			1		
01/17/23 17:07	142941.6			256.3			40.12			86.29			22.23			1		
01/17/23 17:08	145945.3			260.2			54.43			89.4			30.78			1		
01/17/23 17:09	162811.8			1883.4			48.68			722.18			30.72			1		
01/17/23 17:10	180833.5			1783.7			50.4			759.4			35.32			1		
01/17/23 17:11	203938.3			1290.8			49.41			619.76			39.05			1		
01/17/23 17:12	226966.1			181.2			50.95			96.84			44.83			1		
01/17/23 17:13	245449.9			15.7			46.96			9.07			44.67			1		
01/17/23 17:14	273098.6			2.3			44.2			1.45			46.78			1		
01/17/23 17:15	296588.5			1.7			27.08			1.22			31.13			1		
01/17/23 17:16	316458.6			1.7			15.32			1.25			18.79			1		
01/17/23 17:17	322542.9			1.7			11.04			1.28			13.8			1		
01/17/23 17:18	321926.8			1.8			9.69			1.34			12.09			1		
01/17/23 17:19	319077.2			1.7			8.34			1.27			10.32			1		
01/17/23 17:20	320386.4			1.5			7.7			1.16			9.56			1		
01/17/23 17:21	321541.7			1.4			6.93			1.04			8.63			1		
01/17/23 17:22	321079.6			1.2			6.84			0.91			8.51			1		
01/17/23 17:23	319308.2			1.1			6.58			0.84			8.15			1		
01/17/23 17:24	318538.1			1			6.51			0.78			8.03			1		
01/17/23 17:25	318384			1			6.33			0.78			7.81			1		
01/17/23 17:26	314995.3			1			6.07			0.71			7.41			1		
01/17/23 17:27	314841.3			0.9			5.9			0.64			7.2			1		
01/17/23 17:28	315534.4			0.9			5.81			0.64			7.11			1		
01/17/23 17:29	312530.8			0.9			5.73			0.64			6.94			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 17:30	313840.1			0.9			5.72			0.65			6.96			1		
01/17/23 17:31	316304.6			0.8			5.64			0.59			6.91			1		
01/17/23 17:32	315457.4			0.8			5.64			0.59			6.89			1		
01/17/23 17:33	313917.1			0.8			5.72			0.59			6.96			1		
01/17/23 17:34	316535.7			0.8			5.72			0.59			7.02			1		
01/17/23 17:35	317613.9			0.7			5.81			0.53			7.15			1		
01/17/23 17:36	317228.8			1.2	X		5.9	X		0.86	X		7.25	X		1		
01/17/23 17:37	317151.8			0.8	X		6.61	X		0.61	X		8.13	X		1		
01/17/23 17:38	317074.8			0.8	X		6.25	X		0.59	X		7.68	X		1		
01/17/23 17:39	318153			0.7	X		6.34	X		0.53	X		7.82	X		1		
01/17/23 17:40	319154.2			0.7	X		6.34	X		0.53	X		7.84	X		1		
01/17/23 17:41	304136.1			0.7	X		6.43	X		0.5	X		7.58	X		1		
01/17/23 17:42	300670.3			0.7	X		6.25	X		0.5	X		7.29	X		1		
01/17/23 17:43	294971.2			0.7	X		5.1	X		0.5	X		5.82	X		1		
01/17/23 17:44	289811.1			0.6			3.67			0.43			4.12			1		
01/17/23 17:45	282263.5			0.5			2.9			0.36			3.18			1		
01/17/23 17:46	280954.3			0.5			3.54			0.36			3.86			1		
01/17/23 17:47	279259.9			0.6			4.43			0.36			4.79			1		
01/17/23 17:48	274716			0.5			3.78			0.3			4.02			1		
01/17/23 17:49	273098.6			0.5			2.86			0.3			3.02			1		
01/17/23 17:50	273021.6			0.5			2.67			0.3			2.83			1		
01/17/23 17:51	273483.7			0.5			2.49			0.3			2.64			1		
01/17/23 17:52	273098.6			0.5			2.4			0.3			2.54			1		
01/17/23 17:53	280415.2			0.5			2.4			0.3			2.6			1		
01/17/23 17:54	289503			0.5			2.49			0.31			2.79			1		
01/17/23 17:55	289195			0.5			2.36			0.31			2.64			1		
01/17/23 17:56	286345.4			0.5			2.18			0.37			2.42			1		
01/17/23 17:57	286191.3			0.5			1.91			0.37			2.11			1		
01/17/23 17:58	286037.3			0.5			1.91			0.37			2.11			1		
01/17/23 17:59	286268.4			0.5			1.91			0.31			2.12			1		
01/17/23 18:00	285652.3			0.5			2			0.31			2.21			1		
01/17/23 18:01	285883.3			0.5			2			0.31			2.21			1		
01/17/23 18:02	285729.3			0.5			2			0.31			2.21			1		
01/17/23 18:03	286268.4			0.5			1.91			0.31			2.12			1		
01/17/23 18:04	286114.3			0.5			1.91			0.31			2.11			1		
01/17/23 18:05	286884.5			0.5			1.82			0.31			2.02			1		
01/17/23 18:06	285806.3			0.5			1.72			0.31			1.91			1		
01/17/23 18:07	286037.3			0.5			1.63			0.31			1.81			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/17/23 18:08	286191.3			0.5			1.54			0.31			1.71			0		
01/17/23 18:09	286345.4			0.5			1.54			0.31			1.71			0		
01/17/23 18:10	284034.9			0.5			1.54			0.3			1.7			0		
01/17/23 18:11	283264.8			0.5			1.54			0.3			1.69			0		

CT1 SUSD EVENT 24

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 9:01	267861.6			0.5			1.71			0.3			1.78			0		
01/18/23 9:02	268015.6			0.4			1.71			0.24			1.78			0		
01/18/23 9:03	267476.5			0.4			1.62			0.24			1.68			0		
01/18/23 9:04	267861.6			0.4			1.52			0.24			1.58			0		
01/18/23 9:05	268092.6			0.4			1.43			0.24			1.48			0		
01/18/23 9:06	268400.7			0.4			1.43			0.24			1.49			1		
01/18/23 9:07	258465.6			0.4			1.43			0.23			1.43			1		
01/18/23 9:08	237440.3			0.4			1.93			0.22			1.78			1		
01/18/23 9:09	213873.4			0.3			5.9			0.16			4.89			1		
01/18/23 9:10	190614.5			2.4			8.96			1.07			6.62			1		
01/18/23 9:11	169358.1			94.1			11.17			37.56			7.33			1		
01/18/23 9:12	150412.2			757.1			13.53			268.1			7.88			1		
01/18/23 9:13	109285.7			1650.4			15.15			424.85			6.42			1		
01/18/23 9:14	0			0			17.5			0			0			0		
01/18/23 9:15	0			0			8.85			0			0			0		
01/18/23 9:16	0			0			2.95			0			0			0		
01/18/23 9:17	0			0			5.9			0			0			0		
01/18/23 9:18	0			0			5.9			0			0			0		

CT1 SUSD EVENT 25

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 16:05	9627			0			0			0			0			0		
01/23/23 16:06	5314.1			0			0			0			0			0		
01/23/23 16:07	7547.6			0			0			0			0			0		
01/23/23 16:08	6700.4			0			0			0			0			0		
01/23/23 16:09	17097.5			0			0			0			0			0		
01/23/23 16:10	26493.5			0			0			0			0			1		
01/23/23 16:11	36120.5			0			0			0			0			1		
01/23/23 16:12	42666.8			88.5			5.9			8.89			0.98			1		
01/23/23 16:13	51908.8			1044.3			9.83			127.63			1.98			1		
01/23/23 16:14	61843.8			917.3			13.54			133.67			3.25			1		
01/23/23 16:15	77786.1			512.7			18.29			93.88			5.51			1		
01/23/23 16:16	115832			344.1			23.33			93.89			10.48			1		
01/23/23 16:17	143326.7			231.8			35.89			78.25			19.94			1		
01/23/23 16:18	151721.5			171.5			51.72			61.27			30.41			1		
01/23/23 16:19	168279.9			1733.7			40.75			686.9			26.57			1		
01/23/23 16:20	188304			1770			46.02			784.89			33.59			1		
01/23/23 16:21	211716.9			736.6			56.2			367.21			46.11			1		
01/23/23 16:22	234051.5			72			56.95			39.65			51.65			1		
01/23/23 16:23	256463.2			5.7			57.61			3.42			57.26			1		
01/23/23 16:24	281570.4			2.1			57.84			1.4			63.12			1		
01/23/23 16:25	295510.3			1.9			33.4			1.32			38.26			1		
01/23/23 16:26	295818.3			1.9			24.04			1.35			27.56			1		
01/23/23 16:27	295202.2			2.1			18.31			1.45			20.95			1		
01/23/23 16:28	299669.2			2			14.4			1.41			16.73			1		
01/23/23 16:29	316843.7			1.8			12.15			1.38			14.92			1		
01/23/23 16:30	322619.9			1.7			9.86			1.27			12.33			1		
01/23/23 16:31	322773.9			1.6			8.42			1.19			10.53			1		
01/23/23 16:32	322465.9			1.6			7.38			1.19			9.22			1		
01/23/23 16:33	320771.5			1.4			6.85			1.05			8.52			1		
01/23/23 16:34	319385.3			1.3			6.07			0.98			7.52			1		
01/23/23 16:35	318769.1			1.1			5.81			0.85			7.18			1		
01/23/23 16:36	317844.9			1.1			5.46			0.79			6.73			1		
01/23/23 16:37	316997.8			1			5.2			0.72			6.38			1		
01/23/23 16:38	317382.8			0.9			5.2			0.66			6.39			1		
01/23/23 16:39	317536.8			0.8			5.11			0.59			6.29			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 16:40	317921.9			0.9			5.11			0.66			6.29			1		
01/23/23 16:41	318692.1			0.8			5.11			0.59			6.31			1		
01/23/23 16:42	318461			0.8			5.11			0.59			6.3			1		
01/23/23 16:43	317767.9			0.8			5.11			0.59			6.29			1		
01/23/23 16:44	314995.3			0.8			5.11			0.59			6.24			1		
01/23/23 16:45	314533.2			0.8			5.2			0.59			6.33			1		
01/23/23 16:46	315611.5			0.8			5.11			0.59			6.25			1		
01/23/23 16:47	316843.7			0.7			5.11			0.53			6.27			1		
01/23/23 16:48	318307			0.7			5.27			0.54			6.51			1		
01/23/23 16:49	318230			0.7			5.28			0.53			6.52			1		
01/23/23 16:50	317844.9			0.7			5.46			0.53			6.73			1		
01/23/23 16:51	318153			0.7			5.64			0.53			6.95			1		
01/23/23 16:52	316997.8			0.7			5.81			0.53			7.14			1		
01/23/23 16:53	317536.8			0.7			5.9			0.53			7.26			1		
01/23/23 16:54	319077.2			0.7			6.08			0.53			7.51			1		
01/23/23 16:55	321618.7			0.7			6.08			0.53			7.57			1		
01/23/23 16:56	308294.9			0.7			6.43			0.51			7.68			1		
01/23/23 16:57	302364.7			0.6			5.55			0.44			6.5			1		
01/23/23 16:58	306292.5			0.6			2.95			0.45			3.5			1		
01/23/23 16:59	327163.8			0.6			2.45			0.49			3.11			1		
01/23/23 17:00	342952.1			0.6			3.31			0.51			4.4			1		
01/23/23 17:01	336713.8			0.6			3.04			0.5			3.97			1		
01/23/23 17:02	330167.5			0.6			3.17			0.48			4.06			1		
01/23/23 17:03	328319.1			0.6			3.87			0.48			4.93			1		
01/23/23 17:04	327009.8			0.7			3.96			0.54			5.02			1		
01/23/23 17:05	326008.6			0.7			2.73			0.54			3.45			1		
01/23/23 17:06	326162.7			0.7			2.29			0.54			2.89			1		
01/23/23 17:07	325854.6			0.7			2.11			0.54			2.67			1		
01/23/23 17:08	325700.5			0.6			2.03			0.47			2.56			1		
01/23/23 17:09	325546.5			0.6			2.2			0.47			2.78			1		
01/23/23 17:10	325777.6			0.6			2.38			0.47			3			1		
01/23/23 17:11	325623.5			0.6			2.64			0.47			3.33			1		
01/23/23 17:12	325469.5			0.6			2.73			0.47			3.44			1		
01/23/23 17:13	325700.5			0.7			2.55			0.54			3.22			1		
01/23/23 17:14	326316.7			0.7			2.03			0.54			2.56			1		
01/23/23 17:15	324699.3			0.6			1.76			0.47			2.22			1		
01/23/23 17:16	324083.2			0.6			1.67			0.47			2.1			1		
01/23/23 17:17	324006.2			0.6			1.67			0.47			2.1			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 17:18	333633.2			0.6			1.67			0.48			2.16			0		
01/23/23 17:19	352579.1			0.6			1.67			0.51			2.29			0		
01/23/23 17:20	368906.5			0.6			1.43			0.54			2.04			0		
01/23/23 17:21	393089.5			0.5			1			0.5			1.52			0		
01/23/23 17:22	409879			0.6			1.11			0.53			1.76			0		

CT1 SUSD EVENT 26

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 10:04	269786.9			0.4			1.43			0.24			1.49			0		
01/24/23 10:05	269941			0.4			1.43			0.24			1.49			0		
01/24/23 10:06	270634.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:07	270326.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:08	270326.1			0.4			1.43			0.24			1.5			0		
01/24/23 10:09	268246.6			0.4			1.43			0.24			1.48			1		
01/24/23 10:10	250224.9			0.4			1.43			0.22			1.38			1		
01/24/23 10:11	229199.5			0.4			3.25			0.21			2.88			1		
01/24/23 10:12	206248.8			0.3			6.76			0.16			5.4			1		
01/24/23 10:13	182219.8			3.7			8.85			1.57			6.25			1		
01/24/23 10:14	163350.9			224.6			10.62			86.37			6.72			1		
01/24/23 10:15	145483.2			1190.9			12.25			407.86			6.91			1		
01/24/23 10:16	50060.4			1733.1			13.49			204.45			2.62			1		
01/24/23 10:17	20871.3			0			16.86			144.26			1.37			0		
01/24/23 10:18	21102.4			0			5.9			52.04			0.48			0		
01/24/23 10:19	21179.4			0			5.9			9.72			0.48			0		
01/24/23 10:20	21487.5			0			5.9			7.46			0.49			0		
01/24/23 10:21	21718.5			0			5.9			7.53			0.5			0		

CT1 SUSD EVENT 27

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 16:17	12784.7			0			0			0.35			0			0		
01/27/23 16:18	12630.6			0			0			0.35			0			0		
01/27/23 16:19	12168.5			0			0			0.34			0			0		
01/27/23 16:20	16558.4			0			0			0.46			0			0		
01/27/23 16:21	23643.9			0			0			0.66			0			0		
01/27/23 16:22	37275.7			11.8			0			1.04			0			1		
01/27/23 16:23	42897.9			76.7			0			7.74			0			1		
01/27/23 16:24	50060.4			1048.9			12.46			123.73			2.42			1		
01/27/23 16:25	60765.6			1000.6			12.49			143.12			2.94			1		
01/27/23 16:26	72626.1			586.5			17.11			100.3			4.82			1		
01/27/23 16:27	102893.3			374.7			20.92			90.74			8.34			1		
01/27/23 16:28	141016.3			254.4			23.6			84.52			12.9			1		
01/27/23 16:29	149179.9			167			44.56			58.66			25.75			1		
01/27/23 16:30	163967			1325.7			38.62			511.9			24.54			1		
01/27/23 16:31	182912.9			1773.2			40.46			763.68			28.68			1		
01/27/23 16:32	203707.3			1315.7			51.74			631.14			40.85			1		
01/27/23 16:33	226658			164.4			61.15			87.73			53.7			1		
01/27/23 16:34	247375.3			11.8			60.65			6.87			58.14			1		
01/27/23 16:35	275024			2.1			56.64			1.39			60.37			1		
01/27/23 16:36	300824.4			1.8			33.66			1.3			39.25			1		
01/27/23 16:37	314456.2			1.8			18.4			1.3			22.43			1		
01/27/23 16:38	316843.7			1.8			12.66			1.34			15.54			1		
01/27/23 16:39	316843.7			1.9			10.52			1.4			12.91			1		
01/27/23 16:40	319539.3			1.7			8.81			1.29			10.91			1		
01/27/23 16:41	320694.5			1.6			7.18			1.23			8.93			1		
01/27/23 16:42	320771.5			1.5			6.33			1.1			7.87			1		
01/27/23 16:43	319693.3			1.4			5.56			1.03			6.89			1		
01/27/23 16:44	317921.9			1.3			4.95			0.97			6.09			1		
01/27/23 16:45	317690.9			1.2			4.69			0.91			5.77			1		
01/27/23 16:46	316612.7			1.1			4.16			0.84			5.11			1		
01/27/23 16:47	316689.7			1			4.08			0.78			5.01			1		
01/27/23 16:48	323929.2			1			3.99			0.73			5.01			1		
01/27/23 16:49	342952.1			1			3.9			0.77			5.19			1		
01/27/23 16:50	354196.5			0.9			3.17			0.73			4.35			1		
01/27/23 16:51	377840.4			0.9			2.59			0.8			3.8			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 16:52	396709.3			0.8			2.54			0.76			3.91			1		
01/27/23 16:53	420738.3			0.7			2.27			0.72			3.7			1		
01/27/23 16:54	443458			0.7			2.21			0.77			3.8			1		
01/27/23 16:55	450466.4			0.7			2.67			0.78			4.67			1		
01/27/23 16:56	446769.7			0.7			3.18			0.76			5.5			1		
01/27/23 16:57	447154.8			0.7			3.18			0.76			5.51			1		
01/27/23 16:58	445460.4			0.8			3.18			0.86			5.48			1		
01/27/23 16:59	430827.3			0.7			3.18			0.74			5.3			1		
01/27/23 17:00	410726.2			0.7			3.27			0.7			5.2			1		
01/27/23 17:01	392627.4			0.8			3.75			0.74			5.71			1		
01/27/23 17:02	384694.8			0.8			3.79			0.72			5.65			1		
01/27/23 17:03	390162.9			0.9			3.7			0.81			5.59			1		
01/27/23 17:04	399173.8			0.8			3.49			0.76			5.39			1		
01/27/23 17:05	404025.8			0.7			3.36			0.69			5.26			1		
01/27/23 17:06	400406			0.7			3.22			0.67			4.99			1		
01/27/23 17:07	401022.2			0.7			3.4			0.68			5.28			1		
01/27/23 17:08	396093.2			0.7			3.4			0.67			5.21			1		
01/27/23 17:09	398095.6			0.7			2.5			0.67			3.86			1		
01/27/23 17:10	396940.3			0.7			2.15			0.67			3.3			1		
01/27/23 17:11	399866.9			0.7			2.06			0.67			3.19			1		
01/27/23 17:12	399327.8			0.8			2.15			0.76			3.32			1		
01/27/23 17:13	402408.5			0.7			2.41			0.68			3.76			1		
01/27/23 17:14	419120.9			0.7			2.59			0.71			4.21			1		
01/27/23 17:15	441609.6			0.7			2.27			0.76			3.88			1		
01/27/23 17:16	455241.4			0.6			2.03			0.69			3.58			1		
01/27/23 17:17	450312.4			0.7			2.63			0.77			4.59			1		
01/27/23 17:18	450697.5			0.7			2.18			0.77			3.8			1		
01/27/23 17:19	452622.9			0.7			1.45			0.78			2.56			1		
01/27/23 17:20	452083.8			0.7			1.45			0.8			2.62			1		
01/27/23 17:21	451852.7			1.3			1.41			1.46			2.57			1		
01/27/23 17:22	452314.8			2			2.08			2.21			3.8			0		
01/27/23 17:23	451852.7			2.2			2.17			2.41			3.96			0		
01/27/23 17:24	451775.7			1.8			2.17			2.03			3.97			0		
01/27/23 17:25	452853.9			1.5			1.97			1.72			3.61			0		
01/27/23 17:26	451544.7			1.5			1.71			1.62			3.14			0		

CT1 SUSD EVENT 28

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 0:03	286884.5			0.8			1.43			0.54			1.59			0		
02/04/23 0:04	270788.2			0.8			1.52			0.51			1.59			0		
02/04/23 0:05	269247.8			0.8			1.94			0.52			2.01			0		
02/04/23 0:06	268400.7			0.7			2.25			0.47			2.33			0		
02/04/23 0:07	268323.7			0.7			1.97			0.41			2.04			0		
02/04/23 0:08	267630.5			0.7			1.4			0.41			1.45			1		
02/04/23 0:09	249377.7			0.7			1.31			0.38			1.26			1		
02/04/23 0:10	228583.4			0.7			2.61			0.36			2.31			1		
02/04/23 0:11	204477.4			0.6			7.38			0.3			5.83			1		
02/04/23 0:12	181141.6			3.1			10.53			1.33			7.37			1		
02/04/23 0:13	162426.7			221.8			13.9			84.62			8.72			1		
02/04/23 0:14	144559			1118.2			15.93			379.46			8.9			1		
02/04/23 0:15	47133.8			1758.4			18.54			194.44			3.37			1		
02/04/23 0:16	15172.1			0			23.97			100.55			1.4			0		
02/04/23 0:17	15403.2			0			5.9			41.4			0.35			0		
02/04/23 0:18	15942.3			0			5.9			3.97			0.36			0		
02/04/23 0:19	16635.4			0			5.9			6.47			0.38			0		
02/04/23 0:20	16789.5			0			5.9			6.51			0.38			0		

CT1 SUSD EVENT 29

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 16:03	20486.2			0			0			0.28			0			0		
02/04/23 16:04	20178.2			0			0			0.28			0			0		
02/04/23 16:05	20178.2			0			0			0.28			0			0		
02/04/23 16:06	19870.1			0			0			0.27			0			0		
02/04/23 16:07	19947.1			0			0			0.28			0			0		
02/04/23 16:08	22565.7			5.9			0			0.31			0			1		
02/04/23 16:09	30652.4			5.9			0			0.43			0			1		
02/04/23 16:10	38662			31.5			13.77			2.86			2.06			1		
02/04/23 16:11	50984.6			1149.7			13.06			137.68			2.57			1		
02/04/23 16:12	61843.8			908.6			17.04			132			4.08			1		
02/04/23 16:13	76630.9			511.1			22.48			91.98			6.66			1		
02/04/23 16:14	115909			374.4			25.48			101.91			11.41			1		
02/04/23 16:15	142864.6			246.4			39.41			82.67			21.76			1		
02/04/23 16:16	149796.1			187.7			53.1			65.99			30.73			1		
02/04/23 16:17	162811.8			1808.1			47.56			691.28			29.92			1		
02/04/23 16:18	180371.4			1785.2			48.72			756.05			33.96			1		
02/04/23 16:19	202475			1300.5			48.09			618.33			37.63			1		
02/04/23 16:20	225810.8			191.6			48.68			101.61			42.48			1		
02/04/23 16:21	245141.8			18.5			45.9			10.67			43.49			1		
02/04/23 16:22	272174.4			2.5			42.69			1.58			44.91			1		
02/04/23 16:23	294124			1.9			29.11			1.29			33.08			1		
02/04/23 16:24	312222.8			1.8			13.91			1.29			16.79			1		
02/04/23 16:25	310913.5			1.8			9.86			1.29			11.85			1		
02/04/23 16:26	309065.1			1.8			8.21			1.3			9.8			1		
02/04/23 16:27	307601.8			1.7			7.27			1.24			8.64			1		
02/04/23 16:28	308757			1.6			6.51			1.13			7.76			1		
02/04/23 16:29	309681.2			1.4			6.07			1.01			7.27			1		
02/04/23 16:30	310143.3			1.2			5.99			0.88			7.17			1		
02/04/23 16:31	310528.4			1.1			5.81			0.82			6.98			1		
02/04/23 16:32	308294.9			1.1			5.55			0.82			6.62			1		
02/04/23 16:33	306292.5			1			5.29			0.75			6.26			1		
02/04/23 16:34	306369.5			1.1			5.2			0.76			6.15			1		
02/04/23 16:35	304983.3			1			5.02			0.69			5.92			1		
02/04/23 16:36	304829.2			1			4.93			0.69			5.81			1		
02/04/23 16:37	304675.2			0.9			4.93			0.63			5.81			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 16:38	305137.3			0.8			4.93			0.57			5.82			1		
02/04/23 16:39	304675.2			0.9			4.93			0.63			5.81			1		
02/04/23 16:40	303982			0.8			4.93			0.57			5.79			1		
02/04/23 16:41	304444.1			0.8			4.84			0.57			5.7			1		
02/04/23 16:42	304906.2			0.8			4.84			0.57			5.71			1		
02/04/23 16:43	304752.2			0.8			4.84			0.57			5.7			1		
02/04/23 16:44	303982			0.8			4.93			0.57			5.79			1		
02/04/23 16:45	305368.3			0.8			5.02			0.57			5.92			1		
02/04/23 16:46	305753.4			0.8			5.11			0.57			6.03			1		
02/04/23 16:47	304367.1			0.7			5.2			0.5			6.11			1		
02/04/23 16:48	306600.6			0.7			5.28			0.51			6.26			1		
02/04/23 16:49	306908.7			0.7			5.37			0.51			6.37			1		
02/04/23 16:50	305599.4			0.7			5.46			0.51			6.45			1		
02/04/23 16:51	305291.3			0.7			5.2			0.5			6.13			1		
02/04/23 16:52	289195			0.7			3.26			0.48			3.64			1		
02/04/23 16:53	282186.5			0.7			2.15			0.47			2.34			1		
02/04/23 16:54	281185.3			0.6			2.81			0.42			3.06			1		
02/04/23 16:55	275717.2			0.6			3.45			0.41			3.67			1		
02/04/23 16:56	270788.2			0.5			4.18			0.35			4.37			1		
02/04/23 16:57	270480.1			0.6			3.87			0.35			4.05			1		
02/04/23 16:58	270634.1			0.6			2.67			0.35			2.8			1		
02/04/23 16:59	270403.1			0.6			1.94			0.35			2.02			1		
02/04/23 17:00	271481.3			0.5			1.84			0.29			1.93			1		
02/04/23 17:01	271866.4			0.5			1.84			0.29			1.94			1		
02/04/23 17:02	271327.3			0.5			1.94			0.29			2.03			1		
02/04/23 17:03	271943.4			0.5			2.03			0.29			2.13			0		
02/04/23 17:04	271250.3			0.6			2.12			0.35			2.22			0		
02/04/23 17:05	270865.2			0.6			2.12			0.35			2.22			0		
02/04/23 17:06	270403.1			0.6			2.12			0.35			2.22			0		
02/04/23 17:07	270018			0.6			2.03			0.35			2.12			0		

CT1 SUSD EVENT 30

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 23:01	296049.4			0.5			1.52			0.37			1.74			0		
02/04/23 23:02	296357.5			0.5			1.52			0.37			1.74			0		
02/04/23 23:03	287038.5			0.5			1.43			0.36			1.59			0		
02/04/23 23:04	271558.3			0.5			1.43			0.34			1.5			0		
02/04/23 23:05	268708.7			0.6			1.84			0.35			1.91			0		
02/04/23 23:06	264241.8			0.5			2.12			0.29			2.17			1		
02/04/23 23:07	243293.5			0.4			1.97			0.21			1.85			1		
02/04/23 23:08	222576.2			0.3			4.52			0.15			3.89			1		
02/04/23 23:09	197623			0.3			9.98			0.15			7.62			1		
02/04/23 23:10	175673.4			5.2			14.99			2.14			10.17			1		
02/04/23 23:11	156727.5			346.8			18.1			127.61			10.96			1		
02/04/23 23:12	138628.8			1352.3			20.27			440.14			10.86			1		
02/04/23 23:13	25492.3			1836.1			22.91			109.74			2.25			1		
02/04/23 23:14	24953.2			0			23.6			269.61			2.28			0		
02/04/23 23:15	24568.1			0			2.95			26.24			0.28			0		
02/04/23 23:16	24491.1			0			2.95			5.26			0.28			0		
02/04/23 23:17	24645.1			0			5.9			9.58			0.56			0		
02/04/23 23:18	24722.1			0			5.9			8.89			0.56			0		

CT1 SUSD EVENT 31

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 17:52	17636.7			0			0			0			0			0		
02/05/23 17:53	17559.6			0			0			0			0			0		
02/05/23 17:54	17251.6			0			0			0			0			0		
02/05/23 17:55	17251.6			0			0			0			0			0		
02/05/23 17:56	17482.6			0			0			0			0			0		
02/05/23 17:57	22257.6			0			0			0			0			1		
02/05/23 17:58	30575.3			0			0			0			0			1		
02/05/23 17:59	38431			27.5			17.7			2.48			2.63			1		
02/05/23 18:00	53218			1137.9			12.98			142.13			2.67			1		
02/05/23 18:01	60919.6			848.9			18.36			121.43			4.32			1		
02/05/23 18:02	81559.9			478.7			23.6			91.73			7.44			1		
02/05/23 18:03	120530			358			25.75			101.3			11.99			1		
02/05/23 18:04	143326.7			244.5			42.48			82.31			23.54			1		
02/05/23 18:05	147562.6			336.5			55.76			116.6			31.8			1		
02/05/23 18:06	160347.3			1908.5			50.7			718.56			31.42			1		
02/05/23 18:07	177829.9			1807			53.1			754.36			36.48			1		
02/05/23 18:08	199856.5			1492.7			52.95			700.68			40.9			1		
02/05/23 18:09	222422.1			257.1			53.92			134.28			46.35			1		
02/05/23 18:10	242061.2			28.2			50.57			16.01			47.3			1		
02/05/23 18:11	266013.2			3			49.49			1.84			50.87			1		
02/05/23 18:12	291813.5			1.9			37.6			1.3			42.4			1		
02/05/23 18:13	308294.9			1.7			16.88			1.25			20.11			1		
02/05/23 18:14	311144.5			1.7			12.74			1.25			15.32			1		
02/05/23 18:15	311144.5			1.8			10			1.31			12.03			1		
02/05/23 18:16	311067.5			1.7			8.89			1.25			10.69			1		
02/05/23 18:17	310913.5			1.6			8.07			1.14			9.69			1		
02/05/23 18:18	309989.3			1.4			7.64			1.01			9.15			1		
02/05/23 18:19	308140.9			1.2			6.94			0.88			8.26			1		
02/05/23 18:20	307601.8			1.1			6.77			0.81			8.05			1		
02/05/23 18:21	306908.7			1.1			6.69			0.76			7.94			1		
02/05/23 18:22	306831.6			1.5	X		6.3	X		1.06	X		7.47	X		1		
02/05/23 18:23	306061.5			0.9	X		6.51	X		0.66	X		7.7	X		1		
02/05/23 18:24	305753.4			0.9	X		5.99	X		0.63	X		7.07	X		1		
02/05/23 18:25	305368.3			0.8	X		5.99	X		0.57	X		7.07	X		1		
02/05/23 18:26	303828			0.8	X		5.99	X		0.57	X		7.03	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 18:27	303211.9			0.8	X		5.9	X		0.56	X		6.91	X		1		
02/05/23 18:28	302980.8			0.8	X		5.99	X		0.57	X		7.01	X		1		
02/05/23 18:29	304136.1			0.7	X		5.9	X		0.51	X		6.93	X		1		
02/05/23 18:30	305137.3			0.7			5.9			0.51			6.96			1		
02/05/23 18:31	304444.1			0.7			5.9			0.51			6.94			1		
02/05/23 18:32	304290.1			0.7			5.9			0.51			6.94			1		
02/05/23 18:33	303905			0.7			5.99			0.51			7.03			1		
02/05/23 18:34	304367.1			0.6			6.08			0.45			7.15			1		
02/05/23 18:35	304444.1			0.6			6.17			0.45			7.26			1		
02/05/23 18:36	305753.4			0.6			6.17			0.45			7.29			1		
02/05/23 18:37	306600.6			0.6			6.26			0.45			7.41			1		
02/05/23 18:38	306369.5			0.6			6.35			0.45			7.52			1		
02/05/23 18:39	293970			0.6			6.53			0.43			7.41			1		
02/05/23 18:40	281108.3			0.6			6.62			0.41			7.19			1		
02/05/23 18:41	280492.2			0.5			7.9			0.36			8.56			1		
02/05/23 18:42	275563.2			0.6			8.48			0.36			9.03			1		
02/05/23 18:43	276102.3			0.5			8.67			0.3			9.25			1		
02/05/23 18:44	280107.1			0.5			9.86			0.3			10.68			1		
02/05/23 18:45	273252.7			0.5			5.35			0.3			5.65			1		
02/05/23 18:46	272790.6			0.5			2.86			0.3			3.01			1		
02/05/23 18:47	273175.7			0.5			3.13			0.3			3.31			1		
02/05/23 18:48	271635.3			0.5			3.96			0.29			4.16			1		
02/05/23 18:49	272482.5			0.5			4.98			0.29			5.24			1		
02/05/23 18:50	274484.9			0.5			4.61			0.3			4.89			1		
02/05/23 18:51	274330.9			0.5			3.13			0.3			3.32			1		
02/05/23 18:52	275178.1			0.5			2.3			0.3			2.45			1		
02/05/23 18:53	282879.7			0.5			2.03			0.31			2.22			1		
02/05/23 18:54	304213.1			0.5			1.38			0.33			1.63			1		
02/05/23 18:55	320463.5			0.5			1.18			0.34			1.46			1		
02/05/23 18:56	324853.4			0.5			0.97			0.4			1.22			1		
02/05/23 18:57	320848.5			0.7			0.87			0.52			1.08			0		
02/05/23 18:58	319462.3			0.7			0.78			0.52			0.96			0		
02/05/23 18:59	317690.9			0.7			0.79			0.53			0.97			0		
02/05/23 19:00	317690.9			0.7			0.7			0.53			0.87			0		
02/05/23 19:01	318076			0.7			0.7			0.53			0.87			0		

CT1 SUSD EVENT 32

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/05/23 22:17	267707.5			0.4			1.69			0.24			1.74			0		
02/05/23 22:18	267014.4			0.4			1.59			0.23			1.64			0		
02/05/23 22:19	266475.3			0.4			1.62			0.24			1.67			0		
02/05/23 22:20	267784.5			0.5			1.62			0.3			1.67			0		
02/05/23 22:21	267553.5			0.5			1.52			0.3			1.57			0		
02/05/23 22:22	266629.3			0.4			1.5			0.23			1.54			1		
02/05/23 22:23	258080.5			0.4			1.5			0.23			1.49			1		
02/05/23 22:24	236208			0.4			1.81			0.21			1.65			1		
02/05/23 22:25	213950.4			0.4			5.59			0.2			4.63			1		
02/05/23 22:26	188381.1			1.6			8.68			0.69			6.32			1		
02/05/23 22:27	168202.9			72			10.82			28.44			7.03			1		
02/05/23 22:28	150489.2			636.2			12.78			224.87			7.44			1		
02/05/23 22:29	90339.7			1620.3			14.51			343.83			5.07			1		
02/05/23 22:30	0			0			16.18			0			0			0		
02/05/23 22:31	0			0			11.8			0			0			0		
02/05/23 22:32	0			0			2.95			0			0			0		
02/05/23 22:33	0			0			5.9			0			0			0		
02/05/23 22:34	0			0			5.9			0			0			0		

CT1 SUSD EVENT 33

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 15:49	21564.5			0			0			0			0			0		
02/06/23 15:50	21333.4			0			0			0			0			0		
02/06/23 15:51	21487.5			0			0			0			0			0		
02/06/23 15:52	21641.5			0			0			0			0			0		
02/06/23 15:53	21718.5			0			0			0			0			0		
02/06/23 15:54	26647.5			0			0			0			0			1		
02/06/23 15:55	31422.5			0			0			0			0			1		
02/06/23 15:56	40125.3			31.5			19.67			2.97			3.05			1		
02/06/23 15:57	51523.7			1034.1			12.98			125			2.58			1		
02/06/23 15:58	63307.1			811.6			19.01			120.63			4.65			1		
02/06/23 15:59	79480.5			452.3			23.88			84.45			7.34			1		
02/06/23 16:00	122301.4			323.7			22.8			92.96			10.77			1		
02/06/23 16:01	143865.8			214.1			41.77			72.3			23.22			1		
02/06/23 16:02	149257			184.4			55.76			64.65			32.17			1		
02/06/23 16:03	167586.8			1725.3			48.99			678.94			31.73			1		
02/06/23 16:04	187919			1694.6			51.46			747.66			37.37			1		
02/06/23 16:05	209868.5			842.8			52.07			415.43			42.24			1		
02/06/23 16:06	232511.2			81.6			51.3			44.54			46.1			1		
02/06/23 16:07	254691.8			5.6			48.13			3.32			47.37			1		
02/06/23 16:08	279722			1.9			43.83			1.25			47.37			1		
02/06/23 16:09	303134.9			1.6			21.03			1.15			24.64			1		
02/06/23 16:10	314764.3			1.6			12.93			1.15			15.73			1		
02/06/23 16:11	315611.5			1.6			8.98			1.2			10.95			1		
02/06/23 16:12	316073.6			1.6			7.7			1.21			9.4			1		
02/06/23 16:13	313146.9			1.6			6.94			1.15			8.4			1		
02/06/23 16:14	311221.5			1.4			6.07			1.01			7.31			1		
02/06/23 16:15	311221.5			1.2			5.55			0.89			6.68			1		
02/06/23 16:16	310451.4			1.1			5.2			0.83			6.23			1		
02/06/23 16:17	308063.9			1.1			4.84			0.76			5.77			1		
02/06/23 16:18	307370.8			1			4.76			0.7			5.65			1		
02/06/23 16:19	305984.5			0.9			4.67			0.63			5.52			1		
02/06/23 16:20	305907.4			0.9			4.56			0.64			5.39			1		
02/06/23 16:21	307755.8			0.8			4.38			0.58			5.21			1		
02/06/23 16:22	307986.9			0.8			4.38			0.58			5.21			1		
02/06/23 16:23	307139.7			0.8			4.38			0.58			5.2			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 16:24	306754.6			0.8			4.47			0.58			5.3			1		
02/06/23 16:25	307216.7			0.7			4.47			0.52			5.31			1		
02/06/23 16:26	304444.1			0.7			4.47			0.51			5.26			1		
02/06/23 16:27	303905			0.7			4.47			0.51			5.25			1		
02/06/23 16:28	303905			0.7			4.47			0.51			5.25			1		
02/06/23 16:29	304752.2			0.6			4.47			0.45			5.26			1		
02/06/23 16:30	306600.6			0.6			4.47			0.45			5.3			1		
02/06/23 16:31	306831.6			0.6			4.56			0.45			5.41			1		
02/06/23 16:32	290042.2			0.6			4.74			0.43			5.31			1		
02/06/23 16:33	278489.8			0.6			4.99			0.42			5.37			1		
02/06/23 16:34	276949.4			0.6			6.27			0.36			6.71			1		
02/06/23 16:35	271481.3			0.6			6.64			0.35			6.96			1		
02/06/23 16:36	270788.2			0.5			4.59			0.3			4.8			1		
02/06/23 16:37	270865.2			0.5			2.9			0.3			3.04			1		
02/06/23 16:38	270095			0.5			2.25			0.3			2.35			1		
02/06/23 16:39	268862.8			0.5			2.34			0.3			2.43			1		
02/06/23 16:40	270634.1			0.5			2.62			0.3			2.74			1		
02/06/23 16:41	270249			0.5			3.28			0.3			3.42			1		
02/06/23 16:42	269709.9			0.5			3.37			0.3			3.51			1		
02/06/23 16:43	270634.1			0.5			2.72			0.3			2.84			1		
02/06/23 16:44	271019.2			0.5			2.34			0.3			2.45			1		
02/06/23 16:45	274716			0.4			2.15			0.24			2.29			1		
02/06/23 16:46	271943.4			0.5			1.97			0.3			2.07			1		
02/06/23 16:47	270711.2			0.5			1.87			0.3			1.96			1		
02/06/23 16:48	269941			0.5			1.69			0.3			1.76			1		
02/06/23 16:49	269247.8			0.5			1.59			0.3			1.66			1		
02/06/23 16:50	269941			0.4			1.59			0.24			1.66			0		
02/06/23 16:51	270095			0.4			1.59			0.24			1.66			0		
02/06/23 16:52	269632.9			0.4			1.59			0.24			1.66			0		
02/06/23 16:53	285575.2			0.4			1.5			0.25			1.65			0		
02/06/23 16:54	305214.3			0.4			1.5			0.27			1.77			0		

CT1 SUSD EVENT 34

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 23:19	271327.3			0.4			1.78			0.24			1.87			0		
02/06/23 23:20	271096.2			0.4			1.59			0.24			1.67			0		
02/06/23 23:21	272944.6			0.4			1.5			0.24			1.58			0		
02/06/23 23:22	273714.8			0.4			1.4			0.24			1.49			0		
02/06/23 23:23	272713.6			0.5			1.38			0.3			1.46			0		
02/06/23 23:24	267553.5			0.5			1.38			0.29			1.43			1		
02/06/23 23:25	244756.8			0.5			1.59			0.27			1.51			1		
02/06/23 23:26	223346.3			0.4			4.62			0.21			3.99			1		
02/06/23 23:27	198932.3			0.3			9.65			0.15			7.42			1		
02/06/23 23:28	176366.6			4.8			13.12			1.99			8.94			1		
02/06/23 23:29	157574.7			326.5			15.55			120.82			9.47			1		
02/06/23 23:30	139244.9			1263.7			17.7			413.27			9.53			1		
02/06/23 23:31	10089.1			1792.7			19.96			42.54			0.78			1		
02/06/23 23:32	0			0			19.67			0			0			0		
02/06/23 23:33	0			0			2.95			0			0			0		
02/06/23 23:34	0			0			5.9			0			0			0		
02/06/23 23:35	0			0			5.9			0			0			0		
02/06/23 23:36	0			0			5.9			0			0			0		

CT1 SUSD EVENT 35

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 15:46	20640.3			0			0			0.29			0			0		
02/07/23 15:47	20486.2			0			0			0.28			0			0		
02/07/23 15:48	20486.2			0			0			0.57			0			0		
02/07/23 15:49	20486.2			0			0			0.57			0			0		
02/07/23 15:50	20486.2			0			0			0.57			0			0		
02/07/23 15:51	22411.6			11.8			0			0.62			0			1		
02/07/23 15:52	30113.2			11.8			0			0.83			0			1		
02/07/23 15:53	37737.8			38.4			8.85			3.4			1.29			1		
02/07/23 15:54	46748.7			1094			15.73			119.99			2.84			1		
02/07/23 15:55	62460			939.7			17.04			137.78			4.11			1		
02/07/23 15:56	72703.1			566.1			23.6			96.69			6.63			1		
02/07/23 15:57	107591.3			380			25.21			96.04			10.48			1		
02/07/23 15:58	143711.8			253.9			40.81			85.72			22.67			1		
02/07/23 15:59	146253.3			156.7			55.85			53.82			31.56			1		
02/07/23 16:00	159577.1			1493.3			51.63			559.55			31.84			1		
02/07/23 16:01	178831.1			1793.6			51.36			753.2			35.5			1		
02/07/23 16:02	198470.2			1529.2			52.63			712.67			40.37			1		
02/07/23 16:03	222114.1			273			51.73			142.41			44.4			1		
02/07/23 16:04	245141.8			24.8			49.25			14.28			46.66			1		
02/07/23 16:05	262855.5			2.8			45.56			1.75			46.28			1		
02/07/23 16:06	289965.1			1.9			33.9			1.29			37.99			1		
02/07/23 16:07	308449			1.8			15.02			1.3			17.9			1		
02/07/23 16:08	313686.1			1.8			10.77			1.32			13.06			1		
02/07/23 16:09	316689.7			1.8			8.38			1.34			10.26			1		
02/07/23 16:10	315303.4			1.7			7.35			1.27			8.96			1		
02/07/23 16:11	315688.5			1.6			6.77			1.16			8.26			1		
02/07/23 16:12	314764.3			1.4			6.25			1.03			7.6			1		
02/07/23 16:13	314533.2			1.3			5.81			0.96			7.07			1		
02/07/23 16:14	311298.6			1.1			5.47			0.82			6.58			1		
02/07/23 16:15	304829.2			1.1			5.38			0.81			6.34			1		
02/07/23 16:16	308140.9			1.1			4.76			0.76			5.66			1		
02/07/23 16:17	307601.8			1			4.76			0.7			5.65			1		
02/07/23 16:18	308294.9			1			4.84			0.7			5.77			1		
02/07/23 16:19	304367.1			0.9			4.84			0.63			5.7			1		
02/07/23 16:20	304059.1			0.9			4.84			0.63			5.69			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 16:21	303905			0.9			4.83			0.64			5.67			1		
02/07/23 16:22	303674			0.8			4.83			0.57			5.66			1		
02/07/23 16:23	303674			0.8			4.74			0.57			5.56			1		
02/07/23 16:24	303905			0.8			4.74			0.57			5.56			1		
02/07/23 16:25	303211.9			0.8			4.74			0.57			5.55			1		
02/07/23 16:26	303597			0.7			4.74			0.51			5.56			1		
02/07/23 16:27	303905			0.7			4.83			0.51			5.67			1		
02/07/23 16:28	304136.1			0.7			4.83			0.51			5.67			1		
02/07/23 16:29	288963.9			0.7			5.01			0.49			5.59			1		
02/07/23 16:30	284034.9			0.7			5.36			0.48			5.89			1		
02/07/23 16:31	278643.8			0.7			6.35			0.48			6.84			1		
02/07/23 16:32	274484.9			0.6			6.91			0.42			7.33			1		
02/07/23 16:33	271250.3			0.6			7.65			0.35			8.02			1		
02/07/23 16:34	270942.2			0.6			4.89			0.35			5.12			1		
02/07/23 16:35	271404.3			0.6			3			0.36			3.14			1		
02/07/23 16:36	270480.1			0.6			3.28			0.36			3.43			1		
02/07/23 16:37	269941			0.6			4.21			0.36			4.4			1		
02/07/23 16:38	270788.2			0.6			5.15			0.36			5.39			1		
02/07/23 16:39	270865.2			0.6			4.68			0.36			4.9			1		
02/07/23 16:40	269941			0.6			3.18			0.36			3.32			1		
02/07/23 16:41	270172			0.6			2.25			0.36			2.35			1		
02/07/23 16:42	270634.1			0.6			2.06			0.36			2.15			1		
02/07/23 16:43	271019.2			0.6			1.59			0.36			1.67			1		
02/07/23 16:44	289195			0.6			1.22			0.38			1.36			1		
02/07/23 16:45	307909.8			0.6			1.2			0.4			1.43			1		
02/07/23 16:46	325238.4			0.6			1			0.49			1.26			0		
02/07/23 16:47	326393.7			0.7			0.7			0.54			0.89			0		
02/07/23 16:48	331168.7			0.8			0.62			0.62			0.79			0		
02/07/23 16:49	341796.9			0.8			0.62			0.64			0.81			0		
02/07/23 16:50	360973.9			0.8			0.54			0.68			0.75			0		

CT1 SUSD EVENT 36

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 8:33	271943.4			0.6			1.78			0.36			1.87			0		
02/11/23 8:34	272713.6			0.6			1.69			0.36			1.78			0		
02/11/23 8:35	269555.9			0.6			1.69			0.36			1.76			0		
02/11/23 8:36	270711.2			0.6			1.59			0.36			1.67			0		
02/11/23 8:37	270326.1			0.5			1.59			0.3			1.66			0		
02/11/23 8:38	267322.4			0.5			1.59			0.29			1.64			1		
02/11/23 8:39	248222.5			0.5			1.59			0.27			1.53			1		
02/11/23 8:40	227582.2			0.5			3.84			0.26			3.37			1		
02/11/23 8:41	202012.9			0.4			8.58			0.2			6.7			1		
02/11/23 8:42	179832.3			4			10.97			1.69			7.62			1		
02/11/23 8:43	161117.4			260.6			13.11			98.6			8.16			1		
02/11/23 8:44	141940.4			1336.7			15.88			445.54			8.71			1		
02/11/23 8:45	29574.1			1783.7			17.7			123.77			2.02			1		
02/11/23 8:46	11860.5			0			22.53			96.76			1.03			0		
02/11/23 8:47	10320.1			0			2.95			15.83			0.12			0		
02/11/23 8:48	12707.6			0			2.95			2.81			0.14			0		
02/11/23 8:49	13015.7			0			2.95			2.53			0.15			0		
02/11/23 8:50	10859.3			0			2.95			2.03			0.12			0		

CT1 SUSD EVENT 37

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 15:56	19716.1			0			0			0.27			0			0		
02/11/23 15:57	19870.1			0			0			0.27			0			0		
02/11/23 15:58	19562.1			0			0			0.27			0			0		
02/11/23 15:59	19716.1			0			0			0.27			0			0		
02/11/23 16:00	19639.1			0			0			0			0			0		
02/11/23 16:01	25723.3			0			0			0			0			1		
02/11/23 16:02	31730.6			0			0			0			0			1		
02/11/23 16:03	43283			26.6			5.9			2.7			0.99			1		
02/11/23 16:04	53911.2			1028.4			5.16			130.3			1.08			1		
02/11/23 16:05	64462.4			640.9			8.07			96.99			2.01			1		
02/11/23 16:06	85025.6			353.4			10.4			70.57			3.42			1		
02/11/23 16:07	129001.8			222.4			13.85			67.36			6.9			1		
02/11/23 16:08	144327.9			160.6			19.01			54.43			10.6			1		
02/11/23 16:09	157343.6			629.3			28.39			232.42			17.26			1		
02/11/23 16:10	176982.7			1853.5			28.63			770.45			19.59			1		
02/11/23 16:11	197700			1367.3			30.41			634.77			23.23			1		
02/11/23 16:12	220342.7			225.3			33.48			116.55			28.5			1		
02/11/23 16:13	240828.9			21.2			34.44			11.98			32.05			1		
02/11/23 16:14	266090.2			2.2			35.07			1.37			36.06			1		
02/11/23 16:15	291967.6			1.5			24.9			1.03			28.1			1		
02/11/23 16:16	304213.1			1.3			12.34			0.96			14.5			1		
02/11/23 16:17	311914.7			1.4			9.15			1			11.03			1		
02/11/23 16:18	313146.9			1.4			7.61			1.01			9.21			1		
02/11/23 16:19	313224			1.3			7.01			0.94			8.49			1		
02/11/23 16:20	309835.3			1.2			6.68			0.88			8			1		
02/11/23 16:21	308140.9			1.1			6.51			0.82			7.75			1		
02/11/23 16:22	307601.8			1			5.99			0.75			7.12			1		
02/11/23 16:23	307755.8			1			5.81			0.69			6.91			1		
02/11/23 16:24	307755.8			0.9			5.9			0.64			7.02			1		
02/11/23 16:25	307986.9			0.9			5.81			0.64			6.92			1		
02/11/23 16:26	306600.6			0.8			5.72			0.57			6.78			1		
02/11/23 16:27	306369.5			0.8			5.72			0.57			6.78			1		
02/11/23 16:28	306677.6			0.8			5.81			0.57			6.89			1		
02/11/23 16:29	306831.6			0.8			5.9			0.57			7			1		
02/11/23 16:30	300131.3			0.8			5.99			0.56			6.94			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 16:31	288886.9			0.8			5.99			0.54			6.68			1		
02/11/23 16:32	286191.3			0.7			6.44			0.49			7.13			1		
02/11/23 16:33	278566.8			0.7			6.72			0.47			7.23			1		
02/11/23 16:34	273791.8			0.6			3.72			0.41			3.94			1		
02/11/23 16:35	271404.3			0.6			2.49			0.41			2.61			1		
02/11/23 16:36	271327.3			0.6			1.84			0.35			1.93			1		
02/11/23 16:37	272097.4			0.6			1.57			0.35			1.65			1		
02/11/23 16:38	270711.2			0.6			1.48			0.35			1.54			1		
02/11/23 16:39	271327.3			0.6			1.29			0.35			1.35			1		
02/11/23 16:40	271327.3			0.6			1.11			0.35			1.16			0		
02/11/23 16:41	270788.2			0.6			0.92			0.35			0.96			0		
02/11/23 16:42	271712.3			0.5			0.83			0.29			0.87			0		
02/11/23 16:43	270480.1			0.5			0.83			0.29			0.87			0		
02/11/23 16:44	271866.4			0.6			0.74			0.35			0.77			0		

CT1 SUSD EVENT 38

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/13/23 0:32	269478.9			0.6			1.66			0.35			1.73			0		
02/13/23 0:33	268785.8			0.6			1.66			0.35			1.72			0		
02/13/23 0:34	269401.9			0.6			1.57			0.35			1.63			0		
02/13/23 0:35	268323.7			0.6			1.48			0.35			1.53			0		
02/13/23 0:36	269709.9			0.6			1.48			0.35			1.54			0		
02/13/23 0:37	265089			0.6			1.48			0.34			1.51			1		
02/13/23 0:38	245372.9			0.6			1.48			0.32			1.4			1		
02/13/23 0:39	224424.5			0.6			3.58			0.31			3.1			1		
02/13/23 0:40	199240.3			0.5			9.06			0.25			6.98			1		
02/13/23 0:41	176905.7			2.7			11.22			1.11			7.67			1		
02/13/23 0:42	159192			220.9			14.68			82.59			9.03			1		
02/13/23 0:43	139475.9			1166.9			16.52			382.14			8.9			1		
02/13/23 0:44	30883.4			1802			18.71			130.69			2.23			1		
02/13/23 0:45	20024.2			0			19.06			134.56			1.47			0		
02/13/23 0:46	19100			0			2.95			29.98			0.22			0		
02/13/23 0:47	20178.2			0			2.95			4.34			0.23			0		
02/13/23 0:48	19947.1			0			2.95			3.59			0.23			0		
02/13/23 0:49	19562.1			0			2.95			3.52			0.22			0		

CT1 SUSD EVENT 39

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 15:29	0			0			0			0			0			0		
02/14/23 15:30	0			0			0			0			0			0		
02/14/23 15:31	0			0			0			0			0			0		
02/14/23 15:32	0			0			0			0			0			0		
02/14/23 15:33	19254			0			0			0			0			0		
02/14/23 15:34	29035			0.1			0			0			0			1		
02/14/23 15:35	37583.8			0.1			0			0			0			1		
02/14/23 15:36	45901.5			51.6			16.23			5.56			2.88			1		
02/14/23 15:37	55143.4			1148.9			11.8			148.65			2.51			1		
02/14/23 15:38	66849.9			739.5			16.39			116.03			4.23			1		
02/14/23 15:39	90955.9			467.9			20.36			99.91			7.15			1		
02/14/23 15:40	134084.8			332.5			23.33			104.66			12.09			1		
02/14/23 15:41	143942.9			215.4			41.75			72.79			23.23			1		
02/14/23 15:42	158113.8			727.5			47.57			270.18			29.07			1		
02/14/23 15:43	174133.1			1900.7			49.52			777.32			33.33			1		
02/14/23 15:44	196390.7			1624.6			58.68			749.13			44.53			1		
02/14/23 15:45	220573.8			391.8			64.06			202.94			54.61			1		
02/14/23 15:46	239057.6			50.2			65.28			28.19			60.31			1		
02/14/23 15:47	265474.1			3.2			59.56			2.01			61.1			1		
02/14/23 15:48	290735.3			1.8			47.91			1.25			53.83			1		
02/14/23 15:49	297820.8			1.7			21.39			1.16			24.61			1		
02/14/23 15:50	296973.6			1.6			17.01			1.15			19.52			1		
02/14/23 15:51	296742.5			1.8			13.62			1.27			15.62			1		
02/14/23 15:52	295510.3			1.8			12.15			1.22			13.88			1		
02/14/23 15:53	297897.8			1.7			10.66			1.17			12.27			1		
02/14/23 15:54	310759.4			1.5			8.89			1.09			10.68			1		
02/14/23 15:55	312222.8			1.4			7.31			1.03			8.82			1		
02/14/23 15:56	311991.7			1.3			6.52			0.97			7.86			1		
02/14/23 15:57	310143.3			1.2			6.08			0.9			7.28			1		
02/14/23 15:58	314764.3			1.1			5.64			0.85			6.86			1		
02/14/23 15:59	319000.2			1.1			5.37			0.79			6.62			1		
02/14/23 16:00	321772.7			1.1			5.46			0.8			6.79			1		
02/14/23 16:01	323082			1.1			5.55			0.8			6.93			1		
02/14/23 16:02	321849.8			1			5.64			0.73			7.01			1		
02/14/23 16:03	320155.4			1			5.64			0.73			6.97			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 16:04	320232.4			1			5.64			0.73			6.97			1		
02/14/23 16:05	320001.4			1			5.64			0.73			6.97			1		
02/14/23 16:06	317998.9			0.9			5.55			0.66			6.82			1		
02/14/23 16:07	318230			0.9			5.55			0.66			6.82			1		
02/14/23 16:08	327009.8			0.9			5.46			0.68			6.9			1		
02/14/23 16:09	338639.2			0.9			5.37			0.7			7.03			1		
02/14/23 16:10	345647.7			0.8			4.47			0.65			5.97			1		
02/14/23 16:11	340718.7			0.8			4.02			0.64			5.3			1		
02/14/23 16:12	337330			0.8			4.58			0.63			5.97			1		
02/14/23 16:13	334018.3			0.8			4.67			0.62			6.02			1		
02/14/23 16:14	352194			0.8			4.76			0.66			6.47			1		
02/14/23 16:15	367597.3			0.8			3.84			0.69			5.46			1		
02/14/23 16:16	385079.9			0.7			3.5			0.67			5.21			1		
02/14/23 16:17	385387.9			0.6			4.15			0.58			6.18			1		
02/14/23 16:18	391934.3			0.6			3.63			0.58			5.5			1		
02/14/23 16:19	408723.8			0.7			2.18			0.7			3.44			1		
02/14/23 16:20	424435			0.7			1.48			0.73			2.42			1		
02/14/23 16:21	430596.3			0.7			1.5			0.66			2.49			1		
02/14/23 16:22	429441.1			0.6			2.21			0.65			3.67			1		
02/14/23 16:23	437065.7			0.6			2.58			0.66			4.36			1		
02/14/23 16:24	453701.1			0.6			2.77			0.69			4.85			1		
02/14/23 16:25	453778.1			0.6			3.04			0.69			5.33			1		
02/14/23 16:26	453239			0.6			2.45			0.68			4.29			1		
02/14/23 16:27	451775.7			0.7			1.54			0.77			2.69			1		
02/14/23 16:28	453701.1			0.7			1.45			0.78			2.57			1		
02/14/23 16:29	452160.8			0.9			1.54			0.99			2.78			1		
02/14/23 16:30	452853.9			1.5			1.76			1.65			3.19			0		
02/14/23 16:31	453162			1.9			2.26			2.1			4.08			0		
02/14/23 16:32	453932.1			1.8			2.26			2.01			4.09			0		
02/14/23 16:33	453162			1.6			1.91			1.82			3.46			0		
02/14/23 16:34	454086.2			1.6			1.39			1.72			2.51			0		

CT1 SUSD EVENT 40

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 8:31	270172			0.6			1.52			0.36			1.59			0		
02/15/23 8:32	270095			0.4			1.71			0.24			1.79			0		
02/15/23 8:33	269478.9			0.4			1.84			0.24			1.91			0		
02/15/23 8:34	269478.9			0.4			1.84			0.24			1.91			0		
02/15/23 8:35	269401.9			0.4			1.74			0.24			1.81			0		
02/15/23 8:36	267861.6			0.4			1.62			0.24			1.67			1		
02/15/23 8:37	248145.5			0.4			1.64			0.23			1.58			1		
02/15/23 8:38	228044.3			0.4			3.7			0.21			3.26			1		
02/15/23 8:39	204169.3			0.3			7.21			0.16			5.69			1		
02/15/23 8:40	180833.5			4.8			9.68			2.05			6.76			1		
02/15/23 8:41	162426.7			331.3			11.93			126.38			7.49			1		
02/15/23 8:42	143865.8			1323.9			13.77			447.18			7.65			1		
02/15/23 8:43	36197.5			1751.3			15.51			148.97			2.17			1		
02/15/23 8:44	0			0			16.91			0			0			0		
02/15/23 8:45	0			0			2.95			0			0			0		
02/15/23 8:46	0			0			5.9			0			0			0		
02/15/23 8:47	0			0			5.9			0			0			0		
02/15/23 8:48	0			0			5.9			0			0			0		

CT1 SUSD EVENT 41

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 16:11	22257.6			0			0			0			0			0		
02/15/23 16:12	22180.6			0			0			0			0			0		
02/15/23 16:13	22334.6			0			0			0			0			0		
02/15/23 16:14	22411.6			0			0			0			0			0		
02/15/23 16:15	22411.6			0			0			0			0			0		
02/15/23 16:16	25569.3			0			0			0			0			1		
02/15/23 16:17	30960.4			0			0			0			0			1		
02/15/23 16:18	40125.3			38.4			8.85			3.61			1.37			1		
02/15/23 16:19	50214.4			976.9			5.06			115.24			0.98			1		
02/15/23 16:20	61304.7			842			7.29			121.19			1.73			1		
02/15/23 16:21	75783.7			441.3			9.44			78.54			2.76			1		
02/15/23 16:22	111365.1			273.6			12.92			71.55			5.56			1		
02/15/23 16:23	144713			182.9			18.93			62.15			10.59			1		
02/15/23 16:24	148640.8			135.7			19.27			47.36			11.07			1		
02/15/23 16:25	163350.9			1682.6			28.76			645.57			18.16			1		
02/15/23 16:26	181526.6			1808			31.76			770.58			22.27			1		
02/15/23 16:27	203630.2			1157.8			32.22			553.57			25.36			1		
02/15/23 16:28	227274.1			140.4			34.73			74.92			30.5			1		
02/15/23 16:29	246682.2			12			37.21			6.98			35.47			1		
02/15/23 16:30	273406.7			2			37.59			1.26			39.71			1		
02/15/23 16:31	297666.7			1.5			23.9			1.03			27.49			1		
02/15/23 16:32	314379.2			1.3			12.96			0.99			15.75			1		
02/15/23 16:33	314841.3			1.4			8.98			1.01			10.92			1		
02/15/23 16:34	315765.5			1.4			8.24			1.03			10.06			1		
02/15/23 16:35	314841.3			1.3			7.38			0.96			8.97			1		
02/15/23 16:36	313146.9			1.2			7.2			0.89			8.72			1		
02/15/23 16:37	312145.8			1.1			6.6			0.84			7.97			1		
02/15/23 16:38	311683.6			1.1			6.43			0.77			7.74			1		
02/15/23 16:39	310836.5			1			6.34			0.71			7.62			1		
02/15/23 16:40	311067.5			0.9			6.16			0.64			7.41			1		
02/15/23 16:41	310374.4			0.9			6.17			0.65			7.4			1		
02/15/23 16:42	310528.4			0.8			6.08			0.59			7.29			1		
02/15/23 16:43	309912.3			0.8			6.08			0.59			7.28			1		
02/15/23 16:44	310297.3			0.7			6.17			0.52			7.4			1		
02/15/23 16:45	311221.5			0.7			6.17			0.52			7.42			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 16:46	311529.6			0.7			6.26			0.52			7.53			1		
02/15/23 16:47	311452.6			0.7			6.35			0.52			7.64			1		
02/15/23 16:48	311760.7			0.7			6.44			0.52			7.75			1		
02/15/23 16:49	314610.3			0.7			6.53			0.53			7.93			1		
02/15/23 16:50	299361.1			0.7			6.53			0.5			7.55			1		
02/15/23 16:51	289580.1			0.7			4.02			0.49			4.5			1		
02/15/23 16:52	285190.2			0.6			2.72			0.43			3			1		
02/15/23 16:53	280184.1			0.6			3.13			0.36			3.39			1		
02/15/23 16:54	274176.9			0.6			4.43			0.36			4.69			1		
02/15/23 16:55	272944.6			0.6			5.71			0.36			6.03			1		
02/15/23 16:56	272328.5			0.5			4.12			0.3			4.34			1		
02/15/23 16:57	271943.4			0.5			2.81			0.3			2.95			1		
02/15/23 16:58	272482.5			0.5			2.25			0.3			2.37			1		
02/15/23 16:59	271712.3			0.5			1.69			0.3			1.77			1		
02/15/23 17:00	272328.5			0.5			1.59			0.3			1.68			1		
02/15/23 17:01	271558.3			0.5			1.5			0.3			1.57			1		
02/15/23 17:02	272097.4			0.5			1.4			0.3			1.48			0		
02/15/23 17:03	278566.8			0.4			1.4			0.25			1.51			0		
02/15/23 17:04	295818.3			0.5			1.31			0.33			1.5			0		
02/15/23 17:05	300285.3			0.5			1.29			0.33			1.5			0		
02/15/23 17:06	295125.2			0.5			1.09			0.38			1.24			0		

CT1 SUSD EVENT 42

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 8:48	270403.1			0.5			1.62			0.3			1.69			0		
02/16/23 8:49	270018			0.5			1.62			0.3			1.69			0		
02/16/23 8:50	269941			0.5			1.71			0.3			1.79			0		
02/16/23 8:51	270326.1			0.5			1.71			0.3			1.79			0		
02/16/23 8:52	270172			0.5			1.71			0.3			1.79			0		
02/16/23 8:53	262470.4			0.5			1.71			0.29			1.74			1		
02/16/23 8:54	239904.8			0.5			1.93			0.27			1.79			1		
02/16/23 8:55	219649.5			0.4			6			0.21			5.09			1		
02/16/23 8:56	193849.2			0.8			9.8			0.35			7.34			1		
02/16/23 8:57	172900.9			9.2			11.55			3.74			7.72			1		
02/16/23 8:58	155110.2			603.2			15.31			219.69			9.18			1		
02/16/23 8:59	112289.3			1601.6			17.54			422.33			7.61			1		
02/16/23 9:00	4158.9			0			19.41			19.4			0.31			0		
02/16/23 9:01	1925.4			0			15.73			26.98			0.12			0		
02/16/23 9:02	1155.2			0			2.95			0.58			0.01			0		
02/16/23 9:03	7393.5			0			5.9			2.99			0.17			0		
02/16/23 9:04	4621			0			5.9			1.71			0.1			0		

CT1 SUSD EVENT 43

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 16:08	25338.3			0			0			0			0			0		
02/16/23 16:09	25184.2			0			0			0			0			0		
02/16/23 16:10	25030.2			0			0			0			0			0		
02/16/23 16:11	25107.2			0			0			0			0			0		
02/16/23 16:12	25646.3			0			0			0			0			0		
02/16/23 16:13	32577.8			0.1			0			0			0			1		
02/16/23 16:14	38970.1			0.3			0			0			0			1		
02/16/23 16:15	45131.4			36.7			6.56			3.89			1.14			1		
02/16/23 16:16	59841.4			944			6.27			132.7			1.45			1		
02/16/23 16:17	69160.3			512.4			9.01			83.15			2.41			1		
02/16/23 16:18	94190.5			280.7			11.52			62.07			4.19			1		
02/16/23 16:19	141401.3			189.3			16.16			62.85			8.83			1		
02/16/23 16:20	143788.8			133.2			19.81			44.95			11			1		
02/16/23 16:21	141093.3			921.7			29.68			305.35			16.18			1		
02/16/23 16:22	156573.5			1987			31.21			730.32			18.88			1		
02/16/23 16:23	174980.3			1924.9			36.88			791.09			24.94			1		
02/16/23 16:24	194003.2			1664.8			36.2			758.34			27.14			1		
02/16/23 16:25	217262.1			385.4			38.42			196.6			32.26			1		
02/16/23 16:26	239596.7			39.8			39.42			22.38			36.49			1		
02/16/23 16:27	263317.6			3.2			40.85			1.96			41.56			1		
02/16/23 16:28	289580.1			1.9			33.23			1.27			37.19			1		
02/16/23 16:29	309296.2			1.7			14.84			1.21			17.74			1		
02/16/23 16:30	313146.9			1.6			10.93			1.15			13.23			1		
02/16/23 16:31	313455			1.6			8.5			1.15			10.3			1		
02/16/23 16:32	313301			1.5			8.16			1.09			9.88			1		
02/16/23 16:33	313224			1.3			7.38			0.96			8.93			1		
02/16/23 16:34	311452.6			1.2			7.22			0.9			8.69			1		
02/16/23 16:35	309989.3			1.1			7.04			0.77			8.44			1		
02/16/23 16:36	306908.7			1.1			6.78			0.76			8.04			1		
02/16/23 16:37	307062.7			1			6.52			0.7			7.73			1		
02/16/23 16:38	309604.2			0.8			6.44			0.58			7.7			1		
02/16/23 16:39	311529.6			0.9			6.35			0.65			7.64			1		
02/16/23 16:40	311606.6			0.8			6.44			0.59			7.75			1		
02/16/23 16:41	310297.3			0.8			6.53			0.59			7.83			1		
02/16/23 16:42	307755.8			0.8			6.7			0.58			7.97			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/16/23 16:43	306908.7			0.8			6.7			0.58			7.95			1		
02/16/23 16:44	306369.5			0.7			6.62			0.51			7.83			1		
02/16/23 16:45	290658.3			0.7			6.62			0.49			7.43			1		
02/16/23 16:46	289734.1			0.7			7.08			0.49			7.93			1		
02/16/23 16:47	282725.6			0.6			6.17			0.42			6.74			1		
02/16/23 16:48	277334.5			0.6			3.04			0.42			3.26			1		
02/16/23 16:49	274176.9			0.6			2.21			0.36			2.34			1		
02/16/23 16:50	274484.9			0.6			2.06			0.36			2.19			1		
02/16/23 16:51	273175.7			0.6			1.78			0.36			1.88			1		
02/16/23 16:52	273791.8			0.5			1.5			0.3			1.59			1		
02/16/23 16:53	273637.8			0.5			1.31			0.3			1.39			1		
02/16/23 16:54	273175.7			0.5			1.22			0.3			1.29			1		
02/16/23 16:55	273791.8			0.5			1.03			0.3			1.09			0		
02/16/23 16:56	272790.6			0.5			0.94			0.3			0.99			0		
02/16/23 16:57	273175.7			0.5			0.94			0.3			0.99			0		
02/16/23 16:58	274484.9			0.5			0.84			0.3			0.89			0		
02/16/23 16:59	290196.2			0.5			0.84			0.32			0.95			0		

CT1 SUSD EVENT 44

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 3:48	269632.9			0.7			1.71			0.42			1.78			0		
02/17/23 3:49	269478.9			0.7			1.71			0.42			1.78			0		
02/17/23 3:50	270172			0.7			1.62			0.42			1.69			0		
02/17/23 3:51	269170.8			0.7			1.62			0.42			1.68			0		
02/17/23 3:52	269555.9			0.7			1.52			0.42			1.59			0		
02/17/23 3:53	261931.3			0.7			1.52			0.41			1.54			1		
02/17/23 3:54	238672.5			0.7			1.81			0.37			1.67			1		
02/17/23 3:55	217185			0.6			5.49			0.31			4.61			1		
02/17/23 3:56	193233.1			1.7			8.46			0.76			6.32			1		
02/17/23 3:57	169974.3			10.9			10.57			4.37			6.94			1		
02/17/23 3:58	153877.9			615.6			12.5			222.4			7.43			1		
02/17/23 3:59	126691.3			1570.5			13.82			467.21			6.77			1		
02/17/23 4:00	0			1870.1			15.73			0			0			1		
02/17/23 4:01	0			0			12.78			0			0			0		
02/17/23 4:02	0			0			2.95			0			0			0		
02/17/23 4:03	0			0			5.9			0			0			0		
02/17/23 4:04	0			0			5.9			0			0			0		
02/17/23 4:05	0			0			5.9			0			0			0		

CT1 SUSD EVENT 45

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 15:53	30190.3			0			0			1.26			0			0		
02/20/23 15:54	30267.3			0			0			1.26			0			0		
02/20/23 15:55	30344.3			0			0			1.26			0			0		
02/20/23 15:56	30344.3			0			0			1.26			0			0		
02/20/23 15:57	30498.3			0			0			1.27			0			0		
02/20/23 15:58	39817.3			17.7			0			1.66			0			1		
02/20/23 15:59	42666.8			35.4			0			3.55			0			1		
02/20/23 16:00	51446.7			67.4			12.64			8.15			2.52			1		
02/20/23 16:01	62305.9			1040.6			12.91			152.34			3.11			1		
02/20/23 16:02	73242.2			578.5			16.52			99.45			4.67			1		
02/20/23 16:03	101661.1			363.9			21.19			86.84			8.32			1		
02/20/23 16:04	139938			235			23.35			77.23			12.63			1		
02/20/23 16:05	148332.8			152.4			43.94			53.08			25.19			1		
02/20/23 16:06	152029.5			1099.7			41.84			392.64			24.58			1		
02/20/23 16:07	161348.5			1829			37.31			693.14			23.27			1		
02/20/23 16:08	180448.4			1776.7			40.63			752.88			28.33			1		
02/20/23 16:09	202321			1257.9			54.76			597.51			42.81			1		
02/20/23 16:10	223423.3			201.8			66.82			105.9			57.7			1		
02/20/23 16:11	244371.7			18.2			64.78			10.43			61.17			1		
02/20/23 16:12	272174.4			2.7			59.76			1.75			62.86			1		
02/20/23 16:13	295972.4			2.2			36.38			1.5			41.62			1		
02/20/23 16:14	313609			2.1			18.06			1.51			21.89			1		
02/20/23 16:15	315996.5			2.1			12.31			1.52			15.04			1		
02/20/23 16:16	315534.4			2.1			10.18			1.52			12.41			1		
02/20/23 16:17	316689.7			1.9			8.5			1.42			10.41			1		
02/20/23 16:18	315072.3			1.7			7.11			1.28			8.66			1		
02/20/23 16:19	310759.4			1.6			6.25			1.2			7.5			1		
02/20/23 16:20	310605.4			1.6			5.55			1.16			6.66			1		
02/20/23 16:21	311683.6			1.4			4.84			1.03			5.83			1		
02/20/23 16:22	309912.3			1.3			4.67			0.96			5.59			1		
02/20/23 16:23	309912.3			1.2			4.49			0.9			5.38			1		
02/20/23 16:24	311375.6			1.2			4.38			0.85			5.27			1		
02/20/23 16:25	311837.7			1.1			4.2			0.79			5.06			1		
02/20/23 16:26	308063.9			1.1			4.11			0.78			4.9			1		
02/20/23 16:27	305830.4			1.1			4.11			0.77			4.86			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 16:28	305368.3			1			3.93			0.71			4.64			1		
02/20/23 16:29	305522.4			1			3.84			0.71			4.54			1		
02/20/23 16:30	305753.4			1			3.84			0.71			4.54			1		
02/20/23 16:31	306369.5			0.9			3.84			0.64			4.55			1		
02/20/23 16:32	305830.4			0.9			3.75			0.64			4.44			1		
02/20/23 16:33	305753.4			0.9			3.75			0.64			4.44			1		
02/20/23 16:34	307139.7			0.9			3.75			0.64			4.46			1		
02/20/23 16:35	308217.9			0.9			3.84			0.65			4.58			1		
02/20/23 16:36	309450.2			0.9			3.93			0.65			4.7			1		
02/20/23 16:37	298282.9			0.9			4.02			0.63			4.64			1		
02/20/23 16:38	280877.3			0.8			4.11			0.53			4.46			1		
02/20/23 16:39	279413.9			0.8			4.61			0.54			4.98			1		
02/20/23 16:40	276949.4			0.7			5.16			0.48			5.52			1		
02/20/23 16:41	272328.5			0.6			5.35			0.41			5.63			1		
02/20/23 16:42	272482.5			0.7			6.27			0.42			6.61			1		
02/20/23 16:43	272251.5			0.7			6.46			0.42			6.8			1		
02/20/23 16:44	272328.5			0.7			5.53			0.42			5.82			1		
02/20/23 16:45	274330.9			0.6			3.75			0.36			3.97			1		
02/20/23 16:46	273406.7			0.6			3.28			0.36			3.46			1		
02/20/23 16:47	275101.1			0.6			4.03			0.36			4.28			1		
02/20/23 16:48	274253.9			0.6			4.68			0.36			4.96			1		
02/20/23 16:49	276102.3			0.6			4.78			0.36			5.1			1		
02/20/23 16:50	276333.3			0.6			3.47			0.36			3.7			1		
02/20/23 16:51	275255.1			0.7			2.9			0.42			3.09			1		
02/20/23 16:52	276256.3			0.7			2.72			0.43			2.9			1		
02/20/23 16:53	285806.3			0.7			2.62			0.44			2.9			1		
02/20/23 16:54	306677.6			0.6			2.58			0.4			3.06			1		
02/20/23 16:55	329320.3			0.6			2.54			0.49			3.23			1		
02/20/23 16:56	335327.5			0.7			2.41			0.56			3.13			1		
02/20/23 16:57	331707.8			0.8			2.29			0.62			2.94			1		
02/20/23 16:58	332477.9			0.8			2.29			0.62			2.94			1		
02/20/23 16:59	355505.7			0.8			2.29			0.66			3.15			1		
02/20/23 17:00	369291.6			0.8			2.32			0.7			3.32			1		
02/20/23 17:01	380998			0.8			2.09			0.73			3.07			1		
02/20/23 17:02	383462.5			0.7			1.94			0.66			2.87			1		
02/20/23 17:03	390702			0.7			2			0.67			3.01			1		
02/20/23 17:04	406875.4			0.7			2.18			0.69			3.43			1		
02/20/23 17:05	415886.3			0.7			2.12			0.72			3.41			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 17:06	416964.5			0.7			1.94			0.72			3.12			1		
02/20/23 17:07	418812.8			0.7			1.75			0.73			2.83			1		
02/20/23 17:08	428670.9			0.7			1.66			0.74			2.75			1		
02/20/23 17:09	444998.3			0.7			1.38			0.77			2.38			1		
02/20/23 17:10	445383.4			0.7			1.2			0.77			2.06			0		
02/20/23 17:11	444074.1			0.7			1.09			0.76			1.87			0		
02/20/23 17:12	444228.1			0.7			1.2			0.77			2.06			0		
02/20/23 17:13	443380.9			0.7			1.2			0.77			2.05			0		
02/20/23 17:14	443535			0.7			1.2			0.77			2.05			0		

CT1 SUSD EVENT 46

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 15:12	280107.1			0.4			1.62			0.25			1.74			0		
03/16/23 15:13	280800.3			0.4			1.62			0.25			1.75			0		
03/16/23 15:14	276641.4			0.4			1.5			0.24			1.59			0		
03/16/23 15:15	272559.5			0.5			1.43			0.3			1.5			0		
03/16/23 15:16	273483.7			0.5			1.43			0.3			1.5			0		
03/16/23 15:17	170898.4			0.4			1.52			0.15			1			1		
03/16/23 15:18	33656			0			1.69			0.12			0.22			0		
03/16/23 15:19	33656			0			0			0			0			0		
03/16/23 15:20	33656			0			0			0			0			0		
03/16/23 15:21	33347.9			0			0			0			0			0		
03/16/23 15:22	33501.9			0			0			0			0			0		

CT1 SUSD EVENT 47

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 1:45	0			0			0			0			0			0		
03/17/23 1:46	1001.2			0			0			0			0			0		
03/17/23 1:47	0			0			0			0			0			0		
03/17/23 1:48	0			0			0			0			0			0		
03/17/23 1:49	1078.2			0			0			0			0			0		
03/17/23 1:50	15865.3			0			0			0			0			1		
03/17/23 1:51	26108.4			0			0			0			0			1		
03/17/23 1:52	37044.7			82.6			17.7			7.14			2.52			1		
03/17/23 1:53	48212			1328			8.17			149.52			1.51			1		
03/17/23 1:54	60226.5			1016.3			12.17			142.86			2.82			1		
03/17/23 1:55	76707.9			574.2			16.46			102.82			4.85			1		
03/17/23 1:56	118373.5			421.6			22.42			116.54			10.2			1		
03/17/23 1:57	142479.5			291.4			24.88			96.93			13.62			1		
03/17/23 1:58	139013.8			281.8			47			91.46			25.1			1		
03/17/23 1:59	139938			1983.4			39.33			648.2			21.16			1		
03/17/23 2:00	155341.2			2146.4			41.71			778.34			24.89			1		
03/17/23 2:01	174518.2			2007.9			44.73			818.02			29.99			1		
03/17/23 2:02	195466.5			1729			40.32			789.17			30.28			1		
03/17/23 2:03	219110.4			440.8			39.29			225.45			33.07			1		
03/17/23 2:04	240289.8			43.4			38.48			24.32			35.52			1		
03/17/23 2:05	263856.7			4.4			37.1			2.73			37.62			1		
03/17/23 2:06	288809.9			2.6			28.26			1.74			31.36			1		
03/17/23 2:07	310066.3			2.2			12.27			1.63			14.62			1		
03/17/23 2:08	326162.7			2.1			8.42			1.59			10.55			1		
03/17/23 2:09	333941.3			2.1			6.25			1.62			8.02			1		
03/17/23 2:10	334018.3			1.9			5.73			1.47			7.35			1		
03/17/23 2:11	330398.5			1.7			5.22			1.32			6.62			1		
03/17/23 2:12	329397.3			1.6			4.51			1.2			5.71			1		
03/17/23 2:13	328319.1			1.4			4.43			1.06			5.58			1		
03/17/23 2:14	326932.8			1.3			4.25			0.99			5.34			1		
03/17/23 2:15	326162.7			1.2			4.08			0.93			5.11			1		
03/17/23 2:16	325623.5			1.1			4.05			0.87			5.07			1		
03/17/23 2:17	325623.5			1.1			3.96			0.87			4.96			1		
03/17/23 2:18	326316.7			1.1			3.87			0.81			4.86			1		
03/17/23 2:19	326624.8			1.1			3.79			0.81			4.75			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 2:20	326855.8			1			3.79			0.74			4.76			1		
03/17/23 2:21	325854.6			1			3.79			0.74			4.74			1		
03/17/23 2:22	322851			1			3.87			0.73			4.81			1		
03/17/23 2:23	306831.6			0.9			3.87			0.63			4.57			1		
03/17/23 2:24	290889.3			0.9			3.84			0.61			4.3			1		
03/17/23 2:25	288963.9			0.8			3.99			0.55			4.43			1		
03/17/23 2:26	288578.8			0.7			4.43			0.5			4.91			1		
03/17/23 2:27	288809.9			0.6			4.43			0.44			4.91			1		
03/17/23 2:28	288655.9			0.6			4.52			0.43			5.01			1		
03/17/23 2:29	288424.8			0.6			4.7			0.43			5.21			1		
03/17/23 2:30	288424.8			0.6			4.79			0.43			5.31			1		
03/17/23 2:31	288347.8			0.6			4.89			0.43			5.41			1		
03/17/23 2:32	288424.8			0.6			4.89			0.43			5.41			1		
03/17/23 2:33	287731.7			0.6			3.6			0.43			3.97			1		
03/17/23 2:34	288193.8			0.6			2.86			0.43			3.16			1		
03/17/23 2:35	287962.7			0.6			2.67			0.43			2.96			1		
03/17/23 2:36	287962.7			0.6			2.86			0.43			3.16			1		
03/17/23 2:37	288116.8			0.6			3.32			0.43			3.67			1		
03/17/23 2:38	288270.8			0.6			3.41			0.43			3.78			1		
03/17/23 2:39	287885.7			0.6			2.86			0.43			3.16			1		
03/17/23 2:40	287577.6			0.6			2.4			0.37			2.65			1		
03/17/23 2:41	287500.6			0.6			2.21			0.37			2.44			1		
03/17/23 2:42	287346.6			0.6			2.12			0.37			2.34			1		
03/17/23 2:43	287577.6			0.6			2.12			0.37			2.34			1		
03/17/23 2:44	291582.5			0.6			2.12			0.38			2.38			1		
03/17/23 2:45	311683.6			0.6			2.21			0.4			2.65			1		
03/17/23 2:46	330321.5			0.6			2.09			0.49			2.65			1		
03/17/23 2:47	343645.3			0.6			1.97			0.5			2.6			1		
03/17/23 2:48	349267.4			0.7			1.45			0.59			1.95			1		
03/17/23 2:49	362976.3			0.7			1.36			0.62			1.9			1		
03/17/23 2:50	379919.8			0.7			1.27			0.64			1.86			1		
03/17/23 2:51	387467.3			0.7			1.31			0.59			1.95			1		
03/17/23 2:52	388776.6			0.6			1.38			0.59			2.07			0		
03/17/23 2:53	396940.3			0.6			1.54			0.59			2.35			0		
03/17/23 2:54	415039.1			0.6			1.75			0.63			2.79			0		
03/17/23 2:55	426591.5			0.7			1.87			0.65			3.07			0		
03/17/23 2:56	429364			0.7			1.87			0.66			3.09			0		

CT1 SUSD EVENT 48

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 20:09	448387			0.1			1.64			0.1			3.97			0		
03/20/23 20:10	447770.9			0.1			1.7			0.14			2.93			0		
03/20/23 20:11	448541			0.3			0.91			0.29			1.56			0		
03/20/23 20:12	450158.3			0.7			0.65			0.78			1.12			0		
03/20/23 20:13	449542.2			1.1			0.83			1.16			1.43			0		
03/20/23 20:14	448695.1			1			1.48			1.06			2.54			1		
03/20/23 20:15	447616.8			0.7			1.57			0.77			2.7			1		
03/20/23 20:16	431289.4			0.6			1.57			0.65			2.6			1		
03/20/23 20:17	409648			0.6			2.12			0.53			3.34			1		
03/20/23 20:18	387390.3			0.5			2.45			0.49			3.65			1		
03/20/23 20:19	365209.8			0.6			2.86			0.53			4.01			1		
03/20/23 20:20	341180.8			0.7			3.17			0.56			4.16			1		
03/20/23 20:21	316304.6			0.7			3.26			0.52			3.96			1		
03/20/23 20:22	296434.5			0.7			3.26			0.49			3.71			1		
03/20/23 20:23	274947			0.7			3.4			0.46			3.59			1		
03/20/23 20:24	251919.3			0.6			4.43			0.33			4.28			1		
03/20/23 20:25	230893.9			0.5			6.67			0.26			5.92			1		
03/20/23 20:26	207018.9			0.3			21.49			0.15			17.09			1		
03/20/23 20:27	183452			2.5			26.26			1.09			18.51			1		
03/20/23 20:28	163350.9			102.7			30.02			39.16			18.85			1		
03/20/23 20:29	145791.2			658.5			34.64			224.21			19.41			1		
03/20/23 20:30	83408.3			1685.2			34.22			328.19			10.97			1		
03/20/23 20:31	24799.1			0			34.6			150.88			3.3			0		
03/20/23 20:32	24260			0			0.5			0			0			0		
03/20/23 20:33	24106			0			0.2			0			0			0		
03/20/23 20:34	23720.9			0			0.2			0			0			0		
03/20/23 20:35	23489.9			0			0.1			0			0			0		

CT1 SUSD EVENT 49

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 16:03	26570.5			0			0			0			0			0		
03/22/23 16:04	26493.5			0			0			0			0			0		
03/22/23 16:05	26647.5			0			0			0			0			0		
03/22/23 16:06	26493.5			0			0			0			0			0		
03/22/23 16:07	26955.6			0			0			0			0			0		
03/22/23 16:08	34195.1			0			0			0			0			1		
03/22/23 16:09	39201.1			0.3			0			0			0			1		
03/22/23 16:10	48366			73.8			17.7			8.32			3.29			1		
03/22/23 16:11	59225.3			1250.4			12.59			172.98			2.87			1		
03/22/23 16:12	71393.8			793			17.7			132.25			4.86			1		
03/22/23 16:13	97656.3			461.4			20.95			105.24			7.86			1		
03/22/23 16:14	138320.7			306.3			23.06			98.93			12.26			1		
03/22/23 16:15	148563.8			195.1			45.23			67.66			25.81			1		
03/22/23 16:16	158575.9			1148			48.53			425.05			29.57			1		
03/22/23 16:17	175673.4			1898.5			48.27			778.57			32.58			1		
03/22/23 16:18	196544.8			1740.3			57.36			798.61			43.32			1		
03/22/23 16:19	219033.4			386.8			63.03			197.76			53.03			1		
03/22/23 16:20	240058.8			48.4			63.87			27.1			58.92			1		
03/22/23 16:21	263779.7			3.2			58.32			1.96			59.1			1		
03/22/23 16:22	289040.9			1.9			45.34			1.26			50.36			1		
03/22/23 16:23	310528.4			1.7			21.35			1.22			25.48			1		
03/22/23 16:24	315688.5			1.6			16.23			1.22			19.68			1		
03/22/23 16:25	315688.5			1.8			13.01			1.34			15.79			1		
03/22/23 16:26	313455			1.7			12.23			1.27			14.73			1		
03/22/23 16:27	312222.8			1.7			11.18			1.22			13.41			1		
03/22/23 16:28	311760.7			1.5			10.48			1.09			12.55			1		
03/22/23 16:29	310066.3			1.3			9.69			0.96			11.54			1		
03/22/23 16:30	309142.1			1.3			8.67			0.9			10.3			1		
03/22/23 16:31	309142.1			1.1			8.05			0.77			9.56			1		
03/22/23 16:32	309065.1			1			7.96			0.71			9.45			1		
03/22/23 16:33	310220.3			0.9			7.78			0.65			9.27			1		
03/22/23 16:34	309373.2			0.9			7.6			0.65			9.03			1		
03/22/23 16:35	307755.8			0.9			7.51			0.64			8.88			1		
03/22/23 16:36	306831.6			0.9			7.51			0.64			8.85			1		
03/22/23 16:37	306985.7			0.8			7.44			0.59			8.78			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 16:38	307447.8			0.8			7.35			0.59			8.69			1		
03/22/23 16:39	306446.6			0.8			7.26			0.58			8.55			1		
03/22/23 16:40	305676.4			0.7			7.26			0.52			8.53			1		
03/22/23 16:41	306523.6			0.7			7.26			0.52			8.55			1		
03/22/23 16:42	307139.7			0.7			7.17			0.52			8.46			1		
03/22/23 16:43	315688.5			0.7			7.17			0.54			8.7			1		
03/22/23 16:44	328396.1			0.7			7.35			0.56			9.28			1		
03/22/23 16:45	329166.3			0.7			7.6			0.55			9.61			1		
03/22/23 16:46	329089.3			0.7			7.33			0.55			9.27			1		
03/22/23 16:47	328781.2			0.7			7.33			0.55			9.26			1		
03/22/23 16:48	327857			0.7			7.42			0.55			9.35			1		
03/22/23 16:49	313301			0.7			7.51			0.52			9.04			1		
03/22/23 16:50	307986.9			0.7			7.6			0.51			8.99			1		
03/22/23 16:51	301748.6			0.7			7.17			0.51			8.31			1		
03/22/23 16:52	297589.7			0.6			5.36			0.44			6.12			1		
03/22/23 16:53	295356.3			0.6			4.33			0.45			4.92			1		
03/22/23 16:54	295433.3			0.6			4.61			0.38			5.23			1		
03/22/23 16:55	292968.8			0.6			5.35			0.38			6.02			1		
03/22/23 16:56	289195			0.6			5.53			0.37			6.15			1		
03/22/23 16:57	289195			0.6			3.6			0.37			3.99			1		
03/22/23 16:58	288501.8			0.6			2.3			0.37			2.55			1		
03/22/23 16:59	288039.8			0.6			2.21			0.37			2.45			1		
03/22/23 17:00	288270.8			0.6			2.62			0.38			2.9			1		
03/22/23 17:01	288424.8			0.6			3.28			0.38			3.63			1		
03/22/23 17:02	288424.8			0.6			3.47			0.38			3.84			1		
03/22/23 17:03	288578.8			0.6			3.65			0.38			4.05			1		
03/22/23 17:04	288116.8			0.5			2.9			0.31			3.21			1		
03/22/23 17:05	288270.8			0.5			2.62			0.32			2.9			1		
03/22/23 17:06	288655.9			0.6			2.43			0.38			2.7			1		
03/22/23 17:07	288655.9			0.6			2.15			0.38			2.39			1		
03/22/23 17:08	288501.8			0.6			2.06			0.38			2.28			1		
03/22/23 17:09	288424.8			0.5			1.97			0.32			2.18			1		
03/22/23 17:10	288501.8			0.5			1.87			0.32			2.08			1		
03/22/23 17:11	288270.8			0.5			1.87			0.32			2.07			1		
03/22/23 17:12	288193.8			0.5			1.97			0.32			2.18			1		
03/22/23 17:13	294740.1			0.6			1.97			0.39			2.23			1		
03/22/23 17:14	315303.4			0.6			1.97			0.41			2.38			1		
03/22/23 17:15	334018.3			0.5			1.82			0.42			2.33			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 17:16	351654.9			0.6			1.72			0.52			2.33			1		
03/22/23 17:17	368290.4			0.6			1.18			0.55			1.67			1		
03/22/23 17:18	388314.5			0.6			1.01			0.59			1.51			1		
03/22/23 17:19	410110.1			0.6			1.03			0.54			1.62			0		
03/22/23 17:20	433676.9			0.6			1.12			0.57			1.87			0		
03/22/23 17:21	449234.2			0.5			1.33			0.5			2.3			0		
03/22/23 17:22	448001.9			0.5			2.15			0.49			3.71			0		
03/22/23 17:23	446923.7			0.6			2.03			0.58			3.48			0		

CT1 SUSD EVENT 50

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 23:39	286807.5			0.6			1.4			0.38			1.55			0		
03/22/23 23:40	287423.6			0.6			1.48			0.37			1.63			0		
03/22/23 23:41	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:42	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:43	287192.6			0.6			1.5			0.38			1.65			0		
03/22/23 23:44	287500.6			0.6			1.5			0.38			1.66			1		
03/22/23 23:45	279028.9			0.6			1.59			0.37			1.71			1		
03/22/23 23:46	256848.3			0.6			1.59			0.34			1.57			1		
03/22/23 23:47	234282.6			0.5			2.85			0.26			2.57			1		
03/22/23 23:48	210407.6			0.4			8.11			0.21			6.56			1		
03/22/23 23:49	185762.5			2.2			15.96			0.95			11.39			1		
03/22/23 23:50	166816.6			96.8			18.88			37.69			12.1			1		
03/22/23 23:51	148948.9			735.4			21.54			255.83			12.33			1		
03/22/23 23:52	93574.4			1757.9			23.77			384.05			8.55			1		
03/22/23 23:53	24260			0			23.6			130.33			2.2			0		
03/22/23 23:54	24183			0			0.4			0			0			0		
03/22/23 23:55	24414.1			0			0.2			0			0			0		
03/22/23 23:56	24491.1			0			0.1			0			0			0		
03/22/23 23:57	24645.1			0			0.1			0			0			0		

CT1 SUSD EVENT 51

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 14:54	26108.4			0			0			0			0			0		
03/23/23 14:55	26108.4			0			0			0			0			0		
03/23/23 14:56	26185.4			0			0			0			0			0		
03/23/23 14:57	26570.5			0			0			0			0			0		
03/23/23 14:58	26647.5			0			0			0			0			0		
03/23/23 14:59	30960.4			0			0			0			0			1		
03/23/23 15:00	35273.3			0			0			0			0			1		
03/23/23 15:01	43822.1			112.1			53.1			11.47			8.94			1		
03/23/23 15:02	54219.2			1254.4			13.62			158.93			2.84			1		
03/23/23 15:03	64847.4			945.8			18.44			143.13			4.59			1		
03/23/23 15:04	80558.7			509.3			23.91			95.76			7.4			1		
03/23/23 15:05	120607			338.8			26.69			95.41			12.37			1		
03/23/23 15:06	144405			215.8			42.53			72.76			23.6			1		
03/23/23 15:07	148794.9			241.7			57.98			83.97			33.15			1		
03/23/23 15:08	160116.2			1900.9			49.48			710.62			30.44			1		
03/23/23 15:09	178369			1866.5			50.6			777.14			34.67			1		
03/23/23 15:10	200395.6			1485			51.35			694.76			39.53			1		
03/23/23 15:11	223192.3			228.3			52.12			118.96			44.7			1		
03/23/23 15:12	243678.5			20.8			49.71			11.86			46.55			1		
03/23/23 15:13	269401.9			2.4			48.09			1.54			49.78			1		
03/23/23 15:14	290658.3			1.8			31.43			1.24			35.11			1		
03/23/23 15:15	307062.7			1.8			16.13			1.26			19.04			1		
03/23/23 15:16	314456.2			1.8			11.8			1.29			14.26			1		
03/23/23 15:17	314764.3			1.8			8.72			1.29			10.54			1		
03/23/23 15:18	312376.8			1.6			8.1			1.16			9.72			1		
03/23/23 15:19	310836.5			1.4			7.31			1.02			8.73			1		
03/23/23 15:20	310451.4			1.3			6.7			0.91			8			1		
03/23/23 15:21	309373.2			1.2			6.53			0.84			7.76			1		
03/23/23 15:22	309758.3			1.1			6.35			0.78			7.55			1		
03/23/23 15:23	309681.2			1			5.99			0.72			7.13			1		
03/23/23 15:24	308371.9			0.9			5.9			0.65			6.99			1		
03/23/23 15:25	307293.7			0.9			5.99			0.65			7.07			1		
03/23/23 15:26	306446.6			0.8			5.9			0.58			6.95			1		
03/23/23 15:27	307601.8			0.8			5.81			0.59			6.87			1		
03/23/23 15:28	307601.8			0.7			5.72			0.52			6.76			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 15:29	306754.6			0.7			5.72			0.52			6.74			1		
03/23/23 15:30	304521.2			0.7			5.72			0.52			6.69			1		
03/23/23 15:31	297743.8			0.7			5.81			0.51			6.64			1		
03/23/23 15:32	291659.5			0.6			5.72			0.44			6.41			1		
03/23/23 15:33	291043.3			0.6			6.18			0.44			6.91			1		
03/23/23 15:34	290427.2			0.6			6.56			0.38			7.32			1		
03/23/23 15:35	290273.2			0.6			6.56			0.38			7.31			1		
03/23/23 15:36	289657.1			0.6			6.65			0.38			7.4			1		
03/23/23 15:37	289349			0.6			6.74			0.38			7.5			1		
03/23/23 15:38	289811.1			0.6			6.74			0.38			7.51			1		
03/23/23 15:39	289503			0.6			6.84			0.38			7.6			1		
03/23/23 15:40	289734.1			0.6			6.93			0.38			7.72			1		
03/23/23 15:41	289811.1			0.6			6.37			0.38			7.09			1		
03/23/23 15:42	290119.2			0.6			5.06			0.38			5.64			1		
03/23/23 15:43	289734.1			0.6			4.03			0.38			4.48			1		
03/23/23 15:44	289811.1			0.6			3.75			0.38			4.17			1		
03/23/23 15:45	289118			0.6			3.18			0.38			3.54			1		
03/23/23 15:46	289195			0.6			3.09			0.38			3.43			1		
03/23/23 15:47	288963.9			0.6			3			0.38			3.33			1		
03/23/23 15:48	288732.9			0.6			2.81			0.38			3.12			1		
03/23/23 15:49	288963.9			0.6			2.62			0.38			2.91			1		
03/23/23 15:50	289118			0.6			2.34			0.38			2.6			1		
03/23/23 15:51	289118			0.6			2.06			0.38			2.29			1		
03/23/23 15:52	289040.9			0.6			1.78			0.38			1.98			1		
03/23/23 15:53	288732.9			0.5			1.5			0.32			1.66			1		
03/23/23 15:54	288963.9			0.6			1.31			0.38			1.46			1		
03/23/23 15:55	289426			0.6			1.22			0.38			1.35			1		
03/23/23 15:56	288809.9			0.6			1.12			0.38			1.25			0		
03/23/23 15:57	289195			0.6			1.12			0.38			1.25			0		
03/23/23 15:58	289272			0.6			1.03			0.38			1.14			0		
03/23/23 15:59	288809.9			0.6			1.12			0.38			1.25			0		
03/23/23 16:00	287962.7			0.6			1.12			0.38			1.24			0		

CT1 SUSD EVENT 52

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/23/23 22:50	293045.8			0.6			2.53			0.38			2.85			0		
03/23/23 22:51	306600.6			0.6			2.34			0.4			2.76			0		
03/23/23 22:52	307601.8			0.6			1.57			0.4			1.85			0		
03/23/23 22:53	306369.5			0.6			1.45			0.45			1.71			0		
03/23/23 22:54	300824.4			0.6			1.45			0.45			1.68			0		
03/23/23 22:55	299130			0.6			1.57			0.45			1.8			1		
03/23/23 22:56	283033.7			0.6			1.75			0.43			1.9			1		
03/23/23 22:57	261161.2			0.6			2.4			0.39			2.41			1		
03/23/23 22:58	238672.5			0.6			4.38			0.32			4.01			1		
03/23/23 22:59	216414.9			0.4			8.28			0.21			6.89			1		
03/23/23 23:00	191384.7			1.5			19.97			0.66			14.68			1		
03/23/23 23:01	170975.5			12.3			23.09			4.91			15.16			1		
03/23/23 23:02	153492.8			569.6			25.9			204.12			15.28			1		
03/23/23 23:03	106590.1			1630.7			27.37			405.91			11.21			1		
03/23/23 23:04	22950.8			0			26.24			113.01			2.31			0		
03/23/23 23:05	22950.8			0			70.8			1011.33			6.23			0		
03/23/23 23:06	22950.8			0			0.2			0			0			0		
03/23/23 23:07	22642.7			0			0.1			0			0			0		
03/23/23 23:08	22642.7			0			0.1			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 20:23	288347.8			0.8			1.33			0.52			1.49			0		
01/27/23 20:24	287500.6			0.8			1.33			0.52			1.48			0		
01/27/23 20:25	287577.6			0.8			1.33			0.52			1.48			0		
01/27/23 20:26	289426			0.8			1.33			0.52			1.49			0		
01/27/23 20:27	287962.7			0.8			1.33			0.52			1.49			0		
01/27/23 20:28	284959.1			0.8			1.43			0.51			1.58			1		
01/27/23 20:29	265012			0.8			1.43			0.48			1.47			1		
01/27/23 20:30	245912			0.8			3.3			0.46			3.15			1		
01/27/23 20:31	217801.2			0.8			8.63			0.39			7.28			1		
01/27/23 20:32	193233.1			4.6			11.68			2.08			8.75			1		
01/27/23 20:33	170898.4			332.2			14.27			133.7			9.45			1		
01/27/23 20:34	152722.7			1154.4			17.7			415.26			10.48			1		
01/27/23 20:35	50830.5			1894.4			22.88			226.87			4.51			1		
01/27/23 20:36	0			0			29.5			0			0			0		
01/27/23 20:37	0			0			0.2			0			0			0		
01/27/23 20:38	0			0			0.1			0			0			0		
01/27/23 20:39	0			0			0.1			0			0			0		
01/27/23 20:40	0			0			0.1			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:09	0			0			0			0			0			0		
01/29/23 9:10	0			0			0			0			0			0		
01/29/23 9:11	0			0			0			0			0			0		
01/29/23 9:12	0			0			0			0			0			0		
01/29/23 9:13	0			0			0			0			0			0		
01/29/23 9:14	6392.3			0.2			0			0			0			1		
01/29/23 9:15	20640.3			0.2			0			0			0			1		
01/29/23 9:16	36428.6			50.2			29.5			4.3			4.16			1		
01/29/23 9:17	50214.4			1393.8			14.07			164.73			2.74			1		
01/29/23 9:18	58686.2			1094.1			18.44			151.11			4.19			1		
01/29/23 9:19	73473.2			685.3			22.05			118.59			6.28			1		
01/29/23 9:20	106975.2			535.1			25.96			134.76			10.76			1		
01/29/23 9:21	151413.4			406			35.4			144.78			20.77			1		
01/29/23 9:22	157959.8			248.9			50.36			92.58			30.83			1		
01/29/23 9:23	170436.3			1426.1			49.29			572.37			32.56			1		
01/29/23 9:24	191538.7			1873.5			53.46			845.05			39.68			1		
01/29/23 9:25	213642.3			1068.2			59.8			537.3			49.5			1		
01/29/23 9:26	237286.2			311.7			60.83			174.16			55.93			1		
01/29/23 9:27	261315.2			35.2			56.05			21.63			56.76			1		
01/29/23 9:28	287731.7			3.5			55.22			2.34			61.57			1		
01/29/23 9:29	314610.3			2.1			39.67			1.58			48.38			1		
01/29/23 9:30	337330			1.9			19.64			1.54			25.67			1		
01/29/23 9:31	341488.8			1.9			14.4			1.53			19.06			1		
01/29/23 9:32	341488.8			2			11.89			1.6			15.73			1		
01/29/23 9:33	343953.3			2			10.59			1.62			14.11			1		
01/29/23 9:34	351038.8			1.9			10.06			1.58			13.69			1		
01/29/23 9:35	349960.6			1.8			9.46			1.5			12.83			1		
01/29/23 9:36	348420.3			1.7			8.85			1.42			11.95			1		
01/29/23 9:37	347342			1.6			8.5			1.35			11.45			1		
01/29/23 9:38	344569.5			1.5			8.19			1.21			10.94			1		
01/29/23 9:39	344415.4			1.4			7.84			1.14			10.46			1		
01/29/23 9:40	345416.6			1.3			7.57			1.07			10.14			1		
01/29/23 9:41	344492.4			1.3			7.4			1.07			9.88			1		
01/29/23 9:42	344338.4			1.2			7.31			1			9.75			1		
01/29/23 9:43	354889.6			1.2			7.31			1.03			10.05			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:44	373450.4			1.2			7.22			1.08			10.45			1		
01/29/23 9:45	386081.1			1.3			5.99			1.14			8.96			1		
01/29/23 9:46	397017.3			1.2			4.27			1.1			6.56			1		
01/29/23 9:47	411650.4			1.1			4.36			1.06			6.95			1		
01/29/23 9:48	418735.8			1			4.63			0.98			7.51			1		
01/29/23 9:49	436911.6			1			4.63			1.03			7.84			1		
01/29/23 9:50	444536.2			1			4.43			1.06			7.62			1		
01/29/23 9:51	443149.9			0.9			4.7			0.96			8.07			1		
01/29/23 9:52	439992.3			0.9			5.07			0.96			8.65			1		
01/29/23 9:53	441532.6			0.9			5.17			0.94			8.85			1		
01/29/23 9:54	460478.5			1			5.07			1.1			9.05			1		
01/29/23 9:55	461325.7			1			4.7			1.1			8.41			1		
01/29/23 9:56	456781.7			0.9			4.98			0.99			8.81			1		
01/29/23 9:57	455626.5			0.9			3.96			0.99			7			1		
01/29/23 9:58	458707.1			0.9			2.3			1			4.1			1		
01/29/23 9:59	475034.5			0.9			2.12			1.03			3.9			1		
01/29/23 10:00	473648.2			0.9			2.12			1.03			3.89			1		
01/29/23 10:01	476420.8			0.8			2.77			0.93			5.11			1		
01/29/23 10:02	477576			0.8			3.13			0.93			5.8			1		
01/29/23 10:03	478269.2			0.9			3.32			1.04			6.15			1		
01/29/23 10:04	493133.3			0.9			3.04			1.07			5.81			1		
01/29/23 10:05	489436.5			0.8			3.04			0.96			5.77			1		
01/29/23 10:06	487434.1			0.9			2.49			1.06			4.71			1		
01/29/23 10:07	489898.6			1.2			1.82			1.39			3.51			1		
01/29/23 10:08	489898.6			2.2			1.79			2.58			3.4			1		
01/29/23 10:09	480117.6			3.1			1.97			3.54			3.66			1		
01/29/23 10:10	471029.7			3			2.15			3.37			3.92			0		
01/29/23 10:11	468257.1			2.5			2.23			2.76			4.06			0		
01/29/23 10:12	471029.7			2.3			2.27			2.52			4.14			0		
01/29/23 10:13	488127.2			1.9			2.12			2.23			4.01			0		
01/29/23 10:14	491361.9			1.4			2.21			1.6			4.21			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 12:32	320925.6			1			1.27			0.75			1.58			0		
01/29/23 12:33	308449			1			1.36			0.73			1.63			0		
01/29/23 12:34	289888.1			1			1.48			0.69			1.66			0		
01/29/23 12:35	288809.9			0.9			2.25			0.64			2.52			0		
01/29/23 12:36	290350.2			0.9			2.28			0.59			2.57			0		
01/29/23 12:37	288963.9			0.8			2			0.52			2.24			1		
01/29/23 12:38	274561.9			0.7			1.62			0.43			1.72			1		
01/29/23 12:39	253074.5			0.7			1.97			0.41			1.93			1		
01/29/23 12:40	228506.4			0.6			6.01			0.34			5.32			1		
01/29/23 12:41	200472.6			2.9			9.6			1.37			7.46			1		
01/29/23 12:42	176135.5			184.5			12.32			76.52			8.41			1		
01/29/23 12:43	156419.4			909.9			14.16			335.26			8.59			1		
01/29/23 12:44	94652.6			1791.5			20.65			399.42			7.58			1		
01/29/23 12:45	0			0			28.16			0			0			0		
01/29/23 12:46	0			0			0.2			0			0			0		
01/29/23 12:47	0			0			0.1			0			0			0		
01/29/23 12:48	0			0			0.1			0			0			0		
01/29/23 12:49	0			0			0.1			0			0			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 16:04	6854.4			0			0			0			0			0		
02/03/23 16:05	5160.1			0			0			0			0			0		
02/03/23 16:06	6623.4			0			0			0			0			0		
02/03/23 16:07	5314.1			0			0			0			0			0		
02/03/23 16:08	16635.4			0			0			0			0			0		
02/03/23 16:09	1155.2			0.3			0			0			0			1		
02/03/23 16:10	20255.2			0.3			0			0			0			1		
02/03/23 16:11	36351.5			106.2			17.7			9.06			2.48			1		
02/03/23 16:12	47518.9			1432.2			11.31			159.66			2.07			1		
02/03/23 16:13	59841.4			1014.8			15.96			142.66			3.69			1		
02/03/23 16:14	72780.1			680.1			21.43			116.15			6.02			1		
02/03/23 16:15	108207.4			491.4			24.72			124.84			10.34			1		
02/03/23 16:16	148794.9			364			22.57			127.19			12.98			1		
02/03/23 16:17	173131.9			231.9			45.98			94.28			30.76			1		
02/03/23 16:18	224116.5			1079.3			46.65			568.01			40.4			1		
02/03/23 16:19	254768.8			317.6			58.02			190.04			57.13			1		
02/03/23 16:20	275871.2			14.3			53.1			9.29			56.61			1		
02/03/23 16:21	304521.2			2.3			47.92			1.63			56.39			1		
02/03/23 16:22	322619.9			2.1			22.76			1.56			28.37			1		
02/03/23 16:23	321541.7			2.1			18.57			1.57			23.07			1		
02/03/23 16:24	321926.8			2.3			18.13			1.71			22.56			1		
02/03/23 16:25	335096.5			2.4			17.96			1.87			23.26			1		
02/03/23 16:26	336713.8			2.1			15.23			1.67			19.82			1		
02/03/23 16:27	332169.9			1.9			12.49			1.49			16.04			1		
02/03/23 16:28	334480.4			1.8			11.18			1.38			14.46			1		
02/03/23 16:29	332863			1.7			9.86			1.31			12.69			1		
02/03/23 16:30	332246.9			1.7			9.16			1.31			11.76			1		
02/03/23 16:31	332940.1			1.6			8.76			1.26			11.27			1		
02/03/23 16:32	332786			1.5			8.13			1.19			10.46			1		
02/03/23 16:33	332323.9			1.4			7.51			1.12			9.64			1		
02/03/23 16:34	332477.9			1.3			7.33			1.05			9.42			1		
02/03/23 16:35	332786			1.3			7.24			1.05			9.31			1		
02/03/23 16:36	333017.1			1.3			6.97			0.98			8.97			1		
02/03/23 16:37	332092.9			1.3			6.88			0.98			8.83			1		
02/03/23 16:38	332632			1.2			6.79			0.91			8.73			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 16:39	330013.4			1.2			6.7			0.9			8.55			1		
02/03/23 16:40	327240.9			1.2			6.7			0.89			8.48			1		
02/03/23 16:41	329012.2			1.2			6.72			0.91			8.54			1		
02/03/23 16:42	329551.3			1.1			6.72			0.84			8.55			1		
02/03/23 16:43	330860.6			1.1			6.81			0.85			8.71			1		
02/03/23 16:44	329089.3			1.1			6.81			0.84			8.66			1		
02/03/23 16:45	311298.6			1.1			6.99			0.8			8.41			1		
02/03/23 16:46	295818.3			1			7.62			0.69			8.72			1		
02/03/23 16:47	292198.6			1			10.77			0.71			12.16			1		
02/03/23 16:48	292814.7			0.9			11.61			0.64			13.14			1		
02/03/23 16:49	291736.5			0.8			12.36			0.58			13.94			1		
02/03/23 16:50	290812.3			0.7			13.11			0.51			14.74			1		
02/03/23 16:51	291736.5			0.7			13.39			0.51			15.1			1		
02/03/23 16:52	292660.7			0.7			13.58			0.51			15.36			1		
02/03/23 16:53	292429.7			0.7			13.11			0.51			14.82			1		
02/03/23 16:54	291274.4			0.7			8.33			0.51			9.38			1		
02/03/23 16:55	292198.6			0.7			4.78			0.51			5.39			1		
02/03/23 16:56	292891.8			0.7			3.47			0.52			3.92			1		
02/03/23 16:57	291274.4			0.7			2.53			0.51			2.85			1		
02/03/23 16:58	290658.3			0.7			2.25			0.51			2.52			1		
02/03/23 16:59	295202.2			0.7			1.87			0.52			2.14			1		
02/03/23 17:00	294663.1			0.8			1.52			0.53			1.73			1		
02/03/23 17:01	296434.5			0.7			1.31			0.52			1.5			1		
02/03/23 17:02	296742.5			0.7			1.03			0.52			1.18			1		
02/03/23 17:03	295972.4			0.7			0.94			0.52			1.07			0		
02/03/23 17:04	297204.6			0.7			0.84			0.52			0.97			0		
02/03/23 17:05	295433.3			0.7			0.84			0.52			0.96			0		
02/03/23 17:06	294278			0.8			0.75			0.58			0.85			0		
02/03/23 17:07	293122.8			0.8			0.75			0.58			0.85			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 8:10	287038.5			1.1			2.13			0.72			2.36			0		
02/08/23 8:11	288963.9			0.9			2.22			0.59			2.48			0		
02/08/23 8:12	290273.2			0.8			1.97			0.54			2.21			0		
02/08/23 8:13	291582.5			0.8			1.74			0.53			1.96			0		
02/08/23 8:14	291351.4			0.8			1.64			0.53			1.85			0		
02/08/23 8:15	291967.6			0.8			1.55			0.53			1.75			1		
02/08/23 8:16	276872.4			0.8			1.45			0.5			1.55			1		
02/08/23 8:17	252304.3			0.8			2.8			0.47			2.73			1		
02/08/23 8:18	227813.3			0.8			7.08			0.4			6.23			1		
02/08/23 8:19	203476.2			4.6			10.15			2.2			7.98			1		
02/08/23 8:20	178369			272.1			12.59			113.94			8.68			1		
02/08/23 8:21	159885.2			1073			14.52			402.81			8.97			1		
02/08/23 8:22	104125.6			1716.4			20.73			419.56			8.34			1		
02/08/23 8:23	0			0			27.45			0			0			0		
02/08/23 8:24	0			0			17.7			0			0			0		
02/08/23 8:25	0			0			0.2			0			0			0		
02/08/23 8:26	0			0			0.1			0			0			0		
02/08/23 8:27	0			0			0.1			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 15:52	0			0			0			0			0			0		
02/08/23 15:53	0			0			0			0			0			0		
02/08/23 15:54	0			0			0			0			0			0		
02/08/23 15:55	0			0			0			0			0			0		
02/08/23 15:56	0			0			0			0			0			0		
02/08/23 15:57	7701.6			0.2			0			0			0			1		
02/08/23 15:58	24799.1			0.5			0			0			0			1		
02/08/23 15:59	37044.7			44.7			10.11			3.89			1.45			1		
02/08/23 16:00	51369.7			1185.1			7.47			142.99			1.48			1		
02/08/23 16:01	62382.9			750.6			11.14			109.89			2.69			1		
02/08/23 16:02	75398.6			473.8			14.46			83.89			4.21			1		
02/08/23 16:03	117680.4			363.6			18.82			100.42			8.56			1		
02/08/23 16:04	153492.8			240.4			22.62			86.65			13.41			1		
02/08/23 16:05	162426.7			200.2			37.37			76.37			23.46			1		
02/08/23 16:06	179139.2			1668.8			36.69			701.9			25.4			1		
02/08/23 16:07	201011.7			1456.8			39.61			687.74			30.78			1		
02/08/23 16:08	226427			536.9			40.56			285.43			35.49			1		
02/08/23 16:09	248684.6			68.2			42.71			39.85			41.05			1		
02/08/23 16:10	268939.8			5.2			44.42			3.29			46.17			1		
02/08/23 16:11	297435.7			1.9			41.72			1.32			47.95			1		
02/08/23 16:12	322928			1.6			19.25			1.25			24.02			1		
02/08/23 16:13	338408.2			1.5			12.68			1.19			16.58			1		
02/08/23 16:14	342259			1.6			9.46			1.26			12.51			1		
02/08/23 16:15	340102.5			1.6			9.16			1.27			12.04			1		
02/08/23 16:16	335250.5			1.5			8.81			1.18			11.41			1		
02/08/23 16:17	336097.7			1.4			8.54			1.11			11.1			1		
02/08/23 16:18	336174.7			1.3			8.28			1.04			10.75			1		
02/08/23 16:19	335173.5			1.3			8.31			0.98			10.77			1		
02/08/23 16:20	338870.3			1.2			8.22			0.92			10.77			1		
02/08/23 16:21	332400.9			1.2			8.31			0.91			10.68			1		
02/08/23 16:22	314841.3			1.1			8.31			0.79			10.12			1		
02/08/23 16:23	310759.4			1.1			8.62			0.79			10.36			1		
02/08/23 16:24	305522.4			1			9.96			0.73			11.76			1		
02/08/23 16:25	300516.3			0.9			10.97			0.65			12.74			1		
02/08/23 16:26	295356.3			0.9			9.83			0.65			11.22			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/08/23 16:27	292198.6			0.9			5.24			0.64			5.92			1		
02/08/23 16:28	292583.7			0.8			4.4			0.58			4.98			1		
02/08/23 16:29	291736.5			0.8			5.53			0.58			6.23			1		
02/08/23 16:30	291505.5			0.8			6.65			0.58			7.49			1		
02/08/23 16:31	292891.8			0.7			6.18			0.52			7			1		
02/08/23 16:32	291043.3			0.7			4.03			0.51			4.53			1		
02/08/23 16:33	291120.4			0.8			2.66			0.52			3			1		
02/08/23 16:34	290273.2			0.8			2			0.52			2.24			1		
02/08/23 16:35	290812.3			0.9			1.62			0.58			1.82			1		
02/08/23 16:36	292506.7			0.9			1.43			0.59			1.61			1		
02/08/23 16:37	290427.2			0.9			1.33			0.58			1.5			1		
02/08/23 16:38	291890.5			0.8			1.24			0.52			1.4			0		
02/08/23 16:39	290504.3			0.8			1.14			0.52			1.28			0		
02/08/23 16:40	290735.3			0.8			1.14			0.52			1.28			0		
02/08/23 16:41	290889.3			0.8			1.05			0.52			1.18			0		
02/08/23 16:42	289965.1			0.8			1.05			0.52			1.17			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 8:07	290966.3			0.8			1.45			0.53			1.63			0		
02/09/23 8:08	290427.2			0.8			1.45			0.53			1.63			0		
02/09/23 8:09	288809.9			0.8			1.45			0.52			1.62			0		
02/09/23 8:10	291505.5			0.8			1.45			0.53			1.63			0		
02/09/23 8:11	292968.8			0.7			1.55			0.47			1.75			0		
02/09/23 8:12	285190.2			0.8			1.43			0.51			1.57			1		
02/09/23 8:13	264010.8			0.8			1.55			0.48			1.58			1		
02/09/23 8:14	239827.7			0.8			4.37			0.46			4.05			1		
02/09/23 8:15	213257.2			1.2			8.13			0.61			6.7			1		
02/09/23 8:16	189998.4			9.6			10.69			4.28			7.85			1		
02/09/23 8:17	169743.2			535.2			13.2			213.37			8.66			1		
02/09/23 8:18	148178.7			1397.7			16.58			486.19			9.49			1		
02/09/23 8:19	24799.1			1938			21.02			112.79			2.01			1		
02/09/23 8:20	0			0			26.13			0			0			0		
02/09/23 8:21	0			0			0.1			0			0			0		
02/09/23 8:22	0			0			0.1			0			0			0		
02/09/23 8:23	0			0			0.1			0			0			0		
02/09/23 8:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 16:00	0			0			0			0			0			0		
02/09/23 16:01	0			0			0			0			0			0		
02/09/23 16:02	0			0			0			0			0			0		
02/09/23 16:03	0			0			0			0			0			0		
02/09/23 16:04	0			0			0			0			0			0		
02/09/23 16:05	10397.2			0.2			0			0			0			1		
02/09/23 16:06	23489.9			0.2			0			0			0			1		
02/09/23 16:07	37044.7			50.2			9.83			4.37			1.41			1		
02/09/23 16:08	49367.2			1196.5			6.69			138.74			1.28			1		
02/09/23 16:09	60996.6			761.1			10.16			109.04			2.4			1		
02/09/23 16:10	76476.9			467.6			13.28			83.94			3.92			1		
02/09/23 16:11	116063.1			342.2			17.7			93.22			7.94			1		
02/09/23 16:12	151875.5			216.6			20.06			77.25			11.77			1		
02/09/23 16:13	170744.4			196.5			35.6			78.77			23.49			1		
02/09/23 16:14	185608.5			1327.3			34.71			578.49			24.89			1		
02/09/23 16:15	209945.5			928.2			36.49			457.5			29.6			1		
02/09/23 16:16	233589.4			254			39.47			139.29			35.63			1		
02/09/23 16:17	257156.3			23.1			41.67			13.96			41.42			1		
02/09/23 16:18	284497			2.1			43.42			1.41			47.73			1		
02/09/23 16:19	307216.7			1.5			30.01			1.1			35.63			1		
02/09/23 16:20	333479.2			1.5			14.84			1.15			19.13			1		
02/09/23 16:21	342875.1			1.5			10.21			1.21			13.54			1		
02/09/23 16:22	336405.8			1.5			8.76			1.17			11.39			1		
02/09/23 16:23	339255.3			1.5			8.81			1.19			11.55			1		
02/09/23 16:24	334095.3			1.4			8.19			1.11			10.57			1		
02/09/23 16:25	333171.1			1.3			8.13			1.05			10.47			1		
02/09/23 16:26	335789.6			1.3			7.87			0.99			10.21			1		
02/09/23 16:27	336559.8			1.2			7.87			0.92			10.23			1		
02/09/23 16:28	332940.1			1.2			7.87			0.91			10.12			1		
02/09/23 16:29	327548.9			1.2			7.96			0.89			10.07			1		
02/09/23 16:30	307832.8			1.1			7.99			0.79			9.5			1		
02/09/23 16:31	299669.2			1.1			8.39			0.78			9.72			1		
02/09/23 16:32	292891.8			0.9			11.33			0.64			12.82			1		
02/09/23 16:33	295664.3			0.8			11.99			0.59			13.69			1		
02/09/23 16:34	292506.7			0.8			11.89			0.58			13.44			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 16:35	292737.7			0.8			7.68			0.58			8.69			1		
02/09/23 16:36	292121.6			0.8			4.31			0.58			4.86			1		
02/09/23 16:37	293122.8			0.9			4.57			0.59			5.17			1		
02/09/23 16:38	293430.8			0.9			5.71			0.59			6.47			1		
02/09/23 16:39	291197.4			0.8			6.57			0.52			7.39			1		
02/09/23 16:40	292429.7			0.8			5.71			0.52			6.45			1		
02/09/23 16:41	291505.5			0.8			3.62			0.52			4.07			1		
02/09/23 16:42	292583.7			0.8			2.47			0.52			2.8			1		
02/09/23 16:43	292044.6			0.8			1.81			0.52			2.04			1		
02/09/23 16:44	291197.4			0.8			1.52			0.52			1.71			1		
02/09/23 16:45	291351.4			0.8			1.24			0.52			1.39			1		
02/09/23 16:46	291274.4			0.8			1.05			0.52			1.18			0		
02/09/23 16:47	291428.4			0.8			0.86			0.52			0.96			0		
02/09/23 16:48	290581.3			0.8			0.86			0.52			0.96			0		
02/09/23 16:49	291428.4			0.8			0.76			0.52			0.86			0		
02/09/23 16:50	290889.3			0.8			0.76			0.52			0.86			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 23:47	318615.1			0.9			1.09			0.68			1.34			0		
02/09/23 23:48	304290.1			0.9			1.2			0.66			1.41			0		
02/09/23 23:49	290427.2			0.9			1.38			0.63			1.55			0		
02/09/23 23:50	289118			0.9			1.78			0.64			1.99			0		
02/09/23 23:51	288886.9			0.9			2.09			0.58			2.34			0		
02/09/23 23:52	289811.1			0.8			1.9			0.52			2.13			1		
02/09/23 23:53	279645			0.8			1.62			0.5			1.75			1		
02/09/23 23:54	258619.6			0.8			1.74			0.47			1.74			1		
02/09/23 23:55	234975.7			0.7			5.28			0.4			4.79			1		
02/09/23 23:56	209329.4			2.4			9.53			1.17			7.71			1		
02/09/23 23:57	183991.2			87			12.3			37.58			8.75			1		
02/09/23 23:58	163273.9			687.1			14.82			263.48			9.35			1		
02/09/23 23:59	131928.4			1556.3			19.83			482.14			10.11			1		
02/10/23 0:00	0			0			26.35			0			0			0		
02/10/23 0:01	0			0			35.4			0			0			0		
02/10/23 0:02	0			0			0.1			0			0			0		
02/10/23 0:03	0			0			0.1			0			0			0		
02/10/23 0:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/10/23 15:49	0			0			0			0			0			0		
02/10/23 15:50	0			0			0			0			0			0		
02/10/23 15:51	0			0			0			0			0			0		
02/10/23 15:52	0			0			0			0			0			0		
02/10/23 15:53	0			0			0			0			0			0		
02/10/23 15:54	0			0.2			0			0			0			1		
02/10/23 15:55	17174.6			0.2			0			0			0			1		
02/10/23 15:56	33116.9			153.4			53.1			11.92			6.79			1		
02/10/23 15:57	43822.1			1360.4			17.21			140.08			2.92			1		
02/10/23 15:58	57222.9			1070.9			21.02			143.82			4.65			1		
02/10/23 15:59	68313.2			664.2			25.77			106.61			6.81			1		
02/10/23 16:00	96501			501.5			28.62			113.61			10.67			1		
02/10/23 16:01	145406.2			355.3			39.15			121.3			22			1		
02/10/23 16:02	152029.5			225.3			51.84			80.42			30.46			1		
02/10/23 16:03	163042.8			1010			53.1			386.62			33.45			1		
02/10/23 16:04	182065.8			1964.3			53.65			839.84			37.75			1		
02/10/23 16:05	201396.8			1347.8			53.26			637.5			41.46			1		
02/10/23 16:06	227813.3			470.4			53.4			251.65			47.01			1		
02/10/23 16:07	252073.3			55.2			52.33			32.64			50.97			1		
02/10/23 16:08	278489.8			5.4			50.55			3.56			54.4			1		
02/10/23 16:09	307062.7			2.3			41.71			1.64			49.5			1		
02/10/23 16:10	332246.9			2.1			18.54			1.61			23.81			1		
02/10/23 16:11	344030.3			2			12.42			1.64			16.51			1		
02/10/23 16:12	337869.1			2.1			9.8			1.65			12.8			1		
02/10/23 16:13	344569.5			1.9			9.16			1.57			12.2			1		
02/10/23 16:14	338331.2			1.8			8.89			1.4			11.63			1		
02/10/23 16:15	344030.3			1.6			8.28			1.28			11.01			1		
02/10/23 16:16	334249.3			1.5			8.05			1.19			10.39			1		
02/10/23 16:17	341488.8			1.4			7.69			1.15			10.14			1		
02/10/23 16:18	337484			1.3			7.42			1.06			9.68			1		
02/10/23 16:19	341334.8			1.3			7.24			1.07			9.55			1		
02/10/23 16:20	334480.4			1.3			7.15			1.05			9.24			1		
02/10/23 16:21	339717.5			1.3			7.15			1			9.39			1		
02/10/23 16:22	332709			1.2			7.15			0.91			9.19			1		
02/10/23 16:23	337407			1.2			7.24			0.92			9.44			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/10/23 16:24	333633.2			1.1			7.44			0.85			9.6			1		
02/10/23 16:25	338331.2			1.1			7.53			0.87			9.85			1		
02/10/23 16:26	331938.8			1.1			7.62			0.85			9.78			1		
02/10/23 16:27	335866.7			1.1			7.81			0.86			10.13			1		
02/10/23 16:28	335327.5			1.1			7.81			0.86			10.12			1		
02/10/23 16:29	336020.7			1			7.99			0.79			10.37			1		
02/10/23 16:30	334172.3			1			7.99			0.78			10.31			1		
02/10/23 16:31	335250.5			1.1			7.99			0.86			10.35			1		
02/10/23 16:32	326162.7			1			5.81			0.76			7.32			1		
02/10/23 16:33	305753.4			1			3.36			0.72			3.97			1		
02/10/23 16:34	292198.6			1			3.96			0.7			4.48			1		
02/10/23 16:35	291197.4			1			6.66			0.65			7.5			1		
02/10/23 16:36	290350.2			0.9			5.9			0.58			6.62			1		
02/10/23 16:37	291274.4			0.9			3.43			0.59			3.86			1		
02/10/23 16:38	290966.3			0.8			3.24			0.52			3.64			1		
02/10/23 16:39	291736.5			0.8			3.9			0.52			4.4			1		
02/10/23 16:40	290735.3			0.8			4.57			0.52			5.13			1		
02/10/23 16:41	290350.2			0.8			5.23			0.52			5.87			1		
02/10/23 16:42	290966.3			0.8			4.76			0.52			5.35			1		
02/10/23 16:43	295279.3			0.8			3.62			0.53			4.13			1		
02/10/23 16:44	299592.1			0.8			2.76			0.54			3.2			1		
02/10/23 16:45	302133.7			0.8			2.57			0.54			3			1		
02/10/23 16:46	299361.1			0.7			2.25			0.53			2.6			1		
02/10/23 16:47	299284.1			0.8			2.34			0.59			2.71			1		
02/10/23 16:48	298359.9			0.8			2.62			0.59			3.02			1		
02/10/23 16:49	297204.6			0.8			2.81			0.59			3.23			1		
02/10/23 16:50	297974.8			0.7			3			0.52			3.45			1		
02/10/23 16:51	299438.1			0.8			2.9			0.59			3.36			1		
02/10/23 16:52	297666.7			0.8			2.34			0.59			2.69			1		
02/10/23 16:53	314225.2			0.8			2.06			0.62			2.5			1		
02/10/23 16:54	331938.8			0.8			1.87			0.66			2.4			1		
02/10/23 16:55	354350.5			0.8			1.48			0.69			2.02			1		
02/10/23 16:56	357662.2			0.9			1.25			0.75			1.73			1		
02/10/23 16:57	356429.9			1			1.34			0.82			1.85			0		
02/10/23 16:58	360588.8			1.1			1.25			0.91			1.74			0		
02/10/23 16:59	363438.4			1.1			1.61			0.92			2.26			0		
02/10/23 17:00	356044.8			1.1			1.52			0.9			2.09			0		
02/10/23 17:01	351269.8			1.1			1.43			0.88			1.94			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 8:21	291274.4			1			2.09			0.65			2.36			0		
02/12/23 8:22	293353.8			1			2.03			0.67			2.3			0		
02/12/23 8:23	294971.2			0.9			1.71			0.59			1.95			0		
02/12/23 8:24	295048.2			0.9			1.33			0.59			1.52			0		
02/12/23 8:25	294894.2			0.9			1.24			0.59			1.41			0		
02/12/23 8:26	295895.4			0.9			1.24			0.6			1.41			1		
02/12/23 8:27	281262.3			0.9			1.24			0.57			1.34			1		
02/12/23 8:28	258311.6			0.9			1.64			0.53			1.64			1		
02/12/23 8:29	234898.7			0.9			5.18			0.51			4.7			1		
02/12/23 8:30	207404			2.2			9.42			1.05			7.55			1		
02/12/23 8:31	182835.9			121.7			12.31			52.26			8.7			1		
02/12/23 8:32	164275.1			733.8			13.96			283			8.86			1		
02/12/23 8:33	132159.4			1625			19.05			504.17			9.73			1		
02/12/23 8:34	0			2089.8			24.82			0			0			1		
02/12/23 8:35	0			0			35.4			0			0			0		
02/12/23 8:36	0			0			0.1			0			0			0		
02/12/23 8:37	0			0			0.1			0			0			0		
02/12/23 8:38	0			0			0.1			0			0			0		
02/12/23 8:39	0			0			0.1			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:25	0			0			0			0			0			0		
02/12/23 15:26	0			0			0			0			0			0		
02/12/23 15:27	0			0			0			0			0			0		
02/12/23 15:28	0			0			0			0			0			0		
02/12/23 15:29	0			0			0			0			0			0		
02/12/23 15:30	5622.2			0.2			0			0			0			1		
02/12/23 15:31	20486.2			0.2			0			0			0			1		
02/12/23 15:32	34657.2			92.4			11.8			7.53			1.58			1		
02/12/23 15:33	48135			1008.9			6.74			114.05			1.25			1		
02/12/23 15:34	59764.4			666			10.41			93.47			2.4			1		
02/12/23 15:35	71855.9			373.2			12.69			62.98			3.52			1		
02/12/23 15:36	109131.6			259.6			16.58			66.54			6.99			1		
02/12/23 15:37	149257			177.5			20.9			62.22			12.06			1		
02/12/23 15:38	150489.2			136.5			35.99			48.24			20.94			1		
02/12/23 15:39	169897.2			1609.7			35.97			642.12			23.61			1		
02/12/23 15:40	188766.1			1547.7			39.39			685.97			28.73			1		
02/12/23 15:41	213257.2			625.6			41.77			313.24			34.42			1		
02/12/23 15:42	239904.8			103.9			43.58			58.55			40.41			1		
02/12/23 15:43	261700.3			7.5			46.12			4.59			46.64			1		
02/12/23 15:44	288501.8			1.8			45.27			1.24			50.46			1		
02/12/23 15:45	315919.5			1.6			23.5			1.17			28.69			1		
02/12/23 15:46	334557.4			1.5			13.32			1.19			17.22			1		
02/12/23 15:47	336097.7			1.6			9.77			1.25			12.7			1		
02/12/23 15:48	336944.9			1.6			9.25			1.25			12.04			1		
02/12/23 15:49	334865.4			1.5			9.03			1.2			11.68			1		
02/12/23 15:50	337252.9			1.4			8.94			1.13			11.65			1		
02/12/23 15:51	332940.1			1.3			8.67			1.05			11.16			1		
02/12/23 15:52	331707.8			1.3			8.62			0.99			11.05			1		
02/12/23 15:53	321002.6			1.2			8.44			0.89			10.47			1		
02/12/23 15:54	311914.7			1.2			8.26			0.86			9.96			1		
02/12/23 15:55	304598.2			1.1			8.57			0.79			10.09			1		
02/12/23 15:56	298590.9			1			9.18			0.72			10.59			1		
02/12/23 15:57	293738.9			1			10.3			0.71			11.69			1		
02/12/23 15:58	293122.8			1			6.19			0.66			7.01			1		
02/12/23 15:59	290504.3			0.9			3.24			0.58			3.63			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 16:00	293584.9			0.9			2.28			0.59			2.59			1		
02/12/23 16:01	290658.3			0.9			1.71			0.58			1.92			1		
02/12/23 16:02	291813.5			0.9			1.52			0.59			1.72			1		
02/12/23 16:03	289657.1			0.9			1.33			0.58			1.49			1		
02/12/23 16:04	290350.2			0.9			1.24			0.58			1.39			0		
02/12/23 16:05	290119.2			0.9			1.24			0.58			1.39			0		
02/12/23 16:06	289349			0.9			1.24			0.58			1.38			0		
02/12/23 16:07	290581.3			0.9			1.24			0.58			1.39			0		
02/12/23 16:08	291351.4			0.9			1.24			0.59			1.39			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 6:48	508459.4			0.7			1.42			1			3.49			0		
02/15/23 6:49	514774.8			0.7			1.4			1.14			3.57			0		
02/15/23 6:50	509768.7			0.6			1.49			0.99			3.8			0		
02/15/23 6:51	510230.8			0.6			1.55			0.86			3.91			0		
02/15/23 6:52	506842.1			0.6			1.56			0.87			3.92			0		
02/15/23 6:53	216414.9			0.6			1.49			0.4			1.73			1		
02/15/23 6:54	0			0			1.86			0			0			0		
02/15/23 6:55	0			0			0			0			0			0		
02/15/23 6:56	0			0			0			0			0			0		
02/15/23 6:57	0			0			0			0			0			0		
02/15/23 6:58	0			0			0			0			0			0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 7:24	0			0			0			0			0			0		
02/15/23 7:25	0			0			0			0			0			0		
02/15/23 7:26	0			0			0			0			0			0		
02/15/23 7:27	0			0			0			0			0			0		
02/15/23 7:28	0			0			0			0			0			0		
02/15/23 7:29	10320.1			0.3			0			0			0			1		
02/15/23 7:30	25723.3			0.2			0			0			0			1		
02/15/23 7:31	37660.8			39.3			0.98			3.48			0.14			1		
02/15/23 7:32	48982.2			303			0.84			34.86			0.16			1		
02/15/23 7:33	63769.2			262.2			1.11			39.26			0.27			1		
02/15/23 7:34	81636.9			227.5			1.64			43.59			0.52			1		
02/15/23 7:35	127846.5			213.6			4.04			64.13			1.99			1		
02/15/23 7:36	156419.4			188.5			9.75			69.26			5.89			1		
02/15/23 7:37	184299.2			428.2			17.7			185.27			12.6			1		
02/15/23 7:38	186455.7			1298.3			25.34			568.47			18.26			1		
02/15/23 7:39	208636.3			1074			28.22			526.24			22.76			1		
02/15/23 7:40	230277.8			467.7			32.89			252.95			29.28			1		
02/15/23 7:41	254922.9			90.4			34.86			54.1			34.34			1		
02/15/23 7:42	276641.4			7.6			32.99			4.93			35.27			1		
02/15/23 7:43	309758.3			1.7			29.83			1.27			35.7			1		
02/15/23 7:44	333633.2			1.5			11.41			1.16			14.71			1		
02/15/23 7:45	354658.6			1.3			6.88			1.12			9.43			1		
02/15/23 7:46	370831.9			1.4			5.21			1.21			7.46			1		
02/15/23 7:47	391703.3			1.5			5.64			1.34			8.54			1		
02/15/23 7:48	408800.8			1.5			5.12			1.42			8.09			1		
02/15/23 7:49	429595.1			1.4			4.58			1.42			7.6			1		
02/15/23 7:50	455549.5			1.3			4.47			1.43			7.87			1		
02/15/23 7:51	476497.8			1.2			4.47			1.3			8.23			1		
02/15/23 7:52	482967.2			1.1			4.81			1.24			8.98			1		
02/15/23 7:53	494211.5			1.1			5.54			1.26			10.57			1		
02/15/23 7:54	495597.8			1			4.36			1.16			8.34			1		
02/15/23 7:55	500449.8			1.1			2.54			1.28			4.92			1		
02/15/23 7:56	493826.4			1			2.45			1.16			4.68			1		
02/15/23 7:57	500988.9			1			3			1.17			5.8			1		
02/15/23 7:58	498216.3			1			3.45			1.17			6.64			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 7:59	493826.4			1			3.9			1.16			7.45			1		
02/15/23 8:00	473879.3			1			3.9			1.11			7.15			1		
02/15/23 8:01	447000.7			1			2.77			1.03			4.79			1		
02/15/23 8:02	430134.2			1.1			2.11			1.07			3.51			1		
02/15/23 8:03	433985			1.1			1.67			1.08			2.81			1		
02/15/23 8:04	444921.3			1.1			1.7			1.12			2.92			1		
02/15/23 8:05	448926.1			1.1			1.72			1.15			2.99			1		
02/15/23 8:06	447924.9			1			1.97			1.03			3.4			0		
02/15/23 8:07	444228.1			1			2.23			1.03			3.84			0		
02/15/23 8:08	452237.8			1.1			2.5			1.14			4.37			0		
02/15/23 8:09	469643.4			1			2.54			1.1			4.61			0		
02/15/23 8:10	475573.6			1			2.18			1.12			4			0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 23:04	289118			1			1.33			0.65			1.49			0		
02/20/23 23:05	286114.3			1			1.33			0.64			1.47			0		
02/20/23 23:06	288193.8			1			1.33			0.64			1.48			0		
02/20/23 23:07	287962.7			1			1.43			0.64			1.59			0		
02/20/23 23:08	288193.8			1			1.43			0.64			1.59			0		
02/20/23 23:09	287808.7			1			1.43			0.64			1.59			1		
02/20/23 23:10	271250.3			1			1.43			0.61			1.5			1		
02/20/23 23:11	248376.5			1			2.13			0.56			2.04			1		
02/20/23 23:12	225887.8			0.9			6.95			0.5			6.07			1		
02/20/23 23:13	199240.3			3			10.76			1.41			8.28			1		
02/20/23 23:14	175750.5			147.1			13.47			60.73			9.15			1		
02/20/23 23:15	156881.5			852.3			16.23			314.01			9.84			1		
02/20/23 23:16	89492.6			1697			20.57			356.7			7.11			1		
02/20/23 23:17	0			0			25.57			0			0			0		
02/20/23 23:18	0			0			11.8			0			0			0		
02/20/23 23:19	0			0			0.1			0			0			0		
02/20/23 23:20	0			0			0.1			0			0			0		
02/20/23 23:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 16:04	0			0			0			0			0			0		
02/22/23 16:05	0			0			0			0			0			0		
02/22/23 16:06	0			0			0			0			0			0		
02/22/23 16:07	0			0			0			0			0			0		
02/22/23 16:08	0			0			0			0			0			0		
02/22/23 16:09	8009.7			0.3			0			0			0			1		
02/22/23 16:10	22488.7			0.3			0			0			0			1		
02/22/23 16:11	34965.3			64.9			26.55			5.33			3.59			1		
02/22/23 16:12	49290.2			1478.9			15.24			171.15			2.9			1		
02/22/23 16:13	60457.5			1069			18.44			151.71			4.31			1		
02/22/23 16:14	74474.4			681			22.05			119.05			6.34			1		
02/22/23 16:15	111596.1			532.8			25.96			139.65			11.2			1		
02/22/23 16:16	155649.3			384.5			34.12			140.56			20.52			1		
02/22/23 16:17	155110.2			249.9			49.52			91.02			29.68			1		
02/22/23 16:18	172823.8			1417.7			48.15			575.36			32.16			1		
02/22/23 16:19	192925			1881.2			53.28			852.31			39.73			1		
02/22/23 16:20	217955.2			217955.2			58.53			503.32			49.29			1		
02/22/23 16:21	243216.4			253.3			59.82			144.64			56.22			1		
02/22/23 16:22	264472.8			22.7			58.26			14.12			59.54			1		
02/22/23 16:23	290658.3			3.1			55.44			2.13			62.27			1		
02/22/23 16:24	319539.3			2.2			36.8			1.65			45.44			1		
02/22/23 16:25	340795.7			2			19.7			1.6			25.94			1		
02/22/23 16:26	345647.7			2.1			15.01			1.69			20.05			1		
02/22/23 16:27	350037.6			2.2			12.48			1.83			16.89			1		
02/22/23 16:28	351500.9			2.3			11.54			1.86			15.67			1		
02/22/23 16:29	350576.7			2.2			10.59			1.79			14.34			1		
02/22/23 16:30	350037.6			2.1			9.63			1.71			13.03			1		
02/22/23 16:31	346957			1.9			8.94			1.56			11.98			1		
02/22/23 16:32	346494.8			1.7			8.59			1.41			11.5			1		
02/22/23 16:33	344492.4			1.6			8.24			1.33			10.97			1		
02/22/23 16:34	342875.1			1.6			8.01			1.28			10.62			1		
02/22/23 16:35	342336			1.5			7.75			1.2			10.25			1		
02/22/23 16:36	343722.3			1.4			7.57			1.14			10.06			1		
02/22/23 16:37	345647.7			1.4			7.49			1.14			10			1		
02/22/23 16:38	346648.9			1.4			7.49			1.15			10.03			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 16:39	343491.3			1.3			7.57			1.07			10.05			1		
02/22/23 16:40	344415.4			1.3			7.66			1.07			10.2			1		
02/22/23 16:41	343722.3			1.3			7.66			1.07			10.18			1		
02/22/23 16:42	341950.9			1.3			7.75			1.06			10.24			1		
02/22/23 16:43	350576.7			1.2			7.75			1.02			10.5			1		
02/22/23 16:44	362437.2			1.2			7.75			1.05			10.85			1		
02/22/23 16:45	363746.4			1.2			7.49			1.05			10.52			1		
02/22/23 16:46	346957			1.3			7.69			1.02			10.31			1		
02/22/23 16:47	342027.9			1.2			8.1			0.99			10.71			1		
02/22/23 16:48	356275.9			1.2			7.84			1.03			10.79			1		
02/22/23 16:49	382461.3			1.3			7.96			1.12			11.76			1		
02/22/23 16:50	393012.5			1.3			6.44			1.16			9.78			1		
02/22/23 16:51	398480.6			1.2			5.17			1.1			7.97			1		
02/22/23 16:52	409879			1.1			5.81			1.05			9.2			1		
02/22/23 16:53	409648			1.1			6.08			1.05			9.63			1		
02/22/23 16:54	427823.7			1.1			5.72			1.09			9.45			1		
02/22/23 16:55	420969.3			1.1			5.36			1.08			8.71			1		
02/22/23 16:56	425590.3			1.1			3.81			1.09			6.27			1		
02/22/23 16:57	427438.7			1.1			2.9			1.09			4.8			1		
02/22/23 16:58	413267.7			1.1			3.18			1.06			5.07			1		
02/22/23 16:59	403178.6			1.1			3.81			1.03			5.94			1		
02/22/23 17:00	386158.1			1.1			4.02			0.97			6			1		
02/22/23 17:01	373219.4			1.1			3.08			1			4.45			1		
02/22/23 17:02	365979.9			1.2			2.11			1.06			2.99			1		
02/22/23 17:03	363669.4			1.2			1.85			1.05			2.6			1		
02/22/23 17:04	348882.3			1.2			2.03			1.01			2.73			1		
02/22/23 17:05	346571.9			1.2			3.08			1			4.13			1		
02/22/23 17:06	350114.6			1.2			2.99			1.01			4.05			1		
02/22/23 17:07	353657.3			1.2			2.2			1.02			3.01			1		
02/22/23 17:08	358740.4			1.2			2.03			1.04			2.81			1		
02/22/23 17:09	383539.5			1.2			1.85			1.11			2.74			1		
02/22/23 17:10	391626.2			1.2			1.61			1.07			2.44			1		
02/22/23 17:11	386466.2			1.2			1.43			1.05			2.14			1		
02/22/23 17:12	384232.7			1.2			1.52			1.05			2.26			0		
02/22/23 17:13	383847.6			1.2			1.61			1.05			2.39			0		
02/22/23 17:14	402716.5			1.2			1.7			1.1			2.64			0		
02/22/23 17:15	426129.4			1.1			1.63			1.09			2.69			0		
02/22/23 17:16	421508.4			1.1			1.72			1.08			2.81			0		

CT2 SUSD EVENT 17

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 13:03	289118			0.8			1.26			0.53			1.4			0		
02/23/23 13:04	289888.1			0.8			1.26			0.53			1.41			0		
02/23/23 13:05	290196.2			0.8			1.26			0.53			1.41			0		
02/23/23 13:06	292814.7			0.9			1.24			0.59			1.4			0		
02/23/23 13:07	292198.6			0.9			1.33			0.59			1.5			0		
02/23/23 13:08	284805.1			0.9			1.33			0.57			1.47			1		
02/23/23 13:09	261700.3			0.8			1.45			0.48			1.47			1		
02/23/23 13:10	240674.9			0.8			4.37			0.46			4.07			1		
02/23/23 13:11	212641.1			1.8			8.57			0.89			7.05			1		
02/23/23 13:12	187533.9			11.2			11.67			4.92			8.46			1		
02/23/23 13:13	167894.8			565			13.63			222.72			8.84			1		
02/23/23 13:14	146792.4			1444.7			17.06			498.02			9.68			1		
02/23/23 13:15	11783.4			2013.2			21.76			55.88			0.99			1		
02/23/23 13:16	0			0			23.6			0			0			0		
02/23/23 13:17	0			0			0.1			0			0			0		
02/23/23 13:18	0			0			0.1			0			0			0		
02/23/23 13:19	0			0			0.1			0			0			0		
02/23/23 13:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 17:22	0			0			0			0			0			0		
02/27/23 17:23	0			0			0			0			0			0		
02/27/23 17:24	0			0			0			0			0			0		
02/27/23 17:25	0			0			0			0			0			0		
02/27/23 17:26	43591			0			0			0			0			0		
02/27/23 17:27	5699.2			0.3			0			0			0			1		
02/27/23 17:28	23104.8			0.3			0			0			0			1		
02/27/23 17:29	36274.5			59			17.7			5.02			2.48			1		
02/27/23 17:30	49136.2			1437.8			13.16			165.75			2.5			1		
02/27/23 17:31	61535.8			1126.9			18.07			162.96			4.3			1		
02/27/23 17:32	75321.6			703.3			20.81			124.38			6.06			1		
02/27/23 17:33	110672			548.7			23.6			142.6			10.09			1		
02/27/23 17:34	153415.8			403.3			24.11			145.24			14.29			1		
02/27/23 17:35	175134.3			268			43.62			110.21			29.52			1		
02/27/23 17:36	203322.2			1163.4			41.3			555.48			32.45			1		
02/27/23 17:37	232665.3			703.6			50.38			384.46			45.3			1		
02/27/23 17:38	257387.4			106.6			54.41			64.42			54.12			1		
02/27/23 17:39	278720.8			7.3			55.07			4.77			59.32			1		
02/27/23 17:40	303288.9			1.9			52.47			1.35			61.5			1		
02/27/23 17:41	308988.1			1.7			27.22			1.24			32.5			1		
02/27/23 17:42	328473.1			1.6			22.33			1.26			28.35			1		
02/27/23 17:43	349036.4			1.7			19.99			1.37			26.96			1		
02/27/23 17:44	358894.4			1.8			15.22			1.51			21.11			1		
02/27/23 17:45	353657.3			1.8			13.85			1.49			18.93			1		
02/27/23 17:46	350961.8			1.8			12.23			1.48			16.59			1		
02/27/23 17:47	350191.6			1.8			10.6			1.48			14.35			1		
02/27/23 17:48	348959.4			1.7			9.54			1.42			12.87			1		
02/27/23 17:49	348805.3			1.6			8.94			1.35			12.05			1		
02/27/23 17:50	347111			1.6			8.16			1.27			10.94			1		
02/27/23 17:51	345878.7			1.5			7.72			1.2			10.32			1		
02/27/23 17:52	344184.4			1.4			7.4			1.14			9.84			1		
02/27/23 17:53	347419.1			1.3			7.13			1.08			9.58			1		
02/27/23 17:54	345185.6			1.3			7.04			1.07			9.4			1		
02/27/23 17:55	346032.8			1.3			7.13			1.07			9.54			1		
02/27/23 17:56	347419.1			1.3			7.22			1.08			9.69			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 17:57	345339.6			1.2			7.22			1			9.64			1		
02/27/23 17:58	347419.1			1.2			7.31			1.01			9.81			1		
02/27/23 17:59	364593.6			1.2			7.31			1.06			10.3			1		
02/27/23 18:00	391164.1			1.2			6.43			1.13			9.72			1		
02/27/23 18:01	402177.4			1.2			4.72			1.11			7.34			1		
02/27/23 18:02	378225.4			1.1			5.26			0.97			7.7			1		
02/27/23 18:03	371602.1			1.1			6.08			1			8.73			1		
02/27/23 18:04	382615.3			1.1			6.25			1.03			9.25			1		
02/27/23 18:05	396324.2			1.3			5.54			1.16			8.49			1		
02/27/23 18:06	414808			1.2			5.08			1.15			8.15			1		
02/27/23 18:07	408338.7			1.1			5.54			1.04			8.74			1		
02/27/23 18:08	411727.4			1			5.63			0.97			8.95			1		
02/27/23 18:09	408338.7			1			5.72			0.96			9.02			1		
02/27/23 18:10	418581.8			1.1			5.17			1.07			8.37			1		
02/27/23 18:11	400868.1			1.1			3.18			1.03			4.92			1		
02/27/23 18:12	414885			1.1			2.41			1.05			3.87			1		
02/27/23 18:13	400560.1			1.1			2.59			1.01			4.01			1		
02/27/23 18:14	383231.5			1.1			3.31			0.97			4.9			1		
02/27/23 18:15	367828.3			1.1			4.05			0.91			5.76			1		
02/27/23 18:16	370754.9			1.1			2.99			1			4.29			1		
02/27/23 18:17	370908.9			1.1			1.85			1			2.65			1		
02/27/23 18:18	375915			1.1			1.76			1.01			2.56			1		
02/27/23 18:19	389700.8			1.1			1.94			1.05			2.92			1		
02/27/23 18:20	390933.1			1.2			2.15			1.07			3.24			1		
02/27/23 18:21	390162.9			1.2			2.5			1.06			3.77			0		
02/27/23 18:22	393474.6			1.1			2.82			1.06			4.29			0		
02/27/23 18:23	390933.1			1.1			2.73			1.05			4.12			0		
02/27/23 18:24	409339.9			1.2			2.15			1.12			3.39			0		
02/27/23 18:25	424820.1			1.1			1.82			1.09			2.98			0		

CT2 SUSD EVENT 19

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/27/23 23:04	293430.8			0.7			1.45			0.47			1.65			0		
02/27/23 23:05	291813.5			0.8			1.43			0.52			1.61			0		
02/27/23 23:06	294740.1			0.8			1.33			0.53			1.52			0		
02/27/23 23:07	293276.8			0.8			1.33			0.52			1.51			0		
02/27/23 23:08	294432.1			0.8			1.24			0.53			1.41			0		
02/27/23 23:09	293738.9			0.9			1.24			0.59			1.4			1		
02/27/23 23:10	280646.2			0.9			1.33			0.56			1.44			1		
02/27/23 23:11	256001.1			0.9			1.84			0.52			1.82			1		
02/27/23 23:12	233435.4			0.8			6.01			0.46			5.42			1		
02/27/23 23:13	208636.3			2.7			9.53			1.33			7.69			1		
02/27/23 23:14	184530.3			128.3			12.44			55.58			8.87			1		
02/27/23 23:15	163813			736.5			14.25			283.23			9.02			1		
02/27/23 23:16	134392.9			1574			18.52			496.79			9.62			1		
02/27/23 23:17	0			1958			23.98			0			0			1		
02/27/23 23:18	0			0			47.2			0			0			0		
02/27/23 23:19	0			0			0.1			0			0			0		
02/27/23 23:20	0			0			0.1			0			0			0		
02/27/23 23:21	0			0			0.1			0			0			0		
02/27/23 23:22	0			0			0.1			0			0			0		

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 16:49	0			0			0			0			0			0		
02/28/23 16:50	0			0			0			0			0			0		
02/28/23 16:51	0			0			0			0			0			0		
02/28/23 16:52	0			0			0			0			0			0		
02/28/23 16:53	0			0			0			0			0			0		
02/28/23 16:54	9550			0.3			0			0			0			1		
02/28/23 16:55	27263.7			1.2			0			0			0			1		
02/28/23 16:56	41434.6			1374.7			18.44			133.86			2.95			1		
02/28/23 16:57	53911.2			1373.9			14.95			174.07			3.12			1		
02/28/23 16:58	65001.5			903.4			19.67			137.91			4.94			1		
02/28/23 16:59	83793.4			618.3			25.37			121.66			8.22			1		
02/28/23 17:00	129925.9			509.4			27.53			155.41			13.83			1		
02/28/23 17:01	155495.3			359.2			44.84			131.14			26.94			1		
02/28/23 17:02	157728.7			422.7			55.38			156.6			33.77			1		
02/28/23 17:03	169435.1			1892.2			53.29			752.66			34.89			1		
02/28/23 17:04	189228.3			1857.6			56.14			825.4			41.05			1		
02/28/23 17:05	211562.9			1120.2			56.61			556.42			46.28			1		
02/28/23 17:06	237440.3			375.2			56.33			209.22			51.69			1		
02/28/23 17:07	259466.8			48.2			53.6			29.37			53.75			1		
02/28/23 17:08	286114.3			4.2			50.87			2.84			56.24			1		
02/28/23 17:09	310836.5			2.2			38.04			1.63			45.7			1		
02/28/23 17:10	335789.6			2.1			17.98			1.67			23.32			1		
02/28/23 17:11	351346.9			2.1			13.97			1.72			18.97			1		
02/28/23 17:12	353195.3			2.2			11.12			1.84			15.17			1		
02/28/23 17:13	351269.8			2.2			10.18			1.83			13.81			1		
02/28/23 17:14	351963			2.1			9.32			1.7			12.68			1		
02/28/23 17:15	349344.4			1.9			8.72			1.54			11.78			1		
02/28/23 17:16	349190.4			1.7			8.5			1.42			11.47			1		
02/28/23 17:17	347650.1			1.6			7.98			1.27			10.72			1		
02/28/23 17:18	346186.8			1.5			7.81			1.2			10.45			1		
02/28/23 17:19	344338.4			1.5			7.64			1.19			10.16			1		
02/28/23 17:20	343799.3			1.4			7.49			1.14			9.94			1		
02/28/23 17:21	343029.1			1.3			7.31			1.06			9.69			1		
02/28/23 17:22	343645.3			1.3			7.22			1.07			9.59			1		
02/28/23 17:23	344723.5			1.2			7.22			1			9.62			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 17:24	345185.6			1.2			7.22			1			9.63			1		
02/28/23 17:25	345185.6			1.2			7.4			1			9.87			1		
02/28/23 17:26	343722.3			1.2			7.49			1			9.94			1		
02/28/23 17:27	344107.4			1.2			7.49			1			9.95			1		
02/28/23 17:28	343876.3			1.2			7.57			1			10.06			1		
02/28/23 17:29	343106.2			1.2			7.66			0.99			10.16			1		
02/28/23 17:30	345185.6			1.1			7.66			0.93			10.22			1		
02/28/23 17:31	347650.1			1.1			7.75			0.93			10.41			1		
02/28/23 17:32	336328.8			1.1			8.01			0.9			10.42			1		
02/28/23 17:33	328627.2			1.1			7.93			0.88			10.06			1		
02/28/23 17:34	325931.6			1.2			8.05			0.89			10.13			1		
02/28/23 17:35	319693.3			1.1			8.22			0.81			10.16			1		
02/28/23 17:36	312607.8			1.1			6.54			0.8			7.89			1		
02/28/23 17:37	306523.6			1			3.72			0.72			4.41			1		
02/28/23 17:38	301363.5			1			3.69			0.72			4.29			1		
02/28/23 17:39	295510.3			0.9			4.79			0.64			5.47			1		
02/28/23 17:40	292660.7			0.9			6.09			0.64			6.88			1		
02/28/23 17:41	292429.7			0.8			5.53			0.58			6.25			1		
02/28/23 17:42	292121.6			0.8			3.65			0.58			4.12			1		
02/28/23 17:43	303519.9			0.8			2.66			0.54			3.13			1		
02/28/23 17:44	326701.8			0.8			2.15			0.65			2.72			1		
02/28/23 17:45	349113.4			0.8			1.27			0.67			1.71			1		
02/28/23 17:46	364208.5			0.9			1.07			0.76			1.51			1		
02/28/23 17:47	358355.3			1.1			1.06			0.89			1.46			1		
02/28/23 17:48	362591.2			1.1			1.14			0.97			1.6			0		
02/28/23 17:49	381614.2			1.1			1.14			1.03			1.69			0		
02/28/23 17:50	399943.9			1.2			1.07			1.09			1.66			0		
02/28/23 17:51	413267.7			1.1			0.91			1.06			1.45			0		
02/28/23 17:52	416271.3			1			0.91			0.98			1.46			0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/01/23 8:07	290273.2			0.8			1.35			0.53			1.52			0		
03/01/23 8:08	290581.3			0.8			1.45			0.53			1.63			0		
03/01/23 8:09	290273.2			0.8			1.45			0.53			1.63			0		
03/01/23 8:10	291120.4			0.8			1.45			0.53			1.63			0		
03/01/23 8:11	291043.3			0.8			1.45			0.53			1.63			0		
03/01/23 8:12	282186.5			0.8			1.45			0.51			1.58			1		
03/01/23 8:13	259081.7			0.8			1.87			0.48			1.87			1		
03/01/23 8:14	236208			0.7			5.69			0.41			5.19			1		
03/01/23 8:15	209252.4			2.5			8.74			1.23			7.06			1		
03/01/23 8:16	186147.6			104.3			11.54			45.59			8.31			1		
03/01/23 8:17	166893.6			585.4			13.81			229.45			8.91			1		
03/01/23 8:18	144636			1301			15.9			441.77			8.88			1		
03/01/23 8:19	0			1757.1			22.46			0			0			1		
03/01/23 8:20	0			0			36.88			0			0			0		
03/01/23 8:21	0			0			0.1			0			0			0		
03/01/23 8:22	0			0			0.1			0			0			0		
03/01/23 8:23	0			0			0.1			0			0			0		
03/01/23 8:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:05	0			0			0			0			0			0		
03/03/23 15:06	0			0			0			0			0			0		
03/03/23 15:07	0			0			0			0			0			0		
03/03/23 15:08	0			0			0			0			0			0		
03/03/23 15:09	0			0			0			0			0			0		
03/03/23 15:10	6392.3			0.4			0			0			0			1		
03/03/23 15:11	23027.8			0.4			0			0			0			1		
03/03/23 15:12	36582.6			73.8			23.6			6.34			3.34			1		
03/03/23 15:13	48520.1			1275.8			14.07			145.36			2.64			1		
03/03/23 15:14	60611.6			921.1			17.7			131.13			4.15			1		
03/03/23 15:15	74397.4			601.2			21.74			104.97			6.25			1		
03/03/23 15:16	109516.7			460.2			24.72			118.36			10.47			1		
03/03/23 15:17	151952.5			327.3			34.63			116.79			20.34			1		
03/03/23 15:18	159808.1			206.3			49.44			77.4			30.52			1		
03/03/23 15:19	171591.6			1259.1			43.14			507.32			28.61			1		
03/03/23 15:20	191769.8			1556.2			48.59			700.88			36.01			1		
03/03/23 15:21	215105.6			859.8			58.69			434.41			48.8			1		
03/03/23 15:22	240520.9			221.6			63.94			125.15			59.43			1		
03/03/23 15:23	261623.3			20.8			63.18			12.76			63.87			1		
03/03/23 15:24	288039.8			3			60.89			2.03			67.79			1		
03/03/23 15:25	314841.3			2.1			37.4			1.55			45.51			1		
03/03/23 15:26	338023.1			1.9			20			1.54			26.13			1		
03/03/23 15:27	344646.5			2			14.23			1.61			18.95			1		
03/03/23 15:28	344646.5			2.1			12.23			1.69			16.29			1		
03/03/23 15:29	349036.4			2			11.02			1.64			14.86			1		
03/03/23 15:30	350499.7			1.9			9.63			1.57			13.05			1		
03/03/23 15:31	349575.5			1.8			9.28			1.5			12.54			1		
03/03/23 15:32	347111			1.8			8.37			1.44			11.22			1		
03/03/23 15:33	352887.2			1.7			7.57			1.39			10.33			1		
03/03/23 15:34	346879.9			1.6			7.49			1.29			10.03			1		
03/03/23 15:35	346186.8			1.5			6.69			1.22			8.95			1		
03/03/23 15:36	344261.4			1.4			6.52			1.14			8.67			1		
03/03/23 15:37	342952.1			1.4			6.43			1.13			8.52			1		
03/03/23 15:38	341257.8			1.3			6.44			1.07			8.49			1		
03/03/23 15:39	343029.1			1.3			6.26			1.08			8.29			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:40	343645.3			1.3			6.35			1.08			8.43			1		
03/03/23 15:41	342952.1			1.3			6.35			1.01			8.41			1		
03/03/23 15:42	343183.2			1.3			6.44			1.01			8.54			1		
03/03/23 15:43	342490			1.2			6.53			0.93			8.64			1		
03/03/23 15:44	342104.9			1.2			6.53			0.93			8.63			1		
03/03/23 15:45	343029.1			1.2			6.62			0.94			8.77			1		
03/03/23 15:46	342336			1.2			6.62			0.93			8.75			1		
03/03/23 15:47	341642.8			1.2			6.7			0.93			8.85			1		
03/03/23 15:48	343722.3			1.2			6.88			0.94			9.14			1		
03/03/23 15:49	343491.3			1.2			7.15			0.94			9.49			1		
03/03/23 15:50	336559.8			1.2			7.24			0.92			9.42			1		
03/03/23 15:51	322311.8			1.2			7.24			0.88			9.02			1		
03/03/23 15:52	317690.9			1.2			7.26			0.88			8.92			1		
03/03/23 15:53	310682.4			1.1			7.01			0.81			8.41			1		
03/03/23 15:54	304675.2			1			4.61			0.73			5.43			1		
03/03/23 15:55	296511.5			1			3.56			0.72			4.08			1		
03/03/23 15:56	291736.5			0.9			4.31			0.64			4.86			1		
03/03/23 15:57	291505.5			1			5.52			0.65			6.22			1		
03/03/23 15:58	290735.3			0.9			4.76			0.58			5.35			1		
03/03/23 15:59	290812.3			0.9			3.24			0.58			3.64			1		
03/03/23 16:00	290504.3			0.9			2.85			0.58			3.2			1		
03/03/23 16:01	293199.8			0.9			2.66			0.59			3.02			1		
03/03/23 16:02	293584.9			0.9			2.85			0.59			3.24			1		
03/03/23 16:03	292891.8			0.9			3.14			0.59			3.55			1		
03/03/23 16:04	293892.9			0.9			3.24			0.59			3.67			1		
03/03/23 16:05	292044.6			0.8			3.09			0.58			3.49			1		
03/03/23 16:06	290889.3			0.9			2.95			0.58			3.32			1		
03/03/23 16:07	291274.4			0.9			2.66			0.59			3			1		
03/03/23 16:08	290812.3			0.9			2.38			0.58			2.67			1		
03/03/23 16:09	291428.4			0.9			2.09			0.59			2.36			1		
03/03/23 16:10	291043.3			0.9			1.9			0.59			2.14			1		
03/03/23 16:11	293122.8			0.9			1.81			0.59			2.05			1		
03/03/23 16:12	293430.8			0.9			1.71			0.59			1.94			1		
03/03/23 16:13	294355			0.9			1.71			0.59			1.95			0		
03/03/23 16:14	295048.2			0.9			1.62			0.59			1.84			0		
03/03/23 16:15	292968.8			0.9			1.62			0.59			1.83			0		
03/03/23 16:16	292814.7			0.9			1.62			0.59			1.83			0		
03/03/23 16:17	290042.2			0.9			1.62			0.58			1.81			0		

CT2 SUSD EVENT 23

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 22:48	289811.1			0.8			1.52			0.52			1.71			0		
03/03/23 22:49	289888.1			0.8			1.43			0.52			1.6			0		
03/03/23 22:50	289965.1			0.8			1.33			0.52			1.49			0		
03/03/23 22:51	289272			0.9			1.33			0.58			1.49			0		
03/03/23 22:52	289195			0.9			1.33			0.58			1.49			0		
03/03/23 22:53	282494.6			0.9			1.33			0.57			1.45			1		
03/03/23 22:54	260160			0.9			1.52			0.52			1.53			1		
03/03/23 22:55	236593.1			0.8			4.98			0.45			4.56			1		
03/03/23 22:56	209945.5			1.6			9.02			0.77			7.31			1		
03/03/23 22:57	185300.4			9.4			12.18			4.1			8.72			1		
03/03/23 22:58	165892.4			511.8			14.47			199.32			9.27			1		
03/03/23 22:59	145945.3			1246.8			18.82			427.29			10.61			1		
03/03/23 23:00	12476.6			1727			24.71			50.64			1.19			1		
03/03/23 23:01	0			0			36.58			0			0			0		
03/03/23 23:02	0			0			0.2			0			0			0		
03/03/23 23:03	0			0			0.2			0			0			0		
03/03/23 23:04	0			0			0.1			0			0			0		
03/03/23 23:05	0			0			0.1			0			0			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 16:52	0			0			0			0			0			0		
03/04/23 16:53	0			0			0			0			0			0		
03/04/23 16:54	0			0			0			0			0			0		
03/04/23 16:55	0			0			0			0			0			0		
03/04/23 16:56	0			0			0			0			0			0		
03/04/23 16:57	17867.7			0.3			0			0			0			1		
03/04/23 16:58	29112			1.2			0.1			0			0			1		
03/04/23 16:59	42743.9			1282.3			18.36			128.59			3.03			1		
03/04/23 17:00	54450.3			1182.4			17.7			151.12			3.72			1		
03/04/23 17:01	66310.8			743.4			23.93			115.82			6.14			1		
03/04/23 17:02	88953.4			523.6			27.44			109.36			9.43			1		
03/04/23 17:03	136780.4			423.4			36.8			136			19.46			1		
03/04/23 17:04	161502.5			284.3			50.15			107.82			31.3			1		
03/04/23 17:05	196005.7			557			59.18			256.35			44.83			1		
03/04/23 17:06	221960			784.4			62.35			408.75			53.47			1		
03/04/23 17:07	246990.2			148.3			60.34			86.01			57.6			1		
03/04/23 17:08	269478.9			10.6			57.82			6.72			60.22			1		
03/04/23 17:09	296434.5			1.8			54.07			1.27			61.94			1		
03/04/23 17:10	320848.5			1.6			27.93			1.19			34.63			1		
03/04/23 17:11	339640.4			1.5			17.79			1.21			23.35			1		
03/04/23 17:12	341950.9			1.7			13			1.37			17.17			1		
03/04/23 17:13	342182			1.9			11.71			1.53			15.49			1		
03/04/23 17:14	338870.3			1.8			10.5			1.45			13.75			1		
03/04/23 17:15	338100.1			1.8			9.54			1.45			12.47			1		
03/04/23 17:16	337175.9			1.7			8.89			1.32			11.59			1		
03/04/23 17:17	336482.8			1.6			8.72			1.25			11.34			1		
03/04/23 17:18	336636.8			1.4			8.01			1.11			10.42			1		
03/04/23 17:19	335943.7			1.3			7.66			1.04			9.95			1		
03/04/23 17:20	336790.8			1.3			7.69			1.06			10.01			1		
03/04/23 17:21	333941.3			1.3			7.6			1.05			9.81			1		
03/04/23 17:22	333710.2			1.3			7.51			1.05			9.68			1		
03/04/23 17:23	333017.1			1.3			7.33			0.98			9.43			1		
03/04/23 17:24	333325.1			1.3			7.42			0.98			9.56			1		
03/04/23 17:25	332555			1.3			7.42			0.98			9.54			1		
03/04/23 17:26	330475.5			1.3			7.33			0.97			9.36			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 17:27	331245.7			1.3			7.24			0.97			9.27			1		
03/04/23 17:28	330552.6			1.2			7.24			0.9			9.25			1		
03/04/23 17:29	314071.1			1.2			7.33			0.86			8.9			1		
03/04/23 17:30	302210.7			1.2			8.08			0.84			9.43			1		
03/04/23 17:31	293276.8			1.1			10.05			0.76			11.39			1		
03/04/23 17:32	292352.6			1			11.71			0.71			13.23			1		
03/04/23 17:33	291505.5			0.9			12.36			0.64			13.93			1		
03/04/23 17:34	290273.2			0.9			12.83			0.64			14.39			1		
03/04/23 17:35	288732.9			0.9			13.2			0.63			14.73			1		
03/04/23 17:36	290889.3			0.9			13.49			0.64			15.16			1		
03/04/23 17:37	291659.5			0.9			13.39			0.64			15.1			1		
03/04/23 17:38	291197.4			0.9			8.9			0.64			10.01			1		
03/04/23 17:39	290889.3			0.8			5.06			0.58			5.68			1		
03/04/23 17:40	290735.3			0.8			3.28			0.58			3.68			1		
03/04/23 17:41	290504.3			0.8			2.43			0.57			2.73			1		
03/04/23 17:42	291043.3			0.9			2			0.59			2.25			1		
03/04/23 17:43	290504.3			0.9			1.71			0.58			1.92			1		
03/04/23 17:44	290119.2			0.9			1.43			0.58			1.6			1		
03/04/23 17:45	290735.3			0.9			1.24			0.58			1.39			1		
03/04/23 17:46	290581.3			0.9			1.14			0.58			1.28			0		
03/04/23 17:47	289811.1			0.9			1.05			0.58			1.17			0		
03/04/23 17:48	290350.2			0.9			0.95			0.58			1.07			0		
03/04/23 17:49	290504.3			0.9			0.86			0.58			0.96			0		
03/04/23 17:50	290504.3			0.9			0.86			0.58			0.96			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/04/23 22:47	288809.9			0.9			1.71			0.58			1.91			0		
03/04/23 22:48	287808.7			0.8			1.62			0.51			1.8			0		
03/04/23 22:49	288270.8			0.8			1.52			0.52			1.7			0		
03/04/23 22:50	287038.5			0.8			1.43			0.51			1.58			0		
03/04/23 22:51	287500.6			0.8			1.43			0.51			1.59			0		
03/04/23 22:52	284959.1			0.8			1.33			0.51			1.47			1		
03/04/23 22:53	263086.6			0.8			1.43			0.47			1.45			1		
03/04/23 22:54	240443.9			0.8			3.8			0.45			3.53			1		
03/04/23 22:55	213257.2			0.8			7.87			0.38			6.48			1		
03/04/23 22:56	189151.2			6.1			10.96			2.73			8.01			1		
03/04/23 22:57	169666.2			368			13.58			146.63			8.91			1		
03/04/23 22:58	149719			1179.5			18.02			414.79			10.43			1		
03/04/23 22:59	38199.9			1740			22.88			156.18			3.38			1		
03/04/23 23:00	0			0			27.35			0			0			0		
03/04/23 23:01	0			0			5.9			0			0			0		
03/04/23 23:02	0			0			0.1			0			0			0		
03/04/23 23:03	0			0			0.1			0			0			0		
03/04/23 23:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 15:49	0			0			0			0			0			0		
03/05/23 15:50	0			0			0			0			0			0		
03/05/23 15:51	0			0			0			0			0			0		
03/05/23 15:52	0			0			0			0			0			0		
03/05/23 15:53	0			0			0			0			0			0		
03/05/23 15:54	5006			0.3			0			0			0			1		
03/05/23 15:55	21872.5			0.4			0			0			0			1		
03/05/23 15:56	36120.5			159.3			47.2			13.51			6.59			1		
03/05/23 15:57	48212			1290.7			16.79			146.2			3.13			1		
03/05/23 15:58	59995.4			957.6			23.23			134.84			5.38			1		
03/05/23 15:59	73550.3			597.5			27.33			103.25			7.77			1		
03/05/23 16:00	109439.7			482.6			29.21			124.02			12.35			1		
03/05/23 16:01	153107.8			332.7			42.58			119.61			25.19			1		
03/05/23 16:02	177675.8			206.3			58.59			86.08			40.24			1		
03/05/23 16:03	183298			954.5			60.43			410.89			42.81			1		
03/05/23 16:04	171514.6			902.1			56.67			363.27			37.56			1		
03/05/23 16:05	183837.1			1399.4			52.61			603.97			37.37			1		
03/05/23 16:06	206325.8			1115.6			51.82			540.39			41.31			1		
03/05/23 16:07	232203.2			416.3			52.81			227.01			47.39			1		
03/05/23 16:08	255230.9			55.2			51.82			33.05			51.1			1		
03/05/23 16:09	280107.1			5.4			52.52			3.58			56.85			1		
03/05/23 16:10	307832.8			2.5			42.67			1.83			50.76			1		
03/05/23 16:11	331245.7			2.3			19.03			1.78			24.36			1		
03/05/23 16:12	345185.6			2.1			13.56			1.71			18.09			1		
03/05/23 16:13	351500.9			2.2			10.93			1.79			14.85			1		
03/05/23 16:14	350422.7			2.1			10.24			1.71			13.86			1		
03/05/23 16:15	348805.3			2			9.46			1.63			12.75			1		
03/05/23 16:16	347496.1			1.8			8.85			1.49			11.88			1		
03/05/23 16:17	346494.8			1.7			8.63			1.36			11.56			1		
03/05/23 16:18	345955.8			1.6			8.37			1.29			11.18			1		
03/05/23 16:19	344954.5			1.5			8.19			1.21			10.92			1		
03/05/23 16:20	342798.1			1.4			8.01			1.13			10.62			1		
03/05/23 16:21	343106.2			1.4			7.84			1.14			10.39			1		
03/05/23 16:22	341180.8			1.4			7.87			1.15			10.37			1		
03/05/23 16:23	341411.8			1.3			7.87			1.07			10.38			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 16:24	338947.3			1.3			7.87			1.07			10.31			1		
03/05/23 16:25	339563.4			1.3			7.87			1			10.32			1		
03/05/23 16:26	341950.9			1.3			7.78			1			10.28			1		
03/05/23 16:27	341565.8			1.2			7.87			0.93			10.38			1		
03/05/23 16:28	341642.8			1.2			8.05			0.93			10.62			1		
03/05/23 16:29	341257.8			1.3			8.13			1			10.73			1		
03/05/23 16:30	340949.7			1.2			8.22			0.93			10.84			1		
03/05/23 16:31	341488.8			1.2			8.31			0.93			10.97			1		
03/05/23 16:32	323929.2			1.2			8.31			0.88			10.41			1		
03/05/23 16:33	315842.5			1.2			8.62			0.88			10.52			1		
03/05/23 16:34	314533.2			1.1			9.22			0.82			11.2			1		
03/05/23 16:35	304059.1			1			7.01			0.72			8.23			1		
03/05/23 16:36	299669.2			1			3.5			0.71			4.06			1		
03/05/23 16:37	294201			1			2.62			0.71			2.98			1		
03/05/23 16:38	291736.5			0.9			2.34			0.64			2.64			1		
03/05/23 16:39	291659.5			1			2			0.65			2.25			1		
03/05/23 16:40	292506.7			0.9			1.71			0.59			1.94			1		
03/05/23 16:41	291274.4			0.9			1.52			0.59			1.71			1		
03/05/23 16:42	292198.6			0.9			1.33			0.59			1.5			1		
03/05/23 16:43	298667.9			0.9			1.14			0.6			1.32			0		
03/05/23 16:44	320001.4			0.9			1.05			0.64			1.29			0		
03/05/23 16:45	342104.9			0.8			0.83			0.67			1.1			0		
03/05/23 16:46	357123.1			0.9			0.64			0.76			0.88			0		
03/05/23 16:47	357277.1			1.1			0.54			0.9			0.74			0		

CT2 SUSD EVENT 27

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 1:33	289426			0.8			1.74			0.53			1.95			0		
03/06/23 1:34	288578.8			0.8			1.55			0.52			1.73			0		
03/06/23 1:35	289580.1			0.8			1.45			0.53			1.62			0		
03/06/23 1:36	289734.1			0.8			1.45			0.53			1.62			0		
03/06/23 1:37	288732.9			0.8			1.35			0.52			1.51			0		
03/06/23 1:38	281262.3			0.8			1.35			0.51			1.47			1		
03/06/23 1:39	259081.7			0.8			1.77			0.48			1.77			1		
03/06/23 1:40	235976.9			0.8			5.16			0.47			4.71			1		
03/06/23 1:41	208790.3			3.1			7.94			1.5			6.41			1		
03/06/23 1:42	185300.4			117.6			10.39			51.18			7.44			1		
03/06/23 1:43	166046.4			701.5			12.81			273.55			8.22			1		
03/06/23 1:44	146869.5			1427.6			16.23			492.46			9.21			1		
03/06/23 1:45	0			1841.4			22.65			0			0			1		
03/06/23 1:46	0			0			28.03			0			0			0		
03/06/23 1:47	0			0			0.1			0			0			0		
03/06/23 1:48	0			0			0.1			0			0			0		
03/06/23 1:49	0			0			0.1			0			0			0		
03/06/23 1:50	0			0			0.1			0			0			0		

CT2 SUSD EVENT 28

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 13:05	0			0			0			0			0			0		
03/06/23 13:06	0			0			0			0			0			0		
03/06/23 13:07	0			0			0			0			0			0		
03/06/23 13:08	0			0			0			0			0			0		
03/06/23 13:09	0			0			0			0			0			0		
03/06/23 13:10	11167.3			0.3			0			0			0			1		
03/06/23 13:11	24799.1			0.4			0			0			0			1		
03/06/23 13:12	38970.1			51.1			21.63			4.65			3.24			1		
03/06/23 13:13	51369.7			1215.4			15.73			145.83			3.11			1		
03/06/23 13:14	63153.1			876			22.56			129.22			5.48			1		
03/06/23 13:15	77632.1			591.9			27.33			107.31			8.15			1		
03/06/23 13:16	119528.8			470.9			24.72			131.44			11.36			1		
03/06/23 13:17	155880.3			333.6			43.76			121.42			26.21			1		
03/06/23 13:18	171129.5			246			55.85			98.31			36.73			1		
03/06/23 13:19	171668.6			1331.3			53.82			533.71			35.51			1		
03/06/23 13:20	173440			1465.5			50.81			593.43			33.86			1		
03/06/23 13:21	188843.2			1638.3			49.56			722.47			35.97			1		
03/06/23 13:22	213642.3			1064.2			49.43			530.76			40.57			1		
03/06/23 13:23	237902.3			301.6			49.73			167.5			45.45			1		
03/06/23 13:24	259774.9			48.7			48.2			29.54			48.11			1		
03/06/23 13:25	285113.1			5.2			48.33			3.47			52.96			1		
03/06/23 13:26	311837.7			2.7			36.33			1.96			43.53			1		
03/06/23 13:27	336174.7			2.3			17.23			1.84			22.26			1		
03/06/23 13:28	353426.3			2.2			12.15			1.79			16.49			1		
03/06/23 13:29	356198.9			2.3			10.24			1.88			14.01			1		
03/06/23 13:30	356506.9			2.2			9.89			1.81			13.55			1		
03/06/23 13:31	355582.8			2			8.94			1.66			12.21			1		
03/06/23 13:32	354273.5			1.8			8.85	X		1.51			12.05	X		1		
03/06/23 13:33	353041.2			1.6			8.59			1.36			11.65			1		
03/06/23 13:34	352733.2			1.6			7.98			1.29			10.82			1		
03/06/23 13:35	350730.8			1.6			7.93			1.3			10.68			1		
03/06/23 13:36	351192.8			1.4			7.84			1.16			10.58			1		
03/06/23 13:37	350653.7			1.4			7.75			1.15			10.44			1		
03/06/23 13:38	351269.8			1.3			7.75			1.08			10.46			1		
03/06/23 13:39	351192.8			1.3			7.75			1.08			10.46			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 13:40	348728.3			1.3			7.75			1.08			10.38			1		
03/06/23 13:41	348882.3			1.2			7.75			1			10.39			1		
03/06/23 13:42	337869.1			1.2			7.75			0.97			10.06			1		
03/06/23 13:43	315688.5			1.3			7.6			0.92			9.22			1		
03/06/23 13:44	308449			1.2			8.17			0.85			9.68			1		
03/06/23 13:45	304598.2			1.1			10.23			0.79			11.98			1		
03/06/23 13:46	304136.1			1			10.97			0.72			12.82			1		
03/06/23 13:47	304290.1			1			11.8			0.73			13.8			1		
03/06/23 13:48	302133.7			1			11.99			0.73			13.92			1		
03/06/23 13:49	301209.5			0.9			12.17			0.66			14.09			1		
03/06/23 13:50	302518.8			0.9			12.55			0.66			14.59			1		
03/06/23 13:51	301902.6			0.9			12.74			0.66			14.78			1		
03/06/23 13:52	301440.5			0.9			12.92			0.66			14.97			1		
03/06/23 13:53	301286.5			0.9			13.11			0.66			15.18			1		
03/06/23 13:54	299207.1			0.9			13.3			0.65			15.29			1		
03/06/23 13:55	298745			0.9			13.49			0.65			15.48			1		
03/06/23 13:56	298822			0.9			13.77			0.65			15.81			1		
03/06/23 13:57	299130			0.9			13.95			0.65			16.04			1		
03/06/23 13:58	307293.7			0.8			14.14			0.6			16.7			1		
03/06/23 13:59	317305.8			0.9			12.27			0.69			14.96			1		
03/06/23 14:00	318846.1			0.9			5.44			0.69			6.66			1		
03/06/23 14:01	315149.3			0.9			3.69			0.68			4.47			1		
03/06/23 14:02	314379.2			1			4.43			0.74			5.35			1		
03/06/23 14:03	312838.9			1			5.35			0.74			6.43			1		
03/06/23 14:04	311760.7			0.9			6.08			0.67			7.29			1		
03/06/23 14:05	308911.1			0.9			5.07			0.66			6.02			1		
03/06/23 14:06	308757			0.9			3.23			0.66			3.83			1		
03/06/23 14:07	308449			0.9			2.77			0.66			3.28			1		
03/06/23 14:08	308526			0.9			2.58			0.66			3.06			1		
03/06/23 14:09	307986.9			0.9			2.86			0.66			3.38			1		
03/06/23 14:10	308911.1			0.9			3.41			0.66			4.05			1		
03/06/23 14:11	308911.1			0.9			3.41			0.66			4.05			1		
03/06/23 14:12	308294.9			0.9			3.04			0.66			3.6			1		
03/06/23 14:13	318153			0.9			2.4			0.68			2.93			1		
03/06/23 14:14	341026.7			0.9			2.12			0.73			2.78			1		
03/06/23 14:15	362514.2			0.9			1.45			0.77			2.02			1		
03/06/23 14:16	382384.3			1			1.43			0.88			2.1			1		
03/06/23 14:17	401099.2			1.1			1.43			1			2.2			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 14:18	424204			1.1			1.18			1.08			1.92			0		
03/06/23 14:19	446538.6			1			1.11			1.06			1.9			0		
03/06/23 14:20	472107.9			1			1.2			1.12			2.17			0		
03/06/23 14:21	492286.1			1			1.31			1.18			2.48			0		
03/06/23 14:22	495289.7			0.9			1.84			1.07			3.51			0		

CT2 SUSD EVENT 29

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 8:04	290581.3			0.8			1.26			0.52			1.4			0		
03/07/23 8:05	292891.8			0.8			1.26			0.53			1.42			0		
03/07/23 8:06	292814.7			0.8			1.26			0.53			1.41			0		
03/07/23 8:07	292121.6			0.8			1.35			0.53			1.52			0		
03/07/23 8:08	291274.4			0.8			1.35			0.53			1.52			0		
03/07/23 8:09	285498.2			0.8			1.35			0.52			1.49			1		
03/07/23 8:10	265705.1			0.8			1.45			0.48			1.48			1		
03/07/23 8:11	238903.5			0.8			3.87			0.45			3.55			1		
03/07/23 8:12	217416.1			1.6			7.57			0.79			6.32			1		
03/07/23 8:13	190460.5			9			10.2			3.99			7.46			1		
03/07/23 8:14	171591.6			504.9			12.5			202.29			8.24			1		
03/07/23 8:15	149565			1287.5			15.31			449.59			8.8			1		
03/07/23 8:16	0			1838			21.2			0			0			1		
03/07/23 8:17	0			0			18.88			0			0			0		
03/07/23 8:18	0			0			0.1			0			0			0		
03/07/23 8:19	0			0			0.1			0			0			0		
03/07/23 8:20	0			0			0.1			0			0			0		
03/07/23 8:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 30

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 16:43	0			0			0			0			0			0		
03/07/23 16:44	0			0			0			0			0			0		
03/07/23 16:45	0			0			0			0			0			0		
03/07/23 16:46	0			0			0			0			0			0		
03/07/23 16:47	0			0			0			0			0			0		
03/07/23 16:48	3542.7			0.3			0			0			0			1		
03/07/23 16:49	24029			0.3			0			0			0			1		
03/07/23 16:50	37352.7			41.3			10.62			3.61			1.53			1		
03/07/23 16:51	49521.3			1259.2			7.16			145.45			1.36			1		
03/07/23 16:52	61381.7			856.5			11.11			122.71			2.62			1		
03/07/23 16:53	74551.5			549.3			14.28			95.67			4.09			1		
03/07/23 16:54	111904.2			422.3			17.14			110.31			7.37			1		
03/07/23 16:55	155264.2			298.6			22.57			108.21			13.46			1		
03/07/23 16:56	151875.5			196.3			36.82			69.61			21.49			1		
03/07/23 16:57	172900.9			1517.8			35.78			612.59			23.77			1		
03/07/23 16:58	181295.6			1799.1			38.98			761.56			27.15			1		
03/07/23 16:59	211793.9			1211.8			40.15			599.2			32.68			1		
03/07/23 17:00	233127.3			404.9			41.44			220.45			37.13			1		
03/07/23 17:01	252920.5			53			43.61			31.28			42.38			1		
03/07/23 17:02	280107.1			5			43.91			3.27			47.27			1		
03/07/23 17:03	316920.7			2.2			37.88			1.61			46.13			1		
03/07/23 17:04	338870.3			1.9			17.61			1.48			22.92			1		
03/07/23 17:05	340795.7			1.8			12.86			1.4			16.84			1		
03/07/23 17:06	337252.9			1.8			10.24			1.43			13.27			1		
03/07/23 17:07	337561			1.7			9.63			1.37			12.49			1		
03/07/23 17:08	337946.1			1.6			9.2			1.3			11.94			1		
03/07/23 17:09	340333.6			1.6			8.89			1.26			11.63			1		
03/07/23 17:10	341103.8			1.5			8.81			1.19			11.54			1		
03/07/23 17:11	332786			1.4			8.63			1.09			11.04			1		
03/07/23 17:12	336482.8			1.3			8.67			1.05			11.21			1		
03/07/23 17:13	334942.5			1.3			8.85			0.98			11.39			1		
03/07/23 17:14	311452.6			1.3			8.94			0.91			10.7			1		
03/07/23 17:15	300593.3			1.2			10.35			0.83			11.95			1		
03/07/23 17:16	296280.4			1.1			13			0.77			14.8			1		
03/07/23 17:17	295587.3			1			14.42			0.71			16.38			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/07/23 17:18	295741.3			0.9			14.61			0.65			16.6			1		
03/07/23 17:19	294663.1			1			10.09			0.65			11.42			1		
03/07/23 17:20	294894.2			0.9			5.33			0.59			6.04			1		
03/07/23 17:21	295818.3			0.9			3.71			0.59			4.22			1		
03/07/23 17:22	295895.4			0.9			3.81			0.59			4.33			1		
03/07/23 17:23	294894.2			0.9			4.66			0.59			5.28			1		
03/07/23 17:24	293199.8			0.9			5.14			0.59			5.79			1		
03/07/23 17:25	293584.9			0.9			4.76			0.59			5.37			1		
03/07/23 17:26	293584.9			0.9			3.62			0.59			4.08			1		
03/07/23 17:27	295048.2			0.9			2.85			0.59			3.24			1		
03/07/23 17:28	293970			0.9			2.66			0.59			3.01			1		
03/07/23 17:29	293970			0.9			2.57			0.59			2.9			1		
03/07/23 17:30	293970			0.9			2.57			0.59			2.9			1		
03/07/23 17:31	293815.9			0.9			2.57			0.59			2.9			1		
03/07/23 17:32	293276.8			0.9			2.57			0.59			2.9			1		
03/07/23 17:33	292121.6			0.8			2.47			0.52			2.78			1		
03/07/23 17:34	292506.7			0.8			2.38			0.52			2.67			1		
03/07/23 17:35	293507.9			0.8			2.28			0.52			2.58			1		
03/07/23 17:36	292506.7			0.8			2.09			0.52			2.35			1		
03/07/23 17:37	293199.8			0.8			2			0.52			2.25			1		
03/07/23 17:38	294124			0.8			1.9			0.52			2.15			1		
03/07/23 17:39	293430.8			0.8			1.81			0.52			2.04			1		
03/07/23 17:40	292275.6			0.8			1.71			0.52			1.92			0		
03/07/23 17:41	292968.8			0.8			1.71			0.52			1.93			0		
03/07/23 17:42	292583.7			0.8			1.62			0.52			1.82			0		
03/07/23 17:43	295510.3			0.8			1.62			0.53			1.84			0		
03/07/23 17:44	300824.4			0.8			1.62			0.53			1.87			0		

CT2 SUSD EVENT 31

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 11:09	292121.6			0.9			1.52			0.58			1.71			0		
03/08/23 11:10	293199.8			0.9			1.62			0.59			1.82			0		
03/08/23 11:11	293584.9			0.9			1.62			0.59			1.82			0		
03/08/23 11:12	294817.2			0.9			1.62			0.59			1.83			0		
03/08/23 11:13	291890.5			0.8			1.59			0.57			1.79			0		
03/08/23 11:14	282417.6			0.9			1.59			0.62			1.73			1		
03/08/23 11:15	261777.3			0.9			1.84			0.53			1.85			1		
03/08/23 11:16	239673.7			0.9			5.7			0.51			5.25			1		
03/08/23 11:17	212333			0.9			10.35			0.44			8.45			1		
03/08/23 11:18	189151.2			9.1			13.64			4.02			9.92			1		
03/08/23 11:19	167894.8			472.1			17			185.06			10.96			1		
03/08/23 11:20	147793.7			1219.9			20.57			420.79			11.68			1		
03/08/23 11:21	12399.6			1791.9			25.08			51.74			1.19			1		
03/08/23 11:22	0			0			24.44			0			0			0		
03/08/23 11:23	0			0			0.2			0			0			0		
03/08/23 11:24	0			0			0.1			0			0			0		
03/08/23 11:25	0			0			0.1			0			0			0		
03/08/23 11:26	0			0			0.1			0			0			0		

CT2 SUSD EVENT 32

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 18:13	0			0			0			0			0			0		
03/08/23 18:14	0			0			0			0			0			0		
03/08/23 18:15	0			0			0			0			0			0		
03/08/23 18:16	0			0			0			0			0			0		
03/08/23 18:17	0			0			0			0			0			0		
03/08/23 18:18	12630.6			0.1			0			0			0			1		
03/08/23 18:19	27571.7			1.1			0			0			0			1		
03/08/23 18:20	40895.5			1097.4			9.18			104.89			1.44			1		
03/08/23 18:21	52216.8			1132			9.44			138.1			1.9			1		
03/08/23 18:22	64539.4			697.8			12.78			105.13			3.17			1		
03/08/23 18:23	84563.5			471.7			16.82			93.13			5.46			1		
03/08/23 18:24	131389.3			371.4			21.91			113.9			11.06			1		
03/08/23 18:25	163813			239.3			33.51			91.55			21.1			1		
03/08/23 18:26	204862.5			423.7			41.11			202.66			32.36			1		
03/08/23 18:27	234590.7			594			45.65			325.38			41.15			1		
03/08/23 18:28	260082.9			55.2			47.33			33.49			47.3			1		
03/08/23 18:29	286499.4			2.6			46.86			1.75			51.58			1		
03/08/23 18:30	309450.2			1.2			35.91			0.88			42.7			1		
03/08/23 18:31	334942.5			1.1			16.86			0.88			21.69			1		
03/08/23 18:32	348959.4			1.2			12.67			0.99			16.99			1		
03/08/23 18:33	357816.2			1.4			10.59			1.16			14.55			1		
03/08/23 18:34	352502.1			1.5			10.33			1.21			13.99			1		
03/08/23 18:35	350037.6			1.4			9.8			1.13			13.19			1		
03/08/23 18:36	348420.3			1.3			9.2			1.06			12.31			1		
03/08/23 18:37	349267.4			1.2			8.98			1.01			12.05			1		
03/08/23 18:38	348420.3			1.2			8.98		X	1			12.02		X	1		
03/08/23 18:39	348497.3			1.1			8.98		X	0.93			12.03		X	1		
03/08/23 18:40	348574.3			1.1			8.89		X	0.93			11.91		X	1		
03/08/23 18:41	338485.2			1.1			8.89		X	0.83			11.57		X	1		
03/08/23 18:42	330475.5			1.1			8.76			0.83			11.12			1		
03/08/23 18:43	325931.6			1.1			8.58			0.82			10.75			1		
03/08/23 18:44	319539.3			1			8.8			0.74			10.81			1		
03/08/23 18:45	312530.8			0.8			8.99			0.6			10.79			1		
03/08/23 18:46	306215.5			0.9			10.69			0.66			12.58			1		
03/08/23 18:47	300516.3			0.8			11.25			0.58			12.99			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 18:48	297281.7			0.8			6.46			0.59			7.38			1		
03/08/23 18:49	294201			0.7			3.65			0.51			4.13			1		
03/08/23 18:50	294355			0.7			2.72			0.51			3.07			1		
03/08/23 18:51	293353.8			0.7			2.15			0.51			2.43			1		
03/08/23 18:52	294278			0.7			1.97			0.51			2.22			1		
03/08/23 18:53	293353.8			0.7			1.78			0.51			2.01			1		
03/08/23 18:54	292814.7			0.7			1.69			0.51			1.9			1		
03/08/23 18:55	290273.2			0.7			1.69			0.51			1.88			1		
03/08/23 18:56	292891.8			0.8			1.71			0.52			1.93			0		
03/08/23 18:57	291428.4			0.8			1.71			0.52			1.92			0		
03/08/23 18:58	300747.4			0.8			1.71			0.53			1.98			0		
03/08/23 18:59	307755.8			0.7			1.69			0.54			1.99			0		
03/08/23 19:00	308140.9			0.7			1.4			0.54			1.66			0		

CT2 SUSD EVENT 33

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:03	287423.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:04	287577.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:05	287500.6			0.7			1.31			0.44			1.45			0		
03/09/23 23:06	288732.9			0.7			1.31			0.44			1.45			0		
03/09/23 23:07	288270.8			0.7			1.31			0.44			1.45			0		
03/09/23 23:08	281647.4			0.7			1.4			0.49			1.52			1		
03/09/23 23:09	260005.9			0.8			1.52			0.46			1.52			1		
03/09/23 23:10	237363.2			0.7			4.7			0.39			4.29			1		
03/09/23 23:11	208636.3			0.7			9.61			0.32			7.71			1		
03/09/23 23:12	186609.7			8.2			12.29			3.59			8.81			1		
03/09/23 23:13	165122.3			477.8			14.96			184.16			9.49			1		
03/09/23 23:14	144482			1298.6			19.93			438.08			11.07			1		
03/09/23 23:15	0			1935.4			25.69			0			0			1		
03/09/23 23:16	0			0			53.1			0			0			0		
03/09/23 23:17	0			0			0.1			0			0			0		
03/09/23 23:18	0			0			0.1			0			0			0		
03/09/23 23:19	0			0			0.1			0			0			0		
03/09/23 23:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 34

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 15:44	0			0			0			0			0			0		
03/10/23 15:45	0			0			0			0			0			0		
03/10/23 15:46	0			0			0			0			0			0		
03/10/23 15:47	0			0			0			0			0			0		
03/10/23 15:48	0			0			0			0			0			0		
03/10/23 15:49	3696.8			0.1			0			0			0			1		
03/10/23 15:50	22488.7			0.1			0			0			0			1		
03/10/23 15:51	35504.4			49.2			31.47			4.07			4.29			1		
03/10/23 15:52	48366			1238.2			15.59			139.69			2.9			1		
03/10/23 15:53	59918.4			898.9			22.91			125.76			5.27			1		
03/10/23 15:54	73704.3			554.9			26.26			95.52			7.44			1		
03/10/23 15:55	113136.5			440.8			32.03			116.44			13.92			1		
03/10/23 15:56	150797.3			292.1			42.53			102.83			24.65			1		
03/10/23 15:57	154186			215.5			57.23			77.58			33.9			1		
03/10/23 15:58	161887.6			1538.2			52.18			581.57			32.47			1		
03/10/23 15:59	179909.3			1825.6			52.74			766.64			36.45			1		
03/10/23 16:00	202398			1257.7			55.39			594.31			43.08			1		
03/10/23 16:01	227505.2			405.7			53.68			215.48			46.92			1		
03/10/23 16:02	250764			55.2			53.74			32.28			51.77			1		
03/10/23 16:03	274407.9			4.5			52.76			2.91			55.63			1		
03/10/23 16:04	302672.8			2.3			40.58			1.61			47.19			1		
03/10/23 16:05	325546.5			2			19.01			1.49			23.78			1		
03/10/23 16:06	336482.8			1.9			13.12			1.52			16.96			1		
03/10/23 16:07	337638			2			10.5			1.57			13.62			1		
03/10/23 16:08	335866.7			1.9			9.72			1.5			12.54			1		
03/10/23 16:09	333556.2			1.8			9.16			1.37			11.74			1		
03/10/23 16:10	334326.3			1.6			8.54			1.24			10.97			1		
03/10/23 16:11	331476.8			1.4			8.28			1.09			10.54			1		
03/10/23 16:12	331476.8			1.3			7.87			1.04			10.02			1		
03/10/23 16:13	330013.4			1.3			7.78			1.03			9.86			1		
03/10/23 16:14	329551.3			1.3			7.6			0.96			9.62			1		
03/10/23 16:15	328165.1			1.3			7.51			0.96			9.47			1		
03/10/23 16:16	326624.8			1.2			7.33			0.89			9.2			1		
03/10/23 16:17	326393.7			1.2			7.35			0.9			9.22			1		
03/10/23 16:18	325084.4			1.1			7.35			0.83			9.18			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 16:19	328473.1			1.1			7.35			0.84			9.28			1		
03/10/23 16:20	327625.9			1			7.26			0.76			9.14			1		
03/10/23 16:21	325700.5			1			7.35			0.76			9.2			1		
03/10/23 16:22	324930.4			1			7.26			0.76			9.07			1		
03/10/23 16:23	326316.7			1			7.26			0.76			9.11			1		
03/10/23 16:24	315072.3			1			7.35			0.73			8.9			1		
03/10/23 16:25	303288.9			1			7.81			0.71			9.1			1		
03/10/23 16:26	300593.3			0.9			9.13			0.65			10.54			1		
03/10/23 16:27	294894.2			0.8			10.4			0.58			11.78			1		
03/10/23 16:28	290812.3			0.8			11.33			0.57			12.66			1		
03/10/23 16:29	288963.9			0.7			12.27			0.51			13.62			1		
03/10/23 16:30	290196.2			0.8			8.66			0.52			9.66			1		
03/10/23 16:31	290427.2			0.8			4.38			0.52			4.88			1		
03/10/23 16:32	289888.1			0.8			3.52			0.52			3.92			1		
03/10/23 16:33	289503			0.8			4.38			0.51			4.87			1		
03/10/23 16:34	290119.2			0.7			5.33			0.45			5.94			1		
03/10/23 16:35	289272			0.7			5.9			0.45			6.56			1		
03/10/23 16:36	289349			0.7			4.95			0.45			5.5			1		
03/10/23 16:37	289118			0.7			3.52			0.45			3.91			1		
03/10/23 16:38	289349			0.8			2.95			0.51			3.28			1		
03/10/23 16:39	289349			0.7			2.76			0.45			3.07			1		
03/10/23 16:40	287731.7			0.7			2.95			0.45			3.26			1		
03/10/23 16:41	288655.9			0.7			3.33			0.45			3.69			1		
03/10/23 16:42	289195			0.7			3.52			0.45			3.91			1		
03/10/23 16:43	290350.2			0.7			3.33			0.45			3.72			1		
03/10/23 16:44	307139.7			0.7			2.66			0.48			3.14			1		
03/10/23 16:45	328550.1			0.7			1.97			0.5			2.48			1		
03/10/23 16:46	347342			0.7			1.38			0.6			1.85			1		
03/10/23 16:47	349652.5			0.8			1.34			0.66			1.8			1		
03/10/23 16:48	353349.3			0.9			1.43			0.74			1.94			1		
03/10/23 16:49	371140			1			1.52			0.85			2.17			0		
03/10/23 16:50	391164.1			1			1.34			0.9			2.02			0		
03/10/23 16:51	402177.4			0.9			1.18			0.85			1.82			0		
03/10/23 16:52	401407.3			0.9			1.2			0.86			1.85			0		
03/10/23 16:53	409493.9			0.8			1.27			0.78			2			0		

CT2 SUSD EVENT 35

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/10/23 20:39	348112.2			1			1.32			0.79			1.77			0		
03/10/23 20:40	325546.5			1			1.41			0.74			1.76			0		
03/10/23 20:41	311067.5			1			1.61			0.71			1.92			0		
03/10/23 20:42	313224			0.9			1.57			0.67			1.89			0		
03/10/23 20:43	305214.3			0.8			1.48			0.59			1.73			0		
03/10/23 20:44	289888.1			0.8			1.38			0.56			1.54			1		
03/10/23 20:45	275717.2			0.8			1.5			0.54			1.59			1		
03/10/23 20:46	253613.6			0.8			2.28			0.45			2.23			1		
03/10/23 20:47	230893.9			0.6			7.25			0.33			6.43			1		
03/10/23 20:48	203861.3			1.5			15.54			0.7			12.17			1		
03/10/23 20:49	180679.5			10.5			19.71			4.45			13.68			1		
03/10/23 20:50	161117.4			610.4			23.46			229.56			14.52			1		
03/10/23 20:51	139784			1425.8			28.84			465.35			15.49			1		
03/10/23 20:52	0			1896.2			32.93			0			0			1		
03/10/23 20:53	0			0			35.4			0			0			0		
03/10/23 20:54	0			0			0.2			0			0			0		
03/10/23 20:55	0			0			0.2			0			0			0		
03/10/23 20:56	0			0			0.1			0			0			0		
03/10/23 20:57	0			0			0.1			0			0			0		

CT2 SUSD EVENT 36

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 16:54	0			0			0			0			0			0		
03/11/23 16:55	0			0			0			0			0			0		
03/11/23 16:56	0			0			0			0			0			0		
03/11/23 16:57	0			0			0			0			0			0		
03/11/23 16:58	0			0			0			0			0			0		
03/11/23 16:59	4081.8			0.1			0			0			0			1		
03/11/23 17:00	22796.7			0			0			0			0			1		
03/11/23 17:01	36120.5			62.9			29.5			5.31			4.1			1		
03/11/23 17:02	49213.2			1338			14.33			153.65			2.71			1		
03/11/23 17:03	60765.6			971.4			20.13			137.86			4.7			1		
03/11/23 17:04	75090.6			640.9			25.46			112.34			7.34			1		
03/11/23 17:05	114214.7			491.4			27.25			131			11.96			1		
03/11/23 17:06	152337.6			367.1			39.5			130.57			23.13			1		
03/11/23 17:07	158884			257.4			54.73			95.46			33.41			1		
03/11/23 17:08	174518.2			1520			51.63			619.24			34.61			1		
03/11/23 17:09	193618.2			1643.2			55.36			742.61			41.17			1		
03/11/23 17:10	218032.2			826.6			54.16			420.76			45.37			1		
03/11/23 17:11	241445.1			195.9			54.17			110.42			50.25			1		
03/11/23 17:12	265243			17.3			52.26			10.74			53.25			1		
03/11/23 17:13	291813.5			2.5			51.71			1.68			57.98			1		
03/11/23 17:14	317228.8			1.9			28.12			1.38			34.28			1		
03/11/23 17:15	338100.1			1.8			16.98			1.41			22.06			1		
03/11/23 17:16	340256.6			1.9			12.49			1.52			16.34			1		
03/11/23 17:17	337946.1			2			10.93			1.57			14.2			1		
03/11/23 17:18	336482.8			1.9			10.06			1.5			13.01			1		
03/11/23 17:19	333787.2			1.7			9.2			1.35			11.79			1		
03/11/23 17:20	334865.4			1.6			8.89			1.24			11.44			1		
03/11/23 17:21	332709			1.4			8.72			1.09			11.14			1		
03/11/23 17:22	330937.6			1.3			8.37			1.02			10.64			1		
03/11/23 17:23	330167.5			1.2			8.1			0.95			10.28			1		
03/11/23 17:24	329936.4			1.2			8.05			0.9			10.2			1		
03/11/23 17:25	329012.2			1.2			8.05			0.89			10.17			1		
03/11/23 17:26	330475.5			1.1			7.96			0.83			10.1			1		
03/11/23 17:27	331938.8			1.1			7.96			0.83			10.15			1		
03/11/23 17:28	330321.5			1.1			7.87			0.83			9.98			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 17:29	328935.2			1.1			7.87			0.82			9.94			1		
03/11/23 17:30	329012.2			1			7.78			0.76			9.83			1		
03/11/23 17:31	329397.3			1			7.78			0.76			9.84			1		
03/11/23 17:32	328473.1			1			7.69			0.75			9.7			1		
03/11/23 17:33	328011			1			7.78			0.75			9.8			1		
03/11/23 17:34	330937.6			1			7.9			0.77			10.04			1		
03/11/23 17:35	330475.5			1			7.87			0.76			9.99			1		
03/11/23 17:36	333864.3			1			7.87			0.77			10.09			1		
03/11/23 17:37	329936.4			1			8.05			0.76			10.2			1		
03/11/23 17:38	313686.1			1			8.22			0.72			9.91			1		
03/11/23 17:39	310374.4			0.9			8.71			0.66			10.39			1		
03/11/23 17:40	302364.7			0.8			9.22			0.59			10.71			1		
03/11/23 17:41	297127.6			0.8			4.33			0.58			4.95			1		
03/11/23 17:42	292352.6			0.7			3.13			0.5			3.52			1		
03/11/23 17:43	290273.2			0.7			4.31			0.51			4.81			1		
03/11/23 17:44	290196.2			0.7			5.71			0.44			6.37			1		
03/11/23 17:45	289118			0.7			5.53			0.44			6.14			1		
03/11/23 17:46	287577.6			0.7			3.84			0.44			4.24			1		
03/11/23 17:47	288886.9			0.7			2.72			0.44			3.01			1		
03/11/23 17:48	290350.2			0.7			2.43			0.44			2.72			1		
03/11/23 17:49	289349			0.7			2.34			0.44			2.6			1		
03/11/23 17:50	289118			0.7			2.43			0.44			2.71			1		
03/11/23 17:51	289272			0.7			2.62			0.44			2.91			1		
03/11/23 17:52	289118			0.7			2.62			0.44			2.91			1		
03/11/23 17:53	288963.9			0.7			2.62			0.44			2.91			1		
03/11/23 17:54	289040.9			0.7			2.53			0.44			2.81			1		
03/11/23 17:55	289580.1			0.7			2.34			0.44			2.6			1		
03/11/23 17:56	290504.3			0.7			2.15			0.44			2.4			1		
03/11/23 17:57	290119.2			0.7			1.97			0.44			2.19			1		
03/11/23 17:58	291043.3			0.7			1.78			0.45			1.99			1		
03/11/23 17:59	290119.2			0.7			1.69			0.44			1.88			1		
03/11/23 18:00	290273.2			0.7			1.59			0.44			1.78			0		
03/11/23 18:01	288809.9			0.7			1.59			0.44			1.77			0		
03/11/23 18:02	289272			0.7			1.59			0.44			1.77			0		
03/11/23 18:03	289272			1.1	X		1.64	X		0.77	X		1.82	X		0		
03/11/23 18:04	289503			0.6	X		1.61	X		0.43	X		1.79	X		0		

CT2 SUSD EVENT 37

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 7:06	286268.4			0.7			1.4			0.44			1.55			0		
03/12/23 7:07	285960.3			0.6			1.43			0.38			1.57			0		
03/12/23 7:08	287346.6			0.6			1.43			0.38			1.58			0		
03/12/23 7:09	286961.5			0.6			1.43			0.38			1.57			0		
03/12/23 7:10	287654.7			0.6			1.43			0.38			1.58			0		
03/12/23 7:11	286422.4			0.6			1.43			0.38			1.57			1		
03/12/23 7:12	278027.7			0.6			1.43			0.37			1.52			1		
03/12/23 7:13	253459.6			0.6			1.81			0.34			1.76			1		
03/12/23 7:14	230277.8			0.5			6.21			0.28			5.5			1		
03/12/23 7:15	203630.2			1.8			10.02			0.85			7.84			1		
03/12/23 7:16	181603.7			2.1			14.37			0.87			10.02			1		
03/12/23 7:17	159654.1			602.8			17.27			224.67			10.59			1		
03/12/23 7:18	141709.4			1322.4			21.8			437.52			11.87			1		
03/12/23 7:19	10859.3			1777.4			26.65			44.96			1.11			1		
03/12/23 7:20	0			0			29.5			0			0			0		
03/12/23 7:21	0			0			0.1			0			0			0		
03/12/23 7:22	0			0			0.1			0			0			0		
03/12/23 7:23	0			0			0.1			0			0			0		
03/12/23 7:24	0			0			0.1			0			0			0		

CT2 SUSD EVENT 38

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 15:02	0			0			0			0			0			0		
03/12/23 15:03	0			0			0			0			0			0		
03/12/23 15:04	0			0			0			0			0			0		
03/12/23 15:05	0			0			0			0			0			0		
03/12/23 15:06	1848.4			0			0			0			0			0		
03/12/23 15:07	9704			0			0			0			0			1		
03/12/23 15:08	27109.6			0.9			0			0			0			1		
03/12/23 15:09	41357.6			1168.9			9.83			112.77			1.56			1		
03/12/23 15:10	52601.9			1142			10.33			140.34			2.09			1		
03/12/23 15:11	64308.3			698.4			13.66			104.9			3.38			1		
03/12/23 15:12	81791			488.8			17.7			93.33			5.56			1		
03/12/23 15:13	130388			359.1			20.92			109.32			10.48			1		
03/12/23 15:14	151336.4			246.2			33.36			86.97			19.39			1		
03/12/23 15:15	179062.1			562.8			38.45			235.33			26.46			1		
03/12/23 15:16	218879.4			1314			43.9			671.49			36.92			1		
03/12/23 15:17	246297.1			218.2			46.51			125.46			44.02			1		
03/12/23 15:18	269324.8			11.2			45.93			7.06			47.53			1		
03/12/23 15:19	294971.2			1.7			42.99			1.16			48.73			1		
03/12/23 15:20	320232.4			1.4			20.8			1.01			25.59			1		
03/12/23 15:21	331553.8			1.3			13.3			1.02			16.94			1		
03/12/23 15:22	334018.3			1.4			10.06			1.08			12.92			1		
03/12/23 15:23	335866.7			1.4			9.2			1.09			11.87			1		
03/12/23 15:24	336713.8			1.3			8.85			1.02			11.45			1		
03/12/23 15:25	335866.7			1.2			8.63			0.97			11.14			1		
03/12/23 15:26	336405.8			1.1			8.54			0.9			11.04			1		
03/12/23 15:27	335250.5			1.1			8.28			0.9			10.66			1		
03/12/23 15:28	333479.2			1.1			8.01			0.82			10.27			1		
03/12/23 15:29	330860.6			1			7.93			0.75			10.08			1		
03/12/23 15:30	319077.2			1			8.05			0.73			9.86			1		
03/12/23 15:31	309835.3			1			8.31			0.71			9.9			1		
03/12/23 15:32	304829.2			0.9			9.53			0.65			11.16			1		
03/12/23 15:33	298436.9			0.8			10.51			0.58			12.05			1		
03/12/23 15:34	294047			0.8			11.34			0.57			12.81			1		
03/12/23 15:35	293122.8			0.7			11.98			0.5			13.5			1		
03/12/23 15:36	291120.4			0.7			8.33			0.45			9.32			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/12/23 15:37	289657.1			0.6			4.12			0.38			4.59			1		
03/12/23 15:38	290889.3			0.6			3.18			0.38			3.56			1		
03/12/23 15:39	290812.3			0.6			4.03			0.38			4.5			1		
03/12/23 15:40	288270.8			0.7			4.96			0.44			5.5			1		
03/12/23 15:41	289349			0.6			5.81			0.38			6.46			1		
03/12/23 15:42	289580.1			0.6			4.87			0.38			5.42			1		
03/12/23 15:43	290812.3			0.6			3.28			0.38			3.66			1		
03/12/23 15:44	291274.4			0.6			2.53			0.38			2.83			1		
03/12/23 15:45	290504.3			0.6			2.53			0.38			2.82			1		
03/12/23 15:46	290273.2			0.6			2.72			0.38			3.03			1		
03/12/23 15:47	290889.3			0.6			3.09			0.38			3.45			1		
03/12/23 15:48	291582.5			0.6			3.28			0.38			3.67			1		
03/12/23 15:49	288732.9			0.6			3.28			0.38			3.64			1		
03/12/23 15:50	286268.4			0.6			3			0.38			3.3			1		
03/12/23 15:51	290812.3			0.6			2.95			0.39			3.3			1		
03/12/23 15:52	295125.2			0.6			2.34			0.39			2.65			1		
03/12/23 15:53	298513.9			0.6			1.78			0.39			2.04			1		
03/12/23 15:54	320309.4			0.6			1.5			0.42			1.84			1		
03/12/23 15:55	341334.8			0.6			1.38			0.44			1.81			1		
03/12/23 15:56	352271.1			0.6			1.16			0.51			1.57			0		
03/12/23 15:57	351192.8			0.8			1.23			0.65			1.66			0		
03/12/23 15:58	333094.1			0.9			1.32			0.68			1.69			0		
03/12/23 15:59	309758.3			0.9			1.34			0.65			1.6			0		
03/12/23 16:00	296665.5			0.9			1.27			0.63			1.45			0		

CT2 SUSD EVENT 39

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 0:03	286037.3			0.6			1.5			0.38			1.65			0		
03/13/23 0:04	287192.6			0.6			1.31			0.38			1.45			0		
03/13/23 0:05	288039.8			0.6			1.22			0.38			1.35			0		
03/13/23 0:06	286884.5			0.6			1.22			0.38			1.34			0		
03/13/23 0:07	285960.3			0.6			1.22			0.38			1.34			0		
03/13/23 0:08	287192.6			0.6			1.22			0.38			1.34			1		
03/13/23 0:09	270018			0.6			1.24			0.36			1.28			1		
03/13/23 0:10	248761.6			0.6			2.13			0.34			2.03			1		
03/13/23 0:11	223654.4			0.5			7.16			0.28			6.16			1		
03/13/23 0:12	197700			3.4			10.87			1.55			8.26			1		
03/13/23 0:13	174749.2			171.9			13.64			70.14			9.16			1		
03/13/23 0:14	154879.1			764.8			16.82			276.48			10			1		
03/13/23 0:15	88029.3			1530.5			21.24			314.5			7.18			1		
03/13/23 0:16	0			0			26.55			0			0			0		
03/13/23 0:17	0			0			11.8			0			0			0		
03/13/23 0:18	0			0			0.1			0			0			0		
03/13/23 0:19	0			0			0.1			0			0			0		
03/13/23 0:20	0			0			0.1			0			0			0		

CT2 SUSD EVENT 40

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 16:42	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:43	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:44	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:45	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:46	0			0	X		0	X		0	X		0	X		0		
03/13/23 16:47	0			0	X		0	X		0	X		0	X		1		
03/13/23 16:48	15942.3			0.1	X		0	X		0	X		0	X		1		
03/13/23 16:49	31268.5			761.1	X		35.4	X		55.54	X		4.25	X		1		
03/13/23 16:50	44284.2			230.6	X		16.63	X		23.85	X		2.83	X		1		
03/13/23 16:51	56375.7			158.6	X		19.18	X		20.87	X		4.15	X		1		
03/13/23 16:52	67389			133.5	X		24.22	X		21.01	X		6.27	X		1		
03/13/23 16:53	95422.8			120.8	X		27.53	X		26.91	X		10.09	X		1		
03/13/23 16:54	142325.5			110.3	X		35.91	X		36.67	X		19.65	X		1		
03/13/23 16:55	151875.5			90.6	X		51.84	X		32.13	X		30.25	X		1		
03/13/23 16:56	157882.8			79.3	X		51.81	X		29.23	X		31.44	X		1		
03/13/23 16:57	169127.1			76.9	X		50.95	X		30.36	X		33.11	X		1		
03/13/23 16:58	188073			126.9	X		47.5	X		55.71	X		34.33	X		1		
03/13/23 16:59	211562.9			97.6	X		49.92	X		48.21	X		40.59	X		1		
03/13/23 17:00	239442.7			81.8	X		48.53	X		45.74	X		44.64	X		1		
03/13/23 17:01	262008.3			22.9	X		51.78	X		14	X		52.13	X		1		
03/13/23 17:02	288809.9			2.7	X		46.13	X		1.81	X		51.18	X		1		
03/13/23 17:03	312299.8			2	X		23.99	X		1.48	X		28.78	X		1		
03/13/23 17:04	334788.4			1.9	X		14.48	X		1.47	X		18.63	X		1		
03/13/23 17:05	338639.2			1.9	X		10.41	X		1.51	X		13.55	X		1		
03/13/23 17:06	336790.8			1.8	X		9.72	X		1.43	X		12.58	X		1		
03/13/23 17:07	337792.1			1.7	X		8.85	X		1.37	X		11.49	X		1		
03/13/23 17:08	336328.8			1.5			8.54			1.18			11.04			1		
03/13/23 17:09	336405.8			1.4			7.93			1.11			10.25			1		
03/13/23 17:10	336174.7			1.3			7.75			1.04			10.01			1		
03/13/23 17:11	327625.9			1.2			7.4			0.94			9.31			1		
03/13/23 17:12	326624.8			1.2			7.06			0.89			8.86			1		
03/13/23 17:13	327703			1.1			6.97			0.82			8.78			1		
03/13/23 17:14	328473.1			1.1			6.97			0.82			8.8			1		
03/13/23 17:15	327625.9			1			6.97			0.75			8.78			1		
03/13/23 17:16	326239.7			1			6.88			0.75			8.63			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 17:17	324776.3			1			6.99			0.76			8.72			1		
03/13/23 17:18	321310.6			1			6.9			0.75			8.52			1		
03/13/23 17:19	321079.6			0.9			6.9			0.68			8.51			1		
03/13/23 17:20	303211.9			0.9			6.99			0.64			8.14			1		
03/13/23 17:21	291659.5			0.8			7.84			0.56			8.78			1		
03/13/23 17:22	289349			0.7			10.49			0.51			11.66			1		
03/13/23 17:23	289040.9			0.7			10.86			0.44			12.07			1		
03/13/23 17:24	288886.9			0.7			11.24			0.44			12.47			1		
03/13/23 17:25	289888.1			0.7			11.61			0.44			12.94			1		
03/13/23 17:26	288886.9			0.7			11.8			0.44			13.1			1		
03/13/23 17:27	289272			0.7			11.99			0.44			13.32			1		
03/13/23 17:28	289965.1			0.6			10.68			0.38			11.89			1		
03/13/23 17:29	288039.8			0.6			5.62			0.38			6.22			1		
03/13/23 17:30	289349			0.6			3.84			0.38			4.27			1		
03/13/23 17:31	288732.9			0.6			4.68			0.38			5.19			1		
03/13/23 17:32	289657.1			0.6			5.71			0.39			6.35			1		
03/13/23 17:33	288578.8			0.7			5.52			0.45			6.12			1		
03/13/23 17:34	288347.8			0.6			4			0.38			4.43			1		
03/13/23 17:35	289040.9			0.6			2.57			0.39			2.85			1		
03/13/23 17:36	289426			0.6			2			0.39			2.22			1		
03/13/23 17:37	288809.9			0.6			1.62			0.38			1.8			1		
03/13/23 17:38	287808.7			0.6			1.33			0.38			1.47			0		
03/13/23 17:39	287500.6			0.6			1.05			0.38			1.16			0		
03/13/23 17:40	287654.7			0.6			0.95			0.38			1.05			0		
03/13/23 17:41	287885.7			0.6			0.86			0.38			0.95			0		
03/13/23 17:42	287962.7			0.6			0.76			0.38			0.84			0		

CT2 SUSD EVENT 41

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 16:50	44284.2			230.6	X		16.63	X		23.85	X		2.83	X		1		
03/13/23 16:51	56375.7			158.6	X		19.18	X		20.87	X		4.15	X		1		
03/13/23 16:52	67389			133.5	X		24.22	X		21.01	X		6.27	X		1		
03/13/23 16:53	95422.8			120.8	X		27.53	X		26.91	X		10.09	X		1		
03/13/23 16:54	142325.5			110.3	X		35.91	X		36.67	X		19.65	X		1		
03/13/23 16:55	151875.5			90.6	X		51.84	X		32.13	X		30.25	X		1		
03/13/23 16:56	157882.8			79.3	X		51.81	X		29.23	X		31.44	X		1		
03/13/23 16:57	169127.1			76.9	X		50.95	X		30.36	X		33.11	X		1		
03/13/23 16:58	188073			126.9	X		47.5	X		55.71	X		34.33	X		1		
03/13/23 16:59	211562.9			97.6	X		49.92	X		48.21	X		40.59	X		1		
03/13/23 17:00	239442.7			81.8	X		48.53	X		45.74	X		44.64	X		1		
03/13/23 17:01	262008.3			22.9	X		51.78	X		14	X		52.13	X		1		
03/13/23 17:02	288809.9			2.7	X		46.13	X		1.81	X		51.18	X		1		

CT2 SUSD EVENT 42

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 22:47	314456.2			0.9			1.54			0.67			1.86			0		
03/13/23 22:48	311298.6			0.8			1.45			0.59			1.74			0		
03/13/23 22:49	290658.3			0.7			1.36			0.49			1.52			0		
03/13/23 22:50	286191.3			0.7			1.69			0.44			1.85			0		
03/13/23 22:51	285190.2			0.7			2			0.44			2.19			0		
03/13/23 22:52	279568			0.6			1.81			0.37			1.94			1		
03/13/23 22:53	256771.3			0.6			1.62			0.34			1.6			1		
03/13/23 22:54	234975.7			0.5			4.4			0.27			3.97			1		
03/13/23 22:55	208020.1			0.4			9.8			0.22			7.83			1		
03/13/23 22:56	183837.1			7.6			13.52			3.27			9.55			1		
03/13/23 22:57	164506.1			432.1			16.72			165.98			10.57			1		
03/13/23 22:58	142864.6			1214.3			21.85			405			11.99			1		
03/13/23 22:59	13862.9			1779			26.92			57.74			1.44			1		
03/13/23 23:00	0			0			26.97			0			0			0		
03/13/23 23:01	0			0			0.2			0			0			0		
03/13/23 23:02	0			0			0.1			0			0			0		
03/13/23 23:03	0			0			0.1			0			0			0		
03/13/23 23:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 43

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 9:04	0			0			0			0			0			0		
03/14/23 9:05	0			0			0			0			0			0		
03/14/23 9:06	0			0			0			0			0			0		
03/14/23 9:07	0			0			0			0			0			0		
03/14/23 9:08	0			0			0			0			0			0		
03/14/23 9:09	13400.8			0			0			0			0			1		
03/14/23 9:10	28264.9			1.4			0.1			0			0			1		
03/14/23 9:11	41973.7			1240.8			12.98			121.65			2.09			1		
03/14/23 9:12	53911.2			1212.8			12.91			152.57			2.67			1		
03/14/23 9:13	65001.5			764.2			17.39			115.98			4.34			1		
03/14/23 9:14	86797			553.4			21.54			112.11			7.18			1		
03/14/23 9:15	134932			422.1			23.87			132.95			12.37			1		
03/14/23 9:16	152029.5			276.4			39.33			98.14			22.98			1		
03/14/23 9:17	157959.8			601.6			41.85			221.94			25.41			1		
03/14/23 9:18	172284.7			1819.6			43.88			731.94			29.05			1		
03/14/23 9:19	193079			1452.9			45.35			655.01			33.64			1		
03/14/23 9:20	215875.8			693.2			45.23			349.43			37.53			1		
03/14/23 9:21	242600.3			151.7			45.86			85.89			42.74			1		
03/14/23 9:22	265551.1			11.6			46.73			7.17			47.68			1		
03/14/23 9:23	292429.7			2.3			44.3			1.54			49.78			1		
03/14/23 9:24	317305.8			1.8			21.28			1.36			25.95			1		
03/14/23 9:25	332786			1.6			13.91			1.23			17.79			1		
03/14/23 9:26	336251.8			1.6			10.41			1.29			13.45			1		
03/14/23 9:27	335096.5			1.6			9.63			1.29			12.4			1		
03/14/23 9:28	333479.2			1.6			9.2			1.22			11.78			1		
03/14/23 9:29	332400.9			1.5			8.94			1.14			11.41			1		
03/14/23 9:30	331784.8			1.3			8.98			1.02			11.45			1		
03/14/23 9:31	330706.6			1.2			8.54			0.95			10.85			1		
03/14/23 9:32	331784.8			1.1			8.54			0.89			10.89			1		
03/14/23 9:33	331245.7			1.1			8.45			0.82			10.76			1		
03/14/23 9:34	330013.4			1.1			8.54			0.81			10.83			1		
03/14/23 9:35	329705.4			1			8.67			0.76			10.99			1		
03/14/23 9:36	331399.7			1			8.67			0.76			11.04			1		
03/14/23 9:37	334095.3			1			8.76			0.77			11.25			1		
03/14/23 9:38	327086.8			0.9			8.85			0.68			11.12			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 9:39	311375.6			0.9			9.03			0.65			10.8			1		
03/14/23 9:40	308140.9			0.9			9.08			0.65			10.75			1		
03/14/23 9:41	304213.1			0.8			9.98			0.58			11.67			1		
03/14/23 9:42	297127.6			0.8			6.27			0.58			7.16			1		
03/14/23 9:43	298822			0.7			3.13			0.51			3.6			1		
03/14/23 9:44	299900.2			0.6			2.12			0.45			2.44			1		
03/14/23 9:45	293430.8			0.6			1.48			0.44			1.66			1		
03/14/23 9:46	290966.3			0.6			1.29			0.44			1.44			1		
03/14/23 9:47	289657.1			0.7			1.12			0.44			1.25			1		
03/14/23 9:48	290427.2			0.7			0.94			0.44			1.05			0		
03/14/23 9:49	288655.9			0.7			0.84			0.44			0.93			0		
03/14/23 9:50	288809.9			0.7			0.75			0.44			0.83			0		
03/14/23 9:51	287346.6			0.6			0.75			0.38			0.83			0		
03/14/23 9:52	287577.6			0.6			0.66			0.38			0.72			0		

CT2 SUSD EVENT 44

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 23:04	376223			0.9			1.14			0.77			1.65			0		
03/14/23 23:05	357970.3			0.9			1.23			0.74			1.7			0		
03/14/23 23:06	334249.3			1			1.39			0.74			1.78			0		
03/14/23 23:07	312453.8			1			1.76			0.71			2.11			0		
03/14/23 23:08	291813.5			0.9			1.63			0.62			1.83			0		
03/14/23 23:09	282263.5			0.8			1.75			0.55			1.9			1		
03/14/23 23:10	259158.8			0.7			2.09			0.4			2.08			1		
03/14/23 23:11	238441.5			0.5			6.41			0.28			5.87			1		
03/14/23 23:12	211100.8			0.4			13.8			0.22			11.2			1		
03/14/23 23:13	188073			8			18.19			3.51			13.15			1		
03/14/23 23:14	168433.9			386			21.27			151.8			13.77			1		
03/14/23 23:15	147023.5			1117.3			26.55			383.4			14.99			1		
03/14/23 23:16	24799.1			1801.1			30.93			104.42			2.95			1		
03/14/23 23:17	0			0			41.89			0			0			0		
03/14/23 23:18	0			0			0.2			0			0			0		
03/14/23 23:19	0			0			0.1			0			0			0		
03/14/23 23:20	0			0			0.1			0			0			0		
03/14/23 23:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 45

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 16:42	0			0			0			0			0			0		
03/15/23 16:43	0			0			0			0			0			0		
03/15/23 16:44	0			0			0			0			0			0		
03/15/23 16:45	0			0			0			0			0			0		
03/15/23 16:46	0			0			0			0			0			0		
03/15/23 16:47	8394.7			0			0			0			0			1		
03/15/23 16:48	21872.5			0			0			0			0			1		
03/15/23 16:49	34657.2			50.2			41.3			4.06			5.51			1		
03/15/23 16:50	47903.9			1224			18.15			137			3.34			1		
03/15/23 16:51	59225.3			887.8			22.91			122.81			5.21			1		
03/15/23 16:52	71547.8			584.1			27.95			97.54			7.68			1		
03/15/23 16:53	105280.8			429.3			32.03			105.51			12.96			1		
03/15/23 16:54	148332.8			284.7			43.87			98.6			25			1		
03/15/23 16:55	162734.8			180.1			57.98			68.4			36.25			1		
03/15/23 16:56	197931			1009.6			58.63			466.47			44.58			1		
03/15/23 16:57	225579.8			518			61.42			272.83			53.24			1		
03/15/23 16:58	249531.8			55.2			61.05			32.14			58.55			1		
03/15/23 16:59	273945.8			3.2			57.07			2.03			60.07			1		
03/15/23 17:00	301209.5			1.4			47.2			1.02			54.63			1		
03/15/23 17:01	323852.2			1.3			22.17			1.01			27.59			1		
03/15/23 17:02	332246.9			1.4			15.15			1.09			19.33			1		
03/15/23 17:03	333864.3			1.6			11.63			1.28			14.91			1		
03/15/23 17:04	336020.7			1.7			11.01			1.31			14.21			1		
03/15/23 17:05	336559.8			1.6			10.3			1.25			13.32			1		
03/15/23 17:06	335712.6			1.5			9.86			1.17			12.72			1		
03/15/23 17:07	332400.9			1.3			9.16			1.03			11.7			1		
03/15/23 17:08	332169.9			1.3			8.94			0.97			11.41			1		
03/15/23 17:09	329474.3			1.2			8.67			0.89			10.98			1		
03/15/23 17:10	328396.1			1.1			8.49			0.82			10.72			1		
03/15/23 17:11	328935.2			1			8.31			0.76			10.51			1		
03/15/23 17:12	330475.5			1			8.26			0.77			10.49			1		
03/15/23 17:13	330321.5			1			8.26			0.77			10.48			1		
03/15/23 17:14	329012.2			1			8.17			0.77			10.33			1		
03/15/23 17:15	327317.9			0.9			8.17			0.69			10.27			1		
03/15/23 17:16	326932.8			0.9			8.08			0.69			10.15			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 17:17	327317.9			0.9			8.08			0.69			10.16			1		
03/15/23 17:18	328473.1			0.9			7.99			0.7			10.08			1		
03/15/23 17:19	327471.9			0.9			7.99			0.69			10.05			1		
03/15/23 17:20	320848.5			0.9			8.08			0.68			9.96			1		
03/15/23 17:21	306985.7			0.9			8.17			0.65			9.64			1		
03/15/23 17:22	300285.3			0.8			8.94			0.58			10.32			1		
03/15/23 17:23	296511.5			0.8			10.49			0.58			11.95			1		
03/15/23 17:24	290658.3			0.7			11.61			0.51			12.97			1		
03/15/23 17:25	289040.9			0.8			12.66			0.51			14.06			1		
03/15/23 17:26	289195			0.7			13.51			0.45			15.01			1		
03/15/23 17:27	289195			0.6			13.13			0.39			14.59			1		
03/15/23 17:28	288193.8			0.6			7.42			0.38			8.22			1		
03/15/23 17:29	288809.9			0.6			4			0.38			4.43			1		
03/15/23 17:30	289426			0.7			2.66			0.45			2.96			1		
03/15/23 17:31	288347.8			0.6			1.9			0.38			2.11			1		
03/15/23 17:32	289040.9			0.6			1.71			0.39			1.9			1		
03/15/23 17:33	287269.6			0.6			1.33			0.38			1.47			1		
03/15/23 17:34	289118			0.6			1.14			0.39			1.27			1		
03/15/23 17:35	288193.8			0.6			1.05			0.38			1.16			0		
03/15/23 17:36	289272			0.6			1.05			0.39			1.16			0		
03/15/23 17:37	287577.6			0.6			0.95			0.38			1.05			0		
03/15/23 17:38	287808.7			0.6			0.95			0.38			1.05			0		
03/15/23 17:39	286884.5			0.6			0.95			0.38			1.05			0		

CT2 SUSD EVENT 46

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/15/23 21:40	382769.4			0.8			1.67			0.71			2.46			0		
03/15/23 21:41	376608.1			0.9			1.59			0.77			2.29			0		
03/15/23 21:42	376762.1			1			1.32			0.85			1.91			0		
03/15/23 21:43	373989.6			1			1.14			0.85			1.65			0		
03/15/23 21:44	351192.8			0.9			1.14			0.72			1.54			0		
03/15/23 21:45	329551.3			0.9			1.41			0.68			1.78			1		
03/15/23 21:46	306908.7			1			1.61			0.7			1.9			1		
03/15/23 21:47	283341.8			0.9			1.91			0.6			2.08			1		
03/15/23 21:48	259543.8			0.7			3.47			0.45			3.46			1		
03/15/23 21:49	235283.8			0.6			7.53			0.34			6.81			1		
03/15/23 21:50	211408.8			0.6			22.04			0.27			17.9			1		
03/15/23 21:51	186378.7			7.4			26.43			3.21			18.93			1		
03/15/23 21:52	166277.5			445			31.47			172.74			20.1			1		
03/15/23 21:53	146792.4			1189.2			35.4			407.57			19.97			1		
03/15/23 21:54	39817.3			1792.3			37.43			166.5			5.72			1		
03/15/23 21:55	0			0			43.07			0			0			0		
03/15/23 21:56	0			0			0.3			0			0			0		
03/15/23 21:57	0			0			0.2			0			0			0		
03/15/23 21:58	0			0			0.2			0			0			0		
03/15/23 21:59	0			0			0.1			0			0			0		

CT2 SUSD EVENT 47

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 15:40	0			0			0			0			0			0		
03/16/23 15:41	0			0			0			0			0			0		
03/16/23 15:42	0			0			0			0			0			0		
03/16/23 15:43	0			0			0			0			0			0		
03/16/23 15:44	0			0			0			0			0			0		
03/16/23 15:45	16866.5			0			0			0			0			1		
03/16/23 15:46	26878.6			1.1			0.1			0			0			1		
03/16/23 15:47	40972.5			1198.4			21.63			114.54			3.4			1		
03/16/23 15:48	53449.1			1080.1			19.54			134.67			4.01			1		
03/16/23 15:49	66079.7			678.5			25.46			104.65			6.46			1		
03/16/23 15:50	85025.6			489.1			28.62			97.11			9.35			1		
03/16/23 15:51	133006.6			366.1			36.47			113.65			18.64			1		
03/16/23 15:52	152183.6			232.8			51.97			82.71			30.38			1		
03/16/23 15:53	145868.3			550.6			58.05			187.46			32.53			1		
03/16/23 15:54	156111.4			1874.1			53.29			682.97			31.96			1		
03/16/23 15:55	186301.6			1844			61.09			802.03			43.73			1		
03/16/23 15:56	210715.7			780.7			62.11			384.1			50.29			1		
03/16/23 15:57	234205.6			234.9			60.83			128.44			54.74			1		
03/16/23 15:58	256540.2			23.6			58.75			14.14			57.92			1		
03/16/23 15:59	283957.9			3			56.38			1.96			61.52			1		
03/16/23 16:00	306061.5			2.2			36.5			1.57			42.92			1		
03/16/23 16:01	316535.7			2			18.97			1.48			23.08			1		
03/16/23 16:02	338254.2			2			14.53			1.6			18.88			1		
03/16/23 16:03	358586.4			2			11.89			1.7			16.38			1		
03/16/23 16:04	370908.9			1.8			10.85			1.58			15.46			1		
03/16/23 16:05	373989.6			1.7			8.72			1.46			12.53			1		
03/16/23 16:06	373219.4			1.5			8.37			1.3			12			1		
03/16/23 16:07	373065.4			1.4			8.01			1.23			11.49			1		
03/16/23 16:08	371294			1.3			7.66			1.15			10.93			1		
03/16/23 16:09	372834.3			1.2			7.49			1.07			10.72			1		
03/16/23 16:10	371448			1.3			7.33			1.09			10.46			1		
03/16/23 16:11	372064.2			1.2			7.24			1.01			10.35			1		
03/16/23 16:12	371525.1			1.2			7.15			1.01			10.21			1		
03/16/23 16:13	370292.8			1.1			7.06			0.93			10.05			1		
03/16/23 16:14	369445.6			1.1			6.97			0.93			9.9			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 16:15	370677.9			1.1			7.06			0.93			10.06			1		
03/16/23 16:16	368444.4			1.1			7.06			0.92			10			1		
03/16/23 16:17	369599.7			1			6.97			0.85			9.9			1		
03/16/23 16:18	367212.2			1			7.06			0.84			9.96			1		
03/16/23 16:19	368521.4			1			6.97			0.85			9.87			1		
03/16/23 16:20	365902.9			1			7.06			0.84			9.93			1		
03/16/23 16:21	368059.3			1			7.06			0.85			9.99			1		
03/16/23 16:22	367751.3			1			7.15			0.84			10.11			1		
03/16/23 16:23	367289.2			1			7.15			0.84			10.09			1		
03/16/23 16:24	368059.3			0.9			5.99			0.77			8.47			1		
03/16/23 16:25	367058.1			0.9			3.4			0.77			4.79			1		
03/16/23 16:26	366596			0.9			2.77			0.77			3.9			1		
03/16/23 16:27	352271.1			0.9			3.13			0.74			4.23			1		
03/16/23 16:28	362360.2			0.9			3.93			0.76			5.48			1		
03/16/23 16:29	377763.3			0.9			3.93			0.79			5.71			1		
03/16/23 16:30	394706.8			0.9			3.09			0.84			4.68			1		
03/16/23 16:31	400868.1			0.8			3.04			0.78			4.69			1		
03/16/23 16:32	404256.8			0.8			3.41			0.78			5.3			1		
03/16/23 16:33	403948.8			0.8			3.5			0.78			5.44			1		
03/16/23 16:34	400175			0.8			3.6			0.78			5.53			1		
03/16/23 16:35	398095.6			0.8			3.09			0.76			4.72			1		
03/16/23 16:36	400252			0.8			2.45			0.76			3.77			1		
03/16/23 16:37	400329			0.8			2.27			0.76			3.49			1		
03/16/23 16:38	398634.7			0.8			2.27			0.76			3.48			1		
03/16/23 16:39	399250.8			0.8			2.45			0.76			3.76			1		
03/16/23 16:40	399558.9			0.8			2.63			0.76			4.04			1		
03/16/23 16:41	399327.8			0.8			2.54			0.76			3.9			1		
03/16/23 16:42	396555.3			0.8			2.36			0.76			3.6			1		
03/16/23 16:43	397864.5			0.8			2.09			0.76			3.19			1		
03/16/23 16:44	400406			0.8			1.91			0.76			2.93			1		
03/16/23 16:45	402408.5			0.8			1.72			0.77			2.67			1		
03/16/23 16:46	399712.9			0.8			1.82			0.76			2.79			1		
03/16/23 16:47	397864.5			0.8			1.91			0.76			2.91			0		
03/16/23 16:48	397402.4			0.8			1.91			0.76			2.91			0		
03/16/23 16:49	399789.9			0.8			1.82			0.76			2.79			0		
03/16/23 16:50	404102.8			0.8			1.63			0.77			2.54			0		
03/16/23 16:51	401561.3			0.8			1.63			0.77			2.52			0		

CT2 SUSD EVENT 48

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 8:17	307601.8			0.7			1.48			0.53			1.74			0		
03/17/23 8:18	307601.8			0.7			1.38			0.53			1.63			0		
03/17/23 8:19	307678.8			0.7			1.38			0.53			1.63			0		
03/17/23 8:20	308834.1			0.7			1.29			0.53			1.53			0		
03/17/23 8:21	307755.8			0.7			1.29			0.53			1.53			0		
03/17/23 8:22	299592.1			0.7			1.38			0.52			1.59			1		
03/17/23 8:23	276410.3			0.7			1.38			0.48			1.47			1		
03/17/23 8:24	253382.5			0.7			2.61			0.4			2.54			1		
03/17/23 8:25	230200.7			0.6			8.32			0.34			7.36			1		
03/17/23 8:26	202706			2			14.23			0.93			11.08			1		
03/17/23 8:27	180910.5			129.7			17.44			54.77			12.13			1		
03/17/23 8:28	160963.4			740.3			20.65			278.23			12.77			1		
03/17/23 8:29	129001.8			1514.8			24.61			456.06			12.19			1		
03/17/23 8:30	0			1864.6			28.36			0			0			1		
03/17/23 8:31	0			0			50.15			0			0			0		
03/17/23 8:32	0			0			0.2			0			0			0		
03/17/23 8:33	0			0			0.2			0			0			0		
03/17/23 8:34	0			0			0.1			0			0			0		
03/17/23 8:35	0			0			0.1			0			0			0		

CT2 SUSD EVENT 49

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 16:34	0			0			0			0			0			0		
03/17/23 16:35	0			0			0			0			0			0		
03/17/23 16:36	0			0			0			0			0			0		
03/17/23 16:37	0			0			0			0			0			0		
03/17/23 16:38	0			0			0			0			0			0		
03/17/23 16:39	1925.4			0			0			0			0			1		
03/17/23 16:40	15865.3			0			0			0			0			1		
03/17/23 16:41	31114.5			64.9			29.5			4.71			3.52			1		
03/17/23 16:42	44438.2			1099.2			9.08			114.17			1.55			1		
03/17/23 16:43	56375.7			917.6			12.49			120.78			2.71			1		
03/17/23 16:44	67928.1			572			16.46			90.78			4.3			1		
03/17/23 16:45	97271.2			391.6			19.67			88.98			7.35			1		
03/17/23 16:46	145483.2			249.1			23.09			84.58			12.9			1		
03/17/23 16:47	154648.1			164.4			39.27			59.35			23.33			1		
03/17/23 16:48	161810.6			950.1			40.75			358.99			25.34			1		
03/17/23 16:49	162195.6			1551.7			40.95			587.7			25.53			1		
03/17/23 16:50	178677.1			1664			40.95			694.29			28.12			1		
03/17/23 16:51	199702.4			982.4			43.37			458.08			33.28			1		
03/17/23 16:52	225348.7			312.6			45.76			164.42			39.62			1		
03/17/23 16:53	250764			39.5			47.45			23.15			45.71			1		
03/17/23 16:54	276795.4			3.3			49.81			2.13			52.98			1		
03/17/23 16:55	302364.7			1.8			36.82			1.29			42.79			1		
03/17/23 16:56	326008.6			1.7			17.33			1.26			21.71			1		
03/17/23 16:57	336636.8			1.6			11.8			1.25			15.26			1		
03/17/23 16:58	335404.6			1.6			10.48			1.24			13.5			1		
03/17/23 16:59	335404.6			1.6			10.04			1.24			12.94			1		
03/17/23 17:00	334095.3			1.4			9.77			1.1			12.55			1		
03/17/23 17:01	334095.3			1.3			9.57			1.05			12.28			1		
03/17/23 17:02	333479.2			1.3			9.3			0.97			11.91			1		
03/17/23 17:03	333094.1			1.2			9.12			0.9			11.67			1		
03/17/23 17:04	336020.7			1.2			9.03			0.91			11.66			1		
03/17/23 17:05	322003.8			1.1			9.03			0.81			11.17			1		
03/17/23 17:06	312992.9			1.1			9.26			0.8			11.13			1		
03/17/23 17:07	310297.3			1			9.59			0.73			11.43			1		
03/17/23 17:08	311375.6			0.9			9.77			0.67			11.69			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 17:09	309142.1			0.8			10.05			0.6			11.93			1		
03/17/23 17:10	309373.2			0.8			10.14			0.6			12.06			1		
03/17/23 17:11	308988.1			0.8			6.08			0.6			7.22			1		
03/17/23 17:12	310220.3			0.8			3.32			0.6			3.96			1		
03/17/23 17:13	310682.4			0.8			3.69			0.6			4.4			1		
03/17/23 17:14	309450.2			0.8			4.43			0.6			5.26			1		
03/17/23 17:15	308988.1			0.8			5.35			0.6			6.35			1		
03/17/23 17:16	309835.3			0.8			5.44			0.6			6.48			1		
03/17/23 17:17	308526			0.8			3.87			0.6			4.59			1		
03/17/23 17:18	309065.1			0.7			2.86			0.53			3.39			1		
03/17/23 17:19	309296.2			0.7			2.72			0.54			3.23			1		
03/17/23 17:20	307293.7			0.7			2.77			0.53			3.27			1		
03/17/23 17:21	308294.9			0.7			3.09			0.54			3.66			1		
03/17/23 17:22	308603			0.7			3.37			0.54			4			1		
03/17/23 17:23	308757			0.7			3.56			0.54			4.22			1		
03/17/23 17:24	309296.2			0.7			2.9			0.54			3.45			1		
03/17/23 17:25	308757			0.8			2.43			0.61			2.89			1		
03/17/23 17:26	308526			0.8			2.25			0.61			2.66			1		
03/17/23 17:27	306677.6			0.8			2.06			0.6			2.43			1		
03/17/23 17:28	307139.7			0.8			1.97			0.6			2.32			1		
03/17/23 17:29	311452.6			0.8			1.97			0.61			2.35			1		
03/17/23 17:30	332940.1			0.8			1.97			0.66			2.52			1		
03/17/23 17:31	353811.4			0.8			1.84			0.69			2.51			0		
03/17/23 17:32	369060.5			0.9			1.88			0.77			2.66			0		
03/17/23 17:33	377455.3			0.9			1.72			0.8			2.5			0		
03/17/23 17:34	396863.3			1			1.45			0.93			2.21			0		
03/17/23 17:35	411419.3			0.9			1.38			0.89			2.19			0		

CT2 SUSD EVENT 50

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 22:48	306908.7			0.7			1.48			0.53			1.74			0		
03/17/23 22:49	306754.6			0.7			1.38			0.53			1.63			0		
03/17/23 22:50	307447.8			0.7			1.38			0.53			1.63			0		
03/17/23 22:51	307062.7			0.7			1.38			0.53			1.63			0		
03/17/23 22:52	308063.9			0.7			1.38			0.53			1.64			0		
03/17/23 22:53	304598.2			0.7			1.38			0.52			1.62			1		
03/17/23 22:54	284188.9			0.7			1.38			0.49			1.51			1		
03/17/23 22:55	258773.7			0.8			2.19			0.46			2.18			1		
03/17/23 22:56	237209.2			0.7			6.51			0.39			5.93			1		
03/17/23 22:57	210715.7			1			14.81			0.49			11.99			1		
03/17/23 22:58	186147.6			8.9			19.83			3.87			14.19			1		
03/17/23 22:59	165815.4			460.1			23.6			178.16			15.04			1		
03/17/23 23:00	145945.3			1185.3			27.43			403.81			15.38			1		
03/17/23 23:01	34503.2			1768.2			31.9			142.49			4.23			1		
03/17/23 23:02	0			0			35.4			0			0			0		
03/17/23 23:03	0			0			0.2			0			0			0		
03/17/23 23:04	0			0			0.2			0			0			0		
03/17/23 23:05	0			0			0.1			0			0			0		
03/17/23 23:06	0			0			0.1			0			0			0		

CT2 SUSD EVENT 51

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 15:50	0			0			0			0			0			0		
03/18/23 15:51	0			0			0			0			0			0		
03/18/23 15:52	0			0			0			0			0			0		
03/18/23 15:53	0			0			0			0			0			0		
03/18/23 15:54	0			0			0			0			0			0		
03/18/23 15:55	8779.8			0.1			0			0			0			1		
03/18/23 15:56	24876.2			0.1			0			0			0			1		
03/18/23 15:57	38276.9			75.5			29.5			6.75			4.34			1		
03/18/23 15:58	50214.4			1221.7			17.7			143.3			3.42			1		
03/18/23 15:59	61920.8			808			24.58			116.84			5.85			1		
03/18/23 16:00	76399.8			532.2			27.73			94.94			8.14			1		
03/18/23 16:01	118835.6			407.1			32.72			113			14.95			1		
03/18/23 16:02	152106.5			270.7			45.78			96.16			26.77			1		
03/18/23 16:03	155572.3			250.8			55.95			91.13			33.46			1		
03/18/23 16:04	168433.9			1625.1			52.73			639.14			34.13			1		
03/18/23 16:05	188612.1			1598.7			53.62			703.93			38.86			1		
03/18/23 16:06	211023.8			810.3			54.5			399.23			44.19			1		
03/18/23 16:07	236516			171			53.5			94.41			48.62			1		
03/18/23 16:08	260853.1			14.2			52.5			8.65			52.62			1		
03/18/23 16:09	287731.7			2.5			52.99			1.69			58.58			1		
03/18/23 16:10	310528.4			2.1			27.93			1.5			33.32			1		
03/18/23 16:11	317998.9			1.9			16			1.39			19.55			1		
03/18/23 16:12	316997.8			1.9			12.33			1.43			15.01			1		
03/18/23 16:13	328627.2			2			11.35			1.51			14.34			1		
03/18/23 16:14	332632			1.8			9.92			1.39			12.68			1		
03/18/23 16:15	332323.9			1.6			8.98			1.23			11.47			1		
03/18/23 16:16	331168.7			1.4			8.81			1.09			11.21			1		
03/18/23 16:17	328858.2			1.3			8.4			1.03			10.62			1		
03/18/23 16:18	328550.1			1.3			8.31			0.96			10.5			1		
03/18/23 16:19	327317.9			1.2			8.05			0.89			10.12			1		
03/18/23 16:20	328088			1.2			7.87			0.89			9.92			1		
03/18/23 16:21	326162.7			1.1			7.78			0.82			9.75			1		
03/18/23 16:22	325854.6			1.1			7.9			0.83			9.89			1		
03/18/23 16:23	327009.8			1			7.72			0.76			9.7			1		
03/18/23 16:24	327163.8			1			7.72			0.76			9.7			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 16:25	328935.2			1			7.62			0.77			9.64			1		
03/18/23 16:26	328011			1			7.72			0.76			9.72			1		
03/18/23 16:27	326162.7			1			7.72			0.76			9.67			1		
03/18/23 16:28	325854.6			1			7.62			0.76			9.55			1		
03/18/23 16:29	325161.4			0.9			7.62			0.69			9.52			1		
03/18/23 16:30	326393.7			0.9			7.62			0.69			9.56			1		
03/18/23 16:31	325315.5			0.9			7.72			0.69			9.64			1		
03/18/23 16:32	313917.1			0.9			7.81			0.67			9.42			1		
03/18/23 16:33	308988.1			0.8			8.2			0.6			9.74			1		
03/18/23 16:34	309681.2			0.8			8.67			0.6			10.31			1		
03/18/23 16:35	309373.2			0.8			7.93			0.6			9.43			1		
03/18/23 16:36	308294.9			0.8			3.23			0.6			3.82			1		
03/18/23 16:37	309296.2			0.7			2.3			0.53			2.74			1		
03/18/23 16:38	308371.9			0.7			2.86			0.53			3.39			1		
03/18/23 16:39	307909.8			0.7			3.41			0.53			4.04			1		
03/18/23 16:40	310451.4			0.7			3.69			0.53			4.4			1		
03/18/23 16:41	309296.2			0.7			3.13			0.53			3.73			1		
03/18/23 16:42	308140.9			0.7			2.49			0.53			2.95			1		
03/18/23 16:43	311991.7			0.7			2.12			0.54			2.54			1		
03/18/23 16:44	330937.6			0.7			1.57			0.57			1.99			1		
03/18/23 16:45	351809			0.7			1.38			0.61			1.87			1		
03/18/23 16:46	368290.4			0.8			1.25			0.69			1.77			1		
03/18/23 16:47	368675.5			0.9			0.98			0.77			1.39			0		
03/18/23 16:48	370831.9			1			0.8			0.85			1.15			0		
03/18/23 16:49	388930.7			1			0.8			0.89			1.2			0		
03/18/23 16:50	408569.7			0.9			0.82			0.87			1.28			0		
03/18/23 16:51	418658.8			0.8			0.74			0.81			1.19			0		

CT2 SUSD EVENT 52

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/18/23 21:40	309835.3			1			1.61			0.71			1.92			0		
03/18/23 21:41	304906.2			0.9			1.57			0.66			1.84			0		
03/18/23 21:42	304598.2			0.8			1.48			0.59			1.73			0		
03/18/23 21:43	305214.3			0.8			1.4			0.6			1.65			0		
03/18/23 21:44	305753.4			0.7			1.31			0.53			1.54			0		
03/18/23 21:45	296434.5			0.7			1.31			0.52			1.49			1		
03/18/23 21:46	275332.1			0.7			1.31			0.48			1.39			1		
03/18/23 21:47	249223.7			0.8			2.38			0.44			2.28			1		
03/18/23 21:48	227351.2			0.6			6.42			0.33			5.61			1		
03/18/23 21:49	198470.2			1.5			17.13			0.68			13.07			1		
03/18/23 21:50	178137.9			10.3			21.21			4.28			14.52			1		
03/18/23 21:51	157805.7			510.7			25.47			188.17			15.45			1		
03/18/23 21:52	127461.4			1298.2			29.66			386.19			14.52			1		
03/18/23 21:53	0			1791.9			34.07			0			0			1		
03/18/23 21:54	0			0			64.9			0			0			0		
03/18/23 21:55	0			0			0.2			0			0			0		
03/18/23 21:56	0			0			0.2			0			0			0		
03/18/23 21:57	0			0			0.1			0			0			0		
03/18/23 21:58	0			0			0.1			0			0			0		

CT2 SUSD EVENT 53

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 15:37	0			0			0			0			0			0		
03/19/23 15:38	0			0			0			0			0			0		
03/19/23 15:39	0			0			0			0			0			0		
03/19/23 15:40	0			0			0			0			0			0		
03/19/23 15:41	0			0			0			0			0			0		
03/19/23 15:42	19100			0			0			0			0			1		
03/19/23 15:43	31422.5			82.6			35.4			6.06			4.28			1		
03/19/23 15:44	45131.4			1388.1			17.7			146.35			3.07			1		
03/19/23 15:45	57068.8			1152			19.91			153.43			4.36			1		
03/19/23 15:46	68082.1			734.4			24.53			116.72			6.42			1		
03/19/23 15:47	96038.9			519.5			26.69			116.52			9.85			1		
03/19/23 15:48	142710.6			413			37.01			137.56			20.29			1		
03/19/23 15:49	152414.6			282.5			49.82			100.56			29.18			1		
03/19/23 15:50	159346			852.9			51.44			317.31			31.5			1		
03/19/23 15:51	175442.4			1820			52.55			745.53			35.43			1		
03/19/23 15:52	194850.4			1480.4			54.45			673.37			40.76			1		
03/19/23 15:53	217724.2			647.2			51.92			329.02			43.44			1		
03/19/23 15:54	245989			138.1			53.36			79.3			50.44			1		
03/19/23 15:55	269941			10.5			51.48			6.63			53.39			1		
03/19/23 15:56	297127.6			2.2			48.25			1.53			55.09			1		
03/19/23 15:57	321156.6			1.9			22.27			1.43			27.48			1		
03/19/23 15:58	336405.8			1.8			15.41			1.45			19.92			1		
03/19/23 15:59	337330			2			11.63			1.57			15.07			1		
03/19/23 16:00	336328.8			2			10.5			1.57			13.57			1		
03/19/23 16:01	335173.5			1.8			9.89			1.43			12.74			1		
03/19/23 16:02	333402.2			1.7			9.25			1.3			11.84			1		
03/19/23 16:03	331476.8			1.5			9.07			1.16			11.55			1		
03/19/23 16:04	332169.9			1.3			8.89	X		1.02			11.35	X		1		
03/19/23 16:05	329628.4			1.2			8.63			0.95			10.93			1		
03/19/23 16:06	328396.1			1.1			8.37			0.88			10.56			1		
03/19/23 16:07	326547.7			1.2			8.31			0.89			10.43			1		
03/19/23 16:08	329474.3			1.1			8.22			0.83			10.41			1		
03/19/23 16:09	328165.1			1.1			8.22			0.82			10.37			1		
03/19/23 16:10	331553.8			1.1			8.22			0.83			10.48			1		
03/19/23 16:11	331091.7			1.1			8.22			0.83			10.46			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 16:12	329320.3			1			8.13			0.76			10.29			1		
03/19/23 16:13	327780			1			8.13			0.75			10.25			1		
03/19/23 16:14	328242.1			1			8.05			0.75			10.15			1		
03/19/23 16:15	327703			1			8.05			0.75			10.13			1		
03/19/23 16:16	330244.5			0.9			8.05			0.69			10.21			1		
03/19/23 16:17	326085.6			0.9			8.13			0.68			10.19			1		
03/19/23 16:18	315380.4			0.9			8.22			0.66			9.96			1		
03/19/23 16:19	312145.8			0.9			8.71			0.66			10.45			1		
03/19/23 16:20	310605.4			0.8			9.26			0.59			11.05			1		
03/19/23 16:21	309835.3			0.8			9.86			0.6			11.74			1		
03/19/23 16:22	309989.3			0.8			9.86			0.6			11.75			1		
03/19/23 16:23	310220.3			0.8			8.57			0.6			10.22			1		
03/19/23 16:24	309527.2			0.7			4.15			0.53			4.93			1		
03/19/23 16:25	309758.3			0.7			3.13			0.53			3.73			1		
03/19/23 16:26	309681.2			0.7			3.87			0.53			4.61			1		
03/19/23 16:27	309681.2			0.7			4.61			0.53			5.48			1		
03/19/23 16:28	310682.4			0.6			5.25			0.47			6.27			1		
03/19/23 16:29	308757			0.6			4.89			0.47			5.8			1		
03/19/23 16:30	308834.1			0.6			3.6			0.47			4.27			1		
03/19/23 16:31	308911.1			0.6			2.77			0.47			3.28			1		
03/19/23 16:32	309912.3			0.7			2.67			0.53			3.18			1		
03/19/23 16:33	308217.9			0.7			2.86			0.53			3.38			1		
03/19/23 16:34	309065.1			0.7			3.04			0.53			3.61			1		
03/19/23 16:35	309065.1			0.7			3.23			0.53			3.83			1		
03/19/23 16:36	308603			0.7			3.23			0.53			3.83			1		
03/19/23 16:37	307755.8			0.7			2.86			0.53			3.38			1		
03/19/23 16:38	312992.9			0.7			2.21			0.54			2.66			1		
03/19/23 16:39	333864.3			0.7			2.03			0.57			2.6			1		
03/19/23 16:40	355274.7			0.7			1.72			0.6			2.35			1		
03/19/23 16:41	363361.3			0.7			1.7			0.61			2.37			1		
03/19/23 16:42	358432.3			0.8			1.61			0.67			2.22			1		
03/19/23 16:43	364747.7			0.9			1.43			0.76			2			0		
03/19/23 16:44	384001.6			0.9			1.52			0.8			2.24			0		
03/19/23 16:45	404718.9			0.9			1.45			0.86			2.26			0		
03/19/23 16:46	413575.8			0.8			1.36			0.79			2.16			0		
03/19/23 16:47	416194.3			0.7			1.45			0.71			2.32			0		

CT2 SUSD EVENT 54

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 1:03	307139.7			0.7			1.38			0.53			1.63			0		
03/20/23 1:04	307524.8			0.7			1.38			0.53			1.63			0		
03/20/23 1:05	307678.8			0.7			1.48			0.53			1.74			0		
03/20/23 1:06	306831.6			0.7			1.48			0.53			1.74			0		
03/20/23 1:07	307216.7			0.7			1.48			0.53			1.74			0		
03/20/23 1:08	302133.7			0.7			1.48			0.52			1.71			1		
03/20/23 1:09	281801.4			0.7			1.57			0.49			1.7			1		
03/20/23 1:10	256925.3			0.7			2.34			0.45			2.31			1		
03/20/23 1:11	234436.6			0.6			6.61			0.33			5.96			1		
03/20/23 1:12	207635.1			1.9			15.7			0.92			12.52			1		
03/20/23 1:13	183144			14.1			19.96			6.01			14.04			1		
03/20/23 1:14	163736			482.7			23.6			184.54			14.85			1		
03/20/23 1:15	141247.3			1222.1			27.27			402.96			14.8			1		
03/20/23 1:16	0			1732.6			31.71			0			0			1		
03/20/23 1:17	0			0			41.3			0			0			0		
03/20/23 1:18	0			0			0.2			0			0			0		
03/20/23 1:19	0			0			0.1			0			0			0		
03/20/23 1:20	0			0			0.1			0			0			0		
03/20/23 1:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 55

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 16:26	0			0			0			0			0			0		
03/20/23 16:27	0			0			0			0			0			0		
03/20/23 16:28	0			0			0			0			0			0		
03/20/23 16:29	0			0			0			0			0			0		
03/20/23 16:30	0			0			0			0			0			0		
03/20/23 16:31	14633			0			0			0			0			1		
03/20/23 16:32	20178.2			0			0			0			0			1		
03/20/23 16:33	32731.8			88.5			53.1			6.76			6.67			1		
03/20/23 16:34	45824.5			1334.4			18.19			142.78			3.2			1		
03/20/23 16:35	57530.9			985.6			21.52			132.38			4.76			1		
03/20/23 16:36	69391.4			639.1			27.64			103.57			7.37			1		
03/20/23 16:37	98272.4			473.7			27.25			108.68			10.29			1		
03/20/23 16:38	144636			348.4			39.25			117.67			21.82			1		
03/20/23 16:39	166123.5			219.8			56.68			85.26			36.19			1		
03/20/23 16:40	189305.3			745.4			58.46			329.52			42.54			1		
03/20/23 16:41	211485.9			679.6			56.13			335.57			45.61			1		
03/20/23 16:42	237440.3			200.3			58.45			111.03			53.32			1		
03/20/23 16:43	260930.1			19.6			55.03			11.95			55.16			1		
03/20/23 16:44	286499.4			1.7			56.27			1.17			61.94			1		
03/20/23 16:45	294663.1			1.3			32.9			0.89			37.25			1		
03/20/23 16:46	314148.2			1.3			19.01			0.96			22.95			1		
03/20/23 16:47	335481.6			1.3			16.36			1.05			21.09			1		
03/20/23 16:48	337021.9			1.5			11.89			1.16			15.39			1		
03/20/23 16:49	336944.9			1.6			10.67			1.23			13.82			1		
03/20/23 16:50	335481.6			1.5			10.21			1.17			13.17			1		
03/20/23 16:51	333479.2			1.4			9.33			1.1			11.96			1		
03/20/23 16:52	333171.1			1.3			9.25			1.03			11.84			1		
03/20/23 16:53	329705.4			1.2			8.63			0.95			10.93			1		
03/20/23 16:54	329705.4			1.2			8.67			0.89			10.99			1		
03/20/23 16:55	328550.1			1.1			8.49			0.82			10.72			1		
03/20/23 16:56	327317.9			1.1			8.4			0.82			10.57			1		
03/20/23 16:57	327240.9			1.1			8.31			0.82			10.45			1		
03/20/23 16:58	326008.6			1			8.22			0.75			10.3			1		
03/20/23 16:59	327934			1			8.26			0.76			10.41			1		
03/20/23 17:00	328473.1			0.9			8.26			0.7			10.43			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 17:01	327009.8			0.9			8.26			0.69			10.38			1		
03/20/23 17:02	328011			0.9			8.17			0.7			10.3			1		
03/20/23 17:03	322388.9			0.9			8.08			0.68			10.01			1		
03/20/23 17:04	311298.6			0.9			8.08			0.66			9.66			1		
03/20/23 17:05	311067.5			0.9			8.76			0.67			10.47			1		
03/20/23 17:06	310759.4			0.8			9.4	X		0.6			11.23	X		1		
03/20/23 17:07	310682.4			0.8			9.31			0.6			11.11			1		
03/20/23 17:08	310066.3			0.7			9.5			0.53			11.31			1		
03/20/23 17:09	309835.3			0.7			9.59			0.53			11.42			1		
03/20/23 17:10	310220.3			0.7			9.77			0.53			11.65			1		
03/20/23 17:11	310682.4			0.7			9.86			0.53			11.77			1		
03/20/23 17:12	309604.2			0.7			9.77			0.53			11.62			1		
03/20/23 17:13	310759.4			0.7			5.53			0.54			6.6			1		
03/20/23 17:14	326701.8			0.7			3.32			0.56			4.17			1		
03/20/23 17:15	349036.4			0.7			3.5			0.6			4.7			1		
03/20/23 17:16	364054.5			0.8			4.11			0.68			5.75			1		
03/20/23 17:17	361667			0.9			3.84			0.75			5.34			1		
03/20/23 17:18	365671.8			0.9			4.02			0.76			5.65			1		
03/20/23 17:19	382846.4			1			4.11			0.88			6.05			1		
03/20/23 17:20	403178.6			1			3.54			0.94			5.48			1		
03/20/23 17:21	415578.2			0.9			3.23			0.89			5.15			1		
03/20/23 17:22	417965.7			0.8			3.5			0.81			5.63			1		
03/20/23 17:23	428670.9			0.7			3.96			0.74			6.53			1		
03/20/23 17:24	449003.1			0.8			3.13			0.87			5.41			1		
03/20/23 17:25	462943			0.7			2.34			0.81			4.16			1		
03/20/23 17:26	466100.7			0.7			2.53			0.82			4.53			1		
03/20/23 17:27	469258.3			0.7			2.9			0.82			5.23			1		
03/20/23 17:28	471722.8			0.7			3.09			0.83			5.6			1		
03/20/23 17:29	475034.5			0.7			2.9			0.83			5.3			1		
03/20/23 17:30	473417.2			0.7			2.53			0.83			4.6			1		
03/20/23 17:31	471953.9			0.7			2.15			0.83			3.91			1		
03/20/23 17:32	475881.7			0.7			1.87			0.83			3.42			1		
03/20/23 17:33	477576			0.7			1.97			0.84			3.61			1		
03/20/23 17:34	476420.8			0.7			2.49			0.82			4.56			1		
03/20/23 17:35	477191			0.7			2.49			0.82			4.56			1		
03/20/23 17:36	477113.9			0.7			1.75			0.83			3.25			1		
03/20/23 17:37	477268			0.9			1.48			1.06			2.79			1		
03/20/23 17:38	476574.8			1.8			1.34			2.06			2.54			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 17:39	477576			2.5			1.23			2.85			2.34			1		
03/20/23 17:40	478269.2			2.2			1.32			2.55			2.51			0		
03/20/23 17:41	476728.9			1.8			1.32			2.03			2.5			0		
03/20/23 17:42	477499			1.6			1.32			1.82			2.5			0		
03/20/23 17:43	477576			1.6			1.41			1.82			2.67			0		
03/20/23 17:44	478192.2			1.6			1.41			1.82			2.67			0		

CT2 SUSD EVENT 56

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/20/23 20:14	483275.2			0.9			1.01			1.04			1.88			0		
03/20/23 20:15	483660.3			0.7			1.2			0.83			2.23			0		
03/20/23 20:16	481426.8			0.7			1.29			0.83			2.39			0		
03/20/23 20:17	481503.8			0.7			1.11			0.83			2.05			0		
03/20/23 20:18	482582.1			0.7			1.01			0.83			1.88			0		
03/20/23 20:19	481580.9			0.7			1.01			0.83			1.88			1		
03/20/23 20:20	478654.3			0.7			1.2			0.82			2.2			1		
03/20/23 20:21	459939.4			0.7			1.94			0.79			3.42			1		
03/20/23 20:22	435987.4			0.7			2.4			0.75			4.02			1		
03/20/23 20:23	412035.4			0.7			3.13			0.69			4.95			1		
03/20/23 20:24	390394			0.8			3.67			0.73			5.5			1		
03/20/23 20:25	365132.7			0.9			4.05			0.75			5.68			1		
03/20/23 20:26	340641.7			1			4.43			0.76			5.79			1		
03/20/23 20:27	316612.7			1			4.84			0.72			5.89			1		
03/20/23 20:28	292814.7			0.9			5.18			0.61			5.83			1		
03/20/23 20:29	270634.1			0.7			6.82			0.47			7.09			1		
03/20/23 20:30	243986.6			0.7			8.8			0.39			8.25			1		
03/20/23 20:31	223269.3			0.5			29.39			0.28			25.22			1		
03/20/23 20:32	195466.5			3.1			37.05			1.4			27.83			1		
03/20/23 20:33	174518.2			174.1			41.17			70.93			27.6			1		
03/20/23 20:34	153569.8			773.8			46.59			277.49			27.5			1		
03/20/23 20:35	112443.3			1487.5			44.84			390.57			19.38			1		
03/20/23 20:36	0			0			49.56			0			0			0		
03/20/23 20:37	0			0			64.9			0			0			0		
03/20/23 20:38	0			0			0.3			0			0			0		
03/20/23 20:39	0			0			0.3			0			0			0		
03/20/23 20:40	0			0			0.2			0			0			0		

CT2 SUSD EVENT 57

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 11:27	0			0			0			0			0			0		
03/21/23 11:28	0			0			0			0			0			0		
03/21/23 11:29	0			0			0			0			0			0		
03/21/23 11:30	0			0			0			0			0			0		
03/21/23 11:31	0			0			0			0			0			0		
03/21/23 11:32	1925.4			0			0			0			0			1		
03/21/23 11:33	20332.2			0			0			0			0			1		
03/21/23 11:34	32731.8			47.2			32.45			3.6			4.08			1		
03/21/23 11:35	46132.6			1340.2			16.79			144.3			2.98			1		
03/21/23 11:36	57762			1058.5			21.17			142.64			4.7			1		
03/21/23 11:37	71778.9			707.4			26.71			118.6			7.37			1		
03/21/23 11:38	103201.4			514.4			28.1			123.9			11.14			1		
03/21/23 11:39	147177.5			394			38.22			135.39			21.61			1		
03/21/23 11:40	161348.5			258.1			55.21			97.24			34.23			1		
03/21/23 11:41	168356.9			988.9			53.28			388.7			34.47			1		
03/21/23 11:42	185454.5			1493.5			53.61			646.58			38.19			1		
03/21/23 11:43	206710.9			953.2			54.81			460.01			43.53			1		
03/21/23 11:44	232588.2			305.4			57.03			165.85			50.97			1		
03/21/23 11:45	257849.5			35.9			56.54			21.6			56.01			1		
03/21/23 11:46	283880.9			3			55.29			1.96			60.31			1		
03/21/23 11:47	309219.1			1.9			38.4			1.37			45.62			1		
03/21/23 11:48	332863			1.8			19.79			1.41			25.31			1		
03/21/23 11:49	350499.7			1.8			14.62			1.47			19.69			1		
03/21/23 11:50	353272.3			2			13.34			1.62			18.11			1		
03/21/23 11:51	357123.1			2			12.74			1.64			17.48			1		
03/21/23 11:52	370369.8			1.8			11.8			1.55			16.79			1		
03/21/23 11:53	361050.9			1.6			9.54			1.39			13.24			1		
03/21/23 11:54	355659.8			1.5			10.24			1.22			13.99			1		
03/21/23 11:55	356815			1.4			10.77			1.14			14.77			1		
03/21/23 11:56	361744			1.4			10.41			1.17			14.47			1		
03/21/23 11:57	365517.8			1.3			9.98			1.11			14.01			1		
03/21/23 11:58	368290.4			1.2			9.95			1.06			14.08			1		
03/21/23 11:59	371063			1.2			8.54			1.07			12.18			1		
03/21/23 12:00	376069			1.1			7.93			1.01			11.45			1		
03/21/23 12:01	379149.6			1.1			7.75			0.94			11.29			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 12:02	381614.2			1.1			7.75			0.94			11.36			1		
03/21/23 12:03	385696			1.1			7.57			0.95			11.22			1		
03/21/23 12:04	389700.8			1.1			7.42			0.98			11.11			1		
03/21/23 12:05	391395.2			1			7.06			0.9			10.62			1		
03/21/23 12:06	394783.9			1			6.97			0.91			10.58			1		
03/21/23 12:07	398326.6			0.9			6.88			0.83			10.54			1		
03/21/23 12:08	401946.3			0.9			6.97			0.84			10.77			1		
03/21/23 12:09	402870.6			0.9			7.06			0.84			10.93			1		
03/21/23 12:10	405797.2			0.8			7.06			0.76			11.01			1		
03/21/23 12:11	411188.3			0.8			7.06			0.77			11.16			1		
03/21/23 12:12	413498.8			0.9			4.47			0.86			7.1			1		
03/21/23 12:13	418504.8			0.9			2.36			0.89			3.8			1		
03/21/23 12:14	420122.1			0.9			2.27			0.89			3.66			1		
03/21/23 12:15	425359.2			0.8			2.81			0.81			4.6			1		
03/21/23 12:16	426591.5			0.8			3.36			0.81			5.5			1		
03/21/23 12:17	431289.4			0.8			3.9			0.82			6.47			1		
03/21/23 12:18	433522.9			0.8			4.08			0.83			6.8			1		
03/21/23 12:19	438374.9			0.8			4.27			0.84			7.19			1		
03/21/23 12:20	441455.6			0.8			3.54			0.84			6			1		
03/21/23 12:21	445845.5			0.8			2.54			0.85			4.35			1		
03/21/23 12:22	447539.8			0.8			2.36			0.85			4.06			1		
03/21/23 12:23	450928.5			0.8			2.45			0.86			4.25			1		
03/21/23 12:24	453162			0.8			3			0.86			5.22			1		
03/21/23 12:25	459785.3			0.8			3.18			0.88			5.61			1		
03/21/23 12:26	460632.5			0.8			3			0.88			5.3			1		
03/21/23 12:27	467641			0.8			2.3			0.91			4.14			1		
03/21/23 12:28	468488.2			0.8			2.03			0.91			3.65			1		
03/21/23 12:29	472801.1			0.8			1.84			0.92			3.35			1		
03/21/23 12:30	477345			0.8			1.84			0.92			3.38			1		
03/21/23 12:31	480271.6			0.8			2.21			0.93			4.08			1		
03/21/23 12:32	476651.8			0.8			2.54			0.91			4.65			1		
03/21/23 12:33	457089.8			0.8			2			0.87			3.51			1		
03/21/23 12:34	435987.4			0.8			1.45			0.83			2.43			1		
03/21/23 12:35	409108.8			0.8			1.43			0.77			2.25			1		
03/21/23 12:36	403024.6			0.9			1.5			0.83			2.32			1		
03/21/23 12:37	396401.2			1			1.41			0.9			2.15			0		
03/21/23 12:38	395169			1			1.34			0.91			2.04			0		
03/21/23 12:39	396709.3			1			1.34			0.91			2.04			0		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 12:40	400175			1			1.43			0.92			2.2			0		
03/21/23 12:41	398711.7			0.9			1.52			0.83			2.33			0		

CT2 SUSD EVENT 58

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 22:50	402023.4			0.8			1			0.77			1.54			0		
03/25/23 22:51	405566.1			0.8			1			0.77			1.56			0		
03/25/23 22:52	402485.5			0.8			1.09			0.77			1.68			0		
03/25/23 22:53	400406			0.8			1.07			0.75			1.65			0		
03/25/23 22:54	400098			0.8			1.25			0.75			1.92			0		
03/25/23 22:55	393628.6			0.8			1.25			0.74			1.89			1		
03/25/23 22:56	375683.9			0.8			1.34			0.71			1.94			1		
03/25/23 22:57	353272.3			0.9			1.5			0.73			2.03			1		
03/25/23 22:58	328011			0.9			2.11			0.67			2.66			1		
03/25/23 22:59	304521.2			0.9			2.41			0.64			2.82			1		
03/25/23 23:00	280569.2			0.9			3.13			0.6			3.38			1		
03/25/23 23:01	256078.1			0.8			5.51			0.46			5.42			1		
03/25/23 23:02	234667.7			0.6			10.33			0.35			9.31			1		
03/25/23 23:03	207558			2.5			21.86			1.23			17.44			1		
03/25/23 23:04	183529.1			115.9			24.37			49.68			17.18			1		
03/25/23 23:05	166046.4			647.5			27.44			251.05			17.51			1		
03/25/23 23:06	123456.6			1417.3			28.66			408.64			13.6			1		
03/25/23 23:07	0			0			31.4			0			0			0		
03/25/23 23:08	0			0			47.2			0			0			0		
03/25/23 23:09	0			0			0.2			0			0			0		
03/25/23 23:10	0			0			0.1			0			0			0		
03/25/23 23:11	0			0			0.1			0			0			0		

ATTACHMENT 16

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/01/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/23 12:00	0			0			0	X		0.32			0.15786			0.53		
01/02/23 13:00	0.8			1.4			1			0.56			0.27756			0.93		
01/02/23 14:00	0.4			1.5			2			0.74			0.372			1.24		
01/02/23 15:00	0.4			1.5			2			0.74			0.3681			1.23		
01/02/23 16:00	0.4			1.5			2			0.73			0.36678			1.22		
01/02/23 17:00	0.4			1.5			2			0.73			0.36642			1.22		
01/02/23 18:00	0.4			1.5			2			0.73			0.36624			1.22		
01/02/23 19:00	0.4			1.5			2			0.73			0.3645			1.22		
01/02/23 20:00	0.4			1.5			2			0.73			0.36324			1.21		
01/02/23 21:00	0.5			1.5			1			0.72			0.35922			1.2		
01/02/23 22:00	0.7			1.5			1			0.7			0.3501			1.17		
01/02/23 23:00	0.7			1.5			1			0.69			0.34476			1.15		
01/03/23 0:00	0.6			1.5			1			0.71			0.35268			1.18		
01/03/23 1:00	0.6			1.5			1			0.7			0.34998			1.17		
01/03/23 2:00	0.6			1.5			1			0.7			0.3501			1.17		
01/03/23 3:00	0.6			1.5			1			0.7			0.3522			1.17		
01/03/23 4:00	0.5			1.5			1			0.71			0.35742			1.19		
01/03/23 5:00	0.5			1.5			1			0.72			0.36054			1.2		
01/03/23 6:00	0.3			1.5			2			0.76			0.3783			1.26		
01/03/23 7:00	0.5			1.5			1			0.72			0.3624			1.21		
01/03/23 8:00	1			1.5			1			0.65			0.32352			1.08		
01/03/23 9:00	1.1			1.5			1			0.65			0.32706			1.09		
01/03/23 10:00	1.4			1.5			1			0.62			0.31014			1.03		
01/03/23 11:00	1.3			1.5			1			0.61			0.30666			1.02		
01/03/23 12:00	1.2			1.5			1			0.63			0.31536			1.05		
01/03/23 13:00	1.2			1.5			1			0.63			0.3132			1.04		
01/03/23 14:00	1.1			1.5			1			0.65			0.3228			1.08		
01/03/23 15:00	0.4			1.5			2			0.74			0.36984			1.23		
01/03/23 16:00	0.5			1.5			1			0.72			0.35976			1.2		
01/03/23 17:00	0.5			1.5			1			0.72			0.35862			1.2		
01/03/23 18:00	0.5			1.5			1			0.72			0.35922			1.2		
01/03/23 19:00	0.5			1.5			1			0.71			0.35526			1.18		
01/03/23 20:00	0.5			1.5			2			0.73			0.3654			1.22		
01/03/23 21:00	0.4			1.5			2			0.73			0.36396			1.21		
01/03/23 22:00	0.4			1.5			1			0.72			0.35904			1.2		
01/03/23 23:00	0.8			1.5			1			0.67			0.33468			1.12		
01/04/23 0:00	1			1.5			1			0.58			0.28782			0.96		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 1:00	0.8			1.5			1			0.58			0.28848			0.96		
01/04/23 2:00	0.7			1.6			1			0.58			0.28836			0.96		
01/04/23 3:00	0.8			1.5			1			0.58			0.28866			0.96		
01/04/23 4:00	0.8			1.5			1			0.58			0.28818			0.96		
01/04/23 5:00	0.8			1.5			1			0.58			0.28782			0.96		
01/04/23 6:00	0.7			1.5			1			0.58			0.2886			0.96		
01/04/23 7:00	1.4			1.5			1			0.61			0.30546			1.02		
01/04/23 8:00	1			1.5			2			0.46			0.23232			0.77		
01/04/23 9:00	0			0			0	X		0.03			0.01344			0.04		
01/04/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:00	0			0			0	X		0.28			0.13866			0.46		
01/05/23 16:00	1			1.6			1			0.44			0.22128			0.74		
01/05/23 17:00	1.1			1.5			1			0.63			0.31452			1.05		
01/05/23 18:00	1.2			1.5			1			0.55			0.27312			0.91		
01/05/23 19:00	0.6			1.4			3			0.29			0.14328			0.48		
01/05/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 16:00	0.7			1.2			3			0.34			0.17028			0.57		
01/06/23 17:00	1			1.2			1			0.57			0.28368			0.95		
01/06/23 18:00	1.1			1.5			1			0.62			0.30942			1.03		
01/06/23 19:00	1.1			1.5			1			0.62			0.30882			1.03		
01/06/23 20:00	0.9			1.5			1			0.47			0.23376			0.78		
01/06/23 21:00	0.6			1.6			2			0.32			0.16176			0.54		
01/06/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/07/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/23 16:00	0.8			1.2			2			0.33			0.16428			0.55		
01/08/23 17:00	1			1.4			1			0.54			0.27156			0.91		
01/08/23 18:00	1.1			1.5			1			0.63			0.31296			1.04		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 19:00	1.1			1.5			1			0.62			0.3099			1.03		
01/08/23 20:00	1.1			1.5			1			0.62			0.3123			1.04		
01/08/23 21:00	1			1.5			1			0.54			0.26982			0.9		
01/08/23 22:00	0.6			1.3			3			0.28			0.14004			0.47		
01/08/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 13:00	0			0			0	X		0.07			0.0342			0.11		
01/09/23 14:00	0.5			1.6			1			0.35			0.17586			0.59		
01/09/23 15:00	0.9			1.5			1			0.56			0.27978			0.93		
01/09/23 16:00	0.6			1.5			1			0.65			0.3249			1.08		
01/09/23 17:00	0.6			1.5			1			0.65			0.32688			1.09		
01/09/23 18:00	0.8			1.5			1			0.65			0.32304			1.08		
01/09/23 19:00	0.9			1.5			1			0.64			0.3222			1.07		
01/09/23 20:00	0.9			1.5			1			0.64			0.3219			1.07		
01/09/23 21:00	1			1.5			1			0.49			0.2448			0.82		
01/09/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/23 15:00	0			0			0	X		0.06			0.02778			0.09		
01/10/23 16:00	0.5			0.7			2			0.36			0.17946			0.6		
01/10/23 17:00	1			1.5			1			0.59			0.29334			0.98		
01/10/23 18:00	1			1.5			1			0.64			0.31896			1.06		
01/10/23 19:00	0.9			1.5			1			0.64			0.31956			1.07		
01/10/23 20:00	1			1.5			1			0.63			0.31464			1.05		
01/10/23 21:00	1.1			1.5			1			0.61			0.30726			1.02		
01/10/23 22:00	1			1.5			1			0.54			0.27054			0.9		
01/10/23 23:00	0.4			1.6			4			0.29			0.14502			0.48		
01/11/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/23 15:00	0.5			0.9			1			0.33			0.16488			0.55		
01/11/23 16:00	0.9			1.5			1			0.56			0.27936			0.93		
01/11/23 17:00	1			1.5			1			0.64			0.3177			1.06		
01/11/23 18:00	1			1.5			1			0.62			0.30954			1.03		
01/11/23 19:00	1			1.5			1			0.62			0.30762			1.03		
01/11/23 20:00	0.9			1.5			1			0.54			0.27036			0.9		
01/11/23 21:00	0			0			0	X		0.24			0.11802			0.39		
01/11/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/23 15:00	0			0			0	X		0.13			0.06444			0.21		
01/12/23 16:00	0.5			1.7			2			0.36			0.1806			0.6		
01/12/23 17:00	0.9			1.5			1			0.52			0.26106			0.87		
01/12/23 18:00	1.2			1.5			1			0.62			0.31008			1.03		
01/12/23 19:00	1.1			1.5			1			0.62			0.30924			1.03		
01/12/23 20:00	1.1			1.5			1			0.62			0.3099			1.03		
01/12/23 21:00	1			1.5			1			0.53			0.2649			0.88		
01/12/23 22:00	0.5			1.2			1			0.28			0.14202			0.47		
01/12/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/13/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 14:00	0			0			0	X		0.07			0.03504			0.12		
01/14/23 15:00	0			0			0	X		0.35			0.17298			0.58		
01/14/23 16:00	0.8			1.5			1			0.55			0.27294			0.91		
01/14/23 17:00	1.1			1.5			1			0.62			0.31038			1.03		
01/14/23 18:00	1			1.5			1			0.62			0.31218			1.04		
01/14/23 19:00	0.9			1.5			1			0.55			0.27528			0.92		
01/14/23 20:00	0.6			1.6			3			0.3			0.15018			0.5		
01/14/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/23 14:00	0			0			0	X		0.02			0.00846			0.03		
01/15/23 15:00	0.6			0.7			2			0.34			0.16824			0.56		
01/15/23 16:00	0.8			1.4			1			0.56			0.2793			0.93		
01/15/23 17:00	0.9			1.5			1			0.64			0.31962			1.07		
01/15/23 18:00	0.9			1.5			1			0.64			0.31986			1.07		
01/15/23 19:00	1.1			1.5			1			0.62			0.31158			1.04		
01/15/23 20:00	1.1			1.5			1			0.62			0.312			1.04		
01/15/23 21:00	0.8			1.4			2			0.48			0.23976			0.8		
01/15/23 22:00	0.5			1.7			5			0.27			0.13326			0.44		
01/15/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/23 15:00	0.5			0.9			5			0.32			0.15798			0.53		
01/16/23 16:00	0.7			1.3			1			0.46			0.22752			0.76		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 17:00	1			1.5			1			0.62			0.31086			1.04		
01/16/23 18:00	1.1			1.5			1			0.62			0.31056			1.04		
01/16/23 19:00	1.1			1.5			1			0.62			0.31026			1.03		
01/16/23 20:00	1.1			1.5			1			0.62			0.30918			1.03		
01/16/23 21:00	1.2			1.5			1			0.62			0.30834			1.03		
01/16/23 22:00	0.9			1.5			2			0.47			0.2367			0.79		
01/16/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/23 17:00	0			0			0	X		0.33			0.16416			0.55		
01/17/23 18:00	0.9			1.5			1			0.53			0.26526			0.88		
01/17/23 19:00	1.2			1.5			1			0.61			0.30702			1.02		
01/17/23 20:00	1.3			1.5			1			0.61			0.30726			1.02		
01/17/23 21:00	1.3			1.5			1			0.61			0.30636			1.02		
01/17/23 22:00	1.4			1.5			1			0.61			0.30552			1.02		
01/17/23 23:00	1.5			1.5			1			0.61			0.30522			1.02		
01/18/23 0:00	1.3			1.5			1			0.62			0.30756			1.03		
01/18/23 1:00	1.2			1.5			1			0.62			0.3081			1.03		
01/18/23 2:00	1.2			1.5			1			0.62			0.30798			1.03		
01/18/23 3:00	1.2			1.5			1			0.62			0.30762			1.03		
01/18/23 4:00	1.3			1.5			1			0.61			0.30684			1.02		
01/18/23 5:00	1.3			1.5			1			0.61			0.3057			1.02		
01/18/23 6:00	1.2			1.5			1			0.62			0.3087			1.03		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 7:00	1.3			1.5			1			0.61			0.30264			1.01		
01/18/23 8:00	1.1			1.5			2			0.54			0.27198			0.91		
01/18/23 9:00	0.5			1.6			4			0.29			0.14448			0.48		
01/18/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/19/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/21/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/23 16:00	0			0			0	X		0.33			0.16506			0.55		
01/23/23 17:00	1.1			1.5			1			0.52			0.25962			0.87		
01/23/23 18:00	0.8			1.5			1			0.65			0.32418			1.08		
01/23/23 19:00	0.5			1.5			1			0.7			0.3498			1.17		
01/23/23 20:00	0.6			1.5			1			0.68			0.34206			1.14		
01/23/23 21:00	0.8			1.5			1			0.65			0.32622			1.09		
01/23/23 22:00	0.9			1.5			1			0.66			0.32832			1.09		
01/23/23 23:00	1.2			1.5			1			0.63			0.3159			1.05		
01/24/23 0:00	0.8			1.5			1			0.58			0.28872			0.96		
01/24/23 1:00	0.7			1.5			1			0.58			0.28956			0.97		
01/24/23 2:00	0.7			1.5			1			0.58			0.28818			0.96		
01/24/23 3:00	0.7			1.5			1			0.58			0.28812			0.96		
01/24/23 4:00	0.7			1.5			1			0.58			0.28806			0.96		
01/24/23 5:00	0.9			1.5			1			0.63			0.3168			1.06		
01/24/23 6:00	0.6			1.5			2			0.71			0.35676			1.19		
01/24/23 7:00	1.4			1.5			1			0.62			0.30882			1.03		
01/24/23 8:00	1.5			1.5			1			0.61			0.30432			1.01		
01/24/23 9:00	0.6			1.5			3			0.47			0.23532			0.78		
01/24/23 10:00	0.4			1.4			3			0.29			0.1458			0.49		
01/24/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/24/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/25/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/26/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/23 16:00	0			0			0	X		0.35			0.17664			0.59		
01/27/23 17:00	1.3			1.6			1			0.57			0.28554			0.95		
01/27/23 18:00	1.1			1.5			1			0.62			0.31026			1.03		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 19:00	1			1.5			1			0.57			0.28344			0.94		
01/27/23 20:00	0.7			1.5			2			0.39			0.19566			0.65		
01/27/23 21:00	0.6			1.5			2			0.35			0.17358			0.58		
01/27/23 22:00	0.6			1.5			2			0.35			0.17418			0.58		
01/27/23 23:00	0.6			1.5			2			0.35			0.17508			0.58		
01/28/23 0:00	0.6			1.5			2			0.35			0.17472			0.58		
01/28/23 1:00	0.6			1.5			3			0.35			0.17436			0.58		
01/28/23 2:00	0.6			1.4			2			0.35			0.1746			0.58		
01/28/23 3:00	0.6			1.5			3			0.35			0.1746			0.58		
01/28/23 4:00	0.7			1.5			3			0.35			0.17448			0.58		
01/28/23 5:00	0.8			1.5			3			0.35			0.1746			0.58		
01/28/23 6:00	0.7			1.5			2			0.36			0.17946			0.6		
01/28/23 7:00	0.6			1.4			3			0.35			0.17418			0.58		
01/28/23 8:00	0.6			1.3			3			0.35			0.17454			0.58		
01/28/23 9:00	0.6			1.4			3			0.35			0.17484			0.58		
01/28/23 10:00	0.6			1.5			2			0.35			0.17472			0.58		
01/28/23 11:00	0.6			1.5			2			0.35			0.1749			0.58		
01/28/23 12:00	0.6			1.5			2			0.35			0.17508			0.58		
01/28/23 13:00	0.6			1.5			2			0.35			0.17358			0.58		
01/28/23 14:00	0.5			1.5			2			0.35			0.1752			0.58		
01/28/23 15:00	0.6			1.5			2			0.35			0.1755			0.59		
01/28/23 16:00	0.5			1.5			2			0.35			0.1755			0.59		
01/28/23 17:00	0.5			1.5			2			0.35			0.17502			0.58		
01/28/23 18:00	0.6			1.5			2			0.35			0.17442			0.58		
01/28/23 19:00	0.6			1.5			2			0.35			0.17274			0.58		
01/28/23 20:00	0.6			1.5			2			0.35			0.17292			0.58		
01/28/23 21:00	0.6			1.5			2			0.35			0.17424			0.58		
01/28/23 22:00	0.6			1.5			2			0.35			0.1746			0.58		
01/28/23 23:00	0.5			1.5			2			0.35			0.17442			0.58		
01/29/23 0:00	0.6			1.5			2			0.35			0.17394			0.58		
01/29/23 1:00	0.5			1.5			2			0.35			0.1743			0.58		
01/29/23 2:00	0.5			1.4			2			0.35			0.1746			0.58		
01/29/23 3:00	0.5			1.5			2			0.35			0.17442			0.58		
01/29/23 4:00	0.5			1.5			2			0.35			0.17454			0.58		
01/29/23 5:00	0.5			1.5			2			0.35			0.17496			0.58		
01/29/23 6:00	0.5			1.5			2			0.35			0.17466			0.58		
01/29/23 7:00	0.5			1.5			2			0.35			0.17484			0.58		
01/29/23 8:00	0.6			1.4			2			0.41			0.20424			0.68		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:00	0.7			1.5			1			0.51			0.25296			0.84		
01/29/23 10:00	0.9			1.5			1			0.58			0.28878			0.96		
01/29/23 11:00	1			1.5			1			0.61			0.30378			1.01		
01/29/23 12:00	0.7			1.4			2			0.46			0.22884			0.76		
01/29/23 13:00	0.5			1.5			2			0.35			0.17514			0.58		
01/29/23 14:00	0.5			1.5			2			0.35			0.17496			0.58		
01/29/23 15:00	0.5			1.5			2			0.35			0.17514			0.58		
01/29/23 16:00	0.5			1.5			2			0.36			0.1779			0.59		
01/29/23 17:00	0.5			1.5			3			0.35			0.17478			0.58		
01/29/23 18:00	0.5			1.5			3			0.35			0.17478			0.58		
01/29/23 19:00	0.5			1.5			3			0.35			0.17442			0.58		
01/29/23 20:00	0.5			1.5			3			0.35			0.17496			0.58		
01/29/23 21:00	0.5			1.5			3			0.35			0.17472			0.58		
01/29/23 22:00	0.5			1.5			3			0.35			0.17466			0.58		
01/29/23 23:00	0.4			1.5			3			0.35			0.1737			0.58		
01/30/23 0:00	0.4			1.5			3			0.35			0.17478			0.58		
01/30/23 1:00	0.5			1.5			3			0.35			0.17586			0.59		
01/30/23 2:00	0.9			1.3			1			0.49			0.246			0.82		
01/30/23 3:00	1.4			1.6			1			0.61			0.30534			1.02		
01/30/23 4:00	1.4			1.5			1			0.61			0.30456			1.02		
01/30/23 5:00	1.2			1.5			2			0.64			0.32058			1.07		
01/30/23 6:00	0.9			1.5			2			0.68			0.33876			1.13		
01/30/23 7:00	0.1			1.5			2			0.83			0.41376			1.38		
01/30/23 8:00	0.2			1.5			2			0.79			0.39312			1.31		
01/30/23 9:00	1			1.5			1			0.63			0.31326			1.04		
01/30/23 10:00	1.1			1.5			1			0.6			0.30102			1		
01/30/23 11:00	1			1.5			1			0.6			0.30156			1.01		
01/30/23 12:00	0.9			1.5			1			0.61			0.3033			1.01		
01/30/23 13:00	0.9			1.5			1			0.61			0.30384			1.01		
01/30/23 14:00	0.9			1.5			1			0.61			0.30576			1.02		
01/30/23 15:00	0.9			1.5			1			0.61			0.30528			1.02		
01/30/23 16:00	0.9			1.5			1			0.61			0.30468			1.02		
01/30/23 17:00	1.1			1.5			1			0.6			0.30228			1.01		
01/30/23 18:00	1.1			1.5			1			0.6			0.2982			0.99		
01/30/23 19:00	1.1			1.5			1			0.59			0.29736			0.99		
01/30/23 20:00	1.1			1.5			1			0.6			0.29928			1		
01/30/23 21:00	1.1			1.5			1			0.6			0.30066			1		
01/30/23 22:00	1.1			1.5			1			0.6			0.30108			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/30/23 23:00	1.1			1.5			1			0.6			0.30216			1.01		
01/31/23 0:00	1.1			1.5			1			0.6			0.3024			1.01		
01/31/23 1:00	1.1			1.5			1			0.61			0.30366			1.01		
01/31/23 2:00	1.1			1.6			1			0.61			0.30432			1.01		
01/31/23 3:00	1.1			1.5			1			0.61			0.30426			1.01		
01/31/23 4:00	1.2			1.5			1			0.61			0.306			1.02		
01/31/23 5:00	1.2			1.5			1			0.61			0.30702			1.02		
01/31/23 6:00	1.2			1.5			1			0.62			0.31056			1.04		
01/31/23 7:00	1.2			1.5			1			0.63			0.31548			1.05		
01/31/23 8:00	1.2			1.5			1			0.61			0.30672			1.02		
01/31/23 9:00	1.1			1.5			1			0.61			0.30378			1.01		
01/31/23 10:00	1.1			1.5			1			0.61			0.30252			1.01		
01/31/23 11:00	1			1.5			1			0.6			0.3024			1.01		
01/31/23 12:00	1			1.5			1			0.6			0.30006			1		
01/31/23 13:00	0.8			1.5			2			0.54			0.26784			0.89		
01/31/23 14:00	0.5			1.5			2			0.35			0.17298			0.58		
01/31/23 15:00	0.8			1.4			1			0.48			0.2406			0.8		
01/31/23 16:00	1.2			1.5			1			0.6			0.3015			1.01		
01/31/23 17:00	1.1			1.5			1			0.6			0.29928			1		
01/31/23 18:00	1.2			1.5			1			0.6			0.29796			0.99		
01/31/23 19:00	1.2			1.5			1			0.6			0.2982			0.99		
01/31/23 20:00	1.2			1.5			1			0.6			0.29886			1		
01/31/23 21:00	1.2			1.5			1			0.6			0.30012			1		
01/31/23 22:00	1.2			1.5			1			0.6			0.30186			1.01		
01/31/23 23:00	1.2			1.5			1			0.61			0.30252			1.01		
02/01/23 0:00	1.2			1.5			1			0.6			0.30198			1.01		
02/01/23 1:00	1.2			1.5			1			0.61			0.30294			1.01		
02/01/23 2:00	1.3			1.5			1			0.61			0.30288			1.01		
02/01/23 3:00	1.3			1.5			1			0.61			0.30336			1.01		
02/01/23 4:00	1.3			1.5			1			0.61			0.30438			1.01		
02/01/23 5:00	1.3			1.5			1			0.61			0.30474			1.02		
02/01/23 6:00	1.2			1.5			1			0.61			0.30486			1.02		
02/01/23 7:00	1.2			1.5			1			0.61			0.30408			1.01		
02/01/23 8:00	1.3			1.5			1			0.61			0.30456			1.02		
02/01/23 9:00	1.3			1.5			1			0.61			0.30276			1.01		
02/01/23 10:00	0.7			1.5			2			0.44			0.21816			0.73		
02/01/23 11:00	0.5			1.5			2			0.35			0.17742			0.59		
02/01/23 12:00	0.5			1.5			2			0.36			0.17784			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/01/23 13:00	0.5			1.5			2			0.36			0.17778			0.59		
02/01/23 14:00	0.5			1.5			2			0.35			0.17598			0.59		
02/01/23 15:00	0.5			1.5			2			0.35			0.1743			0.58		
02/01/23 16:00	0.5			1.5			2			0.35			0.17376			0.58		
02/01/23 17:00	0.5			1.5			2			0.35			0.17394			0.58		
02/01/23 18:00	0.5			1.5			2			0.35			0.17376			0.58		
02/01/23 19:00	0.5			1.5			3			0.35			0.17298			0.58		
02/01/23 20:00	0.6			1.5			3			0.35			0.17274			0.58		
02/01/23 21:00	0.6			1.5			3			0.34			0.17244			0.57		
02/01/23 22:00	0.8			1.5			3			0.34			0.17202			0.57		
02/01/23 23:00	0.8			1.5			3			0.34			0.17196			0.57		
02/02/23 0:00	0.6			1.5			3			0.34			0.17226			0.57		
02/02/23 1:00	0.7			1.5			2			0.35			0.17652			0.59		
02/02/23 2:00	0.6			1.5			2			0.35			0.17592			0.59		
02/02/23 3:00	0.7			1.5			3			0.35			0.17586			0.59		
02/02/23 4:00	0.7			1.5			3			0.35			0.17568			0.59		
02/02/23 5:00	0.7			1.5			3			0.35			0.17598			0.59		
02/02/23 6:00	0.6			1.5			3			0.35			0.17682			0.59		
02/02/23 7:00	0.6			1.5			3			0.35			0.17634			0.59		
02/02/23 8:00	0.8			1.5			3			0.35			0.1761			0.59		
02/02/23 9:00	0.7			1.5			3			0.35			0.17616			0.59		
02/02/23 10:00	0.6			1.5			2			0.35			0.17574			0.59		
02/02/23 11:00	0.6			1.5			2			0.35			0.17382			0.58		
02/02/23 12:00	0.5			1.5			2			0.35			0.1737			0.58		
02/02/23 13:00	0.5			1.5			2			0.35			0.17352			0.58		
02/02/23 14:00	0.6			1.5			2			0.35			0.17322			0.58		
02/02/23 15:00	0.5			1.5			2			0.35			0.17286			0.58		
02/02/23 16:00	0.5			1.5			2			0.35			0.1728			0.58		
02/02/23 17:00	0.5			1.5			2			0.35			0.17316			0.58		
02/02/23 18:00	0.5			1.5			2			0.35			0.1731			0.58		
02/02/23 19:00	0.5			1.5			3			0.34			0.17202			0.57		
02/02/23 20:00	0.6			1.5			2			0.34			0.17214			0.57		
02/02/23 21:00	0.6			1.5			2			0.35			0.17442			0.58		
02/02/23 22:00	0.5			1.5			3			0.35			0.17358			0.58		
02/02/23 23:00	0.5			1.5			3			0.35			0.1731			0.58		
02/03/23 0:00	0.6			1.5			3			0.35			0.17268			0.58		
02/03/23 1:00	0.6			1.5			2			0.35			0.17466			0.58		
02/03/23 2:00	0.5			1.6			2			0.35			0.17412			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 3:00	0.5			1.5			3			0.35			0.1725			0.58		
02/03/23 4:00	0.5			1.5			3			0.34			0.17172			0.57		
02/03/23 5:00	0.5			1.5			2			0.34			0.17208			0.57		
02/03/23 6:00	0.6			1.5			3			0.34			0.17244			0.57		
02/03/23 7:00	0.6			1.4			1			0.4			0.20106			0.67		
02/03/23 8:00	0.6			1.6			2			0.39			0.19644			0.65		
02/03/23 9:00	0.5			1.5			3			0.34			0.17226			0.57		
02/03/23 10:00	0.5			1.5			2			0.35			0.17514			0.58		
02/03/23 11:00	0.9			1.4			1			0.48			0.24018			0.8		
02/03/23 12:00	1.2			1.5			1			0.6			0.30078			1		
02/03/23 13:00	1.2			1.5			1			0.6			0.30066			1		
02/03/23 14:00	1.1			1.5			1			0.6			0.30054			1		
02/03/23 15:00	1			1.5			1			0.59			0.29454			0.98		
02/03/23 16:00	0.6			1.5			2			0.44			0.21852			0.73		
02/03/23 17:00	0.9			1.5			1			0.52			0.25974			0.87		
02/03/23 18:00	0.9			1.5			1			0.64			0.32118			1.07		
02/03/23 19:00	0.8			1.5			1			0.66			0.33078			1.1		
02/03/23 20:00	0.9			1.5			1			0.66			0.33042			1.1		
02/03/23 21:00	1.2			1.5			1			0.63			0.31434			1.05		
02/03/23 22:00	1.2			1.5			1			0.62			0.3117			1.04		
02/03/23 23:00	1.1			1.5			1			0.56			0.27822			0.93		
02/04/23 0:00	0.8			1.7			4			0.29			0.14706			0.49		
02/04/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/23 16:00	0			0			0	X		0.32			0.15822			0.53		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 17:00	1			1.5			1			0.52			0.25914			0.86		
02/04/23 18:00	1			1.5			1			0.64			0.32094			1.07		
02/04/23 19:00	0.8			1.5			1			0.65			0.32496			1.08		
02/04/23 20:00	0.7			1.5			1			0.66			0.33012			1.1		
02/04/23 21:00	0.7			1.5			1			0.66			0.3294			1.1		
02/04/23 22:00	0.8			1.5			1			0.55			0.27276			0.91		
02/04/23 23:00	0.5			1.5			3			0.28			0.1413			0.47		
02/05/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/23 17:00	0			0			0	X		0.04			0.01914			0.06		
02/05/23 18:00	0.7			0.8			4			0.34			0.16998			0.57		
02/05/23 19:00	0.7			1.4			1			0.4			0.19788			0.66		
02/05/23 20:00	1.2			1.5			1			0.57			0.28254			0.94		
02/05/23 21:00	1.1			1.5			1			0.55			0.27378			0.91		
02/05/23 22:00	0.4			1.7			4			0.31			0.15624			0.52		
02/05/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/23 15:00	0			0			0	X		0.06			0.03066			0.1		
02/06/23 16:00	0.5			1.4			1			0.35			0.17622			0.59		
02/06/23 17:00	0.8			1.5			1			0.6			0.29778			0.99		
02/06/23 18:00	0.7			1.5			1			0.66			0.32934			1.1		
02/06/23 19:00	0.8			1.5			1			0.66			0.32904			1.1		
02/06/23 20:00	0.5			1.5			1			0.7			0.34878			1.16		
02/06/23 21:00	0.9			1.5			1			0.64			0.3198			1.07		
02/06/23 22:00	1			1.5			2			0.53			0.26598			0.89		
02/06/23 23:00	0.6			1.5			2			0.34			0.17142			0.57		
02/07/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/23 15:00	0			0			0	X		0.09			0.04686			0.16		
02/07/23 16:00	0.7			0.6			0			0.39			0.19308			0.64		
02/07/23 17:00	1			1.5			1			0.6			0.3003			1		
02/07/23 18:00	0.6			1.5			1			0.67			0.336			1.12		
02/07/23 19:00	0.7			1.5			1			0.68			0.3405			1.14		
02/07/23 20:00	0.6			1.5			1			0.7			0.34794			1.16		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 21:00	0.8			1.5			1			0.68			0.339			1.13		
02/07/23 22:00	0.9			1.5			1			0.66			0.32898			1.1		
02/07/23 23:00	1.2			1.5			1			0.63			0.31608			1.05		
02/08/23 0:00	1			1.5			1			0.56			0.27882			0.93		
02/08/23 1:00	0.8			1.5			1			0.56			0.2787			0.93		
02/08/23 2:00	0.9			1.5			1			0.54			0.27204			0.91		
02/08/23 3:00	0.9			1.5			1			0.54			0.26892			0.9		
02/08/23 4:00	0.9			1.5			1			0.55			0.27402			0.91		
02/08/23 5:00	1.1			1.5			1			0.57			0.28476			0.95		
02/08/23 6:00	1			1.5			2			0.67			0.33582			1.12		
02/08/23 7:00	1.2			1.5			1			0.59			0.29268			0.98		
02/08/23 8:00	0.7			1.7			3			0.4			0.19962			0.67		
02/08/23 9:00	0.6			1.5			3			0.35			0.17532			0.58		
02/08/23 10:00	0.6			1.5			2			0.35			0.17514			0.58		
02/08/23 11:00	0.6			1.5			2			0.35			0.17574			0.59		
02/08/23 12:00	0.6			1.5			2			0.35			0.17646			0.59		
02/08/23 13:00	0.6			1.5			2			0.35			0.17634			0.59		
02/08/23 14:00	0.7			1.5			2			0.35			0.17616			0.59		
02/08/23 15:00	0.7			1.5			1			0.41			0.20628			0.69		
02/08/23 16:00	0.7			1.4			1			0.42			0.21036			0.7		
02/08/23 17:00	1			1.5			1			0.61			0.30366			1.01		
02/08/23 18:00	0.4			1.5			1			0.71			0.35286			1.18		
02/08/23 19:00	0.6			1.5			1			0.68			0.34026			1.13		
02/08/23 20:00	1.2			1.5			1			0.66			0.32994			1.1		
02/08/23 21:00	0.7			1.5			2			0.71			0.35526			1.18		
02/08/23 22:00	0.8			1.5			1			0.67			0.33726			1.12		
02/08/23 23:00	1.2			1.5			1			0.61			0.30486			1.02		
02/09/23 0:00	0.8			1.5			1			0.58			0.28836			0.96		
02/09/23 1:00	0.8			1.5			1			0.56			0.28026			0.93		
02/09/23 2:00	0.8			1.6			1			0.58			0.28854			0.96		
02/09/23 3:00	0.8			1.5			1			0.58			0.28788			0.96		
02/09/23 4:00	0.9			1.5			1			0.56			0.28134			0.94		
02/09/23 5:00	0.8			1.5			1			0.68			0.34032			1.13		
02/09/23 6:00	0.6			1.5			2			0.71			0.35562			1.19		
02/09/23 7:00	1.1			1.5			2			0.55			0.27324			0.91		
02/09/23 8:00	0.7			1.4			2			0.38			0.18864			0.63		
02/09/23 9:00	0.6			1.5			2			0.35			0.1749			0.58		
02/09/23 10:00	0.6			1.5			2			0.35			0.17616			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 11:00	0.6			1.5			2			0.35			0.17646			0.59		
02/09/23 12:00	0.6			1.5			2			0.35			0.17532			0.58		
02/09/23 13:00	0.6			1.5			2			0.35			0.174			0.58		
02/09/23 14:00	0.6			1.5			2			0.35			0.17394			0.58		
02/09/23 15:00	0.6			1.5			1			0.37			0.18438			0.61		
02/09/23 16:00	0.6			1.5			2			0.41			0.20748			0.69		
02/09/23 17:00	1			1.5			1			0.56			0.27954			0.93		
02/09/23 18:00	0.4			1.5			1			0.71			0.35304			1.18		
02/09/23 19:00	0.7			1.5			1			0.67			0.33252			1.11		
02/09/23 20:00	0.6			1.5			1			0.69			0.34668			1.16		
02/09/23 21:00	0.6			1.5			1			0.7			0.3504			1.17		
02/09/23 22:00	0.8			1.5			1			0.67			0.33432			1.11		
02/09/23 23:00	1			1.5			1			0.49			0.24288			0.81		
02/10/23 0:00	0.7			1.4			2			0.37			0.18636			0.62		
02/10/23 1:00	0.6			1.5			2			0.35			0.17544			0.58		
02/10/23 2:00	0.6			1.4			2			0.35			0.17544			0.58		
02/10/23 3:00	0.6			1.5			2			0.35			0.17538			0.58		
02/10/23 4:00	0.6			1.5			2			0.35			0.17586			0.59		
02/10/23 5:00	0.6			1.5			2			0.35			0.1755			0.59		
02/10/23 6:00	0.6			1.5			2			0.36			0.17862			0.6		
02/10/23 7:00	0.6			1.5			2			0.35			0.17562			0.59		
02/10/23 8:00	0.6			1.5			2			0.35			0.17574			0.59		
02/10/23 9:00	0.6			1.5			2			0.35			0.17592			0.59		
02/10/23 10:00	0.6			1.5			2			0.35			0.17634			0.59		
02/10/23 11:00	0.6			1.5			2			0.35			0.17634			0.59		
02/10/23 12:00	0.6			1.5			2			0.35			0.17676			0.59		
02/10/23 13:00	0.6			1.5			2			0.35			0.17706			0.59		
02/10/23 14:00	0.6			1.5			1			0.35			0.17718			0.59		
02/10/23 15:00	0.6			1.5			1			0.41			0.20664			0.69		
02/10/23 16:00	0.6			1.5			1			0.4			0.19866			0.66		
02/10/23 17:00	0.8			1.5			1			0.56			0.27882			0.93		
02/10/23 18:00	1.1			1.5			1			0.62			0.31044			1.03		
02/10/23 19:00	1.1			1.5			1			0.62			0.31062			1.04		
02/10/23 20:00	1.1			1.5			1			0.64			0.31896			1.06		
02/10/23 21:00	1			1.5			1			0.64			0.32154			1.07		
02/10/23 22:00	1			1.5			1			0.65			0.32286			1.08		
02/10/23 23:00	1.2			1.5			1			0.62			0.31104			1.04		
02/11/23 0:00	1.1			1.5			1			0.64			0.31758			1.06		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 1:00	1.2			1.5			1			0.62			0.31134			1.04		
02/11/23 2:00	1.3			1.5			1			0.61			0.3072			1.02		
02/11/23 3:00	1.3			1.5			1			0.61			0.3072			1.02		
02/11/23 4:00	1.3			1.5			1			0.61			0.30684			1.02		
02/11/23 5:00	1.2			1.5			1			0.62			0.31098			1.04		
02/11/23 6:00	1.3			1.5			1			0.62			0.31152			1.04		
02/11/23 7:00	1.3			1.5			1			0.58			0.29118			0.97		
02/11/23 8:00	0.9			1.6			3			0.36			0.1785			0.6		
02/11/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/23 16:00	0.6			0.7			2			0.33			0.16434			0.55		
02/11/23 17:00	0.9			1.5			1			0.55			0.27618			0.92		
02/11/23 18:00	1			1.5			1			0.63			0.31686			1.06		
02/11/23 19:00	1			1.5			1			0.63			0.31428			1.05		
02/11/23 20:00	1.1			1.5			1			0.63			0.31584			1.05		
02/11/23 21:00	0.9			1.5			1			0.65			0.32598			1.09		
02/11/23 22:00	0.9			1.5			1			0.66			0.32766			1.09		
02/11/23 23:00	1.2			1.5			1			0.63			0.31578			1.05		
02/12/23 0:00	1.1			1.5			1			0.66			0.33054			1.1		
02/12/23 1:00	1			1.5			1			0.66			0.3285			1.1		
02/12/23 2:00	1.1			1.5			1			0.64			0.32232			1.07		
02/12/23 3:00	1			1.5			1			0.66			0.3306			1.1		
02/12/23 4:00	0.9			1.5			1			0.66			0.33126			1.1		
02/12/23 5:00	0.9			1.5			1			0.66			0.32964			1.1		
02/12/23 6:00	1			1.5			1			0.65			0.32448			1.08		
02/12/23 7:00	1			1.5			2			0.54			0.27072			0.9		
02/12/23 8:00	0.8			1.4			2			0.41			0.20514			0.68		
02/12/23 9:00	0.6			1.5			2			0.35			0.17484			0.58		
02/12/23 10:00	0.6			1.5			2			0.35			0.1752			0.58		
02/12/23 11:00	0.6			1.5			2			0.35			0.17562			0.59		
02/12/23 12:00	0.6			1.5			2			0.35			0.1758			0.59		
02/12/23 13:00	0.6			1.5			1			0.35			0.17514			0.58		
02/12/23 14:00	0.5			1.5			2			0.35			0.17334			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:00	0.6			1.4			1			0.47			0.23358			0.78		
02/12/23 16:00	0.6			1.5			1			0.47			0.23568			0.79		
02/12/23 17:00	0.7			1.5			1			0.65			0.3267			1.09		
02/12/23 18:00	0.9			1.5			1			0.63			0.3135			1.05		
02/12/23 19:00	0.7			1.5			1			0.66			0.32802			1.09		
02/12/23 20:00	0.6			1.5			1			0.67			0.33414			1.11		
02/12/23 21:00	0.9			1.5			1			0.6			0.30198			1.01		
02/12/23 22:00	0.8			1.4			1			0.46			0.23082			0.77		
02/12/23 23:00	0.7			1.4			2			0.4			0.19932			0.66		
02/13/23 0:00	0.7			1.5			2			0.35			0.17562			0.59		
02/13/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/23 15:00	0			0			0	X		0.27			0.13344			0.44		
02/14/23 16:00	1.4			1.6			1			0.53			0.26292			0.88		
02/14/23 17:00	0.5			1.5			2			0.71			0.35604			1.19		
02/14/23 18:00	0.4			1.5			2			0.73			0.3639			1.21		
02/14/23 19:00	0.6			1.5			1			0.69			0.34362			1.15		
02/14/23 20:00	0.5			1.5			2			0.71			0.35676			1.19		
02/14/23 21:00	0.8			1.5			1			0.67			0.33732			1.12		
02/14/23 22:00	1.1			1.5			1			0.64			0.3183			1.06		
02/14/23 23:00	0.9			1.5			1			0.67			0.33258			1.11		
02/15/23 0:00	1.1			1.5			1			0.66			0.32922			1.1		
02/15/23 1:00	1.1			1.5			1			0.66			0.32754			1.09		
02/15/23 2:00	1.1			1.5			1			0.65			0.32694			1.09		
02/15/23 3:00	0.9			1.5			1			0.67			0.33378			1.11		
02/15/23 4:00	0.6			1.5			2			0.7			0.35094			1.17		
02/15/23 5:00	0.6			1.5			2			0.71			0.3528			1.18		
02/15/23 6:00	0.5			1.5			2			0.73			0.3639			1.21		
02/15/23 7:00	0.4			1.5			2			0.72			0.35838			1.19		
02/15/23 8:00	0.7			1.4			2			0.42			0.2082			0.69		
02/15/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/23 16:00	0			0			0	X		0.31			0.15294			0.51		
02/15/23 17:00	0.9			1.4			1			0.53			0.26496			0.88		
02/15/23 18:00	0.4			1.5			2			0.72			0.36228			1.21		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 19:00	0.4			1.5			2			0.72			0.3621			1.21		
02/15/23 20:00	0.4			1.5			2			0.72			0.36138			1.2		
02/15/23 21:00	0.4			1.5			2			0.73			0.36432			1.21		
02/15/23 22:00	0.4			1.5			2			0.72			0.36168			1.21		
02/15/23 23:00	0.7			1.5			1			0.68			0.33864			1.13		
02/16/23 0:00	0.8			1.5			1			0.58			0.28908			0.96		
02/16/23 1:00	0.7			1.5			1			0.58			0.28938			0.96		
02/16/23 2:00	0.7			1.5			1			0.58			0.29022			0.97		
02/16/23 3:00	0.8			1.5			1			0.58			0.29004			0.97		
02/16/23 4:00	0.7			1.5			1			0.58			0.28956			0.97		
02/16/23 5:00	0.7			1.5			1			0.58			0.28932			0.96		
02/16/23 6:00	0.9			1.5			1			0.58			0.28848			0.96		
02/16/23 7:00	1.1			1.5			1			0.62			0.30978			1.03		
02/16/23 8:00	0.9			1.6			2			0.46			0.22824			0.76		
02/16/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/23 16:00	0.5			0.9			4			0.31			0.15306			0.51		
02/16/23 17:00	1			1.3			0			0.48			0.23886			0.8		
02/16/23 18:00	1.1			1.5			1			0.6			0.30192			1.01		
02/16/23 19:00	1.1			1.5			1			0.63			0.31578			1.05		
02/16/23 20:00	1.2			1.5			1			0.65			0.32478			1.08		
02/16/23 21:00	1			1.5			1			0.66			0.32802			1.09		
02/16/23 22:00	0.9			1.5			1			0.67			0.3336			1.11		
02/16/23 23:00	1.1			1.5			1			0.64			0.31878			1.06		
02/17/23 0:00	1			1.5			1			0.64			0.32142			1.07		
02/17/23 1:00	1.2			1.5			1			0.61			0.30618			1.02		
02/17/23 2:00	1.2			1.5			1			0.61			0.30606			1.02		
02/17/23 3:00	0.9			1.5			3			0.4			0.1989			0.66		
02/17/23 4:00	0			0			0	X		0			0.0006			0		
02/17/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/18/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/23 15:00	0			0			0	X		0.05			0.02598			0.09		
02/20/23 16:00	0			0			0	X		0.34			0.16926			0.56		
02/20/23 17:00	1			1.4			1			0.61			0.30276			1.01		
02/20/23 18:00	0.8			1.5			1			0.66			0.3318			1.11		
02/20/23 19:00	0.8			1.5			1			0.66			0.3324			1.11		
02/20/23 20:00	0.8			1.5			1			0.66			0.33066			1.1		
02/20/23 21:00	1			1.5			1			0.64			0.31962			1.07		
02/20/23 22:00	1.2			1.5			1			0.54			0.27012			0.9		
02/20/23 23:00	0.8			1.4			2			0.38			0.19098			0.64		
02/21/23 0:00	0.8			1.5			2			0.35			0.17532			0.58		
02/21/23 1:00	0.7			1.5			2			0.35			0.1752			0.58		
02/21/23 2:00	0.7			1.5			2			0.35			0.17544			0.58		
02/21/23 3:00	0.7			1.5			2			0.35			0.1752			0.58		
02/21/23 4:00	0.7			1.5			2			0.35			0.17496			0.58		
02/21/23 5:00	0.7			1.5			2			0.35			0.17514			0.58		
02/21/23 6:00	0.7			1.5			2			0.35			0.17502			0.58		
02/21/23 7:00	0.7			1.5			2			0.35			0.17484			0.58		
02/21/23 8:00	0.7			1.5			2			0.35			0.17556			0.59		
02/21/23 9:00	0.6			1.5			2			0.35			0.17508			0.58		
02/21/23 10:00	0.6			1.5			2			0.35			0.17532			0.58		
02/21/23 11:00	0.6			1.5			2			0.35			0.17574			0.59		
02/21/23 12:00	0.7			1.5			1			0.35			0.17616			0.59		
02/21/23 13:00	0.6			1.5			1			0.35			0.17628			0.59		
02/21/23 14:00	0.6			1.5			2			0.35			0.17562			0.59		
02/21/23 15:00	0.6			1.5			2			0.35			0.1743			0.58		
02/21/23 16:00	0.6			1.5			2			0.35			0.1728			0.58		
02/21/23 17:00	0.6			1.5			2			0.34			0.17148			0.57		
02/21/23 18:00	0.6			1.5			2			0.34			0.17142			0.57		
02/21/23 19:00	0.6			1.5			2			0.35			0.17364			0.58		
02/21/23 20:00	0.6			1.5			2			0.35			0.17352			0.58		
02/21/23 21:00	0.6			1.5			2			0.35			0.17388			0.58		
02/21/23 22:00	0.6			1.5			3			0.35			0.1743			0.58		
02/21/23 23:00	0.6			1.5			3			0.35			0.1746			0.58		
02/22/23 0:00	0.6			1.5			3			0.35			0.17418			0.58		
02/22/23 1:00	0.6			1.5			3			0.35			0.17436			0.58		
02/22/23 2:00	0.6			1.5			3			0.35			0.17424			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 3:00	0.6			1.5			3			0.35			0.17376			0.58		
02/22/23 4:00	0.6			1.5			3			0.35			0.17388			0.58		
02/22/23 5:00	0.6			1.5			3			0.35			0.17304			0.58		
02/22/23 6:00	0.7			1.4			2			0.36			0.18012			0.6		
02/22/23 7:00	0.7			1.5			3			0.35			0.1734			0.58		
02/22/23 8:00	0.6			1.5			3			0.35			0.17304			0.58		
02/22/23 9:00	0.6			1.5			3			0.35			0.17352			0.58		
02/22/23 10:00	0.6			1.5			2			0.35			0.17442			0.58		
02/22/23 11:00	0.6			1.5			2			0.35			0.1749			0.58		
02/22/23 12:00	0.6			1.5			2			0.35			0.17514			0.58		
02/22/23 13:00	0.6			1.5			2			0.35			0.17472			0.58		
02/22/23 14:00	0.6			1.5			2			0.35			0.1746			0.58		
02/22/23 15:00	0.6			1.5			1			0.41			0.20436			0.68		
02/22/23 16:00	0.8			1.5			1			0.47			0.237			0.79		
02/22/23 17:00	1.1			1.5			1			0.54			0.26826			0.89		
02/22/23 18:00	0.7			1.5			1			0.67			0.33396			1.11		
02/22/23 19:00	0.8			1.5			1			0.67			0.33372			1.11		
02/22/23 20:00	0.8			1.5			1			0.66			0.33186			1.11		
02/22/23 21:00	0.9			1.5			1			0.65			0.32376			1.08		
02/22/23 22:00	0.8			1.5			1			0.54			0.27006			0.9		
02/22/23 23:00	0.8			1.5			1			0.52			0.25782			0.86		
02/23/23 0:00	0.8			1.5			1			0.64			0.3186			1.06		
02/23/23 1:00	0.4			1.5			2			0.72			0.3606			1.2		
02/23/23 2:00	0.6			1.5			1			0.7			0.3507			1.17		
02/23/23 3:00	0.5			1.5			2			0.72			0.35772			1.19		
02/23/23 4:00	0.5			1.5			2			0.71			0.35328			1.18		
02/23/23 5:00	0.6			1.5			2			0.7			0.35232			1.17		
02/23/23 6:00	0.4			1.5			2			0.72			0.36132			1.2		
02/23/23 7:00	1.2			1.5			1			0.62			0.30984			1.03		
02/23/23 8:00	1.2			1.5			1			0.62			0.31086			1.04		
02/23/23 9:00	1.2			1.5			1			0.61			0.30744			1.02		
02/23/23 10:00	1.2			1.5			1			0.62			0.30834			1.03		
02/23/23 11:00	1.2			1.5			1			0.62			0.31116			1.04		
02/23/23 12:00	1			1.5			2			0.54			0.2682			0.89		
02/23/23 13:00	0.6			1.4			2			0.39			0.1956			0.65		
02/23/23 14:00	0.6			1.5			2			0.35			0.17532			0.58		
02/23/23 15:00	0.6			1.5			2			0.35			0.17454			0.58		
02/23/23 16:00	0.6			1.5			2			0.35			0.17412			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 17:00	0.6			1.5			2			0.35			0.17394			0.58		
02/23/23 18:00	0.6			1.5			3			0.35			0.1737			0.58		
02/23/23 19:00	0.6			1.4			2			0.37			0.18474			0.62		
02/23/23 20:00	0.8			1.5			1			0.57			0.28422			0.95		
02/23/23 21:00	0.7			1.5			1			0.58			0.28926			0.96		
02/23/23 22:00	1.4			1.5			1			0.57			0.2841			0.95		
02/23/23 23:00	1.4			1.5			1			0.56			0.2823			0.94		
02/24/23 0:00	1.3			1.5			1			0.57			0.28422			0.95		
02/24/23 1:00	1.4			1.5			1			0.57			0.2868			0.96		
02/24/23 2:00	1.3			1.5			1			0.57			0.28266			0.94		
02/24/23 3:00	1.4			1.5			1			0.57			0.28344			0.94		
02/24/23 4:00	1.3			1.5			1			0.57			0.28704			0.96		
02/24/23 5:00	1.1			1.5			1			0.63			0.3168			1.06		
02/24/23 6:00	0.7			1.5			1			0.68			0.3408			1.14		
02/24/23 7:00	1.4			1.5			1			0.57			0.2847			0.95		
02/24/23 8:00	1.4			1.5			1			0.57			0.28308			0.94		
02/24/23 9:00	1.4			1.5			1			0.57			0.28524			0.95		
02/24/23 10:00	1.4			1.5			1			0.58			0.29118			0.97		
02/24/23 11:00	1.4			1.5			1			0.58			0.28974			0.97		
02/24/23 12:00	1.4			1.5			1			0.57			0.28536			0.95		
02/24/23 13:00	1.4			1.5			1			0.57			0.28386			0.95		
02/24/23 14:00	1.3			1.5			1			0.57			0.28422			0.95		
02/24/23 15:00	1.4			1.5			1			0.57			0.28404			0.95		
02/24/23 16:00	1.4			1.5			1			0.57			0.28428			0.95		
02/24/23 17:00	1.3			1.5			1			0.57			0.28488			0.95		
02/24/23 18:00	1.4			1.5			1			0.57			0.2853			0.95		
02/24/23 19:00	1.4			1.5			1			0.57			0.28572			0.95		
02/24/23 20:00	1.4			1.5			1			0.57			0.28332			0.94		
02/24/23 21:00	1.4			1.5			1			0.57			0.28326			0.94		
02/24/23 22:00	1.4			1.5			1			0.56			0.28224			0.94		
02/24/23 23:00	1.4			1.5			1			0.56			0.28098			0.94		
02/25/23 0:00	1.1			1.5			1			0.57			0.28524			0.95		
02/25/23 1:00	0.7			1.5			1			0.58			0.28956			0.97		
02/25/23 2:00	0.7			1.5			1			0.58			0.28956			0.97		
02/25/23 3:00	0.7			1.5			1			0.58			0.28932			0.96		
02/25/23 4:00	0.7			1.5			1			0.58			0.29154			0.97		
02/25/23 5:00	0.7			1.5			1			0.58			0.288			0.96		
02/25/23 6:00	0.6			1.5			3			0.36			0.18234			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/25/23 7:00	0.6			1.5			3			0.35			0.17592			0.59		
02/25/23 8:00	0.6			1.5			3			0.35			0.17586			0.59		
02/25/23 9:00	0.6			1.5			3			0.35			0.17598			0.59		
02/25/23 10:00	0.6			1.5			3			0.35			0.1758			0.59		
02/25/23 11:00	0.6			1.5			3			0.35			0.17622			0.59		
02/25/23 12:00	0.6			1.5			2			0.35			0.17592			0.59		
02/25/23 13:00	0.6			1.5			2			0.35			0.17568			0.59		
02/25/23 14:00	0.6			1.5			2			0.35			0.17604			0.59		
02/25/23 15:00	0.6			1.5			2			0.35			0.17598			0.59		
02/25/23 16:00	0.6			1.5			2			0.35			0.1761			0.59		
02/25/23 17:00	0.6			1.5			2			0.35			0.17598			0.59		
02/25/23 18:00	0.6			1.5			2			0.35			0.1758			0.59		
02/25/23 19:00	0.6			1.5			3			0.35			0.17604			0.59		
02/25/23 20:00	0.6			1.5			3			0.35			0.1761			0.59		
02/25/23 21:00	0.6			1.5			3			0.35			0.17472			0.58		
02/25/23 22:00	0.6			1.5			2			0.35			0.1752			0.58		
02/25/23 23:00	0.6			1.5			2			0.35			0.17544			0.58		
02/26/23 0:00	0.6			1.5			2			0.35			0.17508			0.58		
02/26/23 1:00	0.6			1.5			2			0.35			0.1752			0.58		
02/26/23 2:00	0.6			1.5			2			0.35			0.17556			0.59		
02/26/23 3:00	0.6			1.5			3			0.35			0.17496			0.58		
02/26/23 4:00	0.6			1.5			3			0.35			0.1746			0.58		
02/26/23 5:00	0.6			1.5			3			0.35			0.17436			0.58		
02/26/23 6:00	0.6			1.5			3			0.35			0.17442			0.58		
02/26/23 7:00	0.6			1.5			3			0.35			0.17472			0.58		
02/26/23 8:00	0.6			1.5			3			0.35			0.17448			0.58		
02/26/23 9:00	0.6			1.5			3			0.35			0.17412			0.58		
02/26/23 10:00	0.6			1.5			3			0.35			0.17406			0.58		
02/26/23 11:00	0.6			1.5			2			0.35			0.174			0.58		
02/26/23 12:00	0.6			1.5			2			0.35			0.17412			0.58		
02/26/23 13:00	0.6			1.5			2			0.35			0.17406			0.58		
02/26/23 14:00	0.6			1.5			2			0.35			0.17424			0.58		
02/26/23 15:00	0.6			1.5			2			0.35			0.17424			0.58		
02/26/23 16:00	0.6			1.5			2			0.35			0.17472			0.58		
02/26/23 17:00	0.6			1.5			2			0.35			0.1743			0.58		
02/26/23 18:00	0.6			1.5			3			0.35			0.1737			0.58		
02/26/23 19:00	0.6			1.5			3			0.35			0.174			0.58		
02/26/23 20:00	0.6			1.5			2			0.35			0.17454			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/26/23 21:00	0.6			1.5			3			0.35			0.1752			0.58		
02/26/23 22:00	0.6			1.5			2			0.35			0.17412			0.58		
02/26/23 23:00	0.6			1.5			2			0.35			0.17496			0.58		
02/27/23 0:00	0.6			1.5			3			0.35			0.17592			0.59		
02/27/23 1:00	0.6			1.5			3			0.35			0.17598			0.59		
02/27/23 2:00	0.6			1.4			3			0.35			0.17514			0.58		
02/27/23 3:00	0.6			1.5			3			0.35			0.17448			0.58		
02/27/23 4:00	0.6			1.5			3			0.35			0.17436			0.58		
02/27/23 5:00	0.6			1.5			3			0.35			0.17436			0.58		
02/27/23 6:00	0.6			1.5			3			0.35			0.1737			0.58		
02/27/23 7:00	0.6			1.5			3			0.35			0.17334			0.58		
02/27/23 8:00	0.6			1.5			3			0.35			0.17256			0.58		
02/27/23 9:00	0.6			1.5			3			0.34			0.17148			0.57		
02/27/23 10:00	0.6			1.5			3			0.34			0.17208			0.57		
02/27/23 11:00	0.6			1.5			3			0.34			0.17232			0.57		
02/27/23 12:00	0.6			1.5			3			0.34			0.17244			0.57		
02/27/23 13:00	0.6			1.5			3			0.35			0.17352			0.58		
02/27/23 14:00	0.6			1.5			2			0.35			0.174			0.58		
02/27/23 15:00	0.6			1.5			2			0.35			0.17358			0.58		
02/27/23 16:00	0.6			1.4			2			0.37			0.18426			0.61		
02/27/23 17:00	0.9			1.5			1			0.51			0.25512			0.85		
02/27/23 18:00	0.9			1.5			1			0.52			0.26178			0.87		
02/27/23 19:00	1			1.5			1			0.66			0.32928			1.1		
02/27/23 20:00	1			1.5			1			0.66			0.3282			1.09		
02/27/23 21:00	1.1			1.5			1			0.65			0.32268			1.08		
02/27/23 22:00	1.1			1.5			2			0.54			0.26868			0.9		
02/27/23 23:00	0.7			1.4			2			0.4			0.19752			0.66		
02/28/23 0:00	0.6			1.5			3			0.35			0.17508			0.58		
02/28/23 1:00	0.6			1.5			3			0.35			0.17502			0.58		
02/28/23 2:00	0.6			1.6			3			0.35			0.17514			0.58		
02/28/23 3:00	0.6			1.5			3			0.35			0.1752			0.58		
02/28/23 4:00	0.6			1.5			3			0.35			0.17502			0.58		
02/28/23 5:00	0.6			1.5			3			0.35			0.17448			0.58		
02/28/23 6:00	0.6			1.5			3			0.35			0.17388			0.58		
02/28/23 7:00	0.6			1.5			3			0.35			0.17352			0.58		
02/28/23 8:00	0.6			1.5			3			0.35			0.17358			0.58		
02/28/23 9:00	0.6			1.5			3			0.35			0.1737			0.58		
02/28/23 10:00	0.6			1.5			2			0.35			0.17478			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 11:00	0.6			1.5			2			0.35			0.17508			0.58		
02/28/23 12:00	0.6			1.5			2			0.35			0.17466			0.58		
02/28/23 13:00	0.6			1.5			2			0.35			0.17502			0.58		
02/28/23 14:00	0.6			1.5			2			0.35			0.17562			0.59		
02/28/23 15:00	0.6			1.5			2			0.35			0.17664			0.59		
02/28/23 16:00	0.8			1.4			1			0.41			0.20586			0.69		
02/28/23 17:00	0.9			1.4			1			0.43			0.21348			0.71		
02/28/23 18:00	1.2			1.5			1			0.58			0.28986			0.97		
02/28/23 19:00	1.2			1.5			1			0.62			0.3111			1.04		
02/28/23 20:00	1.2			1.5			1			0.62			0.31008			1.03		
02/28/23 21:00	1.2			1.5			1			0.62			0.31032			1.03		
02/28/23 22:00	1.2			1.5			1			0.62			0.30912			1.03		
02/28/23 23:00	1.2			1.5			1			0.62			0.30816			1.03		
03/01/23 0:00	1.1			1.5			1			0.62			0.30882			1.03		
03/01/23 1:00	1.1			1.5			1			0.62			0.30978			1.03		
03/01/23 2:00	1.2			1.6			1			0.62			0.31026			1.03		
03/01/23 3:00	1.2			1.5			1			0.62			0.31158			1.04		
03/01/23 4:00	1.2			1.5			1			0.63			0.3129			1.04		
03/01/23 5:00	1.2			1.5			1			0.63			0.31542			1.05		
03/01/23 6:00	0.8			1.5			1			0.69			0.3438			1.15		
03/01/23 7:00	1			1.5			2			0.54			0.27114			0.9		
03/01/23 8:00	0.6			1.4			2			0.38			0.18978			0.63		
03/01/23 9:00	0.6			1.5			3			0.35			0.17448			0.58		
03/01/23 10:00	0.6			1.5			3			0.35			0.17538			0.58		
03/01/23 11:00	0.6			1.5			2			0.35			0.17538			0.58		
03/01/23 12:00	0.6			1.5			2			0.35			0.1755			0.59		
03/01/23 13:00	0.6			1.5			2			0.35			0.17556			0.59		
03/01/23 14:00	0.6			1.5			2			0.35			0.17562			0.59		
03/01/23 15:00	0.6			1.5			2			0.35			0.17574			0.59		
03/01/23 16:00	0.6			1.5			2			0.35			0.17574			0.59		
03/01/23 17:00	0.6			1.5			2			0.35			0.1764			0.59		
03/01/23 18:00	0.6			1.5			2			0.35			0.17682			0.59		
03/01/23 19:00	0.6			1.5			2			0.35			0.17598			0.59		
03/01/23 20:00	0.6			1.5			3			0.35			0.17448			0.58		
03/01/23 21:00	0.6			1.5			2			0.35			0.1758			0.59		
03/01/23 22:00	0.6			1.5			2			0.35			0.17676			0.59		
03/01/23 23:00	0.6			1.5			2			0.35			0.17676			0.59		
03/02/23 0:00	0.6			1.5			2			0.35			0.1767			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/02/23 1:00	0.6			1.5			3			0.35			0.17652			0.59		
03/02/23 2:00	0.6			1.5			2			0.36			0.17838			0.59		
03/02/23 3:00	0.6			1.5			3			0.36			0.17844			0.59		
03/02/23 4:00	0.6			1.5			2			0.36			0.1782			0.59		
03/02/23 5:00	0.6			1.5			2			0.36			0.17856			0.6		
03/02/23 6:00	0.7			1.4			2			0.43			0.21258			0.71		
03/02/23 7:00	0.6			1.5			3			0.36			0.1779			0.59		
03/02/23 8:00	0.7			1.5			3			0.36			0.17784			0.59		
03/02/23 9:00	0.7			1.5			2			0.36			0.17784			0.59		
03/02/23 10:00	0.6			1.5			2			0.35			0.17676			0.59		
03/02/23 11:00	0.6			1.5			2			0.35			0.17454			0.58		
03/02/23 12:00	0.6			1.5			2			0.35			0.17724			0.59		
03/02/23 13:00	0.6			1.5			2			0.35			0.17442			0.58		
03/02/23 14:00	0.6			1.5			2			0.35			0.17406			0.58		
03/02/23 15:00	0.6			1.5			2			0.35			0.17406			0.58		
03/02/23 16:00	0.6			1.5			2			0.35			0.17376			0.58		
03/02/23 17:00	0.6			1.5			2			0.35			0.17322			0.58		
03/02/23 18:00	0.6			1.5			2			0.35			0.17328			0.58		
03/02/23 19:00	0.7			1.5			2			0.35			0.17358			0.58		
03/02/23 20:00	0.7			1.5			2			0.35			0.17334			0.58		
03/02/23 21:00	0.7			1.5			2			0.35			0.17382			0.58		
03/02/23 22:00	0.7			1.5			2			0.35			0.17352			0.58		
03/02/23 23:00	0.7			1.5			2			0.35			0.17388			0.58		
03/03/23 0:00	0.6			1.5			2			0.35			0.17376			0.58		
03/03/23 1:00	0.7			1.5			2			0.35			0.17382			0.58		
03/03/23 2:00	0.6			1.6			2			0.35			0.17382			0.58		
03/03/23 3:00	0.7			1.5			2			0.35			0.17508			0.58		
03/03/23 4:00	0.7			1.5			2			0.35			0.1773			0.59		
03/03/23 5:00	0.7			1.5			2			0.35			0.17424			0.58		
03/03/23 6:00	0.6			1.5			3			0.35			0.17394			0.58		
03/03/23 7:00	0.7			1.5			2			0.35			0.17454			0.58		
03/03/23 8:00	0.7			1.5			2			0.35			0.17466			0.58		
03/03/23 9:00	0.7			1.5			2			0.35			0.17448			0.58		
03/03/23 10:00	0.7			1.5			2			0.35			0.17532			0.58		
03/03/23 11:00	0.7			1.4			1			0.38			0.18954			0.63		
03/03/23 12:00	1.4			1.5			0			0.56			0.27864			0.93		
03/03/23 13:00	1.2			1.5			1			0.59			0.29484			0.98		
03/03/23 14:00	1.1			1.5			1			0.6			0.30096			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:00	1			1.5			1			0.47			0.23484			0.78		
03/03/23 16:00	0.7			1.4			1			0.38			0.18762			0.63		
03/03/23 17:00	1			1.5			1			0.52			0.2604			0.87		
03/03/23 18:00	1.2			1.5			1			0.62			0.31224			1.04		
03/03/23 19:00	1.1			1.5			1			0.64			0.318			1.06		
03/03/23 20:00	1			1.5			1			0.65			0.32454			1.08		
03/03/23 21:00	1			1.5			1			0.61			0.30438			1.01		
03/03/23 22:00	0.8			1.5			1			0.45			0.22668			0.76		
03/03/23 23:00	0.7			1.4			2			0.38			0.19098			0.64		
03/04/23 0:00	0.7			1.5			2			0.35			0.17568			0.59		
03/04/23 1:00	0.7			1.5			2			0.35			0.17532			0.58		
03/04/23 2:00	0.7			1.5			2			0.35			0.17526			0.58		
03/04/23 3:00	0.7			1.5			2			0.35			0.17466			0.58		
03/04/23 4:00	0.7			1.5			2			0.35			0.17448			0.58		
03/04/23 5:00	0.7			1.5			2			0.35			0.17466			0.58		
03/04/23 6:00	0.6			1.5			2			0.35			0.17478			0.58		
03/04/23 7:00	0.6			1.5			2			0.35			0.1749			0.58		
03/04/23 8:00	0.6			1.5			2			0.35			0.17442			0.58		
03/04/23 9:00	0.6			1.5			2			0.35			0.174			0.58		
03/04/23 10:00	0.6			1.5			2			0.35			0.17436			0.58		
03/04/23 11:00	0.6			1.5			2			0.35			0.17406			0.58		
03/04/23 12:00	0.6			1.5			2			0.35			0.17394			0.58		
03/04/23 13:00	0.7			1.5			2			0.35			0.17496			0.58		
03/04/23 14:00	0.7			1.5			2			0.35			0.1755			0.59		
03/04/23 15:00	0.7			1.5			2			0.35			0.17532			0.58		
03/04/23 16:00	0.7			1.4			1			0.41			0.2052			0.68		
03/04/23 17:00	0.7			1.5			2			0.39			0.19452			0.65		
03/04/23 18:00	1			1.4			1			0.58			0.28782			0.96		
03/04/23 19:00	0.7			1.5			1			0.68			0.34248			1.14		
03/04/23 20:00	0.9			1.5			1			0.66			0.3285			1.1		
03/04/23 21:00	0.9			1.5			1			0.66			0.3282			1.09		
03/04/23 22:00	0.9			1.5			2			0.49			0.24378			0.81		
03/04/23 23:00	0.7			1.4			2			0.37			0.18408			0.61		
03/05/23 0:00	0.6			1.5			2			0.35			0.17262			0.58		
03/05/23 1:00	0.6			1.5			2			0.34			0.17136			0.57		
03/05/23 2:00	0.6			1.5			2			0.35			0.17316			0.58		
03/05/23 3:00	0.7			1.5			2			0.35			0.1755			0.59		
03/05/23 4:00	0.7			1.5			2			0.35			0.17628			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 5:00	0.6			1.5			2			0.35			0.17694			0.59		
03/05/23 6:00	0.7			1.5			2			0.35			0.17676			0.59		
03/05/23 7:00	0.7			1.5			2			0.35			0.17634			0.59		
03/05/23 8:00	0.6			1.5			2			0.35			0.17376			0.58		
03/05/23 9:00	0.7			1.5			2			0.35			0.17562			0.59		
03/05/23 10:00	0.7			1.5			2			0.35			0.177			0.59		
03/05/23 11:00	0.6			1.5			2			0.35			0.17616			0.59		
03/05/23 12:00	0.6			1.5			2			0.35			0.17454			0.58		
03/05/23 13:00	0.6			1.5			2			0.35			0.1737			0.58		
03/05/23 14:00	0.6			1.5			2			0.35			0.17328			0.58		
03/05/23 15:00	0.7			1.4			1			0.41			0.2031			0.68		
03/05/23 16:00	0.8			1.4			1			0.43			0.21312			0.71		
03/05/23 17:00	0.9			1.5			1			0.57			0.28344			0.94		
03/05/23 18:00	0.6			1.5			1			0.69			0.34698			1.16		
03/05/23 19:00	0.6			1.5			1			0.7			0.3501			1.17		
03/05/23 20:00	0.6			1.5			1			0.7			0.3519			1.17		
03/05/23 21:00	0.7			1.5			1			0.69			0.3426			1.14		
03/05/23 22:00	0.9			1.5			1			0.66			0.3321			1.11		
03/05/23 23:00	1.2			1.5			1			0.62			0.3123			1.04		
03/06/23 0:00	0.9			1.5			1			0.54			0.27168			0.91		
03/06/23 1:00	0.8			1.4			2			0.44			0.21846			0.73		
03/06/23 2:00	0.6			1.6			3			0.35			0.17286			0.58		
03/06/23 3:00	0.7			1.5			2			0.35			0.17376			0.58		
03/06/23 4:00	0.7			1.5			2			0.35			0.17418			0.58		
03/06/23 5:00	0.7			1.4			2			0.38			0.19032			0.63		
03/06/23 6:00	0.8			1.5			1			0.5			0.25218			0.84		
03/06/23 7:00	0.7			1.5			3			0.35			0.17454			0.58		
03/06/23 8:00	0.7			1.5			2			0.35			0.17328			0.58		
03/06/23 9:00	0.6			1.5			2			0.35			0.174			0.58		
03/06/23 10:00	0.6			1.5			2			0.35			0.17442			0.58		
03/06/23 11:00	0.7			1.5			2			0.35			0.174			0.58		
03/06/23 12:00	0.6			1.5			2			0.36			0.1791			0.6		
03/06/23 13:00	0.8			1.5			1			0.45			0.22554			0.75		
03/06/23 14:00	1			1.4			1			0.53			0.2631			0.88		
03/06/23 15:00	1.2			1.5			1			0.62			0.30924			1.03		
03/06/23 16:00	1.2			1.5			1			0.62			0.30918			1.03		
03/06/23 17:00	1.2			1.5			1			0.62			0.30864			1.03		
03/06/23 18:00	1.2			1.5			1			0.61			0.30624			1.02		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 19:00	1.1			1.5			1			0.61			0.30384			1.01		
03/06/23 20:00	1.1			1.5			1			0.61			0.30318			1.01		
03/06/23 21:00	1.2			1.5			1			0.61			0.30306			1.01		
03/06/23 22:00	1.2			1.5			1			0.61			0.3033			1.01		
03/06/23 23:00	1.2			1.5			1			0.61			0.3033			1.01		
03/07/23 0:00	1.2			1.5			1			0.61			0.30324			1.01		
03/07/23 1:00	1.1			1.5			1			0.61			0.30444			1.01		
03/07/23 2:00	1.1			1.5			1			0.61			0.30456			1.02		
03/07/23 3:00	1.1			1.5			1			0.61			0.30516			1.02		
03/07/23 4:00	1.2			1.5			1			0.62			0.30918			1.03		
03/07/23 5:00	1.1			1.5			1			0.65			0.32574			1.09		
03/07/23 6:00	0.6			1.5			1			0.7			0.35142			1.17		
03/07/23 7:00	1.3			1.5			1			0.53			0.26664			0.89		
03/07/23 8:00	0.7			1.4			2			0.38			0.1893			0.63		
03/07/23 9:00	0.6			1.5			2			0.35			0.17424			0.58		
03/07/23 10:00	0.6			1.5			2			0.35			0.17484			0.58		
03/07/23 11:00	0.6			1.5			2			0.35			0.17478			0.58		
03/07/23 12:00	0.6			1.5			2			0.35			0.17502			0.58		
03/07/23 13:00	0.6			1.5			2			0.35			0.1749			0.58		
03/07/23 14:00	0.6			1.5			2			0.35			0.17472			0.58		
03/07/23 15:00	0.6			1.5			2			0.35			0.17466			0.58		
03/07/23 16:00	0.6			1.5			1			0.41			0.20478			0.68		
03/07/23 17:00	0.6			1.5			2			0.36			0.17922			0.6		
03/07/23 18:00	1			1.4			1			0.52			0.2604			0.87		
03/07/23 19:00	1.1			1.5			1			0.61			0.3048			1.02		
03/07/23 20:00	1.2			1.5			1			0.61			0.3033			1.01		
03/07/23 21:00	1.2			1.5			1			0.61			0.30336			1.01		
03/07/23 22:00	1.2			1.5			1			0.61			0.30336			1.01		
03/07/23 23:00	1.2			1.5			1			0.61			0.30318			1.01		
03/08/23 0:00	1.2			1.5			1			0.61			0.3033			1.01		
03/08/23 1:00	1.2			1.5			1			0.61			0.30342			1.01		
03/08/23 2:00	1.2			1.5			1			0.61			0.3036			1.01		
03/08/23 3:00	1.2			1.5			1			0.61			0.30336			1.01		
03/08/23 4:00	1.2			1.5			1			0.61			0.30312			1.01		
03/08/23 5:00	1.2			1.5			1			0.61			0.30402			1.01		
03/08/23 6:00	1.1			1.5			1			0.61			0.30594			1.02		
03/08/23 7:00	1.2			1.5			1			0.62			0.30996			1.03		
03/08/23 8:00	1.2			1.5			1			0.62			0.31152			1.04		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 9:00	1.1			1.5			1			0.62			0.30846			1.03		
03/08/23 10:00	0.9			1.5			1			0.54			0.2712			0.9		
03/08/23 11:00	0.5			1.4			2			0.38			0.18786			0.63		
03/08/23 12:00	0.4			1.5			2			0.35			0.17592			0.59		
03/08/23 13:00	0.4			1.5			2			0.35			0.1752			0.58		
03/08/23 14:00	0.4			1.5			2			0.35			0.17484			0.58		
03/08/23 15:00	0.4			1.5			2			0.35			0.17466			0.58		
03/08/23 16:00	0.4			1.5			2			0.35			0.17412			0.58		
03/08/23 17:00	0.4			1.5			1			0.37			0.18456			0.62		
03/08/23 18:00	0.6			1.5			1			0.46			0.23238			0.77		
03/08/23 19:00	0.7			1.4			1			0.46			0.22932			0.76		
03/08/23 20:00	1			1.5			1			0.63			0.3138			1.05		
03/08/23 21:00	1.1			1.5			1			0.62			0.30918			1.03		
03/08/23 22:00	1.1			1.5			1			0.62			0.30834			1.03		
03/08/23 23:00	1			1.5			1			0.62			0.30894			1.03		
03/09/23 0:00	1			1.5			1			0.62			0.30924			1.03		
03/09/23 1:00	1			1.5			1			0.62			0.3093			1.03		
03/09/23 2:00	1			1.5			1			0.62			0.30918			1.03		
03/09/23 3:00	1.1			1.5			1			0.62			0.30906			1.03		
03/09/23 4:00	1.1			1.5			1			0.62			0.30804			1.03		
03/09/23 5:00	0.9			1.5			1			0.64			0.31752			1.06		
03/09/23 6:00	1			1.5			1			0.62			0.31008			1.03		
03/09/23 7:00	1			1.5			1			0.62			0.3093			1.03		
03/09/23 8:00	1			1.5			1			0.62			0.31104			1.04		
03/09/23 9:00	1			1.5			1			0.62			0.31158			1.04		
03/09/23 10:00	1			1.5			1			0.63			0.3138			1.05		
03/09/23 11:00	0.6			1.5			1			0.67			0.3339			1.11		
03/09/23 12:00	0.5			1.5			1			0.69			0.34704			1.16		
03/09/23 13:00	0.2			1.5			1			0.73			0.36702			1.22		
03/09/23 14:00	0.3			1.5			1			0.72			0.35796			1.19		
03/09/23 15:00	0.5			1.5			1			0.67			0.33738			1.12		
03/09/23 16:00	1			1.5			1			0.61			0.30714			1.02		
03/09/23 17:00	1			1.5			1			0.61			0.3063			1.02		
03/09/23 18:00	1			1.5			1			0.61			0.30696			1.02		
03/09/23 19:00	1			1.5			1			0.62			0.30756			1.03		
03/09/23 20:00	1			1.5			1			0.62			0.3081			1.03		
03/09/23 21:00	1			1.5			1			0.62			0.3081			1.03		
03/09/23 22:00	0.9			1.5			1			0.54			0.26862			0.9		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:00	0.5			1.4			2			0.38			0.19026			0.63		
03/10/23 0:00	0.4			1.5			2			0.34			0.17016			0.57		
03/10/23 1:00	0.4			1.5			2			0.34			0.17184			0.57		
03/10/23 2:00	0.4			1.5			2			0.34			0.17142			0.57		
03/10/23 3:00	0.5			1.5			2			0.34			0.17106			0.57		
03/10/23 4:00	0.4			1.5			2			0.34			0.17178			0.57		
03/10/23 5:00	0.5			1.5			2			0.35			0.17382			0.58		
03/10/23 6:00	0.4			1.5			2			0.35			0.17328			0.58		
03/10/23 7:00	0.4			1.5			2			0.35			0.17352			0.58		
03/10/23 8:00	0.5			1.5			2			0.35			0.17424			0.58		
03/10/23 9:00	0.4			1.5			2			0.35			0.17382			0.58		
03/10/23 10:00	0.5			1.4			1			0.42			0.2088			0.7		
03/10/23 11:00	0.5			1.5			2			0.35			0.17718			0.59		
03/10/23 12:00	0.4			1.5			2			0.35			0.17448			0.58		
03/10/23 13:00	0.4			1.5			1			0.35			0.17484			0.58		
03/10/23 14:00	0.4			1.5			1			0.35			0.17466			0.58		
03/10/23 15:00	0.5			1.5			1			0.41			0.20418			0.68		
03/10/23 16:00	0.5			1.4			1			0.39			0.19584			0.65		
03/10/23 17:00	0.7			1.5			1			0.55			0.27294			0.91		
03/10/23 18:00	0.8			1.5			1			0.63			0.31482			1.05		
03/10/23 19:00	1			1.5			1			0.62			0.3093			1.03		
03/10/23 20:00	0.9			1.4			1			0.5			0.25158			0.84		
03/10/23 21:00	0.6			1.4			2			0.38			0.18786			0.63		
03/10/23 22:00	0.5			1.5			2			0.35			0.17442			0.58		
03/10/23 23:00	0.5			1.5			2			0.35			0.17442			0.58		
03/11/23 0:00	0.5			1.5			2			0.35			0.17412			0.58		
03/11/23 1:00	0.5			1.5			2			0.35			0.174			0.58		
03/11/23 2:00	0.5			1.5			2			0.35			0.17382			0.58		
03/11/23 3:00	0.5			1.5			2			0.35			0.17382			0.58		
03/11/23 4:00	0.5			1.5			2			0.35			0.17406			0.58		
03/11/23 5:00	0.5			1.5			2			0.35			0.17442			0.58		
03/11/23 6:00	0.5			1.5			2			0.35			0.17436			0.58		
03/11/23 7:00	0.5			1.5			2			0.35			0.1746			0.58		
03/11/23 8:00	0.5			1.5			2			0.35			0.17406			0.58		
03/11/23 9:00	0.6			1.5			2			0.35			0.17394			0.58		
03/11/23 10:00	0.6			1.5			2			0.35			0.17406			0.58		
03/11/23 11:00	0.5			1.5			2			0.35			0.17442			0.58		
03/11/23 12:00	0.5			1.5			2			0.35			0.1743			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 13:00	0.5			1.5			2			0.35			0.174			0.58		
03/11/23 14:00	0.4			1.5			2			0.35			0.174			0.58		
03/11/23 15:00	0.4			1.5			2			0.35			0.1731			0.58		
03/11/23 16:00	0.5			1.5			1			0.37			0.18306			0.61		
03/11/23 17:00	0.7			1.5			2			0.4			0.20004			0.67		
03/11/23 18:00	0.4			1.5			2			0.34			0.16842			0.56		
03/11/23 19:00	0.7			1.4			1			0.61			0.30516			1.02		
03/11/23 20:00	0.7			1.5			1			0.65			0.32628			1.09		
03/11/23 21:00	0.4			1.5			1			0.69			0.34668			1.16		
03/11/23 22:00	0.3			1.5			1			0.72			0.36024			1.2		
03/11/23 23:00	0.3			1.5			1			0.72			0.35964			1.2		
03/12/23 0:00	0.5			1.5			1			0.67			0.33582			1.12		
03/12/23 1:00	0.7			1.5			1			0.56			0.28122			0.94		
03/12/23 2:00	0.6			1.6			1			0.56			0.28086			0.94		
03/12/23 3:00	1			1.5			1			0.57			0.28308			0.94		
03/12/23 4:00	0.4			1.5			1			0.69			0.3441			1.15		
03/12/23 5:00	0.4			1.5			1			0.69			0.34374			1.15		
03/12/23 6:00	0.8			1.5			1			0.55			0.27402			0.91		
03/12/23 7:00	0.5			1.4			2			0.37			0.1872			0.62		
03/12/23 8:00	0.5			1.5			2			0.35			0.1731			0.58		
03/12/23 9:00	0.5			1.5			1			0.36			0.17898			0.6		
03/12/23 10:00	0.5			1.5			1			0.35			0.17658			0.59		
03/12/23 11:00	0.5			1.5			1			0.36			0.1782			0.59		
03/12/23 12:00	0.5			1.5			2			0.35			0.17394			0.58		
03/12/23 13:00	0.5			1.5			2			0.35			0.1734			0.58		
03/12/23 14:00	0.5			1.4			1			0.4			0.20202			0.67		
03/12/23 15:00	0.6			1.5			1			0.42			0.21042			0.7		
03/12/23 16:00	0.7			1.4			1			0.45			0.22692			0.76		
03/12/23 17:00	0.3			1.5			1			0.7			0.35172			1.17		
03/12/23 18:00	0.2			1.5			1			0.72			0.35886			1.2		
03/12/23 19:00	0.3			1.5			1			0.7			0.35136			1.17		
03/12/23 20:00	0.2			1.5			1			0.72			0.35784			1.19		
03/12/23 21:00	0.3			1.5			1			0.71			0.35562			1.19		
03/12/23 22:00	0.5			1.5			1			0.68			0.33804			1.13		
03/12/23 23:00	0.7			1.5			1			0.49			0.24624			0.82		
03/13/23 0:00	0.5			1.5			2			0.37			0.18426			0.61		
03/13/23 1:00	0.5			1.5			2			0.35			0.17466			0.58		
03/13/23 2:00	0.5			1.5			2			0.35			0.1755			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 3:00	0.5			1.5			2			0.35			0.17412			0.58		
03/13/23 4:00	0.5			1.4			1			0.42			0.21024			0.7		
03/13/23 5:00	0.6			1.5			1			0.47			0.23466			0.78		
03/13/23 6:00	0.6			1.5			1			0.53			0.2643			0.88		
03/13/23 7:00	0.5			1.5			2			0.35			0.1731			0.58		
03/13/23 8:00	0.5			1.5			2			0.35			0.1734			0.58		
03/13/23 9:00	0.4			1.5			1			0.35			0.1734			0.58		
03/13/23 10:00	0.4			1.5			1			0.35			0.17358			0.58		
03/13/23 11:00	0.4			1.5			1			0.35			0.17382			0.58		
03/13/23 12:00	0.4			1.5			1			0.35			0.17376			0.58		
03/13/23 13:00	0.4			1.5			1			0.35			0.17424			0.58		
03/13/23 14:00	0.5			1.5			1			0.35			0.17424			0.58		
03/13/23 15:00	0.4			1.5			1			0.35			0.17382			0.58		
03/13/23 16:00	0.5			1.4			1			0.4			0.20172			0.67		
03/13/23 17:00	0.5			1.4			1			0.39			0.1944			0.65		
03/13/23 18:00	0.8			1.5			1			0.59			0.29658			0.99		
03/13/23 19:00	0.4			1.5			1			0.67			0.33648			1.12		
03/13/23 20:00	0.3			1.5			1			0.71			0.354			1.18		
03/13/23 21:00	0.4			1.5			1			0.68			0.33894			1.13		
03/13/23 22:00	0.7			1.5			1			0.5			0.24834			0.83		
03/13/23 23:00	0.5			1.5			2			0.37			0.18408			0.61		
03/14/23 0:00	0.5			1.5			2			0.35			0.17346			0.58		
03/14/23 1:00	0.5			1.5			2			0.34			0.17088			0.57		
03/14/23 2:00	0.5			1.4			1			0.34			0.17238			0.57		
03/14/23 3:00	0.5			1.5			1			0.35			0.17268			0.58		
03/14/23 4:00	0.5			1.5			2			0.34			0.17238			0.57		
03/14/23 5:00	0.5			1.5			2			0.34			0.17232			0.57		
03/14/23 6:00	0.5			1.5			2			0.34			0.17184			0.57		
03/14/23 7:00	0.6			1.4			1			0.44			0.22146			0.74		
03/14/23 8:00	0.8			1.5			1			0.54			0.27102			0.9		
03/14/23 9:00	0.6			1.5			1			0.43			0.21684			0.72		
03/14/23 10:00	0.7			1.5			1			0.59			0.29334			0.98		
03/14/23 11:00	0.4			1.5			1			0.67			0.33408			1.11		
03/14/23 12:00	0.4			1.5			1			0.68			0.33948			1.13		
03/14/23 13:00	0.2			1.5			1			0.71			0.35472			1.18		
03/14/23 14:00	0.3			1.5			1			0.68			0.34062			1.14		
03/14/23 15:00	0.6			1.5			1			0.64			0.32034			1.07		
03/14/23 16:00	0.4			1.5			1			0.68			0.3393			1.13		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 17:00	0.3			1.5			1			0.7			0.3486			1.16		
03/14/23 18:00	0.2			1.5			1			0.71			0.35574			1.19		
03/14/23 19:00	0.2			1.5			1			0.72			0.36024			1.2		
03/14/23 20:00	0.2			1.5			1			0.71			0.35514			1.18		
03/14/23 21:00	0.6			1.5			1			0.66			0.32904			1.1		
03/14/23 22:00	0.7			1.5			1			0.56			0.27972			0.93		
03/14/23 23:00	0.6			1.5			2			0.39			0.19332			0.64		
03/15/23 0:00	0.5			1.5			2			0.35			0.1728			0.58		
03/15/23 1:00	0.5			1.5			2			0.35			0.17304			0.58		
03/15/23 2:00	0.5			1.4			2			0.35			0.17346			0.58		
03/15/23 3:00	0.5			1.5			2			0.35			0.17358			0.58		
03/15/23 4:00	0.5			1.5			2			0.35			0.1734			0.58		
03/15/23 5:00	0.4			1.5			2			0.35			0.17346			0.58		
03/15/23 6:00	0.6			1.5			2			0.35			0.17694			0.59		
03/15/23 7:00	0.5			1.5			2			0.35			0.17358			0.58		
03/15/23 8:00	0.4			1.5			2			0.35			0.17364			0.58		
03/15/23 9:00	0.4			1.5			2			0.35			0.17346			0.58		
03/15/23 10:00	0.4			1.5			2			0.35			0.17322			0.58		
03/15/23 11:00	0.4			1.5			2			0.35			0.1728			0.58		
03/15/23 12:00	0.4			1.5			2			0.35			0.17328			0.58		
03/15/23 13:00	0.4			1.5			1			0.35			0.17364			0.58		
03/15/23 14:00	0.4			1.5			1			0.35			0.17382			0.58		
03/15/23 15:00	0.4			1.5			1			0.35			0.17388			0.58		
03/15/23 16:00	0.5			1.5			1			0.4			0.2013			0.67		
03/15/23 17:00	0.5			1.4			1			0.38			0.192			0.64		
03/15/23 18:00	0.8			1.5			1			0.57			0.28692			0.96		
03/15/23 19:00	0.5			1.5			1			0.66			0.33222			1.11		
03/15/23 20:00	0.4			1.5			1			0.69			0.34356			1.15		
03/15/23 21:00	0.8			1.4			1			0.51			0.25602			0.85		
03/15/23 22:00	0.4			1.5			2			0.36			0.1779			0.59		
03/15/23 23:00	0.4			1.5			2			0.35			0.17322			0.58		
03/16/23 0:00	0.4			1.5			2			0.35			0.1737			0.58		
03/16/23 1:00	0.4			1.5			2			0.35			0.17328			0.58		
03/16/23 2:00	0.5			1.4			2			0.35			0.17268			0.58		
03/16/23 3:00	0.5			1.5			2			0.35			0.1728			0.58		
03/16/23 4:00	0.5			1.5			2			0.35			0.17292			0.58		
03/16/23 5:00	0.5			1.5			2			0.35			0.17256			0.58		
03/16/23 6:00	0.6			1.6			2			0.36			0.17994			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 7:00	0.5			1.5			2			0.35			0.1734			0.58		
03/16/23 8:00	0.5			1.5			2			0.35			0.1737			0.58		
03/16/23 9:00	0.5			1.5			2			0.35			0.17394			0.58		
03/16/23 10:00	0.5			1.5			1			0.35			0.1743			0.58		
03/16/23 11:00	0.5			1.5			1			0.35			0.17484			0.58		
03/16/23 12:00	0.4			1.5			1			0.35			0.1743			0.58		
03/16/23 13:00	0.4			1.5			1			0.35			0.17268			0.58		
03/16/23 14:00	0.4			1.5			1			0.34			0.17178			0.57		
03/16/23 15:00	0.4			1.5			1			0.34			0.16872			0.56		
03/16/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/23 1:00	0			0			0	X		0.1			0.05034			0.17		
03/17/23 2:00	0.6			1.7			1			0.4			0.19752			0.66		
03/17/23 3:00	0.7			1.5			1			0.6			0.29946			1		
03/17/23 4:00	0.4			1.5			1			0.71			0.35634			1.19		
03/17/23 5:00	0.4			1.5			1			0.73			0.36252			1.21		
03/17/23 6:00	0.5			1.5			1			0.69			0.34536			1.15		
03/17/23 7:00	1			1.4			2			0.51			0.25392			0.85		
03/17/23 8:00	0.6			1.4			1			0.41			0.20274			0.68		
03/17/23 9:00	0.6			1.5			1			0.37			0.18384			0.61		
03/17/23 10:00	0.6			1.5			1			0.37			0.18468			0.62		
03/17/23 11:00	0.6			1.5			1			0.37			0.18522			0.62		
03/17/23 12:00	0.6			1.5			1			0.37			0.18468			0.62		
03/17/23 13:00	0.6			1.5			1			0.37			0.18456			0.62		
03/17/23 14:00	0.5			1.5			1			0.37			0.18342			0.61		
03/17/23 15:00	0.5			1.5			1			0.37			0.18402			0.61		
03/17/23 16:00	0.7			1.5			1			0.45			0.22668			0.76		
03/17/23 17:00	0.7			1.5			1			0.44			0.21966			0.73		
03/17/23 18:00	0.6			1.5			1			0.66			0.32802			1.09		
03/17/23 19:00	0.3			1.5			1			0.69			0.34566			1.15		
03/17/23 20:00	0.6			1.5			1			0.66			0.33024			1.1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 21:00	0.5			1.5			1			0.68			0.34044			1.13		
03/17/23 22:00	0.8			1.5			1			0.49			0.24324			0.81		
03/17/23 23:00	0.7			1.5			2			0.39			0.19464			0.65		
03/18/23 0:00	0.8			1.5			2			0.37			0.18354			0.61		
03/18/23 1:00	0.6			1.5			2			0.37			0.18402			0.61		
03/18/23 2:00	0.6			1.6			2			0.37			0.1845			0.62		
03/18/23 3:00	0.6			1.5			2			0.37			0.18396			0.61		
03/18/23 4:00	0.6			1.5			2			0.37			0.18366			0.61		
03/18/23 5:00	0.7			1.5			2			0.37			0.1842			0.61		
03/18/23 6:00	0.6			1.5			2			0.37			0.18384			0.61		
03/18/23 7:00	0.6			1.5			2			0.37			0.1839			0.61		
03/18/23 8:00	0.6			1.5			1			0.37			0.18396			0.61		
03/18/23 9:00	0.6			1.5			1			0.37			0.18666			0.62		
03/18/23 10:00	0.6			1.5			1			0.37			0.186			0.62		
03/18/23 11:00	0.6			1.5			1			0.37			0.18552			0.62		
03/18/23 12:00	0.6			1.5			1			0.37			0.1845			0.62		
03/18/23 13:00	0.6			1.5			1			0.37			0.18378			0.61		
03/18/23 14:00	0.6			1.5			1			0.37			0.18378			0.61		
03/18/23 15:00	0.7			1.5			1			0.42			0.21018			0.7		
03/18/23 16:00	0.6			1.5			1			0.42			0.21234			0.71		
03/18/23 17:00	0.8			1.5			1			0.61			0.30336			1.01		
03/18/23 18:00	0.2			1.5			1			0.72			0.35952			1.2		
03/18/23 19:00	0.5			1.5			1			0.66			0.3315			1.11		
03/18/23 20:00	0.6			1.5			1			0.65			0.32586			1.09		
03/18/23 21:00	0.8			1.5			1			0.49			0.2469			0.82		
03/18/23 22:00	0.6			1.5			1			0.37			0.18654			0.62		
03/18/23 23:00	0.6			1.5			1			0.36			0.18246			0.61		
03/19/23 0:00	0.6			1.5			1			0.37			0.18282			0.61		
03/19/23 1:00	0.6			1.5			1			0.36			0.1818			0.61		
03/19/23 2:00	0.6			1.6			1			0.37			0.1833			0.61		
03/19/23 3:00	0.6			1.5			1			0.37			0.18408			0.61		
03/19/23 4:00	0.7			1.5			1			0.37			0.18414			0.61		
03/19/23 5:00	0.6			1.5			2			0.37			0.18432			0.61		
03/19/23 6:00	0.6			1.5			2			0.37			0.1845			0.62		
03/19/23 7:00	0.6			1.5			1			0.37			0.18438			0.61		
03/19/23 8:00	0.6			1.5			2			0.37			0.18372			0.61		
03/19/23 9:00	0.6			1.5			2			0.36			0.18228			0.61		
03/19/23 10:00	0.6			1.5			2			0.36			0.1812			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 11:00	0.6			1.5			2			0.36			0.1821			0.61		
03/19/23 12:00	0.6			1.5			1			0.39			0.19662			0.66		
03/19/23 13:00	0.6			1.5			1			0.37			0.18378			0.61		
03/19/23 14:00	0.6			1.5			1			0.37			0.18426			0.61		
03/19/23 15:00	0.6			1.5			1			0.46			0.23166			0.77		
03/19/23 16:00	0.6			1.5			1			0.41			0.20616			0.69		
03/19/23 17:00	0.8			1.5			1			0.65			0.32718			1.09		
03/19/23 18:00	0.4			1.5			1			0.69			0.3459			1.15		
03/19/23 19:00	0.5			1.5			1			0.67			0.33462			1.12		
03/19/23 20:00	0.5			1.5			1			0.68			0.3378			1.13		
03/19/23 21:00	0.7			1.5			1			0.64			0.32214			1.07		
03/19/23 22:00	0.8			1.5			1			0.63			0.31374			1.05		
03/19/23 23:00	0.8			1.5			1			0.63			0.3171			1.06		
03/20/23 0:00	0.9			1.5			1			0.53			0.26484			0.88		
03/20/23 1:00	0.6			1.4			1			0.39			0.19566			0.65		
03/20/23 2:00	0.6			1.5			1			0.37			0.1845			0.62		
03/20/23 3:00	0.6			1.5			2			0.37			0.18486			0.62		
03/20/23 4:00	0.6			1.5			2			0.37			0.1851			0.62		
03/20/23 5:00	0.6			1.5			1			0.41			0.20256			0.68		
03/20/23 6:00	0.6			1.5			2			0.37			0.18528			0.62		
03/20/23 7:00	0.6			1.4			1			0.41			0.20562			0.69		
03/20/23 8:00	0.6			1.5			1			0.4			0.1986			0.66		
03/20/23 9:00	0.6			1.5			1			0.37			0.18408			0.61		
03/20/23 10:00	0.6			1.5			1			0.37			0.18426			0.61		
03/20/23 11:00	0.6			1.5			1			0.37			0.18444			0.61		
03/20/23 12:00	0.6			1.5			1			0.37			0.18438			0.61		
03/20/23 13:00	0.6			1.5			1			0.37			0.18474			0.62		
03/20/23 14:00	0.6			1.5			1			0.37			0.18438			0.61		
03/20/23 15:00	0.6			1.5			1			0.37			0.1845			0.62		
03/20/23 16:00	0.7			1.5			1			0.48			0.23952			0.8		
03/20/23 17:00	0.9			1.5			1			0.49			0.24636			0.82		
03/20/23 18:00	0.5			1.5			1			0.69			0.34464			1.15		
03/20/23 19:00	0.4			1.5			1			0.69			0.34302			1.14		
03/20/23 20:00	0.3			1.3			1			0.48			0.2391			0.8		
03/20/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/23 16:00	0			0			0	X		0.33			0.16356			0.55		
03/22/23 17:00	0.6			1.5			1			0.54			0.27186			0.91		
03/22/23 18:00	0.3			1.5			1			0.72			0.36102			1.2		
03/22/23 19:00	0.3			1.5			1			0.72			0.35784			1.19		
03/22/23 20:00	0.4			1.5			1			0.7			0.34962			1.17		
03/22/23 21:00	0.7			1.5			1			0.65			0.32526			1.08		
03/22/23 22:00	0.9			1.5			1			0.55			0.27588			0.92		
03/22/23 23:00	0.6			1.4			1			0.4			0.20124			0.67		
03/23/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/23 14:00	0			0			0	X		0.04			0.01938			0.06		
03/23/23 15:00	0.6			1.1			1			0.33			0.16278			0.54		
03/23/23 16:00	0.6			1.4			1			0.46			0.22872			0.76		
03/23/23 17:00	1			1.5			1			0.62			0.30876			1.03		
03/23/23 18:00	1			1.5			1			0.62			0.3084			1.03		
03/23/23 19:00	1			1.5			1			0.61			0.30672			1.02		
03/23/23 20:00	1			1.5			1			0.61			0.30552			1.02		
03/23/23 21:00	1			1.5			1			0.61			0.30456			1.02		
03/23/23 22:00	0.9			1.6			1			0.48			0.24			0.8		
03/23/23 23:00	0			0			0	X		0.19			0.09738			0.32		
03/24/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/24/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/27/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/28/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/30/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
04/01/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/01/23 0:00	0.5			0			1.5			0	X		0.18774			0.63		
01/01/23 1:00	0.5			0			1.5			0	X		0.18642			0.62		
01/01/23 2:00	0.5			0			1.3			0	X		0.18678			0.62		
01/01/23 3:00	0.5			0			1.5			0	X		0.18648			0.62		
01/01/23 4:00	0.5			0			1.5			0	X		0.18564			0.62		
01/01/23 5:00	0.5			0			1.5			0	X		0.18522			0.62		
01/01/23 6:00	0.5			0			1.5			0	X		0.18516			0.62		
01/01/23 7:00	0.5			0			1.5			0	X		0.18522			0.62		
01/01/23 8:00	0.5			0			1.5			0	X		0.18492			0.62		
01/01/23 9:00	0.5			0			1.5			0	X		0.1848			0.62		
01/01/23 10:00	0.5			0			1.5			0	X		0.18444			0.61		
01/01/23 11:00	0.5			0			1.5			0	X		0.18354			0.61		
01/01/23 12:00	0.5			0			1.5			0	X		0.18324			0.61		
01/01/23 13:00	0.5			0			1.5			0	X		0.18354			0.61		
01/01/23 14:00	0.5			0			1.5			0	X		0.18372			0.61		
01/01/23 15:00	0.5			0			1.5			0	X		0.18426			0.61		
01/01/23 16:00	0.5			0			1.5			0	X		0.18474			0.62		
01/01/23 17:00	0.5			0			1.5			0	X		0.1854			0.62		
01/01/23 18:00	0.5			0			1.5			0	X		0.18606			0.62		
01/01/23 19:00	0.5			0			1.5			0	X		0.18648			0.62		
01/01/23 20:00	0.6			0			1.5			0	X		0.18744			0.62		
01/01/23 21:00	0.6			0			1.5			0	X		0.18726			0.62		
01/01/23 22:00	0.5			0			1.5			0	X		0.18684			0.62		
01/01/23 23:00	0.6			0			1.5			0	X		0.18654			0.62		
01/02/23 0:00	0.5			0			1.5			0	X		0.1872			0.62		
01/02/23 1:00	0.5			0			1.5			0	X		0.18726			0.62		
01/02/23 2:00	0.5			0			1.4			0	X		0.18732			0.62		
01/02/23 3:00	0.5			0			1.5			0	X		0.18702			0.62		
01/02/23 4:00	0.6			0			1.5			0	X		0.1866			0.62		
01/02/23 5:00	0.6			0			1.5			0	X		0.1872			0.62		
01/02/23 6:00	0.6			0			1.5			0	X		0.18966			0.63		
01/02/23 7:00	0.7			0			1.4			0	X		0.2979			0.99		
01/02/23 8:00	0.7			1			1.5			0	X		0.2124			0.71		
01/02/23 9:00	0.6			1			1.5			0	X		0.18642			0.62		
01/02/23 10:00	0.6			0			1.2			0	X		0.21552			0.72		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/02/23 11:00	0.6			0			1.3			0	X		0.22074			0.74		
01/02/23 12:00	0.7			0			1.4			0.32			0.24366			0.81		
01/02/23 13:00	0.9			0			1.3			0.56			0.29808			0.99		
01/02/23 14:00	0.4			0			1.5			0.74			0.3945			1.32		
01/02/23 15:00	0.4			0			1.5			0.74			0.39024			1.3		
01/02/23 16:00	0.4			0			1.5			0.73			0.39			1.3		
01/02/23 17:00	0.4			0			1.5			0.73			0.39006			1.3		
01/02/23 18:00	0.4			0			1.5			0.73			0.38934			1.3		
01/02/23 19:00	0.4			0			1.5			0.73			0.38688			1.29		
01/02/23 20:00	0.4			0			1.5			0.73			0.3846			1.28		
01/02/23 21:00	0.5			0			1.5			0.72			0.38124			1.27		
01/02/23 22:00	0.6			0			1.5			0.7			0.37194			1.24		
01/02/23 23:00	0.7			0			1.5			0.69			0.36642			1.22		
01/03/23 0:00	0.6			0			1.5			0.71			0.3738			1.25		
01/03/23 1:00	0.6			0			1.5			0.7			0.37164			1.24		
01/03/23 2:00	0.6			0			1.5			0.7			0.37176			1.24		
01/03/23 3:00	0.6			0			1.5			0.7			0.3747			1.25		
01/03/23 4:00	0.5			0			1.5			0.71			0.37938			1.26		
01/03/23 5:00	0.5			0			1.5			0.72			0.3825			1.28		
01/03/23 6:00	0.3			0			1.5			0.76			0.40026			1.33		
01/03/23 7:00	0.4			0			1.5			0.72			0.38544			1.28		
01/03/23 8:00	1			0			1.5			0.65			0.34638			1.15		
01/03/23 9:00	1			0			1.5			0.65			0.34884			1.16		
01/03/23 10:00	1.2			0			1.5			0.62			0.33216			1.11		
01/03/23 11:00	1.1			0			1.5			0.61			0.32862			1.1		
01/03/23 12:00	1			0			1.5			0.63			0.33756			1.13		
01/03/23 13:00	1.1			0			1.5			0.63			0.33564			1.12		
01/03/23 14:00	1			0			1.5			0.65			0.345			1.15		
01/03/23 15:00	0.4			0			1.5			0.74			0.39138			1.3		
01/03/23 16:00	0.4			0			1.5			0.72			0.38166			1.27		
01/03/23 17:00	0.4			0			1.5			0.72			0.38028			1.27		
01/03/23 18:00	0.4			0			1.5			0.72			0.38052			1.27		
01/03/23 19:00	0.5			0			1.5			0.71			0.37722			1.26		
01/03/23 20:00	0.4			0			1.5			0.73			0.38676			1.29		
01/03/23 21:00	0.4			0			1.5			0.73			0.38592			1.29		
01/03/23 22:00	0.4			0			1.5			0.72			0.38034			1.27		
01/03/23 23:00	0.8			0			1.5			0.67			0.35646			1.19		
01/04/23 0:00	0.9			0			1.5			0.58			0.30888			1.03		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/04/23 1:00	0.7			0			1.5			0.58			0.31092			1.04		
01/04/23 2:00	0.7			0			1.7			0.58			0.31104			1.04		
01/04/23 3:00	0.7			0			1.5			0.58			0.31116			1.04		
01/04/23 4:00	0.7			0			1.5			0.58			0.3108			1.04		
01/04/23 5:00	0.8			0			1.5			0.58			0.3108			1.04		
01/04/23 6:00	0.7			0			1.5			0.58			0.31086			1.04		
01/04/23 7:00	1.3			0			1.5			0.61			0.32772			1.09		
01/04/23 8:00	0.9			0			1.4			0.46			0.25884			0.86		
01/04/23 9:00	0.6			0			1.3			0.03			0.20184			0.67		
01/04/23 10:00	0.5			0			1.5			0	X		0.18432			0.61		
01/04/23 11:00	0.5			0			1.5			0	X		0.18612			0.62		
01/04/23 12:00	0.5			0			1.5			0	X		0.1875			0.63		
01/04/23 13:00	0.5			0			1.5			0	X		0.18672			0.62		
01/04/23 14:00	0.5			0			1.5			0	X		0.18504			0.62		
01/04/23 15:00	0.5			0			1.5			0	X		0.18462			0.62		
01/04/23 16:00	0.5			0			1.5			0	X		0.18342			0.61		
01/04/23 17:00	0.5			0			1.5			0	X		0.1821			0.61		
01/04/23 18:00	0.5			0			1.5			0	X		0.18348			0.61		
01/04/23 19:00	0.5			0			1.5			0	X		0.1854			0.62		
01/04/23 20:00	0.5			0			1.5			0	X		0.18432			0.61		
01/04/23 21:00	0.5			0			1.5			0	X		0.18432			0.61		
01/04/23 22:00	0.5			0			1.5			0	X		0.18366			0.61		
01/04/23 23:00	0.5			0			1.5			0	X		0.18318			0.61		
01/05/23 0:00	0.5			0			1.5			0	X		0.18612			0.62		
01/05/23 1:00	0.5			0			1.5			0	X		0.18624			0.62		
01/05/23 2:00	0.5			0			1.4			0	X		0.18732			0.62		
01/05/23 3:00	0.5			0			1.5			0	X		0.18738			0.62		
01/05/23 4:00	0.5			0			1.5			0	X		0.1872			0.62		
01/05/23 5:00	0.5			0			1.5			0	X		0.186			0.62		
01/05/23 6:00	0.5			0			1.5			0	X		0.18618			0.62		
01/05/23 7:00	0.5			0			1.5			0	X		0.18624			0.62		
01/05/23 8:00	0.5			0			1.5			0	X		0.1866			0.62		
01/05/23 9:00	0.5			0			1.5			0	X		0.1863			0.62		
01/05/23 10:00	0.5			0			1.5			0	X		0.18552			0.62		
01/05/23 11:00	0.7			1			1.5			0	X		0.18594			0.62		
01/05/23 12:00	0.7			0			1.5			0	X		0.18738			0.62		
01/05/23 13:00	0.7			0			1.5			0	X		0.18786			0.63		
01/05/23 14:00	0.7			0			1.5			0	X		0.18786			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/05/23 15:00	1.1			0			1.3			0.28			0.25794			0.86		
01/05/23 16:00	1			0			1.4			0.44			0.237			0.79		
01/05/23 17:00	1.1			0			1.5			0.63			0.33618			1.12		
01/05/23 18:00	1.2			0			1.5			0.55			0.29238			0.97		
01/05/23 19:00	0.7			0			1.3			0.29			0.2088			0.7		
01/05/23 20:00	0.7			0			1.5			0		X	0.18762			0.63		
01/05/23 21:00	0.7			0			1.5			0		X	0.18816			0.63		
01/05/23 22:00	0.7			1			1.5			0		X	0.18786			0.63		
01/05/23 23:00	0.7			0			1.5			0		X	0.18774			0.63		
01/06/23 0:00	0.7			0			1.5			0		X	0.18804			0.63		
01/06/23 1:00	0.7			0			1.5			0		X	0.18768			0.63		
01/06/23 2:00	0.7			0			1.5			0		X	0.18834			0.63		
01/06/23 3:00	0.7			0			1.5			0		X	0.18888			0.63		
01/06/23 4:00	0.7			0			1.5			0		X	0.18888			0.63		
01/06/23 5:00	0.7			0			1.5			0		X	0.18858			0.63		
01/06/23 6:00	0.7			1			1.5			0		X	0.18828			0.63		
01/06/23 7:00	0.7			0			1.5			0		X	0.18786			0.63		
01/06/23 8:00	0.7			0			1.5			0		X	0.1881			0.63		
01/06/23 9:00	0.7			0			1.5			0		X	0.18792			0.63		
01/06/23 10:00	0.7			0			1.5			0		X	0.18762			0.63		
01/06/23 11:00	0.7			0			1.5			0		X	0.18732			0.62		
01/06/23 12:00	0.7			0			1.5			0		X	0.18756			0.63		
01/06/23 13:00	0.7			0			1.5			0		X	0.18756			0.63		
01/06/23 14:00	0.7			0			1.5			0		X	0.18762			0.63		
01/06/23 15:00	0.7			0			1.4			0		X	0.22074			0.74		
01/06/23 16:00	0.8			0			1.4			0.34			0.2433			0.81		
01/06/23 17:00	1.4			0			1.5			0.57			0.30318			1.01		
01/06/23 18:00	1.1			0			1.5			0.62			0.33138			1.1		
01/06/23 19:00	1.2			0			1.5			0.62			0.33132			1.1		
01/06/23 20:00	0.9			0			1.5			0.47			0.2517			0.84		
01/06/23 21:00	0.8			0			1.3			0.32			0.20604			0.69		
01/06/23 22:00	0.7			0			1.5			0		X	0.18714			0.62		
01/06/23 23:00	0.7			0			1.5			0		X	0.18774			0.63		
01/07/23 0:00	0.7			0			1.5			0		X	0.18798			0.63		
01/07/23 1:00	0.7			0			1.5			0		X	0.1881			0.63		
01/07/23 2:00	0.7			1			1.7			0		X	0.18708			0.62		
01/07/23 3:00	0.7			0			1.5			0		X	0.18684			0.62		
01/07/23 4:00	0.7			1			1.5			0		X	0.18552			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/07/23 5:00	0.7			0			1.5			0	X		0.18582			0.62		
01/07/23 6:00	0.7			0			1.5			0	X		0.18636			0.62		
01/07/23 7:00	0.7			0			1.5			0	X		0.18732			0.62		
01/07/23 8:00	0.7			0			1.5			0	X		0.18654			0.62		
01/07/23 9:00	0.7			0			1.5			0	X		0.18546			0.62		
01/07/23 10:00	0.7			0			1.5			0	X		0.18534			0.62		
01/07/23 11:00	0.7			0			1.5			0	X		0.18576			0.62		
01/07/23 12:00	0.7			0			1.5			0	X		0.18678			0.62		
01/07/23 13:00	0.7			0			1.5			0	X		0.18636			0.62		
01/07/23 14:00	0.7			0			1.5			0	X		0.18702			0.62		
01/07/23 15:00	0.7			0			1.5			0	X		0.18636			0.62		
01/07/23 16:00	0.7			0			1.5			0	X		0.18642			0.62		
01/07/23 17:00	0.7			0			1.5			0	X		0.18606			0.62		
01/07/23 18:00	0.7			1			1.5			0	X		0.18498			0.62		
01/07/23 19:00	0.7			1			1.5			0	X		0.1842			0.61		
01/07/23 20:00	0.7			1			1.5			0	X		0.18342			0.61		
01/07/23 21:00	0.7			0			1.5			0	X		0.18318			0.61		
01/07/23 22:00	0.7			0			1.5			0	X		0.18402			0.61		
01/07/23 23:00	0.7			0			1.5			0	X		0.18378			0.61		
01/08/23 0:00	0.7			0			1.5			0	X		0.18288			0.61		
01/08/23 1:00	0.7			0			1.5			0	X		0.1839			0.61		
01/08/23 2:00	0.7			0			1.6			0	X		0.18492			0.62		
01/08/23 3:00	0.7			1			1.5			0	X		0.1848			0.62		
01/08/23 4:00	0.7			0			1.5			0	X		0.18474			0.62		
01/08/23 5:00	0.7			0			1.5			0	X		0.18504			0.62		
01/08/23 6:00	0.7			0			1.5			0	X		0.18582			0.62		
01/08/23 7:00	0.7			0			1.5			0	X		0.18768			0.63		
01/08/23 8:00	0.7			0			1.5			0	X		0.18816			0.63		
01/08/23 9:00	0.7			0			1.5			0	X		0.18834			0.63		
01/08/23 10:00	0.7			0			1.5			0	X		0.18762			0.63		
01/08/23 11:00	0.7			0			1.5			0	X		0.18594			0.62		
01/08/23 12:00	0.7			0			1.5			0	X		0.18588			0.62		
01/08/23 13:00	0.7			0			1.5			0	X		0.18606			0.62		
01/08/23 14:00	0.7			0			1.5			0	X		0.18618			0.62		
01/08/23 15:00	0.8			0			1.3			0	X		0.21846			0.73		
01/08/23 16:00	0.8			0			1.4			0.33			0.2358			0.79		
01/08/23 17:00	1.1			0			1.4			0.54			0.2919			0.97		
01/08/23 18:00	1.1			0			1.5			0.63			0.33564			1.12		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/08/23 19:00	1.2			0			1.5			0.62			0.3321			1.11		
01/08/23 20:00	1.2			0			1.5			0.62			0.33462			1.12		
01/08/23 21:00	1.1			0			1.5			0.54			0.29076			0.97		
01/08/23 22:00	0.8			0			1.3			0.28			0.19296			0.64		
01/08/23 23:00	0.7			0			1.5			0		X	0.18528			0.62		
01/09/23 0:00	0.7			0			1.5			0		X	0.18618			0.62		
01/09/23 1:00	0.7			0			1.5			0		X	0.1857			0.62		
01/09/23 2:00	0.7			0			1.5			0		X	0.18528			0.62		
01/09/23 3:00	0.7			1			1.5			0		X	0.18456			0.62		
01/09/23 4:00	0.7			0			1.5			0		X	0.18348			0.61		
01/09/23 5:00	0.7			0			1.5			0		X	0.18378			0.61		
01/09/23 6:00	0.7			0			1.5			0		X	0.18534			0.62		
01/09/23 7:00	0.7			0			1.5			0		X	0.18564			0.62		
01/09/23 8:00	0.7			0			1.5			0		X	0.18678			0.62		
01/09/23 9:00	0.7			0			1.5			0		X	0.1872			0.62		
01/09/23 10:00	0.7			0			1.5			0		X	0.18732			0.62		
01/09/23 11:00	0.7			0			1.5			0		X	0.18816			0.63		
01/09/23 12:00	0.7			0			1.5			0		X	0.18858			0.63		
01/09/23 13:00	0.7			0			1.4			0.07			0.2199			0.73		
01/09/23 14:00	0.8			0			1.5			0.35			0.20994			0.7		
01/09/23 15:00	1.1			0			1.4			0.56			0.3009			1		
01/09/23 16:00	1			0			1.5			0.65			0.34638			1.15		
01/09/23 17:00	1			0			1.5			0.65			0.34806			1.16		
01/09/23 18:00	1			0			1.5			0.65			0.3438			1.15		
01/09/23 19:00	1.1			0			1.5			0.64			0.3429			1.14		
01/09/23 20:00	1.1			0			1.5			0.64			0.34308			1.14		
01/09/23 21:00	1.1			0			1.4			0.49			0.2781			0.93		
01/09/23 22:00	0.8			0			1.4			0		X	0.20844			0.69		
01/09/23 23:00	0.8			0			1.5			0		X	0.1869			0.62		
01/10/23 0:00	0.7			0			1.5			0		X	0.18672			0.62		
01/10/23 1:00	0.7			0			1.5			0		X	0.18666			0.62		
01/10/23 2:00	0.7			0			1.4			0		X	0.18546			0.62		
01/10/23 3:00	0.7			1			1.5			0		X	0.18546			0.62		
01/10/23 4:00	0.7			0			1.5			0		X	0.18642			0.62		
01/10/23 5:00	0.7			0			1.5			0		X	0.1863			0.62		
01/10/23 6:00	0.7			0			1.5			0		X	0.18528			0.62		
01/10/23 7:00	0.7			0			1.5			0		X	0.18468			0.62		
01/10/23 8:00	0.7			0			1.5			0		X	0.18504			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/10/23 9:00	0.7			0			1.5			0	X		0.18456			0.62		
01/10/23 10:00	0.7			0			1.5			0	X		0.18582			0.62		
01/10/23 11:00	0.7			0			1.5			0	X		0.18654			0.62		
01/10/23 12:00	0.7			0			1.5			0	X		0.18666			0.62		
01/10/23 13:00	0.7			0			1.5			0	X		0.18702			0.62		
01/10/23 14:00	0.7			0			1.5			0	X		0.18732			0.62		
01/10/23 15:00	0.7			0			1.3			0.06			0.21912			0.73		
01/10/23 16:00	0.8			0			1.4			0.36			0.21762			0.73		
01/10/23 17:00	1.2			0			1.4			0.59			0.31452			1.05		
01/10/23 18:00	1.1			0			1.5			0.64			0.34278			1.14		
01/10/23 19:00	1.1			0			1.5			0.64			0.34296			1.14		
01/10/23 20:00	1.1			0			1.5			0.63			0.3384			1.13		
01/10/23 21:00	1.2			0			1.5			0.61			0.33084			1.1		
01/10/23 22:00	1.2			0			1.5			0.54			0.2925			0.98		
01/10/23 23:00	0.7			1			1.3			0.29			0.20184			0.67		
01/11/23 0:00	0.7			1			1.5			0	X		0.18552			0.62		
01/11/23 1:00	0.7			0			1.5			0	X		0.18672			0.62		
01/11/23 2:00	0.7			0			1.5			0	X		0.1881			0.63		
01/11/23 3:00	0.7			1			1.5			0	X		0.18708			0.62		
01/11/23 4:00	0.7			1			1.5			0	X		0.18666			0.62		
01/11/23 5:00	0.7			1			1.5			0	X		0.18684			0.62		
01/11/23 6:00	0.7			1			1.5			0	X		0.18732			0.62		
01/11/23 7:00	0.7			1			1.5			0	X		0.18696			0.62		
01/11/23 8:00	0.7			1			1.5			0	X		0.18672			0.62		
01/11/23 9:00	0.7			0			1.5			0	X		0.18726			0.62		
01/11/23 10:00	0.7			0			1.5			0	X		0.18738			0.62		
01/11/23 11:00	0.7			0			1.5			0	X		0.18732			0.62		
01/11/23 12:00	0.7			1			1.5			0	X		0.1863			0.62		
01/11/23 13:00	0.7			1			1.5			0	X		0.18492			0.62		
01/11/23 14:00	0.7			0			1.3			0	X		0.21648			0.72		
01/11/23 15:00	0.8			0			1.5			0.33			0.22566			0.75		
01/11/23 16:00	1.1			0			1.4			0.56			0.3			1		
01/11/23 17:00	1.1			0			1.5			0.64			0.34098			1.14		
01/11/23 18:00	1.2			0			1.5			0.62			0.33312			1.11		
01/11/23 19:00	1.2			0			1.5			0.62			0.33054			1.1		
01/11/23 20:00	1.1			0			1.5			0.54			0.29076			0.97		
01/11/23 21:00	0.8			0			1.3			0.24			0.2232			0.74		
01/11/23 22:00	0.7			1			1.5			0	X		0.1866			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/11/23 23:00	0.7			1			1.5			0	X		0.18684			0.62		
01/12/23 0:00	0.7			0			1.5			0	X		0.18828			0.63		
01/12/23 1:00	0.7			0			1.5			0	X		0.18864			0.63		
01/12/23 2:00	0.7			0			1.6			0	X		0.18828			0.63		
01/12/23 3:00	0.7			1			1.5			0	X		0.18822			0.63		
01/12/23 4:00	0.7			0			1.5			0	X		0.18876			0.63		
01/12/23 5:00	0.7			0			1.5			0	X		0.18888			0.63		
01/12/23 6:00	0.7			0			1.5			0	X		0.1884			0.63		
01/12/23 7:00	0.7			1			1.5			0	X		0.18762			0.63		
01/12/23 8:00	0.7			1			1.5			0	X		0.1851			0.62		
01/12/23 9:00	0.7			0			1.5			0	X		0.18576			0.62		
01/12/23 10:00	0.7			1			1.5			0	X		0.18576			0.62		
01/12/23 11:00	0.7			0			1.5			0	X		0.18552			0.62		
01/12/23 12:00	0.7			0			1.5			0	X		0.1851			0.62		
01/12/23 13:00	0.7			0			1.5			0	X		0.18468			0.62		
01/12/23 14:00	0.7			0			1.5			0	X		0.1851			0.62		
01/12/23 15:00	0.7			0			1.4			0.13			0.21066			0.7		
01/12/23 16:00	0.7			0			1.5			0.36			0.1962			0.65		
01/12/23 17:00	1			0			1.5			0.52			0.27942			0.93		
01/12/23 18:00	1.2			0			1.5			0.62			0.33024			1.1		
01/12/23 19:00	1.2			0			1.5			0.62			0.33006			1.1		
01/12/23 20:00	1.2			0			1.5			0.62			0.33012			1.1		
01/12/23 21:00	1.1			0			1.5			0.53			0.2835			0.95		
01/12/23 22:00	0.8			0			1.3			0.28			0.20508			0.68		
01/12/23 23:00	0.7			1			1.5			0	X		0.1869			0.62		
01/13/23 0:00	0.7			0			1.5			0	X		0.18504			0.62		
01/13/23 1:00	0.7			1			1.5			0	X		0.1851			0.62		
01/13/23 2:00	0.7			1			1.7			0	X		0.1851			0.62		
01/13/23 3:00	0.7			1			1.5			0	X		0.18522			0.62		
01/13/23 4:00	0.7			1			1.5			0	X		0.18528			0.62		
01/13/23 5:00	0.7			1			1.5			0	X		0.18516			0.62		
01/13/23 6:00	0.7			1			1.5			0	X		0.18552			0.62		
01/13/23 7:00	0.7			1			1.5			0	X		0.18582			0.62		
01/13/23 8:00	0.7			0			1.5			0	X		0.18528			0.62		
01/13/23 9:00	0.7			0			1.5			0	X		0.18498			0.62		
01/13/23 10:00	0.7			0			1.5			0	X		0.18714			0.62		
01/13/23 11:00	0.7			1			1.5			0	X		0.18684			0.62		
01/13/23 12:00	0.7			1			1.5			0	X		0.18672			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/13/23 13:00	0.7			1			1.5			0	X		0.18606			0.62		
01/13/23 14:00	0.7			1			1.5			0	X		0.18594			0.62		
01/13/23 15:00	0.7			1			1.5			0	X		0.18588			0.62		
01/13/23 16:00	0.7			1			1.5			0	X		0.18576			0.62		
01/13/23 17:00	0.7			1			1.5			0	X		0.18588			0.62		
01/13/23 18:00	0.7			1			1.5			0	X		0.186			0.62		
01/13/23 19:00	0.7			0			1.5			0	X		0.18684			0.62		
01/13/23 20:00	0.7			0			1.5			0	X		0.1875			0.63		
01/13/23 21:00	0.7			0			1.5			0	X		0.1878			0.63		
01/13/23 22:00	0.7			0			1.5			0	X		0.18774			0.63		
01/13/23 23:00	0.7			0			1.5			0	X		0.18732			0.62		
01/14/23 0:00	0.7			0			1.5			0	X		0.18678			0.62		
01/14/23 1:00	0.7			0			1.5			0	X		0.18648			0.62		
01/14/23 2:00	0.7			0			1.4			0	X		0.18588			0.62		
01/14/23 3:00	0.7			0			1.5			0	X		0.18516			0.62		
01/14/23 4:00	0.7			0			1.5			0	X		0.18474			0.62		
01/14/23 5:00	0.7			0			1.5			0	X		0.18462			0.62		
01/14/23 6:00	0.7			1			1.5			0	X		0.1845			0.62		
01/14/23 7:00	0.7			1			1.5			0	X		0.18378			0.61		
01/14/23 8:00	0.7			1			1.5			0	X		0.183			0.61		
01/14/23 9:00	0.7			0			1.3			0	X		0.2142			0.71		
01/14/23 10:00	0.7			1			1.5			0	X		0.21084			0.7		
01/14/23 11:00	0.7			0			1.5			0	X		0.1863			0.62		
01/14/23 12:00	0.7			0			1.5			0	X		0.1866			0.62		
01/14/23 13:00	0.7			0			1.5			0	X		0.18726			0.62		
01/14/23 14:00	0.8			0			1.3			0.07			0.23412			0.78		
01/14/23 15:00	0.7			1			1.5			0.35			0.20556			0.69		
01/14/23 16:00	1.1			0			1.4			0.55			0.29322			0.98		
01/14/23 17:00	1.1			0			1.5			0.62			0.33108			1.1		
01/14/23 18:00	1.1			0			1.5			0.62			0.33366			1.11		
01/14/23 19:00	1.2			0			1.5			0.55			0.29706			0.99		
01/14/23 20:00	0.8			1			1.3			0.3			0.2025			0.68		
01/14/23 21:00	0.7			1			1.5			0	X		0.1866			0.62		
01/14/23 22:00	0.7			1			1.5			0	X		0.18678			0.62		
01/14/23 23:00	0.7			1			1.5			0	X		0.18666			0.62		
01/15/23 0:00	0.7			1			1.5			0	X		0.18702			0.62		
01/15/23 1:00	0.7			1			1.5			0	X		0.18732			0.62		
01/15/23 2:00	0.7			1			1.6			0	X		0.1869			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/15/23 3:00	0.7			1			1.5			0	X		0.18648			0.62		
01/15/23 4:00	0.7			1			1.5			0	X		0.18654			0.62		
01/15/23 5:00	0.7			1			1.5			0	X		0.18684			0.62		
01/15/23 6:00	0.7			1			1.5			0	X		0.18642			0.62		
01/15/23 7:00	0.7			1			1.5			0	X		0.18654			0.62		
01/15/23 8:00	0.7			1			1.5			0	X		0.1866			0.62		
01/15/23 9:00	0.7			1			1.5			0	X		0.18684			0.62		
01/15/23 10:00	0.7			1			1.5			0	X		0.18648			0.62		
01/15/23 11:00	0.7			1			1.5			0	X		0.18594			0.62		
01/15/23 12:00	0.7			1			1.5			0	X		0.18576			0.62		
01/15/23 13:00	0.7			1			1.5			0	X		0.18654			0.62		
01/15/23 14:00	0.7			0			1.4			0.02			0.23844			0.79		
01/15/23 15:00	0.8			0			1.5			0.34			0.22338			0.74		
01/15/23 16:00	1.1			0			1.4			0.56			0.30078			1		
01/15/23 17:00	1.1			0			1.5			0.64			0.34098			1.14		
01/15/23 18:00	1.1			0			1.5			0.64			0.34092			1.14		
01/15/23 19:00	1.2			0			1.5			0.62			0.33342			1.11		
01/15/23 20:00	1.2			0			1.5			0.62			0.33516			1.12		
01/15/23 21:00	1			0			1.4			0.48			0.25812			0.86		
01/15/23 22:00	0.8			1			1.3			0.27			0.21168			0.71		
01/15/23 23:00	0.7			1			1.5			0	X		0.18732			0.62		
01/16/23 0:00	0.7			1			1.5			0	X		0.18726			0.62		
01/16/23 1:00	0.7			1			1.5			0	X		0.18744			0.62		
01/16/23 2:00	0.7			0			1.4			0	X		0.18696			0.62		
01/16/23 3:00	0.7			0			1.5			0	X		0.18636			0.62		
01/16/23 4:00	0.7			1			1.5			0	X		0.186			0.62		
01/16/23 5:00	0.7			1			1.5			0	X		0.186			0.62		
01/16/23 6:00	0.7			1			1.5			0	X		0.18594			0.62		
01/16/23 7:00	0.7			1			1.5			0	X		0.1863			0.62		
01/16/23 8:00	0.7			1			1.5			0	X		0.18672			0.62		
01/16/23 9:00	0.7			1			1.5			0	X		0.1875			0.63		
01/16/23 10:00	0.7			1			1.5			0	X		0.1878			0.63		
01/16/23 11:00	0.7			1			1.5			0	X		0.18732			0.62		
01/16/23 12:00	0.7			1			1.5			0	X		0.18726			0.62		
01/16/23 13:00	0.7			1			1.5			0	X		0.18474			0.62		
01/16/23 14:00	0.7			0			1.4			0	X		0.19686			0.66		
01/16/23 15:00	0.8			1			1.4			0.32			0.21708			0.72		
01/16/23 16:00	0.9			0			1.4			0.46			0.24426			0.81		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/16/23 17:00	1.2			0			1.5			0.62			0.33252			1.11		
01/16/23 18:00	1.2			0			1.5			0.62			0.3321			1.11		
01/16/23 19:00	1.2			0			1.5			0.62			0.33216			1.11		
01/16/23 20:00	1.2			0			1.5			0.62			0.3318			1.11		
01/16/23 21:00	1.2			0			1.5			0.62			0.33096			1.1		
01/16/23 22:00	1			1			1.5			0.47			0.26502			0.88		
01/16/23 23:00	0.8			1			1.3			0	X		0.20358			0.68		
01/17/23 0:00	0.7			1			1.5			0	X		0.18732			0.62		
01/17/23 1:00	1			1			1.5			0	X		0.18732			0.62		
01/17/23 2:00	0.7			1			1.6			0	X		0.18774			0.63		
01/17/23 3:00	0.7			1			1.5			0	X		0.18792			0.63		
01/17/23 4:00	0.7			1			1.5			0	X		0.18816			0.63		
01/17/23 5:00	0.7			1			1.5			0	X		0.18804			0.63		
01/17/23 6:00	0.7			1			1.5			0	X		0.19242			0.64		
01/17/23 7:00	0.8			1			1.4			0	X		0.19938			0.66		
01/17/23 8:00	0.7			1			1.5			0	X		0.1881			0.63		
01/17/23 9:00	0.7			1			1.5			0	X		0.1878			0.63		
01/17/23 10:00	0.7			1			1.5			0	X		0.18792			0.63		
01/17/23 11:00	0.7			1			1.5			0	X		0.1881			0.63		
01/17/23 12:00	0.7			1			1.5			0	X		0.18798			0.63		
01/17/23 13:00	0.7			1			1.5			0	X		0.18846			0.63		
01/17/23 14:00	0.7			1			1.5			0	X		0.1881			0.63		
01/17/23 15:00	0.7			1			1.5			0	X		0.18804			0.63		
01/17/23 16:00	0.7			0			1.4			0	X		0.2205			0.74		
01/17/23 17:00	0.8			0			1.5			0.33			0.22758			0.76		
01/17/23 18:00	1.1			0			1.4			0.53			0.28452			0.95		
01/17/23 19:00	1.2			0			1.5			0.61			0.32832			1.09		
01/17/23 20:00	1.3			0			1.5			0.61			0.32826			1.09		
01/17/23 21:00	1.4			0			1.5			0.61			0.32844			1.09		
01/17/23 22:00	1.4			0			1.5			0.61			0.3282			1.09		
01/17/23 23:00	1.5			0			1.5			0.61			0.32712			1.09		
01/18/23 0:00	1.3			0			1.5			0.62			0.32964			1.1		
01/18/23 1:00	1.3			0			1.5			0.62			0.33072			1.1		
01/18/23 2:00	1.3			0			1.5			0.62			0.3303			1.1		
01/18/23 3:00	1.3			0			1.5			0.62			0.33036			1.1		
01/18/23 4:00	1.3			0			1.5			0.61			0.32946			1.1		
01/18/23 5:00	1.4			0			1.5			0.61			0.32886			1.1		
01/18/23 6:00	1.4			0			1.5			0.62			0.33192			1.11		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/18/23 7:00	1.5			0			1.5			0.61			0.32664			1.09		
01/18/23 8:00	1.3			0			1.5			0.54			0.29244			0.97		
01/18/23 9:00	0.8			1			1.3			0.29			0.20466			0.68		
01/18/23 10:00	0.7			1			1.5			0	X		0.18558			0.62		
01/18/23 11:00	0.7			1			1.5			0	X		0.18582			0.62		
01/18/23 12:00	0.7			1			1.5			0	X		0.18594			0.62		
01/18/23 13:00	0.7			1			1.5			0	X		0.1857			0.62		
01/18/23 14:00	0.7			1			1.5			0	X		0.18564			0.62		
01/18/23 15:00	0.7			1			1.5			0	X		0.18612			0.62		
01/18/23 16:00	0.7			1			1.5			0	X		0.18558			0.62		
01/18/23 17:00	0.7			1			1.5			0	X		0.1851			0.62		
01/18/23 18:00	0.7			1			1.5			0	X		0.18516			0.62		
01/18/23 19:00	0.7			1			1.5			0	X		0.18522			0.62		
01/18/23 20:00	0.7			1			1.5			0	X		0.18498			0.62		
01/18/23 21:00	0.7			1			1.5			0	X		0.18504			0.62		
01/18/23 22:00	0.7			1			1.5			0	X		0.18522			0.62		
01/18/23 23:00	0.7			1			1.5			0	X		0.18582			0.62		
01/19/23 0:00	0.7			1			1.5			0	X		0.18546			0.62		
01/19/23 1:00	0.7			1			1.5			0	X		0.18594			0.62		
01/19/23 2:00	0.7			1			1.6			0	X		0.18594			0.62		
01/19/23 3:00	0.7			1			1.5			0	X		0.18588			0.62		
01/19/23 4:00	0.6			1			1.5			0	X		0.18582			0.62		
01/19/23 5:00	0.6			1			1.5			0	X		0.18594			0.62		
01/19/23 6:00	0.6			1			1.5			0	X		0.18606			0.62		
01/19/23 7:00	0.9			1			1.5			0	X		0.18612			0.62		
01/19/23 8:00	0.7			1			1.5			0	X		0.18654			0.62		
01/19/23 9:00	0.7			3			1.1			0	X		0.18654			0.62		
01/19/23 10:00	0.7			0			1.3			0	X		0.18618			0.62		
01/19/23 11:00	0.7			0			0.6			0	X		0.18648			0.62		
01/19/23 12:00	0.7			0			1.5			0	X		0.18558			0.62		
01/19/23 13:00	0.7			0			1.5			0	X		0.18594			0.62		
01/19/23 14:00	0.7			1			1.5			0	X		0.18528			0.62		
01/19/23 15:00	0.7			1			1.5			0	X		0.18564			0.62		
01/19/23 16:00	0.7			1			1.5			0	X		0.18564			0.62		
01/19/23 17:00	1			0			1.4			0	X		0.258			0.86		
01/19/23 18:00	1.9			0			1.5			0	X		0.30432			1.01		
01/19/23 19:00	1.8			0			1.5			0	X		0.3042			1.01		
01/19/23 20:00	1.8			0			1.5			0	X		0.30438			1.01		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/19/23 21:00	1.8			0			1.5			0	X		0.30474			1.02		
01/19/23 22:00	1.8			0			1.5			0	X		0.30468			1.02		
01/19/23 23:00	1.8			0			1.5			0	X		0.3069			1.02		
01/20/23 0:00	1.8			0			1.5			0	X		0.30696			1.02		
01/20/23 1:00	1.8			0			1.5			0	X		0.30732			1.02		
01/20/23 2:00	1.8			0			1.6			0	X		0.30774			1.03		
01/20/23 3:00	1.8			0			1.5			0	X		0.3066			1.02		
01/20/23 4:00	1.8			0			1.5			0	X		0.3075			1.03		
01/20/23 5:00	1.8			0			1.5			0	X		0.3072			1.02		
01/20/23 6:00	1.8			0			1.5			0	X		0.30678			1.02		
01/20/23 7:00	1.7			0			1.5			0	X		0.30768			1.03		
01/20/23 8:00	1.6			0			1.5			0	X		0.30708			1.02		
01/20/23 9:00	1.6			0			1.5			0	X		0.30648			1.02		
01/20/23 10:00	1.5			0			1.5			0	X		0.3066			1.02		
01/20/23 11:00	1.5			0			1.5			0	X		0.2997			1		
01/20/23 12:00	0.8			1			1.5			0	X		0.20826			0.69		
01/20/23 13:00	0.7			1			1.5			0	X		0.18684			0.62		
01/20/23 14:00	0.7			1			1.5			0	X		0.1869			0.62		
01/20/23 15:00	0.7			1			1.5			0	X		0.1872			0.62		
01/20/23 16:00	0.7			1			1.5			0	X		0.18708			0.62		
01/20/23 17:00	1.3			0			1.4			0	X		0.2562			0.85		
01/20/23 18:00	1.8			0			1.5			0	X		0.30438			1.01		
01/20/23 19:00	1.8			0			1.5			0	X		0.30384			1.01		
01/20/23 20:00	1.9			0			1.5			0	X		0.30582			1.02		
01/20/23 21:00	1.9			0			1.5			0	X		0.30576			1.02		
01/20/23 22:00	1.9			0			1.5			0	X		0.30582			1.02		
01/20/23 23:00	1.9			0			1.5			0	X		0.30564			1.02		
01/21/23 0:00	1.3			0			1.5			0	X		0.3084			1.03		
01/21/23 1:00	0.9			0			1.5			0	X		0.30918			1.03		
01/21/23 2:00	0.9			0			1.5			0	X		0.30912			1.03		
01/21/23 3:00	0.9			0			1.5			0	X		0.30954			1.03		
01/21/23 4:00	0.9			0			1.5			0	X		0.30924			1.03		
01/21/23 5:00	0.9			0			1.5			0	X		0.30978			1.03		
01/21/23 6:00	0.9			0			1.5			0	X		0.30924			1.03		
01/21/23 7:00	0.9			0			1.5			0	X		0.31044			1.03		
01/21/23 8:00	0.9			0			1.5			0	X		0.3042			1.01		
01/21/23 9:00	0.9			1			1.5			0	X		0.20634			0.69		
01/21/23 10:00	0.7			1			1.5			0	X		0.18702			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/21/23 11:00	0.7			1			1.5			0	X		0.1869			0.62		
01/21/23 12:00	0.7			1			1.5			0	X		0.18708			0.62		
01/21/23 13:00	0.7			1			1.5			0	X		0.1869			0.62		
01/21/23 14:00	0.7			1			1.5			0	X		0.18684			0.62		
01/21/23 15:00	0.7			1			1.5			0	X		0.18666			0.62		
01/21/23 16:00	0.8			0			1.4			0	X		0.25788			0.86		
01/21/23 17:00	0.8			0			1.5			0	X		0.31194			1.04		
01/21/23 18:00	0.8			0			1.5			0	X		0.31182			1.04		
01/21/23 19:00	0.8			0			1.5			0	X		0.31248			1.04		
01/21/23 20:00	1			0			1.5			0	X		0.31266			1.04		
01/21/23 21:00	2.3			0			1.5			0	X		0.31578			1.05		
01/21/23 22:00	1.6			1			1.5			0	X		0.27456			0.92		
01/21/23 23:00	0.8			1			1.5			0	X		0.18732			0.62		
01/22/23 0:00	0.8			1			1.5			0	X		0.18768			0.63		
01/22/23 1:00	0.7			1			1.5			0	X		0.18792			0.63		
01/22/23 2:00	0.7			1			1.6			0	X		0.18822			0.63		
01/22/23 3:00	0.8			0			1.5			0	X		0.1881			0.63		
01/22/23 4:00	0.7			1			1.5			0	X		0.1884			0.63		
01/22/23 5:00	0.7			1			1.5			0	X		0.18858			0.63		
01/22/23 6:00	0.7			1			1.5			0	X		0.18846			0.63		
01/22/23 7:00	0.7			1			1.5			0	X		0.18744			0.62		
01/22/23 8:00	0.7			1			1.5			0	X		0.18606			0.62		
01/22/23 9:00	0.7			1			1.5			0	X		0.18594			0.62		
01/22/23 10:00	0.7			1			1.5			0	X		0.18498			0.62		
01/22/23 11:00	0.7			1			1.5			0	X		0.18432			0.61		
01/22/23 12:00	0.7			1			1.5			0	X		0.18282			0.61		
01/22/23 13:00	0.7			1			1.5			0	X		0.1827			0.61		
01/22/23 14:00	0.7			1			1.5			0	X		0.18264			0.61		
01/22/23 15:00	0.7			1			1.5			0	X		0.18252			0.61		
01/22/23 16:00	1			0			1.3			0	X		0.25368			0.85		
01/22/23 17:00	1.8			0			1.5			0	X		0.31872			1.06		
01/22/23 18:00	1.8			0			1.5			0	X		0.32052			1.07		
01/22/23 19:00	1.8			0			1.5			0	X		0.32166			1.07		
01/22/23 20:00	1.5			0			1.5			0	X		0.32352			1.08		
01/22/23 21:00	1.5			0			1.5			0	X		0.321			1.07		
01/22/23 22:00	1.6			0			1.5			0	X		0.31794			1.06		
01/22/23 23:00	1.6			0			1.5			0	X		0.31488			1.05		
01/23/23 0:00	1.6			0			1.5			0	X		0.31506			1.05		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/23/23 1:00	1.6			0			1.5			0	X		0.31782			1.06		
01/23/23 2:00	1.6			0			1.5			0	X		0.31848			1.06		
01/23/23 3:00	1.6			0			1.5			0	X		0.31758			1.06		
01/23/23 4:00	1.6			0			1.5			0	X		0.31878			1.06		
01/23/23 5:00	1.6			0			1.5			0	X		0.31716			1.06		
01/23/23 6:00	1.5			0			1.5			0	X		0.3261			1.09		
01/23/23 7:00	1.3			0			1.5			0	X		0.33162			1.11		
01/23/23 8:00	1.5			0			1.5			0	X		0.31278			1.04		
01/23/23 9:00	0.9			1			1.5			0	X		0.2112			0.7		
01/23/23 10:00	0.7			1			1.5			0	X		0.18348			0.61		
01/23/23 11:00	0.7			1			1.5			0	X		0.18294			0.61		
01/23/23 12:00	0.7			1			1.5			0	X		0.18282			0.61		
01/23/23 13:00	0.7			1			1.5			0	X		0.1827			0.61		
01/23/23 14:00	0.7			1			1.5			0	X		0.18258			0.61		
01/23/23 15:00	0.7			1			1.5			0	X		0.21594			0.72		
01/23/23 16:00	1			0			1.3			0.33			0.24798			0.83		
01/23/23 17:00	1.4			0			1.4			0.52			0.27504			0.92		
01/23/23 18:00	1.2			0			1.5			0.65			0.34476			1.15		
01/23/23 19:00	0.7			0			1.5			0.7			0.37248			1.24		
01/23/23 20:00	0.9			0			1.5			0.68			0.36588			1.22		
01/23/23 21:00	1			0			1.5			0.65			0.35724			1.19		
01/23/23 22:00	1			0			1.5			0.66			0.3579			1.19		
01/23/23 23:00	1.3			0			1.5			0.63			0.33768			1.13		
01/24/23 0:00	1.1			0			1.5			0.58			0.31164			1.04		
01/24/23 1:00	1			0			1.5			0.58			0.31212			1.04		
01/24/23 2:00	1			0			1.5			0.58			0.31086			1.04		
01/24/23 3:00	1			0			1.5			0.58			0.31104			1.04		
01/24/23 4:00	1			0			1.5			0.58			0.31116			1.04		
01/24/23 5:00	1.3			0			1.5			0.63			0.34134			1.14		
01/24/23 6:00	0.9			0			1.5			0.71			0.38232			1.27		
01/24/23 7:00	1.8			0			1.5			0.62			0.32862			1.1		
01/24/23 8:00	2			0			1.5			0.61			0.32376			1.08		
01/24/23 9:00	1.2			1			1.5			0.47			0.25266			0.84		
01/24/23 10:00	0.8			1			1.2			0.29			0.20442			0.68		
01/24/23 11:00	0.7			1			1.4			0	X		0.18756			0.63		
01/24/23 12:00	0.7			1			1.4			0	X		0.18762			0.63		
01/24/23 13:00	0.7			1			1.4			0	X		0.18696			0.62		
01/24/23 14:00	0.7			0			1.5			0	X		0.1872			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/24/23 15:00	0.7			1			1.5			0	X		0.18768			0.63		
01/24/23 16:00	0.7			1			1.5			0	X		0.1869			0.62		
01/24/23 17:00	0.7			1			1.5			0	X		0.18894			0.63		
01/24/23 18:00	0.9			0			1.4			0	X		0.2595			0.87		
01/24/23 19:00	0.9			1			1.4			0	X		0.21402			0.71		
01/24/23 20:00	0.9			1			1.5			0	X		0.18894			0.63		
01/24/23 21:00	0.8			1			1.5			0	X		0.18918			0.63		
01/24/23 22:00	0.8			1			1.5			0	X		0.18936			0.63		
01/24/23 23:00	0.9			1			1.5			0	X		0.18948			0.63		
01/25/23 0:00	0.9			1			1.5			0	X		0.18912			0.63		
01/25/23 1:00	0.8			1			1.5			0	X		0.18756			0.63		
01/25/23 2:00	0.8			0			1.3			0	X		0.18732			0.62		
01/25/23 3:00	0.8			1			1.5			0	X		0.18726			0.62		
01/25/23 4:00	0.9			1			1.5			0	X		0.18702			0.62		
01/25/23 5:00	0.9			1			1.5			0	X		0.18708			0.62		
01/25/23 6:00	0.9			1			1.5			0	X		0.19116			0.64		
01/25/23 7:00	0.8			1			1.5			0	X		0.18954			0.63		
01/25/23 8:00	0.9			1			1.5			0	X		0.19176			0.64		
01/25/23 9:00	0.9			1			1.5			0	X		0.19074			0.64		
01/25/23 10:00	0.8			1			1.5			0	X		0.1899			0.63		
01/25/23 11:00	0.7			1			1.5			0	X		0.1875			0.63		
01/25/23 12:00	0.7			1			1.5			0	X		0.18624			0.62		
01/25/23 13:00	0.8			1			1.5			0	X		0.1881			0.63		
01/25/23 14:00	0.7			0			1.5			0	X		0.18582			0.62		
01/25/23 15:00	0.7			1			1.5			0	X		0.18576			0.62		
01/25/23 16:00	0.7			0			1.5			0	X		0.18624			0.62		
01/25/23 17:00	0.7			0			1.5			0	X		0.18816			0.63		
01/25/23 18:00	0.7			1			1.5			0	X		0.18702			0.62		
01/25/23 19:00	0.7			1			1.5			0	X		0.18666			0.62		
01/25/23 20:00	0.7			1			1.5			0	X		0.18678			0.62		
01/25/23 21:00	0.7			1			1.5			0	X		0.18696			0.62		
01/25/23 22:00	0.7			1			1.5			0	X		0.18702			0.62		
01/25/23 23:00	0.7			1			1.5			0	X		0.18762			0.63		
01/26/23 0:00	0.7			1			1.5			0	X		0.18942			0.63		
01/26/23 1:00	0.8			1			1.5			0	X		0.18768			0.63		
01/26/23 2:00	0.8			1			1.8			0	X		0.1869			0.62		
01/26/23 3:00	0.8			1			1.5			0	X		0.18954			0.63		
01/26/23 4:00	0.8			1			1.5			0	X		0.19002			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/26/23 5:00	0.8			1			1.5			0	X		0.18948			0.63		
01/26/23 6:00	0.8			1			1.5			0	X		0.18774			0.63		
01/26/23 7:00	0.8			1			1.5			0	X		0.18948			0.63		
01/26/23 8:00	0.8			1			1.5			0	X		0.18726			0.62		
01/26/23 9:00	0.8			1			1.5			0	X		0.18816			0.63		
01/26/23 10:00	0.8			1			1.5			0	X		0.18804			0.63		
01/26/23 11:00	0.8			1			1.5			0	X		0.18588			0.62		
01/26/23 12:00	0.8			1			1.5			0	X		0.18522			0.62		
01/26/23 13:00	0.8			1			1.5			0	X		0.18504			0.62		
01/26/23 14:00	0.8			1			1.5			0	X		0.18522			0.62		
01/26/23 15:00	0.8			1			1.5			0	X		0.18534			0.62		
01/26/23 16:00	0.8			1			1.5			0	X		0.18534			0.62		
01/26/23 17:00	0.8			1			1.5			0	X		0.18558			0.62		
01/26/23 18:00	0.8			1			1.5			0	X		0.1854			0.62		
01/26/23 19:00	0.8			1			1.5			0	X		0.1857			0.62		
01/26/23 20:00	0.8			1			1.5			0	X		0.18546			0.62		
01/26/23 21:00	0.8			1			1.5			0	X		0.18552			0.62		
01/26/23 22:00	0.8			1			1.5			0	X		0.18564			0.62		
01/26/23 23:00	0.8			1			1.5			0	X		0.18546			0.62		
01/27/23 0:00	0.8			1			1.5			0	X		0.18576			0.62		
01/27/23 1:00	0.8			1			1.5			0	X		0.18738			0.62		
01/27/23 2:00	0.8			1			1.5			0	X		0.18942			0.63		
01/27/23 3:00	0.8			1			1.5			0	X		0.18948			0.63		
01/27/23 4:00	0.8			1			1.5			0	X		0.18948			0.63		
01/27/23 5:00	0.8			1			1.5			0	X		0.18936			0.63		
01/27/23 6:00	0.8			1			1.5			0	X		0.1893			0.63		
01/27/23 7:00	0.8			1			1.4			0	X		0.19332			0.64		
01/27/23 8:00	0.8			1			1.5			0	X		0.18912			0.63		
01/27/23 9:00	0.8			1			1.5			0	X		0.18858			0.63		
01/27/23 10:00	0.7			1			1.5			0	X		0.18714			0.62		
01/27/23 11:00	0.7			1			1.5			0	X		0.18504			0.62		
01/27/23 12:00	0.8			1			1.5			0	X		0.18516			0.62		
01/27/23 13:00	0.8			1			1.5			0	X		0.18474			0.62		
01/27/23 14:00	0.8			1			1.5			0	X		0.18462			0.62		
01/27/23 15:00	1			0			1.4			0	X		0.21654			0.72		
01/27/23 16:00	1.6			0			1.5			0.35			0.27342			0.91		
01/27/23 17:00	1.5			0			1.5			0.57			0.30558			1.02		
01/27/23 18:00	1.3			0			1.5			0.62			0.33162			1.11		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/27/23 19:00	1.2			0			1.5			0.57			0.30468			1.02		
01/27/23 20:00	1			1			1.5			0.39			0.1875			0.63		
01/27/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/27/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/27/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 6:00	0	X		0	X		0	X		0.36			0	X		0	X	
01/28/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/28/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 8:00	0	X		0	X		0	X		0.41			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/29/23 9:00	0			0	X		0			0.51			0.19404			0.65		
01/29/23 10:00	1.2			0			1.4			0.58			0.30996			1.03		
01/29/23 11:00	1.2			0			1.3			0.61			0.32538			1.08		
01/29/23 12:00	1			1			1.5			0.46			0.22788			0.76		
01/29/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 16:00	0	X		0	X		0	X		0.36			0	X		0	X	
01/29/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/29/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/30/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/30/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/30/23 2:00	0	X		0	X		0	X		0.49			0	X		0	X	
01/30/23 3:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 4:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 5:00	0	X		0	X		0	X		0.64			0	X		0	X	
01/30/23 6:00	0	X		0	X		0	X		0.68			0	X		0	X	
01/30/23 7:00	0	X		0	X		0	X		0.83			0	X		0	X	
01/30/23 8:00	0	X		0	X		0	X		0.79			0	X		0	X	
01/30/23 9:00	0	X		0	X		0	X		0.63			0	X		0	X	
01/30/23 10:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 11:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 12:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 13:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 14:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 15:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 16:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/30/23 17:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 18:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
01/30/23 20:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 21:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/30/23 22:00	0	X		0	X		0	X		0.6			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
01/30/23 23:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 0:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 1:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 2:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 3:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 4:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 5:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 6:00	0	X		0	X		0	X		0.62			0	X		0	X	
01/31/23 7:00	0	X		0	X		0	X		0.63			0	X		0	X	
01/31/23 8:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 9:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 10:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/31/23 11:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 12:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 13:00	0	X		0	X		0	X		0.54			0	X		0	X	
01/31/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
01/31/23 15:00	0	X		0	X		0	X		0.48			0	X		0	X	
01/31/23 16:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 17:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 18:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 19:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 20:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 21:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 22:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/31/23 23:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 0:00	0	X		0	X		0	X		0.6			0	X		0	X	
02/01/23 1:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 2:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 3:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 4:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 5:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 6:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 7:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 8:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 9:00	0	X		0	X		0	X		0.61			0	X		0	X	
02/01/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X	
02/01/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 12:00	0	X		0	X		0	X		0.36			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/01/23 13:00	0	X		0	X		0	X		0.36			0	X		0	X	
02/01/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/01/23 21:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/01/23 22:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/01/23 23:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/02/23 0:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/02/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 19:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/02/23 20:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/02/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/02/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/03/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/03/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/03/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/03/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/03/23 4:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/03/23 5:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/03/23 6:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/03/23 7:00	0	X		0	X		0	X		0.4			0	X		0	X	
02/03/23 8:00	0	X		0	X		0	X		0.39			0	X		0	X	
02/03/23 9:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/03/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/03/23 11:00	0	X		0	X		0	X		0.48			0	X		0	X	
02/03/23 12:00	0	X		0	X		0	X		0.6			0	X		0	X	
02/03/23 13:00	0	X		0	X		0	X		0.6			0	X		0	X	
02/03/23 14:00	0	X		0	X		0	X		0.6			0	X		0	X	
02/03/23 15:00	0	X		0	X		0	X		0.59			0	X		0	X	
02/03/23 16:00	0			0	X		0			0.44			0.16956			0.57		
02/03/23 17:00	1.3			0			1.1			0.52			0.279			0.93		
02/03/23 18:00	1.2			0			1.6			0.64			0.34218			1.14		
02/03/23 19:00	1.1			0			1.5			0.66			0.35154			1.17		
02/03/23 20:00	1.1			0			1.5			0.66			0.35052			1.17		
02/03/23 21:00	1.3			0			1.5			0.63			0.3348			1.12		
02/03/23 22:00	1.3			0			1.5			0.62			0.3324			1.11		
02/03/23 23:00	1.4			0			1.5			0.56			0.29982			1		
02/04/23 0:00	0.9			1			1.3			0.29			0.20226			0.67		
02/04/23 1:00	0.8			1			1.5			0	X		0.18768			0.63		
02/04/23 2:00	1.1			1			1.6			0	X		0.18762			0.63		
02/04/23 3:00	0.8			0			1.5			0	X		0.18672			0.62		
02/04/23 4:00	0.9			1			1.5			0	X		0.1893			0.63		
02/04/23 5:00	0.9			1			1.5			0	X		0.18702			0.62		
02/04/23 6:00	0.9			1			1.5			0	X		0.18906			0.63		
02/04/23 7:00	0.8			1			1.5			0	X		0.1872			0.62		
02/04/23 8:00	0.8			1			1.5			0	X		0.18648			0.62		
02/04/23 9:00	0.8			1			1.5			0	X		0.18798			0.63		
02/04/23 10:00	0.8			1			1.5			0	X		0.18582			0.62		
02/04/23 11:00	0.8			1			1.5			0	X		0.18516			0.62		
02/04/23 12:00	0.8			1			1.5			0	X		0.1857			0.62		
02/04/23 13:00	0.8			1			1.5			0	X		0.1854			0.62		
02/04/23 14:00	0.8			1			1.5			0	X		0.1854			0.62		
02/04/23 15:00	0.8			0			1.4			0	X		0.21324			0.71		
02/04/23 16:00	1.1			0			1.5			0.32			0.23994			0.8		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/04/23 17:00	1.3			0			1.3			0.52			0.27846			0.93		
02/04/23 18:00	1.1			0			1.5			0.64			0.34254			1.14		
02/04/23 19:00	1.1			0			1.5			0.65			0.34626			1.15		
02/04/23 20:00	1			0			1.5			0.66			0.35172			1.17		
02/04/23 21:00	1			0			1.5			0.66			0.35112			1.17		
02/04/23 22:00	1.1			0			1.5			0.55			0.29292			0.98		
02/04/23 23:00	0.8			1			1.3			0.28			0.2034			0.68		
02/05/23 0:00	0.7			1			1.5			0	X		0.18822			0.63		
02/05/23 1:00	0.7			1			1.5			0	X		0.18726			0.62		
02/05/23 2:00	0.7			1			1.5			0	X		0.18738			0.62		
02/05/23 3:00	0.7			1			1.5			0	X		0.18852			0.63		
02/05/23 4:00	0.7			1			1.5			0	X		0.18882			0.63		
02/05/23 5:00	0.7			1			1.5			0	X		0.18876			0.63		
02/05/23 6:00	0.7			1			1.5			0	X		0.189			0.63		
02/05/23 7:00	0.7			1			1.5			0	X		0.18924			0.63		
02/05/23 8:00	0.7			1			1.5			0	X		0.189			0.63		
02/05/23 9:00	0.7			1			1.5			0	X		0.18852			0.63		
02/05/23 10:00	0.7			1			1.5			0	X		0.18726			0.62		
02/05/23 11:00	0.7			1			1.5			0	X		0.18744			0.62		
02/05/23 12:00	0.7			1			1.5			0	X		0.18744			0.62		
02/05/23 13:00	0.7			1			1.5			0	X		0.18702			0.62		
02/05/23 14:00	0.7			1			1.5			0	X		0.18696			0.62		
02/05/23 15:00	0.7			1			1.5			0	X		0.18666			0.62		
02/05/23 16:00	0.7			1			1.5			0	X		0.1869			0.62		
02/05/23 17:00	0.8			0			1.4			0.04			0.22002			0.73		
02/05/23 18:00	0.9			1			1.5			0.34			0.2172			0.72		
02/05/23 19:00	1			0			1.5			0.4			0.21276			0.71		
02/05/23 20:00	1.3			0			1.5			0.57			0.30354			1.01		
02/05/23 21:00	1.3			0			1.5			0.55			0.29508			0.98		
02/05/23 22:00	0.9			1			1.4			0.31			0.20058			0.67		
02/05/23 23:00	0.8			1			1.5			0	X		0.18684			0.62		
02/06/23 0:00	0.8			1			1.5			0	X		0.18714			0.62		
02/06/23 1:00	0.8			1			1.5			0	X		0.18678			0.62		
02/06/23 2:00	0.8			1			1.5			0	X		0.18756			0.63		
02/06/23 3:00	0.8			1			1.5			0	X		0.18636			0.62		
02/06/23 4:00	0.8			1			1.5			0	X		0.1857			0.62		
02/06/23 5:00	0.8			1			1.5			0	X		0.1854			0.62		
02/06/23 6:00	0.7			1			1.5			0	X		0.1857			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/06/23 7:00	0.8			1			1.5			0	X		0.18588			0.62		
02/06/23 8:00	0.7			1			1.5			0	X		0.18612			0.62		
02/06/23 9:00	0.7			1			1.5			0	X		0.18666			0.62		
02/06/23 10:00	0.7			1			1.5			0	X		0.18624			0.62		
02/06/23 11:00	0.7			1			1.5			0	X		0.18594			0.62		
02/06/23 12:00	0.8			1			1.5			0	X		0.18576			0.62		
02/06/23 13:00	0.8			1			1.5			0	X		0.1854			0.62		
02/06/23 14:00	0.8			1			1.5			0	X		0.18594			0.62		
02/06/23 15:00	0.8			0			1.4			0.06			0.21906			0.73		
02/06/23 16:00	0.9			1			1.5			0.35			0.20922			0.7		
02/06/23 17:00	1.2			0			1.4			0.6			0.31884			1.06		
02/06/23 18:00	1.1			0			1.5			0.66			0.35136			1.17		
02/06/23 19:00	1.1			0			1.5			0.66			0.35094			1.17		
02/06/23 20:00	0.8			0			1.5			0.7			0.37056			1.24		
02/06/23 21:00	1.2			0			1.5			0.64			0.34152			1.14		
02/06/23 22:00	1.2			1			1.5			0.53			0.28608			0.95		
02/06/23 23:00	1			1			1.3			0.34			0.20946			0.7		
02/07/23 0:00	0.8			1			1.5			0	X		0.18774			0.63		
02/07/23 1:00	0.8			1			1.5			0	X		0.18708			0.62		
02/07/23 2:00	0.8			1			1.6			0	X		0.18714			0.62		
02/07/23 3:00	0.8			1			1.5			0	X		0.18762			0.63		
02/07/23 4:00	0.8			1			1.5			0	X		0.1872			0.62		
02/07/23 5:00	0.8			1			1.5			0	X		0.1872			0.62		
02/07/23 6:00	0.8			1			1.5			0	X		0.18762			0.63		
02/07/23 7:00	0.9			1			1.5			0	X		0.19044			0.63		
02/07/23 8:00	0.8			1			1.5			0	X		0.1872			0.62		
02/07/23 9:00	0.8			1			1.5			0	X		0.1866			0.62		
02/07/23 10:00	0.7			1			1.5			0	X		0.18672			0.62		
02/07/23 11:00	0.7			1			1.5			0	X		0.18684			0.62		
02/07/23 12:00	0.8			1			1.5			0	X		0.18672			0.62		
02/07/23 13:00	0.8			1			1.5			0	X		0.18696			0.62		
02/07/23 14:00	0.8			1			1.5			0	X		0.18702			0.62		
02/07/23 15:00	1			0			1.4			0.09			0.22014			0.73		
02/07/23 16:00	1			0			1.4			0.39			0.22344			0.74		
02/07/23 17:00	1.3			0			1.5			0.6			0.32142			1.07		
02/07/23 18:00	1			0			1.5			0.67			0.35676			1.19		
02/07/23 19:00	0.9			0			1.5			0.68			0.3621			1.21		
02/07/23 20:00	0.8			0			1.5			0.7			0.36912			1.23		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/07/23 21:00	1			0			1.5			0.68			0.36108			1.2		
02/07/23 22:00	1.1			0			1.5			0.66			0.3507			1.17		
02/07/23 23:00	1.4			0			1.5			0.63			0.33798			1.13		
02/08/23 0:00	1.3			0			1.5			0.56			0.30072			1		
02/08/23 1:00	1.2			0			1.5			0.56			0.3006			1		
02/08/23 2:00	1.1			0			1.5			0.54			0.29376			0.98		
02/08/23 3:00	1.2			0			1.5			0.54			0.29016			0.97		
02/08/23 4:00	1.1			0			1.5			0.55			0.2958			0.99		
02/08/23 5:00	1.4			0			1.5			0.57			0.30708			1.02		
02/08/23 6:00	1.4			0			1.5			0.67			0.35784			1.19		
02/08/23 7:00	1.3			0			1.5			0.59			0.31248			1.04		
02/08/23 8:00	1.1			2			1.6			0.4			0.18978			0.63		
02/08/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/08/23 15:00	0			0	X		0			0.41			0.01458			0.05		
02/08/23 16:00	0.9			0			0.9			0.42			0.19206			0.64		
02/08/23 17:00	1.3			0			1.5			0.61			0.32856			1.1		
02/08/23 18:00	0.7			0			1.5			0.71			0.37398			1.25		
02/08/23 19:00	0.9			0			1.5			0.68			0.36186			1.21		
02/08/23 20:00	1.3			0			1.5			0.66			0.3519			1.17		
02/08/23 21:00	0.9			1			1.5			0.71			0.37662			1.26		
02/08/23 22:00	1			0			1.5			0.67			0.35922			1.2		
02/08/23 23:00	1.3			0			1.5			0.61			0.32706			1.09		
02/09/23 0:00	1			0			1.5			0.58			0.3114			1.04		
02/09/23 1:00	1			0			1.5			0.56			0.30312			1.01		
02/09/23 2:00	0.9			0			1.4			0.58			0.31206			1.04		
02/09/23 3:00	1			0			1.5			0.58			0.3114			1.04		
02/09/23 4:00	1.3			0			1.5			0.56			0.30354			1.01		
02/09/23 5:00	1.2			0			1.5			0.68			0.36252			1.21		
02/09/23 6:00	0.8			1			1.5			0.71			0.37662			1.26		
02/09/23 7:00	1.2			1			1.5			0.55			0.29394			0.98		
02/09/23 8:00	0.8			1			1.4			0.38			0.15798			0.53		
02/09/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/09/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/09/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/09/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/09/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/09/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/09/23 15:00	0	X		0	X		0	X		0.37			0	X		0	X	
02/09/23 16:00	0.8			1			0.7			0.41			0.16386			0.55		
02/09/23 17:00	1.3			0			1.2			0.56			0.2997			1		
02/09/23 18:00	0.7			0			1.5			0.71			0.3738			1.25		
02/09/23 19:00	1			0			1.5			0.67			0.35388			1.18		
02/09/23 20:00	0.8			0			1.5			0.69			0.36762			1.23		
02/09/23 21:00	0.8			1			1.5			0.7			0.37056			1.24		
02/09/23 22:00	1			0			1.5			0.67			0.35574			1.19		
02/09/23 23:00	1.2			1			1.4			0.49			0.25254			0.84		
02/10/23 0:00	0	X		0	X		0	X		0.37			0	X		0	X	
02/10/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 6:00	0	X		0	X		0	X		0.36			0	X		0	X	
02/10/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/10/23 15:00	0			0	X		0			0.41			0.02304			0.08		
02/10/23 16:00	1.1			-1			1.4			0.4			0.1899			0.63		
02/10/23 17:00	1.1			0			1.5			0.56			0.29826			0.99		
02/10/23 18:00	1.2			0			1.5			0.62			0.33156			1.11		
02/10/23 19:00	1.2			0			1.5			0.62			0.3321			1.11		
02/10/23 20:00	1.2			0			1.5			0.64			0.34044			1.13		
02/10/23 21:00	1.2			0			1.5			0.64			0.34368			1.15		
02/10/23 22:00	1.2			0			1.5			0.65			0.34536			1.15		
02/10/23 23:00	1.3			0			1.5			0.62			0.3348			1.12		
02/11/23 0:00	1.2			0			1.5			0.64			0.34134			1.14		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/11/23 1:00	1.3			0			1.5			0.62			0.33516			1.12		
02/11/23 2:00	1.3			0			1.4			0.61			0.3297			1.1		
02/11/23 3:00	1.3			0			1.5			0.61			0.32988			1.1		
02/11/23 4:00	1.3			0			1.5			0.61			0.32898			1.1		
02/11/23 5:00	1.3			0			1.5			0.62			0.33282			1.11		
02/11/23 6:00	1.4			0			1.5			0.62			0.33288			1.11		
02/11/23 7:00	1.4			0			1.5			0.58			0.31356			1.05		
02/11/23 8:00	1.1			1			1.4			0.36			0.22812			0.76		
02/11/23 9:00	0.9			1			1.5			0	X		0.19614			0.65		
02/11/23 10:00	0.8			1			1.5			0	X		0.18696			0.62		
02/11/23 11:00	0.8			1			1.5			0	X		0.18708			0.62		
02/11/23 12:00	0.8			1			1.5			0	X		0.18738			0.62		
02/11/23 13:00	0.8			1			1.5			0	X		0.18756			0.63		
02/11/23 14:00	0.8			1			1.5			0	X		0.18768			0.63		
02/11/23 15:00	0.9			0			1.4			0	X		0.22026			0.73		
02/11/23 16:00	0.9			0			1.4			0.33			0.2244			0.75		
02/11/23 17:00	1.3			0			1.5			0.55			0.29628			0.99		
02/11/23 18:00	1.2			0			1.5			0.63			0.3393			1.13		
02/11/23 19:00	1.2			0			1.5			0.63			0.33768			1.13		
02/11/23 20:00	1.2			0			1.5			0.63			0.33924			1.13		
02/11/23 21:00	1.1			0			1.5			0.65			0.34848			1.16		
02/11/23 22:00	1.1			0			1.5			0.66			0.34962			1.17		
02/11/23 23:00	1.3			0			1.5			0.63			0.33768			1.13		
02/12/23 0:00	1.3			0			1.5			0.66			0.35184			1.17		
02/12/23 1:00	1.3			0			1.5			0.66			0.3495			1.17		
02/12/23 2:00	1.3			0			1.5			0.64			0.34386			1.15		
02/12/23 3:00	1.2			0			1.5			0.66			0.35238			1.17		
02/12/23 4:00	1.1			0			1.5			0.66			0.35352			1.18		
02/12/23 5:00	1.2			0			1.5			0.66			0.35166			1.17		
02/12/23 6:00	1.2			0			1.5			0.65			0.34614			1.15		
02/12/23 7:00	1.2			1			1.5			0.54			0.291			0.97		
02/12/23 8:00	1.1			1			1.2			0.41			0.19578			0.65		
02/12/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/12/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/12/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/12/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/12/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/12/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/12/23 15:00	0			0	X		0			0.47			0.14238			0.47		
02/12/23 16:00	1			0			1.4			0.47			0.25344			0.84		
02/12/23 17:00	0.9			0			1.5			0.65			0.34374			1.15		
02/12/23 18:00	1.2			0			1.5			0.63			0.33264			1.11		
02/12/23 19:00	1			0			1.5			0.66			0.34758			1.16		
02/12/23 20:00	0.9			0			1.5			0.67			0.35412			1.18		
02/12/23 21:00	1.1			0			1.5			0.6			0.3234			1.08		
02/12/23 22:00	1			0			1.4			0.46			0.2481			0.83		
02/12/23 23:00	0.9			1			1.4			0.4			0.21438			0.71		
02/13/23 0:00	1			0			1.2			0.35			0.21858			0.73		
02/13/23 1:00	0.8			1			1.5			0	X		0.1869			0.62		
02/13/23 2:00	0.8			1			1.5			0	X		0.18744			0.62		
02/13/23 3:00	0.8			1			1.5			0	X		0.1875			0.63		
02/13/23 4:00	0.8			1			1.5			0	X		0.1875			0.63		
02/13/23 5:00	0.8			1			1.5			0	X		0.18804			0.63		
02/13/23 6:00	0.8			1			1.5			0	X		0.18846			0.63		
02/13/23 7:00	0.9			1			1.4			0	X		0.19548			0.65		
02/13/23 8:00	0.8			1			1.5			0	X		0.18798			0.63		
02/13/23 9:00	0.8			1			1.5			0	X		0.18774			0.63		
02/13/23 10:00	0.8			1			1.5			0	X		0.1875			0.63		
02/13/23 11:00	0.8			1			1.5			0	X		0.18798			0.63		
02/13/23 12:00	0.8			1			1.5			0	X		0.18768			0.63		
02/13/23 13:00	0.8			1			1.5			0	X		0.18642			0.62		
02/13/23 14:00	0.9			1			1.5			0	X		0.18534			0.62		
02/13/23 15:00	0.9			1			1.5			0	X		0.1854			0.62		
02/13/23 16:00	0.9			1			1.5			0	X		0.18558			0.62		
02/13/23 17:00	0.9			1			1.5			0	X		0.18552			0.62		
02/13/23 18:00	0.9			1			1.5			0	X		0.18546			0.62		
02/13/23 19:00	0.9			1			1.5			0	X		0.18576			0.62		
02/13/23 20:00	0.8			1			1.5			0	X		0.18594			0.62		
02/13/23 21:00	0.8			1			1.5			0	X		0.18654			0.62		
02/13/23 22:00	0.8			1			1.5			0	X		0.18702			0.62		
02/13/23 23:00	0.8			1			1.5			0	X		0.1872			0.62		
02/14/23 0:00	0.8			1			1.5			0	X		0.18762			0.63		
02/14/23 1:00	0.8			1			1.5			0	X		0.1881			0.63		
02/14/23 2:00	0.8			1			1.5			0	X		0.18816			0.63		
02/14/23 3:00	0.8			1			1.5			0	X		0.1884			0.63		
02/14/23 4:00	0.8			1			1.5			0	X		0.18822			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/14/23 5:00	0.8			1			1.5			0	X		0.18822			0.63		
02/14/23 6:00	0.8			1			1.5			0	X		0.18672			0.62		
02/14/23 7:00	0.7			1			1.5			0	X		0.18666			0.62		
02/14/23 8:00	0.8			1			1.5			0	X		0.1863			0.62		
02/14/23 9:00	0.8			1			1.5			0	X		0.186			0.62		
02/14/23 10:00	0.8			1			1.5			0	X		0.18594			0.62		
02/14/23 11:00	0.8			1			1.5			0	X		0.18606			0.62		
02/14/23 12:00	0.8			1			1.5			0	X		0.18714			0.62		
02/14/23 13:00	0.8			1			1.5			0	X		0.18768			0.63		
02/14/23 14:00	0.9			1			1.3			0	X		0.20184			0.67		
02/14/23 15:00	1.2			0			1.4			0.27			0.28326			0.94		
02/14/23 16:00	1.5			0			1.5			0.53			0.28326			0.94		
02/14/23 17:00	0.8			0			1.5			0.71			0.3774			1.26		
02/14/23 18:00	0.7			1			1.5			0.73			0.38556			1.29		
02/14/23 19:00	1			0			1.5			0.69			0.36636			1.22		
02/14/23 20:00	0.8			1			1.5			0.71			0.37974			1.27		
02/14/23 21:00	1.1			0			1.5			0.67			0.36048			1.2		
02/14/23 22:00	1.3			0			1.5			0.64			0.34128			1.14		
02/14/23 23:00	1.2			0			1.5			0.67			0.35544			1.18		
02/15/23 0:00	1.2			0			1.5			0.66			0.35148			1.17		
02/15/23 1:00	1.2			0			1.5			0.66			0.34944			1.16		
02/15/23 2:00	1.3			0			1.5			0.65			0.34902			1.16		
02/15/23 3:00	1.2			0			1.5			0.67			0.35616			1.19		
02/15/23 4:00	1			1			1.5			0.7			0.3744			1.25		
02/15/23 5:00	0.9			1			1.5			0.71			0.37584			1.25		
02/15/23 6:00	0.9			1			1.5			0.73			0.37902			1.26		
02/15/23 7:00	0			0	X		0			0.72			0.19056			0.64		
02/15/23 8:00	1			1			1.2			0.42			0.24444			0.81		
02/15/23 9:00	0.9			1			1.4			0	X		0.20544			0.68		
02/15/23 10:00	0.8			1			1.5			0	X		0.18684			0.62		
02/15/23 11:00	0.8			1			1.5			0	X		0.18618			0.62		
02/15/23 12:00	0.8			1			1.5			0	X		0.18552			0.62		
02/15/23 13:00	0.8			1			1.5			0	X		0.18552			0.62		
02/15/23 14:00	0.8			1			1.5			0	X		0.18564			0.62		
02/15/23 15:00	0.8			1			1.4			0	X		0.1968			0.66		
02/15/23 16:00	0.9			0			1.5			0.31			0.25008			0.83		
02/15/23 17:00	1.4			0			1.3			0.53			0.28512			0.95		
02/15/23 18:00	0.7			0			1.5			0.72			0.3828			1.28		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/15/23 19:00	0.7			1			1.5			0.72			0.38436			1.28		
02/15/23 20:00	0.7			1			1.5			0.72			0.38406			1.28		
02/15/23 21:00	0.7			1			1.5			0.73			0.38712			1.29		
02/15/23 22:00	0.7			1			1.5			0.72			0.38346			1.28		
02/15/23 23:00	1			0			1.5			0.68			0.36042			1.2		
02/16/23 0:00	1			0			1.5			0.58			0.31134			1.04		
02/16/23 1:00	1			0			1.5			0.58			0.31194			1.04		
02/16/23 2:00	1			0			1.5			0.58			0.31272			1.04		
02/16/23 3:00	1			0			1.5			0.58			0.31296			1.04		
02/16/23 4:00	1			0			1.5			0.58			0.3126			1.04		
02/16/23 5:00	1			0			1.5			0.58			0.3126			1.04		
02/16/23 6:00	1.3			0			1.5			0.58			0.3117			1.04		
02/16/23 7:00	1.4			0			1.5			0.62			0.3324			1.11		
02/16/23 8:00	1.1			1			1.5			0.46			0.25596			0.85		
02/16/23 9:00	1			1			1.4			0	X		0.2082			0.69		
02/16/23 10:00	0.8			1			1.5			0	X		0.1881			0.63		
02/16/23 11:00	0.9			1			1.5			0	X		0.18816			0.63		
02/16/23 12:00	0.9			1			1.5			0	X		0.1902			0.63		
02/16/23 13:00	0.9			1			1.5			0	X		0.18864			0.63		
02/16/23 14:00	0.9			1			1.5			0	X		0.18852			0.63		
02/16/23 15:00	0.9			0			1.4			0	X		0.19998			0.67		
02/16/23 16:00	1			1			1.5			0.31			0.24354			0.81		
02/16/23 17:00	1.4			0			1.4			0.48			0.25686			0.86		
02/16/23 18:00	1.6			0			1.5			0.6			0.32298			1.08		
02/16/23 19:00	1.4			0			1.5			0.63			0.33828			1.13		
02/16/23 20:00	1.5			0			1.5			0.65			0.34788			1.16		
02/16/23 21:00	1.2			0			1.5			0.66			0.35076			1.17		
02/16/23 22:00	1.2			0			1.5			0.67			0.35628			1.19		
02/16/23 23:00	1.3			0			1.5			0.64			0.34128			1.14		
02/17/23 0:00	1.3			0			1.5			0.64			0.34446			1.15		
02/17/23 1:00	1.5			0			1.5			0.61			0.32868			1.1		
02/17/23 2:00	1.5			0			1.5			0.61			0.32904			1.1		
02/17/23 3:00	1.2			1			1.5			0.4			0.22428			0.75		
02/17/23 4:00	1			1			1.3			0			0.20388			0.68		
02/17/23 5:00	0.9			1			1.5			0	X		0.18822			0.63		
02/17/23 6:00	0.9			1			1.5			0	X		0.18696			0.62		
02/17/23 7:00	0.9			1			1.5			0	X		0.18618			0.62		
02/17/23 8:00	0.8			0			1.4			0	X		0.1854			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/17/23 9:00	0.8			1			1.5			0	X		0.18522			0.62		
02/17/23 10:00	0.8			1			1.5			0	X		0.18594			0.62		
02/17/23 11:00	0.8			0			1.4			0	X		0.1938			0.65		
02/17/23 12:00	1.1			0			1.5			0	X		0.22386			0.75		
02/17/23 13:00	0.8			0			1.5			0	X		0.18858			0.63		
02/17/23 14:00	0.9			0			1.5			0	X		0.18804			0.63		
02/17/23 15:00	0.9			0			1.5			0	X		0.18648			0.62		
02/17/23 16:00	0.9			0			1.5			0	X		0.1872			0.62		
02/17/23 17:00	0.9			0			1.5			0	X		0.18714			0.62		
02/17/23 18:00	0.9			0			1.5			0	X		0.18816			0.63		
02/17/23 19:00	0.9			1			1.5			0	X		0.18816			0.63		
02/17/23 20:00	0.9			1			1.5			0	X		0.18834			0.63		
02/17/23 21:00	1			1			1.5			0	X		0.1884			0.63		
02/17/23 22:00	0.9			1			1.5			0	X		0.1884			0.63		
02/17/23 23:00	0.9			1			1.5			0	X		0.18822			0.63		
02/18/23 0:00	0.9			1			1.5			0	X		0.18786			0.63		
02/18/23 1:00	0.9			1			1.5			0	X		0.18654			0.62		
02/18/23 2:00	0.9			1			1.5			0	X		0.18654			0.62		
02/18/23 3:00	0.9			1			1.5			0	X		0.18666			0.62		
02/18/23 4:00	0.9			1			1.5			0	X		0.1869			0.62		
02/18/23 5:00	0.8			1			1.5			0	X		0.1866			0.62		
02/18/23 6:00	0.9			1			1.5			0	X		0.18612			0.62		
02/18/23 7:00	0.9			1			1.5			0	X		0.18642			0.62		
02/18/23 8:00	0.9			1			1.5			0	X		0.18618			0.62		
02/18/23 9:00	0.9			1			1.5			0	X		0.1866			0.62		
02/18/23 10:00	0.8			1			1.5			0	X		0.1863			0.62		
02/18/23 11:00	0.9			1			1.5			0	X		0.1863			0.62		
02/18/23 12:00	0.9			1			1.5			0	X		0.18618			0.62		
02/18/23 13:00	0.9			0			1.5			0	X		0.18612			0.62		
02/18/23 14:00	0.9			0			1.5			0	X		0.186			0.62		
02/18/23 15:00	0.9			0			1.5			0	X		0.18594			0.62		
02/18/23 16:00	0.9			0			1.5			0	X		0.18654			0.62		
02/18/23 17:00	0.9			1			1.5			0	X		0.18624			0.62		
02/18/23 18:00	0.9			1			1.5			0	X		0.18624			0.62		
02/18/23 19:00	0.9			1			1.5			0	X		0.18636			0.62		
02/18/23 20:00	0.9			1			1.5			0	X		0.18636			0.62		
02/18/23 21:00	0.9			1			1.5			0	X		0.18588			0.62		
02/18/23 22:00	0.9			1			1.5			0	X		0.1857			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/18/23 23:00	0.9			1			1.5			0	X		0.18594			0.62		
02/19/23 0:00	1			1			1.5			0	X		0.18582			0.62		
02/19/23 1:00	1.2			1			1.5			0	X		0.186			0.62		
02/19/23 2:00	1.2			1			1.6			0	X		0.18594			0.62		
02/19/23 3:00	1.1			0			1.5			0	X		0.18636			0.62		
02/19/23 4:00	1.1			1			1.5			0	X		0.1866			0.62		
02/19/23 5:00	1			1			1.5			0	X		0.18684			0.62		
02/19/23 6:00	1			1			1.5			0	X		0.18762			0.63		
02/19/23 7:00	1			1			1.5			0	X		0.18774			0.63		
02/19/23 8:00	0.9			1			1.5			0	X		0.1878			0.63		
02/19/23 9:00	0.9			1			1.5			0	X		0.18762			0.63		
02/19/23 10:00	0.9			1			1.5			0	X		0.18774			0.63		
02/19/23 11:00	0.9			1			1.5			0	X		0.18732			0.62		
02/19/23 12:00	0.9			0			1.5			0	X		0.18708			0.62		
02/19/23 13:00	0.9			1			1.5			0	X		0.18636			0.62		
02/19/23 14:00	0.9			0			1.5			0	X		0.18444			0.61		
02/19/23 15:00	0.9			0			1.5			0	X		0.1863			0.62		
02/19/23 16:00	0.9			1			1.5			0	X		0.18438			0.61		
02/19/23 17:00	0.9			0			1.5			0	X		0.18456			0.62		
02/19/23 18:00	0.9			0			1.5			0	X		0.18768			0.63		
02/19/23 19:00	0.9			1			1.5			0	X		0.18684			0.62		
02/19/23 20:00	0.9			1			1.5			0	X		0.18612			0.62		
02/19/23 21:00	0.9			1			1.5			0	X		0.18618			0.62		
02/19/23 22:00	0.9			1			1.5			0	X		0.18678			0.62		
02/19/23 23:00	0.9			1			1.5			0	X		0.18762			0.63		
02/20/23 0:00	0.9			1			1.5			0	X		0.18792			0.63		
02/20/23 1:00	0.9			1			1.5			0	X		0.18846			0.63		
02/20/23 2:00	0.9			1			1.6			0	X		0.18822			0.63		
02/20/23 3:00	0.9			1			1.5			0	X		0.1881			0.63		
02/20/23 4:00	0.9			1			1.5			0	X		0.18828			0.63		
02/20/23 5:00	0.9			1			1.5			0	X		0.18846			0.63		
02/20/23 6:00	1			1			1.5			0	X		0.1887			0.63		
02/20/23 7:00	1.1			1			1.4			0	X		0.20934			0.7		
02/20/23 8:00	1			1			1.5			0	X		0.1884			0.63		
02/20/23 9:00	0.9			1			1.5			0	X		0.18894			0.63		
02/20/23 10:00	0.9			0			1.5			0	X		0.189			0.63		
02/20/23 11:00	0.9			1			1.5			0	X		0.18678			0.62		
02/20/23 12:00	0.9			0			1.5			0	X		0.18756			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/20/23 13:00	0.9			0			1.5			0	X		0.1863			0.62		
02/20/23 14:00	0.9			0			1.5			0	X		0.18612			0.62		
02/20/23 15:00	1.1			0			1.4			0.05			0.21792			0.73		
02/20/23 16:00	1			0			1.4			0.34			0.21858			0.73		
02/20/23 17:00	1.1			0			1.4			0.61			0.32154			1.07		
02/20/23 18:00	1			0			1.5			0.66			0.35082			1.17		
02/20/23 19:00	1.1			0			1.5			0.66			0.35304			1.18		
02/20/23 20:00	1.1			0			1.5			0.66			0.35172			1.17		
02/20/23 21:00	1.3			0			1.5			0.64			0.33984			1.13		
02/20/23 22:00	1.4			0			1.5			0.54			0.2898			0.97		
02/20/23 23:00	1			1			1.4			0.38			0.15708			0.52		
02/21/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 17:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/21/23 18:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/21/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/21/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/22/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 6:00	0	X		0	X		0	X		0.36			0	X		0	X	
02/22/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/22/23 15:00	0	X		0	X		0	X		0.41			0	X		0	X	
02/22/23 16:00	0			0	X		0			0.47			0.18792			0.63		
02/22/23 17:00	1.5			0			1.6			0.54			0.29004			0.97		
02/22/23 18:00	1.1			0			1.5			0.67			0.35538			1.18		
02/22/23 19:00	1.1			0			1.5			0.67			0.35562			1.19		
02/22/23 20:00	1.2			0			1.5			0.66			0.35514			1.18		
02/22/23 21:00	1.2			0			1.5			0.65			0.34734			1.16		
02/22/23 22:00	1.1			0			1.5			0.54			0.29196			0.97		
02/22/23 23:00	1.1			0			1.5			0.52			0.27882			0.93		
02/23/23 0:00	1.3			0			1.5			0.64			0.34182			1.14		
02/23/23 1:00	0.7			0			1.5			0.72			0.38388			1.28		
02/23/23 2:00	0.9			0			1.5			0.7			0.3738			1.25		
02/23/23 3:00	0.8			0			1.5			0.72			0.38106			1.27		
02/23/23 4:00	0.8			0			1.5			0.71			0.37614			1.25		
02/23/23 5:00	0.9			0			1.5			0.7			0.3753			1.25		
02/23/23 6:00	0.7			1			1.5			0.72			0.38442			1.28		
02/23/23 7:00	1.5			0			1.3			0.62			0.3333			1.11		
02/23/23 8:00	1.5			0			1.5			0.62			0.33426			1.11		
02/23/23 9:00	1.5			0			1.5			0.61			0.3306			1.1		
02/23/23 10:00	1.5			0			1.5			0.62			0.33042			1.1		
02/23/23 11:00	1.4			0			1.5			0.62			0.33336			1.11		
02/23/23 12:00	1.3			1			1.5			0.54			0.2886			0.96		
02/23/23 13:00	0.8			1			1.3			0.39			0.1509			0.5		
02/23/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/23/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/23/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/23/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/23/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/23/23 19:00	0	X		0	X		0	X		0.37			0	X		0	X	
02/23/23 20:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/23/23 21:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/23/23 22:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/23/23 23:00	0	X		0	X		0	X		0.56			0	X		0	X	
02/24/23 0:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 1:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 2:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 3:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 4:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 5:00	0	X		0	X		0	X		0.63			0	X		0	X	
02/24/23 6:00	0	X		0	X		0	X		0.68			0	X		0	X	
02/24/23 7:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 8:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 9:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/24/23 11:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/24/23 12:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 13:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 14:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 15:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 16:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 17:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 18:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 19:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 20:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 21:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/24/23 22:00	0	X		0	X		0	X		0.56			0	X		0	X	
02/24/23 23:00	0	X		0	X		0	X		0.56			0	X		0	X	
02/25/23 0:00	0	X		0	X		0	X		0.57			0	X		0	X	
02/25/23 1:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/25/23 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/25/23 3:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/25/23 4:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/25/23 5:00	0	X		0	X		0	X		0.58			0	X		0	X	
02/25/23 6:00	0	X		0	X		0	X		0.36			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/25/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/25/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/26/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/26/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 9:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/27/23 10:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/27/23 11:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/27/23 12:00	0	X		0	X		0	X		0.34			0	X		0	X	
02/27/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/27/23 16:00	0	X		0	X		0	X		0.37			0	X		0	X	
02/27/23 17:00	0			0	X		0			0.51			0.16296			0.54		
02/27/23 18:00	1.4			0			1.7			0.52			0.28284			0.94		
02/27/23 19:00	1.2			0			1.5			0.66			0.35196			1.17		
02/27/23 20:00	1.2			0			1.4			0.66			0.35154			1.17		
02/27/23 21:00	1.3			0			1.5			0.65			0.34632			1.15		
02/27/23 22:00	1.3			0			1.4			0.54			0.28992			0.97		
02/27/23 23:00	0.8			1			1.4			0.4			0.15318			0.51		
02/28/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
02/28/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
02/28/23 16:00	0			0	X		0			0.41			0.02946			0.1		
02/28/23 17:00	1			0			1.1			0.43			0.20862			0.7		
02/28/23 18:00	1.7			0			1.5			0.58			0.3126			1.04		
02/28/23 19:00	1.3			0			1.4			0.62			0.3327			1.11		
02/28/23 20:00	1.4			0			1.5			0.62			0.33198			1.11		
02/28/23 21:00	1.3			0			1.4			0.62			0.33198			1.11		
02/28/23 22:00	1.4			0			1.5			0.62			0.33096			1.1		
02/28/23 23:00	1.4			0			1.5			0.62			0.3312			1.1		
03/01/23 0:00	1.4			0			1.5			0.62			0.33258			1.11		
03/01/23 1:00	1.4			0			1.5			0.62			0.33342			1.11		
03/01/23 2:00	1.4			0			1.4			0.62			0.33414			1.11		
03/01/23 3:00	1.3			0			1.5			0.62			0.33552			1.12		
03/01/23 4:00	1.3			0			1.4			0.63			0.33624			1.12		
03/01/23 5:00	1.4			0			1.4			0.63			0.33906			1.13		
03/01/23 6:00	1.4			0			1.5			0.69			0.36738			1.22		
03/01/23 7:00	1.3			1			1.5			0.54			0.29328			0.98		
03/01/23 8:00	0.8			1			1.4			0.38			0.15648			0.52		
03/01/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/01/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/02/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 2:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 3:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 4:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 5:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X	
03/02/23 7:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 8:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 9:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/02/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 17:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 18:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/02/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/03/23 11:00	0	X		0	X		0	X		0.38			0	X		0	X	
03/03/23 12:00	0	X		0	X		0	X		0.56			0	X		0	X	
03/03/23 13:00	0	X		0	X		0	X		0.59			0	X		0	X	
03/03/23 14:00	0	X		0	X		0	X		0.6			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/03/23 15:00	0			0	X		0			0.47			0.17214			0.57		
03/03/23 16:00	1			0			1.5			0.38			0.20124			0.67		
03/03/23 17:00	1.4			0			1.4			0.52			0.27918			0.93		
03/03/23 18:00	1.3			0			1.5			0.62			0.33306			1.11		
03/03/23 19:00	1.2			0			1.5			0.64			0.33924			1.13		
03/03/23 20:00	1.2			0			1.5			0.65			0.34656			1.16		
03/03/23 21:00	1.2			0			1.5			0.61			0.32604			1.09		
03/03/23 22:00	1.1			1			1.5			0.45			0.23484			0.78		
03/03/23 23:00	0			0	X		0			0.38			0.00786			0.03		
03/04/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/04/23 16:00	0			0	X		0			0.41			0.01884			0.06		
03/04/23 17:00	0.9			2			0.8			0.39			0.18			0.6		
03/04/23 18:00	1.3			0			1.2			0.58			0.30834			1.03		
03/04/23 19:00	1			0			1.5			0.68			0.36414			1.21		
03/04/23 20:00	1.2			0			1.5			0.66			0.35088			1.17		
03/04/23 21:00	1.2			0			1.5			0.66			0.351			1.17		
03/04/23 22:00	1.2			1			1.5			0.49			0.2508			0.84		
03/04/23 23:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/05/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 1:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/05/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/05/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/05/23 15:00	0			0	X		0			0.41			0.02568			0.09		
03/05/23 16:00	1			0			0.5			0.43			0.20256			0.68		
03/05/23 17:00	1.2			0			1.4			0.57			0.30438			1.01		
03/05/23 18:00	0.9			0			1.5			0.69			0.36816			1.23		
03/05/23 19:00	0.8			0			1.5			0.7			0.37296			1.24		
03/05/23 20:00	0.8			0			1.5			0.7			0.37434			1.25		
03/05/23 21:00	1			0			1.5			0.69			0.36564			1.22		
03/05/23 22:00	1.1			0			1.5			0.66			0.35532			1.18		
03/05/23 23:00	1.3			0			1.5			0.62			0.33582			1.12		
03/06/23 0:00	1.2			0			1.5			0.54			0.29382			0.98		
03/06/23 1:00	1.1			1			1.5			0.44			0.2181			0.73		
03/06/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 5:00	0	X		0	X		0	X		0.38			0	X		0	X	
03/06/23 6:00	0	X		0	X		0	X		0.5			0	X		0	X	
03/06/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/06/23 12:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/06/23 13:00	0			0	X		0			0.45			0.16686			0.56		
03/06/23 14:00	1.4			0			1.5			0.53			0.2832			0.94		
03/06/23 15:00	1.3			0			1.3			0.62			0.33096			1.1		
03/06/23 16:00	1.3			0			1.3			0.62			0.3309			1.1		
03/06/23 17:00	1.3			0			1.5			0.62			0.33048			1.1		
03/06/23 18:00	1.4			0			1.5			0.61			0.32826			1.09		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/06/23 19:00	1.4			0			1.5			0.61			0.32706			1.09		
03/06/23 20:00	1.5			0			1.5			0.61			0.32646			1.09		
03/06/23 21:00	1.5			0			1.5			0.61			0.32634			1.09		
03/06/23 22:00	1.5			0			1.5			0.61			0.32658			1.09		
03/06/23 23:00	1.5			0			1.5			0.61			0.3264			1.09		
03/07/23 0:00	1.5			0			1.5			0.61			0.3264			1.09		
03/07/23 1:00	1.4			0			1.5			0.61			0.32868			1.1		
03/07/23 2:00	1.4			0			1.5			0.61			0.32808			1.09		
03/07/23 3:00	1.4			0			1.5			0.61			0.32844			1.09		
03/07/23 4:00	1.4			0			1.5			0.62			0.33246			1.11		
03/07/23 5:00	1.2			0			1.5			0.65			0.34854			1.16		
03/07/23 6:00	0.8			0			1.5			0.7			0.37398			1.25		
03/07/23 7:00	1.4			1			1.5			0.53			0.288			0.96		
03/07/23 8:00	0.8			1			1.3			0.38			0.15246			0.51		
03/07/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/07/23 16:00	0			0	X		0			0.41			0.06444			0.21		
03/07/23 17:00	0.8			0			1.5			0.36			0.18912			0.63		
03/07/23 18:00	1.3			0			1.4			0.52			0.27984			0.93		
03/07/23 19:00	1.4			0			1.5			0.61			0.32664			1.09		
03/07/23 20:00	1.5			0			1.5			0.61			0.3264			1.09		
03/07/23 21:00	1.5			0			1.5			0.61			0.32664			1.09		
03/07/23 22:00	1.5			0			1.5			0.61			0.32676			1.09		
03/07/23 23:00	1.5			0			1.5			0.61			0.32634			1.09		
03/08/23 0:00	1.5			0			1.5			0.61			0.32634			1.09		
03/08/23 1:00	1.5			0			1.5			0.61			0.32646			1.09		
03/08/23 2:00	1.5			0			1.5			0.61			0.32658			1.09		
03/08/23 3:00	1.5			0			1.5			0.61			0.32658			1.09		
03/08/23 4:00	1.5			0			1.5			0.61			0.32718			1.09		
03/08/23 5:00	1.4			0			1.5			0.61			0.32772			1.09		
03/08/23 6:00	1.4			0			1.5			0.61			0.32922			1.1		
03/08/23 7:00	1.4			0			1.5			0.62			0.33366			1.11		
03/08/23 8:00	1.4			0			1.5			0.62			0.33486			1.12		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/08/23 9:00	1.4			0			1.5			0.62			0.33144			1.1		
03/08/23 10:00	1.3			0			1.5			0.54			0.2922			0.97		
03/08/23 11:00	0.9			0			1.4			0.38			0.15954			0.53		
03/08/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/08/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/08/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/08/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/08/23 16:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/08/23 17:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/08/23 18:00	0.8			1			1.7			0.46			0.16596			0.55		
03/08/23 19:00	1			0			1.4			0.46			0.24756			0.83		
03/08/23 20:00	1.2			0			1.5			0.63			0.33486			1.12		
03/08/23 21:00	1.2			0			1.5			0.62			0.33192			1.11		
03/08/23 22:00	1.2			0			1.5			0.62			0.33216			1.11		
03/08/23 23:00	1.2			0			1.5			0.62			0.3324			1.11		
03/09/23 0:00	1.2			0			1.5			0.62			0.33234			1.11		
03/09/23 1:00	1.2			0			1.5			0.62			0.3324			1.11		
03/09/23 2:00	1.2			0			1.5			0.62			0.33228			1.11		
03/09/23 3:00	1.2			0			1.5			0.62			0.33228			1.11		
03/09/23 4:00	1.2			0			1.5			0.62			0.33186			1.11		
03/09/23 5:00	1.1			0			1.5			0.64			0.34134			1.14		
03/09/23 6:00	1.2			0			1.5			0.62			0.33408			1.11		
03/09/23 7:00	1.2			0			1.5			0.62			0.3324			1.11		
03/09/23 8:00	1.2			0			1.5			0.62			0.3324			1.11		
03/09/23 9:00	1.2			0			1.5			0.62			0.33372			1.11		
03/09/23 10:00	1.1			0			1.5			0.63			0.33576			1.12		
03/09/23 11:00	0.9			0			1.5			0.67			0.35604			1.19		
03/09/23 12:00	0.7			1			1.5			0.69			0.36858			1.23		
03/09/23 13:00	0.4			1			1.5			0.73			0.38892			1.3		
03/09/23 14:00	0.5			1			1.5			0.72			0.37992			1.27		
03/09/23 15:00	0.8			0			1.5			0.67			0.35952			1.2		
03/09/23 16:00	1.2			0			1.5			0.61			0.3291			1.1		
03/09/23 17:00	1.2			0			1.5			0.61			0.32832			1.09		
03/09/23 18:00	1.2			0			1.5			0.61			0.32838			1.09		
03/09/23 19:00	1.2			0			1.5			0.62			0.32898			1.1		
03/09/23 20:00	1.2			0			1.5			0.62			0.3294			1.1		
03/09/23 21:00	1.2			0			1.5			0.62			0.32952			1.1		
03/09/23 22:00	1.1			1			1.5			0.54			0.2889			0.96		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/09/23 23:00	0.7			1			1.3			0.38			0.14802			0.49		
03/10/23 0:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/10/23 1:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/10/23 2:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/10/23 3:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/10/23 4:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/10/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 10:00	0	X		0	X		0	X		0.42			0	X		0	X	
03/10/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 15:00	0			0	X		0			0.41			0.05712			0.19		
03/10/23 16:00	0.9			0			1.5			0.39			0.20358			0.68		
03/10/23 17:00	1			0			1.6			0.55			0.29238			0.97		
03/10/23 18:00	1.1			0			1.5			0.63			0.33624			1.12		
03/10/23 19:00	1.1			0			1.5			0.62			0.3315			1.11		
03/10/23 20:00	1.1			0			1.5			0.5			0.2538			0.85		
03/10/23 21:00	0	X		0	X		0	X		0.38			0	X		0	X	
03/10/23 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/10/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/11/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/11/23 16:00	0			0	X		0			0.37			0.00258			0.01		
03/11/23 17:00	0			0	X		0			0.4			0.17154			0.57		
03/11/23 18:00	0.7			1			1.5			0.34			0.1812			0.6		
03/11/23 19:00	0.9			0			1.5			0.61			0.32568			1.09		
03/11/23 20:00	0.9			0			1.5			0.65			0.34722			1.16		
03/11/23 21:00	0.6			1			1.5			0.69			0.36756			1.23		
03/11/23 22:00	0.4			1			1.5			0.72			0.38088			1.27		
03/11/23 23:00	0.4			1			1.5			0.72			0.37908			1.26		
03/12/23 0:00	0.7			0			1.5			0.67			0.35634			1.19		
03/12/23 1:00	0.9			0			1.5			0.56			0.3027			1.01		
03/12/23 2:00	0.8			0			1.5			0.56			0.30264			1.01		
03/12/23 3:00	1.6			0			1.5			0.57			0.30588			1.02		
03/12/23 4:00	0.6			1			1.5			0.69			0.36534			1.22		
03/12/23 5:00	0.6			1			1.5			0.69			0.36522			1.22		
03/12/23 6:00	1			0			1.5			0.55			0.29526			0.98		
03/12/23 7:00	0.7			1			1.4			0.37			0.15474			0.52		
03/12/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/12/23 9:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/12/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/12/23 11:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/12/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/12/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/12/23 14:00	0	X		0	X		0	X		0.4			0	X		0	X	
03/12/23 15:00	0.8			0			1.3			0.42			0.16716			0.56		
03/12/23 16:00	0.8			0			1.4			0.45			0.2439			0.81		
03/12/23 17:00	0.5			1			1.5			0.7			0.37308			1.24		
03/12/23 18:00	0.4			1			1.5			0.72			0.37968			1.27		
03/12/23 19:00	0.4			1			1.5			0.7			0.37188			1.24		
03/12/23 20:00	0.4			1			1.5			0.72			0.3777			1.26		
03/12/23 21:00	0.4			1			1.5			0.71			0.37602			1.25		
03/12/23 22:00	0.6			1			1.5			0.68			0.35874			1.2		
03/12/23 23:00	0.8			0			1.5			0.49			0.26574			0.89		
03/13/23 0:00	0.6			2			1.5			0.37			0.1542			0.51		
03/13/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/13/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 4:00	0	X		0	X		0	X		0.42			0	X		0	X	
03/13/23 5:00	0	X		0	X		0	X		0.47			0	X		0	X	
03/13/23 6:00	0	X		0	X		0	X		0.53			0	X		0	X	
03/13/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/13/23 16:00	0	X		0	X		0	X		0.4			0.06408			0.21		
03/13/23 17:00	0.7			1			0.5			0.39			0.2061			0.69		
03/13/23 18:00	0.8			0			0.9			0.59			0.3156			1.05		
03/13/23 19:00	0.6			0			1.5			0.67			0.35598			1.19		
03/13/23 20:00	0.4			1			1.5			0.71			0.37356			1.25		
03/13/23 21:00	0.6			0			1.5			0.68			0.35946			1.2		
03/13/23 22:00	0.9			0			1.5			0.5			0.25506			0.85		
03/13/23 23:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/14/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/14/23 1:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/14/23 2:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/14/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/14/23 4:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/14/23 5:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/14/23 6:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/14/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X	
03/14/23 8:00	0	X		0	X		0	X		0.54			0	X		0	X	
03/14/23 9:00	0.7			2			0.6			0.43			0.1671			0.56		
03/14/23 10:00	0.8			0			1.3			0.59			0.31398			1.05		
03/14/23 11:00	0.6			0			1.5			0.67			0.3531			1.18		
03/14/23 12:00	0.5			1			1.5			0.68			0.35766			1.19		
03/14/23 13:00	0.3			1			1.5			0.71			0.37386			1.25		
03/14/23 14:00	0.4			1			1.5			0.68			0.35916			1.2		
03/14/23 15:00	0.8			0			1.5			0.64			0.33876			1.13		
03/14/23 16:00	0.6			1			1.5			0.68			0.3588			1.2		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/14/23 17:00	0.5			1			1.5			0.7			0.36894			1.23		
03/14/23 18:00	0.4			1			1.5			0.71			0.37626			1.25		
03/14/23 19:00	0.4			1			1.5			0.72			0.3813			1.27		
03/14/23 20:00	0.4			1			1.5			0.71			0.37668			1.26		
03/14/23 21:00	0.8			0			1.5			0.66			0.35118			1.17		
03/14/23 22:00	0.9			0			1.5			0.56			0.30162			1.01		
03/14/23 23:00	0.9			1			1.4			0.39			0.17376			0.58		
03/15/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 14:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 15:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/15/23 16:00	0			0	X		0			0.4			0.07734			0.26		
03/15/23 17:00	0.7			0			0.9			0.38			0.20706			0.69		
03/15/23 18:00	1.2			0			1.5			0.57			0.3069			1.02		
03/15/23 19:00	0.7			0			1.5			0.66			0.35256			1.18		
03/15/23 20:00	0.5			0			1.5			0.69			0.36402			1.21		
03/15/23 21:00	1			0			1.5			0.51			0.2601			0.87		
03/15/23 22:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/15/23 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 4:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 6:00	0	X		0	X		0	X		0.36			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/16/23 7:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 8:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 9:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 10:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 11:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 12:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 13:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/16/23 14:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/16/23 15:00	0			0	X		0			0.34			0.08544			0.28		
03/16/23 16:00	0.8			1			1.7			0	X		0.23748			0.79		
03/16/23 17:00	0.7			0			1.5			0	X		0.19542			0.65		
03/16/23 18:00	0.7			0			1.5			0	X		0.19398			0.65		
03/16/23 19:00	0.7			0			1.5			0	X		0.195			0.65		
03/16/23 20:00	0.7			0			1.5			0	X		0.19548			0.65		
03/16/23 21:00	0.8			0			1.4			0	X		0.22344			0.74		
03/16/23 22:00	0.9			0			1.5			0	X		0.22308			0.74		
03/16/23 23:00	0.8			1			1.5			0	X		0.1992			0.66		
03/17/23 0:00	0.8			1			1.5			0	X		0.19788			0.66		
03/17/23 1:00	0.8			0			1.5			0.1			0.22866			0.76		
03/17/23 2:00	0.8			0			1.2			0.4			0.22482			0.75		
03/17/23 3:00	0.8			0			1.5			0.6			0.32556			1.09		
03/17/23 4:00	0.5			1			1.5			0.71			0.37854			1.26		
03/17/23 5:00	0.5			1			1.5			0.73			0.38502			1.28		
03/17/23 6:00	0.7			1			1.5			0.69			0.36804			1.23		
03/17/23 7:00	1.2			1			1.5			0.51			0.27246			0.91		
03/17/23 8:00	0.9			1			1.3			0.41			0.18408			0.61		
03/17/23 9:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 10:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 11:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 12:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 13:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 14:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 15:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/17/23 16:00	0			0	X		0			0.45			0.11046			0.37		
03/17/23 17:00	1.1			0			1.7			0.44			0.23718			0.79		
03/17/23 18:00	0.9			1			1.3			0.66			0.34746			1.16		
03/17/23 19:00	0.5			0			1.4			0.69			0.366			1.22		
03/17/23 20:00	0.8			0			1.5			0.66			0.3501			1.17		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/17/23 21:00	0.7			1			1.5			0.68			0.36084			1.2		
03/17/23 22:00	1			0			1.5			0.49			0.25434			0.85		
03/17/23 23:00	0			0	X		0			0.39			0.05646			0.19		
03/18/23 0:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 1:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 2:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 3:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 4:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 5:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 6:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 7:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 8:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 9:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 10:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 11:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 12:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 13:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 14:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 15:00	0			0	X		0			0.42			0.02304			0.08		
03/18/23 16:00	0.8			0			1.1			0.42			0.20208			0.67		
03/18/23 17:00	1			0			1.5			0.61			0.32322			1.08		
03/18/23 18:00	0.4			1			1.5			0.72			0.3777			1.26		
03/18/23 19:00	0.8			0			1.5			0.66			0.35064			1.17		
03/18/23 20:00	0.8			0			1.5			0.65			0.34512			1.15		
03/18/23 21:00	0.9			0			1.4			0.49			0.24444			0.81		
03/18/23 22:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/18/23 23:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/19/23 0:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 1:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/19/23 2:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 3:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 4:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 5:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 6:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 7:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 8:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 9:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/19/23 10:00	0	X		0	X		0	X		0.36			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/19/23 11:00	0	X		0	X		0	X		0.36			0	X		0	X	
03/19/23 12:00	0	X		0	X		0	X		0.39			0	X		0	X	
03/19/23 13:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 14:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/19/23 15:00	0			0	X		0			0.46			0.1101			0.37		
03/19/23 16:00	0.9			0			1.7			0.41			0.22404			0.75		
03/19/23 17:00	1.1			0			1.5			0.65			0.34884			1.16		
03/19/23 18:00	0.5			0			1.5			0.69			0.36702			1.22		
03/19/23 19:00	0.7			0			1.5			0.67			0.35604			1.19		
03/19/23 20:00	0.6			0			1.5			0.68			0.35904			1.2		
03/19/23 21:00	0.9			0			1.5			0.64			0.34332			1.14		
03/19/23 22:00	1			0			1.5			0.63			0.33516			1.12		
03/19/23 23:00	0.9			0			1.5			0.63			0.33834			1.13		
03/20/23 0:00	1.1			0			1.5			0.53			0.28488			0.95		
03/20/23 1:00	0.7			0			1.4			0.39			0.15564			0.52		
03/20/23 2:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 3:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 4:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 5:00	0	X		0	X		0	X		0.41			0	X		0	X	
03/20/23 6:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 7:00	0	X		0	X		0	X		0.41			0	X		0	X	
03/20/23 8:00	0	X		0	X		0	X		0.4			0	X		0	X	
03/20/23 9:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 10:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 11:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 12:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 13:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 14:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 15:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/20/23 16:00	0			0	X		0			0.48			0.14568			0.49		
03/20/23 17:00	1.7			0			1.5			0.49			0.26574			0.89		
03/20/23 18:00	0.6			1			1.5			0.69			0.36456			1.22		
03/20/23 19:00	0.6			1			1.5			0.69			0.3636			1.21		
03/20/23 20:00	0.6			1			1.3			0.48			0.26106			0.87		
03/20/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/21/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/23 11:00	0			0	X		0			0	X		0.1473			0.49		
03/21/23 12:00	0.9			0			1.5			0	X		0.26076			0.87		
03/21/23 13:00	0.9			1			1.5			0	X		0.20292			0.68		
03/21/23 14:00	0.7			0			1.5			0	X		0.1935			0.65		
03/21/23 15:00	0.7			0			1.5			0	X		0.19242			0.64		
03/21/23 16:00	0.7			0			1.5			0	X		0.19188			0.64		
03/21/23 17:00	0.7			0			1.5			0	X		0.19314			0.64		
03/21/23 18:00	0.7			0			1.5			0	X		0.19302			0.64		
03/21/23 19:00	0.6			1			1.5			0	X		0.1923			0.64		
03/21/23 20:00	0.7			1			1.5			0	X		0.19308			0.64		
03/21/23 21:00	0.7			1			1.5			0	X		0.19356			0.65		
03/21/23 22:00	0.7			0			1.5			0	X		0.19566			0.65		
03/21/23 23:00	0.7			0			1.5			0	X		0.19746			0.66		
03/22/23 0:00	0.7			1			1.5			0	X		0.19788			0.66		
03/22/23 1:00	0.7			1			1.5			0	X		0.19572			0.65		
03/22/23 2:00	0.7			1			1.6			0	X		0.19542			0.65		
03/22/23 3:00	0.7			1			1.5			0	X		0.1953			0.65		
03/22/23 4:00	0.7			1			1.5			0	X		0.19524			0.65		
03/22/23 5:00	0.7			0			1.5			0	X		0.20052			0.67		
03/22/23 6:00	0.8			0			1.4			0	X		0.25074			0.84		
03/22/23 7:00	0.7			0			1.3			0	X		0.1944			0.65		
03/22/23 8:00	0.6			0			1.5			0	X		0.19458			0.65		
03/22/23 9:00	0.7			0			1.5			0	X		0.19614			0.65		
03/22/23 10:00	0.7			0			1.5			0	X		0.19692			0.66		
03/22/23 11:00	0.7			0			1.5			0	X		0.19746			0.66		
03/22/23 12:00	0.6			0			1.5			0	X		0.1962			0.65		
03/22/23 13:00	0.7			0			1.5			0	X		0.19656			0.66		
03/22/23 14:00	0.7			0			1.5			0	X		0.19872			0.66		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/22/23 15:00	0.7			0			1.5			0	X		0.22686			0.76		
03/22/23 16:00	0.7			0			1.5			0.33			0.23682			0.79		
03/22/23 17:00	0.7			0			1.4			0.54			0.29088			0.97		
03/22/23 18:00	0.4			1			1.5			0.72			0.38112			1.27		
03/22/23 19:00	0.4			1			1.5			0.72			0.378			1.26		
03/22/23 20:00	0.6			1			1.5			0.7			0.37068			1.24		
03/22/23 21:00	0.9			0			1.5			0.65			0.3465			1.16		
03/22/23 22:00	1			0			1.5			0.55			0.29676			0.99		
03/22/23 23:00	0.7			0			1.4			0.4			0.23412			0.78		
03/23/23 0:00	0.7			0			1.5			0	X		0.20526			0.68		
03/23/23 1:00	0.7			0			1.5			0	X		0.19968			0.67		
03/23/23 2:00	0.7			0			1.5			0	X		0.19986			0.67		
03/23/23 3:00	0.7			1			1.5			0	X		0.19962			0.67		
03/23/23 4:00	0.7			0			1.5			0	X		0.19878			0.66		
03/23/23 5:00	0.7			0			1.5			0	X		0.1965			0.66		
03/23/23 6:00	0.7			0			1.5			0	X		0.19698			0.66		
03/23/23 7:00	0.7			0			1.5			0	X		0.19926			0.66		
03/23/23 8:00	0.7			1			1.5			0	X		0.19806			0.66		
03/23/23 9:00	0.6			1			1.5			0	X		0.19602			0.65		
03/23/23 10:00	0.7			1			1.5			0	X		0.19608			0.65		
03/23/23 11:00	0.6			0			1.5			0	X		0.19572			0.65		
03/23/23 12:00	0.6			0			1.5			0	X		0.19548			0.65		
03/23/23 13:00	0.7			0			1.5			0	X		0.19572			0.65		
03/23/23 14:00	0.7			0			1.5			0.04			0.21936			0.73		
03/23/23 15:00	0.7			0			1.5			0.33			0.21768			0.73		
03/23/23 16:00	0.9			0			1.5			0.46			0.24462			0.82		
03/23/23 17:00	1			0			1.5			0.62			0.32952			1.1		
03/23/23 18:00	1			0			1.5			0.62			0.32946			1.1		
03/23/23 19:00	1.1			0			1.5			0.61			0.32838			1.09		
03/23/23 20:00	1.1			0			1.5			0.61			0.32802			1.09		
03/23/23 21:00	1.1			0			1.5			0.61			0.3276			1.09		
03/23/23 22:00	1			0			1.4			0.48			0.25938			0.86		
03/23/23 23:00	0.7			0			1.4			0.19			0.21144			0.7		
03/24/23 0:00	0.7			1			1.5			0	X		0.19842			0.66		
03/24/23 1:00	0.7			1			1.5			0	X		0.19836			0.66		
03/24/23 2:00	0.7			1			1.4			0	X		0.1986			0.66		
03/24/23 3:00	0.7			1			1.5			0	X		0.19836			0.66		
03/24/23 4:00	0.7			1			1.5			0	X		0.19842			0.66		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/24/23 5:00	0.7			1			1.5			0	X		0.19818			0.66		
03/24/23 6:00	0.7			1			1.5			0	X		0.1983			0.66		
03/24/23 7:00	0.7			1			1.5			0	X		0.19764			0.66		
03/24/23 8:00	0.7			1			1.5			0	X		0.1974			0.66		
03/24/23 9:00	0.7			1			1.5			0	X		0.19746			0.66		
03/24/23 10:00	0.7			1			1.5			0	X		0.1974			0.66		
03/24/23 11:00	0.7			0			1.5			0	X		0.198			0.66		
03/24/23 12:00	0.7			0			1.5			0	X		0.19788			0.66		
03/24/23 13:00	0.7			0			1.5			0	X		0.19818			0.66		
03/24/23 14:00	0.7			0			1.5			0	X		0.19818			0.66		
03/24/23 15:00	0.7			0			1.5			0	X		0.19788			0.66		
03/24/23 16:00	0.7			0			1.5			0	X		0.19764			0.66		
03/24/23 17:00	0.7			0			1.5			0	X		0.19812			0.66		
03/24/23 18:00	0.7			0			1.5			0	X		0.19818			0.66		
03/24/23 19:00	0.6			1			1.5			0	X		0.19818			0.66		
03/24/23 20:00	0.6			0			1.5			0	X		0.1983			0.66		
03/24/23 21:00	0.6			1			1.5			0	X		0.19932			0.66		
03/24/23 22:00	0.7			1			1.5			0	X		0.19896			0.66		
03/24/23 23:00	0.7			1			1.5			0	X		0.19848			0.66		
03/25/23 0:00	0.6			1			1.5			0	X		0.19776			0.66		
03/25/23 1:00	0.6			1			1.5			0	X		0.19746			0.66		
03/25/23 2:00	0.7			1			1.6			0	X		0.19728			0.66		
03/25/23 3:00	0.7			1			1.5			0	X		0.19758			0.66		
03/25/23 4:00	0.7			1			1.5			0	X		0.19776			0.66		
03/25/23 5:00	0.7			1			1.5			0	X		0.1974			0.66		
03/25/23 6:00	0.7			1			1.5			0	X		0.19752			0.66		
03/25/23 7:00	0.7			1			1.5			0	X		0.19716			0.66		
03/25/23 8:00	0.6			1			1.5			0	X		0.19674			0.66		
03/25/23 9:00	0.6			1			1.5			0	X		0.19632			0.65		
03/25/23 10:00	0.6			1			1.5			0	X		0.19638			0.65		
03/25/23 11:00	0.7			1			1.5			0	X		0.19644			0.65		
03/25/23 12:00	0.7			1			1.5			0	X		0.19614			0.65		
03/25/23 13:00	0.7			0			1.5			0	X		0.19548			0.65		
03/25/23 14:00	0.7			0			1.5			0	X		0.19542			0.65		
03/25/23 15:00	0.7			0			1.5			0	X		0.19548			0.65		
03/25/23 16:00	0.7			0			1.5			0	X		0.1962			0.65		
03/25/23 17:00	0.7			0			1.5			0	X		0.19716			0.66		
03/25/23 18:00	0.7			0			1.5			0	X		0.19818			0.66		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/25/23 19:00	0.8			1			1.5			0	X		0.19836			0.66		
03/25/23 20:00	0.7			0			1.5			0	X		0.19824			0.66		
03/25/23 21:00	0.7			1			1.5			0	X		0.1983			0.66		
03/25/23 22:00	0.7			0			1.5			0	X		0.207			0.69		
03/25/23 23:00	0			0	X		0			0	X		0.12978			0.43		
03/26/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/27/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/28/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
03/30/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/23 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
04/01/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

ATTACHMENT 17

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.47	8.89	14.83
01/02/2023	70.30	107.48	10.90	21.70	36.20
01/03/2023	43.16	158.77	17.15	34.27	57.16
01/04/2023	38.26	76.13	8.09	16.23	27.01
01/05/2023	70.05	62.66	5.86	11.58	19.33
01/06/2023	72.64	70.54	6.51	12.99	21.60
01/07/2023	11.01	41.31	4.50	8.90	14.85
01/08/2023	80.03	72.15	6.89	13.75	22.95
01/09/2023	97.02	81.86	7.88	15.71	26.15
01/10/2023	87.97	77.46	7.47	14.85	24.78
01/11/2023	80.37	71.25	6.96	13.78	22.99
01/12/2023	87.61	71.86	6.88	13.71	22.82
01/13/2023	10.90	41.32	4.55	8.91	14.91
01/14/2023	75.93	69.03	6.51	12.98	21.64
01/15/2023	91.63	75.97	7.42	14.68	24.52
01/16/2023	88.48	78.04	7.60	15.11	25.24
01/17/2023	81.23	76.97	7.38	14.75	24.53
01/18/2023	49.14	78.98	8.55	16.98	28.35
01/19/2023	21.19	46.72	5.30	10.47	17.49
01/20/2023	40.39	62.03	6.78	13.41	22.37
01/21/2023	22.86	59.46	6.41	12.76	21.27
01/22/2023	22.45	50.42	5.46	10.98	18.25
01/23/2023	75.82	95.38	9.25	18.54	30.88
01/24/2023	51.26	82.90	8.97	17.89	29.81
01/25/2023	13.09	41.63	4.56	8.99	15.02
01/26/2023	12.89	41.93	4.56	8.97	14.97
01/27/2023	90.68	65.49	6.08	12.15	20.23
01/28/2023	9.30	37.73	4.14	8.41	13.96
01/29/2023	92.90	62.63	5.49	11.15	18.46
01/30/2023	25.25	66.19	7.20	14.42	24.05
01/31/2023	29.56	64.58	7.04	14.11	23.50
Monthly Avg/Sum*:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
Daily Min:	8.02	37.73	4.14	8.41	13.96
Daily Max:	97.02	158.77	17.15	34.27	57.16
Jan 2023 - Jan 2023	1,651.39	2,129.79	216.81	432.02	720.12
QTD:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
YTD 2023:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.47	11.07	18.41
02/02/2023	8.96	37.94	4.18	8.37	13.99
02/03/2023	53.12	85.39	8.16	16.36	27.29
02/04/2023	108.11	77.99	7.53	14.98	24.95
02/05/2023	87.96	64.19	5.88	11.66	19.40
02/06/2023	84.25	78.56	7.67	15.20	25.38
02/07/2023	74.29	84.12	8.26	16.41	27.37
02/08/2023	102.79	114.57	11.51	22.94	38.30
02/09/2023	110.14	113.63	11.41	22.87	38.08
02/10/2023	71.93	81.12	7.82	15.48	25.86
02/11/2023	108.40	113.45	11.78	23.52	39.21
02/12/2023	106.28	114.76	11.68	23.35	38.89
02/13/2023	35.31	43.33	4.73	9.32	15.55
02/14/2023	68.07	90.12	8.73	17.38	28.96
02/15/2023	139.40	125.21	12.48	24.83	41.34
02/16/2023	113.23	113.19	11.51	23.10	38.43
02/17/2023	51.56	57.29	6.20	12.35	20.58
02/18/2023	14.71	41.46	4.56	8.89	14.89
02/19/2023	16.33	41.56	4.53	8.95	14.93
02/20/2023	93.55	78.91	7.60	15.18	25.29
02/21/2023	10.53	37.94	4.21	8.38	13.95
02/22/2023	74.47	82.53	7.57	15.25	25.37
02/23/2023	63.79	104.53	11.25	22.55	37.54
02/24/2023	33.93	63.80	6.90	13.85	23.09
02/25/2023	11.76	44.64	4.97	9.78	16.39
02/26/2023	8.81	37.99	4.12	8.40	13.93
02/27/2023	78.18	72.19	6.64	13.38	22.27
02/28/2023	82.98	77.32	7.24	14.49	24.11
Monthly Avg/Sum*:	1,832.18 *	2,127.93 *	214.59 *	428.29 *	713.75 *
Daily Min:	8.81	37.94	4.12	8.37	13.93
Daily Max:	139.40	125.21	12.48	24.83	41.34
Jan 2023 - Feb 2023	3,483.57	4,257.72	431.40	860.31	1,433.87
QTD:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *
YTD 2023:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2023	51.98	74.11	8.06	16.05	26.78
03/02/2023	9.67	39.23	4.23	8.55	14.17
03/03/2023	85.29	81.61	7.53	15.10	25.14
03/04/2023	75.09	72.57	6.69	13.45	22.36
03/05/2023	75.04	85.77	8.07	16.09	26.83
03/06/2023	126.20	101.89	9.55	19.18	31.92
03/07/2023	116.20	108.24	10.82	21.73	36.18
03/08/2023	89.84	114.83	11.61	23.23	38.72
03/09/2023	76.00	143.12	15.31	30.58	50.99
03/10/2023	95.18	68.88	6.07	12.24	20.39
03/11/2023	56.34	76.68	7.11	14.40	23.97
03/12/2023	72.36	115.27	11.61	23.25	38.76
03/13/2023	59.09	69.55	7.01	14.14	23.54
03/14/2023	87.90	112.41	11.25	22.52	37.54
03/15/2023	68.63	71.50	6.18	12.49	20.80
03/16/2023	58.11	51.83	4.30	8.72	14.48
03/17/2023	184.98	110.06	9.98	19.98	33.29
03/18/2023	89.16	76.17	6.91	13.89	23.14
03/19/2023	69.83	87.09	8.17	16.41	27.35
03/20/2023	100.82	74.36	5.92	11.91	19.84
03/21/2023	50.51	34.49	2.45	4.94	8.23
03/22/2023	82.62	85.32	8.05	16.02	26.77
03/23/2023	82.43	80.88	7.78	15.50	25.79
03/24/2023	12.46	43.27	4.80	9.57	15.84
03/25/2023	25.39	43.01	4.63	9.10	15.18
03/26/2023	0.00	0.00	0.00	0.00	0.00
03/27/2023	0.00	0.00	0.00	0.00	0.00
03/28/2023	0.00	0.00	0.00	0.00	0.00
03/29/2023	0.00	0.00	0.00	0.00	0.00
03/30/2023	0.00	0.00	0.00	0.00	0.00
03/31/2023	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	1,901.12 *	2,022.14 *	194.09 *	389.04 *	648.00 *
Daily Min:	9.67	34.49	2.45	4.94	8.23
Daily Max:	184.98	143.12	15.31	30.58	50.99
Jan 2023 - Mar 2023	5,384.69	6,279.86	625.49	1,249.35	2,081.87
QTD:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *
YTD 2023:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
01/01/2023	0.00	0.00	0.0	0.00	0.00
01/02/2023	56.95	45.89	4.3	8.07	13.45
01/03/2023	21.50	76.62	8.8	16.62	27.70
01/04/2023	24.58	24.68	2.6	5.13	8.51
01/05/2023	57.48	18.57	0.9	1.83	3.05
01/06/2023	57.39	24.30	1.4	2.78	4.62
01/07/2023	0.00	0.00	0.0	0.00	0.00
01/08/2023	64.32	25.12	1.7	3.33	5.56
01/09/2023	79.81	31.33	2.2	4.61	7.68
01/10/2023	70.81	28.60	2.0	4.08	6.81
01/11/2023	64.59	23.74	1.7	3.33	5.53
01/12/2023	71.90	24.54	1.7	3.38	5.61
01/13/2023	0.00	0.00	0.0	0.00	0.00
01/14/2023	61.07	23.27	1.4	2.78	4.62
01/15/2023	74.99	26.95	1.9	3.96	6.61
01/16/2023	71.17	29.00	2.1	4.35	7.25
01/17/2023	62.55	27.66	2.0	3.91	6.53
01/18/2023	27.47	26.30	2.7	5.54	9.22
01/19/2023	0.00	0.00	0.0	0.00	0.00
01/20/2023	0.00	0.00	0.0	0.00	0.00
01/21/2023	0.00	0.00	0.0	0.00	0.00
01/22/2023	0.00	0.00	0.0	0.00	0.00
01/23/2023	45.51	32.42	2.2	4.76	7.95
01/24/2023	28.15	28.52	3.0	6.02	10.02
01/25/2023	0.00	0.00	0.0	0.00	0.00
01/26/2023	0.00	0.00	0.0	0.00	0.00
01/27/2023	52.26	24.65	1.8	3.42	5.68
01/28/2023	9.30	37.73	4.8	8.41	13.96
01/29/2023	10.01	41.55	5.1	9.23	15.28
01/30/2023	25.25	66.19	7.1	14.42	24.05
01/31/2023	29.56	64.58	7.0	14.11	23.50
Monthly Avg/Sum*:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *
Daily Min:	9.30	18.57	0.9	1.83	3.05
Daily Max:	79.81	76.62	8.8	16.62	27.70
Jan 2023 - Jan 2023	1,066.62	752.21	68.4	134.07	223.19
QTD:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *
YTD 2023:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.8	11.07	18.41
02/02/2023	8.96	37.94	4.8	8.37	13.99
02/03/2023	18.33	53.00	5.9	11.50	19.17
02/04/2023	88.90	28.42	1.9	4.10	6.82
02/05/2023	72.85	19.97	1.1	2.02	3.34
02/06/2023	66.07	28.38	2.1	4.33	7.21
02/07/2023	54.39	31.54	2.3	5.02	8.36
02/08/2023	19.59	58.04	6.5	12.56	20.95
02/09/2023	16.98	57.78	6.5	12.55	20.88
02/10/2023	15.54	47.51	5.5	10.44	17.46
02/11/2023	78.77	51.25	4.8	9.90	16.53
02/12/2023	18.67	58.19	6.1	12.65	21.08
02/13/2023	21.08	1.97	0.1	0.26	0.44
02/14/2023	48.02	35.19	2.8	5.47	9.10
02/15/2023	78.97	56.55	5.7	10.86	18.06
02/16/2023	84.71	51.67	4.7	9.71	16.14
02/17/2023	32.40	11.48	1.1	2.26	3.77
02/18/2023	0.00	0.00	0.0	0.00	0.00
02/19/2023	0.00	0.00	0.0	0.00	0.00
02/20/2023	55.98	29.43	2.2	4.49	7.50
02/21/2023	10.53	37.94	4.8	8.38	13.95
02/22/2023	13.81	47.37	5.5	10.39	17.25
02/23/2023	20.19	61.35	7.1	13.33	22.19
02/24/2023	33.93	63.80	7.2	13.85	23.09
02/25/2023	11.76	44.64	5.4	9.78	16.39
02/26/2023	8.81	37.99	4.8	8.40	13.93
02/27/2023	13.34	44.70	5.4	9.87	16.42
02/28/2023	15.61	46.23	5.4	10.12	16.83
Monthly Avg/Sum*:	927.53 *	1,092.53 *	115.5 *	221.68 *	369.26 *
Daily Min:	8.81	1.97	0.1	0.26	0.44
Daily Max:	88.90	63.80	7.2	13.85	23.09
Jan 2023 - Feb 2023	1,994.15	1,844.74	183.9	355.75	592.45
QTD:	1,994.15 *	1,844.74 *	183.9 *	355.75 *	592.45 *
YTD 2023:	1,994.15 *	1,844.74 *	183.9 *	355.75 *	592.45 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
03/01/2023	15.98	48.98	5.6	10.60	17.71
03/02/2023	9.67	39.23	4.8	8.55	14.17
03/03/2023	17.71	49.06	5.6	10.70	17.80
03/04/2023	13.00	45.07	5.2	9.84	16.34
03/05/2023	13.80	49.68	5.7	10.71	17.89
03/06/2023	20.36	52.61	6.0	11.52	19.14
03/07/2023	21.62	55.27	6.3	12.11	20.14
03/08/2023	22.39	57.71	6.3	12.58	20.91
03/09/2023	23.79	69.25	7.3	14.94	24.88
03/10/2023	9.44	42.96	5.2	9.45	15.73
03/11/2023	9.07	46.22	5.5	10.10	16.79
03/12/2023	11.68	58.61	6.6	12.77	21.29
03/13/2023	8.96	47.05	5.4	10.30	17.12
03/14/2023	10.54	59.12	6.6	12.91	21.51
03/15/2023	8.47	43.30	5.2	9.52	15.84
03/16/2023	4.36	24.48	3.1	5.35	8.88
03/17/2023	80.03	57.91	5.5	11.12	18.50
03/18/2023	11.23	46.72	5.3	10.25	17.07
03/19/2023	12.23	50.34	5.5	10.99	18.33
03/20/2023	28.92	42.52	4.4	8.81	14.66
03/21/2023	0.00	0.00	0.0	0.00	0.00
03/22/2023	67.43	32.81	2.3	4.52	7.54
03/23/2023	64.93	29.97	2.1	4.35	7.24
03/24/2023	0.00	0.00	0.0	0.00	0.00
03/25/2023	0.00	0.00	0.0	0.00	0.00
03/26/2023	0.00	0.00	0.0	0.00	0.00
03/27/2023	0.00	0.00	0.0	0.00	0.00
03/28/2023	0.00	0.00	0.0	0.00	0.00
03/29/2023	0.00	0.00	0.0	0.00	0.00
03/30/2023	0.00	0.00	0.0	0.00	0.00
03/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	485.61 *	1,048.87 *	115.5 *	221.99 *	369.48 *
Daily Min:	4.36	24.48	2.1	4.35	7.24
Daily Max:	80.03	69.25	7.3	14.94	24.88
Jan 2023 - Mar 2023	2,479.76	2,893.61	299.4	577.74	961.93
QTD:	2,479.76 *	2,893.61 *	299.4 *	577.74 *	961.93 *
YTD 2023:	2,479.76 *	2,893.61 *	299.4 *	577.74 *	961.93 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.8	8.89	14.83
01/02/2023	13.35	61.59	7.0	13.63	22.75
01/03/2023	21.66	82.15	8.9	17.65	29.46
01/04/2023	13.68	51.45	5.7	11.10	18.50
01/05/2023	12.57	44.09	5.1	9.75	16.28
01/06/2023	15.25	46.24	5.2	10.21	16.98
01/07/2023	11.01	41.31	4.8	8.90	14.85
01/08/2023	15.71	47.03	5.3	10.42	17.39
01/09/2023	17.21	50.53	5.5	11.10	18.47
01/10/2023	17.16	48.86	5.4	10.77	17.97
01/11/2023	15.78	47.51	5.3	10.45	17.46
01/12/2023	15.71	47.32	5.3	10.33	17.21
01/13/2023	10.90	41.32	4.8	8.91	14.91
01/14/2023	14.86	45.76	5.2	10.20	17.02
01/15/2023	16.64	49.02	5.4	10.72	17.91
01/16/2023	17.31	49.04	5.4	10.76	17.99
01/17/2023	18.68	49.31	5.4	10.84	18.00
01/18/2023	21.67	52.68	5.7	11.44	19.13
01/19/2023	21.19	46.72	5.5	10.47	17.49
01/20/2023	40.39	62.03	6.7	13.41	22.37
01/21/2023	22.86	59.46	6.4	12.76	21.27
01/22/2023	22.45	50.42	5.6	10.98	18.25
01/23/2023	30.31	62.96	6.8	13.78	22.93
01/24/2023	23.11	54.38	6.0	11.87	19.79
01/25/2023	13.09	41.63	4.8	8.99	15.02
01/26/2023	12.89	41.93	4.8	8.97	14.97
01/27/2023	38.42	40.84	4.5	8.73	14.55
01/28/2023	0.00	0.00	0.0	0.00	0.00
01/29/2023	82.89	21.08	0.9	1.92	3.18
01/30/2023	0.00	0.00	0.0	0.00	0.00
01/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *
Daily Min:	8.02	21.08	0.9	1.92	3.18
Daily Max:	82.89	82.15	8.9	17.65	29.46
Jan 2023 - Jan 2023	584.77	1,377.58	152.2	297.95	496.93
QTD:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *
YTD 2023:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
02/01/2023	0.00	0.00	0.0	0.00	0.00
02/02/2023	0.00	0.00	0.0	0.00	0.00
02/03/2023	34.79	32.39	2.4	4.86	8.12
02/04/2023	19.21	49.57	5.6	10.88	18.13
02/05/2023	15.11	44.22	5.0	9.64	16.06
02/06/2023	18.18	50.18	5.7	10.87	18.17
02/07/2023	19.90	52.58	6.0	11.39	19.01
02/08/2023	83.20	56.53	5.4	10.38	17.35
02/09/2023	93.16	55.85	5.5	10.32	17.20
02/10/2023	56.39	33.61	2.3	5.04	8.40
02/11/2023	29.63	62.20	6.3	13.62	22.68
02/12/2023	87.61	56.57	5.3	10.70	17.81
02/13/2023	14.23	41.36	4.8	9.06	15.11
02/14/2023	20.05	54.93	6.3	11.91	19.86
02/15/2023	60.43	68.66	7.2	13.97	23.28
02/16/2023	28.52	61.52	6.6	13.39	22.29
02/17/2023	19.16	45.81	5.1	10.09	16.81
02/18/2023	14.71	41.46	4.8	8.89	14.89
02/19/2023	16.33	41.56	4.8	8.95	14.93
02/20/2023	37.57	49.48	5.5	10.69	17.79
02/21/2023	0.00	0.00	0.0	0.00	0.00
02/22/2023	60.66	35.16	2.6	4.86	8.12
02/23/2023	43.60	43.18	4.5	9.22	15.35
02/24/2023	0.00	0.00	0.0	0.00	0.00
02/25/2023	0.00	0.00	0.0	0.00	0.00
02/26/2023	0.00	0.00	0.0	0.00	0.00
02/27/2023	64.84	27.49	1.8	3.51	5.85
02/28/2023	67.37	31.09	2.0	4.37	7.28
Monthly Avg/Sum*:	904.65 *	1,035.40 *	105.5 *	206.61 *	344.49 *
Daily Min:	14.23	27.49	1.8	3.51	5.85
Daily Max:	93.16	68.66	7.2	13.97	23.28
Jan 2023 - Feb 2023	1,489.42	2,412.98	257.7	504.56	841.42
QTD:	1,489.42 *	2,412.98 *	257.7 *	504.56 *	841.42 *
YTD 2023:	1,489.42 *	2,412.98 *	257.7 *	504.56 *	841.42 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
03/01/2023	36.00	25.13	2.6	5.45	9.07
03/02/2023	0.00	0.00	0.0	0.00	0.00
03/03/2023	67.58	32.55	2.0	4.40	7.34
03/04/2023	62.09	27.50	2.0	3.61	6.02
03/05/2023	61.24	36.09	2.8	5.38	8.94
03/06/2023	105.84	49.28	3.6	7.66	12.78
03/07/2023	94.58	52.97	4.5	9.62	16.04
03/08/2023	67.45	57.12	4.9	10.65	17.81
03/09/2023	52.21	73.87	7.4	15.64	26.11
03/10/2023	85.74	25.92	1.3	2.79	4.66
03/11/2023	47.27	30.46	2.2	4.30	7.18
03/12/2023	60.68	56.66	5.5	10.48	17.47
03/13/2023	50.13	22.50	2.0	3.84	6.42
03/14/2023	77.36	53.29	5.0	9.61	16.03
03/15/2023	60.16	28.20	1.5	2.97	4.96
03/16/2023	53.75	27.35	1.6	3.37	5.60
03/17/2023	104.95	52.15	4.5	8.86	14.79
03/18/2023	77.93	29.45	1.8	3.64	6.07
03/19/2023	57.60	36.75	2.6	5.42	9.02
03/20/2023	71.90	31.84	1.7	3.10	5.18
03/21/2023	50.51	34.49	2.6	4.94	8.23
03/22/2023	15.19	52.51	5.8	11.50	19.23
03/23/2023	17.50	50.91	5.4	11.15	18.55
03/24/2023	12.46	43.27	4.8	9.57	15.84
03/25/2023	25.39	43.01	4.6	9.10	15.18
03/26/2023	0.00	0.00	0.0	0.00	0.00
03/27/2023	0.00	0.00	0.0	0.00	0.00
03/28/2023	0.00	0.00	0.0	0.00	0.00
03/29/2023	0.00	0.00	0.0	0.00	0.00
03/30/2023	0.00	0.00	0.0	0.00	0.00
03/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	1,415.51 *	973.27 *	82.7 *	167.05 *	278.52 *
Daily Min:	12.46	22.50	1.3	2.79	4.66
Daily Max:	105.84	73.87	7.4	15.64	26.11
Jan 2023 - Mar 2023	2,904.93	3,386.25	340.4	671.61	1,119.94
QTD:	2,904.93 *	3,386.25 *	340.4 *	671.61 *	1,119.94 *
YTD 2023:	2,904.93 *	3,386.25 *	340.4 *	671.61 *	1,119.94 *

ATTACHMENT 18

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NO _x	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM ₁₀	16,300	13,692	17,789	17,569	32.67
SO _x	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
01/01/2023	8.02	40.92	4.47	8.89	14.83	
01/02/2023	70.30	107.48	10.90	21.70	36.20	
01/03/2023	43.16	158.77	17.15	34.27	57.16	
01/04/2023	38.26	76.13	8.09	16.23	27.01	
01/05/2023	70.05	62.66	5.86	11.58	19.33	
01/06/2023	72.64	70.54	6.51	12.99	21.60	
01/07/2023	11.01	41.31	4.50	8.90	14.85	
01/08/2023	80.03	72.15	6.89	13.75	22.95	
01/09/2023	97.02	81.86	7.88	15.71	26.15	
01/10/2023	87.97	77.46	7.47	14.85	24.78	
01/11/2023	80.37	71.25	6.96	13.78	22.99	
01/12/2023	87.61	71.86	6.88	13.71	22.82	
01/13/2023	10.90	41.32	4.55	8.91	14.91	
01/14/2023	75.93	69.03	6.51	12.98	21.64	
01/15/2023	91.63	75.97	7.42	14.68	24.52	
01/16/2023	88.48	78.04	7.60	15.11	25.24	
01/17/2023	81.23	76.97	7.38	14.75	24.53	
01/18/2023	49.14	78.98	8.55	16.98	28.35	
01/19/2023	21.19	46.72	5.30	10.47	17.49	
01/20/2023	40.39	62.03	6.78	13.41	22.37	
01/21/2023	22.86	59.46	6.41	12.76	21.27	
01/22/2023	22.45	50.42	5.46	10.98	18.25	
01/23/2023	75.82	95.38	9.25	18.54	30.88	
01/24/2023	51.26	82.90	8.97	17.89	29.81	
01/25/2023	13.09	41.63	4.56	8.99	15.02	
01/26/2023	12.89	41.93	4.56	8.97	14.97	
01/27/2023	90.68	65.49	6.08	12.15	20.23	
01/28/2023	9.30	37.73	4.14	8.41	13.96	
01/29/2023	92.90	62.63	5.49	11.15	18.46	
01/30/2023	25.25	66.19	7.20	14.42	24.05	
01/31/2023	29.56	64.58	7.04	14.11	23.50	
Monthly Avg/Sum*:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *	
Daily Min:	8.02	37.73	4.14	8.41	13.96	
Daily Max:	97.02	158.77	17.15	34.27	57.16	
Jan 2023 - Jan 2023	1,651.39	2,129.79	216.81	432.02	720.12	
QTD:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *	
YTD 2023:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *	

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.47	11.07	18.41
02/02/2023	8.96	37.94	4.18	8.37	13.99
02/03/2023	53.12	85.39	8.16	16.36	27.29
02/04/2023	108.11	77.99	7.53	14.98	24.95
02/05/2023	87.96	64.19	5.88	11.66	19.40
02/06/2023	84.25	78.56	7.67	15.20	25.38
02/07/2023	74.29	84.12	8.26	16.41	27.37
02/08/2023	102.79	114.57	11.51	22.94	38.30
02/09/2023	110.14	113.63	11.41	22.87	38.08
02/10/2023	71.93	81.12	7.82	15.48	25.86
02/11/2023	108.40	113.45	11.78	23.52	39.21
02/12/2023	106.28	114.76	11.68	23.35	38.89
02/13/2023	35.31	43.33	4.73	9.32	15.55
02/14/2023	68.07	90.12	8.73	17.38	28.96
02/15/2023	139.40	125.21	12.48	24.83	41.34
02/16/2023	113.23	113.19	11.51	23.10	38.43
02/17/2023	51.56	57.29	6.20	12.35	20.58
02/18/2023	14.71	41.46	4.56	8.89	14.89
02/19/2023	16.33	41.56	4.53	8.95	14.93
02/20/2023	93.55	78.91	7.60	15.18	25.29
02/21/2023	10.53	37.94	4.21	8.38	13.95
02/22/2023	74.47	82.53	7.57	15.25	25.37
02/23/2023	63.79	104.53	11.25	22.55	37.54
02/24/2023	33.93	63.80	6.90	13.85	23.09
02/25/2023	11.76	44.64	4.97	9.78	16.39
02/26/2023	8.81	37.99	4.12	8.40	13.93
02/27/2023	78.18	72.19	6.64	13.38	22.27
02/28/2023	82.98	77.32	7.24	14.49	24.11
Monthly Avg/Sum*:	1,832.18 *	2,127.93 *	214.59 *	428.29 *	713.75 *
Daily Min:	8.81	37.94	4.12	8.37	13.93
Daily Max:	139.40	125.21	12.48	24.83	41.34
Jan 2023 - Feb 2023	3,483.57	4,257.72	431.40	860.31	1,433.87
QTD:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *
YTD 2023:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2023	51.98	74.11	8.06	16.05	26.78
03/02/2023	9.67	39.23	4.23	8.55	14.17
03/03/2023	85.29	81.61	7.53	15.10	25.14
03/04/2023	75.09	72.57	6.69	13.45	22.36
03/05/2023	75.04	85.77	8.07	16.09	26.83
03/06/2023	126.20	101.89	9.55	19.18	31.92
03/07/2023	116.20	108.24	10.82	21.73	36.18
03/08/2023	89.84	114.83	11.61	23.23	38.72
03/09/2023	76.00	143.12	15.31	30.58	50.99
03/10/2023	95.18	68.88	6.07	12.24	20.39
03/11/2023	56.34	76.68	7.11	14.40	23.97
03/12/2023	72.36	115.27	11.61	23.25	38.76
03/13/2023	59.09	69.55	7.01	14.14	23.54
03/14/2023	87.90	112.41	11.25	22.52	37.54
03/15/2023	68.63	71.50	6.18	12.49	20.80
03/16/2023	58.11	51.83	4.30	8.72	14.48
03/17/2023	184.98	110.06	9.98	19.98	33.29
03/18/2023	89.16	76.17	6.91	13.89	23.14
03/19/2023	69.83	87.09	8.17	16.41	27.35
03/20/2023	100.82	74.36	5.92	11.91	19.84
03/21/2023	50.51	34.49	2.45	4.94	8.23
03/22/2023	82.62	85.32	8.05	16.02	26.77
03/23/2023	82.43	80.88	7.78	15.50	25.79
03/24/2023	12.46	43.27	4.80	9.57	15.84
03/25/2023	25.39	43.01	4.63	9.10	15.18
03/26/2023	0.00	0.00	0.00	0.00	0.00
03/27/2023	0.00	0.00	0.00	0.00	0.00
03/28/2023	0.00	0.00	0.00	0.00	0.00
03/29/2023	0.00	0.00	0.00	0.00	0.00
03/30/2023	0.00	0.00	0.00	0.00	0.00
03/31/2023	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	1,901.12 *	2,022.14 *	194.09 *	389.04 *	648.00 *
Daily Min:	9.67	34.49	2.45	4.94	8.23
Daily Max:	184.98	143.12	15.31	30.58	50.99
Jan 2023 - Mar 2023	5,384.69	6,279.86	625.49	1,249.35	2,081.87
QTD:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *
YTD 2023:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
01/01/2023	0.00	0.00	0.0	0.00	0.00
01/02/2023	56.95	45.89	4.3	8.07	13.45
01/03/2023	21.50	76.62	8.8	16.62	27.70
01/04/2023	24.58	24.68	2.6	5.13	8.51
01/05/2023	57.48	18.57	0.9	1.83	3.05
01/06/2023	57.39	24.30	1.4	2.78	4.62
01/07/2023	0.00	0.00	0.0	0.00	0.00
01/08/2023	64.32	25.12	1.7	3.33	5.56
01/09/2023	79.81	31.33	2.2	4.61	7.68
01/10/2023	70.81	28.60	2.0	4.08	6.81
01/11/2023	64.59	23.74	1.7	3.33	5.53
01/12/2023	71.90	24.54	1.7	3.38	5.61
01/13/2023	0.00	0.00	0.0	0.00	0.00
01/14/2023	61.07	23.27	1.4	2.78	4.62
01/15/2023	74.99	26.95	1.9	3.96	6.61
01/16/2023	71.17	29.00	2.1	4.35	7.25
01/17/2023	62.55	27.66	2.0	3.91	6.53
01/18/2023	27.47	26.30	2.7	5.54	9.22
01/19/2023	0.00	0.00	0.0	0.00	0.00
01/20/2023	0.00	0.00	0.0	0.00	0.00
01/21/2023	0.00	0.00	0.0	0.00	0.00
01/22/2023	0.00	0.00	0.0	0.00	0.00
01/23/2023	45.51	32.42	2.2	4.76	7.95
01/24/2023	28.15	28.52	3.0	6.02	10.02
01/25/2023	0.00	0.00	0.0	0.00	0.00
01/26/2023	0.00	0.00	0.0	0.00	0.00
01/27/2023	52.26	24.65	1.8	3.42	5.68
01/28/2023	9.30	37.73	4.8	8.41	13.96
01/29/2023	10.01	41.55	5.1	9.23	15.28
01/30/2023	25.25	66.19	7.1	14.42	24.05
01/31/2023	29.56	64.58	7.0	14.11	23.50
Monthly Avg/Sum*:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *
Daily Min:	9.30	18.57	0.9	1.83	3.05
Daily Max:	79.81	76.62	8.8	16.62	27.70
Jan 2023 - Jan 2023	1,066.62	752.21	68.4	134.07	223.19
QTD:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *
YTD 2023:	1,066.62 *	752.21 *	68.4 *	134.07 *	223.19 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
02/01/2023	19.34	50.20	5.8	11.07	18.41
02/02/2023	8.96	37.94	4.8	8.37	13.99
02/03/2023	18.33	53.00	5.9	11.50	19.17
02/04/2023	88.90	28.42	1.9	4.10	6.82
02/05/2023	72.85	19.97	1.1	2.02	3.34
02/06/2023	66.07	28.38	2.1	4.33	7.21
02/07/2023	54.39	31.54	2.3	5.02	8.36
02/08/2023	19.59	58.04	6.5	12.56	20.95
02/09/2023	16.98	57.78	6.5	12.55	20.88
02/10/2023	15.54	47.51	5.5	10.44	17.46
02/11/2023	78.77	51.25	4.8	9.90	16.53
02/12/2023	18.67	58.19	6.1	12.65	21.08
02/13/2023	21.08	1.97	0.1	0.26	0.44
02/14/2023	48.02	35.19	2.8	5.47	9.10
02/15/2023	78.97	56.55	5.7	10.86	18.06
02/16/2023	84.71	51.67	4.7	9.71	16.14
02/17/2023	32.40	11.48	1.1	2.26	3.77
02/18/2023	0.00	0.00	0.0	0.00	0.00
02/19/2023	0.00	0.00	0.0	0.00	0.00
02/20/2023	55.98	29.43	2.2	4.49	7.50
02/21/2023	10.53	37.94	4.8	8.38	13.95
02/22/2023	13.81	47.37	5.5	10.39	17.25
02/23/2023	20.19	61.35	7.1	13.33	22.19
02/24/2023	33.93	63.80	7.2	13.85	23.09
02/25/2023	11.76	44.64	5.4	9.78	16.39
02/26/2023	8.81	37.99	4.8	8.40	13.93
02/27/2023	13.34	44.70	5.4	9.87	16.42
02/28/2023	15.61	46.23	5.4	10.12	16.83
Monthly Avg/Sum*:	927.53 *	1,092.53 *	115.5 *	221.68 *	369.26 *
Daily Min:	8.81	1.97	0.1	0.26	0.44
Daily Max:	88.90	63.80	7.2	13.85	23.09
Jan 2023 - Feb 2023	1,994.15	1,844.74	183.9	355.75	592.45
QTD:	1,994.15 *	1,844.74 *	183.9 *	355.75 *	592.45 *
YTD 2023:	1,994.15 *	1,844.74 *	183.9 *	355.75 *	592.45 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
03/01/2023	15.98	48.98	5.6	10.60	17.71
03/02/2023	9.67	39.23	4.8	8.55	14.17
03/03/2023	17.71	49.06	5.6	10.70	17.80
03/04/2023	13.00	45.07	5.2	9.84	16.34
03/05/2023	13.80	49.68	5.7	10.71	17.89
03/06/2023	20.36	52.61	6.0	11.52	19.14
03/07/2023	21.62	55.27	6.3	12.11	20.14
03/08/2023	22.39	57.71	6.3	12.58	20.91
03/09/2023	23.79	69.25	7.3	14.94	24.88
03/10/2023	9.44	42.96	5.2	9.45	15.73
03/11/2023	9.07	46.22	5.5	10.10	16.79
03/12/2023	11.68	58.61	6.6	12.77	21.29
03/13/2023	8.96	47.05	5.4	10.30	17.12
03/14/2023	10.54	59.12	6.6	12.91	21.51
03/15/2023	8.47	43.30	5.2	9.52	15.84
03/16/2023	4.36	24.48	3.1	5.35	8.88
03/17/2023	80.03	57.91	5.5	11.12	18.50
03/18/2023	11.23	46.72	5.3	10.25	17.07
03/19/2023	12.23	50.34	5.5	10.99	18.33
03/20/2023	28.92	42.52	4.4	8.81	14.66
03/21/2023	0.00	0.00	0.0	0.00	0.00
03/22/2023	67.43	32.81	2.3	4.52	7.54
03/23/2023	64.93	29.97	2.1	4.35	7.24
03/24/2023	0.00	0.00	0.0	0.00	0.00
03/25/2023	0.00	0.00	0.0	0.00	0.00
03/26/2023	0.00	0.00	0.0	0.00	0.00
03/27/2023	0.00	0.00	0.0	0.00	0.00
03/28/2023	0.00	0.00	0.0	0.00	0.00
03/29/2023	0.00	0.00	0.0	0.00	0.00
03/30/2023	0.00	0.00	0.0	0.00	0.00
03/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	485.61 *	1,048.87 *	115.5 *	221.99 *	369.48 *
Daily Min:	4.36	24.48	2.1	4.35	7.24
Daily Max:	80.03	69.25	7.3	14.94	24.88
Jan 2023 - Mar 2023	2,479.76	2,893.61	299.4	577.74	961.93
QTD:	2,479.76 *	2,893.61 *	299.4 *	577.74 *	961.93 *
YTD 2023:	2,479.76 *	2,893.61 *	299.4 *	577.74 *	961.93 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.8	8.89	14.83
01/02/2023	13.35	61.59	7.0	13.63	22.75
01/03/2023	21.66	82.15	8.9	17.65	29.46
01/04/2023	13.68	51.45	5.7	11.10	18.50
01/05/2023	12.57	44.09	5.1	9.75	16.28
01/06/2023	15.25	46.24	5.2	10.21	16.98
01/07/2023	11.01	41.31	4.8	8.90	14.85
01/08/2023	15.71	47.03	5.3	10.42	17.39
01/09/2023	17.21	50.53	5.5	11.10	18.47
01/10/2023	17.16	48.86	5.4	10.77	17.97
01/11/2023	15.78	47.51	5.3	10.45	17.46
01/12/2023	15.71	47.32	5.3	10.33	17.21
01/13/2023	10.90	41.32	4.8	8.91	14.91
01/14/2023	14.86	45.76	5.2	10.20	17.02
01/15/2023	16.64	49.02	5.4	10.72	17.91
01/16/2023	17.31	49.04	5.4	10.76	17.99
01/17/2023	18.68	49.31	5.4	10.84	18.00
01/18/2023	21.67	52.68	5.7	11.44	19.13
01/19/2023	21.19	46.72	5.5	10.47	17.49
01/20/2023	40.39	62.03	6.7	13.41	22.37
01/21/2023	22.86	59.46	6.4	12.76	21.27
01/22/2023	22.45	50.42	5.6	10.98	18.25
01/23/2023	30.31	62.96	6.8	13.78	22.93
01/24/2023	23.11	54.38	6.0	11.87	19.79
01/25/2023	13.09	41.63	4.8	8.99	15.02
01/26/2023	12.89	41.93	4.8	8.97	14.97
01/27/2023	38.42	40.84	4.5	8.73	14.55
01/28/2023	0.00	0.00	0.0	0.00	0.00
01/29/2023	82.89	21.08	0.9	1.92	3.18
01/30/2023	0.00	0.00	0.0	0.00	0.00
01/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *
Daily Min:	8.02	21.08	0.9	1.92	3.18
Daily Max:	82.89	82.15	8.9	17.65	29.46
Jan 2023 - Jan 2023	584.77	1,377.58	152.2	297.95	496.93
QTD:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *
YTD 2023:	584.77 *	1,377.58 *	152.2 *	297.95 *	496.93 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
02/01/2023	0.00	0.00	0.0	0.00	0.00
02/02/2023	0.00	0.00	0.0	0.00	0.00
02/03/2023	34.79	32.39	2.4	4.86	8.12
02/04/2023	19.21	49.57	5.6	10.88	18.13
02/05/2023	15.11	44.22	5.0	9.64	16.06
02/06/2023	18.18	50.18	5.7	10.87	18.17
02/07/2023	19.90	52.58	6.0	11.39	19.01
02/08/2023	83.20	56.53	5.4	10.38	17.35
02/09/2023	93.16	55.85	5.5	10.32	17.20
02/10/2023	56.39	33.61	2.3	5.04	8.40
02/11/2023	29.63	62.20	6.3	13.62	22.68
02/12/2023	87.61	56.57	5.3	10.70	17.81
02/13/2023	14.23	41.36	4.8	9.06	15.11
02/14/2023	20.05	54.93	6.3	11.91	19.86
02/15/2023	60.43	68.66	7.2	13.97	23.28
02/16/2023	28.52	61.52	6.6	13.39	22.29
02/17/2023	19.16	45.81	5.1	10.09	16.81
02/18/2023	14.71	41.46	4.8	8.89	14.89
02/19/2023	16.33	41.56	4.8	8.95	14.93
02/20/2023	37.57	49.48	5.5	10.69	17.79
02/21/2023	0.00	0.00	0.0	0.00	0.00
02/22/2023	60.66	35.16	2.6	4.86	8.12
02/23/2023	43.60	43.18	4.5	9.22	15.35
02/24/2023	0.00	0.00	0.0	0.00	0.00
02/25/2023	0.00	0.00	0.0	0.00	0.00
02/26/2023	0.00	0.00	0.0	0.00	0.00
02/27/2023	64.84	27.49	1.8	3.51	5.85
02/28/2023	67.37	31.09	2.0	4.37	7.28
Monthly Avg/Sum*:	904.65 *	1,035.40 *	105.5 *	206.61 *	344.49 *
Daily Min:	14.23	27.49	1.8	3.51	5.85
Daily Max:	93.16	68.66	7.2	13.97	23.28
Jan 2023 - Feb 2023	1,489.42	2,412.98	257.7	504.56	841.42
QTD:	1,489.42 *	2,412.98 *	257.7 *	504.56 *	841.42 *
YTD 2023:	1,489.42 *	2,412.98 *	257.7 *	504.56 *	841.42 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 10:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
03/01/2023	36.00	25.13	2.6	5.45	9.07
03/02/2023	0.00	0.00	0.0	0.00	0.00
03/03/2023	67.58	32.55	2.0	4.40	7.34
03/04/2023	62.09	27.50	2.0	3.61	6.02
03/05/2023	61.24	36.09	2.8	5.38	8.94
03/06/2023	105.84	49.28	3.6	7.66	12.78
03/07/2023	94.58	52.97	4.5	9.62	16.04
03/08/2023	67.45	57.12	4.9	10.65	17.81
03/09/2023	52.21	73.87	7.4	15.64	26.11
03/10/2023	85.74	25.92	1.3	2.79	4.66
03/11/2023	47.27	30.46	2.2	4.30	7.18
03/12/2023	60.68	56.66	5.5	10.48	17.47
03/13/2023	50.13	22.50	2.0	3.84	6.42
03/14/2023	77.36	53.29	5.0	9.61	16.03
03/15/2023	60.16	28.20	1.5	2.97	4.96
03/16/2023	53.75	27.35	1.6	3.37	5.60
03/17/2023	104.95	52.15	4.5	8.86	14.79
03/18/2023	77.93	29.45	1.8	3.64	6.07
03/19/2023	57.60	36.75	2.6	5.42	9.02
03/20/2023	71.90	31.84	1.7	3.10	5.18
03/21/2023	50.51	34.49	2.6	4.94	8.23
03/22/2023	15.19	52.51	5.8	11.50	19.23
03/23/2023	17.50	50.91	5.4	11.15	18.55
03/24/2023	12.46	43.27	4.8	9.57	15.84
03/25/2023	25.39	43.01	4.6	9.10	15.18
03/26/2023	0.00	0.00	0.0	0.00	0.00
03/27/2023	0.00	0.00	0.0	0.00	0.00
03/28/2023	0.00	0.00	0.0	0.00	0.00
03/29/2023	0.00	0.00	0.0	0.00	0.00
03/30/2023	0.00	0.00	0.0	0.00	0.00
03/31/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	1,415.51 *	973.27 *	82.7 *	167.05 *	278.52 *
Daily Min:	12.46	22.50	1.3	2.79	4.66
Daily Max:	105.84	73.87	7.4	15.64	26.11
Jan 2023 - Mar 2023	2,904.93	3,386.25	340.4	671.61	1,119.94
QTD:	2,904.93 *	3,386.25 *	340.4 *	671.61 *	1,119.94 *
YTD 2023:	2,904.93 *	3,386.25 *	340.4 *	671.61 *	1,119.94 *

ATTACHMENT 19

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:54 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2023	0.8256	7.5859	1.0650	14.2128	0.2163	2.9308	0.1084	1.4667	0.3601	4.8854
Feb 2023	0.9164	7.5652	1.0643	14.3537	0.2142	2.9600	0.1074	1.4819	0.3569	4.9340
Mar 2023	0.9505	8.1089	1.0109	14.8234	0.1947	3.0447	0.0971	1.5240	0.3242	5.0748
Sum/Avg	8.1089		14.8234		3.0447		1.5240		5.0748	
Limit Value										

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2023	8.02	40.92	4.47	8.89	14.83
01/02/2023	70.30	107.48	10.90	21.70	36.20
01/03/2023	43.16	158.77	17.15	34.27	57.16
01/04/2023	38.26	76.13	8.09	16.23	27.01
01/05/2023	70.05	62.66	5.86	11.58	19.33
01/06/2023	72.64	70.54	6.51	12.99	21.60
01/07/2023	11.01	41.31	4.50	8.90	14.85
01/08/2023	80.03	72.15	6.89	13.75	22.95
01/09/2023	97.02	81.86	7.88	15.71	26.15
01/10/2023	87.97	77.46	7.47	14.85	24.78
01/11/2023	80.37	71.25	6.96	13.78	22.99
01/12/2023	87.61	71.86	6.88	13.71	22.82
01/13/2023	10.90	41.32	4.55	8.91	14.91
01/14/2023	75.93	69.03	6.51	12.98	21.64
01/15/2023	91.63	75.97	7.42	14.68	24.52
01/16/2023	88.48	78.04	7.60	15.11	25.24
01/17/2023	81.23	76.97	7.38	14.75	24.53
01/18/2023	49.14	78.98	8.55	16.98	28.35
01/19/2023	21.19	46.72	5.30	10.47	17.49
01/20/2023	40.39	62.03	6.78	13.41	22.37
01/21/2023	22.86	59.46	6.41	12.76	21.27
01/22/2023	22.45	50.42	5.46	10.98	18.25
01/23/2023	75.82	95.38	9.25	18.54	30.88
01/24/2023	51.26	82.90	8.97	17.89	29.81
01/25/2023	13.09	41.63	4.56	8.99	15.02
01/26/2023	12.89	41.93	4.56	8.97	14.97
01/27/2023	90.68	65.49	6.08	12.15	20.23
01/28/2023	9.30	37.73	4.14	8.41	13.96
01/29/2023	92.90	62.63	5.49	11.15	18.46
01/30/2023	25.25	66.19	7.20	14.42	24.05
01/31/2023	29.56	64.58	7.04	14.11	23.50
Monthly Avg/Sum*:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
Daily Min:	8.02	37.73	4.14	8.41	13.96
Daily Max:	97.02	158.77	17.15	34.27	57.16
Jan 2023 - Jan 2023	1,651.39	2,129.79	216.81	432.02	720.12
QTD:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *
YTD 2023:	1,651.39 *	2,129.79 *	216.81 *	432.02 *	720.12 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2023	19.34	50.20	5.47	11.07	18.41
02/02/2023	8.96	37.94	4.18	8.37	13.99
02/03/2023	53.12	85.39	8.16	16.36	27.29
02/04/2023	108.11	77.99	7.53	14.98	24.95
02/05/2023	87.96	64.19	5.88	11.66	19.40
02/06/2023	84.25	78.56	7.67	15.20	25.38
02/07/2023	74.29	84.12	8.26	16.41	27.37
02/08/2023	102.79	114.57	11.51	22.94	38.30
02/09/2023	110.14	113.63	11.41	22.87	38.08
02/10/2023	71.93	81.12	7.82	15.48	25.86
02/11/2023	108.40	113.45	11.78	23.52	39.21
02/12/2023	106.28	114.76	11.68	23.35	38.89
02/13/2023	35.31	43.33	4.73	9.32	15.55
02/14/2023	68.07	90.12	8.73	17.38	28.96
02/15/2023	139.40	125.21	12.48	24.83	41.34
02/16/2023	113.23	113.19	11.51	23.10	38.43
02/17/2023	51.56	57.29	6.20	12.35	20.58
02/18/2023	14.71	41.46	4.56	8.89	14.89
02/19/2023	16.33	41.56	4.53	8.95	14.93
02/20/2023	93.55	78.91	7.60	15.18	25.29
02/21/2023	10.53	37.94	4.21	8.38	13.95
02/22/2023	74.47	82.53	7.57	15.25	25.37
02/23/2023	63.79	104.53	11.25	22.55	37.54
02/24/2023	33.93	63.80	6.90	13.85	23.09
02/25/2023	11.76	44.64	4.97	9.78	16.39
02/26/2023	8.81	37.99	4.12	8.40	13.93
02/27/2023	78.18	72.19	6.64	13.38	22.27
02/28/2023	82.98	77.32	7.24	14.49	24.11
Monthly Avg/Sum*:	1,832.18 *	2,127.93 *	214.59 *	428.29 *	713.75 *
Daily Min:	8.81	37.94	4.12	8.37	13.93
Daily Max:	139.40	125.21	12.48	24.83	41.34
Jan 2023 - Feb 2023	3,483.57	4,257.72	431.40	860.31	1,433.87
QTD:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *
YTD 2023:	3,483.57 *	4,257.72 *	431.40 *	860.31 *	1,433.87 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2023 08:47 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2023	51.98	74.11	8.06	16.05	26.78
03/02/2023	9.67	39.23	4.23	8.55	14.17
03/03/2023	85.29	81.61	7.53	15.10	25.14
03/04/2023	75.09	72.57	6.69	13.45	22.36
03/05/2023	75.04	85.77	8.07	16.09	26.83
03/06/2023	126.20	101.89	9.55	19.18	31.92
03/07/2023	116.20	108.24	10.82	21.73	36.18
03/08/2023	89.84	114.83	11.61	23.23	38.72
03/09/2023	76.00	143.12	15.31	30.58	50.99
03/10/2023	95.18	68.88	6.07	12.24	20.39
03/11/2023	56.34	76.68	7.11	14.40	23.97
03/12/2023	72.36	115.27	11.61	23.25	38.76
03/13/2023	59.09	69.55	7.01	14.14	23.54
03/14/2023	87.90	112.41	11.25	22.52	37.54
03/15/2023	68.63	71.50	6.18	12.49	20.80
03/16/2023	58.11	51.83	4.30	8.72	14.48
03/17/2023	184.98	110.06	9.98	19.98	33.29
03/18/2023	89.16	76.17	6.91	13.89	23.14
03/19/2023	69.83	87.09	8.17	16.41	27.35
03/20/2023	100.82	74.36	5.92	11.91	19.84
03/21/2023	50.51	34.49	2.45	4.94	8.23
03/22/2023	82.62	85.32	8.05	16.02	26.77
03/23/2023	82.43	80.88	7.78	15.50	25.79
03/24/2023	12.46	43.27	4.80	9.57	15.84
03/25/2023	25.39	43.01	4.63	9.10	15.18
03/26/2023	0.00	0.00	0.00	0.00	0.00
03/27/2023	0.00	0.00	0.00	0.00	0.00
03/28/2023	0.00	0.00	0.00	0.00	0.00
03/29/2023	0.00	0.00	0.00	0.00	0.00
03/30/2023	0.00	0.00	0.00	0.00	0.00
03/31/2023	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	1,901.12 *	2,022.14 *	194.09 *	389.04 *	648.00 *
Daily Min:	9.67	34.49	2.45	4.94	8.23
Daily Max:	184.98	143.12	15.31	30.58	50.99
Jan 2023 - Mar 2023	5,384.69	6,279.86	625.49	1,249.35	2,081.87
QTD:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *
YTD 2023:	5,384.69 *	6,279.86 *	625.49 *	1,249.35 *	2,081.87 *

Replace the dates with the ones you need

1/1/2023 0:00

3/31/2023 0:00

1D

TOWER AVG.

519-AIT-9504-1

2550

1/1/23 0:00	2208.8
1/2/23 0:00	2098.7
1/3/23 0:00	2286.7
1/4/23 0:00	2343.4
1/5/23 0:00	2509.3
1/6/23 0:00	2778.9
1/7/23 0:00	2424.9
1/8/23 0:00	2250.6
1/9/23 0:00	2464.2
1/10/23 0:00	2426.7
1/11/23 0:00	2116.9
1/12/23 0:00	2330.8
1/13/23 0:00	2111.1
1/14/23 0:00	2141.6
1/15/23 0:00	2373.9
1/16/23 0:00	2163.5
1/17/23 0:00	1803.0
1/18/23 0:00	1950.4
1/19/23 0:00	1792.5
1/20/23 0:00	2069.9
1/21/23 0:00	2109.8
1/22/23 0:00	2251.4
1/23/23 0:00	2127.9
1/24/23 0:00	2332.2
1/25/23 0:00	2494.2
1/26/23 0:00	2431.7
1/27/23 0:00	2180.6
1/28/23 0:00	2338.0
1/29/23 0:00	2155.9
1/30/23 0:00	2129.1
1/31/23 0:00	1981.1
2/1/23 0:00	2149.6
2/2/23 0:00	2019.9
2/3/23 0:00	2146.3
2/4/23 0:00	2143.9
2/5/23 0:00	2544.4
2/6/23 0:00	2595.8
2/7/23 0:00	2707.4
2/8/23 0:00	2734.8
2/9/23 0:00	2545.8
2/10/23 0:00	2857.4
2/11/23 0:00	2695.9
2/12/23 0:00	2875.8
2/13/23 0:00	3484.9
2/14/23 0:00	2704.1
2/15/23 0:00	3097.5
2/16/23 0:00	2899.0
2/17/23 0:00	2952.5
2/18/23 0:00	3167.5

2/19/23 0:00	2940.6
2/20/23 0:00	3256.0
2/21/23 0:00	3272.1
2/22/23 0:00	2471.5
2/23/23 0:00	2243.5
2/24/23 0:00	2473.3
2/25/23 0:00	2215.3
2/26/23 0:00	2647.6
2/27/23 0:00	2539.3
2/28/23 0:00	2739.4
3/1/23 0:00	2332.8
3/2/23 0:00	3127.6
3/3/23 0:00	2686.3
3/4/23 0:00	2749.2
3/5/23 0:00	2720.1
3/6/23 0:00	2728.0
3/7/23 0:00	2805.1
3/8/23 0:00	2991.1
3/9/23 0:00	2983.1
3/10/23 0:00	3169.4
3/11/23 0:00	3099.9
3/12/23 0:00	2660.7
3/13/23 0:00	3059.0
3/14/23 0:00	3007.6
3/15/23 0:00	3177.8
3/16/23 0:00	3297.6
3/17/23 0:00	3305.3
3/18/23 0:00	3223.3
3/19/23 0:00	3008.1
3/20/23 0:00	3150.8
3/21/23 0:00	2546.3
3/22/23 0:00	3251.4
3/23/23 0:00	2745.8
3/24/23 0:00	2805.1
3/25/23 0:00	2948.5
3/26/23 0:00	2490.2
3/27/23 0:00	1749.3
3/28/23 0:00	1909.8
3/29/23 0:00	1797.1
3/30/23 0:00	1761.3
3/31/23 0:00	1884.6

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2550	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.001632	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	5.27

90	Days in quarter

PM-10 pounds this quarter	474	1Q23

fill only these

ATTACHMENT 20

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification: The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis is reported with the 1Q23 QAQR.

INTERIM RESULTS - SAMPLE NOT AUTHORIZED

 0000667863
 ROSEVILLE ENERGY PARK
 ROSEVILLE ENERGY PARK
 5120 PHILLIP ROAD
 ROSEVILLE CA
 US 95747

 Project: W-20230124-004
 Date Authorized: Not Authorized
 Submitter: Brad Westley R
 Submitter ID: A801500
 RD Program/LWR: 351171 005118

SAMPLE INFORMATION

		System ID:	COOLING
		Sample Number:	971410
		Sample Date:	08-Nov-2023
		Sample Name:	REP Cooling Tower
		Sample Point:	REP Cooling Tower
Analyte	Units		
Alkalinity, Hydroxide (as CaCO ₃)	mg/L	< 0.1	
Alkalinity, P as CaCO ₃	mg/L	< 0.1	
Alkalinity, Total (as CaCO ₃)	mg/L	36.9	
Aluminum, Total (as Al)	mg/L	0.9	
Calcium, Total (as CaCO ₃)	mg/L	191.6	
Chloride (as Cl)	mg/L	284.2	
Conductivity	µS/cm	1967.0	
Copper, Total (as Cu)	mg/L	< 0.05	
Hardness - Calcium, Soluble (as CaCO ₃)	mg/L	185.1	
Hardness - Magnesium, Soluble (as CaCO ₃)	mg/L	60.6	
Hardness - Total, Soluble (as CaCO ₃)	mg/L	245.7	
Hardness, Total (Acidified as CaCO ₃)	mg/L	257.4	
Iron, Total (as Fe)	mg/L	< 0.05	
Magnesium, Total (as CaCO ₃)	mg/L	65.8	
Manganese, Total (as Mn)	mg/L	< 0.01	
Metals Poured		Yes	
Organic Phosphorus, Soluble (as PO ₄)	mg/L	0.3	
Orthophosphate, Soluble (as PO ₄)	mg/L	2.6	
pH		6.5	
Polyphosphate, Soluble (as PO ₄)	mg/L	0.2	
Silicon, Soluble (as SiO ₂)	mg/L	58.4	
Sodium, Soluble (as Na)	mg/L	287.2	
Sulfate (as SO ₄)	mg/L	315.4	
Total Inorganic Phosphorus, Sol (as PO ₄)	mg/L	2.8	
Total Phosphorus, Soluble (as PO ₄)	mg/L	3.1	
Zinc, Total (as Zn)	mg/L	0.2	

INTERIM RESULTS - SAMPLE NOT AUTHORIZED

0000667863
ROSEVILLE ENERGY PARK
ROSEVILLE ENERGY PARK
5120 PHILLIP ROAD
ROSEVILLE CA
US 95747

Project: W-20230124-004
Date Authorized: Not Authorized
Submitter: Brad Westley R
Submitter ID: A801500
RD Program/LWR: 351171 005118

SAMPLE INFORMATION

Click link to visit the **CAL-NA-IWT-Laboratories Salesforce Chatter**

Analytical Interpretation Guide

http://nadewillims01/awt_cal/analytinterp/analytinterp.htm

Final Reports are archived in the **F.A.S.T. System**

<http://nadewillims01/fast/fasthome.asp>

Data in Excel format can be queried from the **Solenis Data Search Engine:**

<http://nadewillims01/ahwt-query/query.php>

ATTACHMENT 21

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 22

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

1/1/2023 0:00

3/31/2023 0:00

1D

TOWER AVG.

519-AIT-9504-1

2550

1/1/23 0:00	2208.8
1/2/23 0:00	2098.7
1/3/23 0:00	2286.7
1/4/23 0:00	2343.4
1/5/23 0:00	2509.3
1/6/23 0:00	2778.9
1/7/23 0:00	2424.9
1/8/23 0:00	2250.6
1/9/23 0:00	2464.2
1/10/23 0:00	2426.7
1/11/23 0:00	2116.9
1/12/23 0:00	2330.8
1/13/23 0:00	2111.1
1/14/23 0:00	2141.6
1/15/23 0:00	2373.9
1/16/23 0:00	2163.5
1/17/23 0:00	1803.0
1/18/23 0:00	1950.4
1/19/23 0:00	1792.5
1/20/23 0:00	2069.9
1/21/23 0:00	2109.8
1/22/23 0:00	2251.4
1/23/23 0:00	2127.9
1/24/23 0:00	2332.2
1/25/23 0:00	2494.2
1/26/23 0:00	2431.7
1/27/23 0:00	2180.6
1/28/23 0:00	2338.0
1/29/23 0:00	2155.9
1/30/23 0:00	2129.1
1/31/23 0:00	1981.1
2/1/23 0:00	2149.6
2/2/23 0:00	2019.9
2/3/23 0:00	2146.3
2/4/23 0:00	2143.9
2/5/23 0:00	2544.4
2/6/23 0:00	2595.8
2/7/23 0:00	2707.4
2/8/23 0:00	2734.8
2/9/23 0:00	2545.8
2/10/23 0:00	2857.4
2/11/23 0:00	2695.9
2/12/23 0:00	2875.8
2/13/23 0:00	3484.9
2/14/23 0:00	2704.1
2/15/23 0:00	3097.5
2/16/23 0:00	2899.0
2/17/23 0:00	2952.5
2/18/23 0:00	3167.5

2/19/23 0:00	2940.6
2/20/23 0:00	3256.0
2/21/23 0:00	3272.1
2/22/23 0:00	2471.5
2/23/23 0:00	2243.5
2/24/23 0:00	2473.3
2/25/23 0:00	2215.3
2/26/23 0:00	2647.6
2/27/23 0:00	2539.3
2/28/23 0:00	2739.4
3/1/23 0:00	2332.8
3/2/23 0:00	3127.6
3/3/23 0:00	2686.3
3/4/23 0:00	2749.2
3/5/23 0:00	2720.1
3/6/23 0:00	2728.0
3/7/23 0:00	2805.1
3/8/23 0:00	2991.1
3/9/23 0:00	2983.1
3/10/23 0:00	3169.4
3/11/23 0:00	3099.9
3/12/23 0:00	2660.7
3/13/23 0:00	3059.0
3/14/23 0:00	3007.6
3/15/23 0:00	3177.8
3/16/23 0:00	3297.6
3/17/23 0:00	3305.3
3/18/23 0:00	3223.3
3/19/23 0:00	3008.1
3/20/23 0:00	3150.8
3/21/23 0:00	2546.3
3/22/23 0:00	3251.4
3/23/23 0:00	2745.8
3/24/23 0:00	2805.1
3/25/23 0:00	2948.5
3/26/23 0:00	2490.2
3/27/23 0:00	1749.3
3/28/23 0:00	1909.8
3/29/23 0:00	1797.1
3/30/23 0:00	1761.3
3/31/23 0:00	1884.6

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2550	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.001632	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	5.27

90	Days in quarter

PM-10 pounds this quarter	474	1Q23

fill only these

ATTACHMENT 23

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $PM-10 = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow down water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

1/1/2023 0:00

3/31/2023 0:00

1D

TOWER AVG.

519-AIT-9504-1

2550

1/1/23 0:00	2208.8
1/2/23 0:00	2098.7
1/3/23 0:00	2286.7
1/4/23 0:00	2343.4
1/5/23 0:00	2509.3
1/6/23 0:00	2778.9
1/7/23 0:00	2424.9
1/8/23 0:00	2250.6
1/9/23 0:00	2464.2
1/10/23 0:00	2426.7
1/11/23 0:00	2116.9
1/12/23 0:00	2330.8
1/13/23 0:00	2111.1
1/14/23 0:00	2141.6
1/15/23 0:00	2373.9
1/16/23 0:00	2163.5
1/17/23 0:00	1803.0
1/18/23 0:00	1950.4
1/19/23 0:00	1792.5
1/20/23 0:00	2069.9
1/21/23 0:00	2109.8
1/22/23 0:00	2251.4
1/23/23 0:00	2127.9
1/24/23 0:00	2332.2
1/25/23 0:00	2494.2
1/26/23 0:00	2431.7
1/27/23 0:00	2180.6
1/28/23 0:00	2338.0
1/29/23 0:00	2155.9
1/30/23 0:00	2129.1
1/31/23 0:00	1981.1
2/1/23 0:00	2149.6
2/2/23 0:00	2019.9
2/3/23 0:00	2146.3
2/4/23 0:00	2143.9
2/5/23 0:00	2544.4
2/6/23 0:00	2595.8
2/7/23 0:00	2707.4
2/8/23 0:00	2734.8
2/9/23 0:00	2545.8
2/10/23 0:00	2857.4
2/11/23 0:00	2695.9
2/12/23 0:00	2875.8
2/13/23 0:00	3484.9
2/14/23 0:00	2704.1
2/15/23 0:00	3097.5
2/16/23 0:00	2899.0
2/17/23 0:00	2952.5
2/18/23 0:00	3167.5

2/19/23 0:00	2940.6
2/20/23 0:00	3256.0
2/21/23 0:00	3272.1
2/22/23 0:00	2471.5
2/23/23 0:00	2243.5
2/24/23 0:00	2473.3
2/25/23 0:00	2215.3
2/26/23 0:00	2647.6
2/27/23 0:00	2539.3
2/28/23 0:00	2739.4
3/1/23 0:00	2332.8
3/2/23 0:00	3127.6
3/3/23 0:00	2686.3
3/4/23 0:00	2749.2
3/5/23 0:00	2720.1
3/6/23 0:00	2728.0
3/7/23 0:00	2805.1
3/8/23 0:00	2991.1
3/9/23 0:00	2983.1
3/10/23 0:00	3169.4
3/11/23 0:00	3099.9
3/12/23 0:00	2660.7
3/13/23 0:00	3059.0
3/14/23 0:00	3007.6
3/15/23 0:00	3177.8
3/16/23 0:00	3297.6
3/17/23 0:00	3305.3
3/18/23 0:00	3223.3
3/19/23 0:00	3008.1
3/20/23 0:00	3150.8
3/21/23 0:00	2546.3
3/22/23 0:00	3251.4
3/23/23 0:00	2745.8
3/24/23 0:00	2805.1
3/25/23 0:00	2948.5
3/26/23 0:00	2490.2
3/27/23 0:00	1749.3
3/28/23 0:00	1909.8
3/29/23 0:00	1797.1
3/30/23 0:00	1761.3
3/31/23 0:00	1884.6

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2550	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.001632	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	5.27

90	Days in quarter

PM-10 pounds this quarter	474	1Q23

fill only these

ATTACHMENT 24

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	Bi-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	Bi-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	Bi-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	XAB	1449	1519	Bi-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	070
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730

021

XII

2023

02:01

2023

02:01

2023

130

0

1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30
1-22-23	XAB	1453	1523	BIWEEKLY TEST RUN	131	60
2-3-23	PC	1110	1144	BIWEEKLY TEST RUN	132	94
2-19-23	XAB	1459	1529	BIWEEKLY TEST RUN	132	124
3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154
3-18-23	XAB	1114	1144	BIWEEKLY TEST RUN	133	184

ATTACHMENT 25

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TIME START	Reason	TIME STOP	Total Hrs	YTD Hrs	initials
12-17-22	1406	Weekly Test Run	1436	247.5	26.9	mp
12-25-22	0152	WEEKLY TEST RUN	0222	248.0	26.9	JS
12-31-22	1614	Weekly Test Run	1644	248.5	27.4	JS

2023 Starting Hours 248.5

1-8-23	14:00	Weekly Test Run	14130	249	.5	
1-15-23	17:10	Weekly Test Run	1740	249.5	1.0	ZAR
1-22-23	1623	WEEKLY TEST RUN	1653	250	1.5	HAB
1-28-23	0936	Weekly Test Run	0906	250.5	2	JS
2-5-23	1110	Weekly Test Run	1140	251.0	2.5	DWN
2-12-23	1355	WEEKLY TEST RUN	1425	251.5	3.0	DE
2-19-23	1420	WEEKLY TEST RUN	1450	252.0	3.5	HAB
2-26-23	1355	WEEKLY TEST RUN	1425	252.5	4.0	HAB
3-5-23	1220	Weekly Test Run	1250	253.0	4.5	LIA
3-12-23	1113	Weekly Test Run	1148	253.5	5.0	ZAR
3-18-23	1518	WEEKLY TEST RUN	1548	254.0	5.5	HAB

ATTACHMENT 26

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
005475		JOSH GRAVES		Net 30 Days		0		02-09-23	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
02-10-23		751		29180		11			
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES			PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3. PG111 #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use. BULK DSL #2 DYED CARD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX AB 32 DSL IMPLEMENTATION FEE FEDERAL SUPERFUND TAX ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE Call ETH 916-749-1680							
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS *** SALES TAX: 3.812% 30.66; 7.750% .13									
PRODUCT	PREMIUM	UNLEADED PLUS	UNLEADED	DIESEL		SALES TAX			
GROSS									
NET						TOTAL			

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

DELIVERED BY (SIGNATURE IN FULL)

X

RECEIVED IN GOOD ORDER

X

ATTACHMENT 27

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	XAB	1449	1519	BI-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	070
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730

021

XII

2022

02:01

2023

02:01

2023

130

0

1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30
1-22-23	XAB	1453	1523	BIWEEKLY TEST RUN	131	60
2-3-23	PC	1110	1144	BIWEEKLY TEST RUN	132	94
2-19-23	XAB	1459	1529	BIWEEKLY TEST RUN	132	124
3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154
3-18-23	XAB	1114	1144	BIWEEKLY TEST RUN	133	184



01 Sacramento 916-371-2570 10 Rio Vista Shell 707-374-5620
02 Clarksburg 916-744-1012 11 Marysville 530-743-4647
03 Dixon 707-678-2061 14 Lincoln 916-645-2179
04 Fairfield 707-425-5780 24 San Jose 408-321-8242
06 Woodland 530-661-1200 27 Stockton 209-465-6255
08 Williams 530-473-2811
09 Isleton 916-777-5545

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
005475		JOSH GRAVES		Net 30 Days		0		02-09-23	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
02-10-23		751		29180		11			
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES			PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3. PG111 #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use. BULK DSL #2 DYED CARD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX AB 32 DSL IMPLEMENTATION FEE FEDERAL SUPERFUND TAX ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE Call ETH 916-749-1680							
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS *** SALES TAX: 3.812% 30.66; 7.750% .13									
PRODUCT	PREMIUM	UNLEADED PLUS	UNLEADED	DIESEL		SALES TAX			
GROSS									
NET						TOTAL			

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

DELIVERED BY (SIGNATURE IN FULL)

X

RECEIVED IN GOOD ORDER

X

ATTACHMENT 28

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 29

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

ATTACHMENT 30

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	Bi-weekly Test Run	125	395
7/20/22	DWN	1455	1525	Bi-weekly Test Run	125	425
8/7/22	DE	1212	1242	Bi-weekly Test Run	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly Test Run	127	535
9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	Bi-weekly Test Run	128	580
10-15-22	JN	1314	1344	Bi-weekly Test Run	128	010
10/30/2022	XAB	1449	1519	Bi-weekly Test Run	129	640
11-12-22	JN	1238	1308	Bi-weekly Test Run	129	070
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly Test Run	130	730

021

XII

2023

02:01

02:01

02:01

2023

130

0

1-8-23	LH	13:13	13:43	Bi-weekly Test Run	131	30
1-22-23	XAB	1453	1523	BIWEEKLY TEST RUN	131	60
2-3-23	PC	1110	1144	BIWEEKLY TEST RUN	132	94
2-19-23	XAB	1459	1529	BIWEEKLY TEST RUN	132	124
3-5-23	LIA	13:00	13:30	Bi-weekly Test Run	133	154
3-18-23	XAB	1114	1144	BIWEEKLY TEST RUN	133	184

ATTACHMENT 31

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly test Run	127	535
9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580
10-15-22	JN	1314	1344	Bi weekly test Run	128	010
10/30/2022	XAB	1449	1519	BI-WEEKLY TEST RUN	129	640
11-12-22	JN	1238	1308	Bi weekly test Run	129	070
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly test Run	130	730

021

XII

2022

02:01

2023

02:01

2023

130

0

1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30
1-22-23	XAB	1453	1523	BIWEEKLY TEST RUN	131	60
2-3-23	PC	1110	1144	BIWEEKLY TEST RUN	132	94
2-19-23	XAB	1459	1529	BIWEEKLY TEST RUN	132	124
3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154
3-18-23	XAB	1114	1144	BIWEEKLY TEST RUN	133	184

ATTACHMENT 32

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
005475		JOSH GRAVES		Net 30 Days		0		02-09-23	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
02-10-23		751		29180		11			
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES			PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3. PG111 #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use. BULK DSL #2 DYED CARD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX AB 32 DSL IMPLEMENTATION FEE FEDERAL SUPERFUND TAX ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE Call ETH 916-749-1680							
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS *** SALES TAX: 3.812% 30.66; 7.750% .13									
PRODUCT	PREMIUM	UNLEADED PLUS	UNLEADED	DIESEL		SALES TAX			
GROSS									
NET						TOTAL			

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

DELIVERED BY (SIGNATURE IN FULL)

X

RECEIVED IN GOOD ORDER

X

ATTACHMENT 33

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
7/10/22	DE	1120	1150	Bi-weekly Test Run	125	395
7/20/22	DWN	1455	1525	Bi-weekly Test Run	125	425
8/7/22	DE	1212	1242	Bi-weekly Test Run	126	455
8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505
9-17-22	JN	1410	1440	Bi-weekly Test Run	127	535
9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550
10/2/22	DE	1230	1300	Bi-weekly Test Run	128	580
10-15-22	JN	1314	1344	Bi-weekly Test Run	128	010
10/30/2022	XAB	1449	1519	Bi-weekly Test Run	129	640
11-12-22	JN	1238	1308	Bi-weekly Test Run	129	070
11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700
12-10-22	JN	1200	1230	Bi-weekly Test Run	130	730

021

XII

2022

02:01

2023

02:01

2023

130

0

1-8-23	LH	13:13	13:43	Bi-weekly Test Run	131	30
1-22-23	XAB	1453	1523	BIWEEKLY TEST RUN	131	60
2-3-23	PC	1110	1144	BIWEEKLY TEST RUN	132	94
2-19-23	XAB	1459	1529	BIWEEKLY TEST RUN	132	124
3-5-23	LIA	13:00	13:30	Bi-weekly Test Run	133	154
3-18-23	XAB	1114	1144	BIWEEKLY TEST RUN	133	184



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO: ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
005475		JOSH GRAVES		Net 30 Days		0		02-09-23	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
02-10-23		751		29180		11			
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES			PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3. PG111 #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use. BULK DSL #2 DYED CARD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX AB 32 DSL IMPLEMENTATION FEE FEDERAL SUPERFUND TAX ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE Call ETH 916-749-1680							
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS *** SALES TAX: 3.812% 30.66; 7.750% .13									
PRODUCT	PREMIUM	UNLEADED PLUS	UNLEADED	DIESEL		SALES TAX			
GROSS						TOTAL			
NET									

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

DELIVERED BY (SIGNATURE IN FULL)

X

RECEIVED IN GOOD ORDER

X

ATTACHMENT 34

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 35

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 1Q23 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.