

**DOCKETED**

<b>Docket Number:</b>	01-AFC-25C
<b>Project Title:</b>	Malburg Generating Station-Compliance
<b>TN #:</b>	249914
<b>Document Title:</b>	Malburg Generating Station Quarterly Compliance Report Q1 2023
<b>Description:</b>	N/A
<b>Filer:</b>	Elyse Engel
<b>Organization:</b>	Jacobs Engineering Group Inc.
<b>Submitter Role:</b>	Applicant
<b>Submission Date:</b>	4/28/2023 4:19:07 PM
<b>Docketed Date:</b>	4/28/2023



4305 Santa Fe Avenue, Vernon, California 90058  
Telephone (323) 583-8811

April 28, 2023

Dr. Anwar Ali  
Compliance Project Manager  
Siting, Transmission and Environmental Protection Division  
Compliance Monitoring and Enforcement Office  
California Energy Commission  
715 P Street  
Sacramento, CA 95814  
[anwar.ali@energy.ca.gov](mailto:anwar.ali@energy.ca.gov)

Subject: 2023 Q1 Compliance Report  
January 1, 2023 through March 31, 2023  
Malburg Generating Station (01-AFC-25C)

Dr. Ali,

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of January 1, 2023 through March 31, 2023. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at [MRichards@cityofvernon.org](mailto:MRichards@cityofvernon.org) or (323)-583-8811 x378.

Sincerely,

Rich Olsen  
Assistant General Manager of Generation & Operations  
City of Vernon, Public Utilities Department

Enclosure: MGS 2023 Q1 Compliance Report

*Exclusively Industrial*

# Malburg Generating Station Quarterly Compliance Report (First Quarter 2023)

*Submitted to*  
California Energy Commission

*Submitted by*  
City of Vernon, Public Utilities Department

April 28, 2023

Document no: 230426145101\_6a0a1e47  
Revision no: 0



## Contents

Acronyms and Abbreviations.....	v
1. Introduction .....	1
1.1 Project Location and Description.....	1
1.2 Organization of the Quarterly Compliance Report .....	1
2. Required Quarterly Compliance Report Documentation.....	1

## Appendices

A	MGS Emission Calculations
B	Cooling Tower Blowdown Reports
C	Operation Logs
D	Diesel Fuel Oil Purchase Records
E	Excess Emission Reports

## Table

2-1	Required Quarterly Compliance Report Documentation.....	1
-----	---	---

## Acronyms and Abbreviations

CEC	California Energy Commission's
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COC	Conditions of Certification
CTGs	combustion turbine generators
DAHS	data acquisition and handling system
gr/scf	grain per standard cubic foot
HRSGs	heat recovery steam generators
lb/day	pounds per day
MGS	Malburg Generating Station
NH <sub>3</sub>	ammonia
NO <sub>x</sub>	nitrogen oxides
PM <sub>10</sub>	10 microns
PM <sub>2.5</sub>	2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SO <sub>x</sub>	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

## 1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

### 1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

### 1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

## 2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

**Table 2-1. Required Quarterly Compliance Report Documentation**

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the first quarter of 2023 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM <sub>10</sub> ) emissions from cooling tower operation during the first quarter of 2023 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the first quarter of 2023 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the first quarter of 2023, including the duration and date of occurrence, are provided in Appendix C, Table 1.
AQ-C11	All ammonia (NH <sub>3</sub> ), nitrogen oxides (NO <sub>x</sub> ), sulfur oxides (SO <sub>x</sub> ), carbon monoxide (CO), PM <sub>10</sub> , and volatile organic compound (VOC) emissions from MGS operation during the first quarter of 2023 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on April 11, 2022. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.

## Malburg Generating Station Quarterly Compliance Report (First Quarter 2023)

Condition of Certification	Response
AQ-5	Monthly emissions of CO, PM <sub>10</sub> , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns (PM <sub>2.5</sub> ), VOC, and SO <sub>x</sub> from CTG and duct burner operation during the first quarter of 2023 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NO <sub>x</sub> excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO <sub>x</sub> emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual or quarterly source testing. The most recent NH <sub>3</sub> compliance source test, performed on November 1, 2022 with results submitted to the CEC on November 16, 2022, indicated compliance with the emission limits for both CTGs (0.6 ppm for CTG 1 and 0.5 ppm for CTG 2). NH <sub>3</sub> emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH <sub>3</sub> concentration limit of 5 ppm.
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source test, performed in July 2022, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.67 lb/hr and 0.0003 gr/scf for CTG 1 and 1.83 lb/hr and 0.0007 gr/scf for CTG 2).
AQ-14	See the response for COC AQ-2.
AQ-15	Quarterly hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the first quarter 2023 hours for maintenance and testing did not exceed 50 hours and the total operational hours did not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair did not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COCs AQ-5 and AQ-6.

# Appendix A

## MGS Emission Calculations





Malburg Generating Station  
 Quarterly Compliance Report  
 Appendix A, Table 1

Reporting Period: **Quarter 1 2023**

Table 1. Quarterly Emissions - January 1, 2023 through March 31, 2023

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub>
CTG 1 & Duct Burner	3,361	1,277	704	126	2,749	4,187
CTG 2 & Duct Burner	2,302	776	490	88	1,912	2,902
Cooling Tower	--	--	--	--	127	--
Diesel Firewater Pump	34.1	1.0	0.2	0.0	0.2	0.1
<b>Total</b>	<b>5,697</b>	<b>2,055</b>	<b>1,194</b>	<b>214</b>	<b>4,789</b>	<b>7,090</b>

Malburg Generating Station  
 Quarterly Compliance Report  
 Appendix A, Table 2

Reporting Period: **Quarter 1 2023**

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results <sup>1</sup>

Sampling Period		
Start Date	End Date	TDS (ppm)
1/1/2023	1/7/2023	5,090
1/8/2023	1/14/2023	4,290
1/15/2023	1/21/2023	4,300
1/22/2023	1/28/2023	3,960
1/29/2023	2/4/2023	4,060
2/5/2023	2/11/2023	4,420
2/12/2023	2/18/2023	4,460
2/19/2023	2/25/2023	4,400
2/26/2023	3/4/2023	4,400
3/5/2023	3/11/2023	4,860
3/12/2023	3/18/2023	4,660
3/19/2023	3/25/2023	4,400
3/26/2023	4/1/2023	3,200

<sup>1</sup> Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 3**

**Reporting Period:** January 2023

**Cooling Tower Total Dissolved Solids (TDS) Sampling Results**

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
1/4/2023	1/1/2023	1/7/2023	5,090
1/10/2023	1/8/2023	1/14/2023	4,290
1/17/2023	1/15/2023	1/21/2023	4,300
1/24/2023	1/22/2023	1/28/2023	3,960
1/30/2023	1/29/2023	2/4/2023	4,060

**Methodology (per Condition of Certification [COC] AQ-C7)**

$PM_{10}$  Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>1</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>2</sup>	0.0005
Correction Factor (unitless) <sup>3</sup>	0.2

<sup>1</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>2</sup> Per COC AQ-C4.

<sup>3</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

### Cooling Tower Daily PM<sub>10</sub> Emissions

Date	Circulation Rate (gal/day) <sup>1</sup>	TDS (ppm)	PM <sub>10</sub> Emissions (lb/day)	Above 6.2 lb/day PM <sub>10</sub> Limit? <sup>2</sup>
1/1/2023	38,880,000	5,090	1.65	No
1/2/2023	38,880,000	5,090	1.65	No
1/3/2023	38,880,000	5,090	1.65	No
1/4/2023	38,880,000	5,090	1.65	No
1/5/2023	38,880,000	5,090	1.65	No
1/6/2023	38,880,000	5,090	1.65	No
1/7/2023	38,880,000	5,090	1.65	No
1/8/2023	38,880,000	4,290	1.39	No
1/9/2023	38,880,000	4,290	1.39	No
1/10/2023	38,880,000	4,290	1.39	No
1/11/2023	38,880,000	4,290	1.39	No
1/12/2023	38,880,000	4,290	1.39	No
1/13/2023	38,880,000	4,290	1.39	No
1/14/2023	38,880,000	4,290	1.39	No
1/15/2023	38,880,000	4,300	1.39	No
1/16/2023	38,880,000	4,300	1.39	No
1/17/2023	38,880,000	4,300	1.39	No
1/18/2023	38,880,000	4,300	1.39	No
1/19/2023	38,880,000	4,300	1.39	No
1/20/2023	38,880,000	4,300	1.39	No
1/21/2023	38,880,000	4,300	1.39	No
1/22/2023	38,880,000	3,960	1.28	No
1/23/2023	38,880,000	3,960	1.28	No
1/24/2023	38,880,000	3,960	1.28	No
1/25/2023	38,880,000	3,960	1.28	No
1/26/2023	38,880,000	3,960	1.28	No
1/27/2023	38,880,000	3,960	1.28	No
1/28/2023	38,880,000	3,960	1.28	No
1/29/2023	38,880,000	4,060	1.32	No
1/30/2023	38,880,000	4,060	1.32	No
1/31/2023	38,880,000	4,060	1.32	No

<sup>1</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>2</sup> Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 4**

Reporting Period: **February 2023**

**Cooling Tower Total Dissolved Solids (TDS) Sampling Results**

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
1/30/2023	1/29/2023	2/4/2023	4,060
2/7/2023	2/5/2023	2/11/2023	4,420
2/15/2023	2/12/2023	2/18/2023	4,460
2/21/2023	2/19/2023	2/25/2023	4,400
2/27/2023	2/26/2023	3/4/2023	4,400

**Methodology (per Condition of Certification [COC] AQ-C7)**

$PM_{10}$  Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000  
x Drift Factor (%) / 100 x Correction Factor

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>1</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>2</sup>	0.0005
Correction Factor (unitless) <sup>3</sup>	0.2

<sup>1</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>2</sup> Per COC AQ-C4.

<sup>3</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

**Cooling Tower Daily PM<sub>10</sub> Emissions**

Date	Circulation Rate (gal/day) <sup>1</sup>	TDS (ppm)	PM <sub>10</sub> Emissions (lb/day)	Above 6.2 lb/day PM <sub>10</sub> Limit? <sup>2</sup>
2/1/2023	38,880,000	4,060	1.32	No
2/2/2023	38,880,000	4,060	1.32	No
2/3/2023	38,880,000	4,060	1.32	No
2/4/2023	38,880,000	4,060	1.32	No
2/5/2023	38,880,000	4,420	1.43	No
2/6/2023	38,880,000	4,420	1.43	No
2/7/2023	38,880,000	4,420	1.43	No
2/8/2023	38,880,000	4,420	1.43	No
2/9/2023	38,880,000	4,420	1.43	No
2/10/2023	38,880,000	4,420	1.43	No
2/11/2023	38,880,000	4,420	1.43	No
2/12/2023	38,880,000	4,460	1.45	No
2/13/2023	38,880,000	4,460	1.45	No
2/14/2023	38,880,000	4,460	1.45	No
2/15/2023	38,880,000	4,460	1.45	No
2/16/2023	38,880,000	4,460	1.45	No
2/17/2023	38,880,000	4,460	1.45	No
2/18/2023	38,880,000	4,460	1.45	No
2/19/2023	38,880,000	4,400	1.43	No
2/20/2023	38,880,000	4,400	1.43	No
2/21/2023	38,880,000	4,400	1.43	No
2/22/2023	38,880,000	4,400	1.43	No
2/23/2023	38,880,000	4,400	1.43	No
2/24/2023	38,880,000	4,400	1.43	No
2/25/2023	38,880,000	4,400	1.43	No
2/26/2023	38,880,000	4,400	1.43	No
2/27/2023	38,880,000	4,400	1.43	No
2/28/2023	38,880,000	4,400	1.43	No

<sup>1</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>2</sup> Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 5**

Reporting Period: **March 2023**

**Cooling Tower Total Dissolved Solids (TDS) Sampling Results**

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
2/27/2023	2/26/2023	3/4/2023	4,400
3/8/2023	3/5/2023	3/11/2023	4,860
3/13/2023	3/12/2023	3/18/2023	4,660
3/21/2023	3/19/2023	3/25/2023	4,400
3/27/2023	3/26/2023	4/1/2023	3,200

**Methodology (per Condition of Certification [COC] AQ-C7)**

$PM_{10}$  Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>1</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>2</sup>	0.0005
Correction Factor (unitless) <sup>3</sup>	0.2

<sup>1</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>2</sup> Per COC AQ-C4.

<sup>3</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

### Cooling Tower Daily PM<sub>10</sub> Emissions

Date	Circulation Rate (gal/day) <sup>1</sup>	TDS (ppm)	PM <sub>10</sub> Emissions (lb/day)	Above 6.2 lb/day PM <sub>10</sub> Limit? <sup>2</sup>
3/1/2023	38,880,000	4,400	1.43	No
3/2/2023	38,880,000	4,400	1.43	No
3/3/2023	38,880,000	4,400	1.43	No
3/4/2023	38,880,000	4,400	1.43	No
3/5/2023	38,880,000	4,860	1.57	No
3/6/2023	38,880,000	4,860	1.57	No
3/7/2023	38,880,000	4,860	1.57	No
3/8/2023	38,880,000	4,860	1.57	No
3/9/2023	38,880,000	4,860	1.57	No
3/10/2023	38,880,000	4,860	1.57	No
3/11/2023	38,880,000	4,860	1.57	No
3/12/2023	38,880,000	4,660	1.51	No
3/13/2023	38,880,000	4,660	1.51	No
3/14/2023	38,880,000	4,660	1.51	No
3/15/2023	38,880,000	4,660	1.51	No
3/16/2023	38,880,000	4,660	1.51	No
3/17/2023	38,880,000	4,660	1.51	No
3/18/2023	38,880,000	4,660	1.51	No
3/19/2023	38,880,000	4,400	1.43	No
3/20/2023	38,880,000	4,400	1.43	No
3/21/2023	38,880,000	4,400	1.43	No
3/22/2023	38,880,000	4,400	1.43	No
3/23/2023	38,880,000	4,400	1.43	No
3/24/2023	38,880,000	4,400	1.43	No
3/25/2023	38,880,000	4,400	1.43	No
3/26/2023	38,880,000	3,200	1.04	No
3/27/2023	38,880,000	3,200	1.04	No
3/28/2023	38,880,000	3,200	1.04	No
3/29/2023	38,880,000	3,200	1.04	No
3/30/2023	38,880,000	3,200	1.04	No
3/31/2023	38,880,000	3,200	1.04	No

<sup>1</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>2</sup> Daily emissions limit established in COC AQ-C7.



Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Tables 6, 7, 8, & 9

Reporting Period: **Quarter 1 2023**

**Table 6. Monthly Turbine-Duct Burner Fuel Flow**

Source	January		February		March	
	Fuel Flow (MMscf/month) <sup>1</sup>	Above 405 MMscf/month Limit? <sup>2</sup>	Fuel Flow (MMscf/month) <sup>1</sup>	Above 405 MMscf/month Limit? <sup>2</sup>	Fuel Flow (MMscf/month) <sup>1</sup>	Above 405 MMscf/month Limit? <sup>2</sup>
CTG 1	173.0		228		54	
CTG 1 Duct Burner	0.98		1.87		0.20	
<b>Total CTG 1 &amp; Duct Burner</b>	<b>174</b>	<b>No</b>	<b>229</b>	<b>No</b>	<b>54</b>	<b>No</b>
CTG 2	75		12		230	
CTG 2 Duct Burner	0.49		0.22		0.37	
<b>Total CTG 2 &amp; Duct Burner</b>	<b>76</b>	<b>No</b>	<b>12</b>	<b>No</b>	<b>230</b>	<b>No</b>

<sup>1</sup> Fuel flow data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' and 'ALL\_12MonthSummary\_GasUsage' RegPerfect Reports.

<sup>2</sup> Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

**Table 7. Monthly Emissions - January 2023**

Source	Monthly Emissions (lb/month) <sup>1</sup>					
	NO <sub>x</sub> <sup>2</sup>	CO	VOC	SO <sub>x</sub>	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>3</sup>
CTG 1 & Duct Burner	1,303	500	268	48	1,046	1,592
CTG 2 & Duct Burner	568	206	116	21	454	692
Monthly Emission Limits <sup>4</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>1</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>2</sup> Monthly NO<sub>x</sub> emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>3</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>4</sup> Monthly emission limits are per COC AQ-5.

**Table 8. Monthly Emissions - February 2023**

Source	Monthly Emissions (lb/month) <sup>1</sup>					
	NO <sub>x</sub> <sup>2</sup>	CO	VOC	SO <sub>x</sub>	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>3</sup>
CTG 1 & Duct Burner	1,591	529	353	63	1,379	2,104
CTG 2 & Duct Burner	117	97	19	3	73	112
Monthly Emission Limits <sup>4</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>1</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>2</sup> Monthly NO<sub>x</sub> emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>3</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>4</sup> Monthly emission limits are per COC AQ-5.

**Table 9. Monthly Emissions - March 2023**

Source	Monthly Emissions (lb/month) <sup>1</sup>					
	NOx <sup>2</sup>	CO	VOC	SOx	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>3</sup>
CTG 1 & Duct Burner	466.98	249	83	15.0	324	492
CTG 2 & Duct Burner	1,616.75	473	355	63.4	1,385	2,099
Monthly Emission Limits <sup>4</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>1</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>2</sup> Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>3</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>4</sup> Monthly emission limits are per COC AQ-5.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 10**

Reporting Period: **Quarter 1 2023**

**Methodology**

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

**Emission Factors**

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICES given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM <sub>10</sub> /PM <sub>2.5</sub>	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
NH <sub>3</sub>	0.800	Default for diesel combustion equipment without an SNCR or SCR given in the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Reporting Procedures - June 2020.

**Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions**

Month	Monthly Hours of Operation <sup>1</sup>			Fuel Usage (gal/month) <sup>2</sup>	Monthly Emissions (lb/month)					
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub>
January	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
February	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
March	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
April	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
May	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
June	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
July	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
August	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
September	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
October	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
November	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
December	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00
<b>Q1 Total</b>	<b>0.0</b>	<b>6.5</b>	<b>0.0</b>	<b>72.8</b>	<b>34.1</b>	<b>0.99</b>	<b>0.25</b>	<b>0.02</b>	<b>0.22</b>	<b>0.06</b>
<b>Q2 Total</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>
<b>Q3 Total</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>
<b>Q4 Total</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>Annual Total</b>	<b>0.0</b>	<b>6.5</b>	<b>0.0</b>	<b>72.8</b>	<b>34.1</b>	<b>1.0</b>	<b>0.2</b>	<b>0.0</b>	<b>0.2</b>	<b>0.1</b>
Annual Limit for Maintenance and Testing <sup>3</sup>			50							
Total Annual Limit <sup>3</sup>			200							
Exceeds Limits?			No							

<sup>1</sup> Monthly hours of operation calculated from Device 385/403 run timer readings.


<sup>2</sup> Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

<sup>3</sup> Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

# **Appendix B**

## **Cooling Tower Blowdown Reports**





781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

January 13, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2301019  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 04, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 01/13/23  
 Submitted: 01/04/23  
**PLS Report No.: 2301019**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2301019-01) Sampled: 01/04/23 08:35 Received: 01/04/23											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	5090		1	mg/L	5.0	SM 2540C	01/09/23	01/10/23	vc	BA31130	

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier	
<b>Batch BA31130 --</b>											
<b>Blank</b>											
Prepared: 01/09/23 Analyzed: 01/10/23											
Total Dissolved Solids	ND	5.0	mg/L								
<b>LCS</b>											
Prepared: 01/09/23 Analyzed: 01/10/23											
Total Dissolved Solids	47.0	5.0	mg/L	50.00		94.0	80-120				
<b>Duplicate</b>											
Source: 2301019-01 Prepared: 01/09/23 Analyzed: 01/10/23											
Total Dissolved Solids	4980	5.0	mg/L		5090			2.18	5		
<b>Duplicate</b>											
Source: 2301011-01 Prepared: 01/09/23 Analyzed: 01/10/23											
Total Dissolved Solids	3200	5.0	mg/L		3080			3.73	5		

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Pick Owen Parker*

Authorized Signature(s)



**CHAIN OF CUSTODY AND ANALYSIS REQUEST**

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 1-4-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2201019

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP 10.2

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] CORRECTED TEMP: 10.15

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 61

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>1-4-23</u>	<u>0835</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> <u>John Barie</u>	Date: <u>1-4-23</u>	Time: <u>0835</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 1-4-23 1015

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

January 23, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2301145  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 10, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager





781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 01/23/23  
 Submitted: 01/10/23  
**PLS Report No.: 2301145**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2301145-01) Sampled: 01/10/23 09:20 Received: 01/10/23											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4290	R1	1	mg/L	5.0	- SM 2540C	01/18/23	01/19/23	vc	BA32329	


**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier	
<b>Batch BA32329 - -</b>											
<b>Blank</b>											
Prepared: 01/18/23 Analyzed: 01/19/23											
Total Dissolved Solids	ND	5.0	mg/L								
<b>LCS</b>											
Prepared: 01/18/23 Analyzed: 01/19/23											
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120				
<b>Duplicate</b>											
Source: 2301145-01 Prepared: 01/18/23 Analyzed: 01/19/23											
Total Dissolved Solids	4410	5.0	mg/L		4290			2.69	5		
<b>Duplicate</b>											
Source: 2301258-01 Prepared: 01/18/23 Analyzed: 01/19/23											
Total Dissolved Solids	4620	5.0	mg/L		4570			1.00	5		

**Notes and Definitions**

- R1 Sample Analyzed Past Holding Time.
- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
[213] 745-5312 FAX [213] 745-6372

DATE: 1-10-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 1301145

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP: 15°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] CORRECTED TEMP: 13°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>1-10-23</u>	<u>0920</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>1-10-23</u>	Time: <u>0920</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:  
Arrived at the lab 1-10-23 1055

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 01, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2301317  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 17, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 02/01/23  
 Submitted: 01/17/23  
**PLS Report No.: 2301317**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4300</b>		1	mg/L	5.0	- SM 2540C	01/24/23	01/25/23	vc	BA33145

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BA33145 - -</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	47.0	5.0	mg/L	50.00		94.0	80-120			
<b>Duplicate</b>										
<b>Source: 2301317-01</b>										
Total Dissolved Solids	4420	5.0	mg/L		4300			2.75	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rich Owen Parker*

Authorized Signature(s)



# CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 1-17-23 PAGE: 1 OF 2

FILE NO.: \_\_\_\_\_ LAB NO.: 20012017

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 3.2°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 3.0°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>1-17-23</u>	<u>0940</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>John Tombari</u>	Date: <u>1-17-23</u>	Time: <u>0940</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 1-17-23 1025

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 06, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2301399  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 24, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #: 74548  
 Report Date: 02/06/23  
 Submitted: 01/24/23  
**PLS Report No.: 2301399**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2301399-01) Sampled: 01/24/23 08:50 Received: 01/24/23										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3960		1	mg/L	5.0	- SM 2540C	01/31/23	02/01/23	vc	BB30147

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BB30147 ---</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
<b>Duplicate</b>										
Source: 2301440-01 Prepared: 01/31/23 Analyzed: 02/01/23										
Total Dissolved Solids	4230	5.0	mg/L		4060			4.30	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Parlin*  
 \_\_\_\_\_  
 Authorized Signature(s)





### CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 1-24-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2301399

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.40c

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.6c

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		IDS											SAMPLE CONDITIONS/ CONTAINER/COMMENTS	
				WATER	SOIL	SLUDGE	OTHER		#	TYPE													
	<u>1-24-23</u>	<u>0850</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X												

Relinquished by (Signature & Name): <i>MA</i>	Received by (Signature & Name): <i>John Barie</i>	Date: <u>1-24-23</u>	Time: <u>0850</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 1-24-23 1015

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER





781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 06, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2301440  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 30, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 02/06/23  
 Submitted: 01/30/23  
**PLS Report No.: 2301440**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2301440-01) Sampled: 01/30/23 08:55 Received: 01/30/23**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4060</b>		1	mg/L	5.0	- SM 2540C	01/31/23	02/01/23	vc	BB30147


**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BB30147 --</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
<b>Duplicate</b>										
<b>Source: 2301440-01</b>										
Total Dissolved Solids	4230	5.0	mg/L		4060			4.30	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 1-30-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 1301440

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 10.0°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.2°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>1-30-23</u>	<u>0855</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>[Signature]</u> <u>Jombani</u>	Date: <u>1-30-23</u>	Time: <u>0855</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 1-30-23 1030

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 13, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2302056  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 07, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 02/13/23  
 Submitted: 02/07/23  
**PLS Report No.: 2302056**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2302056-01) Sampled: 02/07/23 08:15 Received: 02/07/23										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4420</b>		1	mg/L	5.0	- SM 2540C	02/07/23	02/08/23	vc	BB30904


**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BB30904 --</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120			
<b>Duplicate</b>										
<b>Source: 2302022-01</b>		<b>Prepared: 02/07/23 Analyzed: 02/08/23</b>								
Total Dissolved Solids	1470	5.0	mg/L		1400			4.30	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

  
 Authorized Signature(s)





### CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-7-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 1302050

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.3°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.5°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>2-7-23</u>	<u>0815</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>MA</i>	Received by (Signature & Name): <i>[Signature] John Baik</i>	Date: <u>2-7-23</u>	Time: <u>0815</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 2-7-23 10:55

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 23, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2302113  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 15, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 02/23/23  
 Submitted: 02/15/23  
**PLS Report No.: 2302113**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2302113-01) Sampled: 02/15/23 08:25 Received: 02/15/23**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4460</b>		1	mg/L	5.0	- SM 2540C	02/21/23	02/22/23	vc	BB32314

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BB32314 --</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120			
<b>Duplicate</b>										
Source: 2302113-01 Prepared: 02/21/23 Analyzed: 02/22/23										
Total Dissolved Solids	4650	5.0	mg/L		4460			4.24	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Parlin*  
 Authorized Signature(s)





## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: \_\_\_\_\_ PAGE: \_\_\_\_\_ OF \_\_\_\_\_

FILE NO.: \_\_\_\_\_ LAB NO.: 2002113

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.10c

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.3c

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>2-15-23</u>	<u>825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i>	Date: <u>2-15-23</u>	Time: <u>0825</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 2-15-23 930

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

February 27, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2302170  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 21, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 02/27/23  
 Submitted: 02/21/23  
**PLS Report No.: 2302170**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly


Sample ID: Cooling Tower Blowdown Water (2302170-01) Sampled: 02/21/23 08:25 Received: 02/21/23										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4400		1	mg/L	5.0	- SM 2540C	02/21/23	02/22/23	vc	BB32314

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BB32314 --</b>										
<b>Blank</b> Prepared: 02/21/23 Analyzed: 02/22/23										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b> Prepared: 02/21/23 Analyzed: 02/22/23										
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120			
<b>Duplicate</b> Source: 2302113-01 Prepared: 02/21/23 Analyzed: 02/22/23										
Total Dissolved Solids	4650	5.0	mg/L		4460			4.24	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: \_\_\_\_\_ PAGE: \_\_\_\_\_ OF \_\_\_\_\_

FILE NO.: \_\_\_\_\_ LAB NO.: 1002470

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.20C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.42

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>2/1/23</u>	<u>0825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>2-2-23</u>	Time: <u>0825</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 2-2-23 1140

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

March 07, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2302245  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 27, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 03/07/23  
 Submitted: 02/27/23  
**PLS Report No.: 2302245**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2302245-01) Sampled: 02/27/23 07:40 Received: 02/27/23										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4400		1	mg/L	5.0	- SM 2540C	02/28/23	03/01/23	vc	BC30216

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BC30216 - -</b>										
<b>Blank</b>	<b>Prepared: 02/28/23 Analyzed: 03/01/23</b>									
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>	<b>Prepared: 02/28/23 Analyzed: 03/01/23</b>									
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
<b>Duplicate</b>	<b>Source: 2302245-01 Prepared: 02/28/23 Analyzed: 03/01/23</b>									
Total Dissolved Solids	4310	5.0	mg/L		4400			2.14	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

*Rick Owen Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)





# CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-27-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: W0245

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.5°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.2°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 06

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>2/27/23</u>	<u>0740</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>2/27/23</u>	Time: <u>0740</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 2/27/23 0900

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

March 17, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2303104  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 08, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager





781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 03/17/23  
 Submitted: 03/08/23  
**PLS Report No.: 2303104**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2303104-01) Sampled: 03/08/23 08:35 Received: 03/08/23**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4860		1	mg/L	5.0	- SM 2540C	03/14/23	03/15/23	vc	BC31609

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BC31609 --</b>										
<b>Blank</b>										
Prepared: 03/14/23 Analyzed: 03/15/23										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 03/14/23 Analyzed: 03/15/23										
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
<b>Duplicate</b>										
Source: 2303153-01 Prepared: 03/14/23 Analyzed: 03/15/23										
Total Dissolved Solids	4840	5.0	mg/L		4660			3.90	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 3/8/23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2303104

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.6°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.8°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>3/8/23</u>	<u>0835</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>3/8/23</u>	Time: <u>0835</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 3/8/23 1200

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

March 17, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2303153  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 13, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 03/17/23  
 Submitted: 03/13/23  
**PLS Report No.: 2303153**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2303153-01) Sampled: 03/13/23 08:10 Received: 03/13/23**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4660		1	mg/L	5.0	- SM 2540C	03/14/23	03/15/23	vc	BC31609

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BC31609 - -</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
<b>Duplicate</b>										
Source: 2303153-01 Prepared: 03/14/23 Analyzed: 03/15/23										
Total Dissolved Solids	4840	5.0	mg/L		4660			3.90	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Perlin*  
 \_\_\_\_\_  
 Authorized Signature(s)



### CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 3-13-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 12079521

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 08°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 10°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>3-13-23</u>	<u>0810</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): [Signature] Received by (Signature & Name): [Signature] Date: 3/13/23 Time: 0810 SAMPLE DISPOSITION

Relinquished by (Signature & Name): \_\_\_\_\_ Received by (Signature & Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Relinquished by (Signature & Name): \_\_\_\_\_ Received by (Signature & Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

1. Samples returned to client? Yes No  
 2. Samples will not be stored over 30 days, unless additional storage time is requested  
 3. Storage time requested: \_\_\_\_\_ days,  
 By: \_\_\_\_\_ Date: \_\_\_\_\_

SPECIAL INSTRUCTION: Arrived at the lab 3-13-23 0850

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

April 06, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2303253  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 21, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #: 74548  
 Report Date: 04/06/23  
 Submitted: 03/21/23  
**PLS Report No.: 2303253**

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2303253-01) Sampled: 03/21/23 08:20 Received: 03/21/23**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4400		1	mg/L	5.0	- SM 2540C	03/27/23	03/28/23	vc	BC32902

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BC32902 - -</b>										
<b>Blank</b>	<b>Prepared: 03/27/23 Analyzed: 03/28/23</b>									
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>	<b>Prepared: 03/27/23 Analyzed: 03/28/23</b>									
Total Dissolved Solids	55.0	5.0	mg/L	50.00		110	80-120			
<b>Duplicate</b>	<b>Source: 2303253-01 Prepared: 03/27/23 Analyzed: 03/28/23</b>									
Total Dissolved Solids	4600	5.0	mg/L		4400			4.33	5	
<b>Duplicate</b>	<b>Source: 2303283-07 Prepared: 03/27/23 Analyzed: 03/28/23</b>									
Total Dissolved Solids	55.0	5.0	mg/L		54.0			1.83	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

  
 \_\_\_\_\_  
 Authorized Signature(s)







781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

March 31, 2023

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2303329  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 27, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 03/31/23  
 Submitted: 03/27/23  
**PLS Report No.: 2303329**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2303329-01) Sampled: 03/27/23 07:35 Received: 03/27/23											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	3200		1	mg/L	5.0	- SM 2540C	03/28/23	03/29/23	vc	BC33126	

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
<b>Batch BC33126 - -</b>											
<b>Blank</b>											
Total Dissolved Solids	ND	5.0	mg/L								
<b>LCS</b>											
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120				
<b>Duplicate</b>											
Source: 2303329-01 Prepared: 03/28/23 Analyzed: 03/29/23											
Total Dissolved Solids	3350	5.0	mg/L		3200			4.52	5		
<b>Duplicate</b>											
Source: 2303293-07 Prepared: 03/28/23 Analyzed: 03/29/23											
Total Dissolved Solids	2340	5.0	mg/L		2240			4.59	5		

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

*Pick Owen Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 3-27-23 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 1303920

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.92

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.12

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: \_\_\_\_\_

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>3-27-23</u>	<u>0735</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>NA</u>	Received by (Signature & Name): <u>[Signature] Tom Barie</u>	Date: <u>3-27-23</u>	Time: <u>0735</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 3-27-23 1:00

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

# Appendix C

## Operation Logs



**Malburg Generating Station**  
**Appendix C, Table 1**  
**Combustion Turbine Generator (CTG) Startup and Shutdown Events**  
**During Quarter 1, 2023**

**CTG 1**

<b>Date</b>	<b>Event Type <sup>1</sup></b>	<b>Event Start</b>	<b>Event End</b>	<b>Duration (hrs:min)</b>
1/9/2023	Cold Start	1:43	1:56	0:13
1/25/2023	Shutdown	22:14	22:22	0:08
1/26/2023	Warm Start	10:05	10:18	0:13
3/3/2023	Shutdown	0:01	0:10	0:09
3/9/2023	Cold Start	15:09	15:34	0:25
3/11/2023	Shutdown	0:01	0:09	0:08
3/28/2023	Cold Start	4:16	4:29	0:13

**CTG 2**

<b>Date</b>	<b>Event Type <sup>1</sup></b>	<b>Event Start</b>	<b>Event End</b>	<b>Duration (hrs:min)</b>
1/8/2023	Trip / Shutdown	22:02	22:02	0:00
1/24/2023	Cold Start	14:31	14:44	0:13
1/26/2023	Shutdown	11:14	11:22	0:08
2/27/2023	Cold Start	14:45	14:58	0:13
3/29/2023	Shutdown	22:00	22:07	0:07

<sup>1</sup> A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

**Malburg Generating Station**  
**Appendix C, Table 2**  
**Diesel Firewater Pump Testing Times**  
**During Quarter 1, 2023**

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
1/1/2023	19:15	355.2	355.7	Testing	0.5
1/8/2023	18:18	355.7	356.2	Testing	0.5
1/15/2023	18:17	356.2	356.7	Testing	0.5
1/22/2023	21:20	356.7	357.2	Testing	0.5
1/29/2023	18:04	357.2	357.7	Testing	0.5
2/5/2023	18:51	357.7	358.2	Testing	0.5
2/12/2023	18:23	358.2	358.7	Testing	0.5
2/19/2023	22:06	358.7	359.2	Testing	0.5
2/26/2023	18:12	359.2	359.7	Testing	0.5
3/5/2023	17:26	359.7	360.2	Testing	0.5
3/12/2023	19:51	360.2	360.7	Testing	0.5
3/19/2023	18:42	360.7	361.2	Testing	0.5
3/26/2023	18:14	361.2	361.7	Testing	0.5

# **Appendix D**

## **Diesel Fuel Oil Purchase Records**



# Invoice



SC Commercial, LLC, DBA SC Fuels  
 1800 West Katella Ave, Suite 400  
 P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO:

**P.O. BOX 14237**  
**ORANGE, CA 92863-1237**

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

**INVOICE: 2100721-IN**

**INVOICE DATE: 4/11/2022**

**DUE DATE: 5/11/2022**

**SHIP DATE: 4/11/2022**

**SHIP VIA: 924**

**ORDER DATE: 4/1/2022**

**ORDER NUMBER: 2100721**

**CUSTOMER PO: 055.0002948**

**TERMS: N30**

**SALEPERSON: Todd Cripps**  
**714-938-5714**

**ACCT NO (Bill-to): 01-0001045**

CITY OF VERNON  
 4305 SANTA FE AVE  
 ATTN: DEPARTMENT D  
 VERNON, CA 90058  
 (323) 583-8811

**ACCT NO (Ship-to) 01-0001045 103L**

CITY OF VERNON-SOTO ST-L  
 4963 SOTO ST  
 VERNON, CA 90058

ITEM CODE	ITEM DESCRIPTION	QUANTITY ORDERED	QUANTITY DELIVERED	PACKAGE DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH277210983D40 0	CH MEROPA 150 277210983	1	1.00	400 LB DR	400.00	3.39000	1,356.00
	Whse: 101						
	\$3.39 PER TC						
422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL MTO/ \$4.35 PER TC	2	2.00	55 G DR	110.00	4.35000	478.50
	Whse: 101						
	Federal Lust					0.00100	0.11
	Federal Oil Spill					0.00214	0.24
	CA - AB 32 - DSL					0.00828	0.91
						4.36142	479.76
CH273204981D05 5	CH REGAL R&O ISO 150 273204981 FORMERLY - 273213981 1 BACKORDERED ON 2104708	0	0.00	55 G DR	0.00	0.00000	0.00
	Whse: 101						
	/FUELCHLUBE FUEL SURCHARGE LUBES						9.92
	/RCFLUBE REG COMPLIANCE FEE LUBES						12.95
DRUMDEPOSITC 001	DRUM DEPOSIT FEE	3	3.00	MISC CHRG	3.00	25.00000	75.00
	Whse: 101						
MSRTNDRMC001	RETURN DRUM	0	-2.00	MISC CHRG	2.00-	15.00000	30.00-
	Whse: 101						

Save time, pay online! View invoices, make payments and more.  
 Sign up for the Customer Portal today. Email: [creditinquiries@scfuels.com](mailto:creditinquiries@scfuels.com) or Call 888-SCFuels  
 Ext. 6017 or login to Customer Portal: <https://customerportal.scfuels.com>  
 24-hour Emergency Response Call CHEMTREC: 800-424-9300

Net Invoice: 1,903.63  
 Less Discount: 0.00  
 Freight: 0.00  
 Sales Tax: 190.52  
**Invoice Total: 2,094.15**

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH(A.P.R. 18%) WILL APPLY TO ALL PAST DUE INVOICES.  
 - ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.  
 - It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with federal and state laws.  
 - Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.



# Appendix E

## Excess Emission Reports



# Startup/Shutdown Excess Emissions Report

## U1 CO Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:54 **Location:** Vernon, California

**Tag Name:** U1\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours


### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 CO Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:54 **Location:** Vernon, California

**Tag Name:** U1\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 NOx Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:55 **Location:** Vernon, California

**Tag Name:** U1\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 NOx Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:55 **Location:** Vernon, California

**Tag Name:** U1\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 VOC Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:55 **Location:** Vernon, California

**Tag Name:** U1\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 VOC Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:55 **Location:** Vernon, California

**Tag Name:** U1\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,383.47 Hours

Non-Operating Time: 776.53 Hours Report Time: 2,160.00 Hours



No invalid events were found in the reporting period.

# Excess Emission Report

## Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 08:56 Location: Vernon, California



Tag Name: U1\_CONormal\_Ppmvdc\_1H

Total Operating Time: 1,388.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 772.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,388.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %



# Excess Emission Report



## Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 08:57 Location: Vernon, California

Tag Name: U1\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 1,388.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 772.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,388.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 08:57 Location: Vernon, California



Tag Name: U1\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 1,388.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 772.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,388.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Quad K Excess Emissions Report

## U1 NOX 4-Hour Events

From: 01/01/2023 00:00 To: 03/31/2023 23:59  
Generated: 04/07/2023 08:58

Facility Name: Malburg Generating Station  
Location: Vernon, California



Tag Name: U1\_NOx4H\_Ppmvdc\_1H

Total Operating Time: 1,388.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 772.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,388.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 09:04 Location: Vernon, California



Tag Name: U1\_CO\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 1,388.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 772.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,388.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## U2 CO Startup/Shutdown Events



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:59 **Location:** Vernon, California

**Tag Name:** U2\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours Report Time: 2,160.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## U2 CO Startup/Shutdown Events



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:59

**Location:** Vernon, California

**Tag Name:** U2\_CO\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours

Report Time: 2,160.00 Hours



No invalid events were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U2 NOx Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:59 **Location:** Vernon, California

**Tag Name:** U2\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours Report Time: 2,160.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U2 NOx Startup/Shutdown



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 08:59 **Location:** Vernon, California

**Tag Name:** U2\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.



# Startup/Shutdown Event Report

## U2 VOC Startup/Shutdown Events



**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 09:00 **Location:** Vernon, California

**Tag Name:** U2\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours Report Time: 2,160.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## U2 VOC Startup/Shutdown Events




**From:** 01/01/2023 00:00 **To:** 03/31/2023 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 04/07/2023 09:00 **Location:** Vernon, California

**Tag Name:** U2\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 960.87 Hours

Non-Operating Time: 1,199.13 Hours Report Time: 2,160.00 Hours



No invalid events were found in the reporting period.

# Excess Emission Report

## Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 09:01 Location: Vernon, California



Tag Name: U2\_CONormal\_Ppmvdc\_1H

Total Operating Time: 965.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,195.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 09:01 Location: Vernon, California



Tag Name: U2\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 965.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,195.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 09:02 Location: Vernon, California



Tag Name: U2\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 965.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,195.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Quad K Excess Emissions Report

## U2 NOX 4-Hour Events

From: 01/01/2023 00:00 To: 03/31/2023 23:59  
Generated: 04/07/2023 09:02

Facility Name: Malburg Generating Station  
Location: Vernon, California



Tag Name: U2\_NOx4H\_Ppmvdc\_1H

Total Operating Time: 965.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,195.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 01/01/2023 00:00 To: 03/31/2023 23:59 Facility Name: Malburg Generating Station  
Generated: 04/07/2023 09:03 Location: Vernon, California



Tag Name: U2\_CO\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 965.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,195.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %