

DOCKETED	
Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	251193
Document Title:	Malburg Generating Station Quarterly Compliance Report Q2 2023
Description:	N/A
Filer:	Elyse Engel
Organization:	Jacobs Engineering Group Inc.
Submitter Role:	Applicant
Submission Date:	7/27/2023 8:42:19 AM
Docketed Date:	7/27/2023



July 27, 2023

**NOTICE OF INTENT TO FILE
2023 Q2 Compliance Report for the
Malburg Generating Station (01-AFC-25C)**

Dear Dr. Ali:

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of April 1, 2023 through June 30, 2023. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at MRichards@cityofvernon.org or (323) 583-8811 x378.

Thank you,

A handwritten signature in blue ink, appearing to read 'Rich Olsen', is positioned below the 'Thank you,' text.

Rich Olsen
Assistant General Manager of Generation & Operations

Copies: Todd Dusenberry
Lisa Umeda
Matt Richards
Document Control

Enclosure: MGS 2023 Q2 Compliance Report

Malburg Generating Station Quarterly Compliance Report (Second Quarter 2023)

Submitted to
California Energy Commission

Submitted by
City of Vernon, Public Utilities Department

July 27, 2023

Document no: 230725091020_137f3134
Revision no: 0



Contents

Acronyms and Abbreviations.....	iii
1. Introduction	1
1.1 Project Location and Description.....	1
1.2 Organization of the Quarterly Compliance Report	1
2. Required Quarterly Compliance Report Documentation.....	1

Appendices

A	MGS Emission Calculations
B	Cooling Tower Blowdown Reports
C	Operation Logs
D	Diesel Fuel Oil Purchase Records
E	Excess Emission Reports

Table

2-1	Required Quarterly Compliance Report Documentation.....	1
-----	---	---

Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COC	Conditions of Certification
CTGs	combustion turbine generators
DAHS	data acquisition and handling system
gr/scf	grain per standard cubic foot
HRSGs	heat recovery steam generators
lb/day	pounds per day
MGS	Malburg Generating Station
NH ₃	ammonia
NO _x	nitrogen oxides
PM ₁₀	particulate matter with aerodynamic diameter less than or equal to 10 microns
PM _{2.5}	particulate matter with aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SO _x	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Table 2-1. Required Quarterly Compliance Report Documentation

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the second quarter of 2023 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM ₁₀) emissions from cooling tower operation during the second quarter of 2023 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the second quarter of 2023 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the second quarter of 2023, including the duration and date of occurrence, are provided in Appendix C, Table 1.
AQ-C11	All ammonia (NH ₃), nitrogen oxides (NO _x), sulfur oxides (SO _x), carbon monoxide (CO), PM ₁₀ , and volatile organic compound (VOC) emissions from MGS operation during the second quarter of 2023 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on April 11, 2022. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.

Malburg Generating Station Quarterly Compliance Report (Second Quarter 2023)

Condition of Certification	Response
AQ-5	Monthly emissions of CO, PM ₁₀ , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns (PM _{2.5}), VOC, and SO _x from CTG and duct burner operation during the second quarter of 2023 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NO _x excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO _x emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual or quarterly source testing. The most recent NH ₃ compliance source test, performed on May 16, 2023, with results submitted to the CEC on June 23, 2022, indicated compliance with the emission limits for both CTGs (0.8 ppm for CTG 1 and 0.6 ppm for CTG 2). NH ₃ emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH ₃ concentration limit of 5 ppm.
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source test, performed in July 2022, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.67 lb/hr and 0.0003 gr/scf for CTG 1 and 1.83 lb/hr and 0.0007 gr/scf for CTG 2).
AQ-14	See the response for COC AQ-2.
AQ-15	Quarterly hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the second quarter 2023 hours for maintenance and testing did not exceed 50 hours and the total operational hours did not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair did not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COCs AQ-5 and AQ-6.

Appendix A

MGS Emission Calculations



Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 1

Reporting Period: **Quarter 2 2023**

Table 1. Quarterly Emissions - April 1, 2023 through June 30, 2023

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
CTG 1 & Duct Burner	2,138	805	415	76	1,629	2,471
CTG 2 & Duct Burner	1,666	785	317	57	1,239	1,878
Cooling Tower	--	--	--	--	229	--
Diesel Firewater Pump	37.3	1.1	0.3	0.0	0.2	0.1
Total	3,841	1,591	733	132	3,097	4,349

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 2**

Reporting Period: **Quarter 2 2023**

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results ^{1, 2}

Sampling Period		
Start Date	End Date	TDS (ppm)
3/26/2023	4/1/2023	3,200
4/2/2023	4/8/2023	4,650
4/9/2023	4/15/2023	4,180
4/16/2023	4/22/2023	4,140
4/23/2023	4/29/2023	4,480
4/30/2023	5/6/2023	--
5/7/2023	5/13/2023	--
5/14/2023	5/20/2023	--
5/21/2023	5/27/2023	--
5/28/2023	6/3/2023	--
6/4/2023	6/10/2023	4,320
6/11/2023	6/17/2023	5,020
6/18/2023	6/24/2023	4,510
6/25/2023	7/1/2023	4,880

¹ Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

² MGS experienced a planned outage for the majority of May 2023; therefore, Cooling Tower Blowdown Reports were not prepared during that time.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 3**

Reporting Period: April 2023

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date ¹	Period Start Date	End Date	TDS (ppm)
3/27/2023	3/26/2023	4/1/2023	3,200
4/4/2023	4/2/2023	4/8/2023	4,650
4/11/2023	4/9/2023	4/15/2023	4,180
4/18/2023	4/16/2023	4/22/2023	4,140
4/25/2023	4/23/2023	4/29/2023	4,480
--	4/30/2023	5/6/2023	--

¹ MGS experienced a planned outage for the majority of May 2023; therefore, a Cooling Tower Blowdown Reports were not prepared during that time.

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm) ²	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ³
4/1/2023	38,880,000	3,200	1.04	No
4/2/2023	38,880,000	4,650	1.51	No
4/3/2023	38,880,000	4,650	1.51	No
4/4/2023	38,880,000	4,650	1.51	No
4/5/2023	38,880,000	4,650	1.51	No
4/6/2023	38,880,000	4,650	1.51	No
4/7/2023	38,880,000	4,650	1.51	No
4/8/2023	38,880,000	4,650	1.51	No
4/9/2023	38,880,000	4,180	1.35	No
4/10/2023	38,880,000	4,180	1.35	No
4/11/2023	38,880,000	4,180	1.35	No
4/12/2023	38,880,000	4,180	1.35	No
4/13/2023	38,880,000	4,180	1.35	No
4/14/2023	38,880,000	4,180	1.35	No
4/15/2023	38,880,000	4,180	1.35	No
4/16/2023	38,880,000	4,140	1.34	No
4/17/2023	38,880,000	4,140	1.34	No
4/18/2023	38,880,000	4,140	1.34	No
4/19/2023	38,880,000	4,140	1.34	No
4/20/2023	38,880,000	4,140	1.34	No
4/21/2023	38,880,000	4,140	1.34	No
4/22/2023	0	4,140	0.00	No
4/23/2023	0	4,480	0.00	No
4/24/2023	0	4,480	0.00	No
4/25/2023	0	4,480	0.00	No
4/26/2023	38,880,000	4,480	1.45	No
4/27/2023	38,880,000	4,480	1.45	No
4/28/2023	38,880,000	4,480	1.45	No
4/29/2023	38,880,000	4,480	1.45	No
4/30/2023	38,880,000	4,400	1.43	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² MGS experienced a planned outage for the majority of May 2023; therefore, Cooling Tower Blowdown Reports were not prepared during that time. For days that MGS operated during that time, sample results were assumed to be best represented by the average of results sampled on April 25, 2023 and June 6, 2023.

³ Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 4**

Reporting Period: May 2023

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date ¹	Period Start Date	End Date	TDS (ppm)
--	4/30/2023	5/6/2023	--
--	5/7/2023	5/13/2023	--
--	5/14/2023	5/20/2023	--
--	5/21/2023	5/27/2023	--
--	5/28/2023	6/3/2023	--

¹ MGS experienced a planned outage for the majority of May 2023; therefore, a Cooling Tower Blowdown Reports were not prepared during that time.

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000
x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm) ²	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ³
5/1/2023	38,880,000	4,400	1.43	No
5/2/2023	38,880,000	4,400	1.43	No
5/3/2023	38,880,000	4,400	1.43	No
5/4/2023	38,880,000	4,400	1.43	No
5/5/2023	38,880,000	4,400	1.43	No
5/6/2023	0	--	0.00	No
5/7/2023	38,880,000	4,400	1.43	No
5/8/2023	38,880,000	4,400	1.43	No
5/9/2023	38,880,000	4,400	1.43	No
5/10/2023	38,880,000	4,400	1.43	No
5/11/2023	38,880,000	4,400	1.43	No
5/12/2023	38,880,000	4,400	1.43	No
5/13/2023	0	--	0.00	No
5/14/2023	0	--	0.00	No
5/15/2023	38,880,000	4,400	1.43	No
5/16/2023	38,880,000	4,400	1.43	No
5/17/2023	38,880,000	4,400	1.43	No
5/18/2023	38,880,000	4,400	1.43	No
5/19/2023	38,880,000	4,400	1.43	No
5/20/2023	38,880,000	4,400	1.43	No
5/21/2023	0	--	0.00	No
5/22/2023	0	--	0.00	No
5/23/2023	0	--	0.00	No
5/24/2023	0	--	0.00	No
5/25/2023	0	--	0.00	No
5/26/2023	0	--	0.00	No
5/27/2023	0	--	0.00	No
5/28/2023	0	--	0.00	No
5/29/2023	0	--	0.00	No
5/30/2023	0	--	0.00	No
5/31/2023	0	--	0.00	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² MGS experienced a planned outage for the majority of May 2023; therefore, Cooling Tower Blowdown Reports were not prepared during that time. For days that MGS operated during that time, sample results were assumed to be best represented by the average of results sampled on April 25, 2023 and June 6, 2023.

³ Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 5**

Reporting Period: June 2023

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date ¹	Period Start Date	End Date	TDS (ppm)
--	5/28/2023	6/3/2023	--
6/6/2023	6/4/2023	6/10/2023	4,320
6/12/2023	6/11/2023	6/17/2023	5,020
6/20/2023	6/18/2023	6/24/2023	4,510
6/26/2023	6/25/2023	7/1/2023	4,880

¹ MGS experienced a planned outage for the majority of May 2023; therefore, a Cooling Tower Blowdown Reports were not prepared during that time.

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
6/1/2023	0	--	0.00	No
6/2/2023	0	--	0.00	No
6/3/2023	0	--	0.00	No
6/4/2023	38,880,000	4,320	1.40	No
6/5/2023	38,880,000	4,320	1.40	No
6/6/2023	38,880,000	4,320	1.40	No
6/7/2023	38,880,000	4,320	1.40	No
6/8/2023	38,880,000	4,320	1.40	No
6/9/2023	38,880,000	4,320	1.40	No
6/10/2023	38,880,000	4,320	1.40	No
6/11/2023	38,880,000	5,020	1.63	No
6/12/2023	38,880,000	5,020	1.63	No
6/13/2023	38,880,000	5,020	1.63	No
6/14/2023	38,880,000	5,020	1.63	No
6/15/2023	38,880,000	5,020	1.63	No
6/16/2023	38,880,000	5,020	1.63	No
6/17/2023	38,880,000	5,020	1.63	No
6/18/2023	38,880,000	4,510	1.46	No
6/19/2023	38,880,000	4,510	1.46	No
6/20/2023	38,880,000	4,510	1.46	No
6/21/2023	38,880,000	4,510	1.46	No
6/22/2023	38,880,000	4,510	1.46	No
6/23/2023	38,880,000	4,510	1.46	No
6/24/2023	38,880,000	4,510	1.46	No
6/25/2023	38,880,000	4,880	1.58	No
6/26/2023	38,880,000	4,880	1.58	No
6/27/2023	38,880,000	4,880	1.58	No
6/28/2023	38,880,000	4,880	1.58	No
6/29/2023	38,880,000	4,880	1.58	No
6/30/2023	38,880,000	4,880	1.58	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

Malburg Generating Station
Quarterly Compliance Report
Appendix A, Tables 6, 7, 8, & 9

Reporting Period: **Quarter 2 2023**

Table 6. Monthly Turbine-Duct Burner Fuel Flow

Source	April	Above 405	May	Above 405	June	Above 405
	Fuel Flow (MMscf/month) ^{1,2}	MMscf/month Limit? ³	Fuel Flow (MMscf/month) ^{1,2}	MMscf/month Limit? ³	Fuel Flow (MMscf/month) ^{1,2}	MMscf/month Limit? ³
CTG 1	155.6		35.1		79.2	
CTG 1 Duct Burner	0.74		0.10		0.00	
Total CTG 1 & Duct Burner	156	No	35	No	79	No
CTG 2	28.2		65.6		111.6	
CTG 2 Duct Burner	0.06		0.07		0.34	
Total CTG 2 & Duct Burner	28	No	66	No	112	No

¹ CTG 1 and CTG 1 Duct Burner fuel flow data obtained from 'U1_MonthlySummary_MassEmissionsAndFuel', 'All_12MonthSummary_GasUsage', and 'Daily Operating Report Fuel and Generation' RegPerfect Reports, based on data availability. Because data substitution was implemented for April and a portion of May, per-device fuel flow is not available from the DAHS directly. Instead, total fuel flow was apportioned to the CTG or Duct Burner based on the pre-substituted ratio.

² CTG 2 and CTG 2 Duct Burner fuel flow data obtained from 'U2_MonthlySummary_MassEmissionsAndFuel' and 'All_12MonthSummary_GasUsage' RegPerfect Reports.

³ Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - April 2023

Source	Monthly Emissions (lb/month) ¹					
	NOx ²	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,138	345	239	44	941	1,429
CTG 2 & Duct Burner	279	151	44	8	170	258
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 8. Monthly Emissions - May 2023

Source	Monthly Emissions (lb/month) ¹					
	NOx ²	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	402	210	54	10	212	321
CTG 2 & Duct Burner	544	272	101	18	395	599
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 9. Monthly Emissions - June 2023

Source	Monthly Emissions (lb/month) ¹					
	NOx ²	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	597.95	249	122	22.1	476	721
CTG 2 & Duct Burner	841.97	362	172	31.0	673	1,022
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 10

Reporting Period: **Quarter 2 2023**

Methodology

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

Emission Factors

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICes given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM ₁₀ /PM _{2.5}	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
NH ₃	0.80	Default for diesel combustion equipment without an SNCR or SCR given in the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Reporting Procedures - June 2020.

Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions

Month	Monthly Hours of Operation ¹			Fuel Usage (gal/month) ²	Monthly Emissions (lb/month)					
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
January	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
February	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
March	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
April	0.0	2.6	0.0	29.1	13.7	0.40	0.10	0.01	0.09	0.02
May	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
June	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
July	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
August	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
September	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
October	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
November	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00
December	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q1 Total	0.0	6.5	0.0	72.8	34.1	0.99	0.25	0.02	0.22	0.06
Q2 Total	0.0	7.1	0.0	79.5	37.3	1.08	0.27	0.02	0.24	0.06
Q3 Total	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00	0.00	0.00
Q4 Total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Annual Total	0.0	13.6	0.0	152.3	71.4	2.1	0.5	0.0	0.5	0.1
Annual Limit for Maintenance and Testing ³			50							
Total Annual Limit ³			200							
Exceeds Limits?			No							

¹ Monthly hours of operation calculated from Device 385/403 run timer readings.

² Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

³ Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

Appendix B

Cooling Tower Blowdown Reports





781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 31, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2303329
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 27, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

File #:74548
Report Date: 03/31/23
Submitted: 03/27/23
PLS Report No.: 2303329

Sample ID: Cooling Tower Blowdown Water (2303329-01) Sampled: 03/27/23 07:35 Received: 03/27/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3200		1	mg/L	5.0	- SM 2540C	03/28/23	03/29/23	vc	BC33126

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
Batch BC33126 - -									
Blank									
Prepared: 03/28/23 Analyzed: 03/29/23									
Total Dissolved Solids	ND	5.0	mg/L						
LCS									
Prepared: 03/28/23 Analyzed: 03/29/23									
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0 80-120			
Duplicate									
Source: 2303329-01 Prepared: 03/28/23 Analyzed: 03/29/23									
Total Dissolved Solids	3350	5.0	mg/L		3200		4.52	5	
Duplicate									
Source: 2303293-07 Prepared: 03/28/23 Analyzed: 03/29/23									
Total Dissolved Solids	2340	5.0	mg/L		2240		4.59	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 3-27-23 PAGE: 1 OF 1

FILE NO.: LAB NO.: 1303329

CLIENT NAME: CITY OF VERNON				PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY				P.O.NO.				AIRBILL NO:															
ADDRESS: 4963 SOTO ST. VERNON CA 90058												ANALYSES REQUESTED				OBSERVED TEMP: <u>0.92</u>											
PROJECT MANAGER MATT RICHARDS				PHONE NO:				FAX NO:				CORRECTED TEMP: <u>1.12</u>															
SAMPLER NAME: JOHN BARIE				SIGNATURE: <u>[Signature]</u>								THERMO ID: <u>66</u>															
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal																											
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																											
UST PROJECT: Y N GLOBAL ID#: -----																											
SAMPLE ID		DATE SAMPLED		TIME SAMPLED		SAMPLE DESCRIPTION				MATRIX				TAT		CONTAINER		SAMPLE CONDITIONS/ CONTAINER/COMMENTS									
										WATER		SOIL		SLUDGE		OTHER						#		TYPE			
		<u>3-27-23</u>		<u>0735</u>		COOLING TOWER BLOWDOWN				X								N		1		P		X			

Relinquished by (Signature & Name): <u>NA</u>				Received by (Signature & Name): <u>[Signature]</u> <u>Tom Barie</u>				Date: <u>3-27-23</u>		Time: <u>0735</u>		SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____			
Relinquished by (Signature & Name):				Received by (Signature & Name):				Date:		Time:					
Relinquished by (Signature & Name):				Received by (Signature & Name):				Date:		Time:					
SPECIAL INSTRUCTION: <u>Arrived at the lab 3-27-23 1:00</u>															

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

April 12, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2304014
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 04, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX: (323) 476-3640

File #: 74548

Report Date: 04/12/23

Submitted: 04/04/23

PLS Report No.: 2304014

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2304014-01) Sampled: 04/04/23 09:55 Received: 04/04/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4650		1	mg/L	5.0	- SM 2540C	04/11/23	04/11/23	vc	BD31202

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BD31202 - -										
Blank										
Prepared & Analyzed: 04/11/23										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 04/11/23										
Total Dissolved Solids	57.0	5.0	mg/L	50.00		114	80-120			
Duplicate										
Source: 2304013-01 Prepared & Analyzed: 04/11/23										
Total Dissolved Solids	1050	5.0	mg/L		1030			1.61	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 4.4.23 PAGE: 1 OF 7

FILE NO.: LAB NO.: 2204014

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 0.70

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.90

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>4.4.23</u>	<u>0955</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature& Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> <u>John Barie</u>	Date: <u>4.4.23</u>	Time: <u>0955</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 4.4.23 1120

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

April 18, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2304075
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 11, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX: (323) 476-3640

File #: 74548
Report Date: 04/18/23
Submitted: 04/11/23
PLS Report No.: 2304075

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2304075-01) Sampled: 04/11/23 09:05 Received: 04/11/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4180		1	mg/L	5.0	- SM 2540C	04/13/23	04/14/23	vc	BD31705

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BD31705 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	52.0	5.0	mg/L	50.00		104	80-120			
Duplicate										
Source: 2304075-01										
Total Dissolved Solids	4350	5.0	mg/L		4180			4.18	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 1/11/23 PAGE: 1 OF 1

FILE NO.: LAB NO.: 2304075

CLIENT NAME: CITY OF VERNON				PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY				P.O.NO.				AIRBILL NO:											
ADDRESS: 4963 SOTO ST. VERNON CA 90058												ANALYSES REQUESTED				OBSERVED TEMP <u>0.9°C</u>							
PROJECT MANAGER MATT RICHARDS				PHONE NO:				FAX NO:				CORRECTED TEMP <u>0.7°C</u>											
SAMPLER NAME: JOHN BARIE				SIGNATURE: <u>F</u>								THERMO ID: <u>60</u>											
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal																							
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																							
UST PROJECT: Y N GLOBAL ID#: -----																							
SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		IDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS		
				WATER	SOIL	SLUDGE	OTHER		#	TYPE													
	<u>1-11-23</u>	<u>0905</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X												
Relinquished by (Signature& Name): <u>MA</u>												Received by (Signature & Name): <u>Tom Barie</u>				Date: <u>1-11-23</u> Time: <u>0905</u>				SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____			
Relinquished by (Signature& Name):												Received by (Signature & Name):				Date: Time:							
Relinquished by (Signature& Name):												Received by (Signature & Name):				Date: Time:							
SPECIAL INSTRUCTION: Arrived at the lab <u>1-11-23 1030</u>																							

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

April 24, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2304123
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 18, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

File #:74548

Report Date: 04/24/23

Submitted: 04/18/23

PLS Report No.: 2304123

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2304123-01) Sampled: 04/18/23 08:35 Received: 04/18/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4140		1	mg/L	5.0	- SM 2540C	04/19/23	04/20/23	vc	BD32103

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BD32103 - -										
Blank										
Prepared: 04/19/23 Analyzed: 04/20/23										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared: 04/19/23 Analyzed: 04/20/23										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
Duplicate										
Source: 2304123-01 Prepared: 04/19/23 Analyzed: 04/20/23										
Total Dissolved Solids	4160	5.0	mg/L		4140			0.482	5	
Duplicate										
Source: 2304116-03 Prepared: 04/19/23 Analyzed: 04/20/23										
Total Dissolved Solids	690	5.0	mg/L		688			0.290	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parlier

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 4/18/23 PAGE: 1 OF 1

FILE NO.: LAB NO.: 2004123

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP: 1.1°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] CORRECTED TEMP: 1.3°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: --- -- -- -- -- -- -- -- -- --

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>4/18/23</u>	<u>0835</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature& Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>4/18/23</u>	Time: <u>0835</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 4/18/23 1130

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

May 02, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2304275
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 25, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

File #:74548

Report Date: 05/02/23

Submitted: 04/25/23

PLS Report No.: 2304275

Sample ID: Cooling Tower Blowdown Water (2304275-01) Sampled: 04/25/23 08:30 Received: 04/25/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4480		1	mg/L	5.0	- SM 2540C	04/27/23	04/28/23	vc	BE30202

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BE30202 --										
Blank Prepared: 04/27/23 Analyzed: 04/28/23										
Total Dissolved Solids	ND	5.0	mg/L							
LCS Prepared: 04/27/23 Analyzed: 04/28/23										
Total Dissolved Solids	59.0	5.0	mg/L	50.00		118	80-120			
Duplicate Source: 2304275-01 Prepared: 04/27/23 Analyzed: 04/28/23										
Total Dissolved Solids	4510	5.0	mg/L		4480			0.482	5	

Notes and Definitions

NA	Not Applicable
ND	Analyte NOT DETECTED at or above the reported limit(s)
NR	Not Reported
MDL	Method Detection Limit
PQL	Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 4-25-23 PAGE: 1 OF 1

FILE NO.: LAB NO.: 2304275

CLIENT NAME: CITY OF VERNON

PROJECT NAME/NO.

MALBURG GENERATING STATION WEEKLY

P.O.NO.

AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058

ANALYSES REQUESTED

OBSERVED TEMP 10.8°C

PROJECT MANAGER MATT RICHARDS

PHONE NO: 7

FAX NO:

CORRECTED TEMP: 1.2°C

SAMPLER NAME: JOHN BARIE

SIGNATURE:

THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS											SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE												
	<u>4-25-23</u>	<u>9:23</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X											

Relinquished by (Signature& Name):

Received by (Signature & Name):

Date:

Time:

SAMPLE DISPOSITION

Relinquished by (Signature& Name):

Received by (Signature & Name):

Date:

Time:

1. Samples returned to client? Yes No
2. Samples will not be stored over 30 days, unless additional storage time is requested
3. Storage time requested: _____ days,
By: _____ Date: _____

Relinquished by (Signature& Name):

Received by (Signature & Name):

Date:

Time:

SPECIAL INSTRUCTION:

Arrived at the lab 4-25-23 10:55

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

June 14, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2306036
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 06, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX: (323) 476-3640

File #: 74548

Report Date: 06/14/23

Submitted: 06/06/23

PLS Report No.: 2306036

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2306036-01) Sampled: 06/06/23 10:15 Received: 06/06/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4320		1	mg/L	5.0	SM 2540C	06/12/23	06/13/23	vc	BF31402

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
Batch BF31402 - -									
Blank									
Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	ND	5.0	mg/L						
LCS									
Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	56.0	5.0	mg/L	50.00		112 80-120			
Duplicate									
Source: 2306036-01 Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	4160	5.0	mg/L		4320		3.77	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

CHAIN OF CUSTODY AND ANALYSIS REQUEST



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

June 16, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2306090
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 12, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX: (323) 476-3640

File #: 74548

Report Date: 06/16/23

Submitted: 06/12/23

PLS Report No.: 2306090

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2306090-01) Sampled: 06/12/23 08:25 Received: 06/12/23										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	5020		1	mg/L	5.0	SM 2540C	06/12/23	06/13/23	vc	BF31402

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
Batch BF31402 - -									
Blank									
Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	ND	5.0	mg/L						
LCS									
Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	56.0	5.0	mg/L	50.00		112 80-120			
Duplicate Source: 2306036-01									
Prepared: 06/12/23 Analyzed: 06/13/23									
Total Dissolved Solids	4160	5.0	mg/L		4320		3.77	5	

Notes and Definitions

NA Not Applicable
ND Analyte NOT DETECTED at or above the reported limit(s)
NR Not Reported
MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 5/24 PAGE: 1 OF 1
FILE NO.: LAB NO.: 1306090

CLIENT NAME: CITY OF VERNON		PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY		P.O.NO.		AIRBILL NO:											
ADDRESS: 4963 SOTO ST. VERNON CA 90058				ANALYSES REQUESTED				OBSERVED TEMP <u>1.5°C</u>									
PROJECT MANAGER MATT RICHARDS		PHONE NO:		FAX NO:				CORRECTED TEMP: <u>1.2°C</u>									
SAMPLER NAME: JOHN BARIE		SIGNATURE: <u>[Signature]</u>		TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal				THERMO ID: <u>66</u>									
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																	
UST PROJECT: Y N GLOBAL ID#: --- -- -- -- -- -- -- -- -- --																	
SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS					SAMPLE CONDITIONS/ CONTAINER/COMMENTS	
				WATER	SOIL	SLUDGE	OTHER		#	TYPE							
	<u>5/24</u>	<u>0825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X						

Relinquished by (Signature& Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>5/24</u>	Time: <u>0825</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 5/24 0900

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

June 26, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2306165
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 20, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX: (323) 476-3640

File #: 74548

Report Date: 06/26/23

Submitted: 06/20/23

PLS Report No.: 2306165

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2306165-01) Sampled: 06/20/23 09:25 Received: 06/20/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4510		1	mg/L	5.0	- SM 2540C	06/21/23	06/22/23	vc	BF32313

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BF32313 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	48.0	5.0	mg/L	50.00		96.0	80-120			
Duplicate Source: 2306165-01 Prepared: 06/21/23 Analyzed: 06/22/23										
Total Dissolved Solids	4510	5.0	mg/L		4510			0.0738	5	
Duplicate Source: 2306129-04 Prepared: 06/21/23 Analyzed: 06/22/23										
Total Dissolved Solids	1870	5.0	mg/L		1920			2.82	5	

Notes and Definitions

NA	Not Applicable
ND	Analyte NOT DETECTED at or above the reported limit(s)
NR	Not Reported
MDL	Method Detection Limit
PQL	Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: _____ PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 23010165

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 1-8°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 2.0°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 61

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other


UST PROJECT: Y N GLOBAL ID#: --- -- -- -- -- -- -- -- -- --

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS											SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE												
	6/20/13	0925	COOLING TOWER BLOWDOWN	X				N	1	P	X											

Relinquished by (Signature& Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> <u>Jon Barie</u>	Date: <u>6/20/13</u>	Time: <u>0925</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature& Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 6/20/13 12a

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



POSITIVE
LAB SERVICE

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 03, 2023

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2306228
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 26, 2023.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

File #:74548

Report Date: 07/03/23

Submitted: 06/26/23

PLS Report No.: 2306228

Sample ID: Cooling Tower Blowdown Water (2306228-01) Sampled: 06/26/23 08:20 Received: 06/26/23

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4880		1	mg/L	5.0	- SM 2540C	06/29/23	06/30/23	vc	BF33032

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
Batch BF33032 - -									
Blank									
Prepared: 06/29/23 Analyzed: 06/30/23									
Total Dissolved Solids	ND	5.0	mg/L						
LCS									
Prepared: 06/29/23 Analyzed: 06/30/23									
Total Dissolved Solids	50.0	5.0	mg/L	50.00		100 80-120			
Duplicate									
Source: 2306228-01 Prepared: 06/29/23 Analyzed: 06/30/23									
Total Dissolved Solids	5090	5.0	mg/L		4880		4.28	5	

Notes and Definitions

NA	Not Applicable
ND	Analyte NOT DETECTED at or above the reported limit(s)
NR	Not Reported
MDL	Method Detection Limit
PQL	Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 6-26-23 PAGE: 1 OF 1

FILE NO.: LAB NO.: 1201228

CLIENT NAME: CITY OF VERNON				PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY				P.O.NO.				AIRBILL NO:																																																																																																																																																																																					
ADDRESS: 4963 SOTO ST. VERNON CA 90058												ANALYSES REQUESTED				OBSERVED TEMP <u>16.3°C</u>																																																																																																																																																																																	
PROJECT MANAGER MATT RICHARDS				PHONE NO:				FAX NO:				CORRECTED TEMP: <u>1.5°C</u>																																																																																																																																																																																					
SAMPLER NAME: JOHN BARIE				SIGNATURE:								THERMO ID: <u>60</u>																																																																																																																																																																																					
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal																																																																																																																																																																																																	
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																																																																																																																																																																																																	
UST PROJECT: Y N GLOBAL ID#: -----																																																																																																																																																																																																	
<table border="1"><thead><tr><th rowspan="2">SAMPLE ID</th><th rowspan="2">DATE SAMPLED</th><th rowspan="2">TIME SAMPLED</th><th rowspan="2">SAMPLE DESCRIPTION</th><th colspan="4">MATRIX</th><th rowspan="2">TAT</th><th colspan="2">CONTAINER</th><th rowspan="2">TDS</th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2"></th><th rowspan="2">SAMPLE CONDITIONS/CONTAINER/COMMENTS</th></tr><tr><th>WATER</th><th>SOIL</th><th>SLUDGE</th><th>OTHER</th><th>#</th><th>TYPE</th></tr></thead><tbody><tr><td></td><td><u>6/26/23</u></td><td><u>0820</u></td><td>COOLING TOWER BLOWDOWN</td><td>X</td><td></td><td></td><td></td><td>N</td><td>1</td><td>P</td><td>X</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></tbody></table>												SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/CONTAINER/COMMENTS	WATER	SOIL	SLUDGE	OTHER	#	TYPE		<u>6/26/23</u>	<u>0820</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X																																																																																																																																															
SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS																								SAMPLE CONDITIONS/CONTAINER/COMMENTS																																																																																																																																																														
				WATER	SOIL	SLUDGE	OTHER		#	TYPE																																																																																																																																																																																							
	<u>6/26/23</u>	<u>0820</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X																																																																																																																																																																																						
Relinquished by (Signature& Name): <u>MA</u>												Received by (Signature & Name): <u>Jr Tompkins</u>				Date: <u>6-26-23</u> Time: <u>0820</u>				SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested. 3. Storage time requested: _____ days. By: _____ Date: _____																																																																																																																																																																													
Relinquished by (Signature& Name):												Received by (Signature & Name):				Date: Time:																																																																																																																																																																																	
Relinquished by (Signature& Name):												Received by (Signature & Name):				Date: Time:																																																																																																																																																																																	
SPECIAL INSTRUCTION: Arrived at the lab <u>6/26/23 1030</u>																																																																																																																																																																																																	

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Appendix C

Operation Logs



Malburg Generating Station
Appendix C, Table 1
Combustion Turbine Generator (CTG) Startup and Shutdown Events
During Quarter 2, 2023

CTG 1

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
4/21/2023	Shutdown	21:59	22:07	0:08
5/1/2023	Cold Start	22:44	22:50	0:06
5/2/2023	Trip / Shutdown	0:01	0:01	0:00
5/2/2023	Warm Start	1:52	2:52	1:00
5/6/2023	Shutdown	0:02	0:11	0:09
5/15/2023	Cold Start	20:59	22:26	1:27
5/16/2023	Shutdown	21:54	22:02	0:08
6/11/2023	Cold Start	11:06	12:53	1:47
6/22/2023	Shutdown	21:19	21:27	0:08

CTG 2

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
4/26/2023	Cold Start	14:09	15:43	1:34
4/29/2023	Shutdown	07:56	08:05	0:09
4/29/2023	Warm Start	14:06	15:07	1:01
4/30/2023	Shutdown	14:57	15:05	0:08
5/7/2023	Cold Start	21:31	22:59	1:28
5/13/2023	Shutdown	00:00	00:05	0:05
5/16/2023	Cold Start	05:42	06:54	1:12
5/20/2023	Shutdown	06:56	07:04	0:08
6/4/2023	Cold Start	17:16	18:39	1:23
6/11/2023	Trip / Shutdown	10:26	10:26	0:00
6/22/2023	Cold Start	04:39	05:55	1:16

¹ A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

Malburg Generating Station
Appendix C, Table 2
Diesel Firewater Pump Testing Times
During Quarter 2, 2023

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
4/2/2023	22:15	361.7	362.3	Testing	0.6
4/9/2023	23:22	362.3	362.8	Testing	0.5
4/16/2023	19:35	362.8	363.3	Testing	0.5
4/23/2023	19:02	363.3	363.8	Testing	0.5
4/30/2023	18:17	363.8	364.3	Testing	0.5
5/8/2023	18:18	364.3	364.8	Testing	0.5
5/15/2023	18:46	364.8	365.3	Testing	0.5
5/21/2023	18:57	365.3	366.3	Testing ¹	1
5/28/2023	18:21	366.3	366.8	Testing	0.5
6/4/2023	21:48	366.8	367.3	Testing	0.5
6/11/2023	21:59	367.3	367.8	Testing	0.5
6/18/2023	21:07	367.8	368.3	Testing	0.5
6/25/2023	17:06	368.3	368.8	Testing	0.5

¹ Contractor performed testing on the diesel firewater pump during the Spring Outage which was not recorded. To account for this 0.5-hour run, the end hour for the test run on May 21, 2023 has been manually adjusted from the log's reading of 365.8.

Appendix D

Diesel Fuel Oil Purchase Records



Invoice

Page 1 of 1



SC Commercial, LLC, DBA SC Fuels
1800 West Katella Ave, Suite 400
P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO:

P.O. BOX 14237
ORANGE, CA 92863-1237

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

INVOICE: 2100721-IN

INVOICE DATE: 4/11/2022

DUE DATE: 5/11/2022

SHIP DATE: 4/11/2022

SHIP VIA: 924

ORDER DATE: 4/1/2022

ORDER NUMBER: 2100721

CUSTOMER PO: 055.0002948

TERMS: N30

SALEPERSON: Todd Cripps

714-938-5714

ACCT NO (Bill-to): 01-0001045

CITY OF VERNON
4305 SANTA FE AVE
ATTN: DEPARTMENT D
VERNON, CA 90058
(323) 583-8811

ACCT NO (Ship-to) 01-0001045 103L

CITY OF VERNON-SOTO ST-L
4963 SOTO ST
VERNON, CA 90058

ITEM CODE	ITEM DESCRIPTION	QUANTITY ORDERED	QUANTITY DELIVERED	PACKAGE DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH277210983D40 0	CH MEROPA 150 277210983	1	1.00	400 LB DR	400.00	3.39000	1,356.00
	Whse: 101						
	\$3.39 PER TC						
422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL MTO/ \$4.35 PER TC	2	2.00	55 G DR	110.00	4.35000	478.50
	Whse: 101						
	Federal Lust					0.00100	0.11
	Federal Oil Spill					0.00214	0.24
	CA - AB 32 - DSL					0.00828	0.91
						4.36142	479.76
CH273204981D05 5	CH REGAL R&O ISO 150 273204981 FORMERLY - 273213981 1 BACKORDERED ON 2104708	0	0.00	55 G DR	0.00	0.00000	0.00
	Whse: 101						
	/FUELCHLUBE FUEL SURCHARGE LUBES						9.92
	/RCFLUBE REG COMPLIANCE FEE LUBES						12.95
DRUMDEPOSITC 001	DRUM DEPOSIT FEE	3	3.00	MISC CHRG	3.00	25.00000	75.00
	Whse: 101						
MSRTNDRMC001	RETURN DRUM	0	-2.00	MISC CHRG	2.00-	15.00000	30.00-
	Whse: 101						

Save time, pay online! View invoices, make payments and more.
Sign up for the Customer Portal today. Email: creditinquiries@scfuels.com or Call 888-SCFuels
Ext. 6017 or login to Customer Portal: <https://customerportal.scfuels.com>
24-hour Emergency Response Call CHEMTREC: 800-424-9300

Net Invoice: 1,903.63
Less Discount: 0.00
Freight: 0.00
Sales Tax: 190.52
Invoice Total: 2,094.15

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER
- CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH(A.P.R. 18%) WILL APPLY TO ALL PAST DUE INVOICES.
- ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.
- It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with federal and state laws.
- Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.

Appendix E

Excess Emission Reports



Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station

Generated: 07/06/2023 23:26 Location: Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:26 **Location:** Vernon, California
Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours **Report Time:** 2,184.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
04/21/2023 20:38 04/21/2023 21:07	30		
05/01/2023 21:44 05/01/2023 23:00	77		
05/02/2023 00:52 05/02/2023 02:22	91		
05/05/2023 22:42 05/05/2023 23:11	30		

Total CMS Downtime	228	Minute(s)
Total Downtime as a percentage of operating time	0.42	%
Total Availability as a percentage of operating time	99.58	%

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station

Generated: 07/06/2023 23:27 Location: Vernon, California

Tag Name: U1_NOxRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report



U1 NOx Startup/Shutdown

From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station

Generated: 07/06/2023 23:27 **Location:** Vernon, California

Tag Name: U1_NOxRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours Report Time: 2,184.00 Hours

--

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:28 **Location:** Vernon, California
Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:28 **Location:** Vernon, California
Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 896.18 Hours
Non-Operating Time: 1,287.82 Hours **Report Time:** 2,184.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
04/21/2023 20:38 04/21/2023 21:07	30		
05/01/2023 21:44 05/01/2023 23:00	77		
05/02/2023 00:52 05/02/2023 02:22	91		
05/05/2023 22:42 05/05/2023 23:11	30		

Total CMS Downtime	228	Minute(s)
Total Downtime as a percentage of operating time	0.42	%
Total Availability as a percentage of operating time	99.58	%

Excess Emission Report

Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:28 Location: Vernon, California



Tag Name: U1_CONormal_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	903.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:29 Location: Vernon, California



Tag Name: U1_NOxNormal_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	903.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:30 Location: Vernon, California



Tag Name: U1_VOCNormal_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	903.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:31 Location: Vernon, California



Tag Name: U1_NOx4H_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	903.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:35 Location: Vernon, California



Tag Name: U1_CO_3HrRoll_Ppmvdc_1H
Total Operating Time: 903.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,281.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	903.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:30 **Location:** Vernon, California
Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:30 **Location:** Vernon, California
Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

--

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station

Generated: 07/06/2023 23:32 Location: Vernon, California

Tag Name: U2_NOxRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station
Generated: 07/06/2023 23:32 **Location:** Vernon, California
Tag Name: U2_NOxRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

--

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station

Generated: 07/06/2023 23:33 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

Unit Operation					
----------------	--	--	--	--	--

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 04/01/2023 00:00 **To:** 06/30/2023 23:59 **Facility Name:** Malburg Generating Station

Generated: 07/06/2023 23:33 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 684.47 Hours
Non-Operating Time: 1,499.53 Hours Report Time: 2,184.00 Hours

--

No invalid events were found in the reporting period.

Excess Emission Report

Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:33 Location: Vernon, California



Tag Name: U2_CONormal_Ppmvdc_1H
Total Operating Time: 691.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,493.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	691.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:34 Location: Vernon, California



Tag Name: U2_NOxNormal_Ppmvdc_1H
Total Operating Time: 691.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,493.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	691.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:34 Location: Vernon, California



Tag Name: U2_VOCNormal_Ppmvdc_1H
Total Operating Time: 691.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,493.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	691.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:35 Location: Vernon, California



Tag Name: U2_NOx4H_Ppmvdc_1H
Total Operating Time: 691.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,493.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	691.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 04/01/2023 00:00 To: 06/30/2023 23:59 Facility Name: Malburg Generating Station
Generated: 07/06/2023 23:36 Location: Vernon, California



Tag Name: U2_CO_3HrRoll_Ppmvdc_1H
Total Operating Time: 691.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,493.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	691.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %