

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	252875-4
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2023 - Part IV
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/31/2023 4:28:41 PM
Docketed Date:	10/31/2023

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2023 16:00	0	11.5	15.9	15.8	0.4	827,830.5	0.67	0.67
07/14/2023 17:00	0	1.7	7.9	14.4	8.7	910,140.5	0.08	1.00
07/14/2023 18:00	1	1.8	12.6	12.6	25.4	1,010,899.2	0.00	1.00
07/14/2023 19:00	1	2.3	13.5	11.9	30.5	981,573.0	0.00	1.00
07/14/2023 20:00	1	2.3	13.0	12.0	29.9	982,600.5	0.00	1.00
07/14/2023 21:00	1	2.1	12.3	12.6	24.8	1,014,694.0	0.00	1.00
07/14/2023 22:00	0	2.0	11.3	13.0	20.6	1,011,120.6	0.00	1.00
07/14/2023 23:00	0	1.6	7.3	14.4	6.9	924,045.4	0.00	1.00
Average/Sum#:	1	3.2	11.7	13.3	18.4	957,863.0	0.75 #	7.67 #
Minimum:	0	1.6	7.3	11.9	0.4	827,830.5	0.00	0.00
Maximum:	1	11.5	15.9	15.8	30.5	1,014,694.0	0.67	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2023 00:00	0	1.7	7.4	14.5	12.0	1,012,732.1	0.00	1.00
07/15/2023 01:00	0	1.6	7.4	14.5	10.8	976,784.7	0.00	1.00
07/15/2023 02:00	0	1.7	7.3	14.5	11.1	965,016.2	0.00	1.00
07/15/2023 03:00	0	1.6	7.3	14.5	11.8	993,046.7	0.00	1.00
07/15/2023 04:00	0	1.6	7.3	14.5	11.7	998,182.0	0.00	1.00
07/15/2023 05:00	0	1.6	7.2	14.5	11.4	999,465.8	0.00	1.00
07/15/2023 06:00	0	1.7	7.5	14.4	10.6	908,876.4	0.00	1.00
07/15/2023 07:00	0	1.7	7.5	14.3	9.3	799,660.8	0.00	1.00
07/15/2023 08:00	0	1.7	7.5	14.4	8.6	810,488.6	0.00	1.00
07/15/2023 09:00	0	1.7	7.2	14.4	5.6	808,171.1	0.00	1.00
07/15/2023 10:00	0	1.7	7.2	14.5	7.9	819,087.0	0.00	1.00
07/15/2023 11:00	0	1.6	7.0	14.5	5.9	817,589.2	0.00	1.00
07/15/2023 12:00	0	1.6	6.8	14.5	6.4	887,986.1	0.00	1.00
07/15/2023 13:00	0	1.6	6.6	14.5	8.7	957,313.2	0.00	1.00
07/15/2023 14:00	0	1.6	6.9	14.6	9.1	911,428.0	0.00	1.00
07/15/2023 15:00	0	1.9	8.7	13.6	15.6	862,549.8	0.00	1.00
07/15/2023 16:00	1	2.3	11.6	12.0	30.0	970,291.0	0.00	1.00
07/15/2023 17:00	1	2.3	11.4	11.9	29.5	950,076.2	0.00	1.00
07/15/2023 18:00	1	2.3	11.4	11.9	30.1	946,728.7	0.00	1.00
07/15/2023 19:00	1	2.3	11.6	11.9	30.5	950,684.8	0.00	1.00
07/15/2023 20:00	1	2.3	11.7	11.9	31.0	971,074.0	0.00	1.00
07/15/2023 21:00	1	2.3	11.8	11.9	31.2	988,267.9	0.00	1.00
07/15/2023 22:00	1	2.2	11.5	12.2	27.7	999,994.6	0.00	1.00
07/15/2023 23:00	0	1.9	9.6	13.4	16.6	1,016,478.1	0.00	1.00
Average/Sum#:	0	1.9	8.6	13.7	16.0	930,082.2	0.00 #	24.00 #
Minimum:	0	1.6	6.6	11.9	5.6	799,660.8	0.00	1.00
Maximum:	1	2.3	11.8	14.6	31.2	1,016,478.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2023 00:00	0	1.7	7.2	14.4	11.3	998,626.4	0.00	1.00
07/16/2023 01:00	0	1.6	7.0	14.5	11.5	1,014,443.9	0.00	1.00
07/16/2023 02:00	0	1.6	7.1	14.5	11.5	1,019,579.2	0.00	1.00
07/16/2023 03:00	0	1.6	7.0	14.5	10.8	1,017,439.5	0.00	1.00
07/16/2023 04:00	0	1.6	6.7	14.5	10.2	1,003,959.3	0.00	1.00
07/16/2023 05:00	0	1.6	6.7	14.5	10.9	1,021,077.1	0.00	1.00
07/16/2023 06:00	0	1.6	6.9	14.4	8.6	897,289.0	0.00	1.00
07/16/2023 07:00	0	1.7	6.7	14.3	0.9	797,793.4	0.00	1.00
07/16/2023 08:00	0	1.7	6.6	14.3	0.9	797,793.4	0.00	1.00
07/16/2023 09:00	0	1.7	6.9	14.4	6.4	808,171.1	0.00	1.00
07/16/2023 10:00	0	1.6	6.7	14.6	9.1	922,948.6	0.00	1.00
07/16/2023 11:00	0	1.6	6.9	14.6	10.2	949,684.9	0.00	1.00
07/16/2023 12:00	0	1.6	6.9	14.5	9.5	896,117.1	0.00	1.00
07/16/2023 13:00	0	1.6	6.5	14.5	9.6	950,038.2	0.00	1.00
07/16/2023 14:00	1	2.3	10.9	12.3	26.5	1,008,915.5	0.00	1.00
07/16/2023 15:00	1	2.3	11.4	11.8	31.3	996,068.1	0.00	1.00
07/16/2023 16:00	1	2.3	11.4	11.9	32.0	1,002,723.0	0.00	1.00
07/16/2023 17:00	1	2.3	11.5	11.9	32.6	1,005,918.3	0.00	1.00
07/16/2023 18:00	1	2.3	11.4	11.9	31.7	997,245.3	0.00	1.00
07/16/2023 19:00	1	2.3	11.4	11.9	31.3	1,002,266.5	0.00	1.00
07/16/2023 20:00	1	2.0	10.4	12.8	22.2	1,023,517.9	0.00	1.00
07/16/2023 21:00	1	2.0	10.5	12.9	20.8	1,020,563.5	0.00	1.00
07/16/2023 22:00	0	1.6	6.6	14.4	7.1	944,481.5	0.00	1.00
07/16/2023 23:00	0	1.6	6.6	14.4	5.9	876,220.9	0.00	1.00
Average/Sum#:	0	1.8	8.2	13.7	15.1	957,203.4	0.00 #	24.00 #
Minimum:	0	1.6	6.5	11.8	0.9	797,793.4	0.00	1.00
Maximum:	1	2.3	11.5	14.6	32.6	1,023,517.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2023 00:00	0	1.7	6.4	14.5	9.8	990,693.0	0.00	1.00
07/17/2023 01:00	0	1.6	7.1	14.6	11.9	996,854.0	0.00	1.00
07/17/2023 02:00	0	1.6	7.3	14.5	8.8	867,444.8	0.00	1.00
07/17/2023 03:00	0	1.7	7.2	14.4	7.5	813,227.4	0.00	1.00
07/17/2023 04:00	0	1.6	7.1	14.4	6.9	824,604.2	0.00	1.00
07/17/2023 05:00	0	1.6	6.8	14.6	9.8	984,464.0	0.00	1.00
07/17/2023 06:00	0	1.6	7.2	14.5	11.3	1,008,452.7	0.00	1.00
07/17/2023 07:00	0	1.6	7.6	14.3	6.5	815,845.0	0.00	1.00
07/17/2023 08:00	0	1.7	7.4	14.4	7.7	809,856.5	0.00	1.00
07/17/2023 09:00	0	1.7	7.5	14.4	8.8	807,539.0	0.00	1.00
07/17/2023 10:00	0	1.6	7.2	14.6	9.6	945,337.6	0.00	1.00
07/17/2023 11:00	0	1.6	7.1	14.5	9.6	973,789.1	0.00	1.00
07/17/2023 12:00	0	1.6	7.1	14.5	7.2	958,169.1	0.00	1.00
07/17/2023 13:00	0	1.6	7.3	14.5	11.3	1,008,666.6	0.00	1.00
07/17/2023 14:00	0	1.6	7.2	14.5	11.4	1,003,745.3	0.00	1.00
07/17/2023 15:00	0	1.8	8.7	13.8	16.1	956,475.4	0.00	1.00
07/17/2023 16:00	1	2.3	12.1	12.0	30.6	1,009,835.1	0.00	1.00
07/17/2023 17:00	0	1.9	10.5	13.3	18.3	1,019,860.8	0.00	1.00
07/17/2023 18:00	0	1.6	7.2	14.5	9.4	996,042.3	0.00	1.00
07/17/2023 19:00	0	1.6	7.0	14.6	10.5	999,245.1	0.00	1.00
07/17/2023 20:00	0	1.6	6.9	14.6	10.5	1,017,721.4	0.00	1.00
07/17/2023 21:00	0	1.6	6.9	14.5	11.3	1,013,588.0	0.00	1.00
07/17/2023 22:00	0	1.6	6.9	14.5	11.0	1,002,033.5	0.00	1.00
07/17/2023 23:00	0	1.6	7.0	14.5	11.0	996,470.2	0.00	1.00
Average/Sum#:	0	1.7	7.5	14.3	11.1	950,831.7	0.00 #	24.00 #
Minimum:	0	1.6	6.4	12.0	6.5	807,539.0	0.00	1.00
Maximum:	1	2.3	12.1	14.6	30.6	1,019,860.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2023 00:00	0	1.6	8.0	14.5	14.6	1,050,177.3	0.00	1.00
07/18/2023 01:00	0	1.6	8.0	14.5	14.2	1,052,745.0	0.00	1.00
07/18/2023 02:00	0	1.6	7.6	14.5	12.5	1,031,775.7	0.00	1.00
07/18/2023 03:00	0	1.7	7.4	14.5	11.8	1,009,308.6	0.00	1.00
07/18/2023 04:00	0	1.6	8.1	14.5	14.4	1,059,806.1	0.00	1.00
07/18/2023 05:00	0	1.6	8.2	14.5	14.7	1,067,509.1	0.00	1.00
07/18/2023 06:00	0	1.6	7.9	14.5	14.1	1,066,011.3	0.00	1.00
07/18/2023 07:00	0	1.6	7.6	14.4	9.3	889,072.4	0.00	1.00
07/18/2023 08:00	0	1.7	7.5	14.4	9.3	826,078.9	0.00	1.00
07/18/2023 09:00	0	1.7	7.3	14.5	9.4	895,261.2	0.00	1.00
07/18/2023 10:00	0	1.6	7.4	14.6	12.0	1,012,287.2	0.00	1.00
07/18/2023 11:00	0	1.6	7.6	14.5	11.9	1,031,561.7	0.00	1.00
07/18/2023 12:00	0	1.6	7.5	14.5	12.1	1,035,413.2	0.00	1.00
07/18/2023 13:00	0	1.6	7.5	14.5	12.0	1,029,422.0	0.00	1.00
07/18/2023 14:00	0	1.7	7.7	14.4	12.7	1,017,587.7	0.00	1.00
07/18/2023 15:00	1	2.0	11.0	13.0	22.2	1,033,482.0	0.00	1.00
07/18/2023 16:00	0	1.9	10.8	13.2	19.2	1,027,779.7	0.00	1.00
07/18/2023 17:00	0	1.9	9.5	13.6	16.7	1,027,068.3	0.00	1.00
07/18/2023 18:00	1	2.0	11.0	13.0	22.7	1,037,989.0	0.00	1.00
07/18/2023 19:00	1	2.3	13.2	12.0	32.3	1,046,763.4	0.00	1.00
07/18/2023 20:00	1	2.1	12.4	12.5	26.5	1,046,957.5	0.00	1.00
07/18/2023 21:00	1	2.1	12.3	12.7	25.3	1,059,967.9	0.00	1.00
07/18/2023 22:00	0	2.0	11.3	13.1	22.1	1,062,708.4	0.00	1.00
07/18/2023 23:00	0	1.9	10.5	13.4	19.8	1,057,560.8	0.00	1.00
Average/Sum#:	0	1.8	9.1	13.9	16.3	1,019,762.3	0.00 #	24.00 #
Minimum:	0	1.6	7.3	12.0	9.3	826,078.9	0.00	1.00
Maximum:	1	2.3	13.2	14.6	32.3	1,067,509.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2023 00:00	0	1.6	7.7	14.4	12.5	1,035,074.2	0.00	1.00
07/19/2023 01:00	0	1.6	7.4	14.5	12.2	1,029,422.0	0.00	1.00
07/19/2023 02:00	0	1.6	7.4	14.4	12.1	986,828.3	0.00	1.00
07/19/2023 03:00	0	1.6	7.3	14.4	10.7	956,490.3	0.00	1.00
07/19/2023 04:00	0	1.7	7.3	14.4	12.3	993,359.4	0.00	1.00
07/19/2023 05:00	0	1.6	7.5	14.5	13.0	1,041,832.4	0.00	1.00
07/19/2023 06:00	0	1.6	7.5	14.5	13.1	1,044,186.1	0.00	1.00
07/19/2023 07:00	0	1.7	7.5	14.4	10.7	929,312.5	0.00	1.00
07/19/2023 08:00	0	1.7	7.4	14.3	9.5	838,046.2	0.00	1.00
07/19/2023 09:00	0	1.6	7.1	14.4	8.6	906,558.9	0.00	1.00
07/19/2023 10:00	0	1.6	7.2	14.4	8.3	877,695.7	0.00	1.00
07/19/2023 11:00	0	1.6	7.2	14.5	11.4	989,409.1	0.00	1.00
07/19/2023 12:00	0	1.6	7.3	14.5	10.9	1,029,849.9	0.00	1.00
07/19/2023 13:00	0	1.8	8.8	14.0	15.2	998,489.0	0.00	1.00
07/19/2023 14:00	1	2.2	12.7	12.4	27.2	1,045,595.8	0.00	1.00
07/19/2023 15:00	1	2.3	12.7	12.1	30.1	1,030,803.1	0.00	1.00
07/19/2023 16:00	1	2.2	12.7	12.2	30.0	1,036,197.8	0.00	1.00
07/19/2023 17:00	1	2.2	12.9	12.3	29.0	1,033,596.9	0.00	1.00
07/19/2023 18:00	1	2.2	13.2	12.2	31.0	1,043,438.4	0.00	1.00
07/19/2023 19:00	1	2.3	13.2	12.0	33.0	1,046,763.4	0.00	1.00
07/19/2023 20:00	1	2.3	13.3	12.0	32.9	1,048,917.5	0.00	1.00
07/19/2023 21:00	1	2.2	13.2	12.3	30.1	1,056,686.1	0.00	1.00
07/19/2023 22:00	1	2.1	12.7	12.5	27.0	1,052,500.5	0.00	1.00
07/19/2023 23:00	0	2.0	11.0	13.2	21.1	1,054,278.9	0.00	1.00
Average/Sum#:	0	1.9	9.7	13.5	18.8	1,004,388.9	0.00 #	24.00 #
Minimum:	0	1.6	7.1	12.0	8.3	838,046.2	0.00	1.00
Maximum:	1	2.3	13.3	14.5	33.0	1,056,686.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2023 00:00	0	1.7	7.7	14.4	13.1	1,033,388.7	0.00	1.00
07/20/2023 01:00	0	1.6	7.1	14.5	12.5	1,011,662.3	0.00	1.00
07/20/2023 02:00	0	1.5	7.6	14.5	13.6	1,020,649.1	0.00	1.00
07/20/2023 03:00	0	1.6	7.3	14.5	12.4	1,007,596.8	0.00	1.00
07/20/2023 04:00	0	1.6	7.6	14.5	14.4	1,038,194.9	0.00	1.00
07/20/2023 05:00	0	1.6	7.7	14.5	14.2	1,045,256.0	0.00	1.00
07/20/2023 06:00	0	1.6	7.8	14.5	13.9	1,030,063.9	0.00	1.00
07/20/2023 07:00	0	1.7	7.4	14.3	10.8	834,311.4	0.00	1.00
07/20/2023 08:00	0	1.7	7.2	14.3	8.3	803,603.1	0.00	1.00
07/20/2023 09:00	0	1.6	7.0	14.4	7.2	829,028.5	0.00	1.00
07/20/2023 10:00	0	1.6	7.0	14.5	9.2	901,252.4	0.00	1.00
07/20/2023 11:00	0	1.6	7.2	14.6	11.6	985,116.1	0.00	1.00
07/20/2023 12:00	0	1.6	7.4	14.5	11.8	1,030,063.9	0.00	1.00
07/20/2023 13:00	0	1.6	7.4	14.5	12.1	1,026,640.3	0.00	1.00
07/20/2023 14:00	0	1.6	7.3	14.5	11.5	1,020,221.2	0.00	1.00
07/20/2023 15:00	1	2.1	10.6	13.1	23.2	1,003,191.1	0.00	1.00
07/20/2023 16:00	1	2.1	13.3	12.4	30.4	1,044,145.8	0.00	1.00
07/20/2023 17:00	1	2.2	13.4	12.4	30.0	1,040,118.1	0.00	1.00
07/20/2023 18:00	1	2.3	13.1	12.1	32.2	1,034,849.1	0.00	1.00
07/20/2023 19:00	1	2.3	12.9	11.9	34.4	1,037,110.7	0.00	1.00
07/20/2023 20:00	1	2.1	12.6	12.3	28.6	1,028,979.1	0.00	1.00
07/20/2023 21:00	1	2.1	12.5	12.7	25.2	1,038,758.5	0.00	1.00
07/20/2023 22:00	0	2.0	11.0	13.2	20.4	1,039,339.8	0.00	1.00
07/20/2023 23:00	0	1.7	8.9	13.9	13.9	970,335.0	0.00	1.00
Average/Sum#:	0	1.8	9.1	13.8	17.3	993,911.5	0.00 #	24.00 #
Minimum:	0	1.5	7.0	11.9	7.2	803,603.1	0.00	1.00
Maximum:	1	2.3	13.4	14.6	34.4	1,045,256.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2023 00:00	0	1.6	6.8	14.5	10.9	1,018,295.4	0.00	1.00
07/21/2023 01:00	0	1.6	6.8	14.5	11.3	1,017,653.5	0.00	1.00
07/21/2023 02:00	0	1.6	7.1	14.5	11.2	971,221.4	0.00	1.00
07/21/2023 03:00	0	1.6	7.1	14.5	11.0	948,540.4	0.00	1.00
07/21/2023 04:00	0	1.6	7.1	14.5	11.4	968,867.8	0.00	1.00
07/21/2023 05:00	0	1.6	7.1	14.5	11.3	962,448.6	0.00	1.00
07/21/2023 06:00	0	1.6	7.7	14.4	12.3	949,116.4	0.00	1.00
07/21/2023 07:00	0	1.7	7.2	14.4	9.2	833,663.4	0.00	1.00
07/21/2023 08:00	0	1.7	7.0	14.4	7.6	813,438.1	0.00	1.00
07/21/2023 09:00	0	1.7	7.0	14.4	7.5	812,806.0	0.00	1.00
07/21/2023 10:00	0	1.6	7.1	14.5	9.3	823,580.4	0.00	1.00
07/21/2023 11:00	0	1.6	7.0	14.5	8.7	914,304.7	0.00	1.00
07/21/2023 12:00	0	1.6	6.9	14.5	7.0	902,108.3	0.00	1.00
07/21/2023 13:00	0	1.6	6.8	14.5	7.7	990,265.0	0.00	1.00
07/21/2023 14:00	0	1.8	8.7	13.9	14.7	974,052.0	0.00	1.00
07/21/2023 15:00	1	2.1	11.6	12.7	25.6	1,034,082.4	0.00	1.00
07/21/2023 16:00	0	2.0	11.1	13.1	21.4	1,028,648.4	0.00	1.00
07/21/2023 17:00	0	1.9	9.9	13.4	18.0	1,012,461.1	0.00	1.00
07/21/2023 18:00	1	2.0	10.5	13.0	21.3	1,010,427.2	0.00	1.00
07/21/2023 19:00	1	2.3	11.7	11.9	30.8	1,009,874.4	0.00	1.00
07/21/2023 20:00	1	2.0	10.8	12.7	22.5	1,013,708.1	0.00	1.00
07/21/2023 21:00	0	1.9	9.3	13.5	16.4	1,020,961.4	0.00	1.00
07/21/2023 22:00	0	1.9	10.0	13.3	18.4	1,022,203.2	0.00	1.00
07/21/2023 23:00	0	1.9	9.4	13.5	17.0	1,023,182.1	0.00	1.00
Average/Sum#:	0	1.8	8.4	13.9	14.3	961,496.2	0.00 #	24.00 #
Minimum:	0	1.6	6.8	11.9	7.0	812,806.0	0.00	1.00
Maximum:	1	2.3	11.7	14.5	30.8	1,034,082.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2023 00:00	0	1.6	6.9	14.5	10.9	1,010,806.4	0.00	1.00
07/22/2023 01:00	0	1.6	7.2	14.6	11.6	985,116.1	0.00	1.00
07/22/2023 02:00	0	1.7	7.3	14.4	9.4	851,992.6	0.00	1.00
07/22/2023 03:00	0	1.6	7.3	14.4	9.6	857,049.0	0.00	1.00
07/22/2023 04:00	0	1.7	7.1	14.4	9.8	817,230.3	0.00	1.00
07/22/2023 05:00	0	1.7	7.2	14.4	9.9	860,630.6	0.00	1.00
07/22/2023 06:00	0	1.7	7.2	14.4	10.1	860,419.9	0.00	1.00
07/22/2023 07:00	0	1.7	6.9	14.4	9.3	810,488.6	0.00	1.00
07/22/2023 08:00	0	1.7	6.9	14.4	6.8	809,224.5	0.00	1.00
07/22/2023 09:00	0	1.7	7.0	14.4	8.4	808,381.7	0.00	1.00
07/22/2023 10:00	0	1.6	7.0	14.5	8.3	818,873.0	0.00	1.00
07/22/2023 11:00	0	1.6	6.9	14.5	4.9	829,785.6	0.00	1.00
07/22/2023 12:00	0	1.6	7.2	14.6	8.3	901,646.4	0.00	1.00
07/22/2023 13:00	0	1.6	6.9	14.6	8.3	914,688.5	0.00	1.00
07/22/2023 14:00	0	1.6	6.9	14.6	11.1	1,016,634.6	0.00	1.00
07/22/2023 15:00	0	1.6	6.8	14.6	11.1	1,005,766.1	0.00	1.00
07/22/2023 16:00	0	1.6	7.0	14.6	12.7	1,016,199.8	0.00	1.00
07/22/2023 17:00	1	2.0	10.2	13.3	20.1	988,508.2	0.00	1.00
07/22/2023 18:00	1	2.2	11.6	12.3	27.2	1,005,890.0	0.00	1.00
07/22/2023 19:00	1	2.3	11.8	11.9	31.0	1,007,744.2	0.00	1.00
07/22/2023 20:00	0	2.0	10.5	13.0	20.0	1,012,334.0	0.00	1.00
07/22/2023 21:00	0	2.0	10.6	13.1	20.1	1,019,870.0	0.00	1.00
07/22/2023 22:00	0	2.0	10.2	13.2	19.1	1,014,974.7	0.00	1.00
07/22/2023 23:00	0	1.7	7.6	14.2	10.7	981,080.2	0.00	1.00
Average/Sum#:	0	1.8	8.0	14.1	12.9	925,222.3	0.00 #	24.00 #
Minimum:	0	1.6	6.8	11.9	4.9	808,381.7	0.00	1.00
Maximum:	1	2.3	11.8	14.6	31.0	1,019,870.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2023 00:00	0	1.6	6.9	14.5	10.7	1,017,653.5	0.00	1.00
07/23/2023 01:00	0	1.6	6.7	14.5	10.9	1,017,653.5	0.00	1.00
07/23/2023 02:00	0	1.6	6.9	14.5	11.0	1,016,583.6	0.00	1.00
07/23/2023 03:00	0	1.6	6.9	14.5	11.4	1,018,723.4	0.00	1.00
07/23/2023 04:00	0	1.6	6.8	14.5	11.3	1,015,299.8	0.00	1.00
07/23/2023 05:00	0	1.7	6.8	14.4	10.5	957,543.7	0.00	1.00
07/23/2023 06:00	0	1.7	6.9	14.4	10.3	918,778.4	0.00	1.00
07/23/2023 07:00	0	1.7	6.9	14.4	8.4	821,443.9	0.00	1.00
07/23/2023 08:00	0	1.6	7.0	14.5	9.9	934,846.1	0.00	1.00
07/23/2023 09:00	0	1.6	6.8	14.6	10.5	1,039,023.6	0.00	1.00
07/23/2023 10:00	0	1.6	6.8	14.6	11.1	1,037,719.4	0.00	1.00
07/23/2023 11:00	0	1.6	6.9	14.6	11.2	1,035,763.0	0.00	1.00
07/23/2023 12:00	0	1.8	8.7	13.9	15.2	981,094.8	0.00	1.00
07/23/2023 13:00	0	1.9	9.7	13.4	16.6	1,023,416.5	0.00	1.00
07/23/2023 14:00	0	1.7	8.1	14.0	12.5	979,634.6	0.00	1.00
07/23/2023 15:00	0	1.6	6.8	14.5	10.0	1,003,531.3	0.00	1.00
07/23/2023 16:00	0	1.7	7.6	14.2	13.3	979,445.0	0.00	1.00
07/23/2023 17:00	1	2.3	12.3	12.0	31.4	1,024,606.4	0.00	1.00
07/23/2023 18:00	0	1.9	10.7	13.1	18.9	980,016.3	0.00	1.00
07/23/2023 19:00	0	1.5	6.6	14.6	5.1	994,245.6	0.00	1.00
07/23/2023 20:00	0	1.6	7.0	14.6	9.6	973,378.2	0.00	1.00
07/23/2023 21:00	0	1.6	7.1	14.6	11.5	999,462.4	0.00	1.00
07/23/2023 22:00	0	1.6	7.4	14.6	12.1	980,768.7	0.00	1.00
07/23/2023 23:00	0	1.6	7.1	14.5	9.0	924,575.4	0.00	1.00
Average/Sum#:	0	1.7	7.6	14.3	12.2	986,467.0	0.00 #	24.00 #
Minimum:	0	1.5	6.6	12.0	5.1	821,443.9	0.00	1.00
Maximum:	1	2.3	12.3	14.6	31.4	1,039,023.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2023 00:00	0	1.6	7.7	14.6	13.4	1,050,326.8	0.00	1.00
07/24/2023 01:00	0	1.6	7.3	14.5	12.7	1,015,727.7	0.00	1.00
07/24/2023 02:00	0	1.8	7.3	14.5	11.0	971,221.4	0.00	1.00
07/24/2023 03:00	0	1.6	7.2	14.5	11.9	985,985.6	0.00	1.00
07/24/2023 04:00	0	1.6	7.2	14.5	12.5	1,019,151.3	0.00	1.00
07/24/2023 05:00	0	1.6	7.2	14.5	12.1	1,019,365.3	0.00	1.00
07/24/2023 06:00	0	1.6	7.3	14.5	13.0	1,029,636.0	0.00	1.00
07/24/2023 07:00	0	1.7	7.4	14.4	10.3	881,066.6	0.00	1.00
07/24/2023 08:00	0	1.7	7.2	14.4	9.1	833,663.4	0.00	1.00
07/24/2023 09:00	0	1.7	7.1	14.4	7.0	814,280.8	0.00	1.00
07/24/2023 10:00	0	1.7	7.1	14.4	6.4	822,076.0	0.00	1.00
07/24/2023 11:00	0	1.6	7.1	14.4	5.5	823,550.8	0.00	1.00
07/24/2023 12:00	0	1.6	7.0	14.5	7.0	907,029.7	0.00	1.00
07/24/2023 13:00	0	1.6	7.4	14.5	11.4	1,028,352.1	0.00	1.00
07/24/2023 14:00	0	1.6	6.6	14.3	1.2	806,508.0	0.00	1.00
07/24/2023 15:00	0	1.7	6.9	14.5	6.0	821,654.6	0.00	1.00
07/24/2023 16:00	0	1.6	7.1	14.5	9.2	819,087.0	0.00	1.00
07/24/2023 17:00	0	1.6	6.9	14.5	7.8	819,087.0	0.00	1.00
07/24/2023 18:00	0	1.6	6.8	14.4	5.0	809,013.8	0.00	1.00
07/24/2023 19:00	0	1.7	6.6	14.3	3.7	815,222.5	0.00	1.00
07/24/2023 20:00	0	1.7	6.6	14.3	3.0	810,657.7	0.00	1.00
07/24/2023 21:00	0	1.7	6.8	14.4	8.8	918,989.1	0.00	1.00
07/24/2023 22:00	0	1.7	7.0	14.4	9.9	913,090.0	0.00	1.00
07/24/2023 23:00	0	1.7	6.9	14.4	10.8	948,273.7	0.00	1.00
Average/Sum#:	0	1.7	7.1	14.4	8.7	903,459.0	0.00 #	24.00 #
Minimum:	0	1.6	6.6	14.3	1.2	806,508.0	0.00	1.00
Maximum:	0	1.8	7.7	14.6	13.4	1,050,326.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2023 00:00	0	1.7	7.0	14.4	10.7	893,286.1	0.00	1.00
07/25/2023 01:00	0	1.7	7.2	14.3	10.3	808,167.9	0.00	1.00
07/25/2023 02:00	0	1.7	7.6	14.4	10.9	814,070.1	0.00	1.00
07/25/2023 03:00	0	1.7	7.6	14.3	11.0	801,943.2	0.00	1.00
07/25/2023 04:00	0	1.7	7.5	14.3	10.9	802,980.7	0.00	1.00
07/25/2023 05:00	0	1.7	7.4	14.4	10.9	877,695.7	0.00	1.00
07/25/2023 06:00	0	1.7	7.3	14.4	11.5	894,128.8	0.00	1.00
07/25/2023 07:00	0	1.7	7.4	14.3	10.3	817,089.9	0.00	1.00
07/25/2023 08:00	0	1.7	7.2	14.3	9.3	848,213.2	0.00	1.00
07/25/2023 09:00	0	1.7	7.1	14.3	9.0	804,018.1	0.00	1.00
07/25/2023 10:00	0	1.6	6.8	14.3	5.4	817,712.3	0.00	1.00
07/25/2023 11:00	0	1.7	7.0	14.3	1.9	802,980.7	0.00	1.00
07/25/2023 12:00	0	1.6	6.7	14.5	7.3	952,391.9	0.00	1.00
07/25/2023 13:00	0	1.6	6.5	14.5	6.0	964,374.3	0.00	1.00
07/25/2023 14:00	0	1.6	6.5	14.5	9.6	1,014,016.0	0.00	1.00
07/25/2023 15:00	0	1.6	6.5	14.5	7.7	966,728.0	0.00	1.00
07/25/2023 16:00	0	1.7	8.0	14.2	13.2	1,006,833.5	0.00	1.00
07/25/2023 17:00	0	1.9	10.5	13.3	18.4	1,032,113.5	0.00	1.00
07/25/2023 18:00	0	2.0	10.6	13.2	20.6	1,038,806.2	0.00	1.00
07/25/2023 19:00	1	2.3	13.2	12.1	32.3	1,050,877.6	0.00	1.00
07/25/2023 20:00	1	2.1	12.4	12.6	25.2	1,044,227.3	0.00	1.00
07/25/2023 21:00	0	1.9	10.2	13.4	18.0	1,042,223.3	0.00	1.00
07/25/2023 22:00	0	1.8	9.6	13.6	17.6	1,043,764.0	0.00	1.00
07/25/2023 23:00	0	1.6	6.9	14.5	10.2	1,009,522.5	0.00	1.00
Average/Sum#:	0	1.8	8.1	14.0	12.4	922,840.2	0.00 #	24.00 #
Minimum:	0	1.6	6.5	12.1	1.9	801,943.2	0.00	1.00
Maximum:	1	2.3	13.2	14.5	32.3	1,050,877.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2023 00:00	0	1.6	7.2	14.5	12.5	1,048,037.6	0.00	1.00
07/26/2023 01:00	0	1.7	6.7	14.4	10.3	962,389.3	0.00	1.00
07/26/2023 02:00	0	1.6	7.0	14.4	11.0	971,870.0	0.00	1.00
07/26/2023 03:00	0	1.6	6.9	14.5	11.8	996,898.2	0.00	1.00
07/26/2023 04:00	0	1.6	6.9	14.5	11.9	996,470.2	0.00	1.00
07/26/2023 05:00	0	1.6	7.5	14.5	13.8	1,041,832.4	0.00	1.00
07/26/2023 06:00	0	1.6	7.3	14.5	13.1	1,028,566.1	0.00	1.00
07/26/2023 07:00	0	1.6	7.1	14.5	10.8	954,531.6	0.00	1.00
07/26/2023 08:00	0	1.6	7.0	14.5	9.6	943,405.0	0.00	1.00
07/26/2023 09:00	0	1.6	6.9	14.5	11.2	1,005,457.1	0.00	1.00
07/26/2023 10:00	0	1.6	7.1	14.5	12.0	1,023,644.7	0.00	1.00
07/26/2023 11:00	0	1.6	7.2	14.5	11.8	1,040,548.6	0.00	1.00
07/26/2023 12:00	0	1.7	7.2	14.3	11.1	996,360.0	0.00	1.00
07/26/2023 13:00	1	2.3	12.6	12.2	29.2	1,041,864.4	0.00	1.00
07/26/2023 14:00	1	2.2	12.9	12.2	30.0	1,044,382.8	0.00	1.00
07/26/2023 15:00	1	2.1	12.9	12.5	27.4	1,048,424.8	0.00	1.00
07/26/2023 16:00	1	2.2	13.1	12.3	29.0	1,037,737.1	0.00	1.00
07/26/2023 17:00	1	2.2	12.9	12.3	28.9	1,039,010.9	0.00	1.00
07/26/2023 18:00	0	1.9	10.9	13.2	20.4	1,046,631.5	0.00	1.00
07/26/2023 19:00	1	2.1	12.8	12.5	27.2	1,047,772.7	0.00	1.00
07/26/2023 20:00	0	1.8	9.3	13.7	15.9	1,045,707.7	0.00	1.00
07/26/2023 21:00	0	1.9	9.8	13.4	18.6	1,046,422.8	0.00	1.00
07/26/2023 22:00	1	2.1	12.0	12.7	25.5	1,063,307.9	0.00	1.00
07/26/2023 23:00	0	1.9	10.4	13.3	20.4	1,060,583.1	0.00	1.00
Average/Sum#:	0	1.8	9.2	13.7	17.6	1,022,160.7	0.00 #	24.00 #
Minimum:	0	1.6	6.7	12.2	9.6	943,405.0	0.00	1.00
Maximum:	1	2.3	13.1	14.5	30.0	1,063,307.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2023 00:00	1	2.2	12.8	12.4	28.8	1,065,090.0	0.00	1.00
07/27/2023 01:00	0	1.7	8.4	14.0	14.2	1,004,443.0	0.00	1.00
07/27/2023 02:00	0	1.6	7.1	14.4	11.1	955,436.9	0.00	1.00
07/27/2023 03:00	0	1.7	7.2	14.4	10.3	879,381.1	0.00	1.00
07/27/2023 04:00	0	1.6	7.8	14.5	14.4	1,042,474.3	0.00	1.00
07/27/2023 05:00	0	1.6	8.0	14.5	15.7	1,061,731.8	0.00	1.00
07/27/2023 06:00	0	1.6	7.8	14.5	14.4	1,052,531.0	0.00	1.00
07/27/2023 07:00	0	1.7	7.5	14.3	10.4	832,444.0	0.00	1.00
07/27/2023 08:00	0	1.7	7.4	14.3	10.2	800,905.8	0.00	1.00
07/27/2023 09:00	0	1.7	7.3	14.3	9.1	800,283.3	0.00	1.00
07/27/2023 10:00	0	1.7	7.3	14.4	7.0	811,752.6	0.00	1.00
07/27/2023 11:00	0	1.7	7.1	14.4	6.1	837,455.7	0.00	1.00
07/27/2023 12:00	0	1.6	7.0	14.6	10.0	1,017,069.3	0.00	1.00
07/27/2023 13:00	0	1.6	6.7	14.5	10.0	1,014,443.9	0.00	1.00
07/27/2023 14:00	0	1.6	6.7	14.5	8.6	980,850.2	0.00	1.00
07/27/2023 15:00	0	1.6	6.6	14.5	6.8	963,732.4	0.00	1.00
07/27/2023 16:00	0	1.8	8.6	13.9	15.6	1,019,634.3	0.00	1.00
07/27/2023 17:00	0	1.8	9.2	13.7	16.8	1,041,903.7	0.00	1.00
07/27/2023 18:00	0	1.6	6.7	14.3	2.6	840,536.1	0.00	1.00
07/27/2023 19:00	0	1.7	6.8	14.4	4.0	813,648.8	0.00	1.00
07/27/2023 20:00	0	1.6	6.9	14.4	5.0	825,657.6	0.00	1.00
07/27/2023 21:00	0	1.7	6.9	14.4	6.1	811,331.3	0.00	1.00
07/27/2023 22:00	0	1.6	7.3	14.5	10.2	948,540.4	0.00	1.00
07/27/2023 23:00	0	1.6	7.3	14.6	11.7	1,018,808.3	0.00	1.00
Average/Sum#:	0	1.7	7.6	14.3	10.8	935,003.6	0.00 #	24.00 #
Minimum:	0	1.6	6.6	12.4	2.6	800,283.3	0.00	1.00
Maximum:	1	2.2	12.8	14.6	28.8	1,065,090.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2023 00:00	0	1.6	7.1	14.5	9.0	939,767.5	0.00	1.00
07/28/2023 01:00	0	1.6	7.3	14.5	11.9	985,129.7	0.00	1.00
07/28/2023 02:00	0	1.5	7.4	14.4	11.3	932,894.0	0.00	1.00
07/28/2023 03:00	0	1.7	7.3	14.4	10.5	918,146.4	0.00	1.00
07/28/2023 04:00	0	1.7	7.3	14.4	10.4	907,191.0	0.00	1.00
07/28/2023 05:00	0	1.7	7.2	14.4	11.2	952,276.6	0.00	1.00
07/28/2023 06:00	0	1.7	7.2	14.4	12.2	936,264.9	0.00	1.00
07/28/2023 07:00	0	1.7	7.7	14.3	11.4	837,423.8	0.00	1.00
07/28/2023 08:00	0	1.7	7.6	14.3	10.5	802,150.7	0.00	1.00
07/28/2023 09:00	0	1.7	7.5	14.3	10.3	801,735.7	0.00	1.00
07/28/2023 10:00	0	1.7	7.5	14.4	9.3	812,384.7	0.00	1.00
07/28/2023 11:00	0	1.6	7.3	14.4	7.2	811,963.3	0.00	1.00
07/28/2023 12:00	0	1.7	7.2	14.4	5.3	818,283.7	0.00	1.00
07/28/2023 13:00	0	1.6	6.6	14.5	7.6	983,203.9	0.00	1.00
07/28/2023 14:00	0	1.6	6.9	14.4	2.9	813,648.8	0.00	1.00
07/28/2023 15:00	0	1.7	7.3	14.3	6.6	915,232.0	0.00	1.00
07/28/2023 16:00	0	1.8	9.8	13.7	17.0	1,035,627.2	0.00	1.00
07/28/2023 17:00	0	1.8	9.9	13.7	16.7	1,033,915.4	0.00	1.00
07/28/2023 18:00	0	1.8	9.9	13.8	16.9	1,047,513.2	0.00	1.00
07/28/2023 19:00	0	1.8	9.9	13.8	16.7	1,043,077.1	0.00	1.00
07/28/2023 20:00	0	1.6	7.3	14.4	7.0	846,093.6	0.00	1.00
07/28/2023 21:00	0	1.6	7.4	14.5	9.7	868,728.6	0.00	1.00
07/28/2023 22:00	0	1.6	7.4	14.6	11.0	958,597.1	0.00	1.00
07/28/2023 23:00	0	1.6	7.5	14.6	12.1	1,012,287.2	0.00	1.00
Average/Sum#:	0	1.7	7.7	14.3	10.6	917,230.7	0.00 #	24.00 #
Minimum:	0	1.5	6.6	13.7	2.9	801,735.7	0.00	1.00
Maximum:	0	1.8	9.9	14.6	17.0	1,047,513.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2023 00:00	0	1.6	7.3	14.4	11.4	982,614.7	0.00	1.00
07/29/2023 01:00	0	1.7	7.5	14.3	9.4	825,804.4	0.00	1.00
07/29/2023 02:00	0	1.6	7.5	14.4	9.5	837,455.7	0.00	1.00
07/29/2023 03:00	0	1.7	7.7	14.4	10.2	839,983.8	0.00	1.00
07/29/2023 04:00	0	1.7	7.8	14.3	10.5	803,395.6	0.00	1.00
07/29/2023 05:00	0	1.7	7.7	14.3	9.9	806,922.9	0.00	1.00
07/29/2023 06:00	0	1.7	7.6	14.3	10.0	819,579.7	0.00	1.00
07/29/2023 07:00	0	1.7	7.6	14.3	10.1	802,565.7	0.00	1.00
07/29/2023 08:00	0	1.7	7.6	14.3	9.7	801,528.2	0.00	1.00
07/29/2023 09:00	0	1.7	7.6	14.4	9.8	812,384.7	0.00	1.00
07/29/2023 10:00	0	1.7	7.6	14.4	9.7	811,120.6	0.00	1.00
07/29/2023 11:00	0	1.6	7.5	14.4	8.0	809,435.2	0.00	1.00
07/29/2023 12:00	0	1.7	7.3	14.5	6.4	820,584.8	0.00	1.00
07/29/2023 13:00	0	1.6	7.3	14.5	5.9	819,728.9	0.00	1.00
07/29/2023 14:00	0	1.6	7.3	14.5	5.4	818,231.1	0.00	1.00
07/29/2023 15:00	0	1.6	7.3	14.6	6.5	829,914.7	0.00	1.00
07/29/2023 16:00	0	1.6	7.4	14.6	8.1	838,174.7	0.00	1.00
07/29/2023 17:00	0	1.6	7.4	14.6	6.9	829,914.7	0.00	1.00
07/29/2023 18:00	0	1.6	7.3	14.6	8.4	831,653.6	0.00	1.00
07/29/2023 19:00	0	1.6	7.2	14.5	8.4	819,942.8	0.00	1.00
07/29/2023 20:00	0	1.6	7.1	14.5	8.7	822,510.5	0.00	1.00
07/29/2023 21:00	0	1.7	7.2	14.5	9.0	823,794.4	0.00	1.00
07/29/2023 22:00	0	1.7	7.2	14.4	9.0	812,806.0	0.00	1.00
07/29/2023 23:00	0	1.6	7.4	14.4	9.1	842,722.7	0.00	1.00
Average/Sum#:	0	1.7	7.4	14.4	8.8	827,615.4	0.00 #	24.00 #
Minimum:	0	1.6	7.1	14.3	5.4	801,528.2	0.00	1.00
Maximum:	0	1.7	7.8	14.6	11.4	982,614.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2023 00:00	0	1.7	7.3	14.4	9.8	814,070.1	0.00	1.00
07/30/2023 01:00	0	1.7	7.3	14.4	9.8	814,280.8	0.00	1.00
07/30/2023 02:00	0	1.7	7.5	14.4	9.8	814,702.2	0.00	1.00
07/30/2023 03:00	0	1.7	7.5	14.4	10.0	814,912.8	0.00	1.00
07/30/2023 04:00	0	1.7	7.5	14.4	10.1	816,387.6	0.00	1.00
07/30/2023 05:00	0	1.7	7.7	14.3	10.4	816,882.4	0.00	1.00
07/30/2023 06:00	0	1.7	7.7	14.3	10.6	804,225.6	0.00	1.00
07/30/2023 07:00	0	1.7	7.7	14.3	10.5	803,810.6	0.00	1.00
07/30/2023 08:00	0	1.7	7.6	14.4	10.4	814,702.2	0.00	1.00
07/30/2023 09:00	0	1.7	7.6	14.4	10.3	813,227.4	0.00	1.00
07/30/2023 10:00	0	1.7	7.6	14.4	10.0	812,174.0	0.00	1.00
07/30/2023 11:00	0	1.6	7.4	14.4	7.3	810,699.2	0.00	1.00
07/30/2023 12:00	0	1.6	7.3	14.5	6.2	821,012.7	0.00	1.00
07/30/2023 13:00	0	1.6	7.2	14.5	2.5	819,728.9	0.00	1.00
07/30/2023 14:00	0	1.6	7.0	14.5	2.3	834,493.0	0.00	1.00
07/30/2023 15:00	0	1.6	7.2	14.5	6.3	818,017.1	0.00	1.00
07/30/2023 16:00	0	1.6	7.1	14.5	7.0	819,728.9	0.00	1.00
07/30/2023 17:00	0	1.6	7.4	14.6	9.4	854,477.3	0.00	1.00
07/30/2023 18:00	0	1.6	7.1	14.4	3.4	820,601.2	0.00	1.00
07/30/2023 19:00	0	1.6	7.6	14.5	9.7	820,370.8	0.00	1.00
07/30/2023 20:00	0	1.6	7.5	14.5	9.4	819,728.9	0.00	1.00
07/30/2023 21:00	0	1.6	7.5	14.5	9.2	827,859.8	0.00	1.00
07/30/2023 22:00	0	1.6	7.3	14.5	8.9	822,296.5	0.00	1.00
07/30/2023 23:00	0	1.7	7.4	14.4	8.8	810,488.6	0.00	1.00
Average/Sum#:	0	1.7	7.4	14.4	8.4	818,286.6	0.00 #	24.00 #
Minimum:	0	1.6	7.0	14.3	2.3	803,810.6	0.00	1.00
Maximum:	0	1.7	7.7	14.6	10.6	854,477.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2023 00:00	0	1.6	7.5	14.5	8.9	864,021.2	0.00	1.00
07/31/2023 01:00	0	1.7	7.3	14.4	6.7	812,595.4	0.00	1.00
07/31/2023 02:00	0	1.7	7.5	14.4	7.7	821,443.9	0.00	1.00
07/31/2023 03:00	0	1.7	7.4	14.4	8.2	812,806.0	0.00	1.00
07/31/2023 04:00	0	1.7	7.4	14.4	9.3	825,025.5	0.00	1.00
07/31/2023 05:00	0	1.7	7.5	14.4	9.5	861,894.6	0.00	1.00
07/31/2023 06:00	0	1.6	7.3	14.5	11.2	977,854.6	0.00	1.00
07/31/2023 07:00	0	1.7	7.7	14.3	9.2	818,749.8	0.00	1.00
07/31/2023 08:00	0	1.7	7.6	14.4	9.4	813,859.4	0.00	1.00
07/31/2023 09:00	0	1.7	7.7	14.4	9.8	812,595.4	0.00	1.00
07/31/2023 10:00	0	1.6	7.3	14.4	8.1	848,832.4	0.00	1.00
07/31/2023 11:00	0	1.7	7.8	14.5	13.1	1,054,884.7	0.00	1.00
07/31/2023 12:00	0	1.6	7.4	14.5	11.6	1,043,330.2	0.00	1.00
07/31/2023 13:00	1	2.1	11.7	12.7	24.1	1,047,609.7	0.00	1.00
07/31/2023 14:00	1	2.1	11.9	12.7	23.1	1,038,257.5	0.00	1.00
07/31/2023 15:00	0	2.0	11.3	13.0	21.2	1,044,229.4	0.00	1.00
07/31/2023 16:00	0	2.0	11.3	13.1	20.5	1,047,609.7	0.00	1.00
07/31/2023 17:00	0	1.9	9.9	13.5	16.6	1,036,506.2	0.00	1.00
07/31/2023 18:00	0	1.8	9.3	13.7	15.0	1,037,529.2	0.00	1.00
07/31/2023 19:00	0	1.9	9.6	13.6	16.7	1,039,824.6	0.00	1.00
07/31/2023 20:00	0	1.8	9.5	13.8	16.3	1,058,700.1	0.00	1.00
07/31/2023 21:00	0	1.7	8.6	13.9	13.4	1,008,874.5	0.00	1.00
07/31/2023 22:00	0	1.6	6.8	14.4	5.9	929,523.1	0.00	1.00
07/31/2023 23:00	0	1.7	6.6	14.5	8.7	1,011,662.3	0.00	1.00
Average/Sum#:	0	1.8	8.5	14.0	12.7	944,509.1	0.00 #	24.00 #
Minimum:	0	1.6	6.6	12.7	5.9	812,595.4	0.00	1.00
Maximum:	1	2.1	11.9	14.5	24.1	1,058,700.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2023 00:00	0	1.6	6.7	14.4	7.8	915,828.9	0.00	1.00
08/01/2023 01:00	0	1.6	7.2	14.4	8.0	868,215.1	0.00	1.00
08/01/2023 02:00	0	1.7	7.1	14.5	9.0	914,732.7	0.00	1.00
08/01/2023 03:00	0	1.6	7.2	14.4	10.7	888,440.4	0.00	1.00
08/01/2023 04:00	0	1.7	7.2	14.4	11.2	896,235.6	0.00	1.00
08/01/2023 05:00	0	1.6	7.2	14.5	12.2	973,361.2	0.00	1.00
08/01/2023 06:00	0	1.6	7.1	14.5	12.7	993,688.6	0.00	1.00
08/01/2023 07:00	0	1.6	7.3	14.4	10.5	883,173.4	0.00	1.00
08/01/2023 08:00	0	1.7	7.1	14.3	7.8	796,548.5	0.00	1.00
08/01/2023 09:00	0	1.6	7.1	14.5	11.3	956,457.3	0.00	1.00
08/01/2023 10:00	0	1.6	7.1	14.5	8.3	896,545.0	0.00	1.00
08/01/2023 11:00	0	1.7	7.0	14.6	11.4	984,681.3	0.00	1.00
08/01/2023 12:00	0	1.6	7.2	14.6	11.6	989,680.8	0.00	1.00
08/01/2023 13:00	0	1.6	6.8	14.6	10.9	989,680.8	0.00	1.00
08/01/2023 14:00	0	1.6	6.4	14.5	10.2	975,073.0	0.00	1.00
08/01/2023 15:00	0	1.6	6.6	14.5	9.8	954,103.6	0.00	1.00
08/01/2023 16:00	0	1.6	6.4	14.6	10.5	988,159.2	0.00	1.00
08/01/2023 17:00	0	1.6	6.5	14.5	9.8	952,819.8	0.00	1.00
08/01/2023 18:00	0	1.6	6.5	14.4	6.6	882,752.0	0.00	1.00
08/01/2023 19:00	0	1.6	6.4	14.5	9.9	950,252.1	0.00	1.00
08/01/2023 20:00	0	1.6	6.6	14.5	10.0	968,653.8	0.00	1.00
08/01/2023 21:00	0	1.6	6.6	14.5	9.7	962,448.6	0.00	1.00
08/01/2023 22:00	0	1.7	6.7	14.5	10.5	957,955.2	0.00	1.00
08/01/2023 23:00	0	1.6	7.1	14.4	6.7	816,176.9	0.00	1.00
Average/Sum#:	0	1.6	6.9	14.5	9.9	931,486.0	0.00 #	24.00 #
Minimum:	0	1.6	6.4	14.3	6.6	796,548.5	0.00	1.00
Maximum:	0	1.7	7.3	14.6	12.7	993,688.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2023 00:00	0	1.7	6.8	14.5	10.1	947,470.5	0.00	1.00
08/02/2023 01:00	0	1.6	7.0	14.5	10.8	947,042.6	0.00	1.00
08/02/2023 02:00	0	1.7	7.3	14.4	9.8	888,229.7	0.00	1.00
08/02/2023 03:00	0	1.7	7.0	14.4	11.5	941,742.6	0.00	1.00
08/02/2023 04:00	0	1.7	7.0	14.4	11.7	952,066.0	0.00	1.00
08/02/2023 05:00	0	1.7	7.0	14.4	11.8	958,807.7	0.00	1.00
08/02/2023 06:00	0	1.6	7.0	14.4	11.6	955,647.5	0.00	1.00
08/02/2023 07:00	0	1.7	7.4	14.3	9.1	805,470.5	0.00	1.00
08/02/2023 08:00	0	1.7	7.3	14.3	7.9	773,932.3	0.00	1.00
08/02/2023 09:00	0	1.7	7.4	14.3	8.0	773,102.3	0.00	1.00
08/02/2023 10:00	0	1.7	7.1	14.3	6.6	789,908.9	0.00	1.00
08/02/2023 11:00	0	1.7	6.8	14.4	2.1	780,993.3	0.00	1.00
08/02/2023 12:00	0	1.7	6.8	14.4	1.5	782,678.7	0.00	1.00
08/02/2023 13:00	0	1.6	6.5	14.4	6.3	893,918.1	0.00	1.00
08/02/2023 14:00	0	1.6	6.6	14.3	0.9	771,027.4	0.00	1.00
08/02/2023 15:00	0	1.7	6.4	14.3	0.5	770,197.5	0.00	1.00
08/02/2023 16:00	0	1.7	6.4	14.3	0.9	770,197.5	0.00	1.00
08/02/2023 17:00	0	1.7	6.3	14.4	2.5	819,758.5	0.00	1.00
08/02/2023 18:00	0	1.7	6.6	14.3	1.9	774,139.8	0.00	1.00
08/02/2023 19:00	0	1.6	6.4	14.4	5.1	868,215.1	0.00	1.00
08/02/2023 20:00	0	1.6	6.7	14.4	6.7	883,384.1	0.00	1.00
08/02/2023 21:00	0	1.7	6.7	14.4	7.5	882,962.7	0.00	1.00
08/02/2023 22:00	0	1.7	6.9	14.4	8.0	892,654.0	0.00	1.00
08/02/2023 23:00	0	1.7	7.2	14.3	8.6	773,517.3	0.00	1.00
Average/Sum#:	0	1.7	6.9	14.4	6.7	849,877.7	0.00 #	24.00 #
Minimum:	0	1.6	6.3	14.3	0.5	770,197.5	0.00	1.00
Maximum:	0	1.7	7.4	14.5	11.8	958,807.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2023 00:00	0	1.7	7.0	14.4	9.8	883,805.4	0.00	1.00
08/03/2023 01:00	0	1.7	7.2	14.4	9.3	838,087.7	0.00	1.00
08/03/2023 02:00	0	1.7	7.5	14.3	8.9	799,660.8	0.00	1.00
08/03/2023 03:00	0	1.7	7.4	14.3	9.7	816,467.4	0.00	1.00
08/03/2023 04:00	0	1.7	7.4	14.3	9.2	775,177.2	0.00	1.00
08/03/2023 05:00	0	1.7	7.0	14.4	9.2	873,060.7	0.00	1.00
08/03/2023 06:00	0	1.7	7.2	14.4	10.7	894,339.5	0.00	1.00
08/03/2023 07:00	0	1.7	7.4	14.3	8.9	773,102.3	0.00	1.00
08/03/2023 08:00	0	1.7	7.4	14.3	8.4	772,479.8	0.00	1.00
08/03/2023 09:00	0	1.7	7.3	14.3	8.4	771,857.4	0.00	1.00
08/03/2023 10:00	0	1.7	7.2	14.3	8.1	771,027.4	0.00	1.00
08/03/2023 11:00	0	1.7	7.2	14.4	7.7	782,046.7	0.00	1.00
08/03/2023 12:00	0	1.7	7.1	14.4	7.0	780,571.9	0.00	1.00
08/03/2023 13:00	0	1.7	7.0	14.4	6.6	779,307.8	0.00	1.00
08/03/2023 14:00	0	1.6	6.8	14.4	2.6	777,833.1	0.00	1.00
08/03/2023 15:00	0	1.6	6.8	14.4	1.4	777,411.7	0.00	1.00
08/03/2023 16:00	0	1.7	6.8	14.4	3.5	777,411.7	0.00	1.00
08/03/2023 17:00	0	1.6	6.8	14.4	3.6	776,569.0	0.00	1.00
08/03/2023 18:00	0	1.6	6.7	14.4	2.5	795,319.5	0.00	1.00
08/03/2023 19:00	0	1.7	6.7	14.5	6.1	851,824.8	0.00	1.00
08/03/2023 20:00	0	1.6	6.8	14.4	5.5	826,500.3	0.00	1.00
08/03/2023 21:00	0	1.6	6.8	14.4	6.3	824,393.5	0.00	1.00
08/03/2023 22:00	0	1.6	6.7	14.3	4.8	800,490.8	0.00	1.00
08/03/2023 23:00	0	1.7	6.8	14.3	3.1	770,819.9	0.00	1.00
Average/Sum#:	0	1.7	7.0	14.4	6.7	803,731.9	0.00 #	24.00 #
Minimum:	0	1.6	6.7	14.3	1.4	770,819.9	0.00	1.00
Maximum:	0	1.7	7.5	14.5	10.7	894,339.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2023 00:00	0	1.7	7.1	14.3	8.3	771,857.4	0.00	1.00
08/04/2023 01:00	0	1.7	7.1	14.3	7.9	772,272.4	0.00	1.00
08/04/2023 02:00	0	1.7	7.3	14.3	8.3	773,309.8	0.00	1.00
08/04/2023 03:00	0	1.7	7.3	14.3	8.4	773,932.3	0.00	1.00
08/04/2023 04:00	0	1.7	7.3	14.3	8.4	773,517.3	0.00	1.00
08/04/2023 05:00	0	1.7	7.1	14.3	7.7	795,303.6	0.00	1.00
08/04/2023 06:00	0	1.7	7.1	14.3	8.1	809,205.3	0.00	1.00
08/04/2023 07:00	0	1.7	7.2	14.3	7.4	773,102.3	0.00	1.00
08/04/2023 08:00	0	1.7	7.1	14.3	6.6	772,687.3	0.00	1.00
08/04/2023 09:00	0	1.7	7.1	14.3	5.9	771,234.9	0.00	1.00
08/04/2023 10:00	0	1.7	7.0	14.3	6.4	770,405.0	0.00	1.00
08/04/2023 11:00	0	1.7	7.0	14.4	5.8	781,414.6	0.00	1.00
08/04/2023 12:00	0	1.6	6.8	14.4	3.1	780,150.5	0.00	1.00
08/04/2023 13:00	0	1.6	6.6	14.4	0.7	778,886.5	0.00	1.00
08/04/2023 14:00	0	1.7	6.7	14.5	1.3	789,558.7	0.00	1.00
08/04/2023 15:00	0	1.6	6.7	14.5	1.7	788,702.9	0.00	1.00
08/04/2023 16:00	0	1.6	6.6	14.5	0.9	788,488.9	0.00	1.00
08/04/2023 17:00	0	1.6	6.4	14.5	0.9	805,820.7	0.00	1.00
08/04/2023 18:00	0	1.8	7.6	14.1	9.4	925,368.4	0.00	1.00
08/04/2023 19:00	0	1.9	9.4	13.6	15.7	988,987.0	0.00	1.00
08/04/2023 20:00	0	1.8	9.4	13.7	15.8	1,000,630.8	0.00	1.00
08/04/2023 21:00	0	1.8	8.7	13.7	13.5	964,112.8	0.00	1.00
08/04/2023 22:00	0	1.6	6.5	14.4	7.7	907,191.0	0.00	1.00
08/04/2023 23:00	0	1.6	6.6	14.3	4.8	815,222.5	0.00	1.00
Average/Sum#:	0	1.7	7.2	14.3	6.9	819,640.1	0.00 #	24.00 #
Minimum:	0	1.6	6.4	13.6	0.7	770,405.0	0.00	1.00
Maximum:	0	1.9	9.4	14.5	15.8	1,000,630.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2023 00:00	0	1.7	6.3	14.4	7.9	941,321.3	0.00	1.00
08/05/2023 01:00	0	1.6	6.6	14.4	9.7	928,680.4	0.00	1.00
08/05/2023 02:00	0	1.7	6.6	14.4	9.5	944,481.5	0.00	1.00
08/05/2023 03:00	0	1.7	6.8	14.4	10.8	938,793.1	0.00	1.00
08/05/2023 04:00	0	1.7	7.0	14.4	9.9	881,909.3	0.00	1.00
08/05/2023 05:00	0	1.7	7.2	14.3	8.0	793,851.2	0.00	1.00
08/05/2023 06:00	0	1.7	7.0	14.3	8.4	820,617.2	0.00	1.00
08/05/2023 07:00	0	1.7	7.1	14.3	7.0	770,405.0	0.00	1.00
08/05/2023 08:00	0	1.7	7.0	14.3	6.2	769,367.5	0.00	1.00
08/05/2023 09:00	0	1.7	7.1	14.4	6.2	779,939.9	0.00	1.00
08/05/2023 10:00	0	1.6	6.9	14.4	5.0	778,675.8	0.00	1.00
08/05/2023 11:00	0	1.6	6.6	14.4	0.8	777,411.7	0.00	1.00
08/05/2023 12:00	0	1.6	6.6	14.4	1.1	776,990.3	0.00	1.00
08/05/2023 13:00	0	1.6	6.6	14.4	0.6	776,779.6	0.00	1.00
08/05/2023 14:00	0	1.6	6.5	14.5	3.1	842,623.9	0.00	1.00
08/05/2023 15:00	0	1.6	6.2	14.4	2.9	862,526.7	0.00	1.00
08/05/2023 16:00	0	1.6	6.2	14.3	1.0	768,952.5	0.00	1.00
08/05/2023 17:00	0	1.7	6.7	14.3	4.7	873,734.3	0.00	1.00
08/05/2023 18:00	0	1.9	9.5	13.5	15.6	981,174.1	0.00	1.00
08/05/2023 19:00	0	1.9	9.4	13.4	16.0	986,898.5	0.00	1.00
08/05/2023 20:00	0	1.9	8.9	13.5	15.5	978,028.1	0.00	1.00
08/05/2023 21:00	0	1.8	8.2	13.7	12.0	946,424.4	0.00	1.00
08/05/2023 22:00	0	1.7	6.3	14.4	3.8	880,645.2	0.00	1.00
08/05/2023 23:00	0	1.6	6.3	14.4	3.3	841,669.3	0.00	1.00
Average/Sum#:	0	1.7	7.1	14.2	7.0	860,079.2	0.00 #	24.00 #
Minimum:	0	1.6	6.2	13.4	0.6	768,952.5	0.00	1.00
Maximum:	0	1.9	9.5	14.5	16.0	986,898.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2023 00:00	0	1.6	6.3	14.4	4.2	861,051.9	0.00	1.00
08/06/2023 01:00	0	1.6	6.4	14.4	1.7	823,972.1	0.00	1.00
08/06/2023 02:00	0	1.7	6.8	14.4	3.8	823,340.1	0.00	1.00
08/06/2023 03:00	0	1.7	6.7	14.3	1.7	771,857.4	0.00	1.00
08/06/2023 04:00	0	1.7	6.6	14.3	1.2	780,779.4	0.00	1.00
08/06/2023 05:00	0	1.7	6.6	14.4	5.6	848,200.4	0.00	1.00
08/06/2023 06:00	0	1.6	6.7	14.4	5.0	834,927.5	0.00	1.00
08/06/2023 07:00	0	1.7	6.5	14.3	0.4	769,990.0	0.00	1.00
08/06/2023 08:00	0	1.7	6.5	14.4	5.2	867,793.7	0.00	1.00
08/06/2023 09:00	0	1.6	6.8	14.4	2.3	777,833.1	0.00	1.00
08/06/2023 10:00	0	1.6	6.8	14.4	1.6	777,201.0	0.00	1.00
08/06/2023 11:00	0	1.6	6.6	14.5	0.7	787,847.0	0.00	1.00
08/06/2023 12:00	0	1.6	6.5	14.5	3.4	836,632.7	0.00	1.00
08/06/2023 13:00	0	1.6	6.6	14.5	7.1	936,985.8	0.00	1.00
08/06/2023 14:00	0	1.6	6.8	14.5	10.5	982,776.0	0.00	1.00
08/06/2023 15:00	0	1.6	6.3	14.6	8.7	985,116.1	0.00	1.00
08/06/2023 16:00	0	1.6	6.2	14.5	6.9	923,291.6	0.00	1.00
08/06/2023 17:00	0	1.7	6.9	14.3	8.1	928,718.7	0.00	1.00
08/06/2023 18:00	0	1.9	9.4	13.5	16.2	995,053.4	0.00	1.00
08/06/2023 19:00	0	2.0	10.3	13.2	18.1	994,877.9	0.00	1.00
08/06/2023 20:00	0	2.0	10.4	13.1	19.1	990,199.2	0.00	1.00
08/06/2023 21:00	0	1.8	9.3	13.5	14.5	953,415.5	0.00	1.00
08/06/2023 22:00	0	1.6	6.3	14.5	7.6	950,252.1	0.00	1.00
08/06/2023 23:00	0	1.6	6.5	14.4	4.1	846,725.6	0.00	1.00
Average/Sum#:	0	1.7	7.1	14.2	6.6	877,034.9	0.00 #	24.00 #
Minimum:	0	1.6	6.2	13.1	0.4	769,990.0	0.00	1.00
Maximum:	0	2.0	10.4	14.6	19.1	995,053.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2023 00:00	0	1.7	6.8	14.5	9.1	912,593.0	0.00	1.00
08/07/2023 01:00	0	1.6	7.0	14.4	7.4	825,657.6	0.00	1.00
08/07/2023 02:00	0	1.6	6.8	14.4	4.3	794,898.2	0.00	1.00
08/07/2023 03:00	0	1.7	6.8	14.4	3.2	780,361.2	0.00	1.00
08/07/2023 04:00	0	1.7	6.9	14.4	7.4	850,728.6	0.00	1.00
08/07/2023 05:00	0	1.6	6.9	14.6	11.1	978,595.0	0.00	1.00
08/07/2023 06:00	0	1.6	6.9	14.5	11.0	958,811.0	0.00	1.00
08/07/2023 07:00	0	1.6	7.1	14.4	4.9	804,800.2	0.00	1.00
08/07/2023 08:00	0	1.7	6.8	14.4	3.3	784,153.5	0.00	1.00
08/07/2023 09:00	0	1.6	6.8	14.5	8.8	887,130.2	0.00	1.00
08/07/2023 10:00	0	1.6	6.9	14.5	10.3	925,859.3	0.00	1.00
08/07/2023 11:00	0	1.7	7.5	14.2	11.7	952,056.5	0.00	1.00
08/07/2023 12:00	0	2.0	10.8	13.0	19.1	989,625.8	0.00	1.00
08/07/2023 13:00	0	1.6	6.2	14.5	4.8	968,225.8	0.00	1.00
08/07/2023 14:00	0	1.6	6.2	14.6	7.2	979,247.1	0.00	1.00
08/07/2023 15:00	0	1.1	6.3	14.6	11.9	984,029.2	0.00	1.00
08/07/2023 16:00	1	1.3	9.5	13.5	20.6	950,824.7	0.00	1.00
08/07/2023 17:00	1	1.3	10.3	13.2	20.9	988,475.4	0.00	1.00
08/07/2023 18:00	0	1.8	10.4	13.1	18.5	985,810.0	0.00	1.00
08/07/2023 19:00	1	2.2	12.7	12.4	26.5	994,846.5	0.00	1.00
08/07/2023 20:00	0	2.0	10.5	13.1	18.5	988,794.6	0.00	1.00
08/07/2023 21:00	0	2.0	10.3	13.2	19.1	1,000,924.7	0.00	1.00
08/07/2023 22:00	0	2.0	10.8	13.0	20.2	995,519.5	0.00	1.00
08/07/2023 23:00	0	1.6	6.6	14.4	5.4	905,926.9	0.00	1.00
Average/Sum#:	0	1.7	8.1	14.0	11.9	924,495.6	0.00 #	24.00 #
Minimum:	0	1.1	6.2	12.4	3.2	780,361.2	0.00	1.00
Maximum:	1	2.2	12.7	14.6	26.5	1,000,924.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2023 00:00	0	1.6	6.7	14.5	9.7	931,850.5	0.00	1.00
08/08/2023 01:00	0	1.6	6.9	14.5	10.1	922,435.7	0.00	1.00
08/08/2023 02:00	0	1.6	7.1	14.5	9.2	899,540.6	0.00	1.00
08/08/2023 03:00	0	1.7	7.0	14.4	9.2	867,793.7	0.00	1.00
08/08/2023 04:00	0	1.7	6.9	14.4	7.6	836,191.6	0.00	1.00
08/08/2023 05:00	0	1.7	6.8	14.5	10.0	941,265.3	0.00	1.00
08/08/2023 06:00	0	1.6	7.1	14.5	11.0	951,108.0	0.00	1.00
08/08/2023 07:00	0	1.7	7.1	14.3	7.1	772,894.8	0.00	1.00
08/08/2023 08:00	0	1.7	7.0	14.3	6.0	772,687.3	0.00	1.00
08/08/2023 09:00	0	1.8	7.1	14.3	6.0	772,272.4	0.00	1.00
08/08/2023 10:00	0	1.7	7.1	14.4	8.0	783,310.7	0.00	1.00
08/08/2023 11:00	0	1.7	7.1	14.4	7.3	781,836.0	0.00	1.00
08/08/2023 12:00	0	1.7	7.0	14.4	7.0	780,150.5	0.00	1.00
08/08/2023 13:00	0	1.6	6.8	14.4	2.8	778,675.8	0.00	1.00
08/08/2023 14:00	0	1.6	6.6	14.5	1.7	812,025.9	0.00	1.00
08/08/2023 15:00	0	1.6	6.4	14.3	1.3	771,027.4	0.00	1.00
08/08/2023 16:00	0	1.6	6.3	14.3	0.5	771,649.9	0.00	1.00
08/08/2023 17:00	0	1.6	6.3	14.3	0.8	783,684.2	0.00	1.00
08/08/2023 18:00	0	1.7	6.3	14.4	3.4	849,253.8	0.00	1.00
08/08/2023 19:00	0	1.6	6.7	14.5	10.9	991,548.8	0.00	1.00
08/08/2023 20:00	0	1.6	6.8	14.4	6.7	868,425.7	0.00	1.00
08/08/2023 21:00	0	1.7	6.6	14.3	4.7	818,542.3	0.00	1.00
08/08/2023 22:00	0	1.7	6.7	14.3	5.2	816,467.4	0.00	1.00
08/08/2023 23:00	0	1.7	6.8	14.3	3.7	772,064.9	0.00	1.00
Average/Sum#:	0	1.7	6.8	14.4	6.2	835,279.3	0.00 #	24.00 #
Minimum:	0	1.6	6.3	14.3	0.5	771,027.4	0.00	1.00
Maximum:	0	1.8	7.1	14.5	11.0	991,548.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2023 00:00	0	1.7	6.8	14.3	5.6	772,064.9	0.00	1.00
08/09/2023 01:00	0	1.7	6.9	14.3	6.7	772,687.3	0.00	1.00
08/09/2023 02:00	0	1.7	7.2	14.3	6.7	773,309.8	0.00	1.00
08/09/2023 03:00	0	1.7	7.1	14.3	7.0	773,309.8	0.00	1.00
08/09/2023 04:00	0	1.7	7.2	14.2	7.7	762,381.0	0.00	1.00
08/09/2023 05:00	0	1.7	7.1	14.2	7.6	773,418.2	0.00	1.00
08/09/2023 06:00	0	1.7	7.2	14.2	7.1	778,528.0	0.00	1.00
08/09/2023 07:00	0	1.7	7.2	14.3	7.7	773,932.3	0.00	1.00
08/09/2023 08:00	0	1.7	7.1	14.3	7.0	772,687.3	0.00	1.00
08/09/2023 09:00	0	1.7	7.1	14.3	6.4	771,442.4	0.00	1.00
08/09/2023 10:00	0	1.7	7.0	14.4	6.1	782,889.4	0.00	1.00
08/09/2023 11:00	0	1.7	7.0	14.4	6.4	781,625.3	0.00	1.00
08/09/2023 12:00	0	1.7	6.9	14.4	4.2	781,203.9	0.00	1.00
08/09/2023 13:00	0	1.7	6.6	14.5	4.6	844,121.7	0.00	1.00
08/09/2023 14:00	0	1.6	6.8	14.5	5.5	865,519.0	0.00	1.00
08/09/2023 15:00	0	1.6	7.1	14.6	10.3	932,512.8	0.00	1.00
08/09/2023 16:00	0	1.6	7.1	14.6	11.3	975,117.1	0.00	1.00
08/09/2023 17:00	0	1.6	6.4	14.4	3.6	870,111.2	0.00	1.00
08/09/2023 18:00	0	1.7	6.8	14.4	8.0	914,354.1	0.00	1.00
08/09/2023 19:00	0	1.8	8.8	13.8	15.8	1,009,902.3	0.00	1.00
08/09/2023 20:00	0	1.7	7.8	14.1	11.2	934,229.4	0.00	1.00
08/09/2023 21:00	0	1.6	6.5	14.5	7.4	912,593.0	0.00	1.00
08/09/2023 22:00	0	1.6	6.6	14.4	6.0	841,880.0	0.00	1.00
08/09/2023 23:00	0	1.7	6.5	14.4	0.9	780,571.9	0.00	1.00
Average/Sum#:	0	1.7	7.0	14.3	7.1	831,266.3	0.00 #	24.00 #
Minimum:	0	1.6	6.4	13.8	0.9	762,381.0	0.00	1.00
Maximum:	0	1.8	8.8	14.6	15.8	1,009,902.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2023 00:00	0	1.7	6.5	14.4	0.9	780,993.3	0.00	1.00
08/10/2023 01:00	0	1.7	6.5	14.3	1.1	770,405.0	0.00	1.00
08/10/2023 02:00	0	1.7	6.6	14.3	1.3	770,405.0	0.00	1.00
08/10/2023 03:00	0	1.7	6.6	14.3	2.7	771,649.9	0.00	1.00
08/10/2023 04:00	0	1.7	6.7	14.3	2.1	771,857.4	0.00	1.00
08/10/2023 05:00	0	1.7	6.9	14.3	5.6	777,667.1	0.00	1.00
08/10/2023 06:00	0	1.7	6.8	14.4	9.8	902,134.6	0.00	1.00
08/10/2023 07:00	0	1.7	7.1	14.3	8.3	797,793.4	0.00	1.00
08/10/2023 08:00	0	1.7	7.1	14.3	6.4	772,064.9	0.00	1.00
08/10/2023 09:00	0	1.7	7.0	14.3	6.3	771,442.4	0.00	1.00
08/10/2023 10:00	0	1.7	7.1	14.4	6.5	782,678.7	0.00	1.00
08/10/2023 11:00	0	1.6	6.9	14.4	4.1	781,414.6	0.00	1.00
08/10/2023 12:00	0	1.6	6.6	14.4	0.6	778,465.1	0.00	1.00
08/10/2023 13:00	0	1.6	6.4	14.5	2.4	821,226.7	0.00	1.00
08/10/2023 14:00	0	1.6	6.6	14.5	1.7	789,130.8	0.00	1.00
08/10/2023 15:00	0	1.6	6.7	14.6	5.8	885,126.4	0.00	1.00
08/10/2023 16:00	0	1.6	6.9	14.5	9.6	966,300.1	0.00	1.00
08/10/2023 17:00	0	1.6	6.5	14.4	1.7	799,111.8	0.00	1.00
08/10/2023 18:00	0	1.6	6.3	14.4	1.9	823,340.1	0.00	1.00
08/10/2023 19:00	0	1.6	6.4	14.3	3.3	783,269.2	0.00	1.00
08/10/2023 20:00	0	1.6	6.6	14.3	3.6	799,660.8	0.00	1.00
08/10/2023 21:00	0	1.7	6.4	14.3	1.8	793,643.7	0.00	1.00
08/10/2023 22:00	0	1.6	6.6	14.3	4.0	800,075.8	0.00	1.00
08/10/2023 23:00	0	1.7	6.6	14.4	5.2	867,793.7	0.00	1.00
Average/Sum#:	0	1.7	6.7	14.4	4.0	806,568.8	0.00 #	24.00 #
Minimum:	0	1.6	6.3	14.3	0.6	770,405.0	0.00	1.00
Maximum:	0	1.7	7.1	14.6	9.8	966,300.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2023 00:00	0	1.9	8.9	13.7	16.7	1,013,944.6	0.00	1.00
08/11/2023 01:00	0	1.6	6.8	14.5	10.9	1,009,736.5	0.00	1.00
08/11/2023 02:00	0	1.6	6.8	14.4	10.4	951,223.2	0.00	1.00
08/11/2023 03:00	0	1.7	6.9	14.4	10.6	917,093.0	0.00	1.00
08/11/2023 04:00	0	1.7	6.8	14.4	10.5	915,407.5	0.00	1.00
08/11/2023 05:00	0	1.7	6.8	14.4	10.6	923,202.7	0.00	1.00
08/11/2023 06:00	0	1.7	6.7	14.4	11.0	960,071.8	0.00	1.00
08/11/2023 07:00	0	1.7	6.9	14.5	12.1	1,012,946.1	0.00	1.00
08/11/2023 08:00	0	1.8	8.3	14.0	16.1	1,035,007.0	0.00	1.00
08/11/2023 09:00	0	1.9	10.2	13.3	19.9	1,037,339.0	0.00	1.00
08/11/2023 10:00	1	2.1	12.0	12.7	24.7	1,036,253.5	0.00	1.00
08/11/2023 11:00	1	2.3	13.3	12.0	30.6	1,019,990.4	0.00	1.00
08/11/2023 12:00	0	1.8	8.8	13.7	13.9	969,818.7	0.00	1.00
08/11/2023 13:00	0	1.6	6.6	14.3	0.7	772,272.4	0.00	1.00
08/11/2023 14:00	0	1.7	6.4	14.3	0.4	771,234.9	0.00	1.00
08/11/2023 15:00	0	1.7	6.4	14.3	0.8	770,197.5	0.00	1.00
08/11/2023 16:00	0	1.6	6.1	14.3	0.4	769,367.5	0.00	1.00
08/11/2023 17:00	0	1.6	6.0	14.3	0.5	790,946.3	0.00	1.00
08/11/2023 18:00	0	1.8	7.9	14.0	14.3	976,459.1	0.00	1.00
08/11/2023 19:00	0	1.8	8.7	13.8	15.9	1,008,552.1	0.00	1.00
08/11/2023 20:00	0	1.8	8.6	13.9	15.8	1,017,286.7	0.00	1.00
08/11/2023 21:00	0	1.8	8.5	13.9	15.4	1,015,134.7	0.00	1.00
08/11/2023 22:00	0	1.8	8.4	13.8	15.3	1,003,923.1	0.00	1.00
08/11/2023 23:00	0	1.8	8.3	13.9	15.3	1,014,743.5	0.00	1.00
Average/Sum#:	0	1.8	8.0	14.0	12.2	946,339.7	0.00 #	24.00 #
Minimum:	0	1.6	6.0	12.0	0.4	769,367.5	0.00	1.00
Maximum:	1	2.3	13.3	14.5	30.6	1,037,339.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2023 00:00	0	1.6	6.6	14.3	4.2	843,648.4	0.00	1.00
08/12/2023 01:00	0	1.7	6.6	14.3	1.1	778,704.5	0.00	1.00
08/12/2023 02:00	0	1.7	6.7	14.3	1.6	773,932.3	0.00	1.00
08/12/2023 03:00	0	1.7	6.8	14.3	2.8	773,724.8	0.00	1.00
08/12/2023 04:00	0	1.7	6.8	14.3	4.7	774,139.8	0.00	1.00
08/12/2023 05:00	0	1.7	6.8	14.3	6.4	774,139.8	0.00	1.00
08/12/2023 06:00	0	1.7	6.9	14.3	6.8	777,667.1	0.00	1.00
08/12/2023 07:00	0	1.7	7.0	14.3	7.3	774,969.7	0.00	1.00
08/12/2023 08:00	0	1.7	7.0	14.3	5.6	773,517.3	0.00	1.00
08/12/2023 09:00	0	1.7	7.0	14.4	4.2	785,417.6	0.00	1.00
08/12/2023 10:00	0	1.6	6.8	14.4	5.0	783,310.7	0.00	1.00
08/12/2023 11:00	0	1.6	6.1	14.4	1.1	818,494.4	0.00	1.00
08/12/2023 12:00	0	1.7	6.1	14.4	4.5	888,019.0	0.00	1.00
08/12/2023 13:00	0	1.6	6.1	14.4	3.6	907,823.0	0.00	1.00
08/12/2023 14:00	0	1.6	6.0	14.4	2.4	862,316.0	0.00	1.00
08/12/2023 15:00	0	1.6	6.1	14.4	2.4	851,992.6	0.00	1.00
08/12/2023 16:00	0	1.6	5.9	14.3	0.7	771,027.4	0.00	1.00
08/12/2023 17:00	0	1.6	5.9	14.3	0.2	770,612.4	0.00	1.00
08/12/2023 18:00	0	1.7	6.6	14.3	6.1	883,486.2	0.00	1.00
08/12/2023 19:00	0	1.8	8.9	13.7	16.1	998,919.0	0.00	1.00
08/12/2023 20:00	0	1.8	8.5	13.9	14.7	994,006.5	0.00	1.00
08/12/2023 21:00	0	1.6	6.3	14.4	3.8	889,072.4	0.00	1.00
08/12/2023 22:00	0	1.6	6.9	14.4	9.4	952,276.6	0.00	1.00
08/12/2023 23:00	0	1.6	6.5	14.3	3.5	821,239.7	0.00	1.00
Average/Sum#:	0	1.7	6.7	14.3	4.9	834,269.1	0.00 #	24.00 #
Minimum:	0	1.6	5.9	13.7	0.2	770,612.4	0.00	1.00
Maximum:	0	1.8	8.9	14.4	16.1	998,919.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2023 00:00	0	1.7	6.4	14.4	6.0	880,013.2	0.00	1.00
08/13/2023 01:00	0	1.7	6.5	14.4	5.9	879,591.8	0.00	1.00
08/13/2023 02:00	0	1.6	6.6	14.3	1.7	824,352.0	0.00	1.00
08/13/2023 03:00	0	1.7	6.5	14.4	8.7	907,401.7	0.00	1.00
08/13/2023 04:00	0	1.6	6.7	14.4	5.5	830,081.9	0.00	1.00
08/13/2023 05:00	0	1.7	6.8	14.4	6.7	817,019.7	0.00	1.00
08/13/2023 06:00	0	1.7	6.6	14.3	3.3	774,554.7	0.00	1.00
08/13/2023 07:00	0	1.7	6.5	14.4	0.9	781,203.9	0.00	1.00
08/13/2023 08:00	0	1.7	6.5	14.4	0.9	779,518.5	0.00	1.00
08/13/2023 09:00	0	1.6	6.5	14.4	0.4	779,518.5	0.00	1.00
08/13/2023 10:00	0	1.6	6.4	14.4	0.9	778,675.8	0.00	1.00
08/13/2023 11:00	0	1.6	6.1	14.3	0.4	767,915.1	0.00	1.00
08/13/2023 12:00	0	1.6	6.0	14.4	0.9	822,708.0	0.00	1.00
08/13/2023 13:00	0	1.6	5.9	14.3	0.6	799,660.8	0.00	1.00
08/13/2023 14:00	0	1.6	6.1	14.5	4.8	913,448.9	0.00	1.00
08/13/2023 15:00	0	1.6	6.3	14.5	6.5	947,684.5	0.00	1.00
08/13/2023 16:00	0	1.6	6.3	14.5	7.4	944,688.9	0.00	1.00
08/13/2023 17:00	0	1.6	6.1	14.4	5.0	878,538.4	0.00	1.00
08/13/2023 18:00	0	1.8	8.3	13.8	13.7	966,119.3	0.00	1.00
08/13/2023 19:00	0	1.9	8.8	13.6	15.5	994,427.2	0.00	1.00
08/13/2023 20:00	0	1.9	8.7	13.6	15.4	988,049.1	0.00	1.00
08/13/2023 21:00	0	1.8	8.6	13.7	15.3	997,397.4	0.00	1.00
08/13/2023 22:00	0	1.7	6.7	14.3	8.5	955,899.7	0.00	1.00
08/13/2023 23:00	0	1.6	6.1	14.4	6.7	907,823.0	0.00	1.00
Average/Sum#:	0	1.7	6.8	14.3	5.9	871,512.2	0.00 #	24.00 #
Minimum:	0	1.6	5.9	13.6	0.4	767,915.1	0.00	1.00
Maximum:	0	1.9	8.8	14.5	15.5	997,397.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2023 00:00	0	1.6	5.9	14.5	6.6	958,383.1	0.00	1.00
08/14/2023 01:00	0	1.6	6.1	14.5	8.6	955,387.5	0.00	1.00
08/14/2023 02:00	0	1.6	6.6	14.5	8.8	936,343.9	0.00	1.00
08/14/2023 03:00	0	1.6	6.7	14.5	10.0	922,007.8	0.00	1.00
08/14/2023 04:00	0	1.6	6.7	14.5	8.9	905,103.9	0.00	1.00
08/14/2023 05:00	0	1.6	6.8	14.6	10.5	974,247.6	0.00	1.00
08/14/2023 06:00	0	1.6	6.8	14.6	10.2	987,724.5	0.00	1.00
08/14/2023 07:00	0	1.6	6.6	14.4	5.2	829,449.8	0.00	1.00
08/14/2023 08:00	0	1.6	6.4	14.5	5.1	878,571.3	0.00	1.00
08/14/2023 09:00	0	1.6	6.3	14.5	8.2	959,453.0	0.00	1.00
08/14/2023 10:00	0	1.6	6.3	14.5	9.0	965,444.2	0.00	1.00
08/14/2023 11:00	0	1.8	7.6	14.0	12.4	952,841.5	0.00	1.00
08/14/2023 12:00	1	2.1	10.5	12.9	21.3	996,256.2	0.00	1.00
08/14/2023 13:00	0	2.0	10.4	13.0	19.4	993,439.4	0.00	1.00
08/14/2023 14:00	0	1.9	9.0	13.3	14.5	974,633.7	0.00	1.00
08/14/2023 15:00	1	2.1	10.5	12.7	21.5	986,653.6	0.00	1.00
08/14/2023 16:00	0	1.9	9.5	13.2	16.2	973,891.9	0.00	1.00
08/14/2023 17:00	0	1.9	9.3	13.3	15.5	970,669.6	0.00	1.00
08/14/2023 18:00	1	2.3	11.3	12.3	26.2	988,055.6	0.00	1.00
08/14/2023 19:00	1	2.3	11.8	11.8	29.4	979,213.7	0.00	1.00
08/14/2023 20:00	1	2.0	10.9	12.7	20.1	982,812.5	0.00	1.00
08/14/2023 21:00	0	2.0	10.4	12.9	18.3	985,300.8	0.00	1.00
08/14/2023 22:00	0	1.9	9.5	13.2	16.5	981,361.5	0.00	1.00
08/14/2023 23:00	0	1.8	8.0	13.8	11.5	956,668.3	0.00	1.00
Average/Sum#:	0	1.8	8.3	13.7	13.9	958,079.8	0.00 #	24.00 #
Minimum:	0	1.6	5.9	11.8	5.1	829,449.8	0.00	1.00
Maximum:	1	2.3	11.8	14.6	29.4	996,256.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2023 00:00	0	1.6	5.9	14.5	0.8	950,680.1	0.00	1.00
08/15/2023 01:00	0	1.7	6.2	14.5	6.2	949,396.2	0.00	1.00
08/15/2023 02:00	0	1.7	6.5	14.5	7.9	949,182.3	0.00	1.00
08/15/2023 03:00	0	1.6	6.5	14.6	9.2	962,075.0	0.00	1.00
08/15/2023 04:00	0	1.6	6.4	14.5	8.3	947,684.5	0.00	1.00
08/15/2023 05:00	0	1.6	6.5	14.5	9.8	972,291.3	0.00	1.00
08/15/2023 06:00	0	1.6	6.3	14.5	9.0	972,291.3	0.00	1.00
08/15/2023 07:00	0	1.6	6.6	14.3	4.6	827,464.3	0.00	1.00
08/15/2023 08:00	0	1.7	6.2	14.4	4.1	916,460.9	0.00	1.00
08/15/2023 09:00	0	1.6	6.3	14.5	7.9	945,116.8	0.00	1.00
08/15/2023 10:00	0	1.6	6.3	14.5	5.4	901,894.3	0.00	1.00
08/15/2023 11:00	0	1.6	6.3	14.5	5.1	901,252.4	0.00	1.00
08/15/2023 12:00	0	1.6	6.3	14.5	6.3	936,557.9	0.00	1.00
08/15/2023 13:00	0	1.6	6.3	14.5	7.3	964,802.3	0.00	1.00
08/15/2023 14:00	1	2.2	10.8	12.5	24.0	984,192.3	0.00	1.00
08/15/2023 15:00	1	2.3	11.8	11.9	30.8	992,071.9	0.00	1.00
08/15/2023 16:00	1	2.3	11.6	11.9	30.6	990,093.8	0.00	1.00
08/15/2023 17:00	1	2.3	11.5	11.9	30.0	981,725.1	0.00	1.00
08/15/2023 18:00	1	2.2	11.3	12.1	26.4	971,513.2	0.00	1.00
08/15/2023 19:00	1	2.3	11.5	12.0	28.7	985,216.2	0.00	1.00
08/15/2023 20:00	1	2.1	10.9	12.5	22.1	983,051.1	0.00	1.00
08/15/2023 21:00	0	1.9	9.5	13.3	16.6	991,030.8	0.00	1.00
08/15/2023 22:00	1	2.1	10.7	12.8	20.1	982,604.3	0.00	1.00
08/15/2023 23:00	0	1.7	7.7	13.9	8.9	918,296.9	0.00	1.00
Average/Sum#:	0	1.8	8.2	13.7	13.8	953,206.1	0.00 #	24.00 #
Minimum:	0	1.6	5.9	11.9	0.8	827,464.3	0.00	1.00
Maximum:	1	2.3	11.8	14.6	30.8	992,071.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2023 00:00	0	1.7	6.7	14.5	9.2	981,706.1	0.00	1.00
08/16/2023 01:00	0	1.6	6.5	14.5	7.7	948,540.4	0.00	1.00
08/16/2023 02:00	0	1.6	6.6	14.5	7.8	887,344.2	0.00	1.00
08/16/2023 03:00	0	1.6	6.7	14.4	8.6	872,850.0	0.00	1.00
08/16/2023 04:00	0	1.7	6.6	14.5	8.7	904,676.0	0.00	1.00
08/16/2023 05:00	0	1.6	6.7	14.5	10.5	974,217.1	0.00	1.00
08/16/2023 06:00	0	1.6	6.7	14.5	10.7	979,352.4	0.00	1.00
08/16/2023 07:00	0	1.6	6.7	14.5	9.3	933,562.3	0.00	1.00
08/16/2023 08:00	0	1.6	6.3	14.5	7.0	928,640.9	0.00	1.00
08/16/2023 09:00	0	1.6	6.5	14.5	4.9	897,614.9	0.00	1.00
08/16/2023 10:00	0	1.6	6.5	14.5	7.0	913,662.8	0.00	1.00
08/16/2023 11:00	0	1.6	6.7	14.5	10.1	944,474.9	0.00	1.00
08/16/2023 12:00	0	1.6	6.4	14.5	8.5	967,797.9	0.00	1.00
08/16/2023 13:00	0	1.7	6.9	14.3	10.8	947,185.2	0.00	1.00
08/16/2023 14:00	1	2.4	11.4	12.1	27.7	985,051.9	0.00	1.00
08/16/2023 15:00	1	2.3	11.5	11.9	29.8	977,160.4	0.00	1.00
08/16/2023 16:00	1	2.3	11.6	11.9	30.4	977,160.4	0.00	1.00
08/16/2023 17:00	1	2.3	11.5	11.9	30.2	972,747.8	0.00	1.00
08/16/2023 18:00	1	2.3	11.5	12.1	27.2	975,403.6	0.00	1.00
08/16/2023 19:00	1	2.3	11.2	11.9	28.0	968,335.2	0.00	1.00
08/16/2023 20:00	1	2.2	11.8	12.2	26.4	985,513.3	0.00	1.00
08/16/2023 21:00	1	2.1	11.4	12.6	22.3	986,645.5	0.00	1.00
08/16/2023 22:00	1	2.1	10.8	12.7	21.2	982,812.5	0.00	1.00
08/16/2023 23:00	0	1.6	6.4	14.5	4.4	947,684.5	0.00	1.00
Average/Sum#:	0	1.9	8.4	13.6	15.4	951,672.5	0.00 #	24.00 #
Minimum:	0	1.6	6.3	11.9	4.4	872,850.0	0.00	1.00
Maximum:	1	2.4	11.8	14.5	30.4	986,645.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2023 00:00	0	1.6	6.3	14.5	6.2	968,439.8	0.00	1.00
08/17/2023 01:00	0	1.7	6.0	14.5	4.2	954,317.6	0.00	1.00
08/17/2023 02:00	0	1.7	6.3	14.5	8.0	969,723.6	0.00	1.00
08/17/2023 03:00	0	1.6	6.3	14.5	9.1	976,784.7	0.00	1.00
08/17/2023 04:00	0	1.6	6.5	14.5	8.2	969,081.7	0.00	1.00
08/17/2023 05:00	0	1.6	6.4	14.5	10.0	977,640.6	0.00	1.00
08/17/2023 06:00	0	1.6	6.4	14.5	9.5	974,217.1	0.00	1.00
08/17/2023 07:00	0	1.6	6.5	14.3	3.1	805,678.0	0.00	1.00
08/17/2023 08:00	0	1.6	6.4	14.4	0.2	780,571.9	0.00	1.00
08/17/2023 09:00	0	1.7	6.4	14.4	0.7	779,518.5	0.00	1.00
08/17/2023 10:00	0	1.6	6.4	14.4	0.3	778,465.1	0.00	1.00
08/17/2023 11:00	0	1.6	6.3	14.5	1.2	804,750.8	0.00	1.00
08/17/2023 12:00	0	1.6	6.4	14.5	6.6	905,317.9	0.00	1.00
08/17/2023 13:00	0	1.6	6.4	14.5	7.9	953,675.7	0.00	1.00
08/17/2023 14:00	0	1.5	6.0	14.4	1.7	851,360.6	0.00	1.00
08/17/2023 15:00	0	1.6	6.2	14.3	0.9	782,854.3	0.00	1.00
08/17/2023 16:00	0	1.6	5.9	14.4	1.5	834,084.8	0.00	1.00
08/17/2023 17:00	0	1.7	6.7	14.3	6.1	871,866.9	0.00	1.00
08/17/2023 18:00	0	1.9	9.5	13.4	15.9	973,934.6	0.00	1.00
08/17/2023 19:00	0	1.9	9.2	13.4	15.9	972,291.3	0.00	1.00
08/17/2023 20:00	0	1.9	8.9	13.5	15.7	977,658.0	0.00	1.00
08/17/2023 21:00	0	1.5	6.3	14.3	2.6	826,219.4	0.00	1.00
08/17/2023 22:00	0	1.6	6.2	14.4	5.1	894,760.8	0.00	1.00
08/17/2023 23:00	0	1.6	6.3	14.4	5.4	876,431.6	0.00	1.00
Average/Sum#:	0	1.6	6.7	14.3	6.1	894,151.9	0.00 #	24.00 #
Minimum:	0	1.5	5.9	13.4	0.2	778,465.1	0.00	1.00
Maximum:	0	1.9	9.5	14.5	15.9	977,658.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2023 00:00	0	1.6	6.5	14.4	2.6	819,758.5	0.00	1.00
08/18/2023 01:00	0	1.7	6.6	14.3	0.8	767,500.1	0.00	1.00
08/18/2023 02:00	0	1.7	6.6	14.3	0.7	767,707.6	0.00	1.00
08/18/2023 03:00	0	1.7	6.6	14.3	1.8	768,537.6	0.00	1.00
08/18/2023 04:00	0	1.7	6.6	14.3	0.8	767,500.1	0.00	1.00
08/18/2023 05:00	0	1.7	6.6	14.3	1.2	771,027.4	0.00	1.00
08/18/2023 06:00	0	1.6	6.8	14.3	5.9	820,202.2	0.00	1.00
08/18/2023 07:00	0	1.7	6.9	14.3	2.7	776,422.1	0.00	1.00
08/18/2023 08:00	0	1.7	6.9	14.3	3.1	771,234.9	0.00	1.00
08/18/2023 09:00	0	1.7	7.0	14.3	1.9	770,405.0	0.00	1.00
08/18/2023 10:00	0	1.7	6.9	14.3	1.3	769,367.5	0.00	1.00
08/18/2023 11:00	0	1.7	6.8	14.4	1.1	779,939.9	0.00	1.00
08/18/2023 12:00	0	1.6	6.5	14.4	0.5	778,254.4	0.00	1.00
08/18/2023 13:00	0	1.6	6.5	14.4	0.3	781,836.0	0.00	1.00
08/18/2023 14:00	0	1.6	6.5	14.4	0.4	778,465.1	0.00	1.00
08/18/2023 15:00	0	1.6	6.5	14.4	0.6	774,883.5	0.00	1.00
08/18/2023 16:00	0	1.6	6.5	14.5	0.6	792,768.3	0.00	1.00
08/18/2023 17:00	0	1.6	6.5	14.5	0.6	796,619.8	0.00	1.00
08/18/2023 18:00	0	1.6	6.6	14.5	0.7	786,991.1	0.00	1.00
08/18/2023 19:00	0	1.6	6.6	14.5	0.8	786,349.2	0.00	1.00
08/18/2023 20:00	0	1.6	6.6	14.4	0.8	774,883.5	0.00	1.00
08/18/2023 21:00	0	1.6	6.4	14.4	0.4	776,147.6	0.00	1.00
08/18/2023 22:00	0	1.6	6.5	14.4	0.7	776,990.3	0.00	1.00
08/18/2023 23:00	0	1.7	6.6	14.4	0.6	779,939.9	0.00	1.00
Average/Sum#:	0	1.6	6.6	14.4	1.3	780,572.2	0.00 #	24.00 #
Minimum:	0	1.6	6.4	14.3	0.3	767,500.1	0.00	1.00
Maximum:	0	1.7	7.0	14.5	5.9	820,202.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2023 00:00	0	1.7	6.7	14.4	2.7	806,907.0	0.00	1.00
08/19/2023 01:00	0	1.7	6.7	14.3	0.8	767,500.1	0.00	1.00
08/19/2023 02:00	0	1.7	6.9	14.3	1.0	767,085.1	0.00	1.00
08/19/2023 03:00	0	1.7	6.8	14.3	2.2	767,500.1	0.00	1.00
08/19/2023 04:00	0	1.7	6.9	14.3	1.9	767,707.6	0.00	1.00
08/19/2023 05:00	0	1.7	6.8	14.3	2.1	767,915.1	0.00	1.00
08/19/2023 06:00	0	1.7	6.8	14.3	1.5	767,292.6	0.00	1.00
08/19/2023 07:00	0	1.7	6.8	14.3	1.5	767,292.6	0.00	1.00
08/19/2023 08:00	0	1.7	6.8	14.3	0.9	766,047.7	0.00	1.00
08/19/2023 09:00	0	1.7	6.8	14.4	0.9	776,358.3	0.00	1.00
08/19/2023 10:00	0	1.6	6.8	14.4	1.1	774,883.5	0.00	1.00
08/19/2023 11:00	0	1.6	6.8	14.4	1.1	777,201.0	0.00	1.00
08/19/2023 12:00	0	1.6	6.8	14.4	0.9	779,518.5	0.00	1.00
08/19/2023 13:00	0	1.6	6.6	14.5	0.8	791,484.5	0.00	1.00
08/19/2023 14:00	0	1.6	6.6	14.5	0.8	789,558.7	0.00	1.00
08/19/2023 15:00	0	1.5	6.4	14.5	0.2	789,986.7	0.00	1.00
08/19/2023 16:00	0	1.6	6.4	14.5	0.4	789,558.7	0.00	1.00
08/19/2023 17:00	0	1.6	6.5	14.5	0.6	784,423.4	0.00	1.00
08/19/2023 18:00	0	1.6	6.5	14.5	0.6	784,637.4	0.00	1.00
08/19/2023 19:00	0	1.6	6.5	14.4	0.5	774,251.5	0.00	1.00
08/19/2023 20:00	0	1.6	6.5	14.4	1.1	774,883.5	0.00	1.00
08/19/2023 21:00	0	1.6	6.5	14.4	0.6	775,094.2	0.00	1.00
08/19/2023 22:00	0	1.6	6.7	14.4	1.2	779,518.5	0.00	1.00
08/19/2023 23:00	0	1.6	6.8	14.4	3.3	801,007.9	0.00	1.00
Average/Sum#:	0	1.6	6.7	14.4	1.2	778,650.6	0.00 #	24.00 #
Minimum:	0	1.5	6.4	14.3	0.2	766,047.7	0.00	1.00
Maximum:	0	1.7	6.9	14.5	3.3	806,907.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2023 00:00	0	1.7	6.8	14.5	6.6	845,833.5	0.00	1.00
08/20/2023 01:00	0	1.6	6.8	14.4	2.6	807,117.7	0.00	1.00
08/20/2023 02:00	0	1.7	7.0	14.4	2.5	823,129.4	0.00	1.00
08/20/2023 03:00	0	1.7	6.9	14.4	3.6	824,604.2	0.00	1.00
08/20/2023 04:00	0	1.6	6.8	14.4	2.5	806,274.9	0.00	1.00
08/20/2023 05:00	0	1.7	6.7	14.4	1.2	778,886.5	0.00	1.00
08/20/2023 06:00	0	1.7	6.7	14.4	0.8	777,833.1	0.00	1.00
08/20/2023 07:00	0	1.7	6.7	14.4	0.8	777,201.0	0.00	1.00
08/20/2023 08:00	0	1.7	6.6	14.4	0.5	776,147.6	0.00	1.00
08/20/2023 09:00	0	1.6	6.6	14.4	0.4	775,515.6	0.00	1.00
08/20/2023 10:00	0	1.6	6.6	14.4	0.5	775,936.9	0.00	1.00
08/20/2023 11:00	0	1.6	6.4	14.4	0.6	775,094.2	0.00	1.00
08/20/2023 12:00	0	1.6	6.4	14.4	0.3	774,462.2	0.00	1.00
08/20/2023 13:00	0	1.6	6.4	14.4	0.6	775,515.6	0.00	1.00
08/20/2023 14:00	0	1.6	6.5	14.4	0.6	775,304.9	0.00	1.00
08/20/2023 15:00	0	1.6	6.4	14.4	0.5	775,936.9	0.00	1.00
08/20/2023 16:00	0	1.6	6.5	14.4	0.5	777,201.0	0.00	1.00
08/20/2023 17:00	0	1.6	6.5	14.4	0.4	774,883.5	0.00	1.00
08/20/2023 18:00	0	1.6	6.5	14.4	0.8	774,672.8	0.00	1.00
08/20/2023 19:00	0	1.6	6.4	14.4	0.5	774,462.2	0.00	1.00
08/20/2023 20:00	0	1.6	6.4	14.4	0.6	775,094.2	0.00	1.00
08/20/2023 21:00	0	1.6	6.5	14.4	0.6	775,304.9	0.00	1.00
08/20/2023 22:00	0	1.6	6.4	14.4	0.5	775,094.2	0.00	1.00
08/20/2023 23:00	0	1.6	6.5	14.4	0.3	775,304.9	0.00	1.00
Average/Sum#:	0	1.6	6.6	14.4	1.2	785,283.8	0.00 #	24.00 #
Minimum:	0	1.6	6.4	14.4	0.3	774,462.2	0.00	1.00
Maximum:	0	1.7	7.0	14.5	6.6	845,833.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/21/2023 00:00	0	1.6	6.5	14.4	0.3	773,830.1	0.00	1.00
08/21/2023 01:00	0	1.7	6.5	14.4	0.5	772,776.7	0.00	1.00
08/21/2023 02:00	0	1.8	6.6	14.4	1.2	775,515.6	0.00	1.00
08/21/2023 03:00	0	1.6	6.6	14.4	0.4	775,936.9	0.00	1.00
08/21/2023 04:00	0	2.2	7.6	14.4	0.2	756,975.7	0.13	1.00
08/21/2023 05:00	0	27.0	35.5	16.8	0.0	455,250.1	0.07	0.07
08/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2023 13:00	0	13.9	15.5	15.9	0.7	768,521.0	0.58	0.58
08/21/2023 14:00	0	2.2	7.7	14.4	9.1	796,372.9	0.40	1.00
08/21/2023 15:00	0	1.7	7.7	14.4	8.7	789,420.5	0.00	1.00
08/21/2023 16:00	0	1.7	7.7	14.4	8.4	787,313.7	0.00	1.00
08/21/2023 17:00	0	1.7	7.5	14.4	6.9	775,936.9	0.00	1.00
08/21/2023 18:00	0	1.7	7.4	14.4	7.2	776,358.3	0.00	1.00
08/21/2023 19:00	0	1.7	7.4	14.4	7.2	778,043.7	0.00	1.00
08/21/2023 20:00	0	1.7	7.4	14.3	6.6	766,670.2	0.00	1.00
08/21/2023 21:00	0	1.7	7.3	14.3	7.2	767,707.6	0.00	1.00
08/21/2023 22:00	0	1.7	7.4	14.3	7.9	767,915.1	0.00	1.00
08/21/2023 23:00	0	1.7	7.3	14.3	7.5	767,915.1	0.00	1.00
Average/Sum#:	0	4.0	9.4	14.6	4.7	756,027.1	1.18 #	15.65 #
Minimum:	0	1.6	6.5	14.3	0.0	455,250.1	0.00	0.00
Maximum:	0	27.0	35.5	16.8	9.1	796,372.9	0.58	1.00
%SI	37.50	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2023 00:00	0	1.7	7.3	14.3	7.9	767,915.1	0.00	1.00
08/22/2023 01:00	0	1.7	7.4	14.3	8.1	768,122.6	0.00	1.00
08/22/2023 02:00	0	1.7	7.5	14.3	8.1	767,915.1	0.00	1.00
08/22/2023 03:00	0	1.7	7.4	14.3	8.1	768,330.1	0.00	1.00
08/22/2023 04:00	0	1.7	7.4	14.3	8.4	768,122.6	0.00	1.00
08/22/2023 05:00	0	1.7	7.4	14.3	7.9	768,952.5	0.00	1.00
08/22/2023 06:00	0	1.7	7.4	14.3	8.4	783,891.7	0.00	1.00
08/22/2023 07:00	0	1.7	7.6	14.3	9.6	768,745.1	0.00	1.00
08/22/2023 08:00	0	1.7	7.7	14.3	9.4	768,330.1	0.00	1.00
08/22/2023 09:00	0	1.7	7.5	14.4	8.8	779,307.8	0.00	1.00
08/22/2023 10:00	0	1.7	7.3	14.4	8.7	779,729.2	0.00	1.00
08/22/2023 11:00	0	1.7	7.4	14.4	9.1	779,097.1	0.00	1.00
08/22/2023 12:00	0	1.7	7.2	14.4	6.7	776,990.3	0.00	1.00
08/22/2023 13:00	0	1.7	7.2	14.4	5.9	776,358.3	0.00	1.00
08/22/2023 14:00	0	1.6	7.1	14.4	6.3	776,147.6	0.00	1.00
08/22/2023 15:00	0	1.7	7.2	14.4	6.1	775,304.9	0.00	1.00
08/22/2023 16:00	0	1.7	7.1	14.4	6.1	775,726.2	0.00	1.00
08/22/2023 17:00	0	1.6	7.0	14.5	5.9	804,536.8	0.00	1.00
08/22/2023 18:00	0	1.6	7.1	14.5	8.0	834,279.0	0.00	1.00
08/22/2023 19:00	0	1.6	6.7	14.5	9.5	937,413.8	0.00	1.00
08/22/2023 20:00	0	1.6	6.8	14.3	5.5	802,773.2	0.00	1.00
08/22/2023 21:00	0	1.7	6.7	14.4	8.0	869,268.5	0.00	1.00
08/22/2023 22:00	0	1.6	6.9	14.4	6.1	832,820.7	0.00	1.00
08/22/2023 23:00	0	1.7	7.2	14.4	7.3	797,637.0	0.00	1.00
Average/Sum#:	0	1.7	7.2	14.4	7.7	792,821.5	0.00 #	24.00 #
Minimum:	0	1.6	6.7	14.3	5.5	767,915.1	0.00	1.00
Maximum:	0	1.7	7.7	14.5	9.6	937,413.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2023 00:00	0	1.7	7.2	14.4	8.4	776,779.6	0.00	1.00
08/23/2023 01:00	0	1.7	7.3	14.4	7.9	777,201.0	0.00	1.00
08/23/2023 02:00	0	1.7	7.4	14.4	7.6	778,043.7	0.00	1.00
08/23/2023 03:00	0	1.7	7.4	14.3	8.0	766,462.7	0.00	1.00
08/23/2023 04:00	0	1.7	7.3	14.3	7.9	767,292.6	0.00	1.00
08/23/2023 05:00	0	1.7	7.1	14.4	8.2	815,334.2	0.00	1.00
08/23/2023 06:00	0	1.7	7.3	14.4	10.1	861,684.0	0.00	1.00
08/23/2023 07:00	0	1.7	7.6	14.3	9.2	776,007.2	0.00	1.00
08/23/2023 08:00	0	1.7	7.6	14.3	8.7	768,330.1	0.00	1.00
08/23/2023 09:00	0	1.7	7.6	14.4	9.9	779,097.1	0.00	1.00
08/23/2023 10:00	0	1.6	7.5	14.4	8.2	777,411.7	0.00	1.00
08/23/2023 11:00	0	1.7	7.2	14.4	4.8	775,726.2	0.00	1.00
08/23/2023 12:00	0	1.7	7.1	14.4	5.4	775,304.9	0.00	1.00
08/23/2023 13:00	0	1.7	7.1	14.5	6.3	785,921.2	0.00	1.00
08/23/2023 14:00	0	1.6	7.0	14.5	7.7	859,955.7	0.00	1.00
08/23/2023 15:00	0	1.6	7.3	14.5	11.2	977,854.6	0.00	1.00
08/23/2023 16:00	0	1.6	7.2	14.5	11.3	976,784.7	0.00	1.00
08/23/2023 17:00	0	1.8	8.2	14.1	12.0	921,944.8	0.00	1.00
08/23/2023 18:00	1	2.1	11.2	13.0	22.7	1,000,719.9	0.00	1.00
08/23/2023 19:00	1	2.1	12.0	12.6	25.8	997,204.9	0.00	1.00
08/23/2023 20:00	0	1.8	9.3	13.7	16.1	989,028.7	0.00	1.00
08/23/2023 21:00	0	1.8	8.6	13.9	14.2	968,378.7	0.00	1.00
08/23/2023 22:00	0	1.6	6.7	14.5	10.7	966,942.0	0.00	1.00
08/23/2023 23:00	0	1.6	7.0	14.4	9.4	889,704.5	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.2	10.5	855,379.8	0.00 #	24.00 #
Minimum:	0	1.6	6.7	12.6	4.8	766,462.7	0.00	1.00
Maximum:	1	2.1	12.0	14.5	25.8	1,000,719.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2023 00:00	0	1.7	6.9	14.4	9.0	885,069.5	0.00	1.00
08/24/2023 01:00	0	1.7	7.0	14.3	6.2	768,745.1	0.00	1.00
08/24/2023 02:00	0	1.7	7.2	14.4	7.4	776,990.3	0.00	1.00
08/24/2023 03:00	0	1.7	7.2	14.4	7.7	776,990.3	0.00	1.00
08/24/2023 04:00	0	1.7	7.1	14.4	9.0	837,034.3	0.00	1.00
08/24/2023 05:00	0	1.7	7.3	14.4	10.4	892,654.0	0.00	1.00
08/24/2023 06:00	0	1.6	7.3	14.5	12.0	970,365.6	0.00	1.00
08/24/2023 07:00	0	1.6	7.4	14.4	8.6	826,921.6	0.00	1.00
08/24/2023 08:00	0	1.7	7.1	14.3	4.3	766,047.7	0.00	1.00
08/24/2023 09:00	0	1.7	7.1	14.4	6.6	776,358.3	0.00	1.00
08/24/2023 10:00	0	1.6	7.1	14.4	6.8	775,094.2	0.00	1.00
08/24/2023 11:00	0	1.7	7.1	14.4	5.5	774,883.5	0.00	1.00
08/24/2023 12:00	0	1.6	7.0	14.5	3.3	787,205.0	0.00	1.00
08/24/2023 13:00	0	1.6	6.9	14.5	1.5	786,563.1	0.00	1.00
08/24/2023 14:00	0	1.7	7.0	14.5	5.6	784,851.4	0.00	1.00
08/24/2023 15:00	0	1.6	7.0	14.5	3.7	784,851.4	0.00	1.00
08/24/2023 16:00	0	1.6	6.8	14.5	1.9	784,851.4	0.00	1.00
08/24/2023 17:00	0	1.6	6.9	14.5	3.7	784,423.4	0.00	1.00
08/24/2023 18:00	0	1.7	7.0	14.5	7.0	815,877.4	0.00	1.00
08/24/2023 19:00	0	1.6	6.7	14.3	3.0	783,269.2	0.00	1.00
08/24/2023 20:00	0	1.7	6.8	14.4	4.5	779,518.5	0.00	1.00
08/24/2023 21:00	0	1.6	6.8	14.4	4.7	829,871.2	0.00	1.00
08/24/2023 22:00	0	1.7	7.0	14.5	7.7	853,964.5	0.00	1.00
08/24/2023 23:00	0	1.7	7.0	14.4	6.4	785,628.2	0.00	1.00
Average/Sum#:	0	1.7	7.0	14.4	6.1	807,834.5	0.00 #	24.00 #
Minimum:	0	1.6	6.7	14.3	1.5	766,047.7	0.00	1.00
Maximum:	0	1.7	7.4	14.5	12.0	970,365.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2023 00:00	0	1.7	7.0	14.4	8.3	839,773.2	0.00	1.00
08/25/2023 01:00	0	1.7	7.3	14.3	8.9	782,854.3	0.00	1.00
08/25/2023 02:00	0	1.7	7.6	14.3	9.0	772,687.3	0.00	1.00
08/25/2023 03:00	0	1.7	7.6	14.3	9.7	770,405.0	0.00	1.00
08/25/2023 04:00	0	1.7	7.5	14.3	9.4	792,813.7	0.00	1.00
08/25/2023 05:00	0	1.7	7.0	14.4	11.3	943,638.7	0.00	1.00
08/25/2023 06:00	0	1.7	7.2	14.4	11.7	915,196.8	0.00	1.00
08/25/2023 07:00	0	1.7	7.8	14.3	9.9	774,139.8	0.00	1.00
08/25/2023 08:00	0	1.7	7.7	14.3	9.8	769,575.0	0.00	1.00
08/25/2023 09:00	0	1.7	7.6	14.3	9.2	769,160.0	0.00	1.00
08/25/2023 10:00	0	1.7	7.6	14.3	9.4	768,122.6	0.00	1.00
08/25/2023 11:00	0	1.7	7.6	14.4	9.2	779,307.8	0.00	1.00
08/25/2023 12:00	0	1.7	7.5	14.4	8.9	779,307.8	0.00	1.00
08/25/2023 13:00	0	1.6	7.2	14.4	5.0	778,043.7	0.00	1.00
08/25/2023 14:00	0	1.7	7.3	14.5	7.6	788,060.9	0.00	1.00
08/25/2023 15:00	0	1.6	7.3	14.5	7.6	787,419.0	0.00	1.00
08/25/2023 16:00	0	1.6	7.3	14.5	7.6	787,419.0	0.00	1.00
08/25/2023 17:00	0	1.6	7.3	14.5	8.1	786,563.1	0.00	1.00
08/25/2023 18:00	0	1.6	7.3	14.5	9.1	787,419.0	0.00	1.00
08/25/2023 19:00	0	1.6	7.4	14.5	9.7	788,274.9	0.00	1.00
08/25/2023 20:00	0	1.6	7.3	14.4	8.6	777,201.0	0.00	1.00
08/25/2023 21:00	0	1.7	7.3	14.4	7.6	782,468.0	0.00	1.00
08/25/2023 22:00	0	1.7	7.1	14.4	7.0	779,729.2	0.00	1.00
08/25/2023 23:00	0	1.7	7.1	14.4	7.2	781,836.0	0.00	1.00
Average/Sum#:	0	1.7	7.4	14.4	8.7	795,059.0	0.00 #	24.00 #
Minimum:	0	1.6	7.0	14.3	5.0	768,122.6	0.00	1.00
Maximum:	0	1.7	7.8	14.5	11.7	943,638.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2023 00:00	0	1.7	7.0	14.5	9.4	902,750.2	0.00	1.00
08/26/2023 01:00	0	1.6	7.2	14.4	10.8	896,657.0	0.00	1.00
08/26/2023 02:00	0	1.7	7.5	14.4	8.9	820,811.9	0.00	1.00
08/26/2023 03:00	0	1.7	7.4	14.4	9.9	841,669.3	0.00	1.00
08/26/2023 04:00	0	1.7	7.4	14.3	9.6	822,899.6	0.00	1.00
08/26/2023 05:00	0	1.7	7.2	14.4	10.8	889,072.4	0.00	1.00
08/26/2023 06:00	0	1.7	7.3	14.4	11.3	899,185.1	0.00	1.00
08/26/2023 07:00	0	1.7	7.8	14.3	10.0	772,479.8	0.00	1.00
08/26/2023 08:00	0	1.7	7.8	14.3	9.4	772,064.9	0.00	1.00
08/26/2023 09:00	0	1.7	7.7	14.3	9.1	771,234.9	0.00	1.00
08/26/2023 10:00	0	1.7	7.7	14.4	9.6	781,836.0	0.00	1.00
08/26/2023 11:00	0	1.7	7.5	14.4	9.0	780,782.6	0.00	1.00
08/26/2023 12:00	0	1.6	7.3	14.4	6.6	778,675.8	0.00	1.00
08/26/2023 13:00	0	1.6	7.1	14.5	6.1	789,558.7	0.00	1.00
08/26/2023 14:00	0	1.6	7.2	14.5	7.0	788,274.9	0.00	1.00
08/26/2023 15:00	0	1.6	7.2	14.5	7.8	786,991.1	0.00	1.00
08/26/2023 16:00	0	1.6	7.4	14.5	9.1	787,205.0	0.00	1.00
08/26/2023 17:00	0	1.6	7.2	14.5	8.7	828,715.7	0.00	1.00
08/26/2023 18:00	0	1.7	7.0	14.4	4.2	812,384.7	0.00	1.00
08/26/2023 19:00	0	1.7	6.8	14.3	2.8	771,234.9	0.00	1.00
08/26/2023 20:00	0	1.7	6.8	14.3	4.4	785,966.6	0.00	1.00
08/26/2023 21:00	0	1.6	6.8	14.3	3.3	785,551.6	0.00	1.00
08/26/2023 22:00	0	1.7	7.1	14.3	7.3	798,415.9	0.00	1.00
08/26/2023 23:00	0	1.7	7.2	14.3	8.4	800,283.3	0.00	1.00
Average/Sum#:	0	1.7	7.3	14.4	8.1	811,029.2	0.00 #	24.00 #
Minimum:	0	1.6	6.8	14.3	2.8	771,234.9	0.00	1.00
Maximum:	0	1.7	7.8	14.5	11.3	902,750.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2023 00:00	0	1.7	7.2	14.3	8.9	823,937.0	0.00	1.00
08/27/2023 01:00	0	1.7	7.3	14.3	9.0	794,681.1	0.00	1.00
08/27/2023 02:00	0	1.7	7.5	14.3	8.4	774,139.8	0.00	1.00
08/27/2023 03:00	0	1.6	7.7	14.3	8.5	787,834.0	0.00	1.00
08/27/2023 04:00	0	1.7	7.7	14.3	10.0	777,667.1	0.00	1.00
08/27/2023 05:00	0	1.7	7.4	14.4	10.5	855,363.5	0.00	1.00
08/27/2023 06:00	0	1.7	7.5	14.4	11.4	885,912.2	0.00	1.00
08/27/2023 07:00	0	1.7	7.8	14.3	10.2	771,442.4	0.00	1.00
08/27/2023 08:00	0	1.7	7.8	14.3	9.5	770,819.9	0.00	1.00
08/27/2023 09:00	0	1.7	7.8	14.4	10.1	781,203.9	0.00	1.00
08/27/2023 10:00	0	1.7	7.8	14.4	9.8	779,939.9	0.00	1.00
08/27/2023 11:00	0	1.6	7.5	14.4	8.8	778,465.1	0.00	1.00
08/27/2023 12:00	0	1.6	7.2	14.4	5.0	778,465.1	0.00	1.00
08/27/2023 13:00	0	1.7	7.2	14.5	7.8	793,838.2	0.00	1.00
08/27/2023 14:00	0	1.6	7.3	14.5	8.5	792,554.4	0.00	1.00
08/27/2023 15:00	0	1.6	7.2	14.5	8.5	804,750.8	0.00	1.00
08/27/2023 16:00	0	1.6	7.2	14.5	7.7	812,239.8	0.00	1.00
08/27/2023 17:00	0	1.6	7.1	14.6	9.2	876,866.3	0.00	1.00
08/27/2023 18:00	0	1.6	7.2	14.4	5.2	778,675.8	0.00	1.00
08/27/2023 19:00	0	1.7	6.8	14.4	6.6	854,520.8	0.00	1.00
08/27/2023 20:00	0	1.6	6.8	14.5	10.8	969,723.6	0.00	1.00
08/27/2023 21:00	0	1.6	6.8	14.5	11.0	971,221.4	0.00	1.00
08/27/2023 22:00	0	1.6	7.0	14.5	11.3	961,592.7	0.00	1.00
08/27/2023 23:00	0	1.6	7.3	14.5	10.3	876,003.7	0.00	1.00
Average/Sum#:	0	1.7	7.3	14.4	9.0	827,160.8	0.00 #	24.00 #
Minimum:	0	1.6	6.8	14.3	5.0	770,819.9	0.00	1.00
Maximum:	0	1.7	7.8	14.6	11.4	971,221.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2023 00:00	0	1.7	7.4	14.4	8.8	813,859.4	0.00	1.00
08/28/2023 01:00	0	1.7	7.3	14.4	8.6	778,886.5	0.00	1.00
08/28/2023 02:00	0	1.7	7.5	14.4	8.8	779,729.2	0.00	1.00
08/28/2023 03:00	0	1.7	7.4	14.4	9.0	779,939.9	0.00	1.00
08/28/2023 04:00	0	1.7	7.4	14.4	9.1	784,153.5	0.00	1.00
08/28/2023 05:00	0	1.7	7.2	14.4	10.5	920,253.2	0.00	1.00
08/28/2023 06:00	0	1.6	7.5	14.5	12.9	1,013,374.0	0.00	1.00
08/28/2023 07:00	0	1.7	7.7	14.4	10.7	852,414.0	0.00	1.00
08/28/2023 08:00	0	1.7	7.7	14.3	10.1	769,160.0	0.00	1.00
08/28/2023 09:00	0	1.7	7.7	14.4	10.4	780,571.9	0.00	1.00
08/28/2023 10:00	0	1.7	7.6	14.4	9.8	778,886.5	0.00	1.00
08/28/2023 11:00	0	1.6	7.3	14.4	8.4	780,361.2	0.00	1.00
08/28/2023 12:00	0	1.7	7.1	14.5	6.6	804,750.8	0.00	1.00
08/28/2023 13:00	0	1.6	7.1	14.6	8.8	889,691.1	0.00	1.00
08/28/2023 14:00	0	1.6	6.8	14.6	10.1	967,943.9	0.00	1.00
08/28/2023 15:00	0	1.6	7.0	14.6	9.7	976,856.1	0.00	1.00
08/28/2023 16:00	0	1.6	6.9	14.5	8.5	923,505.6	0.00	1.00
08/28/2023 17:00	0	1.6	6.9	14.4	3.2	776,569.0	0.00	1.00
08/28/2023 18:00	0	1.7	6.9	14.5	7.6	854,606.4	0.00	1.00
08/28/2023 19:00	0	1.8	10.1	13.7	17.3	994,354.3	0.00	1.00
08/28/2023 20:00	0	1.7	8.5	14.1	11.4	907,042.3	0.00	1.00
08/28/2023 21:00	0	1.6	6.8	14.4	5.4	823,761.4	0.00	1.00
08/28/2023 22:00	0	1.7	7.0	14.4	7.0	836,402.3	0.00	1.00
08/28/2023 23:00	0	1.7	7.2	14.3	8.5	787,004.0	0.00	1.00
Average/Sum#:	0	1.7	7.4	14.4	9.2	848,919.9	0.00 #	24.00 #
Minimum:	0	1.6	6.8	13.7	3.2	769,160.0	0.00	1.00
Maximum:	0	1.8	10.1	14.6	17.3	1,013,374.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2023 00:00	0	1.7	7.2	14.4	9.0	838,298.4	0.00	1.00
08/29/2023 01:00	0	1.7	7.1	14.4	10.2	909,929.8	0.00	1.00
08/29/2023 02:00	0	1.7	7.5	14.5	11.1	899,112.7	0.00	1.00
08/29/2023 03:00	0	1.6	7.5	14.4	11.4	864,844.2	0.00	1.00
08/29/2023 04:00	0	1.7	7.4	14.4	11.3	872,850.0	0.00	1.00
08/29/2023 05:00	0	1.6	7.3	14.5	12.0	950,680.1	0.00	1.00
08/29/2023 06:00	0	1.7	7.2	14.4	11.6	931,840.6	0.00	1.00
08/29/2023 07:00	0	1.7	8.4	14.3	16.2	1,021,881.1	0.00	1.00
08/29/2023 08:00	1	2.0	11.9	13.0	24.3	1,039,722.5	0.00	1.00
08/29/2023 09:00	1	2.1	13.1	12.5	27.8	1,029,839.7	0.00	1.00
08/29/2023 10:00	1	2.1	13.2	12.5	27.8	1,028,372.5	0.00	1.00
08/29/2023 11:00	1	2.2	13.3	12.4	28.4	1,018,046.2	0.00	1.00
08/29/2023 12:00	1	2.2	13.5	12.4	28.8	1,021,268.4	0.00	1.00
08/29/2023 13:00	1	2.2	13.5	12.3	29.2	1,012,577.9	0.00	1.00
08/29/2023 14:00	1	2.2	13.5	12.2	29.4	1,004,244.5	0.00	1.00
08/29/2023 15:00	1	2.2	13.5	12.2	29.6	1,004,559.4	0.00	1.00
08/29/2023 16:00	1	2.2	13.2	12.1	29.9	994,077.6	0.00	1.00
08/29/2023 17:00	0	1.7	8.5	14.1	12.4	965,847.0	0.00	1.00
08/29/2023 18:00	0	1.8	9.8	13.7	16.4	990,550.3	0.00	1.00
08/29/2023 19:00	0	1.7	8.7	14.0	11.5	905,804.8	0.00	1.00
08/29/2023 20:00	0	1.7	7.0	14.4	4.4	774,251.5	0.00	1.00
08/29/2023 21:00	0	1.6	7.1	14.4	7.2	774,040.8	0.00	1.00
08/29/2023 22:00	0	1.7	7.2	14.4	7.1	774,462.2	0.00	1.00
08/29/2023 23:00	0	1.7	7.1	14.4	6.3	775,726.2	0.00	1.00
Average/Sum#:	0	1.9	9.7	13.6	17.2	933,451.2	0.00 #	24.00 #
Minimum:	0	1.6	7.0	12.1	4.4	774,040.8	0.00	1.00
Maximum:	1	2.2	13.5	14.5	29.9	1,039,722.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2023 00:00	0	1.7	7.1	14.4	7.4	774,883.5	0.00	1.00
08/30/2023 01:00	0	1.7	7.2	14.4	7.4	775,094.2	0.00	1.00
08/30/2023 02:00	0	1.7	7.3	14.4	7.6	775,094.2	0.00	1.00
08/30/2023 03:00	0	1.7	7.4	14.3	8.3	763,972.8	0.00	1.00
08/30/2023 04:00	0	1.7	7.3	14.3	8.5	764,180.3	0.00	1.00
08/30/2023 05:00	0	1.7	7.6	14.3	10.0	765,632.7	0.00	1.00
08/30/2023 06:00	0	1.7	7.6	14.3	9.6	783,684.2	0.00	1.00
08/30/2023 07:00	0	1.7	7.9	14.4	10.4	834,927.5	0.00	1.00
08/30/2023 08:00	0	1.7	7.8	14.4	10.9	860,841.2	0.00	1.00
08/30/2023 09:00	1	2.2	13.4	12.5	28.5	1,031,470.0	0.00	1.00
08/30/2023 10:00	1	2.2	13.6	12.4	29.0	1,021,429.5	0.00	1.00
08/30/2023 11:00	1	2.2	13.7	12.4	29.6	1,024,329.4	0.00	1.00
08/30/2023 12:00	1	2.1	13.2	12.5	27.5	1,010,113.5	0.00	1.00
08/30/2023 13:00	0	1.8	9.6	13.7	16.1	989,409.1	0.00	1.00
08/30/2023 14:00	0	1.6	7.5	14.4	5.5	818,705.1	0.00	1.00
08/30/2023 15:00	0	1.7	7.1	14.5	3.7	782,711.6	0.00	1.00
08/30/2023 16:00	0	1.6	7.2	14.5	6.5	782,497.7	0.00	1.00
08/30/2023 17:00	0	1.6	7.2	14.5	6.4	780,999.8	0.00	1.00
08/30/2023 18:00	0	1.6	7.2	14.6	8.3	838,609.4	0.00	1.00
08/30/2023 19:00	0	1.6	7.2	14.5	6.7	785,279.3	0.00	1.00
08/30/2023 20:00	0	1.7	7.0	14.4	6.6	771,512.6	0.00	1.00
08/30/2023 21:00	0	1.6	7.0	14.4	4.7	772,355.4	0.00	1.00
08/30/2023 22:00	0	1.7	7.1	14.4	6.3	772,987.4	0.00	1.00
08/30/2023 23:00	0	1.7	7.1	14.4	6.0	772,987.4	0.00	1.00
Average/Sum#:	0	1.8	8.4	14.1	11.3	835,571.2	0.00 #	24.00 #
Minimum:	0	1.6	7.0	12.4	3.7	763,972.8	0.00	1.00
Maximum:	1	2.2	13.7	14.6	29.6	1,031,470.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2023 00:00	0	1.7	7.2	14.4	6.3	791,738.0	0.00	1.00
08/31/2023 01:00	0	1.7	7.3	14.4	8.3	773,830.1	0.00	1.00
08/31/2023 02:00	0	1.7	7.5	14.4	8.2	775,515.6	0.00	1.00
08/31/2023 03:00	0	1.7	7.4	14.4	8.3	774,040.8	0.00	1.00
08/31/2023 04:00	0	1.7	7.4	14.4	8.7	794,687.5	0.00	1.00
08/31/2023 05:00	0	1.6	7.3	14.5	10.0	893,121.5	0.00	1.00
08/31/2023 06:00	0	1.6	7.3	14.5	11.4	911,095.2	0.00	1.00
08/31/2023 07:00	0	1.6	7.5	14.4	8.8	790,684.6	0.00	1.00
08/31/2023 08:00	1	2.2	12.9	12.5	29.3	985,985.6	0.00	1.00
08/31/2023 09:00	1	2.2	13.6	12.1	32.1	996,878.7	0.00	1.00
08/31/2023 10:00	1	2.2	13.8	12.2	30.0	1,006,133.4	0.00	1.00
08/31/2023 11:00	1	2.2	13.7	12.2	30.0	1,005,031.6	0.00	1.00
08/31/2023 12:00	1	2.2	13.7	12.2	30.3	1,005,503.8	0.00	1.00
08/31/2023 13:00	1	2.2	13.5	12.1	30.8	996,256.2	0.00	1.00
08/31/2023 14:00	1	2.3	13.3	12.1	31.2	998,746.1	0.00	1.00
08/31/2023 15:00	1	2.3	13.3	12.1	31.3	997,812.4	0.00	1.00
08/31/2023 16:00	1	2.2	13.3	12.1	31.0	995,322.5	0.00	1.00
08/31/2023 17:00	0	1.8	9.7	13.6	15.3	971,165.8	0.00	1.00
08/31/2023 18:00	0	1.6	7.1	14.4	1.9	779,307.8	0.00	1.00
08/31/2023 19:00	0	1.7	7.1	14.4	5.4	772,566.0	0.00	1.00
08/31/2023 20:00	0	1.7	7.0	14.4	5.9	772,776.7	0.00	1.00
08/31/2023 21:00	0	1.7	6.9	14.4	4.2	774,251.5	0.00	1.00
08/31/2023 22:00	0	1.7	7.1	14.4	6.4	801,640.0	0.00	1.00
08/31/2023 23:00	0	1.7	7.0	14.3	6.2	765,010.3	0.00	1.00
Average/Sum#:	0	1.9	9.7	13.5	16.3	880,379.2	0.00 #	24.00 #
Minimum:	0	1.6	6.9	12.1	1.9	765,010.3	0.00	1.00
Maximum:	1	2.3	13.8	14.5	32.1	1,006,133.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2023 00:00	0	1.7	7.0	14.3	6.4	766,047.7	0.00	1.00
09/01/2023 01:00	0	1.7	7.0	14.3	6.4	765,632.7	0.00	1.00
09/01/2023 02:00	0	1.7	7.2	14.3	6.1	765,632.7	0.00	1.00
09/01/2023 03:00	0	1.7	7.1	14.3	6.7	766,047.7	0.00	1.00
09/01/2023 04:00	0	1.7	7.1	14.3	6.3	766,255.2	0.00	1.00
09/01/2023 05:00	0	1.7	7.1	14.3	6.9	781,194.4	0.00	1.00
09/01/2023 06:00	0	1.7	7.1	14.3	8.4	823,314.5	0.00	1.00
09/01/2023 07:00	0	1.7	7.4	14.4	9.8	853,678.1	0.00	1.00
09/01/2023 08:00	0	1.7	7.6	14.3	9.0	766,462.7	0.00	1.00
09/01/2023 09:00	0	1.7	7.6	14.3	9.0	768,952.5	0.00	1.00
09/01/2023 10:00	0	1.7	7.2	14.4	8.4	817,230.3	0.00	1.00
09/01/2023 11:00	0	1.7	7.6	14.3	9.1	766,047.7	0.00	1.00
09/01/2023 12:00	0	1.7	7.4	14.3	8.9	765,425.2	0.00	1.00
09/01/2023 13:00	0	1.7	7.5	14.4	10.0	776,358.3	0.00	1.00
09/01/2023 14:00	0	1.6	7.4	14.5	9.4	795,977.9	0.00	1.00
09/01/2023 15:00	0	1.6	7.0	14.6	8.4	873,823.2	0.00	1.00
09/01/2023 16:00	0	1.6	7.2	14.5	7.6	787,419.0	0.00	1.00
09/01/2023 17:00	0	1.6	7.0	14.5	7.4	786,349.2	0.00	1.00
09/01/2023 18:00	0	1.6	7.0	14.5	7.9	787,205.0	0.00	1.00
09/01/2023 19:00	0	1.6	7.1	14.5	9.4	788,060.9	0.00	1.00
09/01/2023 20:00	0	1.6	7.1	14.5	9.4	788,702.9	0.00	1.00
09/01/2023 21:00	0	1.6	7.5	14.4	10.3	779,729.2	0.00	1.00
09/01/2023 22:00	0	1.6	7.4	14.5	10.0	846,475.4	0.00	1.00
09/01/2023 23:00	0	1.6	7.3	14.5	10.2	826,790.0	0.00	1.00
Average/Sum#:	0	1.7	7.2	14.4	8.4	792,033.9	0.00 #	24.00 #
Minimum:	0	1.6	7.0	14.3	6.1	765,425.2	0.00	1.00
Maximum:	0	1.7	7.6	14.6	10.3	873,823.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2023 00:00	0	1.6	7.3	14.5	10.3	828,501.8	0.00	1.00
09/02/2023 01:00	0	1.6	7.5	14.4	10.7	789,420.5	0.00	1.00
09/02/2023 02:00	0	1.7	7.7	14.4	10.3	787,103.0	0.00	1.00
09/02/2023 03:00	0	1.7	7.7	14.4	10.7	793,423.4	0.00	1.00
09/02/2023 04:00	0	1.6	7.5	14.4	10.2	785,417.6	0.00	1.00
09/02/2023 05:00	0	1.6	7.3	14.5	10.1	839,628.3	0.00	1.00
09/02/2023 06:00	0	1.7	7.4	14.4	9.9	781,414.6	0.00	1.00
09/02/2023 07:00	0	1.7	7.4	14.4	10.1	782,678.7	0.00	1.00
09/02/2023 08:00	0	1.7	7.4	14.4	10.1	782,678.7	0.00	1.00
09/02/2023 09:00	0	1.7	7.3	14.4	9.3	792,159.3	0.00	1.00
09/02/2023 10:00	0	1.6	7.2	14.5	9.5	847,759.3	0.00	1.00
09/02/2023 11:00	0	1.6	7.0	14.6	10.4	934,251.7	0.00	1.00
09/02/2023 12:00	0	1.6	7.2	14.5	8.6	805,820.7	0.00	1.00
09/02/2023 13:00	0	1.6	7.0	14.5	9.4	840,912.2	0.00	1.00
09/02/2023 14:00	0	1.6	7.1	14.6	9.3	863,172.1	0.00	1.00
09/02/2023 15:00	0	1.6	7.2	14.7	11.9	991,507.4	0.00	1.00
09/02/2023 16:00	0	1.6	7.1	14.5	7.1	794,908.1	0.00	1.00
09/02/2023 17:00	0	1.6	6.9	14.5	7.5	811,170.0	0.00	1.00
09/02/2023 18:00	0	1.6	7.1	14.5	7.7	815,877.4	0.00	1.00
09/02/2023 19:00	0	1.6	7.2	14.5	7.3	797,903.7	0.00	1.00
09/02/2023 20:00	0	1.6	7.1	14.5	7.1	791,056.6	0.00	1.00
09/02/2023 21:00	0	1.6	7.0	14.5	8.2	801,969.2	0.00	1.00
09/02/2023 22:00	0	1.6	7.1	14.5	9.8	843,051.9	0.00	1.00
09/02/2023 23:00	0	1.6	7.0	14.5	9.2	791,056.6	0.00	1.00
Average/Sum#:	0	1.6	7.2	14.5	9.4	820,535.1	0.00 #	24.00 #
Minimum:	0	1.6	6.9	14.4	7.1	781,414.6	0.00	1.00
Maximum:	0	1.7	7.7	14.7	11.9	991,507.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2023 00:00	0	1.6	7.0	14.6	9.9	883,604.8	0.00	1.00
09/03/2023 01:00	0	1.6	7.1	14.5	8.3	812,239.8	0.00	1.00
09/03/2023 02:00	0	1.6	7.5	14.5	9.7	849,899.0	0.00	1.00
09/03/2023 03:00	0	1.6	7.4	14.5	9.1	811,170.0	0.00	1.00
09/03/2023 04:00	0	1.6	7.3	14.5	9.4	815,877.4	0.00	1.00
09/03/2023 05:00	0	1.6	7.3	14.5	9.3	814,379.6	0.00	1.00
09/03/2023 06:00	0	1.6	7.3	14.5	9.4	813,737.6	0.00	1.00
09/03/2023 07:00	0	1.6	7.3	14.5	9.4	820,156.8	0.00	1.00
09/03/2023 08:00	0	1.6	7.3	14.5	9.6	822,082.6	0.00	1.00
09/03/2023 09:00	0	1.6	7.2	14.5	9.2	832,139.3	0.00	1.00
09/03/2023 10:00	0	1.6	8.0	14.7	14.6	1,047,609.7	0.00	1.00
09/03/2023 11:00	0	1.6	7.7	14.6	11.7	944,685.5	0.00	1.00
09/03/2023 12:00	0	1.6	7.1	14.5	8.8	789,986.7	0.00	1.00
09/03/2023 13:00	0	1.6	7.0	14.5	8.7	789,772.7	0.00	1.00
09/03/2023 14:00	0	1.6	7.1	14.5	8.6	789,130.8	0.00	1.00
09/03/2023 15:00	0	1.6	7.1	14.6	8.6	801,221.9	0.00	1.00
09/03/2023 16:00	0	1.6	7.1	14.6	7.1	801,221.9	0.00	1.00
09/03/2023 17:00	0	1.6	7.1	14.6	7.1	801,004.6	0.00	1.00
09/03/2023 18:00	0	1.6	7.0	14.6	7.1	800,787.2	0.00	1.00
09/03/2023 19:00	0	1.6	7.0	14.5	6.1	789,344.8	0.00	1.00
09/03/2023 20:00	0	1.6	7.0	14.5	6.9	791,270.5	0.00	1.00
09/03/2023 21:00	0	1.6	7.1	14.5	8.5	821,440.7	0.00	1.00
09/03/2023 22:00	0	1.6	7.0	14.5	9.3	791,484.5	0.00	1.00
09/03/2023 23:00	0	1.6	7.0	14.5	9.3	791,912.4	0.00	1.00
Average/Sum#:	0	1.6	7.2	14.5	9.0	826,090.0	0.00 #	24.00 #
Minimum:	0	1.6	7.0	14.5	6.1	789,130.8	0.00	1.00
Maximum:	0	1.6	8.0	14.7	14.6	1,047,609.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2023 00:00	0	1.6	7.3	14.5	10.0	792,340.4	0.00	1.00
09/04/2023 01:00	0	1.6	7.4	14.5	10.3	793,838.2	0.00	1.00
09/04/2023 02:00	0	1.7	0.0	14.4	10.1	781,414.6	0.00	1.00
09/04/2023 03:00	0	1.6	0.0	14.4	10.3	782,046.7	0.00	1.00
09/04/2023 04:00	0	1.7	0.0	14.4	10.2	782,678.7	0.00	1.00
09/04/2023 05:00	0	1.7	0.0	14.4	10.2	783,310.7	0.00	1.00
09/04/2023 06:00	0	1.7	0.0	14.4	10.3	783,100.1	0.00	1.00
09/04/2023 07:00	0	1.7	0.0	14.4	10.2	782,889.4	0.00	1.00
09/04/2023 08:00	0	1.7	0.0	14.4	9.9	782,678.7	0.00	1.00
09/04/2023 09:00	0	1.6	0.0	14.5	9.3	794,480.1	0.00	1.00
09/04/2023 10:00	0	1.6	0.0	14.5	9.0	794,266.1	0.00	1.00
09/04/2023 11:00	0	1.6	0.0	14.5	9.2	793,196.3	0.00	1.00
09/04/2023 12:00	0	1.6	0.0	14.5	9.4	792,340.4	0.00	1.00
09/04/2023 13:00	0	1.6	0.0	14.5	9.2	791,698.5	0.00	1.00
09/04/2023 14:00	0	1.6	0.0	14.5	7.8	790,842.6	0.00	1.00
09/04/2023 15:00	0	1.6	0.0	14.6	1.3	801,656.7	0.00	1.00
09/04/2023 16:00	0	1.6	0.0	14.6	2.8	801,221.9	0.00	1.00
09/04/2023 17:00	0	1.6	0.0	14.6	5.6	821,002.5	0.00	1.00
09/04/2023 18:00	0	1.6	0.0	14.7	7.0	908,679.3	0.00	1.00
09/04/2023 19:00	0	1.7	0.0	14.4	13.4	990,620.5	0.00	1.00
09/04/2023 20:00	0	1.7	0.0	14.1	13.5	993,436.8	0.00	1.00
09/04/2023 21:00	0	1.6	0.0	14.5	8.3	886,702.3	0.00	1.00
09/04/2023 22:00	0	1.6	0.0	14.6	9.5	907,080.6	0.00	1.00
09/04/2023 23:00	0	1.6	0.0	14.5	7.6	822,938.5	0.00	1.00
Average/Sum#:	0	1.6	7.4	14.5	8.9	823,102.5	0.00 #	24.00 #
Minimum:	0	1.6	7.3	14.1	1.3	781,414.6	0.00	1.00
Maximum:	0	1.7	7.4	14.7	13.5	993,436.8	0.00	1.00
%SI	91.67	0.00	91.67	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2023 00:00	0	1.6	0.0	14.6	10.0	918,166.4	0.00	1.00
09/05/2023 01:00	0	1.6	0.0	14.5	9.2	823,152.4	0.00	1.00
09/05/2023 02:00	0	1.7	0.0	14.5	8.9	829,571.6	0.00	1.00
09/05/2023 03:00	0	1.7	0.0	14.5	10.5	853,322.6	0.00	1.00
09/05/2023 04:00	0	1.6	7.2	14.6	11.5	970,552.4	0.00	1.00
09/05/2023 05:00	0	1.6	7.2	14.6	12.1	997,940.8	0.00	1.00
09/05/2023 06:00	0	1.7	7.9	14.4	15.3	992,727.3	0.00	1.00
09/05/2023 07:00	1	2.2	13.6	12.4	30.1	1,055,906.8	0.00	1.00
09/05/2023 08:00	1	2.1	13.4	12.5	29.4	1,049,239.9	0.00	1.00
09/05/2023 09:00	0	1.7	8.9	14.2	14.9	1,001,928.1	0.00	1.00
09/05/2023 10:00	0	1.6	7.9	14.7	13.7	1,039,437.3	0.00	1.00
09/05/2023 11:00	1	2.0	11.8	13.1	24.5	1,035,144.4	0.00	1.00
09/05/2023 12:00	0	1.7	9.6	13.9	16.2	963,879.1	0.00	1.00
09/05/2023 13:00	0	1.6	6.8	14.7	9.4	1,030,602.3	0.00	1.00
09/05/2023 14:00	0	1.6	6.8	14.7	10.8	1,031,927.5	0.00	1.00
09/05/2023 15:00	0	1.6	7.0	14.7	10.2	1,031,706.7	0.00	1.00
09/05/2023 16:00	0	1.6	6.9	14.7	10.7	1,029,497.9	0.00	1.00
09/05/2023 17:00	0	1.6	6.8	14.6	6.1	924,904.9	0.00	1.00
09/05/2023 18:00	0	1.7	7.9	14.4	14.0	1,003,682.7	0.00	1.00
09/05/2023 19:00	0	1.8	9.6	13.7	17.0	1,030,491.8	0.00	1.00
09/05/2023 20:00	0	1.7	7.9	14.3	12.8	998,019.9	0.00	1.00
09/05/2023 21:00	0	1.6	6.8	14.7	11.5	1,029,056.2	0.00	1.00
09/05/2023 22:00	0	1.6	6.8	14.6	11.1	981,420.8	0.00	1.00
09/05/2023 23:00	0	1.6	6.9	14.6	10.7	947,946.0	0.00	1.00
Average/Sum#:	0	1.7	8.4	14.3	13.8	982,092.7	0.00 #	24.00 #
Minimum:	0	1.6	6.8	12.4	6.1	823,152.4	0.00	1.00
Maximum:	1	2.2	13.6	14.7	30.1	1,055,906.8	0.00	1.00
%SI	16.67	0.00	16.67	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2023 00:00	0	1.6	6.8	14.6	9.6	944,902.8	0.00	1.00
09/06/2023 01:00	0	1.6	7.1	14.5	9.1	872,580.1	0.00	1.00
09/06/2023 02:00	0	1.7	7.5	14.4	9.2	793,634.1	0.00	1.00
09/06/2023 03:00	0	1.6	7.4	14.4	10.3	806,907.0	0.00	1.00
09/06/2023 04:00	0	1.7	7.2	14.5	9.9	859,313.8	0.00	1.00
09/06/2023 05:00	0	1.6	7.2	14.6	12.3	990,767.7	0.00	1.00
09/06/2023 06:00	0	1.6	7.4	14.7	13.3	1,030,602.3	0.00	1.00
09/06/2023 07:00	0	1.6	7.6	14.6	11.6	893,821.1	0.00	1.00
09/06/2023 08:00	0	1.6	7.5	14.5	9.3	803,253.0	0.00	1.00
09/06/2023 09:00	0	1.6	7.5	14.5	8.1	802,825.0	0.00	1.00
09/06/2023 10:00	0	1.6	7.4	14.5	8.6	803,253.0	0.00	1.00
09/06/2023 11:00	0	1.6	7.4	14.5	7.5	801,755.2	0.00	1.00
09/06/2023 12:00	0	1.6	7.3	14.6	6.3	817,742.0	0.00	1.00
09/06/2023 13:00	0	1.6	7.1	14.6	2.2	811,655.7	0.00	1.00
09/06/2023 14:00	0	1.6	7.1	14.6	1.6	809,699.3	0.00	1.00
09/06/2023 15:00	-1	1.6	7.0	14.6	1.4	808,829.9	0.00	1.00
09/06/2023 16:00	0	1.6	7.0	14.6	1.2	808,829.9	0.00	1.00
09/06/2023 17:00	0	1.6	7.0	14.7	4.2	885,045.7	0.00	1.00
09/06/2023 18:00	0	1.6	6.8	14.6	5.2	948,598.1	0.00	1.00
09/06/2023 19:00	0	1.6	7.0	14.6	7.2	877,301.1	0.00	1.00
09/06/2023 20:00	0	1.6	6.8	14.6	8.5	968,813.4	0.00	1.00
09/06/2023 21:00	0	1.6	6.9	14.6	8.2	932,730.2	0.00	1.00
09/06/2023 22:00	0	1.6	6.8	14.6	9.2	969,682.9	0.00	1.00
09/06/2023 23:00	0	1.6	7.0	14.6	7.2	883,387.4	0.00	1.00
Average/Sum#:	0	1.6	7.2	14.6	7.6	871,913.8	0.00 #	24.00 #
Minimum:	-1	1.6	6.8	14.4	1.2	793,634.1	0.00	1.00
Maximum:	0	1.7	7.6	14.7	13.3	1,030,602.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2023 00:00	0	1.6	7.0	14.6	8.2	913,819.1	0.00	1.00
09/07/2023 01:00	0	1.6	6.9	14.5	4.1	811,170.0	0.00	1.00
09/07/2023 02:00	0	1.7	7.2	14.5	3.8	805,392.7	0.00	1.00
09/07/2023 03:00	0	1.7	7.4	14.5	9.4	805,820.7	0.00	1.00
09/07/2023 04:00	0	1.6	7.4	14.5	9.6	806,462.6	0.00	1.00
09/07/2023 05:00	0	1.6	7.1	14.5	9.6	896,545.0	0.00	1.00
09/07/2023 06:00	0	1.6	7.1	14.6	11.5	1,002,070.9	0.00	1.00
09/07/2023 07:00	0	1.6	7.4	14.5	9.4	858,885.9	0.00	1.00
09/07/2023 08:00	0	1.6	7.4	14.5	9.0	805,820.7	0.00	1.00
09/07/2023 09:00	0	1.6	7.0	14.6	6.7	909,036.9	0.00	1.00
09/07/2023 10:00	0	1.6	7.2	14.5	5.2	843,265.9	0.00	1.00
09/07/2023 11:00	0	1.6	6.8	14.6	2.8	863,824.2	0.00	1.00
09/07/2023 12:00	0	1.6	7.1	14.6	6.3	867,736.8	0.00	1.00
09/07/2023 13:00	0	1.6	6.9	14.6	2.0	836,218.3	0.00	1.00
09/07/2023 14:00	0	1.6	7.1	14.7	8.9	943,356.7	0.00	1.00
09/07/2023 15:00	0	1.6	7.3	14.8	11.3	991,598.0	0.00	1.00
09/07/2023 16:00	0	1.6	6.9	14.7	4.1	877,315.1	0.00	1.00
09/07/2023 17:00	0	1.6	7.2	14.8	8.7	945,351.8	0.00	1.00
09/07/2023 18:00	0	1.5	7.0	14.7	8.0	933,196.5	0.00	1.00
09/07/2023 19:00	0	1.6	7.1	14.7	6.9	871,793.2	0.00	1.00
09/07/2023 20:00	0	1.6	7.2	14.8	11.0	1,005,516.7	0.00	1.00
09/07/2023 21:00	0	1.6	7.5	14.8	12.2	1,027,966.3	0.00	1.00
09/07/2023 22:00	0	1.5	7.5	14.6	8.7	934,686.5	0.00	1.00
09/07/2023 23:00	0	1.6	6.9	14.6	4.9	870,127.9	0.00	1.00
Average/Sum#:	0	1.6	7.2	14.6	7.6	892,790.8	0.00 #	24.00 #
Minimum:	0	1.5	6.8	14.5	2.0	805,392.7	0.00	1.00
Maximum:	0	1.7	7.5	14.8	12.2	1,027,966.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2023 00:00	0	1.6	7.0	14.5	5.6	813,309.7	0.00	1.00
09/08/2023 01:00	0	1.6	7.2	14.5	8.4	823,152.4	0.00	1.00
09/08/2023 02:00	0	1.7	7.4	14.5	9.1	820,156.8	0.00	1.00
09/08/2023 03:00	0	1.6	7.4	14.5	9.6	821,440.7	0.00	1.00
09/08/2023 04:00	0	1.6	7.3	14.5	9.5	822,724.5	0.00	1.00
09/08/2023 05:00	0	1.7	8.6	14.3	15.5	984,948.1	0.00	1.00
09/08/2023 06:00	0	1.8	9.9	13.9	19.1	1,058,369.4	0.00	1.00
09/08/2023 07:00	0	1.8	9.9	13.8	19.0	1,053,299.5	0.00	1.00
09/08/2023 08:00	0	1.7	8.7	14.2	12.5	964,115.6	0.00	1.00
09/08/2023 09:00	0	1.6	7.1	14.5	4.8	818,231.1	0.00	1.00
09/08/2023 10:00	0	1.6	7.1	14.6	8.9	830,349.4	0.00	1.00
09/08/2023 11:00	0	1.6	7.2	14.7	10.2	923,919.7	0.00	1.00
09/08/2023 12:00	0	1.6	7.3	14.6	6.8	895,994.8	0.00	1.00
09/08/2023 13:00	0	1.6	7.0	14.7	10.1	1,007,631.3	0.00	1.00
09/08/2023 14:00	0	1.6	7.0	14.7	11.1	1,038,332.9	0.00	1.00
09/08/2023 15:00	0	1.6	7.1	14.7	12.1	1,038,112.0	0.00	1.00
09/08/2023 16:00	0	1.7	8.7	14.1	14.8	991,221.6	0.00	1.00
09/08/2023 17:00	1	2.0	11.5	13.0	23.8	1,043,189.4	0.00	1.00
09/08/2023 18:00	1	2.3	12.9	12.2	31.6	1,043,123.6	0.00	1.00
09/08/2023 19:00	0	1.9	11.0	13.2	20.4	1,031,692.3	0.00	1.00
09/08/2023 20:00	1	2.0	12.1	13.0	24.6	1,058,270.4	0.00	1.00
09/08/2023 21:00	1	2.1	12.9	12.7	27.2	1,051,450.7	0.00	1.00
09/08/2023 22:00	0	1.9	11.3	13.3	21.6	1,047,069.1	0.00	1.00
09/08/2023 23:00	0	1.6	6.9	14.6	10.1	989,028.7	0.00	1.00
Average/Sum#:	0	1.7	8.8	14.1	14.4	957,047.2	0.00 #	24.00 #
Minimum:	0	1.6	6.9	12.2	4.8	813,309.7	0.00	1.00
Maximum:	1	2.3	12.9	14.7	31.6	1,058,369.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2023 00:00	0	1.6	6.8	14.6	11.4	1,007,939.8	0.00	1.00
09/09/2023 01:00	0	1.6	6.8	14.6	11.4	1,005,114.0	0.00	1.00
09/09/2023 02:00	0	1.6	7.1	14.5	10.3	918,156.3	0.00	1.00
09/09/2023 03:00	0	1.6	7.1	14.6	11.1	940,120.7	0.00	1.00
09/09/2023 04:00	0	1.6	7.1	14.7	12.5	1,022,650.8	0.00	1.00
09/09/2023 05:00	0	1.6	7.2	14.7	12.9	1,031,264.9	0.00	1.00
09/09/2023 06:00	0	1.6	7.2	14.7	13.0	1,031,485.8	0.00	1.00
09/09/2023 07:00	0	1.6	7.4	14.5	10.4	842,623.9	0.00	1.00
09/09/2023 08:00	0	1.6	7.1	14.7	11.7	1,024,859.5	0.00	1.00
09/09/2023 09:00	0	1.6	7.2	14.5	3.9	813,095.7	0.00	1.00
09/09/2023 10:00	0	1.6	7.0	14.6	0.7	814,698.8	0.00	1.00
09/09/2023 11:00	0	1.6	7.0	14.7	3.3	878,861.2	0.00	1.00
09/09/2023 12:00	0	1.6	7.2	14.7	9.9	961,468.4	0.00	1.00
09/09/2023 13:00	0	1.6	7.1	14.7	11.1	1,035,240.7	0.00	1.00
09/09/2023 14:00	0	1.6	7.0	14.7	6.3	889,463.2	0.00	1.00
09/09/2023 15:00	0	1.5	7.3	14.7	11.0	1,006,747.8	0.00	1.00
09/09/2023 16:00	0	1.6	6.8	14.6	5.8	915,340.6	0.00	1.00
09/09/2023 17:00	0	1.7	8.8	14.2	14.4	998,044.7	0.00	1.00
09/09/2023 18:00	1	2.1	12.7	12.8	25.7	1,042,960.4	0.00	1.00
09/09/2023 19:00	0	1.8	9.8	13.8	15.7	1,012,023.9	0.00	1.00
09/09/2023 20:00	0	1.6	6.9	14.7	10.7	1,025,522.2	0.00	1.00
09/09/2023 21:00	0	1.8	9.6	13.9	17.2	1,058,956.3	0.00	1.00
09/09/2023 22:00	0	1.7	8.8	14.1	14.6	1,025,457.2	0.00	1.00
09/09/2023 23:00	0	1.6	6.9	14.5	6.3	872,152.2	0.00	1.00
Average/Sum#:	0	1.6	7.7	14.5	10.9	965,593.7	0.00 #	24.00 #
Minimum:	0	1.5	6.8	12.8	0.7	813,095.7	0.00	1.00
Maximum:	1	2.1	12.7	14.7	25.7	1,058,956.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2023 00:00	0	1.6	6.9	14.6	9.7	949,684.9	0.00	1.00
09/10/2023 01:00	0	1.6	7.3	14.6	9.7	870,562.6	0.00	1.00
09/10/2023 02:00	0	1.6	7.5	14.5	9.9	835,990.8	0.00	1.00
09/10/2023 03:00	0	1.6	7.2	14.6	10.2	919,253.3	0.00	1.00
09/10/2023 04:00	0	1.6	7.7	14.5	11.1	815,021.5	0.00	1.00
09/10/2023 05:00	0	1.6	7.3	14.6	11.2	909,254.3	0.00	1.00
09/10/2023 06:00	0	1.6	7.3	14.6	12.1	967,509.2	0.00	1.00
09/10/2023 07:00	0	1.6	7.2	14.6	12.2	965,335.5	0.00	1.00
09/10/2023 08:00	0	1.6	7.2	14.7	13.0	1,037,228.5	0.00	1.00
09/10/2023 09:00	0	1.6	7.3	14.6	9.2	916,210.1	0.00	1.00
09/10/2023 10:00	0	1.6	7.0	14.6	7.9	876,214.2	0.00	1.00
09/10/2023 11:00	0	1.6	6.9	14.6	0.6	814,698.8	0.00	1.00
09/10/2023 12:00	0	1.6	6.8	14.6	1.0	813,612.0	0.00	1.00
09/10/2023 13:00	0	1.6	6.7	14.7	4.1	891,451.1	0.00	1.00
09/10/2023 14:00	0	1.6	6.7	14.7	7.9	948,436.8	0.00	1.00
09/10/2023 15:00	0	1.6	6.6	14.5	2.9	848,829.1	0.00	1.00
09/10/2023 16:00	0	1.7	7.5	14.4	8.1	918,778.4	0.00	1.00
09/10/2023 17:00	1	2.2	12.9	12.6	28.0	1,041,752.5	0.00	1.00
09/10/2023 18:00	1	2.1	13.1	12.6	27.7	1,044,392.3	0.00	1.00
09/10/2023 19:00	0	1.9	10.9	13.4	19.4	1,036,745.6	0.00	1.00
09/10/2023 20:00	0	1.6	7.4	14.5	9.9	998,396.0	0.00	1.00
09/10/2023 21:00	0	1.8	9.3	14.0	17.4	1,058,426.1	0.00	1.00
09/10/2023 22:00	0	1.8	9.3	13.9	14.9	1,011,809.0	0.00	1.00
09/10/2023 23:00	0	1.6	7.1	14.4	3.8	796,794.3	0.00	1.00
Average/Sum#:	0	1.7	8.0	14.3	10.9	928,599.5	0.00 #	24.00 #
Minimum:	0	1.6	6.6	12.6	0.6	796,794.3	0.00	1.00
Maximum:	1	2.2	13.1	14.7	28.0	1,058,426.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2023 00:00	0	1.6	7.2	14.5	8.8	803,467.0	0.00	1.00
09/11/2023 01:00	0	1.6	7.2	14.5	8.9	804,108.9	0.00	1.00
09/11/2023 02:00	0	1.6	7.3	14.5	8.8	805,392.7	0.00	1.00
09/11/2023 03:00	0	1.7	7.5	14.5	9.6	808,174.4	0.00	1.00
09/11/2023 04:00	0	1.6	7.4	14.5	9.2	820,798.7	0.00	1.00
09/11/2023 05:00	0	1.6	7.5	14.5	8.8	826,148.1	0.00	1.00
09/11/2023 06:00	0	1.6	7.2	14.7	11.9	1,036,786.8	0.00	1.00
09/11/2023 07:00	0	1.6	7.5	14.5	10.5	899,326.7	0.00	1.00
09/11/2023 08:00	0	1.6	7.4	14.5	9.1	805,820.7	0.00	1.00
09/11/2023 09:00	0	1.6	7.4	14.5	7.9	803,894.9	0.00	1.00
09/11/2023 10:00	0	1.6	7.3	14.5	6.6	801,755.2	0.00	1.00
09/11/2023 11:00	0	1.6	7.0	14.6	4.9	833,392.6	0.00	1.00
09/11/2023 12:00	0	1.6	6.8	14.7	5.9	930,546.0	0.00	1.00
09/11/2023 13:00	0	1.5	6.6	14.6	3.9	900,124.8	0.00	1.00
09/11/2023 14:00	0	1.6	6.6	14.6	7.7	954,684.4	0.00	1.00
09/11/2023 15:00	0	1.6	6.7	14.6	6.1	911,210.6	0.00	1.00
09/11/2023 16:00	0	1.6	6.8	14.6	7.4	910,558.5	0.00	1.00
09/11/2023 17:00	0	1.6	6.6	14.6	3.1	868,389.0	0.00	1.00
09/11/2023 18:00	0	1.5	6.8	14.7	8.6	947,774.2	0.00	1.00
09/11/2023 19:00	0	1.6	7.0	14.6	2.8	823,828.3	0.00	1.00
09/11/2023 20:00	0	1.6	6.7	14.6	4.8	864,258.9	0.00	1.00
09/11/2023 21:00	0	1.6	6.7	14.6	6.6	925,557.0	0.00	1.00
09/11/2023 22:00	0	1.6	6.8	14.5	3.3	829,999.6	0.00	1.00
09/11/2023 23:00	0	1.6	6.7	14.5	0.7	802,183.1	0.00	1.00
Average/Sum#:	0	1.6	7.0	14.6	6.9	863,257.5	0.00 #	24.00 #
Minimum:	0	1.5	6.6	14.5	0.7	801,755.2	0.00	1.00
Maximum:	0	1.7	7.5	14.7	11.9	1,036,786.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2023 00:00	0	1.7	6.7	14.5	1.9	802,611.1	0.00	1.00
09/12/2023 01:00	0	1.6	6.8	14.5	8.3	802,611.1	0.00	1.00
09/12/2023 02:00	0	1.7	7.0	14.5	8.7	802,825.0	0.00	1.00
09/12/2023 03:00	0	1.7	7.3	14.4	10.0	791,316.6	0.00	1.00
09/12/2023 04:00	0	1.6	7.3	14.4	10.0	791,738.0	0.00	1.00
09/12/2023 05:00	0	1.7	7.4	14.4	10.0	792,159.3	0.00	1.00
09/12/2023 06:00	0	1.7	7.3	14.4	10.1	791,948.7	0.00	1.00
09/12/2023 07:00	0	1.7	7.3	14.4	10.0	793,634.1	0.00	1.00
09/12/2023 08:00	0	1.7	7.3	14.4	9.8	793,002.1	0.00	1.00
09/12/2023 09:00	0	1.6	7.2	14.5	9.6	804,322.9	0.00	1.00
09/12/2023 10:00	0	1.6	7.2	14.5	9.5	803,894.9	0.00	1.00
09/12/2023 11:00	0	1.6	7.2	14.5	9.1	802,611.1	0.00	1.00
09/12/2023 12:00	0	1.6	7.1	14.5	7.8	801,541.2	0.00	1.00
09/12/2023 13:00	-1	1.6	6.8	14.6	1.9	811,873.0	0.00	1.00
09/12/2023 14:00	0	1.6	6.8	14.6	2.3	824,697.8	0.00	1.00
09/12/2023 15:00	0	1.6	6.8	14.6	3.6	823,393.6	0.00	1.00
09/12/2023 16:00	0	1.6	6.8	14.6	1.8	808,612.5	0.00	1.00
09/12/2023 17:00	0	1.6	7.0	14.6	4.2	808,177.8	0.00	1.00
09/12/2023 18:00	0	1.6	7.0	14.6	1.4	807,743.0	0.00	1.00
09/12/2023 19:00	0	1.7	7.4	14.5	6.4	914,946.7	0.00	1.00
09/12/2023 20:00	0	1.8	9.6	14.0	15.7	1,039,968.7	0.00	1.00
09/12/2023 21:00	0	1.6	6.9	14.5	3.5	848,829.1	0.00	1.00
09/12/2023 22:00	0	1.7	7.0	14.5	7.3	800,043.4	0.00	1.00
09/12/2023 23:00	0	1.6	7.1	14.5	9.5	800,257.4	0.00	1.00
Average/Sum#:	0	1.6	7.2	14.5	7.2	819,281.6	0.00 #	24.00 #
Minimum:	-1	1.6	6.7	14.0	1.4	791,316.6	0.00	1.00
Maximum:	0	1.8	9.6	14.6	15.7	1,039,968.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2023 00:00	0	1.6	7.0	14.5	9.7	800,471.3	0.00	1.00
09/13/2023 01:00	0	1.6	7.0	14.5	9.7	801,113.3	0.00	1.00
09/13/2023 02:00	0	1.7	7.3	14.5	9.6	801,755.2	0.00	1.00
09/13/2023 03:00	0	1.6	7.3	14.5	9.9	802,825.0	0.00	1.00
09/13/2023 04:00	0	1.6	7.3	14.5	9.9	804,750.8	0.00	1.00
09/13/2023 05:00	0	1.6	7.3	14.4	10.1	793,212.7	0.00	1.00
09/13/2023 06:00	0	1.6	7.3	14.4	9.9	792,791.4	0.00	1.00
09/13/2023 07:00	0	1.7	7.3	14.4	9.9	791,948.7	0.00	1.00
09/13/2023 08:00	0	1.6	7.2	14.5	7.2	804,750.8	0.00	1.00
09/13/2023 09:00	0	1.6	7.2	14.5	2.6	803,894.9	0.00	1.00
09/13/2023 10:00	-1	1.6	7.2	14.5	1.9	803,039.0	0.00	1.00
09/13/2023 11:00	0	1.6	7.1	14.6	4.1	872,953.7	0.00	1.00
09/13/2023 12:00	0	1.8	9.5	14.0	14.9	1,036,197.8	0.00	1.00
09/13/2023 13:00	0	1.6	7.4	14.4	6.1	894,971.5	0.00	1.00
09/13/2023 14:00	0	1.6	6.5	14.7	7.0	983,776.8	0.00	1.00
09/13/2023 15:00	0	1.8	9.2	13.8	16.0	1,019,353.2	0.00	1.00
09/13/2023 16:00	0	1.8	9.2	13.8	15.8	1,019,739.0	0.00	1.00
09/13/2023 17:00	0	1.8	9.3	13.7	16.0	1,015,276.0	0.00	1.00
09/13/2023 18:00	0	1.8	9.3	13.8	15.9	1,027,839.8	0.00	1.00
09/13/2023 19:00	0	1.8	9.1	13.9	15.8	1,032,154.7	0.00	1.00
09/13/2023 20:00	0	1.8	8.9	13.9	15.3	1,030,394.0	0.00	1.00
09/13/2023 21:00	0	1.6	7.8	14.2	9.6	929,777.8	0.00	1.00
09/13/2023 22:00	0	1.6	6.6	14.5	0.3	798,973.5	0.00	1.00
09/13/2023 23:00	0	1.6	6.7	14.5	0.4	799,401.5	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.3	9.5	885,890.1	0.00 #	24.00 #
Minimum:	-1	1.6	6.5	13.7	0.3	791,948.7	0.00	1.00
Maximum:	0	1.8	9.5	14.7	16.0	1,036,197.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2023 00:00	0	1.6	6.9	14.5	1.1	818,231.1	0.00	1.00
09/14/2023 01:00	0	1.6	6.9	14.5	0.9	816,733.3	0.00	1.00
09/14/2023 02:00	0	1.7	7.0	14.6	8.0	949,250.2	0.00	1.00
09/14/2023 03:00	0	1.6	7.0	14.5	1.9	802,397.1	0.00	1.00
09/14/2023 04:00	0	1.6	6.9	14.5	0.6	803,039.0	0.00	1.00
09/14/2023 05:00	0	1.6	7.0	14.5	3.2	822,510.5	0.00	1.00
09/14/2023 06:00	0	1.6	6.9	14.6	10.3	967,726.6	0.00	1.00
09/14/2023 07:00	0	1.6	7.3	14.5	8.2	875,575.7	0.00	1.00
09/14/2023 08:00	0	1.6	7.0	14.5	6.7	819,300.9	0.00	1.00
09/14/2023 09:00	0	1.6	6.8	14.6	9.2	936,642.8	0.00	1.00
09/14/2023 10:00	0	1.6	6.8	14.7	11.0	1,012,711.4	0.00	1.00
09/14/2023 11:00	0	1.6	7.5	14.6	11.8	1,008,591.9	0.00	1.00
09/14/2023 12:00	0	1.9	9.5	13.9	15.1	1,028,242.1	0.00	1.00
09/14/2023 13:00	0	1.6	6.4	14.7	7.5	1,013,815.8	0.00	1.00
09/14/2023 14:00	0	1.6	6.3	14.7	8.1	1,012,932.3	0.00	1.00
09/14/2023 15:00	0	1.8	8.4	14.0	13.9	991,542.6	0.00	1.00
09/14/2023 16:00	0	1.9	9.9	13.5	17.2	1,018,925.8	0.00	1.00
09/14/2023 17:00	0	1.9	10.2	13.3	17.6	1,011,211.8	0.00	1.00
09/14/2023 18:00	0	1.8	9.9	13.5	16.8	1,022,071.7	0.00	1.00
09/14/2023 19:00	0	1.8	9.0	13.9	15.0	1,030,785.3	0.00	1.00
09/14/2023 20:00	0	1.8	8.9	13.9	15.0	1,025,503.2	0.00	1.00
09/14/2023 21:00	0	1.8	9.5	13.7	16.4	1,040,572.3	0.00	1.00
09/14/2023 22:00	0	1.7	8.5	14.0	13.6	1,003,252.2	0.00	1.00
09/14/2023 23:00	0	1.6	6.7	14.5	4.8	858,457.9	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.3	9.7	945,417.6	0.00 #	24.00 #
Minimum:	0	1.6	6.3	13.3	0.6	802,397.1	0.00	1.00
Maximum:	0	1.9	10.2	14.7	17.6	1,040,572.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2023 00:00	0	1.6	6.7	14.5	5.8	845,833.5	0.00	1.00
09/15/2023 01:00	0	1.6	6.8	14.5	6.5	814,165.6	0.00	1.00
09/15/2023 02:00	0	1.6	6.9	14.5	6.5	810,528.1	0.00	1.00
09/15/2023 03:00	0	1.7	7.2	14.4	9.6	791,105.9	0.00	1.00
09/15/2023 04:00	0	1.6	7.1	14.5	9.3	818,873.0	0.00	1.00
09/15/2023 05:00	0	1.7	7.3	14.4	11.2	932,262.0	0.00	1.00
09/15/2023 06:00	0	2.0	11.9	13.0	23.4	1,054,456.8	0.00	1.00
09/15/2023 07:00	0	1.7	8.3	14.2	12.5	951,443.4	0.00	1.00
09/15/2023 08:00	0	1.7	7.2	14.4	9.3	805,221.5	0.00	1.00
09/15/2023 09:00	0	1.6	7.1	14.5	8.4	805,178.7	0.00	1.00
09/15/2023 10:00	0	1.6	7.1	14.5	7.3	804,536.8	0.00	1.00
09/15/2023 11:00	0	1.6	7.1	14.5	1.0	803,680.9	0.00	1.00
09/15/2023 12:00	0	1.6	6.9	14.5	0.5	809,244.2	0.00	1.00
09/15/2023 13:00	0	1.6	6.8	14.6	0.4	820,133.0	0.00	1.00
09/15/2023 14:00	0	1.6	6.5	14.7	1.6	879,082.1	0.00	1.00
09/15/2023 15:00	0	1.6	7.1	14.5	6.4	974,003.1	0.00	1.00
09/15/2023 16:00	0	2.0	10.5	13.4	17.6	1,031,998.2	0.00	1.00
09/15/2023 17:00	0	2.0	11.0	13.1	20.5	1,030,404.1	0.00	1.00
09/15/2023 18:00	1	2.1	12.0	12.7	23.1	1,026,233.3	0.00	1.00
09/15/2023 19:00	0	1.9	9.8	13.6	15.8	1,036,823.1	0.00	1.00
09/15/2023 20:00	0	1.9	10.3	13.3	17.7	1,029,410.7	0.00	1.00
09/15/2023 21:00	0	1.9	9.9	13.5	16.9	1,035,580.9	0.00	1.00
09/15/2023 22:00	0	1.8	9.5	13.7	16.0	1,040,191.9	0.00	1.00
09/15/2023 23:00	0	1.7	8.3	14.1	13.1	1,012,971.3	0.00	1.00
Average/Sum#:	0	1.7	8.3	14.1	10.9	915,140.1	0.00 #	24.00 #
Minimum:	0	1.6	6.5	12.7	0.4	791,105.9	0.00	1.00
Maximum:	1	2.1	12.0	14.7	23.4	1,054,456.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2023 00:00	0	1.6	6.8	14.5	8.4	889,056.0	0.00	1.00
09/16/2023 01:00	0	1.6	6.7	14.5	5.8	835,776.8	0.00	1.00
09/16/2023 02:00	0	1.7	7.0	14.5	8.7	821,226.7	0.00	1.00
09/16/2023 03:00	0	1.6	7.1	14.5	9.3	804,322.9	0.00	1.00
09/16/2023 04:00	0	1.6	7.1	14.4	9.5	793,002.1	0.00	1.00
09/16/2023 05:00	0	1.7	7.2	14.4	9.4	797,005.0	0.00	1.00
09/16/2023 06:00	0	1.7	7.2	14.4	9.6	793,844.8	0.00	1.00
09/16/2023 07:00	0	1.7	7.2	14.4	9.5	793,844.8	0.00	1.00
09/16/2023 08:00	0	1.6	7.3	14.4	9.6	797,005.0	0.00	1.00
09/16/2023 09:00	0	1.6	7.2	14.5	8.2	818,445.0	0.00	1.00
09/16/2023 10:00	0	1.6	7.0	14.5	7.7	843,265.9	0.00	1.00
09/16/2023 11:00	0	1.6	6.7	14.6	3.9	908,819.6	0.00	1.00
09/16/2023 12:00	0	1.6	6.7	14.7	9.1	996,145.8	0.00	1.00
09/16/2023 13:00	0	1.6	6.7	14.7	7.3	978,696.7	0.00	1.00
09/16/2023 14:00	0	1.6	6.7	14.6	3.8	891,212.7	0.00	1.00
09/16/2023 15:00	0	1.6	6.8	14.7	3.7	919,944.0	0.00	1.00
09/16/2023 16:00	0	1.5	6.6	14.5	0.7	798,545.6	0.00	1.00
09/16/2023 17:00	0	1.6	6.5	14.6	1.4	856,216.3	0.00	1.00
09/16/2023 18:00	0	1.6	6.8	14.5	1.2	814,593.5	0.00	1.00
09/16/2023 19:00	0	1.6	6.6	14.5	0.1	801,113.3	0.00	1.00
09/16/2023 20:00	0	1.6	6.6	14.5	0.4	800,685.3	0.00	1.00
09/16/2023 21:00	0	1.6	6.7	14.5	0.5	801,541.2	0.00	1.00
09/16/2023 22:00	0	1.6	6.7	14.5	0.1	801,755.2	0.00	1.00
09/16/2023 23:00	0	1.6	6.8	14.5	1.2	802,825.0	0.00	1.00
Average/Sum#:	0	1.6	6.9	14.5	5.4	839,953.7	0.00 #	24.00 #
Minimum:	0	1.5	6.5	14.4	0.1	793,002.1	0.00	1.00
Maximum:	0	1.7	7.3	14.7	9.6	996,145.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2023 00:00	0	1.7	7.1	14.4	6.9	791,527.3	0.00	1.00
09/17/2023 01:00	0	1.7	7.2	14.4	6.5	792,159.3	0.00	1.00
09/17/2023 02:00	0	1.6	7.3	14.4	6.6	792,791.4	0.00	1.00
09/17/2023 03:00	0	1.7	7.3	14.4	7.1	792,791.4	0.00	1.00
09/17/2023 04:00	0	1.6	7.2	14.4	7.3	793,212.7	0.00	1.00
09/17/2023 05:00	0	1.7	7.3	14.4	7.9	793,634.1	0.00	1.00
09/17/2023 06:00	0	1.7	7.4	14.4	8.9	793,634.1	0.00	1.00
09/17/2023 07:00	0	1.7	7.3	14.4	8.5	794,055.5	0.00	1.00
09/17/2023 08:00	0	1.6	7.2	14.4	7.8	794,055.5	0.00	1.00
09/17/2023 09:00	0	1.6	7.1	14.5	5.5	805,820.7	0.00	1.00
09/17/2023 10:00	0	1.6	7.1	14.5	5.5	804,750.8	0.00	1.00
09/17/2023 11:00	0	1.6	7.1	14.5	2.3	803,894.9	0.00	1.00
09/17/2023 12:00	0	1.6	7.1	14.5	0.7	802,397.1	0.00	1.00
09/17/2023 13:00	0	1.6	7.0	14.5	0.6	801,969.2	0.00	1.00
09/17/2023 14:00	0	1.6	6.9	14.5	0.8	801,327.2	0.00	1.00
09/17/2023 15:00	0	1.6	6.9	14.5	0.8	800,899.3	0.00	1.00
09/17/2023 16:00	0	1.6	6.6	14.6	0.2	812,525.1	0.00	1.00
09/17/2023 17:00	0	1.6	6.5	14.6	0.7	838,392.0	0.00	1.00
09/17/2023 18:00	0	1.6	6.8	14.5	0.8	810,100.1	0.00	1.00
09/17/2023 19:00	0	1.6	6.6	14.5	0.3	804,108.9	0.00	1.00
09/17/2023 20:00	0	1.6	6.8	14.5	2.3	827,645.9	0.00	1.00
09/17/2023 21:00	0	1.6	6.7	14.5	0.4	804,108.9	0.00	1.00
09/17/2023 22:00	0	1.7	6.8	14.5	2.3	805,178.7	0.00	1.00
09/17/2023 23:00	0	1.7	7.1	14.5	7.5	806,676.6	0.00	1.00
Average/Sum#:	0	1.6	7.0	14.5	4.1	802,819.0	0.00 #	24.00 #
Minimum:	0	1.6	6.5	14.4	0.2	791,527.3	0.00	1.00
Maximum:	0	1.7	7.4	14.6	8.9	838,392.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2023 00:00	0	1.7	7.1	14.4	7.4	794,898.2	0.00	1.00
09/18/2023 01:00	0	1.7	7.1	14.4	8.8	794,266.1	0.00	1.00
09/18/2023 02:00	0	1.7	7.3	14.4	9.5	794,266.1	0.00	1.00
09/18/2023 03:00	0	1.7	7.4	14.4	9.8	794,898.2	0.00	1.00
09/18/2023 04:00	0	1.7	7.3	14.4	9.6	794,898.2	0.00	1.00
09/18/2023 05:00	0	1.7	7.3	14.4	9.6	795,108.9	0.00	1.00
09/18/2023 06:00	0	1.7	7.2	14.4	9.7	795,530.2	0.00	1.00
09/18/2023 07:00	0	1.7	7.2	14.4	9.7	795,951.6	0.00	1.00
09/18/2023 08:00	0	1.7	7.2	14.4	9.3	795,108.9	0.00	1.00
09/18/2023 09:00	0	1.6	7.1	14.5	9.2	805,820.7	0.00	1.00
09/18/2023 10:00	0	1.6	7.1	14.5	8.7	805,820.7	0.00	1.00
09/18/2023 11:00	0	1.6	7.1	14.5	7.1	804,964.8	0.00	1.00
09/18/2023 12:00	0	1.6	7.0	14.5	4.1	803,253.0	0.00	1.00
09/18/2023 13:00	0	1.6	7.0	14.5	0.6	802,611.1	0.00	1.00
09/18/2023 14:00	0	1.6	6.9	14.5	0.5	801,969.2	0.00	1.00
09/18/2023 15:00	0	1.6	6.7	14.5	0.4	800,471.3	0.00	1.00
09/18/2023 16:00	0	1.6	6.5	14.6	0.3	813,394.6	0.00	1.00
09/18/2023 17:00	0	1.6	6.4	14.6	1.3	875,779.5	0.00	1.00
09/18/2023 18:00	0	1.6	6.5	14.6	4.7	937,947.0	0.00	1.00
09/18/2023 19:00	0	1.6	6.9	14.4	1.9	812,384.7	0.00	1.00
09/18/2023 20:00	0	1.7	7.0	14.5	2.2	806,034.6	0.00	1.00
09/18/2023 21:00	0	1.6	6.9	14.5	2.4	809,244.2	0.00	1.00
09/18/2023 22:00	0	1.6	6.9	14.5	2.6	807,960.4	0.00	1.00
09/18/2023 23:00	0	1.6	6.8	14.5	1.1	804,322.9	0.00	1.00
Average/Sum#:	0	1.6	7.0	14.5	5.4	810,287.7	0.00 #	24.00 #
Minimum:	0	1.6	6.4	14.4	0.3	794,266.1	0.00	1.00
Maximum:	0	1.7	7.4	14.6	9.8	937,947.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2023 00:00	0	1.7	7.2	14.5	7.3	805,178.7	0.00	1.00
09/19/2023 01:00	0	1.6	7.1	14.5	6.2	806,034.6	0.00	1.00
09/19/2023 02:00	0	1.6	7.3	14.5	6.0	806,676.6	0.00	1.00
09/19/2023 03:00	0	1.7	7.3	14.5	7.0	806,890.5	0.00	1.00
09/19/2023 04:00	0	1.7	7.3	14.4	9.2	796,583.6	0.00	1.00
09/19/2023 05:00	0	1.6	7.2	14.5	9.3	859,527.8	0.00	1.00
09/19/2023 06:00	0	1.6	7.0	14.6	11.1	972,291.3	0.00	1.00
09/19/2023 07:00	0	1.6	7.4	14.4	10.0	838,087.7	0.00	1.00
09/19/2023 08:00	0	1.6	7.2	14.4	9.8	795,319.5	0.00	1.00
09/19/2023 09:00	0	1.6	7.2	14.5	9.5	806,890.5	0.00	1.00
09/19/2023 10:00	0	1.6	7.1	14.5	9.3	806,248.6	0.00	1.00
09/19/2023 11:00	0	1.6	7.1	14.5	8.8	805,178.7	0.00	1.00
09/19/2023 12:00	0	1.6	7.1	14.5	1.8	804,108.9	0.00	1.00
09/19/2023 13:00	0	1.6	7.1	14.5	0.7	803,253.0	0.00	1.00
09/19/2023 14:00	0	1.6	6.8	14.6	0.4	814,264.1	0.00	1.00
09/19/2023 15:00	0	1.6	6.6	14.6	0.4	813,612.0	0.00	1.00
09/19/2023 16:00	0	1.6	6.6	14.6	0.2	812,090.4	0.00	1.00
09/19/2023 17:00	0	1.6	6.5	14.6	1.0	855,998.9	0.00	1.00
09/19/2023 18:00	0	1.6	6.6	14.6	3.0	891,212.7	0.00	1.00
09/19/2023 19:00	0	1.5	6.7	14.5	0.4	800,257.4	0.00	1.00
09/19/2023 20:00	0	1.6	6.6	14.5	0.2	801,755.2	0.00	1.00
09/19/2023 21:00	0	1.6	6.7	14.5	0.3	807,532.4	0.00	1.00
09/19/2023 22:00	0	1.6	6.7	14.5	0.5	803,039.0	0.00	1.00
09/19/2023 23:00	0	1.6	6.7	14.5	0.6	803,253.0	0.00	1.00
Average/Sum#:	0	1.6	7.0	14.5	4.7	821,470.2	0.00 #	24.00 #
Minimum:	0	1.5	6.5	14.4	0.2	795,319.5	0.00	1.00
Maximum:	0	1.7	7.4	14.6	11.1	972,291.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2023 00:00	0	1.6	6.8	14.5	0.7	804,536.8	0.00	1.00
09/20/2023 01:00	0	1.6	6.8	14.5	0.5	803,680.9	0.00	1.00
09/20/2023 02:00	0	1.7	7.3	14.5	5.3	804,750.8	0.00	1.00
09/20/2023 03:00	0	1.7	7.2	14.4	8.2	792,370.0	0.00	1.00
09/20/2023 04:00	0	1.7	7.2	14.4	9.6	793,002.1	0.00	1.00
09/20/2023 05:00	0	1.7	7.3	14.4	9.9	798,058.4	0.00	1.00
09/20/2023 06:00	0	1.7	7.4	14.4	9.9	807,960.4	0.00	1.00
09/20/2023 07:00	0	1.7	7.3	14.4	9.7	798,479.8	0.00	1.00
09/20/2023 08:00	0	1.7	7.2	14.4	9.5	793,423.4	0.00	1.00
09/20/2023 09:00	0	1.6	7.3	14.5	8.7	805,178.7	0.00	1.00
09/20/2023 10:00	0	1.6	7.2	14.5	7.8	804,322.9	0.00	1.00
09/20/2023 11:00	0	8.2	16.5	15.1	2.5	713,281.2	0.20	0.33
09/20/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.2	8.0	14.5	6.9	793,253.8	0.20 #	11.33 #
Minimum:	0	1.6	6.8	14.4	0.5	713,281.2	0.00	0.00
Maximum:	0	8.2	16.5	15.1	9.9	807,960.4	0.20	1.00
%SI	50.00	50.00	50.00	50.00	50.00	50.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/24/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 08:00	0	2.5	4.9	20.3	0.0	896,973.0	0.10	0.10
09/26/2023 09:00	0	9.1	13.2	15.0	5.7	897,321.1	0.90	1.00
09/26/2023 10:00	0	1.7	8.2	14.5	10.0	815,663.4	0.00	1.00
09/26/2023 11:00	0	1.6	7.8	14.5	8.8	809,030.2	0.00	1.00
09/26/2023 12:00	0	1.6	7.8	14.5	8.6	808,816.3	0.00	1.00
09/26/2023 13:00	0	5.6	13.5	14.9	5.1	756,607.0	0.20	0.57
09/26/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	3.7	9.2	15.6	6.4	830,735.2	1.20 #	4.67 #
Minimum:	0	1.6	4.9	14.5	0.0	756,607.0	0.00	0.00
Maximum:	0	9.1	13.5	20.3	10.0	897,321.1	0.90	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2023 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2023 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/02/2023 23:47 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2023	16.56	60.17	6.56	13.10	21.79
07/02/2023	16.28	68.41	7.36	14.73	24.57
07/03/2023	18.70	62.30	6.74	13.49	22.48
07/04/2023	16.63	54.01	5.87	11.74	19.61
07/05/2023	17.13	57.92	6.26	12.55	20.89
07/06/2023	21.73	62.31	6.78	13.50	22.53
07/07/2023	214.15	78.62	7.24	14.40	24.00
07/08/2023	29.97	61.34	6.69	13.39	22.38
07/09/2023	46.66	57.24	6.60	13.18	21.95
07/10/2023	14.50	49.21	5.40	10.70	17.83
07/11/2023	13.76	50.43	5.52	11.03	18.45
07/12/2023	13.33	50.60	5.52	11.01	18.39
07/13/2023	14.14	55.01	6.01	12.00	19.99
07/14/2023	42.05	96.79	9.61	19.25	32.12
07/15/2023	28.72	129.35	14.03	28.05	46.73
07/16/2023	31.39	130.45	14.26	28.47	47.52
07/17/2023	31.73	116.73	12.79	25.60	42.66
07/18/2023	32.37	133.51	14.56	29.13	48.52
07/19/2023	28.18	140.02	15.20	30.40	50.66
07/20/2023	32.40	132.35	14.51	29.00	48.29
07/21/2023	34.79	126.36	13.81	27.57	46.05
07/22/2023	36.06	119.67	12.99	25.99	43.34
07/23/2023	35.81	122.12	13.37	26.74	44.60
07/24/2023	32.47	109.17	11.87	23.72	39.59
07/25/2023	33.84	119.48	13.00	25.95	43.29
07/26/2023	29.85	138.57	15.15	30.24	50.39
07/27/2023	33.88	115.73	12.63	25.26	42.11
07/28/2023	35.93	112.63	12.32	24.64	41.09
07/29/2023	31.54	100.47	10.94	21.74	36.31
07/30/2023	31.53	99.35	10.82	21.47	35.89
07/31/2023	35.34	122.62	13.36	26.66	44.44
Monthly Avg/Sum:	1,051.42 sum	2,932.94 sum	317.77 sum	634.70 sum	1,058.46 sum
Daily Min:	13.33	49.21	5.40	10.70	17.83
Daily Max:	214.15	140.02	15.20	30.40	50.66
Jul 2023 - Jul 2023	1,051.42 sum	2,932.94 sum	317.77 sum	634.70 sum	1,058.46 sum
QTD:	1,051.42 sum	2,932.94 sum	317.77 sum	634.70 sum	1,058.46 sum
YTD 2023:	6,984.37 sum	9,388.15 sum	956.73 sum	1,911.28 sum	3,185.80 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/02/2023 23:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2023	34.00	110.47	12.20	24.31	40.58
08/02/2023	31.72	103.95	11.26	22.59	37.60
08/03/2023	31.03	98.39	10.68	21.39	35.60
08/04/2023	33.49	102.22	11.08	22.28	37.00
08/05/2023	35.01	107.25	11.73	23.41	39.03
08/06/2023	36.22	109.06	11.95	23.89	39.82
08/07/2023	31.37	114.96	13.08	26.20	43.66
08/08/2023	26.86	101.42	11.06	22.13	36.83
08/09/2023	30.03	102.61	11.07	22.27	37.00
08/10/2023	27.89	98.24	10.71	21.47	35.69
08/11/2023	35.78	124.26	13.41	26.87	44.77
08/12/2023	29.95	102.60	11.19	22.52	37.47
08/13/2023	31.67	107.50	11.78	23.60	39.30
08/14/2023	29.28	129.07	14.16	28.35	47.24
08/15/2023	30.70	129.61	14.18	28.38	47.33
08/16/2023	24.74	130.82	14.27	28.52	47.53
08/17/2023	28.18	108.62	12.03	24.07	40.11
08/18/2023	25.81	94.77	10.37	20.71	34.56
08/19/2023	25.79	94.27	10.34	20.53	34.41
08/20/2023	27.11	94.41	10.41	20.66	34.69
08/21/2023	53.67	91.55	8.69	17.26	28.89
08/22/2023	26.61	97.01	10.55	20.95	35.09
08/23/2023	31.02	108.49	11.73	23.38	39.06
08/24/2023	29.31	97.59	10.68	21.22	35.52
08/25/2023	26.76	97.17	10.53	20.99	35.06
08/26/2023	27.38	98.94	10.74	21.47	35.73
08/27/2023	27.78	100.10	10.90	21.81	36.34
08/28/2023	29.68	103.58	11.25	22.45	37.46
08/29/2023	27.61	129.22	14.08	28.12	46.86
08/30/2023	31.50	109.37	11.84	23.56	39.36
08/31/2023	22.73	124.25	13.48	26.93	44.88
Monthly Avg/Sum:	940.68 sum	3,321.77 sum	361.43 sum	722.29 sum	1,204.47 sum
Daily Min:	22.73	91.55	8.69	17.26	28.89
Daily Max:	53.67	130.82	14.27	28.52	47.53
Jul 2023 - Aug 2023	1,992.10 sum	6,254.71 sum	679.20 sum	1,356.99 sum	2,262.93 sum
QTD:	1,992.10 sum	6,254.71 sum	679.20 sum	1,356.99 sum	2,262.93 sum
YTD 2023:	7,925.05 sum	12,709.92 sum	1,318.16 sum	2,633.57 sum	4,390.27 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/02/2023 23:47 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2023	26.39	96.99	10.51	20.83	34.94
09/02/2023	28.00	98.22	10.69	21.37	35.60
09/03/2023	83.97	89.16	8.76	17.41	29.17
09/04/2023	28.84	98.99	10.76	21.50	35.82
09/05/2023	29.93	122.88	13.28	26.60	44.30
09/06/2023	29.02	102.78	11.24	22.44	37.40
09/07/2023	29.82	104.95	11.42	22.78	37.99
09/08/2023	74.01	97.44	10.49	21.02	34.97
09/09/2023	31.56	98.83	12.70	25.39	42.32
09/10/2023	30.82	110.52	12.53	25.04	41.79
09/11/2023	32.94	101.78	11.13	22.21	37.07
09/12/2023	31.39	90.57	11.05	22.10	36.84
09/13/2023	35.36	104.95	11.99	23.95	39.94
09/14/2023	35.32	118.08	12.82	25.69	42.77
09/15/2023	32.14	118.66	12.86	25.70	42.86
09/16/2023	29.52	99.98	10.87	21.77	36.30
09/17/2023	29.53	96.70	10.55	20.93	34.90
09/18/2023	30.30	97.74	10.64	21.09	35.22
09/19/2023	30.67	97.93	10.70	21.28	35.50
09/20/2023	40.11	73.73	7.73	15.45	25.74
09/21/2023	13.91	50.50	5.45	11.02	18.33
09/22/2023	13.99	49.44	5.38	10.86	18.10
09/23/2023	13.76	48.22	5.22	10.43	17.36
09/24/2023	13.49	49.84	5.45	10.76	17.98
09/25/2023	13.40	49.54	5.31	10.59	17.66
09/26/2023	82.76	72.70	6.41	12.74	21.26
09/27/2023	13.22	47.98	5.15	10.32	17.24
09/28/2023	14.58	48.06	5.18	10.42	17.33
09/29/2023	13.34	47.85	5.13	10.37	17.27
09/30/2023	13.31	47.58	5.11	10.32	17.18
Monthly Avg/Sum:	925.40 sum	2,532.59 sum	276.51 sum	552.38 sum	921.15 sum
Daily Min:	13.22	47.58	5.11	10.32	17.18
Daily Max:	83.97	122.88	13.28	26.60	44.30
Jul 2023 - Sep 2023	2,917.50 sum	8,787.30 sum	955.71 sum	1,909.37 sum	3,184.08 sum
QTD:	2,917.50 sum	8,787.30 sum	955.71 sum	1,909.37 sum	3,184.08 sum
YTD 2023:	8,850.45 sum	15,242.51 sum	1,594.67 sum	3,185.95 sum	5,311.42 sum

Monthly Summary By Day Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOX_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOX_SUSD, LbPerHr 1 Hour(s)
07/01/2023	0.0	0.0	0.0	0.0
07/02/2023	0.0	0.0	0.0	0.0
07/03/2023	0.0	0.0	0.0	0.0
07/04/2023	0.0	0.0	0.0	0.0
07/05/2023	0.0	0.0	0.0	0.0
07/06/2023	0.0	0.0	0.0	0.0
07/07/2023	0.0	0.0	137.6	10.4
07/08/2023	0.0	0.0	0.0	0.0
07/09/2023	0.0	0.0	10.3	0.2
07/10/2023	0.0	0.0	0.0	0.0
07/11/2023	0.0	0.0	0.0	0.0
07/12/2023	0.0	0.0	0.0	0.0
07/13/2023	0.0	0.0	0.0	0.0
07/14/2023	0.0	0.0	16.8	9.4
07/15/2023	0.0	0.0	0.0	0.0
07/16/2023	0.0	0.0	0.0	0.0
07/17/2023	0.0	0.0	0.0	0.0
07/18/2023	0.0	0.0	0.0	0.0
07/19/2023	0.0	0.0	0.0	0.0
07/20/2023	0.0	0.0	0.0	0.0
07/21/2023	0.0	0.0	0.0	0.0
07/22/2023	0.0	0.0	0.0	0.0
07/23/2023	0.0	0.0	0.0	0.0
07/24/2023	0.0	0.0	0.0	0.0
07/25/2023	0.0	0.0	0.0	0.0
07/26/2023	0.0	0.0	0.0	0.0
07/27/2023	0.0	0.0	0.0	0.0
07/28/2023	0.0	0.0	0.0	0.0
07/29/2023	0.0	0.0	0.0	0.0
07/30/2023	0.0	0.0	0.0	0.0
07/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	164.7 sum	20.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	137.6	10.4
Jul 2023 - Jul 2023	0.0 sum	0.0 sum	164.7 sum	20.0 sum
QTD:	0.0 sum	0.0 sum	164.7 sum	20.0 sum
YTD 2023:	2,164.0 sum	338.4 sum	1,595.1 sum	357.0 sum

Monthly Summary By Day Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2023	0.0	0.0	0.0	0.0
08/02/2023	0.0	0.0	0.0	0.0
08/03/2023	0.0	0.0	0.0	0.0
08/04/2023	0.0	0.0	0.0	0.0
08/05/2023	0.0	0.0	0.0	0.0
08/06/2023	0.0	0.0	0.0	0.0
08/07/2023	0.0	0.0	0.0	0.0
08/08/2023	0.0	0.0	0.0	0.0
08/09/2023	0.0	0.0	0.0	0.0
08/10/2023	0.0	0.0	0.0	0.0
08/11/2023	0.0	0.0	0.0	0.0
08/12/2023	0.0	0.0	0.0	0.0
08/13/2023	0.0	0.0	0.0	0.0
08/14/2023	0.0	0.0	0.0	0.0
08/15/2023	0.0	0.0	0.0	0.0
08/16/2023	0.0	0.0	0.0	0.0
08/17/2023	0.0	0.0	0.0	0.0
08/18/2023	0.0	0.0	0.0	0.0
08/19/2023	0.0	0.0	0.0	0.0
08/20/2023	0.0	0.0	0.0	0.0
08/21/2023	0.0	0.0	28.1	13.1
08/22/2023	0.0	0.0	0.0	0.0
08/23/2023	0.0	0.0	0.0	0.0
08/24/2023	0.0	0.0	0.0	0.0
08/25/2023	0.0	0.0	0.0	0.0
08/26/2023	0.0	0.0	0.0	0.0
08/27/2023	0.0	0.0	0.0	0.0
08/28/2023	0.0	0.0	0.0	0.0
08/29/2023	0.0	0.0	0.0	0.0
08/30/2023	0.0	0.0	0.0	0.0
08/31/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	28.1 sum	13.1 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	28.1	13.1
Jul 2023 - Aug 2023	0.0 sum	0.0 sum	192.8 sum	33.1 sum
QTD:	0.0 sum	0.0 sum	192.8 sum	33.1 sum
YTD 2023:	2,164.0 sum	338.4 sum	1,623.2 sum	370.1 sum

Monthly Summary By Day Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOX_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOX_SUSD, LbPerHr 1 Hour(s)
09/01/2023	0.0	0.0	0.0	0.0
09/02/2023	0.0	0.0	0.0	0.0
09/03/2023	45.0	10.0	0.0	0.0
09/04/2023	0.0	0.0	0.0	0.0
09/05/2023	0.0	0.0	0.0	0.0
09/06/2023	0.0	0.0	0.0	0.0
09/07/2023	0.0	0.2	0.0	0.0
09/08/2023	42.5	11.9	0.0	0.0
09/09/2023	0.0	0.0	0.0	0.0
09/10/2023	0.0	0.0	0.0	0.0
09/11/2023	0.0	0.0	0.0	0.0
09/12/2023	0.0	0.0	0.0	0.0
09/13/2023	0.0	0.0	0.0	0.0
09/14/2023	0.0	0.0	0.0	0.0
09/15/2023	0.0	0.0	0.0	0.0
09/16/2023	0.0	0.0	0.0	0.0
09/17/2023	0.0	0.0	0.0	0.0
09/18/2023	0.0	0.0	0.0	0.0
09/19/2023	0.0	0.0	0.0	0.0
09/20/2023	0.0	0.0	11.3	2.1
09/21/2023	0.0	0.0	0.0	0.0
09/22/2023	0.0	0.0	0.0	0.0
09/23/2023	0.0	0.0	0.0	0.0
09/24/2023	0.0	0.0	0.0	0.0
09/25/2023	0.0	0.0	0.0	0.0
09/26/2023	0.0	0.0	50.3	14.2
09/27/2023	0.0	0.0	0.0	0.0
09/28/2023	0.0	0.0	0.0	0.0
09/29/2023	0.0	0.0	0.0	0.0
09/30/2023	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	87.5 sum	22.1 sum	61.6 sum	16.3 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	45.0	11.9	50.3	14.2
Jul 2023 - Sep 2023	87.5 sum	22.1 sum	254.4 sum	49.4 sum
QTD:	87.5 sum	22.1 sum	254.4 sum	49.4 sum
YTD 2023:	2,251.5 sum	360.5 sum	1,684.8 sum	386.4 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 00:57 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2023	0.5260	6.6976	1.4667	13.0909	0.3175	2.7209	0.1590	1.3621	0.5292	4.5342
Aug 2023	0.4704	6.5712	1.6608	13.0229	0.3612	2.7355	0.1806	1.3696	0.6021	4.5589
Sep 2023	0.4631	6.5084	1.2665	12.5949	0.2763	2.6667	0.1384	1.3350	0.4609	4.4444
Sum/Avg	6.5084		12.5949		2.6667		1.3350		4.4444	
Limit Value										

AQ57 CT1 HOURLY EMISSIONS

Date/Tim Mod	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/01/23 0:00	0.8			1.5			1			0.63			0.31536			1.05	
07/01/23 1:00	0.8			1.5			1			0.63			0.3147			1.05	
07/01/23 2:00	0.8			1.5			1			0.63			0.3129			1.04	
07/01/23 3:00	0.9			1.5			1			0.62			0.3117			1.04	
07/01/23 4:00	0.9			1.5			1			0.62			0.3084			1.03	
07/01/23 5:00	0.9			1.5			1			0.61			0.30714			1.02	
07/01/23 6:00	1			1.5			1			0.59			0.2952			0.98	
07/01/23 7:00	0.8			1.5			0			0.43			0.21696			0.72	
07/01/23 8:00	0.7			1.5			0			0.44			0.21798			0.73	
07/01/23 9:00	0.7			1.5			0			0.44			0.21768			0.73	
07/01/23 10:00	0.7			1.5			0			0.44			0.21786			0.73	
07/01/23 11:00	0.7			1.5			0			0.44			0.21762			0.73	
07/01/23 12:00	0.7			1.5			0			0.44			0.21828			0.73	
07/01/23 13:00	0.7			1.5			0			0.44			0.21894			0.73	
07/01/23 14:00	0.6			1.5			0			0.44			0.21804			0.73	
07/01/23 15:00	0.6			1.5			0			0.44			0.2184			0.73	
07/01/23 16:00	0.6			1.5			0			0.44			0.21852			0.73	
07/01/23 17:00	0.7			1.5			1			0.51			0.25326			0.84	
07/01/23 18:00	0.3			1.5			1			0.65			0.32658			1.09	
07/01/23 19:00	0.3			1.5			1			0.65			0.3261			1.09	
07/01/23 20:00	0.4			1.5			1			0.65			0.32394			1.08	
07/01/23 21:00	0.5			1.5			1			0.64			0.32136			1.07	
07/01/23 22:00	0.6			1.5			1			0.64			0.31902			1.06	
07/01/23 23:00	0.6			1.5			1			0.64			0.3183			1.06	
07/02/23 0:00	0.8			1.5			1			0.63			0.31728			1.06	
07/02/23 1:00	1			1.5			1			0.63			0.31518			1.05	
07/02/23 2:00	0.9			1.5			1			0.63			0.31518			1.05	
07/02/23 3:00	0.9			1.5			1			0.63			0.3144			1.05	
07/02/23 4:00	0.9			1.5			1			0.63			0.31356			1.05	
07/02/23 5:00	0.9			1.5			1			0.63			0.31362			1.05	
07/02/23 6:00	0.9			1.5			1			0.63			0.31374			1.05	
07/02/23 7:00	0.9			1.5			0			0.49			0.24624			0.82	

Monday, October 30, 2023

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/02/23 8:00	0.7			1.5			0			0.44			0.21984			0.73	
07/02/23 9:00	0.8			1.5			0			0.44			0.22182			0.74	
07/02/23 10:00	0.7			1.5			0			0.44			0.22092			0.74	
07/02/23 11:00	0.8			1.5			1			0.51			0.2559			0.85	
07/02/23 12:00	0.5			1.5			1			0.64			0.32244			1.07	
07/02/23 13:00	0.5			1.5			1			0.65			0.32448			1.08	
07/02/23 14:00	0.4			1.5			1			0.65			0.3261			1.09	
07/02/23 15:00	0.4			1.5			1			0.65			0.3246			1.08	
07/02/23 16:00	0.3			1.5			1			0.65			0.32424			1.08	
07/02/23 17:00	0.3			1.5			1			0.65			0.3261			1.09	
07/02/23 18:00	0.3			1.5			1			0.68			0.3387			1.13	
07/02/23 19:00	0.2			1.5			2			0.75			0.37596			1.25	
07/02/23 20:00	0.2			1.5			1			0.73			0.36318			1.21	
07/02/23 21:00	0.5			1.5			1			0.65			0.32478			1.08	
07/02/23 22:00	0.5			1.5			1			0.66			0.32898			1.1	
07/02/23 23:00	0.6			1.5			1			0.64			0.31986			1.07	
07/03/23 0:00	0.7			1.5			1			0.63			0.31512			1.05	
07/03/23 1:00	0.8			1.5			1			0.63			0.31398			1.05	
07/03/23 2:00	0.8			1.5			1			0.63			0.3135			1.05	
07/03/23 3:00	1			1.5			1			0.62			0.31188			1.04	
07/03/23 4:00	0.9			1.5			1			0.62			0.31146			1.04	
07/03/23 5:00	1			1.5			1			0.62			0.31086			1.04	
07/03/23 6:00	1			1.5			1			0.62			0.31062			1.04	
07/03/23 7:00	0.9			1.5			0			0.51			0.2529			0.84	
07/03/23 8:00	0.7			1.5			0			0.44			0.21954			0.73	
07/03/23 9:00	0.6			1.5			0			0.44			0.21816			0.73	
07/03/23 10:00	0.6			1.5			0			0.44			0.21756			0.73	
07/03/23 11:00	0.6			1.5			0			0.44			0.21792			0.73	
07/03/23 12:00	0.6			1.5			0			0.44			0.21828			0.73	
07/03/23 13:00	0.6			1.5			0			0.44			0.21828			0.73	
07/03/23 14:00	0.6			1.5			0			0.44			0.2187			0.73	
07/03/23 15:00	0.6			1.5			0			0.5			0.2496			0.83	
07/03/23 16:00	0.5			1.5			1			0.64			0.32118			1.07	
07/03/23 17:00	0.5			1.5			1			0.64			0.31974			1.07	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/03/23 18:00	0.6			1.5			1			0.64			0.31908			1.06	
07/03/23 19:00	0.6			1.5			1			0.63			0.3156			1.05	
07/03/23 20:00	0.7			1.5			1			0.62			0.31236			1.04	
07/03/23 21:00	0.8			1.5			1			0.62			0.31158			1.04	
07/03/23 22:00	0.9			1.5			1			0.62			0.30984			1.03	
07/03/23 23:00	0.9			1.5			1			0.62			0.30996			1.03	
07/04/23 0:00	1			1.5			1			0.62			0.31002			1.03	
07/04/23 1:00	0.8			1.5			1			0.62			0.31188			1.04	
07/04/23 2:00	0.8			1.5			1			0.62			0.31122			1.04	
07/04/23 3:00	1			1.5			1			0.62			0.31188			1.04	
07/04/23 4:00	1			1.5			1			0.62			0.31224			1.04	
07/04/23 5:00	1.1			1.5			1			0.62			0.31176			1.04	
07/04/23 6:00	1			1.5			1			0.54			0.26862			0.9	
07/04/23 7:00	0.7			1.5			0			0.44			0.2184			0.73	
07/04/23 8:00	0.7			1.5			1			0.44			0.2202			0.73	
07/04/23 9:00	0.7			1.5			0			0.44			0.22056			0.74	
07/04/23 10:00	0.6			1.5			0			0.44			0.22086			0.74	
07/04/23 11:00	0.6			1.5			0			0.44			0.2196			0.73	
07/04/23 12:00	0.6			1.5			0			0.44			0.22014			0.73	
07/04/23 13:00	0.6			1.5			0			0.44			0.2208			0.74	
07/04/23 14:00	0.6			1.5			0			0.44			0.22092			0.74	
07/04/23 15:00	0.6			1.5			0			0.44			0.22092			0.74	
07/04/23 16:00	0.6			1.5			0			0.44			0.22092			0.74	
07/04/23 17:00	0.6			1.5			0			0.44			0.22068			0.74	
07/04/23 18:00	0.6			1.5			0			0.44			0.21996			0.73	
07/04/23 19:00	0.6			1.5			0			0.44			0.22044			0.73	
07/04/23 20:00	0.6			1.5			0			0.44			0.21876			0.73	
07/04/23 21:00	0.6			1.5			0			0.44			0.21852			0.73	
07/04/23 22:00	0.6			1.5			0			0.44			0.21804			0.73	
07/04/23 23:00	0.6			1.5			0			0.44			0.21786			0.73	
07/05/23 0:00	0.6			1.5			0			0.44			0.21804			0.73	
07/05/23 1:00	0.6			1.5			0			0.44			0.21942			0.73	
07/05/23 2:00	0.7			1.6			1			0.44			0.21972			0.73	
07/05/23 3:00	0.7			1.5			1			0.44			0.2193			0.73	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/05/23 4:00	0.7			1.5			1			0.44			0.21912			0.73	
07/05/23 5:00	0.7			1.5			1			0.44			0.219			0.73	
07/05/23 6:00	0.7			1.5			1			0.44			0.21906			0.73	
07/05/23 7:00	0.7			1.5			1			0.44			0.21936			0.73	
07/05/23 8:00	0.7			1.5			1			0.44			0.22032			0.73	
07/05/23 9:00	0.7			1.5			1			0.44			0.22056			0.74	
07/05/23 10:00	0.6			1.5			0			0.44			0.2205			0.74	
07/05/23 11:00	0.6			1.5			0			0.44			0.2208			0.74	
07/05/23 12:00	0.6			1.5			0			0.44			0.22086			0.74	
07/05/23 13:00	1			1.5			0			0.52			0.25752			0.86	
07/05/23 14:00	1			1.5			0			0.56			0.27798			0.93	
07/05/23 15:00	0.9			1.5			1			0.61			0.30474			1.02	
07/05/23 16:00	0.6			1.5			1			0.64			0.31944			1.06	
07/05/23 17:00	0.6			1.5			1			0.64			0.31896			1.06	
07/05/23 18:00	0.6			1.5			1			0.64			0.32052			1.07	
07/05/23 19:00	0.4			1.5			1			0.69			0.34326			1.14	
07/05/23 20:00	0.6			1.5			1			0.65			0.32676			1.09	
07/05/23 21:00	0.9			1.5			1			0.63			0.31428			1.05	
07/05/23 22:00	0.9			1.5			1			0.63			0.3144			1.05	
07/05/23 23:00	1.1			1.5			1			0.62			0.30918			1.03	
07/06/23 0:00	1.2			1.5			1			0.62			0.30876			1.03	
07/06/23 1:00	1.2			1.5			1			0.62			0.30774			1.03	
07/06/23 2:00	1.2			1.5			1			0.61			0.30672			1.02	
07/06/23 3:00	1.3			1.5			1			0.61			0.30618			1.02	
07/06/23 4:00	1.3			1.5			1			0.61			0.30588			1.02	
07/06/23 5:00	1.3			1.5			1			0.61			0.30504			1.02	
07/06/23 6:00	1.2			1.5			1			0.61			0.30456			1.02	
07/06/23 7:00	1			1.5			1			0.54			0.26892			0.9	
07/06/23 8:00	0.7			1.5			0			0.44			0.21906			0.73	
07/06/23 9:00	0.7			1.5			0			0.44			0.2199			0.73	
07/06/23 10:00	0.7			1.5			0			0.44			0.22086			0.74	
07/06/23 11:00	0.6			1.5			0			0.44			0.22128			0.74	
07/06/23 12:00	0.6			1.5			0			0.44			0.22008			0.73	
07/06/23 13:00	0.6			1.5			0			0.44			0.2205			0.74	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/06/23 14:00	0.6			1.5			0			0.44			0.22062			0.74	
07/06/23 15:00	0.6			1.5			0			0.44			0.22026			0.73	
07/06/23 16:00	1			1.5			0			0.52			0.25764			0.86	
07/06/23 17:00	0.7			1.5			1			0.63			0.31746			1.06	
07/06/23 18:00	0.6			1.5			1			0.65			0.32544			1.08	
07/06/23 19:00	0.3			1.5			1			0.75			0.37548			1.25	
07/06/23 20:00	0.3			1.5			1			0.72			0.3594			1.2	
07/06/23 21:00	0.7			1.5			1			0.64			0.32142			1.07	
07/06/23 22:00	1.1			1.5			1			0.62			0.31056			1.04	
07/06/23 23:00	1.1			1.5			1			0.62			0.30948			1.03	
07/07/23 0:00	1.2			1.5			1			0.62			0.30834			1.03	
07/07/23 1:00	1.2			1.5			1			0.62			0.30756			1.03	
07/07/23 2:00	1.2			1.5			1			0.61			0.30708			1.02	
07/07/23 3:00	1.3			1.5			1			0.61			0.30594			1.02	
07/07/23 4:00	1.2			1.5			1			0.61			0.30726			1.02	
07/07/23 5:00	1.2			1.5			1			0.62			0.30888			1.03	
07/07/23 6:00	1.2			1.5			1			0.62			0.30882			1.03	
07/07/23 7:00	1.2			1.5			1			0.62			0.31008			1.03	
07/07/23 8:00	0.8			1.5			0			0.48			0.23832			0.79	
07/07/23 9:00	0.9			1.5			1			0.58			0.28764			0.96	
07/07/23 10:00	1			1.5			1			0.63			0.3141			1.05	
07/07/23 11:00	1.4			1.5			1			0.57			0.28602			0.95	
07/07/23 12:00	1.4			1.5			1			0.56			0.27858			0.93	
07/07/23 13:00	2.7			1.5			1			0.57			0.28464			0.95	
07/07/23 14:00	1.2			1.5			1			0.58			0.2886			0.96	
07/07/23 15:00	1.6			1.5			0			0.55			0.27726			0.92	
07/07/23 16:00	0.8			1.5			0			0.47			0.23634			0.79	
07/07/23 17:00	0.8			1.5			0			0.5			0.24972			0.83	
07/07/23 18:00	0.8			1.5			0			0.49			0.24516			0.82	
07/07/23 19:00	0.4			1.6			2			0.73			0.36648			1.22	
07/07/23 20:00	0.2			1.5			2			0.74			0.37176			1.24	
07/07/23 21:00	0.5			1.5			1			0.66			0.32994			1.1	
07/07/23 22:00	0.8			1.5			1			0.63			0.31476			1.05	
07/07/23 23:00	0.9			1.5			1			0.62			0.31128			1.04	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 0:00	0.9			1.5			1			0.63			0.31266			1.04	
07/08/23 1:00	1			1.5			1			0.62			0.3123			1.04	
07/08/23 2:00	1			1.5			1			0.62			0.31146			1.04	
07/08/23 3:00	1.1			1.5			1			0.62			0.31098			1.04	
07/08/23 4:00	1			1.5			1			0.62			0.31074			1.04	
07/08/23 5:00	1.1			1.5			1			0.62			0.3105			1.04	
07/08/23 6:00	1.1			1.5			1			0.62			0.31002			1.03	
07/08/23 7:00	1			1.5			1			0.54			0.26916			0.9	
07/08/23 8:00	0.7			1.5			0			0.44			0.22062			0.74	
07/08/23 9:00	0.7			1.5			0			0.44			0.22224			0.74	
07/08/23 10:00	0.7			1.5			0			0.44			0.22224			0.74	
07/08/23 11:00	0.6			1.5			0			0.44			0.22158			0.74	
07/08/23 12:00	0.6			1.5			0			0.44			0.22212			0.74	
07/08/23 13:00	0.6			1.5			0			0.44			0.22152			0.74	
07/08/23 14:00	0.6			1.5			0			0.44			0.22074			0.74	
07/08/23 15:00	0.6			1.5			0			0.44			0.22098			0.74	
07/08/23 16:00	0.6			1.5			0			0.44			0.22092			0.74	
07/08/23 17:00	0.8			1.5			0			0.52			0.25956			0.87	
07/08/23 18:00	0.6			1.5			1			0.65			0.32586			1.09	
07/08/23 19:00	0.3			1.5			1			0.77			0.38334			1.28	
07/08/23 20:00	0.5			1.5			1			0.69			0.34476			1.15	
07/08/23 21:00	1.1			1.5			1			0.62			0.31044			1.03	
07/08/23 22:00	1.1			1.5			1			0.62			0.30918			1.03	
07/08/23 23:00	1.2			1.5			1			0.62			0.30804			1.03	
07/09/23 0:00	1.2			1.5			1			0.61			0.30708			1.02	
07/09/23 1:00	1.2			1.5			1			0.62			0.30762			1.03	
07/09/23 2:00	1.2			1.5			1			0.62			0.30882			1.03	
07/09/23 3:00	1.3			1.5			1			0.62			0.3084			1.03	
07/09/23 4:00	1.3			1.5			1			0.62			0.30768			1.03	
07/09/23 5:00	1.2			1.5			1			0.62			0.30906			1.03	
07/09/23 6:00	1			1.5			1			0.56			0.2784			0.93	
07/09/23 7:00	0.6			1.5			1			0.53			0.26352			0.88	
07/09/23 8:00	0.8			1.5			1			0.54			0.26892			0.9	
07/09/23 9:00	0.7			1.5			0			0.44			0.2223			0.74	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 10:00	0.6			1.5			0			0.44			0.22134			0.74	
07/09/23 11:00	0.6			1.5			0			0.44			0.2214			0.74	
07/09/23 12:00	0.6			1.5			0			0.44			0.2205			0.74	
07/09/23 13:00	0.6			1.5			0			0.44			0.21834			0.73	
07/09/23 14:00	0.6			1.5			0			0.44			0.21858			0.73	
07/09/23 15:00	0.6			1.5			0			0.44			0.21828			0.73	
07/09/23 16:00	0.6			1.5			0			0.44			0.21816			0.73	
07/09/23 17:00	0.6			1.5			0			0.43			0.21516			0.72	
07/09/23 18:00	0.8			1.5			0			0.47			0.2346			0.78	
07/09/23 19:00	1.1			1.5			1			0.55			0.2751			0.92	
07/09/23 20:00	1.2			1.5			1			0.55			0.27486			0.92	
07/09/23 21:00	1.1			1.5			1			0.55			0.27612			0.92	
07/09/23 22:00	1.5			1.5			1			0.5			0.24984			0.83	
07/09/23 23:00	0.7			1.5			0			0.43			0.2154			0.72	
07/10/23 0:00	0.7			1.5			1			0.43			0.21564			0.72	
07/10/23 1:00	0.7			1.5			1			0.43			0.21534			0.72	
07/10/23 2:00	0.7			1.6			1			0.43			0.2151			0.72	
07/10/23 3:00	0.7			1.5			1			0.43			0.21522			0.72	
07/10/23 4:00	0.7			1.5			1			0.43			0.2151			0.72	
07/10/23 5:00	0.7			1.5			1			0.43			0.21522			0.72	
07/10/23 6:00	0.7			1.5			1			0.43			0.21528			0.72	
07/10/23 7:00	0.7			1.5			1			0.43			0.21546			0.72	
07/10/23 8:00	0.7			1.5			1			0.43			0.216			0.72	
07/10/23 9:00	0.7			1.5			0			0.43			0.2166			0.72	
07/10/23 10:00	0.7			1.5			0			0.43			0.21696			0.72	
07/10/23 11:00	0.6			1.5			0			0.43			0.21678			0.72	
07/10/23 12:00	0.6			1.5			0			0.44			0.21798			0.73	
07/10/23 13:00	0.6			1.5			0			0.44			0.21912			0.73	
07/10/23 14:00	0.6			1.5			0			0.44			0.21996			0.73	
07/10/23 15:00	0.6			1.5			0			0.44			0.22038			0.73	
07/10/23 16:00	0.6			1.5			0			0.44			0.22008			0.73	
07/10/23 17:00	0.6			1.5			0			0.44			0.21972			0.73	
07/10/23 18:00	0.6			1.5			0			0.45			0.2232			0.74	
07/10/23 19:00	0.8			1.5			0			0.49			0.24612			0.82	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/10/23 20:00	1.2			1.5			0			0.57			0.28254			0.94	
07/10/23 21:00	0.9			1.4			0			0.48			0.2379			0.79	
07/10/23 22:00	0.7			1.4			0			0.46			0.23034			0.77	
07/10/23 23:00	0.7			1.5			0			0.45			0.2241			0.75	
07/11/23 0:00	0.7			1.5			0			0.44			0.21978			0.73	
07/11/23 1:00	0.7			1.5			0			0.44			0.22068			0.74	
07/11/23 2:00	0.7			1.5			0			0.44			0.2211			0.74	
07/11/23 3:00	0.7			1.5			0			0.44			0.22116			0.74	
07/11/23 4:00	0.7			1.5			0			0.44			0.22092			0.74	
07/11/23 5:00	0.7			1.5			0			0.44			0.22194			0.74	
07/11/23 6:00	0.8			1.5			0			0.48			0.23766			0.79	
07/11/23 7:00	0.8			1.5			0			0.44			0.21906			0.73	
07/11/23 8:00	0.7			1.5			0			0.44			0.2211			0.74	
07/11/23 9:00	0.6			1.5			0			0.44			0.22164			0.74	
07/11/23 10:00	0.6			1.5			0			0.44			0.2211			0.74	
07/11/23 11:00	0.6			1.5			0			0.44			0.2205			0.74	
07/11/23 12:00	0.6			1.5			0			0.44			0.22146			0.74	
07/11/23 13:00	0.6			1.5			0			0.44			0.2214			0.74	
07/11/23 14:00	0.6			1.5			0			0.44			0.22116			0.74	
07/11/23 15:00	0.6			1.5			0			0.44			0.22128			0.74	
07/11/23 16:00	0.6			1.5			0			0.45			0.22488			0.75	
07/11/23 17:00	0.6			1.4			0			0.47			0.2355			0.79	
07/11/23 18:00	0.6			1.5			0			0.46			0.23082			0.77	
07/11/23 19:00	0.6			1.5			0			0.54			0.26844			0.89	
07/11/23 20:00	0.6			1.5			0			0.54			0.27144			0.9	
07/11/23 21:00	0.6			1.5			0			0.54			0.27132			0.9	
07/11/23 22:00	0.7			1.5			0			0.49			0.24588			0.82	
07/11/23 23:00	0.7			1.5			0			0.46			0.22932			0.76	
07/12/23 0:00	0.7			1.5			0			0.44			0.21888			0.73	
07/12/23 1:00	0.7			1.5			0			0.44			0.2193			0.73	
07/12/23 2:00	0.7			1.5			0			0.44			0.21822			0.73	
07/12/23 3:00	0.7			1.5			0			0.43			0.21738			0.72	
07/12/23 4:00	0.7			1.5			0			0.43			0.21738			0.72	
07/12/23 5:00	0.7			1.5			0			0.43			0.21726			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/12/23 6:00	0.7			1.5			0			0.43			0.21726			0.72	
07/12/23 7:00	0.7			1.5			0			0.44			0.21882			0.73	
07/12/23 8:00	0.6			1.5			0			0.44			0.22128			0.74	
07/12/23 9:00	0.6			1.5			0			0.44			0.22092			0.74	
07/12/23 10:00	0.6			1.5			0			0.44			0.22116			0.74	
07/12/23 11:00	0.6			1.5			0			0.44			0.22182			0.74	
07/12/23 12:00	0.6			1.5			0			0.44			0.22236			0.74	
07/12/23 13:00	0.6			1.5			0			0.44			0.22116			0.74	
07/12/23 14:00	0.6			1.5			0			0.44			0.22068			0.74	
07/12/23 15:00	0.8			1.5			0			0.44			0.22044			0.73	
07/12/23 16:00	0.6			1.5			0			0.44			0.22068			0.74	
07/12/23 17:00	0.6			1.5			0			0.46			0.22914			0.76	
07/12/23 18:00	0.6			1.5			0			0.49			0.2448			0.82	
07/12/23 19:00	0.6			1.5			0			0.55			0.27252			0.91	
07/12/23 20:00	0.6			1.5			0			0.54			0.26964			0.9	
07/12/23 21:00	0.6			1.5			0			0.54			0.2706			0.9	
07/12/23 22:00	0.6			1.5			0			0.52			0.25854			0.86	
07/12/23 23:00	0.7			1.5			0			0.47			0.23706			0.79	
07/13/23 0:00	0.6			1.5			0			0.49			0.24606			0.82	
07/13/23 1:00	0.7			1.5			0			0.43			0.21696			0.72	
07/13/23 2:00	0.7			1.5			0			0.43			0.21732			0.72	
07/13/23 3:00	0.7			1.5			0			0.44			0.2187			0.73	
07/13/23 4:00	0.7			1.5			0			0.44			0.2196			0.73	
07/13/23 5:00	0.7			1.5			0			0.44			0.21936			0.73	
07/13/23 6:00	0.7			1.5			0			0.44			0.21966			0.73	
07/13/23 7:00	0.7			1.5			0			0.44			0.22038			0.73	
07/13/23 8:00	0.6			1.5			0			0.44			0.22092			0.74	
07/13/23 9:00	0.6			1.5			0			0.44			0.21966			0.73	
07/13/23 10:00	0.6			1.5			0			0.44			0.21882			0.73	
07/13/23 11:00	0.6			1.5			0			0.47			0.2331			0.78	
07/13/23 12:00	0.6			1.5			0			0.44			0.22002			0.73	
07/13/23 13:00	0.6			1.5			0			0.47			0.237			0.79	
07/13/23 14:00	0.6			1.5			0			0.49			0.24588			0.82	
07/13/23 15:00	0.6			1.5			0			0.44			0.222			0.74	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/13/23 16:00	0.6			1.5			0			0.47			0.23526			0.78	
07/13/23 17:00	0.6			1.5			0			0.47			0.2373			0.79	
07/13/23 18:00	0.6			1.5			0			0.51			0.25374			0.85	
07/13/23 19:00	0.5			1.6			1			0.73			0.36354			1.21	
07/13/23 20:00	0.2			1.5			1			0.72			0.36186			1.21	
07/13/23 21:00	0.6			1.5			1			0.65			0.32442			1.08	
07/13/23 22:00	0.7			1.5			1			0.64			0.3186			1.06	
07/13/23 23:00	0.8			1.5			1			0.63			0.31296			1.04	
07/14/23 0:00	0.9			1.5			1			0.62			0.31128			1.04	
07/14/23 1:00	0.9			1.5			1			0.63			0.31254			1.04	
07/14/23 2:00	0.9			1.5			1			0.62			0.31224			1.04	
07/14/23 3:00	1			1.5			1			0.62			0.3108			1.04	
07/14/23 4:00	1			1.5			1			0.62			0.31038			1.03	
07/14/23 5:00	1			1.5			1			0.62			0.31188			1.04	
07/14/23 6:00	1			1.5			1			0.63			0.31266			1.04	
07/14/23 7:00	1			1.5			1			0.63			0.31344			1.04	
07/14/23 8:00	0.8			1.4			0			0.47			0.23616			0.79	
07/14/23 9:00	0.7			1.5			0			0.44			0.22062			0.74	
07/14/23 10:00	0.7			1.5			0			0.44			0.2205			0.74	
07/14/23 11:00	0.7			1.5			0			0.44			0.22104			0.74	
07/14/23 12:00	0.7			1.5			1			0.53			0.2631			0.88	
07/14/23 13:00	0.5			1.5			1			0.66			0.33162			1.11	
07/14/23 14:00	0.7			1.5			0			0.51			0.25452			0.85	
07/14/23 15:00	0.6			1.5			0			0.48			0.2421			0.81	
07/14/23 16:00	0.7			1.5			0			0.47			0.23532			0.78	
07/14/23 17:00	0.5			1.5			1			0.63			0.3171			1.06	
07/14/23 18:00	0.3			1.5			1			0.73			0.3651			1.22	
07/14/23 19:00	0.2			1.5			2			0.78			0.39084			1.3	
07/14/23 20:00	0.2			1.5			2			0.77			0.38424			1.28	
07/14/23 21:00	0.2			1.5			1			0.72			0.3597			1.2	
07/14/23 22:00	0.4			1.5			1			0.68			0.33756			1.13	
07/14/23 23:00	0.7			1.4			0			0.49			0.24654			0.82	
07/15/23 0:00	0.7			1.5			0			0.54			0.26802			0.89	
07/15/23 1:00	0.7			1.5			0			0.51			0.2571			0.86	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/15/23 2:00	0.7			1.5			0			0.51			0.25302			0.84	
07/15/23 3:00	0.7			1.5			0			0.52			0.26034			0.87	
07/15/23 4:00	0.7			1.5			0			0.52			0.2622			0.87	
07/15/23 5:00	0.6			1.5			0			0.52			0.26208			0.87	
07/15/23 6:00	0.7			1.5			0			0.48			0.24216			0.81	
07/15/23 7:00	0.7			1.5			0			0.43			0.21636			0.72	
07/15/23 8:00	0.7			1.5			0			0.43			0.21648			0.72	
07/15/23 9:00	0.7			1.5			0			0.43			0.2157			0.72	
07/15/23 10:00	0.7			1.5			0			0.43			0.2157			0.72	
07/15/23 11:00	0.7			1.5			0			0.43			0.21564			0.72	
07/15/23 12:00	0.7			1.5			0			0.49			0.24348			0.81	
07/15/23 13:00	0.7			1.5			0			0.52			0.25854			0.86	
07/15/23 14:00	0.6			1.5			0			0.5			0.24834			0.83	
07/15/23 15:00	0.6			1.5			1			0.56			0.27798			0.93	
07/15/23 16:00	0.2			1.5			2			0.76			0.38142			1.27	
07/15/23 17:00	0.2			1.5			2			0.76			0.37872			1.26	
07/15/23 18:00	0.2			1.5			2			0.76			0.38196			1.27	
07/15/23 19:00	0.2			1.5			2			0.76			0.38202			1.27	
07/15/23 20:00	0.3			1.5			2			0.78			0.39036			1.3	
07/15/23 21:00	0.3			1.5			2			0.78			0.39246			1.31	
07/15/23 22:00	0.3			1.5			1			0.75			0.37524			1.25	
07/15/23 23:00	0.6			1.5			1			0.64			0.32238			1.07	
07/16/23 0:00	0.9			1.5			0			0.54			0.27102			0.9	
07/16/23 1:00	0.8			1.5			0			0.53			0.26652			0.89	
07/16/23 2:00	0.7			1.5			0			0.53			0.26724			0.89	
07/16/23 3:00	0.7			1.5			0			0.53			0.2664			0.89	
07/16/23 4:00	0.7			1.5			0			0.53			0.26292			0.88	
07/16/23 5:00	0.7			1.5			0			0.53			0.26706			0.89	
07/16/23 6:00	0.8			1.5			0			0.48			0.23862			0.8	
07/16/23 7:00	0.9			1.5			0			0.43			0.21612			0.72	
07/16/23 8:00	0.9			1.5			0			0.43			0.21678			0.72	
07/16/23 9:00	0.8			1.5			0			0.43			0.21678			0.72	
07/16/23 10:00	0.7			1.5			0			0.49			0.24498			0.82	
07/16/23 11:00	0.7			1.5			0			0.52			0.26064			0.87	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/16/23 12:00	0.7			1.5			0			0.53			0.26658			0.89	
07/16/23 13:00	0.7			1.5			0			0.53			0.26466			0.88	
07/16/23 14:00	0.4			1.6			1			0.73			0.36744			1.22	
07/16/23 15:00	0.3			1.5			2			0.77			0.38418			1.28	
07/16/23 16:00	0.3			1.5			2			0.76			0.38214			1.27	
07/16/23 17:00	0.2			1.5			2			0.76			0.38172			1.27	
07/16/23 18:00	0.2			1.5			2			0.76			0.3789			1.26	
07/16/23 19:00	0.2			1.5			2			0.76			0.38022			1.27	
07/16/23 20:00	0.3			1.5			1			0.69			0.34644			1.15	
07/16/23 21:00	0.4			1.5			1			0.68			0.33996			1.13	
07/16/23 22:00	0.7			1.4			0			0.5			0.25182			0.84	
07/16/23 23:00	0.7			1.5			0			0.47			0.23376			0.78	
07/17/23 0:00	0.7			1.5			0			0.52			0.26016			0.87	
07/17/23 1:00	0.7			1.5			0			0.52			0.25752			0.86	
07/17/23 2:00	0.7			1.5			0			0.46			0.22788			0.76	
07/17/23 3:00	0.7			1.5			0			0.43			0.21684			0.72	
07/17/23 4:00	0.7			1.4			0			0.44			0.21978			0.73	
07/17/23 5:00	0.7			1.5			0			0.51			0.25392			0.85	
07/17/23 6:00	0.6			1.5			0			0.53			0.2643			0.88	
07/17/23 7:00	0.7			1.5			0			0.44			0.22098			0.74	
07/17/23 8:00	0.7			1.5			0			0.43			0.21618			0.72	
07/17/23 9:00	0.7			1.5			0			0.43			0.21582			0.72	
07/17/23 10:00	0.7			1.5			0			0.48			0.24198			0.81	
07/17/23 11:00	0.7			1.4			0			0.51			0.25572			0.85	
07/17/23 12:00	0.7			1.5			0			0.51			0.25296			0.84	
07/17/23 13:00	0.7			1.5			0			0.53			0.26604			0.89	
07/17/23 14:00	0.7			1.5			0			0.53			0.26502			0.88	
07/17/23 15:00	0.6			1.5			0			0.56			0.28062			0.94	
07/17/23 16:00	0.2			1.5			2			0.76			0.37842			1.26	
07/17/23 17:00	0.4			1.5			1			0.65			0.32394			1.08	
07/17/23 18:00	0.7			1.5			0			0.53			0.26376			0.88	
07/17/23 19:00	0.6			1.5			0			0.52			0.25998			0.87	
07/17/23 20:00	0.6			1.5			0			0.53			0.2634			0.88	
07/17/23 21:00	0.7			1.5			0			0.53			0.26616			0.89	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/17/23 22:00	0.6			1.5			0			0.53			0.26316			0.88	
07/17/23 23:00	0.6			1.5			0			0.52			0.26136			0.87	
07/18/23 0:00	0.6			1.5			0			0.55			0.27384			0.91	
07/18/23 1:00	0.6			1.5			0			0.55			0.27468			0.92	
07/18/23 2:00	0.6			1.5			0			0.54			0.27018			0.9	
07/18/23 3:00	0.6			1.5			0			0.53			0.2646			0.88	
07/18/23 4:00	0.6			1.5			0			0.55			0.27636			0.92	
07/18/23 5:00	0.6			1.5			0			0.56			0.2781			0.93	
07/18/23 6:00	0.6			1.5			0			0.56			0.27828			0.93	
07/18/23 7:00	0.7			1.5			0			0.47			0.23676			0.79	
07/18/23 8:00	0.7			1.5			0			0.44			0.22074			0.74	
07/18/23 9:00	0.7			1.5			0			0.47			0.23484			0.78	
07/18/23 10:00	0.7			1.5			0			0.52			0.2604			0.87	
07/18/23 11:00	0.7			1.5			0			0.53			0.26598			0.89	
07/18/23 12:00	0.6			1.5			0			0.55			0.27294			0.91	
07/18/23 13:00	0.6			1.5			0			0.54			0.27144			0.9	
07/18/23 14:00	0.8			1.5			0			0.51			0.25458			0.85	
07/18/23 15:00	0.4			1.5			1			0.67			0.3348			1.12	
07/18/23 16:00	0.4			1.5			1			0.66			0.33066			1.1	
07/18/23 17:00	0.6			1.5			1			0.62			0.31212			1.04	
07/18/23 18:00	0.5			1.5			1			0.69			0.34302			1.14	
07/18/23 19:00	0.2			1.5			2			0.78			0.39162			1.31	
07/18/23 20:00	0.2			1.5			1			0.73			0.36744			1.22	
07/18/23 21:00	0.3			1.5			1			0.72			0.36156			1.21	
07/18/23 22:00	0.5			1.5			1			0.69			0.34308			1.14	
07/18/23 23:00	0.7			1.5			1			0.65			0.32712			1.09	
07/19/23 0:00	1.2			1.5			0			0.55			0.27438			0.91	
07/19/23 1:00	0.6			1.5			0			0.54			0.2694			0.9	
07/19/23 2:00	0.6			1.7			0			0.52			0.26226			0.87	
07/19/23 3:00	0.7			1.5			0			0.51			0.2541			0.85	
07/19/23 4:00	0.6			1.5			0			0.53			0.264			0.88	
07/19/23 5:00	0.6			1.5			0			0.55			0.27258			0.91	
07/19/23 6:00	0.6			1.5			0			0.55			0.273			0.91	
07/19/23 7:00	0.7			1.5			0			0.49			0.2472			0.82	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/19/23 8:00	0.7			1.5			0			0.45			0.22668			0.76	
07/19/23 9:00	0.6			1.5			0			0.48			0.24138			0.8	
07/19/23 10:00	0.7			1.5			0			0.47			0.23376			0.78	
07/19/23 11:00	0.6			1.5			0			0.52			0.26022			0.87	
07/19/23 12:00	0.6			1.5			0			0.54			0.27156			0.91	
07/19/23 13:00	0.7			1.5			0			0.57			0.28452			0.95	
07/19/23 14:00	0.2			1.5			1			0.75			0.37332			1.24	
07/19/23 15:00	0.2			1.5			1			0.76			0.38184			1.27	
07/19/23 16:00	0.2			1.5			1			0.76			0.37938			1.26	
07/19/23 17:00	0.1			1.5			1			0.75			0.37338			1.24	
07/19/23 18:00	0.1			1.5			2			0.76			0.38172			1.27	
07/19/23 19:00	0.2			1.5			2			0.78			0.39156			1.31	
07/19/23 20:00	0.2			1.5			2			0.78			0.39126			1.3	
07/19/23 21:00	0.2			1.5			1			0.76			0.37932			1.26	
07/19/23 22:00	0.2			1.5			1			0.73			0.36744			1.22	
07/19/23 23:00	0.6			1.5			1			0.67			0.33468			1.12	
07/20/23 0:00	1.4			1.5			0			0.55			0.27378			0.91	
07/20/23 1:00	0.7			1.5			0			0.53			0.26502			0.88	
07/20/23 2:00	0.7			1.4			0			0.53			0.26688			0.89	
07/20/23 3:00	0.7			1.5			0			0.53			0.26352			0.88	
07/20/23 4:00	0.6			1.5			0			0.54			0.27162			0.91	
07/20/23 5:00	0.6			1.5			0			0.55			0.2733			0.91	
07/20/23 6:00	0.6			1.5			0			0.54			0.26946			0.9	
07/20/23 7:00	0.7			1.5			0			0.45			0.22506			0.75	
07/20/23 8:00	0.7			1.5			0			0.44			0.21756			0.73	
07/20/23 9:00	0.7			1.5			0			0.44			0.22074			0.74	
07/20/23 10:00	0.7			1.5			0			0.47			0.23634			0.79	
07/20/23 11:00	0.7			1.5			0			0.51			0.25566			0.85	
07/20/23 12:00	0.7			1.5			0			0.54			0.27192			0.91	
07/20/23 13:00	0.7			1.5			0			0.54			0.27138			0.9	
07/20/23 14:00	0.7			1.5			0			0.54			0.27			0.9	
07/20/23 15:00	0.6			1.6			1			0.65			0.3267			1.09	
07/20/23 16:00	0.1			1.5			1			0.75			0.37332			1.24	
07/20/23 17:00	0.1			1.5			1			0.74			0.37086			1.24	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/20/23 18:00	0.2			1.5			2			0.77			0.38412			1.28	
07/20/23 19:00	0.2			1.5			2			0.79			0.39474			1.32	
07/20/23 20:00	0.2			1.5			1			0.74			0.37026			1.23	
07/20/23 21:00	0.2			1.5			1			0.71			0.35502			1.18	
07/20/23 22:00	0.5			1.5			1			0.66			0.33246			1.11	
07/20/23 23:00	0.8			1.4			0			0.56			0.2778			0.93	
07/21/23 0:00	0.7			1.5			0			0.53			0.26712			0.89	
07/21/23 1:00	0.7			1.5			0			0.53			0.26706			0.89	
07/21/23 2:00	0.7			1.5			0			0.51			0.25458			0.85	
07/21/23 3:00	0.7			1.5			0			0.5			0.2484			0.83	
07/21/23 4:00	0.7			1.5			0			0.51			0.25374			0.85	
07/21/23 5:00	0.7			1.5			0			0.5			0.2514			0.84	
07/21/23 6:00	0.9			1.5			0			0.51			0.25296			0.84	
07/21/23 7:00	1.1			1.5			0			0.44			0.22188			0.74	
07/21/23 8:00	0.8			1.5			0			0.43			0.21732			0.72	
07/21/23 9:00	0.7			1.5			0			0.43			0.21696			0.72	
07/21/23 10:00	0.7			1.5			0			0.43			0.21672			0.72	
07/21/23 11:00	0.8			1.5			0			0.48			0.24054			0.8	
07/21/23 12:00	0.7			1.4			0			0.48			0.23874			0.8	
07/21/23 13:00	0.7			1.5			0			0.52			0.26154			0.87	
07/21/23 14:00	0.7			1.5			0			0.56			0.28218			0.94	
07/21/23 15:00	0.3			1.5			1			0.71			0.35562			1.19	
07/21/23 16:00	0.3			1.5			1			0.67			0.33456			1.12	
07/21/23 17:00	0.5			1.5			1			0.63			0.31542			1.05	
07/21/23 18:00	0.4			1.5			1			0.66			0.33228			1.11	
07/21/23 19:00	0.2			1.5			2			0.76			0.38178			1.27	
07/21/23 20:00	0.3			1.5			1			0.69			0.34704			1.16	
07/21/23 21:00	0.6			1.5			1			0.63			0.31266			1.04	
07/21/23 22:00	0.6			1.5			1			0.64			0.32064			1.07	
07/21/23 23:00	0.7			1.5			1			0.62			0.31128			1.04	
07/22/23 0:00	0.8			1.4			0			0.53			0.2643			0.88	
07/22/23 1:00	0.7			1.5			0			0.5			0.25164			0.84	
07/22/23 2:00	0.7			1.4			0			0.45			0.22656			0.76	
07/22/23 3:00	0.8			1.5			0			0.46			0.22776			0.76	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/22/23 4:00	0.8			1.5			0			0.43			0.2172			0.72	
07/22/23 5:00	0.8			1.5			0			0.46			0.22818			0.76	
07/22/23 6:00	1.4			1.5			0			0.46			0.22836			0.76	
07/22/23 7:00	1			1.5			0			0.43			0.21558			0.72	
07/22/23 8:00	0.9			1.5			0			0.43			0.2163			0.72	
07/22/23 9:00	0.8			1.5			0			0.43			0.21576			0.72	
07/22/23 10:00	0.7			1.5			0			0.43			0.21546			0.72	
07/22/23 11:00	0.7			1.5			0			0.44			0.21882			0.73	
07/22/23 12:00	0.7			1.5			0			0.47			0.23526			0.78	
07/22/23 13:00	0.7			1.5			0			0.48			0.23892			0.8	
07/22/23 14:00	0.7			1.5			0			0.53			0.2637			0.88	
07/22/23 15:00	0.7			1.5			0			0.52			0.26052			0.87	
07/22/23 16:00	0.7			1.5			0			0.52			0.26226			0.87	
07/22/23 17:00	0.5			1.5			1			0.62			0.31188			1.04	
07/22/23 18:00	0.2			1.5			1			0.72			0.3621			1.21	
07/22/23 19:00	0.2			1.5			2			0.76			0.38076			1.27	
07/22/23 20:00	0.4			1.5			1			0.67			0.33324			1.11	
07/22/23 21:00	0.4			1.5			1			0.66			0.33006			1.1	
07/22/23 22:00	0.6			1.5			1			0.65			0.32328			1.08	
07/22/23 23:00	1.1			1.5			0			0.54			0.26862			0.9	
07/23/23 0:00	0.8			1.5			0			0.53			0.26658			0.89	
07/23/23 1:00	0.7			1.5			0			0.53			0.26748			0.89	
07/23/23 2:00	0.6			1.5			0			0.53			0.26706			0.89	
07/23/23 3:00	0.7			1.5			0			0.53			0.26748			0.89	
07/23/23 4:00	0.7			1.5			0			0.53			0.26646			0.89	
07/23/23 5:00	0.7			1.5			0			0.51			0.2547			0.85	
07/23/23 6:00	0.7			1.5			0			0.49			0.24462			0.82	
07/23/23 7:00	0.7			1.5			0			0.44			0.21852			0.73	
07/23/23 8:00	0.7			1.5			0			0.49			0.2451			0.82	
07/23/23 9:00	0.7			1.5			0			0.54			0.26838			0.89	
07/23/23 10:00	0.7			1.5			0			0.54			0.26862			0.9	
07/23/23 11:00	0.7			1.5			0			0.54			0.26856			0.9	
07/23/23 12:00	0.7			1.5			0			0.57			0.28308			0.94	
07/23/23 13:00	0.5			1.5			1			0.64			0.32034			1.07	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/23/23 14:00	0.7			1.4			0			0.56			0.27912			0.93	
07/23/23 15:00	0.6			1.5			0			0.53			0.26298			0.88	
07/23/23 16:00	1.2			1.5			0			0.54			0.27			0.9	
07/23/23 17:00	0.2			1.6			2			0.76			0.38226			1.27	
07/23/23 18:00	0.3			1.4			1			0.63			0.31722			1.06	
07/23/23 19:00	0.6			1.4			0			0.51			0.25722			0.86	
07/23/23 20:00	0.7			1.5			0			0.5			0.25026			0.83	
07/23/23 21:00	0.7			1.5			0			0.52			0.25752			0.86	
07/23/23 22:00	0.7			1.5			0			0.51			0.2532			0.84	
07/23/23 23:00	0.7			1.5			0			0.48			0.24216			0.81	
07/24/23 0:00	0.7			1.5			0			0.54			0.2706			0.9	
07/24/23 1:00	0.7			1.5			0			0.53			0.26562			0.89	
07/24/23 2:00	0.6			1.6			0			0.51			0.25428			0.85	
07/24/23 3:00	0.6			1.5			0			0.52			0.2577			0.86	
07/24/23 4:00	0.6			1.5			0			0.53			0.26658			0.89	
07/24/23 5:00	0.6			1.5			0			0.53			0.26652			0.89	
07/24/23 6:00	0.6			1.5			0			0.54			0.26928			0.9	
07/24/23 7:00	0.7			1.5			0			0.47			0.23448			0.78	
07/24/23 8:00	0.7			1.5			0			0.44			0.22212			0.74	
07/24/23 9:00	0.7			1.5			0			0.43			0.21672			0.72	
07/24/23 10:00	0.6			1.5			0			0.44			0.21876			0.73	
07/24/23 11:00	0.7			1.5			0			0.44			0.21984			0.73	
07/24/23 12:00	0.6			1.5			0			0.48			0.2388			0.8	
07/24/23 13:00	0.6			1.5			0			0.54			0.2709			0.9	
07/24/23 14:00	0.6			1.5			0			0.44			0.22038			0.73	
07/24/23 15:00	0.6			1.5			0			0.44			0.21822			0.73	
07/24/23 16:00	0.7			1.5			0			0.43			0.21666			0.72	
07/24/23 17:00	0.7			1.5			0			0.43			0.21654			0.72	
07/24/23 18:00	0.6			1.5			0			0.43			0.21744			0.72	
07/24/23 19:00	0.6			1.5			0			0.44			0.2217			0.74	
07/24/23 20:00	0.6			1.5			0			0.44			0.21912			0.73	
07/24/23 21:00	0.6			1.5			0			0.49			0.24456			0.82	
07/24/23 22:00	0.7			1.5			0			0.49			0.243			0.81	
07/24/23 23:00	0.7			1.5			0			0.5			0.25224			0.84	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/25/23 0:00	0.7			1.5			0			0.47			0.23736			0.79	
07/25/23 1:00	0.7			1.5			0			0.44			0.21768			0.73	
07/25/23 2:00	0.7			1.5			0			0.43			0.21594			0.72	
07/25/23 3:00	0.8			1.5			0			0.43			0.21594			0.72	
07/25/23 4:00	0.8			1.5			0			0.43			0.216			0.72	
07/25/23 5:00	0.7			1.5			0			0.46			0.23238			0.77	
07/25/23 6:00	0.7			1.5			0			0.47			0.23682			0.79	
07/25/23 7:00	0.8			1.5			0			0.44			0.22038			0.73	
07/25/23 8:00	0.7			1.5			0			0.46			0.22914			0.76	
07/25/23 9:00	0.7			1.5			0			0.43			0.21696			0.72	
07/25/23 10:00	0.7			1.5			0			0.44			0.22092			0.74	
07/25/23 11:00	0.6			1.5			0			0.43			0.2172			0.72	
07/25/23 12:00	0.6			1.5			0			0.5			0.25092			0.84	
07/25/23 13:00	0.6			1.5			0			0.51			0.25488			0.85	
07/25/23 14:00	0.6			1.5			0			0.54			0.26808			0.89	
07/25/23 15:00	0.6			1.4			0			0.51			0.25554			0.85	
07/25/23 16:00	0.7			1.5			0			0.56			0.27822			0.93	
07/25/23 17:00	0.5			1.5			1			0.65			0.3261			1.09	
07/25/23 18:00	0.5			1.5			1			0.67			0.33276			1.11	
07/25/23 19:00	0.2			1.5			2			0.77			0.38724			1.29	
07/25/23 20:00	0.2			1.5			1			0.72			0.36114			1.2	
07/25/23 21:00	0.6			1.5			1			0.65			0.32322			1.08	
07/25/23 22:00	0.8			1.5			1			0.63			0.31272			1.04	
07/25/23 23:00	0.7			1.5			0			0.53			0.26394			0.88	
07/26/23 0:00	0.6			1.5			0			0.55			0.2742			0.91	
07/26/23 1:00	0.6			1.5			0			0.51			0.2559			0.85	
07/26/23 2:00	0.6			1.6			0			0.52			0.25842			0.86	
07/26/23 3:00	0.7			1.5			0			0.52			0.26094			0.87	
07/26/23 4:00	0.6			1.5			0			0.52			0.26058			0.87	
07/26/23 5:00	0.6			1.5			0			0.54			0.27216			0.91	
07/26/23 6:00	0.6			1.5			0			0.54			0.26904			0.9	
07/26/23 7:00	0.7			1.5			0			0.5			0.25026			0.83	
07/26/23 8:00	0.7			1.5			0			0.5			0.24768			0.83	
07/26/23 9:00	0.6			1.5			0			0.53			0.26352			0.88	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/26/23 10:00	0.6			1.5			0			0.54			0.26802			0.89	
07/26/23 11:00	0.6			1.5			0			0.55			0.2733			0.91	
07/26/23 12:00	0.7			1.5			0			0.54			0.2709			0.9	
07/26/23 13:00	0.2			1.5			1			0.76			0.38034			1.27	
07/26/23 14:00	0.2			1.5			1			0.76			0.38154			1.27	
07/26/23 15:00	0.1			1.5			1			0.74			0.36942			1.23	
07/26/23 16:00	0.1			1.5			1			0.75			0.37398			1.25	
07/26/23 17:00	0.1			1.5			1			0.75			0.3747			1.25	
07/26/23 18:00	0.4			1.5			1			0.67			0.33564			1.12	
07/26/23 19:00	0.1			1.5			1			0.74			0.36774			1.23	
07/26/23 20:00	0.8			1.5			1			0.62			0.3111			1.04	
07/26/23 21:00	0.7			1.5			1			0.65			0.32424			1.08	
07/26/23 22:00	0.2			1.5			1			0.72			0.36222			1.21	
07/26/23 23:00	0.6			1.5			1			0.67			0.33312			1.11	
07/27/23 0:00	0.2			1.5			1			0.75			0.37656			1.26	
07/27/23 1:00	0.7			1.5			0			0.57			0.28368			0.95	
07/27/23 2:00	0.6			1.5			0			0.51			0.25404			0.85	
07/27/23 3:00	0.7			1.5			0			0.47			0.23316			0.78	
07/27/23 4:00	0.6			1.5			0			0.54			0.27198			0.91	
07/27/23 5:00	0.6			1.5			0			0.55			0.27672			0.92	
07/27/23 6:00	0.6			1.5			0			0.55			0.27462			0.92	
07/27/23 7:00	0.7			1.5			0			0.45			0.2247			0.75	
07/27/23 8:00	0.7			1.5			0			0.43			0.21672			0.72	
07/27/23 9:00	0.7			1.5			0			0.43			0.21618			0.72	
07/27/23 10:00	0.7			1.5			0			0.43			0.21618			0.72	
07/27/23 11:00	0.7			1.5			0			0.45			0.22332			0.74	
07/27/23 12:00	0.7			1.5			0			0.53			0.26436			0.88	
07/27/23 13:00	0.6			1.5			0			0.54			0.26766			0.89	
07/27/23 14:00	0.6			1.5			0			0.52			0.25926			0.86	
07/27/23 15:00	0.6			1.5			0			0.51			0.25434			0.85	
07/27/23 16:00	0.8			1.5			0			0.59			0.29478			0.98	
07/27/23 17:00	0.7			1.5			1			0.62			0.3108			1.04	
07/27/23 18:00	0.7			1.4			0			0.46			0.2289			0.76	
07/27/23 19:00	0.6			1.5			0			0.44			0.21786			0.73	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/27/23 20:00	0.6			1.5			0			0.44			0.22008			0.73	
07/27/23 21:00	0.7			1.5			0			0.43			0.21576			0.72	
07/27/23 22:00	0.7			1.5			0			0.5			0.24822			0.83	
07/27/23 23:00	0.7			1.5			0			0.52			0.26244			0.87	
07/28/23 0:00	0.7			1.5			0			0.49			0.24558			0.82	
07/28/23 1:00	0.7			1.5			0			0.51			0.25746			0.86	
07/28/23 2:00	0.6			1.4			0			0.5			0.24756			0.83	
07/28/23 3:00	0.7			1.5			0			0.49			0.24372			0.81	
07/28/23 4:00	0.7			1.5			0			0.48			0.24054			0.8	
07/28/23 5:00	0.6			1.5			0			0.51			0.2526			0.84	
07/28/23 6:00	0.6			1.5			0			0.5			0.24828			0.83	
07/28/23 7:00	0.7			1.5			0			0.45			0.2259			0.75	
07/28/23 8:00	0.7			1.5			0			0.43			0.21708			0.72	
07/28/23 9:00	0.7			1.5			0			0.43			0.21642			0.72	
07/28/23 10:00	0.7			1.5			0			0.43			0.21648			0.72	
07/28/23 11:00	0.7			1.5			0			0.43			0.21636			0.72	
07/28/23 12:00	0.6			1.5			0			0.44			0.21894			0.73	
07/28/23 13:00	0.6			1.5			0			0.52			0.25944			0.86	
07/28/23 14:00	0.6			1.5			0			0.44			0.2187			0.73	
07/28/23 15:00	0.7			1.5			0			0.5			0.24918			0.83	
07/28/23 16:00	0.8			1.5			1			0.62			0.30828			1.03	
07/28/23 17:00	0.7			1.5			1			0.62			0.30774			1.03	
07/28/23 18:00	0.8			1.5			1			0.61			0.30744			1.02	
07/28/23 19:00	0.8			1.5			1			0.61			0.30534			1.02	
07/28/23 20:00	0.7			1.4			0			0.45			0.2256			0.75	
07/28/23 21:00	0.7			1.5			0			0.46			0.22752			0.76	
07/28/23 22:00	0.7			1.5			0			0.49			0.24696			0.82	
07/28/23 23:00	0.7			1.5			0			0.52			0.26124			0.87	
07/29/23 0:00	0.6			1.5			0			0.52			0.26142			0.87	
07/29/23 1:00	0.7			1.5			0			0.45			0.22254			0.74	
07/29/23 2:00	0.7			1.6			0			0.44			0.2223			0.74	
07/29/23 3:00	0.7			1.5			0			0.45			0.22272			0.74	
07/29/23 4:00	0.7			1.5			0			0.43			0.21606			0.72	
07/29/23 5:00	0.7			1.5			0			0.43			0.21702			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/29/23 6:00	0.7			1.5			0			0.44			0.2205			0.74	
07/29/23 7:00	0.7			1.5			0			0.43			0.21642			0.72	
07/29/23 8:00	0.7			1.5			0			0.43			0.2169			0.72	
07/29/23 9:00	0.7			1.5			0			0.43			0.21612			0.72	
07/29/23 10:00	0.7			1.5			0			0.43			0.21612			0.72	
07/29/23 11:00	0.7			1.5			0			0.43			0.21582			0.72	
07/29/23 12:00	0.6			1.5			0			0.43			0.21654			0.72	
07/29/23 13:00	0.7			1.5			0			0.43			0.21678			0.72	
07/29/23 14:00	0.7			1.5			0			0.43			0.21672			0.72	
07/29/23 15:00	0.7			1.5			0			0.43			0.21648			0.72	
07/29/23 16:00	0.7			1.5			0			0.44			0.2181			0.73	
07/29/23 17:00	0.7			1.5			0			0.43			0.21624			0.72	
07/29/23 18:00	0.7			1.5			0			0.43			0.21648			0.72	
07/29/23 19:00	0.7			1.5			0			0.43			0.21642			0.72	
07/29/23 20:00	0.6			1.5			0			0.43			0.21582			0.72	
07/29/23 21:00	0.7			1.5			0			0.43			0.21576			0.72	
07/29/23 22:00	0.7			1.5			0			0.43			0.21612			0.72	
07/29/23 23:00	0.7			1.5			0			0.45			0.22386			0.75	
07/30/23 0:00	0.7			1.5			0			0.43			0.21612			0.72	
07/30/23 1:00	0.7			1.5			0			0.43			0.21618			0.72	
07/30/23 2:00	0.7			1.5			0			0.43			0.21612			0.72	
07/30/23 3:00	0.7			1.5			0			0.43			0.21606			0.72	
07/30/23 4:00	0.7			1.5			0			0.43			0.21642			0.72	
07/30/23 5:00	0.7			1.5			0			0.44			0.21966			0.73	
07/30/23 6:00	0.7			1.5			0			0.43			0.21624			0.72	
07/30/23 7:00	0.7			1.5			0			0.43			0.21678			0.72	
07/30/23 8:00	0.7			1.5			0			0.43			0.21708			0.72	
07/30/23 9:00	0.7			1.5			0			0.43			0.21636			0.72	
07/30/23 10:00	0.7			1.5			0			0.43			0.21642			0.72	
07/30/23 11:00	0.7			1.5			0			0.43			0.21624			0.72	
07/30/23 12:00	0.6			1.5			0			0.43			0.21666			0.72	
07/30/23 13:00	0.6			1.5			0			0.43			0.21672			0.72	
07/30/23 14:00	0.6			1.5			0			0.44			0.22062			0.74	
07/30/23 15:00	0.7			1.5			0			0.43			0.2166			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/30/23 16:00	0.7			1.5			0			0.43			0.2166			0.72	
07/30/23 17:00	0.7			1.5			0			0.45			0.22278			0.74	
07/30/23 18:00	0.6			1.5			0			0.44			0.22038			0.73	
07/30/23 19:00	0.7			1.5			0			0.43			0.21636			0.72	
07/30/23 20:00	0.7			1.5			0			0.43			0.21522			0.72	
07/30/23 21:00	0.7			1.5			0			0.43			0.21678			0.72	
07/30/23 22:00	0.7			1.5			0			0.43			0.21534			0.72	
07/30/23 23:00	0.7			1.5			0			0.43			0.21546			0.72	
07/31/23 0:00	0.7			1.5			0			0.45			0.22578			0.75	
07/31/23 1:00	0.7			1.5			0			0.43			0.21582			0.72	
07/31/23 2:00	0.7			1.4			1			0.44			0.21804			0.73	
07/31/23 3:00	0.7			1.5			0			0.43			0.21552			0.72	
07/31/23 4:00	0.7			1.5			0			0.44			0.21858			0.73	
07/31/23 5:00	0.7			1.5			0			0.46			0.22866			0.76	
07/31/23 6:00	0.7			1.5			0			0.51			0.25536			0.85	
07/31/23 7:00	0.7			1.5			0			0.44			0.22092			0.74	
07/31/23 8:00	0.7			1.5			0			0.43			0.21684			0.72	
07/31/23 9:00	0.7			1.5			0			0.43			0.2163			0.72	
07/31/23 10:00	0.7			1.5			0			0.45			0.22596			0.75	
07/31/23 11:00	0.6			1.5			0			0.55			0.27618			0.92	
07/31/23 12:00	0.6			1.5			0			0.55			0.27432			0.91	
07/31/23 13:00	0.5			1.5			1			0.72			0.3594			1.2	
07/31/23 14:00	0.3			1.5			1			0.71			0.35616			1.19	
07/31/23 15:00	0.4			1.5			1			0.69			0.34404			1.15	
07/31/23 16:00	0.4			1.5			1			0.68			0.33984			1.13	
07/31/23 17:00	0.6			1.5			1			0.64			0.31806			1.06	
07/31/23 18:00	0.7			1.5			1			0.62			0.30924			1.03	
07/31/23 19:00	0.7			1.5			1			0.63			0.3141			1.05	
07/31/23 20:00	0.8			1.5			1			0.62			0.30954			1.03	
07/31/23 21:00	0.9			1.5			1			0.58			0.28956			0.97	
07/31/23 22:00	0.7			1.4			0			0.49			0.2472			0.82	
07/31/23 23:00	0.6			1.5			0			0.53			0.26514			0.88	
08/01/23 0:00	0.7			1.5			0			0.49			0.24348			0.81	
08/01/23 1:00	0.7			1.5			0			0.46			0.23052			0.77	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/01/23 2:00	0.7			1.2			1			0.48			0.23904			0.8	
08/01/23 3:00	0.7			1.6			0			0.47			0.23568			0.79	
08/01/23 4:00	0.7			1.5			0			0.48			0.23766			0.79	
08/01/23 5:00	0.6			1.5			0			0.51			0.25422			0.85	
08/01/23 6:00	0.6			1.5			0			0.52			0.25992			0.87	
08/01/23 7:00	0.7			1.5			0			0.47			0.2349			0.78	
08/01/23 8:00	0.7			1.5			0			0.43			0.2154			0.72	
08/01/23 9:00	0.7			1.5			0			0.5			0.25062			0.84	
08/01/23 10:00	0.7			1.5			0			0.47			0.2355			0.79	
08/01/23 11:00	0.7			1.5			0			0.51			0.25452			0.85	
08/01/23 12:00	0.7			1.5			0			0.51			0.25554			0.85	
08/01/23 13:00	0.7			1.5			0			0.51			0.2559			0.85	
08/01/23 14:00	0.6			1.5			0			0.51			0.25704			0.86	
08/01/23 15:00	0.7			1.4			0			0.5			0.2511			0.84	
08/01/23 16:00	0.7			1.5			0			0.51			0.25608			0.85	
08/01/23 17:00	0.6			1.5			0			0.5			0.25128			0.84	
08/01/23 18:00	0.6			1.5			0			0.47			0.23634			0.79	
08/01/23 19:00	0.6			1.5			0			0.5			0.25014			0.83	
08/01/23 20:00	0.6			1.5			0			0.51			0.25422			0.85	
08/01/23 21:00	0.6			1.5			0			0.5			0.25248			0.84	
08/01/23 22:00	0.6			1.5			0			0.5			0.25062			0.84	
08/01/23 23:00	0.7			1.5			0			0.43			0.21672			0.72	
08/02/23 0:00	0.6			1.5			0			0.49			0.24732			0.82	
08/02/23 1:00	0.6			1.5			0			0.49			0.24726			0.82	
08/02/23 2:00	0.7			1.5			0			0.47			0.23532			0.78	
08/02/23 3:00	0.7			1.5			1			0.5			0.24972			0.83	
08/02/23 4:00	0.6			1.5			0			0.5			0.25248			0.84	
08/02/23 5:00	0.6			1.5			0			0.51			0.25428			0.85	
08/02/23 6:00	0.6			1.5			0			0.51			0.25374			0.85	
08/02/23 7:00	0.7			1.5			0			0.43			0.21714			0.72	
08/02/23 8:00	0.7			1.5			0			0.42			0.20898			0.7	
08/02/23 9:00	0.7			1.5			0			0.42			0.2085			0.7	
08/02/23 10:00	0.7			1.5			0			0.43			0.21312			0.71	
08/02/23 11:00	0.7			1.5			0			0.42			0.20796			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/02/23 12:00	0.6			1.5			0			0.42			0.20934			0.7	
08/02/23 13:00	0.6			1.4			0			0.48			0.23922			0.8	
08/02/23 14:00	0.6			1.5			0			0.42			0.21			0.7	
08/02/23 15:00	0.6			1.5			0			0.42			0.20964			0.7	
08/02/23 16:00	0.6			1.5			0			0.42			0.20922			0.7	
08/02/23 17:00	0.6			1.5			0			0.44			0.2193			0.73	
08/02/23 18:00	0.7			1.5			0			0.42			0.21018			0.7	
08/02/23 19:00	0.6			1.5			0			0.46			0.23202			0.77	
08/02/23 20:00	0.6			1.5			0			0.47			0.23502			0.78	
08/02/23 21:00	0.6			1.5			0			0.47			0.2346			0.78	
08/02/23 22:00	0.7			1.5			0			0.47			0.23694			0.79	
08/02/23 23:00	0.7			1.5			0			0.42			0.20814			0.69	
08/03/23 0:00	0.6			1.5			0			0.47			0.23436			0.78	
08/03/23 1:00	0.7			1.5			0			0.44			0.22206			0.74	
08/03/23 2:00	0.7			1.6			0			0.43			0.21516			0.72	
08/03/23 3:00	0.7			1.5			0			0.44			0.21936			0.73	
08/03/23 4:00	0.7			1.5			0			0.42			0.20832			0.69	
08/03/23 5:00	0.7			1.5			0			0.46			0.23088			0.77	
08/03/23 6:00	0.7			1.5			0			0.47			0.23706			0.79	
08/03/23 7:00	0.7			1.5			0			0.42			0.2082			0.69	
08/03/23 8:00	0.7			1.5			0			0.42			0.20868			0.7	
08/03/23 9:00	0.7			1.5			0			0.42			0.2082			0.69	
08/03/23 10:00	0.7			1.5			0			0.42			0.20814			0.69	
08/03/23 11:00	0.7			1.5			0			0.42			0.2082			0.69	
08/03/23 12:00	0.7			1.5			0			0.42			0.2088			0.7	
08/03/23 13:00	0.7			1.5			0			0.42			0.2088			0.7	
08/03/23 14:00	0.6			1.5			0			0.42			0.20868			0.7	
08/03/23 15:00	0.6			1.5			0			0.42			0.20856			0.7	
08/03/23 16:00	0.6			1.5			0			0.42			0.20802			0.69	
08/03/23 17:00	0.6			1.5			0			0.42			0.2079			0.69	
08/03/23 18:00	0.6			1.5			0			0.43			0.21288			0.71	
08/03/23 19:00	0.6			1.5			0			0.45			0.22374			0.75	
08/03/23 20:00	0.6			1.5			0			0.44			0.21972			0.73	
08/03/23 21:00	0.7			1.5			0			0.44			0.219			0.73	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/03/23 22:00	0.7			1.5			0			0.43			0.21558			0.72	
08/03/23 23:00	0.7			1.5			0			0.41			0.20736			0.69	
08/04/23 0:00	0.7			1.5			0			0.41			0.20748			0.69	
08/04/23 1:00	0.7			1.5			0			0.42			0.20784			0.69	
08/04/23 2:00	0.7			1.5			0			0.42			0.20784			0.69	
08/04/23 3:00	0.8			1.5			0			0.42			0.20784			0.69	
08/04/23 4:00	0.7			1.5			0			0.42			0.20772			0.69	
08/04/23 5:00	0.7			1.5			0			0.43			0.21366			0.71	
08/04/23 6:00	0.7			1.5			0			0.44			0.21756			0.73	
08/04/23 7:00	0.7			1.5			0			0.42			0.20826			0.69	
08/04/23 8:00	0.7			1.5			0			0.42			0.20868			0.7	
08/04/23 9:00	0.7			1.5			0			0.42			0.20808			0.69	
08/04/23 10:00	0.7			1.5			0			0.42			0.20802			0.69	
08/04/23 11:00	0.7			1.5			0			0.42			0.2082			0.69	
08/04/23 12:00	0.7			1.5			0			0.42			0.20868			0.7	
08/04/23 13:00	0.6			1.5			0			0.42			0.20874			0.7	
08/04/23 14:00	0.6			1.5			0			0.42			0.2088			0.7	
08/04/23 15:00	0.6			1.5			0			0.42			0.20856			0.7	
08/04/23 16:00	0.6			1.5			0			0.42			0.20814			0.69	
08/04/23 17:00	0.6			1.5			0			0.43			0.21252			0.71	
08/04/23 18:00	0.8			1.5			0			0.52			0.25878			0.86	
08/04/23 19:00	0.8			1.5			1			0.6			0.29856			1	
08/04/23 20:00	0.8			1.5			1			0.59			0.29706			0.99	
08/04/23 21:00	0.7			1.5			1			0.57			0.28542			0.95	
08/04/23 22:00	0.7			1.5			0			0.48			0.24126			0.8	
08/04/23 23:00	0.7			1.5			0			0.44			0.21996			0.73	
08/05/23 0:00	0.7			1.5			0			0.5			0.25026			0.83	
08/05/23 1:00	0.7			1.5			0			0.49			0.24696			0.82	
08/05/23 2:00	0.6			1.6			0			0.5			0.25104			0.84	
08/05/23 3:00	0.7			1.5			0			0.5			0.24942			0.83	
08/05/23 4:00	0.7			1.5			0			0.47			0.2343			0.78	
08/05/23 5:00	0.8			1.5			0			0.43			0.21342			0.71	
08/05/23 6:00	0.9			1.5			0			0.44			0.22068			0.74	
08/05/23 7:00	0.8			1.5			0			0.42			0.2079			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/05/23 8:00	0.8			1.5			0			0.42			0.20832			0.69	
08/05/23 9:00	0.7			1.5			0			0.42			0.20778			0.69	
08/05/23 10:00	0.7			1.5			0			0.41			0.20748			0.69	
08/05/23 11:00	0.7			1.5			0			0.41			0.20748			0.69	
08/05/23 12:00	0.7			1.5			0			0.42			0.20814			0.69	
08/05/23 13:00	0.6			1.5			0			0.42			0.20844			0.69	
08/05/23 14:00	0.7			1.5			0			0.45			0.22278			0.74	
08/05/23 15:00	0.6			1.5			0			0.46			0.2316			0.77	
08/05/23 16:00	0.6			1.5			0			0.42			0.20952			0.7	
08/05/23 17:00	0.7			1.5			0			0.47			0.23748			0.79	
08/05/23 18:00	0.6			1.5			1			0.6			0.30102			1	
08/05/23 19:00	0.6			1.5			1			0.61			0.3072			1.02	
08/05/23 20:00	0.7			1.5			1			0.6			0.2991			1	
08/05/23 21:00	0.8			1.5			0			0.56			0.28008			0.93	
08/05/23 22:00	0.7			1.5			0			0.47			0.23472			0.78	
08/05/23 23:00	0.7			1.5			0			0.45			0.22398			0.75	
08/06/23 0:00	0.7			1.5			0			0.46			0.22914			0.76	
08/06/23 1:00	0.7			1.5			0			0.44			0.21894			0.73	
08/06/23 2:00	0.7			1.6			0			0.44			0.21888			0.73	
08/06/23 3:00	0.9			1.5			0			0.42			0.20838			0.69	
08/06/23 4:00	1.1			1.5			0			0.42			0.21036			0.7	
08/06/23 5:00	1			1.5			0			0.45			0.22506			0.75	
08/06/23 6:00	1			1.4			0			0.44			0.22176			0.74	
08/06/23 7:00	1			1.5			0			0.42			0.20808			0.69	
08/06/23 8:00	1			1.5			0			0.46			0.23118			0.77	
08/06/23 9:00	0.9			1.5			0			0.41			0.20688			0.69	
08/06/23 10:00	0.7			1.5			0			0.41			0.20664			0.69	
08/06/23 11:00	0.7			1.5			0			0.41			0.20694			0.69	
08/06/23 12:00	0.8			1.5			0			0.45			0.22356			0.75	
08/06/23 13:00	0.6			1.5			0			0.49			0.24732			0.82	
08/06/23 14:00	0.6			1.5			0			0.52			0.25938			0.86	
08/06/23 15:00	0.6			1.5			0			0.51			0.2568			0.86	
08/06/23 16:00	0.6			1.5			0			0.49			0.24372			0.81	
08/06/23 17:00	0.8			1.5			0			0.5			0.2523			0.84	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/06/23 18:00	0.6			1.5			1			0.61			0.30594			1.02	
08/06/23 19:00	0.4			1.5			1			0.64			0.31818			1.06	
08/06/23 20:00	0.5			1.5			1			0.64			0.32076			1.07	
08/06/23 21:00	0.6			1.5			1			0.58			0.29076			0.97	
08/06/23 22:00	0.7			1.5			0			0.5			0.24942			0.83	
08/06/23 23:00	0.7			1.5			0			0.45			0.2253			0.75	
08/07/23 0:00	0.8			1.5			0			0.48			0.2388			0.8	
08/07/23 1:00	0.8			1.5			0			0.44			0.21954			0.73	
08/07/23 2:00	0.7			1.5			0			0.42			0.21102			0.7	
08/07/23 3:00	0.8			1.5			0			0.41			0.20706			0.69	
08/07/23 4:00	0.7			1.5			0			0.45			0.22566			0.75	
08/07/23 5:00	0.7			1.5			0			0.5			0.25164			0.84	
08/07/23 6:00	0.7			1.5			0			0.5			0.2505			0.84	
08/07/23 7:00	1			1.5			0			0.43			0.21414			0.71	
08/07/23 8:00	0.9			1.5			0			0.42			0.20892			0.7	
08/07/23 9:00	0	X		0	X		0	X		0.47			0.23316			0.78	
08/07/23 10:00	0.7			1.4			0			0.49			0.24384			0.81	
08/07/23 11:00	1.2			1.5			0			0.53			0.26298			0.88	
08/07/23 12:00	0.3			1.5			1			0.65			0.32628			1.09	
08/07/23 13:00	0.6			1.5			0			0.51			0.2556			0.85	
08/07/23 14:00	0.8			1.5			0			0.51			0.2541			0.85	
08/07/23 15:00	0.6			1.4			0			0.51			0.25596			0.85	
08/07/23 16:00	0.5			1.5			1			0.59			0.29286			0.98	
08/07/23 17:00	0.3			1.5			1			0.63			0.3174			1.06	
08/07/23 18:00	0.4			1.5			1			0.64			0.3207			1.07	
08/07/23 19:00	0.1			1.5			1			0.71			0.35424			1.18	
08/07/23 20:00	0.3			1.5			1			0.64			0.32034			1.07	
08/07/23 21:00	0.4			1.5			1			0.64			0.31926			1.06	
08/07/23 22:00	0.4			1.5			1			0.65			0.32544			1.08	
08/07/23 23:00	0.6			1.5			0			0.48			0.2409			0.8	
08/08/23 0:00	0.6			1.5			0			0.49			0.24378			0.81	
08/08/23 1:00	0.6			1.5			0			0.48			0.24144			0.8	
08/08/23 2:00	0.6			1.5			0			0.47			0.23532			0.78	
08/08/23 3:00	0.6			1.5			0			0.46			0.2304			0.77	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/08/23 4:00	0.6			1.5			0			0.44			0.22182			0.74	
08/08/23 5:00	0.6			1.5			0			0.49			0.24588			0.82	
08/08/23 6:00	0.6			1.5			0			0.5			0.24864			0.83	
08/08/23 7:00	0.6			1.5			0			0.42			0.20856			0.7	
08/08/23 8:00	0.7			1.5			0			0.42			0.20898			0.7	
08/08/23 9:00	0.6			1.5			0			0.42			0.20844			0.69	
08/08/23 10:00	0.6			1.5			0			0.42			0.20826			0.69	
08/08/23 11:00	0.6			1.5			0			0.42			0.20838			0.69	
08/08/23 12:00	0.5			1.5			0			0.42			0.20868			0.7	
08/08/23 13:00	0.6			1.5			0			0.42			0.2088			0.7	
08/08/23 14:00	0.6			1.5			0			0.43			0.2145			0.72	
08/08/23 15:00	0.5			1.5			0			0.42			0.21018			0.7	
08/08/23 16:00	0.5			1.5			0			0.42			0.20988			0.7	
08/08/23 17:00	0.5			1.5			0			0.43			0.21282			0.71	
08/08/23 18:00	0.5			1.5			0			0.45			0.22686			0.76	
08/08/23 19:00	0.5			1.5			0			0.52			0.26046			0.87	
08/08/23 20:00	0.5			1.5			0			0.46			0.2313			0.77	
08/08/23 21:00	0.6			1.5			0			0.44			0.22116			0.74	
08/08/23 22:00	0.6			1.5			0			0.44			0.22038			0.73	
08/08/23 23:00	0.6			1.5			0			0.42			0.2082			0.69	
08/09/23 0:00	0.6			1.5			0			0.42			0.20784			0.69	
08/09/23 1:00	0.6			1.5			0			0.42			0.2079			0.69	
08/09/23 2:00	0.6			1.5			0			0.42			0.20796			0.69	
08/09/23 3:00	0.7			1.5			0			0.42			0.20808			0.69	
08/09/23 4:00	0.6			1.5			0			0.42			0.20802			0.69	
08/09/23 5:00	0.6			1.5			0			0.42			0.2109			0.7	
08/09/23 6:00	0.6			1.5			0			0.42			0.21234			0.71	
08/09/23 7:00	0.6			1.5			0			0.42			0.20844			0.69	
08/09/23 8:00	0.6			1.5			0			0.42			0.20868			0.7	
08/09/23 9:00	0.6			1.5			0			0.42			0.20838			0.69	
08/09/23 10:00	0.6			1.5			0			0.42			0.20826			0.69	
08/09/23 11:00	0.6			1.5			0			0.42			0.20826			0.69	
08/09/23 12:00	0.6			1.5			0			0.42			0.20874			0.7	
08/09/23 13:00	0.6			1.5			0			0.44			0.22218			0.74	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/09/23 14:00	0.6			1.5			0			0.46			0.22914			0.76	
08/09/23 15:00	0.6			1.5			0			0.49			0.2433			0.81	
08/09/23 16:00	0.6			1.5			0			0.51			0.25356			0.85	
08/09/23 17:00	0.6			1.5			0			0.47			0.2328			0.78	
08/09/23 18:00	1			1.5			0			0.49			0.2442			0.81	
08/09/23 19:00	0.8			1.5			1			0.59			0.29646			0.99	
08/09/23 20:00	0.8			1.4			0			0.52			0.26028			0.87	
08/09/23 21:00	0.6			1.5			0			0.48			0.23892			0.8	
08/09/23 22:00	0.6			1.5			0			0.45			0.2238			0.75	
08/09/23 23:00	0.6			1.5			0			0.41			0.2073			0.69	
08/10/23 0:00	0.6			1.5			0			0.41			0.20736			0.69	
08/10/23 1:00	0.6			1.5			0			0.42			0.20754			0.69	
08/10/23 2:00	0.6			1.5			0			0.42			0.20754			0.69	
08/10/23 3:00	0.6			1.5			0			0.42			0.20766			0.69	
08/10/23 4:00	0.6			1.5			0			0.42			0.20778			0.69	
08/10/23 5:00	0.6			1.5			0			0.42			0.20904			0.7	
08/10/23 6:00	0.6			1.5			0			0.48			0.23892			0.8	
08/10/23 7:00	0.6			1.5			0			0.43			0.21516			0.72	
08/10/23 8:00	0.6			1.5			0			0.42			0.20898			0.7	
08/10/23 9:00	0.6			1.5			0			0.42			0.20856			0.7	
08/10/23 10:00	0.6			1.5			0			0.42			0.2085			0.7	
08/10/23 11:00	0.6			1.5			0			0.42			0.20844			0.69	
08/10/23 12:00	0.6			1.5			0			0.42			0.20838			0.69	
08/10/23 13:00	0.6			1.5			0			0.43			0.21648			0.72	
08/10/23 14:00	0.6			1.5			0			0.42			0.20868			0.7	
08/10/23 15:00	0.6			1.5			0			0.46			0.23004			0.77	
08/10/23 16:00	0.6			1.5			0			0.51			0.25446			0.85	
08/10/23 17:00	0.6			1.5			0			0.43			0.21414			0.71	
08/10/23 18:00	0.5			1.5			0			0.44			0.22032			0.73	
08/10/23 19:00	0.6			1.5			0			0.43			0.21276			0.71	
08/10/23 20:00	0.6			1.5			0			0.43			0.21624			0.72	
08/10/23 21:00	0.6			1.5			0			0.43			0.2142			0.71	
08/10/23 22:00	0.6			1.4			0			0.43			0.21552			0.72	
08/10/23 23:00	0.6			1.5			0			0.46			0.23004			0.77	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/11/23 0:00	0.9			1.5			1			0.59			0.29646			0.99	
08/11/23 1:00	0.7			1.5			0			0.53			0.26418			0.88	
08/11/23 2:00	0.5			1.5			0			0.5			0.25242			0.84	
08/11/23 3:00	0.6			1.5			0			0.49			0.24342			0.81	
08/11/23 4:00	0.6			1.5			0			0.49			0.243			0.81	
08/11/23 5:00	0.5			1.5			0			0.49			0.24486			0.82	
08/11/23 6:00	0.5			1.5			0			0.51			0.25488			0.85	
08/11/23 7:00	0.6			1.5			0			0.53			0.2652			0.88	
08/11/23 8:00	1.4			1.5			1			0.59			0.29304			0.98	
08/11/23 9:00	0.5			1.5			1			0.65			0.32634			1.09	
08/11/23 10:00	0.2			1.5			1			0.71			0.354			1.18	
08/11/23 11:00	0.1			1.5			2			0.76			0.37986			1.27	
08/11/23 12:00	0.6			1.4			1			0.58			0.28872			0.96	
08/11/23 13:00	0.6			1.5			0			0.42			0.21018			0.7	
08/11/23 14:00	0.5			1.5			0			0.42			0.21006			0.7	
08/11/23 15:00	0.6			1.5			0			0.42			0.20994			0.7	
08/11/23 16:00	0.5			1.5			0			0.42			0.2091			0.7	
08/11/23 17:00	0.5			1.5			0			0.43			0.21474			0.72	
08/11/23 18:00	0.7			1.5			1			0.55			0.27744			0.92	
08/11/23 19:00	0.7			1.5			1			0.59			0.29568			0.99	
08/11/23 20:00	0.8			1.5			1			0.59			0.29322			0.98	
08/11/23 21:00	0.9			1.5			1			0.59			0.2925			0.98	
08/11/23 22:00	0.9			1.5			1			0.58			0.29244			0.97	
08/11/23 23:00	1			1.5			1			0.58			0.2913			0.97	
08/12/23 0:00	0.7			1.4			0			0.46			0.22764			0.76	
08/12/23 1:00	0.7			1.5			0			0.42			0.20976			0.7	
08/12/23 2:00	0.6			1.5			0			0.42			0.20856			0.7	
08/12/23 3:00	0.7			1.5			0			0.42			0.2085			0.7	
08/12/23 4:00	0.6			1.5			0			0.42			0.2085			0.7	
08/12/23 5:00	0.6			1.5			0			0.42			0.2085			0.7	
08/12/23 6:00	0.6			1.5			0			0.42			0.20934			0.7	
08/12/23 7:00	0.6			1.5			0			0.42			0.20892			0.7	
08/12/23 8:00	0.6			1.5			0			0.42			0.20898			0.7	
08/12/23 9:00	0.6			1.5			0			0.42			0.2091			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/12/23 10:00	0.6			1.5			0			0.42			0.20862			0.7	
08/12/23 11:00	0.6			1.5			0			0.44			0.21798			0.73	
08/12/23 12:00	0.5			1.5			0			0.47			0.23742			0.79	
08/12/23 13:00	0.5			1.4			0			0.49			0.24324			0.81	
08/12/23 14:00	0.6			1.5			0			0.46			0.23118			0.77	
08/12/23 15:00	0.6			1.4			0			0.46			0.22878			0.76	
08/12/23 16:00	0.6			1.5			0			0.42			0.20994			0.7	
08/12/23 17:00	0.5			1.5			0			0.42			0.2097			0.7	
08/12/23 18:00	0.7			1.5			0			0.48			0.2397			0.8	
08/12/23 19:00	0.7			1.5			1			0.59			0.29706			0.99	
08/12/23 20:00	0.9			1.5			1			0.57			0.2862			0.95	
08/12/23 21:00	0.6			1.5			0			0.47			0.23658			0.79	
08/12/23 22:00	0.7			1.5			0			0.51			0.25272			0.84	
08/12/23 23:00	0.6			1.5			0			0.44			0.22182			0.74	
08/13/23 0:00	0.6			1.5			0			0.47			0.2343			0.78	
08/13/23 1:00	0.6			1.5			0			0.47			0.23382			0.78	
08/13/23 2:00	0.6			1.4			0			0.44			0.22218			0.74	
08/13/23 3:00	0.6			1.5			0			0.48			0.24096			0.8	
08/13/23 4:00	0.6			1.5			0			0.44			0.2208			0.74	
08/13/23 5:00	0.7			1.5			0			0.43			0.2166			0.72	
08/13/23 6:00	0.8			1.5			0			0.42			0.20862			0.7	
08/13/23 7:00	0.8			1.5			0			0.42			0.20766			0.69	
08/13/23 8:00	0.8			1.5			0			0.42			0.20772			0.69	
08/13/23 9:00	0.6			1.5			0			0.42			0.20772			0.69	
08/13/23 10:00	0.6			1.5			0			0.42			0.2076			0.69	
08/13/23 11:00	0.6			1.5			0			0.42			0.2082			0.69	
08/13/23 12:00	0.6			1.5			0			0.44			0.2205			0.74	
08/13/23 13:00	0.6			1.5			0			0.44			0.2181			0.73	
08/13/23 14:00	0.5			1.5			0			0.48			0.24114			0.8	
08/13/23 15:00	0.5			1.5			0			0.5			0.25008			0.83	
08/13/23 16:00	0.6			1.5			0			0.5			0.24918			0.83	
08/13/23 17:00	0.6			1.5			0			0.47			0.2349			0.78	
08/13/23 18:00	0.7			1.5			0			0.57			0.28296			0.94	
08/13/23 19:00	0.6			1.5			1			0.6			0.30018			1	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/13/23 20:00	0.7			1.5			1			0.6			0.2982			0.99	
08/13/23 21:00	0.7			1.5			1			0.59			0.29712			0.99	
08/13/23 22:00	0.7			1.5			0			0.52			0.25824			0.86	
08/13/23 23:00	0.6			1.5			0			0.48			0.2418			0.81	
08/14/23 0:00	0.6			1.5			0			0.5			0.2508			0.84	
08/14/23 1:00	0.6			1.5			0			0.5			0.25074			0.84	
08/14/23 2:00	0.6			1.5			0			0.49			0.24582			0.82	
08/14/23 3:00	0.6			1.5			0			0.48			0.24162			0.81	
08/14/23 4:00	0.6			1.5			0			0.47			0.23688			0.79	
08/14/23 5:00	0.7			1.5			0			0.5			0.25056			0.84	
08/14/23 6:00	0.7			1.5			0			0.51			0.25416			0.85	
08/14/23 7:00	0.8			1.5			0			0.44			0.22098			0.74	
08/14/23 8:00	0.8			1.5			0			0.46			0.23058			0.77	
08/14/23 9:00	0.6			1			0			0.5			0.252			0.84	
08/14/23 10:00	0.6			1.5			0			0.51			0.25362			0.85	
08/14/23 11:00	0.7			1.5			0			0.54			0.27066			0.9	
08/14/23 12:00	0.4			1.5			1			0.67			0.33348			1.11	
08/14/23 13:00	0.3			1.5			1			0.65			0.32742			1.09	
08/14/23 14:00	0.5			1.5			1			0.62			0.30918			1.03	
08/14/23 15:00	0.3			1.5			1			0.68			0.34026			1.13	
08/14/23 16:00	0.4			1.5			1			0.63			0.3135			1.05	
08/14/23 17:00	0.5			1.5			1			0.62			0.30756			1.03	
08/14/23 18:00	0.2			1.5			1			0.72			0.35796			1.19	
08/14/23 19:00	0.2			1.5			2			0.75			0.37494			1.25	
08/14/23 20:00	0.3			1.5			1			0.67			0.33738			1.12	
08/14/23 21:00	0.4			1.5			1			0.66			0.32922			1.1	
08/14/23 22:00	0.7			1.5			1			0.63			0.31398			1.05	
08/14/23 23:00	1			1.5			0			0.56			0.27978			0.93	
08/15/23 0:00	0.8			1.5			0			0.5			0.2487			0.83	
08/15/23 1:00	0.9			1.5			0			0.5			0.24846			0.83	
08/15/23 2:00	0.8			1.5			0			0.5			0.24864			0.83	
08/15/23 3:00	0.8			1.5			0			0.5			0.24774			0.83	
08/15/23 4:00	0.9			1.5			0			0.5			0.24828			0.83	
08/15/23 5:00	1			1.5			0			0.51			0.25434			0.85	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/15/23 6:00	0.9			1.5			0			0.51			0.25464			0.85	
08/15/23 7:00	1			1.5			0			0.45			0.2241			0.75	
08/15/23 8:00	0.9			1.5			0			0.49			0.2439			0.81	
08/15/23 9:00	0.7			1.5			0			0.5			0.24768			0.83	
08/15/23 10:00	0.6			1.5			0			0.47			0.23694			0.79	
08/15/23 11:00	0.6			1.5			0			0.47			0.23658			0.79	
08/15/23 12:00	0.6			1.5			0			0.49			0.24666			0.82	
08/15/23 13:00	0.6			1.5			0			0.51			0.25464			0.85	
08/15/23 14:00	0.4			1.6			1			0.69			0.3465			1.16	
08/15/23 15:00	0.1			1.5			2			0.75			0.37716			1.26	
08/15/23 16:00	0.1			1.5			2			0.75			0.37584			1.25	
08/15/23 17:00	0.1			1.5			2			0.74			0.372			1.24	
08/15/23 18:00	0.1			1.5			1			0.72			0.3597			1.2	
08/15/23 19:00	0.1			1.5			2			0.74			0.36768			1.23	
08/15/23 20:00	0.2			1.5			1			0.69			0.34584			1.15	
08/15/23 21:00	0.5			1.5			1			0.63			0.31302			1.04	
08/15/23 22:00	0.3			1.5			1			0.66			0.33162			1.11	
08/15/23 23:00	0.7			1.4			0			0.53			0.26436			0.88	
08/16/23 0:00	0.6			1.5			0			0.52			0.25782			0.86	
08/16/23 1:00	0.6			1.5			0			0.5			0.24852			0.83	
08/16/23 2:00	0.6			1.5			0			0.47			0.23274			0.78	
08/16/23 3:00	0.6			1.5			0			0.46			0.2322			0.77	
08/16/23 4:00	0.6			1.5			0			0.47			0.23688			0.79	
08/16/23 5:00	0.6			1.5			0			0.51			0.25464			0.85	
08/16/23 6:00	0.6			1.5			0			0.51			0.25584			0.85	
08/16/23 7:00	0.9			1.5			0			0.49			0.24426			0.81	
08/16/23 8:00	0.8			1.5			0			0.49			0.24348			0.81	
08/16/23 9:00	0.7			1.5			0			0.47			0.23544			0.78	
08/16/23 10:00	0.6			1.4			0			0.48			0.24			0.8	
08/16/23 11:00	0.6			1.4			0			0.5			0.24918			0.83	
08/16/23 12:00	0.6			1.5			0			0.51			0.25536			0.85	
08/16/23 13:00	0.7			1.5			0			0.52			0.25788			0.86	
08/16/23 14:00	0.2			1.6			2			0.73			0.36588			1.22	
08/16/23 15:00	0.1			1.5			2			0.74			0.3714			1.24	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/16/23 16:00	0.1			1.5			2			0.74			0.37056			1.24	
08/16/23 17:00	0.1			1.5			2			0.74			0.3675			1.23	
08/16/23 18:00	0.1			1.5			2			0.72			0.36018			1.2	
08/16/23 19:00	0.1			1.5			2			0.73			0.36624			1.22	
08/16/23 20:00	0.1			1.5			1			0.72			0.35958			1.2	
08/16/23 21:00	0.1			1.5			1			0.68			0.34152			1.14	
08/16/23 22:00	0.2			1.5			1			0.67			0.3366			1.12	
08/16/23 23:00	0.6			1.4			0			0.5			0.249			0.83	
08/17/23 0:00	0.6			1.4			0			0.49			0.24672			0.82	
08/17/23 1:00	0.6			1.5			0			0.5			0.25008			0.83	
08/17/23 2:00	0.6			1.5			0			0.51			0.25422			0.85	
08/17/23 3:00	0.6			1.5			0			0.51			0.2565			0.86	
08/17/23 4:00	0.6			1.5			0			0.51			0.25404			0.85	
08/17/23 5:00	0.6			1.5			0			0.51			0.25632			0.85	
08/17/23 6:00	0.6			1.5			0			0.51			0.25542			0.85	
08/17/23 7:00	0.6			1.5			0			0.44			0.2178			0.73	
08/17/23 8:00	0.7			1.5			0			0.42			0.20796			0.69	
08/17/23 9:00	0.6			1.5			0			0.42			0.2076			0.69	
08/17/23 10:00	0.6			1.5			0			0.42			0.2076			0.69	
08/17/23 11:00	0.6			1.5			0			0.42			0.2118			0.71	
08/17/23 12:00	0.6			1.4			0			0.48			0.23928			0.8	
08/17/23 13:00	0.5			1.5			0			0.5			0.25182			0.84	
08/17/23 14:00	0.5			1.5			0			0.46			0.22872			0.76	
08/17/23 15:00	0.5			1.4			0			0.43			0.2136			0.71	
08/17/23 16:00	0.5			1.5			0			0.45			0.22368			0.75	
08/17/23 17:00	0.6			1.5			0			0.47			0.23682			0.79	
08/17/23 18:00	0.4			1.5			1			0.61			0.30426			1.01	
08/17/23 19:00	0.5			1.5			1			0.61			0.30354			1.01	
08/17/23 20:00	0.6			1.5			1			0.6			0.29976			1	
08/17/23 21:00	0.7			1.4			0			0.45			0.22326			0.74	
08/17/23 22:00	0.6			1.5			0			0.48			0.23814			0.79	
08/17/23 23:00	0.6			1.5			0			0.47			0.23298			0.78	
08/18/23 0:00	0.6			1.5			0			0.44			0.21774			0.73	
08/18/23 1:00	0.6			1.5			0			0.41			0.20688			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/18/23 2:00	0.6			1.5			0			0.41			0.20688			0.69	
08/18/23 3:00	0.6			1.5			0			0.41			0.20694			0.69	
08/18/23 4:00	0.6			1.5			0			0.41			0.20688			0.69	
08/18/23 5:00	0.6			1.5			0			0.42			0.20754			0.69	
08/18/23 6:00	0.6			1.5			0			0.44			0.22074			0.74	
08/18/23 7:00	0.6			1.5			0			0.42			0.2094			0.7	
08/18/23 8:00	0.6			1.5			0			0.42			0.20814			0.69	
08/18/23 9:00	0.6			1.5			0			0.42			0.20772			0.69	
08/18/23 10:00	0.6			1.5			0			0.42			0.2076			0.69	
08/18/23 11:00	0.6			1.5			0			0.42			0.20754			0.69	
08/18/23 12:00	0.5			1.5			0			0.42			0.20802			0.69	
08/18/23 13:00	0.5			1.5			0			0.42			0.20952			0.7	
08/18/23 14:00	0.6			1.5			0			0.42			0.20898			0.7	
08/18/23 15:00	0.6			1.5			0			0.42			0.20808			0.69	
08/18/23 16:00	0.6			1.5			0			0.42			0.20946			0.7	
08/18/23 17:00	0.6			1.5			0			0.42			0.21018			0.7	
08/18/23 18:00	0.6			1.5			0			0.42			0.20778			0.69	
08/18/23 19:00	0.6			1.5			0			0.41			0.20694			0.69	
08/18/23 20:00	0.6			1.5			0			0.41			0.20628			0.69	
08/18/23 21:00	0.6			1.5			0			0.41			0.20652			0.69	
08/18/23 22:00	0.6			1.5			0			0.41			0.20652			0.69	
08/18/23 23:00	0.6			1.5			0			0.41			0.20682			0.69	
08/19/23 0:00	0.6			1.5			0			0.43			0.21402			0.71	
08/19/23 1:00	0.6			1.5			0			0.41			0.2067			0.69	
08/19/23 2:00	0.6			1.5			0			0.41			0.20652			0.69	
08/19/23 3:00	0.7			1.5			0			0.41			0.2064			0.69	
08/19/23 4:00	0.6			1.5			0			0.41			0.2064			0.69	
08/19/23 5:00	0.6			1.5			0			0.41			0.20634			0.69	
08/19/23 6:00	0.6			1.5			0			0.41			0.20634			0.69	
08/19/23 7:00	0.6			1.5			0			0.41			0.2064			0.69	
08/19/23 8:00	0.6			1.5			0			0.41			0.2067			0.69	
08/19/23 9:00	0.6			1.5			0			0.41			0.20628			0.69	
08/19/23 10:00	0.6			1.5			0			0.41			0.20604			0.69	
08/19/23 11:00	0.6			1.5			0			0.41			0.20688			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/19/23 12:00	0.6			1.5			0			0.42			0.2082			0.69	
08/19/23 13:00	0.6			1.5			0			0.42			0.20832			0.69	
08/19/23 14:00	0.6			1.5			0			0.42			0.20856			0.7	
08/19/23 15:00	0.6			1.5			0			0.42			0.2091			0.7	
08/19/23 16:00	0.6			1.5			0			0.42			0.20826			0.69	
08/19/23 17:00	0.6			1.5			0			0.41			0.20664			0.69	
08/19/23 18:00	0.6			1.5			0			0.41			0.207			0.69	
08/19/23 19:00	0.6			1.5			0			0.41			0.20706			0.69	
08/19/23 20:00	0.6			1.5			0			0.41			0.20652			0.69	
08/19/23 21:00	0.6			1.5			0			0.41			0.20616			0.69	
08/19/23 22:00	0.6			1.5			0			0.41			0.20718			0.69	
08/19/23 23:00	0.6			1.5			0			0.43			0.21276			0.71	
08/20/23 0:00	0.6			1.5			0			0.44			0.22158			0.74	
08/20/23 1:00	0.6			1.5			0			0.43			0.2145			0.72	
08/20/23 2:00	0.6			1.7			0			0.44			0.21876			0.73	
08/20/23 3:00	0.6			1.5			0			0.44			0.21918			0.73	
08/20/23 4:00	0.6			1.5			0			0.43			0.21432			0.71	
08/20/23 5:00	0.7			1.5			0			0.41			0.20658			0.69	
08/20/23 6:00	0.7			1.5			0			0.41			0.20664			0.69	
08/20/23 7:00	0.7			1.5			0			0.41			0.20652			0.69	
08/20/23 8:00	0.7			1.5			0			0.41			0.2064			0.69	
08/20/23 9:00	0.6			1.5			0			0.41			0.2067			0.69	
08/20/23 10:00	0.6			1.5			0			0.41			0.2067			0.69	
08/20/23 11:00	0.6			1.5			0			0.41			0.20646			0.69	
08/20/23 12:00	0.6			1.5			0			0.41			0.20658			0.69	
08/20/23 13:00	0.6			1.5			0			0.41			0.20682			0.69	
08/20/23 14:00	0.6			1.5			0			0.41			0.20688			0.69	
08/20/23 15:00	0.6			1.5			0			0.41			0.20694			0.69	
08/20/23 16:00	0.6			1.5			0			0.41			0.20712			0.69	
08/20/23 17:00	0.6			1.5			0			0.41			0.20664			0.69	
08/20/23 18:00	0.6			1.5			0			0.41			0.20634			0.69	
08/20/23 19:00	0.6			1.5			0			0.41			0.20622			0.69	
08/20/23 20:00	0.6			1.5			0			0.41			0.2064			0.69	
08/20/23 21:00	0.6			1.5			0			0.41			0.2064			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/20/23 22:00	0.6			1.5			0			0.41			0.20598			0.69	
08/20/23 23:00	0.7			1.5			0			0.41			0.20592			0.69	
08/21/23 0:00	0.6			1.5			0			0.41			0.20568			0.69	
08/21/23 1:00	0.7			1.5			0			0.41			0.20592			0.69	
08/21/23 2:00	0.7			1.5			0			0.41			0.20604			0.69	
08/21/23 3:00	0.7			1.5			0			0.41			0.20598			0.69	
08/21/23 4:00	0.6			1.5			0			0.42			0.21102			0.7	
08/21/23 5:00	0.6			1.5			0			0.51			0.25284			0.84	
08/21/23 6:00	0.6			1.5			0			0.52			0.258			0.86	
08/21/23 7:00	0.6			1.5			0			0.5			0.25146			0.84	
08/21/23 8:00	0.6			1.5			0			0.48			0.23916			0.8	
08/21/23 9:00	0.6			1.5			0			0.48			0.23994			0.8	
08/21/23 10:00	0.5			1.5			0			0.43			0.2142			0.71	
08/21/23 11:00	0.6			1.5			0			0.43			0.21492			0.72	
08/21/23 12:00	0.6			1.5			0			0.43			0.21606			0.72	
08/21/23 13:00	0.6			1.5			0			0.46			0.22794			0.76	
08/21/23 14:00	0.6			1.5			0			0.42			0.21168			0.71	
08/21/23 15:00	0.6			1.5			0			0.42			0.2109			0.7	
08/21/23 16:00	0.6			1.5			0			0.42			0.20988			0.7	
08/21/23 17:00	0.6			1.5			0			0.41			0.20676			0.69	
08/21/23 18:00	0.5			1.5			0			0.41			0.20718			0.69	
08/21/23 19:00	0.5			1.5			0			0.41			0.20706			0.69	
08/21/23 20:00	0.6			1.5			0			0.41			0.20706			0.69	
08/21/23 21:00	0.6			1.5			0			0.41			0.20712			0.69	
08/21/23 22:00	0.6			1.5			0			0.41			0.20712			0.69	
08/21/23 23:00	0.6			1.5			0			0.41			0.20688			0.69	
08/22/23 0:00	0.6			1.5			0			0.41			0.20658			0.69	
08/22/23 1:00	0.6			1.5			0			0.41			0.20682			0.69	
08/22/23 2:00	0.6			1.5			0			0.41			0.20712			0.69	
08/22/23 3:00	0.6			1.5			0			0.41			0.20664			0.69	
08/22/23 4:00	0.6			1.5			0			0.41			0.20658			0.69	
08/22/23 5:00	0.6			1.5			0			0.41			0.207			0.69	
08/22/23 6:00	0.6			1.5			0			0.42			0.21066			0.7	
08/22/23 7:00	0.7			1.5			0			0.41			0.20694			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/22/23 8:00	0.7			1.5			0			0.41			0.20748			0.69	
08/22/23 9:00	0.7			1.5			0			0.41			0.2073			0.69	
08/22/23 10:00	0.7			1.5			0			0.42			0.20754			0.69	
08/22/23 11:00	0.6			1.5			0			0.41			0.20748			0.69	
08/22/23 12:00	0.6			1.5			0			0.42			0.20778			0.69	
08/22/23 13:00	0.6			1.5			0			0.42			0.20784			0.69	
08/22/23 14:00	0.6			1.5			0			0.42			0.2079			0.69	
08/22/23 15:00	0.6			1.5			0			0.42			0.2076			0.69	
08/22/23 16:00	0.6			1.5			0			0.41			0.20724			0.69	
08/22/23 17:00	0.6			1.5			0			0.42			0.21132			0.7	
08/22/23 18:00	0.6			1.5			0			0.44			0.21966			0.73	
08/22/23 19:00	0.6			1.5			0			0.49			0.246			0.82	
08/22/23 20:00	0.6			1.5			0			0.43			0.21696			0.72	
08/22/23 21:00	0.6			1.5			0			0.46			0.231			0.77	
08/22/23 22:00	0.7			1.4			0			0.44			0.2214			0.74	
08/22/23 23:00	0.7			1.5			0			0.42			0.21228			0.71	
08/23/23 0:00	0.7			1.5			0			0.41			0.20628			0.69	
08/23/23 1:00	0.7			1.5			0			0.41			0.20628			0.69	
08/23/23 2:00	0.7			1.5			0			0.41			0.20622			0.69	
08/23/23 3:00	0.7			1.5			0			0.41			0.20646			0.69	
08/23/23 4:00	0.7			1.5			0			0.41			0.20652			0.69	
08/23/23 5:00	0.7			1.5			0			0.43			0.21594			0.72	
08/23/23 6:00	0.7			1.5			0			0.46			0.2283			0.76	
08/23/23 7:00	0.9			1.5			0			0.42			0.2097			0.7	
08/23/23 8:00	0.8			1.5			0			0.41			0.20748			0.69	
08/23/23 9:00	0.7			1.5			0			0.41			0.20688			0.69	
08/23/23 10:00	0.6			1.5			0			0.41			0.20646			0.69	
08/23/23 11:00	0.6			1.5			0			0.41			0.20658			0.69	
08/23/23 12:00	0.6			1.5			0			0.42			0.2076			0.69	
08/23/23 13:00	0.6			1.5			0			0.42			0.20766			0.69	
08/23/23 14:00	0.6			1.5			0			0.46			0.22764			0.76	
08/23/23 15:00	0.6			1.5			0			0.52			0.25794			0.86	
08/23/23 16:00	0.6			1.5			0			0.51			0.25722			0.86	
08/23/23 17:00	0.7			1.5			0			0.52			0.258			0.86	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/23/23 18:00	0.4			1.5			1			0.66			0.33			1.1	
08/23/23 19:00	0.3			1.5			1			0.69			0.34656			1.16	
08/23/23 20:00	0.8			1.5			1			0.59			0.29436			0.98	
08/23/23 21:00	1.1			1.5			1			0.56			0.27846			0.93	
08/23/23 22:00	0.7			1.5			0			0.51			0.25356			0.85	
08/23/23 23:00	0.6			1.5			0			0.47			0.23712			0.79	
08/24/23 0:00	0.7			1.5			0			0.47			0.2355			0.79	
08/24/23 1:00	0.7			1.5			0			0.41			0.20694			0.69	
08/24/23 2:00	0.7			1.5			0			0.41			0.20586			0.69	
08/24/23 3:00	0.7			1.5			0			0.41			0.20592			0.69	
08/24/23 4:00	0.6			1.5			0			0.44			0.22194			0.74	
08/24/23 5:00	0.8			1.5			0			0.47			0.23694			0.79	
08/24/23 6:00	0.8			1.5			0			0.51			0.25368			0.85	
08/24/23 7:00	0.9			1.5			0			0.44			0.21996			0.73	
08/24/23 8:00	0.9			1.5			0			0.41			0.20706			0.69	
08/24/23 9:00	0.7			1.5			0			0.41			0.2067			0.69	
08/24/23 10:00	0.7			1.5			0			0.41			0.2064			0.69	
08/24/23 11:00	0.6			1.5			0			0.41			0.20676			0.69	
08/24/23 12:00	0.6			1.5			0			0.42			0.20772			0.69	
08/24/23 13:00	0.6			1.5			0			0.42			0.20766			0.69	
08/24/23 14:00	0.6			1.5			0			0.41			0.20718			0.69	
08/24/23 15:00	0.6			1.5			0			0.41			0.207			0.69	
08/24/23 16:00	0.6			1.5			0			0.41			0.20694			0.69	
08/24/23 17:00	0.6			1.5			0			0.41			0.20664			0.69	
08/24/23 18:00	0.6			1.5			0			0.43			0.21534			0.72	
08/24/23 19:00	0.6			1.4			0			0.42			0.21234			0.71	
08/24/23 20:00	0.6			1.5			0			0.41			0.20718			0.69	
08/24/23 21:00	0.6			1.4			0			0.44			0.22038			0.73	
08/24/23 22:00	0.6			1.5			0			0.45			0.22356			0.75	
08/24/23 23:00	0.6			1.5			0			0.42			0.20838			0.69	
08/25/23 0:00	0.6			1.4			0			0.44			0.22248			0.74	
08/25/23 1:00	0.6			1.5			0			0.42			0.21006			0.7	
08/25/23 2:00	0.6			1.6			0			0.41			0.20718			0.69	
08/25/23 3:00	0.7			1.5			0			0.41			0.2067			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/25/23 4:00	0.6			1.5			0			0.43			0.213			0.71	
08/25/23 5:00	0.6			1.5			0			0.5			0.25014			0.83	
08/25/23 6:00	0.6			1.5			0			0.49			0.24252			0.81	
08/25/23 7:00	0.7			1.5			0			0.42			0.20868			0.7	
08/25/23 8:00	0.7			1.5			0			0.42			0.2076			0.69	
08/25/23 9:00	0.7			1.5			0			0.41			0.2073			0.69	
08/25/23 10:00	0.6			1.5			0			0.41			0.20724			0.69	
08/25/23 11:00	0.6			1.5			0			0.41			0.20742			0.69	
08/25/23 12:00	0.6			1.5			0			0.42			0.20796			0.69	
08/25/23 13:00	0.6			1.5			0			0.42			0.20802			0.69	
08/25/23 14:00	0.6			1.5			0			0.41			0.20736			0.69	
08/25/23 15:00	0.6			1.5			0			0.41			0.20736			0.69	
08/25/23 16:00	0.6			1.5			0			0.41			0.20736			0.69	
08/25/23 17:00	0.6			1.5			0			0.41			0.20712			0.69	
08/25/23 18:00	0.6			1.5			0			0.41			0.20742			0.69	
08/25/23 19:00	0.6			1.5			0			0.41			0.20742			0.69	
08/25/23 20:00	0.6			1.5			0			0.41			0.20718			0.69	
08/25/23 21:00	0.6			1.5			0			0.42			0.20808			0.69	
08/25/23 22:00	0.6			1.5			0			0.41			0.20718			0.69	
08/25/23 23:00	0.6			1.5			0			0.41			0.20706			0.69	
08/26/23 0:00	0.6			1.5			0			0.47			0.23562			0.79	
08/26/23 1:00	0.6			1.5			0			0.48			0.23778			0.79	
08/26/23 2:00	0.6			1.6			0			0.43			0.21714			0.72	
08/26/23 3:00	0.6			1.5			0			0.45			0.22302			0.74	
08/26/23 4:00	0.6			1.5			0			0.44			0.2211			0.74	
08/26/23 5:00	0.6			1.5			0			0.47			0.23526			0.78	
08/26/23 6:00	0.7			1.5			0			0.48			0.23796			0.79	
08/26/23 7:00	0.7			1.5			0			0.42			0.20808			0.69	
08/26/23 8:00	0.7			1.5			0			0.42			0.20826			0.69	
08/26/23 9:00	0.7			1.5			0			0.42			0.20796			0.69	
08/26/23 10:00	0.6			1.5			0			0.42			0.20778			0.69	
08/26/23 11:00	0.6			1.5			0			0.42			0.20778			0.69	
08/26/23 12:00	0.6			1.5			0			0.42			0.20808			0.69	
08/26/23 13:00	0.6			1.5			0			0.42			0.20814			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/26/23 14:00	0.6			1.5			0			0.41			0.2073			0.69	
08/26/23 15:00	0.6			1.5			0			0.41			0.20724			0.69	
08/26/23 16:00	0.6			1.5			0			0.41			0.20718			0.69	
08/26/23 17:00	0.6			1.5			0			0.43			0.2157			0.72	
08/26/23 18:00	0.6			1.5			0			0.43			0.21642			0.72	
08/26/23 19:00	0.6			1.5			0			0.42			0.20796			0.69	
08/26/23 20:00	0.6			1.5			0			0.42			0.21156			0.71	
08/26/23 21:00	0.6			1.5			0			0.42			0.21168			0.71	
08/26/23 22:00	0.6			1.5			0			0.43			0.21468			0.72	
08/26/23 23:00	0.6			1.5			0			0.43			0.2148			0.72	
08/27/23 0:00	0.6			1.5			0			0.44			0.22128			0.74	
08/27/23 1:00	0.6			1.5			0			0.43			0.21306			0.71	
08/27/23 2:00	0.6			1.7			0			0.42			0.20802			0.69	
08/27/23 3:00	0.7			1.5			0			0.42			0.21162			0.71	
08/27/23 4:00	0.7			1.5			0			0.42			0.20874			0.7	
08/27/23 5:00	0.6			1.5			0			0.45			0.22638			0.75	
08/27/23 6:00	0.6			1.5			0			0.47			0.23484			0.78	
08/27/23 7:00	0.7			1.5			0			0.42			0.20802			0.69	
08/27/23 8:00	0.7			1.5			0			0.42			0.20778			0.69	
08/27/23 9:00	0.7			1.5			0			0.41			0.20718			0.69	
08/27/23 10:00	0.6			1.5			0			0.41			0.20748			0.69	
08/27/23 11:00	0.6			1.5			0			0.41			0.20718			0.69	
08/27/23 12:00	0.6			1.5			0			0.42			0.20844			0.69	
08/27/23 13:00	0.6			1.5			0			0.42			0.20886			0.7	
08/27/23 14:00	0.6			1.5			0			0.42			0.2079			0.69	
08/27/23 15:00	0.6			1.5			0			0.42			0.21204			0.71	
08/27/23 16:00	0.6			1.5			0			0.43			0.2142			0.71	
08/27/23 17:00	0.6			1.5			0			0.45			0.22674			0.76	
08/27/23 18:00	0.6			1.5			0			0.42			0.20814			0.69	
08/27/23 19:00	0.5			1.5			0			0.46			0.22818			0.76	
08/27/23 20:00	0.5			1.5			0			0.51			0.25434			0.85	
08/27/23 21:00	0.6			1.5			0			0.51			0.25434			0.85	
08/27/23 22:00	0.6			1.5			0			0.5			0.25164			0.84	
08/27/23 23:00	0.7			1.5			0			0.46			0.22908			0.76	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/28/23 0:00	0.7			1.4			0			0.43			0.21588			0.72	
08/28/23 1:00	0.7			1.5			0			0.41			0.20664			0.69	
08/28/23 2:00	0.6			1.5			0			0.41			0.20664			0.69	
08/28/23 3:00	0.7			1.5			0			0.41			0.20652			0.69	
08/28/23 4:00	0.7			1.5			0			0.42			0.2076			0.69	
08/28/23 5:00	0.6			1.5			0			0.49			0.24384			0.81	
08/28/23 6:00	0.6			1.5			0			0.53			0.26436			0.88	
08/28/23 7:00	0.7			1.5			0			0.45			0.22674			0.76	
08/28/23 8:00	0.8			1.5			0			0.42			0.20766			0.69	
08/28/23 9:00	0.8			1.5			0			0.41			0.207			0.69	
08/28/23 10:00	0.7			1.5			0			0.41			0.20694			0.69	
08/28/23 11:00	0.6			1.5			0			0.42			0.20784			0.69	
08/28/23 12:00	0.6			1.5			0			0.42			0.21204			0.71	
08/28/23 13:00	0.6			1.4			0			0.46			0.2313			0.77	
08/28/23 14:00	0.5			1.5			0			0.5			0.2505			0.84	
08/28/23 15:00	0.5			1.5			0			0.5			0.25242			0.84	
08/28/23 16:00	0.5			1.5			0			0.49			0.24288			0.81	
08/28/23 17:00	0.5			1.5			0			0.42			0.20796			0.69	
08/28/23 18:00	0.5			1.5			0			0.45			0.22488			0.75	
08/28/23 19:00	0.8			1.5			1			0.59			0.29544			0.98	
08/28/23 20:00	0.7			1.4			0			0.51			0.25308			0.84	
08/28/23 21:00	0.6			1.5			0			0.44			0.21948			0.73	
08/28/23 22:00	0.7			1.4			0			0.44			0.2223			0.74	
08/28/23 23:00	0.6			1.5			0			0.42			0.21186			0.71	
08/29/23 0:00	0.6			1.5			0			0.45			0.22254			0.74	
08/29/23 1:00	0.6			1.5			0			0.48			0.24144			0.8	
08/29/23 2:00	0.6			1.5			0			0.47			0.23472			0.78	
08/29/23 3:00	0.7			1.5			0			0.46			0.22944			0.76	
08/29/23 4:00	0.6			1.5			0			0.46			0.23148			0.77	
08/29/23 5:00	0.6			1.5			0			0.5			0.24822			0.83	
08/29/23 6:00	0.6			1.5			0			0.49			0.24732			0.82	
08/29/23 7:00	1.9			1.5			1			0.55			0.27378			0.91	
08/29/23 8:00	0.5			1.5			1			0.68			0.33906			1.13	
08/29/23 9:00	0.1			1.5			1			0.72			0.35946			1.2	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/29/23 10:00	0.1			1.5			1			0.72			0.35982			1.2	
08/29/23 11:00	0.1			1.5			1			0.72			0.36114			1.2	
08/29/23 12:00	0.1			1.5			1			0.73			0.36324			1.21	
08/29/23 13:00	0.1			1.5			2			0.73			0.3648			1.22	
08/29/23 14:00	0.1			1.5			2			0.73			0.36552			1.22	
08/29/23 15:00	0.1			1.5			2			0.73			0.3657			1.22	
08/29/23 16:00	0.1			1.5			2			0.73			0.36654			1.22	
08/29/23 17:00	0.9			1.4			0			0.54			0.27006			0.9	
08/29/23 18:00	0.7			1.5			1			0.59			0.29526			0.98	
08/29/23 19:00	0.8			1.4			0			0.52			0.25782			0.86	
08/29/23 20:00	0.7			1.5			0			0.41			0.20628			0.69	
08/29/23 21:00	0.7			1.5			0			0.41			0.20592			0.69	
08/29/23 22:00	0.7			1.5			0			0.41			0.20622			0.69	
08/29/23 23:00	0.7			1.5			0			0.41			0.20604			0.69	
08/30/23 0:00	0.9			1.5			0			0.41			0.20586			0.69	
08/30/23 1:00	1			1.5			0			0.41			0.20562			0.69	
08/30/23 2:00	1			1.5			0			0.41			0.20586			0.69	
08/30/23 3:00	1.1			1.5			0			0.41			0.20568			0.69	
08/30/23 4:00	1			1.5			0			0.41			0.20556			0.69	
08/30/23 5:00	1			1.5			0			0.41			0.20604			0.69	
08/30/23 6:00	1			1.5			0			0.42			0.21084			0.7	
08/30/23 7:00	0.9			1.5			0			0.44			0.222			0.74	
08/30/23 8:00	1			1.5			0			0.46			0.22866			0.76	
08/30/23 9:00	0.3			1.5			1			0.72			0.3606			1.2	
08/30/23 10:00	0.1			1.5			2			0.72			0.36186			1.21	
08/30/23 11:00	0.1			1.5			2			0.73			0.36342			1.21	
08/30/23 12:00	0.1			1.5			1			0.71			0.3552			1.18	
08/30/23 13:00	0.7			1.5			1			0.59			0.29508			0.98	
08/30/23 14:00	0.7			1.4			0			0.44			0.21876			0.73	
08/30/23 15:00	0.6			1.5			0			0.41			0.20586			0.69	
08/30/23 16:00	0.7			1.5			0			0.41			0.2058			0.69	
08/30/23 17:00	0.7			1.5			0			0.41			0.2058			0.69	
08/30/23 18:00	0.7			1.5			0			0.44			0.21756			0.73	
08/30/23 19:00	0.6			1.5			0			0.41			0.20658			0.69	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/30/23 20:00	0.6			1.5			0			0.41			0.20574			0.69	
08/30/23 21:00	0.7			1.5			0			0.41			0.20532			0.68	
08/30/23 22:00	0.8			1.5			0			0.41			0.20544			0.68	
08/30/23 23:00	0.8			1.5			0			0.41			0.2052			0.68	
08/31/23 0:00	0.8			1.5			0			0.42			0.20988			0.7	
08/31/23 1:00	0.8			1.5			0			0.41			0.20574			0.69	
08/31/23 2:00	0.7			1.6			0			0.41			0.20586			0.69	
08/31/23 3:00	0.7			1.5			0			0.41			0.2055			0.69	
08/31/23 4:00	0.7			1.5			0			0.42			0.21072			0.7	
08/31/23 5:00	0.7			1.5			0			0.47			0.23334			0.78	
08/31/23 6:00	0.7			1.5			0			0.48			0.23772			0.79	
08/31/23 7:00	0.7			1.5			0			0.42			0.20994			0.7	
08/31/23 8:00	0.3			1.6			2			0.69			0.34542			1.15	
08/31/23 9:00	0.1			1.5			2			0.73			0.3669			1.22	
08/31/23 10:00	0.1			1.5			2			0.73			0.36582			1.22	
08/31/23 11:00	0.1			1.5			2			0.73			0.366			1.22	
08/31/23 12:00	0.1			1.5			2			0.73			0.3669			1.22	
08/31/23 13:00	0.1			1.5			2			0.74			0.36786			1.23	
08/31/23 14:00	0.1			1.5			2			0.74			0.36852			1.23	
08/31/23 15:00	0.1			1.5			2			0.74			0.36822			1.23	
08/31/23 16:00	0.1			1.5			2			0.73			0.36708			1.22	
08/31/23 17:00	0.7			1.5			1			0.59			0.29346			0.98	
08/31/23 18:00	0.6			1.4			0			0.42			0.20802			0.69	
08/31/23 19:00	0.6			1.5			0			0.41			0.20598			0.69	
08/31/23 20:00	0.7			1.5			0			0.41			0.2055			0.69	
08/31/23 21:00	0.6			1.5			0			0.41			0.20592			0.69	
08/31/23 22:00	0.6			1.5			0			0.43			0.21294			0.71	
08/31/23 23:00	0.6			1.5			0			0.41			0.2061			0.69	
09/01/23 0:00	0.6			1.5			0			0.42			0.2091			0.7	
09/01/23 1:00	0.6			1.5			0			0.42			0.20892			0.7	
09/01/23 2:00	0.6			1.5			0			0.42			0.20886			0.7	
09/01/23 3:00	0.6			1.5			0			0.42			0.20898			0.7	
09/01/23 4:00	0.6			1.5			0			0.42			0.20898			0.7	
09/01/23 5:00	0.6			1.5			0			0.43			0.21288			0.71	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/01/23 6:00	0.6			1.5			0			0.45			0.22386			0.75	
09/01/23 7:00	0.6			1.5			0			0.46			0.22956			0.77	
09/01/23 8:00	0.6			1.5			0			0.42			0.2091			0.7	
09/01/23 9:00	0.6			1.5			0			0.42			0.2097			0.7	
09/01/23 10:00	0.6			1.5			1			0.44			0.21954			0.73	
09/01/23 11:00	0.6			1.5			0			0.42			0.20928			0.7	
09/01/23 12:00	0.6			1.5			0			0.42			0.2094			0.7	
09/01/23 13:00	0.6			1.5			0			0.42			0.20958			0.7	
09/01/23 14:00	0.6			1.5			0			0.42			0.21156			0.71	
09/01/23 15:00	0.6			1.5			0			0.46			0.22836			0.76	
09/01/23 16:00	0.6			1.5			0			0.42			0.20916			0.7	
09/01/23 17:00	0.6			1.5			0			0.42			0.20892			0.7	
09/01/23 18:00	0.6			1.5			0			0.42			0.20916			0.7	
09/01/23 19:00	0.6			1.5			0			0.42			0.2091			0.7	
09/01/23 20:00	0.6			1.5			0			0.42			0.20892			0.7	
09/01/23 21:00	0.6			1.5			0			0.42			0.20934			0.7	
09/01/23 22:00	0.6			1.5			0			0.45			0.22374			0.75	
09/01/23 23:00	0.6			1.5			0			0.44			0.21846			0.73	
09/02/23 0:00	0.6			1.5			0			0.44			0.21882			0.73	
09/02/23 1:00	0.6			1.5			0			0.42			0.21162			0.71	
09/02/23 2:00	0.6			1.6			0			0.42			0.21114			0.7	
09/02/23 3:00	0.7			1.5			0			0.43			0.21282			0.71	
09/02/23 4:00	0.6			1.5			0			0.42			0.21066			0.7	
09/02/23 5:00	0.6			1.5			0			0.44			0.22158			0.74	
09/02/23 6:00	0.7			1.5			0			0.42			0.20982			0.7	
09/02/23 7:00	0.7			1.5			0			0.42			0.20988			0.7	
09/02/23 8:00	0.7			1.5			0			0.42			0.20946			0.7	
09/02/23 9:00	0.7			1.5			0			0.43			0.21258			0.71	
09/02/23 10:00	0.6			1.5			0			0.45			0.22458			0.75	
09/02/23 11:00	0.6			1.5			0			0.49			0.2442			0.81	
09/02/23 12:00	0.6			1.5			0			0.43			0.21336			0.71	
09/02/23 13:00	0.6			1.5			0			0.44			0.22242			0.74	
09/02/23 14:00	0.6			1.5			0			0.45			0.22494			0.75	
09/02/23 15:00	0.6			1.5			0			0.51			0.25464			0.85	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/02/23 16:00	0.6			1.5			0			0.42			0.2106			0.7	
09/02/23 17:00	0.6			1.5			0			0.43			0.21492			0.72	
09/02/23 18:00	0.6			1.5			0			0.43			0.21624			0.72	
09/02/23 19:00	0.5			1.5			0			0.42			0.21162			0.71	
09/02/23 20:00	0.6			1.5			0			0.42			0.20976			0.7	
09/02/23 21:00	0.6			1.5			0			0.42			0.2124			0.71	
09/02/23 22:00	0.7			1.5			0			0.45			0.22302			0.74	
09/02/23 23:00	0.7			1.5			0			0.42			0.20952			0.7	
09/03/23 0:00	0.6			1.5			0			0.46			0.23004			0.77	
09/03/23 1:00	0.9			1.5			0			0.43			0.21498			0.72	
09/03/23 2:00	0.7			1.5			0			0.38			0.18912			0.63	
09/03/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X
09/03/23 11:00	0.5			1.9			2			0.37			0.18486			0.62	
09/03/23 12:00	0.5			1.3			1			0.42			0.21024			0.7	
09/03/23 13:00	0.5			1.4			0			0.42			0.21018			0.7	
09/03/23 14:00	0.5			1.5			0			0.42			0.20994			0.7	
09/03/23 15:00	0.6			1.5			0			0.42			0.2097			0.7	
09/03/23 16:00	0.6			1.5			0			0.42			0.20982			0.7	
09/03/23 17:00	0.6			1.5			0			0.42			0.20964			0.7	
09/03/23 18:00	0.6			1.5			0			0.42			0.20964			0.7	
09/03/23 19:00	0.5			1.5			0			0.42			0.20982			0.7	
09/03/23 20:00	0.5			1.5			0			0.42			0.20994			0.7	
09/03/23 21:00	0.5			1.5			0			0.44			0.2178			0.73	
09/03/23 22:00	0.5			1.5			0			0.42			0.2097			0.7	
09/03/23 23:00	0.6			1.5			0			0.42			0.20934			0.7	
09/04/23 0:00	0.6			1.5			0			0.42			0.20934			0.7	
09/04/23 1:00	0.6			1.5			0			0.42			0.20952			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/04/23 2:00	0.6			1.5			0			0.42			0.20976			0.7	
09/04/23 3:00	0.7			1.5			0			0.42			0.2097			0.7	
09/04/23 4:00	0.7			1.5			0			0.42			0.21			0.7	
09/04/23 5:00	0.7			1.5			1			0.42			0.20982			0.7	
09/04/23 6:00	0.7			1.5			1			0.42			0.20994			0.7	
09/04/23 7:00	0.6			1.5			0			0.42			0.2103			0.7	
09/04/23 8:00	0.6			1.5			0			0.42			0.21042			0.7	
09/04/23 9:00	0.6			1.5			0			0.42			0.21042			0.7	
09/04/23 10:00	0.6			1.5			0			0.42			0.21042			0.7	
09/04/23 11:00	0.6			1.5			0			0.42			0.21036			0.7	
09/04/23 12:00	0.5			1.5			0			0.42			0.21096			0.7	
09/04/23 13:00	0.6			1.5			0			0.42			0.21096			0.7	
09/04/23 14:00	0.5			1.5			0			0.42			0.20994			0.7	
09/04/23 15:00	0.6			1.5			0			0.42			0.20976			0.7	
09/04/23 16:00	0.6			1.5			0			0.42			0.2097			0.7	
09/04/23 17:00	0.6			1.5			0			0.43			0.2148			0.72	
09/04/23 18:00	0.6			1.5			0			0.47			0.23436			0.78	
09/04/23 19:00	0.7			1.5			1			0.54			0.26754			0.89	
09/04/23 20:00	0.8			1.5			1			0.56			0.2817			0.94	
09/04/23 21:00	0.5			1.5			0			0.47			0.23562			0.79	
09/04/23 22:00	0.6			1.5			0			0.47			0.23388			0.78	
09/04/23 23:00	0.6			1.5			0			0.43			0.21474			0.72	
09/05/23 0:00	0.6			1.5			0			0.47			0.23598			0.79	
09/05/23 1:00	0.6			1.5			0			0.43			0.21468			0.72	
09/05/23 2:00	0.6			1.7			0			0.43			0.21648			0.72	
09/05/23 3:00	0.6			1.5			1			0.44			0.22224			0.74	
09/05/23 4:00	0.6			1.5			1			0.5			0.24924			0.83	
09/05/23 5:00	0.6			1.5			1			0.51			0.25668			0.86	
09/05/23 6:00	0.6			1.5			1			0.52			0.26154			0.87	
09/05/23 7:00	0.4			1.6			1			0.7			0.34902			1.16	
09/05/23 8:00	0.1			1.5			2			0.74			0.36822			1.23	
09/05/23 9:00	0.7			1.5			1			0.55			0.2763			0.92	
09/05/23 10:00	0.6			1.5			1			0.53			0.26442			0.88	
09/05/23 11:00	0.4			1.5			1			0.67			0.33708			1.12	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/05/23 12:00	0.4			1.5			1			0.56			0.28188			0.94	
09/05/23 13:00	0.5			1.5			0			0.53			0.26268			0.88	
09/05/23 14:00	0.5			1.5			0			0.52			0.26232			0.87	
09/05/23 15:00	0.5			1.5			0			0.52			0.26214			0.87	
09/05/23 16:00	0.5			1.5			0			0.52			0.26184			0.87	
09/05/23 17:00	0.5			1.5			0			0.48			0.23898			0.8	
09/05/23 18:00	0.7			1.5			1			0.54			0.26808			0.89	
09/05/23 19:00	0.6			1.5			1			0.62			0.3075			1.03	
09/05/23 20:00	0.7			1.5			1			0.54			0.27036			0.9	
09/05/23 21:00	0.6			1.5			0			0.52			0.26142			0.87	
09/05/23 22:00	0.6			1.5			0			0.51			0.25314			0.84	
09/05/23 23:00	0.6			1.5			0			0.49			0.24414			0.81	
09/06/23 0:00	0.6			1.5			0			0.49			0.24324			0.81	
09/06/23 1:00	0.6			1.5			0			0.46			0.22818			0.76	
09/06/23 2:00	0.7			1.5			0			0.42			0.2106			0.7	
09/06/23 3:00	0.7			1.5			0			0.43			0.21378			0.71	
09/06/23 4:00	0.7			1.5			0			0.45			0.22416			0.75	
09/06/23 5:00	0.6			1.5			0			0.51			0.25458			0.85	
09/06/23 6:00	0.6			1.5			1			0.52			0.26094			0.87	
09/06/23 7:00	0.7			1.5			0			0.46			0.23016			0.77	
09/06/23 8:00	0.6			1.5			0			0.42			0.21006			0.7	
09/06/23 9:00	0.6			1.5			0			0.42			0.20994			0.7	
09/06/23 10:00	0.6			1.5			0			0.42			0.20994			0.7	
09/06/23 11:00	0.6			1.5			0			0.42			0.21			0.7	
09/06/23 12:00	0.6			1.5			0			0.42			0.21144			0.7	
09/06/23 13:00	0.6			1.5			0			0.42			0.21006			0.7	
09/06/23 14:00	0.6			1.5			0			0.42			0.2094			0.7	
09/06/23 15:00	0.6			1.5			0			0.42			0.20934			0.7	
09/06/23 16:00	0.6			1.5			0			0.42			0.20946			0.7	
09/06/23 17:00	0.6			1.5			0			0.45			0.22602			0.75	
09/06/23 18:00	0.5			1.5			0			0.49			0.24516			0.82	
09/06/23 19:00	0.6			1.5			0			0.45			0.22674			0.76	
09/06/23 20:00	0.5			1.5			0			0.5			0.25002			0.83	
09/06/23 21:00	0.6			1.5			0			0.48			0.24072			0.8	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/06/23 22:00	0.6			1.5			0			0.5			0.24984			0.83	
09/06/23 23:00	0.6			1.5			0			0.45			0.22704			0.76	
09/07/23 0:00	0.6			1.5			0			0.47			0.23484			0.78	
09/07/23 1:00	0.6			1.5			0			0.42			0.21162			0.71	
09/07/23 2:00	0.7			1.5			0			0.42			0.20994			0.7	
09/07/23 3:00	0.7			1.5			0			0.42			0.2103			0.7	
09/07/23 4:00	0.7			1.5			0			0.42			0.21012			0.7	
09/07/23 5:00	0.6			1.5			0			0.47			0.2337			0.78	
09/07/23 6:00	0.6			1.5			1			0.52			0.25788			0.86	
09/07/23 7:00	0.7			1.5			0			0.45			0.22446			0.75	
09/07/23 8:00	0.6			1.5			0			0.42			0.2106			0.7	
09/07/23 9:00	0.6			1.5			0			0.47			0.23394			0.78	
09/07/23 10:00	0.6			1.5			0			0.44			0.22056			0.74	
09/07/23 11:00	0.6			1.5			0			0.45			0.22254			0.74	
09/07/23 12:00	0.6			1.5			0			0.45			0.22422			0.75	
09/07/23 13:00	0.6			1.5			0			0.43			0.21654			0.72	
09/07/23 14:00	0.6			1.5			0			0.48			0.24168			0.81	
09/07/23 15:00	0.6			1.5			0			0.5			0.2508			0.84	
09/07/23 16:00	0.6			1.5			0			0.45			0.22386			0.75	
09/07/23 17:00	0.6			1.5			0			0.48			0.23832			0.79	
09/07/23 18:00	0.6			1.5			0			0.48			0.23826			0.79	
09/07/23 19:00	0.6			1.5			0			0.44			0.22152			0.74	
09/07/23 20:00	0.6			1.5			0			0.5			0.25116			0.84	
09/07/23 21:00	0.6			1.5			0			0.51			0.2565			0.86	
09/07/23 22:00	0.6			1.5			0			0.48			0.24042			0.8	
09/07/23 23:00	0.6			1.5			0			0.44			0.2202			0.73	
09/08/23 0:00	0			0			0	X		0.18			0.08814			0.29	
09/08/23 1:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 2:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 3:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 4:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 5:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 6:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 7:00	0	X		0	X		0	X		0	X		0	X		0	X

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/08/23 8:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 9:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 10:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 11:00	0	X		0	X		0	X		0	X		0	X		0	X
09/08/23 12:00	0			0			0	X		0.35			0.17418			0.58	
09/08/23 13:00	0.5			1.1			1			0.51			0.25704			0.86	
09/08/23 14:00	0.5			1			1			0.53			0.26406			0.88	
09/08/23 15:00	0.5			1			1			0.53			0.26412			0.88	
09/08/23 16:00	0.8			1			1			0.56			0.27792			0.93	
09/08/23 17:00	0.3			1			2			0.69			0.34386			1.15	
09/08/23 18:00	0.1			1			2			0.76			0.3807			1.27	
09/08/23 19:00	0.4			0.9			1			0.66			0.3303			1.1	
09/08/23 20:00	0.2			1			1			0.7			0.34764			1.16	
09/08/23 21:00	0.1			1			2			0.72			0.3585			1.2	
09/08/23 22:00	0.4			1			1			0.66			0.32826			1.09	
09/08/23 23:00	0.6			1			1			0.51			0.255			0.85	
09/09/23 0:00	0.6			1			1			0.52			0.25986			0.87	
09/09/23 1:00	0.6			1			1			0.52			0.25914			0.86	
09/09/23 2:00	0.6			1.1			1			0.48			0.24012			0.8	
09/09/23 3:00	0.6			1			1			0.48			0.2418			0.81	
09/09/23 4:00	0.6			1			1			0.52			0.25908			0.86	
09/09/23 5:00	0.6			1			1			0.52			0.2616			0.87	
09/09/23 6:00	0.6			1			1			0.52			0.2616			0.87	
09/09/23 7:00	0.7			1			1			0.44			0.22032			0.73	
09/09/23 8:00	0.6			1			1			0.52			0.26016			0.87	
09/09/23 9:00	0.6			1			1			0.43			0.21288			0.71	
09/09/23 10:00	0.6			1			0			0.42			0.21036			0.7	
09/09/23 11:00	0.6			1			1			0.45			0.22338			0.74	
09/09/23 12:00	0.7			1			1			0.49			0.24564			0.82	
09/09/23 13:00	0.5			1			1			0.53			0.2637			0.88	
09/09/23 14:00	0.6			1			0			0.45			0.22662			0.76	
09/09/23 15:00	0.5			1			1			0.51			0.25638			0.85	
09/09/23 16:00	0.5			1.1			0			0.47			0.23718			0.79	
09/09/23 17:00	0.6			1			1			0.55			0.27498			0.92	