

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	252875-5
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2023 - Part V
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/31/2023 4:28:41 PM
Docketed Date:	10/31/2023

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/09/23 18:00	0.1			1			2			0.7			0.35244			1.17	
09/09/23 19:00	0.5			1			1			0.59			0.29652			0.99	
09/09/23 20:00	0.5			1			1			0.52			0.26088			0.87	
09/09/23 21:00	0.8			1			1			0.6			0.29766			0.99	
09/09/23 22:00	0.8			1			1			0.57			0.28494			0.95	
09/09/23 23:00	0.6			1			1			0.46			0.22818			0.76	
09/10/23 0:00	0.6			1			1			0.49			0.2448			0.82	
09/10/23 1:00	0.6			1			1			0.45			0.22398			0.75	
09/10/23 2:00	0.6			1			0			0.44			0.21852			0.73	
09/10/23 3:00	0.6			1.1			1			0.47			0.2364			0.79	
09/10/23 4:00	0.7			1			1			0.43			0.213			0.71	
09/10/23 5:00	0.6			1			1			0.47			0.2334			0.78	
09/10/23 6:00	0.6			1.3			0			0.5			0.24876			0.83	
09/10/23 7:00	0.6			1.5			0			0.5			0.24852			0.83	
09/10/23 8:00	0.6			1.5			1			0.54			0.2682			0.89	
09/10/23 9:00	0.6			1.5			0			0.47			0.23568			0.79	
09/10/23 10:00	0.6			1.5			0			0.45			0.22584			0.75	
09/10/23 11:00	0.6			1.5			0			0.42			0.21042			0.7	
09/10/23 12:00	0.6			1.5			0			0.42			0.21096			0.7	
09/10/23 13:00	0.6			1.5			0			0.45			0.22728			0.76	
09/10/23 14:00	0.6			1.5			0			0.48			0.24174			0.81	
09/10/23 15:00	0.5			1.5			0			0.45			0.22326			0.74	
09/10/23 16:00	0.6			1.5			0			0.49			0.24528			0.82	
09/10/23 17:00	0.1			1.5			1			0.72			0.36084			1.2	
09/10/23 18:00	0.1			1.5			1			0.72			0.36162			1.21	
09/10/23 19:00	0.4			1.5			1			0.64			0.32214			1.07	
09/10/23 20:00	0.7			1.5			0			0.52			0.26166			0.87	
09/10/23 21:00	0.9			1.5			1			0.6			0.30042			1	
09/10/23 22:00	0.7			1.5			1			0.58			0.29076			0.97	
09/10/23 23:00	0.7			1.5			0			0.42			0.21222			0.71	
09/11/23 0:00	0.7			1.5			0			0.42			0.21012			0.7	
09/11/23 1:00	0.7			1.5			0			0.42			0.20994			0.7	
09/11/23 2:00	0.7			1.5			0			0.42			0.21036			0.7	
09/11/23 3:00	0.7			1.5			0			0.42			0.21096			0.7	

Date/Tim Mod	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/11/23 4:00	0.7			1.5			0			0.43			0.21414			0.71	
09/11/23 5:00	0.7			1.5			0			0.43			0.2151			0.72	
09/11/23 6:00	0.6			1.5			1			0.52			0.26208			0.87	
09/11/23 7:00	1.2			1.5			1			0.47			0.23502			0.78	
09/11/23 8:00	1.3			1.5			0			0.42			0.21078			0.7	
09/11/23 9:00	0.8			1.5			0			0.42			0.21018			0.7	
09/11/23 10:00	0.7			1.5			0			0.42			0.20994			0.7	
09/11/23 11:00	0.6			1.5			0			0.43			0.21498			0.72	
09/11/23 12:00	0.6			1.5			0			0.47			0.23742			0.79	
09/11/23 13:00	0.6			1.5			0			0.47			0.23328			0.78	
09/11/23 14:00	0.5			1.5			0			0.49			0.2469			0.82	
09/11/23 15:00	0.5			1.5			0			0.47			0.23562			0.79	
09/11/23 16:00	0.5			1.5			0			0.47			0.2355			0.79	
09/11/23 17:00	0.5			1.5			0			0.45			0.225			0.75	
09/11/23 18:00	0.5			1.4			0			0.48			0.2412			0.8	
09/11/23 19:00	0.6			1.5			0			0.43			0.21294			0.71	
09/11/23 20:00	0.6			1.5			0			0.45			0.22332			0.74	
09/11/23 21:00	0.6			1.5			0			0.48			0.2385			0.8	
09/11/23 22:00	0.6			1.5			0			0.43			0.21738			0.72	
09/11/23 23:00	0.6			1.5			0			0.42			0.20976			0.7	
09/12/23 0:00	0.6			1.5			0			0.42			0.21012			0.7	
09/12/23 1:00	0.6			1.5			0			0.45			0.22698			0.76	
09/12/23 2:00	0.6			1.5			0			0.49			0.2454			0.82	
09/12/23 3:00	0.7			1.5			0			0.53			0.26388			0.88	
09/12/23 4:00	0.6			1.5			0			0.57			0.28728			0.96	
09/12/23 5:00	0.7			1.5			0			0.55			0.27636			0.92	
09/12/23 6:00	0.7			1.5			0			0.56			0.28242			0.94	
09/12/23 7:00	0.7			1.5			0			0.46			0.23004			0.77	
09/12/23 8:00	0.7			1.3			1			0.42			0.2106			0.7	
09/12/23 9:00	0.7			1.1			1			0.42			0.20916			0.7	
09/12/23 10:00	0.6			1.1			1			0.42			0.20982			0.7	
09/12/23 11:00	0.6			1			1			0.42			0.21048			0.7	
09/12/23 12:00	0.6			0.9			1			0.42			0.21084			0.7	
09/12/23 13:00	0.6			0.8			1			0.42			0.21048			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/12/23 14:00	0.6			0.8			1			0.43			0.21306			0.71	
09/12/23 15:00	0.6			0.8			1			0.43			0.213			0.71	
09/12/23 16:00	0.6			0.7			1			0.42			0.20946			0.7	
09/12/23 17:00	0.6			0.7			1			0.42			0.20922			0.7	
09/12/23 18:00	0.6			0.7			1			0.42			0.20916			0.7	
09/12/23 19:00	0.7			0.8			1			0.48			0.24036			0.8	
09/12/23 20:00	0.8			1.6			0			0.59			0.29598			0.99	
09/12/23 21:00	0.7			1.1			1			0.44			0.22224			0.74	
09/12/23 22:00	0.6			0.8			1			0.42			0.20886			0.7	
09/12/23 23:00	0.7			0.8			1			0.42			0.20886			0.7	
09/13/23 0:00	0.6			0.8			1			0.42			0.20898			0.7	
09/13/23 1:00	0.6			0.8			1			0.42			0.20898			0.7	
09/13/23 2:00	0.6			0.9			1			0.42			0.20922			0.7	
09/13/23 3:00	0.7			0.9			1			0.42			0.20946			0.7	
09/13/23 4:00	0.7			0.9			1			0.42			0.20988			0.7	
09/13/23 5:00	0.8			1			1			0.42			0.21018			0.7	
09/13/23 6:00	0.8			1.4			0			0.42			0.21006			0.7	
09/13/23 7:00	0.8			1.5			0			0.42			0.21042			0.7	
09/13/23 8:00	0.7			1.5			0			0.42			0.21042			0.7	
09/13/23 9:00	0.6			1.5			0			0.42			0.21048			0.7	
09/13/23 10:00	0.6			1.5			0			0.42			0.21036			0.7	
09/13/23 11:00	0.6			1.5			0			0.45			0.22548			0.75	
09/13/23 12:00	0.8			1.5			1			0.59			0.29574			0.99	
09/13/23 13:00	0.7			1.4			0			0.48			0.2394			0.8	
09/13/23 14:00	0.6			1.5			0			0.5			0.25038			0.83	
09/13/23 15:00	0.8			1.5			1			0.6			0.30006			1	
09/13/23 16:00	0.7			1.5			1			0.6			0.30066			1	
09/13/23 17:00	0.6			1.5			1			0.61			0.3036			1.01	
09/13/23 18:00	0.6			1.5			1			0.6			0.30228			1.01	
09/13/23 19:00	0.7			1.5			1			0.6			0.29904			1	
09/13/23 20:00	0.8			1.5			1			0.6			0.29802			0.99	
09/13/23 21:00	0.8			1.5			0			0.51			0.25584			0.85	
09/13/23 22:00	0.7			1.5			0			0.42			0.20916			0.7	
09/13/23 23:00	0.7			1.5			0			0.42			0.20946			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/14/23 0:00	0.7			1.5			0			0.43			0.21402			0.71	
09/14/23 1:00	0.6			1.5			0			0.43			0.21354			0.71	
09/14/23 2:00	0.6			1.6			0			0.49			0.2445			0.82	
09/14/23 3:00	0.7			1.5			0			0.42			0.20952			0.7	
09/14/23 4:00	0.7			1.5			0			0.42			0.2097			0.7	
09/14/23 5:00	0.7			1.5			0			0.43			0.2151			0.72	
09/14/23 6:00	0.7			1.5			0			0.5			0.24822			0.83	
09/14/23 7:00	0.7			1.5			0			0.46			0.2289			0.76	
09/14/23 8:00	0.7			1.5			0			0.43			0.21438			0.71	
09/14/23 9:00	0.6			1.5			0			0.48			0.2412			0.8	
09/14/23 10:00	0.6			1.5			0			0.51			0.2571			0.86	
09/14/23 11:00	0.7			1.5			0			0.52			0.2604			0.87	
09/14/23 12:00	0.8			1.5			1			0.6			0.29826			0.99	
09/14/23 13:00	0.7			1.5			0			0.52			0.25854			0.86	
09/14/23 14:00	0.6			1.5			0			0.52			0.2577			0.86	
09/14/23 15:00	0.7			1.5			1			0.56			0.2823			0.94	
09/14/23 16:00	0.5			1.5			1			0.63			0.31344			1.04	
09/14/23 17:00	0.4			1.5			1			0.64			0.31998			1.07	
09/14/23 18:00	0.5			1.5			1			0.63			0.31446			1.05	
09/14/23 19:00	0.7			1.5			1			0.6			0.29832			0.99	
09/14/23 20:00	0.9			1.5			1			0.59			0.2961			0.99	
09/14/23 21:00	0.7			1.5			1			0.62			0.30942			1.03	
09/14/23 22:00	0.8			1.5			1			0.57			0.28356			0.95	
09/14/23 23:00	0.6			1.5			0			0.45			0.2247			0.75	
09/15/23 0:00	0.6			1.5			0			0.44			0.22134			0.74	
09/15/23 1:00	0.6			1.5			0			0.43			0.21282			0.71	
09/15/23 2:00	0.6			1.5			0			0.42			0.21168			0.71	
09/15/23 3:00	0.7			1.5			0			0.42			0.20952			0.7	
09/15/23 4:00	0.6			1.5			0			0.43			0.21348			0.71	
09/15/23 5:00	0.8			1.5			1			0.49			0.24696			0.82	
09/15/23 6:00	0.3			1.5			1			0.69			0.34398			1.15	
09/15/23 7:00	0.9			1.5			1			0.52			0.2601			0.87	
09/15/23 8:00	0.7			1.5			0			0.43			0.21384			0.71	
09/15/23 9:00	0.7			1.5			0			0.42			0.21072			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/15/23 10:00	0.7			1.5			0			0.42			0.2106			0.7	
09/15/23 11:00	0.6			1.5			0			0.42			0.2109			0.7	
09/15/23 12:00	0.6			1.5			0			0.43			0.21372			0.71	
09/15/23 13:00	0.6			1.5			0			0.43			0.21264			0.71	
09/15/23 14:00	0.6			1.5			0			0.45			0.2235			0.75	
09/15/23 15:00	0.7			1.5			0			0.51			0.25608			0.85	
09/15/23 16:00	0.5			1.5			1			0.64			0.32202			1.07	
09/15/23 17:00	0.3			1.5			1			0.67			0.3357			1.12	
09/15/23 18:00	0.1			1.5			1			0.7			0.35112			1.17	
09/15/23 19:00	0.5			1.5			1			0.63			0.31374			1.05	
09/15/23 20:00	0.5			1.5			1			0.65			0.32472			1.08	
09/15/23 21:00	0.6			1.5			1			0.63			0.31746			1.06	
09/15/23 22:00	0.8			1.5			1			0.62			0.30936			1.03	
09/15/23 23:00	1			1.5			1			0.56			0.28218			0.94	
09/16/23 0:00	0.6			1.5			0			0.46			0.23244			0.77	
09/16/23 1:00	0.6			1.5			0			0.44			0.21834			0.73	
09/16/23 2:00	0.6			1.5			0			0.43			0.21438			0.71	
09/16/23 3:00	0.7			1.5			0			0.42			0.20982			0.7	
09/16/23 4:00	0.7			1.5			0			0.42			0.21006			0.7	
09/16/23 5:00	0.7			1.5			0			0.42			0.21138			0.7	
09/16/23 6:00	0.7			1.5			0			0.42			0.21036			0.7	
09/16/23 7:00	0.7			1.5			0			0.42			0.21066			0.7	
09/16/23 8:00	0.7			1.5			0			0.42			0.21168			0.71	
09/16/23 9:00	0.6			1.5			0			0.43			0.21378			0.71	
09/16/23 10:00	0.6			1.5			0			0.44			0.22032			0.73	
09/16/23 11:00	0.6			1.5			0			0.47			0.23436			0.78	
09/16/23 12:00	0.6			1.5			0			0.51			0.25344			0.84	
09/16/23 13:00	0.6			1.5			0			0.5			0.249			0.83	
09/16/23 14:00	0.6			1.5			0			0.46			0.23016			0.77	
09/16/23 15:00	0.6			1.5			0			0.47			0.23388			0.78	
09/16/23 16:00	0.6			1.5			0			0.42			0.20994			0.7	
09/16/23 17:00	0.6			1.5			0			0.44			0.22152			0.74	
09/16/23 18:00	0.6			1.5			0			0.43			0.21402			0.71	
09/16/23 19:00	0.6			1.5			0			0.42			0.20994			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/16/23 20:00	0.6			1.5			0			0.42			0.20952			0.7	
09/16/23 21:00	0.6			1.5			0			0.42			0.20946			0.7	
09/16/23 22:00	0.6			1.5			0			0.42			0.20952			0.7	
09/16/23 23:00	0.6			1.5			0			0.42			0.20964			0.7	
09/17/23 0:00	0.6			1.5			0			0.42			0.2097			0.7	
09/17/23 1:00	0.7			1.5			0			0.42			0.21			0.7	
09/17/23 2:00	0.7			1.5			0			0.42			0.21018			0.7	
09/17/23 3:00	0.7			1.5			0			0.42			0.21018			0.7	
09/17/23 4:00	0.7			1.5			0			0.42			0.21018			0.7	
09/17/23 5:00	0.7			1.5			0			0.42			0.21036			0.7	
09/17/23 6:00	0.7			1.5			0			0.42			0.21042			0.7	
09/17/23 7:00	0.7			1.5			0			0.42			0.21042			0.7	
09/17/23 8:00	0.7			1.5			0			0.42			0.21066			0.7	
09/17/23 9:00	0.7			1.5			0			0.42			0.21048			0.7	
09/17/23 10:00	0.6			1.5			0			0.42			0.21036			0.7	
09/17/23 11:00	0.6			1.5			0			0.42			0.21048			0.7	
09/17/23 12:00	0.6			1.5			0			0.42			0.21048			0.7	
09/17/23 13:00	0.6			1.5			0			0.42			0.21042			0.7	
09/17/23 14:00	0.6			1.5			0			0.42			0.21			0.7	
09/17/23 15:00	0.6			1.5			0			0.42			0.21			0.7	
09/17/23 16:00	0.6			1.5			0			0.42			0.20988			0.7	
09/17/23 17:00	0.6			1.5			0			0.43			0.2166			0.72	
09/17/23 18:00	0.6			1.5			0			0.43			0.21264			0.71	
09/17/23 19:00	0.6			1.5			0			0.42			0.21036			0.7	
09/17/23 20:00	0.6			1.5			0			0.43			0.21636			0.72	
09/17/23 21:00	0.6			1.5			0			0.42			0.20994			0.7	
09/17/23 22:00	0.6			1.5			0			0.42			0.21006			0.7	
09/17/23 23:00	0.6			1.5			0			0.42			0.21036			0.7	
09/18/23 0:00	0.7			1.5			0			0.42			0.2106			0.7	
09/18/23 1:00	0.6			1.5			0			0.42			0.2106			0.7	
09/18/23 2:00	0.7			1.5			0			0.42			0.21054			0.7	
09/18/23 3:00	0.7			1.5			0			0.42			0.21048			0.7	
09/18/23 4:00	0.7			1.5			0			0.42			0.21048			0.7	
09/18/23 5:00	0.7			1.5			0			0.42			0.2106			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/18/23 6:00	0.7			1.5			0			0.42			0.21054			0.7	
09/18/23 7:00	0.7			1.5			0			0.42			0.21066			0.7	
09/18/23 8:00	0.7			1.5			0			0.42			0.21078			0.7	
09/18/23 9:00	0.7			1.5			0			0.42			0.21066			0.7	
09/18/23 10:00	0.6			1.5			0			0.42			0.21078			0.7	
09/18/23 11:00	0.6			1.5			0			0.42			0.21072			0.7	
09/18/23 12:00	0.6			1.5			0			0.42			0.21054			0.7	
09/18/23 13:00	0.6			1.5			0			0.42			0.2106			0.7	
09/18/23 14:00	0.6			1.5			0			0.42			0.21012			0.7	
09/18/23 15:00	0.6			1.5			0			0.42			0.21006			0.7	
09/18/23 16:00	0.6			1.5			0			0.42			0.21024			0.7	
09/18/23 17:00	0.6			1.5			0			0.45			0.2262			0.75	
09/18/23 18:00	0.6			1.5			0			0.48			0.24192			0.81	
09/18/23 19:00	0.6			1.5			0			0.43			0.21618			0.72	
09/18/23 20:00	0.6			1.5			0			0.42			0.21108			0.7	
09/18/23 21:00	0.6			1.5			0			0.42			0.21156			0.71	
09/18/23 22:00	0.6			1.5			0			0.42			0.21126			0.7	
09/18/23 23:00	0.6			1.5			0			0.42			0.21018			0.7	
09/19/23 0:00	0.6			1.5			0			0.42			0.21018			0.7	
09/19/23 1:00	0.6			1.5			0			0.42			0.21018			0.7	
09/19/23 2:00	0.6			1.5			0			0.42			0.21036			0.7	
09/19/23 3:00	0.7			1.5			0			0.42			0.21066			0.7	
09/19/23 4:00	0.7			1.5			0			0.42			0.21102			0.7	
09/19/23 5:00	0.7			1.5			0			0.45			0.2241			0.75	
09/19/23 6:00	0.6			1.5			1			0.5			0.24984			0.83	
09/19/23 7:00	0.7			1.5			0			0.44			0.2223			0.74	
09/19/23 8:00	0.7			1.5			0			0.42			0.21072			0.7	
09/19/23 9:00	0.7			1.5			0			0.42			0.2106			0.7	
09/19/23 10:00	0.6			1.5			0			0.42			0.21072			0.7	
09/19/23 11:00	0.6			1.5			0			0.42			0.21078			0.7	
09/19/23 12:00	0.6			1.5			0			0.42			0.21072			0.7	
09/19/23 13:00	0.6			1.5			0			0.42			0.21084			0.7	
09/19/23 14:00	0.6			1.5			0			0.42			0.21018			0.7	
09/19/23 15:00	0.6			1.5			0			0.42			0.21006			0.7	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/19/23 16:00	0.6			1.5			0			0.42			0.20988			0.7	
09/19/23 17:00	0.6			1.5			0			0.44			0.22134			0.74	
09/19/23 18:00	0.6			1.5			0			0.46			0.2304			0.77	
09/19/23 19:00	0.6			1.5			0			0.42			0.20988			0.7	
09/19/23 20:00	0.6			1.5			0			0.42			0.21018			0.7	
09/19/23 21:00	0.7			1.5			0			0.42			0.21126			0.7	
09/19/23 22:00	0.7			1.5			0			0.42			0.20958			0.7	
09/19/23 23:00	0.7			1.5			0			0.42			0.20982			0.7	
09/20/23 0:00	0.7			1.5			0			0.42			0.21018			0.7	
09/20/23 1:00	0.7			1.5			0			0.42			0.20982			0.7	
09/20/23 2:00	0.7			1.5			0			0.42			0.2097			0.7	
09/20/23 3:00	0.8			1.5			0			0.42			0.20976			0.7	
09/20/23 4:00	0.8			1.5			0			0.42			0.21018			0.7	
09/20/23 5:00	0.8			1.5			0			0.42			0.21144			0.7	
09/20/23 6:00	0.8			1.5			0			0.43			0.21384			0.71	
09/20/23 7:00	0.8			1.5			0			0.42			0.21138			0.7	
09/20/23 8:00	0.8			1.5			0			0.42			0.21036			0.7	
09/20/23 9:00	0.8			1.5			0			0.42			0.21042			0.7	
09/20/23 10:00	0.7			1.5			0			0.42			0.21042			0.7	
09/20/23 11:00	0.7			1.4			0			0.44			0.22032			0.73	
09/20/23 12:00	0.6			1.5			0			0.43			0.2145			0.72	
09/20/23 13:00	0.6			1.5			0			0.43			0.21438			0.71	
09/20/23 14:00	0.6			1.5			0			0.43			0.21408			0.71	
09/20/23 15:00	0.6			1.5			0			0.43			0.21384			0.71	
09/20/23 16:00	0.6			1.5			0			0.43			0.2139			0.71	
09/20/23 17:00	0.7			1.5			0			0.45			0.22482			0.75	
09/20/23 18:00	0.6			1.5			0			0.48			0.24054			0.8	
09/20/23 19:00	0.6			1.5			0			0.48			0.24156			0.81	
09/20/23 20:00	0.6			1.5			0			0.43			0.2133			0.71	
09/20/23 21:00	0.7			1.5			0			0.44			0.22122			0.74	
09/20/23 22:00	0.7			1.5			0			0.44			0.21846			0.73	
09/20/23 23:00	0.7			1.5			0			0.43			0.21258			0.71	
09/21/23 0:00	0.7			1.5			0			0.42			0.2124			0.71	
09/21/23 1:00	0.7			1.5			0			0.43			0.21354			0.71	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/21/23 2:00	0.8			1.5			0			0.43			0.21432			0.71	
09/21/23 3:00	0.8			1.5			1			0.43			0.2139			0.71	
09/21/23 4:00	0.8			1.5			1			0.43			0.21414			0.71	
09/21/23 5:00	0.8			1.5			1			0.43			0.21468			0.72	
09/21/23 6:00	0.7			1.5			1			0.53			0.26316			0.88	
09/21/23 7:00	0.7			1.5			1			0.49			0.24348			0.81	
09/21/23 8:00	0.7			1.5			1			0.46			0.23238			0.77	
09/21/23 9:00	0.7			1.5			1			0.44			0.21966			0.73	
09/21/23 10:00	0.7			1.5			1			0.47			0.2337			0.78	
09/21/23 11:00	0.6			1.5			0			0.45			0.22656			0.76	
09/21/23 12:00	0.6			1.5			0			0.43			0.21444			0.71	
09/21/23 13:00	0.6			1.5			1			0.48			0.23946			0.8	
09/21/23 14:00	0.6			1.5			0			0.53			0.2649			0.88	
09/21/23 15:00	0.6			1.5			0			0.51			0.25572			0.85	
09/21/23 16:00	0.6			1.5			0			0.49			0.24438			0.81	
09/21/23 17:00	0.6			1.5			0			0.47			0.23328			0.78	
09/21/23 18:00	0.6			1.5			0			0.52			0.2613			0.87	
09/21/23 19:00	0.6			1.5			0			0.44			0.2193			0.73	
09/21/23 20:00	0.7			1.5			0			0.43			0.21444			0.71	
09/21/23 21:00	0.7			1.5			0			0.45			0.22638			0.75	
09/21/23 22:00	0.7			1.5			0			0.43			0.21474			0.72	
09/21/23 23:00	0.7			1.5			0			0.43			0.21462			0.72	
09/22/23 0:00	0.7			1.5			1			0.43			0.21432			0.71	
09/22/23 1:00	0.7			1.5			1			0.43			0.21492			0.72	
09/22/23 2:00	0.7			1.5			0			0.43			0.21486			0.72	
09/22/23 3:00	0.8			1.5			0			0.43			0.21456			0.72	
09/22/23 4:00	0.8			1.5			1			0.43			0.21504			0.72	
09/22/23 5:00	0.7			1.5			1			0.43			0.21492			0.72	
09/22/23 6:00	0.7			1.5			1			0.46			0.23124			0.77	
09/22/23 7:00	0.7			1.5			1			0.51			0.25506			0.85	
09/22/23 8:00	0.7			1.5			0			0.47			0.23424			0.78	
09/22/23 9:00	0.8			1.5			0			0.43			0.2133			0.71	
09/22/23 10:00	0.7			1.5			0			0.43			0.21318			0.71	
09/22/23 11:00	0.7			1.5			1			0.43			0.21324			0.71	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/22/23 12:00	0.6			1.5			0			0.43			0.21414			0.71	
09/22/23 13:00	0.6			1.5			0			0.43			0.21486			0.72	
09/22/23 14:00	0.6			1.5			0			0.45			0.22428			0.75	
09/22/23 15:00	0.7			1.5			0			0.43			0.21504			0.72	
09/22/23 16:00	0.6			1.5			0			0.48			0.23988			0.8	
09/22/23 17:00	0.6			1.5			0			0.54			0.2715			0.91	
09/22/23 18:00	0.6			1.5			1			0.54			0.2718			0.91	
09/22/23 19:00	0.6			1.4			1			0.54			0.27174			0.91	
09/22/23 20:00	0.6			1.4			0			0.52			0.25992			0.87	
09/22/23 21:00	0.7			1.5			0			0.48			0.2376			0.79	
09/22/23 22:00	0.7			1.5			0			0.43			0.21342			0.71	
09/22/23 23:00	0.7			1.5			0			0.43			0.21414			0.71	
09/23/23 0:00	0.8			1.5			0			0.43			0.2151			0.72	
09/23/23 1:00	0.8			1.5			0			0.43			0.21504			0.72	
09/23/23 2:00	0.7			1.6			0			0.43			0.21522			0.72	
09/23/23 3:00	0.8			1.5			1			0.43			0.21498			0.72	
09/23/23 4:00	0.8			1.5			1			0.43			0.2145			0.72	
09/23/23 5:00	0.8			1.5			1			0.43			0.21444			0.71	
09/23/23 6:00	0.8			1.5			1			0.43			0.21522			0.72	
09/23/23 7:00	0.8			1.5			1			0.44			0.21786			0.73	
09/23/23 8:00	0.7			1.5			1			0.44			0.21816			0.73	
09/23/23 9:00	0.7			1.5			0			0.44			0.2181			0.73	
09/23/23 10:00	0.7			1.5			0			0.43			0.21738			0.72	
09/23/23 11:00	0.6			1.5			0			0.43			0.21642			0.72	
09/23/23 12:00	0.6			1.5			0			0.43			0.21522			0.72	
09/23/23 13:00	0.6			1.5			0			0.43			0.21432			0.71	
09/23/23 14:00	0.6			1.5			0			0.43			0.21438			0.71	
09/23/23 15:00	0.6			1.5			0			0.43			0.2142			0.71	
09/23/23 16:00	0.6			1.5			0			0.43			0.21408			0.71	
09/23/23 17:00	0.6			1.5			0			0.45			0.22608			0.75	
09/23/23 18:00	0.6			1.5			0			0.46			0.22902			0.76	
09/23/23 19:00	0.6			1.5			0			0.43			0.2139			0.71	
09/23/23 20:00	0.6			1.5			0			0.43			0.21318			0.71	
09/23/23 21:00	0.6			1.5			0			0.43			0.21522			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/23/23 22:00	0.7			1.5			0			0.46			0.22974			0.77	
09/23/23 23:00	0.7			1.5			0			0.43			0.21516			0.72	
09/24/23 0:00	0.7			1.5			0			0.43			0.21534			0.72	
09/24/23 1:00	0.7			1.5			0			0.43			0.21618			0.72	
09/24/23 2:00	0.7			1.5			0			0.43			0.2163			0.72	
09/24/23 3:00	0.8			1.5			1			0.43			0.21576			0.72	
09/24/23 4:00	0.7			1.5			1			0.43			0.21612			0.72	
09/24/23 5:00	0.7			1.5			1			0.43			0.216			0.72	
09/24/23 6:00	0.8			1.5			1			0.43			0.2163			0.72	
09/24/23 7:00	0.8			1.5			1			0.43			0.21624			0.72	
09/24/23 8:00	0.7			1.5			1			0.43			0.21612			0.72	
09/24/23 9:00	0.7			1.5			1			0.43			0.21618			0.72	
09/24/23 10:00	0.7			1.5			1			0.43			0.21672			0.72	
09/24/23 11:00	0.6			1.5			0			0.43			0.2169			0.72	
09/24/23 12:00	0.6			1.5			0			0.43			0.21714			0.72	
09/24/23 13:00	0.6			1.5			0			0.43			0.21702			0.72	
09/24/23 14:00	0.6			1.5			0			0.43			0.2172			0.72	
09/24/23 15:00	0.6			1.5			0			0.44			0.21768			0.73	
09/24/23 16:00	0.6			1.5			0			0.43			0.21504			0.72	
09/24/23 17:00	0.6			1.5			0			0.48			0.24018			0.8	
09/24/23 18:00	0.6			1.5			1			0.54			0.27144			0.9	
09/24/23 19:00	0.6			1.5			0			0.52			0.26136			0.87	
09/24/23 20:00	0.6			1.5			0			0.49			0.24624			0.82	
09/24/23 21:00	0.6			1.5			1			0.53			0.2646			0.88	
09/24/23 22:00	0.6			1.5			0			0.45			0.22266			0.74	
09/24/23 23:00	0.7			1.5			0			0.43			0.2145			0.72	
09/25/23 0:00	0.7			1.5			0			0.43			0.21606			0.72	
09/25/23 1:00	0.7			1.5			0			0.43			0.21576			0.72	
09/25/23 2:00	0.7			1.5			1			0.43			0.21492			0.72	
09/25/23 3:00	0.7			1.5			1			0.43			0.21522			0.72	
09/25/23 4:00	0.7			1.5			1			0.43			0.21564			0.72	
09/25/23 5:00	0.7			1.5			1			0.43			0.21576			0.72	
09/25/23 6:00	0.6			1.5			1			0.5			0.24822			0.83	
09/25/23 7:00	0.7			1.5			1			0.47			0.23652			0.79	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/25/23 8:00	0.7			1.5			0			0.43			0.21534			0.72	
09/25/23 9:00	0.7			1.5			0			0.43			0.21492			0.72	
09/25/23 10:00	0.7			1.5			1			0.43			0.21564			0.72	
09/25/23 11:00	0.6			1.5			0			0.43			0.21486			0.72	
09/25/23 12:00	0.6			1.5			0			0.43			0.21522			0.72	
09/25/23 13:00	0.6			1.5			0			0.43			0.21636			0.72	
09/25/23 14:00	0.6			1.5			0			0.43			0.21582			0.72	
09/25/23 15:00	0.6			1.5			0			0.43			0.21666			0.72	
09/25/23 16:00	0.6			1.5			0			0.44			0.21762			0.73	
09/25/23 17:00	0.9			1.5			0			0.49			0.24312			0.81	
09/25/23 18:00	0.6			1.5			0			0.43			0.21498			0.72	
09/25/23 19:00	0.6			1.5			0			0.43			0.21432			0.71	
09/25/23 20:00	0.6			1.5			0			0.43			0.21402			0.71	
09/25/23 21:00	0.6			1.5			0			0.48			0.23772			0.79	
09/25/23 22:00	0.6			1.5			0			0.47			0.2328			0.78	
09/25/23 23:00	0.7			1.5			0			0.43			0.21354			0.71	
09/26/23 0:00	0.7			1.5			0			0.43			0.21378			0.71	
09/26/23 1:00	0.7			1.5			0			0.43			0.21462			0.72	
09/26/23 2:00	0.7			1.5			0			0.43			0.21522			0.72	
09/26/23 3:00	0.7			1.5			1			0.43			0.21588			0.72	
09/26/23 4:00	0.7			1.5			0			0.43			0.21606			0.72	
09/26/23 5:00	0.7			1.5			1			0.45			0.2247			0.75	
09/26/23 6:00	0.6			1.5			1			0.49			0.24504			0.82	
09/26/23 7:00	0.6			1.5			0			0.45			0.2265			0.76	
09/26/23 8:00	0.6			1.5			1			0.53			0.26286			0.88	
09/26/23 9:00	0.6			1.5			0			0.47			0.23718			0.79	
09/26/23 10:00	0.6			1.5			0			0.43			0.21468			0.72	
09/26/23 11:00	0.6			1.5			0			0.43			0.21366			0.71	
09/26/23 12:00	0.6			1.5			0			0.43			0.21336			0.71	
09/26/23 13:00	0.6			1.5			0			0.47			0.2331			0.78	
09/26/23 14:00	0.6			1.5			0			0.43			0.21588			0.72	
09/26/23 15:00	0.6			1.5			0			0.43			0.21624			0.72	
09/26/23 16:00	0.6			1.5			0			0.43			0.21594			0.72	
09/26/23 17:00	0.6			1.5			0			0.44			0.21942			0.73	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 18:00	0.9			1.5			0			0.48			0.23814			0.79	
09/26/23 19:00	0.6			1.5			0			0.44			0.21936			0.73	
09/26/23 20:00	0.6			1.5			0			0.43			0.2154			0.72	
09/26/23 21:00	1			1.5			0			0.43			0.21546			0.72	
09/26/23 22:00	0.8			1.5			0			0.44			0.22218			0.74	
09/26/23 23:00	0.7			1.5			0			0.43			0.21594			0.72	
09/27/23 0:00	0.7			1.5			0			0.43			0.21732			0.72	
09/27/23 1:00	0.7			1.5			0			0.43			0.2169			0.72	
09/27/23 2:00	0.7			1.5			0			0.43			0.21666			0.72	
09/27/23 3:00	0.7			1.5			0			0.43			0.2169			0.72	
09/27/23 4:00	0.7			1.5			0			0.43			0.21684			0.72	
09/27/23 5:00	0.7			1.5			0			0.43			0.21684			0.72	
09/27/23 6:00	0.7			1.5			1			0.43			0.21678			0.72	
09/27/23 7:00	0.8			1.5			1			0.43			0.21618			0.72	
09/27/23 8:00	0.7			1.5			0			0.43			0.21636			0.72	
09/27/23 9:00	0.7			1.5			0			0.43			0.21582			0.72	
09/27/23 10:00	0.7			1.5			0			0.43			0.21492			0.72	
09/27/23 11:00	0.6			1.5			0			0.43			0.2145			0.72	
09/27/23 12:00	0.6			1.5			0			0.43			0.2148			0.72	
09/27/23 13:00	0.6			1.5			0			0.43			0.21516			0.72	
09/27/23 14:00	0.6			1.5			0			0.43			0.21474			0.72	
09/27/23 15:00	0.6			1.5			0			0.43			0.21486			0.72	
09/27/23 16:00	0.6			1.5			0			0.43			0.21474			0.72	
09/27/23 17:00	0.6			1.5			0			0.43			0.21474			0.72	
09/27/23 18:00	0.6			1.5			0			0.43			0.21468			0.72	
09/27/23 19:00	0.6			1.5			0			0.43			0.21438			0.71	
09/27/23 20:00	0.7			1.5			0			0.43			0.21426			0.71	
09/27/23 21:00	0.6			1.5			0			0.43			0.2148			0.72	
09/27/23 22:00	0.7			1.5			0			0.43			0.21408			0.71	
09/27/23 23:00	0.7			1.5			0			0.43			0.2139			0.71	
09/28/23 0:00	0.7			1.5			0			0.43			0.21342			0.71	
09/28/23 1:00	0.7			1.5			0			0.43			0.21336			0.71	
09/28/23 2:00	0.7			1.6			0			0.43			0.21396			0.71	
09/28/23 3:00	0.8			1.5			0			0.43			0.2151			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/28/23 4:00	0.8			1.5			1			0.43			0.21528			0.72	
09/28/23 5:00	0.7			1.5			1			0.43			0.2151			0.72	
09/28/23 6:00	0.9			1.5			1			0.46			0.22878			0.76	
09/28/23 7:00	1			1.5			1			0.49			0.24576			0.82	
09/28/23 8:00	0.8			1.5			1			0.43			0.2148			0.72	
09/28/23 9:00	0.7			1.5			1			0.43			0.21576			0.72	
09/28/23 10:00	0.7			1.5			1			0.43			0.21582			0.72	
09/28/23 11:00	0.7			1.5			0			0.43			0.21546			0.72	
09/28/23 12:00	0.7			1.5			0			0.43			0.21492			0.72	
09/28/23 13:00	0.7			1.5			0			0.43			0.21396			0.71	
09/28/23 14:00	0.7			1.5			0			0.43			0.21348			0.71	
09/28/23 15:00	0.7			1.5			0			0.43			0.2136			0.71	
09/28/23 16:00	0.7			1.5			0			0.43			0.21384			0.71	
09/28/23 17:00	0.7			1.5			0			0.44			0.21864			0.73	
09/28/23 18:00	0.7			1.5			0			0.43			0.21372			0.71	
09/28/23 19:00	0.6			1.5			0			0.43			0.21378			0.71	
09/28/23 20:00	0.7			1.5			0			0.43			0.21378			0.71	
09/28/23 21:00	0.8			1.5			0			0.43			0.21504			0.72	
09/28/23 22:00	0.8			1.5			0			0.43			0.21498			0.72	
09/28/23 23:00	0.8			1.5			0			0.43			0.21468			0.72	
09/29/23 0:00	0.8			1.5			0			0.43			0.2145			0.72	
09/29/23 1:00	0.8			1.5			0			0.43			0.21468			0.72	
09/29/23 2:00	0.7			1.4			0			0.43			0.2145			0.72	
09/29/23 3:00	0.8			1.5			0			0.43			0.21456			0.72	
09/29/23 4:00	0.7			1.5			0			0.43			0.21468			0.72	
09/29/23 5:00	0.7			1.5			0			0.43			0.21462			0.72	
09/29/23 6:00	0.7			1.5			0			0.43			0.21486			0.72	
09/29/23 7:00	0.7			1.5			1			0.44			0.22044			0.73	
09/29/23 8:00	0.7			1.5			0			0.43			0.21462			0.72	
09/29/23 9:00	0.7			1.5			0			0.43			0.21444			0.71	
09/29/23 10:00	0.7			1.5			0			0.43			0.21426			0.71	
09/29/23 11:00	0.7			1.5			0			0.43			0.21528			0.72	
09/29/23 12:00	0.6			1.5			0			0.43			0.21558			0.72	
09/29/23 13:00	0.6			1.5			0			0.43			0.21606			0.72	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/29/23 14:00	0.6			1.5			0			0.43			0.21642			0.72	
09/29/23 15:00	0.6			1.5			0			0.43			0.216			0.72	
09/29/23 16:00	0.6			1.5			0			0.43			0.21522			0.72	
09/29/23 17:00	0.6			1.5			0			0.47			0.23358			0.78	
09/29/23 18:00	0.6			1.5			0			0.43			0.21384			0.71	
09/29/23 19:00	0.6			1.5			0			0.43			0.21342			0.71	
09/29/23 20:00	0.6			1.5			0			0.43			0.21366			0.71	
09/29/23 21:00	0.7			1.5			0			0.43			0.21384			0.71	
09/29/23 22:00	0.7			1.5			0			0.43			0.21372			0.71	
09/29/23 23:00	0.7			1.5			0			0.43			0.2139			0.71	
09/30/23 0:00	0.7			1.5			0			0.43			0.21408			0.71	
09/30/23 1:00	0.7			1.5			0			0.43			0.21402			0.71	
09/30/23 2:00	0.7			1.4			0			0.43			0.21438			0.71	
09/30/23 3:00	0.7			1.5			1			0.43			0.21468			0.72	
09/30/23 4:00	0.7			1.5			0			0.43			0.21456			0.72	
09/30/23 5:00	0.7			1.5			1			0.43			0.21402			0.71	
09/30/23 6:00	0.7			1.5			1			0.43			0.2139			0.71	
09/30/23 7:00	0.7			1.5			1			0.43			0.21402			0.71	
09/30/23 8:00	0.7			1.5			1			0.43			0.21432			0.71	
09/30/23 9:00	0.7			1.5			1			0.43			0.21384			0.71	
09/30/23 10:00	0.7			1.5			1			0.43			0.21372			0.71	
09/30/23 11:00	0.7			1.5			0			0.43			0.2157			0.72	
09/30/23 12:00	0.7			1.5			0			0.43			0.2148			0.72	
09/30/23 13:00	0.7			1.5			0			0.43			0.21468			0.72	
09/30/23 14:00	0.6			1.5			0			0.43			0.21462			0.72	
09/30/23 15:00	0.6			1.5			0			0.43			0.21516			0.72	
09/30/23 16:00	0.6			1.5			0			0.43			0.21522			0.72	
09/30/23 17:00	0.6			1.5			0			0.43			0.21522			0.72	
09/30/23 18:00	0.6			1.5			0			0.43			0.2151			0.72	
09/30/23 19:00	0.6			1.5			0			0.43			0.2151			0.72	
09/30/23 20:00	0.6			1.5			0			0.43			0.2151			0.72	
09/30/23 21:00	0.7			1.5			0			0.43			0.21462			0.72	
09/30/23 22:00	0.7			1.5			0			0.43			0.21438			0.71	
09/30/23 23:00	0.8			1.5			1			0.43			0.2145			0.72	

AQ57 CT2 HOURLY EMISSIONS

Date/Tim Mod	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/01/23 0:00	0	X		0	X		0	X		0.63			0	X		0	X
07/01/23 1:00	0	X		0	X		0	X		0.63			0	X		0	X
07/01/23 2:00	0	X		0	X		0	X		0.63			0	X		0	X
07/01/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/01/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/01/23 5:00	0	X		0	X		0	X		0.61			0	X		0	X
07/01/23 6:00	0	X		0	X		0	X		0.59			0	X		0	X
07/01/23 7:00	0	X		0	X		0	X		0.43			0	X		0	X
07/01/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/01/23 17:00	0	X		0	X		0	X		0.51			0	X		0	X
07/01/23 18:00	0	X		0	X		0	X		0.65			0	X		0	X
07/01/23 19:00	0	X		0	X		0	X		0.65			0	X		0	X
07/01/23 20:00	0	X		0	X		0	X		0.65			0	X		0	X
07/01/23 21:00	0	X		0	X		0	X		0.64			0	X		0	X
07/01/23 22:00	0	X		0	X		0	X		0.64			0	X		0	X
07/01/23 23:00	0	X		0	X		0	X		0.64			0	X		0	X
07/02/23 0:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 1:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 2:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 3:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 4:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 5:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 6:00	0	X		0	X		0	X		0.63			0	X		0	X
07/02/23 7:00	0	X		0	X		0	X		0.49			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/02/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/02/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/02/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/02/23 11:00	0	X		0	X		0	X		0.51			0	X		0	X
07/02/23 12:00	0	X		0	X		0	X		0.64			0	X		0	X
07/02/23 13:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 14:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 15:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 16:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 17:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 18:00	0	X		0	X		0	X		0.68			0	X		0	X
07/02/23 19:00	0	X		0	X		0	X		0.75			0	X		0	X
07/02/23 20:00	0	X		0	X		0	X		0.73			0	X		0	X
07/02/23 21:00	0	X		0	X		0	X		0.65			0	X		0	X
07/02/23 22:00	0	X		0	X		0	X		0.66			0	X		0	X
07/02/23 23:00	0	X		0	X		0	X		0.64			0	X		0	X
07/03/23 0:00	0	X		0	X		0	X		0.63			0	X		0	X
07/03/23 1:00	0	X		0	X		0	X		0.63			0	X		0	X
07/03/23 2:00	0	X		0	X		0	X		0.63			0	X		0	X
07/03/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 6:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 7:00	0	X		0	X		0	X		0.51			0	X		0	X
07/03/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/03/23 15:00	0	X		0	X		0	X		0.5			0	X		0	X
07/03/23 16:00	0	X		0	X		0	X		0.64			0	X		0	X
07/03/23 17:00	0	X		0	X		0	X		0.64			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/03/23 18:00	0	X		0	X		0	X		0.64			0	X		0	X
07/03/23 19:00	0	X		0	X		0	X		0.63			0	X		0	X
07/03/23 20:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 21:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 22:00	0	X		0	X		0	X		0.62			0	X		0	X
07/03/23 23:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 0:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 1:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 2:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/04/23 6:00	0	X		0	X		0	X		0.54			0	X		0	X
07/04/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 17:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 18:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 19:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 20:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 21:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 22:00	0	X		0	X		0	X		0.44			0	X		0	X
07/04/23 23:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 0:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 1:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 2:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 3:00	0	X		0	X		0	X		0.44			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/05/23 4:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 5:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 6:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/05/23 13:00	0	X		0	X		0	X		0.52			0	X		0	X
07/05/23 14:00	0	X		0	X		0	X		0.56			0	X		0	X
07/05/23 15:00	0	X		0	X		0	X		0.61			0	X		0	X
07/05/23 16:00	0	X		0	X		0	X		0.64			0	X		0	X
07/05/23 17:00	0	X		0	X		0	X		0.64			0	X		0	X
07/05/23 18:00	0	X		0	X		0	X		0.64			0	X		0	X
07/05/23 19:00	0	X		0	X		0	X		0.69			0	X		0	X
07/05/23 20:00	0	X		0	X		0	X		0.65			0	X		0	X
07/05/23 21:00	0	X		0	X		0	X		0.63			0	X		0	X
07/05/23 22:00	0	X		0	X		0	X		0.63			0	X		0	X
07/05/23 23:00	0	X		0	X		0	X		0.62			0	X		0	X
07/06/23 0:00	0	X		0	X		0	X		0.62			0	X		0	X
07/06/23 1:00	0	X		0	X		0	X		0.62			0	X		0	X
07/06/23 2:00	0	X		0	X		0	X		0.61			0	X		0	X
07/06/23 3:00	0	X		0	X		0	X		0.61			0	X		0	X
07/06/23 4:00	0	X		0	X		0	X		0.61			0	X		0	X
07/06/23 5:00	0	X		0	X		0	X		0.61			0	X		0	X
07/06/23 6:00	0	X		0	X		0	X		0.61			0	X		0	X
07/06/23 7:00	0	X		0	X		0	X		0.54			0	X		0	X
07/06/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/06/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/06/23 16:00	0	X		0	X		0	X		0.52			0	X		0	X
07/06/23 17:00	0	X		0	X		0	X		0.63			0	X		0	X
07/06/23 18:00	0	X		0	X		0	X		0.65			0	X		0	X
07/06/23 19:00	0	X		0	X		0	X		0.75			0	X		0	X
07/06/23 20:00	0	X		0	X		0	X		0.72			0	X		0	X
07/06/23 21:00	0	X		0	X		0	X		0.64			0	X		0	X
07/06/23 22:00	0	X		0	X		0	X		0.62			0	X		0	X
07/06/23 23:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 0:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 1:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 2:00	0	X		0	X		0	X		0.61			0	X		0	X
07/07/23 3:00	0	X		0	X		0	X		0.61			0	X		0	X
07/07/23 4:00	0	X		0	X		0	X		0.61			0	X		0	X
07/07/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 6:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 7:00	0	X		0	X		0	X		0.62			0	X		0	X
07/07/23 8:00	0	X		0	X		0	X		0.48			0	X		0	X
07/07/23 9:00	0			0	X		0			0.58			0.0483			0.16	
07/07/23 10:00	0			0	X		0			0.63			0.05832			0.19	
07/07/23 11:00	0	X		0	X		0	X		0.57			0	X		0	X
07/07/23 12:00	0			0	X		0			0.56			0.0588			0.2	
07/07/23 13:00	0			0	X		0			0.57			0.05124			0.17	
07/07/23 14:00	0	X		0	X		0	X		0.58			0	X		0	X
07/07/23 15:00	0	X		0	X		0	X		0.55			0	X		0	X
07/07/23 16:00	0			0	X		0			0.47			0.05712			0.19	
07/07/23 17:00	0	X		0	X		0	X		0.5			0.0513			0.17	
07/07/23 18:00	0	X		0	X		0	X		0.49			0	X		0	X
07/07/23 19:00	0	X		0	X		0	X		0.73			0	X		0	X
07/07/23 20:00	0	X		0	X		0	X		0.74			0	X		0	X
07/07/23 21:00	0	X		0	X		0	X		0.66			0	X		0	X
07/07/23 22:00	0	X		0	X		0	X		0.63			0	X		0	X
07/07/23 23:00	0	X		0	X		0	X		0.62			0	X		0	X

Date/Tim Mod	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 0:00	0	X		0	X		0	X		0.63			0	X		0	X
07/08/23 1:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 2:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 6:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 7:00	0	X		0	X		0	X		0.54			0	X		0	X
07/08/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 9:00	0	X		0	X		0	X		0.44			0.05832			0.19	
07/08/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/08/23 17:00	0	X		0	X		0	X		0.52			0.04716			0.16	
07/08/23 18:00	0	X		0	X		0	X		0.65			0.0714			0.24	
07/08/23 19:00	0	X		0	X		0	X		0.77			0	X		0	X
07/08/23 20:00	0	X		0	X		0	X		0.69			0	X		0	X
07/08/23 21:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 22:00	0	X		0	X		0	X		0.62			0	X		0	X
07/08/23 23:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 0:00	0	X		0	X		0	X		0.61			0	X		0	X
07/09/23 1:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 2:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/09/23 6:00	0	X		0	X		0	X		0.56			0.13848			0.46	
07/09/23 7:00	0	X		0	X		0	X		0.53			0.28308			0.94	
07/09/23 8:00	1.1			1			0.3			0.54			0.18768			0.63	
07/09/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/09/23 17:00	0	X		0	X		0	X		0.43			0	X		0	X
07/09/23 18:00	0	X		0	X		0	X		0.47			0	X		0	X
07/09/23 19:00	0	X		0	X		0	X		0.55			0	X		0	X
07/09/23 20:00	0	X		0	X		0	X		0.55			0	X		0	X
07/09/23 21:00	0	X		0	X		0	X		0.55			0	X		0	X
07/09/23 22:00	0	X		0	X		0	X		0.5			0	X		0	X
07/09/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 7:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
07/10/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 17:00	0	X		0	X		0	X		0.44			0	X		0	X
07/10/23 18:00	0	X		0	X		0	X		0.45			0	X		0	X
07/10/23 19:00	0	X		0	X		0	X		0.49			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/10/23 20:00	0	X		0	X		0	X		0.57			0	X		0	X
07/10/23 21:00	0	X		0	X		0	X		0.48			0	X		0	X
07/10/23 22:00	0	X		0	X		0	X		0.46			0	X		0	X
07/10/23 23:00	0	X		0	X		0	X		0.45			0	X		0	X
07/11/23 0:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 1:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 2:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 3:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 4:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 5:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 6:00	0	X		0	X		0	X		0.48			0	X		0	X
07/11/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/11/23 16:00	0	X		0	X		0	X		0.45			0	X		0	X
07/11/23 17:00	0	X		0	X		0	X		0.47			0	X		0	X
07/11/23 18:00	0	X		0	X		0	X		0.46			0	X		0	X
07/11/23 19:00	0	X		0	X		0	X		0.54			0	X		0	X
07/11/23 20:00	0	X		0	X		0	X		0.54			0	X		0	X
07/11/23 21:00	0	X		0	X		0	X		0.54			0	X		0	X
07/11/23 22:00	0	X		0	X		0	X		0.49			0	X		0	X
07/11/23 23:00	0	X		0	X		0	X		0.46			0	X		0	X
07/12/23 0:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 1:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 2:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
07/12/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
07/12/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/12/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
07/12/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 13:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 14:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
07/12/23 17:00	0	X		0	X		0	X		0.46			0	X		0	X
07/12/23 18:00	0	X		0	X		0	X		0.49			0	X		0	X
07/12/23 19:00	0	X		0	X		0	X		0.55			0	X		0	X
07/12/23 20:00	0	X		0	X		0	X		0.54			0	X		0	X
07/12/23 21:00	0	X		0	X		0	X		0.54			0	X		0	X
07/12/23 22:00	0	X		0	X		0	X		0.52			0	X		0	X
07/12/23 23:00	0	X		0	X		0	X		0.47			0	X		0	X
07/13/23 0:00	0	X		0	X		0	X		0.49			0	X		0	X
07/13/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
07/13/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
07/13/23 3:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 4:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 5:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 6:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 11:00	0	X		0	X		0	X		0.47			0	X		0	X
07/13/23 12:00	0	X		0	X		0	X		0.44			0	X		0	X
07/13/23 13:00	0	X		0	X		0	X		0.47			0	X		0	X
07/13/23 14:00	0	X		0	X		0	X		0.49			0	X		0	X
07/13/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/13/23 16:00	0	X		0	X		0	X		0.47			0	X		0	X
07/13/23 17:00	0	X		0	X		0	X		0.47			0	X		0	X
07/13/23 18:00	0	X		0	X		0	X		0.51			0	X		0	X
07/13/23 19:00	0	X		0	X		0	X		0.73			0	X		0	X
07/13/23 20:00	0	X		0	X		0	X		0.72			0	X		0	X
07/13/23 21:00	0	X		0	X		0	X		0.65			0	X		0	X
07/13/23 22:00	0	X		0	X		0	X		0.64			0	X		0	X
07/13/23 23:00	0	X		0	X		0	X		0.63			0	X		0	X
07/14/23 0:00	0	X		0	X		0	X		0.62			0	X		0	X
07/14/23 1:00	0	X		0	X		0	X		0.63			0	X		0	X
07/14/23 2:00	0	X		0	X		0	X		0.62			0	X		0	X
07/14/23 3:00	0	X		0	X		0	X		0.62			0	X		0	X
07/14/23 4:00	0	X		0	X		0	X		0.62			0	X		0	X
07/14/23 5:00	0	X		0	X		0	X		0.62			0	X		0	X
07/14/23 6:00	0	X		0	X		0	X		0.63			0	X		0	X
07/14/23 7:00	0	X		0	X		0	X		0.63			0	X		0	X
07/14/23 8:00	0	X		0	X		0	X		0.47			0	X		0	X
07/14/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
07/14/23 10:00	0	X		0	X		0	X		0.44			0	X		0	X
07/14/23 11:00	0	X		0	X		0	X		0.44			0	X		0	X
07/14/23 12:00	0	X		0	X		0	X		0.53			0	X		0	X
07/14/23 13:00	0	X		0	X		0	X		0.66			0	X		0	X
07/14/23 14:00	0	X		0	X		0	X		0.51			0	X		0	X
07/14/23 15:00	0	X		0	X		0	X		0.48			0	X		0	X
07/14/23 16:00	0			0	X		0			0.47			0.18498			0.62	
07/14/23 17:00	0.8			0			1.6			0.63			0.2592			0.86	
07/14/23 18:00	0.3			1			1.3			0.73			0.36762			1.23	
07/14/23 19:00	0.2			1			1.5			0.78			0.38706			1.29	
07/14/23 20:00	0.2			1			1.5			0.77			0.38316			1.28	
07/14/23 21:00	0.3			1			1.5			0.72			0.369			1.23	
07/14/23 22:00	0.5			0			1.5			0.68			0.34998			1.17	
07/14/23 23:00	0.8			0			1.4			0.49			0.26316			0.88	
07/15/23 0:00	0.8			0			1.5			0.54			0.28398			0.95	
07/15/23 1:00	0.7			0			1.5			0.51			0.2739			0.91	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/15/23 2:00	0.7			0			1.5			0.51			0.2706			0.9	
07/15/23 3:00	0.8			0			1.5			0.52			0.27846			0.93	
07/15/23 4:00	0.8			0			1.5			0.52			0.2799			0.93	
07/15/23 5:00	0.8			0			1.5			0.52			0.28026			0.93	
07/15/23 6:00	0.8			0			1.5			0.48			0.25884			0.86	
07/15/23 7:00	0.9			0			1.5			0.43			0.23124			0.77	
07/15/23 8:00	0.9			0			1.5			0.43			0.23082			0.77	
07/15/23 9:00	0.8			0			1.5			0.43			0.23016			0.77	
07/15/23 10:00	0.8			0			1.5			0.43			0.22968			0.77	
07/15/23 11:00	0.8			0			1.5			0.43			0.22926			0.76	
07/15/23 12:00	0.8			0			1.5			0.49			0.249			0.83	
07/15/23 13:00	0.8			0			1.5			0.52			0.26844			0.89	
07/15/23 14:00	0.8			0			1.5			0.5			0.25158			0.84	
07/15/23 15:00	0.7			0			1.5			0.56			0.27588			0.92	
07/15/23 16:00	0.3			1			1.5			0.76			0.37836			1.26	
07/15/23 17:00	0.2			1			1.5			0.76			0.37464			1.25	
07/15/23 18:00	0.2			1			1.5			0.76			0.37332			1.24	
07/15/23 19:00	0.2			1			1.5			0.76			0.37488			1.25	
07/15/23 20:00	0.2			1			1.5			0.78			0.38292			1.28	
07/15/23 21:00	0.2			1			1.5			0.78			0.3897			1.3	
07/15/23 22:00	0.3			1			1.5			0.75			0.38118			1.27	
07/15/23 23:00	0.6			0			1.5			0.64			0.33402			1.11	
07/16/23 0:00	0.9			0			1.5			0.54			0.2844			0.95	
07/16/23 1:00	0.8			0			1.5			0.53			0.28446			0.95	
07/16/23 2:00	0.8			0			1.5			0.53			0.2859			0.95	
07/16/23 3:00	0.8			0			1.5			0.53			0.2853			0.95	
07/16/23 4:00	0.8			0			1.5			0.53			0.28152			0.94	
07/16/23 5:00	0.8			0			1.5			0.53			0.28632			0.95	
07/16/23 6:00	0.9			0			1.5			0.48			0.25554			0.85	
07/16/23 7:00	1			0			1.5			0.43			0.2307			0.77	
07/16/23 8:00	1			0			1.5			0.43			0.2307			0.77	
07/16/23 9:00	0.9			0			1.5			0.43			0.23016			0.77	
07/16/23 10:00	0.8			0			1.5			0.49			0.25476			0.85	
07/16/23 11:00	0.8			0			1.5			0.52			0.26214			0.87	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/16/23 12:00	0.8			0			1.5			0.53			0.25128			0.84	
07/16/23 13:00	0.8			0			1.5			0.53			0.2664			0.89	
07/16/23 14:00	0.4			1			1.6			0.73			0.38016			1.27	
07/16/23 15:00	0.3			1			1.5			0.77			0.39714			1.32	
07/16/23 16:00	0.3			1			1.5			0.76			0.3954			1.32	
07/16/23 17:00	0.2			1			1.5			0.76			0.39666			1.32	
07/16/23 18:00	0.2			1			1.5			0.76			0.39324			1.31	
07/16/23 19:00	0.2			1			1.5			0.76			0.39522			1.32	
07/16/23 20:00	0.4			1			1.5			0.69			0.36324			1.21	
07/16/23 21:00	0.4			1			1.5			0.68			0.35772			1.19	
07/16/23 22:00	0.8			0			1.5			0.5			0.26898			0.9	
07/16/23 23:00	0.8			0			1.5			0.47			0.24954			0.83	
07/17/23 0:00	0.7			0			1.5			0.52			0.2778			0.93	
07/17/23 1:00	0.7			0			1.5			0.52			0.27516			0.92	
07/17/23 2:00	0.8			0			1.5			0.46			0.24324			0.81	
07/17/23 3:00	0.8			0			1.5			0.43			0.2316			0.77	
07/17/23 4:00	0.8			0			1.5			0.44			0.23484			0.78	
07/17/23 5:00	0.7			0			1.5			0.51			0.27174			0.91	
07/17/23 6:00	0.7			0			1.5			0.53			0.28278			0.94	
07/17/23 7:00	0.8			0			1.5			0.44			0.23592			0.79	
07/17/23 8:00	0.8			0			1.5			0.43			0.23064			0.77	
07/17/23 9:00	0.8			0			1.5			0.43			0.22998			0.77	
07/17/23 10:00	0.7			0			1.5			0.48			0.26094			0.87	
07/17/23 11:00	0.7			0			1.5			0.51			0.27306			0.91	
07/17/23 12:00	0.7			0			1.5			0.51			0.26868			0.9	
07/17/23 13:00	0.7			0			1.5			0.53			0.28284			0.94	
07/17/23 14:00	0.7			0			1.5			0.53			0.28146			0.94	
07/17/23 15:00	0.7			0			1.5			0.56			0.29754			0.99	
07/17/23 16:00	0.2			1			1.5			0.76			0.39378			1.31	
07/17/23 17:00	0.5			0			1.5			0.65			0.3396			1.13	
07/17/23 18:00	0.7			0			1.5			0.53			0.2793			0.93	
07/17/23 19:00	0.7			0			1.5			0.52			0.27582			0.92	
07/17/23 20:00	0.7			0			1.5			0.53			0.28092			0.94	
07/17/23 21:00	0.7			0			1.5			0.53			0.28422			0.95	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/17/23 22:00	0.7			0			1.5			0.53			0.28098			0.94	
07/17/23 23:00	0.7			0			1.5			0.52			0.27942			0.93	
07/18/23 0:00	0.7			0			1.5			0.55			0.29448			0.98	
07/18/23 1:00	0.7			0			1.5			0.55			0.2952			0.98	
07/18/23 2:00	0.7			0			1.5			0.54			0.28932			0.96	
07/18/23 3:00	0.7			0			1.5			0.53			0.28302			0.94	
07/18/23 4:00	0.7			0			1.5			0.55			0.29718			0.99	
07/18/23 5:00	0.7			0			1.5			0.56			0.29934			1	
07/18/23 6:00	0.7			0			1.5			0.56			0.29892			1	
07/18/23 7:00	0.8			0			1.5			0.47			0.2532			0.84	
07/18/23 8:00	0.8			0			1.5			0.44			0.23526			0.78	
07/18/23 9:00	0.8			0			1.5			0.47			0.25104			0.84	
07/18/23 10:00	0.7			0			1.5			0.52			0.27942			0.93	
07/18/23 11:00	0.7			0			1.5			0.53			0.28926			0.96	
07/18/23 12:00	0.7			0			1.5			0.55			0.29034			0.97	
07/18/23 13:00	0.7			0			1.5			0.54			0.28866			0.96	
07/18/23 14:00	0.9			0			1.5			0.51			0.2898			0.97	
07/18/23 15:00	0.5			1			1.5			0.67			0.35772			1.19	
07/18/23 16:00	0.5			0			1.5			0.66			0.34674			1.16	
07/18/23 17:00	0.7			0			1.5			0.62			0.3285			1.1	
07/18/23 18:00	0.5			1			1.5			0.69			0.35928			1.2	
07/18/23 19:00	0.2			1			1.5			0.78			0.40818			1.36	
07/18/23 20:00	0.3			1			1.5			0.73			0.38532			1.28	
07/18/23 21:00	0.3			1			1.5			0.72			0.38082			1.27	
07/18/23 22:00	0.5			0			1.5			0.69			0.36318			1.21	
07/18/23 23:00	0.7			0			1.5			0.65			0.34752			1.16	
07/19/23 0:00	1.5			0			1.5			0.55			0.29478			0.98	
07/19/23 1:00	0.7			0			1.5			0.54			0.28866			0.96	
07/19/23 2:00	0.7			0			1.5			0.52			0.28104			0.94	
07/19/23 3:00	0.8			0			1.5			0.51			0.2724			0.91	
07/19/23 4:00	0.7			0			1.5			0.53			0.2829			0.94	
07/19/23 5:00	0.7			0			1.5			0.55			0.29214			0.97	
07/19/23 6:00	0.7			0			1.5			0.55			0.2928			0.98	
07/19/23 7:00	0.8			0			1.5			0.49			0.26466			0.88	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/19/23 8:00	0.8			0			1.5			0.45			0.24234			0.81	
07/19/23 9:00	0.8			0			1.5			0.48			0.25818			0.86	
07/19/23 10:00	0.8			0			1.5			0.47			0.24996			0.83	
07/19/23 11:00	0.7			0			1.5			0.52			0.27744			0.92	
07/19/23 12:00	0.7			0			1.5			0.54			0.28878			0.96	
07/19/23 13:00	0.8			0			1.5			0.57			0.30186			1.01	
07/19/23 14:00	0.2			1			1.5			0.75			0.3894			1.3	
07/19/23 15:00	0.2			1			1.5			0.76			0.39744			1.32	
07/19/23 16:00	0.2			1			1.5			0.76			0.39498			1.32	
07/19/23 17:00	0.2			1			1.5			0.75			0.38946			1.3	
07/19/23 18:00	0.3			1			1.5			0.76			0.39774			1.33	
07/19/23 19:00	0.3			1			1.5			0.78			0.40818			1.36	
07/19/23 20:00	0.2			1			1.5			0.78			0.40902			1.36	
07/19/23 21:00	0.2			1			1.5			0.76			0.39816			1.33	
07/19/23 22:00	0.3			1			1.5			0.73			0.38736			1.29	
07/19/23 23:00	0.6			0			1.5			0.67			0.35568			1.19	
07/20/23 0:00	1.6			0			1.5			0.55			0.2943			0.98	
07/20/23 1:00	0.7			0			1.5			0.53			0.28368			0.95	
07/20/23 2:00	0.7			0			1.4			0.53			0.2862			0.95	
07/20/23 3:00	0.7			0			1.5			0.53			0.28254			0.94	
07/20/23 4:00	0.7			0			1.5			0.54			0.29112			0.97	
07/20/23 5:00	0.7			0			1.5			0.55			0.2931			0.98	
07/20/23 6:00	0.7			0			1.5			0.54			0.28884			0.96	
07/20/23 7:00	0.9			0			1.5			0.45			0.24126			0.8	
07/20/23 8:00	0.9			0			1.5			0.44			0.23238			0.77	
07/20/23 9:00	0.8			0			1.5			0.44			0.2361			0.79	
07/20/23 10:00	0.8			0			1.5			0.47			0.25272			0.84	
07/20/23 11:00	0.8			0			1.5			0.51			0.27192			0.91	
07/20/23 12:00	0.8			0			1.5			0.54			0.28884			0.96	
07/20/23 13:00	0.8			0			1.5			0.54			0.28788			0.96	
07/20/23 14:00	0.8			0			1.5			0.54			0.28608			0.95	
07/20/23 15:00	0.7			1			1.6			0.65			0.34284			1.14	
07/20/23 16:00	0.3			1			1.5			0.75			0.38886			1.3	
07/20/23 17:00	0.3			1			1.5			0.74			0.38736			1.29	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/20/23 18:00	0.3			1			1.5			0.77			0.399			1.33	
07/20/23 19:00	0.3			1			1.5			0.79			0.40896			1.36	
07/20/23 20:00	0.3			1			1.5			0.74			0.38772			1.29	
07/20/23 21:00	0.4			1			1.5			0.71			0.3732			1.24	
07/20/23 22:00	0.6			0			1.5			0.66			0.35064			1.17	
07/20/23 23:00	0.9			0			1.5			0.56			0.2976			0.99	
07/21/23 0:00	0.8			0			1.5			0.53			0.28554			0.95	
07/21/23 1:00	0.8			0			1.5			0.53			0.28536			0.95	
07/21/23 2:00	0.8			0			1.5			0.51			0.27234			0.91	
07/21/23 3:00	0.8			0			1.5			0.5			0.26598			0.89	
07/21/23 4:00	0.8			0			1.5			0.51			0.27168			0.91	
07/21/23 5:00	0.8			0			1.5			0.5			0.26988			0.9	
07/21/23 6:00	0.9			0			1.5			0.51			0.2703			0.9	
07/21/23 7:00	1.2			0			1.5			0.44			0.23742			0.79	
07/21/23 8:00	1			0			1.5			0.43			0.23166			0.77	
07/21/23 9:00	0.9			0			1.5			0.43			0.23148			0.77	
07/21/23 10:00	0.9			0			1.5			0.43			0.23094			0.77	
07/21/23 11:00	0.9			0			1.5			0.48			0.25638			0.85	
07/21/23 12:00	0.9			0			1.5			0.48			0.25296			0.84	
07/21/23 13:00	0.8			0			1.5			0.52			0.27768			0.93	
07/21/23 14:00	0.8			0			1.5			0.56			0.29874			1	
07/21/23 15:00	0.4			1			1.5			0.71			0.37152			1.24	
07/21/23 16:00	0.5			0			1.5			0.67			0.35154			1.17	
07/21/23 17:00	0.6			0			1.5			0.63			0.3327			1.11	
07/21/23 18:00	0.5			1			1.5			0.66			0.34974			1.17	
07/21/23 19:00	0.3			1			1.5			0.76			0.39822			1.33	
07/21/23 20:00	0.4			1			1.5			0.69			0.3642			1.21	
07/21/23 21:00	0.7			0			1.5			0.63			0.33102			1.1	
07/21/23 22:00	0.7			0			1.5			0.64			0.34038			1.13	
07/21/23 23:00	0.8			0			1.5			0.62			0.33174			1.11	
07/22/23 0:00	0.8			0			1.5			0.53			0.28344			0.94	
07/22/23 1:00	0.8			0			1.5			0.5			0.27192			0.91	
07/22/23 2:00	0.9			0			1.5			0.45			0.24264			0.81	
07/22/23 3:00	0.9			0			1.5			0.46			0.24408			0.81	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/22/23 4:00	0.9			0			1.5			0.43			0.23274			0.78	
07/22/23 5:00	0.9			0			1.5			0.46			0.2451			0.82	
07/22/23 6:00	1.5			0			1.5			0.46			0.24504			0.82	
07/22/23 7:00	1.1			0			1.5			0.43			0.23082			0.77	
07/22/23 8:00	1.1			0			1.5			0.43			0.23046			0.77	
07/22/23 9:00	1			0			1.5			0.43			0.23022			0.77	
07/22/23 10:00	0.9			0			1.5			0.43			0.22962			0.77	
07/22/23 11:00	0.9			0			1.5			0.44			0.23268			0.78	
07/22/23 12:00	0.8			0			1.5			0.47			0.24888			0.83	
07/22/23 13:00	0.8			0			1.5			0.48			0.25248			0.84	
07/22/23 14:00	0.8			0			1.5			0.53			0.28062			0.94	
07/22/23 15:00	0.8			0			1.5			0.52			0.27762			0.93	
07/22/23 16:00	0.8			0			1.5			0.52			0.2805			0.94	
07/22/23 17:00	0.6			1			1.5			0.62			0.32916			1.1	
07/22/23 18:00	0.4			1			1.5			0.72			0.37902			1.26	
07/22/23 19:00	0.3			1			1.5			0.76			0.39738			1.32	
07/22/23 20:00	0.5			0			1.5			0.67			0.3504			1.17	
07/22/23 21:00	0.6			0			1.5			0.66			0.34854			1.16	
07/22/23 22:00	0.7			0			1.5			0.65			0.34242			1.14	
07/22/23 23:00	1.1			0			1.5			0.54			0.288			0.96	
07/23/23 0:00	0.9			0			1.5			0.53			0.28536			0.95	
07/23/23 1:00	0.8			0			1.5			0.53			0.28536			0.95	
07/23/23 2:00	0.8			0			1.5			0.53			0.28506			0.95	
07/23/23 3:00	0.8			0			1.5			0.53			0.28566			0.95	
07/23/23 4:00	0.9			0			1.5			0.53			0.2847			0.95	
07/23/23 5:00	0.9			0			1.5			0.51			0.2727			0.91	
07/23/23 6:00	0.8			0			1.5			0.49			0.26166			0.87	
07/23/23 7:00	0.9			0			1.5			0.44			0.23394			0.78	
07/23/23 8:00	0.8			0			1.5			0.49			0.26214			0.87	
07/23/23 9:00	0.8			0			1.5			0.54			0.2868			0.96	
07/23/23 10:00	0.7			0			1.5			0.54			0.28644			0.95	
07/23/23 11:00	0.7			0			1.5			0.54			0.2859			0.95	
07/23/23 12:00	0.7			0			1.5			0.57			0.3009			1	
07/23/23 13:00	0.6			0			1.5			0.64			0.3363			1.12	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/23/23 14:00	0.7			0			1.4			0.56			0.29616			0.99	
07/23/23 15:00	0.7			0			1.5			0.53			0.2814			0.94	
07/23/23 16:00	1.3			0			1.5			0.54			0.28752			0.96	
07/23/23 17:00	0.3			1			1.6			0.76			0.39954			1.33	
07/23/23 18:00	0.4			0			1.4			0.63			0.33492			1.12	
07/23/23 19:00	0.8			0			1.4			0.51			0.27444			0.91	
07/23/23 20:00	0.8			0			1.5			0.5			0.26868			0.9	
07/23/23 21:00	0.7			0			1.5			0.52			0.27588			0.92	
07/23/23 22:00	0.8			0			1.5			0.51			0.27072			0.9	
07/23/23 23:00	0.8			0			1.5			0.48			0.25926			0.86	
07/24/23 0:00	0.7			0			1.5			0.54			0.28992			0.97	
07/24/23 1:00	0.7			0			1.5			0.53			0.28482			0.95	
07/24/23 2:00	0.8			0			1.6			0.51			0.27234			0.91	
07/24/23 3:00	0.8			0			1.5			0.52			0.27648			0.92	
07/24/23 4:00	0.8			0			1.5			0.53			0.28578			0.95	
07/24/23 5:00	0.8			0			1.5			0.53			0.28584			0.95	
07/24/23 6:00	0.7			0			1.5			0.54			0.28872			0.96	
07/24/23 7:00	0.9			0			1.5			0.47			0.25092			0.84	
07/24/23 8:00	0.8			0			1.5			0.44			0.23742			0.79	
07/24/23 9:00	0.8			0			1.5			0.43			0.2319			0.77	
07/24/23 10:00	0.8			0			1.5			0.44			0.23412			0.78	
07/24/23 11:00	0.8			0			1.5			0.44			0.23454			0.78	
07/24/23 12:00	0.8			0			1.5			0.48			0.25434			0.85	
07/24/23 13:00	0.7			0			1.5			0.54			0.28836			0.96	
07/24/23 14:00	0.8			0			1.4			0.44			0.23322			0.78	
07/24/23 15:00	0.8			0			1.5			0.44			0.2304			0.77	
07/24/23 16:00	0.8			0			1.5			0.43			0.22968			0.77	
07/24/23 17:00	0.8			0			1.5			0.43			0.22968			0.77	
07/24/23 18:00	0.8			0			1.5			0.43			0.2304			0.77	
07/24/23 19:00	0.8			0			1.5			0.44			0.23574			0.79	
07/24/23 20:00	0.8			0			1.5			0.44			0.23442			0.78	
07/24/23 21:00	0.8			0			1.5			0.49			0.26172			0.87	
07/24/23 22:00	0.8			0			1.5			0.49			0.26004			0.87	
07/24/23 23:00	0.8			0			1.5			0.5			0.27006			0.9	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/25/23 0:00	0.8			0			1.5			0.47			0.2544			0.85	
07/25/23 1:00	0.9			0			1.5			0.44			0.2337			0.78	
07/25/23 2:00	0.9			0			1.5			0.43			0.23184			0.77	
07/25/23 3:00	0.9			0			1.5			0.43			0.2319			0.77	
07/25/23 4:00	0.9			0			1.5			0.43			0.2322			0.77	
07/25/23 5:00	0.9			0			1.5			0.46			0.24996			0.83	
07/25/23 6:00	0.8			0			1.5			0.47			0.25464			0.85	
07/25/23 7:00	0.9			0			1.5			0.44			0.23628			0.79	
07/25/23 8:00	0.9			0			1.5			0.46			0.24528			0.82	
07/25/23 9:00	0.9			0			1.5			0.43			0.2325			0.78	
07/25/23 10:00	0.9			0			1.5			0.44			0.23646			0.79	
07/25/23 11:00	0.9			0			1.5			0.43			0.2322			0.77	
07/25/23 12:00	0.8			0			1.5			0.5			0.26706			0.89	
07/25/23 13:00	0.8			0			1.5			0.51			0.27042			0.9	
07/25/23 14:00	0.8			0			1.5			0.54			0.28434			0.95	
07/25/23 15:00	0.8			0			1.5			0.51			0.27108			0.9	
07/25/23 16:00	0.9			0			1.5			0.56			0.29556			0.99	
07/25/23 17:00	0.7			0			1.5			0.65			0.34368			1.15	
07/25/23 18:00	0.6			0			1.5			0.67			0.35046			1.17	
07/25/23 19:00	0.3			1			1.5			0.77			0.40518			1.35	
07/25/23 20:00	0.3			1			1.5			0.72			0.37974			1.27	
07/25/23 21:00	0.7			0			1.5			0.65			0.34248			1.14	
07/25/23 22:00	0.9			0			1.5			0.63			0.33384			1.11	
07/25/23 23:00	0.8			0			1.5			0.53			0.28308			0.94	
07/26/23 0:00	0.8			0			1.5			0.55			0.29388			0.98	
07/26/23 1:00	0.8			0			1.5			0.51			0.27408			0.91	
07/26/23 2:00	0.8			0			1.5			0.52			0.27678			0.92	
07/26/23 3:00	0.8			0			1.5			0.52			0.27954			0.93	
07/26/23 4:00	0.8			0			1.5			0.52			0.27942			0.93	
07/26/23 5:00	0.8			0			1.5			0.54			0.29214			0.97	
07/26/23 6:00	0.8			0			1.5			0.54			0.28842			0.96	
07/26/23 7:00	0.8			0			1.5			0.5			0.26766			0.89	
07/26/23 8:00	0.8			0			1.5			0.5			0.26454			0.88	
07/26/23 9:00	0.8			0			1.5			0.53			0.28194			0.94	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/26/23 10:00	0.8			0			1.5			0.54			0.28704			0.96	
07/26/23 11:00	0.7			0			1.5			0.55			0.29178			0.97	
07/26/23 12:00	0.8			0			1.5			0.54			0.28812			0.96	
07/26/23 13:00	0.3			1			1.5			0.76			0.39714			1.32	
07/26/23 14:00	0.3			1			1.5			0.76			0.3981			1.33	
07/26/23 15:00	0.2			1			1.5			0.74			0.38586			1.29	
07/26/23 16:00	0.2			1			1.5			0.75			0.39102			1.3	
07/26/23 17:00	0.2			1			1.5			0.75			0.3915			1.31	
07/26/23 18:00	0.5			0			1.5			0.67			0.3531			1.18	
07/26/23 19:00	0.3			1			1.5			0.74			0.38562			1.29	
07/26/23 20:00	0.8			0			1.5			0.62			0.32988			1.1	
07/26/23 21:00	0.7			0			1.5			0.65			0.34386			1.15	
07/26/23 22:00	0.3			1			1.5			0.72			0.38202			1.27	
07/26/23 23:00	0.7			0			1.5			0.67			0.35316			1.18	
07/27/23 0:00	0.3			1			1.5			0.75			0.39666			1.32	
07/27/23 1:00	0.8			0			1.5			0.57			0.30366			1.01	
07/27/23 2:00	0.8			0			1.5			0.51			0.2721			0.91	
07/27/23 3:00	0.8			0			1.5			0.47			0.25044			0.83	
07/27/23 4:00	0.8			0			1.5			0.54			0.29232			0.97	
07/27/23 5:00	0.8			0			1.5			0.55			0.29772			0.99	
07/27/23 6:00	0.8			0			1.5			0.55			0.29514			0.98	
07/27/23 7:00	0.9			0			1.5			0.45			0.24072			0.8	
07/27/23 8:00	0.9			0			1.5			0.43			0.2316			0.77	
07/27/23 9:00	0.9			0			1.5			0.43			0.23142			0.77	
07/27/23 10:00	0.9			0			1.5			0.43			0.23118			0.77	
07/27/23 11:00	0.8			0			1.5			0.45			0.2385			0.8	
07/27/23 12:00	0.7			0			1.5			0.53			0.28074			0.94	
07/27/23 13:00	0.7			0			1.5			0.54			0.28446			0.95	
07/27/23 14:00	0.7			0			1.5			0.52			0.27504			0.92	
07/27/23 15:00	0.7			0			1.5			0.51			0.27024			0.9	
07/27/23 16:00	0.9			0			1.5			0.59			0.31272			1.04	
07/27/23 17:00	0.8			0			1.5			0.62			0.32868			1.1	
07/27/23 18:00	0.8			0			1.4			0.46			0.24306			0.81	
07/27/23 19:00	0.8			0			1.5			0.44			0.23172			0.77	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/27/23 20:00	0.8			0			1.5			0.44			0.23514			0.78	
07/27/23 21:00	0.8			0			1.5			0.43			0.23106			0.77	
07/27/23 22:00	0.8			0			1.5			0.5			0.26598			0.89	
07/27/23 23:00	0.7			0			1.5			0.52			0.28122			0.94	
07/28/23 0:00	0.8			0			1.5			0.49			0.26352			0.88	
07/28/23 1:00	0.7			0			1.5			0.51			0.27624			0.92	
07/28/23 2:00	0.8			0			1.4			0.5			0.26568			0.89	
07/28/23 3:00	0.8			0			1.5			0.49			0.26148			0.87	
07/28/23 4:00	0.8			0			1.5			0.48			0.25836			0.86	
07/28/23 5:00	0.8			0			1.5			0.51			0.2712			0.9	
07/28/23 6:00	0.8			0			1.5			0.5			0.26664			0.89	
07/28/23 7:00	0.9			0			1.5			0.45			0.24216			0.81	
07/28/23 8:00	0.9			0			1.5			0.43			0.23196			0.77	
07/28/23 9:00	0.9			0			1.5			0.43			0.23184			0.77	
07/28/23 10:00	0.8			0			1.5			0.43			0.23136			0.77	
07/28/23 11:00	0.9			0			1.5			0.43			0.23124			0.77	
07/28/23 12:00	0.8			0			1.5			0.44			0.23304			0.78	
07/28/23 13:00	0.7			0			1.5			0.52			0.2757			0.92	
07/28/23 14:00	0.8			0			1.5			0.44			0.23172			0.77	
07/28/23 15:00	0.9			0			1.5			0.5			0.26466			0.88	
07/28/23 16:00	0.9			0			1.5			0.62			0.3267			1.09	
07/28/23 17:00	0.9			0			1.5			0.62			0.32616			1.09	
07/28/23 18:00	0.9			0			1.5			0.61			0.32586			1.09	
07/28/23 19:00	0.9			0			1.5			0.61			0.32448			1.08	
07/28/23 20:00	0.9			0			1.5			0.45			0.24096			0.8	
07/28/23 21:00	0.8			0			1.5			0.46			0.2436			0.81	
07/28/23 22:00	0.8			0			1.5			0.49			0.2646			0.88	
07/28/23 23:00	0.8			0			1.5			0.52			0.27942			0.93	
07/29/23 0:00	0.7			0			1.5			0.52			0.27984			0.93	
07/29/23 1:00	0.9			0			1.5			0.45			0.2388			0.8	
07/29/23 2:00	0.8			0			1.5			0.44			0.2385			0.8	
07/29/23 3:00	0.9			0			1.5			0.45			0.23922			0.8	
07/29/23 4:00	0.9			0			1.5			0.43			0.23232			0.77	
07/29/23 5:00	0.9			0			1.5			0.43			0.23334			0.78	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/29/23 6:00	0.9			0			1.5			0.44			0.237			0.79	
07/29/23 7:00	0.9			0			1.5			0.43			0.23208			0.77	
07/29/23 8:00	0.9			0			1.5			0.43			0.23178			0.77	
07/29/23 9:00	0.9			0			1.5			0.43			0.23136			0.77	
07/29/23 10:00	0.9			0			1.5			0.43			0.231			0.77	
07/29/23 11:00	0.8			0			1.5			0.43			0.23052			0.77	
07/29/23 12:00	0.8			0			1.5			0.43			0.2301			0.77	
07/29/23 13:00	0.8			0			1.5			0.43			0.22986			0.77	
07/29/23 14:00	0.8			0			1.5			0.43			0.22944			0.76	
07/29/23 15:00	0.8			0			1.5			0.43			0.22908			0.76	
07/29/23 16:00	0.8			0			1.5			0.44			0.23136			0.77	
07/29/23 17:00	0.8			0			1.5			0.43			0.22908			0.76	
07/29/23 18:00	0.8			0			1.5			0.43			0.22956			0.77	
07/29/23 19:00	0.8			0			1.5			0.43			0.22992			0.77	
07/29/23 20:00	0.8			0			1.5			0.43			0.23064			0.77	
07/29/23 21:00	0.8			0			1.5			0.43			0.231			0.77	
07/29/23 22:00	0.8			0			1.5			0.43			0.23148			0.77	
07/29/23 23:00	0.8			0			1.5			0.45			0.24			0.8	
07/30/23 0:00	0.8			0			1.5			0.43			0.23184			0.77	
07/30/23 1:00	0.8			0			1.5			0.43			0.2319			0.77	
07/30/23 2:00	0.9			0			1.5			0.43			0.23202			0.77	
07/30/23 3:00	0.9			0			1.5			0.43			0.23208			0.77	
07/30/23 4:00	0.9			0			1.5			0.43			0.2325			0.78	
07/30/23 5:00	0.9			0			1.5			0.44			0.23622			0.79	
07/30/23 6:00	0.9			0			1.5			0.43			0.23256			0.78	
07/30/23 7:00	0.9			0			1.5			0.43			0.23244			0.77	
07/30/23 8:00	0.9			0			1.5			0.43			0.23202			0.77	
07/30/23 9:00	0.9			0			1.5			0.43			0.2316			0.77	
07/30/23 10:00	0.9			0			1.5			0.43			0.2313			0.77	
07/30/23 11:00	0.9			0			1.5			0.43			0.23088			0.77	
07/30/23 12:00	0.8			0			1.5			0.43			0.23022			0.77	
07/30/23 13:00	0.8			0			1.5			0.43			0.22986			0.77	
07/30/23 14:00	0.8			0			1.5			0.44			0.234			0.78	
07/30/23 15:00	0.8			0			1.5			0.43			0.22938			0.76	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/30/23 16:00	0.8			0			1.5			0.43			0.22986			0.77	
07/30/23 17:00	0.8			0			1.5			0.45			0.23586			0.79	
07/30/23 18:00	0.8			0			1.5			0.44			0.2337			0.78	
07/30/23 19:00	0.8			0			1.5			0.43			0.23004			0.77	
07/30/23 20:00	0.8			0			1.5			0.43			0.22986			0.77	
07/30/23 21:00	0.9			0			1.5			0.43			0.23214			0.77	
07/30/23 22:00	0.8			0			1.5			0.43			0.23058			0.77	
07/30/23 23:00	0.8			0			1.5			0.43			0.23082			0.77	
07/31/23 0:00	0.9			0			1.5			0.45			0.24228			0.81	
07/31/23 1:00	0.9			0			1.5			0.43			0.23142			0.77	
07/31/23 2:00	0.9			0			1.5			0.44			0.23394			0.78	
07/31/23 3:00	0.9			0			1.5			0.43			0.23148			0.77	
07/31/23 4:00	0.9			0			1.5			0.44			0.23496			0.78	
07/31/23 5:00	0.9			0			1.5			0.46			0.24546			0.82	
07/31/23 6:00	0.8			0			1.5			0.51			0.2742			0.91	
07/31/23 7:00	0.9			0			1.5			0.44			0.23676			0.79	
07/31/23 8:00	0.9			0			1.5			0.43			0.23178			0.77	
07/31/23 9:00	0.9			0			1.5			0.43			0.23142			0.77	
07/31/23 10:00	0.8			0			1.5			0.45			0.24174			0.81	
07/31/23 11:00	0.8			0			1.5			0.55			0.2958			0.99	
07/31/23 12:00	0.8			0			1.5			0.55			0.29256			0.98	
07/31/23 13:00	0.6			1			1.5			0.72			0.37638			1.25	
07/31/23 14:00	0.3			1			1.5			0.71			0.37302			1.24	
07/31/23 15:00	0.5			0			1.5			0.69			0.36144			1.2	
07/31/23 16:00	0.4			0			1.5			0.68			0.35802			1.19	
07/31/23 17:00	0.7			0			1.5			0.64			0.33606			1.12	
07/31/23 18:00	0.8			0			1.5			0.62			0.3273			1.09	
07/31/23 19:00	0.8			0			1.5			0.63			0.33258			1.11	
07/31/23 20:00	0.9			0			1.5			0.62			0.32934			1.1	
07/31/23 21:00	1			0			1.5			0.58			0.30942			1.03	
07/31/23 22:00	0.8			0			1.4			0.49			0.26472			0.88	
07/31/23 23:00	0.7			0			1.5			0.53			0.28368			0.95	
08/01/23 0:00	0.8			0			1.5			0.49			0.26082			0.87	
08/01/23 1:00	0.8			0			1.5			0.46			0.24726			0.82	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/01/23 2:00	0.8			0			1.6			0.48			0.2565			0.86	
08/01/23 3:00	0.8			0			1.5			0.47			0.25302			0.84	
08/01/23 4:00	0.8			0			1.5			0.48			0.25524			0.85	
08/01/23 5:00	0.8			0			1.5			0.51			0.27294			0.91	
08/01/23 6:00	0.8			0			1.5			0.52			0.27864			0.93	
08/01/23 7:00	0.9			0			1.5			0.47			0.25152			0.84	
08/01/23 8:00	0.9			0			1.5			0.43			0.23034			0.77	
08/01/23 9:00	0.8			0			1.5			0.5			0.2682			0.89	
08/01/23 10:00	0.8			0			1.5			0.47			0.2514			0.84	
08/01/23 11:00	0.8			0			1.5			0.51			0.2718			0.91	
08/01/23 12:00	0.8			0			1.5			0.51			0.27318			0.91	
08/01/23 13:00	0.8			0			1.5			0.51			0.27318			0.91	
08/01/23 14:00	0.7			0			1.5			0.51			0.27342			0.91	
08/01/23 15:00	0.8			0			1.5			0.5			0.26754			0.89	
08/01/23 16:00	0.7			0			1.5			0.51			0.27276			0.91	
08/01/23 17:00	0.7			0			1.5			0.5			0.26718			0.89	
08/01/23 18:00	0.8			0			1.5			0.47			0.2514			0.84	
08/01/23 19:00	0.7			0			1.5			0.5			0.26646			0.89	
08/01/23 20:00	0.8			0			1.5			0.51			0.27162			0.91	
08/01/23 21:00	0.8			0			1.5			0.5			0.26988			0.9	
08/01/23 22:00	0.8			0			1.5			0.5			0.26862			0.9	
08/01/23 23:00	0.9			0			1.5			0.43			0.23244			0.77	
08/02/23 0:00	0.8			0			1.5			0.49			0.26568			0.89	
08/02/23 1:00	0.8			0			1.5			0.49			0.26556			0.89	
08/02/23 2:00	0.8			0			1.5			0.47			0.25296			0.84	
08/02/23 3:00	0.8			0			1.5			0.5			0.2682			0.89	
08/02/23 4:00	0.8			0			1.5			0.5			0.27114			0.9	
08/02/23 5:00	0.8			0			1.5			0.51			0.27306			0.91	
08/02/23 6:00	0.8			0			1.5			0.51			0.27216			0.91	
08/02/23 7:00	0.9			0			1.5			0.43			0.23292			0.78	
08/02/23 8:00	0.9			0			1.5			0.42			0.2238			0.75	
08/02/23 9:00	0.9			0			1.5			0.42			0.22356			0.75	
08/02/23 10:00	0.9			0			1.5			0.43			0.22842			0.76	
08/02/23 11:00	0.8			0			1.5			0.42			0.22242			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/02/23 12:00	0.8			0			1.5			0.42			0.2229			0.74	
08/02/23 13:00	0.8			0			1.5			0.48			0.25458			0.85	
08/02/23 14:00	0.8			0			1.4			0.42			0.22296			0.74	
08/02/23 15:00	0.8			0			1.5			0.42			0.22272			0.74	
08/02/23 16:00	0.8			0			1.5			0.42			0.22272			0.74	
08/02/23 17:00	0.8			0			1.5			0.44			0.23346			0.78	
08/02/23 18:00	0.8			0			1.5			0.42			0.22386			0.75	
08/02/23 19:00	0.8			0			1.5			0.46			0.24726			0.82	
08/02/23 20:00	0.8			0			1.5			0.47			0.25158			0.84	
08/02/23 21:00	0.8			0			1.5			0.47			0.25146			0.84	
08/02/23 22:00	0.8			0			1.5			0.47			0.25422			0.85	
08/02/23 23:00	0.9			0			1.5			0.42			0.22368			0.75	
08/03/23 0:00	0.8			0			1.5			0.47			0.2517			0.84	
08/03/23 1:00	0.8			0			1.5			0.44			0.23868			0.8	
08/03/23 2:00	0.9			0			1.5			0.43			0.23124			0.77	
08/03/23 3:00	0.9			0			1.5			0.44			0.2361			0.79	
08/03/23 4:00	0.9			0			1.5			0.42			0.22416			0.75	
08/03/23 5:00	0.8			0			1.5			0.46			0.24864			0.83	
08/03/23 6:00	0.8			0			1.5			0.47			0.2547			0.85	
08/03/23 7:00	0.9			0			1.5			0.42			0.22356			0.75	
08/03/23 8:00	0.9			0			1.5			0.42			0.22338			0.74	
08/03/23 9:00	0.9			0			1.5			0.42			0.2232			0.74	
08/03/23 10:00	0.9			0			1.5			0.42			0.22296			0.74	
08/03/23 11:00	0.9			0			1.5			0.42			0.22272			0.74	
08/03/23 12:00	0.9			0			1.5			0.42			0.2223			0.74	
08/03/23 13:00	0.9			0			1.5			0.42			0.22194			0.74	
08/03/23 14:00	0.8			0			1.5			0.42			0.22152			0.74	
08/03/23 15:00	0.8			0			1.5			0.42			0.2214			0.74	
08/03/23 16:00	0.8			0			1.5			0.42			0.2214			0.74	
08/03/23 17:00	0.8			0			1.5			0.42			0.22116			0.74	
08/03/23 18:00	0.8			0			1.5			0.43			0.2265			0.76	
08/03/23 19:00	0.8			0			1.5			0.45			0.23886			0.8	
08/03/23 20:00	0.8			0			1.5			0.44			0.23538			0.78	
08/03/23 21:00	0.8			0			1.5			0.44			0.23478			0.78	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/03/23 22:00	0.9			0			1.5			0.43			0.23148			0.77	
08/03/23 23:00	0.9			0			1.5			0.41			0.2229			0.74	
08/04/23 0:00	0.9			0			1.5			0.41			0.2232			0.74	
08/04/23 1:00	0.9			0			1.5			0.42			0.22332			0.74	
08/04/23 2:00	0.9			0			1.5			0.42			0.22362			0.75	
08/04/23 3:00	0.9			0			1.5			0.42			0.2238			0.75	
08/04/23 4:00	0.9			0			1.5			0.42			0.22368			0.75	
08/04/23 5:00	0.9			0			1.5			0.43			0.22998			0.77	
08/04/23 6:00	0.9			0			1.5			0.44			0.234			0.78	
08/04/23 7:00	0.9			0			1.5			0.42			0.22356			0.75	
08/04/23 8:00	0.9			0			1.5			0.42			0.22344			0.74	
08/04/23 9:00	0.9			0			1.5			0.42			0.22302			0.74	
08/04/23 10:00	0.9			0			1.5			0.42			0.22278			0.74	
08/04/23 11:00	0.9			0			1.5			0.42			0.22254			0.74	
08/04/23 12:00	0.9			0			1.5			0.42			0.22218			0.74	
08/04/23 13:00	0.9			0			1.5			0.42			0.22182			0.74	
08/04/23 14:00	0.8			0			1.5			0.42			0.2214			0.74	
08/04/23 15:00	0.9			0			1.5			0.42			0.22116			0.74	
08/04/23 16:00	0.8			0			1.5			0.42			0.2211			0.74	
08/04/23 17:00	0.8			0			1.5			0.43			0.22596			0.75	
08/04/23 18:00	0.9			0			1.5			0.52			0.2757			0.92	
08/04/23 19:00	0.9			0			1.5			0.6			0.31632			1.05	
08/04/23 20:00	1			0			1.5			0.59			0.31566			1.05	
08/04/23 21:00	0.8			0			1.5			0.57			0.30414			1.01	
08/04/23 22:00	0.8			0			1.5			0.48			0.25836			0.86	
08/04/23 23:00	0.9			0			1.5			0.44			0.23574			0.79	
08/05/23 0:00	0.8			0			1.5			0.5			0.26808			0.89	
08/05/23 1:00	0.8			0			1.5			0.49			0.26448			0.88	
08/05/23 2:00	0.8			0			1.5			0.5			0.26898			0.9	
08/05/23 3:00	0.8			0			1.5			0.5			0.26736			0.89	
08/05/23 4:00	0.9			0			1.5			0.47			0.25116			0.84	
08/05/23 5:00	1			0			1.5			0.43			0.22956			0.77	
08/05/23 6:00	1.1			0			1.5			0.44			0.2373			0.79	
08/05/23 7:00	1			0			1.5			0.42			0.22278			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/05/23 8:00	0.9			0			1.5			0.42			0.22248			0.74	
08/05/23 9:00	0.9			0			1.5			0.42			0.22212			0.74	
08/05/23 10:00	0.9			0			1.5			0.41			0.22176			0.74	
08/05/23 11:00	0.9			0			1.5			0.41			0.2214			0.74	
08/05/23 12:00	0.9			0			1.5			0.42			0.22128			0.74	
08/05/23 13:00	0.9			0			1.5			0.42			0.22122			0.74	
08/05/23 14:00	0.9			0			1.5			0.45			0.23628			0.79	
08/05/23 15:00	0.8			0			1.5			0.46			0.24564			0.82	
08/05/23 16:00	0.9			0			1.4			0.42			0.22236			0.74	
08/05/23 17:00	0.9			0			1.5			0.47			0.25266			0.84	
08/05/23 18:00	0.8			0			1.5			0.6			0.31812			1.06	
08/05/23 19:00	0.7			0			1.5			0.61			0.3243			1.08	
08/05/23 20:00	0.8			0			1.5			0.6			0.3171			1.06	
08/05/23 21:00	0.9			0			1.5			0.56			0.29856			1	
08/05/23 22:00	0.9			0			1.5			0.47			0.2508			0.84	
08/05/23 23:00	0.9			0			1.5			0.45			0.2397			0.8	
08/06/23 0:00	0.9			0			1.5			0.46			0.24522			0.82	
08/06/23 1:00	0.9			0			1.5			0.44			0.23466			0.78	
08/06/23 2:00	0.9			0			1.5			0.44			0.23448			0.78	
08/06/23 3:00	1.1			0			1.5			0.42			0.2232			0.74	
08/06/23 4:00	1.2			0			1.5			0.42			0.22578			0.75	
08/06/23 5:00	1.2			0			1.5			0.45			0.24156			0.81	
08/06/23 6:00	1.1			0			1.4			0.44			0.23778			0.79	
08/06/23 7:00	1.2			0			1.5			0.42			0.22266			0.74	
08/06/23 8:00	1.1			0			1.5			0.46			0.24714			0.82	
08/06/23 9:00	1			0			1.5			0.41			0.22152			0.74	
08/06/23 10:00	0.9			0			1.5			0.41			0.22134			0.74	
08/06/23 11:00	0.9			0			1.5			0.41			0.22092			0.74	
08/06/23 12:00	0.9			0			1.5			0.45			0.2346			0.78	
08/06/23 13:00	0.8			0			1.5			0.49			0.26274			0.88	
08/06/23 14:00	0.8			0			1.5			0.52			0.27558			0.92	
08/06/23 15:00	0.7			0			1.5			0.51			0.27192			0.91	
08/06/23 16:00	0.8			0			1.5			0.49			0.2589			0.86	
08/06/23 17:00	0.8			0			1.5			0.5			0.26856			0.9	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/06/23 18:00	0.7			0			1.5			0.61			0.32262			1.08	
08/06/23 19:00	0.5			0			1.5			0.64			0.33564			1.12	
08/06/23 20:00	0.5			0			1.5			0.64			0.3384			1.13	
08/06/23 21:00	0.8			0			1.5			0.58			0.30912			1.03	
08/06/23 22:00	0.8			0			1.5			0.5			0.26646			0.89	
08/06/23 23:00	0.9			0			1.5			0.45			0.24114			0.8	
08/07/23 0:00	0.9			0			1.5			0.48			0.2559			0.85	
08/07/23 1:00	0.9			0			1.5			0.44			0.23514			0.78	
08/07/23 2:00	0.9			0			1.5			0.42			0.22638			0.75	
08/07/23 3:00	0.9			0			1.6			0.41			0.22224			0.74	
08/07/23 4:00	0.9			0			1.5			0.45			0.24228			0.81	
08/07/23 5:00	0.8			0			1.5			0.5			0.27012			0.9	
08/07/23 6:00	0.8			0			1.5			0.5			0.26886			0.9	
08/07/23 7:00	1.1			0			1.5			0.43			0.2292			0.76	
08/07/23 8:00	1			0			1.5			0.42			0.22332			0.74	
08/07/23 9:00	0.9			0			1.5			0.47			0.24876			0.83	
08/07/23 10:00	1			0			1.5			0.49			0.25962			0.87	
08/07/23 11:00	1.4			0			1.5			0.53			0.27948			0.93	
08/07/23 12:00	0.5			0			1.5			0.65			0.34254			1.14	
08/07/23 13:00	0.8			0			1.5			0.51			0.2715			0.91	
08/07/23 14:00	0.8			0			1.5			0.51			0.2703			0.9	
08/07/23 15:00	0.7			0			1.1			0.51			0.27162			0.91	
08/07/23 16:00	0.6			1			1			0.59			0.30828			1.03	
08/07/23 17:00	0.4			1			1			0.63			0.33348			1.11	
08/07/23 18:00	0.4			0			1.3			0.64			0.3369			1.12	
08/07/23 19:00	0.1			1			1.5			0.71			0.3705			1.24	
08/07/23 20:00	0.4			0			1.5			0.64			0.33792			1.13	
08/07/23 21:00	0.5			0			1.5			0.64			0.33768			1.13	
08/07/23 22:00	0.5			0			1.5			0.65			0.34458			1.15	
08/07/23 23:00	0.7			0			1.5			0.48			0.258			0.86	
08/08/23 0:00	0.7			0			1.5			0.49			0.2613			0.87	
08/08/23 1:00	0.7			0			1.5			0.48			0.25866			0.86	
08/08/23 2:00	0.7			0			1.5			0.47			0.25224			0.84	
08/08/23 3:00	0.7			0			1.5			0.46			0.24714			0.82	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/08/23 4:00	0.7			0			1.5			0.44			0.23814			0.79	
08/08/23 5:00	0.6			0			1.5			0.49			0.26394			0.88	
08/08/23 6:00	0.7			0			1.5			0.5			0.2667			0.89	
08/08/23 7:00	0.8			0			1.5			0.42			0.2235			0.75	
08/08/23 8:00	0.8			0			1.5			0.42			0.22344			0.74	
08/08/23 9:00	0.8			0			1.6			0.42			0.22332			0.74	
08/08/23 10:00	0.8			0			1.5			0.42			0.22308			0.74	
08/08/23 11:00	0.7			0			1.5			0.42			0.22266			0.74	
08/08/23 12:00	0.7			0			1.5			0.42			0.22218			0.74	
08/08/23 13:00	0.7			0			1.4			0.42			0.22176			0.74	
08/08/23 14:00	0.7			0			1.5			0.43			0.2277			0.76	
08/08/23 15:00	0.7			0			1.5			0.42			0.22296			0.74	
08/08/23 16:00	0.7			0			1.5			0.42			0.22314			0.74	
08/08/23 17:00	0.7			0			1.5			0.43			0.22662			0.76	
08/08/23 18:00	0.7			0			1.5			0.45			0.24186			0.81	
08/08/23 19:00	0.6			0			1.5			0.52			0.27804			0.93	
08/08/23 20:00	0.7			0			1.5			0.46			0.24732			0.82	
08/08/23 21:00	0.7			0			1.5			0.44			0.2367			0.79	
08/08/23 22:00	0.7			0			1.5			0.44			0.2361			0.79	
08/08/23 23:00	0.7			0			1.5			0.42			0.22326			0.74	
08/09/23 0:00	0.7			0			1.5			0.42			0.22326			0.74	
08/09/23 1:00	0.8			0			1.5			0.42			0.22344			0.74	
08/09/23 2:00	0.8			0			1.5			0.42			0.22362			0.75	
08/09/23 3:00	0.8			0			1.5			0.42			0.22362			0.75	
08/09/23 4:00	0.8			0			1.5			0.42			0.2238			0.75	
08/09/23 5:00	0.8			0			1.5			0.42			0.22704			0.76	
08/09/23 6:00	0.8			0			1.5			0.42			0.22854			0.76	
08/09/23 7:00	0.8			0			1.5			0.42			0.2238			0.75	
08/09/23 8:00	0.8			0			1.5			0.42			0.22344			0.74	
08/09/23 9:00	0.8			0			1.5			0.42			0.22308			0.74	
08/09/23 10:00	0.8			0			1.5			0.42			0.22296			0.74	
08/09/23 11:00	0.8			0			1.5			0.42			0.2226			0.74	
08/09/23 12:00	0.8			0			1.5			0.42			0.22248			0.74	
08/09/23 13:00	0.7			0			1.5			0.44			0.2367			0.79	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/09/23 14:00	0.7			0			1.5			0.46			0.2427			0.81	
08/09/23 15:00	0.7			0			1.5			0.49			0.2574			0.86	
08/09/23 16:00	0.7			0			1.5			0.51			0.26916			0.9	
08/09/23 17:00	0.7			0			1.5			0.47			0.2478			0.83	
08/09/23 18:00	1			0			1.5			0.49			0.2604			0.87	
08/09/23 19:00	0.9			0			1.5			0.59			0.31416			1.05	
08/09/23 20:00	0.9			0			1.5			0.52			0.27834			0.93	
08/09/23 21:00	0.7			0			1.5			0.48			0.2559			0.85	
08/09/23 22:00	0.7			0			1.5			0.45			0.23976			0.8	
08/09/23 23:00	0.8			0			1.5			0.41			0.2223			0.74	
08/10/23 0:00	0.8			0			1.5			0.41			0.22242			0.74	
08/10/23 1:00	0.8			0			1.5			0.42			0.22278			0.74	
08/10/23 2:00	0.8			0			1.5			0.42			0.22278			0.74	
08/10/23 3:00	0.8			0			1.5			0.42			0.22314			0.74	
08/10/23 4:00	0.8			0			1.5			0.42			0.2232			0.74	
08/10/23 5:00	0.8			0			1.5			0.42			0.22488			0.75	
08/10/23 6:00	0.7			0			1.5			0.48			0.25692			0.86	
08/10/23 7:00	0.8			0			1.5			0.43			0.2307			0.77	
08/10/23 8:00	0.8			0			1.5			0.42			0.22326			0.74	
08/10/23 9:00	0.8			0			1.5			0.42			0.22308			0.74	
08/10/23 10:00	0.8			0			1.5			0.42			0.2229			0.74	
08/10/23 11:00	0.8			0			1.5			0.42			0.22254			0.74	
08/10/23 12:00	0.7			0			1.5			0.42			0.2217			0.74	
08/10/23 13:00	0.7			0			1.5			0.43			0.23028			0.77	
08/10/23 14:00	0.7			0			1.5			0.42			0.22128			0.74	
08/10/23 15:00	0.8			0			1.5			0.46			0.24432			0.81	
08/10/23 16:00	0.7			0			1.5			0.51			0.27096			0.9	
08/10/23 17:00	0.7			0			1.5			0.43			0.22758			0.76	
08/10/23 18:00	0.7			0			1.5			0.44			0.23448			0.78	
08/10/23 19:00	0.7			0			1.5			0.43			0.2265			0.76	
08/10/23 20:00	0.8			0			1.5			0.43			0.23124			0.77	
08/10/23 21:00	0.7			0			1.5			0.43			0.2295			0.77	
08/10/23 22:00	0.8			0			1.5			0.43			0.23136			0.77	
08/10/23 23:00	0.7			0			1.5			0.46			0.24714			0.82	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/11/23 0:00	1			0			1.5			0.59			0.31986			1.07	
08/11/23 1:00	0.7			0			1.5			0.53			0.28314			0.94	
08/11/23 2:00	0.7			0			1.5			0.5			0.2709			0.9	
08/11/23 3:00	0.7			0			1.5			0.49			0.26118			0.87	
08/11/23 4:00	0.7			0			1.5			0.49			0.2607			0.87	
08/11/23 5:00	0.7			0			1.5			0.49			0.26292			0.88	
08/11/23 6:00	0.7			0			1.5			0.51			0.27342			0.91	
08/11/23 7:00	0.7			0			1.5			0.53			0.28404			0.95	
08/11/23 8:00	1.3			0			1.5			0.59			0.3129			1.04	
08/11/23 9:00	0.5			0			1.5			0.65			0.34542			1.15	
08/11/23 10:00	0.3			1			1.5			0.71			0.3723			1.24	
08/11/23 11:00	0.1			1			1.5			0.76			0.39774			1.33	
08/11/23 12:00	0.7			0			1.5			0.58			0.30594			1.02	
08/11/23 13:00	0.7			0			1.4			0.42			0.22332			0.74	
08/11/23 14:00	0.7			0			1.5			0.42			0.22302			0.74	
08/11/23 15:00	0.7			0			1.5			0.42			0.22272			0.74	
08/11/23 16:00	0.7			0			1.5			0.42			0.22248			0.74	
08/11/23 17:00	0.7			0			1.5			0.43			0.22872			0.76	
08/11/23 18:00	0.8			0			1.6			0.55			0.2952			0.98	
08/11/23 19:00	0.8			0			1.5			0.59			0.31374			1.05	
08/11/23 20:00	1			0			1.5			0.59			0.312			1.04	
08/11/23 21:00	1			0			1.5			0.59			0.31134			1.04	
08/11/23 22:00	1			0			1.5			0.58			0.3123			1.04	
08/11/23 23:00	1			0			1.5			0.58			0.31122			1.04	
08/12/23 0:00	0.8			0			1.4			0.46			0.24396			0.81	
08/12/23 1:00	0.8			0			1.5			0.42			0.22518			0.75	
08/12/23 2:00	0.8			0			1.5			0.42			0.2238			0.75	
08/12/23 3:00	0.8			0			1.5			0.42			0.22374			0.75	
08/12/23 4:00	0.8			0			1.5			0.42			0.22386			0.75	
08/12/23 5:00	0.8			0			1.5			0.42			0.22386			0.75	
08/12/23 6:00	0.8			0			1.5			0.42			0.22488			0.75	
08/12/23 7:00	0.8			0			1.5			0.42			0.2241			0.75	
08/12/23 8:00	0.8			0			1.5			0.42			0.22368			0.75	
08/12/23 9:00	0.8			0			1.5			0.42			0.22368			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/12/23 10:00	0.8			0			1.5			0.42			0.22308			0.74	
08/12/23 11:00	0.7			0			1.5			0.44			0.2331			0.78	
08/12/23 12:00	0.7			0			1.5			0.47			0.2529			0.84	
08/12/23 13:00	0.7			0			1.5			0.49			0.25854			0.86	
08/12/23 14:00	0.7			0			1.4			0.46			0.24558			0.82	
08/12/23 15:00	0.7			0			1.5			0.46			0.24264			0.81	
08/12/23 16:00	0.7			0			1.4			0.42			0.22296			0.74	
08/12/23 17:00	0.7			0			1.4			0.42			0.22284			0.74	
08/12/23 18:00	0.8			0			1.5			0.48			0.25548			0.85	
08/12/23 19:00	0.8			0			1.5			0.59			0.31512			1.05	
08/12/23 20:00	0.9			0			1.5			0.57			0.30486			1.02	
08/12/23 21:00	0.7			0			1.5			0.47			0.2532			0.84	
08/12/23 22:00	0.8			0			1.5			0.51			0.2712			0.9	
08/12/23 23:00	0.7			0			1.5			0.44			0.23748			0.79	
08/13/23 0:00	0.7			0			1.5			0.47			0.25062			0.84	
08/13/23 1:00	0.7			0			1.5			0.47			0.2505			0.84	
08/13/23 2:00	0.8			0			1.5			0.44			0.23838			0.79	
08/13/23 3:00	0.7			0			1.5			0.48			0.25842			0.86	
08/13/23 4:00	0.7			0			1.5			0.44			0.2364			0.79	
08/13/23 5:00	0.8			0			1.5			0.43			0.23268			0.78	
08/13/23 6:00	0.9			0			1.5			0.42			0.22398			0.75	
08/13/23 7:00	1			0			1.5			0.42			0.22248			0.74	
08/13/23 8:00	1			0			1.5			0.42			0.222			0.74	
08/13/23 9:00	0.8			0			1.5			0.42			0.222			0.74	
08/13/23 10:00	0.8			0			1.5			0.42			0.22176			0.74	
08/13/23 11:00	0.8			0			1.5			0.42			0.22206			0.74	
08/13/23 12:00	0.7			0			1.5			0.44			0.2343			0.78	
08/13/23 13:00	0.7			0			1.5			0.44			0.23124			0.77	
08/13/23 14:00	0.7			0			1.5			0.48			0.25614			0.85	
08/13/23 15:00	0.7			0			1.5			0.5			0.26574			0.89	
08/13/23 16:00	0.6			0			1.5			0.5			0.2649			0.88	
08/13/23 17:00	0.7			0			1.5			0.47			0.2502			0.83	
08/13/23 18:00	0.8			0			1.5			0.57			0.30054			1	
08/13/23 19:00	0.7			0			1.5			0.6			0.31806			1.06	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/13/23 20:00	0.7			0			1.5			0.6			0.31602			1.05	
08/13/23 21:00	0.8			0			1.5			0.59			0.31464			1.05	
08/13/23 22:00	0.7			0			1.5			0.52			0.27642			0.92	
08/13/23 23:00	0.7			0			1.4			0.48			0.25854			0.86	
08/14/23 0:00	0.7			0			1.5			0.5			0.26874			0.9	
08/14/23 1:00	0.7			0			1.5			0.5			0.2679			0.89	
08/14/23 2:00	0.7			0			1.5			0.49			0.26256			0.88	
08/14/23 3:00	0.7			0			1.5			0.48			0.25854			0.86	
08/14/23 4:00	0.7			0			1.5			0.47			0.2538			0.85	
08/14/23 5:00	0.8			0			1.5			0.5			0.26892			0.9	
08/14/23 6:00	0.9			0			1.5			0.51			0.27264			0.91	
08/14/23 7:00	0.9			0			1.5			0.44			0.23622			0.79	
08/14/23 8:00	0.8			0			1.5			0.46			0.24636			0.82	
08/14/23 9:00	0.7			0			1.5			0.5			0.26904			0.9	
08/14/23 10:00	0.6			0			1.5			0.51			0.27072			0.9	
08/14/23 11:00	0.7			0			1.5			0.54			0.28806			0.96	
08/14/23 12:00	0.4			1			1.5			0.67			0.3492			1.16	
08/14/23 13:00	0.3			0			1.5			0.65			0.34386			1.15	
08/14/23 14:00	0.5			0			1.5			0.62			0.32454			1.08	
08/14/23 15:00	0.3			1			1.5			0.68			0.35448			1.18	
08/14/23 16:00	0.5			0			1.5			0.63			0.32856			1.1	
08/14/23 17:00	0.5			0			1.5			0.62			0.32322			1.08	
08/14/23 18:00	0.3			1			1.5			0.72			0.3723			1.24	
08/14/23 19:00	0.3			1			1.5			0.75			0.39042			1.3	
08/14/23 20:00	0.3			1			1.4			0.67			0.3531			1.18	
08/14/23 21:00	0.5			0			1.5			0.66			0.34536			1.15	
08/14/23 22:00	0.7			0			1.5			0.63			0.33108			1.1	
08/14/23 23:00	1			0			1.5			0.56			0.2976			0.99	
08/15/23 0:00	0.9			0			1.5			0.5			0.26658			0.89	
08/15/23 1:00	1			0			1.5			0.5			0.26622			0.89	
08/15/23 2:00	0.9			0			1.5			0.5			0.26616			0.89	
08/15/23 3:00	0.9			0			1.5			0.5			0.26556			0.89	
08/15/23 4:00	1			0			1.5			0.5			0.26574			0.89	
08/15/23 5:00	1.1			0			1.5			0.51			0.27264			0.91	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/15/23 6:00	1.1			0			1.5			0.51			0.27264			0.91	
08/15/23 7:00	1.2			0			1.4			0.45			0.23928			0.8	
08/15/23 8:00	1			0			1.5			0.49			0.261			0.87	
08/15/23 9:00	0.8			0			1.5			0.5			0.26502			0.88	
08/15/23 10:00	0.8			0			1.5			0.47			0.2529			0.84	
08/15/23 11:00	0.7			0			1.5			0.47			0.25272			0.84	
08/15/23 12:00	0.7			0			1.5			0.49			0.26262			0.88	
08/15/23 13:00	0.7			0			1.5			0.51			0.27054			0.9	
08/15/23 14:00	0.5			1			1.5			0.69			0.36222			1.21	
08/15/23 15:00	0.3			1			1.5			0.75			0.3912			1.3	
08/15/23 16:00	0.2			1			1.5			0.75			0.39042			1.3	
08/15/23 17:00	0.3			1			1.5			0.74			0.38712			1.29	
08/15/23 18:00	0.2			1			1.5			0.72			0.37458			1.25	
08/15/23 19:00	0.2			1			1.5			0.74			0.38418			1.28	
08/15/23 20:00	0.3			1			1.5			0.69			0.3618			1.21	
08/15/23 21:00	0.5			0			1.5			0.63			0.33			1.1	
08/15/23 22:00	0.4			1			1.5			0.66			0.34872			1.16	
08/15/23 23:00	0.7			0			1.4			0.53			0.28164			0.94	
08/16/23 0:00	0.7			0			1.5			0.52			0.27528			0.92	
08/16/23 1:00	0.7			0			1.5			0.5			0.26598			0.89	
08/16/23 2:00	0.7			0			1.5			0.47			0.24882			0.83	
08/16/23 3:00	0.7			0			1.5			0.46			0.24858			0.83	
08/16/23 4:00	0.7			0			1.5			0.47			0.25368			0.85	
08/16/23 5:00	0.7			0			1.5			0.51			0.27318			0.91	
08/16/23 6:00	0.7			0			1.5			0.51			0.27462			0.92	
08/16/23 7:00	1			0			1.5			0.49			0.26178			0.87	
08/16/23 8:00	0.9			0			1.5			0.49			0.2604			0.87	
08/16/23 9:00	0.8			0			1.5			0.47			0.2517			0.84	
08/16/23 10:00	0.7			0			1.5			0.48			0.2562			0.85	
08/16/23 11:00	0.7			0			1.5			0.5			0.26484			0.88	
08/16/23 12:00	0.6			0			1.5			0.51			0.27138			0.9	
08/16/23 13:00	0.7			0			1.5			0.52			0.2739			0.91	
08/16/23 14:00	0.2			1			1.6			0.73			0.3798			1.27	
08/16/23 15:00	0.2			1			1.5			0.74			0.38532			1.28	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/16/23 16:00	0.2			1			1.5			0.74			0.38532			1.28	
08/16/23 17:00	0.2			1			1.5			0.74			0.38358			1.28	
08/16/23 18:00	0.2			1			1.5			0.72			0.37608			1.25	
08/16/23 19:00	0.2			1			1.5			0.73			0.38184			1.27	
08/16/23 20:00	0.1			1			1.5			0.72			0.37566			1.25	
08/16/23 21:00	0.2			1			1.5			0.68			0.3588			1.2	
08/16/23 22:00	0.3			1			1.5			0.67			0.3531			1.18	
08/16/23 23:00	0.7			0			1.4			0.5			0.26574			0.89	
08/17/23 0:00	0.6			0			1.5			0.49			0.27156			0.91	
08/17/23 1:00	0.7			0			1.5			0.5			0.2676			0.89	
08/17/23 2:00	0.6			0			1.5			0.51			0.27192			0.91	
08/17/23 3:00	0.6			0			1.5			0.51			0.2739			0.91	
08/17/23 4:00	0.7			0			1.5			0.51			0.27174			0.91	
08/17/23 5:00	0.6			0			1.5			0.51			0.27414			0.91	
08/17/23 6:00	0.6			0			1.5			0.51			0.27318			0.91	
08/17/23 7:00	0.7			0			1.4			0.44			0.23298			0.78	
08/17/23 8:00	0.8			0			1.5			0.42			0.2223			0.74	
08/17/23 9:00	0.7			0			1.5			0.42			0.222			0.74	
08/17/23 10:00	0.7			0			1.5			0.42			0.2217			0.74	
08/17/23 11:00	0.7			0			1.5			0.42			0.22566			0.75	
08/17/23 12:00	0.7			0			1.5			0.48			0.25386			0.85	
08/17/23 13:00	0.6			0			1.5			0.5			0.26742			0.89	
08/17/23 14:00	0.7			0			1.4			0.46			0.24246			0.81	
08/17/23 15:00	0.7			0			1.4			0.43			0.22638			0.75	
08/17/23 16:00	0.6			0			1.5			0.45			0.23754			0.79	
08/17/23 17:00	0.7			0			1.5			0.47			0.25212			0.84	
08/17/23 18:00	0.6			0			1.5			0.61			0.32004			1.07	
08/17/23 19:00	0.6			0			1.5			0.61			0.3195			1.07	
08/17/23 20:00	0.7			0			1.5			0.6			0.31698			1.06	
08/17/23 21:00	0.7			0			1.3			0.45			0.23892			0.8	
08/17/23 22:00	0.7			0			1.5			0.48			0.25482			0.85	
08/17/23 23:00	0.7			0			1.5			0.47			0.2496			0.83	
08/18/23 0:00	0.7			0			1.5			0.44			0.23346			0.78	
08/18/23 1:00	0.7			0			1.5			0.41			0.22194			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/18/23 2:00	0.7			0			1.5			0.41			0.222			0.74	
08/18/23 3:00	0.7			0			1.5			0.41			0.22224			0.74	
08/18/23 4:00	0.7			0			1.5			0.41			0.22194			0.74	
08/18/23 5:00	0.7			0			1.5			0.42			0.22296			0.74	
08/18/23 6:00	0.7			0			1.5			0.44			0.23718			0.79	
08/18/23 7:00	0.7			0			1.5			0.42			0.22452			0.75	
08/18/23 8:00	0.8			0			1.5			0.42			0.22302			0.74	
08/18/23 9:00	0.7			0			1.5			0.42			0.22278			0.74	
08/18/23 10:00	0.7			0			1.5			0.42			0.22248			0.74	
08/18/23 11:00	0.7			0			1.5			0.42			0.22212			0.74	
08/18/23 12:00	0.7			0			1.5			0.42			0.22164			0.74	
08/18/23 13:00	0.7			0			1.5			0.42			0.22266			0.74	
08/18/23 14:00	0.7			0			1.5			0.42			0.2217			0.74	
08/18/23 15:00	0.7			0			1.5			0.42			0.22068			0.74	
08/18/23 16:00	0.7			0			1.5			0.42			0.2223			0.74	
08/18/23 17:00	0.7			0			1.5			0.42			0.22338			0.74	
08/18/23 18:00	0.7			0			1.5			0.42			0.22068			0.74	
08/18/23 19:00	0.7			0			1.5			0.41			0.2205			0.74	
08/18/23 20:00	0.7			0			1.5			0.41			0.22068			0.74	
08/18/23 21:00	0.7			0			1.5			0.41			0.22104			0.74	
08/18/23 22:00	0.7			0			1.5			0.41			0.22128			0.74	
08/18/23 23:00	0.7			0			1.5			0.41			0.22212			0.74	
08/19/23 0:00	0.7			0			1.5			0.43			0.2298			0.77	
08/19/23 1:00	0.7			0			1.5			0.41			0.22194			0.74	
08/19/23 2:00	0.7			0			1.5			0.41			0.22182			0.74	
08/19/23 3:00	0.7			0			1.5			0.41			0.22194			0.74	
08/19/23 4:00	0.7			0			1.5			0.41			0.222			0.74	
08/19/23 5:00	0.7			0			1.5			0.41			0.22206			0.74	
08/19/23 6:00	0.7			0			1.5			0.41			0.22188			0.74	
08/19/23 7:00	0.7			0			1.5			0.41			0.22188			0.74	
08/19/23 8:00	0.7			0			1.5			0.41			0.22152			0.74	
08/19/23 9:00	0.7			0			1.5			0.41			0.2211			0.74	
08/19/23 10:00	0.7			0			1.5			0.41			0.22068			0.74	
08/19/23 11:00	0.7			0			1.5			0.41			0.22134			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/19/23 12:00	0.7			0			1.5			0.42			0.222			0.74	
08/19/23 13:00	0.7			0			1.5			0.42			0.22194			0.74	
08/19/23 14:00	0.7			0			1.5			0.42			0.2214			0.74	
08/19/23 15:00	0.7			0			1.4			0.42			0.22152			0.74	
08/19/23 16:00	0.7			0			1.5			0.42			0.2214			0.74	
08/19/23 17:00	0.6			0			1.5			0.41			0.21996			0.73	
08/19/23 18:00	0.7			0			1.5			0.41			0.22002			0.73	
08/19/23 19:00	0.7			0			1.5			0.41			0.2205			0.74	
08/19/23 20:00	0.7			0			1.5			0.41			0.22068			0.74	
08/19/23 21:00	0.7			0			1.5			0.41			0.22074			0.74	
08/19/23 22:00	0.7			0			1.5			0.41			0.222			0.74	
08/19/23 23:00	0.7			0			1.5			0.43			0.22812			0.76	
08/20/23 0:00	0.7			0			1.5			0.44			0.23718			0.79	
08/20/23 1:00	0.7			0			1.5			0.43			0.22986			0.77	
08/20/23 2:00	0.7			0			1.6			0.44			0.23442			0.78	
08/20/23 3:00	0.7			0			1.5			0.44			0.23484			0.78	
08/20/23 4:00	0.7			0			1.5			0.43			0.22962			0.77	
08/20/23 5:00	0.8			0			1.5			0.41			0.22182			0.74	
08/20/23 6:00	0.9			0			1.5			0.41			0.22152			0.74	
08/20/23 7:00	0.8			0			1.5			0.41			0.22134			0.74	
08/20/23 8:00	0.8			0			1.5			0.41			0.22104			0.74	
08/20/23 9:00	0.7			0			1.5			0.41			0.22086			0.74	
08/20/23 10:00	0.7			0			1.5			0.41			0.22098			0.74	
08/20/23 11:00	0.7			0			1.5			0.41			0.22074			0.74	
08/20/23 12:00	0.7			0			1.5			0.41			0.22056			0.74	
08/20/23 13:00	0.7			0			1.5			0.41			0.22086			0.74	
08/20/23 14:00	0.7			0			1.5			0.41			0.2208			0.74	
08/20/23 15:00	0.7			0			1.5			0.41			0.22098			0.74	
08/20/23 16:00	0.7			0			1.5			0.41			0.22134			0.74	
08/20/23 17:00	0.7			0			1.5			0.41			0.22068			0.74	
08/20/23 18:00	0.7			0			1.5			0.41			0.22062			0.74	
08/20/23 19:00	0.7			0			1.5			0.41			0.22056			0.74	
08/20/23 20:00	0.7			0			1.5			0.41			0.22074			0.74	
08/20/23 21:00	0.7			0			1.5			0.41			0.2208			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/20/23 22:00	0.7			0			1.5			0.41			0.22074			0.74	
08/20/23 23:00	0.8			0			1.5			0.41			0.2208			0.74	
08/21/23 0:00	0.7			0			1.5			0.41			0.22038			0.73	
08/21/23 1:00	0.7			0			1.5			0.41			0.22008			0.73	
08/21/23 2:00	0.7			0			1.7			0.41			0.22086			0.74	
08/21/23 3:00	0.8			0			1.5			0.41			0.22098			0.74	
08/21/23 4:00	0.7			0			1.5			0.42			0.21558			0.72	
08/21/23 5:00	0			0	X		0			0.51			0.08178			0.27	
08/21/23 6:00	0	X		0	X		0	X		0.52			0	X		0	X
08/21/23 7:00	0	X		0	X		0	X		0.5			0	X		0	X
08/21/23 8:00	0	X		0	X		0	X		0.48			0	X		0	X
08/21/23 9:00	0	X		0	X		0	X		0.48			0	X		0	X
08/21/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
08/21/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
08/21/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
08/21/23 13:00	0			0	X		0			0.46			0.16836			0.56	
08/21/23 14:00	0.6			0			1.6			0.42			0.2268			0.76	
08/21/23 15:00	0.6			0			1.5			0.42			0.22482			0.75	
08/21/23 16:00	0.6			0			1.5			0.42			0.22422			0.75	
08/21/23 17:00	0.6			0			1.5			0.41			0.22098			0.74	
08/21/23 18:00	0.6			0			1.5			0.41			0.2211			0.74	
08/21/23 19:00	0.6			0			1.5			0.41			0.22158			0.74	
08/21/23 20:00	0.6			0			1.5			0.41			0.2217			0.74	
08/21/23 21:00	0.6			0			1.5			0.41			0.222			0.74	
08/21/23 22:00	0.6			0			1.5			0.41			0.22206			0.74	
08/21/23 23:00	0.7			0			1.5			0.41			0.22206			0.74	
08/22/23 0:00	0.6			0			1.5			0.41			0.22206			0.74	
08/22/23 1:00	0.6			0			1.5			0.41			0.22212			0.74	
08/22/23 2:00	0.7			0			1.5			0.41			0.22206			0.74	
08/22/23 3:00	0.7			0			1.5			0.41			0.22218			0.74	
08/22/23 4:00	0.7			0			1.5			0.41			0.22212			0.74	
08/22/23 5:00	0.7			0			1.5			0.41			0.22236			0.74	
08/22/23 6:00	0.7			0			1.5			0.42			0.22668			0.76	
08/22/23 7:00	0.7			0			1.5			0.41			0.2223			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/22/23 8:00	0.8			0			1.5			0.41			0.22218			0.74	
08/22/23 9:00	0.8			0			1.5			0.41			0.22194			0.74	
08/22/23 10:00	0.8			0			1.5			0.42			0.22206			0.74	
08/22/23 11:00	0.7			0			1.5			0.41			0.22188			0.74	
08/22/23 12:00	0.7			0			1.5			0.42			0.22128			0.74	
08/22/23 13:00	0.7			0			1.5			0.42			0.2211			0.74	
08/22/23 14:00	0.7			0			1.5			0.42			0.22104			0.74	
08/22/23 15:00	0.7			0			1.5			0.42			0.2208			0.74	
08/22/23 16:00	0.7			0			1.5			0.41			0.22092			0.74	
08/22/23 17:00	0.6			0			1.5			0.42			0.2256			0.75	
08/22/23 18:00	0.7			0			1.5			0.44			0.23394			0.78	
08/22/23 19:00	0.7			0			1.5			0.49			0.26286			0.88	
08/22/23 20:00	0.7			0			1.5			0.43			0.23214			0.77	
08/22/23 21:00	0.7			0			1.6			0.46			0.24756			0.83	
08/22/23 22:00	0.8			0			1.5			0.44			0.23718			0.79	
08/22/23 23:00	0.8			0			1.5			0.42			0.22716			0.76	
08/23/23 0:00	0.8			0			1.5			0.41			0.22122			0.74	
08/23/23 1:00	0.8			0			1.5			0.41			0.22134			0.74	
08/23/23 2:00	0.8			0			1.5			0.41			0.22158			0.74	
08/23/23 3:00	0.8			0			1.5			0.41			0.22164			0.74	
08/23/23 4:00	0.8			0			1.5			0.41			0.22188			0.74	
08/23/23 5:00	0.7			0			1.5			0.43			0.2322			0.77	
08/23/23 6:00	0.8			0			1.5			0.46			0.2454			0.82	
08/23/23 7:00	1			0			1.5			0.42			0.2244			0.75	
08/23/23 8:00	0.9			0			1.5			0.41			0.22218			0.74	
08/23/23 9:00	0.8			0			1.5			0.41			0.22188			0.74	
08/23/23 10:00	0.7			0			1.5			0.41			0.2214			0.74	
08/23/23 11:00	0.7			0			1.5			0.41			0.22092			0.74	
08/23/23 12:00	0.7			0			1.5			0.42			0.2208			0.74	
08/23/23 13:00	0.7			0			1.5			0.42			0.22038			0.73	
08/23/23 14:00	0.7			0			1.5			0.46			0.24114			0.8	
08/23/23 15:00	0.6			0			1.5			0.52			0.2742			0.91	
08/23/23 16:00	0.6			0			1.5			0.51			0.2739			0.91	
08/23/23 17:00	0.7			0			1.5			0.52			0.27468			0.92	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/23/23 18:00	0.4			1			1.5			0.66			0.34638			1.15	
08/23/23 19:00	0.3			1			1.5			0.69			0.36264			1.21	
08/23/23 20:00	0.8			0			1.5			0.59			0.312			1.04	
08/23/23 21:00	1.1			0			1.5			0.56			0.297			0.99	
08/23/23 22:00	0.8			0			1.5			0.51			0.27114			0.9	
08/23/23 23:00	0.8			0			1.5			0.47			0.25338			0.84	
08/24/23 0:00	0.8			0			1.5			0.47			0.25206			0.84	
08/24/23 1:00	0.9			0			1.5			0.41			0.2223			0.74	
08/24/23 2:00	0.9			0			1.5			0.41			0.22128			0.74	
08/24/23 3:00	0.8			0			1.5			0.41			0.22128			0.74	
08/24/23 4:00	0.7			0			1.5			0.44			0.23838			0.79	
08/24/23 5:00	0.9			0			1.5			0.47			0.25422			0.85	
08/24/23 6:00	0.8			0			1.5			0.51			0.2721			0.91	
08/24/23 7:00	1			0			1.5			0.44			0.2355			0.79	
08/24/23 8:00	0.9			0			1.5			0.41			0.22152			0.74	
08/24/23 9:00	0.8			0			1.5			0.41			0.2211			0.74	
08/24/23 10:00	0.8			0			1.5			0.41			0.22074			0.74	
08/24/23 11:00	0.7			0			1.5			0.41			0.22068			0.74	
08/24/23 12:00	0.7			0			1.5			0.42			0.22074			0.74	
08/24/23 13:00	0.7			0			1.5			0.42			0.22056			0.74	
08/24/23 14:00	0.7			0			1.5			0.41			0.22008			0.73	
08/24/23 15:00	0.7			0			1.5			0.41			0.22008			0.73	
08/24/23 16:00	0.7			0			1.5			0.41			0.22008			0.73	
08/24/23 17:00	0.7			0			1.5			0.41			0.21996			0.73	
08/24/23 18:00	0.7			0			1.5			0.43			0.22878			0.76	
08/24/23 19:00	0.7			0			1.4			0.42			0.2265			0.76	
08/24/23 20:00	0.7			0			1.5			0.41			0.222			0.74	
08/24/23 21:00	0.7			0			1.5			0.44			0.23634			0.79	
08/24/23 22:00	0.7			0			1.5			0.45			0.23946			0.8	
08/24/23 23:00	0.7			0			1.5			0.42			0.22374			0.75	
08/25/23 0:00	0.7			0			1.5			0.44			0.23916			0.8	
08/25/23 1:00	0.7			0			1.5			0.42			0.22638			0.75	
08/25/23 2:00	0.8			0			1.5			0.41			0.22344			0.74	
08/25/23 3:00	0.8			0			1.5			0.41			0.22278			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/25/23 4:00	0.7			0			1.5			0.43			0.22926			0.76	
08/25/23 5:00	0.6			0			1.5			0.5			0.26874			0.9	
08/25/23 6:00	0.6			0			1.5			0.49			0.26064			0.87	
08/25/23 7:00	0.8			0			1.5			0.42			0.22386			0.75	
08/25/23 8:00	0.8			0			1.5			0.42			0.22254			0.74	
08/25/23 9:00	0.8			0			1.5			0.41			0.22242			0.74	
08/25/23 10:00	0.7			0			1.5			0.41			0.22212			0.74	
08/25/23 11:00	0.7			0			1.5			0.41			0.22194			0.74	
08/25/23 12:00	0.7			0			1.5			0.42			0.22194			0.74	
08/25/23 13:00	0.7			0			1.5			0.42			0.22158			0.74	
08/25/23 14:00	0.7			0			1.5			0.41			0.22098			0.74	
08/25/23 15:00	0.7			0			1.5			0.41			0.2208			0.74	
08/25/23 16:00	0.7			0			1.5			0.41			0.2208			0.74	
08/25/23 17:00	0.7			0			1.5			0.41			0.22056			0.74	
08/25/23 18:00	0.7			0			1.5			0.41			0.2208			0.74	
08/25/23 19:00	0.7			0			1.5			0.41			0.22104			0.74	
08/25/23 20:00	0.7			0			1.5			0.41			0.22134			0.74	
08/25/23 21:00	0.7			0			1.5			0.42			0.22284			0.74	
08/25/23 22:00	0.7			0			1.5			0.41			0.22206			0.74	
08/25/23 23:00	0.7			0			1.5			0.41			0.22266			0.74	
08/26/23 0:00	0.7			0			1.5			0.47			0.25314			0.84	
08/26/23 1:00	0.7			0			1.5			0.48			0.25536			0.85	
08/26/23 2:00	0.7			0			1.6			0.43			0.23376			0.78	
08/26/23 3:00	0.7			0			1.5			0.45			0.2397			0.8	
08/26/23 4:00	0.7			0			1.5			0.44			0.23796			0.79	
08/26/23 5:00	0.7			0			1.5			0.47			0.2532			0.84	
08/26/23 6:00	0.7			0			1.5			0.48			0.25608			0.85	
08/26/23 7:00	0.8			0			1.5			0.42			0.22338			0.74	
08/26/23 8:00	0.8			0			1.5			0.42			0.22326			0.74	
08/26/23 9:00	0.8			0			1.5			0.42			0.22302			0.74	
08/26/23 10:00	0.7			0			1.5			0.42			0.22266			0.74	
08/26/23 11:00	0.8			0			1.5			0.42			0.22236			0.74	
08/26/23 12:00	0.7			0			1.5			0.42			0.22176			0.74	
08/26/23 13:00	0.7			0			1.5			0.42			0.2214			0.74	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/26/23 14:00	0.7			0			1.5			0.41			0.22104			0.74	
08/26/23 15:00	0.7			0			1.5			0.41			0.22068			0.74	
08/26/23 16:00	0.7			0			1.5			0.41			0.22074			0.74	
08/26/23 17:00	0.7			0			1.5			0.43			0.23238			0.77	
08/26/23 18:00	0.6			0			1.5			0.43			0.23136			0.77	
08/26/23 19:00	0.7			0			1.5			0.42			0.22302			0.74	
08/26/23 20:00	0.7			0			1.5			0.42			0.22728			0.76	
08/26/23 21:00	0.7			0			1.5			0.42			0.22716			0.76	
08/26/23 22:00	0.7			0			1.5			0.43			0.23088			0.77	
08/26/23 23:00	0.7			0			1.5			0.43			0.23142			0.77	
08/27/23 0:00	0.7			0			1.5			0.44			0.23826			0.79	
08/27/23 1:00	0.7			0			1.5			0.43			0.2298			0.77	
08/27/23 2:00	0.7			0			1.5			0.42			0.22386			0.75	
08/27/23 3:00	0.8			0			1.5			0.42			0.22782			0.76	
08/27/23 4:00	0.8			0			1.5			0.42			0.22488			0.75	
08/27/23 5:00	0.7			0			1.5			0.45			0.2436			0.81	
08/27/23 6:00	0.7			0			1.5			0.47			0.2523			0.84	
08/27/23 7:00	0.8			0			1.5			0.42			0.22308			0.74	
08/27/23 8:00	0.8			0			1.5			0.42			0.2229			0.74	
08/27/23 9:00	0.8			0			1.5			0.41			0.22248			0.74	
08/27/23 10:00	0.7			0			1.5			0.41			0.22212			0.74	
08/27/23 11:00	0.7			0			1.5			0.41			0.2217			0.74	
08/27/23 12:00	0.7			0			1.5			0.42			0.2217			0.74	
08/27/23 13:00	0.7			0			1.5			0.42			0.2226			0.74	
08/27/23 14:00	0.7			0			1.5			0.42			0.22224			0.74	
08/27/23 15:00	0.7			0			1.5			0.42			0.22566			0.75	
08/27/23 16:00	0.7			0			1.5			0.43			0.22776			0.76	
08/27/23 17:00	0.7			0			1.5			0.45			0.24204			0.81	
08/27/23 18:00	0.7			0			1.5			0.42			0.22176			0.74	
08/27/23 19:00	0.7			0			1.5			0.46			0.24336			0.81	
08/27/23 20:00	0.6			0			1.5			0.51			0.27192			0.91	
08/27/23 21:00	0.6			0			1.5			0.51			0.27234			0.91	
08/27/23 22:00	0.7			0			1.5			0.5			0.26964			0.9	
08/27/23 23:00	0.7			0			1.5			0.46			0.24564			0.82	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/28/23 0:00	0.8			0			1.5			0.43			0.23178			0.77	
08/28/23 1:00	0.8			0			1.5			0.41			0.22182			0.74	
08/28/23 2:00	0.7			0			1.5			0.41			0.22206			0.74	
08/28/23 3:00	0.7			0			1.5			0.41			0.22212			0.74	
08/28/23 4:00	0.7			0			1.5			0.42			0.22332			0.74	
08/28/23 5:00	0.7			0			1.5			0.49			0.26208			0.87	
08/28/23 6:00	0.7			0			1.5			0.53			0.28416			0.95	
08/28/23 7:00	0.8			0			1.5			0.45			0.24276			0.81	
08/28/23 8:00	0.8			0			1.5			0.42			0.22242			0.74	
08/28/23 9:00	0.9			0			1.5			0.41			0.2223			0.74	
08/28/23 10:00	0.8			0			1.5			0.41			0.22182			0.74	
08/28/23 11:00	0.7			0			1.5			0.42			0.22224			0.74	
08/28/23 12:00	0.7			0			1.5			0.42			0.22566			0.75	
08/28/23 13:00	0.7			0			1.5			0.46			0.24558			0.82	
08/28/23 14:00	0.7			0			1.5			0.5			0.26718			0.89	
08/28/23 15:00	0.7			0			1.5			0.5			0.26964			0.9	
08/28/23 16:00	0.7			0			1.5			0.49			0.25896			0.86	
08/28/23 17:00	0.7			0			1.5			0.42			0.22116			0.74	
08/28/23 18:00	0.7			0			1.5			0.45			0.23964			0.8	
08/28/23 19:00	0.8			0			1.5			0.59			0.31368			1.05	
08/28/23 20:00	0.8			0			1.5			0.51			0.27024			0.9	
08/28/23 21:00	0.7			0			1.5			0.44			0.2346			0.78	
08/28/23 22:00	0.7			0			1.5			0.44			0.2382			0.79	
08/28/23 23:00	0.8			0			1.5			0.42			0.22758			0.76	
08/29/23 0:00	0.7			0			1.5			0.45			0.23874			0.8	
08/29/23 1:00	0.7			0			1.5			0.48			0.25914			0.86	
08/29/23 2:00	0.7			0			1.6			0.47			0.25212			0.84	
08/29/23 3:00	0.7			0			1.5			0.46			0.2463			0.82	
08/29/23 4:00	0.7			0			1.5			0.46			0.24858			0.83	
08/29/23 5:00	0.7			0			1.5			0.5			0.26658			0.89	
08/29/23 6:00	0.7			0			1.5			0.49			0.26538			0.88	
08/29/23 7:00	2			0			1.5			0.55			0.2955			0.99	
08/29/23 8:00	0.7			1			1.5			0.68			0.35988			1.2	
08/29/23 9:00	0.2			1			1.5			0.72			0.37902			1.26	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/29/23 10:00	0.2			1			1.5			0.72			0.37848			1.26	
08/29/23 11:00	0.1			1			1.5			0.72			0.37914			1.26	
08/29/23 12:00	0.1			1			1.5			0.73			0.38034			1.27	
08/29/23 13:00	0.1			1			1.5			0.73			0.38154			1.27	
08/29/23 14:00	0.1			1			1.5			0.73			0.3828			1.28	
08/29/23 15:00	0.1			1			1.5			0.73			0.38292			1.28	
08/29/23 16:00	0.1			1			1.5			0.73			0.38328			1.28	
08/29/23 17:00	0.8			0			1.4			0.54			0.28776			0.96	
08/29/23 18:00	0.8			0			1.5			0.59			0.31248			1.04	
08/29/23 19:00	0.9			0			1.4			0.52			0.27384			0.91	
08/29/23 20:00	0.8			0			1.5			0.41			0.2205			0.74	
08/29/23 21:00	0.8			0			1.5			0.41			0.22044			0.73	
08/29/23 22:00	0.8			0			1.5			0.41			0.22056			0.74	
08/29/23 23:00	0.8			0			1.5			0.41			0.22092			0.74	
08/30/23 0:00	0.9			0			1.5			0.41			0.22068			0.74	
08/30/23 1:00	1			0			1.5			0.41			0.22074			0.74	
08/30/23 2:00	1			0			1.5			0.41			0.22074			0.74	
08/30/23 3:00	1.1			0			1.5			0.41			0.22092			0.74	
08/30/23 4:00	1			0			1.5			0.41			0.22098			0.74	
08/30/23 5:00	1			0			1.5			0.41			0.2214			0.74	
08/30/23 6:00	1			0			1.5			0.42			0.22662			0.76	
08/30/23 7:00	0.9			0			1.5			0.44			0.23778			0.79	
08/30/23 8:00	0.9			0			1.5			0.46			0.24516			0.82	
08/30/23 9:00	0.3			1			1.5			0.72			0.37962			1.27	
08/30/23 10:00	0.2			1			1.5			0.72			0.3804			1.27	
08/30/23 11:00	0.1			1			1.5			0.73			0.38148			1.27	
08/30/23 12:00	0.2			1			1.5			0.71			0.37176			1.24	
08/30/23 13:00	0.8			0			1.5			0.59			0.31212			1.04	
08/30/23 14:00	0.8			0			1.4			0.44			0.23316			0.78	
08/30/23 15:00	0.7			0			1.5			0.41			0.21948			0.73	
08/30/23 16:00	0.7			0			1.5			0.41			0.21942			0.73	
08/30/23 17:00	0.7			0			1.5			0.41			0.219			0.73	
08/30/23 18:00	0.7			0			1.5			0.44			0.23148			0.77	
08/30/23 19:00	0.7			0			1.5			0.41			0.2202			0.73	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/30/23 20:00	0.7			0			1.5			0.41			0.21972			0.73	
08/30/23 21:00	1			0			1.5			0.41			0.21996			0.73	
08/30/23 22:00	1.5			0			1.5			0.41			0.22014			0.73	
08/30/23 23:00	1.5			0			1.5			0.41			0.22014			0.73	
08/31/23 0:00	1.3			0			1.5			0.42			0.22548			0.75	
08/31/23 1:00	1			0			1.5			0.41			0.22038			0.73	
08/31/23 2:00	0.8			0			1.5			0.41			0.22086			0.74	
08/31/23 3:00	0.8			0			1.5			0.41			0.22044			0.73	
08/31/23 4:00	0.8			0			1.5			0.42			0.22632			0.75	
08/31/23 5:00	0.7			0			1.5			0.47			0.25044			0.83	
08/31/23 6:00	0.7			0			1.5			0.48			0.25548			0.85	
08/31/23 7:00	0.8			0			1.5			0.42			0.22518			0.75	
08/31/23 8:00	0.3			1			1.6			0.69			0.36288			1.21	
08/31/23 9:00	0.1			1			1.5			0.73			0.38436			1.28	
08/31/23 10:00	0.1			1			1.5			0.73			0.38352			1.28	
08/31/23 11:00	0.1			1			1.5			0.73			0.3831			1.28	
08/31/23 12:00	0.1			1			1.5			0.73			0.38328			1.28	
08/31/23 13:00	0.1			1			1.5			0.74			0.38412			1.28	
08/31/23 14:00	0.1			1			1.5			0.74			0.38508			1.28	
08/31/23 15:00	0.1			1			1.5			0.74			0.38472			1.28	
08/31/23 16:00	0.1			1			1.5			0.73			0.38376			1.28	
08/31/23 17:00	0.7			0			1.5			0.59			0.31062			1.04	
08/31/23 18:00	0.7			0			1.5			0.42			0.22194			0.74	
08/31/23 19:00	0.7			0			1.5			0.41			0.22002			0.73	
08/31/23 20:00	0.7			0			1.5			0.41			0.22008			0.73	
08/31/23 21:00	0.7			0			1.5			0.41			0.2205			0.74	
08/31/23 22:00	0.7			0			1.5			0.43			0.2283			0.76	
08/31/23 23:00	0.7			0			1.5			0.41			0.22122			0.74	
09/01/23 0:00	0.7			-1			1.5			0.42			0.22458			0.75	
09/01/23 1:00	0.7			-1			1.5			0.42			0.2244			0.75	
09/01/23 2:00	0.7			-1			1.5			0.42			0.2244			0.75	
09/01/23 3:00	0.7			0			1.5			0.42			0.22458			0.75	
09/01/23 4:00	0.7			-1			1.5			0.42			0.22458			0.75	
09/01/23 5:00	0.7			-1			1.5			0.43			0.22902			0.76	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/01/23 6:00	0.7			0			1.5			0.45			0.24132			0.8	
09/01/23 7:00	0.7			1			1.5			0.46			0.24642			0.82	
09/01/23 8:00	0.7			1			1.5			0.42			0.22464			0.75	
09/01/23 9:00	0.7			1			1.5			0.42			0.22542			0.75	
09/01/23 10:00	0.7			0			1.5			0.44			0.23592			0.79	
09/01/23 11:00	0.7			1			1.5			0.42			0.22452			0.75	
09/01/23 12:00	0.7			1			1.5			0.42			0.22434			0.75	
09/01/23 13:00	0.7			1			1.5			0.42			0.22416			0.75	
09/01/23 14:00	0.7			1			1.5			0.42			0.2262			0.75	
09/01/23 15:00	0.7			-1			1.5			0.46			0.2445			0.82	
09/01/23 16:00	0.7			-1			1.5			0.42			0.2238			0.75	
09/01/23 17:00	0.7			-1			1.5			0.42			0.2235			0.75	
09/01/23 18:00	0.7			0			1.5			0.42			0.22374			0.75	
09/01/23 19:00	0.7			1			1.5			0.42			0.22398			0.75	
09/01/23 20:00	0.7			1			1.5			0.42			0.22416			0.75	
09/01/23 21:00	0.7			2			1.5			0.42			0.22506			0.75	
09/01/23 22:00	0.7			1			1.5			0.45			0.2406			0.8	
09/01/23 23:00	0.7			1			1.5			0.44			0.23502			0.78	
09/02/23 0:00	0.7			1			1.5			0.44			0.2355			0.79	
09/02/23 1:00	0.7			2			1.5			0.42			0.22788			0.76	
09/02/23 2:00	0.8			2			1.6			0.42			0.22722			0.76	
09/02/23 3:00	0.8			2			1.5			0.43			0.22902			0.76	
09/02/23 4:00	0.8			1			1.5			0.42			0.22674			0.76	
09/02/23 5:00	0.7			1			1.5			0.44			0.23862			0.8	
09/02/23 6:00	0.8			1			1.5			0.42			0.2256			0.75	
09/02/23 7:00	0.8			2			1.5			0.42			0.22596			0.75	
09/02/23 8:00	0.8			2			1.5			0.42			0.2259			0.75	
09/02/23 9:00	0.8			1			1.5			0.43			0.22866			0.76	
09/02/23 10:00	0.7			1			1.5			0.45			0.24096			0.8	
09/02/23 11:00	0.7			1			1.5			0.49			0.26142			0.87	
09/02/23 12:00	0.7			0			1.5			0.43			0.22902			0.76	
09/02/23 13:00	0.7			1			1.5			0.44			0.23898			0.8	
09/02/23 14:00	0.7			0			1.5			0.45			0.2415			0.81	
09/02/23 15:00	0.7			1			1.5			0.51			0.273			0.91	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/02/23 16:00	0.7			-1			1.5			0.42			0.2259			0.75	
09/02/23 17:00	0.7			-1			1.5			0.43			0.23052			0.77	
09/02/23 18:00	0.7			-1			1.5			0.43			0.2319			0.77	
09/02/23 19:00	0.7			-1			1.5			0.42			0.2268			0.76	
09/02/23 20:00	0.7			-1			1.5			0.42			0.22488			0.75	
09/02/23 21:00	0.7			0			1.5			0.42			0.22794			0.76	
09/02/23 22:00	0.8			1			1.5			0.45			0.23958			0.8	
09/02/23 23:00	0.8			1			1.5			0.42			0.22488			0.75	
09/03/23 0:00	0.8			1			1.5			0.46			0.2472			0.82	
09/03/23 1:00	1			0			1.5			0.43			0.23088			0.77	
09/03/23 2:00	0.8			0			1.5			0.38			0.24156			0.81	
09/03/23 3:00	0.8			0			1.5			0		X	0.23052			0.77	
09/03/23 4:00	0.8			1			1.5			0		X	0.2319			0.77	
09/03/23 5:00	0.7			1			1.5			0		X	0.23142			0.77	
09/03/23 6:00	0.7			1			1.5			0		X	0.2313			0.77	
09/03/23 7:00	0.7			1			1.5			0		X	0.2331			0.78	
09/03/23 8:00	0.7			1			1.5			0		X	0.23364			0.78	
09/03/23 9:00	0.7			0			1.5			0		X	0.23652			0.79	
09/03/23 10:00	0.7			1			1.5			0		X	0.28848			0.96	
09/03/23 11:00	0.8			0			1.5			0.37			0.2643			0.88	
09/03/23 12:00	0.7			1			1.5			0.42			0.22452			0.75	
09/03/23 13:00	0.7			1			1.5			0.42			0.22446			0.75	
09/03/23 14:00	0.7			0			1.5			0.42			0.22428			0.75	
09/03/23 15:00	0.7			0			1.5			0.42			0.22416			0.75	
09/03/23 16:00	0.7			-1			1.5			0.42			0.22416			0.75	
09/03/23 17:00	0.7			-1			1.5			0.42			0.2241			0.75	
09/03/23 18:00	0.7			-1			1.5			0.42			0.2241			0.75	
09/03/23 19:00	0.7			-2			1.5			0.42			0.22434			0.75	
09/03/23 20:00	0.7			-1			1.5			0.42			0.22494			0.75	
09/03/23 21:00	0.7			0			1.5			0.44			0.23346			0.78	
09/03/23 22:00	0.7			1			1.5			0.42			0.225			0.75	
09/03/23 23:00	0.7			1			1.5			0.42			0.22512			0.75	
09/04/23 0:00	0.8			1			1.5			0.42			0.22518			0.75	
09/04/23 1:00	0.8			1			1.5			0.42			0.2256			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/04/23 2:00	0.8			0	X		1.5			0.42			0.2256			0.75	
09/04/23 3:00	0.8			0	X		1.5			0.42			0.22572			0.75	
09/04/23 4:00	0.8			0	X		1.5			0.42			0.22596			0.75	
09/04/23 5:00	0.8			0	X		1.5			0.42			0.22608			0.75	
09/04/23 6:00	0.8			0	X		1.5			0.42			0.22602			0.75	
09/04/23 7:00	0.8			0	X		1.5			0.42			0.22602			0.75	
09/04/23 8:00	0.8			0	X		1.5			0.42			0.22596			0.75	
09/04/23 9:00	0.8			0	X		1.5			0.42			0.22584			0.75	
09/04/23 10:00	0.8			0	X		1.5			0.42			0.22578			0.75	
09/04/23 11:00	0.8			0	X		1.5			0.42			0.22548			0.75	
09/04/23 12:00	0.7			0	X		1.5			0.42			0.22518			0.75	
09/04/23 13:00	0.8			0	X		1.5			0.42			0.225			0.75	
09/04/23 14:00	0.7			0	X		1.5			0.42			0.22476			0.75	
09/04/23 15:00	0.7			0	X		1.5			0.42			0.22428			0.75	
09/04/23 16:00	0.7			0	X		1.5			0.42			0.22416			0.75	
09/04/23 17:00	0.7			0	X		1.5			0.43			0.22968			0.77	
09/04/23 18:00	0.7			0	X		1.5			0.47			0.2502			0.83	
09/04/23 19:00	0.9			0	X		1.5			0.54			0.28596			0.95	
09/04/23 20:00	0.9			0	X		1.5			0.56			0.30006			1	
09/04/23 21:00	0.7			0	X		1.5			0.47			0.25206			0.84	
09/04/23 22:00	0.7			0	X		1.5			0.47			0.25038			0.83	
09/04/23 23:00	0.7			0	X		1.5			0.43			0.23076			0.77	
09/05/23 0:00	0.7			0	X		1.5			0.47			0.25344			0.84	
09/05/23 1:00	0.8			0	X		1.5			0.43			0.23082			0.77	
09/05/23 2:00	0.8			0	X		1.6			0.43			0.23262			0.78	
09/05/23 3:00	0.8			0	X		1.6			0.44			0.23928			0.8	
09/05/23 4:00	0.8			0			1.5			0.5			0.2679			0.89	
09/05/23 5:00	0.7			0			1.5			0.51			0.27546			0.92	
09/05/23 6:00	0.8			0			1.5			0.52			0.28272			0.94	
09/05/23 7:00	0.3			1			1.5			0.7			0.39324			1.31	
09/05/23 8:00	0.2			1			1.5			0.74			0.38616			1.29	
09/05/23 9:00	0.8			0			1.5			0.55			0.29412			0.98	
09/05/23 10:00	0.8			0			1.5			0.53			0.28236			0.94	
09/05/23 11:00	0.5			1			1.5			0.67			0.35376			1.18	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/05/23 12:00	0.6			0			1.4			0.56			0.29562			0.99	
09/05/23 13:00	0.7			0			1.5			0.53			0.27996			0.93	
09/05/23 14:00	0.7			0			1.5			0.52			0.28032			0.93	
09/05/23 15:00	0.7			0			1.5			0.52			0.28026			0.93	
09/05/23 16:00	0.7			0			1.5			0.52			0.27966			0.93	
09/05/23 17:00	0.7			0			1.5			0.48			0.2553			0.85	
09/05/23 18:00	0.8			0			1.5			0.54			0.28584			0.95	
09/05/23 19:00	0.7			0			1.5			0.62			0.32508			1.08	
09/05/23 20:00	0.9			0			1.5			0.54			0.2886			0.96	
09/05/23 21:00	0.8			0			1.5			0.52			0.27954			0.93	
09/05/23 22:00	0.7			0			1.5			0.51			0.2709			0.9	
09/05/23 23:00	0.8			0			1.5			0.49			0.26166			0.87	
09/06/23 0:00	0.8			0			1.5			0.49			0.26082			0.87	
09/06/23 1:00	0.8			0			1.5			0.46			0.24468			0.82	
09/06/23 2:00	0.8			0			1.5			0.42			0.22602			0.75	
09/06/23 3:00	0.8			0			1.5			0.43			0.2298			0.77	
09/06/23 4:00	0.8			0			1.5			0.45			0.24096			0.8	
09/06/23 5:00	0.8			0			1.5			0.51			0.27348			0.91	
09/06/23 6:00	0.8			0			1.5			0.52			0.27996			0.93	
09/06/23 7:00	0.9			0			1.5			0.46			0.24672			0.82	
09/06/23 8:00	0.8			0			1.5			0.42			0.22524			0.75	
09/06/23 9:00	0.8			0			1.5			0.42			0.22512			0.75	
09/06/23 10:00	0.8			0			1.5			0.42			0.22524			0.75	
09/06/23 11:00	0.8			0			1.5			0.42			0.22482			0.75	
09/06/23 12:00	0.8			0			1.5			0.42			0.22572			0.75	
09/06/23 13:00	0.7			0			1.5			0.42			0.22404			0.75	
09/06/23 14:00	0.7			0			1.5			0.42			0.2235			0.75	
09/06/23 15:00	0.7			-1			1.5			0.42			0.22326			0.74	
09/06/23 16:00	0.7			0			1.5			0.42			0.22326			0.74	
09/06/23 17:00	0.7			0			1.5			0.45			0.24042			0.8	
09/06/23 18:00	0.7			0			1.5			0.49			0.26184			0.87	
09/06/23 19:00	0.7			0			1.5			0.45			0.24216			0.81	
09/06/23 20:00	0.7			0			1.5			0.5			0.26742			0.89	
09/06/23 21:00	0.7			0			1.5			0.48			0.25746			0.86	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/06/23 22:00	0.7			0			1.5			0.5			0.26766			0.89	
09/06/23 23:00	0.8			0			1.5			0.45			0.24384			0.81	
09/07/23 0:00	0.8			0			1.5			0.47			0.25224			0.84	
09/07/23 1:00	0.8			0			1.5			0.42			0.22746			0.76	
09/07/23 2:00	0.8			0			1.6			0.42			0.22584			0.75	
09/07/23 3:00	0.9			0			1.5			0.42			0.22596			0.75	
09/07/23 4:00	0.8			0			1.5			0.42			0.22614			0.75	
09/07/23 5:00	0.8			0			1.5			0.47			0.2514			0.84	
09/07/23 6:00	0.7			0			1.5			0.52			0.2766			0.92	
09/07/23 7:00	0.8			0			1.5			0.45			0.24084			0.8	
09/07/23 8:00	0.8			0			1.5			0.42			0.22596			0.75	
09/07/23 9:00	0.8			0			1.5			0.47			0.25092			0.84	
09/07/23 10:00	0.8			0			1.5			0.44			0.23646			0.79	
09/07/23 11:00	0.8			0			1.5			0.45			0.23844			0.79	
09/07/23 12:00	0.8			0			1.5			0.45			0.23952			0.8	
09/07/23 13:00	0.7			0			1.5			0.43			0.23082			0.77	
09/07/23 14:00	0.8			0			1.5			0.48			0.25626			0.85	
09/07/23 15:00	0.8			0			1.5			0.5			0.26502			0.88	
09/07/23 16:00	0.7			0			1.5			0.45			0.23832			0.79	
09/07/23 17:00	0.8			0			1.5			0.48			0.25266			0.84	
09/07/23 18:00	0.8			0			1.5			0.48			0.2535			0.85	
09/07/23 19:00	0.8			0			1.5			0.44			0.23682			0.79	
09/07/23 20:00	0.8			0			1.5			0.5			0.26874			0.9	
09/07/23 21:00	0.8			0			1.5			0.51			0.27474			0.92	
09/07/23 22:00	0.8			0			1.5			0.48			0.258			0.86	
09/07/23 23:00	0.8			0			1.5			0.44			0.24018			0.8	
09/08/23 0:00	0.8			0			1.5			0.18			0.22806			0.76	
09/08/23 1:00	0.8			0			1.5			0	X		0.23082			0.77	
09/08/23 2:00	0.8			0			1.5			0	X		0.22998			0.77	
09/08/23 3:00	0.8			0			1.5			0	X		0.23034			0.77	
09/08/23 4:00	0.8			0			1.5			0	X		0.2307			0.77	
09/08/23 5:00	0.9			0			1.5			0	X		0.28482			0.95	
09/08/23 6:00	1			0			1.5			0	X		0.3246			1.08	
09/08/23 7:00	0.9			0			1.5			0	X		0.32766			1.09	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/08/23 8:00	0.9			0			1.4			0	X		0.28302			0.94	
09/08/23 9:00	0.8			0			1.5			0	X		0.22944			0.76	
09/08/23 10:00	0.8			0			1.5			0	X		0.2292			0.76	
09/08/23 11:00	0.8			0			1.5			0	X		0.25098			0.84	
09/08/23 12:00	0.8			0			1.5			0.35			0.24732			0.82	
09/08/23 13:00	0.7			0			1.5			0.51			0.27372			0.91	
09/08/23 14:00	0.7			0			1.5			0.53			0.28206			0.94	
09/08/23 15:00	0.7			0			1.5			0.53			0.282			0.94	
09/08/23 16:00	1			0			1.5			0.56			0.29532			0.98	
09/08/23 17:00	0.4			1			1.5			0.69			0.36108			1.2	
09/08/23 18:00	0.2			1			1.5			0.76			0.39762			1.33	
09/08/23 19:00	0.5			0			1.5			0.66			0.34806			1.16	
09/08/23 20:00	0.4			1			1.5			0.7			0.3663			1.22	
09/08/23 21:00	0.3			1			1.5			0.72			0.37776			1.26	
09/08/23 22:00	0.6			0			1.5			0.66			0.34866			1.16	
09/08/23 23:00	0.8			0			1.5			0.51			0.273			0.91	
09/09/23 0:00	0.7			0			1.5			0.52			0.27822			0.93	
09/09/23 1:00	0.7			0			1.5			0.52			0.27744			0.92	
09/09/23 2:00	0.8			0			1.5			0.48			0.25746			0.86	
09/09/23 3:00	0.8			0			1.5			0.48			0.2595			0.87	
09/09/23 4:00	0.8			0			1.5			0.52			0.2778			0.93	
09/09/23 5:00	0.8			0			1.5			0.52			0.28014			0.93	
09/09/23 6:00	0.8			0			1.5			0.52			0.2802			0.93	
09/09/23 7:00	0.9			0			1.5			0.44			0.23628			0.79	
09/09/23 8:00	0.8			0			1.5			0.52			0.2784			0.93	
09/09/23 9:00	0.8			0			1.5			0.43			0.228			0.76	
09/09/23 10:00	0.8			0			1.5			0.42			0.22488			0.75	
09/09/23 11:00	0.8			0			1.5			0.45			0.23874			0.8	
09/09/23 12:00	0.9			0			1.5			0.49			0.26118			0.87	
09/09/23 13:00	0.8			0			1.5			0.53			0.28122			0.94	
09/09/23 14:00	0.8			0			1.5			0.45			0.24162			0.81	
09/09/23 15:00	0.8			0			1.5			0.51			0.27348			0.91	
09/09/23 16:00	0.8			0			1.5			0.47			0.25266			0.84	
09/09/23 17:00	0.7			0			1.5			0.55			0.29298			0.98	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/09/23 18:00	0.2			1			1.5			0.7			0.37014			1.23	
09/09/23 19:00	0.7			0			1.5			0.59			0.31482			1.05	
09/09/23 20:00	0.8			0			1.5			0.52			0.27858			0.93	
09/09/23 21:00	0.9			0			1.5			0.6			0.32478			1.08	
09/09/23 22:00	0.9			0			1.5			0.57			0.30552			1.02	
09/09/23 23:00	0.8			0			1.5			0.46			0.24456			0.82	
09/10/23 0:00	0.8			0			1.5			0.49			0.26214			0.87	
09/10/23 1:00	0.9			0			1.5			0.45			0.2403			0.8	
09/10/23 2:00	0.8			0			1.5			0.44			0.23442			0.78	
09/10/23 3:00	0.8			0			1.5			0.47			0.25374			0.85	
09/10/23 4:00	0.9			0			1.5			0.43			0.22854			0.76	
09/10/23 5:00	0.8			0			1.5			0.47			0.25098			0.84	
09/10/23 6:00	0.8			0			1.5			0.5			0.26706			0.89	
09/10/23 7:00	0.8			0			1.5			0.5			0.26646			0.89	
09/10/23 8:00	0.8			0			1.5			0.54			0.28176			0.94	
09/10/23 9:00	0.8			0			1.5			0.47			0.2529			0.84	
09/10/23 10:00	0.8			0			1.5			0.45			0.24186			0.81	
09/10/23 11:00	0.8			0			1.5			0.42			0.22488			0.75	
09/10/23 12:00	0.8			0			1.5			0.42			0.22458			0.75	
09/10/23 13:00	0.8			0			1.5			0.45			0.24216			0.81	
09/10/23 14:00	0.8			0			1.5			0.48			0.25764			0.86	
09/10/23 15:00	0.7			0			1.5			0.45			0.23802			0.79	
09/10/23 16:00	0.8			0			1.5			0.49			0.26166			0.87	
09/10/23 17:00	0.3			1			1.5			0.72			0.37884			1.26	
09/10/23 18:00	0.2			1			1.5			0.72			0.3798			1.27	
09/10/23 19:00	0.5			0			1.5			0.64			0.34068			1.14	
09/10/23 20:00	0.9			0			1.5			0.52			0.27996			0.93	
09/10/23 21:00	1			0			1.5			0.6			0.31998			1.07	
09/10/23 22:00	0.8			0			1.5			0.58			0.31032			1.03	
09/10/23 23:00	0.9			0			1.5			0.42			0.22692			0.76	
09/11/23 0:00	0.9			0			1.5			0.42			0.2253			0.75	
09/11/23 1:00	0.9			0			1.5			0.42			0.22548			0.75	
09/11/23 2:00	0.9			0			1.5			0.42			0.22584			0.75	
09/11/23 3:00	0.9			0			1.5			0.42			0.22662			0.76	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/11/23 4:00	0.9			0			1.5			0.43			0.23016			0.77	
09/11/23 5:00	0.9			0			1.5			0.43			0.23166			0.77	
09/11/23 6:00	0.8			0			1.5			0.52			0.28164			0.94	
09/11/23 7:00	1.4			0			1.5			0.47			0.25218			0.84	
09/11/23 8:00	1.5			0			1.5			0.42			0.22596			0.75	
09/11/23 9:00	1			0			1.5			0.42			0.22542			0.75	
09/11/23 10:00	0.9			0			1.5			0.42			0.22482			0.75	
09/11/23 11:00	0.8			0			1.5			0.43			0.23004			0.77	
09/11/23 12:00	0.8			0			1.5			0.47			0.25278			0.84	
09/11/23 13:00	0.8			0			1.4			0.47			0.24846			0.83	
09/11/23 14:00	0.7			0			1.5			0.49			0.26352			0.88	
09/11/23 15:00	0.8			0			1.5			0.47			0.25152			0.84	
09/11/23 16:00	0.8			0			1.5			0.47			0.25134			0.84	
09/11/23 17:00	0.8			0			1.5			0.45			0.2397			0.8	
09/11/23 18:00	0.8			0			1.5			0.48			0.25746			0.86	
09/11/23 19:00	0.8			0			1.5			0.43			0.2274			0.76	
09/11/23 20:00	0.8			0			1.5			0.45			0.23856			0.8	
09/11/23 21:00	0.8			0			1.5			0.48			0.25548			0.85	
09/11/23 22:00	0.8			0			1.5			0.43			0.23274			0.78	
09/11/23 23:00	0.8			0			1.5			0.42			0.22494			0.75	
09/12/23 0:00	0.8			0			1.5			0.42			0.22506			0.75	
09/12/23 1:00	0.8			0			1.5			0.45			0.22506			0.75	
09/12/23 2:00	0.8			0			1.5			0.49			0.22512			0.75	
09/12/23 3:00	0.8			0			1.5			0.53			0.22536			0.75	
09/12/23 4:00	0.8			0			1.5			0.57			0.22548			0.75	
09/12/23 5:00	0.8			0			1.5			0.55			0.2256			0.75	
09/12/23 6:00	0.8			0			1.5			0.56			0.22554			0.75	
09/12/23 7:00	0.8			0			1.5			0.46			0.22602			0.75	
09/12/23 8:00	0.8			0			1.5			0.42			0.22584			0.75	
09/12/23 9:00	0.8			0			1.5			0.42			0.22554			0.75	
09/12/23 10:00	0.8			0			1.5			0.42			0.22542			0.75	
09/12/23 11:00	0.8			0			1.5			0.42			0.22506			0.75	
09/12/23 12:00	0.8			0			1.5			0.42			0.22476			0.75	
09/12/23 13:00	0.8			-1			1.5			0.42			0.2241			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/12/23 14:00	0.8			0			1.5			0.43			0.22764			0.76	
09/12/23 15:00	0.8			0			1.5			0.43			0.22728			0.76	
09/12/23 16:00	0.8			0			1.5			0.42			0.2232			0.74	
09/12/23 17:00	0.8			0			1.5			0.42			0.22308			0.74	
09/12/23 18:00	0.8			0			1.5			0.42			0.22296			0.74	
09/12/23 19:00	0.9			0			1.5			0.48			0.25656			0.86	
09/12/23 20:00	1			0			1.5			0.59			0.3144			1.05	
09/12/23 21:00	0.9			0			1.4			0.44			0.23802			0.79	
09/12/23 22:00	0.8			0			1.5			0.42			0.22434			0.75	
09/12/23 23:00	0.8			0			1.5			0.42			0.2244			0.75	
09/13/23 0:00	0.8			0			1.5			0.42			0.22446			0.75	
09/13/23 1:00	0.8			0			1.5			0.42			0.22464			0.75	
09/13/23 2:00	0.9			0			1.5			0.42			0.22482			0.75	
09/13/23 3:00	0.9			0			1.5			0.42			0.22512			0.75	
09/13/23 4:00	0.9			0			1.5			0.42			0.22566			0.75	
09/13/23 5:00	0.9			0			1.5			0.42			0.2259			0.75	
09/13/23 6:00	0.9			0			1.5			0.42			0.22578			0.75	
09/13/23 7:00	0.9			0			1.5			0.42			0.22554			0.75	
09/13/23 8:00	0.9			0			1.5			0.42			0.22566			0.75	
09/13/23 9:00	0.8			0			1.5			0.42			0.22542			0.75	
09/13/23 10:00	0.8			-1			1.5			0.42			0.22518			0.75	
09/13/23 11:00	0.8			0			1.5			0.45			0.24096			0.8	
09/13/23 12:00	1			0			1.5			0.59			0.31326			1.04	
09/13/23 13:00	0.9			0			1.4			0.48			0.25488			0.85	
09/13/23 14:00	0.8			0			1.5			0.5			0.26724			0.89	
09/13/23 15:00	0.8			0			1.5			0.6			0.3171			1.06	
09/13/23 16:00	0.8			0			1.5			0.6			0.31722			1.06	
09/13/23 17:00	0.7			0			1.5			0.61			0.32028			1.07	
09/13/23 18:00	0.8			0			1.5			0.6			0.31974			1.07	
09/13/23 19:00	0.8			0			1.5			0.6			0.31656			1.06	
09/13/23 20:00	0.9			0			1.5			0.6			0.31602			1.05	
09/13/23 21:00	1			0			1.4			0.51			0.27294			0.91	
09/13/23 22:00	0.8			0			1.4			0.42			0.22404			0.75	
09/13/23 23:00	0.8			0			1.5			0.42			0.22416			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/14/23 0:00	0.8			0			1.5			0.43			0.22944			0.76	
09/14/23 1:00	0.8			0			1.5			0.43			0.22902			0.76	
09/14/23 2:00	0.8			0			1.6			0.49			0.26202			0.87	
09/14/23 3:00	0.8			0			1.5			0.42			0.225			0.75	
09/14/23 4:00	0.8			0			1.5			0.42			0.22518			0.75	
09/14/23 5:00	0.8			0			1.5			0.43			0.23064			0.77	
09/14/23 6:00	0.8			0			1.5			0.5			0.26712			0.89	
09/14/23 7:00	0.9			0			1.5			0.46			0.24552			0.82	
09/14/23 8:00	0.8			0			1.5			0.43			0.22974			0.77	
09/14/23 9:00	0.8			0			1.5			0.48			0.25854			0.86	
09/14/23 10:00	0.8			0			1.5			0.51			0.2751			0.92	
09/14/23 11:00	0.9			0			1.5			0.52			0.2784			0.93	
09/14/23 12:00	1			0			1.6			0.6			0.31536			1.05	
09/14/23 13:00	0.8			0			1.5			0.52			0.2754			0.92	
09/14/23 14:00	0.8			0			1.5			0.52			0.27516			0.92	
09/14/23 15:00	0.8			0			1.5			0.56			0.29976			1	
09/14/23 16:00	0.6			0			1.5			0.63			0.33036			1.1	
09/14/23 17:00	0.5			0			1.5			0.64			0.33672			1.12	
09/14/23 18:00	0.6			0			1.4			0.63			0.33138			1.1	
09/14/23 19:00	0.8			0			1.5			0.6			0.31614			1.05	
09/14/23 20:00	1			0			1.5			0.59			0.31452			1.05	
09/14/23 21:00	0.8			0			1.5			0.62			0.32826			1.09	
09/14/23 22:00	0.9			0			1.5			0.57			0.3033			1.01	
09/14/23 23:00	0.8			0			1.5			0.45			0.24072			0.8	
09/15/23 0:00	0.8			0			1.5			0.44			0.23718			0.79	
09/15/23 1:00	0.8			0			1.5			0.43			0.2283			0.76	
09/15/23 2:00	0.8			0			1.5			0.42			0.22728			0.76	
09/15/23 3:00	0.8			0			1.5			0.42			0.2253			0.75	
09/15/23 4:00	0.8			0			1.5			0.43			0.22962			0.77	
09/15/23 5:00	0.9			0			1.5			0.49			0.2655			0.89	
09/15/23 6:00	0.4			0			1.5			0.69			0.36498			1.22	
09/15/23 7:00	0.9			0			1.5			0.52			0.2793			0.93	
09/15/23 8:00	0.8			0			1.5			0.43			0.22932			0.76	
09/15/23 9:00	0.8			0			1.5			0.42			0.22578			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/15/23 10:00	0.8			0			1.5			0.42			0.2256			0.75	
09/15/23 11:00	0.9			0			1.5			0.42			0.22536			0.75	
09/15/23 12:00	0.8			0			1.5			0.43			0.22692			0.76	
09/15/23 13:00	0.8			0			1.4			0.43			0.22638			0.75	
09/15/23 14:00	0.8			0			1.5			0.45			0.2388			0.8	
09/15/23 15:00	0.9			0			1.5			0.51			0.27312			0.91	
09/15/23 16:00	0.6			0			1.5			0.64			0.33912			1.13	
09/15/23 17:00	0.4			0			1.5			0.67			0.35214			1.17	
09/15/23 18:00	0.3			1			1.5			0.7			0.3687			1.23	
09/15/23 19:00	0.6			0			1.5			0.63			0.33162			1.11	
09/15/23 20:00	0.6			0			1.5			0.65			0.34278			1.14	
09/15/23 21:00	0.7			0			1.5			0.63			0.33576			1.12	
09/15/23 22:00	0.8			0			1.5			0.62			0.32814			1.09	
09/15/23 23:00	1			0			1.5			0.56			0.3018			1.01	
09/16/23 0:00	0.8			0			1.5			0.46			0.2493			0.83	
09/16/23 1:00	0.8			0			1.5			0.44			0.23436			0.78	
09/16/23 2:00	0.8			0			1.5			0.43			0.23028			0.77	
09/16/23 3:00	0.8			0			1.5			0.42			0.22554			0.75	
09/16/23 4:00	0.8			0			1.5			0.42			0.22584			0.75	
09/16/23 5:00	0.8			0			1.5			0.42			0.22698			0.76	
09/16/23 6:00	0.8			0			1.5			0.42			0.22608			0.75	
09/16/23 7:00	0.8			0			1.5			0.42			0.22608			0.75	
09/16/23 8:00	0.8			0			1.5			0.42			0.22698			0.76	
09/16/23 9:00	0.8			0			1.5			0.43			0.2295			0.77	
09/16/23 10:00	0.8			0			1.5			0.44			0.23646			0.79	
09/16/23 11:00	0.8			0			1.5			0.47			0.25086			0.84	
09/16/23 12:00	0.8			0			1.5			0.51			0.2706			0.9	
09/16/23 13:00	0.7			0			1.5			0.5			0.26586			0.89	
09/16/23 14:00	0.8			0			1.5			0.46			0.246			0.82	
09/16/23 15:00	0.8			0			1.5			0.47			0.2499			0.83	
09/16/23 16:00	0.8			0			1.4			0.42			0.22392			0.75	
09/16/23 17:00	0.8			0			1.5			0.44			0.23634			0.79	
09/16/23 18:00	0.8			0			1.5			0.43			0.22842			0.76	
09/16/23 19:00	0.8			0			1.4			0.42			0.22464			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/16/23 20:00	0.8			0			1.5			0.42			0.22452			0.75	
09/16/23 21:00	0.8			0			1.5			0.42			0.22476			0.75	
09/16/23 22:00	0.8			0			1.5			0.42			0.22482			0.75	
09/16/23 23:00	0.8			0			1.5			0.42			0.22512			0.75	
09/17/23 0:00	0.8			0			1.5			0.42			0.22542			0.75	
09/17/23 1:00	0.8			0			1.5			0.42			0.2256			0.75	
09/17/23 2:00	0.8			0			1.5			0.42			0.22578			0.75	
09/17/23 3:00	0.9			0			1.5			0.42			0.22578			0.75	
09/17/23 4:00	0.8			0			1.5			0.42			0.2259			0.75	
09/17/23 5:00	0.8			0			1.5			0.42			0.22602			0.75	
09/17/23 6:00	0.8			0			1.5			0.42			0.22602			0.75	
09/17/23 7:00	0.8			0			1.5			0.42			0.22614			0.75	
09/17/23 8:00	0.8			0			1.5			0.42			0.22614			0.75	
09/17/23 9:00	0.8			0			1.5			0.42			0.22596			0.75	
09/17/23 10:00	0.8			0			1.5			0.42			0.22566			0.75	
09/17/23 11:00	0.8			0			1.5			0.42			0.22542			0.75	
09/17/23 12:00	0.8			0			1.5			0.42			0.225			0.75	
09/17/23 13:00	0.9			0			1.5			0.42			0.22488			0.75	
09/17/23 14:00	0.8			0			1.5			0.42			0.2247			0.75	
09/17/23 15:00	0.8			0			1.5			0.42			0.22458			0.75	
09/17/23 16:00	0.8			0			1.5			0.42			0.22428			0.75	
09/17/23 17:00	0.8			0			1.5			0.43			0.23142			0.77	
09/17/23 18:00	0.8			0			1.4			0.43			0.22716			0.76	
09/17/23 19:00	0.8			0			1.5			0.42			0.22548			0.75	
09/17/23 20:00	0.8			0			1.5			0.43			0.23208			0.77	
09/17/23 21:00	0.8			0			1.5			0.42			0.22548			0.75	
09/17/23 22:00	0.8			0			1.5			0.42			0.22578			0.75	
09/17/23 23:00	0.9			0			1.5			0.42			0.2262			0.75	
09/18/23 0:00	0.9			0			1.5			0.42			0.22638			0.75	
09/18/23 1:00	0.9			0			1.5			0.42			0.2262			0.75	
09/18/23 2:00	0.9			0			1.5			0.42			0.2262			0.75	
09/18/23 3:00	0.9			0			1.5			0.42			0.22638			0.75	
09/18/23 4:00	0.9			0			1.5			0.42			0.22638			0.75	
09/18/23 5:00	0.9			0			1.5			0.42			0.22644			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/18/23 6:00	0.9			0			1.5			0.42			0.22656			0.76	
09/18/23 7:00	0.9			0			1.5			0.42			0.22668			0.76	
09/18/23 8:00	0.9			0			1.5			0.42			0.22644			0.75	
09/18/23 9:00	0.9			0			1.5			0.42			0.22596			0.75	
09/18/23 10:00	0.8			0			1.5			0.42			0.22596			0.75	
09/18/23 11:00	0.9			0			1.5			0.42			0.22572			0.75	
09/18/23 12:00	0.9			0			1.4			0.42			0.22524			0.75	
09/18/23 13:00	0.9			0			1.5			0.42			0.22506			0.75	
09/18/23 14:00	0.8			0			1.5			0.42			0.22488			0.75	
09/18/23 15:00	0.8			0			1.5			0.42			0.22446			0.75	
09/18/23 16:00	0.8			0			1.5			0.42			0.22452			0.75	
09/18/23 17:00	0.8			0			1.5			0.45			0.24174			0.81	
09/18/23 18:00	0.8			0			1.5			0.48			0.2589			0.86	
09/18/23 19:00	0.8			0			1.4			0.43			0.23136			0.77	
09/18/23 20:00	0.8			0			1.5			0.42			0.22602			0.75	
09/18/23 21:00	0.8			0			1.5			0.42			0.22692			0.76	
09/18/23 22:00	0.8			0			1.5			0.42			0.22656			0.76	
09/18/23 23:00	0.8			0			1.5			0.42			0.22554			0.75	
09/19/23 0:00	0.9			0			1.5			0.42			0.22578			0.75	
09/19/23 1:00	0.9			0			1.5			0.42			0.22602			0.75	
09/19/23 2:00	0.9			0			1.5			0.42			0.2262			0.75	
09/19/23 3:00	0.9			0			1.5			0.42			0.22626			0.75	
09/19/23 4:00	0.9			0			1.5			0.42			0.22686			0.76	
09/19/23 5:00	0.9			0			1.5			0.45			0.24102			0.8	
09/19/23 6:00	0.7			0			1.5			0.5			0.26838			0.89	
09/19/23 7:00	0.8			0			1.5			0.44			0.23868			0.8	
09/19/23 8:00	0.9			0			1.5			0.42			0.2265			0.76	
09/19/23 9:00	0.9			0			1.5			0.42			0.22626			0.75	
09/19/23 10:00	0.9			0			1.5			0.42			0.22608			0.75	
09/19/23 11:00	0.9			0			1.5			0.42			0.22578			0.75	
09/19/23 12:00	0.9			0			1.5			0.42			0.22548			0.75	
09/19/23 13:00	0.8			0			1.5			0.42			0.22524			0.75	
09/19/23 14:00	0.8			0			1.5			0.42			0.22476			0.75	
09/19/23 15:00	0.8			0			1.5			0.42			0.22458			0.75	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/19/23 16:00	0.8			0			1.5			0.42			0.22416			0.75	
09/19/23 17:00	0.8			0			1.5			0.44			0.23628			0.79	
09/19/23 18:00	0.8			0			1.5			0.46			0.246			0.82	
09/19/23 19:00	0.8			0			1.4			0.42			0.2244			0.75	
09/19/23 20:00	0.8			0			1.5			0.42			0.22482			0.75	
09/19/23 21:00	0.8			0			1.5			0.42			0.22644			0.75	
09/19/23 22:00	0.8			0			1.5			0.42			0.22518			0.75	
09/19/23 23:00	0.8			0			1.5			0.42			0.22524			0.75	
09/20/23 0:00	0.9			0			1.5			0.42			0.2256			0.75	
09/20/23 1:00	0.9			0			1.5			0.42			0.22536			0.75	
09/20/23 2:00	0.9			0			1.6			0.42			0.22566			0.75	
09/20/23 3:00	0.9			0			1.5			0.42			0.22566			0.75	
09/20/23 4:00	0.9			0			1.5			0.42			0.22584			0.75	
09/20/23 5:00	0.9			0			1.5			0.42			0.22728			0.76	
09/20/23 6:00	0.9			0			1.5			0.43			0.2301			0.77	
09/20/23 7:00	0.9			0			1.5			0.42			0.2274			0.76	
09/20/23 8:00	0.9			0			1.5			0.42			0.22596			0.75	
09/20/23 9:00	0.9			0			1.5			0.42			0.22578			0.75	
09/20/23 10:00	0.9			0			1.5			0.42			0.22554			0.75	
09/20/23 11:00	0.9			0			1.5			0.44			0.18126			0.6	
09/20/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 17:00	0	X		0	X		0	X		0.45			0	X		0	X
09/20/23 18:00	0	X		0	X		0	X		0.48			0	X		0	X
09/20/23 19:00	0	X		0	X		0	X		0.48			0	X		0	X
09/20/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/20/23 21:00	0	X		0	X		0	X		0.44			0	X		0	X
09/20/23 22:00	0	X		0	X		0	X		0.44			0	X		0	X
09/20/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 0:00	0	X		0	X		0	X		0.42			0	X		0	X
09/21/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/21/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 6:00	0	X		0	X		0	X		0.53			0	X		0	X
09/21/23 7:00	0	X		0	X		0	X		0.49			0	X		0	X
09/21/23 8:00	0	X		0	X		0	X		0.46			0	X		0	X
09/21/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
09/21/23 10:00	0	X		0	X		0	X		0.47			0	X		0	X
09/21/23 11:00	0	X		0	X		0	X		0.45			0	X		0	X
09/21/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 13:00	0	X		0	X		0	X		0.48			0	X		0	X
09/21/23 14:00	0	X		0	X		0	X		0.53			0	X		0	X
09/21/23 15:00	0	X		0	X		0	X		0.51			0	X		0	X
09/21/23 16:00	0	X		0	X		0	X		0.49			0	X		0	X
09/21/23 17:00	0	X		0	X		0	X		0.47			0	X		0	X
09/21/23 18:00	0	X		0	X		0	X		0.52			0	X		0	X
09/21/23 19:00	0	X		0	X		0	X		0.44			0	X		0	X
09/21/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 21:00	0	X		0	X		0	X		0.45			0	X		0	X
09/21/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/21/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 6:00	0	X		0	X		0	X		0.46			0	X		0	X
09/22/23 7:00	0	X		0	X		0	X		0.51			0	X		0	X
09/22/23 8:00	0	X		0	X		0	X		0.47			0	X		0	X
09/22/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/22/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 14:00	0	X		0	X		0	X		0.45			0	X		0	X
09/22/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 16:00	0	X		0	X		0	X		0.48			0	X		0	X
09/22/23 17:00	0	X		0	X		0	X		0.54			0	X		0	X
09/22/23 18:00	0	X		0	X		0	X		0.54			0	X		0	X
09/22/23 19:00	0	X		0	X		0	X		0.54			0	X		0	X
09/22/23 20:00	0	X		0	X		0	X		0.52			0	X		0	X
09/22/23 21:00	0	X		0	X		0	X		0.48			0	X		0	X
09/22/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/22/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
09/23/23 8:00	0	X		0	X		0	X		0.44			0	X		0	X
09/23/23 9:00	0	X		0	X		0	X		0.44			0	X		0	X
09/23/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 17:00	0	X		0	X		0	X		0.45			0	X		0	X
09/23/23 18:00	0	X		0	X		0	X		0.46			0	X		0	X
09/23/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/23/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/23/23 22:00	0	X		0	X		0	X		0.46			0	X		0	X
09/23/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 7:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 15:00	0	X		0	X		0	X		0.44			0	X		0	X
09/24/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/24/23 17:00	0	X		0	X		0	X		0.48			0	X		0	X
09/24/23 18:00	0	X		0	X		0	X		0.54			0	X		0	X
09/24/23 19:00	0	X		0	X		0	X		0.52			0	X		0	X
09/24/23 20:00	0	X		0	X		0	X		0.49			0	X		0	X
09/24/23 21:00	0	X		0	X		0	X		0.53			0	X		0	X
09/24/23 22:00	0	X		0	X		0	X		0.45			0	X		0	X
09/24/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 6:00	0	X		0	X		0	X		0.5			0	X		0	X
09/25/23 7:00	0	X		0	X		0	X		0.47			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/25/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 16:00	0	X		0	X		0	X		0.44			0	X		0	X
09/25/23 17:00	0	X		0	X		0	X		0.49			0	X		0	X
09/25/23 18:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/25/23 21:00	0	X		0	X		0	X		0.48			0	X		0	X
09/25/23 22:00	0	X		0	X		0	X		0.47			0	X		0	X
09/25/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 5:00	0	X		0	X		0	X		0.45			0	X		0	X
09/26/23 6:00	0	X		0	X		0	X		0.49			0	X		0	X
09/26/23 7:00	0	X		0	X		0	X		0.45			0	X		0	X
09/26/23 8:00	0			0	X		0			0.53			0.02358			0.08	
09/26/23 9:00	0.8			0			1.8			0.47			0.23196			0.77	
09/26/23 10:00	0.8			0			1.5			0.43			0.22872			0.76	
09/26/23 11:00	0.8			0			1.5			0.43			0.22686			0.76	
09/26/23 12:00	0.8			0			1.5			0.43			0.2268			0.76	
09/26/23 13:00	0.8			0			1.5			0.47			0.1989			0.66	
09/26/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 17:00	0	X		0	X		0	X		0.44			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 18:00	0	X		0	X		0	X		0.48			0	X		0	X
09/26/23 19:00	0	X		0	X		0	X		0.44			0	X		0	X
09/26/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X
09/26/23 22:00	0	X		0	X		0	X		0.44			0	X		0	X
09/26/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 7:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 17:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 18:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/27/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/28/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 6:00	0	X		0	X		0	X		0.46			0	X		0	X
09/28/23 7:00	0	X		0	X		0	X		0.49			0	X		0	X
09/28/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 17:00	0	X		0	X		0	X		0.44			0	X		0	X
09/28/23 18:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/28/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 7:00	0	X		0	X		0	X		0.44			0	X		0	X
09/29/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/29/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 17:00	0	X		0	X		0	X		0.47			0	X		0	X
09/29/23 18:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/29/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 0:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 1:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 2:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 3:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 4:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 5:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 6:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 7:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 8:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 9:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 10:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 11:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 12:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 13:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 14:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 15:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 16:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 17:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 18:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 19:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 20:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 21:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 22:00	0	X		0	X		0	X		0.43			0	X		0	X
09/30/23 23:00	0	X		0	X		0	X		0.43			0	X		0	X

CT1 SUSD EVENT 1

Date/Tim Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/03/23 2:23	338254.2			0.6			1.54			0.5			1.99			0	
09/03/23 2:24	338100.1			0.6			1.54			0.5			1.99			0	
09/03/23 2:25	338023.1			0.6			1.54			0.5			1.99			0	
09/03/23 2:26	338331.2			0.6			1.54			0.5			1.99			0	
09/03/23 2:27	338023.1			0.6			1.54			0.5			1.99			0	
09/03/23 2:28	338100.1			0.6			1.54			0.5			1.99			1	
09/03/23 2:29	333941.3			0.6			1.54			0.49			1.96			1	
09/03/23 2:30	314764.3			0.7			1.52			0.52			1.82			1	
09/03/23 2:31	292352.6			0.7			1.97			0.48			2.19			1	
09/03/23 2:32	270095			0.7			2.36			0.45			2.43			1	
09/03/23 2:33	248222.5			0.7			3.09			0.38			2.92			1	
09/03/23 2:34	225810.8			0.5			6.29			0.25			5.41			1	
09/03/23 2:35	203168.1			0.3			20.91			0.15			16.18			1	
09/03/23 2:36	177598.8			2			27.68			0.84			18.72			1	
09/03/23 2:37	157112.6			96.8			32.12			35.17			19.22			1	
09/03/23 2:38	138166.7			826			35.25			264.03			18.54			1	
09/03/23 2:39	34349.1			1824			34.88			144.94			4.56			1	
09/03/23 2:40	0			0			45.38			0			0			0	
09/03/23 2:41	0			0			0.3			0			0			0	
09/03/23 2:42	0			0			0.2			0			0			0	
09/03/23 2:43	0			0			0.2			0			0			0	
09/03/23 2:44	0			0			0.2			0			0			0	

CT1 SUSD EVENT 2

Date/Tim Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/03/23 11:04	0			0			0			0			0			0	
09/03/23 11:05	0			0			0			0			0			0	
09/03/23 11:06	0			0			0			0			0			0	
09/03/23 11:07	0			0			0			0			0			0	
09/03/23 11:08	0			0			0			0			0			0	
09/03/23 11:09	0			-0.1			0			0			0			1	
09/03/23 11:10	0			-0.1			0			0			0			1	
09/03/23 11:11	23797.9			25.6			13.77			1.41			1.25			1	
09/03/23 11:12	40895.5			859.4			11.8			81.38			1.84			1	
09/03/23 11:13	55682.5			454			16.72			58.43			3.54			1	
09/03/23 11:14	78556.3			216.2			21.54			39.3			6.44			1	
09/03/23 11:15	123533.6			136.8			24.14			39.1			11.35			1	
09/03/23 11:16	137858.6			99.6			39.11			31.78			20.53			1	
09/03/23 11:17	145175.1			711.4			43.58			238.88			24.08			1	
09/03/23 11:18	160501.3			1934.6			42.04			718.45			25.69			1	
09/03/23 11:19	180525.4			1768.3			45.18			738.62			31.06			1	
09/03/23 11:20	204092.3			622.6			46.61			293.92			36.21			1	
09/03/23 11:21	226889			46.7			46.3			24.51			40			1	
09/03/23 11:22	248761.6			3.1			46.27			1.8			43.83			1	
09/03/23 11:23	274716			1.5			39.72			0.94			41.54			1	
09/03/23 11:24	297281.7			1.3			17.51			0.9			19.82			1	
09/03/23 11:25	316458.6			1.2			11.89			0.9			14.32			1	
09/03/23 11:26	336020.7			1.2			9.98			0.94			12.76			1	
09/03/23 11:27	352502.1			1.2			8.76			0.99			11.76			1	
09/03/23 11:28	370446.8			1.1			6.78			0.91			9.56			1	
09/03/23 11:29	392165.3			0.9			6.08			0.82			9.08			1	
09/03/23 11:30	414500			0.8			6.18			0.8			9.75			1	
09/03/23 11:31	438837			0.7			6.18			0.67			10.33			1	
09/03/23 11:32	436141.4			0.6			7.65			0.56			12.7			1	
09/03/23 11:33	434909.2			0.6			7.65			0.56			12.67			1	
09/03/23 11:34	430057.2			0.6			7.38			0.55			12.07			1	
09/03/23 11:35	416502.4			0.6			7.38			0.53			11.69			1	

Monday, October 30, 2023

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/03/23 11:36	409570.9			0.6			5.72			0.52			8.91			1	
09/03/23 11:37	406644.3			0.6			3.41			0.52			5.28			1	
09/03/23 11:38	404410.9			0.6			2.95			0.52			4.54			1	
09/03/23 11:39	394244.8			0.6			3.6			0.5			5.4			1	
09/03/23 11:40	385619			0.6			4.7			0.49			6.9			1	
09/03/23 11:41	379457.7			0.5			5.08			0.48			7.34			1	
09/03/23 11:42	372911.3			0.5			3.54			0.47			5.03			1	
09/03/23 11:43	366750.1			0.5			2.18			0.46			3.04			1	
09/03/23 11:44	360819.8			0.5			2.09			0.45			2.87			1	
09/03/23 11:45	355890.8			0.5			2.54			0.45			3.44			1	
09/03/23 11:46	351115.8			0.5			3.13			0.44			4.18			1	
09/03/23 11:47	348343.3			0.5			3.31			0.43			4.39			1	
09/03/23 11:48	347265			0.5			3.4			0.43			4.49			1	
09/03/23 11:49	346802.9			0.5			2.68			0.43			3.54			1	
09/03/23 11:50	346571.9			0.5			2.23			0.43			2.95			1	
09/03/23 11:51	346263.8			0.5			2.06			0.43			2.71			1	
09/03/23 11:52	344338.4			0.5			1.91			0.43			2.5			1	
09/03/23 11:53	343722.3			0.5			1.91			0.43			2.49			1	
09/03/23 11:54	343260.2			0.5			2			0.43			2.61			1	
09/03/23 11:55	343491.3			0.5			2.09			0.43			2.73			0	
09/03/23 11:56	343491.3			0.5			2.18			0.43			2.85			0	
09/03/23 11:57	343106.2			0.5			2.18			0.43			2.85			0	
09/03/23 11:58	343106.2			0.5			1.54			0.43			2.02			0	
09/03/23 11:59	340949.7			0.5			1.27			0.43			1.65			0	

CT1 SUSD EVENT 3

Date/Tim Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/07/23 23:49	340025.5			0.6			1.54			0.5			2			0	
09/07/23 23:50	340025.5			0.6			1.54			0.5			2			0	
09/07/23 23:51	340102.5			0.6			1.54			0.5			2			0	
09/07/23 23:52	340025.5			0.6			1.54			0.5			2			0	
09/07/23 23:53	340256.6			0.6			1.54			0.5			2			0	
09/07/23 23:54	339486.4			0.6			1.45			0.5			1.88			1	
09/07/23 23:55	327394.9			0.6			1.54			0.48			1.92			1	
09/07/23 23:56	305753.4			0.7			1.52			0.51			1.77			1	
09/07/23 23:57	282571.6			0.7			2.15			0.47			2.31			1	
09/07/23 23:58	260314			0.7			2.49			0.44			2.47			1	
09/07/23 23:59	237132.2			0.6			3.33			0.31			3.01			1	
09/08/23 0:00	215798.8			0.5			6			0.25			4.93			1	
09/08/23 0:01	191230.7			0.3			20.81			0.14			15.15			1	
09/08/23 0:02	167278.7			2.9			26.25			1.12			16.72			1	
09/08/23 0:03	148794.9			226			29.91			77.8			16.95			1	
09/08/23 0:04	129617.9			1166.2			31.52			349.54			15.55			1	
09/08/23 0:05	0			1949.6			32.27			0			0			1	
09/08/23 0:06	0			0			42.78			0			0			0	
09/08/23 0:07	0			0			0.3			0			0			0	
09/08/23 0:08	0			0			0.2			0			0			0	
09/08/23 0:09	0			0			0.2			0			0			0	
09/08/23 0:10	0			0			0.1			0			0			0	

CT1 SUSD EVENT 4

Date/Tim Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/08/23 12:05	0			0			0			0			0			0	
09/08/23 12:06	0			0			0			0			0			0	
09/08/23 12:07	0			0			0			0			0			0	
09/08/23 12:08	4235.9			0			0			0			0			0	
09/08/23 12:09	24953.2			0			0			0			0			0	
09/08/23 12:10	24876.2			0			0			0			0			1	
09/08/23 12:11	31730.6			0			0			0			0			1	
09/08/23 12:12	41511.6			59			41.3			5.67			6.53			1	
09/08/23 12:13	52062.8			1079.3			16.01			129.98			3.17			1	
09/08/23 12:14	63461.2			753.8			21.86			110.69			5.28			1	
09/08/23 12:15	81868			364.6			25.96			69.05			8.09			1	
09/08/23 12:16	124303.8			198.2			35.4			57.01			16.76			1	
09/08/23 12:17	140785.2			113.5			51.28			36.95			27.49			1	
09/08/23 12:18	149334			365.2			61.66			126.15			35.05			1	
09/08/23 12:19	166123.5			1931.9			57.34			742.51			36.27			1	
09/08/23 12:20	188612.1			1614.1			61.13			704.21			43.89			1	
09/08/23 12:21	212718.1			218.4			62.74			107.48			50.8			1	
09/08/23 12:22	232665.3			19.5			59.88			10.47			53.03			1	
09/08/23 12:23	257695.4			1.9			54.32			1.13			53.29			1	
09/08/23 12:24	282571.6			1.5			37.74			1			40.6			1	
09/08/23 12:25	303597			1.4			17.88			0.97			20.67			1	
09/08/23 12:26	324160.2			1.5			12.25			1.14			15.11			1	
09/08/23 12:27	341488.8			1.5			11.18			1.18			14.54			1	
09/08/23 12:28	356583.9			1.4			8.05			1.18			10.92			1	
09/08/23 12:29	358971.4			1.4			6.54			1.13			8.93			1	
09/08/23 12:30	351886			1.2			7.26			0.96			9.73			1	
09/08/23 12:31	348420.3			1			7.06			0.79			9.37			1	
09/08/23 12:32	347111			1			6.26			0.79			8.27			1	
09/08/23 12:33	346263.8			0.9			6.17			0.73			8.14			1	
09/08/23 12:34	345647.7			0.8			5.99			0.65			7.88			1	
09/08/23 12:35	345262.6			0.7			5.72			0.58			7.52			1	
09/08/23 12:36	345339.6			0.7			5.54			0.58			7.28			1	

Monday, October 30, 2023

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/08/23 12:37	344800.5			0.6			5.36			0.51			7.03			1	
09/08/23 12:38	344492.4			0.6			5.26			0.51			6.9			1	
09/08/23 12:39	344261.4			0.6			5.17			0.51			6.78			1	
09/08/23 12:40	343876.3			0.6			5.17			0.51			6.77			1	
09/08/23 12:41	343491.3			0.6			5.16			0.51			6.75			1	
09/08/23 12:42	343645.3			0.6			5.07			0.51			6.63			1	
09/08/23 12:43	343106.2			0.6			4.98			0.44			6.5			1	
09/08/23 12:44	343337.2			0.6			4.98			0.44			6.51			1	
09/08/23 12:45	342952.1			0.6			4.98			0.44			6.5			1	
09/08/23 12:46	342875.1			0.6			4.98			0.44			6.5			1	
09/08/23 12:47	342182			0.6			4.98			0.44			6.48			1	
09/08/23 12:48	342336			0.6			4.98			0.44			6.49			1	
09/08/23 12:49	342490			0.6			4.79			0.44			6.25			1	
09/08/23 12:50	342182			0.6			4.52			0.44			5.88			1	
09/08/23 12:51	341873.9			0.6			4.24			0.44			5.52			1	
09/08/23 12:52	341796.9			0.6			3.23			0.44			4.2			1	
09/08/23 12:53	341565.8			0.6			3.04			0.44			3.96			1	
09/08/23 12:54	341411.8			0.6			2.95			0.44			3.83			1	
09/08/23 12:55	341488.8			0.6			2.95			0.44			3.84			1	
09/08/23 12:56	341334.8			0.6			3.23			0.44			4.19			1	
09/08/23 12:57	341411.8			0.6			3.41			0.44			4.43			1	
09/08/23 12:58	341334.8			0.6			2.58			0.44			3.35			1	
09/08/23 12:59	341257.8			0.6			2.12			0.44			2.76			1	
09/08/23 13:00	341026.7			0.6			2.03			0.44			2.63			1	
09/08/23 13:01	341103.8			0.6			1.84			0.44			2.39			1	
09/08/23 13:02	340872.7			0.6			1.94			0.44			2.51			1	
09/08/23 13:03	348343.3			0.6			2.12			0.45			2.81			0	
09/08/23 13:04	363592.4			0.6			2.25			0.47			3.11			0	
09/08/23 13:05	369907.7			0.5			2.28			0.41			3.22			0	
09/08/23 13:06	371833.1			0.5			2.06			0.4			2.92			0	
09/08/23 13:07	372295.2			0.5			1.78			0.4			2.52			0	

Monthly Summary By Day Report

Unit CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2023	16.56	60.17	6.2	13.10	21.79
07/02/2023	16.28	68.41	7.0	14.73	24.57
07/03/2023	18.70	62.30	6.4	13.49	22.48
07/04/2023	16.63	54.01	5.5	11.74	19.61
07/05/2023	17.13	57.92	5.9	12.55	20.89
07/06/2023	21.73	62.31	6.6	13.50	22.53
07/07/2023	28.01	65.89	7.0	14.29	23.81
07/08/2023	20.62	61.34	6.4	13.34	22.31
07/09/2023	21.71	56.89	6.0	12.34	20.57
07/10/2023	14.50	49.21	4.9	10.70	17.83
07/11/2023	13.76	50.43	5.1	11.03	18.45
07/12/2023	13.33	50.60	5.2	11.01	18.39
07/13/2023	14.14	55.01	5.6	12.00	19.99
07/14/2023	17.56	65.21	6.9	14.23	23.76
07/15/2023	13.39	63.43	7.1	13.81	23.04
07/16/2023	14.58	63.60	7.2	13.91	23.23
07/17/2023	14.33	56.35	6.6	12.40	20.67
07/18/2023	14.56	64.46	7.2	14.08	23.49
07/19/2023	12.58	68.10	7.7	14.77	24.61
07/20/2023	14.04	64.12	7.4	14.07	23.47
07/21/2023	15.42	61.24	6.7	13.37	22.35
07/22/2023	15.88	57.56	6.2	12.59	21.00
07/23/2023	15.91	59.01	6.9	12.95	21.61
07/24/2023	14.00	52.44	5.7	11.47	19.14
07/25/2023	14.61	57.63	6.2	12.57	20.96
07/26/2023	12.61	67.49	7.8	14.69	24.47
07/27/2023	14.72	55.85	6.2	12.23	20.38
07/28/2023	15.81	54.17	5.6	11.93	19.87
07/29/2023	13.70	48.46	4.9	10.50	17.55
07/30/2023	13.62	47.94	4.8	10.37	17.34
07/31/2023	15.56	58.88	6.3	12.92	21.53
Monthly Avg/Sum:	495.98 sum	1,820.43 sum	195.2 sum	396.68 sum	661.69 sum
Daily Min:	12.58	47.94	4.8	10.37	17.34
Daily Max:	28.01	68.41	7.8	14.77	24.61
Jul 2023 - Jul 2023	495.98 sum	1,820.43 sum	195.2 sum	396.68 sum	661.69 sum
QTD:	495.98 sum	1,820.43 sum	195.2 sum	396.68 sum	661.69 sum
YTD 2023:	3,520.08 sum	4,890.13 sum	507.7 sum	1,001.80 sum	1,669.29 sum

Monthly Summary By Day Report

Unit CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2023	14.74	52.99	6.2	11.74	19.62
08/02/2023	13.62	49.74	5.1	10.90	18.15
08/03/2023	13.39	47.24	4.8	10.35	17.19
08/04/2023	14.45	49.28	5.2	10.79	17.88
08/05/2023	15.25	51.64	5.4	11.34	18.86
08/06/2023	16.00	52.66	5.5	11.56	19.27
08/07/2023	13.19	55.84	6.3	12.70	21.17
08/08/2023	11.55	48.70	4.9	10.70	17.81
08/09/2023	12.93	49.45	5.1	10.77	17.87
08/10/2023	11.89	47.46	4.9	10.39	17.26
08/11/2023	16.23	60.11	6.6	13.01	21.69
08/12/2023	13.03	49.71	5.1	10.88	18.13
08/13/2023	14.05	51.74	5.4	11.44	19.01
08/14/2023	13.11	62.57	6.9	13.76	22.97
08/15/2023	13.46	62.64	6.6	13.80	23.01
08/16/2023	10.94	63.19	6.9	13.87	23.11
08/17/2023	12.66	52.43	5.8	11.67	19.40
08/18/2023	11.31	45.86	4.8	10.03	16.70
08/19/2023	11.45	45.71	4.8	9.93	16.62
08/20/2023	12.10	45.65	4.8	9.97	16.74
08/21/2023	11.94	47.86	5.1	10.43	17.45
08/22/2023	11.96	46.50	4.8	10.13	16.93
08/23/2023	14.20	52.24	5.6	11.33	18.92
08/24/2023	13.07	46.57	4.9	10.25	17.16
08/25/2023	11.84	46.55	4.9	10.12	16.91
08/26/2023	12.20	47.45	4.8	10.37	17.24
08/27/2023	12.37	48.16	5.1	10.54	17.54
08/28/2023	13.26	49.58	5.3	10.85	18.10
08/29/2023	12.49	62.40	6.9	13.64	22.73
08/30/2023	14.27	52.78	5.7	11.41	19.07
08/31/2023	10.47	60.18	6.6	13.08	21.82
Monthly Avg/Sum:	403.42 sum	1,604.88 sum	170.8 sum	351.75 sum	586.33 sum
Daily Min:	10.47	45.65	4.8	9.93	16.62
Daily Max:	16.23	63.19	6.9	13.87	23.11
Jul 2023 - Aug 2023	899.40 sum	3,425.31 sum	366.0 sum	748.43 sum	1,248.02 sum
QTD:	899.40 sum	3,425.31 sum	366.0 sum	748.43 sum	1,248.02 sum
YTD 2023:	3,923.50 sum	6,495.01 sum	678.5 sum	1,353.55 sum	2,255.62 sum

Monthly Summary By Day Report

Unit CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:26 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2023	11.81	46.96	4.8	10.04	16.87
09/02/2023	12.37	47.47	4.9	10.29	17.17
09/03/2023	68.21	38.83	3.1	6.37	10.72
09/04/2023	12.22	47.78	5.0	10.37	17.30
09/05/2023	12.62	59.16	6.6	12.84	21.41
09/06/2023	12.06	49.36	5.1	10.84	18.07
09/07/2023	12.46	50.59	5.2	11.01	18.36
09/08/2023	56.39	33.51	3.6	7.14	11.88
09/09/2023	12.79	38.34	6.3	12.26	20.44
09/10/2023	12.65	50.80	5.7	12.12	20.23
09/11/2023	13.74	49.34	4.9	10.73	17.89
09/12/2023	13.92	39.14	5.3	11.02	18.40
09/13/2023	15.42	48.45	5.7	11.60	19.33
09/14/2023	15.53	57.09	6.1	12.45	20.71
09/15/2023	14.02	57.58	6.0	12.45	20.76
09/16/2023	12.54	48.41	4.9	10.52	17.51
09/17/2023	12.54	46.77	4.8	10.11	16.85
09/18/2023	12.48	47.10	4.8	10.18	16.99
09/19/2023	12.76	47.60	4.8	10.27	17.13
09/20/2023	13.76	47.44	4.8	10.37	17.25
09/21/2023	13.91	50.50	5.2	11.02	18.33
09/22/2023	13.99	49.44	5.1	10.86	18.10
09/23/2023	13.76	48.22	4.8	10.43	17.36
09/24/2023	13.49	49.84	5.1	10.76	17.98
09/25/2023	13.40	49.54	4.8	10.59	17.66
09/26/2023	13.98	49.25	4.9	10.68	17.82
09/27/2023	13.22	47.98	4.8	10.32	17.24
09/28/2023	14.58	48.06	4.8	10.42	17.33
09/29/2023	13.34	47.85	4.8	10.37	17.27
09/30/2023	13.31	47.58	4.8	10.32	17.18
Monthly Avg/Sum:	497.27 sum	1,439.98 sum	151.5 sum	318.75 sum	531.54 sum
Daily Min:	11.81	33.51	3.1	6.37	10.72
Daily Max:	68.21	59.16	6.6	12.84	21.41
Jul 2023 - Sep 2023	1,396.67 sum	4,865.29 sum	517.5 sum	1,067.18 sum	1,779.56 sum
QTD:	1,396.67 sum	4,865.29 sum	517.5 sum	1,067.18 sum	1,779.56 sum
YTD 2023:	4,420.77 sum	7,934.99 sum	830.0 sum	1,672.30 sum	2,787.16 sum

Startup / Shutdown Events

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:43 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
09/03/2023 03:00	09/03/2023 10:00	8
09/08/2023 01:00	09/08/2023 11:00	11

Startup / Shutdown Events

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:43 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	19.00 Hour(s)
Offline Percentage:	0.86 %
Total Online:	2,189.00 Hour(s)
Online Percentage:	99.14 %

Startup / Shutdown Events

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:43 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	09/03/2023 02:28	09/03/2023 02:39	Shutdown	12
2	09/03/2023 11:09	09/03/2023 11:54	warm Startup	46
3	09/07/2023 23:54	09/08/2023 00:05	Shutdown	12
4	09/08/2023 12:10	09/08/2023 13:02	cold Startup	53

Startup / Shutdown Events

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/02/2023 23:43 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	53	0.04
Warm Startup	1	46	0.04
Shutdown	2	24	0.02
Total Process Events:	4	123	0.09

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,187.17 Hour(s)
Total Startup Time:	99 Minute(s)
Total Shutdown Time:	24 Minute(s)
Total Startup/Shutdown Time:	123 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.09 %

CT2 SUSD EVENT 1

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 9:34	0			0			0			0			0			0	
07/07/23 9:35	0			0			0			0			0			0	
07/07/23 9:36	0			0			0			0			0			0	
07/07/23 9:37	0			0			0			0			0			0	
07/07/23 9:38	0			0			0			0			0			0	
07/07/23 9:39	6931.4			0.1			0			0			0			1	
07/07/23 9:40	23952			0.1			0			0			0			1	
07/07/23 9:41	37583.8			47.2			14.75			4.21			2.16			1	
07/07/23 9:42	49675.3			1391			11.8			163.79			2.29			1	
07/07/23 9:43	61227.7			983.9			15.96			142.72			3.81			1	
07/07/23 9:44	76245.8			598.3			20.06			108.07			5.96			1	
07/07/23 9:45	115755			466.7			24.44			128.07			11.04			1	
07/07/23 9:46	151644.5			321.6			34.17			115.6			20.22			1	
07/07/23 9:47	146099.3			237.6			47.4			82.27			27.01			1	
07/07/23 9:48	143865.8			1516.5			36.73			517.34			20.62			1	
07/07/23 9:49	23720.9			1990.5			37.76			111.84			3.49			1	
07/07/23 9:50	0			0			54.01			0			0			0	
07/07/23 9:51	0			0			4.1			0			0			0	
07/07/23 9:52	0			0			3.3			0			0			0	
07/07/23 9:53	0			0			2.9			0			0			0	
07/07/23 9:54	0			0			2.8			0			0			0	

CT2 SUSD EVENT 2

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 9:34	0			0			0			0			0			0	
07/07/23 9:35	0			0			0			0			0			0	
07/07/23 9:36	0			0			0			0			0			0	
07/07/23 9:37	0			0			0			0			0			0	
07/07/23 9:38	0			0			0			0			0			0	
07/07/23 9:39	6931.4			0.1			0			0			0			1	
07/07/23 9:40	23952			0.1			0			0			0			1	
07/07/23 9:41	37583.8			47.2			14.75			4.21			2.16			1	
07/07/23 9:42	49675.3			1391			11.8			163.79			2.29			1	
07/07/23 9:43	61227.7			983.9			15.96			142.72			3.81			1	
07/07/23 9:44	76245.8			598.3			20.06			108.07			5.96			1	
07/07/23 9:45	115755			466.7			24.44			128.07			11.04			1	
07/07/23 9:46	151644.5			321.6			34.17			115.6			20.22			1	
07/07/23 9:47	146099.3			237.6			47.4			82.27			27.01			1	
07/07/23 9:48	143865.8			1516.5			36.73			517.34			20.62			1	
07/07/23 9:49	23720.9			1990.5			37.76			111.84			3.49			1	
07/07/23 9:50	0			0			54.01			0			0			0	
07/07/23 9:51	0			0			4.1			0			0			0	
07/07/23 9:52	0			0			3.3			0			0			0	
07/07/23 9:53	0			0			2.9			0			0			0	
07/07/23 9:54	0			0			2.8			0			0			0	

CT2 SUSD EVENT 3

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 10:09	0			0			0.8			0			0			0	
07/07/23 10:10	0			0			0.7			0			0			0	
07/07/23 10:11	0			0			0.7			0			0			0	
07/07/23 10:12	0			0			0.8			0			0			0	
07/07/23 10:13	0			0			1			0			0			0	
07/07/23 10:14	4081.8			1.2			1.3			0			0			1	
07/07/23 10:15	20409.2			1.1			1.5			0			0			1	
07/07/23 10:16	33810			171.1			206.5			13.71			27.23			1	
07/07/23 10:17	46594.7			1194.1			33.13			131.77			6.02			1	
07/07/23 10:18	58455.1			946.8			29.5			131.19			6.73			1	
07/07/23 10:19	71470.8			628.8			29.81			106.55			8.31			1	
07/07/23 10:20	108053.4			461.6			32.59			118.21			13.74			1	
07/07/23 10:21	148024.7			133.5	X		24.84	X		46.87	X		14.35	X		1	
07/07/23 10:22	145021.1			133.5	X		63.97	X		45.91	X		36.2	X		1	
07/07/23 10:23	141709.4			84.6	X		52.71	X		28.41	X		29.14	X		1	
07/07/23 10:24	140015			84.6	X		55.46	X		28.07	X		30.3	X		1	
07/07/23 10:25	139398.9			87.5	X		59.2	X		28.9	X		32.19	X		1	
07/07/23 10:26	138859.8			87.5	X		60.02	X		28.81	X		32.52	X		1	
07/07/23 10:27	89492.6			87.5	X		60.22	X		18.56	X		21.03	X		1	
07/07/23 10:28	0			0	X		59.51	X		0	X		0	X		0	
07/07/23 10:29	0			0			200.6			0			0			0	
07/07/23 10:30	0			0			3.6			0			0			0	
07/07/23 10:31	0			0			3.5			0			0			0	
07/07/23 10:32	0			0			3.3			0			0			0	

CT2 SUSD EVENT 4

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 10:09	0			0			0.8			0			0			0	
07/07/23 10:10	0			0			0.7			0			0			0	
07/07/23 10:11	0			0			0.7			0			0			0	
07/07/23 10:12	0			0			0.8			0			0			0	
07/07/23 10:13	0			0			1			0			0			0	
07/07/23 10:14	4081.8			1.2			1.3			0			0			1	
07/07/23 10:15	20409.2			1.1			1.5			0			0			1	
07/07/23 10:16	33810			171.1			206.5			13.71			27.23			1	
07/07/23 10:17	46594.7			1194.1			33.13			131.77			6.02			1	
07/07/23 10:18	58455.1			946.8			29.5			131.19			6.73			1	
07/07/23 10:19	71470.8			628.8			29.81			106.55			8.31			1	
07/07/23 10:20	108053.4			461.6			32.59			118.21			13.74			1	
07/07/23 10:21	148024.7			133.5	X		24.84	X		46.87	X		14.35	X		1	
07/07/23 10:22	145021.1			133.5	X		63.97	X		45.91	X		36.2	X		1	
07/07/23 10:23	141709.4			84.6	X		52.71	X		28.41	X		29.14	X		1	
07/07/23 10:24	140015			84.6	X		55.46	X		28.07	X		30.3	X		1	
07/07/23 10:25	139398.9			87.5	X		59.2	X		28.9	X		32.19	X		1	
07/07/23 10:26	138859.8			87.5	X		60.02	X		28.81	X		32.52	X		1	
07/07/23 10:27	89492.6			87.5	X		60.22	X		18.56	X		21.03	X		1	
07/07/23 10:28	0			0	X		59.51	X		0	X		0	X		0	
07/07/23 10:29	0			0			200.6			0			0			0	
07/07/23 10:30	0			0			3.6			0			0			0	
07/07/23 10:31	0			0			3.5			0			0			0	
07/07/23 10:32	0			0			3.3			0			0			0	

CT2 SUSD EVENT 5

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 12:43	0			0			0.2			0			0			0	
07/07/23 12:44	0			0			0.2			0			0			0	
07/07/23 12:45	0			0			0.2			0			0			0	
07/07/23 12:46	0			0			0.2			0			0			0	
07/07/23 12:47	0			0			0.2			0			0			0	
07/07/23 12:48	11398.4			0.6			0.2			0			0			1	
07/07/23 12:49	27340.7			0.9			0.2			0			0			1	
07/07/23 12:50	40202.3			82.6			38.35			7.88			6.02			1	
07/07/23 12:51	52216.8			1183.9			23.21			146.56			4.73			1	
07/07/23 12:52	64000.3			711.7			27.64			108.02			6.9			1	
07/07/23 12:53	83793.4			505.6			33.93			100.39			11.09			1	
07/07/23 12:54	131158.2			352.7			41.03			109.65			21			1	
07/07/23 12:55	146253.3			226.8			56.38			78.65			32.17			1	
07/07/23 12:56	140708.2			634			59.19			211.45			32.49			1	
07/07/23 12:57	139630			1909.2			56.05			632.09			30.54			1	
07/07/23 12:58	137242.5			1968.6			56.25			640.3			30.11			1	
07/07/23 12:59	136626.3			2039.8			58.39			660.69			31.13			1	
07/07/23 13:00	136472.3			2030			58.19			656.62			30.97			1	
07/07/23 13:01	24722.1			2019.4			58.19			118.43			5.62			1	
07/07/23 13:02	0			0			66.87			0			0			0	
07/07/23 13:03	0			0			1.2			0			0			0	
07/07/23 13:04	0			0			1.1			0			0			0	
07/07/23 13:05	0			0			1			0			0			0	
07/07/23 13:06	0			0			0.8			0			0			0	

CT2 SUSD EVENT 6

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 12:43	0			0			0.2			0			0			0	
07/07/23 12:44	0			0			0.2			0			0			0	
07/07/23 12:45	0			0			0.2			0			0			0	
07/07/23 12:46	0			0			0.2			0			0			0	
07/07/23 12:47	0			0			0.2			0			0			0	
07/07/23 12:48	11398.4			0.6			0.2			0			0			1	
07/07/23 12:49	27340.7			0.9			0.2			0			0			1	
07/07/23 12:50	40202.3			82.6			38.35			7.88			6.02			1	
07/07/23 12:51	52216.8			1183.9			23.21			146.56			4.73			1	
07/07/23 12:52	64000.3			711.7			27.64			108.02			6.9			1	
07/07/23 12:53	83793.4			505.6			33.93			100.39			11.09			1	
07/07/23 12:54	131158.2			352.7			41.03			109.65			21			1	
07/07/23 12:55	146253.3			226.8			56.38			78.65			32.17			1	
07/07/23 12:56	140708.2			634			59.19			211.45			32.49			1	
07/07/23 12:57	139630			1909.2			56.05			632.09			30.54			1	
07/07/23 12:58	137242.5			1968.6			56.25			640.3			30.11			1	
07/07/23 12:59	136626.3			2039.8			58.39			660.69			31.13			1	
07/07/23 13:00	136472.3			2030			58.19			656.62			30.97			1	
07/07/23 13:01	24722.1			2019.4			58.19			118.43			5.62			1	
07/07/23 13:02	0			0			66.87			0			0			0	
07/07/23 13:03	0			0			1.2			0			0			0	
07/07/23 13:04	0			0			1.1			0			0			0	
07/07/23 13:05	0			0			1			0			0			0	
07/07/23 13:06	0			0			0.8			0			0			0	

CT2 SUSD EVENT 7

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 16:10	0			0			0			0			0			0	
07/07/23 16:11	0			0			0			0			0			0	
07/07/23 16:12	0			0			0			0			0			0	
07/07/23 16:13	0			0			0			0			0			0	
07/07/23 16:14	0			0			0			0			0			0	
07/07/23 16:15	2772.6			0.3			0			0			0			1	
07/07/23 16:16	21718.5			0.6			0			0			0			1	
07/07/23 16:17	37429.8			69.1			32.03			6.13			4.67			1	
07/07/23 16:18	49521.3			1105.1			23.6			129.63			4.56			1	
07/07/23 16:19	61458.7			664.5			27.64			96.84			6.63			1	
07/07/23 16:20	83562.3			417.5			35.12			82.71			11.45			1	
07/07/23 16:21	128847.7			285			40.79			87.08			20.51			1	
07/07/23 16:22	143480.8			172.4			59.66			58.62			33.38			1	
07/07/23 16:23	137165.5			504.3			61.58			164.01			32.96			1	
07/07/23 16:24	136395.3			1774.8			56.15			573.66			29.87			1	
07/07/23 16:25	135009			1951.1			58.21			624.56			30.67			1	
07/07/23 16:26	134392.9			1958			58.02			623.69			30.41			1	
07/07/23 16:27	97194.2			2015.4			60.02			464.21			22.75			1	
07/07/23 16:28	0			0			60.82			0			0			0	
07/07/23 16:29	0			0			94.4			0			0			0	
07/07/23 16:30	0			0			0.9			0			0			0	
07/07/23 16:31	0			0			0.7			0			0			0	
07/07/23 16:32	0			0			0.6			0			0			0	

CT2 SUSD EVENT 8

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 16:10	0			0			0			0			0			0	
07/07/23 16:11	0			0			0			0			0			0	
07/07/23 16:12	0			0			0			0			0			0	
07/07/23 16:13	0			0			0			0			0			0	
07/07/23 16:14	0			0			0			0			0			0	
07/07/23 16:15	2772.6			0.3			0			0			0			1	
07/07/23 16:16	21718.5			0.6			0			0			0			1	
07/07/23 16:17	37429.8			69.1			32.03			6.13			4.67			1	
07/07/23 16:18	49521.3			1105.1			23.6			129.63			4.56			1	
07/07/23 16:19	61458.7			664.5			27.64			96.84			6.63			1	
07/07/23 16:20	83562.3			417.5			35.12			82.71			11.45			1	
07/07/23 16:21	128847.7			285			40.79			87.08			20.51			1	
07/07/23 16:22	143480.8			172.4			59.66			58.62			33.38			1	
07/07/23 16:23	137165.5			504.3			61.58			164.01			32.96			1	
07/07/23 16:24	136395.3			1774.8			56.15			573.66			29.87			1	
07/07/23 16:25	135009			1951.1			58.21			624.56			30.67			1	
07/07/23 16:26	134392.9			1958			58.02			623.69			30.41			1	
07/07/23 16:27	97194.2			2015.4			60.02			464.21			22.75			1	
07/07/23 16:28	0			0			60.82			0			0			0	
07/07/23 16:29	0			0			94.4			0			0			0	
07/07/23 16:30	0			0			0.9			0			0			0	
07/07/23 16:31	0			0			0.7			0			0			0	
07/07/23 16:32	0			0			0.6			0			0			0	

CT2 SUSD EVENT 9

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 17:19	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:20	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:21	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:22	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:23	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:24	1386.3			1.1	X		0	X		0	X		0	X		1	
07/07/23 17:25	13708.8			1.1	X		0	X		0	X		0	X		1	
07/07/23 17:26	30421.3			182.9	X		106.2	X		13.18	X		12.6	X		1	
07/07/23 17:27	44053.1			1134.6	X		23.6	X		118.35	X		4.05	X		1	
07/07/23 17:28	55759.6			836.4	X		29.5	X		110.46	X		6.41	X		1	
07/07/23 17:29	69699.5			509.2	X		25.08	X		84.11	X		6.82	X		1	
07/07/23 17:30	105357.9			373.1	X		38.77	X		93.21	X		15.94	X		1	
07/07/23 17:31	142556.6			224.9	X		50.89	X		76.03	X		28.31	X		1	
07/07/23 17:32	138936.8			155.2	X		66.47	X		51.09	X		36.02	X		1	
07/07/23 17:33	134932			1377.2	X		56.91	X		440.53	X		29.96	X		1	
07/07/23 17:34	135240			1960.6	X		58.21	X		628.46	X		30.71	X		1	
07/07/23 17:35	96809.1			2055.6	X		60.22	X		471.65	X		22.74	X		1	
07/07/23 17:36	0			0	X		58.76	X		0	X		0	X		0	
07/07/23 17:37	0			0	X		76.7	X		0	X		0	X		0	
07/07/23 17:38	0			0	X		0.7	X		0	X		0	X		0	
07/07/23 17:39	0			0	X		0.6	X		0	X		0	X		0	
07/07/23 17:40	0			0	X		0.5	X		0	X		0	X		0	

CT2 SUSD EVENT 10

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/07/23 17:19	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:20	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:21	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:22	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:23	0			0	X		0	X		0	X		0	X		0	
07/07/23 17:24	1386.3			1.1	X		0	X		0	X		0	X		1	
07/07/23 17:25	13708.8			1.1	X		0	X		0	X		0	X		1	
07/07/23 17:26	30421.3			182.9	X		106.2	X		13.18	X		12.6	X		1	
07/07/23 17:27	44053.1			1134.6	X		23.6	X		118.35	X		4.05	X		1	
07/07/23 17:28	55759.6			836.4	X		29.5	X		110.46	X		6.41	X		1	
07/07/23 17:29	69699.5			509.2	X		25.08	X		84.11	X		6.82	X		1	
07/07/23 17:30	105357.9			373.1	X		38.77	X		93.21	X		15.94	X		1	
07/07/23 17:31	142556.6			224.9	X		50.89	X		76.03	X		28.31	X		1	
07/07/23 17:32	138936.8			155.2	X		66.47	X		51.09	X		36.02	X		1	
07/07/23 17:33	134932			1377.2	X		56.91	X		440.53	X		29.96	X		1	
07/07/23 17:34	135240			1960.6	X		58.21	X		628.46	X		30.71	X		1	
07/07/23 17:35	96809.1			2055.6	X		60.22	X		471.65	X		22.74	X		1	
07/07/23 17:36	0			0	X		58.76	X		0	X		0	X		0	
07/07/23 17:37	0			0	X		76.7	X		0	X		0	X		0	
07/07/23 17:38	0			0	X		0.7	X		0	X		0	X		0	
07/07/23 17:39	0			0	X		0.6	X		0	X		0	X		0	
07/07/23 17:40	0			0	X		0.5	X		0	X		0	X		0	

CT2 SUSD EVENT 11

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 9:26	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:27	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:28	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:29	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:30	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:31	8009.7			0.1	X		0	X		0	X		0	X		1	
07/08/23 9:32	21487.5			0.1	X		0	X		0	X		0	X		1	
07/08/23 9:33	34965.3			123.9	X		82.6	X		10.26	X		11.26	X		1	
07/08/23 9:34	47980.9			1325.7	X		18.15	X		150.75	X		3.4	X		1	
07/08/23 9:35	59533.3			977.7	X		21.86	X		137.87	X		5.07	X		1	
07/08/23 9:36	72164			637.8	X		26.39	X		109.08	X		7.43	X		1	
07/08/23 9:37	107206.2			465.5	X		27.81	X		118.28	X		11.63	X		1	
07/08/23 9:38	148640.8			310	X		40.07	X		109.22	X		23.24	X		1	
07/08/23 9:39	149179.9			212.2	X		59	X		75.05	X		34.34	X		1	
07/08/23 9:40	144405			1230	X		50.89	X		420.97	X		28.66	X		1	
07/08/23 9:41	142633.6			1977.1	X		55.66	X		668.27	X		30.96	X		1	
07/08/23 9:42	141709.4			2004	X		59.59	X		673.34	X		32.95	X		1	
07/08/23 9:43	114676.8			2060.5	X		66.93	X		559.95	X		29.94	X		1	
07/08/23 9:44	0			0	X		64.9	X		0	X		0	X		0	
07/08/23 9:45	0			0	X		120.95	X		0	X		0	X		0	
07/08/23 9:46	0			0	X		1.5	X		0	X		0	X		0	
07/08/23 9:47	0			0	X		1.3	X		0	X		0	X		0	
07/08/23 9:48	0			0	X		1.1	X		0	X		0	X		0	

CT2 SUSD EVENT 12

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 9:26	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:27	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:28	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:29	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:30	0			0	X		0	X		0	X		0	X		0	
07/08/23 9:31	8009.7			0.1	X		0	X		0	X		0	X		1	
07/08/23 9:32	21487.5			0.1	X		0	X		0	X		0	X		1	
07/08/23 9:33	34965.3			123.9	X		82.6	X		10.26	X		11.26	X		1	
07/08/23 9:34	47980.9			1325.7	X		18.15	X		150.75	X		3.4	X		1	
07/08/23 9:35	59533.3			977.7	X		21.86	X		137.87	X		5.07	X		1	
07/08/23 9:36	72164			637.8	X		26.39	X		109.08	X		7.43	X		1	
07/08/23 9:37	107206.2			465.5	X		27.81	X		118.28	X		11.63	X		1	
07/08/23 9:38	148640.8			310	X		40.07	X		109.22	X		23.24	X		1	
07/08/23 9:39	149179.9			212.2	X		59	X		75.05	X		34.34	X		1	
07/08/23 9:40	144405			1230	X		50.89	X		420.97	X		28.66	X		1	
07/08/23 9:41	142633.6			1977.1	X		55.66	X		668.27	X		30.96	X		1	
07/08/23 9:42	141709.4			2004	X		59.59	X		673.34	X		32.95	X		1	
07/08/23 9:43	114676.8			2060.5	X		66.93	X		559.95	X		29.94	X		1	
07/08/23 9:44	0			0	X		64.9	X		0	X		0	X		0	
07/08/23 9:45	0			0	X		120.95	X		0	X		0	X		0	
07/08/23 9:46	0			0	X		1.5	X		0	X		0	X		0	
07/08/23 9:47	0			0	X		1.3	X		0	X		0	X		0	
07/08/23 9:48	0			0	X		1.1	X		0	X		0	X		0	

CT2 SUSD EVENT 13

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 17:46	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:47	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:48	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:49	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:50	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:51	3311.7			0.2	X		0	X		0	X		0	X		1	
07/08/23 17:52	21641.5			0.2	X		0	X		0	X		0	X		1	
07/08/23 17:53	36505.6			64.9	X		47.2	X		5.62	X		6.73	X		1	
07/08/23 17:54	48828.1			1180	X		22.42	X		136.56	X		4.27	X		1	
07/08/23 17:55	60457.5			716.4	X		27.64	X		102.63	X		6.52	X		1	
07/08/23 17:56	76553.9			457.7	X		32.87	X		83.09	X		9.82	X		1	
07/08/23 17:57	124303.8			325.6	X		39.96	X		95.91	X		19.37	X		1	
07/08/23 17:58	145791.2			192	X		54.92	X		66.35	X		31.24	X		1	
07/08/23 17:59	150874.3			320.6	X		63.61	X		114.69	X		37.45	X		1	
07/08/23 18:00	153184.8			1545.4	X		58.28	X		561.12	X		34.83	X		1	
07/08/23 18:01	145868.3			1592.8	X		58.13	X		550.87	X		33.09	X		1	
07/08/23 18:02	38045.9			1653.8	X		59.36	X		149.19	X		8.81	X		1	
07/08/23 18:03	0			0	X		59.91	X		0	X		0	X		0	
07/08/23 18:04	0			0	X		1.5	X		0	X		0	X		0	
07/08/23 18:05	0			0	X		1.2	X		0	X		0	X		0	
07/08/23 18:06	0			0	X		0.9	X		0	X		0	X		0	
07/08/23 18:07	0			0	X		0.7	X		0	X		0	X		0	

CT2 SUSD EVENT 14

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/08/23 17:46	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:47	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:48	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:49	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:50	0			0	X		0	X		0	X		0	X		0	
07/08/23 17:51	3311.7			0.2	X		0	X		0	X		0	X		1	
07/08/23 17:52	21641.5			0.2	X		0	X		0	X		0	X		1	
07/08/23 17:53	36505.6			64.9	X		47.2	X		5.62	X		6.73	X		1	
07/08/23 17:54	48828.1			1180	X		22.42	X		136.56	X		4.27	X		1	
07/08/23 17:55	60457.5			716.4	X		27.64	X		102.63	X		6.52	X		1	
07/08/23 17:56	76553.9			457.7	X		32.87	X		83.09	X		9.82	X		1	
07/08/23 17:57	124303.8			325.6	X		39.96	X		95.91	X		19.37	X		1	
07/08/23 17:58	145791.2			192	X		54.92	X		66.35	X		31.24	X		1	
07/08/23 17:59	150874.3			320.6	X		63.61	X		114.69	X		37.45	X		1	
07/08/23 18:00	153184.8			1545.4	X		58.28	X		561.12	X		34.83	X		1	
07/08/23 18:01	145868.3			1592.8	X		58.13	X		550.87	X		33.09	X		1	
07/08/23 18:02	38045.9			1653.8	X		59.36	X		149.19	X		8.81	X		1	
07/08/23 18:03	0			0	X		59.91	X		0	X		0	X		0	
07/08/23 18:04	0			0	X		1.5	X		0	X		0	X		0	
07/08/23 18:05	0			0	X		1.2	X		0	X		0	X		0	
07/08/23 18:06	0			0	X		0.9	X		0	X		0	X		0	
07/08/23 18:07	0			0	X		0.7	X		0	X		0	X		0	

CT2 SUSD EVENT 15

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 6:34	0			0	X		0	X		0	X		0	X		0	
07/09/23 6:35	0			0	X		0	X		0	X		0	X		0	
07/09/23 6:36	0			0	X		0	X		0	X		0	X		0	
07/09/23 6:37	0			0	X		0	X		0	X		0	X		0	
07/09/23 6:38	0			0	X		0	X		0	X		0	X		0	
07/09/23 6:39	7239.5			0.1	X		0	X		0	X		0	X		1	
07/09/23 6:40	21564.5			0.1	X		0	X		0	X		0	X		1	
07/09/23 6:41	35658.4			59	X		41.3	X		4.99	X		5.75	X		1	
07/09/23 6:42	48597.1			1400.1	X		16.34	X		161.41	X		3.1	X		1	
07/09/23 6:43	59764.4			1013.8	X		21.17	X		143.64	X		4.94	X		1	
07/09/23 6:44	73242.2			672.9	X		26.08	X		116.89	X		7.46	X		1	
07/09/23 6:45	109054.6			496.7	X		27.81	X		128.42	X		11.83	X		1	
07/09/23 6:46	150489.2			370.9	X		39.25	X		132.35	X		23.05	X		1	
07/09/23 6:47	173208.9			252.1	X		55.74	X		103.48	X		37.66	X		1	
07/09/23 6:48	197160.9			970.6	X		60.07	X		453.67	X		46.21	X		1	
07/09/23 6:49	219264.5			537.5	X		62.84	X		279.37	X		53.75	X		1	
07/09/23 6:50	243524.5			143.2	X		57.66	X		82.67	X		54.78	X		1	
07/09/23 6:51	266013.2			12.5	X		50.74	X		7.89	X		52.66	X		1	
07/09/23 6:52	294817.2			1.7	X		46.13	X		1.2	X		53.05	X		1	
07/09/23 6:53	320078.4			1.4	X		28.34	X		1.03	X		35.39	X		1	
07/09/23 6:54	340564.6			1.4	X		19.55	X		1.14	X		25.98	X		1	
07/09/23 6:55	361204.9			1.7	X		14.23	X		1.49	X		20.05	X		1	
07/09/23 6:56	383924.6			1.9	X		12.48	X		1.71	X		18.7	X		1	
07/09/23 6:57	401330.2			2	X		9.11	X		1.9	X		14.26	X		1	
07/09/23 6:58	424204			2.1	X		7.15	X		2.07	X		11.83	X		1	
07/09/23 6:59	446230.5			2.1	X		6.54	X		2.21	X		11.38	X		1	
07/09/23 7:00	465561.6			2	X		5.99	X		2.24	X		10.88	X		1	
07/09/23 7:01	481734.9			2	X		5.99	X		2.32	X		11.26	X		1	
07/09/23 7:02	482428.1			1.9	X		6.45	X		2.21	X		12.15	X		1	
07/09/23 7:03	480194.6			1.8	X		6.63	X		2.07	X		12.41	X		1	
07/09/23 7:04	481734.9			1.8	X		6.27	X		2	X		11.78	X		1	
07/09/23 7:05	480656.7			1.7	X		6.08	X		1.89	X		11.41	X		1	

Monday, October 30, 2023

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 7:06	478423.2			1.6	X		5.99	X		1.78	X		11.18	X		1	
07/09/23 7:07	479578.5			1.6	X		5.9	X		1.78	X		11.04	X		1	
07/09/23 7:08	480656.7			1.7	X		5.9	X		1.89	X		11.06	X		1	
07/09/23 7:09	479501.4			1.7	X		5.81	X		1.89	X		10.86	X		1	
07/09/23 7:10	478423.2			1.6	X		5.81	X		1.78	X		10.84	X		1	
07/09/23 7:11	478192.2			1.6	X		5.9	X		1.78	X		11.01	X		1	
07/09/23 7:12	480964.8			1.6	X		5.99	X		1.79	X		11.24	X		1	
07/09/23 7:13	479886.5			1.5	X		6.08	X		1.68	X		11.39	X		1	
07/09/23 7:14	480194.6			1.5	X		6.36	X		1.68	X		11.92	X		1	
07/09/23 7:15	480040.6			1.4	X		6.64	X		1.57	X		12.43	X		1	
07/09/23 7:16	480425.6			1.3	X		6.73	X		1.47	X		12.61	X		1	
07/09/23 7:17	471414.8			1.3	X		6.82	X		1.44	X		12.55	X		1	
07/09/23 7:18	451467.6			1.2	X		6.55	X		1.28	X		11.53	X		1	
07/09/23 7:19	445691.4			1.1	X		6.27	X		1.17	X		10.9	X		1	
07/09/23 7:20	445152.3			1.1	X		5.62	X		1.17	X		9.77	X		1	
07/09/23 7:21	455395.4			1.1	X		4.98	X		1.19	X		8.85	X		1	
07/09/23 7:22	472955.1			1.1	X		4.61	X		1.24	X		8.51	X		1	
07/09/23 7:23	480194.6			1	X		4.87	X		1.17	X		9.12	X		1	
07/09/23 7:24	479347.4			1.1	X		5.53	X		1.26	X		10.34	X		1	
07/09/23 7:25	478192.2			1.1	X		5.44	X		1.25	X		10.15	X		1	
07/09/23 7:26	478423.2			1.1	X		4.7	X		1.25	X		8.77	X		1	
07/09/23 7:27	476805.9			1.1	X		4.7	X		1.25	X		8.75	X		1	
07/09/23 7:28	476651.8			1	X		4.79	X		1.15	X		8.91	X		1	
07/09/23 7:29	478654.3			1	X		5.16	X		1.15	X		9.64	X		1	
07/09/23 7:30	476959.9			1	X		5.07	X		1.15	X		9.43	X		1	
07/09/23 7:31	477268			1	X		3.96	X		1.15	X		7.38	X		1	
07/09/23 7:32	477653.1			1	X		3.5	X		1.15	X		6.53	X		1	
07/09/23 7:33	477113.9			1	X		3.23	X		1.15	X		6.01	X		1	
07/09/23 7:34	479193.4			2.2	X		2.79	X		2.47	X		5.23	X		1	
07/09/23 7:35	477576			3.9	X		0.2	X		4.38	X		0.38	X		1	
07/09/23 7:36	475419.6			0.2	X		0	X		0.23	X		0	X		1	
07/09/23 7:37	476805.9			0	X		0	X		0	X		0	X		1	
07/09/23 7:38	476959.9			0	X		0	X		0	X		0	X		1	
07/09/23 7:39	476035.7			0.2	X		1.48	X		0.24	X		2.74	X		1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 7:40	470028.5			2.2	X		2.45	X		2.41	X		4.5	X		1	
07/09/23 7:41	456473.7			2.6	X		2.5	X		2.79	X		4.45	X		1	
07/09/23 7:42	447770.9			2.6	X		2.5	X		2.74	X		4.36	X		1	
07/09/23 7:43	429210			2.6	X		2.5	X		2.63	X		4.18	X		1	
07/09/23 7:44	404179.8			2.6	X		2.5	X		2.47	X		3.94	X		1	
07/09/23 7:45	384001.6			12.2	X		12.2	X		11.1	X		18.27	X		1	
07/09/23 7:46	367982.3			12.2	X		12.2	X		10.64	X		17.51	X		1	
07/09/23 7:47	366750.1			12.2	X		12.2	X		10.6	X		17.45	X		1	
07/09/23 7:48	366442			12.2	X		12.2	X		10.6	X		17.44	X		1	
07/09/23 7:49	365825.9			20.1	X		20.13	X		17.46	X		28.74	X		1	
07/09/23 7:50	364824.7			25.1	X		25.12	X		21.72	X		35.75	X		1	
07/09/23 7:51	364901.7			3.9	X		1.06	X		3.35	X		1.5	X		1	
07/09/23 7:52	364593.6			1.2	X		0.79	X		1.07	X		1.13	X		1	
07/09/23 7:53	365517.8			1.2	X		0.63	X		1.01	X		0.89	X		1	
07/09/23 7:54	367289.2			1.2	X		0.54	X		1.01	X		0.77	X		1	
07/09/23 7:55	366365			1.2	X		0.45	X		1.01	X		0.64	X		1	
07/09/23 7:56	366365			1.2	X		0.45	X		1.01	X		0.64	X		1	
07/09/23 7:57	366981.1			1.2			0.45			1.01			0.64			1	
07/09/23 7:58	367058.1			1.2			0.36			1.01			0.51			1	
07/09/23 7:59	366210.9			1.2			0.36			1.01			0.51			1	
07/09/23 8:00	365748.8			1.2			0.27			1.01			0.38			0	
07/09/23 8:01	365902.9			1.1			0.27			0.93			0.38			0	
07/09/23 8:02	366596			1.1			0.27			0.93			0.38			0	
07/09/23 8:03	367135.1			1.1			0.27			0.93			0.38			0	
07/09/23 8:04	365979.9			1.1			0.27			0.93			0.38			0	

CT2 SUSD EVENT 16

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/09/23 8:12	330398.5			1.1			0.27			0.85			0.35			0	
07/09/23 8:13	330244.5			1.2			0.27			0.92			0.35			0	
07/09/23 8:14	331168.7			1.2			0.27			0.93			0.35			0	
07/09/23 8:15	330244.5			1.1			0.27			0.85			0.35			0	
07/09/23 8:16	330167.5			1.1			0.27			0.85			0.35			0	
07/09/23 8:17	328165.1			1.1			0.27			0.85			0.35			1	
07/09/23 8:18	306523.6			1			0.27			0.73			0.33			1	
07/09/23 8:19	281724.4			1			0.37			0.68			0.41			1	
07/09/23 8:20	256309.2			1			0.38			0.58			0.38			1	
07/09/23 8:21	233281.4			0.9			1.32			0.51			1.2			1	
07/09/23 8:22	205863.7			1.2			2.12			0.6			1.7			1	
07/09/23 8:23	181911.7			8.4			2.58			3.6			1.83			1	
07/09/23 8:24	163196.8			381.8			3.09			147.69			1.97			1	
07/09/23 8:25	144096.9			994.9			3.67			339.84			2.06			1	
07/09/23 8:26	37198.7			1371.4			5.16			120.95			0.75			1	
07/09/23 8:27	0			0			6.39			0			0			0	
07/09/23 8:28	0			0			0.1			0			0			0	
07/09/23 8:29	0			0			0.1			0			0			0	
07/09/23 8:30	0			0			0			0			0			0	
07/09/23 8:31	0			0			0			0			0			0	

CT2 SUSD EVENT 17

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/14/23 16:15	0			0			0			0			0			0	
07/14/23 16:16	0			0			0			0			0			0	
07/14/23 16:17	0			0			0			0			0			0	
07/14/23 16:18	0			0			0			0			0			0	
07/14/23 16:19	0			0			0			0			0			0	
07/14/23 16:20	8240.7			0.1			0			0			0			1	
07/14/23 16:21	25723.3			0.7			0			0			0			1	
07/14/23 16:22	39740.2			1140.9			16.23			107.52			2.52			1	
07/14/23 16:23	50753.5			995.3			15.86			119.64			3.14			1	
07/14/23 16:24	63615.2			539.3			19.47			81.36			4.83			1	
07/14/23 16:25	88414.3			302.5			24.14			63.38			8.32			1	
07/14/23 16:26	133545.7			184.4			29.5			58.36			15.37			1	
07/14/23 16:27	148255.8			105.2			41.91			36.97			24.24			1	
07/14/23 16:28	182758.9			490.2			40.41			212.34			28.8			1	
07/14/23 16:29	188227			507.9			53.74			226.58			39.46			1	
07/14/23 16:30	213488.3			113.6			57.08			57.5			47.54			1	
07/14/23 16:31	239442.7			16.3			64.52			9.26			60.28			1	
07/14/23 16:32	265705.1			1.6			66.9			0.98			69.36			1	
07/14/23 16:33	293815.9			1.2			49.44			0.85			56.68			1	
07/14/23 16:34	316073.6			1.2			23.32			0.9			28.76			1	
07/14/23 16:35	337098.9			1.5			14.8			1.16			19.46			1	
07/14/23 16:36	358663.4			1.5			11.98			1.29			16.76			1	
07/14/23 16:37	371448			1.5			10.37			1.34			15.03			1	
07/14/23 16:38	371448			1.5			8.53			1.28			12.37			1	
07/14/23 16:39	372526.3			1.4			7.08			1.2			10.29			1	
07/14/23 16:40	372218.2			1.3			5.81			1.14			8.43			1	
07/14/23 16:41	369907.7			1.3			4.98			1.13			7.18			1	
07/14/23 16:42	369291.6			1.2			4.06			1.05			5.84			1	
07/14/23 16:43	369060.5			1.1			3.78			0.97			5.44			1	
07/14/23 16:44	368213.4			1			3.23			0.89			4.63			1	
07/14/23 16:45	370677.9			1			2.9			0.91			4.2			1	
07/14/23 16:46	381075			0.9			2.81			0.85			4.18			1	

Monday, October 30, 2023

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
07/14/23 16:47	384925.8			0.9			2.53			0.85			3.8			1	
07/14/23 16:48	385696			0.9			2.53			0.86			3.81			1	
07/14/23 16:49	384309.7			0.9			2.43			0.85			3.65			1	
07/14/23 16:50	384463.7			0.9			2.34			0.85			3.51			1	
07/14/23 16:51	384463.7			0.9			2.25			0.85			3.37			1	
07/14/23 16:52	384925.8			0.9			2.15			0.85			3.23			1	
07/14/23 16:53	383154.5			0.9			2.25			0.85			3.36			1	
07/14/23 16:54	385002.8			0.9			2.34			0.85			3.52			1	
07/14/23 16:55	385696			0.8			2.34			0.77			3.52			1	
07/14/23 16:56	377994.4			0.8			2.53			0.76			3.73			1	
07/14/23 16:57	374528.7			0.9			2.57			0.76			3.75			1	
07/14/23 16:58	377147.2			0.8			2.53			0.75			3.72			1	
07/14/23 16:59	381306.1			0.8			2.72			0.76			4.04			1	
07/14/23 17:00	379226.7			0.8			2.62			0.76			3.88			1	
07/14/23 17:01	381075			0.8			1.78			0.76			2.65			1	
07/14/23 17:02	379996.8			0.8			1.69			0.76			2.5			1	
07/14/23 17:03	379534.7			0.8			1.69			0.76			2.5			1	
07/14/23 17:04	379842.8			0.8			1.78			0.76			2.64			1	
07/14/23 17:05	382384.3			0.8			1.78			0.76			2.65			0	
07/14/23 17:06	381845.2			0.7			1.78			0.68			2.65			0	
07/14/23 17:07	382846.4			0.7			1.78			0.68			2.66			0	
07/14/23 17:08	383385.5			0.8			1.87			0.77			2.8			0	
07/14/23 17:09	384309.7			0.8			1.78			0.77			2.67			0	

CT2 SUSD EVENT 18

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/21/23 4:47	365363.8			0.7			1.52			0.6			2.09			0	
08/21/23 4:48	365286.8			0.7			1.61			0.6			2.21			0	
08/21/23 4:49	363361.3			0.7			1.52			0.59			2.07			0	
08/21/23 4:50	362745.2			0.7			1.52			0.59			2.07			0	
08/21/23 4:51	363900.5			0.7			1.52			0.59			2.08			0	
08/21/23 4:52	360665.8			0.7			1.52			0.59			2.06			1	
08/21/23 4:53	345493.7			0.7			1.52			0.56			1.97			1	
08/21/23 4:54	323313.1			0.7			1.61			0.53			1.95			1	
08/21/23 4:55	298128.8			0.7			1.97			0.49			2.2			1	
08/21/23 4:56	276025.3			0.7			2.4			0.46			2.48			1	
08/21/23 4:57	251534.2			0.6			3.81			0.33			3.6			1	
08/21/23 4:58	229276.5			0.5			7.28			0.26			6.27			1	
08/21/23 4:59	201858.9			0.3			28			0.15			21.23			1	
08/21/23 5:00	179216.2			4.2			34.8			1.72			23.42			1	
08/21/23 5:01	157959.8			293.9			38.97			105.92			23.11			1	
08/21/23 5:02	137858.6			954.9			42.08			300.31			21.78			1	
08/21/23 5:03	59764.4			1471.2			42.37			200.56			9.51			1	
08/21/23 5:04	0			0			47.89			0			0			0	
08/21/23 5:05	0			0			23.6			0			0			0	
08/21/23 5:06	0			0			0.3			0			0			0	
08/21/23 5:07	0			0			0.2			0			0			0	
08/21/23 5:08	0			0			0.2			0			0			0	

CT2 SUSD EVENT 19

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/21/23 13:20	0			0			0			0			0			0	
08/21/23 13:21	0			0			0			0			0			0	
08/21/23 13:22	0			0			0			0			0			0	
08/21/23 13:23	0			0			0			0			0			0	
08/21/23 13:24	0			0			0			0			0			0	
08/21/23 13:25	5468.1			0			0			0			0			1	
08/21/23 13:26	22565.7			-0.1			0			0			0			1	
08/21/23 13:27	36428.6			62			36.88			5.14			5.04			1	
08/21/23 13:28	48982.2			1170.2			18.88			130.71			3.47			1	
08/21/23 13:29	60842.6			725.4			24.84			100.67			5.67			1	
08/21/23 13:30	76322.8			463.3			27.25			80.68			7.81			1	
08/21/23 13:31	118835.6			331.2			35.13			89.86			15.69			1	
08/21/23 13:32	148178.7			201.7			46.75			68.23			26.02			1	
08/21/23 13:33	175211.3			208.5			56.42			83.37			37.12			1	
08/21/23 13:34	202783.1			819.8			60.52			379.3			46.08			1	
08/21/23 13:35	231047.9			185.4			59.69			97.76			51.8			1	
08/21/23 13:36	253767.6			12.8			59.24			7.39			56.46			1	
08/21/23 13:37	282725.6			1.3			56.1			0.83			59.57			1	
08/21/23 13:38	306754.6			1.1			28.15			0.74			32.42			1	
08/21/23 13:39	329243.3			1.1			16.63			0.81			20.56			1	
08/21/23 13:40	347342			1.2			11.8			0.98			15.39			1	
08/21/23 13:41	366981.1			1.4			11.36			1.18			15.66			1	
08/21/23 13:42	370677.9			1.3			8.89			1.12			12.38			1	
08/21/23 13:43	372218.2			1.1			8.19			0.97			11.45			1	
08/21/23 13:44	371910.1			1.1			7.75			0.9			10.83			1	
08/21/23 13:45	369907.7			1			7.66			0.82			10.64			1	
08/21/23 13:46	369907.7			1			7.51			0.83			10.43			1	
08/21/23 13:47	369522.6			0.9			7.15			0.75			9.92			1	
08/21/23 13:48	369676.7			0.8			6.97			0.68			9.68			1	
08/21/23 13:49	368675.5			0.8			6.7			0.68			9.28			1	
08/21/23 13:50	368598.4			0.8			6.7			0.68			9.28			1	
08/21/23 13:51	367366.2			0.8			6.62			0.67			9.13			1	

Monday, October 30, 2023

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/21/23 13:52	367674.3			0.7			6.53			0.6			9.01			1	
08/21/23 13:53	365748.8			0.7			6.54			0.61			8.98			1	
08/21/23 13:54	365363.8			0.7			6.54			0.61			8.97			1	
08/21/23 13:55	365748.8			0.7			6.44			0.61			8.85			1	
08/21/23 13:56	364670.6			0.7			6.44			0.6			8.83			1	
08/21/23 13:57	364824.7			0.7			6.54			0.6			8.95			1	
08/21/23 13:58	363669.4			0.6			6.54			0.53			8.93			1	
08/21/23 13:59	364978.7			0.7			6.44			0.6			8.83			1	
08/21/23 14:00	363207.3			0.7			5.36			0.6			7.31			1	
08/21/23 14:01	374066.6			0.6			3.09			0.54			4.34			1	
08/21/23 14:02	385002.8			0.7			2.72			0.64			3.94			1	
08/21/23 14:03	385233.9			0.6			2.58			0.57			3.73			1	
08/21/23 14:04	377609.3			0.6			2.95			0.56			4.18			1	
08/21/23 14:05	371063			0.6			3.18			0.54			4.43			1	
08/21/23 14:06	368521.4			0.6			3.27			0.53			4.52			1	
08/21/23 14:07	370061.8			0.7			3.27			0.61			4.54			1	
08/21/23 14:08	369368.6			0.6			3.27			0.54			4.53			1	
08/21/23 14:09	368367.4			0.6			3.27			0.53			4.52			1	
08/21/23 14:10	369676.7			0.6			3.18			0.54			4.41			1	
08/21/23 14:11	369522.6			0.7			3.09			0.61			4.28			1	
08/21/23 14:12	368444.4			0.6			2.81			0.53			3.89			1	
08/21/23 14:13	369368.6			0.6			2.54			0.54			3.53			1	
08/21/23 14:14	368906.5			0.6			2.36			0.53			3.27			1	
08/21/23 14:15	369060.5			0.6			2.27			0.54			3.15			1	
08/21/23 14:16	369445.6			0.6			2.27			0.54			3.15			1	
08/21/23 14:17	368675.5			0.6			2.27			0.53			3.14			1	
08/21/23 14:18	367828.3			0.6			2.27			0.53			3.13			1	
08/21/23 14:19	368752.5			0.6			2.09			0.53			2.89			1	
08/21/23 14:20	368444.4			0.6			2.09			0.53			2.89			1	
08/21/23 14:21	368675.5			0.6			1.91			0.53			2.64			1	
08/21/23 14:22	372064.2			0.6			1.91			0.54			2.66			1	
08/21/23 14:23	373373.4			0.6			1.72			0.54			2.42			1	
08/21/23 14:24	372603.3			0.6			1.72			0.54			2.41			0	
08/21/23 14:25	372603.3			0.6			1.72			0.54			2.41			0	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
08/21/23 14:26	373373.4			0.6			1.72			0.54			2.42			0	
08/21/23 14:27	373681.5			0.6			1.72			0.54			2.42			0	
08/21/23 14:28	373219.4			0.6			1.72			0.54			2.42			0	

CT2 SUSD EVENT 20

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/20/23 11:03	367597.3			0.9			1.48			0.78			2.06			0	
09/20/23 11:04	367520.2			0.9			1.48			0.78			2.06			0	
09/20/23 11:05	369291.6			0.9			1.48			0.79			2.07			0	
09/20/23 11:06	366750.1			0.9			1.48			0.78			2.06			0	
09/20/23 11:07	366827.1			0.9			1.48			0.78			2.06			0	
09/20/23 11:08	366750.1			0.8			1.48			0.7			2.06			1	
09/20/23 11:09	351809			0.9			1.48			0.75			1.98			1	
09/20/23 11:10	329166.3			0.9			1.57			0.7			1.96			1	
09/20/23 11:11	304213.1			0.9			2.03			0.65			2.35			1	
09/20/23 11:12	283418.8			1			2.28			0.62			2.46			1	
09/20/23 11:13	258234.6			0.9			3.58			0.52			3.52			1	
09/20/23 11:14	234205.6			0.6			7.02			0.33			6.26			1	
09/20/23 11:15	210484.7			0.6			26.27			0.27			21.05			1	
09/20/23 11:16	184838.3			3.7			34.79			1.58			24.48			1	
09/20/23 11:17	162888.8			247.7			39.47			93.3			24.47			1	
09/20/23 11:18	143095.7			883.7			43.21			292.57			23.55			1	
09/20/23 11:19	78171.2			1566.2			45.49			283.27			13.54			1	
09/20/23 11:20	0			0			49.49			0			0			0	
09/20/23 11:21	0			0			0.5			0			0			0	
09/20/23 11:22	0			0			0.3			0			0			0	
09/20/23 11:23	0			0			0.2			0			0			0	
09/20/23 11:24	0			0			0.2			0			0			0	

CT2 SUSD EVENT 21

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 8:49	0			0			0			0			0			0	
09/26/23 8:50	0			0			0			0			0			0	
09/26/23 8:51	0			0			0			0			0			0	
09/26/23 8:52	0			0			0			0			0			0	
09/26/23 8:53	37660.8			0			0			0			0			0	
09/26/23 8:54	2387.5			0			0			0			0			1	
09/26/23 8:55	16173.4			0			0			0			0			1	
09/26/23 8:56	33270.9			1.9			0.8			0			0			1	
09/26/23 8:57	46132.6			1636.7			17.11			174.75			3.01			1	
09/26/23 8:58	58686.2			1113.5			18.49			151.3			4.13			1	
09/26/23 8:59	71316.8			665.1			21.31			109.72			5.78			1	
09/26/23 9:00	104972.8			513.3			24.84			124.67			9.93			1	
09/26/23 9:01	147485.6			375.1			25.85			127.95			14.51			1	
09/26/23 9:02	157882.8			236.7			42.83			86.45			25.75			1	
09/26/23 9:03	172746.8			1271.3			36.97			507.95			24.31			1	
09/26/23 9:04	193002			1477.7			38.8			659.56			28.5			1	
09/26/23 9:05	215567.7			704			49.75			351.11			40.84			1	
09/26/23 9:06	240520.9			150			58.58			83.49			53.65			1	
09/26/23 9:07	266783.3			10.3			60.97			6.37			61.92			1	
09/26/23 9:08	295972.4			2.2			57.36			1.5			64.64			1	
09/26/23 9:09	319385.3			1.9			27.44			1.38			33.36			1	
09/26/23 9:10	340872.7			1.8			17.43			1.43			22.62			1	
09/26/23 9:11	361513			1.9			13.59			1.57			18.7			1	
09/26/23 9:12	374528.7			1.8			12.59			1.6			17.95			1	
09/26/23 9:13	375915			1.7			9.92			1.48			14.2			1	
09/26/23 9:14	377224.2			1.6			9.48			1.4			13.61			1	
09/26/23 9:15	389315.8			1.5			8.4			1.37			12.45			1	
09/26/23 9:16	411958.4			1.4			6.9			1.3			10.82			1	
09/26/23 9:17	431058.4			1.3			6.36			1.29			10.44			1	
09/26/23 9:18	435525.3			1.1			5.9			1.13			9.78			1	
09/26/23 9:19	436680.6			0.9			5.9			0.95			9.81			1	
09/26/23 9:20	436141.4			0.9			5.9			0.94			9.8			1	

Monday, October 30, 2023

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 9:21	434139			0.8			5.9			0.85			9.75			1	
09/26/23 9:22	435217.3			0.8			5.81			0.85			9.62			1	
09/26/23 9:23	434524.1			0.8			5.81			0.85			9.6			1	
09/26/23 9:24	433137.8			0.8			5.71			0.84			9.42			1	
09/26/23 9:25	433908			0.9			5.8			0.86			9.59			1	
09/26/23 9:26	433214.8			0.8			5.71			0.84			9.42			1	
09/26/23 9:27	434370.1			0.9			5.9			0.86			9.76			1	
09/26/23 9:28	434370.1			0.8			5.9			0.76			9.76			1	
09/26/23 9:29	436988.6			0.8			5.8			0.77			9.66			1	
09/26/23 9:30	437296.7			0.8			5.9			0.77			9.82			1	
09/26/23 9:31	436141.4			0.8			5.9			0.77			9.8			1	
09/26/23 9:32	437065.7			0.8			6			0.77			9.98			1	
09/26/23 9:33	434370.1			0.8			6.09			0.76			10.07			1	
09/26/23 9:34	435371.3			0.8			5.61			0.77			9.31			1	
09/26/23 9:35	435602.3			0.7			3			0.66			4.97			1	
09/26/23 9:36	438374.9			0.7			2.09			0.68			3.49			1	
09/26/23 9:37	437527.8			0.7			2.19			0.67			3.65			1	
09/26/23 9:38	433368.9			0.7			2.57			0.67			4.24			1	
09/26/23 9:39	426437.4			0.7			3.18			0.74			5.17			1	
09/26/23 9:40	423048.8			0.7			3.56			0.73			5.73			1	
09/26/23 9:41	415732.2			0.7			3.65			0.72			5.78			1	
09/26/23 9:42	410341.1			0.7			3.37			0.71			5.27			1	
09/26/23 9:43	402947.6			0.7			2.58			0.69			3.96			1	
09/26/23 9:44	399096.8			0.8			2.3			0.77			3.5			1	
09/26/23 9:45	391549.2			0.8			2.3			0.75			3.44			1	
09/26/23 9:46	387005.3			0.8			2.49			0.74			3.67			1	
09/26/23 9:47	380612.9			0.8			2.58			0.73			3.74			1	
09/26/23 9:48	374143.6			0.8			2.54			0.71			3.62			1	
09/26/23 9:49	374066.6			0.8			2.36			0.71			3.36			1	
09/26/23 9:50	374759.7			0.8			2			0.71			2.85			1	
09/26/23 9:51	375683.9			0.8			1.75			0.72			2.5			1	
09/26/23 9:52	375683.9			0.8			1.66			0.72			2.37			1	
09/26/23 9:53	375375.8			0.8			1.66			0.72			2.37			1	
09/26/23 9:54	374605.7			0.8			1.75			0.72			2.5			0	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Tim Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 9:55	375298.8			0.8			1.75			0.72			2.5			0	
09/26/23 9:56	374220.6			0.7			1.84			0.64			2.63			0	
09/26/23 9:57	372911.3			0.7			1.82			0.63			2.58			0	
09/26/23 9:58	372526.3			0.8			1.84			0.72			2.62			0	

CT2 SUSD EVENT 22

Date/Tim Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
09/26/23 13:17	363977.5			0.8			1.48			0.7			2.04			0	
09/26/23 13:18	364670.6			0.8			1.48			0.7			2.05			0	
09/26/23 13:19	363746.4			0.8			1.48			0.7			2.04			0	
09/26/23 13:20	365286.8			0.8			1.48			0.7			2.05			0	
09/26/23 13:21	365132.7			0.8			1.48			0.7			2.05			0	
09/26/23 13:22	365055.7			0.8			1.48			0.7			2.05			1	
09/26/23 13:23	348728.3			0.8			1.48			0.67			1.96			1	
09/26/23 13:24	329243.3			0.8			1.57			0.63			1.96			1	
09/26/23 13:25	306215.5			0.8			2.12			0.59			2.47			1	
09/26/23 13:26	283033.7			0.8			2.47			0.5			2.67			1	
09/26/23 13:27	258465.6			0.7			3.74			0.41			3.68			1	
09/26/23 13:28	234359.6			0.6			7.22			0.33			6.44			1	
09/26/23 13:29	210638.7			0.4			27.61			0.22			22.14			1	
09/26/23 13:30	183760.1			4.3			35.78			1.81			25.03			1	
09/26/23 13:31	163042.8			250.1			41.16			94.33			25.55			1	
09/26/23 13:32	142941.6			937.8			45.4			310.05			24.7			1	
09/26/23 13:33	48828.1			1590			46.25			179.73			8.6			1	
09/26/23 13:34	0			0			51.41			0			0			0	
09/26/23 13:35	0			0			0.3			0			0			0	
09/26/23 13:36	0			0			0.2			0			0			0	
09/26/23 13:37	0			0			0.2			0			0			0	
09/26/23 13:38	0			0			0.1			0			0			0	

Monthly Summary By Day Report

Unit CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2023	0.00	0.00	0.0	0.00	0.00
07/02/2023	0.00	0.00	0.0	0.00	0.00
07/03/2023	0.00	0.00	0.0	0.00	0.00
07/04/2023	0.00	0.00	0.0	0.00	0.00
07/05/2023	0.00	0.00	0.0	0.00	0.00
07/06/2023	0.00	0.00	0.0	0.00	0.00
07/07/2023	182.81	12.73	0.0	0.11	0.19
07/08/2023	0.00	0.00	0.0	0.05	0.07
07/09/2023	18.90	0.35	0.4	0.84	1.38
07/10/2023	0.00	0.00	0.0	0.00	0.00
07/11/2023	0.00	0.00	0.0	0.00	0.00
07/12/2023	0.00	0.00	0.0	0.00	0.00
07/13/2023	0.00	0.00	0.0	0.00	0.00
07/14/2023	24.49	31.58	2.7	5.02	8.36
07/15/2023	15.33	65.92	7.3	14.24	23.69
07/16/2023	16.81	66.85	7.6	14.56	24.29
07/17/2023	17.40	60.38	6.7	13.20	21.99
07/18/2023	17.81	69.05	7.7	15.05	25.03
07/19/2023	15.60	71.92	8.1	15.63	26.05
07/20/2023	18.36	68.23	7.6	14.93	24.82
07/21/2023	19.37	65.12	7.2	14.20	23.70
07/22/2023	20.18	62.11	6.4	13.40	22.34
07/23/2023	19.90	63.11	7.2	13.79	22.99
07/24/2023	18.47	56.73	6.1	12.25	20.45
07/25/2023	19.23	61.85	6.6	13.38	22.33
07/26/2023	17.24	71.08	8.1	15.55	25.92
07/27/2023	19.16	59.88	6.4	13.03	21.73
07/28/2023	20.12	58.46	6.3	12.71	21.22
07/29/2023	17.84	52.01	4.9	11.24	18.76
07/30/2023	17.91	51.41	4.8	11.10	18.55
07/31/2023	19.78	63.74	6.6	13.74	22.91
Monthly Avg/Sum:	536.71 sum	1,112.51 sum	118.7 sum	238.02 sum	396.77 sum
Daily Min:	15.33	0.35	0.0	0.05	0.07
Daily Max:	182.81	71.92	8.1	15.63	26.05
Jul 2023 - Jul 2023	536.71 sum	1,112.51 sum	118.7 sum	238.02 sum	396.77 sum
QTD:	536.71 sum	1,112.51 sum	118.7 sum	238.02 sum	396.77 sum
YTD 2023:	3,440.14 sum	4,498.02 sum	458.8 sum	909.48 sum	1,516.51 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:25 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2023	19.26	57.48	6.9	12.57	20.96
08/02/2023	18.10	54.21	5.9	11.69	19.45
08/03/2023	17.64	51.15	5.0	11.04	18.41
08/04/2023	19.04	52.94	5.3	11.49	19.12
08/05/2023	19.76	55.61	5.9	12.07	20.17
08/06/2023	20.22	56.40	5.8	12.33	20.55
08/07/2023	18.18	59.12	6.6	13.50	22.49
08/08/2023	15.31	52.72	5.4	11.43	19.02
08/09/2023	17.10	53.16	5.4	11.50	19.13
08/10/2023	16.00	50.78	5.0	11.08	18.43
08/11/2023	19.55	64.15	6.9	13.86	23.08
08/12/2023	16.92	52.89	5.5	11.64	19.34
08/13/2023	17.62	55.76	6.1	12.16	20.29
08/14/2023	16.17	66.50	7.4	14.59	24.27
08/15/2023	17.24	66.97	7.8	14.58	24.32
08/16/2023	13.80	67.63	7.9	14.65	24.42
08/17/2023	15.52	56.19	6.2	12.40	20.71
08/18/2023	14.50	48.91	4.8	10.68	17.86
08/19/2023	14.34	48.56	4.8	10.60	17.79
08/20/2023	15.01	48.76	4.8	10.69	17.95
08/21/2023	41.73	43.69	3.1	6.83	11.44
08/22/2023	14.65	50.51	4.9	10.82	18.16
08/23/2023	16.82	56.25	5.8	12.05	20.14
08/24/2023	16.24	51.02	5.1	10.97	18.36
08/25/2023	14.92	50.62	5.0	10.87	18.15
08/26/2023	15.18	51.49	5.2	11.10	18.49
08/27/2023	15.41	51.94	5.2	11.27	18.80
08/28/2023	16.42	54.00	5.5	11.60	19.36
08/29/2023	15.12	66.82	7.4	14.48	24.13
08/30/2023	17.23	56.59	5.7	12.15	20.29
08/31/2023	12.26	64.07	6.9	13.85	23.06
Monthly Avg/Sum:	537.26 sum	1,716.89 sum	179.2 sum	370.54 sum	618.14 sum
Daily Min:	12.26	43.69	3.1	6.83	11.44
Daily Max:	41.73	67.63	7.9	14.65	24.42
Jul 2023 - Aug 2023	1,073.97 sum	2,829.40 sum	297.9 sum	608.56 sum	1,014.91 sum
QTD:	1,073.97 sum	2,829.40 sum	297.9 sum	608.56 sum	1,014.91 sum
YTD 2023:	3,977.40 sum	6,214.91 sum	638.0 sum	1,280.02 sum	2,134.65 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 02:25 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2023	14.58	50.03	4.8	10.79	18.07
09/02/2023	15.63	50.75	5.0	11.08	18.43
09/03/2023	15.76	50.33	5.0	11.04	18.45
09/04/2023	16.62	51.21	5.1	11.13	18.52
09/05/2023	17.31	63.72	7.2	13.76	22.89
09/06/2023	16.96	53.42	5.5	11.60	19.33
09/07/2023	17.36	54.36	5.9	11.77	19.63
09/08/2023	17.62	63.93	6.8	13.88	23.09
09/09/2023	18.77	60.49	6.7	13.13	21.88
09/10/2023	18.17	59.72	6.5	12.92	21.56
09/11/2023	19.20	52.44	5.6	11.48	19.18
09/12/2023	17.47	51.43	5.0	11.08	18.44
09/13/2023	19.94	56.50	5.8	12.35	20.61
09/14/2023	19.79	60.99	6.4	13.24	22.06
09/15/2023	18.12	61.08	6.3	13.25	22.10
09/16/2023	16.98	51.57	5.1	11.25	18.79
09/17/2023	16.99	49.93	4.8	10.82	18.05
09/18/2023	17.82	50.64	4.9	10.91	18.23
09/19/2023	17.91	50.33	4.9	11.01	18.37
09/20/2023	26.35	26.29	2.3	5.08	8.49
09/21/2023	0.00	0.00	0.0	0.00	0.00
09/22/2023	0.00	0.00	0.0	0.00	0.00
09/23/2023	0.00	0.00	0.0	0.00	0.00
09/24/2023	0.00	0.00	0.0	0.00	0.00
09/25/2023	0.00	0.00	0.0	0.00	0.00
09/26/2023	68.78	23.45	0.9	2.06	3.44
09/27/2023	0.00	0.00	0.0	0.00	0.00
09/28/2023	0.00	0.00	0.0	0.00	0.00
09/29/2023	0.00	0.00	0.0	0.00	0.00
09/30/2023	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	428.13 sum	1,092.61 sum	110.5 sum	233.63 sum	389.61 sum
Daily Min:	14.58	23.45	0.9	2.06	3.44
Daily Max:	68.78	63.93	7.2	13.88	23.09
Jul 2023 - Sep 2023	1,502.10 sum	3,922.01 sum	408.4 sum	842.19 sum	1,404.52 sum
QTD:	1,502.10 sum	3,922.01 sum	408.4 sum	842.19 sum	1,404.52 sum
YTD 2023:	4,405.53 sum	7,307.52 sum	748.5 sum	1,513.65 sum	2,524.26 sum

Startup / Shutdown Events

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:45 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2023 00:00	07/07/2023 08:00	153
07/07/2023 11:00	07/07/2023 11:00	1
07/07/2023 14:00	07/07/2023 15:00	2
07/07/2023 18:00	07/08/2023 08:00	15
07/08/2023 10:00	07/08/2023 16:00	7
07/08/2023 19:00	07/09/2023 05:00	11
07/09/2023 09:00	07/14/2023 15:00	127
08/21/2023 06:00	08/21/2023 12:00	7
09/20/2023 12:00	09/26/2023 07:00	140
09/26/2023 14:00	09/30/2023 23:00	106

Startup / Shutdown Events

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:45 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	569.00 Hour(s)
Offline Percentage:	25.77 %
Total Online:	1,639.00 Hour(s)
Online Percentage:	74.23 %

Startup / Shutdown Events

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:45 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/07/2023 09:39	07/07/2023 09:49	Cold Startup	11
2	07/07/2023 09:49	07/07/2023 09:49	Shutdown	1
3	07/07/2023 10:14	07/07/2023 10:27	Cold Startup	14
4	07/07/2023 10:27	07/07/2023 10:27	Shutdown	1
5	07/07/2023 12:48	07/07/2023 13:01	Cold Startup	14
6	07/07/2023 13:01	07/07/2023 13:01	Shutdown	1
7	07/07/2023 16:15	07/07/2023 16:27	Cold Startup	13
8	07/07/2023 16:27	07/07/2023 16:27	Shutdown	1
9	07/07/2023 17:24	07/07/2023 17:35	Cold Startup	12
10	07/07/2023 17:35	07/07/2023 17:35	Shutdown	1
11	07/08/2023 09:31	07/08/2023 09:43	Cold Startup	13
12	07/08/2023 09:43	07/08/2023 09:43	Shutdown	1
13	07/08/2023 17:51	07/08/2023 18:02	Cold Startup	12
14	07/08/2023 18:01	07/08/2023 18:02	Shutdown	2
15	07/09/2023 06:39	07/09/2023 07:59	Cold Startup	81
16	07/09/2023 08:17	07/09/2023 08:26	Shutdown	10
17	07/14/2023 16:20	07/14/2023 17:04	Cold Startup	45
18	08/21/2023 04:52	08/21/2023 05:03	Shutdown	12
19	08/21/2023 13:25	08/21/2023 14:23	Cold Startup	59
20	09/20/2023 11:08	09/20/2023 11:19	Shutdown	12
21	09/26/2023 08:54	09/26/2023 09:53	Cold Startup	60
22	09/26/2023 13:22	09/26/2023 13:33	Shutdown	12

Startup / Shutdown Events

CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2023 23:45 **Location:** Roseville, CA

Startup / Shutdown Events

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/02/2023 23:45 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	11	334	0.34
Warm Startup	0		0.00
Shutdown	11	54	0.06
Total Process Events:	22	388	0.4

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,626.60 Hour(s)
Total Startup Time:	334 Minute(s)
Total Shutdown Time:	54 Minute(s)
Total Startup/Shutdown Time:	388 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.40 %

Replace the dates with the ones you need

7/1/2023 0:00

9/30/2023 0:00

1D

TOWER AVG.

519-AIT-9504-1

4028

7/1/23 0:00	3415.8
7/2/23 0:00	3333.1
7/3/23 0:00	3695.8
7/4/23 0:00	3869.9
7/5/23 0:00	3605.8
7/6/23 0:00	3317.9
7/7/23 0:00	3242.9
7/8/23 0:00	3450.6
7/9/23 0:00	3197.3
7/10/23 0:00	3175.3
7/11/23 0:00	3508.0
7/12/23 0:00	3030.9
7/13/23 0:00	2869.7
7/14/23 0:00	3271.1
7/15/23 0:00	3142.9
7/16/23 0:00	3765.6
7/17/23 0:00	3555.6
7/18/23 0:00	3746.1
7/19/23 0:00	3336.5
7/20/23 0:00	4006.9
7/21/23 0:00	3860.5
7/22/23 0:00	4639.5
7/23/23 0:00	4478.5
7/24/23 0:00	4422.9
7/25/23 0:00	4866.5
7/26/23 0:00	4256.6
7/27/23 0:00	4379.5
7/28/23 0:00	4222.3
7/29/23 0:00	4016.8
7/30/23 0:00	4543.2
7/31/23 0:00	4283.3
8/1/23 0:00	4701.9
8/2/23 0:00	4305.5
8/3/23 0:00	3716.7
8/4/23 0:00	4200.3
8/5/23 0:00	4030.8
8/6/23 0:00	3728.5
8/7/23 0:00	3951.1
8/8/23 0:00	4308.3
8/9/23 0:00	4378.0
8/10/23 0:00	3931.0
8/11/23 0:00	4090.2
8/12/23 0:00	3853.8
8/13/23 0:00	3906.4
8/14/23 0:00	4048.3
8/15/23 0:00	3825.3
8/16/23 0:00	4332.7
8/17/23 0:00	4549.1
8/18/23 0:00	4235.4

8/19/23 0:00	4007.6
8/20/23 0:00	4205.3
8/21/23 0:00	4849.2
8/22/23 0:00	3878.0
8/23/23 0:00	4122.8
8/24/23 0:00	4210.8
8/25/23 0:00	4029.7
8/26/23 0:00	4326.0
8/27/23 0:00	4134.7
8/28/23 0:00	3993.5
8/29/23 0:00	4156.7
8/30/23 0:00	4435.9
8/31/23 0:00	4373.2
9/1/23 0:00	4278.8
9/2/23 0:00	4955.0
9/3/23 0:00	4402.7
9/4/23 0:00	4328.3
9/5/23 0:00	4576.4
9/6/23 0:00	4147.5
9/7/23 0:00	3389.2
9/8/23 0:00	3833.7
9/9/23 0:00	3746.8
9/10/23 0:00	3424.2
9/11/23 0:00	4030.1
9/12/23 0:00	3768.1
9/13/23 0:00	3756.0
9/14/23 0:00	4175.1
9/15/23 0:00	4578.7
9/16/23 0:00	3812.7
9/17/23 0:00	4408.4
9/18/23 0:00	4349.6
9/19/23 0:00	4193.1
9/20/23 0:00	4710.9
9/21/23 0:00	4182.9
9/22/23 0:00	4696.2
9/23/23 0:00	4064.6
9/24/23 0:00	4676.2
9/25/23 0:00	4532.2
9/26/23 0:00	4016.5
9/27/23 0:00	4401.1
9/28/23 0:00	3723.9

Resize to show allsize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	4028	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00257792	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	8.32
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	765	3Q23
---------------------------	------------	-------------

fill only these

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

7/1/2023 0:00

9/30/2023 0:00

1D

TOWER AVG.

519-AIT-9504-1

4028

7/1/23 0:00	3415.8
7/2/23 0:00	3333.1
7/3/23 0:00	3695.8
7/4/23 0:00	3869.9
7/5/23 0:00	3605.8
7/6/23 0:00	3317.9
7/7/23 0:00	3242.9
7/8/23 0:00	3450.6
7/9/23 0:00	3197.3
7/10/23 0:00	3175.3
7/11/23 0:00	3508.0
7/12/23 0:00	3030.9
7/13/23 0:00	2869.7
7/14/23 0:00	3271.1
7/15/23 0:00	3142.9
7/16/23 0:00	3765.6
7/17/23 0:00	3555.6
7/18/23 0:00	3746.1
7/19/23 0:00	3336.5
7/20/23 0:00	4006.9
7/21/23 0:00	3860.5
7/22/23 0:00	4639.5
7/23/23 0:00	4478.5
7/24/23 0:00	4422.9
7/25/23 0:00	4866.5
7/26/23 0:00	4256.6
7/27/23 0:00	4379.5
7/28/23 0:00	4222.3
7/29/23 0:00	4016.8
7/30/23 0:00	4543.2
7/31/23 0:00	4283.3
8/1/23 0:00	4701.9
8/2/23 0:00	4305.5
8/3/23 0:00	3716.7
8/4/23 0:00	4200.3
8/5/23 0:00	4030.8
8/6/23 0:00	3728.5
8/7/23 0:00	3951.1
8/8/23 0:00	4308.3
8/9/23 0:00	4378.0
8/10/23 0:00	3931.0
8/11/23 0:00	4090.2
8/12/23 0:00	3853.8
8/13/23 0:00	3906.4
8/14/23 0:00	4048.3
8/15/23 0:00	3825.3
8/16/23 0:00	4332.7
8/17/23 0:00	4549.1
8/18/23 0:00	4235.4

8/19/23 0:00	4007.6
8/20/23 0:00	4205.3
8/21/23 0:00	4849.2
8/22/23 0:00	3878.0
8/23/23 0:00	4122.8
8/24/23 0:00	4210.8
8/25/23 0:00	4029.7
8/26/23 0:00	4326.0
8/27/23 0:00	4134.7
8/28/23 0:00	3993.5
8/29/23 0:00	4156.7
8/30/23 0:00	4435.9
8/31/23 0:00	4373.2
9/1/23 0:00	4278.8
9/2/23 0:00	4955.0
9/3/23 0:00	4402.7
9/4/23 0:00	4328.3
9/5/23 0:00	4576.4
9/6/23 0:00	4147.5
9/7/23 0:00	3389.2
9/8/23 0:00	3833.7
9/9/23 0:00	3746.8
9/10/23 0:00	3424.2
9/11/23 0:00	4030.1
9/12/23 0:00	3768.1
9/13/23 0:00	3756.0
9/14/23 0:00	4175.1
9/15/23 0:00	4578.7
9/16/23 0:00	3812.7
9/17/23 0:00	4408.4
9/18/23 0:00	4349.6
9/19/23 0:00	4193.1
9/20/23 0:00	4710.9
9/21/23 0:00	4182.9
9/22/23 0:00	4696.2
9/23/23 0:00	4064.6
9/24/23 0:00	4676.2
9/25/23 0:00	4532.2
9/26/23 0:00	4016.5
9/27/23 0:00	4401.1
9/28/23 0:00	3723.9

Resize to show allsize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	4028	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00257792	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	8.32
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	765	3Q23
---------------------------	------------	-------------

fill only these