

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	252875-6
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2023 - Part VI
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/31/2023 4:28:41 PM
Docketed Date:	10/31/2023

III. Emissions Deviations

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

CO Ppmvdc EDS/CMS Summary Report



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:45 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_Ppmvdc_3H, CT1_UnitOn_TF_1H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,189.00 Hour(s)
Operating time for CMS: 2,189.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 01:46 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,189.00 Hour(s)
Operating time for CMS: 2,189.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:47 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_Ppmvdc_3H, CT2_UnitOn_TF_1H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,639.00 Hour(s)
Operating time for CMS: 1,639.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.37
4. Total Availability as a percentage of operating time	99.63

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59
Generated: 10/03/2023 01:48

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility



CMS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,639.00 Hour(s)
Operating time for CMS: 1,639.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.37
4. Total Availability as a percentage of operating time	99.63

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:49 Location: Roseville, CA



Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 2,189.00 Hour(s)
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/07/2023 09:00	08/07/2023 09:59	1	23 - Maintenance	

Total Operating Time:	2,189.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	100.00

NOx Invalid Data

CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:50 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 2,189.00 Hour(s)
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/07/2023 09:00	08/07/2023 09:59	1	23 - Maintenance	

Total Operating Time:	2,189.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	100.00

NOx SCR Invalid Data



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:51 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 2,189.00 Hour(s)
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	2,189.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:52 Location: Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 2,189.00 Hour(s)
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/07/2023 09:00	08/07/2023 09:59	1	23 - Maintenance	

Total Operating Time:	2,189.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	100.00

CO Invalid Data

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:52 Location: Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,639.00 Hour(s)
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,639.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:53 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 1,639.00 Hour(s)
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/07/2023 17:00	07/07/2023 17:59	1		
2	07/08/2023 09:00	07/08/2023 09:59	1		
3	07/08/2023 17:00	07/08/2023 17:59	1		
4	07/08/2023 18:00	07/08/2023 18:59	1		
5	07/09/2023 06:00	07/09/2023 06:59	1		
6	07/09/2023 07:00	07/09/2023 07:59	1	3 - Quality assurance calibration	

Total Operating Time:	1,639.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.63 %
Percent Monitor Downtime:	0.37 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	16.67

NOx SCR Invalid Data

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:54 Location: Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,639.00 Hour(s)
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/04/2023 02:00	09/04/2023 02:59	1	3 - Quality assurance calibration	
2	09/04/2023 03:00	09/04/2023 03:59	1		
3	09/04/2023 04:00	09/04/2023 04:59	1		
4	09/04/2023 05:00	09/04/2023 05:59	1		
5	09/04/2023 06:00	09/04/2023 06:59	1		
6	09/04/2023 07:00	09/04/2023 07:59	1		
7	09/04/2023 08:00	09/04/2023 08:59	1		
8	09/04/2023 09:00	09/04/2023 09:59	1		
9	09/04/2023 10:00	09/04/2023 10:59	1		
10	09/04/2023 11:00	09/04/2023 11:59	1		
11	09/04/2023 12:00	09/04/2023 12:59	1		
12	09/04/2023 13:00	09/04/2023 13:59	1		
13	09/04/2023 14:00	09/04/2023 14:59	1		
14	09/04/2023 15:00	09/04/2023 15:59	1		
15	09/04/2023 16:00	09/04/2023 16:59	1		
16	09/04/2023 17:00	09/04/2023 17:59	1		
17	09/04/2023 18:00	09/04/2023 18:59	1		
18	09/04/2023 19:00	09/04/2023 19:59	1		
19	09/04/2023 20:00	09/04/2023 20:59	1		
20	09/04/2023 21:00	09/04/2023 21:59	1		
21	09/04/2023 22:00	09/04/2023 22:59	1		
22	09/04/2023 23:00	09/04/2023 23:59	1		
23	09/05/2023 00:00	09/05/2023 00:59	1		
24	09/05/2023 01:00	09/05/2023 01:59	1		
25	09/05/2023 02:00	09/05/2023 02:59	1	3 - Quality assurance calibration	
26	09/05/2023 03:00	09/05/2023 03:59	1	3 - Quality assurance calibration	

NOx SCR Invalid Data



CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:54 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,639.00 Hour(s)
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

Total Operating Time:	1,639.00 Hour(s)
Total Monitor Downtime (Online only):	26.00 Hour(s)
Percent Monitor Availability:	98.41 %
Percent Monitor Downtime:	1.59 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	11.54

02 Invalid Data

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:55 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,639.00 Hour(s)
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/07/2023 17:00	07/07/2023 17:59	1		
2	07/08/2023 09:00	07/08/2023 09:59	1		
3	07/08/2023 17:00	07/08/2023 17:59	1		
4	07/08/2023 18:00	07/08/2023 18:59	1		
5	07/09/2023 06:00	07/09/2023 06:59	1		
6	07/09/2023 07:00	07/09/2023 07:59	1	3 - Quality assurance calibration	

Total Operating Time:	1,639.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.63 %
Percent Monitor Downtime:	0.37 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	16.67

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/01/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/01/23 02:25	200.0	182.1	177.8	R-A /Span * 100		2.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/01/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/01/23 02:20	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/01/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/01/23 03:25	200.0	178.7	180.7	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/01/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	07/01/23 03:20	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/01/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/01/23 03:25	200.0	182.1	180.9	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/01/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/01/23 03:20	10.0	8.4	8.2	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/01/23 03:15		18.1	18.0	R-A		0.1
	Zero	07/01/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/02/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/02/23 02:24	200.0	182.1	177.5	R-A /Span * 100		2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/02/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/02/23 02:20	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/02/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/02/23 03:25	200.0	178.7	180.7	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/02/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	07/02/23 03:19	10.0	8.7	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/02/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/02/23 03:25	200.0	182.1	180.7	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/02/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	07/02/23 03:19	10.0	8.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/02/23 03:15	18.1	18.0		R-A	0.1
	Zero	07/02/23 03:19	0.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/03/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/03/23 02:25	200.0	182.1		R-A /Span * 100	2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/03/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/03/23 02:19	30.0	25.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/03/23 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	07/03/23 03:25	200.0	178.7		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/03/23 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	07/03/23 03:20	10.0	8.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/03/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/03/23 03:25	200.0	182.1		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/03/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/03/23 03:20	10.0	8.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/03/23 03:14	18.1	18.0		R-A	0.1
	Zero	07/03/23 03:20	0.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/04/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/04/23 02:25	200.0	182.1		R-A /Span * 100	1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/04/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	07/04/23 02:19	30.0	25.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/04/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/04/23 03:25	200.0	178.7		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/04/23 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	07/04/23 03:19	10.0	8.7	8.8	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/04/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/04/23 03:25	200.0	182.1	180.5	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/04/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/04/23 03:19	10.0	8.4	8.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/04/23 03:15		18.1	18.0	R-A	0.1
	Zero	07/04/23 03:19		0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/05/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/05/23 02:25	200.0	182.1	177.7	R-A /Span * 100	2.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/05/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/05/23 02:19	30.0	25.2	25.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/05/23 03:25	200.0	178.7	179.7	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/05/23 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	07/05/23 03:19	10.0	8.7	8.7	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/05/23 03:25	200.0	182.1	180.1	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/05/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/05/23 03:19	10.0	8.4	8.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/05/23 03:14		18.1	18.0	R-A	0.1
	Zero	07/05/23 03:19		0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/06/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/06/23 02:24	200.0	182.1	176.4	>1x Alert R-A /Span * 100	2.9

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/06/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/06/23 02:19	30.0	25.2		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/06/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/06/23 03:25	200.0	178.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/06/23 03:15	10.0	0.1		R-A /Span * 100	1.0
	High	07/06/23 03:20	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/06/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/06/23 03:25	200.0	182.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/06/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	07/06/23 03:20	10.0	8.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/06/23 03:15		18.1		R-A	0.1
	Zero	07/06/23 03:20		0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/07/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/07/23 02:25	200.0	182.1	>1x Alert	R-A /Span * 100	2.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/07/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/07/23 02:19	30.0	25.2		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/07/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/07/23 03:25	200.0	178.7		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/07/23 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	07/07/23 03:19	10.0	8.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/07/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/07/23 03:25	200.0	182.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/07/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/07/23 03:19	10.0	8.4		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/07/23 03:14	18.1	18.0	R-A		0.1
	Zero	07/07/23 03:19	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/08/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/08/23 02:25	200.0	181.1	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/08/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/08/23 02:20	30.0	24.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/08/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/08/23 03:25	200.0	179.6	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/08/23 03:15	10.0	-0.1	R-A /Span * 100		1.0
	High	07/08/23 03:20	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/08/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/08/23 03:25	200.0	180.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/08/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	07/08/23 03:20	10.0	8.1	R-A		0.8
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/08/23 03:15	18.0	18.0	R-A		0.0
	Zero	07/08/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/09/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 02:25	200.0	181.0	R-A /Span * 100		0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/09/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 02:20	30.0	24.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/09/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 03:24	200.0	179.6	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/09/23 03:14	10.0	-0.1	R-A /Span * 100		1.0
	High	07/09/23 03:20	10.0	8.9	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/09/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 03:24	200.0	182.1	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/09/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 03:20	10.0	8.9	R-A		0.8
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/09/23 03:14	18.0	18.0	R-A		0.0
	Zero	07/09/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/09/23 07:38	200.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 07:48	200.0	181.5	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/09/23 07:38	10.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 07:44	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/09/23 07:38	200.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 07:48	200.0	184.8	>1x Alert R-A /Span * 100		3.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/09/23 07:38	10.0	0.0	R-A /Span * 100		0.0
	High	07/09/23 07:44	10.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/09/23 07:38	21.0	18.0	R-A		0.0
	Zero	07/09/23 07:44	21.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/10/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/10/23 02:24	200.0	181.1	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/10/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/10/23 02:19	30.0	25.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/10/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/10/23 03:25	200.0	178.7	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/10/23 03:15	10.0	-0.1	R-A /Span * 100		1.0
	High	07/10/23 03:20	10.0	8.9	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/10/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/10/23 03:25	200.0	182.1	179.5	R-A /Span * 100		1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/10/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/10/23 03:20	10.0	8.9	8.1	R-A		0.8
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/10/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/10/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/11/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/11/23 02:25	200.0	182.1	181.2	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/11/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/11/23 02:20	30.0	25.2	25.1	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/11/23 03:24	200.0	178.7	179.4	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/11/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	07/11/23 03:19	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/11/23 03:24	200.0	182.1	179.6	R-A /Span * 100		1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/11/23 03:19	10.0	8.9	8.1	R-A		0.8
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/11/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/11/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/12/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/12/23 02:24	200.0	182.1	182.1	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/12/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/12/23 02:20	30.0	25.2	25.2	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/12/23 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	07/12/23 03:25	200.0	178.7	180.6	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/12/23 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	07/12/23 03:20	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/12/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/12/23 03:25	200.0	182.1	179.4	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/12/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/12/23 03:20	10.0	8.9	8.1	R-A		0.8
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/12/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/12/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/13/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/13/23 02:24	200.0	182.1	182.5	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/13/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/13/23 02:19	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/13/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/13/23 03:25	200.0	178.7	179.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/13/23 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	07/13/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/13/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/13/23 03:25	200.0	182.1	181.7	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/13/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/13/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/13/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/13/23 03:20		0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/14/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/14/23 02:25	200.0	184.5	179.2 >1x Alert	R-A /Span * 100	2.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/14/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	07/14/23 02:19	30.0	25.2	24.7	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/14/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/14/23 03:25	200.0	182.1	180.0	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/14/23 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	07/14/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/14/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/14/23 03:25	200.0	184.5	181.1	R-A /Span * 100	1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/14/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/14/23 03:20	10.0	8.9	8.7	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/14/23 03:15		18.0	18.0	R-A	0.0
	Zero	07/14/23 03:20		0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/14/23 18:25	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/14/23 18:35	200.0	182.2	182.2	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/14/23 18:25	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/14/23 18:29	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/14/23 18:25	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/14/23 18:35	200.0	184.8	184.4	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/14/23 18:25	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	07/14/23 18:29	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/14/23 18:25	21.0	18.0	18.0	R-A	0.0
	Zero	07/14/23 18:29	21.0	0.0	0.1	R-A	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 02:25	200.0	184.5	184.3	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/15/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 02:20	30.0	25.2	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/15/23 02:25	200.0	184.8	177.2	>1x Alert R-A /Span * 100		3.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/15/23 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	07/15/23 02:19	30.0	25.4	24.1	>1x Alert R-A /Span * 100		4.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:25	200.0	182.1	180.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:25	200.0	184.5	181.2	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:19	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/15/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/15/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:25	200.0	182.2	182.5	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:25	200.0	184.8	183.7	R-A /Span * 100		0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/15/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	07/15/23 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/15/23 03:15	21.0	18.0	R-A		0.0
	Zero	07/15/23 03:20	21.0	0.1	R-A		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 02:14	200.0	0.1	R-A /Span * 100		0.1
	High	07/16/23 02:24	200.0	175.2	>1x Alert	R-A /Span * 100	4.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Warning	
	Zero	07/16/23 02:14	30.0	0.1	R-A /Span * 100		0.3
	High	07/16/23 02:19	30.0	23.8	>2x	R-A /Span * 100	5.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 02:25	200.0	184.5	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/16/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 02:20	30.0	25.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 03:25	200.0	182.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/16/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 03:20	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 03:25	200.0	184.5	R-A /Span * 100		1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/16/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 03:20	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/16/23 03:15		18.0	R-A		0.0
	Zero	07/16/23 03:20		0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/16/23 03:25	200.0	182.2	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/16/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/16/23 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/16/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/16/23 03:25	200.0	184.8		R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/16/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/16/23 03:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/16/23 03:14	21.0	18.0		R-A	0.0
	Zero	07/16/23 03:20	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 02:25	200.0	184.5		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/17/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 02:20	30.0	25.2		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 02:15	200.0	0.0		R-A /Span * 100	0.1
	High	07/17/23 02:25	200.0	184.8	>1x Alert	R-A /Span * 100	4.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Warning	
	Zero	07/17/23 02:15	30.0	0.0		R-A /Span * 100	0.3
	High	07/17/23 02:20	30.0	25.4	>2x	R-A /Span * 100	5.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 03:25	200.0	182.1		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/17/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 03:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 03:25	200.0	184.5		R-A /Span * 100	1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/17/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	07/17/23 03:20	10.0	8.9		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/17/23 03:15	18.0	18.0	R-A		0.0
	Zero	07/17/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/17/23 03:25	200.0	182.2	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/17/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/17/23 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/17/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/17/23 03:25	200.0	184.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/17/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/17/23 03:19	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/17/23 03:14	21.0	18.0	R-A		0.0
	Zero	07/17/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 02:24	200.0	184.5	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 02:19	30.0	25.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 02:25	200.0	184.8	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 02:19	30.0	25.4	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 03:24	200.0	182.1	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/18/23 03:19	10.0	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:24	200.0	184.5		R-A /Span * 100	1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:19	10.0	8.9		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/18/23 03:14	18.0	18.0		R-A	0.0
	Zero	07/18/23 03:19	0.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:24	200.0	182.2		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:24	200.0	184.8		R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/18/23 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/18/23 03:14	21.0	18.0		R-A	0.0
	Zero	07/18/23 03:19	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/19/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	07/19/23 02:25	200.0	184.5		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/19/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	07/19/23 02:19	30.0	25.2		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/19/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/19/23 02:24	200.0	184.8		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/19/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/19/23 02:20	30.0	25.4		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:25	200.0	182.1	179.3	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:25	200.0	184.5	181.4	R-A /Span * 100		1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:20	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/19/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/19/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:25	200.0	182.2	181.9	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:25	200.0	184.8	182.7	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/19/23 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/19/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/19/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 02:25	200.0	184.5	183.8	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 02:20	30.0	25.2	25.2	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 02:25	200.0	184.8	183.2	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 02:20	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:24	200.0	182.2	181.5	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:24	200.0	184.8	182.6	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/20/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/20/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:24	200.0	182.1	179.3	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:24	200.0	184.5	181.2	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/20/23 03:20	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/20/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/20/23 03:20		0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 02:25	200.0	184.5	184.3	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 02:19	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 02:25	200.0	184.8	183.6	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 02:20	30.0	25.4	25.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:25	200.0	182.1	179.4	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:25	200.0	184.5	181.1	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:20	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/21/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/21/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:24	200.0	182.2	182.2	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:24	200.0	184.8	182.7	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/21/23 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/21/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/21/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 02:25	200.0	184.5	184.5	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 02:20	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 02:24	200.0	184.8	183.1	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 02:19	30.0	25.4	25.2	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:24	200.0	182.2	182.5	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:24	200.0	184.8	182.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/22/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/22/23 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:24	200.0	182.1	179.9	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:24	200.0	184.5	181.4	R-A /Span * 100		1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/22/23 03:20	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/22/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/22/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/23/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 02:24	200.0	184.5	184.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/23/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 02:19	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/23/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 02:25	200.0	184.8	183.1	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/23/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 02:20	30.0	25.4	25.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:25	200.0	182.1	180.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:25	200.0	184.5	181.1	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:19	10.0	8.9	8.7	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/23/23 03:14	18.0	18.0	R-A		0.0
	Zero	07/23/23 03:19	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:25	200.0	183.2	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	07/23/23 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:25	200.0	182.7	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/23/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/23/23 03:19	10.0	9.4	>1x Alert R-A /Span * 100		3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/23/23 03:14	21.0	18.0	R-A		0.0
	Zero	07/23/23 03:19	21.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 02:25	200.0	184.7	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 02:19	30.0	25.4	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 02:25	200.0	183.4	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 02:19	30.0	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 03:25	200.0	179.4	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/24/23 03:20	10.0	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:25	200.0	184.5		R-A /Span * 100	1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:20	10.0	8.9		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/24/23 03:14	18.0	18.0		R-A	0.0
	Zero	07/24/23 03:20	0.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:25	200.0	182.2		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:25	200.0	184.8		R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/24/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/24/23 03:19	10.0	9.7	>1x Alert	R-A /Span * 100	3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/24/23 03:14	21.0	18.0		R-A	0.0
	Zero	07/24/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/25/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/25/23 02:24	200.0	184.5		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/25/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/25/23 02:19	30.0	25.2		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/25/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/25/23 02:24	200.0	184.8		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/25/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/25/23 02:20	30.0	25.4		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/25/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:24	200.0	182.1	179.0	R-A /Span * 100		1.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/25/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/25/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:24	200.0	184.5	180.9	R-A /Span * 100		1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/25/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/25/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/25/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/25/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:25	200.0	182.2	182.8	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/25/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/25/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:25	200.0	184.8	184.7	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/25/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/25/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/25/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/25/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/26/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 02:25	200.0	184.5	185.0	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/26/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 02:20	30.0	25.2	25.3	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/26/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 02:24	200.0	184.8	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/26/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 02:19	30.0	25.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/26/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:25	200.0	182.1	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/26/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/26/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:25	200.0	184.5	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/26/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:19	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/26/23 03:14	18.0	18.0	R-A		0.0
	Zero	07/26/23 03:19	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/26/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:25	200.0	182.2	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/26/23 03:15	10.0	0.0	R-A /Span * 100		1.0
	High	07/26/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/26/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:25	200.0	184.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/26/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	07/26/23 03:20	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/26/23 03:15	21.0	18.0	R-A		0.0
	Zero	07/26/23 03:20	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 02:24	200.0	184.5	184.3	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 02:20	30.0	25.2	25.1	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 02:25	200.0	184.8	182.7	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 02:19	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:24	200.0	182.1	180.8	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:24	200.0	184.5	181.3	R-A /Span * 100		1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:20	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/27/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/27/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:24	200.0	182.2	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:24	200.0	184.8	183.9	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/27/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/27/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/27/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/28/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 02:25	200.0	184.5	184.8	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/28/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 02:19	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/28/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 02:24	200.0	184.8	183.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/28/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 02:20	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 03:24	200.0	182.1	180.6	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 03:24	200.0	184.5	181.1	R-A /Span * 100		1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/28/23 03:19	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/28/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/28/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/28/23 03:24	200.0	182.2	182.5	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	07/28/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/28/23 03:24	200.0	184.8		R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/28/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/28/23 03:19	10.0	9.7		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/28/23 03:14	21.0	18.0		R-A	0.0
	Zero	07/28/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/29/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 02:24	200.0	184.8		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/29/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 02:19	30.0	25.4		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/29/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 02:25	200.0	184.5		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/29/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 02:19	30.0	25.2		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 03:25	200.0	182.1		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	07/29/23 03:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 03:25	200.0	184.5		R-A /Span * 100	1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	07/29/23 03:20	10.0	8.9		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/29/23 03:14		18.0	18.0	R-A		0.0
	Zero	07/29/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/29/23 03:25	200.0	182.2	181.7	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	07/29/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/29/23 03:25	200.0	184.8	183.9	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/29/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/29/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/29/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	07/29/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/30/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 02:24	200.0	184.5	185.9	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/30/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 02:19	30.0	25.2	25.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/30/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 02:25	200.0	184.8	184.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/30/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 02:19	30.0	25.4	25.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/30/23 03:24	200.0	182.2	181.8	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	07/30/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 03:24	200.0	184.8	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/30/23 03:14	21.0	18.0	R-A		0.0
	Zero	07/30/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 03:25	200.0	182.1	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	07/30/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 03:25	200.0	184.5	R-A /Span * 100		1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/30/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	07/30/23 03:20	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	07/30/23 03:14		18.0	R-A		0.0
	Zero	07/30/23 03:20		0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/31/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 02:25	200.0	184.5	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/31/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 02:19	30.0	25.2	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	07/31/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 02:25	200.0	184.8	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	07/31/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 02:20	30.0	25.4	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 03:25	200.0	182.1	180.3	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	07/31/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 03:25	200.0	184.5	180.8	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/31/23 03:15		18.0	18.0	R-A		0.0
	Zero	07/31/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	07/31/23 03:25	200.0	182.2	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	07/31/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 03:25	200.0	184.8	184.0	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	07/31/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	07/31/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	07/31/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	07/31/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 02:25	200.0	184.5	184.8	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 02:20	30.0	25.2	25.3	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 02:25	200.0	184.8	183.1	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 02:19	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:24	200.0	182.1	180.8	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:24	200.0	184.5	180.8	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/01/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/01/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/01/23 03:24	200.0	182.2	182.4	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/01/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:24	200.0	184.8	184.1	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/01/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/01/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/01/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/01/23 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 02:25	200.0	184.5	184.1	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/02/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 02:20	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 02:24	200.0	184.8	182.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/02/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 02:19	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 03:24	200.0	182.1	179.4	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 03:24	200.0	184.5	180.6	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/02/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/02/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/02/23 03:25	200.0	182.2	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/02/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/02/23 03:25	200.0	184.8	183.8	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/02/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/02/23 03:19	10.0	9.7		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/02/23 03:14	21.0	18.0		R-A	0.0
	Zero	08/02/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 02:24	200.0	184.5		R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 02:20	30.0	25.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 02:25	200.0	184.8		R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 02:20	30.0	25.4		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 03:25	200.0	182.1		R-A /Span * 100	1.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 03:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 03:25	200.0	184.5		R-A /Span * 100	1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/03/23 03:20	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/03/23 03:15		18.0		R-A	0.0
	Zero	08/03/23 03:20		0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	08/03/23 03:25	200.0	182.2		R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	08/03/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/03/23 03:25	200.0	184.8	183.5	R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/03/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/03/23 03:20	10.0	9.7	9.6	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/03/23 03:15	21.0	18.0	18.0	R-A	0.0
	Zero	08/03/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/04/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 02:25	200.0	184.5	184.1	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/04/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 02:20	30.0	25.2	25.4	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/04/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 02:25	200.0	184.8	182.1	R-A /Span * 100	1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/04/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 02:20	30.0	25.4	25.0	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 03:24	200.0	182.1	179.3	R-A /Span * 100	1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 03:24	200.0	184.5	180.6	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	08/04/23 03:20	10.0	8.9	8.8	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/04/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/04/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/04/23 03:25	200.0	182.2	182.9	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/04/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/04/23 03:25	200.0	184.8	184.2	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/04/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/04/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/04/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 02:24	200.0	184.5	184.1	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 02:19	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 02:25	200.0	184.8	182.5	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 02:20	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/05/23 03:24	200.0	182.1	179.6	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	08/05/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 03:24	200.0	184.5	180.8	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/05/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/05/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/05/23 03:25	200.0	182.2	183.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/05/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/05/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 03:25	200.0	184.8	184.3	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/05/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/05/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/05/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	08/05/23 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 02:25	200.0	184.5	184.2	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 02:20	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 02:25	200.0	184.8	182.8	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 02:20	30.0	25.4	25.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/06/23 03:25	200.0	182.1	179.7	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	08/06/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 03:25	200.0	184.5	180.8	R-A /Span * 100		1.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/06/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/06/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/06/23 03:25	200.0	182.2	183.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/06/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 03:25	200.0	184.8	184.2	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/06/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/06/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/06/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	08/06/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 02:24	200.0	184.8	182.8	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 02:19	30.0	25.4	25.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 02:25	200.0	184.5	185.8	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 02:20	30.0	25.2	25.5	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/07/23 03:25	200.0	182.1	179.9	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	08/07/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 03:25	200.0	184.5	181.0	R-A /Span * 100		1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/07/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/07/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	08/07/23 03:25	200.0	182.2	183.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	08/07/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/07/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 03:25	200.0	184.8	183.9	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/07/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/07/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/07/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/07/23 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 02:25	200.0	184.5	184.1	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/08/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 02:19	30.0	25.2	24.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 02:25	200.0	184.8	182.3	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/08/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 02:20	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:24	200.0	182.1	182.1	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:24	200.0	184.5	183.4	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:19	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/08/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/08/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:24	200.0	182.2	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:24	200.0	184.8	184.7	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/08/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/08/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/08/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/08/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/09/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 02:24	200.0	184.5	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/09/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 02:19	30.0	25.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/09/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 02:24	200.0	184.8	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/09/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 02:19	30.0	25.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:24	200.0	182.1	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:24	200.0	184.5	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:19	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/09/23 03:14		18.0	R-A		0.0
	Zero	08/09/23 03:19		0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:25	200.0	182.2	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:25	200.0	184.8	183.6	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/09/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/09/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/09/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/10/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 02:25	200.0	184.5	184.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/10/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 02:20	30.0	25.2	25.1	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/10/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 02:25	200.0	181.1	179.4	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/10/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 02:20	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:24	200.0	180.8	182.5	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:24	200.0	181.1	182.4	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/10/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/10/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:24	200.0	183.3	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:24	200.0	183.2	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/10/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/10/23 03:20	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/10/23 03:14	18.0	18.0	R-A		0.0
	Zero	08/10/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/11/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 02:25	200.0	184.2	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/11/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 02:20	30.0	24.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/11/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 02:25	200.0	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/11/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 02:19	30.0	24.9	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/11/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:25	200.0	183.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/11/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:20	10.0	9.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/11/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:25	200.0	184.5	183.1	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/11/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:20	10.0	8.9	8.6	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/11/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/11/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:25	200.0	180.8	182.4	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:25	200.0	181.1	181.8	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/11/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/11/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/11/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/12/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/12/23 02:25	200.0	184.5	183.5	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/12/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/12/23 02:20	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/12/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/12/23 02:24	200.0	181.1	180.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/12/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/12/23 02:19	30.0	25.4	25.0	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:24	200.0	180.8		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:24	200.0	181.1		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/12/23 03:14	21.0	18.0		R-A	0.0
	Zero	08/12/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:25	200.0	182.1		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:25	200.0	184.5		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/12/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/12/23 03:20	10.0	8.9	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/12/23 03:14		18.0		R-A	0.0
	Zero	08/12/23 03:20		0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/13/23 02:24	200.0	181.6		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/13/23 02:19	30.0	25.2		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 02:24	200.0	181.1	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 02:19	30.0	25.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:25	200.0	178.4	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:25	200.0	181.6	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:20	10.0	8.9	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/13/23 03:15	18.0	18.0	R-A		0.0
	Zero	08/13/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:25	200.0	180.8	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/13/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:25	200.0	181.1	R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/13/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/13/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/13/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/13/23 03:19	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 02:24	200.0	181.1	180.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 02:20	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 02:25	200.0	181.6	183.7	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 02:20	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:25	200.0	178.4	180.8	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:25	200.0	181.6	183.0	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:19	10.0	8.9	8.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/14/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/14/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:25	200.0	180.8	181.4	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:25	200.0	181.1	182.6	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/14/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/14/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/14/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/14/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/15/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 02:25	200.0	181.6	183.6	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/15/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 02:19	30.0	25.2	24.9	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/15/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 02:24	200.0	181.1	180.4	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/15/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 02:20	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:25	200.0	178.4	181.1	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:25	200.0	181.6	183.1	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:20	10.0	8.9	8.6	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/15/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/15/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/15/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:25	200.0	180.8	181.9	R-A /Span * 100		0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/15/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:25	200.0	181.1	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/15/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/15/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/15/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/15/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 02:24	200.0	181.6	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 02:20	30.0	25.2	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 02:25	200.0	181.1	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 02:20	30.0	25.4	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:24	200.0	178.4	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:24	200.0	181.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:19	10.0	8.9	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/16/23 03:14	18.0	18.0	R-A		0.0
	Zero	08/16/23 03:19	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:25	200.0	181.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/16/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:25	200.0	181.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/16/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/16/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/16/23 03:15	21.0	18.0	R-A		0.0
	Zero	08/16/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 02:24	200.0	183.8	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 02:20	30.0	25.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 02:25	200.0	180.4	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 02:20	30.0	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 03:24	200.0	178.4	R-A /Span * 100		1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/17/23 03:19	10.0	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:24	200.0	181.6	183.3	R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:19	10.0	8.9	8.6	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/17/23 03:14		18.0	18.0	R-A	0.0
	Zero	08/17/23 03:19		0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:25	200.0	180.8	182.2	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:25	200.0	181.1	182.3	R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/17/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/17/23 03:19	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/17/23 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	08/17/23 03:19	21.0	0.0	0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 02:25	200.0	181.6	183.7	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 02:20	30.0	25.2	25.1	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 02:25	200.0	181.1	180.3	R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 02:20	30.0	25.4	25.1	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:24	200.0	178.4		R-A /Span * 100	1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:24	200.0	181.6		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:19	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/18/23 03:14	18.0	18.0		R-A	0.0
	Zero	08/18/23 03:19	0.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:24	200.0	180.8		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:24	200.0	181.1		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/18/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/18/23 03:19	10.0	9.7		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/18/23 03:14	21.0	18.0		R-A	0.0
	Zero	08/18/23 03:19	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/19/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/19/23 02:25	200.0	181.6		R-A /Span * 100	1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/19/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	08/19/23 02:19	30.0	25.2		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/19/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 02:25	200.0	181.1	182.1	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/19/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 02:19	30.0	25.4	25.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:25	200.0	178.4	182.2	R-A /Span * 100		1.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:25	200.0	181.6	183.1	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/19/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/19/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:25	200.0	180.8	181.5	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:25	200.0	181.1	182.2	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/19/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/19/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/19/23 03:19	21.0	0.0	0.1	R-A		0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 02:25	200.0	181.6	184.6	R-A /Span * 100		1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 02:19	30.0	25.2	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 02:25	200.0	181.1	181.8	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 02:20	30.0	25.4	25.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:25	200.0	178.4	181.9	R-A /Span * 100		1.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:25	200.0	181.6	183.1	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/20/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/20/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:24	200.0	180.8	181.8	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:24	200.0	181.1	182.6	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/20/23 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/20/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/20/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 02:25	200.0	181.6	185.0	R-A /Span * 100		1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 02:19	30.0	25.2	25.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 02:25	200.0	181.1	182.3	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 02:19	30.0	25.4	25.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:24	200.0	178.4	182.2	R-A /Span * 100		1.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:24	200.0	181.6	183.1	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/21/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/21/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:25	200.0	180.8	182.1	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:25	200.0	181.1	182.6	R-A /Span * 100		0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/21/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	08/21/23 03:20	21.0	0.0	0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 15:13	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 15:24	200.0	180.8	180.8	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 15:13	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 15:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/21/23 15:13	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 15:24	200.0	181.1	182.1	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/21/23 15:13	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/21/23 15:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/21/23 15:13	21.0	18.0	18.0	R-A		0.0
	Zero	08/21/23 15:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 02:24	200.0	181.6	183.9	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 02:19	30.0	25.2	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 02:25	200.0	181.1	181.9	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 02:19	30.0	25.4	25.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:24	200.0	178.4	181.5	R-A /Span * 100		1.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:24	200.0	181.6	182.7	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/22/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/22/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:25	200.0	180.8	181.1	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:25	200.0	181.1	182.3	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/22/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/22/23 03:15	21.0	18.0	18.0	R-A		0.0
	Zero	08/22/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 02:25	200.0	181.6	184.4	R-A /Span * 100		1.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 02:20	30.0	25.2	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 02:25	200.0	181.1	180.0	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 02:20	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:25	200.0	178.4	181.5	R-A /Span * 100		1.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:25	200.0	181.6	182.9	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/23/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/23/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:25	200.0	180.8	181.4	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:25	200.0	181.1	181.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/23/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/23/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/23/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 02:25	200.0	181.6	R-A /Span * 100		1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 02:20	30.0	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 02:25	200.0	181.1	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 02:19	30.0	25.4	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:25	200.0	178.4	R-A /Span * 100		1.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:25	200.0	181.6	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:19	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/24/23 03:14		18.0	R-A		0.0
	Zero	08/24/23 03:19		0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:25	200.0	180.8	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/24/23 03:19	10.0	9.1	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/24/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/24/23 03:25	200.0	181.1		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/24/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/24/23 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/24/23 03:15	21.0	18.0		R-A	0.0
	Zero	08/24/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 02:25	200.0	181.6		R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 02:20	30.0	25.2		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 02:25	200.0	181.1		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 02:19	30.0	25.4		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:24	200.0	178.4		R-A /Span * 100	1.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:24	200.0	181.6		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:19	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/25/23 03:14		18.0		R-A	0.0
	Zero	08/25/23 03:19		0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:25	200.0	180.8		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/25/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:25	200.0	181.1		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/25/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/25/23 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/25/23 03:15	21.0	18.0		R-A	0.0
	Zero	08/25/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/26/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 02:25	200.0	181.6		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/26/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 02:20	30.0	25.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/26/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 02:25	200.0	181.1		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/26/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 02:19	30.0	25.4		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 03:24	200.0	178.4		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/26/23 03:24	200.0	181.6		R-A /Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/26/23 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/26/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/26/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/26/23 03:25	200.0	180.8	181.8	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/26/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/26/23 03:25	200.0	181.1	182.3	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/26/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/26/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/26/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/26/23 03:19	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 02:25	200.0	181.6	183.6	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 02:20	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 02:25	200.0	181.1	180.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 02:20	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:24	200.0	178.4	180.4	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:24	200.0	181.6	182.8	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/27/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/27/23 03:19		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:24	200.0	180.8	182.1	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	08/27/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:24	200.0	181.1	182.4	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/27/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/27/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/27/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/27/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 02:25	200.0	181.6	183.7	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 02:20	30.0	25.2	25.2	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 02:24	200.0	181.1	180.6	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:56

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 02:19	30.0	25.4	25.0	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:25	200.0	178.4	180.7	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:25	200.0	181.6	182.8	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/28/23 03:14		18.0	18.0	R-A		0.0
	Zero	08/28/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:25	200.0	180.8	181.4	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:25	200.0	181.1	182.8	R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/28/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/28/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/28/23 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	08/28/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 02:24	200.0	181.6	183.8	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 02:19	30.0	25.2	25.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 02:24	200.0	181.1	180.7	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 02:19	30.0	25.4	24.9	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:25	200.0	178.4	180.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:25	200.0	181.6	182.8	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	08/29/23 03:15		18.0	18.0	R-A		0.0
	Zero	08/29/23 03:20		0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:25	200.0	180.8	181.8	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:25	200.0	181.1	182.8	R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	08/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	08/29/23 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/29/23 03:15	21.0	18.0	R-A		0.0
	Zero	08/29/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 02:25	200.0	183.7	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 02:20	30.0	25.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 02:25	200.0	180.8	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 02:20	30.0	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 03:24	200.0	180.7	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	08/30/23 03:20	10.0	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 03:24	200.0	182.9	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/30/23 03:15	18.0	18.0	R-A		0.0
	Zero	08/30/23 03:20	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	08/30/23 03:25	200.0	181.1	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	10.0	-0.1	R-A /Span * 100		1.0
	High	08/30/23 03:20	10.0	9.0	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/30/23 03:25	200.0	181.1		R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/30/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	08/30/23 03:20	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/30/23 03:15	21.0	18.0		R-A	0.0
	Zero	08/30/23 03:20	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 02:25	200.0	181.6		R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 02:20	30.0	25.2		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 02:24	200.0	181.1		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 02:19	30.0	25.4		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 03:24	200.0	178.4		R-A /Span * 100	1.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 03:24	200.0	181.6		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	08/31/23 03:19	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/31/23 03:14	18.0	18.0		R-A	0.0
	Zero	08/31/23 03:19	18.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/31/23 03:25	200.0	180.8	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	10.0	-0.1	R-A /Span * 100		1.0
	High	08/31/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	08/31/23 03:25	200.0	181.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	08/31/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	08/31/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	08/31/23 03:14	21.0	18.0	R-A		0.0
	Zero	08/31/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 02:24	200.0	181.6	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 02:19	30.0	25.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 02:25	200.0	181.1	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 02:19	30.0	25.4	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 03:24	200.0	180.8	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/01/23 03:24	200.0	181.1	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/01/23 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/01/23 03:14	21.0	18.0		R-A	0.0
	Zero	09/01/23 03:19	21.0	0.1		R-A	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/01/23 03:25	200.0	178.4		R-A /Span * 100	1.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/01/23 03:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/01/23 03:25	200.0	181.6		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/01/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/01/23 03:20	10.0	8.9		R-A	0.6
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/01/23 03:14	18.0	18.0		R-A	0.1
	Zero	09/01/23 03:20	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/02/23 02:25	200.0	181.6		R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/02/23 02:19	30.0	25.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/02/23 02:25	200.0	181.1		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	09/02/23 02:20	30.0	25.4		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/02/23 03:25	200.0	178.4		R-A /Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:25	200.0	181.6	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:20	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/02/23 03:15	18.0	18.1	R-A		0.1
	Zero	09/02/23 03:20	18.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:25	200.0	180.8	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/02/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:25	200.0	181.1	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/02/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/02/23 03:19	10.0	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/02/23 03:14	21.0	18.0	R-A		0.2
	Zero	09/02/23 03:19	21.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/03/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 02:24	200.0	181.6	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/03/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 02:19	30.0	25.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/03/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 02:25	200.0	181.1	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/03/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 02:19	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/03/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 03:25	200.0	180.8	180.6	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/03/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/03/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 03:25	200.0	181.1	181.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/03/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/03/23 03:14	21.0	18.0	18.2	R-A		0.2
	Zero	09/03/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/03/23 13:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 13:24	200.0	178.4	177.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/03/23 13:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 13:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/03/23 13:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 13:24	200.0	181.6	180.6	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/03/23 13:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/03/23 13:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/03/23 13:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/03/23 13:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 02:25	200.0	181.6	183.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 02:20	30.0	21.1	20.7	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 02:25	200.0	181.1	181.0	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 02:19	30.0	25.4	25.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:25	200.0	178.4	178.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:25	200.0	181.6	181.5	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/04/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/04/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:25	200.0	180.8	180.8	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/04/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:25	200.0	181.1	180.9	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/04/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/04/23 03:20	10.0	9.7	9.6	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/04/23 03:15	21.0	18.0	18.2	R-A	0.2
	Zero	09/04/23 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 02:25	200.0	181.6	184.2	R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 02:20	30.0	21.5	20.9	R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 02:25	200.0	181.1	180.9	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Fail	
	Zero	09/05/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 02:20	30.0	25.4	21.3	>4x R-A /Span * 100	13.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 03:24	200.0	178.4	179.2	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 03:24	200.0	181.6	181.6	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/05/23 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	09/05/23 03:20	18.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/05/23 03:25	200.0	180.8	181.0	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	09/05/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/05/23 03:25	200.0	181.1	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	09/05/23 03:20	10.0	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/05/23 03:15	21.0	18.0	R-A		0.2
	Zero	09/05/23 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/05/23 03:32	200.0	0.0	R-A /Span * 100		0.0
	High	09/05/23 03:42	200.0	181.1	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/05/23 03:32	30.0	0.0	R-A /Span * 100		0.0
	High	09/05/23 03:37	30.0	21.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 02:24	200.0	181.1	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 02:19	30.0	21.5	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 02:25	200.0	181.6	R-A /Span * 100		1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 02:20	30.0	21.1	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 03:25	200.0	178.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/06/23 03:25	200.0	181.6	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/06/23 03:20	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/06/23 03:14	18.0	18.1		R-A	0.1
	Zero	09/06/23 03:20	18.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/06/23 03:24	200.0	181.3		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/06/23 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/06/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/06/23 03:24	200.0	181.3		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/06/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/06/23 03:19	10.0	9.7		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/06/23 03:15	21.0	18.2		R-A	0.2
	Zero	09/06/23 03:19	21.0	0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/07/23 02:25	200.0	183.9		R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	09/07/23 02:20	30.0	21.1		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/07/23 02:24	200.0	179.9		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	09/07/23 02:19	30.0	21.5		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/07/23 03:25	200.0	178.4		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	09/07/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:25	200.0	181.6	181.6	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/07/23 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	09/07/23 03:20	18.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:25	200.0	180.8	181.7	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/07/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:25	200.0	181.1	180.3	R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/07/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/07/23 03:19	10.0	9.7	9.6	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/07/23 03:15	21.0	18.0	18.2	R-A	0.2
	Zero	09/07/23 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/08/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/08/23 02:24	200.0	181.1	180.5	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/08/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/08/23 02:19	30.0	21.5	21.2	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/08/23 03:24	200.0	180.8	180.6	R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/08/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 03:24	200.0	181.1	180.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/08/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 03:19	10.0	9.7	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/08/23 03:14	21.0	18.0	18.2	R-A		0.2
	Zero	09/08/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/08/23 14:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 14:25	200.0	178.4	177.6	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/08/23 14:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 14:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/08/23 14:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 14:25	200.0	181.6	180.3	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/08/23 14:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/08/23 14:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/08/23 14:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/08/23 14:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 02:25	200.0	181.6	183.0	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 02:20	30.0	21.1	20.8	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 02:24	200.0	181.1	180.0	R-A /Span * 100		0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:25	200.0	178.4	177.6	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:25	200.0	181.6	181.3	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/09/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/09/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:25	200.0	180.8	180.8	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/09/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:25	200.0	181.1	180.4	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/09/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/09/23 03:20	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/09/23 03:15	21.0	18.0	18.2	R-A		0.2
	Zero	09/09/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 02:25	200.0	181.6	183.8	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 02:20	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 02:25	200.0	181.1	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 02:20	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:24	200.0	180.8	181.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:24	200.0	181.1	180.7	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:19	10.0	9.7	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/10/23 03:14	21.0	18.0	18.2	R-A		0.2
	Zero	09/10/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:24	200.0	178.4	177.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:24	200.0	181.6	181.3	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/10/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/10/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/10/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/10/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/11/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 02:24	200.0	182.2	181.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/11/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/11/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 02:25	200.0	181.6	183.1	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/11/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 02:20	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:25	200.0	178.4	177.6	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/11/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:25	200.0	181.6	181.4	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/11/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/11/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/11/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/11/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:25	200.0	178.3	180.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/11/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/11/23 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:25	200.0	182.2	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/11/23 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	09/11/23 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/11/23 03:15	21.0	18.0	R-A		0.2
	Zero	09/11/23 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/12/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 02:24	200.0	182.2	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/12/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 02:19	30.0	21.5	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/12/23 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 02:25	200.0	181.6	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/12/23 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 02:20	30.0	21.1	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:24	200.0	178.3	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:24	200.0	182.2	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:19	10.0	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/12/23 03:14	21.0	18.0	R-A		0.2
	Zero	09/12/23 03:19	21.0	0.0	R-A		0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:24	200.0	178.4	178.1	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:24	200.0	181.6	181.2	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/12/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/12/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/12/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/12/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/13/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 02:25	200.0	181.6	183.2	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/13/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 02:20	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/13/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 02:24	200.0	182.2	183.4	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/13/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 02:20	30.0	21.5	21.3	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/13/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 03:24	200.0	178.4	178.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/13/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/13/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/13/23 03:24	200.0	181.6	181.4	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/13/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/13/23 03:19	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/13/23 03:14	18.0	18.1		R-A	0.1
	Zero	09/13/23 03:19	18.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/13/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/13/23 03:25	200.0	178.3		R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/13/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/13/23 03:20	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/13/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/13/23 03:25	200.0	182.2		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/13/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/13/23 03:20	10.0	9.5		R-A /Span * 100	5.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/13/23 03:15	21.0	18.0		R-A	0.2
	Zero	09/13/23 03:20	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/14/23 02:25	200.0	182.3		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/14/23 02:20	30.0	21.1		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/14/23 02:25	200.0	182.2		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	09/14/23 02:20	30.0	21.5		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/14/23 03:25	200.0	180.0		R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:20	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:25	200.0	182.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:20	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/14/23 03:14	18.0	18.1	R-A		0.1
	Zero	09/14/23 03:20	18.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:24	200.0	178.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:20	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:24	200.0	182.2	R-A /Span * 100		0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/14/23 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	09/14/23 03:20	10.0	9.5	R-A /Span * 100		5.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/14/23 03:14	21.0	18.0	R-A		0.2
	Zero	09/14/23 03:20	21.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/15/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 02:25	200.0	182.3	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/15/23 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 02:20	30.0	21.1	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/15/23 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 02:25	200.0	182.2	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/15/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 02:19	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/15/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:24	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/15/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/15/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:24	200.0	182.3	180.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/15/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/15/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/15/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:24	200.0	178.3	180.7	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/15/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:24	200.0	182.2	183.2	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/15/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/15/23 03:20	10.0	9.5	9.5	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/15/23 03:15	21.0	18.0	18.2	R-A		0.2
	Zero	09/15/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 02:24	200.0	182.3	182.9	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 02:19	30.0	21.1	20.8	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 02:25	200.0	182.2	182.9	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 02:20	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:24	200.0	180.0	180.7	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:24	200.0	182.3	180.7	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/16/23 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	09/16/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:25	200.0	178.3	180.6	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:25	200.0	182.2	183.1	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/16/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/16/23 03:20	10.0	9.5	9.5	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/16/23 03:14	21.0	18.0	18.2	R-A	0.2
	Zero	09/16/23 03:20	21.0	0.0	0.1	R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 02:24	200.0	182.2	183.1	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 02:19	30.0	21.5	21.2	R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 02:25	200.0	182.3	182.6	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 02:20	30.0	21.1	20.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:25	200.0	180.0	180.8	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:20	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:25	200.0	182.3	180.7	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/17/23 03:15	18.0	18.0	18.1	R-A	0.1
	Zero	09/17/23 03:20	18.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:25	200.0	178.3	180.6	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/17/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/17/23 03:25	200.0	182.2		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/17/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/17/23 03:20	10.0	9.5		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/17/23 03:15	21.0	18.0		R-A	0.2
	Zero	09/17/23 03:20	21.0	0.0		R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/18/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 02:24	200.0	182.2		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/18/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 02:19	30.0	21.5		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/18/23 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 02:25	200.0	182.3		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/18/23 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 02:20	30.0	21.1		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/18/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 03:25	200.0	180.0		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/18/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 03:20	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/18/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 03:25	200.0	182.3		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/18/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/18/23 03:20	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/18/23 03:15	18.0	18.0		R-A	0.0
	Zero	09/18/23 03:20	18.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/18/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/18/23 03:25	200.0	178.3	180.4	R-A /Span * 100		1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/18/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/18/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/18/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/18/23 03:25	200.0	182.2	182.9	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/18/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/18/23 03:20	10.0	9.5	9.5	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/18/23 03:14	21.0	18.0	18.2	R-A		0.2
	Zero	09/18/23 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/19/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 02:25	200.0	182.3	183.4	R-A /Span * 100		0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/19/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 02:20	30.0	21.1	21.0	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/19/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 02:25	200.0	182.2	182.9	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/19/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 02:19	30.0	21.5	21.3	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 03:24	200.0	178.3	180.6	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/19/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 03:19	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/19/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/19/23 03:24	200.0	182.2	183.5	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/19/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/19/23 03:19	10.0	9.5		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/19/23 03:14	21.0	18.0		R-A	0.2
	Zero	09/19/23 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/19/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/19/23 03:25	200.0	180.0		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/19/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/19/23 03:20	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/19/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/19/23 03:25	200.0	182.3		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/19/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/19/23 03:20	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/19/23 03:15	18.0	18.0		R-A	0.1
	Zero	09/19/23 03:20	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/20/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/20/23 02:25	200.0	182.3		R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/20/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/20/23 02:20	30.0	21.1		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/20/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/20/23 02:25	200.0	182.2		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/20/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/20/23 02:19	30.0	21.5		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/20/23 03:25	200.0	180.0		R-A /Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/20/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/20/23 03:25	200.0	182.3	180.8	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/20/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/20/23 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	09/20/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	09/20/23 03:25	200.0	178.3	180.6	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	09/20/23 03:19	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/20/23 03:25	200.0	182.2	183.1	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/20/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/20/23 03:19	10.0	9.5	9.4	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/20/23 03:14	21.0	18.0	18.2	R-A		0.2
	Zero	09/20/23 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/21/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 02:25	200.0	182.3	183.1	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/21/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 02:19	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 03:24	200.0	180.0	181.3	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/21/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 03:24	200.0	182.3	180.7	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/21/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/21/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/21/23 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	09/21/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/22/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 02:25	200.0	182.3	182.8	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/22/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 02:19	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 03:25	200.0	180.0	180.8	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/22/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 03:25	200.0	182.3	180.5	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/22/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/22/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/22/23 03:15	18.0	18.0	18.1	R-A		0.1
	Zero	09/22/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/23/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 02:25	200.0	182.3	182.7	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/23/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 02:19	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 03:25	200.0	180.0	179.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/23/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 03:25	200.0	182.3	180.5	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/23/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/23/23 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/23/23 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	09/23/23 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/24/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 02:25	200.0	182.3	182.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/24/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 02:20	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/24/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 03:25	200.0	180.0	179.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/24/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/24/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 03:25	200.0	182.3	180.2	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/24/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/24/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/24/23 03:15	18.0	18.0	18.1	R-A	0.1
	Zero	09/24/23 03:20	18.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/25/23 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 02:25	200.0	182.3	182.1	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/25/23 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 02:20	30.0	21.1	20.8	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/25/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 03:25	200.0	180.0	179.9	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/25/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 03:20	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/25/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 03:25	200.0	182.3	180.1	R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/25/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/25/23 03:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/25/23 03:15	18.0	18.0	18.1	R-A	0.1
	Zero	09/25/23 03:20	18.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/26/23 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/26/23 02:25	200.0	182.3	182.4	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/26/23 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/26/23 02:20	30.0	21.1	20.8	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/26/23 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/26/23 03:25	200.0	180.0	179.7	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/26/23 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	09/26/23 03:20	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/26/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/26/23 03:25	200.0	182.3	180.0	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/26/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/26/23 03:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/26/23 03:15	18.0	18.0	18.1	R-A		0.1
	Zero	09/26/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/26/23 10:58	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/26/23 11:08	200.0	178.3	180.0	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/26/23 10:58	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	09/26/23 11:03	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/26/23 10:58	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/26/23 11:08	200.0	182.2	182.9	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/26/23 10:58	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/26/23 11:03	10.0	9.5	9.5	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/26/23 10:58	21.0	18.0	18.2	R-A		0.2
	Zero	09/26/23 11:03	21.0	0.0	0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/27/23 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/27/23 02:25	200.0	182.3	182.3	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/27/23 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/27/23 02:20	30.0	21.1	20.8	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/27/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/27/23 03:25	200.0	180.0	179.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/27/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/27/23 03:20	10.0	9.1	9.2	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/27/23 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	09/27/23 03:25	200.0	182.3		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/27/23 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	09/27/23 03:20	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/27/23 03:15	18.0	18.0		R-A	0.1
	Zero	09/27/23 03:20	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/28/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 02:25	200.0	182.3		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/28/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 02:19	30.0	21.1		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/28/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 03:24	200.0	180.0		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/28/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/28/23 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 03:24	200.0	182.3		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/28/23 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	09/28/23 03:19	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	09/28/23 03:14	18.0	18.0		R-A	0.1
	Zero	09/28/23 03:19	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	09/29/23 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	09/29/23 02:24	200.0	182.3		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	09/29/23 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	09/29/23 02:19	30.0	21.1		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/29/23 03:24	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/29/23 03:20	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/29/23 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/29/23 03:24	200.0	182.3	180.5	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/29/23 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/29/23 03:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/29/23 03:15	18.0	18.0	18.1	R-A		0.1
	Zero	09/29/23 03:20	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/30/23 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 02:24	200.0	182.3	182.8	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/30/23 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 02:19	30.0	21.1	20.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/30/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 03:24	200.0	180.0	182.2	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/30/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	09/30/23 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 03:24	200.0	182.3	180.6	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	09/30/23 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	09/30/23 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	09/30/23 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	09/30/23 03:19	18.0	0.0	0.0	R-A		0.0

Monthly Summary Report

Units CT1 and CT2



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 01:56 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Jul 23	744.00	744.00	250.26	250.26	418.95	418.95	108.25	108.25
Aug 23	744.00	1,488.00	107.04	357.30	735.65	1,154.60	106.99	215.24
Sep 23	699.17	2,187.17	50.91	408.21	472.00	1,626.60	54.04	269.28
Sum/Avg	2,187.17		408.21		1,626.60		269.28	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 00:57 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2023	0.5260	6.6976	1.4667	13.0909	0.3175	2.7209	0.1590	1.3621	0.5292	4.5342
Aug 2023	0.4704	6.5712	1.6608	13.0229	0.3612	2.7355	0.1806	1.3696	0.6021	4.5589
Sep 2023	0.4631	6.5084	1.2665	12.5949	0.2763	2.6667	0.1384	1.3350	0.4609	4.4444
Sum/Avg	6.5084		12.5949		2.6667		1.3350		4.4444	
Limit Value										

AQ34 3HR AVG LOAD

ALL_UnitOn_TF_1H				CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/01/23 0:00	1			65			0					
07/01/23 1:00	1			65			0					
07/01/23 2:00	1			65			0					
07/01/23 3:00	1			65			0					
07/01/23 4:00	1			65			0					
07/01/23 5:00	1			65			0					
07/01/23 6:00	1			64			0					
07/01/23 7:00	1			57			0					
07/01/23 8:00	1			50			0					
07/01/23 9:00	1			44			0					
07/01/23 10:00	1			44			0					
07/01/23 11:00	1			44			0					
07/01/23 12:00	1			44			0					
07/01/23 13:00	1			44			0					
07/01/23 14:00	1			44			0					
07/01/23 15:00	1			44			0					
07/01/23 16:00	1			44			0					
07/01/23 17:00	1			47			0					
07/01/23 18:00	1			55			0					
07/01/23 19:00	1			62			0					
07/01/23 20:00	1			66			0					
07/01/23 21:00	1			66			0					
07/01/23 22:00	1			66			0					
07/01/23 23:00	1			66			0					
07/02/23 0:00	1			66			0					
07/02/23 1:00	1			66			0					
07/02/23 2:00	1			66			0					
07/02/23 3:00	1			66			0					
07/02/23 4:00	1			66			0					
07/02/23 5:00	1			66			0					
07/02/23 6:00	1			66			0					
07/02/23 7:00	1			61			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/02/23 8:00	1			54			0					
07/02/23 9:00	1			47			0					
07/02/23 10:00	1			44			0					
07/02/23 11:00	1			47			0					
07/02/23 12:00	1			55			0					
07/02/23 13:00	1			62			0					
07/02/23 14:00	1			66			0					
07/02/23 15:00	1			66			0					
07/02/23 16:00	1			66			0					
07/02/23 17:00	1			66			0					
07/02/23 18:00	1			67			0					
07/02/23 19:00	1			69			0					
07/02/23 20:00	1			71			0					
07/02/23 21:00	1			70			0					
07/02/23 22:00	1			68			0					
07/02/23 23:00	1			66			0					
07/03/23 0:00	1			66			0					
07/03/23 1:00	1			65			0					
07/03/23 2:00	1			65			0					
07/03/23 3:00	1			65			0					
07/03/23 4:00	1			65			0					
07/03/23 5:00	1			65			0					
07/03/23 6:00	1			65			0					
07/03/23 7:00	1			61			0					
07/03/23 8:00	1			54			0					
07/03/23 9:00	1			47			0					
07/03/23 10:00	1			44			0					
07/03/23 11:00	1			44			0					
07/03/23 12:00	1			44			0					
07/03/23 13:00	1			44			0					
07/03/23 14:00	1			44			0					
07/03/23 15:00	1			47			0					
07/03/23 16:00	1			54			0					
07/03/23 17:00	1			61			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/03/23 18:00	1			65			0					
07/03/23 19:00	1			65			0					
07/03/23 20:00	1			65			0					
07/03/23 21:00	1			65			0					
07/03/23 22:00	1			65			0					
07/03/23 23:00	1			65			0					
07/04/23 0:00	1			65			0					
07/04/23 1:00	1			65			0					
07/04/23 2:00	1			65			0					
07/04/23 3:00	1			65			0					
07/04/23 4:00	1			65			0					
07/04/23 5:00	1			65			0					
07/04/23 6:00	1			63			0					
07/04/23 7:00	1			56			0					
07/04/23 8:00	1			49			0					
07/04/23 9:00	1			44			0					
07/04/23 10:00	1			44			0					
07/04/23 11:00	1			44			0					
07/04/23 12:00	1			44			0					
07/04/23 13:00	1			44			0					
07/04/23 14:00	1			44			0					
07/04/23 15:00	1			44			0					
07/04/23 16:00	1			44			0					
07/04/23 17:00	1			44			0					
07/04/23 18:00	1			44			0					
07/04/23 19:00	1			44			0					
07/04/23 20:00	1			44			0					
07/04/23 21:00	1			44			0					
07/04/23 22:00	1			44			0					
07/04/23 23:00	1			44			0					
07/05/23 0:00	1			44			0					
07/05/23 1:00	1			44			0					
07/05/23 2:00	1			44			0					
07/05/23 3:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/05/23 4:00	1			44			0					
07/05/23 5:00	1			44			0					
07/05/23 6:00	1			44			0					
07/05/23 7:00	1			44			0					
07/05/23 8:00	1			44			0					
07/05/23 9:00	1			44			0					
07/05/23 10:00	1			44			0					
07/05/23 11:00	1			44			0					
07/05/23 12:00	1			44			0					
07/05/23 13:00	1			47			0					
07/05/23 14:00	1			52			0					
07/05/23 15:00	1			59			0					
07/05/23 16:00	1			63			0					
07/05/23 17:00	1			65			0					
07/05/23 18:00	1			66			0					
07/05/23 19:00	1			67			0					
07/05/23 20:00	1			68			0					
07/05/23 21:00	1			68			0					
07/05/23 22:00	1			67			0					
07/05/23 23:00	1			66			0					
07/06/23 0:00	1			66			0					
07/06/23 1:00	1			66			0					
07/06/23 2:00	1			66			0					
07/06/23 3:00	1			66			0					
07/06/23 4:00	1			66			0					
07/06/23 5:00	1			65			0					
07/06/23 6:00	1			65			0					
07/06/23 7:00	1			63			0					
07/06/23 8:00	1			56			0					
07/06/23 9:00	1			49			0					
07/06/23 10:00	1			44			0					
07/06/23 11:00	1			44			0					
07/06/23 12:00	1			44			0					
07/06/23 13:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/06/23 14:00	1			44			0					
07/06/23 15:00	1			44			0					
07/06/23 16:00	1			47			0					
07/06/23 17:00	1			54			0					
07/06/23 18:00	1			62			0					
07/06/23 19:00	1			69			0					
07/06/23 20:00	1			72			0					
07/06/23 21:00	1			71			0					
07/06/23 22:00	1			68			0					
07/06/23 23:00	1			66			0					
07/07/23 0:00	1			66			0					
07/07/23 1:00	1			65			0					
07/07/23 2:00	1			65			0					
07/07/23 3:00	1			65			0					
07/07/23 4:00	1			65			0					
07/07/23 5:00	1			65			0					
07/07/23 6:00	1			65			0					
07/07/23 7:00	1			65			0					
07/07/23 8:00	1			60			0					
07/07/23 9:00	1			59			0					
07/07/23 10:00	1			58			1					
07/07/23 11:00	1			63			1					
07/07/23 12:00	1			62			1					
07/07/23 13:00	1			61			0					
07/07/23 14:00	1			60			0					
07/07/23 15:00	1			60			0					
07/07/23 16:00	1			56			0					
07/07/23 17:00	1			53			1					
07/07/23 18:00	1			50			1					
07/07/23 19:00	1			59			0					
07/07/23 20:00	1			66			0					
07/07/23 21:00	1			72			0					
07/07/23 22:00	1			70			0					
07/07/23 23:00	1			67			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/08/23 0:00	1			66			0					
07/08/23 1:00	1			66			0					
07/08/23 2:00	1			66			0					
07/08/23 3:00	1			66			0					
07/08/23 4:00	1			66			0					
07/08/23 5:00	1			66			0					
07/08/23 6:00	1			66			0					
07/08/23 7:00	1			63			0					
07/08/23 8:00	1			56			0					
07/08/23 9:00	1			49			0					
07/08/23 10:00	1			45			0					
07/08/23 11:00	1			45			0					
07/08/23 12:00	1			45			0					
07/08/23 13:00	1			45			0					
07/08/23 14:00	1			45			0					
07/08/23 15:00	1			44			0					
07/08/23 16:00	1			44			0					
07/08/23 17:00	1			47			0					
07/08/23 18:00	1			55			1					
07/08/23 19:00	1			66			1					
07/08/23 20:00	1			71			0					
07/08/23 21:00	1			71			0					
07/08/23 22:00	1			68			0					
07/08/23 23:00	1			66			0					
07/09/23 0:00	1			66			0					
07/09/23 1:00	1			66			0					
07/09/23 2:00	1			66			0					
07/09/23 3:00	1			66			0					
07/09/23 4:00	1			66			0					
07/09/23 5:00	1			66			0					
07/09/23 6:00	1			63			5					
07/09/23 7:00	1			60			24					
07/09/23 8:00	1			58			33					
07/09/23 9:00	1			53			28					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/09/23 10:00	1			50			10					
07/09/23 11:00	1			45			0					
07/09/23 12:00	1			45			0					
07/09/23 13:00	1			45			0					
07/09/23 14:00	1			44			0					
07/09/23 15:00	1			44			0					
07/09/23 16:00	1			44			0					
07/09/23 17:00	1			44			0					
07/09/23 18:00	1			46			0					
07/09/23 19:00	1			52			0					
07/09/23 20:00	1			57			0					
07/09/23 21:00	1			61			0					
07/09/23 22:00	1			59			0					
07/09/23 23:00	1			53			0					
07/10/23 0:00	1			48			0					
07/10/23 1:00	1			44			0					
07/10/23 2:00	1			44			0					
07/10/23 3:00	1			44			0					
07/10/23 4:00	1			44			0					
07/10/23 5:00	1			44			0					
07/10/23 6:00	1			44			0					
07/10/23 7:00	1			44			0					
07/10/23 8:00	1			44			0					
07/10/23 9:00	1			44			0					
07/10/23 10:00	1			44			0					
07/10/23 11:00	1			45			0					
07/10/23 12:00	1			45			0					
07/10/23 13:00	1			44			0					
07/10/23 14:00	1			44			0					
07/10/23 15:00	1			44			0					
07/10/23 16:00	1			44			0					
07/10/23 17:00	1			44			0					
07/10/23 18:00	1			44			0					
07/10/23 19:00	1			47			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/10/23 20:00	1			52			0					
07/10/23 21:00	1			53			0					
07/10/23 22:00	1			52			0					
07/10/23 23:00	1			47			0					
07/11/23 0:00	1			45			0					
07/11/23 1:00	1			44			0					
07/11/23 2:00	1			44			0					
07/11/23 3:00	1			44			0					
07/11/23 4:00	1			44			0					
07/11/23 5:00	1			44			0					
07/11/23 6:00	1			46			0					
07/11/23 7:00	1			46			0					
07/11/23 8:00	1			46			0					
07/11/23 9:00	1			44			0					
07/11/23 10:00	1			44			0					
07/11/23 11:00	1			44			0					
07/11/23 12:00	1			44			0					
07/11/23 13:00	1			44			0					
07/11/23 14:00	1			44			0					
07/11/23 15:00	1			44			0					
07/11/23 16:00	1			44			0					
07/11/23 17:00	1			46			0					
07/11/23 18:00	1			47			0					
07/11/23 19:00	1			51			0					
07/11/23 20:00	1			54			0					
07/11/23 21:00	1			58			0					
07/11/23 22:00	1			56			0					
07/11/23 23:00	1			52			0					
07/12/23 0:00	1			48			0					
07/12/23 1:00	1			45			0					
07/12/23 2:00	1			44			0					
07/12/23 3:00	1			44			0					
07/12/23 4:00	1			44			0					
07/12/23 5:00	1			44			0					

Tuesday, October 3, 2023

Date/Tim Value	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe			Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod			
	SI	Mod	Value	SI	Mod							
07/12/23 6:00	1			44			0					
07/12/23 7:00	1			44			0					
07/12/23 8:00	1			44			0					
07/12/23 9:00	1			44			0					
07/12/23 10:00	1			44			0					
07/12/23 11:00	1			44			0					
07/12/23 12:00	1			44			0					
07/12/23 13:00	1			44			0					
07/12/23 14:00	1			44			0					
07/12/23 15:00	1			44			0					
07/12/23 16:00	1			44			0					
07/12/23 17:00	1			45			0					
07/12/23 18:00	1			47			0					
07/12/23 19:00	1			51			0					
07/12/23 20:00	1			55			0					
07/12/23 21:00	1			57			0					
07/12/23 22:00	1			56			0					
07/12/23 23:00	1			53			0					
07/13/23 0:00	1			52			0					
07/13/23 1:00	1			48			0					
07/13/23 2:00	1			47			0					
07/13/23 3:00	1			44			0					
07/13/23 4:00	1			44			0					
07/13/23 5:00	1			44			0					
07/13/23 6:00	1			44			0					
07/13/23 7:00	1			44			0					
07/13/23 8:00	1			44			0					
07/13/23 9:00	1			44			0					
07/13/23 10:00	1			44			0					
07/13/23 11:00	1			45			0					
07/13/23 12:00	1			45			0					
07/13/23 13:00	1			47			0					
07/13/23 14:00	1			48			0					
07/13/23 15:00	1			48			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/13/23 16:00	1			48			0					
07/13/23 17:00	1			47			0					
07/13/23 18:00	1			50			0					
07/13/23 19:00	1			58			0					
07/13/23 20:00	1			66			0					
07/13/23 21:00	1			71			0					
07/13/23 22:00	1			69			0					
07/13/23 23:00	1			66			0					
07/14/23 0:00	1			65			0					
07/14/23 1:00	1			65			0					
07/14/23 2:00	1			65			0					
07/14/23 3:00	1			65			0					
07/14/23 4:00	1			65			0					
07/14/23 5:00	1			65			0					
07/14/23 6:00	1			65			0					
07/14/23 7:00	1			65			0					
07/14/23 8:00	1			60			0					
07/14/23 9:00	1			53			0					
07/14/23 10:00	1			46			0					
07/14/23 11:00	1			44			0					
07/14/23 12:00	1			48			0					
07/14/23 13:00	1			56			0					
07/14/23 14:00	1			59			0					
07/14/23 15:00	1			57			0					
07/14/23 16:00	1			50			9					
07/14/23 17:00	1			53			28					
07/14/23 18:00	1			61			52					
07/14/23 19:00	1			72			68					
07/14/23 20:00	1			76			74					
07/14/23 21:00	1			76			74					
07/14/23 22:00	1			74			73					
07/14/23 23:00	1			66			66					
07/15/23 0:00	1			61			62					
07/15/23 1:00	1			57			58					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/15/23 2:00	1			57			58					
07/15/23 3:00	1			57			58					
07/15/23 4:00	1			57			58					
07/15/23 5:00	1			58			59					
07/15/23 6:00	1			56			57					
07/15/23 7:00	1			52			53					
07/15/23 8:00	1			48			49					
07/15/23 9:00	1			45			46					
07/15/23 10:00	1			45			46					
07/15/23 11:00	1			45			46					
07/15/23 12:00	1			47			48					
07/15/23 13:00	1			51			51					
07/15/23 14:00	1			54			53					
07/15/23 15:00	1			57			55					
07/15/23 16:00	1			64			61					
07/15/23 17:00	1			71			68					
07/15/23 18:00	1			75			72					
07/15/23 19:00	1			75			72					
07/15/23 20:00	1			76			72					
07/15/23 21:00	1			77			74					
07/15/23 22:00	1			76			74					
07/15/23 23:00	1			73			72					
07/16/23 0:00	1			68			67					
07/16/23 1:00	1			62			63					
07/16/23 2:00	1			60			60					
07/16/23 3:00	1			59			60					
07/16/23 4:00	1			59			60					
07/16/23 5:00	1			59			60					
07/16/23 6:00	1			56			57					
07/16/23 7:00	1			52			53					
07/16/23 8:00	1			48			49					
07/16/23 9:00	1			46			47					
07/16/23 10:00	1			48			49					
07/16/23 11:00	1			52			52					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/16/23 12:00	1			56			53					
07/16/23 13:00	1			58			54					
07/16/23 14:00	1			63			60					
07/16/23 15:00	1			68			68					
07/16/23 16:00	1			74			75					
07/16/23 17:00	1			75			76					
07/16/23 18:00	1			75			76					
07/16/23 19:00	1			75			76					
07/16/23 20:00	1			73			75					
07/16/23 21:00	1			72			73					
07/16/23 22:00	1			65			67					
07/16/23 23:00	1			58			60					
07/17/23 0:00	1			54			56					
07/17/23 1:00	1			55			56					
07/17/23 2:00	1			54			56					
07/17/23 3:00	1			51			52					
07/17/23 4:00	1			47			48					
07/17/23 5:00	1			50			51					
07/17/23 6:00	1			54			55					
07/17/23 7:00	1			54			55					
07/17/23 8:00	1			50			52					
07/17/23 9:00	1			46			47					
07/17/23 10:00	1			48			49					
07/17/23 11:00	1			51			53					
07/17/23 12:00	1			54			56					
07/17/23 13:00	1			56			58					
07/17/23 14:00	1			57			58					
07/17/23 15:00	1			60			61					
07/17/23 16:00	1			65			67					
07/17/23 17:00	1			68			70					
07/17/23 18:00	1			67			68					
07/17/23 19:00	1			61			62					
07/17/23 20:00	1			58			59					
07/17/23 21:00	1			58			59					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/17/23 22:00	1			58			59					
07/17/23 23:00	1			58			59					
07/18/23 0:00	1			59			60					
07/18/23 1:00	1			60			61					
07/18/23 2:00	1			61			62					
07/18/23 3:00	1			60			61					
07/18/23 4:00	1			60			61					
07/18/23 5:00	1			60			62					
07/18/23 6:00	1			62			63					
07/18/23 7:00	1			58			59					
07/18/23 8:00	1			53			54					
07/18/23 9:00	1			49			51					
07/18/23 10:00	1			51			53					
07/18/23 11:00	1			55			57					
07/18/23 12:00	1			59			60					
07/18/23 13:00	1			60			61					
07/18/23 14:00	1			59			61					
07/18/23 15:00	1			61			65					
07/18/23 16:00	1			64			68					
07/18/23 17:00	1			68			70					
07/18/23 18:00	1			68			70					
07/18/23 19:00	1			71			73					
07/18/23 20:00	1			74			76					
07/18/23 21:00	1			76			77					
07/18/23 22:00	1			74			76					
07/18/23 23:00	1			72			74					
07/19/23 0:00	1			68			70					
07/19/23 1:00	1			63			65					
07/19/23 2:00	1			59			61					
07/19/23 3:00	1			58			59					
07/19/23 4:00	1			57			58					
07/19/23 5:00	1			58			59					
07/19/23 6:00	1			59			61					
07/19/23 7:00	1			58			60					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/19/23 8:00	1			54			55					
07/19/23 9:00	1			51			52					
07/19/23 10:00	1			50			51					
07/19/23 11:00	1			53			54					
07/19/23 12:00	1			56			57					
07/19/23 13:00	1			60			61					
07/19/23 14:00	1			66			68					
07/19/23 15:00	1			72			73					
07/19/23 16:00	1			76			78					
07/19/23 17:00	1			76			78					
07/19/23 18:00	1			76			78					
07/19/23 19:00	1			77			78					
07/19/23 20:00	1			78			79					
07/19/23 21:00	1			78			80					
07/19/23 22:00	1			77			79					
07/19/23 23:00	1			74			76					
07/20/23 0:00	1			69			71					
07/20/23 1:00	1			63			65					
07/20/23 2:00	1			59			61					
07/20/23 3:00	1			58			60					
07/20/23 4:00	1			59			60					
07/20/23 5:00	1			59			61					
07/20/23 6:00	1			60			61					
07/20/23 7:00	1			56			57					
07/20/23 8:00	1			51			52					
07/20/23 9:00	1			47			48					
07/20/23 10:00	1			48			49					
07/20/23 11:00	1			51			52					
07/20/23 12:00	1			56			57					
07/20/23 13:00	1			59			60					
07/20/23 14:00	1			60			61					
07/20/23 15:00	1			63			64					
07/20/23 16:00	1			68			69					
07/20/23 17:00	1			73			75					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/20/23 18:00	1			76			77					
07/20/23 19:00	1			77			78					
07/20/23 20:00	1			77			78					
07/20/23 21:00	1			75			77					
07/20/23 22:00	1			73			74					
07/20/23 23:00	1			68			70					
07/21/23 0:00	1			63			65					
07/21/23 1:00	1			59			61					
07/21/23 2:00	1			57			58					
07/21/23 3:00	1			56			57					
07/21/23 4:00	1			55			56					
07/21/23 5:00	1			55			56					
07/21/23 6:00	1			55			56					
07/21/23 7:00	1			52			53					
07/21/23 8:00	1			49			50					
07/21/23 9:00	1			46			47					
07/21/23 10:00	1			46			47					
07/21/23 11:00	1			48			49					
07/21/23 12:00	1			50			51					
07/21/23 13:00	1			53			54					
07/21/23 14:00	1			57			58					
07/21/23 15:00	1			64			65					
07/21/23 16:00	1			68			69					
07/21/23 17:00	1			69			70					
07/21/23 18:00	1			68			69					
07/21/23 19:00	1			70			72					
07/21/23 20:00	1			71			73					
07/21/23 21:00	1			71			72					
07/21/23 22:00	1			68			70					
07/21/23 23:00	1			66			68					
07/22/23 0:00	1			64			66					
07/22/23 1:00	1			60			61					
07/22/23 2:00	1			54			55					
07/22/23 3:00	1			50			51					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/22/23 4:00	1			47			48					
07/22/23 5:00	1			48			49					
07/22/23 6:00	1			48			49					
07/22/23 7:00	1			48			49					
07/22/23 8:00	1			47			48					
07/22/23 9:00	1			46			47					
07/22/23 10:00	1			46			47					
07/22/23 11:00	1			46			47					
07/22/23 12:00	1			48			49					
07/22/23 13:00	1			50			51					
07/22/23 14:00	1			54			55					
07/22/23 15:00	1			56			57					
07/22/23 16:00	1			58			59					
07/22/23 17:00	1			60			62					
07/22/23 18:00	1			65			67					
07/22/23 19:00	1			71			73					
07/22/23 20:00	1			72			74					
07/22/23 21:00	1			71			72					
07/22/23 22:00	1			68			70					
07/22/23 23:00	1			65			67					
07/23/23 0:00	1			62			64					
07/23/23 1:00	1			59			60					
07/23/23 2:00	1			59			60					
07/23/23 3:00	1			59			60					
07/23/23 4:00	1			59			60					
07/23/23 5:00	1			58			59					
07/23/23 6:00	1			56			57					
07/23/23 7:00	1			52			53					
07/23/23 8:00	1			51			52					
07/23/23 9:00	1			53			54					
07/23/23 10:00	1			57			58					
07/23/23 11:00	1			59			60					
07/23/23 12:00	1			60			62					
07/23/23 13:00	1			63			64					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/23/23 14:00	1			64			66					
07/23/23 15:00	1			62			64					
07/23/23 16:00	1			60			62					
07/23/23 17:00	1			65			66					
07/23/23 18:00	1			67			69					
07/23/23 19:00	1			65			67					
07/23/23 20:00	1			58			60					
07/23/23 21:00	1			55			57					
07/23/23 22:00	1			55			57					
07/23/23 23:00	1			55			56					
07/24/23 0:00	1			56			57					
07/24/23 1:00	1			57			58					
07/24/23 2:00	1			57			59					
07/24/23 3:00	1			56			58					
07/24/23 4:00	1			56			58					
07/24/23 5:00	1			57			59					
07/24/23 6:00	1			58			60					
07/24/23 7:00	1			56			57					
07/24/23 8:00	1			52			53					
07/24/23 9:00	1			47			49					
07/24/23 10:00	1			46			47					
07/24/23 11:00	1			46			47					
07/24/23 12:00	1			48			49					
07/24/23 13:00	1			52			53					
07/24/23 14:00	1			52			53					
07/24/23 15:00	1			50			51					
07/24/23 16:00	1			46			47					
07/24/23 17:00	1			46			47					
07/24/23 18:00	1			46			47					
07/24/23 19:00	1			46			47					
07/24/23 20:00	1			46			47					
07/24/23 21:00	1			49			50					
07/24/23 22:00	1			50			52					
07/24/23 23:00	1			53			55					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/25/23 0:00	1			53			54					
07/25/23 1:00	1			51			52					
07/25/23 2:00	1			48			49					
07/25/23 3:00	1			46			47					
07/25/23 4:00	1			46			47					
07/25/23 5:00	1			47			49					
07/25/23 6:00	1			49			51					
07/25/23 7:00	1			50			51					
07/25/23 8:00	1			49			50					
07/25/23 9:00	1			47			48					
07/25/23 10:00	1			47			48					
07/25/23 11:00	1			46			47					
07/25/23 12:00	1			49			50					
07/25/23 13:00	1			52			53					
07/25/23 14:00	1			56			57					
07/25/23 15:00	1			57			58					
07/25/23 16:00	1			59			60					
07/25/23 17:00	1			62			63					
07/25/23 18:00	1			66			68					
07/25/23 19:00	1			71			73					
07/25/23 20:00	1			73			75					
07/25/23 21:00	1			73			75					
07/25/23 22:00	1			69			71					
07/25/23 23:00	1			65			66					
07/26/23 0:00	1			62			64					
07/26/23 1:00	1			59			60					
07/26/23 2:00	1			58			59					
07/26/23 3:00	1			57			58					
07/26/23 4:00	1			57			59					
07/26/23 5:00	1			58			60					
07/26/23 6:00	1			59			61					
07/26/23 7:00	1			58			60					
07/26/23 8:00	1			56			57					
07/26/23 9:00	1			56			57					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/26/23 10:00	1			57			58					
07/26/23 11:00	1			59			60					
07/26/23 12:00	1			60			61					
07/26/23 13:00	1			65			67					
07/26/23 14:00	1			71			73					
07/26/23 15:00	1			76			78					
07/26/23 16:00	1			76			77					
07/26/23 17:00	1			76			77					
07/26/23 18:00	1			74			75					
07/26/23 19:00	1			74			75					
07/26/23 20:00	1			71			72					
07/26/23 21:00	1			70			72					
07/26/23 22:00	1			70			71					
07/26/23 23:00	1			71			73					
07/27/23 0:00	1			74			76					
07/27/23 1:00	1			70			72					
07/27/23 2:00	1			66			67					
07/27/23 3:00	1			57			58					
07/27/23 4:00	1			56			57					
07/27/23 5:00	1			57			59					
07/27/23 6:00	1			61			62					
07/27/23 7:00	1			57			58					
07/27/23 8:00	1			51			53					
07/27/23 9:00	1			46			48					
07/27/23 10:00	1			45			47					
07/27/23 11:00	1			46			47					
07/27/23 12:00	1			50			51					
07/27/23 13:00	1			54			56					
07/27/23 14:00	1			57			59					
07/27/23 15:00	1			56			58					
07/27/23 16:00	1			58			59					
07/27/23 17:00	1			62			63					
07/27/23 18:00	1			60			61					
07/27/23 19:00	1			54			55					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/27/23 20:00	1			47			48					
07/27/23 21:00	1			46			47					
07/27/23 22:00	1			49			50					
07/27/23 23:00	1			53			54					
07/28/23 0:00	1			55			57					
07/28/23 1:00	1			56			58					
07/28/23 2:00	1			55			56					
07/28/23 3:00	1			55			56					
07/28/23 4:00	1			53			55					
07/28/23 5:00	1			53			55					
07/28/23 6:00	1			54			55					
07/28/23 7:00	1			52			54					
07/28/23 8:00	1			49			50					
07/28/23 9:00	1			46			48					
07/28/23 10:00	1			46			47					
07/28/23 11:00	1			46			47					
07/28/23 12:00	1			46			47					
07/28/23 13:00	1			50			51					
07/28/23 14:00	1			50			51					
07/28/23 15:00	1			53			54					
07/28/23 16:00	1			56			57					
07/28/23 17:00	1			62			64					
07/28/23 18:00	1			66			68					
07/28/23 19:00	1			66			68					
07/28/23 20:00	1			60			62					
07/28/23 21:00	1			55			56					
07/28/23 22:00	1			51			52					
07/28/23 23:00	1			54			55					
07/29/23 0:00	1			57			58					
07/29/23 1:00	1			54			56					
07/29/23 2:00	1			51			52					
07/29/23 3:00	1			47			49					
07/29/23 4:00	1			47			48					
07/29/23 5:00	1			47			48					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/29/23 6:00	1			46			47					
07/29/23 7:00	1			46			47					
07/29/23 8:00	1			46			47					
07/29/23 9:00	1			46			47					
07/29/23 10:00	1			46			47					
07/29/23 11:00	1			46			47					
07/29/23 12:00	1			45			47					
07/29/23 13:00	1			45			46					
07/29/23 14:00	1			45			46					
07/29/23 15:00	1			45			46					
07/29/23 16:00	1			45			46					
07/29/23 17:00	1			45			46					
07/29/23 18:00	1			46			47					
07/29/23 19:00	1			46			47					
07/29/23 20:00	1			46			47					
07/29/23 21:00	1			46			47					
07/29/23 22:00	1			46			47					
07/29/23 23:00	1			47			48					
07/30/23 0:00	1			46			48					
07/30/23 1:00	1			46			48					
07/30/23 2:00	1			46			47					
07/30/23 3:00	1			46			47					
07/30/23 4:00	1			46			47					
07/30/23 5:00	1			46			47					
07/30/23 6:00	1			46			47					
07/30/23 7:00	1			46			47					
07/30/23 8:00	1			46			47					
07/30/23 9:00	1			46			47					
07/30/23 10:00	1			46			47					
07/30/23 11:00	1			46			47					
07/30/23 12:00	1			46			47					
07/30/23 13:00	1			46			47					
07/30/23 14:00	1			46			47					
07/30/23 15:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
07/30/23 16:00	1			46			47					
07/30/23 17:00	1			47			48					
07/30/23 18:00	1			47			48					
07/30/23 19:00	1			47			48					
07/30/23 20:00	1			46			47					
07/30/23 21:00	1			46			47					
07/30/23 22:00	1			45			47					
07/30/23 23:00	1			45			47					
07/31/23 0:00	1			46			48					
07/31/23 1:00	1			46			48					
07/31/23 2:00	1			47			48					
07/31/23 3:00	1			46			47					
07/31/23 4:00	1			46			47					
07/31/23 5:00	1			47			48					
07/31/23 6:00	1			50			52					
07/31/23 7:00	1			51			52					
07/31/23 8:00	1			50			51					
07/31/23 9:00	1			46			47					
07/31/23 10:00	1			47			48					
07/31/23 11:00	1			52			53					
07/31/23 12:00	1			56			58					
07/31/23 13:00	1			65			66					
07/31/23 14:00	1			69			70					
07/31/23 15:00	1			72			74					
07/31/23 16:00	1			71			73					
07/31/23 17:00	1			69			71					
07/31/23 18:00	1			68			70					
07/31/23 19:00	1			67			69					
07/31/23 20:00	1			67			68					
07/31/23 21:00	1			66			68					
07/31/23 22:00	1			62			63					
07/31/23 23:00	1			59			60					
08/01/23 0:00	1			56			57					
08/01/23 1:00	1			56			57					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/01/23 2:00	1			54			55					
08/01/23 3:00	1			54			55					
08/01/23 4:00	1			54			56					
08/01/23 5:00	1			55			57					
08/01/23 6:00	1			57			59					
08/01/23 7:00	1			57			58					
08/01/23 8:00	1			53			54					
08/01/23 9:00	1			52			53					
08/01/23 10:00	1			52			53					
08/01/23 11:00	1			56			57					
08/01/23 12:00	1			56			58					
08/01/23 13:00	1			58			60					
08/01/23 14:00	1			58			60					
08/01/23 15:00	1			58			59					
08/01/23 16:00	1			58			59					
08/01/23 17:00	1			57			58					
08/01/23 18:00	1			56			57					
08/01/23 19:00	1			56			57					
08/01/23 20:00	1			56			57					
08/01/23 21:00	1			58			59					
08/01/23 22:00	1			58			59					
08/01/23 23:00	1			55			56					
08/02/23 0:00	1			54			56					
08/02/23 1:00	1			54			55					
08/02/23 2:00	1			56			57					
08/02/23 3:00	1			56			57					
08/02/23 4:00	1			56			57					
08/02/23 5:00	1			58			59					
08/02/23 6:00	1			58			60					
08/02/23 7:00	1			55			56					
08/02/23 8:00	1			51			52					
08/02/23 9:00	1			47			48					
08/02/23 10:00	1			46			47					
08/02/23 11:00	1			46			47					

Tuesday, October 3, 2023

Date/Tim	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe			Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod			
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod			
08/02/23 12:00	1			46			47					
08/02/23 13:00	1			49			50					
08/02/23 14:00	1			49			50					
08/02/23 15:00	1			49			50					
08/02/23 16:00	1			46			47					
08/02/23 17:00	1			46			48					
08/02/23 18:00	1			46			48					
08/02/23 19:00	1			49			50					
08/02/23 20:00	1			50			51					
08/02/23 21:00	1			53			54					
08/02/23 22:00	1			53			54					
08/02/23 23:00	1			51			52					
08/03/23 0:00	1			51			52					
08/03/23 1:00	1			49			51					
08/03/23 2:00	1			50			51					
08/03/23 3:00	1			49			50					
08/03/23 4:00	1			48			49					
08/03/23 5:00	1			49			50					
08/03/23 6:00	1			51			52					
08/03/23 7:00	1			51			52					
08/03/23 8:00	1			49			50					
08/03/23 9:00	1			46			47					
08/03/23 10:00	1			46			47					
08/03/23 11:00	1			46			47					
08/03/23 12:00	1			46			47					
08/03/23 13:00	1			46			47					
08/03/23 14:00	1			46			47					
08/03/23 15:00	1			46			47					
08/03/23 16:00	1			46			47					
08/03/23 17:00	1			46			47					
08/03/23 18:00	1			46			47					
08/03/23 19:00	1			48			49					
08/03/23 20:00	1			49			50					
08/03/23 21:00	1			49			50					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/03/23 22:00	1			49			50					
08/03/23 23:00	1			48			49					
08/04/23 0:00	1			46			48					
08/04/23 1:00	1			45			47					
08/04/23 2:00	1			45			47					
08/04/23 3:00	1			46			47					
08/04/23 4:00	1			46			47					
08/04/23 5:00	1			46			48					
08/04/23 6:00	1			47			49					
08/04/23 7:00	1			47			49					
08/04/23 8:00	1			47			48					
08/04/23 9:00	1			46			47					
08/04/23 10:00	1			46			47					
08/04/23 11:00	1			46			47					
08/04/23 12:00	1			46			47					
08/04/23 13:00	1			46			47					
08/04/23 14:00	1			45			46					
08/04/23 15:00	1			45			46					
08/04/23 16:00	1			45			46					
08/04/23 17:00	1			46			47					
08/04/23 18:00	1			51			52					
08/04/23 19:00	1			58			59					
08/04/23 20:00	1			64			66					
08/04/23 21:00	1			66			68					
08/04/23 22:00	1			62			64					
08/04/23 23:00	1			56			58					
08/05/23 0:00	1			54			55					
08/05/23 1:00	1			54			56					
08/05/23 2:00	1			57			59					
08/05/23 3:00	1			57			59					
08/05/23 4:00	1			56			57					
08/05/23 5:00	1			52			54					
08/05/23 6:00	1			50			51					
08/05/23 7:00	1			47			49					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/05/23 8:00	1			46			48					
08/05/23 9:00	1			45			46					
08/05/23 10:00	1			45			46					
08/05/23 11:00	1			45			46					
08/05/23 12:00	1			45			46					
08/05/23 13:00	1			45			46					
08/05/23 14:00	1			46			47					
08/05/23 15:00	1			49			50					
08/05/23 16:00	1			49			50					
08/05/23 17:00	1			51			52					
08/05/23 18:00	1			55			57					
08/05/23 19:00	1			62			64					
08/05/23 20:00	1			66			68					
08/05/23 21:00	1			66			68					
08/05/23 22:00	1			61			63					
08/05/23 23:00	1			56			57					
08/06/23 0:00	1			52			53					
08/06/23 1:00	1			50			51					
08/06/23 2:00	1			50			51					
08/06/23 3:00	1			48			49					
08/06/23 4:00	1			47			48					
08/06/23 5:00	1			48			49					
08/06/23 6:00	1			49			50					
08/06/23 7:00	1			49			50					
08/06/23 8:00	1			49			50					
08/06/23 9:00	1			48			49					
08/06/23 10:00	1			48			49					
08/06/23 11:00	1			46			47					
08/06/23 12:00	1			47			48					
08/06/23 13:00	1			51			51					
08/06/23 14:00	1			55			56					
08/06/23 15:00	1			58			59					
08/06/23 16:00	1			57			58					
08/06/23 17:00	1			57			58					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/06/23 18:00	1			60			61					
08/06/23 19:00	1			65			66					
08/06/23 20:00	1			68			70					
08/06/23 21:00	1			68			70					
08/06/23 22:00	1			64			66					
08/06/23 23:00	1			58			59					
08/07/23 0:00	1			54			55					
08/07/23 1:00	1			51			53					
08/07/23 2:00	1			50			52					
08/07/23 3:00	1			47			49					
08/07/23 4:00	1			48			49					
08/07/23 5:00	1			52			53					
08/07/23 6:00	1			55			57					
08/07/23 7:00	1			54			56					
08/07/23 8:00	1			50			52					
08/07/23 9:00	1			49			50					
08/07/23 10:00	1			52			53					
08/07/23 11:00	1			56			58					
08/07/23 12:00	1			62			64					
08/07/23 13:00	1			63			64					
08/07/23 14:00	1			62			63					
08/07/23 15:00	1			58			59					
08/07/23 16:00	1			61			62					
08/07/23 17:00	1			64			66					
08/07/23 18:00	1			68			69					
08/07/23 19:00	1			71			72					
08/07/23 20:00	1			71			72					
08/07/23 21:00	1			71			73					
08/07/23 22:00	1			70			72					
08/07/23 23:00	1			65			67					
08/08/23 0:00	1			61			62					
08/08/23 1:00	1			55			56					
08/08/23 2:00	1			55			56					
08/08/23 3:00	1			53			55					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/08/23 4:00	1			52			53					
08/08/23 5:00	1			53			54					
08/08/23 6:00	1			54			55					
08/08/23 7:00	1			53			54					
08/08/23 8:00	1			50			51					
08/08/23 9:00	1			46			47					
08/08/23 10:00	1			46			47					
08/08/23 11:00	1			46			47					
08/08/23 12:00	1			46			47					
08/08/23 13:00	1			46			47					
08/08/23 14:00	1			46			47					
08/08/23 15:00	1			46			47					
08/08/23 16:00	1			46			47					
08/08/23 17:00	1			46			47					
08/08/23 18:00	1			48			49					
08/08/23 19:00	1			53			54					
08/08/23 20:00	1			54			55					
08/08/23 21:00	1			54			55					
08/08/23 22:00	1			50			51					
08/08/23 23:00	1			48			49					
08/09/23 0:00	1			47			48					
08/09/23 1:00	1			46			47					
08/09/23 2:00	1			46			47					
08/09/23 3:00	1			46			47					
08/09/23 4:00	1			46			47					
08/09/23 5:00	1			46			47					
08/09/23 6:00	1			47			48					
08/09/23 7:00	1			47			48					
08/09/23 8:00	1			46			47					
08/09/23 9:00	1			46			47					
08/09/23 10:00	1			46			47					
08/09/23 11:00	1			46			47					
08/09/23 12:00	1			46			47					
08/09/23 13:00	1			47			48					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/09/23 14:00	1			49			50					
08/09/23 15:00	1			52			53					
08/09/23 16:00	1			55			56					
08/09/23 17:00	1			55			56					
08/09/23 18:00	1			55			56					
08/09/23 19:00	1			58			59					
08/09/23 20:00	1			61			62					
08/09/23 21:00	1			60			62					
08/09/23 22:00	1			55			56					
08/09/23 23:00	1			50			51					
08/10/23 0:00	1			47			48					
08/10/23 1:00	1			46			47					
08/10/23 2:00	1			46			47					
08/10/23 3:00	1			46			47					
08/10/23 4:00	1			46			47					
08/10/23 5:00	1			46			47					
08/10/23 6:00	1			48			50					
08/10/23 7:00	1			49			50					
08/10/23 8:00	1			49			50					
08/10/23 9:00	1			46			47					
08/10/23 10:00	1			46			47					
08/10/23 11:00	1			46			47					
08/10/23 12:00	1			46			47					
08/10/23 13:00	1			47			47					
08/10/23 14:00	1			47			47					
08/10/23 15:00	1			49			50					
08/10/23 16:00	1			52			53					
08/10/23 17:00	1			52			54					
08/10/23 18:00	1			51			53					
08/10/23 19:00	1			48			49					
08/10/23 20:00	1			48			49					
08/10/23 21:00	1			47			48					
08/10/23 22:00	1			48			49					
08/10/23 23:00	1			49			50					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/11/23 0:00	1			55			57					
08/11/23 1:00	1			60			61					
08/11/23 2:00	1			62			63					
08/11/23 3:00	1			58			59					
08/11/23 4:00	1			57			58					
08/11/23 5:00	1			56			57					
08/11/23 6:00	1			57			58					
08/11/23 7:00	1			59			60					
08/11/23 8:00	1			62			63					
08/11/23 9:00	1			66			68					
08/11/23 10:00	1			71			73					
08/11/23 11:00	1			75			77					
08/11/23 12:00	1			74			75					
08/11/23 13:00	1			64			65					
08/11/23 14:00	1			53			54					
08/11/23 15:00	1			46			47					
08/11/23 16:00	1			46			46					
08/11/23 17:00	1			46			47					
08/11/23 18:00	1			52			53					
08/11/23 19:00	1			59			60					
08/11/23 20:00	1			65			67					
08/11/23 21:00	1			66			68					
08/11/23 22:00	1			66			68					
08/11/23 23:00	1			66			68					
08/12/23 0:00	1			61			63					
08/12/23 1:00	1			54			56					
08/12/23 2:00	1			48			49					
08/12/23 3:00	1			46			47					
08/12/23 4:00	1			46			47					
08/12/23 5:00	1			46			47					
08/12/23 6:00	1			46			47					
08/12/23 7:00	1			46			47					
08/12/23 8:00	1			46			47					
08/12/23 9:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/12/23 10:00	1			46			47					
08/12/23 11:00	1			47			48					
08/12/23 12:00	1			49			50					
08/12/23 13:00	1			52			53					
08/12/23 14:00	1			53			54					
08/12/23 15:00	1			52			53					
08/12/23 16:00	1			49			50					
08/12/23 17:00	1			48			49					
08/12/23 18:00	1			49			50					
08/12/23 19:00	1			55			57					
08/12/23 20:00	1			62			64					
08/12/23 21:00	1			62			63					
08/12/23 22:00	1			59			60					
08/12/23 23:00	1			54			55					
08/13/23 0:00	1			53			55					
08/13/23 1:00	1			52			53					
08/13/23 2:00	1			52			53					
08/13/23 3:00	1			53			54					
08/13/23 4:00	1			51			53					
08/13/23 5:00	1			51			52					
08/13/23 6:00	1			48			49					
08/13/23 7:00	1			47			48					
08/13/23 8:00	1			46			47					
08/13/23 9:00	1			46			47					
08/13/23 10:00	1			46			47					
08/13/23 11:00	1			46			47					
08/13/23 12:00	1			46			47					
08/13/23 13:00	1			47			48					
08/13/23 14:00	1			50			51					
08/13/23 15:00	1			53			54					
08/13/23 16:00	1			55			57					
08/13/23 17:00	1			55			56					
08/13/23 18:00	1			58			59					
08/13/23 19:00	1			61			63					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/13/23 20:00	1			65			67					
08/13/23 21:00	1			66			68					
08/13/23 22:00	1			64			66					
08/13/23 23:00	1			60			62					
08/14/23 0:00	1			57			59					
08/14/23 1:00	1			56			58					
08/14/23 2:00	1			57			58					
08/14/23 3:00	1			56			57					
08/14/23 4:00	1			55			56					
08/14/23 5:00	1			55			57					
08/14/23 6:00	1			56			58					
08/14/23 7:00	1			55			57					
08/14/23 8:00	1			53			55					
08/14/23 9:00	1			53			54					
08/14/23 10:00	1			56			57					
08/14/23 11:00	1			60			61					
08/14/23 12:00	1			64			65					
08/14/23 13:00	1			68			69					
08/14/23 14:00	1			69			71					
08/14/23 15:00	1			69			71					
08/14/23 16:00	1			69			70					
08/14/23 17:00	1			69			70					
08/14/23 18:00	1			70			71					
08/14/23 19:00	1			73			74					
08/14/23 20:00	1			74			75					
08/14/23 21:00	1			73			74					
08/14/23 22:00	1			70			71					
08/14/23 23:00	1			67			69					
08/15/23 0:00	1			63			64					
08/15/23 1:00	1			59			60					
08/15/23 2:00	1			57			58					
08/15/23 3:00	1			57			58					
08/15/23 4:00	1			57			58					
08/15/23 5:00	1			57			59					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/15/23 6:00	1			58			59					
08/15/23 7:00	1			56			57					
08/15/23 8:00	1			55			56					
08/15/23 9:00	1			54			55					
08/15/23 10:00	1			56			57					
08/15/23 11:00	1			55			56					
08/15/23 12:00	1			54			56					
08/15/23 13:00	1			56			57					
08/15/23 14:00	1			62			63					
08/15/23 15:00	1			69			71					
08/15/23 16:00	1			75			77					
08/15/23 17:00	1			77			78					
08/15/23 18:00	1			76			77					
08/15/23 19:00	1			75			77					
08/15/23 20:00	1			74			76					
08/15/23 21:00	1			72			73					
08/15/23 22:00	1			70			71					
08/15/23 23:00	1			66			67					
08/16/23 0:00	1			63			64					
08/16/23 1:00	1			58			60					
08/16/23 2:00	1			56			57					
08/16/23 3:00	1			54			55					
08/16/23 4:00	1			53			54					
08/16/23 5:00	1			55			56					
08/16/23 6:00	1			57			58					
08/16/23 7:00	1			58			59					
08/16/23 8:00	1			57			58					
08/16/23 9:00	1			55			56					
08/16/23 10:00	1			55			56					
08/16/23 11:00	1			55			56					
08/16/23 12:00	1			57			58					
08/16/23 13:00	1			58			59					
08/16/23 14:00	1			64			65					
08/16/23 15:00	1			70			72					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/16/23 16:00	1			76			77					
08/16/23 17:00	1			76			78					
08/16/23 18:00	1			75			77					
08/16/23 19:00	1			75			77					
08/16/23 20:00	1			74			76					
08/16/23 21:00	1			73			75					
08/16/23 22:00	1			72			74					
08/16/23 23:00	1			66			68					
08/17/23 0:00	1			61			63					
08/17/23 1:00	1			57			58					
08/17/23 2:00	1			57			59					
08/17/23 3:00	1			58			59					
08/17/23 4:00	1			58			59					
08/17/23 5:00	1			58			60					
08/17/23 6:00	1			58			60					
08/17/23 7:00	1			55			56					
08/17/23 8:00	1			51			52					
08/17/23 9:00	1			47			48					
08/17/23 10:00	1			46			47					
08/17/23 11:00	1			46			47					
08/17/23 12:00	1			49			50					
08/17/23 13:00	1			53			54					
08/17/23 14:00	1			54			55					
08/17/23 15:00	1			52			53					
08/17/23 16:00	1			49			50					
08/17/23 17:00	1			50			51					
08/17/23 18:00	1			57			58					
08/17/23 19:00	1			62			63					
08/17/23 20:00	1			66			67					
08/17/23 21:00	1			61			62					
08/17/23 22:00	1			57			58					
08/17/23 23:00	1			52			53					
08/18/23 0:00	1			52			53					
08/18/23 1:00	1			49			50					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/18/23 2:00	1			47			48					
08/18/23 3:00	1			46			47					
08/18/23 4:00	1			45			47					
08/18/23 5:00	1			45			47					
08/18/23 6:00	1			47			48					
08/18/23 7:00	1			47			48					
08/18/23 8:00	1			47			48					
08/18/23 9:00	1			46			47					
08/18/23 10:00	1			45			47					
08/18/23 11:00	1			45			47					
08/18/23 12:00	1			45			46					
08/18/23 13:00	1			45			46					
08/18/23 14:00	1			46			47					
08/18/23 15:00	1			46			47					
08/18/23 16:00	1			46			47					
08/18/23 17:00	1			46			47					
08/18/23 18:00	1			46			47					
08/18/23 19:00	1			46			47					
08/18/23 20:00	1			46			47					
08/18/23 21:00	1			46			47					
08/18/23 22:00	1			46			47					
08/18/23 23:00	1			46			47					
08/19/23 0:00	1			47			48					
08/19/23 1:00	1			47			48					
08/19/23 2:00	1			47			48					
08/19/23 3:00	1			46			47					
08/19/23 4:00	1			45			46					
08/19/23 5:00	1			45			46					
08/19/23 6:00	1			45			47					
08/19/23 7:00	1			45			47					
08/19/23 8:00	1			45			46					
08/19/23 9:00	1			45			46					
08/19/23 10:00	1			45			46					
08/19/23 11:00	1			45			46					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/19/23 12:00	1			45			46					
08/19/23 13:00	1			45			47					
08/19/23 14:00	1			45			47					
08/19/23 15:00	1			45			47					
08/19/23 16:00	1			45			47					
08/19/23 17:00	1			45			47					
08/19/23 18:00	1			46			47					
08/19/23 19:00	1			46			47					
08/19/23 20:00	1			45			47					
08/19/23 21:00	1			45			47					
08/19/23 22:00	1			46			47					
08/19/23 23:00	1			46			48					
08/20/23 0:00	1			48			49					
08/20/23 1:00	1			48			50					
08/20/23 2:00	1			49			50					
08/20/23 3:00	1			49			50					
08/20/23 4:00	1			49			50					
08/20/23 5:00	1			48			49					
08/20/23 6:00	1			47			48					
08/20/23 7:00	1			46			47					
08/20/23 8:00	1			46			47					
08/20/23 9:00	1			46			47					
08/20/23 10:00	1			46			47					
08/20/23 11:00	1			46			47					
08/20/23 12:00	1			45			47					
08/20/23 13:00	1			45			47					
08/20/23 14:00	1			46			47					
08/20/23 15:00	1			46			47					
08/20/23 16:00	1			46			47					
08/20/23 17:00	1			46			47					
08/20/23 18:00	1			46			47					
08/20/23 19:00	1			46			47					
08/20/23 20:00	1			46			47					
08/20/23 21:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/20/23 22:00	1			46			47					
08/20/23 23:00	1			45			47					
08/21/23 0:00	1			45			46					
08/21/23 1:00	1			45			46					
08/21/23 2:00	1			45			46					
08/21/23 3:00	1			45			47					
08/21/23 4:00	1			46			46					
08/21/23 5:00	1			50			32					
08/21/23 6:00	1			54			16					
08/21/23 7:00	1			57			1					
08/21/23 8:00	1			56			0					
08/21/23 9:00	1			54			0					
08/21/23 10:00	1			51			0					
08/21/23 11:00	1			48			0					
08/21/23 12:00	1			46			0					
08/21/23 13:00	1			46			8					
08/21/23 14:00	1			45			24					
08/21/23 15:00	1			45			39					
08/21/23 16:00	1			46			47					
08/21/23 17:00	1			46			47					
08/21/23 18:00	1			46			47					
08/21/23 19:00	1			46			47					
08/21/23 20:00	1			46			47					
08/21/23 21:00	1			46			47					
08/21/23 22:00	1			46			47					
08/21/23 23:00	1			46			47					
08/22/23 0:00	1			46			47					
08/22/23 1:00	1			46			47					
08/22/23 2:00	1			46			47					
08/22/23 3:00	1			46			47					
08/22/23 4:00	1			46			47					
08/22/23 5:00	1			46			47					
08/22/23 6:00	1			46			47					
08/22/23 7:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/22/23 8:00	1			46			47					
08/22/23 9:00	1			46			47					
08/22/23 10:00	1			46			47					
08/22/23 11:00	1			46			47					
08/22/23 12:00	1			46			47					
08/22/23 13:00	1			45			47					
08/22/23 14:00	1			45			46					
08/22/23 15:00	1			45			46					
08/22/23 16:00	1			45			46					
08/22/23 17:00	1			46			47					
08/22/23 18:00	1			47			48					
08/22/23 19:00	1			51			52					
08/22/23 20:00	1			51			52					
08/22/23 21:00	1			52			54					
08/22/23 22:00	1			50			52					
08/22/23 23:00	1			50			51					
08/23/23 0:00	1			48			49					
08/23/23 1:00	1			46			48					
08/23/23 2:00	1			46			47					
08/23/23 3:00	1			46			47					
08/23/23 4:00	1			46			47					
08/23/23 5:00	1			47			48					
08/23/23 6:00	1			48			50					
08/23/23 7:00	1			48			50					
08/23/23 8:00	1			48			49					
08/23/23 9:00	1			46			47					
08/23/23 10:00	1			45			47					
08/23/23 11:00	1			45			47					
08/23/23 12:00	1			45			47					
08/23/23 13:00	1			46			47					
08/23/23 14:00	1			48			49					
08/23/23 15:00	1			52			53					
08/23/23 16:00	1			56			57					
08/23/23 17:00	1			59			60					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/23/23 18:00	1			63			64					
08/23/23 19:00	1			68			69					
08/23/23 20:00	1			70			71					
08/23/23 21:00	1			68			69					
08/23/23 22:00	1			63			64					
08/23/23 23:00	1			59			60					
08/24/23 0:00	1			55			57					
08/24/23 1:00	1			51			52					
08/24/23 2:00	1			48			50					
08/24/23 3:00	1			46			47					
08/24/23 4:00	1			47			48					
08/24/23 5:00	1			50			51					
08/24/23 6:00	1			54			55					
08/24/23 7:00	1			54			55					
08/24/23 8:00	1			51			53					
08/24/23 9:00	1			47			48					
08/24/23 10:00	1			46			47					
08/24/23 11:00	1			46			47					
08/24/23 12:00	1			46			47					
08/24/23 13:00	1			46			47					
08/24/23 14:00	1			46			46					
08/24/23 15:00	1			46			46					
08/24/23 16:00	1			46			46					
08/24/23 17:00	1			45			46					
08/24/23 18:00	1			46			47					
08/24/23 19:00	1			47			48					
08/24/23 20:00	1			47			48					
08/24/23 21:00	1			47			48					
08/24/23 22:00	1			48			49					
08/24/23 23:00	1			48			49					
08/25/23 0:00	1			49			50					
08/25/23 1:00	1			48			49					
08/25/23 2:00	1			48			49					
08/25/23 3:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/25/23 4:00	1			46			48					
08/25/23 5:00	1			50			52					
08/25/23 6:00	1			53			55					
08/25/23 7:00	1			53			54					
08/25/23 8:00	1			49			50					
08/25/23 9:00	1			46			47					
08/25/23 10:00	1			46			47					
08/25/23 11:00	1			46			47					
08/25/23 12:00	1			46			47					
08/25/23 13:00	1			46			47					
08/25/23 14:00	1			46			47					
08/25/23 15:00	1			46			47					
08/25/23 16:00	1			46			47					
08/25/23 17:00	1			46			47					
08/25/23 18:00	1			46			47					
08/25/23 19:00	1			46			47					
08/25/23 20:00	1			46			47					
08/25/23 21:00	1			46			47					
08/25/23 22:00	1			46			47					
08/25/23 23:00	1			46			47					
08/26/23 0:00	1			49			50					
08/26/23 1:00	1			51			52					
08/26/23 2:00	1			52			53					
08/26/23 3:00	1			51			52					
08/26/23 4:00	1			50			51					
08/26/23 5:00	1			51			52					
08/26/23 6:00	1			52			54					
08/26/23 7:00	1			51			52					
08/26/23 8:00	1			49			50					
08/26/23 9:00	1			46			47					
08/26/23 10:00	1			45			47					
08/26/23 11:00	1			45			47					
08/26/23 12:00	1			46			47					
08/26/23 13:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/26/23 14:00	1			46			47					
08/26/23 15:00	1			45			46					
08/26/23 16:00	1			45			47					
08/26/23 17:00	1			46			48					
08/26/23 18:00	1			47			49					
08/26/23 19:00	1			47			49					
08/26/23 20:00	1			47			48					
08/26/23 21:00	1			47			48					
08/26/23 22:00	1			47			48					
08/26/23 23:00	1			48			49					
08/27/23 0:00	1			49			50					
08/27/23 1:00	1			49			50					
08/27/23 2:00	1			48			49					
08/27/23 3:00	1			47			48					
08/27/23 4:00	1			46			47					
08/27/23 5:00	1			48			49					
08/27/23 6:00	1			50			51					
08/27/23 7:00	1			50			51					
08/27/23 8:00	1			48			49					
08/27/23 9:00	1			46			47					
08/27/23 10:00	1			46			47					
08/27/23 11:00	1			46			47					
08/27/23 12:00	1			45			46					
08/27/23 13:00	1			45			46					
08/27/23 14:00	1			45			47					
08/27/23 15:00	1			46			47					
08/27/23 16:00	1			47			48					
08/27/23 17:00	1			48			49					
08/27/23 18:00	1			48			49					
08/27/23 19:00	1			49			50					
08/27/23 20:00	1			52			53					
08/27/23 21:00	1			56			57					
08/27/23 22:00	1			58			59					
08/27/23 23:00	1			56			57					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/28/23 0:00	1			53			54					
08/28/23 1:00	1			48			50					
08/28/23 2:00	1			46			48					
08/28/23 3:00	1			45			47					
08/28/23 4:00	1			45			47					
08/28/23 5:00	1			49			50					
08/28/23 6:00	1			54			55					
08/28/23 7:00	1			56			57					
08/28/23 8:00	1			53			54					
08/28/23 9:00	1			48			49					
08/28/23 10:00	1			46			47					
08/28/23 11:00	1			46			47					
08/28/23 12:00	1			46			47					
08/28/23 13:00	1			48			49					
08/28/23 14:00	1			52			53					
08/28/23 15:00	1			56			57					
08/28/23 16:00	1			57			58					
08/28/23 17:00	1			53			54					
08/28/23 18:00	1			50			51					
08/28/23 19:00	1			54			55					
08/28/23 20:00	1			58			60					
08/28/23 21:00	1			58			60					
08/28/23 22:00	1			53			54					
08/28/23 23:00	1			49			50					
08/29/23 0:00	1			49			50					
08/29/23 1:00	1			51			52					
08/29/23 2:00	1			53			54					
08/29/23 3:00	1			53			55					
08/29/23 4:00	1			53			54					
08/29/23 5:00	1			54			55					
08/29/23 6:00	1			56			57					
08/29/23 7:00	1			59			61					
08/29/23 8:00	1			65			67					
08/29/23 9:00	1			72			74					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/29/23 10:00	1			76			78					
08/29/23 11:00	1			77			79					
08/29/23 12:00	1			77			79					
08/29/23 13:00	1			77			79					
08/29/23 14:00	1			77			79					
08/29/23 15:00	1			77			79					
08/29/23 16:00	1			77			79					
08/29/23 17:00	1			72			74					
08/29/23 18:00	1			69			70					
08/29/23 19:00	1			63			64					
08/29/23 20:00	1			57			58					
08/29/23 21:00	1			51			52					
08/29/23 22:00	1			46			47					
08/29/23 23:00	1			46			47					
08/30/23 0:00	1			46			47					
08/30/23 1:00	1			46			47					
08/30/23 2:00	1			45			47					
08/30/23 3:00	1			45			47					
08/30/23 4:00	1			45			47					
08/30/23 5:00	1			46			47					
08/30/23 6:00	1			46			47					
08/30/23 7:00	1			48			49					
08/30/23 8:00	1			50			51					
08/30/23 9:00	1			60			61					
08/30/23 10:00	1			69			70					
08/30/23 11:00	1			77			79					
08/30/23 12:00	1			77			78					
08/30/23 13:00	1			73			75					
08/30/23 14:00	1			64			65					
08/30/23 15:00	1			54			55					
08/30/23 16:00	1			47			48					
08/30/23 17:00	1			46			47					
08/30/23 18:00	1			47			48					
08/30/23 19:00	1			47			48					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
08/30/23 20:00	1			47			48					
08/30/23 21:00	1			46			47					
08/30/23 22:00	1			46			47					
08/30/23 23:00	1			46			47					
08/31/23 0:00	1			46			47					
08/31/23 1:00	1			46			47					
08/31/23 2:00	1			46			47					
08/31/23 3:00	1			46			47					
08/31/23 4:00	1			46			47					
08/31/23 5:00	1			49			50					
08/31/23 6:00	1			52			53					
08/31/23 7:00	1			52			53					
08/31/23 8:00	1			59			60					
08/31/23 9:00	1			66			68					
08/31/23 10:00	1			76			78					
08/31/23 11:00	1			77			79					
08/31/23 12:00	1			77			79					
08/31/23 13:00	1			77			79					
08/31/23 14:00	1			77			79					
08/31/23 15:00	1			77			79					
08/31/23 16:00	1			77			79					
08/31/23 17:00	1			73			75					
08/31/23 18:00	1			63			65					
08/31/23 19:00	1			53			54					
08/31/23 20:00	1			46			47					
08/31/23 21:00	1			46			47					
08/31/23 22:00	1			47			48					
08/31/23 23:00	1			47			48					
09/01/23 0:00	1			47			48					
09/01/23 1:00	1			46			47					
09/01/23 2:00	1			46			47					
09/01/23 3:00	1			46			47					
09/01/23 4:00	1			46			47					
09/01/23 5:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/01/23 6:00	1			48			49					
09/01/23 7:00	1			49			50					
09/01/23 8:00	1			49			50					
09/01/23 9:00	1			48			49					
09/01/23 10:00	1			47			48					
09/01/23 11:00	1			47			48					
09/01/23 12:00	1			47			48					
09/01/23 13:00	1			46			47					
09/01/23 14:00	1			46			47					
09/01/23 15:00	1			48			49					
09/01/23 16:00	1			48			49					
09/01/23 17:00	1			48			49					
09/01/23 18:00	1			46			47					
09/01/23 19:00	1			46			47					
09/01/23 20:00	1			45			47					
09/01/23 21:00	1			45			47					
09/01/23 22:00	1			46			48					
09/01/23 23:00	1			47			49					
09/02/23 0:00	1			48			50					
09/02/23 1:00	1			47			48					
09/02/23 2:00	1			47			48					
09/02/23 3:00	1			46			47					
09/02/23 4:00	1			46			47					
09/02/23 5:00	1			47			48					
09/02/23 6:00	1			47			48					
09/02/23 7:00	1			46			48					
09/02/23 8:00	1			45			47					
09/02/23 9:00	1			45			47					
09/02/23 10:00	1			47			48					
09/02/23 11:00	1			50			51					
09/02/23 12:00	1			50			52					
09/02/23 13:00	1			50			52					
09/02/23 14:00	1			49			50					
09/02/23 15:00	1			52			54					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/02/23 16:00	1			51			52					
09/02/23 17:00	1			50			51					
09/02/23 18:00	1			47			48					
09/02/23 19:00	1			47			48					
09/02/23 20:00	1			47			48					
09/02/23 21:00	1			46			47					
09/02/23 22:00	1			47			49					
09/02/23 23:00	1			47			49					
09/03/23 0:00	1			49			50					
09/03/23 1:00	1			48			49					
09/03/23 2:00	1			45			51					
09/03/23 3:00	1			28			48					
09/03/23 4:00	1			12			47					
09/03/23 5:00	1			0			45					
09/03/23 6:00	1			0			45					
09/03/23 7:00	1			0			45					
09/03/23 8:00	1			0			45					
09/03/23 9:00	1			0			45					
09/03/23 10:00	1			0			49					
09/03/23 11:00	1			11			51					
09/03/23 12:00	1			26			52					
09/03/23 13:00	1			42			48					
09/03/23 14:00	1			46			47					
09/03/23 15:00	1			46			47					
09/03/23 16:00	1			46			47					
09/03/23 17:00	1			46			47					
09/03/23 18:00	1			46			47					
09/03/23 19:00	1			46			47					
09/03/23 20:00	1			46			47					
09/03/23 21:00	1			47			48					
09/03/23 22:00	1			47			48					
09/03/23 23:00	1			47			48					
09/04/23 0:00	1			46			47					
09/04/23 1:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/04/23 2:00	1			46			47					
09/04/23 3:00	1			46			47					
09/04/23 4:00	1			46			47					
09/04/23 5:00	1			46			47					
09/04/23 6:00	1			46			47					
09/04/23 7:00	1			46			47					
09/04/23 8:00	1			46			47					
09/04/23 9:00	1			46			47					
09/04/23 10:00	1			45			47					
09/04/23 11:00	1			45			47					
09/04/23 12:00	1			45			47					
09/04/23 13:00	1			45			46					
09/04/23 14:00	1			45			46					
09/04/23 15:00	1			45			46					
09/04/23 16:00	1			45			46					
09/04/23 17:00	1			46			47					
09/04/23 18:00	1			48			49					
09/04/23 19:00	1			54			55					
09/04/23 20:00	1			59			61					
09/04/23 21:00	1			60			61					
09/04/23 22:00	1			56			58					
09/04/23 23:00	1			51			52					
09/05/23 0:00	1			51			52					
09/05/23 1:00	1			49			50					
09/05/23 2:00	1			49			50					
09/05/23 3:00	1			48			49					
09/05/23 4:00	1			51			52					
09/05/23 5:00	1			54			56					
09/05/23 6:00	1			58			60					
09/05/23 7:00	1			65			67					
09/05/23 8:00	1			71			74					
09/05/23 9:00	1			73			75					
09/05/23 10:00	1			68			69					
09/05/23 11:00	1			66			67					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/05/23 12:00	1			66			67					
09/05/23 13:00	1			66			67					
09/05/23 14:00	1			62			63					
09/05/23 15:00	1			60			61					
09/05/23 16:00	1			60			61					
09/05/23 17:00	1			58			59					
09/05/23 18:00	1			58			60					
09/05/23 19:00	1			61			62					
09/05/23 20:00	1			64			65					
09/05/23 21:00	1			63			65					
09/05/23 22:00	1			60			61					
09/05/23 23:00	1			57			59					
09/06/23 0:00	1			56			57					
09/06/23 1:00	1			54			55					
09/06/23 2:00	1			51			52					
09/06/23 3:00	1			48			49					
09/06/23 4:00	1			48			49					
09/06/23 5:00	1			52			53					
09/06/23 6:00	1			56			57					
09/06/23 7:00	1			56			57					
09/06/23 8:00	1			52			53					
09/06/23 9:00	1			47			49					
09/06/23 10:00	1			45			47					
09/06/23 11:00	1			45			47					
09/06/23 12:00	1			45			47					
09/06/23 13:00	1			45			47					
09/06/23 14:00	1			46			47					
09/06/23 15:00	1			46			47					
09/06/23 16:00	1			46			47					
09/06/23 17:00	1			47			48					
09/06/23 18:00	1			50			51					
09/06/23 19:00	1			52			53					
09/06/23 20:00	1			54			55					
09/06/23 21:00	1			53			55					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/06/23 22:00	1			55			57					
09/06/23 23:00	1			54			55					
09/07/23 0:00	1			53			55					
09/07/23 1:00	1			50			51					
09/07/23 2:00	1			48			49					
09/07/23 3:00	1			45			47					
09/07/23 4:00	1			45			47					
09/07/23 5:00	1			47			49					
09/07/23 6:00	1			52			53					
09/07/23 7:00	1			53			55					
09/07/23 8:00	1			51			53					
09/07/23 9:00	1			49			50					
09/07/23 10:00	1			49			50					
09/07/23 11:00	1			50			51					
09/07/23 12:00	1			49			50					
09/07/23 13:00	1			48			49					
09/07/23 14:00	1			50			51					
09/07/23 15:00	1			52			53					
09/07/23 16:00	1			53			54					
09/07/23 17:00	1			53			54					
09/07/23 18:00	1			52			53					
09/07/23 19:00	1			52			53					
09/07/23 20:00	1			53			54					
09/07/23 21:00	1			55			56					
09/07/23 22:00	1			56			58					
09/07/23 23:00	1			53			55					
09/08/23 0:00	1			36			50					
09/08/23 1:00	1			18			47					
09/08/23 2:00	1			2			45					
09/08/23 3:00	1			0			45					
09/08/23 4:00	1			0			45					
09/08/23 5:00	1			0			50					
09/08/23 6:00	1			0			57					
09/08/23 7:00	1			0			64					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/08/23 8:00	1			0			64					
09/08/23 9:00	1			0			57					
09/08/23 10:00	1			0			50					
09/08/23 11:00	1			0			47					
09/08/23 12:00	1			9			47					
09/08/23 13:00	1			28			51					
09/08/23 14:00	1			48			55					
09/08/23 15:00	1			59			60					
09/08/23 16:00	1			61			62					
09/08/23 17:00	1			65			67					
09/08/23 18:00	1			71			73					
09/08/23 19:00	1			74			76					
09/08/23 20:00	1			74			76					
09/08/23 21:00	1			74			75					
09/08/23 22:00	1			74			76					
09/08/23 23:00	1			68			70					
09/09/23 0:00	1			63			64					
09/09/23 1:00	1			59			60					
09/09/23 2:00	1			57			58					
09/09/23 3:00	1			56			57					
09/09/23 4:00	1			56			57					
09/09/23 5:00	1			57			59					
09/09/23 6:00	1			59			61					
09/09/23 7:00	1			56			57					
09/09/23 8:00	1			56			57					
09/09/23 9:00	1			51			53					
09/09/23 10:00	1			50			52					
09/09/23 11:00	1			47			48					
09/09/23 12:00	1			50			51					
09/09/23 13:00	1			54			56					
09/09/23 14:00	1			55			56					
09/09/23 15:00	1			56			57					
09/09/23 16:00	1			53			55					
09/09/23 17:00	1			58			59					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/09/23 18:00	1			63			65					
09/09/23 19:00	1			68			70					
09/09/23 20:00	1			67			68					
09/09/23 21:00	1			64			66					
09/09/23 22:00	1			64			65					
09/09/23 23:00	1			61			63					
09/10/23 0:00	1			57			58					
09/10/23 1:00	1			51			53					
09/10/23 2:00	1			51			52					
09/10/23 3:00	1			50			51					
09/10/23 4:00	1			49			50					
09/10/23 5:00	1			50			52					
09/10/23 6:00	1			51			53					
09/10/23 7:00	1			55			56					
09/10/23 8:00	1			57			58					
09/10/23 9:00	1			56			57					
09/10/23 10:00	1			54			55					
09/10/23 11:00	1			49			51					
09/10/23 12:00	1			47			48					
09/10/23 13:00	1			47			48					
09/10/23 14:00	1			50			51					
09/10/23 15:00	1			51			52					
09/10/23 16:00	1			53			54					
09/10/23 17:00	1			60			61					
09/10/23 18:00	1			69			71					
09/10/23 19:00	1			74			76					
09/10/23 20:00	1			69			71					
09/10/23 21:00	1			66			67					
09/10/23 22:00	1			65			66					
09/10/23 23:00	1			60			61					
09/11/23 0:00	1			53			54					
09/11/23 1:00	1			46			47					
09/11/23 2:00	1			46			47					
09/11/23 3:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/11/23 4:00	1			46			47					
09/11/23 5:00	1			46			48					
09/11/23 6:00	1			51			52					
09/11/23 7:00	1			53			54					
09/11/23 8:00	1			52			53					
09/11/23 9:00	1			48			49					
09/11/23 10:00	1			46			47					
09/11/23 11:00	1			46			47					
09/11/23 12:00	1			48			49					
09/11/23 13:00	1			50			51					
09/11/23 14:00	1			53			54					
09/11/23 15:00	1			53			54					
09/11/23 16:00	1			53			55					
09/11/23 17:00	1			51			53					
09/11/23 18:00	1			52			53					
09/11/23 19:00	1			50			51					
09/11/23 20:00	1			50			51					
09/11/23 21:00	1			50			51					
09/11/23 22:00	1			50			52					
09/11/23 23:00	1			49			50					
09/12/23 0:00	1			47			48					
09/12/23 1:00	1			46			47					
09/12/23 2:00	1			46			46					
09/12/23 3:00	1			47			46					
09/12/23 4:00	1			48			45					
09/12/23 5:00	1			48			45					
09/12/23 6:00	1			48			44					
09/12/23 7:00	1			47			45					
09/12/23 8:00	1			47			46					
09/12/23 9:00	1			46			47					
09/12/23 10:00	1			45			47					
09/12/23 11:00	1			45			47					
09/12/23 12:00	1			46			47					
09/12/23 13:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/12/23 14:00	1			46			47					
09/12/23 15:00	1			47			48					
09/12/23 16:00	1			47			48					
09/12/23 17:00	1			46			47					
09/12/23 18:00	1			46			47					
09/12/23 19:00	1			49			50					
09/12/23 20:00	1			56			57					
09/12/23 21:00	1			57			58					
09/12/23 22:00	1			54			55					
09/12/23 23:00	1			47			48					
09/13/23 0:00	1			46			47					
09/13/23 1:00	1			46			47					
09/13/23 2:00	1			46			47					
09/13/23 3:00	1			46			47					
09/13/23 4:00	1			46			47					
09/13/23 5:00	1			46			47					
09/13/23 6:00	1			46			47					
09/13/23 7:00	1			46			47					
09/13/23 8:00	1			46			47					
09/13/23 9:00	1			46			47					
09/13/23 10:00	1			46			47					
09/13/23 11:00	1			47			48					
09/13/23 12:00	1			54			55					
09/13/23 13:00	1			56			58					
09/13/23 14:00	1			58			60					
09/13/23 15:00	1			59			60					
09/13/23 16:00	1			63			64					
09/13/23 17:00	1			66			67					
09/13/23 18:00	1			66			68					
09/13/23 19:00	1			66			68					
09/13/23 20:00	1			66			67					
09/13/23 21:00	1			64			65					
09/13/23 22:00	1			57			58					
09/13/23 23:00	1			50			51					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/14/23 0:00	1			46			47					
09/14/23 1:00	1			47			48					
09/14/23 2:00	1			50			51					
09/14/23 3:00	1			49			50					
09/14/23 4:00	1			49			50					
09/14/23 5:00	1			46			47					
09/14/23 6:00	1			50			51					
09/14/23 7:00	1			51			52					
09/14/23 8:00	1			51			52					
09/14/23 9:00	1			51			52					
09/14/23 10:00	1			53			54					
09/14/23 11:00	1			57			59					
09/14/23 12:00	1			61			63					
09/14/23 13:00	1			62			63					
09/14/23 14:00	1			61			62					
09/14/23 15:00	1			60			62					
09/14/23 16:00	1			63			65					
09/14/23 17:00	1			67			68					
09/14/23 18:00	1			68			70					
09/14/23 19:00	1			68			69					
09/14/23 20:00	1			67			68					
09/14/23 21:00	1			67			68					
09/14/23 22:00	1			66			68					
09/14/23 23:00	1			61			63					
09/15/23 0:00	1			55			56					
09/15/23 1:00	1			49			50					
09/15/23 2:00	1			47			48					
09/15/23 3:00	1			46			47					
09/15/23 4:00	1			46			47					
09/15/23 5:00	1			50			51					
09/15/23 6:00	1			59			61					
09/15/23 7:00	1			63			65					
09/15/23 8:00	1			60			62					
09/15/23 9:00	1			50			52					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/15/23 10:00	1			45			47					
09/15/23 11:00	1			45			47					
09/15/23 12:00	1			45			47					
09/15/23 13:00	1			46			47					
09/15/23 14:00	1			47			48					
09/15/23 15:00	1			51			52					
09/15/23 16:00	1			59			60					
09/15/23 17:00	1			66			67					
09/15/23 18:00	1			71			72					
09/15/23 19:00	1			71			72					
09/15/23 20:00	1			71			72					
09/15/23 21:00	1			69			71					
09/15/23 22:00	1			69			71					
09/15/23 23:00	1			67			69					
09/16/23 0:00	1			61			63					
09/16/23 1:00	1			55			56					
09/16/23 2:00	1			49			50					
09/16/23 3:00	1			47			48					
09/16/23 4:00	1			46			47					
09/16/23 5:00	1			45			47					
09/16/23 6:00	1			45			47					
09/16/23 7:00	1			45			47					
09/16/23 8:00	1			45			47					
09/16/23 9:00	1			46			47					
09/16/23 10:00	1			47			48					
09/16/23 11:00	1			49			50					
09/16/23 12:00	1			52			54					
09/16/23 13:00	1			55			56					
09/16/23 14:00	1			55			56					
09/16/23 15:00	1			53			54					
09/16/23 16:00	1			50			51					
09/16/23 17:00	1			49			50					
09/16/23 18:00	1			47			48					
09/16/23 19:00	1			47			48					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/16/23 20:00	1			46			47					
09/16/23 21:00	1			46			47					
09/16/23 22:00	1			46			47					
09/16/23 23:00	1			46			47					
09/17/23 0:00	1			46			47					
09/17/23 1:00	1			46			47					
09/17/23 2:00	1			45			47					
09/17/23 3:00	1			45			47					
09/17/23 4:00	1			45			47					
09/17/23 5:00	1			45			47					
09/17/23 6:00	1			45			47					
09/17/23 7:00	1			46			47					
09/17/23 8:00	1			46			47					
09/17/23 9:00	1			46			47					
09/17/23 10:00	1			45			47					
09/17/23 11:00	1			45			47					
09/17/23 12:00	1			45			47					
09/17/23 13:00	1			45			46					
09/17/23 14:00	1			45			46					
09/17/23 15:00	1			46			47					
09/17/23 16:00	1			46			47					
09/17/23 17:00	1			46			47					
09/17/23 18:00	1			46			47					
09/17/23 19:00	1			47			47					
09/17/23 20:00	1			47			48					
09/17/23 21:00	1			47			48					
09/17/23 22:00	1			47			48					
09/17/23 23:00	1			46			47					
09/18/23 0:00	1			46			47					
09/18/23 1:00	1			46			47					
09/18/23 2:00	1			46			47					
09/18/23 3:00	1			46			47					
09/18/23 4:00	1			46			47					
09/18/23 5:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/18/23 6:00	1			46			47					
09/18/23 7:00	1			46			47					
09/18/23 8:00	1			46			47					
09/18/23 9:00	1			46			47					
09/18/23 10:00	1			46			47					
09/18/23 11:00	1			46			47					
09/18/23 12:00	1			46			47					
09/18/23 13:00	1			45			47					
09/18/23 14:00	1			45			46					
09/18/23 15:00	1			45			46					
09/18/23 16:00	1			45			47					
09/18/23 17:00	1			47			48					
09/18/23 18:00	1			50			51					
09/18/23 19:00	1			50			51					
09/18/23 20:00	1			49			50					
09/18/23 21:00	1			46			47					
09/18/23 22:00	1			46			47					
09/18/23 23:00	1			46			47					
09/19/23 0:00	1			46			47					
09/19/23 1:00	1			46			47					
09/19/23 2:00	1			46			47					
09/19/23 3:00	1			46			47					
09/19/23 4:00	1			46			47					
09/19/23 5:00	1			47			48					
09/19/23 6:00	1			50			52					
09/19/23 7:00	1			51			53					
09/19/23 8:00	1			50			52					
09/19/23 9:00	1			47			48					
09/19/23 10:00	1			46			47					
09/19/23 11:00	1			46			47					
09/19/23 12:00	1			46			47					
09/19/23 13:00	1			46			47					
09/19/23 14:00	1			46			47					
09/19/23 15:00	1			46			47					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/19/23 16:00	1			46			47					
09/19/23 17:00	1			47			48					
09/19/23 18:00	1			49			50					
09/19/23 19:00	1			49			50					
09/19/23 20:00	1			48			49					
09/19/23 21:00	1			46			47					
09/19/23 22:00	1			46			47					
09/19/23 23:00	1			46			47					
09/20/23 0:00	1			46			47					
09/20/23 1:00	1			45			47					
09/20/23 2:00	1			45			47					
09/20/23 3:00	1			45			47					
09/20/23 4:00	1			45			47					
09/20/23 5:00	1			46			47					
09/20/23 6:00	1			46			47					
09/20/23 7:00	1			46			47					
09/20/23 8:00	1			46			47					
09/20/23 9:00	1			46			47					
09/20/23 10:00	1			45			47					
09/20/23 11:00	1			46			40					
09/20/23 12:00	1			46			25					
09/20/23 13:00	1			45			9					
09/20/23 14:00	1			44			0					
09/20/23 15:00	1			44			0					
09/20/23 16:00	1			44			0					
09/20/23 17:00	1			45			0					
09/20/23 18:00	1			47			0					
09/20/23 19:00	1			50			0					
09/20/23 20:00	1			49			0					
09/20/23 21:00	1			48			0					
09/20/23 22:00	1			46			0					
09/20/23 23:00	1			46			0					
09/21/23 0:00	1			45			0					
09/21/23 1:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/21/23 2:00	1			44			0					
09/21/23 3:00	1			44			0					
09/21/23 4:00	1			44			0					
09/21/23 5:00	1			44			0					
09/21/23 6:00	1			48			0					
09/21/23 7:00	1			51			0					
09/21/23 8:00	1			53			0					
09/21/23 9:00	1			49			0					
09/21/23 10:00	1			48			0					
09/21/23 11:00	1			48			0					
09/21/23 12:00	1			47			0					
09/21/23 13:00	1			47			0					
09/21/23 14:00	1			50			0					
09/21/23 15:00	1			54			0					
09/21/23 16:00	1			55			0					
09/21/23 17:00	1			52			0					
09/21/23 18:00	1			53			0					
09/21/23 19:00	1			51			0					
09/21/23 20:00	1			49			0					
09/21/23 21:00	1			46			0					
09/21/23 22:00	1			46			0					
09/21/23 23:00	1			45			0					
09/22/23 0:00	1			44			0					
09/22/23 1:00	1			44			0					
09/22/23 2:00	1			44			0					
09/22/23 3:00	1			44			0					
09/22/23 4:00	1			44			0					
09/22/23 5:00	1			44			0					
09/22/23 6:00	1			46			0					
09/22/23 7:00	1			49			0					
09/22/23 8:00	1			51			0					
09/22/23 9:00	1			50			0					
09/22/23 10:00	1			46			0					
09/22/23 11:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/22/23 12:00	1			44			0					
09/22/23 13:00	1			44			0					
09/22/23 14:00	1			45			0					
09/22/23 15:00	1			45			0					
09/22/23 16:00	1			47			0					
09/22/23 17:00	1			51			0					
09/22/23 18:00	1			57			0					
09/22/23 19:00	1			60			0					
09/22/23 20:00	1			59			0					
09/22/23 21:00	1			56			0					
09/22/23 22:00	1			51			0					
09/22/23 23:00	1			46			0					
09/23/23 0:00	1			44			0					
09/23/23 1:00	1			44			0					
09/23/23 2:00	1			44			0					
09/23/23 3:00	1			44			0					
09/23/23 4:00	1			44			0					
09/23/23 5:00	1			44			0					
09/23/23 6:00	1			44			0					
09/23/23 7:00	1			45			0					
09/23/23 8:00	1			45			0					
09/23/23 9:00	1			45			0					
09/23/23 10:00	1			45			0					
09/23/23 11:00	1			45			0					
09/23/23 12:00	1			45			0					
09/23/23 13:00	1			45			0					
09/23/23 14:00	1			45			0					
09/23/23 15:00	1			45			0					
09/23/23 16:00	1			45			0					
09/23/23 17:00	1			46			0					
09/23/23 18:00	1			47			0					
09/23/23 19:00	1			47			0					
09/23/23 20:00	1			46			0					
09/23/23 21:00	1			45			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/23/23 22:00	1			46			0					
09/23/23 23:00	1			46			0					
09/24/23 0:00	1			46			0					
09/24/23 1:00	1			45			0					
09/24/23 2:00	1			45			0					
09/24/23 3:00	1			45			0					
09/24/23 4:00	1			45			0					
09/24/23 5:00	1			45			0					
09/24/23 6:00	1			45			0					
09/24/23 7:00	1			45			0					
09/24/23 8:00	1			45			0					
09/24/23 9:00	1			45			0					
09/24/23 10:00	1			45			0					
09/24/23 11:00	1			45			0					
09/24/23 12:00	1			45			0					
09/24/23 13:00	1			45			0					
09/24/23 14:00	1			45			0					
09/24/23 15:00	1			45			0					
09/24/23 16:00	1			44			0					
09/24/23 17:00	1			47			0					
09/24/23 18:00	1			51			0					
09/24/23 19:00	1			56			0					
09/24/23 20:00	1			56			0					
09/24/23 21:00	1			56			0					
09/24/23 22:00	1			53			0					
09/24/23 23:00	1			50			0					
09/25/23 0:00	1			45			0					
09/25/23 1:00	1			45			0					
09/25/23 2:00	1			45			0					
09/25/23 3:00	1			45			0					
09/25/23 4:00	1			44			0					
09/25/23 5:00	1			45			0					
09/25/23 6:00	1			47			0					
09/25/23 7:00	1			49			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/25/23 8:00	1			49			0					
09/25/23 9:00	1			46			0					
09/25/23 10:00	1			44			0					
09/25/23 11:00	1			44			0					
09/25/23 12:00	1			44			0					
09/25/23 13:00	1			44			0					
09/25/23 14:00	1			44			0					
09/25/23 15:00	1			44			0					
09/25/23 16:00	1			44			0					
09/25/23 17:00	1			47			0					
09/25/23 18:00	1			47			0					
09/25/23 19:00	1			47			0					
09/25/23 20:00	1			45			0					
09/25/23 21:00	1			47			0					
09/25/23 22:00	1			48			0					
09/25/23 23:00	1			48			0					
09/26/23 0:00	1			46			0					
09/26/23 1:00	1			45			0					
09/26/23 2:00	1			44			0					
09/26/23 3:00	1			44			0					
09/26/23 4:00	1			44			0					
09/26/23 5:00	1			45			0					
09/26/23 6:00	1			48			0					
09/26/23 7:00	1			49			0					
09/26/23 8:00	1			52			0					
09/26/23 9:00	1			50			13					
09/26/23 10:00	1			50			29					
09/26/23 11:00	1			46			45					
09/26/23 12:00	1			46			47					
09/26/23 13:00	1			48			43					
09/26/23 14:00	1			47			27					
09/26/23 15:00	1			47			12					
09/26/23 16:00	1			45			0					
09/26/23 17:00	1			45			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/26/23 18:00	1			47			0					
09/26/23 19:00	1			48			0					
09/26/23 20:00	1			47			0					
09/26/23 21:00	1			45			0					
09/26/23 22:00	1			46			0					
09/26/23 23:00	1			46			0					
09/27/23 0:00	1			46			0					
09/27/23 1:00	1			45			0					
09/27/23 2:00	1			45			0					
09/27/23 3:00	1			45			0					
09/27/23 4:00	1			45			0					
09/27/23 5:00	1			45			0					
09/27/23 6:00	1			45			0					
09/27/23 7:00	1			45			0					
09/27/23 8:00	1			45			0					
09/27/23 9:00	1			45			0					
09/27/23 10:00	1			45			0					
09/27/23 11:00	1			45			0					
09/27/23 12:00	1			45			0					
09/27/23 13:00	1			44			0					
09/27/23 14:00	1			44			0					
09/27/23 15:00	1			44			0					
09/27/23 16:00	1			44			0					
09/27/23 17:00	1			44			0					
09/27/23 18:00	1			44			0					
09/27/23 19:00	1			44			0					
09/27/23 20:00	1			44			0					
09/27/23 21:00	1			44			0					
09/27/23 22:00	1			44			0					
09/27/23 23:00	1			44			0					
09/28/23 0:00	1			44			0					
09/28/23 1:00	1			44			0					
09/28/23 2:00	1			44			0					
09/28/23 3:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/28/23 4:00	1			44			0					
09/28/23 5:00	1			44			0					
09/28/23 6:00	1			45			0					
09/28/23 7:00	1			48			0					
09/28/23 8:00	1			48			0					
09/28/23 9:00	1			47			0					
09/28/23 10:00	1			44			0					
09/28/23 11:00	1			44			0					
09/28/23 12:00	1			44			0					
09/28/23 13:00	1			44			0					
09/28/23 14:00	1			44			0					
09/28/23 15:00	1			44			0					
09/28/23 16:00	1			44			0					
09/28/23 17:00	1			44			0					
09/28/23 18:00	1			44			0					
09/28/23 19:00	1			44			0					
09/28/23 20:00	1			44			0					
09/28/23 21:00	1			44			0					
09/28/23 22:00	1			44			0					
09/28/23 23:00	1			44			0					
09/29/23 0:00	1			44			0					
09/29/23 1:00	1			44			0					
09/29/23 2:00	1			44			0					
09/29/23 3:00	1			44			0					
09/29/23 4:00	1			44			0					
09/29/23 5:00	1			44			0					
09/29/23 6:00	1			44			0					
09/29/23 7:00	1			45			0					
09/29/23 8:00	1			45			0					
09/29/23 9:00	1			45			0					
09/29/23 10:00	1			44			0					
09/29/23 11:00	1			44			0					
09/29/23 12:00	1			44			0					
09/29/23 13:00	1			44			0					

Tuesday, October 3, 2023

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe			CT2_Load_Total_3Hr_MWe					
Date/Tim	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
Value	SI	Mod	Value	SI	Mod							
09/29/23 14:00	1			44			0					
09/29/23 15:00	1			44			0					
09/29/23 16:00	1			44			0					
09/29/23 17:00	1			46			0					
09/29/23 18:00	1			46			0					
09/29/23 19:00	1			46			0					
09/29/23 20:00	1			44			0					
09/29/23 21:00	1			44			0					
09/29/23 22:00	1			44			0					
09/29/23 23:00	1			44			0					
09/30/23 0:00	1			44			0					
09/30/23 1:00	1			44			0					
09/30/23 2:00	1			44			0					
09/30/23 3:00	1			44			0					
09/30/23 4:00	1			44			0					
09/30/23 5:00	1			44			0					
09/30/23 6:00	1			44			0					
09/30/23 7:00	1			44			0					
09/30/23 8:00	1			44			0					
09/30/23 9:00	1			44			0					
09/30/23 10:00	1			44			0					
09/30/23 11:00	1			44			0					
09/30/23 12:00	1			44			0					
09/30/23 13:00	1			44			0					
09/30/23 14:00	1			44			0					
09/30/23 15:00	1			44			0					
09/30/23 16:00	1			44			0					
09/30/23 17:00	1			44			0					
09/30/23 18:00	1			44			0					
09/30/23 19:00	1			44			0					
09/30/23 20:00	1			44			0					
09/30/23 21:00	1			44			0					
09/30/23 22:00	1			44			0					
09/30/23 23:00	1			44			0					

Tuesday, October 3, 2023

CEMs Log

Date/Time	Operator	Description
09/14/23 0:12	Operator (DE)	REPLACE UNIT 1 HIGH NOX/CO CYCLINDER. CYLINDER NUMBER CC407283. NOX 182.3, CO 180.0. EXP 4/21/31
09/12/23 4:22	Operator (LH)	CHANGE UNIT 2 LOW 9 NOC/CO BOTTLE 9.472PPM NOX, 9.085PPM CO, EB0004641 EXP 2/13/26
09/10/23 13:20	Operator (KRB)	CHANGE OUTCT 2 HIGH NOX/CO CYCLINDER CHANGE OUT EB0102637 NOX 18.2 CO 178.3 EXP 2/13/31
09/04/23 22:26	Operator (DWN)	GCV VALUE FOR EACH UNIT UPDATED TO 103340 FOR EACH UNIT
09/04/23 20:37	Operator (LH)	UNIT 2 LOW CO/NOX 30PPM BOTTLE SWAPPED CYLINDER NUMBER CC474292 EXP 2/17/26 21.54 NOX, 20.09 CO
09/03/23 15:08	Operator (GAB)	CHANGED UNIT 1 NOX INLET BOTTLE. NOX 21.07 PPM. CC12023. EXP. 2/06/26
09/01/23 0:03	Operator (DWN)	CHANGED UNIT 1 LOW NOX/CO. EB0155358. NOX 8.902. CO 9.054. EXP 12/13/25
08/31/23 16:44	Operator (KRB)	CHANGED CT1 02 CYCLINDER 18.02% CYL# EB0056025 EXP 3/30/31
08/30/23 1:05	Operator (RC)	CHANGED CT2 02 BOTTLE, 18.02% CYL# CC250263 EXP DATE 01/29/31
08/12/23 4:28	Operator (LH)	178.4 PPM CO CYLINDER ID EB0096609
08/12/23 4:26	Operator (LH)	REPLACED CEMS 1 HIGH NOX/CO BOTTLE 181.6 PPM EXP 2/13/31
08/09/23 12:53	Operator (EO)	CHANGED CT2 HIGH NOX BOTTLE. CYL # CC154081 181.1 PPM NOX, 180.8 PPM CO. EXP. DATE 11/04/2030
08/04/23 2/15/26 23:07	Operator (RC)	CHANGED UNIT 2 LOW (30 PPM) BOTTLE, NOX 25.38PPM, CYL # CC345499, EXP
08/04/23 23:03	Operator (RC)	CHANGED UNIT 1 02 BOTTLE. 17.99% ALM-022415, EXP 03/30/31
08/02/23 13:00	Operator (DE)	UPDATED GCV FOR AUGUST TO 101,950 FOR ALL THREE GCV ENTRIES.
07/27/23 10:23	Operator (LHR)	CHANGED UNIT 2 O2 BOTTLE. 18.00% BOTTLE # ALM-016181. EXP 4/17/2031
07/22/23 2/13/26 13:50	Operator (DWN)	CHANGED UNIT 2 LOW (9 PPM) BOTTLE. CO 9.104 / NOX 9.691. EB0102296 EXP.
07/14/23 10:13	Operator (BRB)	SPANNED UNIT 1 INLET GASSES TO FIX THE 1X THIS AM. UNIT 1 HI NOX INLET WAS OFF IN REPORT.
07/13/23 4:15	Operator (RG3)	CHANGED UNIT 1 HIGH NOX/CO DAILY CALIBRATION BOTTLE CC409745. NOX 184.5 PPM. CO 182.1 PPM EXP 2/13/2031
07/07/23 12:05	Operator (DE)	CHANGED UNIT 1 LOW (9) PPM BOTTLE. EB0094089 NOX 8.858 / CO 9.102. EXP 11/16/25
07/07/23 12:04	Operator (DE)	CHANGED UNIT 1 O2 BOTTLE. 18.04% BOTTLE # CC264823. EXP 10-25-30
07/05/23 15:29	Operator (GAB)	CHANGED UNIT 2 NOX INLET BOTTLE. NOX 25.40 PPM. CC367702. EXP. 2/15/26

Date/Time	Operator	Description
07/03/23 7:49	Operator (RC)	UPDATED JULY GCV FOR EACH UNIT TO 105900

Cylinder Gas Audit

10/03/2023

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	07:36	L	200	49.800	45.600	24.9
08/08/2023	07:41	M	200	109.200	107.900	54.6
08/08/2023	07:53	L	200	49.800	45.600	24.9
08/08/2023	07:58	M	200	109.200	107.800	54.6
08/08/2023	08:10	L	200	49.800	45.600	24.9
08/08/2023	08:15	M	200	109.200	107.600	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	45.600	Std	8.4
M	109.200	107.767	Std	1.3

Cylinder Gas Audit

10/03/2023

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	08:38	L	200	49.700	50.000	24.9
08/08/2023	08:42	M	200	109.100	113.600	54.6
08/08/2023	08:55	L	200	49.700	50.300	24.9
08/08/2023	09:00	M	200	109.100	113.800	54.6
08/08/2023	09:12	L	200	49.700	50.300	24.9
08/08/2023	09:17	M	200	109.100	113.600	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.700	50.200	Std	1.0
M	109.100	113.667	Std	4.2

Cylinder Gas Audit

10/03/2023

Page 3

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	11:35	L	10	2.400	2.200	24.0
08/08/2023	11:40	M	10	5.700	5.600	57.0
08/08/2023	11:47	L	10	2.400	2.200	24.0
08/08/2023	11:52	M	10	5.700	5.600	57.0
08/08/2023	11:59	L	10	2.400	2.200	24.0
08/08/2023	12:04	M	10	5.700	5.600	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.200	Std	8.3
M	5.700		5.600	Std	1.8

Cylinder Gas Audit

10/03/2023

Page 4

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	12:39	L	10	2.400	2.300	24.0
08/08/2023	12:43	M	10	5.700	5.800	57.0
08/08/2023	12:51	L	10	2.400	2.300	24.0
08/08/2023	12:56	M	10	5.700	5.700	57.0
08/08/2023	13:03	L	10	2.400	2.300	24.0
08/08/2023	13:08	M	10	5.700	5.800	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.300	Std	4.2
M	5.700		5.767	Std	1.2

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2023 00:00	4,257.6	705.2	4,962.8	105,900.0	525.6	0.63	0.3	1.1
07/01/2023 01:00	4,279.6	673.6	4,953.2	105,900.0	524.5	0.63	0.3	1.0
07/01/2023 02:00	4,307.2	616.8	4,924.0	105,900.0	521.5	0.63	0.3	1.0
07/01/2023 03:00	4,305.7	600.3	4,906.0	105,900.0	519.5	0.62	0.3	1.0
07/01/2023 04:00	4,292.1	561.4	4,853.5	105,900.0	514.0	0.62	0.3	1.0
07/01/2023 05:00	4,290.0	544.2	4,834.2	105,900.0	511.9	0.61	0.3	1.0
07/01/2023 06:00	4,272.9	424.1	4,646.1	105,900.0	492.0	0.60	0.3	1.0
07/01/2023 07:00	3,414.8	0.0	3,414.8	105,900.0	361.6	0.43	0.2	0.7
07/01/2023 08:00	3,430.7	0.0	3,430.7	105,900.0	363.3	0.44	0.2	0.7
07/01/2023 09:00	3,426.0	0.0	3,426.0	105,900.0	362.8	0.44	0.2	0.7
07/01/2023 10:00	3,428.6	0.0	3,428.6	105,900.0	363.1	0.44	0.2	0.7
07/01/2023 11:00	3,424.8	0.0	3,424.8	105,900.0	362.7	0.44	0.2	0.7
07/01/2023 12:00	3,435.3	0.0	3,435.3	105,900.0	363.8	0.44	0.2	0.7
07/01/2023 13:00	3,445.4	0.0	3,445.4	105,900.0	364.9	0.44	0.2	0.7
07/01/2023 14:00	3,431.7	0.0	3,431.7	105,900.0	363.4	0.44	0.2	0.7
07/01/2023 15:00	3,437.6	0.0	3,437.6	105,900.0	364.0	0.44	0.2	0.7
07/01/2023 16:00	3,439.3	0.0	3,439.3	105,900.0	364.2	0.44	0.2	0.7
07/01/2023 17:00	3,820.8	351.6	3,986.1	105,900.0	422.1	0.53	0.3	0.9
07/01/2023 18:00	4,085.8	1,054.4	5,140.2	105,900.0	544.3	0.65	0.3	1.1
07/01/2023 19:00	4,092.4	1,040.1	5,132.5	105,900.0	543.5	0.65	0.3	1.1
07/01/2023 20:00	4,109.8	988.1	5,097.9	105,900.0	539.9	0.65	0.3	1.1
07/01/2023 21:00	4,153.1	904.5	5,057.6	105,900.0	535.6	0.64	0.3	1.1
07/01/2023 22:00	4,192.2	828.2	5,020.4	105,900.0	531.7	0.64	0.3	1.1
07/01/2023 23:00	4,213.1	795.9	5,009.0	105,900.0	530.5	0.64	0.3	1.1
Average/Sum#:	3,874.4	420.4	4,284.9	105,900.0	453.8	0.55	0.3	0.9
Minimum:	3,414.8	0.0	3,414.8	105,900.0	361.6	0.43	0.2	0.7
Maximum:	4,307.2	1,054.4	5,140.2	105,900.0	544.3	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2023 00:00	4,235.2	757.8	4,993.0	105,900.0	528.8	0.63	0.3	1.1
07/02/2023 01:00	4,267.8	692.4	4,960.2	105,900.0	525.3	0.63	0.3	1.1
07/02/2023 02:00	4,301.9	658.1	4,960.0	105,900.0	525.3	0.63	0.3	1.1
07/02/2023 03:00	4,313.7	634.3	4,948.0	105,900.0	524.0	0.63	0.3	1.0
07/02/2023 04:00	4,332.2	602.8	4,935.0	105,900.0	522.6	0.63	0.3	1.0
07/02/2023 05:00	4,334.2	601.8	4,936.0	105,900.0	522.7	0.63	0.3	1.0
07/02/2023 06:00	4,357.1	580.5	4,937.6	105,900.0	522.9	0.63	0.3	1.0
07/02/2023 07:00	3,839.6	131.2	3,875.0	105,900.0	410.4	0.51	0.3	0.8
07/02/2023 08:00	3,459.7	0.0	3,459.7	105,900.0	366.4	0.44	0.2	0.7
07/02/2023 09:00	3,490.7	0.0	3,490.7	105,900.0	369.7	0.44	0.2	0.7
07/02/2023 10:00	3,476.5	0.0	3,476.5	105,900.0	368.2	0.44	0.2	0.7
07/02/2023 11:00	3,899.5	271.8	4,027.2	105,900.0	426.5	0.53	0.3	0.9
07/02/2023 12:00	4,217.4	857.3	5,074.7	105,900.0	537.4	0.65	0.3	1.1
07/02/2023 13:00	4,172.6	934.2	5,106.8	105,900.0	540.8	0.65	0.3	1.1
07/02/2023 14:00	4,131.6	1,000.2	5,131.8	105,900.0	543.5	0.65	0.3	1.1
07/02/2023 15:00	4,105.1	1,003.1	5,108.2	105,900.0	541.0	0.65	0.3	1.1
07/02/2023 16:00	4,090.2	1,012.9	5,103.1	105,900.0	540.4	0.65	0.3	1.1
07/02/2023 17:00	4,090.5	1,041.6	5,132.1	105,900.0	543.5	0.65	0.3	1.1
07/02/2023 18:00	4,081.0	1,249.3	5,330.3	105,900.0	564.5	0.68	0.3	1.1
07/02/2023 19:00	4,059.7	1,857.3	5,917.0	105,900.0	626.6	0.75	0.4	1.3
07/02/2023 20:00	4,118.9	1,597.3	5,716.2	105,900.0	605.3	0.73	0.4	1.2
07/02/2023 21:00	4,204.6	906.8	5,111.4	105,900.0	541.3	0.65	0.3	1.1
07/02/2023 22:00	4,230.1	947.5	5,177.6	105,900.0	548.3	0.66	0.3	1.1
07/02/2023 23:00	4,250.3	783.3	5,033.6	105,900.0	533.1	0.64	0.3	1.1
Average/Sum#:	4,085.8	755.1	4,830.9	105,900.0	511.6	0.62	0.3	1.0
Minimum:	3,459.7	0.0	3,459.7	105,900.0	366.4	0.44	0.2	0.7
Maximum:	4,357.1	1,857.3	5,917.0	105,900.0	626.6	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2023 00:00	4,285.2	674.6	4,959.8	105,900.0	525.2	0.63	0.3	1.1
07/03/2023 01:00	4,315.0	626.7	4,941.7	105,900.0	523.3	0.63	0.3	1.0
07/03/2023 02:00	4,325.6	608.0	4,933.6	105,900.0	522.5	0.63	0.3	1.0
07/03/2023 03:00	4,350.5	558.0	4,908.5	105,900.0	519.8	0.62	0.3	1.0
07/03/2023 04:00	4,368.9	532.8	4,901.7	105,900.0	519.1	0.62	0.3	1.0
07/03/2023 05:00	4,391.9	500.9	4,892.8	105,900.0	518.1	0.62	0.3	1.0
07/03/2023 06:00	4,401.9	486.6	4,888.5	105,900.0	517.7	0.62	0.3	1.0
07/03/2023 07:00	3,937.4	122.8	3,980.4	105,900.0	421.5	0.52	0.3	0.9
07/03/2023 08:00	3,455.2	0.0	3,455.2	105,900.0	365.9	0.44	0.2	0.7
07/03/2023 09:00	3,433.4	0.0	3,433.4	105,900.0	363.6	0.44	0.2	0.7
07/03/2023 10:00	3,423.9	0.0	3,423.9	105,900.0	362.6	0.43	0.2	0.7
07/03/2023 11:00	3,429.6	0.0	3,429.6	105,900.0	363.2	0.44	0.2	0.7
07/03/2023 12:00	3,435.5	0.0	3,435.5	105,900.0	363.8	0.44	0.2	0.7
07/03/2023 13:00	3,435.7	0.0	3,435.7	105,900.0	363.8	0.44	0.2	0.7
07/03/2023 14:00	3,442.1	0.0	3,442.1	105,900.0	364.5	0.44	0.2	0.7
07/03/2023 15:00	3,773.4	328.8	3,927.9	105,900.0	416.0	0.52	0.3	0.9
07/03/2023 16:00	4,202.1	852.8	5,054.9	105,900.0	535.3	0.64	0.3	1.1
07/03/2023 17:00	4,206.2	826.1	5,032.3	105,900.0	532.9	0.64	0.3	1.1
07/03/2023 18:00	4,217.4	804.3	5,021.7	105,900.0	531.8	0.64	0.3	1.1
07/03/2023 19:00	4,242.7	723.8	4,966.5	105,900.0	526.0	0.63	0.3	1.1
07/03/2023 20:00	4,264.5	651.2	4,915.7	105,900.0	520.6	0.62	0.3	1.0
07/03/2023 21:00	4,299.8	603.6	4,903.4	105,900.0	519.3	0.62	0.3	1.0
07/03/2023 22:00	4,330.0	546.5	4,876.5	105,900.0	516.4	0.62	0.3	1.0
07/03/2023 23:00	4,361.7	516.7	4,878.4	105,900.0	516.6	0.62	0.3	1.0
Average/Sum#:	4,013.7	415.2	4,418.3	105,900.0	467.9	0.56	0.3	0.9
Minimum:	3,423.9	0.0	3,423.9	105,900.0	362.6	0.43	0.2	0.7
Maximum:	4,401.9	852.8	5,054.9	105,900.0	535.3	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2023 00:00	4,368.3	511.0	4,879.3	105,900.0	516.7	0.62	0.3	1.0
07/04/2023 01:00	4,318.7	589.3	4,908.0	105,900.0	519.8	0.62	0.3	1.0
07/04/2023 02:00	4,340.8	556.8	4,897.6	105,900.0	518.7	0.62	0.3	1.0
07/04/2023 03:00	4,376.0	532.3	4,908.3	105,900.0	519.8	0.62	0.3	1.0
07/04/2023 04:00	4,404.8	509.1	4,913.9	105,900.0	520.4	0.62	0.3	1.0
07/04/2023 05:00	4,418.6	487.5	4,906.1	105,900.0	519.6	0.62	0.3	1.0
07/04/2023 06:00	4,109.7	226.4	4,227.4	105,900.0	447.7	0.55	0.3	0.9
07/04/2023 07:00	3,437.6	0.0	3,437.6	105,900.0	364.0	0.44	0.2	0.7
07/04/2023 08:00	3,465.2	0.0	3,465.2	105,900.0	367.0	0.44	0.2	0.7
07/04/2023 09:00	3,471.5	0.0	3,471.5	105,900.0	367.6	0.44	0.2	0.7
07/04/2023 10:00	3,476.1	0.0	3,476.1	105,900.0	368.1	0.44	0.2	0.7
07/04/2023 11:00	3,455.7	0.0	3,455.7	105,900.0	366.0	0.44	0.2	0.7
07/04/2023 12:00	3,464.7	0.0	3,464.7	105,900.0	366.9	0.44	0.2	0.7
07/04/2023 13:00	3,475.0	0.0	3,475.0	105,900.0	368.0	0.44	0.2	0.7
07/04/2023 14:00	3,476.4	0.0	3,476.4	105,900.0	368.2	0.44	0.2	0.7
07/04/2023 15:00	3,476.9	0.0	3,476.9	105,900.0	368.2	0.44	0.2	0.7
07/04/2023 16:00	3,476.9	0.0	3,476.9	105,900.0	368.2	0.44	0.2	0.7
07/04/2023 17:00	3,472.9	0.0	3,472.9	105,900.0	367.8	0.44	0.2	0.7
07/04/2023 18:00	3,462.0	0.0	3,462.0	105,900.0	366.6	0.44	0.2	0.7
07/04/2023 19:00	3,469.7	0.0	3,469.7	105,900.0	367.4	0.44	0.2	0.7
07/04/2023 20:00	3,442.8	0.0	3,442.8	105,900.0	364.6	0.44	0.2	0.7
07/04/2023 21:00	3,439.0	0.0	3,439.0	105,900.0	364.2	0.44	0.2	0.7
07/04/2023 22:00	3,431.8	0.0	3,431.8	105,900.0	363.4	0.44	0.2	0.7
07/04/2023 23:00	3,428.9	0.0	3,428.9	105,900.0	363.1	0.44	0.2	0.7
Average/Sum#:	3,715.0	142.2	3,852.7	105,900.0	408.0	0.49	0.2	0.8
Minimum:	3,428.9	0.0	3,428.9	105,900.0	363.1	0.44	0.2	0.7
Maximum:	4,418.6	589.3	4,913.9	105,900.0	520.4	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2023 00:00	3,431.1	0.0	3,431.1	105,900.0	363.4	0.44	0.2	0.7
07/05/2023 01:00	3,453.7	0.0	3,453.7	105,900.0	365.7	0.44	0.2	0.7
07/05/2023 02:00	3,457.6	0.0	3,457.6	105,900.0	366.2	0.44	0.2	0.7
07/05/2023 03:00	3,451.2	0.0	3,451.2	105,900.0	365.5	0.44	0.2	0.7
07/05/2023 04:00	3,449.0	0.0	3,449.0	105,900.0	365.2	0.44	0.2	0.7
07/05/2023 05:00	3,446.6	0.0	3,446.6	105,900.0	365.0	0.44	0.2	0.7
07/05/2023 06:00	3,447.5	0.0	3,447.5	105,900.0	365.1	0.44	0.2	0.7
07/05/2023 07:00	3,452.7	0.0	3,452.7	105,900.0	365.6	0.44	0.2	0.7
07/05/2023 08:00	3,467.1	0.0	3,467.1	105,900.0	367.2	0.44	0.2	0.7
07/05/2023 09:00	3,470.9	0.0	3,470.9	105,900.0	367.6	0.44	0.2	0.7
07/05/2023 10:00	3,470.2	0.0	3,470.2	105,900.0	367.5	0.44	0.2	0.7
07/05/2023 11:00	3,474.6	0.0	3,474.6	105,900.0	368.0	0.44	0.2	0.7
07/05/2023 12:00	3,476.0	0.0	3,476.0	105,900.0	368.1	0.44	0.2	0.7
07/05/2023 13:00	3,958.6	200.7	4,052.9	105,900.0	429.2	0.53	0.3	0.9
07/05/2023 14:00	4,168.0	296.2	4,375.3	105,900.0	463.3	0.57	0.3	0.9
07/05/2023 15:00	4,282.4	513.8	4,796.2	105,900.0	507.9	0.61	0.3	1.0
07/05/2023 16:00	4,265.1	762.3	5,027.4	105,900.0	532.4	0.64	0.3	1.1
07/05/2023 17:00	4,273.5	746.8	5,020.3	105,900.0	531.6	0.64	0.3	1.1
07/05/2023 18:00	4,290.7	753.9	5,044.6	105,900.0	534.2	0.64	0.3	1.1
07/05/2023 19:00	4,304.2	1,098.3	5,402.5	105,900.0	572.1	0.69	0.3	1.1
07/05/2023 20:00	4,340.3	802.1	5,142.4	105,900.0	544.6	0.65	0.3	1.1
07/05/2023 21:00	4,375.4	570.5	4,945.9	105,900.0	523.8	0.63	0.3	1.0
07/05/2023 22:00	4,410.6	537.2	4,947.8	105,900.0	524.0	0.63	0.3	1.0
07/05/2023 23:00	4,434.3	431.6	4,865.9	105,900.0	515.3	0.62	0.3	1.0
Average/Sum#:	3,835.5	279.7	4,107.1	105,900.0	434.9	0.52	0.2	0.9
Minimum:	3,431.1	0.0	3,431.1	105,900.0	363.4	0.44	0.2	0.7
Maximum:	4,434.3	1,098.3	5,402.5	105,900.0	572.1	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2023 00:00	4,447.1	412.6	4,859.7	105,900.0	514.6	0.62	0.3	1.0
07/06/2023 01:00	4,458.1	384.8	4,842.9	105,900.0	512.9	0.62	0.3	1.0
07/06/2023 02:00	4,467.6	359.9	4,827.5	105,900.0	511.2	0.61	0.3	1.0
07/06/2023 03:00	4,470.4	348.1	4,818.5	105,900.0	510.3	0.61	0.3	1.0
07/06/2023 04:00	4,474.9	338.9	4,813.8	105,900.0	509.8	0.61	0.3	1.0
07/06/2023 05:00	4,478.0	322.7	4,800.7	105,900.0	508.4	0.61	0.3	1.0
07/06/2023 06:00	4,480.0	313.1	4,793.1	105,900.0	507.6	0.61	0.3	1.0
07/06/2023 07:00	4,152.0	154.3	4,232.2	105,900.0	448.2	0.55	0.3	0.9
07/06/2023 08:00	3,447.5	0.0	3,447.5	105,900.0	365.1	0.44	0.2	0.7
07/06/2023 09:00	3,460.5	0.0	3,460.5	105,900.0	366.5	0.44	0.2	0.7
07/06/2023 10:00	3,476.3	0.0	3,476.3	105,900.0	368.1	0.44	0.2	0.7
07/06/2023 11:00	3,482.8	0.0	3,482.8	105,900.0	368.8	0.44	0.2	0.7
07/06/2023 12:00	3,463.4	0.0	3,463.4	105,900.0	366.8	0.44	0.2	0.7
07/06/2023 13:00	3,470.2	0.0	3,470.2	105,900.0	367.5	0.44	0.2	0.7
07/06/2023 14:00	3,472.0	0.0	3,472.0	105,900.0	367.7	0.44	0.2	0.7
07/06/2023 15:00	3,466.9	0.0	3,466.9	105,900.0	367.1	0.44	0.2	0.7
07/06/2023 16:00	3,955.3	211.4	4,054.7	105,900.0	429.4	0.53	0.3	0.9
07/06/2023 17:00	4,309.9	685.9	4,995.8	105,900.0	529.1	0.63	0.3	1.1
07/06/2023 18:00	4,324.5	796.9	5,121.4	105,900.0	542.4	0.65	0.3	1.1
07/06/2023 19:00	4,321.5	1,587.5	5,909.0	105,900.0	625.8	0.75	0.4	1.3
07/06/2023 20:00	4,339.8	1,316.8	5,656.6	105,900.0	599.0	0.72	0.4	1.2
07/06/2023 21:00	4,375.2	683.2	5,058.4	105,900.0	535.7	0.64	0.3	1.1
07/06/2023 22:00	4,406.9	480.8	4,887.7	105,900.0	517.6	0.62	0.3	1.0
07/06/2023 23:00	4,425.2	445.5	4,870.7	105,900.0	515.8	0.62	0.3	1.0
Average/Sum#:	4,067.8	368.4	4,428.4	105,900.0	469.0	0.56	0.3	0.9
Minimum:	3,447.5	0.0	3,447.5	105,900.0	365.1	0.44	0.2	0.7
Maximum:	4,480.0	1,587.5	5,909.0	105,900.0	625.8	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2023 00:00	4,443.0	409.9	4,852.9	105,900.0	513.9	0.62	0.3	1.0
07/07/2023 01:00	4,451.0	389.1	4,840.1	105,900.0	512.6	0.62	0.3	1.0
07/07/2023 02:00	4,457.0	375.4	4,832.4	105,900.0	511.8	0.61	0.3	1.0
07/07/2023 03:00	4,459.9	355.0	4,814.9	105,900.0	509.9	0.61	0.3	1.0
07/07/2023 04:00	4,461.9	373.8	4,835.7	105,900.0	512.1	0.61	0.3	1.0
07/07/2023 05:00	4,463.1	398.4	4,861.5	105,900.0	514.8	0.62	0.3	1.0
07/07/2023 06:00	4,465.7	394.7	4,860.4	105,900.0	514.7	0.62	0.3	1.0
07/07/2023 07:00	4,463.5	416.2	4,879.7	105,900.0	516.8	0.62	0.3	1.0
07/07/2023 08:00	3,751.1	1.7	3,751.1	105,900.0	397.2	0.48	0.2	0.8
07/07/2023 09:00	4,257.8	384.5	4,527.0	105,900.0	479.4	0.59	0.3	1.0
07/07/2023 10:00	4,424.0	519.1	4,943.1	105,900.0	523.5	0.63	0.3	1.0
07/07/2023 11:00	4,407.0	94.1	4,501.1	105,900.0	476.7	0.57	0.3	1.0
07/07/2023 12:00	4,334.3	63.8	4,384.1	105,900.0	464.3	0.56	0.3	0.9
07/07/2023 13:00	4,370.9	108.6	4,479.5	105,900.0	474.4	0.57	0.3	0.9
07/07/2023 14:00	4,349.1	192.9	4,542.0	105,900.0	481.0	0.58	0.3	1.0
07/07/2023 15:00	4,280.7	108.1	4,363.9	105,900.0	462.1	0.56	0.3	0.9
07/07/2023 16:00	3,717.5	18.6	3,719.7	105,900.0	393.9	0.47	0.2	0.8
07/07/2023 17:00	3,853.5	178.3	3,930.2	105,900.0	416.2	0.51	0.3	0.9
07/07/2023 18:00	3,821.7	122.0	3,858.3	105,900.0	408.6	0.50	0.3	0.8
07/07/2023 19:00	4,201.9	1,565.7	5,767.6	105,900.0	610.8	0.73	0.4	1.2
07/07/2023 20:00	4,226.8	1,623.6	5,850.4	105,900.0	619.6	0.74	0.4	1.2
07/07/2023 21:00	4,274.1	918.8	5,192.9	105,900.0	549.9	0.66	0.3	1.1
07/07/2023 22:00	4,310.7	643.3	4,954.0	105,900.0	524.6	0.63	0.3	1.0
07/07/2023 23:00	4,358.1	541.0	4,899.1	105,900.0	518.8	0.62	0.3	1.0
Average/Sum#:	4,275.2	424.9	4,685.1	105,900.0	496.2	0.60	0.3	1.0
Minimum:	3,717.5	1.7	3,719.7	105,900.0	393.9	0.47	0.2	0.8
Maximum:	4,465.7	1,623.6	5,850.4	105,900.0	619.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2023 00:00	4,384.9	535.6	4,920.5	105,900.0	521.1	0.63	0.3	1.0
07/08/2023 01:00	4,398.4	516.2	4,914.6	105,900.0	520.5	0.62	0.3	1.0
07/08/2023 02:00	4,411.5	490.0	4,901.5	105,900.0	519.1	0.62	0.3	1.0
07/08/2023 03:00	4,418.9	475.2	4,894.1	105,900.0	518.3	0.62	0.3	1.0
07/08/2023 04:00	4,423.0	467.5	4,890.5	105,900.0	517.9	0.62	0.3	1.0
07/08/2023 05:00	4,432.3	454.2	4,886.5	105,900.0	517.5	0.62	0.3	1.0
07/08/2023 06:00	4,440.8	438.8	4,879.6	105,900.0	516.7	0.62	0.3	1.0
07/08/2023 07:00	4,126.7	210.2	4,236.0	105,900.0	448.6	0.55	0.3	0.9
07/08/2023 08:00	3,472.1	0.0	3,472.1	105,900.0	367.7	0.44	0.2	0.7
07/08/2023 09:00	3,497.9	0.0	3,497.9	105,900.0	370.4	0.44	0.2	0.7
07/08/2023 10:00	3,497.4	0.0	3,497.4	105,900.0	370.4	0.44	0.2	0.7
07/08/2023 11:00	3,487.7	0.0	3,487.7	105,900.0	369.3	0.44	0.2	0.7
07/08/2023 12:00	3,495.5	0.0	3,495.5	105,900.0	370.2	0.44	0.2	0.7
07/08/2023 13:00	3,486.6	0.0	3,486.6	105,900.0	369.2	0.44	0.2	0.7
07/08/2023 14:00	3,473.7	0.0	3,473.7	105,900.0	367.9	0.44	0.2	0.7
07/08/2023 15:00	3,477.5	0.0	3,477.5	105,900.0	368.3	0.44	0.2	0.7
07/08/2023 16:00	3,476.9	0.0	3,476.9	105,900.0	368.2	0.44	0.2	0.7
07/08/2023 17:00	3,965.0	255.8	4,085.2	105,900.0	432.6	0.54	0.3	0.9
07/08/2023 18:00	4,337.7	790.5	5,128.2	105,900.0	543.1	0.65	0.3	1.1
07/08/2023 19:00	4,371.5	1,661.1	6,032.6	105,900.0	638.9	0.77	0.4	1.3
07/08/2023 20:00	4,394.3	1,032.0	5,426.3	105,900.0	574.6	0.69	0.3	1.1
07/08/2023 21:00	4,427.0	458.5	4,885.5	105,900.0	517.4	0.62	0.3	1.0
07/08/2023 22:00	4,446.1	419.8	4,865.9	105,900.0	515.3	0.62	0.3	1.0
07/08/2023 23:00	4,455.7	391.9	4,847.6	105,900.0	513.4	0.62	0.3	1.0
Average/Sum#:	4,033.3	358.2	4,381.7	105,900.0	464.0	0.56	0.3	0.9
Minimum:	3,472.1	0.0	3,472.1	105,900.0	367.7	0.44	0.2	0.7
Maximum:	4,455.7	1,661.1	6,032.6	105,900.0	638.9	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2023 00:00	4,469.3	363.8	4,833.1	105,900.0	511.8	0.61	0.3	1.0
07/09/2023 01:00	4,473.9	367.9	4,841.8	105,900.0	512.7	0.62	0.3	1.0
07/09/2023 02:00	4,479.3	381.2	4,860.5	105,900.0	514.7	0.62	0.3	1.0
07/09/2023 03:00	4,487.7	366.4	4,854.1	105,900.0	514.0	0.62	0.3	1.0
07/09/2023 04:00	4,491.2	350.9	4,842.1	105,900.0	512.8	0.62	0.3	1.0
07/09/2023 05:00	4,490.4	373.9	4,864.3	105,900.0	515.1	0.62	0.3	1.0
07/09/2023 06:00	4,287.4	180.2	4,381.1	105,900.0	464.0	0.57	0.3	0.9
07/09/2023 07:00	4,147.6	0.0	4,147.6	105,900.0	439.2	0.53	0.3	0.9
07/09/2023 08:00	4,133.6	298.3	4,232.0	105,900.0	448.2	0.56	0.3	0.9
07/09/2023 09:00	3,498.9	0.0	3,498.9	105,900.0	370.5	0.44	0.2	0.7
07/09/2023 10:00	3,483.3	0.0	3,483.3	105,900.0	368.9	0.44	0.2	0.7
07/09/2023 11:00	3,484.3	0.0	3,484.3	105,900.0	369.0	0.44	0.2	0.7
07/09/2023 12:00	3,469.9	0.0	3,469.9	105,900.0	367.5	0.44	0.2	0.7
07/09/2023 13:00	3,436.7	0.0	3,436.7	105,900.0	363.9	0.44	0.2	0.7
07/09/2023 14:00	3,439.8	0.0	3,439.8	105,900.0	364.3	0.44	0.2	0.7
07/09/2023 15:00	3,435.1	0.0	3,435.1	105,900.0	363.8	0.44	0.2	0.7
07/09/2023 16:00	3,433.0	0.0	3,433.0	105,900.0	363.6	0.44	0.2	0.7
07/09/2023 17:00	3,386.5	0.0	3,386.5	105,900.0	358.6	0.43	0.2	0.7
07/09/2023 18:00	3,678.3	53.9	3,691.8	105,900.0	391.0	0.47	0.2	0.8
07/09/2023 19:00	4,200.5	128.9	4,329.4	105,900.0	458.5	0.55	0.3	0.9
07/09/2023 20:00	4,239.4	86.2	4,325.6	105,900.0	458.1	0.55	0.3	0.9
07/09/2023 21:00	4,271.0	80.2	4,345.6	105,900.0	460.2	0.55	0.3	0.9
07/09/2023 22:00	3,913.4	40.2	3,932.3	105,900.0	416.4	0.50	0.3	0.8
07/09/2023 23:00	3,389.8	0.0	3,389.8	105,900.0	359.0	0.43	0.2	0.7
Average/Sum#:	3,925.8	128.0	4,039.1	105,900.0	427.7	0.52	0.3	0.8
Minimum:	3,386.5	0.0	3,386.5	105,900.0	358.6	0.43	0.2	0.7
Maximum:	4,491.2	381.2	4,864.3	105,900.0	515.1	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2023 00:00	3,394.0	0.0	3,394.0	105,900.0	359.4	0.43	0.2	0.7
07/10/2023 01:00	3,389.0	0.0	3,389.0	105,900.0	358.9	0.43	0.2	0.7
07/10/2023 02:00	3,384.8	0.0	3,384.8	105,900.0	358.5	0.43	0.2	0.7
07/10/2023 03:00	3,386.9	0.0	3,386.9	105,900.0	358.7	0.43	0.2	0.7
07/10/2023 04:00	3,385.7	0.0	3,385.7	105,900.0	358.5	0.43	0.2	0.7
07/10/2023 05:00	3,386.8	0.0	3,386.8	105,900.0	358.7	0.43	0.2	0.7
07/10/2023 06:00	3,388.1	0.0	3,388.1	105,900.0	358.8	0.43	0.2	0.7
07/10/2023 07:00	3,391.2	0.0	3,391.2	105,900.0	359.1	0.43	0.2	0.7
07/10/2023 08:00	3,399.0	0.0	3,399.0	105,900.0	360.0	0.43	0.2	0.7
07/10/2023 09:00	3,409.1	0.0	3,409.1	105,900.0	361.0	0.43	0.2	0.7
07/10/2023 10:00	3,414.3	0.0	3,414.3	105,900.0	361.6	0.43	0.2	0.7
07/10/2023 11:00	3,411.7	0.0	3,411.7	105,900.0	361.3	0.43	0.2	0.7
07/10/2023 12:00	3,430.8	0.0	3,430.8	105,900.0	363.3	0.44	0.2	0.7
07/10/2023 13:00	3,448.4	0.0	3,448.4	105,900.0	365.2	0.44	0.2	0.7
07/10/2023 14:00	3,462.2	0.0	3,462.2	105,900.0	366.6	0.44	0.2	0.7
07/10/2023 15:00	3,468.5	0.0	3,468.5	105,900.0	367.3	0.44	0.2	0.7
07/10/2023 16:00	3,463.9	0.0	3,463.9	105,900.0	366.8	0.44	0.2	0.7
07/10/2023 17:00	3,458.0	0.0	3,458.0	105,900.0	366.2	0.44	0.2	0.7
07/10/2023 18:00	3,512.9	0.0	3,512.9	105,900.0	372.0	0.45	0.2	0.7
07/10/2023 19:00	3,840.9	86.0	3,873.6	105,900.0	410.2	0.50	0.2	0.8
07/10/2023 20:00	4,311.0	136.0	4,447.0	105,900.0	470.9	0.56	0.3	0.9
07/10/2023 21:00	3,743.8	7.1	3,744.5	105,900.0	396.5	0.48	0.2	0.8
07/10/2023 22:00	3,625.3	0.0	3,625.3	105,900.0	383.9	0.46	0.2	0.8
07/10/2023 23:00	3,527.0	0.0	3,527.0	105,900.0	373.5	0.45	0.2	0.7
Average/Sum#:	3,501.4	9.5	3,508.4	105,900.0	371.5	0.45	0.2	0.7
Minimum:	3,384.8	0.0	3,384.8	105,900.0	358.5	0.43	0.2	0.7
Maximum:	4,311.0	136.0	4,447.0	105,900.0	470.9	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2023 00:00	3,459.0	0.0	3,459.0	105,900.0	366.3	0.44	0.2	0.7
07/11/2023 01:00	3,472.7	0.0	3,472.7	105,900.0	367.8	0.44	0.2	0.7
07/11/2023 02:00	3,479.9	0.0	3,479.9	105,900.0	368.5	0.44	0.2	0.7
07/11/2023 03:00	3,480.6	0.0	3,480.6	105,900.0	368.6	0.44	0.2	0.7
07/11/2023 04:00	3,477.0	0.0	3,477.0	105,900.0	368.2	0.44	0.2	0.7
07/11/2023 05:00	3,493.1	0.0	3,493.1	105,900.0	369.9	0.44	0.2	0.7
07/11/2023 06:00	3,740.7	1.1	3,740.7	105,900.0	396.1	0.48	0.2	0.8
07/11/2023 07:00	3,447.7	0.0	3,447.7	105,900.0	365.1	0.44	0.2	0.7
07/11/2023 08:00	3,479.4	0.0	3,479.4	105,900.0	368.5	0.44	0.2	0.7
07/11/2023 09:00	3,488.1	0.0	3,488.1	105,900.0	369.4	0.44	0.2	0.7
07/11/2023 10:00	3,480.0	0.0	3,480.0	105,900.0	368.5	0.44	0.2	0.7
07/11/2023 11:00	3,470.5	0.0	3,470.5	105,900.0	367.5	0.44	0.2	0.7
07/11/2023 12:00	3,485.4	0.0	3,485.4	105,900.0	369.1	0.44	0.2	0.7
07/11/2023 13:00	3,484.5	0.0	3,484.5	105,900.0	369.0	0.44	0.2	0.7
07/11/2023 14:00	3,480.5	0.0	3,480.5	105,900.0	368.6	0.44	0.2	0.7
07/11/2023 15:00	3,482.6	0.0	3,482.6	105,900.0	368.8	0.44	0.2	0.7
07/11/2023 16:00	3,539.6	0.8	3,539.6	105,900.0	374.8	0.45	0.2	0.7
07/11/2023 17:00	3,706.7	0.0	3,706.7	105,900.0	392.5	0.47	0.2	0.8
07/11/2023 18:00	3,632.6	0.0	3,632.6	105,900.0	384.7	0.46	0.2	0.8
07/11/2023 19:00	4,225.1	0.0	4,225.1	105,900.0	447.4	0.54	0.3	0.9
07/11/2023 20:00	4,271.9	0.0	4,271.9	105,900.0	452.4	0.54	0.3	0.9
07/11/2023 21:00	4,269.6	0.0	4,269.6	105,900.0	452.2	0.54	0.3	0.9
07/11/2023 22:00	3,870.1	0.0	3,870.1	105,900.0	409.8	0.49	0.2	0.8
07/11/2023 23:00	3,608.6	0.0	3,608.6	105,900.0	382.2	0.46	0.2	0.8
Average/Sum#:	3,626.1	0.1	3,626.1	105,900.0	384.0	0.46	0.2	0.7
Minimum:	3,447.7	0.0	3,447.7	105,900.0	365.1	0.44	0.2	0.7
Maximum:	4,271.9	1.1	4,271.9	105,900.0	452.4	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2023 00:00	3,444.6	0.0	3,444.6	105,900.0	364.8	0.44	0.2	0.7
07/12/2023 01:00	3,450.9	0.0	3,450.9	105,900.0	365.5	0.44	0.2	0.7
07/12/2023 02:00	3,434.8	0.0	3,434.8	105,900.0	363.7	0.44	0.2	0.7
07/12/2023 03:00	3,421.6	0.0	3,421.6	105,900.0	362.3	0.43	0.2	0.7
07/12/2023 04:00	3,421.1	0.0	3,421.1	105,900.0	362.3	0.43	0.2	0.7
07/12/2023 05:00	3,419.3	0.0	3,419.3	105,900.0	362.1	0.43	0.2	0.7
07/12/2023 06:00	3,419.5	0.0	3,419.5	105,900.0	362.1	0.43	0.2	0.7
07/12/2023 07:00	3,443.6	0.0	3,443.6	105,900.0	364.7	0.44	0.2	0.7
07/12/2023 08:00	3,482.7	0.0	3,482.7	105,900.0	368.8	0.44	0.2	0.7
07/12/2023 09:00	3,477.0	0.0	3,477.0	105,900.0	368.2	0.44	0.2	0.7
07/12/2023 10:00	3,481.1	0.0	3,481.1	105,900.0	368.6	0.44	0.2	0.7
07/12/2023 11:00	3,490.7	0.0	3,490.7	105,900.0	369.7	0.44	0.2	0.7
07/12/2023 12:00	3,499.3	0.0	3,499.3	105,900.0	370.6	0.44	0.2	0.7
07/12/2023 13:00	3,480.6	0.0	3,480.6	105,900.0	368.6	0.44	0.2	0.7
07/12/2023 14:00	3,473.3	0.0	3,473.3	105,900.0	367.8	0.44	0.2	0.7
07/12/2023 15:00	3,469.3	0.0	3,469.3	105,900.0	367.4	0.44	0.2	0.7
07/12/2023 16:00	3,473.2	0.0	3,473.2	105,900.0	367.8	0.44	0.2	0.7
07/12/2023 17:00	3,606.3	0.0	3,606.3	105,900.0	381.9	0.46	0.2	0.8
07/12/2023 18:00	3,852.7	0.0	3,852.7	105,900.0	408.0	0.49	0.2	0.8
07/12/2023 19:00	4,289.0	0.0	4,289.0	105,900.0	454.2	0.55	0.3	0.9
07/12/2023 20:00	4,243.5	0.0	4,243.5	105,900.0	449.4	0.54	0.3	0.9
07/12/2023 21:00	4,258.4	0.0	4,258.4	105,900.0	451.0	0.54	0.3	0.9
07/12/2023 22:00	4,069.0	0.0	4,069.0	105,900.0	430.9	0.52	0.3	0.9
07/12/2023 23:00	3,731.0	0.0	3,731.0	105,900.0	395.1	0.47	0.2	0.8
Average/Sum#:	3,618.0	0.0	3,618.0	105,900.0	383.1	0.46	0.2	0.7
Minimum:	3,419.3	0.0	3,419.3	105,900.0	362.1	0.43	0.2	0.7
Maximum:	4,289.0	0.0	4,289.0	105,900.0	454.2	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2023 00:00	3,872.8	0.0	3,872.8	105,900.0	410.1	0.49	0.2	0.8
07/13/2023 01:00	3,414.7	0.0	3,414.7	105,900.0	361.6	0.43	0.2	0.7
07/13/2023 02:00	3,420.5	0.0	3,420.5	105,900.0	362.2	0.43	0.2	0.7
07/13/2023 03:00	3,441.6	0.0	3,441.6	105,900.0	364.5	0.44	0.2	0.7
07/13/2023 04:00	3,456.0	0.0	3,456.0	105,900.0	366.0	0.44	0.2	0.7
07/13/2023 05:00	3,452.0	0.0	3,452.0	105,900.0	365.6	0.44	0.2	0.7
07/13/2023 06:00	3,457.3	0.0	3,457.3	105,900.0	366.1	0.44	0.2	0.7
07/13/2023 07:00	3,468.1	0.0	3,468.1	105,900.0	367.3	0.44	0.2	0.7
07/13/2023 08:00	3,476.9	0.0	3,476.9	105,900.0	368.2	0.44	0.2	0.7
07/13/2023 09:00	3,456.7	0.0	3,456.7	105,900.0	366.1	0.44	0.2	0.7
07/13/2023 10:00	3,443.9	0.0	3,443.9	105,900.0	364.7	0.44	0.2	0.7
07/13/2023 11:00	3,668.6	0.0	3,668.6	105,900.0	388.5	0.47	0.2	0.8
07/13/2023 12:00	3,462.5	0.0	3,462.5	105,900.0	366.7	0.44	0.2	0.7
07/13/2023 13:00	3,729.7	0.0	3,729.7	105,900.0	395.0	0.47	0.2	0.8
07/13/2023 14:00	3,869.5	0.0	3,869.5	105,900.0	409.8	0.49	0.2	0.8
07/13/2023 15:00	3,493.8	0.0	3,493.8	105,900.0	370.0	0.44	0.2	0.7
07/13/2023 16:00	3,702.4	0.0	3,702.4	105,900.0	392.1	0.47	0.2	0.8
07/13/2023 17:00	3,734.5	0.0	3,734.5	105,900.0	395.5	0.47	0.2	0.8
07/13/2023 18:00	3,993.6	0.0	3,993.6	105,900.0	422.9	0.51	0.3	0.8
07/13/2023 19:00	4,244.5	1,476.5	5,721.0	105,900.0	605.9	0.73	0.4	1.2
07/13/2023 20:00	4,246.8	1,448.0	5,694.8	105,900.0	603.1	0.72	0.4	1.2
07/13/2023 21:00	4,295.8	810.1	5,105.9	105,900.0	540.7	0.65	0.3	1.1
07/13/2023 22:00	4,314.2	699.5	5,013.7	105,900.0	531.0	0.64	0.3	1.1
07/13/2023 23:00	4,323.9	601.7	4,925.6	105,900.0	521.6	0.63	0.3	1.0
Average/Sum#:	3,726.7	209.8	3,936.5	105,900.0	416.9	0.50	0.2	0.8
Minimum:	3,414.7	0.0	3,414.7	105,900.0	361.6	0.43	0.2	0.7
Maximum:	4,323.9	1,476.5	5,721.0	105,900.0	605.9	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2023 00:00	4,347.8	550.9	4,898.7	105,900.0	518.8	0.62	0.3	1.0
07/14/2023 01:00	4,359.0	559.7	4,918.7	105,900.0	520.9	0.62	0.3	1.0
07/14/2023 02:00	4,379.0	535.5	4,914.5	105,900.0	520.4	0.62	0.3	1.0
07/14/2023 03:00	4,394.7	496.4	4,891.1	105,900.0	518.0	0.62	0.3	1.0
07/14/2023 04:00	4,403.7	480.8	4,884.5	105,900.0	517.3	0.62	0.3	1.0
07/14/2023 05:00	4,416.7	491.7	4,908.4	105,900.0	519.8	0.62	0.3	1.0
07/14/2023 06:00	4,425.1	496.0	4,921.1	105,900.0	521.1	0.63	0.3	1.0
07/14/2023 07:00	4,418.1	514.4	4,932.5	105,900.0	522.4	0.63	0.3	1.0
07/14/2023 08:00	3,715.1	12.9	3,716.8	105,900.0	393.6	0.47	0.2	0.8
07/14/2023 09:00	3,471.7	0.0	3,471.7	105,900.0	367.7	0.44	0.2	0.7
07/14/2023 10:00	3,470.2	0.0	3,470.2	105,900.0	367.5	0.44	0.2	0.7
07/14/2023 11:00	3,478.5	0.0	3,478.5	105,900.0	368.4	0.44	0.2	0.7
07/14/2023 12:00	3,984.3	364.1	4,140.9	105,900.0	438.5	0.55	0.3	0.9
07/14/2023 13:00	4,246.5	972.5	5,219.0	105,900.0	552.7	0.66	0.3	1.1
07/14/2023 14:00	3,947.4	207.3	4,005.4	105,900.0	424.2	0.53	0.3	0.9
07/14/2023 15:00	3,809.8	0.0	3,809.8	105,900.0	403.5	0.48	0.2	0.8
07/14/2023 16:00	3,703.5	0.0	3,703.5	105,900.0	392.2	0.47	0.2	0.8
07/14/2023 17:00	4,153.8	1,045.4	4,990.1	105,900.0	528.5	0.66	0.3	1.1
07/14/2023 18:00	4,209.1	1,537.3	5,746.4	105,900.0	608.5	0.73	0.4	1.2
07/14/2023 19:00	4,215.2	1,935.6	6,150.8	105,900.0	651.4	0.78	0.4	1.3
07/14/2023 20:00	4,214.2	1,832.6	6,046.8	105,900.0	640.4	0.77	0.4	1.3
07/14/2023 21:00	4,243.4	1,417.9	5,661.3	105,900.0	599.5	0.72	0.4	1.2
07/14/2023 22:00	4,234.6	1,078.1	5,312.7	105,900.0	562.6	0.68	0.3	1.1
07/14/2023 23:00	3,879.8	4.7	3,879.9	105,900.0	410.9	0.49	0.2	0.8
Average/Sum#:	4,088.4	605.6	4,669.7	105,900.0	494.5	0.60	0.3	1.0
Minimum:	3,470.2	0.0	3,470.2	105,900.0	367.5	0.44	0.2	0.7
Maximum:	4,425.1	1,935.6	6,150.8	105,900.0	651.4	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2023 00:00	4,217.9	0.0	4,217.9	105,900.0	446.7	0.54	0.3	0.9
07/15/2023 01:00	4,046.3	0.0	4,046.3	105,900.0	428.5	0.51	0.3	0.9
07/15/2023 02:00	3,981.7	0.0	3,981.7	105,900.0	421.7	0.51	0.3	0.8
07/15/2023 03:00	4,097.1	0.0	4,097.1	105,900.0	433.9	0.52	0.3	0.9
07/15/2023 04:00	4,126.6	0.0	4,126.6	105,900.0	437.0	0.52	0.3	0.9
07/15/2023 05:00	4,124.2	0.0	4,124.2	105,900.0	436.8	0.52	0.3	0.9
07/15/2023 06:00	3,810.8	0.0	3,810.8	105,900.0	403.6	0.48	0.2	0.8
07/15/2023 07:00	3,405.5	0.0	3,405.5	105,900.0	360.6	0.43	0.2	0.7
07/15/2023 08:00	3,407.1	0.0	3,407.1	105,900.0	360.8	0.43	0.2	0.7
07/15/2023 09:00	3,394.5	0.0	3,394.5	105,900.0	359.5	0.43	0.2	0.7
07/15/2023 10:00	3,394.7	0.0	3,394.7	105,900.0	359.5	0.43	0.2	0.7
07/15/2023 11:00	3,394.2	0.0	3,394.2	105,900.0	359.4	0.43	0.2	0.7
07/15/2023 12:00	3,832.0	0.0	3,832.0	105,900.0	405.8	0.49	0.2	0.8
07/15/2023 13:00	4,069.0	0.0	4,069.0	105,900.0	430.9	0.52	0.3	0.9
07/15/2023 14:00	3,908.6	0.0	3,908.6	105,900.0	413.9	0.50	0.2	0.8
07/15/2023 15:00	4,054.7	640.3	4,374.9	105,900.0	463.3	0.60	0.3	1.0
07/15/2023 16:00	4,153.3	1,849.7	6,003.0	105,900.0	635.7	0.76	0.4	1.3
07/15/2023 17:00	4,127.4	1,833.2	5,960.6	105,900.0	631.2	0.76	0.4	1.3
07/15/2023 18:00	4,137.9	1,873.4	6,011.3	105,900.0	636.6	0.76	0.4	1.3
07/15/2023 19:00	4,146.5	1,866.0	6,012.5	105,900.0	636.7	0.76	0.4	1.3
07/15/2023 20:00	4,176.7	1,966.4	6,143.1	105,900.0	650.6	0.78	0.4	1.3
07/15/2023 21:00	4,186.2	1,990.1	6,176.3	105,900.0	654.1	0.78	0.4	1.3
07/15/2023 22:00	4,209.4	1,695.7	5,905.1	105,900.0	625.4	0.75	0.4	1.3
07/15/2023 23:00	4,233.2	840.1	5,073.3	105,900.0	537.3	0.64	0.3	1.1
Average/Sum#:	3,943.1	606.5	4,536.3	105,900.0	480.4	0.58	0.3	1.0
Minimum:	3,394.2	0.0	3,394.2	105,900.0	359.4	0.43	0.2	0.7
Maximum:	4,233.2	1,990.1	6,176.3	105,900.0	654.1	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2023 00:00	4,243.7	95.8	4,265.7	105,900.0	451.7	0.55	0.3	0.9
07/16/2023 01:00	4,194.4	0.0	4,194.4	105,900.0	444.2	0.53	0.3	0.9
07/16/2023 02:00	4,205.9	0.0	4,205.9	105,900.0	445.4	0.53	0.3	0.9
07/16/2023 03:00	4,193.0	0.0	4,193.0	105,900.0	444.0	0.53	0.3	0.9
07/16/2023 04:00	4,137.4	0.0	4,137.4	105,900.0	438.2	0.53	0.3	0.9
07/16/2023 05:00	4,203.0	0.0	4,203.0	105,900.0	445.1	0.53	0.3	0.9
07/16/2023 06:00	3,755.6	0.0	3,755.6	105,900.0	397.7	0.48	0.2	0.8
07/16/2023 07:00	3,401.2	0.0	3,401.2	105,900.0	360.2	0.43	0.2	0.7
07/16/2023 08:00	3,411.3	0.0	3,411.3	105,900.0	361.3	0.43	0.2	0.7
07/16/2023 09:00	3,411.5	0.0	3,411.5	105,900.0	361.3	0.43	0.2	0.7
07/16/2023 10:00	3,855.5	0.0	3,855.5	105,900.0	408.3	0.49	0.2	0.8
07/16/2023 11:00	4,102.4	0.0	4,102.4	105,900.0	434.4	0.52	0.3	0.9
07/16/2023 12:00	4,195.8	0.0	4,195.8	105,900.0	444.3	0.53	0.3	0.9
07/16/2023 13:00	4,164.5	8.7	4,164.9	105,900.0	441.1	0.53	0.3	0.9
07/16/2023 14:00	4,144.1	1,638.3	5,782.4	105,900.0	612.4	0.73	0.4	1.2
07/16/2023 15:00	4,120.5	1,925.5	6,046.0	105,900.0	640.3	0.77	0.4	1.3
07/16/2023 16:00	4,105.5	1,909.1	6,014.6	105,900.0	636.9	0.77	0.4	1.3
07/16/2023 17:00	4,093.3	1,913.9	6,007.2	105,900.0	636.2	0.76	0.4	1.3
07/16/2023 18:00	4,064.5	1,899.1	5,963.6	105,900.0	631.5	0.76	0.4	1.3
07/16/2023 19:00	4,108.5	1,875.7	5,984.2	105,900.0	633.7	0.76	0.4	1.3
07/16/2023 20:00	4,176.6	1,275.3	5,451.9	105,900.0	577.4	0.69	0.3	1.2
07/16/2023 21:00	4,222.7	1,128.1	5,350.8	105,900.0	566.6	0.68	0.3	1.1
07/16/2023 22:00	3,963.5	4.2	3,963.6	105,900.0	419.7	0.50	0.3	0.8
07/16/2023 23:00	3,679.4	0.0	3,679.4	105,900.0	389.6	0.47	0.2	0.8
Average/Sum#:	4,006.4	569.7	4,572.6	105,900.0	484.2	0.58	0.3	1.0
Minimum:	3,401.2	0.0	3,401.2	105,900.0	360.2	0.43	0.2	0.7
Maximum:	4,243.7	1,925.5	6,046.0	105,900.0	640.3	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2023 00:00	4,094.0	0.0	4,094.0	105,900.0	433.6	0.52	0.3	0.9
07/17/2023 01:00	4,052.5	0.0	4,052.5	105,900.0	429.2	0.51	0.3	0.9
07/17/2023 02:00	3,586.6	0.0	3,586.6	105,900.0	379.8	0.45	0.2	0.8
07/17/2023 03:00	3,413.1	0.0	3,413.1	105,900.0	361.4	0.43	0.2	0.7
07/17/2023 04:00	3,459.0	0.0	3,459.0	105,900.0	366.3	0.44	0.2	0.7
07/17/2023 05:00	3,996.6	0.0	3,996.6	105,900.0	423.2	0.51	0.3	0.8
07/17/2023 06:00	4,159.2	0.0	4,159.2	105,900.0	440.5	0.53	0.3	0.9
07/17/2023 07:00	3,477.7	0.0	3,477.7	105,900.0	368.3	0.44	0.2	0.7
07/17/2023 08:00	3,402.5	0.0	3,402.5	105,900.0	360.3	0.43	0.2	0.7
07/17/2023 09:00	3,396.4	0.0	3,396.4	105,900.0	359.7	0.43	0.2	0.7
07/17/2023 10:00	3,808.0	0.0	3,808.0	105,900.0	403.3	0.48	0.2	0.8
07/17/2023 11:00	4,024.4	0.0	4,024.4	105,900.0	426.2	0.51	0.3	0.9
07/17/2023 12:00	3,980.8	0.0	3,980.8	105,900.0	421.6	0.51	0.3	0.8
07/17/2023 13:00	4,186.7	0.0	4,186.7	105,900.0	443.4	0.53	0.3	0.9
07/17/2023 14:00	4,170.6	0.0	4,170.6	105,900.0	441.7	0.53	0.3	0.9
07/17/2023 15:00	4,159.0	547.1	4,416.1	105,900.0	467.7	0.60	0.3	1.0
07/17/2023 16:00	4,136.3	1,819.6	5,955.9	105,900.0	630.7	0.76	0.4	1.3
07/17/2023 17:00	4,180.1	917.9	5,098.0	105,900.0	539.9	0.65	0.3	1.1
07/17/2023 18:00	4,151.1	3.9	4,151.2	105,900.0	439.6	0.53	0.3	0.9
07/17/2023 19:00	4,091.2	0.0	4,091.2	105,900.0	433.3	0.52	0.3	0.9
07/17/2023 20:00	4,145.4	0.0	4,145.4	105,900.0	439.0	0.53	0.3	0.9
07/17/2023 21:00	4,189.1	0.0	4,189.1	105,900.0	443.6	0.53	0.3	0.9
07/17/2023 22:00	4,141.5	0.0	4,141.5	105,900.0	438.6	0.52	0.3	0.9
07/17/2023 23:00	4,113.3	0.0	4,113.3	105,900.0	435.6	0.52	0.3	0.9
Average/Sum#:	3,938.1	137.0	4,062.9	105,900.0	430.3	0.52	0.3	0.9
Minimum:	3,396.4	0.0	3,396.4	105,900.0	359.7	0.43	0.2	0.7
Maximum:	4,189.1	1,819.6	5,955.9	105,900.0	630.7	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2023 00:00	4,309.8	0.0	4,309.8	105,900.0	456.4	0.55	0.3	0.9
07/18/2023 01:00	4,323.4	0.0	4,323.4	105,900.0	457.8	0.55	0.3	0.9
07/18/2023 02:00	4,252.4	0.0	4,252.4	105,900.0	450.3	0.54	0.3	0.9
07/18/2023 03:00	4,164.6	0.0	4,164.6	105,900.0	441.0	0.53	0.3	0.9
07/18/2023 04:00	4,349.0	0.0	4,349.0	105,900.0	460.6	0.55	0.3	0.9
07/18/2023 05:00	4,377.0	0.0	4,377.0	105,900.0	463.5	0.56	0.3	0.9
07/18/2023 06:00	4,379.8	0.0	4,379.8	105,900.0	463.8	0.56	0.3	0.9
07/18/2023 07:00	3,726.1	0.0	3,726.1	105,900.0	394.6	0.47	0.2	0.8
07/18/2023 08:00	3,474.0	0.0	3,474.0	105,900.0	367.9	0.44	0.2	0.7
07/18/2023 09:00	3,696.3	0.0	3,696.3	105,900.0	391.4	0.47	0.2	0.8
07/18/2023 10:00	4,098.1	0.4	4,098.1	105,900.0	434.0	0.52	0.3	0.9
07/18/2023 11:00	4,186.3	0.0	4,186.3	105,900.0	443.3	0.53	0.3	0.9
07/18/2023 12:00	4,295.5	0.0	4,295.5	105,900.0	454.9	0.55	0.3	0.9
07/18/2023 13:00	4,272.2	0.0	4,272.2	105,900.0	452.4	0.54	0.3	0.9
07/18/2023 14:00	3,983.9	76.8	4,006.9	105,900.0	424.3	0.52	0.3	0.9
07/18/2023 15:00	4,145.1	1,124.0	5,269.1	105,900.0	558.0	0.67	0.3	1.1
07/18/2023 16:00	4,256.1	948.0	5,204.1	105,900.0	551.1	0.66	0.3	1.1
07/18/2023 17:00	4,255.4	656.4	4,911.8	105,900.0	520.2	0.62	0.3	1.0
07/18/2023 18:00	4,263.6	1,135.2	5,398.8	105,900.0	571.7	0.69	0.3	1.1
07/18/2023 19:00	4,280.8	1,882.7	6,163.5	105,900.0	652.7	0.78	0.4	1.3
07/18/2023 20:00	4,293.1	1,489.9	5,783.0	105,900.0	612.4	0.73	0.4	1.2
07/18/2023 21:00	4,310.1	1,380.3	5,690.4	105,900.0	602.6	0.72	0.4	1.2
07/18/2023 22:00	4,327.1	1,072.6	5,399.7	105,900.0	571.8	0.69	0.3	1.1
07/18/2023 23:00	4,353.3	795.3	5,148.6	105,900.0	545.2	0.65	0.3	1.1
Average/Sum#:	4,182.2	440.1	4,620.0	105,900.0	489.2	0.59	0.3	1.0
Minimum:	3,474.0	0.0	3,474.0	105,900.0	367.9	0.44	0.2	0.7
Maximum:	4,379.8	1,882.7	6,163.5	105,900.0	652.7	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2023 00:00	4,305.0	33.7	4,317.8	105,900.0	457.3	0.55	0.3	0.9
07/19/2023 01:00	4,239.9	0.0	4,239.9	105,900.0	449.0	0.54	0.3	0.9
07/19/2023 02:00	4,127.5	0.0	4,127.5	105,900.0	437.1	0.53	0.3	0.9
07/19/2023 03:00	3,998.7	0.0	3,998.7	105,900.0	423.5	0.51	0.3	0.8
07/19/2023 04:00	4,155.0	0.0	4,155.0	105,900.0	440.0	0.53	0.3	0.9
07/19/2023 05:00	4,290.2	0.0	4,290.2	105,900.0	454.3	0.54	0.3	0.9
07/19/2023 06:00	4,296.4	0.0	4,296.4	105,900.0	455.0	0.55	0.3	0.9
07/19/2023 07:00	3,890.7	0.0	3,890.7	105,900.0	412.0	0.49	0.2	0.8
07/19/2023 08:00	3,567.2	0.0	3,567.2	105,900.0	377.8	0.45	0.2	0.8
07/19/2023 09:00	3,799.3	0.0	3,799.3	105,900.0	402.3	0.48	0.2	0.8
07/19/2023 10:00	3,678.7	0.0	3,678.7	105,900.0	389.6	0.47	0.2	0.8
07/19/2023 11:00	4,095.8	0.0	4,095.8	105,900.0	433.7	0.52	0.3	0.9
07/19/2023 12:00	4,273.4	0.0	4,273.4	105,900.0	452.6	0.54	0.3	0.9
07/19/2023 13:00	4,287.1	406.6	4,478.2	105,900.0	474.2	0.60	0.3	1.0
07/19/2023 14:00	4,267.5	1,607.8	5,875.3	105,900.0	622.2	0.75	0.4	1.2
07/19/2023 15:00	4,251.6	1,757.6	6,009.2	105,900.0	636.4	0.76	0.4	1.3
07/19/2023 16:00	4,237.0	1,733.6	5,970.6	105,900.0	632.3	0.76	0.4	1.3
07/19/2023 17:00	4,235.3	1,640.7	5,876.0	105,900.0	622.3	0.75	0.4	1.2
07/19/2023 18:00	4,251.0	1,756.9	6,007.9	105,900.0	636.2	0.76	0.4	1.3
07/19/2023 19:00	4,263.6	1,898.8	6,162.4	105,900.0	652.6	0.78	0.4	1.3
07/19/2023 20:00	4,290.3	1,867.4	6,157.7	105,900.0	652.1	0.78	0.4	1.3
07/19/2023 21:00	4,305.1	1,664.3	5,969.4	105,900.0	632.2	0.76	0.4	1.3
07/19/2023 22:00	4,309.5	1,473.0	5,782.5	105,900.0	612.4	0.73	0.4	1.2
07/19/2023 23:00	4,322.3	945.4	5,267.7	105,900.0	557.8	0.67	0.3	1.1
Average/Sum#:	4,155.8	699.4	4,845.3	105,900.0	513.1	0.62	0.3	1.0
Minimum:	3,567.2	0.0	3,567.2	105,900.0	377.8	0.45	0.2	0.8
Maximum:	4,322.3	1,898.8	6,162.4	105,900.0	652.6	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2023 00:00	4,276.5	62.8	4,309.2	105,900.0	456.3	0.55	0.3	0.9
07/20/2023 01:00	4,170.7	0.0	4,170.7	105,900.0	441.7	0.53	0.3	0.9
07/20/2023 02:00	4,200.6	0.0	4,200.6	105,900.0	444.8	0.53	0.3	0.9
07/20/2023 03:00	4,147.3	0.0	4,147.3	105,900.0	439.2	0.53	0.3	0.9
07/20/2023 04:00	4,275.2	0.0	4,275.2	105,900.0	452.7	0.54	0.3	0.9
07/20/2023 05:00	4,301.0	0.0	4,301.0	105,900.0	455.5	0.55	0.3	0.9
07/20/2023 06:00	4,240.4	0.0	4,240.4	105,900.0	449.1	0.54	0.3	0.9
07/20/2023 07:00	3,541.8	0.0	3,541.8	105,900.0	375.1	0.45	0.2	0.7
07/20/2023 08:00	3,424.4	0.0	3,424.4	105,900.0	362.6	0.43	0.2	0.7
07/20/2023 09:00	3,474.1	0.0	3,474.1	105,900.0	367.9	0.44	0.2	0.7
07/20/2023 10:00	3,719.3	0.0	3,719.3	105,900.0	393.9	0.47	0.2	0.8
07/20/2023 11:00	4,023.7	0.0	4,023.7	105,900.0	426.1	0.51	0.3	0.9
07/20/2023 12:00	4,279.8	0.0	4,279.8	105,900.0	453.2	0.54	0.3	0.9
07/20/2023 13:00	4,270.8	0.0	4,270.8	105,900.0	452.3	0.54	0.3	0.9
07/20/2023 14:00	4,249.2	0.0	4,249.2	105,900.0	450.0	0.54	0.3	0.9
07/20/2023 15:00	4,240.4	1,126.5	5,141.6	105,900.0	544.5	0.68	0.3	1.1
07/20/2023 16:00	4,244.4	1,631.0	5,875.4	105,900.0	622.2	0.75	0.4	1.2
07/20/2023 17:00	4,235.0	1,601.8	5,836.8	105,900.0	618.1	0.74	0.4	1.2
07/20/2023 18:00	4,225.0	1,819.9	6,044.9	105,900.0	640.2	0.77	0.4	1.3
07/20/2023 19:00	4,217.4	1,994.9	6,212.3	105,900.0	657.9	0.79	0.4	1.3
07/20/2023 20:00	4,217.6	1,609.8	5,827.4	105,900.0	617.1	0.74	0.4	1.2
07/20/2023 21:00	4,246.3	1,340.6	5,586.9	105,900.0	591.7	0.71	0.4	1.2
07/20/2023 22:00	4,260.8	971.8	5,232.6	105,900.0	554.1	0.67	0.3	1.1
07/20/2023 23:00	4,123.0	415.7	4,372.4	105,900.0	463.0	0.58	0.3	1.0
Average/Sum#:	4,108.5	524.0	4,614.9	105,900.0	488.7	0.59	0.3	1.0
Minimum:	3,424.4	0.0	3,424.4	105,900.0	362.6	0.43	0.2	0.7
Maximum:	4,301.0	1,994.9	6,212.3	105,900.0	657.9	0.79	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2023 00:00	4,204.3	0.0	4,204.3	105,900.0	445.2	0.53	0.3	0.9
07/21/2023 01:00	4,203.3	0.0	4,203.3	105,900.0	445.1	0.54	0.3	0.9
07/21/2023 02:00	4,006.6	0.0	4,006.6	105,900.0	424.3	0.51	0.3	0.8
07/21/2023 03:00	3,909.1	0.0	3,909.1	105,900.0	414.0	0.50	0.2	0.8
07/21/2023 04:00	3,993.0	0.0	3,993.0	105,900.0	422.9	0.51	0.3	0.8
07/21/2023 05:00	3,956.8	0.0	3,956.8	105,900.0	419.0	0.50	0.3	0.8
07/21/2023 06:00	3,980.9	0.0	3,980.9	105,900.0	421.6	0.50	0.3	0.8
07/21/2023 07:00	3,491.9	0.0	3,491.9	105,900.0	369.8	0.44	0.2	0.7
07/21/2023 08:00	3,420.3	0.0	3,420.3	105,900.0	362.2	0.43	0.2	0.7
07/21/2023 09:00	3,414.8	0.0	3,414.8	105,900.0	361.6	0.43	0.2	0.7
07/21/2023 10:00	3,410.7	0.0	3,410.7	105,900.0	361.2	0.43	0.2	0.7
07/21/2023 11:00	3,784.5	12.6	3,785.4	105,900.0	400.9	0.48	0.2	0.8
07/21/2023 12:00	3,757.5	0.0	3,757.5	105,900.0	397.9	0.48	0.2	0.8
07/21/2023 13:00	4,116.3	0.0	4,116.3	105,900.0	435.9	0.52	0.3	0.9
07/21/2023 14:00	4,209.7	491.4	4,440.7	105,900.0	470.3	0.60	0.3	1.0
07/21/2023 15:00	4,193.7	1,402.7	5,596.4	105,900.0	592.7	0.71	0.4	1.2
07/21/2023 16:00	4,174.7	1,090.6	5,265.3	105,900.0	557.6	0.67	0.3	1.1
07/21/2023 17:00	4,149.3	814.4	4,963.7	105,900.0	525.7	0.63	0.3	1.1
07/21/2023 18:00	4,126.7	1,102.5	5,229.2	105,900.0	553.8	0.66	0.3	1.1
07/21/2023 19:00	4,118.9	1,889.3	6,008.2	105,900.0	636.3	0.76	0.4	1.3
07/21/2023 20:00	4,169.8	1,291.7	5,461.5	105,900.0	578.4	0.69	0.3	1.2
07/21/2023 21:00	4,184.8	736.3	4,921.1	105,900.0	521.1	0.63	0.3	1.0
07/21/2023 22:00	4,189.8	856.5	5,046.3	105,900.0	534.4	0.64	0.3	1.1
07/21/2023 23:00	4,205.4	693.6	4,899.0	105,900.0	518.8	0.62	0.3	1.0
Average/Sum#:	3,973.9	432.6	4,395.1	105,900.0	465.4	0.56	0.3	0.9
Minimum:	3,410.7	0.0	3,410.7	105,900.0	361.2	0.43	0.2	0.7
Maximum:	4,209.7	1,889.3	6,008.2	105,900.0	636.3	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2023 00:00	4,159.6	4.8	4,159.7	105,900.0	440.5	0.53	0.3	0.9
07/22/2023 01:00	3,960.3	0.0	3,960.3	105,900.0	419.4	0.50	0.3	0.8
07/22/2023 02:00	3,565.9	0.0	3,565.9	105,900.0	377.6	0.45	0.2	0.8
07/22/2023 03:00	3,584.3	0.0	3,584.3	105,900.0	379.6	0.46	0.2	0.8
07/22/2023 04:00	3,418.5	0.0	3,418.5	105,900.0	362.0	0.43	0.2	0.7
07/22/2023 05:00	3,591.3	0.0	3,591.3	105,900.0	380.3	0.46	0.2	0.8
07/22/2023 06:00	3,593.9	0.0	3,593.9	105,900.0	380.6	0.46	0.2	0.8
07/22/2023 07:00	3,392.5	0.0	3,392.5	105,900.0	359.3	0.43	0.2	0.7
07/22/2023 08:00	3,403.8	0.0	3,403.8	105,900.0	360.5	0.43	0.2	0.7
07/22/2023 09:00	3,395.2	0.0	3,395.2	105,900.0	359.6	0.43	0.2	0.7
07/22/2023 10:00	3,390.7	0.0	3,390.7	105,900.0	359.1	0.43	0.2	0.7
07/22/2023 11:00	3,444.1	0.0	3,444.1	105,900.0	364.7	0.44	0.2	0.7
07/22/2023 12:00	3,702.6	0.0	3,702.6	105,900.0	392.1	0.47	0.2	0.8
07/22/2023 13:00	3,760.1	0.0	3,760.1	105,900.0	398.2	0.48	0.2	0.8
07/22/2023 14:00	4,150.0	0.0	4,150.0	105,900.0	439.5	0.53	0.3	0.9
07/22/2023 15:00	4,100.2	0.0	4,100.2	105,900.0	434.2	0.52	0.3	0.9
07/22/2023 16:00	4,127.6	0.0	4,127.6	105,900.0	437.1	0.52	0.3	0.9
07/22/2023 17:00	4,112.8	970.4	4,908.5	105,900.0	519.8	0.65	0.3	1.1
07/22/2023 18:00	4,097.8	1,601.3	5,699.1	105,900.0	603.5	0.72	0.4	1.2
07/22/2023 19:00	4,115.9	1,876.8	5,992.7	105,900.0	634.6	0.76	0.4	1.3
07/22/2023 20:00	4,164.5	1,079.7	5,244.2	105,900.0	555.4	0.67	0.3	1.1
07/22/2023 21:00	4,173.8	1,021.0	5,194.8	105,900.0	550.1	0.66	0.3	1.1
07/22/2023 22:00	4,187.7	900.1	5,087.8	105,900.0	538.8	0.65	0.3	1.1
07/22/2023 23:00	4,131.0	170.0	4,227.9	105,900.0	447.7	0.55	0.3	0.9
Average/Sum#:	3,821.8	317.7	4,129.0	105,900.0	437.3	0.53	0.3	0.9
Minimum:	3,390.7	0.0	3,390.7	105,900.0	359.1	0.43	0.2	0.7
Maximum:	4,187.7	1,876.8	5,992.7	105,900.0	634.6	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2023 00:00	4,195.9	1.8	4,195.9	105,900.0	444.3	0.53	0.3	0.9
07/23/2023 01:00	4,209.7	0.0	4,209.7	105,900.0	445.8	0.54	0.3	0.9
07/23/2023 02:00	4,203.1	0.0	4,203.1	105,900.0	445.1	0.53	0.3	0.9
07/23/2023 03:00	4,210.0	0.0	4,210.0	105,900.0	445.8	0.53	0.3	0.9
07/23/2023 04:00	4,193.6	0.0	4,193.6	105,900.0	444.1	0.53	0.3	0.9
07/23/2023 05:00	4,008.1	0.0	4,008.1	105,900.0	424.5	0.51	0.3	0.8
07/23/2023 06:00	3,849.7	0.0	3,849.7	105,900.0	407.7	0.49	0.2	0.8
07/23/2023 07:00	3,439.5	0.0	3,439.5	105,900.0	364.2	0.44	0.2	0.7
07/23/2023 08:00	3,857.2	0.0	3,857.2	105,900.0	408.5	0.49	0.2	0.8
07/23/2023 09:00	4,224.0	0.0	4,224.0	105,900.0	447.3	0.54	0.3	0.9
07/23/2023 10:00	4,227.7	0.0	4,227.7	105,900.0	447.7	0.54	0.3	0.9
07/23/2023 11:00	4,226.7	0.0	4,226.7	105,900.0	447.6	0.54	0.3	0.9
07/23/2023 12:00	4,232.7	473.9	4,455.4	105,900.0	471.8	0.60	0.3	1.0
07/23/2023 13:00	4,221.8	819.8	5,041.6	105,900.0	533.9	0.64	0.3	1.1
07/23/2023 14:00	4,189.4	384.3	4,393.1	105,900.0	465.2	0.58	0.3	1.0
07/23/2023 15:00	4,139.1	0.0	4,139.1	105,900.0	438.3	0.53	0.3	0.9
07/23/2023 16:00	4,170.6	239.5	4,249.6	105,900.0	450.0	0.56	0.3	0.9
07/23/2023 17:00	4,162.1	1,854.2	6,016.3	105,900.0	637.1	0.76	0.4	1.3
07/23/2023 18:00	3,989.7	1,003.0	4,992.7	105,900.0	528.7	0.64	0.3	1.1
07/23/2023 19:00	4,048.2	0.0	4,048.2	105,900.0	428.7	0.51	0.3	0.9
07/23/2023 20:00	3,938.4	0.0	3,938.4	105,900.0	417.1	0.50	0.3	0.8
07/23/2023 21:00	4,052.5	0.0	4,052.5	105,900.0	429.2	0.51	0.3	0.9
07/23/2023 22:00	3,984.9	0.0	3,984.9	105,900.0	422.0	0.51	0.3	0.8
07/23/2023 23:00	3,811.1	0.0	3,811.1	105,900.0	403.6	0.48	0.2	0.8
Average/Sum#:	4,074.4	199.0	4,248.7	105,900.0	449.9	0.54	0.3	0.9
Minimum:	3,439.5	0.0	3,439.5	105,900.0	364.2	0.44	0.2	0.7
Maximum:	4,232.7	1,854.2	6,016.3	105,900.0	637.1	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2023 00:00	4,258.9	0.0	4,258.9	105,900.0	451.0	0.54	0.3	0.9
07/24/2023 01:00	4,180.4	0.0	4,180.4	105,900.0	442.7	0.53	0.3	0.9
07/24/2023 02:00	4,002.1	0.0	4,002.1	105,900.0	423.8	0.51	0.3	0.8
07/24/2023 03:00	4,056.0	0.0	4,056.0	105,900.0	429.5	0.51	0.3	0.9
07/24/2023 04:00	4,195.7	0.0	4,195.7	105,900.0	444.3	0.53	0.3	0.9
07/24/2023 05:00	4,194.9	0.0	4,194.9	105,900.0	444.2	0.53	0.3	0.9
07/24/2023 06:00	4,237.7	0.0	4,237.7	105,900.0	448.8	0.54	0.3	0.9
07/24/2023 07:00	3,689.9	0.0	3,689.9	105,900.0	390.8	0.47	0.2	0.8
07/24/2023 08:00	3,495.3	0.0	3,495.3	105,900.0	370.2	0.44	0.2	0.7
07/24/2023 09:00	3,410.9	0.0	3,410.9	105,900.0	361.2	0.43	0.2	0.7
07/24/2023 10:00	3,443.3	0.0	3,443.3	105,900.0	364.6	0.44	0.2	0.7
07/24/2023 11:00	3,459.5	0.0	3,459.5	105,900.0	366.4	0.44	0.2	0.7
07/24/2023 12:00	3,758.7	0.0	3,758.7	105,900.0	398.0	0.48	0.2	0.8
07/24/2023 13:00	4,263.1	0.0	4,263.1	105,900.0	451.5	0.54	0.3	0.9
07/24/2023 14:00	3,468.4	0.0	3,468.4	105,900.0	367.3	0.44	0.2	0.7
07/24/2023 15:00	3,434.0	0.0	3,434.0	105,900.0	363.7	0.44	0.2	0.7
07/24/2023 16:00	3,410.1	0.0	3,410.1	105,900.0	361.1	0.43	0.2	0.7
07/24/2023 17:00	3,408.3	0.0	3,408.3	105,900.0	360.9	0.43	0.2	0.7
07/24/2023 18:00	3,421.7	0.0	3,421.7	105,900.0	362.4	0.43	0.2	0.7
07/24/2023 19:00	3,488.7	0.0	3,488.7	105,900.0	369.5	0.45	0.2	0.7
07/24/2023 20:00	3,448.8	0.0	3,448.8	105,900.0	365.2	0.44	0.2	0.7
07/24/2023 21:00	3,848.6	0.0	3,848.6	105,900.0	407.6	0.49	0.2	0.8
07/24/2023 22:00	3,824.3	0.0	3,824.3	105,900.0	405.0	0.49	0.2	0.8
07/24/2023 23:00	3,970.2	0.0	3,970.2	105,900.0	420.4	0.51	0.3	0.8
Average/Sum#:	3,765.4	0.0	3,765.4	105,900.0	398.8	0.48	0.2	0.8
Minimum:	3,408.3	0.0	3,408.3	105,900.0	360.9	0.43	0.2	0.7
Maximum:	4,263.1	0.0	4,263.1	105,900.0	451.5	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2023 00:00	3,735.7	0.0	3,735.7	105,900.0	395.6	0.47	0.2	0.8
07/25/2023 01:00	3,425.7	0.0	3,425.7	105,900.0	362.8	0.43	0.2	0.7
07/25/2023 02:00	3,398.7	0.0	3,398.7	105,900.0	359.9	0.43	0.2	0.7
07/25/2023 03:00	3,398.5	0.0	3,398.5	105,900.0	359.9	0.43	0.2	0.7
07/25/2023 04:00	3,399.7	0.0	3,399.7	105,900.0	360.0	0.43	0.2	0.7
07/25/2023 05:00	3,657.0	0.0	3,657.0	105,900.0	387.3	0.47	0.2	0.8
07/25/2023 06:00	3,727.4	0.0	3,727.4	105,900.0	394.7	0.47	0.2	0.8
07/25/2023 07:00	3,467.9	0.0	3,467.9	105,900.0	367.3	0.44	0.2	0.7
07/25/2023 08:00	3,606.2	0.0	3,606.2	105,900.0	381.9	0.46	0.2	0.8
07/25/2023 09:00	3,414.5	0.0	3,414.5	105,900.0	361.6	0.43	0.2	0.7
07/25/2023 10:00	3,477.1	0.0	3,477.1	105,900.0	368.2	0.44	0.2	0.7
07/25/2023 11:00	3,418.6	0.0	3,418.6	105,900.0	362.0	0.43	0.2	0.7
07/25/2023 12:00	3,949.2	0.0	3,949.2	105,900.0	418.2	0.50	0.3	0.8
07/25/2023 13:00	4,011.1	0.0	4,011.1	105,900.0	424.8	0.51	0.3	0.8
07/25/2023 14:00	4,219.0	0.0	4,219.0	105,900.0	446.8	0.54	0.3	0.9
07/25/2023 15:00	4,021.5	0.0	4,021.5	105,900.0	425.9	0.51	0.3	0.9
07/25/2023 16:00	4,237.0	294.8	4,378.5	105,900.0	463.7	0.58	0.3	1.0
07/25/2023 17:00	4,256.8	875.4	5,132.2	105,900.0	543.5	0.65	0.3	1.1
07/25/2023 18:00	4,256.8	979.8	5,236.6	105,900.0	554.6	0.66	0.3	1.1
07/25/2023 19:00	4,256.4	1,838.4	6,094.8	105,900.0	645.4	0.77	0.4	1.3
07/25/2023 20:00	4,269.6	1,414.5	5,684.1	105,900.0	601.9	0.72	0.4	1.2
07/25/2023 21:00	4,294.0	793.3	5,087.3	105,900.0	538.7	0.65	0.3	1.1
07/25/2023 22:00	4,274.6	647.4	4,922.0	105,900.0	521.2	0.63	0.3	1.0
07/25/2023 23:00	4,153.5	2.3	4,153.5	105,900.0	439.9	0.53	0.3	0.9
Average/Sum#:	3,846.9	285.2	4,125.7	105,900.0	436.9	0.52	0.3	0.9
Minimum:	3,398.5	0.0	3,398.5	105,900.0	359.9	0.43	0.2	0.7
Maximum:	4,294.0	1,838.4	6,094.8	105,900.0	645.4	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2023 00:00	4,315.7	0.0	4,315.7	105,900.0	457.0	0.55	0.3	0.9
07/26/2023 01:00	4,027.8	0.0	4,027.8	105,900.0	426.5	0.51	0.3	0.9
07/26/2023 02:00	4,067.4	0.0	4,067.4	105,900.0	430.7	0.52	0.3	0.9
07/26/2023 03:00	4,106.8	0.0	4,106.8	105,900.0	434.9	0.52	0.3	0.9
07/26/2023 04:00	4,101.1	0.0	4,101.1	105,900.0	434.3	0.52	0.3	0.9
07/26/2023 05:00	4,283.0	0.0	4,283.0	105,900.0	453.6	0.55	0.3	0.9
07/26/2023 06:00	4,234.1	0.0	4,234.1	105,900.0	448.4	0.54	0.3	0.9
07/26/2023 07:00	3,938.2	0.0	3,938.2	105,900.0	417.1	0.50	0.3	0.8
07/26/2023 08:00	3,898.3	0.0	3,898.3	105,900.0	412.8	0.50	0.2	0.8
07/26/2023 09:00	4,147.2	0.0	4,147.2	105,900.0	439.2	0.53	0.3	0.9
07/26/2023 10:00	4,217.8	0.0	4,217.8	105,900.0	446.7	0.54	0.3	0.9
07/26/2023 11:00	4,301.1	0.0	4,301.1	105,900.0	455.5	0.55	0.3	0.9
07/26/2023 12:00	4,233.4	128.5	4,263.0	105,900.0	451.5	0.55	0.3	0.9
07/26/2023 13:00	4,278.0	1,707.7	5,985.7	105,900.0	633.9	0.76	0.4	1.3
07/26/2023 14:00	4,265.5	1,739.2	6,004.7	105,900.0	635.9	0.76	0.4	1.3
07/26/2023 15:00	4,263.6	1,550.3	5,813.9	105,900.0	615.7	0.74	0.4	1.2
07/26/2023 16:00	4,252.9	1,633.0	5,885.9	105,900.0	623.3	0.75	0.4	1.2
07/26/2023 17:00	4,269.5	1,627.9	5,897.4	105,900.0	624.5	0.75	0.4	1.2
07/26/2023 18:00	4,271.0	1,011.6	5,282.6	105,900.0	559.4	0.67	0.3	1.1
07/26/2023 19:00	4,274.7	1,512.9	5,787.6	105,900.0	612.9	0.74	0.4	1.2
07/26/2023 20:00	4,287.2	609.1	4,896.3	105,900.0	518.5	0.62	0.3	1.0
07/26/2023 21:00	4,310.5	792.7	5,103.2	105,900.0	540.4	0.65	0.3	1.1
07/26/2023 22:00	4,331.2	1,369.8	5,701.0	105,900.0	603.7	0.73	0.4	1.2
07/26/2023 23:00	4,352.6	890.2	5,242.8	105,900.0	555.2	0.67	0.3	1.1
Average/Sum#:	4,209.5	607.2	4,812.6	105,900.0	509.7	0.61	0.3	1.0
Minimum:	3,898.3	0.0	3,898.3	105,900.0	412.8	0.50	0.2	0.8
Maximum:	4,352.6	1,739.2	6,004.7	105,900.0	635.9	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2023 00:00	4,363.9	1,562.1	5,926.0	105,900.0	627.6	0.75	0.4	1.3
07/27/2023 01:00	4,296.0	323.5	4,464.2	105,900.0	472.8	0.59	0.3	1.0
07/27/2023 02:00	3,998.4	0.0	3,998.4	105,900.0	423.4	0.51	0.3	0.8
07/27/2023 03:00	3,669.4	0.0	3,669.4	105,900.0	388.6	0.47	0.2	0.8
07/27/2023 04:00	4,280.7	0.0	4,280.7	105,900.0	453.3	0.54	0.3	0.9
07/27/2023 05:00	4,355.2	0.0	4,355.2	105,900.0	461.2	0.55	0.3	0.9
07/27/2023 06:00	4,321.8	0.0	4,321.8	105,900.0	457.7	0.55	0.3	0.9
07/27/2023 07:00	3,536.2	0.0	3,536.2	105,900.0	374.5	0.45	0.2	0.7
07/27/2023 08:00	3,410.5	0.0	3,410.5	105,900.0	361.2	0.43	0.2	0.7
07/27/2023 09:00	3,402.3	0.0	3,402.3	105,900.0	360.3	0.43	0.2	0.7
07/27/2023 10:00	3,402.3	0.0	3,402.3	105,900.0	360.3	0.43	0.2	0.7
07/27/2023 11:00	3,515.0	0.0	3,515.0	105,900.0	372.2	0.44	0.2	0.7
07/27/2023 12:00	4,160.6	0.0	4,160.6	105,900.0	440.6	0.53	0.3	0.9
07/27/2023 13:00	4,212.7	0.0	4,212.7	105,900.0	446.1	0.54	0.3	0.9
07/27/2023 14:00	4,080.6	0.0	4,080.6	105,900.0	432.1	0.52	0.3	0.9
07/27/2023 15:00	4,002.4	0.0	4,002.4	105,900.0	423.9	0.51	0.3	0.8
07/27/2023 16:00	4,274.3	468.3	4,639.6	105,900.0	491.3	0.60	0.3	1.0
07/27/2023 17:00	4,297.2	593.9	4,891.1	105,900.0	518.0	0.62	0.3	1.0
07/27/2023 18:00	3,602.1	2.5	3,602.2	105,900.0	381.5	0.46	0.2	0.8
07/27/2023 19:00	3,428.4	0.0	3,428.4	105,900.0	363.1	0.44	0.2	0.7
07/27/2023 20:00	3,463.8	0.0	3,463.8	105,900.0	366.8	0.44	0.2	0.7
07/27/2023 21:00	3,395.8	0.0	3,395.8	105,900.0	359.6	0.43	0.2	0.7
07/27/2023 22:00	3,906.7	0.0	3,906.7	105,900.0	413.7	0.50	0.2	0.8
07/27/2023 23:00	4,130.0	0.0	4,130.0	105,900.0	437.4	0.53	0.3	0.9
Average/Sum#:	3,896.1	122.9	4,008.2	105,900.0	424.5	0.51	0.3	0.8
Minimum:	3,395.8	0.0	3,395.8	105,900.0	359.6	0.43	0.2	0.7
Maximum:	4,363.9	1,562.1	5,926.0	105,900.0	627.6	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2023 00:00	3,864.8	0.0	3,864.8	105,900.0	409.3	0.49	0.2	0.8
07/28/2023 01:00	4,052.1	0.0	4,052.1	105,900.0	429.1	0.52	0.3	0.9
07/28/2023 02:00	3,896.0	0.0	3,896.0	105,900.0	412.6	0.50	0.2	0.8
07/28/2023 03:00	3,835.8	0.0	3,835.8	105,900.0	406.2	0.49	0.2	0.8
07/28/2023 04:00	3,785.8	0.0	3,785.8	105,900.0	400.9	0.48	0.2	0.8
07/28/2023 05:00	3,975.8	0.0	3,975.8	105,900.0	421.0	0.50	0.3	0.8
07/28/2023 06:00	3,907.5	0.0	3,907.5	105,900.0	413.8	0.50	0.2	0.8
07/28/2023 07:00	3,555.6	0.0	3,555.6	105,900.0	376.5	0.45	0.2	0.8
07/28/2023 08:00	3,416.0	0.0	3,416.0	105,900.0	361.8	0.43	0.2	0.7
07/28/2023 09:00	3,406.2	0.0	3,406.2	105,900.0	360.7	0.43	0.2	0.7
07/28/2023 10:00	3,406.9	0.0	3,406.9	105,900.0	360.8	0.43	0.2	0.7
07/28/2023 11:00	3,405.4	0.0	3,405.4	105,900.0	360.6	0.43	0.2	0.7
07/28/2023 12:00	3,445.4	0.0	3,445.4	105,900.0	364.9	0.43	0.2	0.7
07/28/2023 13:00	4,082.9	0.0	4,082.9	105,900.0	432.4	0.52	0.3	0.9
07/28/2023 14:00	3,441.7	0.0	3,441.7	105,900.0	364.5	0.44	0.2	0.7
07/28/2023 15:00	3,878.5	153.5	3,921.5	105,900.0	415.3	0.51	0.3	0.9
07/28/2023 16:00	4,264.0	587.3	4,851.3	105,900.0	513.8	0.62	0.3	1.0
07/28/2023 17:00	4,270.6	572.8	4,843.4	105,900.0	512.9	0.62	0.3	1.0
07/28/2023 18:00	4,271.7	566.9	4,838.6	105,900.0	512.4	0.62	0.3	1.0
07/28/2023 19:00	4,282.9	522.5	4,805.4	105,900.0	508.9	0.61	0.3	1.0
07/28/2023 20:00	3,550.6	2.2	3,550.6	105,900.0	376.0	0.45	0.2	0.8
07/28/2023 21:00	3,580.8	0.0	3,580.8	105,900.0	379.2	0.46	0.2	0.8
07/28/2023 22:00	3,886.9	0.0	3,886.9	105,900.0	411.6	0.49	0.2	0.8
07/28/2023 23:00	4,111.1	0.0	4,111.1	105,900.0	435.4	0.52	0.3	0.9
Average/Sum#:	3,815.6	100.2	3,911.1	105,900.0	414.2	0.50	0.2	0.8
Minimum:	3,405.4	0.0	3,405.4	105,900.0	360.6	0.43	0.2	0.7
Maximum:	4,282.9	587.3	4,851.3	105,900.0	513.8	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2023 00:00	4,114.6	0.0	4,114.6	105,900.0	435.7	0.52	0.3	0.9
07/29/2023 01:00	3,502.1	0.0	3,502.1	105,900.0	370.9	0.44	0.2	0.7
07/29/2023 02:00	3,498.7	0.0	3,498.7	105,900.0	370.5	0.44	0.2	0.7
07/29/2023 03:00	3,505.6	0.0	3,505.6	105,900.0	371.2	0.44	0.2	0.7
07/29/2023 04:00	3,400.3	0.0	3,400.3	105,900.0	360.1	0.43	0.2	0.7
07/29/2023 05:00	3,415.3	0.0	3,415.3	105,900.0	361.7	0.43	0.2	0.7
07/29/2023 06:00	3,470.4	0.0	3,470.4	105,900.0	367.5	0.44	0.2	0.7
07/29/2023 07:00	3,405.9	0.0	3,405.9	105,900.0	360.7	0.43	0.2	0.7
07/29/2023 08:00	3,413.6	0.0	3,413.6	105,900.0	361.5	0.43	0.2	0.7
07/29/2023 09:00	3,401.7	0.0	3,401.7	105,900.0	360.2	0.43	0.2	0.7
07/29/2023 10:00	3,401.0	0.0	3,401.0	105,900.0	360.2	0.43	0.2	0.7
07/29/2023 11:00	3,397.0	0.0	3,397.0	105,900.0	359.7	0.43	0.2	0.7
07/29/2023 12:00	3,407.9	0.0	3,407.9	105,900.0	360.9	0.43	0.2	0.7
07/29/2023 13:00	3,411.6	0.0	3,411.6	105,900.0	361.3	0.43	0.2	0.7
07/29/2023 14:00	3,411.0	0.0	3,411.0	105,900.0	361.2	0.43	0.2	0.7
07/29/2023 15:00	3,407.2	0.0	3,407.2	105,900.0	360.8	0.43	0.2	0.7
07/29/2023 16:00	3,432.1	0.0	3,432.1	105,900.0	363.5	0.43	0.2	0.7
07/29/2023 17:00	3,403.2	0.0	3,403.2	105,900.0	360.4	0.43	0.2	0.7
07/29/2023 18:00	3,406.7	0.0	3,406.7	105,900.0	360.8	0.43	0.2	0.7
07/29/2023 19:00	3,405.9	0.0	3,405.9	105,900.0	360.7	0.43	0.2	0.7
07/29/2023 20:00	3,396.3	0.0	3,396.3	105,900.0	359.7	0.43	0.2	0.7
07/29/2023 21:00	3,395.3	0.0	3,395.3	105,900.0	359.6	0.43	0.2	0.7
07/29/2023 22:00	3,400.9	0.0	3,400.9	105,900.0	360.2	0.43	0.2	0.7
07/29/2023 23:00	3,523.2	0.0	3,523.2	105,900.0	373.1	0.45	0.2	0.7
Average/Sum#:	3,455.3	0.0	3,455.3	105,900.0	365.9	0.44	0.2	0.7
Minimum:	3,395.3	0.0	3,395.3	105,900.0	359.6	0.43	0.2	0.7
Maximum:	4,114.6	0.0	4,114.6	105,900.0	435.7	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2023 00:00	3,401.3	0.0	3,401.3	105,900.0	360.2	0.43	0.2	0.7
07/30/2023 01:00	3,401.8	0.0	3,401.8	105,900.0	360.3	0.43	0.2	0.7
07/30/2023 02:00	3,401.5	0.0	3,401.5	105,900.0	360.2	0.43	0.2	0.7
07/30/2023 03:00	3,400.1	0.0	3,400.1	105,900.0	360.1	0.43	0.2	0.7
07/30/2023 04:00	3,405.6	0.0	3,405.6	105,900.0	360.7	0.43	0.2	0.7
07/30/2023 05:00	3,457.5	0.0	3,457.5	105,900.0	366.1	0.44	0.2	0.7
07/30/2023 06:00	3,403.5	0.0	3,403.5	105,900.0	360.4	0.43	0.2	0.7
07/30/2023 07:00	3,411.6	0.0	3,411.6	105,900.0	361.3	0.43	0.2	0.7
07/30/2023 08:00	3,416.2	0.0	3,416.2	105,900.0	361.8	0.43	0.2	0.7
07/30/2023 09:00	3,405.2	0.0	3,405.2	105,900.0	360.6	0.43	0.2	0.7
07/30/2023 10:00	3,406.4	0.0	3,406.4	105,900.0	360.7	0.43	0.2	0.7
07/30/2023 11:00	3,403.2	0.0	3,403.2	105,900.0	360.4	0.43	0.2	0.7
07/30/2023 12:00	3,409.7	0.0	3,409.7	105,900.0	361.1	0.43	0.2	0.7
07/30/2023 13:00	3,410.9	0.0	3,410.9	105,900.0	361.2	0.43	0.2	0.7
07/30/2023 14:00	3,471.9	0.0	3,471.9	105,900.0	367.7	0.44	0.2	0.7
07/30/2023 15:00	3,409.1	0.0	3,409.1	105,900.0	361.0	0.43	0.2	0.7
07/30/2023 16:00	3,408.5	0.0	3,408.5	105,900.0	361.0	0.43	0.2	0.7
07/30/2023 17:00	3,506.4	0.0	3,506.4	105,900.0	371.3	0.44	0.2	0.7
07/30/2023 18:00	3,468.5	0.0	3,468.5	105,900.0	367.3	0.44	0.2	0.7
07/30/2023 19:00	3,405.3	0.0	3,405.3	105,900.0	360.6	0.43	0.2	0.7
07/30/2023 20:00	3,387.0	0.0	3,387.0	105,900.0	358.7	0.43	0.2	0.7
07/30/2023 21:00	3,411.7	0.0	3,411.7	105,900.0	361.3	0.43	0.2	0.7
07/30/2023 22:00	3,389.5	0.0	3,389.5	105,900.0	358.9	0.43	0.2	0.7
07/30/2023 23:00	3,390.9	0.0	3,390.9	105,900.0	359.1	0.43	0.2	0.7
Average/Sum#:	3,416.0	0.0	3,416.0	105,900.0	361.8	0.43	0.2	0.7
Minimum:	3,387.0	0.0	3,387.0	105,900.0	358.7	0.43	0.2	0.7
Maximum:	3,506.4	0.0	3,506.4	105,900.0	371.3	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2023 00:00	3,553.1	0.0	3,553.1	105,900.0	376.3	0.45	0.2	0.8
07/31/2023 01:00	3,396.5	0.0	3,396.5	105,900.0	359.7	0.43	0.2	0.7
07/31/2023 02:00	3,431.6	0.0	3,431.6	105,900.0	363.4	0.43	0.2	0.7
07/31/2023 03:00	3,391.7	0.0	3,391.7	105,900.0	359.2	0.43	0.2	0.7
07/31/2023 04:00	3,440.2	0.0	3,440.2	105,900.0	364.3	0.44	0.2	0.7
07/31/2023 05:00	3,598.3	0.0	3,598.3	105,900.0	381.1	0.46	0.2	0.8
07/31/2023 06:00	4,019.0	0.0	4,019.0	105,900.0	425.6	0.51	0.3	0.9
07/31/2023 07:00	3,477.0	0.0	3,477.0	105,900.0	368.2	0.44	0.2	0.7
07/31/2023 08:00	3,412.8	0.0	3,412.8	105,900.0	361.4	0.43	0.2	0.7
07/31/2023 09:00	3,404.1	0.0	3,404.1	105,900.0	360.5	0.43	0.2	0.7
07/31/2023 10:00	3,556.2	0.0	3,556.2	105,900.0	376.6	0.45	0.2	0.8
07/31/2023 11:00	4,346.7	0.0	4,346.7	105,900.0	460.3	0.55	0.3	0.9
07/31/2023 12:00	4,317.0	0.3	4,317.0	105,900.0	457.2	0.55	0.3	0.9
07/31/2023 13:00	4,300.0	1,356.7	5,656.7	105,900.0	599.0	0.72	0.4	1.2
07/31/2023 14:00	4,286.0	1,319.3	5,605.3	105,900.0	593.6	0.71	0.4	1.2
07/31/2023 15:00	4,278.8	1,135.3	5,414.1	105,900.0	573.4	0.69	0.3	1.1
07/31/2023 16:00	4,269.4	1,078.9	5,348.3	105,900.0	566.4	0.68	0.3	1.1
07/31/2023 17:00	4,263.3	742.5	5,005.8	105,900.0	530.1	0.64	0.3	1.1
07/31/2023 18:00	4,264.0	603.0	4,867.0	105,900.0	515.4	0.62	0.3	1.0
07/31/2023 19:00	4,283.0	660.6	4,943.6	105,900.0	523.5	0.63	0.3	1.0
07/31/2023 20:00	4,313.5	557.9	4,871.4	105,900.0	515.9	0.62	0.3	1.0
07/31/2023 21:00	4,267.0	377.0	4,557.3	105,900.0	482.6	0.59	0.3	1.0
07/31/2023 22:00	3,890.3	0.0	3,890.3	105,900.0	412.0	0.49	0.2	0.8
07/31/2023 23:00	4,173.0	0.0	4,173.0	105,900.0	441.9	0.53	0.3	0.9
Average/Sum#:	3,913.9	326.3	4,236.5	105,900.0	448.7	0.54	0.3	0.9
Minimum:	3,391.7	0.0	3,391.7	105,900.0	359.2	0.43	0.2	0.7
Maximum:	4,346.7	1,356.7	5,656.7	105,900.0	599.0	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2023 00:00	3,980.4	0.0	3,980.4	101,950.0	405.8	0.49	0.2	0.8
08/01/2023 01:00	3,768.7	0.0	3,768.7	101,950.0	384.2	0.46	0.2	0.8
08/01/2023 02:00	3,907.9	0.0	3,907.9	101,950.0	398.4	0.48	0.2	0.8
08/01/2023 03:00	3,852.5	0.0	3,852.5	101,950.0	392.8	0.47	0.2	0.8
08/01/2023 04:00	3,885.3	0.0	3,885.3	101,950.0	396.1	0.48	0.2	0.8
08/01/2023 05:00	4,156.3	0.0	4,156.3	101,950.0	423.7	0.51	0.3	0.8
08/01/2023 06:00	4,248.8	0.0	4,248.8	101,950.0	433.2	0.52	0.3	0.9
08/01/2023 07:00	3,839.8	0.0	3,839.8	101,950.0	391.5	0.47	0.2	0.8
08/01/2023 08:00	3,521.0	0.0	3,521.0	101,950.0	359.0	0.43	0.2	0.7
08/01/2023 09:00	4,097.5	0.0	4,097.5	101,950.0	417.7	0.50	0.3	0.8
08/01/2023 10:00	3,849.8	0.0	3,849.8	101,950.0	392.5	0.47	0.2	0.8
08/01/2023 11:00	4,161.3	0.0	4,161.3	101,950.0	424.2	0.51	0.3	0.8
08/01/2023 12:00	4,177.2	0.0	4,177.2	101,950.0	425.9	0.51	0.3	0.9
08/01/2023 13:00	4,183.3	0.0	4,183.3	101,950.0	426.5	0.51	0.3	0.9
08/01/2023 14:00	4,202.0	0.0	4,202.0	101,950.0	428.4	0.51	0.3	0.9
08/01/2023 15:00	4,105.4	0.0	4,105.4	101,950.0	418.5	0.50	0.3	0.8
08/01/2023 16:00	4,186.8	0.0	4,186.8	101,950.0	426.8	0.51	0.3	0.9
08/01/2023 17:00	4,107.8	0.0	4,107.8	101,950.0	418.8	0.50	0.3	0.8
08/01/2023 18:00	3,863.6	0.0	3,863.6	101,950.0	393.9	0.47	0.2	0.8
08/01/2023 19:00	4,088.8	0.0	4,088.8	101,950.0	416.9	0.50	0.3	0.8
08/01/2023 20:00	4,156.1	0.0	4,156.1	101,950.0	423.7	0.51	0.3	0.8
08/01/2023 21:00	4,128.0	0.0	4,128.0	101,950.0	420.8	0.51	0.3	0.8
08/01/2023 22:00	4,097.2	0.0	4,097.2	101,950.0	417.7	0.50	0.3	0.8
08/01/2023 23:00	3,543.1	0.0	3,543.1	101,950.0	361.2	0.43	0.2	0.7
Average/Sum#:	4,004.5	0.0	4,004.5	101,950.0	408.3	0.49	0.3	0.8
Minimum:	3,521.0	0.0	3,521.0	101,950.0	359.0	0.43	0.2	0.7
Maximum:	4,248.8	0.0	4,248.8	101,950.0	433.2	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2023 00:00	4,043.4	0.0	4,043.4	101,950.0	412.2	0.49	0.2	0.8
08/02/2023 01:00	4,041.9	0.0	4,041.9	101,950.0	412.1	0.49	0.2	0.8
08/02/2023 02:00	3,846.7	0.0	3,846.7	101,950.0	392.2	0.47	0.2	0.8
08/02/2023 03:00	4,082.8	0.0	4,082.8	101,950.0	416.2	0.50	0.2	0.8
08/02/2023 04:00	4,127.2	0.0	4,127.2	101,950.0	420.8	0.50	0.3	0.8
08/02/2023 05:00	4,157.4	0.0	4,157.4	101,950.0	423.8	0.51	0.3	0.8
08/02/2023 06:00	4,147.8	0.0	4,147.8	101,950.0	422.9	0.51	0.3	0.8
08/02/2023 07:00	3,550.1	0.0	3,550.1	101,950.0	361.9	0.44	0.2	0.7
08/02/2023 08:00	3,416.5	0.0	3,416.5	101,950.0	348.3	0.42	0.2	0.7
08/02/2023 09:00	3,408.7	0.0	3,408.7	101,950.0	347.5	0.42	0.2	0.7
08/02/2023 10:00	3,483.6	0.0	3,483.6	101,950.0	355.2	0.43	0.2	0.7
08/02/2023 11:00	3,399.7	0.0	3,399.7	101,950.0	346.6	0.42	0.2	0.7
08/02/2023 12:00	3,421.8	0.0	3,421.8	101,950.0	348.9	0.42	0.2	0.7
08/02/2023 13:00	3,910.5	0.0	3,910.5	101,950.0	398.7	0.48	0.2	0.8
08/02/2023 14:00	3,433.4	0.0	3,433.4	101,950.0	350.0	0.42	0.2	0.7
08/02/2023 15:00	3,427.3	0.0	3,427.3	101,950.0	349.4	0.42	0.2	0.7
08/02/2023 16:00	3,420.0	0.0	3,420.0	101,950.0	348.7	0.42	0.2	0.7
08/02/2023 17:00	3,585.0	0.0	3,585.0	101,950.0	365.5	0.44	0.2	0.7
08/02/2023 18:00	3,435.9	0.0	3,435.9	101,950.0	350.3	0.42	0.2	0.7
08/02/2023 19:00	3,793.3	0.0	3,793.3	101,950.0	386.7	0.47	0.2	0.8
08/02/2023 20:00	3,841.8	0.0	3,841.8	101,950.0	391.7	0.47	0.2	0.8
08/02/2023 21:00	3,835.5	0.0	3,835.5	101,950.0	391.0	0.47	0.2	0.8
08/02/2023 22:00	3,873.5	0.0	3,873.5	101,950.0	394.9	0.47	0.2	0.8
08/02/2023 23:00	3,403.1	0.0	3,403.1	101,950.0	346.9	0.42	0.2	0.7
Average/Sum#:	3,712.0	0.0	3,712.0	101,950.0	378.4	0.46	0.2	0.8
Minimum:	3,399.7	0.0	3,399.7	101,950.0	346.6	0.42	0.2	0.7
Maximum:	4,157.4	0.0	4,157.4	101,950.0	423.8	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2023 00:00	3,831.5	0.0	3,831.5	101,950.0	390.6	0.47	0.2	0.8
08/03/2023 01:00	3,630.2	0.0	3,630.2	101,950.0	370.1	0.45	0.2	0.7
08/03/2023 02:00	3,517.1	0.0	3,517.1	101,950.0	358.6	0.43	0.2	0.7
08/03/2023 03:00	3,585.7	0.0	3,585.7	101,950.0	365.6	0.44	0.2	0.7
08/03/2023 04:00	3,405.9	0.0	3,405.9	101,950.0	347.2	0.42	0.2	0.7
08/03/2023 05:00	3,774.7	0.0	3,774.7	101,950.0	384.8	0.46	0.2	0.8
08/03/2023 06:00	3,875.9	0.0	3,875.9	101,950.0	395.1	0.47	0.2	0.8
08/03/2023 07:00	3,403.6	0.0	3,403.6	101,950.0	347.0	0.42	0.2	0.7
08/03/2023 08:00	3,411.6	0.0	3,411.6	101,950.0	347.8	0.42	0.2	0.7
08/03/2023 09:00	3,403.9	0.0	3,403.9	101,950.0	347.0	0.42	0.2	0.7
08/03/2023 10:00	3,402.9	0.0	3,402.9	101,950.0	346.9	0.42	0.2	0.7
08/03/2023 11:00	3,403.9	0.0	3,403.9	101,950.0	347.0	0.42	0.2	0.7
08/03/2023 12:00	3,413.1	0.0	3,413.1	101,950.0	348.0	0.42	0.2	0.7
08/03/2023 13:00	3,413.1	0.0	3,413.1	101,950.0	348.0	0.42	0.2	0.7
08/03/2023 14:00	3,411.2	0.0	3,411.2	101,950.0	347.8	0.42	0.2	0.7
08/03/2023 15:00	3,409.2	0.0	3,409.2	101,950.0	347.6	0.42	0.2	0.7
08/03/2023 16:00	3,401.1	0.0	3,401.1	101,950.0	346.7	0.42	0.2	0.7
08/03/2023 17:00	3,398.4	0.0	3,398.4	101,950.0	346.5	0.42	0.2	0.7
08/03/2023 18:00	3,479.9	0.0	3,479.9	101,950.0	354.8	0.43	0.2	0.7
08/03/2023 19:00	3,658.1	0.0	3,658.1	101,950.0	372.9	0.45	0.2	0.7
08/03/2023 20:00	3,591.7	0.0	3,591.7	101,950.0	366.2	0.44	0.2	0.7
08/03/2023 21:00	3,580.0	0.0	3,580.0	101,950.0	365.0	0.44	0.2	0.7
08/03/2023 22:00	3,524.1	0.0	3,524.1	101,950.0	359.3	0.43	0.2	0.7
08/03/2023 23:00	3,390.2	0.0	3,390.2	101,950.0	345.6	0.41	0.2	0.7
Average/Sum#:	3,513.2	0.0	3,513.2	101,950.0	358.2	0.43	0.2	0.7
Minimum:	3,390.2	0.0	3,390.2	101,950.0	345.6	0.41	0.2	0.7
Maximum:	3,875.9	0.0	3,875.9	101,950.0	395.1	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2023 00:00	3,392.0	0.0	3,392.0	101,950.0	345.8	0.41	0.2	0.7
08/04/2023 01:00	3,398.0	0.0	3,398.0	101,950.0	346.4	0.42	0.2	0.7
08/04/2023 02:00	3,397.9	0.0	3,397.9	101,950.0	346.4	0.42	0.2	0.7
08/04/2023 03:00	3,397.7	0.0	3,397.7	101,950.0	346.4	0.42	0.2	0.7
08/04/2023 04:00	3,396.0	0.0	3,396.0	101,950.0	346.2	0.42	0.2	0.7
08/04/2023 05:00	3,493.0	0.0	3,493.0	101,950.0	356.1	0.43	0.2	0.7
08/04/2023 06:00	3,556.9	0.0	3,556.9	101,950.0	362.6	0.44	0.2	0.7
08/04/2023 07:00	3,405.0	0.0	3,405.0	101,950.0	347.1	0.42	0.2	0.7
08/04/2023 08:00	3,411.9	0.0	3,411.9	101,950.0	347.8	0.42	0.2	0.7
08/04/2023 09:00	3,401.4	0.0	3,401.4	101,950.0	346.8	0.42	0.2	0.7
08/04/2023 10:00	3,401.1	0.0	3,401.1	101,950.0	346.7	0.42	0.2	0.7
08/04/2023 11:00	3,403.2	0.0	3,403.2	101,950.0	347.0	0.42	0.2	0.7
08/04/2023 12:00	3,411.2	0.0	3,411.2	101,950.0	347.8	0.42	0.2	0.7
08/04/2023 13:00	3,412.2	0.0	3,412.2	101,950.0	347.9	0.42	0.2	0.7
08/04/2023 14:00	3,413.7	0.0	3,413.7	101,950.0	348.0	0.42	0.2	0.7
08/04/2023 15:00	3,409.6	0.0	3,409.6	101,950.0	347.6	0.42	0.2	0.7
08/04/2023 16:00	3,402.4	0.0	3,402.4	101,950.0	346.9	0.42	0.2	0.7
08/04/2023 17:00	3,474.1	0.0	3,474.1	101,950.0	354.2	0.43	0.2	0.7
08/04/2023 18:00	4,100.9	276.0	4,230.6	101,950.0	431.3	0.54	0.3	0.9
08/04/2023 19:00	4,269.2	611.3	4,880.5	101,950.0	497.6	0.60	0.3	1.0
08/04/2023 20:00	4,268.3	588.3	4,856.6	101,950.0	495.1	0.59	0.3	1.0
08/04/2023 21:00	4,250.7	539.3	4,666.0	101,950.0	475.7	0.59	0.3	1.0
08/04/2023 22:00	3,943.7	0.0	3,943.7	101,950.0	402.1	0.48	0.2	0.8
08/04/2023 23:00	3,596.0	0.0	3,596.0	101,950.0	366.6	0.44	0.2	0.7
Average/Sum#:	3,583.6	84.0	3,656.3	101,950.0	372.8	0.45	0.2	0.8
Minimum:	3,392.0	0.0	3,392.0	101,950.0	345.8	0.41	0.2	0.7
Maximum:	4,269.2	611.3	4,880.5	101,950.0	497.6	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2023 00:00	4,091.5	0.0	4,091.5	101,950.0	417.1	0.50	0.3	0.8
08/05/2023 01:00	4,037.4	0.0	4,037.4	101,950.0	411.6	0.49	0.2	0.8
08/05/2023 02:00	4,103.6	0.0	4,103.6	101,950.0	418.4	0.50	0.3	0.8
08/05/2023 03:00	4,077.1	0.0	4,077.1	101,950.0	415.7	0.50	0.2	0.8
08/05/2023 04:00	3,829.9	0.0	3,829.9	101,950.0	390.5	0.47	0.2	0.8
08/05/2023 05:00	3,489.3	0.0	3,489.3	101,950.0	355.7	0.43	0.2	0.7
08/05/2023 06:00	3,607.2	0.0	3,607.2	101,950.0	367.8	0.44	0.2	0.7
08/05/2023 07:00	3,399.0	0.0	3,399.0	101,950.0	346.5	0.42	0.2	0.7
08/05/2023 08:00	3,406.0	0.0	3,406.0	101,950.0	347.2	0.42	0.2	0.7
08/05/2023 09:00	3,397.2	0.0	3,397.2	101,950.0	346.3	0.42	0.2	0.7
08/05/2023 10:00	3,392.0	0.0	3,392.0	101,950.0	345.8	0.41	0.2	0.7
08/05/2023 11:00	3,391.8	0.0	3,391.8	101,950.0	345.8	0.41	0.2	0.7
08/05/2023 12:00	3,402.6	0.0	3,402.6	101,950.0	346.9	0.42	0.2	0.7
08/05/2023 13:00	3,407.5	0.0	3,407.5	101,950.0	347.4	0.42	0.2	0.7
08/05/2023 14:00	3,641.7	8.7	3,642.3	101,950.0	371.3	0.45	0.2	0.7
08/05/2023 15:00	3,786.5	0.0	3,786.5	101,950.0	386.0	0.46	0.2	0.8
08/05/2023 16:00	3,425.5	0.0	3,425.5	101,950.0	349.2	0.42	0.2	0.7
08/05/2023 17:00	3,852.2	134.8	3,881.9	101,950.0	395.8	0.49	0.2	0.8
08/05/2023 18:00	4,219.1	701.7	4,920.8	101,950.0	501.7	0.60	0.3	1.0
08/05/2023 19:00	4,213.0	809.2	5,022.2	101,950.0	512.0	0.61	0.3	1.0
08/05/2023 20:00	4,211.8	678.0	4,889.8	101,950.0	498.5	0.60	0.3	1.0
08/05/2023 21:00	4,180.3	510.2	4,578.3	101,950.0	466.8	0.58	0.3	1.0
08/05/2023 22:00	3,836.7	0.0	3,836.7	101,950.0	391.2	0.47	0.2	0.8
08/05/2023 23:00	3,661.2	0.0	3,661.2	101,950.0	373.3	0.45	0.2	0.7
Average/Sum#:	3,752.5	118.4	3,861.6	101,950.0	393.7	0.47	0.2	0.8
Minimum:	3,391.8	0.0	3,391.8	101,950.0	345.8	0.41	0.2	0.7
Maximum:	4,219.1	809.2	5,022.2	101,950.0	512.0	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2023 00:00	3,746.3	0.0	3,746.3	101,950.0	381.9	0.46	0.2	0.8
08/06/2023 01:00	3,579.5	0.0	3,579.5	101,950.0	364.9	0.44	0.2	0.7
08/06/2023 02:00	3,578.1	0.0	3,578.1	101,950.0	364.8	0.44	0.2	0.7
08/06/2023 03:00	3,407.0	0.0	3,407.0	101,950.0	347.3	0.41	0.2	0.7
08/06/2023 04:00	3,438.6	0.0	3,438.6	101,950.0	350.6	0.42	0.2	0.7
08/06/2023 05:00	3,679.7	0.0	3,679.7	101,950.0	375.1	0.45	0.2	0.8
08/06/2023 06:00	3,625.6	0.0	3,625.6	101,950.0	369.6	0.44	0.2	0.7
08/06/2023 07:00	3,401.5	0.0	3,401.5	101,950.0	346.8	0.42	0.2	0.7
08/06/2023 08:00	3,779.6	0.0	3,779.6	101,950.0	385.3	0.46	0.2	0.8
08/06/2023 09:00	3,381.8	0.0	3,381.8	101,950.0	344.8	0.41	0.2	0.7
08/06/2023 10:00	3,378.4	0.0	3,378.4	101,950.0	344.4	0.41	0.2	0.7
08/06/2023 11:00	3,383.3	0.0	3,383.3	101,950.0	344.9	0.41	0.2	0.7
08/06/2023 12:00	3,652.9	13.8	3,655.0	101,950.0	372.6	0.45	0.2	0.7
08/06/2023 13:00	4,043.0	0.0	4,043.0	101,950.0	412.2	0.49	0.2	0.8
08/06/2023 14:00	4,240.6	0.0	4,240.6	101,950.0	432.3	0.52	0.3	0.9
08/06/2023 15:00	4,197.7	0.0	4,197.7	101,950.0	428.0	0.51	0.3	0.9
08/06/2023 16:00	3,984.4	0.0	3,984.4	101,950.0	406.2	0.49	0.2	0.8
08/06/2023 17:00	4,073.3	184.7	4,125.0	101,950.0	420.5	0.52	0.3	0.9
08/06/2023 18:00	4,220.7	780.6	5,001.3	101,950.0	509.9	0.61	0.3	1.0
08/06/2023 19:00	4,202.7	998.6	5,201.3	101,950.0	530.3	0.64	0.3	1.1
08/06/2023 20:00	4,216.2	1,027.6	5,243.8	101,950.0	534.6	0.64	0.3	1.1
08/06/2023 21:00	4,219.6	693.1	4,753.3	101,950.0	484.6	0.60	0.3	1.0
08/06/2023 22:00	4,077.2	0.0	4,077.2	101,950.0	415.7	0.50	0.2	0.8
08/06/2023 23:00	3,682.9	0.0	3,682.9	101,950.0	375.5	0.45	0.2	0.8
Average/Sum#:	3,799.6	154.1	3,941.0	101,950.0	401.8	0.48	0.2	0.8
Minimum:	3,378.4	0.0	3,378.4	101,950.0	344.4	0.41	0.2	0.7
Maximum:	4,240.6	1,027.6	5,243.8	101,950.0	534.6	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2023 00:00	3,903.7	0.0	3,903.7	101,950.0	398.0	0.48	0.2	0.8
08/07/2023 01:00	3,588.9	0.0	3,588.9	101,950.0	365.9	0.44	0.2	0.7
08/07/2023 02:00	3,449.7	0.0	3,449.7	101,950.0	351.7	0.42	0.2	0.7
08/07/2023 03:00	3,384.6	0.0	3,384.6	101,950.0	345.1	0.41	0.2	0.7
08/07/2023 04:00	3,688.9	0.0	3,688.9	101,950.0	376.1	0.45	0.2	0.8
08/07/2023 05:00	4,113.6	0.0	4,113.6	101,950.0	419.4	0.50	0.3	0.8
08/07/2023 06:00	4,095.5	0.0	4,095.5	101,950.0	417.5	0.50	0.3	0.8
08/07/2023 07:00	3,500.7	0.0	3,500.7	101,950.0	356.9	0.43	0.2	0.7
08/07/2023 08:00	3,415.0	0.0	3,415.0	101,950.0	348.2	0.42	0.2	0.7
08/07/2023 09:00	3,811.9	0.0	3,811.9	101,950.0	388.6	0.47	0.2	0.8
08/07/2023 10:00	3,981.1	29.2	3,986.1	101,950.0	406.4	0.49	0.2	0.8
08/07/2023 11:00	4,153.0	218.2	4,299.2	101,950.0	438.3	0.54	0.3	0.9
08/07/2023 12:00	4,240.5	1,093.7	5,334.2	101,950.0	543.8	0.65	0.3	1.1
08/07/2023 13:00	4,178.0	5.2	4,178.2	101,950.0	426.0	0.51	0.3	0.9
08/07/2023 14:00	4,151.1	20.5	4,153.8	101,950.0	423.5	0.51	0.3	0.9
08/07/2023 15:00	4,184.8	0.0	4,184.8	101,950.0	426.6	0.51	0.3	0.9
08/07/2023 16:00	4,193.3	814.0	4,787.5	101,950.0	488.1	0.61	0.3	1.0
08/07/2023 17:00	4,196.0	992.9	5,188.9	101,950.0	529.0	0.64	0.3	1.1
08/07/2023 18:00	4,200.7	1,041.7	5,242.4	101,950.0	534.5	0.64	0.3	1.1
08/07/2023 19:00	4,222.5	1,568.3	5,790.8	101,950.0	590.4	0.71	0.4	1.2
08/07/2023 20:00	4,236.7	1,000.0	5,236.7	101,950.0	533.9	0.64	0.3	1.1
08/07/2023 21:00	4,260.6	958.2	5,218.8	101,950.0	532.1	0.64	0.3	1.1
08/07/2023 22:00	4,275.8	1,044.4	5,320.2	101,950.0	542.4	0.65	0.3	1.1
08/07/2023 23:00	3,937.8	1.0	3,937.8	101,950.0	401.5	0.48	0.2	0.8
Average/Sum#:	3,973.5	366.1	4,325.5	101,950.0	441.0	0.53	0.3	0.9
Minimum:	3,384.6	0.0	3,384.6	101,950.0	345.1	0.41	0.2	0.7
Maximum:	4,275.8	1,568.3	5,790.8	101,950.0	590.4	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2023 00:00	3,984.8	0.0	3,984.8	101,950.0	406.3	0.49	0.2	0.8
08/08/2023 01:00	3,947.1	0.0	3,947.1	101,950.0	402.4	0.48	0.2	0.8
08/08/2023 02:00	3,846.9	0.0	3,846.9	101,950.0	392.2	0.47	0.2	0.8
08/08/2023 03:00	3,766.6	0.0	3,766.6	101,950.0	384.0	0.46	0.2	0.8
08/08/2023 04:00	3,626.0	0.0	3,626.0	101,950.0	369.7	0.44	0.2	0.7
08/08/2023 05:00	4,020.0	0.0	4,020.0	101,950.0	409.8	0.49	0.2	0.8
08/08/2023 06:00	4,065.2	0.0	4,065.2	101,950.0	414.4	0.50	0.2	0.8
08/08/2023 07:00	3,409.4	0.0	3,409.4	101,950.0	347.6	0.42	0.2	0.7
08/08/2023 08:00	3,416.5	0.0	3,416.5	101,950.0	348.3	0.42	0.2	0.7
08/08/2023 09:00	3,408.0	0.0	3,408.0	101,950.0	347.4	0.42	0.2	0.7
08/08/2023 10:00	3,405.1	0.0	3,405.1	101,950.0	347.1	0.42	0.2	0.7
08/08/2023 11:00	3,406.7	0.0	3,406.7	101,950.0	347.3	0.42	0.2	0.7
08/08/2023 12:00	3,411.7	0.0	3,411.7	101,950.0	347.8	0.42	0.2	0.7
08/08/2023 13:00	3,413.0	0.0	3,413.0	101,950.0	348.0	0.42	0.2	0.7
08/08/2023 14:00	3,506.9	0.0	3,506.9	101,950.0	357.5	0.43	0.2	0.7
08/08/2023 15:00	3,435.6	0.0	3,435.6	101,950.0	350.3	0.42	0.2	0.7
08/08/2023 16:00	3,430.8	0.0	3,430.8	101,950.0	349.8	0.42	0.2	0.7
08/08/2023 17:00	3,479.6	0.0	3,479.6	101,950.0	354.7	0.43	0.2	0.7
08/08/2023 18:00	3,709.0	0.0	3,709.0	101,950.0	378.1	0.45	0.2	0.8
08/08/2023 19:00	4,258.4	0.0	4,258.4	101,950.0	434.1	0.52	0.3	0.9
08/08/2023 20:00	3,781.2	0.0	3,781.2	101,950.0	385.5	0.46	0.2	0.8
08/08/2023 21:00	3,615.4	0.0	3,615.4	101,950.0	368.6	0.44	0.2	0.7
08/08/2023 22:00	3,602.4	0.0	3,602.4	101,950.0	367.3	0.44	0.2	0.7
08/08/2023 23:00	3,403.7	0.0	3,403.7	101,950.0	347.0	0.42	0.2	0.7
Average/Sum#:	3,639.6	0.0	3,639.6	101,950.0	371.1	0.45	0.2	0.7
Minimum:	3,403.7	0.0	3,403.7	101,950.0	347.0	0.42	0.2	0.7
Maximum:	4,258.4	0.0	4,258.4	101,950.0	434.1	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2023 00:00	3,397.5	0.0	3,397.5	101,950.0	346.4	0.42	0.2	0.7
08/09/2023 01:00	3,399.0	0.0	3,399.0	101,950.0	346.5	0.42	0.2	0.7
08/09/2023 02:00	3,400.1	0.0	3,400.1	101,950.0	346.6	0.42	0.2	0.7
08/09/2023 03:00	3,401.3	0.0	3,401.3	101,950.0	346.8	0.42	0.2	0.7
08/09/2023 04:00	3,401.1	0.0	3,401.1	101,950.0	346.7	0.42	0.2	0.7
08/09/2023 05:00	3,447.9	0.0	3,447.9	101,950.0	351.5	0.43	0.2	0.7
08/09/2023 06:00	3,470.9	0.0	3,470.9	101,950.0	353.9	0.43	0.2	0.7
08/09/2023 07:00	3,407.3	0.0	3,407.3	101,950.0	347.4	0.42	0.2	0.7
08/09/2023 08:00	3,411.4	0.0	3,411.4	101,950.0	347.8	0.42	0.2	0.7
08/09/2023 09:00	3,406.4	0.0	3,406.4	101,950.0	347.3	0.42	0.2	0.7
08/09/2023 10:00	3,404.8	0.0	3,404.8	101,950.0	347.1	0.42	0.2	0.7
08/09/2023 11:00	3,404.9	0.0	3,404.9	101,950.0	347.1	0.42	0.2	0.7
08/09/2023 12:00	3,412.8	0.0	3,412.8	101,950.0	347.9	0.42	0.2	0.7
08/09/2023 13:00	3,632.5	0.0	3,632.5	101,950.0	370.3	0.45	0.2	0.7
08/09/2023 14:00	3,745.6	0.0	3,745.6	101,950.0	381.9	0.46	0.2	0.8
08/09/2023 15:00	3,977.1	0.0	3,977.1	101,950.0	405.5	0.49	0.2	0.8
08/09/2023 16:00	4,145.0	0.0	4,145.0	101,950.0	422.6	0.51	0.3	0.8
08/09/2023 17:00	3,805.6	0.0	3,805.6	101,950.0	388.0	0.47	0.2	0.8
08/09/2023 18:00	3,981.1	52.4	3,992.6	101,950.0	407.0	0.50	0.2	0.8
08/09/2023 19:00	4,308.7	537.9	4,846.6	101,950.0	494.1	0.59	0.3	1.0
08/09/2023 20:00	4,121.1	258.3	4,255.4	101,950.0	433.8	0.54	0.3	0.9
08/09/2023 21:00	3,906.2	0.0	3,906.2	101,950.0	398.2	0.48	0.2	0.8
08/09/2023 22:00	3,658.8	0.0	3,658.8	101,950.0	373.0	0.45	0.2	0.7
08/09/2023 23:00	3,388.8	0.0	3,388.8	101,950.0	345.5	0.41	0.2	0.7
Average/Sum#:	3,626.5	35.4	3,655.0	101,950.0	372.6	0.45	0.2	0.7
Minimum:	3,388.8	0.0	3,388.8	101,950.0	345.5	0.41	0.2	0.7
Maximum:	4,308.7	537.9	4,846.6	101,950.0	494.1	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2023 00:00	3,389.5	0.0	3,389.5	101,950.0	345.6	0.41	0.2	0.7
08/10/2023 01:00	3,393.2	0.0	3,393.2	101,950.0	345.9	0.42	0.2	0.7
08/10/2023 02:00	3,393.2	0.0	3,393.2	101,950.0	345.9	0.42	0.2	0.7
08/10/2023 03:00	3,395.1	0.0	3,395.1	101,950.0	346.1	0.42	0.2	0.7
08/10/2023 04:00	3,396.5	0.0	3,396.5	101,950.0	346.3	0.42	0.2	0.7
08/10/2023 05:00	3,417.0	0.0	3,417.0	101,950.0	348.4	0.42	0.2	0.7
08/10/2023 06:00	3,906.1	0.0	3,906.1	101,950.0	398.2	0.48	0.2	0.8
08/10/2023 07:00	3,517.2	0.0	3,517.2	101,950.0	358.6	0.43	0.2	0.7
08/10/2023 08:00	3,416.3	0.0	3,416.3	101,950.0	348.3	0.42	0.2	0.7
08/10/2023 09:00	3,409.8	0.0	3,409.8	101,950.0	347.6	0.42	0.2	0.7
08/10/2023 10:00	3,409.0	0.0	3,409.0	101,950.0	347.5	0.42	0.2	0.7
08/10/2023 11:00	3,407.4	0.0	3,407.4	101,950.0	347.4	0.42	0.2	0.7
08/10/2023 12:00	3,406.2	0.0	3,406.2	101,950.0	347.3	0.42	0.2	0.7
08/10/2023 13:00	3,539.2	0.0	3,539.2	101,950.0	360.8	0.43	0.2	0.7
08/10/2023 14:00	3,411.1	0.0	3,411.1	101,950.0	347.8	0.42	0.2	0.7
08/10/2023 15:00	3,760.9	0.0	3,760.9	101,950.0	383.4	0.46	0.2	0.8
08/10/2023 16:00	4,159.8	0.0	4,159.8	101,950.0	424.1	0.51	0.3	0.8
08/10/2023 17:00	3,500.5	0.0	3,500.5	101,950.0	356.9	0.43	0.2	0.7
08/10/2023 18:00	3,601.7	0.0	3,601.7	101,950.0	367.2	0.44	0.2	0.7
08/10/2023 19:00	3,477.7	0.0	3,477.7	101,950.0	354.6	0.43	0.2	0.7
08/10/2023 20:00	3,535.0	0.0	3,535.0	101,950.0	360.4	0.43	0.2	0.7
08/10/2023 21:00	3,501.8	0.0	3,501.8	101,950.0	357.0	0.43	0.2	0.7
08/10/2023 22:00	3,523.5	0.0	3,523.5	101,950.0	359.2	0.43	0.2	0.7
08/10/2023 23:00	3,760.7	0.0	3,760.7	101,950.0	383.4	0.46	0.2	0.8
Average/Sum#:	3,526.2	0.0	3,526.2	101,950.0	359.5	0.43	0.2	0.7
Minimum:	3,389.5	0.0	3,389.5	101,950.0	345.6	0.41	0.2	0.7
Maximum:	4,159.8	0.0	4,159.8	101,950.0	424.1	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2023 00:00	4,370.8	516.7	4,846.2	101,950.0	494.1	0.60	0.3	1.0
08/11/2023 01:00	4,318.8	2.1	4,318.8	101,950.0	440.3	0.53	0.3	0.9
08/11/2023 02:00	4,126.2	0.0	4,126.2	101,950.0	420.7	0.50	0.3	0.8
08/11/2023 03:00	3,979.4	0.0	3,979.4	101,950.0	405.7	0.49	0.2	0.8
08/11/2023 04:00	3,972.2	0.0	3,972.2	101,950.0	405.0	0.49	0.2	0.8
08/11/2023 05:00	4,003.0	0.0	4,003.0	101,950.0	408.1	0.49	0.2	0.8
08/11/2023 06:00	4,166.3	0.0	4,166.3	101,950.0	424.8	0.51	0.3	0.8
08/11/2023 07:00	4,335.1	3.2	4,335.2	101,950.0	442.0	0.53	0.3	0.9
08/11/2023 08:00	4,446.5	343.8	4,790.3	101,950.0	488.4	0.59	0.3	1.0
08/11/2023 09:00	4,412.3	922.4	5,334.7	101,950.0	543.9	0.65	0.3	1.1
08/11/2023 10:00	4,398.3	1,388.5	5,786.8	101,950.0	590.0	0.71	0.4	1.2
08/11/2023 11:00	4,374.9	1,834.8	6,209.7	101,950.0	633.1	0.76	0.4	1.3
08/11/2023 12:00	4,326.8	524.4	4,720.1	101,950.0	481.2	0.59	0.3	1.0
08/11/2023 13:00	3,436.1	0.0	3,436.1	101,950.0	350.3	0.42	0.2	0.7
08/11/2023 14:00	3,433.9	0.0	3,433.9	101,950.0	350.1	0.42	0.2	0.7
08/11/2023 15:00	3,431.8	0.0	3,431.8	101,950.0	349.9	0.42	0.2	0.7
08/11/2023 16:00	3,418.5	0.0	3,418.5	101,950.0	348.5	0.42	0.2	0.7
08/11/2023 17:00	3,510.1	0.0	3,510.1	101,950.0	357.9	0.43	0.2	0.7
08/11/2023 18:00	4,292.7	362.1	4,535.3	101,950.0	462.4	0.57	0.3	0.9
08/11/2023 19:00	4,309.3	524.8	4,834.1	101,950.0	492.8	0.59	0.3	1.0
08/11/2023 20:00	4,328.4	465.3	4,793.7	101,950.0	488.7	0.59	0.3	1.0
08/11/2023 21:00	4,333.8	448.4	4,782.2	101,950.0	487.5	0.59	0.3	1.0
08/11/2023 22:00	4,318.9	461.9	4,780.8	101,950.0	487.4	0.59	0.3	1.0
08/11/2023 23:00	4,337.7	424.7	4,762.4	101,950.0	485.5	0.58	0.3	1.0
Average/Sum#:	4,099.2	342.6	4,429.5	101,950.0	451.6	0.54	0.3	0.9
Minimum:	3,418.5	0.0	3,418.5	101,950.0	348.5	0.42	0.2	0.7
Maximum:	4,446.5	1,834.8	6,209.7	101,950.0	633.1	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2023 00:00	3,721.2	1.6	3,721.2	101,950.0	379.4	0.46	0.2	0.8
08/12/2023 01:00	3,429.3	0.0	3,429.3	101,950.0	349.6	0.42	0.2	0.7
08/12/2023 02:00	3,409.6	0.0	3,409.6	101,950.0	347.6	0.42	0.2	0.7
08/12/2023 03:00	3,408.6	0.0	3,408.6	101,950.0	347.5	0.42	0.2	0.7
08/12/2023 04:00	3,408.2	0.0	3,408.2	101,950.0	347.5	0.42	0.2	0.7
08/12/2023 05:00	3,408.4	0.0	3,408.4	101,950.0	347.5	0.42	0.2	0.7
08/12/2023 06:00	3,422.0	0.0	3,422.0	101,950.0	348.9	0.42	0.2	0.7
08/12/2023 07:00	3,415.8	0.0	3,415.8	101,950.0	348.2	0.42	0.2	0.7
08/12/2023 08:00	3,415.9	0.0	3,415.9	101,950.0	348.3	0.42	0.2	0.7
08/12/2023 09:00	3,417.9	0.0	3,417.9	101,950.0	348.5	0.42	0.2	0.7
08/12/2023 10:00	3,410.7	0.0	3,410.7	101,950.0	347.7	0.42	0.2	0.7
08/12/2023 11:00	3,563.1	0.0	3,563.1	101,950.0	363.3	0.44	0.2	0.7
08/12/2023 12:00	3,880.9	0.0	3,880.9	101,950.0	395.7	0.48	0.2	0.8
08/12/2023 13:00	3,976.7	0.0	3,976.7	101,950.0	405.4	0.49	0.2	0.8
08/12/2023 14:00	3,779.6	0.0	3,779.6	101,950.0	385.3	0.46	0.2	0.8
08/12/2023 15:00	3,740.2	0.0	3,740.2	101,950.0	381.3	0.46	0.2	0.8
08/12/2023 16:00	3,432.4	0.0	3,432.4	101,950.0	349.9	0.42	0.2	0.7
08/12/2023 17:00	3,428.6	0.0	3,428.6	101,950.0	349.5	0.42	0.2	0.7
08/12/2023 18:00	3,890.6	120.9	3,918.4	101,950.0	399.5	0.49	0.2	0.8
08/12/2023 19:00	4,284.4	571.5	4,855.9	101,950.0	495.1	0.59	0.3	1.0
08/12/2023 20:00	4,287.7	420.3	4,678.6	101,950.0	477.0	0.58	0.3	1.0
08/12/2023 21:00	3,867.2	0.0	3,867.2	101,950.0	394.3	0.47	0.2	0.8
08/12/2023 22:00	4,131.2	1.7	4,131.3	101,950.0	421.2	0.51	0.3	0.8
08/12/2023 23:00	3,625.8	0.0	3,625.8	101,950.0	369.7	0.45	0.2	0.7
Average/Sum#:	3,656.5	46.5	3,697.8	101,950.0	377.0	0.46	0.2	0.8
Minimum:	3,408.2	0.0	3,408.2	101,950.0	347.5	0.42	0.2	0.7
Maximum:	4,287.7	571.5	4,855.9	101,950.0	495.1	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2023 00:00	3,829.9	0.0	3,829.9	101,950.0	390.5	0.47	0.2	0.8
08/13/2023 01:00	3,822.6	0.0	3,822.6	101,950.0	389.7	0.47	0.2	0.8
08/13/2023 02:00	3,632.6	0.0	3,632.6	101,950.0	370.3	0.44	0.2	0.7
08/13/2023 03:00	3,939.6	0.0	3,939.6	101,950.0	401.6	0.48	0.2	0.8
08/13/2023 04:00	3,609.5	0.0	3,609.5	101,950.0	368.0	0.44	0.2	0.7
08/13/2023 05:00	3,540.8	0.0	3,540.8	101,950.0	361.0	0.43	0.2	0.7
08/13/2023 06:00	3,410.5	0.0	3,410.5	101,950.0	347.7	0.42	0.2	0.7
08/13/2023 07:00	3,395.2	0.0	3,395.2	101,950.0	346.1	0.42	0.2	0.7
08/13/2023 08:00	3,395.4	0.0	3,395.4	101,950.0	346.2	0.42	0.2	0.7
08/13/2023 09:00	3,395.8	0.0	3,395.8	101,950.0	346.2	0.42	0.2	0.7
08/13/2023 10:00	3,394.1	0.0	3,394.1	101,950.0	346.0	0.42	0.2	0.7
08/13/2023 11:00	3,404.1	0.0	3,404.1	101,950.0	347.0	0.42	0.2	0.7
08/13/2023 12:00	3,605.0	0.0	3,605.0	101,950.0	367.5	0.44	0.2	0.7
08/13/2023 13:00	3,565.9	0.0	3,565.9	101,950.0	363.5	0.43	0.2	0.7
08/13/2023 14:00	3,941.8	0.0	3,941.8	101,950.0	401.9	0.48	0.2	0.8
08/13/2023 15:00	4,088.7	0.0	4,088.7	101,950.0	416.8	0.50	0.3	0.8
08/13/2023 16:00	4,073.5	0.0	4,073.5	101,950.0	415.3	0.50	0.2	0.8
08/13/2023 17:00	3,839.9	0.0	3,839.9	101,950.0	391.5	0.47	0.2	0.8
08/13/2023 18:00	4,222.9	516.3	4,625.6	101,950.0	471.6	0.58	0.3	1.0
08/13/2023 19:00	4,228.7	678.5	4,907.2	101,950.0	500.3	0.60	0.3	1.0
08/13/2023 20:00	4,245.6	629.1	4,874.7	101,950.0	497.0	0.60	0.3	1.0
08/13/2023 21:00	4,263.9	593.8	4,857.7	101,950.0	495.2	0.59	0.3	1.0
08/13/2023 22:00	4,182.7	143.7	4,221.5	101,950.0	430.4	0.53	0.3	0.9
08/13/2023 23:00	3,952.9	0.0	3,952.9	101,950.0	403.0	0.48	0.2	0.8
Average/Sum#:	3,790.9	106.7	3,888.5	101,950.0	396.4	0.48	0.2	0.8
Minimum:	3,394.1	0.0	3,394.1	101,950.0	346.0	0.42	0.2	0.7
Maximum:	4,263.9	678.5	4,907.2	101,950.0	500.3	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2023 00:00	4,099.6	0.0	4,099.6	101,950.0	418.0	0.50	0.3	0.8
08/14/2023 01:00	4,098.9	0.0	4,098.9	101,950.0	417.9	0.50	0.3	0.8
08/14/2023 02:00	4,018.3	0.0	4,018.3	101,950.0	409.7	0.49	0.2	0.8
08/14/2023 03:00	3,950.4	0.0	3,950.4	101,950.0	402.7	0.48	0.2	0.8
08/14/2023 04:00	3,872.0	0.0	3,872.0	101,950.0	394.8	0.47	0.2	0.8
08/14/2023 05:00	4,096.0	0.0	4,096.0	101,950.0	417.6	0.50	0.3	0.8
08/14/2023 06:00	4,155.0	0.0	4,155.0	101,950.0	423.6	0.51	0.3	0.8
08/14/2023 07:00	3,612.3	0.0	3,612.3	101,950.0	368.3	0.44	0.2	0.7
08/14/2023 08:00	3,769.2	0.0	3,769.2	101,950.0	384.3	0.46	0.2	0.8
08/14/2023 09:00	4,119.7	0.0	4,119.7	101,950.0	420.0	0.50	0.3	0.8
08/14/2023 10:00	4,145.8	0.0	4,145.8	101,950.0	422.7	0.51	0.3	0.8
08/14/2023 11:00	4,229.1	369.6	4,425.0	101,950.0	451.1	0.56	0.3	0.9
08/14/2023 12:00	4,238.9	1,212.8	5,451.7	101,950.0	555.8	0.67	0.3	1.1
08/14/2023 13:00	4,211.6	1,140.8	5,352.4	101,950.0	545.7	0.66	0.3	1.1
08/14/2023 14:00	4,211.4	842.8	5,054.2	101,950.0	515.3	0.62	0.3	1.0
08/14/2023 15:00	4,207.6	1,355.0	5,562.6	101,950.0	567.1	0.68	0.3	1.1
08/14/2023 16:00	4,187.1	938.0	5,125.1	101,950.0	522.5	0.63	0.3	1.0
08/14/2023 17:00	4,168.3	859.2	5,027.5	101,950.0	512.6	0.62	0.3	1.0
08/14/2023 18:00	4,189.0	1,663.1	5,852.1	101,950.0	596.6	0.72	0.4	1.2
08/14/2023 19:00	4,205.5	1,923.8	6,129.3	101,950.0	624.9	0.75	0.4	1.2
08/14/2023 20:00	4,211.7	1,304.2	5,515.9	101,950.0	562.3	0.68	0.3	1.1
08/14/2023 21:00	4,221.7	1,160.2	5,381.9	101,950.0	548.7	0.66	0.3	1.1
08/14/2023 22:00	4,246.4	886.9	5,133.3	101,950.0	523.3	0.63	0.3	1.0
08/14/2023 23:00	4,220.8	458.1	4,573.5	101,950.0	466.3	0.57	0.3	1.0
Average/Sum#:	4,111.9	588.1	4,688.4	101,950.0	478.0	0.58	0.3	0.9
Minimum:	3,612.3	0.0	3,612.3	101,950.0	368.3	0.44	0.2	0.7
Maximum:	4,246.4	1,923.8	6,129.3	101,950.0	624.9	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2023 00:00	4,065.4	0.0	4,065.4	101,950.0	414.5	0.50	0.2	0.8
08/15/2023 01:00	4,061.7	0.0	4,061.7	101,950.0	414.1	0.50	0.2	0.8
08/15/2023 02:00	4,065.2	0.0	4,065.2	101,950.0	414.4	0.50	0.2	0.8
08/15/2023 03:00	4,050.4	0.0	4,050.4	101,950.0	412.9	0.50	0.2	0.8
08/15/2023 04:00	4,058.6	0.0	4,058.6	101,950.0	413.8	0.50	0.2	0.8
08/15/2023 05:00	4,157.6	0.0	4,157.6	101,950.0	423.9	0.51	0.3	0.8
08/15/2023 06:00	4,162.7	0.0	4,162.7	101,950.0	424.4	0.51	0.3	0.8
08/15/2023 07:00	3,664.0	0.0	3,664.0	101,950.0	373.5	0.45	0.2	0.7
08/15/2023 08:00	3,987.4	0.0	3,987.4	101,950.0	406.5	0.49	0.2	0.8
08/15/2023 09:00	4,048.9	0.0	4,048.9	101,950.0	412.8	0.50	0.2	0.8
08/15/2023 10:00	3,873.0	0.0	3,873.0	101,950.0	394.9	0.47	0.2	0.8
08/15/2023 11:00	3,867.6	0.0	3,867.6	101,950.0	394.3	0.47	0.2	0.8
08/15/2023 12:00	4,032.0	0.0	4,032.0	101,950.0	411.1	0.50	0.2	0.8
08/15/2023 13:00	4,162.9	0.0	4,162.9	101,950.0	424.4	0.51	0.3	0.8
08/15/2023 14:00	4,205.4	1,504.5	5,664.8	101,950.0	577.5	0.70	0.3	1.2
08/15/2023 15:00	4,206.8	1,958.5	6,165.3	101,950.0	628.6	0.75	0.4	1.3
08/15/2023 16:00	4,178.0	1,966.2	6,144.2	101,950.0	626.4	0.75	0.4	1.3
08/15/2023 17:00	4,145.1	1,935.9	6,081.0	101,950.0	620.0	0.74	0.4	1.2
08/15/2023 18:00	4,139.9	1,740.3	5,880.2	101,950.0	599.5	0.72	0.4	1.2
08/15/2023 19:00	4,150.6	1,860.2	6,010.8	101,950.0	612.8	0.74	0.4	1.2
08/15/2023 20:00	4,197.2	1,456.6	5,653.8	101,950.0	576.4	0.69	0.3	1.2
08/15/2023 21:00	4,224.1	893.6	5,117.7	101,950.0	521.7	0.63	0.3	1.0
08/15/2023 22:00	4,228.3	1,193.3	5,421.6	101,950.0	552.7	0.66	0.3	1.1
08/15/2023 23:00	4,125.5	370.0	4,321.6	101,950.0	440.6	0.55	0.3	0.9
Average/Sum#:	4,085.8	620.0	4,696.6	101,950.0	478.8	0.58	0.3	0.9
Minimum:	3,664.0	0.0	3,664.0	101,950.0	373.5	0.45	0.2	0.7
Maximum:	4,228.3	1,966.2	6,165.3	101,950.0	628.6	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2023 00:00	4,215.0	0.0	4,215.0	101,950.0	429.7	0.52	0.3	0.9
08/16/2023 01:00	4,063.0	0.0	4,063.0	101,950.0	414.2	0.50	0.2	0.8
08/16/2023 02:00	3,804.5	0.0	3,804.5	101,950.0	387.9	0.46	0.2	0.8
08/16/2023 03:00	3,796.2	0.0	3,796.2	101,950.0	387.0	0.46	0.2	0.8
08/16/2023 04:00	3,872.8	0.0	3,872.8	101,950.0	394.8	0.47	0.2	0.8
08/16/2023 05:00	4,162.5	0.0	4,162.5	101,950.0	424.4	0.51	0.3	0.8
08/16/2023 06:00	4,182.4	0.0	4,182.4	101,950.0	426.4	0.51	0.3	0.9
08/16/2023 07:00	3,993.2	0.0	3,993.2	101,950.0	407.1	0.49	0.2	0.8
08/16/2023 08:00	3,980.8	0.0	3,980.8	101,950.0	405.8	0.49	0.2	0.8
08/16/2023 09:00	3,848.7	0.0	3,848.7	101,950.0	392.4	0.47	0.2	0.8
08/16/2023 10:00	3,923.2	0.0	3,923.2	101,950.0	400.0	0.48	0.2	0.8
08/16/2023 11:00	4,073.8	3.5	4,073.9	101,950.0	415.3	0.50	0.2	0.8
08/16/2023 12:00	4,174.2	0.0	4,174.2	101,950.0	425.6	0.51	0.3	0.9
08/16/2023 13:00	4,179.3	164.9	4,215.6	101,950.0	429.8	0.53	0.3	0.9
08/16/2023 14:00	4,153.4	1,828.3	5,981.7	101,950.0	609.8	0.73	0.4	1.2
08/16/2023 15:00	4,139.8	1,931.5	6,071.3	101,950.0	619.0	0.74	0.4	1.2
08/16/2023 16:00	4,134.1	1,923.3	6,057.4	101,950.0	617.6	0.74	0.4	1.2
08/16/2023 17:00	4,101.5	1,906.1	6,007.6	101,950.0	612.5	0.74	0.4	1.2
08/16/2023 18:00	4,105.0	1,782.7	5,887.7	101,950.0	600.3	0.72	0.4	1.2
08/16/2023 19:00	4,140.7	1,846.6	5,987.3	101,950.0	610.4	0.73	0.4	1.2
08/16/2023 20:00	4,185.6	1,692.5	5,878.1	101,950.0	599.3	0.72	0.4	1.2
08/16/2023 21:00	4,172.2	1,411.0	5,583.2	101,950.0	569.2	0.68	0.3	1.1
08/16/2023 22:00	4,199.3	1,303.8	5,503.1	101,950.0	561.0	0.67	0.3	1.1
08/16/2023 23:00	4,071.0	4.8	4,071.1	101,950.0	415.0	0.50	0.2	0.8
Average/Sum#:	4,069.7	658.3	4,722.3	101,950.0	481.4	0.58	0.3	1.0
Minimum:	3,796.2	0.0	3,796.2	101,950.0	387.0	0.46	0.2	0.8
Maximum:	4,215.0	1,931.5	6,071.3	101,950.0	619.0	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2023 00:00	4,033.0	0.0	4,033.0	101,950.0	411.2	0.49	0.2	0.8
08/17/2023 01:00	4,087.9	0.0	4,087.9	101,950.0	416.8	0.50	0.3	0.8
08/17/2023 02:00	4,156.4	0.0	4,156.4	101,950.0	423.7	0.51	0.3	0.8
08/17/2023 03:00	4,193.5	0.0	4,193.5	101,950.0	427.5	0.51	0.3	0.9
08/17/2023 04:00	4,153.4	0.0	4,153.4	101,950.0	423.4	0.51	0.3	0.8
08/17/2023 05:00	4,190.7	0.0	4,190.7	101,950.0	427.2	0.51	0.3	0.9
08/17/2023 06:00	4,175.5	0.0	4,175.5	101,950.0	425.7	0.51	0.3	0.9
08/17/2023 07:00	3,560.2	0.0	3,560.2	101,950.0	363.0	0.44	0.2	0.7
08/17/2023 08:00	3,399.7	0.0	3,399.7	101,950.0	346.6	0.42	0.2	0.7
08/17/2023 09:00	3,394.0	0.0	3,394.0	101,950.0	346.0	0.42	0.2	0.7
08/17/2023 10:00	3,394.0	0.0	3,394.0	101,950.0	346.0	0.42	0.2	0.7
08/17/2023 11:00	3,462.6	0.0	3,462.6	101,950.0	353.0	0.43	0.2	0.7
08/17/2023 12:00	3,912.0	0.0	3,912.0	101,950.0	398.8	0.48	0.2	0.8
08/17/2023 13:00	4,116.9	0.0	4,116.9	101,950.0	419.7	0.50	0.3	0.8
08/17/2023 14:00	3,738.8	0.0	3,738.8	101,950.0	381.2	0.46	0.2	0.8
08/17/2023 15:00	3,491.6	0.0	3,491.6	101,950.0	356.0	0.43	0.2	0.7
08/17/2023 16:00	3,656.9	0.0	3,656.9	101,950.0	372.8	0.45	0.2	0.7
08/17/2023 17:00	3,835.2	158.9	3,871.7	101,950.0	394.7	0.49	0.2	0.8
08/17/2023 18:00	4,157.0	817.4	4,974.4	101,950.0	507.1	0.61	0.3	1.0
08/17/2023 19:00	4,179.9	782.3	4,962.2	101,950.0	505.9	0.61	0.3	1.0
08/17/2023 20:00	4,218.2	682.1	4,900.3	101,950.0	499.6	0.60	0.3	1.0
08/17/2023 21:00	3,649.4	4.0	3,649.5	101,950.0	372.1	0.45	0.2	0.7
08/17/2023 22:00	3,892.8	0.0	3,892.8	101,950.0	396.9	0.48	0.2	0.8
08/17/2023 23:00	3,808.6	0.0	3,808.6	101,950.0	388.3	0.47	0.2	0.8
Average/Sum#:	3,869.1	101.9	3,965.7	101,950.0	404.3	0.49	0.2	0.8
Minimum:	3,394.0	0.0	3,394.0	101,950.0	346.0	0.42	0.2	0.7
Maximum:	4,218.2	817.4	4,974.4	101,950.0	507.1	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2023 00:00	3,559.5	0.0	3,559.5	101,950.0	362.9	0.43	0.2	0.7
08/18/2023 01:00	3,382.0	0.0	3,382.0	101,950.0	344.8	0.41	0.2	0.7
08/18/2023 02:00	3,382.2	0.0	3,382.2	101,950.0	344.8	0.41	0.2	0.7
08/18/2023 03:00	3,382.7	0.0	3,382.7	101,950.0	344.9	0.41	0.2	0.7
08/18/2023 04:00	3,381.7	0.0	3,381.7	101,950.0	344.8	0.41	0.2	0.7
08/18/2023 05:00	3,393.2	0.0	3,393.2	101,950.0	345.9	0.41	0.2	0.7
08/18/2023 06:00	3,609.1	0.0	3,609.1	101,950.0	367.9	0.44	0.2	0.7
08/18/2023 07:00	3,422.9	0.0	3,422.9	101,950.0	349.0	0.42	0.2	0.7
08/18/2023 08:00	3,403.1	0.0	3,403.1	101,950.0	346.9	0.42	0.2	0.7
08/18/2023 09:00	3,395.5	0.0	3,395.5	101,950.0	346.2	0.42	0.2	0.7
08/18/2023 10:00	3,393.9	0.0	3,393.9	101,950.0	346.0	0.42	0.2	0.7
08/18/2023 11:00	3,392.9	0.0	3,392.9	101,950.0	345.9	0.42	0.2	0.7
08/18/2023 12:00	3,401.0	0.0	3,401.0	101,950.0	346.7	0.42	0.2	0.7
08/18/2023 13:00	3,425.0	0.0	3,425.0	101,950.0	349.2	0.42	0.2	0.7
08/18/2023 14:00	3,416.0	0.0	3,416.0	101,950.0	348.3	0.42	0.2	0.7
08/18/2023 15:00	3,401.9	0.0	3,401.9	101,950.0	346.8	0.42	0.2	0.7
08/18/2023 16:00	3,423.9	0.0	3,423.9	101,950.0	349.1	0.42	0.2	0.7
08/18/2023 17:00	3,435.6	0.0	3,435.6	101,950.0	350.3	0.42	0.2	0.7
08/18/2023 18:00	3,397.1	0.0	3,397.1	101,950.0	346.3	0.42	0.2	0.7
08/18/2023 19:00	3,383.0	0.0	3,383.0	101,950.0	344.9	0.41	0.2	0.7
08/18/2023 20:00	3,372.5	0.0	3,372.5	101,950.0	343.8	0.41	0.2	0.7
08/18/2023 21:00	3,376.2	0.0	3,376.2	101,950.0	344.2	0.41	0.2	0.7
08/18/2023 22:00	3,375.9	0.0	3,375.9	101,950.0	344.2	0.41	0.2	0.7
08/18/2023 23:00	3,381.0	0.0	3,381.0	101,950.0	344.7	0.41	0.2	0.7
Average/Sum#:	3,412.0	0.0	3,412.0	101,950.0	347.9	0.42	0.2	0.7
Minimum:	3,372.5	0.0	3,372.5	101,950.0	343.8	0.41	0.2	0.7
Maximum:	3,609.1	0.0	3,609.1	101,950.0	367.9	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2023 00:00	3,498.9	0.0	3,498.9	101,950.0	356.7	0.43	0.2	0.2	0.7	0.7
08/19/2023 01:00	3,379.2	0.0	3,379.2	101,950.0	344.5	0.41	0.2	0.2	0.7	0.7
08/19/2023 02:00	3,375.7	0.0	3,375.7	101,950.0	344.2	0.41	0.2	0.2	0.7	0.7
08/19/2023 03:00	3,374.6	0.0	3,374.6	101,950.0	344.0	0.41	0.2	0.2	0.7	0.7
08/19/2023 04:00	3,373.8	0.0	3,373.8	101,950.0	344.0	0.41	0.2	0.2	0.7	0.7
08/19/2023 05:00	3,373.0	0.0	3,373.0	101,950.0	343.9	0.41	0.2	0.2	0.7	0.7
08/19/2023 06:00	3,373.3	0.0	3,373.3	101,950.0	343.9	0.41	0.2	0.2	0.7	0.7
08/19/2023 07:00	3,374.4	0.0	3,374.4	101,950.0	344.0	0.41	0.2	0.2	0.7	0.7
08/19/2023 08:00	3,379.5	0.0	3,379.5	101,950.0	344.5	0.41	0.2	0.2	0.7	0.7
08/19/2023 09:00	3,372.1	0.0	3,372.1	101,950.0	343.8	0.41	0.2	0.2	0.7	0.7
08/19/2023 10:00	3,368.4	0.0	3,368.4	101,950.0	343.4	0.41	0.2	0.2	0.7	0.7
08/19/2023 11:00	3,382.3	0.0	3,382.3	101,950.0	344.8	0.41	0.2	0.2	0.7	0.7
08/19/2023 12:00	3,403.4	0.0	3,403.4	101,950.0	347.0	0.42	0.2	0.2	0.7	0.7
08/19/2023 13:00	3,405.8	0.0	3,405.8	101,950.0	347.2	0.42	0.2	0.2	0.7	0.7
08/19/2023 14:00	3,409.5	0.0	3,409.5	101,950.0	347.6	0.42	0.2	0.2	0.7	0.7
08/19/2023 15:00	3,418.0	0.0	3,418.0	101,950.0	348.5	0.42	0.2	0.2	0.7	0.7
08/19/2023 16:00	3,404.9	0.0	3,404.9	101,950.0	347.1	0.42	0.2	0.2	0.7	0.7
08/19/2023 17:00	3,378.4	0.0	3,378.4	101,950.0	344.4	0.41	0.2	0.2	0.7	0.7
08/19/2023 18:00	3,383.9	0.0	3,383.9	101,950.0	345.0	0.41	0.2	0.2	0.7	0.7
08/19/2023 19:00	3,385.2	0.0	3,385.2	101,950.0	345.1	0.41	0.2	0.2	0.7	0.7
08/19/2023 20:00	3,376.3	0.0	3,376.3	101,950.0	344.2	0.41	0.2	0.2	0.7	0.7
08/19/2023 21:00	3,369.9	0.0	3,369.9	101,950.0	343.6	0.41	0.2	0.2	0.7	0.7
08/19/2023 22:00	3,386.5	0.0	3,386.5	101,950.0	345.3	0.41	0.2	0.2	0.7	0.7
08/19/2023 23:00	3,478.2	0.0	3,478.2	101,950.0	354.6	0.42	0.2	0.2	0.7	0.7
Average/Sum#:	3,392.7	0.0	3,392.7	101,950.0	345.9	0.41	0.2	0.2	0.7	0.7
Minimum:	3,368.4	0.0	3,368.4	101,950.0	343.4	0.41	0.2	0.2	0.7	0.7
Maximum:	3,498.9	0.0	3,498.9	101,950.0	356.7	0.43	0.2	0.2	0.7	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2023 00:00	3,622.2	0.0	3,622.2	101,950.0	369.3	0.44	0.2	0.7
08/20/2023 01:00	3,506.2	0.0	3,506.2	101,950.0	357.5	0.43	0.2	0.7
08/20/2023 02:00	3,576.0	0.0	3,576.0	101,950.0	364.6	0.44	0.2	0.7
08/20/2023 03:00	3,582.8	0.0	3,582.8	101,950.0	365.3	0.44	0.2	0.7
08/20/2023 04:00	3,503.3	0.0	3,503.3	101,950.0	357.2	0.43	0.2	0.7
08/20/2023 05:00	3,377.3	0.0	3,377.3	101,950.0	344.3	0.41	0.2	0.7
08/20/2023 06:00	3,377.8	0.0	3,377.8	101,950.0	344.4	0.41	0.2	0.7
08/20/2023 07:00	3,376.6	0.0	3,376.6	101,950.0	344.2	0.41	0.2	0.7
08/20/2023 08:00	3,374.6	0.0	3,374.6	101,950.0	344.0	0.41	0.2	0.7
08/20/2023 09:00	3,378.9	0.0	3,378.9	101,950.0	344.5	0.41	0.2	0.7
08/20/2023 10:00	3,379.5	0.0	3,379.5	101,950.0	344.5	0.41	0.2	0.7
08/20/2023 11:00	3,375.5	0.0	3,375.5	101,950.0	344.1	0.41	0.2	0.7
08/20/2023 12:00	3,377.2	0.0	3,377.2	101,950.0	344.3	0.41	0.2	0.7
08/20/2023 13:00	3,381.5	0.0	3,381.5	101,950.0	344.7	0.41	0.2	0.7
08/20/2023 14:00	3,382.4	0.0	3,382.4	101,950.0	344.8	0.41	0.2	0.7
08/20/2023 15:00	3,382.9	0.0	3,382.9	101,950.0	344.9	0.41	0.2	0.7
08/20/2023 16:00	3,385.7	0.0	3,385.7	101,950.0	345.2	0.41	0.2	0.7
08/20/2023 17:00	3,377.7	0.0	3,377.7	101,950.0	344.4	0.41	0.2	0.7
08/20/2023 18:00	3,373.7	0.0	3,373.7	101,950.0	343.9	0.41	0.2	0.7
08/20/2023 19:00	3,371.4	0.0	3,371.4	101,950.0	343.7	0.41	0.2	0.7
08/20/2023 20:00	3,374.6	0.0	3,374.6	101,950.0	344.0	0.41	0.2	0.7
08/20/2023 21:00	3,374.0	0.0	3,374.0	101,950.0	344.0	0.41	0.2	0.7
08/20/2023 22:00	3,367.6	0.0	3,367.6	101,950.0	343.3	0.41	0.2	0.7
08/20/2023 23:00	3,366.4	0.0	3,366.4	101,950.0	343.2	0.41	0.2	0.7
Average/Sum#:	3,414.4	0.0	3,414.4	101,950.0	348.1	0.42	0.2	0.7
Minimum:	3,366.4	0.0	3,366.4	101,950.0	343.2	0.41	0.2	0.7
Maximum:	3,622.2	0.0	3,622.2	101,950.0	369.3	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2023 00:00	3,362.8	0.0	3,362.8	101,950.0	342.8	0.41	0.2	0.7
08/21/2023 01:00	3,366.1	0.0	3,366.1	101,950.0	343.2	0.41	0.2	0.7
08/21/2023 02:00	3,367.9	0.0	3,367.9	101,950.0	343.4	0.41	0.2	0.7
08/21/2023 03:00	3,367.5	0.0	3,367.5	101,950.0	343.3	0.41	0.2	0.7
08/21/2023 04:00	3,449.6	0.0	3,449.6	101,950.0	351.7	0.42	0.2	0.7
08/21/2023 05:00	4,133.6	0.0	4,133.6	101,950.0	421.4	0.50	0.3	0.8
08/21/2023 06:00	4,217.7	0.0	4,217.7	101,950.0	430.0	0.52	0.3	0.9
08/21/2023 07:00	4,110.4	0.0	4,110.4	101,950.0	419.1	0.50	0.3	0.8
08/21/2023 08:00	3,909.6	0.0	3,909.6	101,950.0	398.6	0.48	0.2	0.8
08/21/2023 09:00	3,922.8	0.0	3,922.8	101,950.0	399.9	0.48	0.2	0.8
08/21/2023 10:00	3,502.1	0.0	3,502.1	101,950.0	357.0	0.43	0.2	0.7
08/21/2023 11:00	3,513.4	0.0	3,513.4	101,950.0	358.2	0.43	0.2	0.7
08/21/2023 12:00	3,532.4	0.0	3,532.4	101,950.0	360.1	0.43	0.2	0.7
08/21/2023 13:00	3,726.0	0.0	3,726.0	101,950.0	379.9	0.45	0.2	0.8
08/21/2023 14:00	3,460.5	0.0	3,460.5	101,950.0	352.8	0.42	0.2	0.7
08/21/2023 15:00	3,448.0	0.0	3,448.0	101,950.0	351.5	0.42	0.2	0.7
08/21/2023 16:00	3,431.5	0.0	3,431.5	101,950.0	349.8	0.42	0.2	0.7
08/21/2023 17:00	3,379.9	0.0	3,379.9	101,950.0	344.6	0.41	0.2	0.7
08/21/2023 18:00	3,386.9	0.0	3,386.9	101,950.0	345.3	0.41	0.2	0.7
08/21/2023 19:00	3,384.9	0.0	3,384.9	101,950.0	345.1	0.41	0.2	0.7
08/21/2023 20:00	3,384.9	0.0	3,384.9	101,950.0	345.1	0.41	0.2	0.7
08/21/2023 21:00	3,385.6	0.0	3,385.6	101,950.0	345.2	0.41	0.2	0.7
08/21/2023 22:00	3,386.1	0.0	3,386.1	101,950.0	345.2	0.41	0.2	0.7
08/21/2023 23:00	3,382.2	0.0	3,382.2	101,950.0	344.8	0.41	0.2	0.7
Average/Sum#:	3,563.0	0.0	3,563.0	101,950.0	363.3	0.43	0.2	0.7
Minimum:	3,362.8	0.0	3,362.8	101,950.0	342.8	0.41	0.2	0.7
Maximum:	4,217.7	0.0	4,217.7	101,950.0	430.0	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2023 00:00	3,376.9	0.0	3,376.9	101,950.0	344.3	0.41	0.2	0.7
08/22/2023 01:00	3,380.7	0.0	3,380.7	101,950.0	344.7	0.41	0.2	0.7
08/22/2023 02:00	3,385.7	0.0	3,385.7	101,950.0	345.2	0.41	0.2	0.7
08/22/2023 03:00	3,377.9	0.0	3,377.9	101,950.0	344.4	0.41	0.2	0.7
08/22/2023 04:00	3,377.0	0.0	3,377.0	101,950.0	344.3	0.41	0.2	0.7
08/22/2023 05:00	3,384.2	0.0	3,384.2	101,950.0	345.0	0.41	0.2	0.7
08/22/2023 06:00	3,443.9	0.0	3,443.9	101,950.0	351.1	0.42	0.2	0.7
08/22/2023 07:00	3,382.8	0.0	3,382.8	101,950.0	344.9	0.41	0.2	0.7
08/22/2023 08:00	3,391.6	0.0	3,391.6	101,950.0	345.8	0.41	0.2	0.7
08/22/2023 09:00	3,389.4	0.0	3,389.4	101,950.0	345.5	0.41	0.2	0.7
08/22/2023 10:00	3,392.8	0.0	3,392.8	101,950.0	345.9	0.42	0.2	0.7
08/22/2023 11:00	3,391.6	0.0	3,391.6	101,950.0	345.8	0.41	0.2	0.7
08/22/2023 12:00	3,396.5	0.0	3,396.5	101,950.0	346.3	0.42	0.2	0.7
08/22/2023 13:00	3,397.6	0.0	3,397.6	101,950.0	346.4	0.42	0.2	0.7
08/22/2023 14:00	3,398.9	0.0	3,398.9	101,950.0	346.5	0.42	0.2	0.7
08/22/2023 15:00	3,394.2	0.0	3,394.2	101,950.0	346.0	0.42	0.2	0.7
08/22/2023 16:00	3,387.6	0.0	3,387.6	101,950.0	345.4	0.41	0.2	0.7
08/22/2023 17:00	3,454.6	0.0	3,454.6	101,950.0	352.2	0.42	0.2	0.7
08/22/2023 18:00	3,591.4	0.0	3,591.4	101,950.0	366.1	0.44	0.2	0.7
08/22/2023 19:00	4,021.8	0.2	4,021.8	101,950.0	410.0	0.49	0.2	0.8
08/22/2023 20:00	3,547.3	0.0	3,547.3	101,950.0	361.6	0.43	0.2	0.7
08/22/2023 21:00	3,776.3	0.0	3,776.3	101,950.0	385.0	0.46	0.2	0.8
08/22/2023 22:00	3,619.2	0.0	3,619.2	101,950.0	369.0	0.44	0.2	0.7
08/22/2023 23:00	3,470.0	0.0	3,470.0	101,950.0	353.8	0.42	0.2	0.7
Average/Sum#:	3,463.7	0.0	3,463.7	101,950.0	353.1	0.42	0.2	0.7
Minimum:	3,376.9	0.0	3,376.9	101,950.0	344.3	0.41	0.2	0.7
Maximum:	4,021.8	0.2	4,021.8	101,950.0	410.0	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2023 00:00	3,371.8	0.0	3,371.8	101,950.0	343.8	0.41	0.2	0.7
08/23/2023 01:00	3,372.7	0.0	3,372.7	101,950.0	343.8	0.41	0.2	0.7
08/23/2023 02:00	3,371.6	0.0	3,371.6	101,950.0	343.7	0.41	0.2	0.7
08/23/2023 03:00	3,375.1	0.0	3,375.1	101,950.0	344.1	0.41	0.2	0.7
08/23/2023 04:00	3,376.2	0.0	3,376.2	101,950.0	344.2	0.41	0.2	0.7
08/23/2023 05:00	3,530.4	0.0	3,530.4	101,950.0	359.9	0.43	0.2	0.7
08/23/2023 06:00	3,732.1	0.0	3,732.1	101,950.0	380.5	0.46	0.2	0.8
08/23/2023 07:00	3,427.8	0.0	3,427.8	101,950.0	349.5	0.42	0.2	0.7
08/23/2023 08:00	3,392.0	0.0	3,392.0	101,950.0	345.8	0.41	0.2	0.7
08/23/2023 09:00	3,382.2	0.0	3,382.2	101,950.0	344.8	0.41	0.2	0.7
08/23/2023 10:00	3,375.5	0.0	3,375.5	101,950.0	344.1	0.41	0.2	0.7
08/23/2023 11:00	3,377.6	0.0	3,377.6	101,950.0	344.3	0.41	0.2	0.7
08/23/2023 12:00	3,394.2	0.0	3,394.2	101,950.0	346.0	0.42	0.2	0.7
08/23/2023 13:00	3,395.2	0.0	3,395.2	101,950.0	346.1	0.42	0.2	0.7
08/23/2023 14:00	3,721.0	0.0	3,721.0	101,950.0	379.4	0.46	0.2	0.8
08/23/2023 15:00	4,217.1	0.0	4,217.1	101,950.0	429.9	0.52	0.3	0.9
08/23/2023 16:00	4,205.4	0.0	4,205.4	101,950.0	428.7	0.52	0.3	0.9
08/23/2023 17:00	4,080.7	286.5	4,218.2	101,950.0	430.0	0.53	0.3	0.9
08/23/2023 18:00	4,237.3	1,157.9	5,395.2	101,950.0	550.0	0.66	0.3	1.1
08/23/2023 19:00	4,246.0	1,419.6	5,665.6	101,950.0	577.6	0.69	0.3	1.2
08/23/2023 20:00	4,246.5	565.4	4,811.9	101,950.0	490.6	0.59	0.3	1.0
08/23/2023 21:00	4,228.3	421.3	4,552.7	101,950.0	464.1	0.57	0.3	0.9
08/23/2023 22:00	4,145.5	0.0	4,145.5	101,950.0	422.6	0.51	0.3	0.8
08/23/2023 23:00	3,876.4	0.0	3,876.4	101,950.0	395.2	0.48	0.2	0.8
Average/Sum#:	3,711.6	160.4	3,861.8	101,950.0	393.7	0.47	0.2	0.8
Minimum:	3,371.6	0.0	3,371.6	101,950.0	343.7	0.41	0.2	0.7
Maximum:	4,246.5	1,419.6	5,665.6	101,950.0	577.6	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2023 00:00	3,850.3	0.0	3,850.3	101,950.0	392.5	0.47	0.2	0.2	0.8	0.8
08/24/2023 01:00	3,382.8	0.0	3,382.8	101,950.0	344.9	0.41	0.2	0.2	0.7	0.7
08/24/2023 02:00	3,365.6	0.0	3,365.6	101,950.0	343.1	0.41	0.2	0.2	0.7	0.7
08/24/2023 03:00	3,366.3	0.0	3,366.3	101,950.0	343.2	0.41	0.2	0.2	0.7	0.7
08/24/2023 04:00	3,628.6	0.0	3,628.6	101,950.0	369.9	0.44	0.2	0.2	0.7	0.7
08/24/2023 05:00	3,873.4	0.0	3,873.4	101,950.0	394.9	0.47	0.2	0.2	0.8	0.8
08/24/2023 06:00	4,146.7	0.0	4,146.7	101,950.0	422.8	0.51	0.3	0.3	0.8	0.8
08/24/2023 07:00	3,595.4	0.0	3,595.4	101,950.0	366.6	0.44	0.2	0.2	0.7	0.7
08/24/2023 08:00	3,384.8	0.0	3,384.8	101,950.0	345.1	0.41	0.2	0.2	0.7	0.7
08/24/2023 09:00	3,379.0	0.0	3,379.0	101,950.0	344.5	0.41	0.2	0.2	0.7	0.7
08/24/2023 10:00	3,374.1	0.0	3,374.1	101,950.0	344.0	0.41	0.2	0.2	0.7	0.7
08/24/2023 11:00	3,380.1	0.0	3,380.1	101,950.0	344.6	0.41	0.2	0.2	0.7	0.7
08/24/2023 12:00	3,395.4	0.0	3,395.4	101,950.0	346.2	0.42	0.2	0.2	0.7	0.7
08/24/2023 13:00	3,395.1	0.0	3,395.1	101,950.0	346.1	0.42	0.2	0.2	0.7	0.7
08/24/2023 14:00	3,387.3	0.0	3,387.3	101,950.0	345.3	0.41	0.2	0.2	0.7	0.7
08/24/2023 15:00	3,384.4	0.0	3,384.4	101,950.0	345.0	0.41	0.2	0.2	0.7	0.7
08/24/2023 16:00	3,382.8	0.0	3,382.8	101,950.0	344.9	0.41	0.2	0.2	0.7	0.7
08/24/2023 17:00	3,378.5	0.0	3,378.5	101,950.0	344.4	0.41	0.2	0.2	0.7	0.7
08/24/2023 18:00	3,520.1	0.0	3,520.1	101,950.0	358.9	0.43	0.2	0.2	0.7	0.7
08/24/2023 19:00	3,470.9	0.0	3,470.9	101,950.0	353.9	0.43	0.2	0.2	0.7	0.7
08/24/2023 20:00	3,387.1	0.0	3,387.1	101,950.0	345.3	0.41	0.2	0.2	0.7	0.7
08/24/2023 21:00	3,602.5	0.0	3,602.5	101,950.0	367.3	0.44	0.2	0.2	0.7	0.7
08/24/2023 22:00	3,654.4	0.0	3,654.4	101,950.0	372.6	0.45	0.2	0.2	0.7	0.7
08/24/2023 23:00	3,407.0	0.0	3,407.0	101,950.0	347.3	0.41	0.2	0.2	0.7	0.7
Average/Sum#:	3,503.9	0.0	3,503.9	101,950.0	357.2	0.43	0.2	0.2	0.7	0.7
Minimum:	3,365.6	0.0	3,365.6	101,950.0	343.1	0.41	0.2	0.2	0.7	0.7
Maximum:	4,146.7	0.0	4,146.7	101,950.0	422.8	0.51	0.3	0.3	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2023 00:00	3,637.4	0.0	3,637.4	101,950.0	370.8	0.44	0.2	0.7
08/25/2023 01:00	3,433.8	0.0	3,433.8	101,950.0	350.1	0.42	0.2	0.7
08/25/2023 02:00	3,386.8	0.0	3,386.8	101,950.0	345.3	0.41	0.2	0.7
08/25/2023 03:00	3,379.2	0.0	3,379.2	101,950.0	344.5	0.41	0.2	0.7
08/25/2023 04:00	3,481.9	0.0	3,481.9	101,950.0	355.0	0.42	0.2	0.7
08/25/2023 05:00	4,089.1	0.0	4,089.1	101,950.0	416.9	0.50	0.3	0.8
08/25/2023 06:00	3,964.8	0.0	3,964.8	101,950.0	404.2	0.48	0.2	0.8
08/25/2023 07:00	3,411.4	0.0	3,411.4	101,950.0	347.8	0.42	0.2	0.7
08/25/2023 08:00	3,394.3	0.0	3,394.3	101,950.0	346.0	0.42	0.2	0.7
08/25/2023 09:00	3,389.4	0.0	3,389.4	101,950.0	345.5	0.41	0.2	0.7
08/25/2023 10:00	3,387.8	0.0	3,387.8	101,950.0	345.4	0.41	0.2	0.7
08/25/2023 11:00	3,390.9	0.0	3,390.9	101,950.0	345.7	0.41	0.2	0.7
08/25/2023 12:00	3,399.4	0.0	3,399.4	101,950.0	346.6	0.42	0.2	0.7
08/25/2023 13:00	3,400.7	0.0	3,400.7	101,950.0	346.7	0.42	0.2	0.7
08/25/2023 14:00	3,390.2	0.0	3,390.2	101,950.0	345.6	0.41	0.2	0.7
08/25/2023 15:00	3,389.6	0.0	3,389.6	101,950.0	345.6	0.41	0.2	0.7
08/25/2023 16:00	3,390.1	0.0	3,390.1	101,950.0	345.6	0.41	0.2	0.7
08/25/2023 17:00	3,386.3	0.0	3,386.3	101,950.0	345.2	0.41	0.2	0.7
08/25/2023 18:00	3,391.1	0.0	3,391.1	101,950.0	345.7	0.41	0.2	0.7
08/25/2023 19:00	3,390.5	0.0	3,390.5	101,950.0	345.7	0.41	0.2	0.7
08/25/2023 20:00	3,387.0	0.0	3,387.0	101,950.0	345.3	0.41	0.2	0.7
08/25/2023 21:00	3,401.9	0.0	3,401.9	101,950.0	346.8	0.41	0.2	0.7
08/25/2023 22:00	3,387.1	0.0	3,387.1	101,950.0	345.3	0.41	0.2	0.7
08/25/2023 23:00	3,385.3	0.0	3,385.3	101,950.0	345.1	0.41	0.2	0.7
Average/Sum#:	3,460.3	0.0	3,460.3	101,950.0	352.8	0.42	0.2	0.7
Minimum:	3,379.2	0.0	3,379.2	101,950.0	344.5	0.41	0.2	0.7
Maximum:	4,089.1	0.0	4,089.1	101,950.0	416.9	0.50	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2023 00:00	3,851.8	0.0	3,851.8	101,950.0	392.7	0.47	0.2	0.8
08/26/2023 01:00	3,887.1	0.0	3,887.1	101,950.0	396.3	0.47	0.2	0.8
08/26/2023 02:00	3,549.9	0.0	3,549.9	101,950.0	361.9	0.43	0.2	0.7
08/26/2023 03:00	3,645.8	0.0	3,645.8	101,950.0	371.7	0.45	0.2	0.7
08/26/2023 04:00	3,614.3	0.0	3,614.3	101,950.0	368.5	0.44	0.2	0.7
08/26/2023 05:00	3,845.9	0.0	3,845.9	101,950.0	392.1	0.47	0.2	0.8
08/26/2023 06:00	3,890.3	0.0	3,890.3	101,950.0	396.6	0.48	0.2	0.8
08/26/2023 07:00	3,402.0	0.0	3,402.0	101,950.0	346.8	0.42	0.2	0.7
08/26/2023 08:00	3,405.0	0.0	3,405.0	101,950.0	347.1	0.42	0.2	0.7
08/26/2023 09:00	3,399.6	0.0	3,399.6	101,950.0	346.6	0.42	0.2	0.7
08/26/2023 10:00	3,396.9	0.0	3,396.9	101,950.0	346.3	0.42	0.2	0.7
08/26/2023 11:00	3,396.8	0.0	3,396.8	101,950.0	346.3	0.42	0.2	0.7
08/26/2023 12:00	3,401.7	0.0	3,401.7	101,950.0	346.8	0.42	0.2	0.7
08/26/2023 13:00	3,402.5	0.0	3,402.5	101,950.0	346.9	0.42	0.2	0.7
08/26/2023 14:00	3,389.3	0.0	3,389.3	101,950.0	345.5	0.41	0.2	0.7
08/26/2023 15:00	3,387.6	0.0	3,387.6	101,950.0	345.4	0.41	0.2	0.7
08/26/2023 16:00	3,386.6	0.0	3,386.6	101,950.0	345.3	0.41	0.2	0.7
08/26/2023 17:00	3,525.9	0.0	3,525.9	101,950.0	359.5	0.43	0.2	0.7
08/26/2023 18:00	3,537.7	0.0	3,537.7	101,950.0	360.7	0.43	0.2	0.7
08/26/2023 19:00	3,399.4	0.0	3,399.4	101,950.0	346.6	0.41	0.2	0.7
08/26/2023 20:00	3,458.7	0.0	3,458.7	101,950.0	352.6	0.42	0.2	0.7
08/26/2023 21:00	3,460.3	0.0	3,460.3	101,950.0	352.8	0.42	0.2	0.7
08/26/2023 22:00	3,509.6	0.0	3,509.6	101,950.0	357.8	0.43	0.2	0.7
08/26/2023 23:00	3,511.7	0.0	3,511.7	101,950.0	358.0	0.43	0.2	0.7
Average/Sum#:	3,527.4	0.0	3,527.4	101,950.0	359.6	0.43	0.2	0.7
Minimum:	3,386.6	0.0	3,386.6	101,950.0	345.3	0.41	0.2	0.7
Maximum:	3,890.3	0.0	3,890.3	101,950.0	396.6	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2023 00:00	3,617.0	0.0	3,617.0	101,950.0	368.8	0.44	0.2	0.7
08/27/2023 01:00	3,483.1	0.0	3,483.1	101,950.0	355.1	0.43	0.2	0.7
08/27/2023 02:00	3,401.1	0.0	3,401.1	101,950.0	346.7	0.41	0.2	0.7
08/27/2023 03:00	3,459.8	0.0	3,459.8	101,950.0	352.7	0.42	0.2	0.7
08/27/2023 04:00	3,412.6	0.0	3,412.6	101,950.0	347.9	0.41	0.2	0.7
08/27/2023 05:00	3,700.4	0.0	3,700.4	101,950.0	377.3	0.45	0.2	0.8
08/27/2023 06:00	3,839.0	0.0	3,839.0	101,950.0	391.4	0.47	0.2	0.8
08/27/2023 07:00	3,401.1	0.0	3,401.1	101,950.0	346.7	0.42	0.2	0.7
08/27/2023 08:00	3,396.8	0.0	3,396.8	101,950.0	346.3	0.42	0.2	0.7
08/27/2023 09:00	3,386.9	0.0	3,386.9	101,950.0	345.3	0.41	0.2	0.7
08/27/2023 10:00	3,391.4	0.0	3,391.4	101,950.0	345.8	0.41	0.2	0.7
08/27/2023 11:00	3,387.4	0.0	3,387.4	101,950.0	345.3	0.41	0.2	0.7
08/27/2023 12:00	3,407.2	0.0	3,407.2	101,950.0	347.4	0.42	0.2	0.7
08/27/2023 13:00	3,414.1	0.0	3,414.1	101,950.0	348.1	0.42	0.2	0.7
08/27/2023 14:00	3,398.4	0.0	3,398.4	101,950.0	346.5	0.42	0.2	0.7
08/27/2023 15:00	3,466.2	0.0	3,466.2	101,950.0	353.4	0.42	0.2	0.7
08/27/2023 16:00	3,502.0	0.0	3,502.0	101,950.0	357.0	0.43	0.2	0.7
08/27/2023 17:00	3,707.2	0.0	3,707.2	101,950.0	377.9	0.45	0.2	0.8
08/27/2023 18:00	3,402.8	0.0	3,402.8	101,950.0	346.9	0.42	0.2	0.7
08/27/2023 19:00	3,730.0	0.0	3,730.0	101,950.0	380.3	0.46	0.2	0.8
08/27/2023 20:00	4,158.0	0.0	4,158.0	101,950.0	423.9	0.51	0.3	0.8
08/27/2023 21:00	4,157.5	0.0	4,157.5	101,950.0	423.9	0.51	0.3	0.8
08/27/2023 22:00	4,113.7	0.0	4,113.7	101,950.0	419.4	0.50	0.3	0.8
08/27/2023 23:00	3,744.5	0.0	3,744.5	101,950.0	381.8	0.46	0.2	0.8
Average/Sum#:	3,586.6	0.0	3,586.6	101,950.0	365.7	0.44	0.2	0.7
Minimum:	3,386.9	0.0	3,386.9	101,950.0	345.3	0.41	0.2	0.7
Maximum:	4,158.0	0.0	4,158.0	101,950.0	423.9	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2023 00:00	3,529.6	0.0	3,529.6	101,950.0	359.8	0.43	0.2	0.7
08/28/2023 01:00	3,378.1	0.0	3,378.1	101,950.0	344.4	0.41	0.2	0.7
08/28/2023 02:00	3,378.2	0.0	3,378.2	101,950.0	344.4	0.41	0.2	0.7
08/28/2023 03:00	3,375.8	0.0	3,375.8	101,950.0	344.2	0.41	0.2	0.7
08/28/2023 04:00	3,393.8	0.0	3,393.8	101,950.0	346.0	0.41	0.2	0.7
08/28/2023 05:00	3,985.8	0.0	3,985.8	101,950.0	406.4	0.49	0.2	0.8
08/28/2023 06:00	4,321.8	0.0	4,321.8	101,950.0	440.6	0.53	0.3	0.9
08/28/2023 07:00	3,706.6	0.0	3,706.6	101,950.0	377.9	0.46	0.2	0.8
08/28/2023 08:00	3,394.5	0.0	3,394.5	101,950.0	346.1	0.42	0.2	0.7
08/28/2023 09:00	3,383.8	0.0	3,383.8	101,950.0	345.0	0.41	0.2	0.7
08/28/2023 10:00	3,383.1	0.0	3,383.1	101,950.0	344.9	0.41	0.2	0.7
08/28/2023 11:00	3,397.9	0.0	3,397.9	101,950.0	346.4	0.41	0.2	0.7
08/28/2023 12:00	3,466.1	0.0	3,466.1	101,950.0	353.4	0.42	0.2	0.7
08/28/2023 13:00	3,781.4	0.0	3,781.4	101,950.0	385.5	0.46	0.2	0.8
08/28/2023 14:00	4,095.5	0.0	4,095.5	101,950.0	417.5	0.50	0.3	0.8
08/28/2023 15:00	4,126.5	0.0	4,126.5	101,950.0	420.7	0.51	0.3	0.8
08/28/2023 16:00	3,970.9	0.0	3,970.9	101,950.0	404.8	0.49	0.2	0.8
08/28/2023 17:00	3,399.4	0.0	3,399.4	101,950.0	346.6	0.42	0.2	0.7
08/28/2023 18:00	3,676.3	3.1	3,676.4	101,950.0	374.8	0.45	0.2	0.7
08/28/2023 19:00	4,237.9	592.2	4,830.1	101,950.0	492.4	0.59	0.3	1.0
08/28/2023 20:00	4,001.0	261.4	4,136.9	101,950.0	421.8	0.52	0.3	0.9
08/28/2023 21:00	3,587.7	0.0	3,587.7	101,950.0	365.8	0.44	0.2	0.7
08/28/2023 22:00	3,633.9	0.0	3,633.9	101,950.0	370.5	0.44	0.2	0.7
08/28/2023 23:00	3,463.5	0.0	3,463.5	101,950.0	353.1	0.42	0.2	0.7
Average/Sum#:	3,669.5	35.7	3,699.9	101,950.0	377.2	0.45	0.2	0.8
Minimum:	3,375.8	0.0	3,375.8	101,950.0	344.2	0.41	0.2	0.7
Maximum:	4,321.8	592.2	4,830.1	101,950.0	492.4	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2023 00:00	3,638.1	0.0	3,638.1	101,950.0	370.9	0.44	0.2	0.7
08/29/2023 01:00	3,946.6	0.0	3,946.6	101,950.0	402.4	0.48	0.2	0.8
08/29/2023 02:00	3,837.3	0.0	3,837.3	101,950.0	391.2	0.47	0.2	0.8
08/29/2023 03:00	3,751.0	0.0	3,751.0	101,950.0	382.4	0.46	0.2	0.8
08/29/2023 04:00	3,783.8	0.0	3,783.8	101,950.0	385.8	0.46	0.2	0.8
08/29/2023 05:00	4,058.2	0.0	4,058.2	101,950.0	413.7	0.50	0.2	0.8
08/29/2023 06:00	4,043.6	0.0	4,043.6	101,950.0	412.2	0.50	0.2	0.8
08/29/2023 07:00	4,412.2	82.9	4,476.0	101,950.0	456.3	0.55	0.3	0.9
08/29/2023 08:00	4,400.1	1,143.3	5,543.4	101,950.0	565.1	0.68	0.3	1.1
08/29/2023 09:00	4,389.3	1,486.7	5,876.0	101,950.0	599.1	0.72	0.4	1.2
08/29/2023 10:00	4,374.3	1,508.4	5,882.7	101,950.0	599.7	0.72	0.4	1.2
08/29/2023 11:00	4,357.5	1,546.3	5,903.8	101,950.0	601.9	0.72	0.4	1.2
08/29/2023 12:00	4,337.9	1,600.4	5,938.3	101,950.0	605.4	0.73	0.4	1.2
08/29/2023 13:00	4,311.4	1,652.0	5,963.4	101,950.0	608.0	0.73	0.4	1.2
08/29/2023 14:00	4,280.3	1,695.3	5,975.6	101,950.0	609.2	0.73	0.4	1.2
08/29/2023 15:00	4,256.5	1,721.7	5,978.2	101,950.0	609.5	0.73	0.4	1.2
08/29/2023 16:00	4,243.8	1,748.0	5,991.8	101,950.0	610.9	0.73	0.4	1.2
08/29/2023 17:00	4,225.1	300.6	4,414.5	101,950.0	450.1	0.55	0.3	0.9
08/29/2023 18:00	4,255.1	571.3	4,826.4	101,950.0	492.1	0.59	0.3	1.0
08/29/2023 19:00	4,025.3	291.8	4,215.0	101,950.0	429.7	0.53	0.3	0.9
08/29/2023 20:00	3,372.5	0.0	3,372.5	101,950.0	343.8	0.41	0.2	0.7
08/29/2023 21:00	3,366.4	0.0	3,366.4	101,950.0	343.2	0.41	0.2	0.7
08/29/2023 22:00	3,371.5	0.0	3,371.5	101,950.0	343.7	0.41	0.2	0.7
08/29/2023 23:00	3,368.2	0.0	3,368.2	101,950.0	343.4	0.41	0.2	0.7
Average/Sum#:	4,016.9	639.5	4,646.8	101,950.0	473.7	0.57	0.3	0.9
Minimum:	3,366.4	0.0	3,366.4	101,950.0	343.2	0.41	0.2	0.7
Maximum:	4,412.2	1,748.0	5,991.8	101,950.0	610.9	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2023 00:00	3,365.5	0.0	3,365.5	101,950.0	343.1	0.41	0.2	0.7
08/30/2023 01:00	3,361.9	0.0	3,361.9	101,950.0	342.7	0.41	0.2	0.7
08/30/2023 02:00	3,364.9	0.0	3,364.9	101,950.0	343.1	0.41	0.2	0.7
08/30/2023 03:00	3,362.6	0.0	3,362.6	101,950.0	342.8	0.41	0.2	0.7
08/30/2023 04:00	3,360.2	0.0	3,360.2	101,950.0	342.6	0.41	0.2	0.7
08/30/2023 05:00	3,368.7	0.0	3,368.7	101,950.0	343.4	0.41	0.2	0.7
08/30/2023 06:00	3,447.1	0.0	3,447.1	101,950.0	351.4	0.42	0.2	0.7
08/30/2023 07:00	3,629.4	0.0	3,629.4	101,950.0	370.0	0.44	0.2	0.7
08/30/2023 08:00	3,734.7	30.3	3,737.7	101,950.0	381.1	0.46	0.2	0.8
08/30/2023 09:00	4,363.9	1,530.7	5,894.6	101,950.0	601.0	0.72	0.4	1.2
08/30/2023 10:00	4,341.6	1,573.8	5,915.4	101,950.0	603.1	0.72	0.4	1.2
08/30/2023 11:00	4,315.7	1,625.2	5,940.9	101,950.0	605.7	0.73	0.4	1.2
08/30/2023 12:00	4,303.7	1,503.2	5,806.9	101,950.0	592.0	0.71	0.4	1.2
08/30/2023 13:00	4,271.0	552.8	4,823.8	101,950.0	491.8	0.59	0.3	1.0
08/30/2023 14:00	3,570.6	37.5	3,576.2	101,950.0	364.6	0.44	0.2	0.7
08/30/2023 15:00	3,365.4	0.0	3,365.4	101,950.0	343.1	0.41	0.2	0.7
08/30/2023 16:00	3,364.8	0.0	3,364.8	101,950.0	343.0	0.41	0.2	0.7
08/30/2023 17:00	3,364.5	0.0	3,364.5	101,950.0	343.0	0.41	0.2	0.7
08/30/2023 18:00	3,556.4	1.0	3,556.5	101,950.0	362.6	0.43	0.2	0.7
08/30/2023 19:00	3,377.6	0.0	3,377.6	101,950.0	344.3	0.41	0.2	0.7
08/30/2023 20:00	3,363.2	0.0	3,363.2	101,950.0	342.9	0.41	0.2	0.7
08/30/2023 21:00	3,356.9	0.0	3,356.9	101,950.0	342.2	0.41	0.2	0.7
08/30/2023 22:00	3,358.1	0.0	3,358.1	101,950.0	342.4	0.41	0.2	0.7
08/30/2023 23:00	3,355.0	0.0	3,355.0	101,950.0	342.0	0.41	0.2	0.7
Average/Sum#:	3,609.3	285.6	3,892.4	101,950.0	396.8	0.48	0.2	0.8
Minimum:	3,355.0	0.0	3,355.0	101,950.0	342.0	0.41	0.2	0.7
Maximum:	4,363.9	1,625.2	5,940.9	101,950.0	605.7	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2023 00:00	3,430.7	0.0	3,430.7	101,950.0	349.8	0.42	0.2	0.7
08/31/2023 01:00	3,363.0	0.0	3,363.0	101,950.0	342.9	0.41	0.2	0.7
08/31/2023 02:00	3,365.3	0.0	3,365.3	101,950.0	343.1	0.41	0.2	0.7
08/31/2023 03:00	3,359.3	0.0	3,359.3	101,950.0	342.5	0.41	0.2	0.7
08/31/2023 04:00	3,445.1	0.0	3,445.1	101,950.0	351.2	0.42	0.2	0.7
08/31/2023 05:00	3,814.2	0.0	3,814.2	101,950.0	388.9	0.47	0.2	0.8
08/31/2023 06:00	3,885.9	0.0	3,885.9	101,950.0	396.2	0.47	0.2	0.8
08/31/2023 07:00	3,432.3	0.0	3,432.3	101,950.0	349.9	0.42	0.2	0.7
08/31/2023 08:00	4,207.8	1,547.3	5,646.8	101,950.0	575.7	0.70	0.4	1.2
08/31/2023 09:00	4,203.3	1,794.4	5,997.7	101,950.0	611.5	0.73	0.4	1.2
08/31/2023 10:00	4,269.9	1,710.9	5,980.8	101,950.0	609.7	0.73	0.4	1.2
08/31/2023 11:00	4,252.6	1,731.1	5,983.7	101,950.0	610.0	0.73	0.4	1.2
08/31/2023 12:00	4,253.4	1,744.7	5,998.1	101,950.0	611.5	0.73	0.4	1.2
08/31/2023 13:00	4,226.6	1,787.0	6,013.6	101,950.0	613.1	0.74	0.4	1.2
08/31/2023 14:00	4,203.8	1,820.6	6,024.4	101,950.0	614.2	0.74	0.4	1.2
08/31/2023 15:00	4,197.9	1,821.9	6,019.8	101,950.0	613.7	0.74	0.4	1.2
08/31/2023 16:00	4,208.8	1,791.8	6,000.6	101,950.0	611.8	0.74	0.4	1.2
08/31/2023 17:00	4,214.5	626.7	4,797.3	101,950.0	489.1	0.59	0.3	1.0
08/31/2023 18:00	3,400.6	0.0	3,400.6	101,950.0	346.7	0.41	0.2	0.7
08/31/2023 19:00	3,367.6	0.0	3,367.6	101,950.0	343.3	0.41	0.2	0.7
08/31/2023 20:00	3,359.6	0.0	3,359.6	101,950.0	342.5	0.41	0.2	0.7
08/31/2023 21:00	3,366.6	0.0	3,366.6	101,950.0	343.2	0.41	0.2	0.7
08/31/2023 22:00	3,480.7	0.0	3,480.7	101,950.0	354.9	0.42	0.2	0.7
08/31/2023 23:00	3,369.6	0.0	3,369.6	101,950.0	343.5	0.41	0.2	0.7
Average/Sum#:	3,778.3	682.4	4,454.3	101,950.0	454.1	0.54	0.3	0.9
Minimum:	3,359.3	0.0	3,359.3	101,950.0	342.5	0.41	0.2	0.7
Maximum:	4,269.9	1,821.9	6,024.4	101,950.0	614.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2023 00:00	3,372.2	0.0	3,372.2	101,950.0	343.8	0.41	0.2	0.7
09/01/2023 01:00	3,369.5	0.0	3,369.5	101,950.0	343.5	0.41	0.2	0.7
09/01/2023 02:00	3,368.4	0.0	3,368.4	101,950.0	343.4	0.41	0.2	0.7
09/01/2023 03:00	3,370.4	0.0	3,370.4	101,950.0	343.6	0.41	0.2	0.7
09/01/2023 04:00	3,370.1	0.0	3,370.1	101,950.0	343.6	0.41	0.2	0.7
09/01/2023 05:00	3,433.7	0.0	3,433.7	101,950.0	350.1	0.42	0.2	0.7
09/01/2023 06:00	3,610.2	0.0	3,610.2	101,950.0	368.1	0.44	0.2	0.7
09/01/2023 07:00	3,702.8	0.0	3,702.8	101,950.0	377.5	0.45	0.2	0.8
09/01/2023 08:00	3,372.5	0.0	3,372.5	101,950.0	343.8	0.41	0.2	0.7
09/01/2023 09:00	3,381.9	0.0	3,381.9	101,950.0	344.8	0.41	0.2	0.7
09/01/2023 10:00	3,541.0	0.0	3,541.0	101,950.0	361.0	0.43	0.2	0.7
09/01/2023 11:00	3,374.8	0.0	3,374.8	101,950.0	344.1	0.41	0.2	0.7
09/01/2023 12:00	3,377.5	0.0	3,377.5	101,950.0	344.3	0.41	0.2	0.7
09/01/2023 13:00	3,380.1	0.0	3,380.1	101,950.0	344.6	0.41	0.2	0.7
09/01/2023 14:00	3,411.9	0.0	3,411.9	101,950.0	347.8	0.41	0.2	0.7
09/01/2023 15:00	3,682.6	0.0	3,682.6	101,950.0	375.4	0.45	0.2	0.8
09/01/2023 16:00	3,373.4	0.0	3,373.4	101,950.0	343.9	0.41	0.2	0.7
09/01/2023 17:00	3,369.1	0.0	3,369.1	101,950.0	343.5	0.41	0.2	0.7
09/01/2023 18:00	3,373.3	0.0	3,373.3	101,950.0	343.9	0.41	0.2	0.7
09/01/2023 19:00	3,372.2	0.0	3,372.2	101,950.0	343.8	0.41	0.2	0.7
09/01/2023 20:00	3,369.2	0.0	3,369.2	101,950.0	343.5	0.41	0.2	0.7
09/01/2023 21:00	3,376.7	0.0	3,376.7	101,950.0	344.3	0.41	0.2	0.7
09/01/2023 22:00	3,608.8	0.0	3,608.8	101,950.0	367.9	0.44	0.2	0.7
09/01/2023 23:00	3,523.0	0.0	3,523.0	101,950.0	359.2	0.43	0.2	0.7
Average/Sum#:	3,436.9	0.0	3,436.9	101,950.0	350.4	0.42	0.2	0.7
Minimum:	3,368.4	0.0	3,368.4	101,950.0	343.4	0.41	0.2	0.7
Maximum:	3,702.8	0.0	3,702.8	101,950.0	377.5	0.45	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2023 00:00	3,528.9	0.0	3,528.9	101,950.0	359.8	0.43	0.2	0.7			
09/02/2023 01:00	3,412.9	0.0	3,412.9	101,950.0	347.9	0.42	0.2	0.7			
09/02/2023 02:00	3,405.0	0.0	3,405.0	101,950.0	347.1	0.41	0.2	0.7			
09/02/2023 03:00	3,432.0	0.0	3,432.0	101,950.0	349.9	0.42	0.2	0.7			
09/02/2023 04:00	3,398.0	0.0	3,398.0	101,950.0	346.4	0.41	0.2	0.7			
09/02/2023 05:00	3,574.1	0.0	3,574.1	101,950.0	364.4	0.44	0.2	0.7			
09/02/2023 06:00	3,383.9	0.0	3,383.9	101,950.0	345.0	0.41	0.2	0.7			
09/02/2023 07:00	3,385.2	0.0	3,385.2	101,950.0	345.1	0.41	0.2	0.7			
09/02/2023 08:00	3,378.1	0.0	3,378.1	101,950.0	344.4	0.41	0.2	0.7			
09/02/2023 09:00	3,428.5	0.0	3,428.5	101,950.0	349.5	0.42	0.2	0.7			
09/02/2023 10:00	3,622.2	0.0	3,622.2	101,950.0	369.3	0.44	0.2	0.7			
09/02/2023 11:00	3,938.8	0.0	3,938.8	101,950.0	401.6	0.48	0.2	0.8			
09/02/2023 12:00	3,441.1	0.0	3,441.1	101,950.0	350.8	0.42	0.2	0.7			
09/02/2023 13:00	3,587.5	0.0	3,587.5	101,950.0	365.7	0.44	0.2	0.7			
09/02/2023 14:00	3,627.9	0.0	3,627.9	101,950.0	369.9	0.44	0.2	0.7			
09/02/2023 15:00	4,106.5	0.0	4,106.5	101,950.0	418.7	0.50	0.3	0.8			
09/02/2023 16:00	3,396.9	0.0	3,396.9	101,950.0	346.3	0.41	0.2	0.7			
09/02/2023 17:00	3,466.6	0.0	3,466.6	101,950.0	353.4	0.42	0.2	0.7			
09/02/2023 18:00	3,487.6	0.0	3,487.6	101,950.0	355.6	0.42	0.2	0.7			
09/02/2023 19:00	3,413.2	0.0	3,413.2	101,950.0	348.0	0.41	0.2	0.7			
09/02/2023 20:00	3,382.6	0.0	3,382.6	101,950.0	344.9	0.41	0.2	0.7			
09/02/2023 21:00	3,425.8	0.0	3,425.8	101,950.0	349.3	0.42	0.2	0.7			
09/02/2023 22:00	3,597.0	0.0	3,597.0	101,950.0	366.7	0.44	0.2	0.7			
09/02/2023 23:00	3,378.9	0.0	3,378.9	101,950.0	344.5	0.41	0.2	0.7			
Average/Sum#:	3,508.3	0.0	3,508.3	101,950.0	357.7	0.43	0.2	0.7			
Minimum:	3,378.1	0.0	3,378.1	101,950.0	344.4	0.41	0.2	0.7			
Maximum:	4,106.5	0.0	4,106.5	101,950.0	418.7	0.50	0.3	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2023 00:00	3,709.6	0.0	3,709.6	101,950.0	378.2	0.45	0.2	0.8
09/03/2023 01:00	3,467.4	0.0	3,467.4	101,950.0	353.5	0.42	0.2	0.7
09/03/2023 02:00	3,049.7	0.0	3,049.7	101,950.0	310.9	0.41	0.2	0.7
09/03/2023 03:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 04:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 05:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 06:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 07:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 08:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 09:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 10:00	0.0	0.0	0.0	101,950.0	0.0	0.00	0.0	0.0
09/03/2023 11:00	2,981.4	0.0	2,981.4	101,950.0	304.0	0.42	0.2	0.7
09/03/2023 12:00	3,390.5	0.0	3,390.5	101,950.0	345.7	0.41	0.2	0.7
09/03/2023 13:00	3,389.5	0.0	3,389.5	101,950.0	345.6	0.41	0.2	0.7
09/03/2023 14:00	3,385.9	0.0	3,385.9	101,950.0	345.2	0.41	0.2	0.7
09/03/2023 15:00	3,382.4	0.0	3,382.4	101,950.0	344.8	0.41	0.2	0.7
09/03/2023 16:00	3,383.7	0.0	3,383.7	101,950.0	345.0	0.41	0.2	0.7
09/03/2023 17:00	3,381.3	0.0	3,381.3	101,950.0	344.7	0.41	0.2	0.7
09/03/2023 18:00	3,381.0	0.0	3,381.0	101,950.0	344.7	0.41	0.2	0.7
09/03/2023 19:00	3,384.2	0.0	3,384.2	101,950.0	345.0	0.41	0.2	0.7
09/03/2023 20:00	3,385.6	0.0	3,385.6	101,950.0	345.2	0.41	0.2	0.7
09/03/2023 21:00	3,513.1	0.0	3,513.1	101,950.0	358.2	0.43	0.2	0.7
09/03/2023 22:00	3,381.6	0.0	3,381.6	101,950.0	344.8	0.41	0.2	0.7
09/03/2023 23:00	3,376.7	0.0	3,376.7	101,950.0	344.3	0.41	0.2	0.7
Average/Sum#:	3,371.5	0.0	3,371.5	101,950.0	343.7	0.42	0.2	0.7
Minimum:	2,981.4	0.0	2,981.4	101,950.0	304.0	0.41	0.2	0.7
Maximum:	3,709.6	0.0	3,709.6	101,950.0	378.2	0.45	0.2	0.8
%SI	33.33	33.33	33.33	0.00	33.33	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2023 00:00	3,376.0	0.0	3,376.0	101,950.0	344.2	0.41	0.2	0.7
09/04/2023 01:00	3,378.8	0.0	3,378.8	101,950.0	344.5	0.41	0.2	0.7
09/04/2023 02:00	3,383.0	0.0	3,383.0	101,950.0	344.9	0.41	0.2	0.7
09/04/2023 03:00	3,382.4	0.0	3,382.4	101,950.0	344.8	0.41	0.2	0.7
09/04/2023 04:00	3,387.0	0.0	3,387.0	101,950.0	345.3	0.41	0.2	0.7
09/04/2023 05:00	3,384.2	0.0	3,384.2	101,950.0	345.0	0.41	0.2	0.7
09/04/2023 06:00	3,385.8	0.0	3,385.8	101,950.0	345.2	0.41	0.2	0.7
09/04/2023 07:00	3,391.7	0.0	3,391.7	101,950.0	345.8	0.41	0.2	0.7
09/04/2023 08:00	3,393.3	0.0	3,393.3	101,950.0	345.9	0.42	0.2	0.7
09/04/2023 09:00	3,393.4	0.0	3,393.4	101,950.0	346.0	0.42	0.2	0.7
09/04/2023 10:00	3,393.3	0.0	3,393.3	101,950.0	345.9	0.42	0.2	0.7
09/04/2023 11:00	3,393.0	0.0	3,393.0	101,950.0	345.9	0.42	0.2	0.7
09/04/2023 12:00	3,402.4	0.0	3,402.4	101,950.0	346.9	0.42	0.2	0.7
09/04/2023 13:00	3,402.7	0.0	3,402.7	101,950.0	346.9	0.42	0.2	0.7
09/04/2023 14:00	3,386.0	0.0	3,386.0	101,950.0	345.2	0.41	0.2	0.7
09/04/2023 15:00	3,382.8	0.0	3,382.8	101,950.0	344.9	0.41	0.2	0.7
09/04/2023 16:00	3,382.1	0.0	3,382.1	101,950.0	344.8	0.41	0.2	0.7
09/04/2023 17:00	3,464.1	0.0	3,464.1	101,950.0	353.2	0.42	0.2	0.7
09/04/2023 18:00	3,779.9	0.0	3,779.9	101,950.0	385.4	0.46	0.2	0.8
09/04/2023 19:00	4,207.0	230.0	4,315.1	101,950.0	439.9	0.54	0.3	0.9
09/04/2023 20:00	4,264.6	361.5	4,543.0	101,950.0	463.2	0.57	0.3	0.9
09/04/2023 21:00	3,800.5	0.0	3,800.5	101,950.0	387.5	0.47	0.2	0.8
09/04/2023 22:00	3,771.6	0.0	3,771.6	103,340.0	389.8	0.47	0.2	0.8
09/04/2023 23:00	3,463.5	0.0	3,463.5	103,340.0	357.9	0.43	0.2	0.7
Average/Sum#:	3,514.5	24.6	3,530.7	102,065.8	360.4	0.43	0.2	0.7
Minimum:	3,376.0	0.0	3,376.0	101,950.0	344.2	0.41	0.2	0.7
Maximum:	4,264.6	361.5	4,543.0	103,340.0	463.2	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2023 00:00	3,806.2	0.0	3,806.2	103,340.0	393.3	0.47	0.2	0.8
09/05/2023 01:00	3,462.5	0.0	3,462.5	103,340.0	357.8	0.43	0.2	0.7
09/05/2023 02:00	3,491.0	0.0	3,491.0	103,340.0	360.8	0.43	0.2	0.7
09/05/2023 03:00	3,584.3	0.0	3,584.3	103,340.0	370.4	0.44	0.2	0.7
09/05/2023 04:00	4,019.3	0.0	4,019.3	103,340.0	415.4	0.50	0.2	0.8
09/05/2023 05:00	4,140.0	0.0	4,140.0	103,340.0	427.8	0.51	0.3	0.9
09/05/2023 06:00	4,218.2	0.0	4,218.2	103,340.0	435.9	0.52	0.3	0.9
09/05/2023 07:00	4,384.1	1,414.7	5,629.0	103,340.0	581.7	0.72	0.4	1.2
09/05/2023 08:00	4,368.3	1,570.3	5,938.6	103,340.0	613.7	0.74	0.4	1.2
09/05/2023 09:00	4,300.0	301.0	4,456.5	103,340.0	460.5	0.57	0.3	1.0
09/05/2023 10:00	4,264.4	2.8	4,264.5	103,340.0	440.7	0.53	0.3	0.9
09/05/2023 11:00	4,227.9	1,208.2	5,436.1	103,340.0	561.8	0.67	0.3	1.1
09/05/2023 12:00	4,220.7	614.5	4,546.4	103,340.0	469.8	0.60	0.3	1.0
09/05/2023 13:00	4,236.3	0.0	4,236.3	103,340.0	437.8	0.53	0.3	0.9
09/05/2023 14:00	4,230.8	0.0	4,230.8	103,340.0	437.2	0.52	0.3	0.9
09/05/2023 15:00	4,227.9	0.0	4,227.9	103,340.0	436.9	0.52	0.3	0.9
09/05/2023 16:00	4,223.3	0.0	4,223.3	103,340.0	436.4	0.52	0.3	0.9
09/05/2023 17:00	3,854.0	0.0	3,854.0	103,340.0	398.3	0.48	0.2	0.8
09/05/2023 18:00	4,258.0	205.1	4,323.6	103,340.0	446.8	0.55	0.3	0.9
09/05/2023 19:00	4,268.9	690.2	4,959.1	103,340.0	512.5	0.62	0.3	1.0
09/05/2023 20:00	4,229.4	261.8	4,360.3	103,340.0	450.6	0.56	0.3	0.9
09/05/2023 21:00	4,216.5	0.0	4,216.5	103,340.0	435.7	0.52	0.3	0.9
09/05/2023 22:00	4,082.8	0.0	4,082.8	103,340.0	421.9	0.51	0.3	0.8
09/05/2023 23:00	3,937.2	0.0	3,937.2	103,340.0	406.9	0.49	0.2	0.8
Average/Sum#:	4,093.8	261.2	4,318.5	103,340.0	446.3	0.54	0.3	0.9
Minimum:	3,462.5	0.0	3,462.5	103,340.0	357.8	0.43	0.2	0.7
Maximum:	4,384.1	1,570.3	5,938.6	103,340.0	613.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2023 00:00	3,923.3	0.0	3,923.3	103,340.0	405.4	0.49	0.2	0.8
09/06/2023 01:00	3,680.5	0.0	3,680.5	103,340.0	380.3	0.46	0.2	0.8
09/06/2023 02:00	3,396.1	0.0	3,396.1	103,340.0	351.0	0.42	0.2	0.7
09/06/2023 03:00	3,448.3	0.0	3,448.3	103,340.0	356.3	0.43	0.2	0.7
09/06/2023 04:00	3,615.1	0.0	3,615.1	103,340.0	373.6	0.45	0.2	0.7
09/06/2023 05:00	4,106.2	0.0	4,106.2	103,340.0	424.3	0.51	0.3	0.8
09/06/2023 06:00	4,208.0	0.0	4,208.0	103,340.0	434.9	0.52	0.3	0.9
09/06/2023 07:00	3,712.2	0.0	3,712.2	103,340.0	383.6	0.46	0.2	0.8
09/06/2023 08:00	3,387.6	0.0	3,387.6	103,340.0	350.1	0.42	0.2	0.7
09/06/2023 09:00	3,385.8	0.0	3,385.8	103,340.0	349.9	0.42	0.2	0.7
09/06/2023 10:00	3,385.9	0.0	3,385.9	103,340.0	349.9	0.42	0.2	0.7
09/06/2023 11:00	3,387.3	0.0	3,387.3	103,340.0	350.0	0.42	0.2	0.7
09/06/2023 12:00	3,410.2	0.0	3,410.2	103,340.0	352.4	0.42	0.2	0.7
09/06/2023 13:00	3,387.8	0.0	3,387.8	103,340.0	350.1	0.42	0.2	0.7
09/06/2023 14:00	3,377.1	0.0	3,377.1	103,340.0	349.0	0.42	0.2	0.7
09/06/2023 15:00	3,376.4	0.0	3,376.4	103,340.0	348.9	0.42	0.2	0.7
09/06/2023 16:00	3,378.6	0.0	3,378.6	103,340.0	349.1	0.42	0.2	0.7
09/06/2023 17:00	3,645.6	0.0	3,645.6	103,340.0	376.7	0.45	0.2	0.8
09/06/2023 18:00	3,954.0	0.0	3,954.0	103,340.0	408.6	0.49	0.2	0.8
09/06/2023 19:00	3,656.8	0.0	3,656.8	103,340.0	377.9	0.45	0.2	0.8
09/06/2023 20:00	4,032.8	0.0	4,032.8	103,340.0	416.7	0.50	0.3	0.8
09/06/2023 21:00	3,882.3	0.0	3,882.3	103,340.0	401.2	0.48	0.2	0.8
09/06/2023 22:00	4,029.3	0.0	4,029.3	103,340.0	416.4	0.50	0.2	0.8
09/06/2023 23:00	3,661.8	0.0	3,661.8	103,340.0	378.4	0.45	0.2	0.8
Average/Sum#:	3,642.9	0.0	3,642.9	103,340.0	376.4	0.45	0.2	0.8
Minimum:	3,376.4	0.0	3,376.4	103,340.0	348.9	0.42	0.2	0.7
Maximum:	4,208.0	0.0	4,208.0	103,340.0	434.9	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2023 00:00	3,787.9	0.0	3,787.9	103,340.0	391.4	0.47	0.2	0.8
09/07/2023 01:00	3,412.8	0.0	3,412.8	103,340.0	352.7	0.42	0.2	0.7
09/07/2023 02:00	3,386.2	0.0	3,386.2	103,340.0	349.9	0.42	0.2	0.7
09/07/2023 03:00	3,392.1	0.0	3,392.1	103,340.0	350.5	0.42	0.2	0.7
09/07/2023 04:00	3,389.1	0.0	3,389.1	103,340.0	350.2	0.42	0.2	0.7
09/07/2023 05:00	3,768.9	0.0	3,768.9	103,340.0	389.5	0.47	0.2	0.8
09/07/2023 06:00	4,159.2	0.0	4,159.2	103,340.0	429.8	0.52	0.3	0.9
09/07/2023 07:00	3,620.5	0.0	3,620.5	103,340.0	374.1	0.45	0.2	0.7
09/07/2023 08:00	3,396.1	0.0	3,396.1	103,340.0	351.0	0.42	0.2	0.7
09/07/2023 09:00	3,772.7	0.0	3,772.7	103,340.0	389.9	0.47	0.2	0.8
09/07/2023 10:00	3,557.5	0.0	3,557.5	103,340.0	367.6	0.44	0.2	0.7
09/07/2023 11:00	3,589.4	0.0	3,589.4	103,340.0	370.9	0.45	0.2	0.7
09/07/2023 12:00	3,616.0	0.0	3,616.0	103,340.0	373.7	0.45	0.2	0.7
09/07/2023 13:00	3,491.9	0.0	3,491.9	103,340.0	360.9	0.43	0.2	0.7
09/07/2023 14:00	3,897.6	0.0	3,897.6	103,340.0	402.8	0.48	0.2	0.8
09/07/2023 15:00	4,044.8	0.0	4,044.8	103,340.0	418.0	0.50	0.3	0.8
09/07/2023 16:00	3,610.8	0.0	3,610.8	103,340.0	373.1	0.45	0.2	0.7
09/07/2023 17:00	3,844.0	0.0	3,844.0	103,340.0	397.2	0.48	0.2	0.8
09/07/2023 18:00	3,842.8	0.0	3,842.8	103,340.0	397.1	0.48	0.2	0.8
09/07/2023 19:00	3,572.9	0.0	3,572.9	103,340.0	369.2	0.44	0.2	0.7
09/07/2023 20:00	4,050.3	0.0	4,050.3	103,340.0	418.6	0.50	0.3	0.8
09/07/2023 21:00	4,136.8	0.0	4,136.8	103,340.0	427.5	0.51	0.3	0.9
09/07/2023 22:00	3,877.3	0.0	3,877.3	103,340.0	400.7	0.48	0.2	0.8
09/07/2023 23:00	3,550.9	0.0	3,550.9	103,340.0	367.0	0.45	0.2	0.7
Average/Sum#:	3,698.7	0.0	3,698.7	103,340.0	382.2	0.46	0.2	0.8
Minimum:	3,386.2	0.0	3,386.2	103,340.0	349.9	0.42	0.2	0.7
Maximum:	4,159.2	0.0	4,159.2	103,340.0	429.8	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2023 00:00	1,421.2	0.0	1,421.2	103,340.0	146.9	0.00	0.0	0.0
09/08/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.00	0.0	0.0
09/08/2023 12:00	2,808.9	0.0	2,808.9	103,340.0	290.3	0.00	0.0	0.0
09/08/2023 13:00	4,145.4	0.0	4,145.4	103,340.0	428.4	0.52	0.3	0.9
09/08/2023 14:00	4,258.5	0.0	4,258.5	103,340.0	440.1	0.53	0.3	0.9
09/08/2023 15:00	4,259.3	0.0	4,259.3	103,340.0	440.2	0.53	0.3	0.9
09/08/2023 16:00	4,239.9	457.3	4,482.3	103,340.0	463.2	0.58	0.3	1.0
09/08/2023 17:00	4,270.2	1,276.0	5,546.2	103,340.0	573.1	0.69	0.3	1.1
09/08/2023 18:00	4,278.7	1,860.9	6,139.6	103,340.0	634.5	0.76	0.4	1.3
09/08/2023 19:00	4,301.1	1,025.9	5,327.0	103,340.0	550.5	0.66	0.3	1.1
09/08/2023 20:00	4,336.2	1,270.4	5,606.6	103,340.0	579.4	0.69	0.3	1.2
09/08/2023 21:00	4,338.1	1,444.1	5,782.2	103,340.0	597.5	0.72	0.4	1.2
09/08/2023 22:00	4,333.2	961.4	5,294.6	103,340.0	547.1	0.66	0.3	1.1
09/08/2023 23:00	4,113.0	1.5	4,113.0	103,340.0	425.0	0.51	0.3	0.9
Average/Sum#:	3,931.1	638.3	4,552.7	103,340.0	470.5	0.62	0.3	1.1
Minimum:	1,421.2	0.0	1,421.2	103,340.0	146.9	0.51	0.3	0.9
Maximum:	4,338.1	1,860.9	6,139.6	103,340.0	634.5	0.76	0.4	1.3
%SI	45.83	45.83	45.83	0.00	45.83	54.17	54.17	54.17

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2023 00:00	4,191.0	0.0	4,191.0	103,340.0	433.1	0.52	0.3	0.9
09/09/2023 01:00	4,179.5	0.0	4,179.5	103,340.0	431.9	0.52	0.3	0.9
09/09/2023 02:00	3,872.8	0.0	3,872.8	103,340.0	400.2	0.48	0.2	0.8
09/09/2023 03:00	3,900.1	0.0	3,900.1	103,340.0	403.0	0.48	0.2	0.8
09/09/2023 04:00	4,178.2	0.0	4,178.2	103,340.0	431.8	0.52	0.3	0.9
09/09/2023 05:00	4,219.4	0.0	4,219.4	103,340.0	436.0	0.52	0.3	0.9
09/09/2023 06:00	4,218.7	0.0	4,218.7	103,340.0	436.0	0.52	0.3	0.9
09/09/2023 07:00	3,553.2	0.0	3,553.2	103,340.0	367.2	0.44	0.2	0.7
09/09/2023 08:00	4,195.4	0.0	4,195.4	103,340.0	433.6	0.52	0.3	0.9
09/09/2023 09:00	3,433.8	0.0	3,433.8	103,340.0	354.8	0.43	0.2	0.7
09/09/2023 10:00	3,392.9	0.0	3,392.9	103,340.0	350.6	0.42	0.2	0.7
09/09/2023 11:00	3,602.9	0.0	3,602.9	103,340.0	372.3	0.45	0.2	0.7
09/09/2023 12:00	3,959.6	18.8	3,961.9	103,340.0	409.4	0.49	0.2	0.8
09/09/2023 13:00	4,253.2	0.0	4,253.2	103,340.0	439.5	0.53	0.3	0.9
09/09/2023 14:00	3,655.0	0.0	3,655.0	103,340.0	377.7	0.45	0.2	0.8
09/09/2023 15:00	4,135.0	0.0	4,135.0	103,340.0	427.3	0.51	0.3	0.9
09/09/2023 16:00	3,825.2	0.0	3,825.2	103,340.0	395.3	0.47	0.2	0.8
09/09/2023 17:00	4,238.1	418.2	4,434.7	103,340.0	458.3	0.58	0.3	1.0
09/09/2023 18:00	4,283.7	1,400.9	5,684.6	103,340.0	587.4	0.71	0.4	1.2
09/09/2023 19:00	4,284.8	646.1	4,782.3	103,340.0	494.2	0.61	0.3	1.0
09/09/2023 20:00	4,207.4	0.0	4,207.4	103,340.0	434.8	0.52	0.3	0.9
09/09/2023 21:00	4,355.2	495.1	4,800.8	103,340.0	496.1	0.60	0.3	1.0
09/09/2023 22:00	4,305.8	376.3	4,595.6	103,340.0	474.9	0.58	0.3	1.0
09/09/2023 23:00	3,680.2	0.0	3,680.2	103,340.0	380.3	0.46	0.2	0.8
Average/Sum#:	4,005.0	139.8	4,123.1	103,340.0	426.1	0.51	0.3	0.9
Minimum:	3,392.9	0.0	3,392.9	103,340.0	350.6	0.42	0.2	0.7
Maximum:	4,355.2	1,400.9	5,684.6	103,340.0	587.4	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2023 00:00	3,948.4	0.0	3,948.4	103,340.0	408.0	0.49	0.2	0.8
09/10/2023 01:00	3,612.8	0.0	3,612.8	103,340.0	373.3	0.45	0.2	0.7
09/10/2023 02:00	3,524.6	0.0	3,524.6	103,340.0	364.2	0.44	0.2	0.7
09/10/2023 03:00	3,813.1	0.0	3,813.1	103,340.0	394.0	0.47	0.2	0.8
09/10/2023 04:00	3,435.5	0.0	3,435.5	103,340.0	355.0	0.43	0.2	0.7
09/10/2023 05:00	3,764.7	0.0	3,764.7	103,340.0	389.0	0.47	0.2	0.8
09/10/2023 06:00	4,012.2	0.0	4,012.2	103,340.0	414.6	0.50	0.2	0.8
09/10/2023 07:00	4,008.0	0.0	4,008.0	103,340.0	414.2	0.50	0.2	0.8
09/10/2023 08:00	4,325.6	0.0	4,325.6	103,340.0	447.0	0.54	0.3	0.9
09/10/2023 09:00	3,801.0	0.0	3,801.0	103,340.0	392.8	0.47	0.2	0.8
09/10/2023 10:00	3,642.5	0.0	3,642.5	103,340.0	376.4	0.45	0.2	0.8
09/10/2023 11:00	3,393.2	0.0	3,393.2	103,340.0	350.7	0.42	0.2	0.7
09/10/2023 12:00	3,402.2	0.0	3,402.2	103,340.0	351.6	0.42	0.2	0.7
09/10/2023 13:00	3,665.1	0.0	3,665.1	103,340.0	378.8	0.46	0.2	0.8
09/10/2023 14:00	3,898.3	0.0	3,898.3	103,340.0	402.9	0.48	0.2	0.8
09/10/2023 15:00	3,600.8	0.0	3,600.8	103,340.0	372.1	0.45	0.2	0.7
09/10/2023 16:00	3,909.6	164.1	3,955.5	103,340.0	408.8	0.51	0.3	0.8
09/10/2023 17:00	4,279.7	1,539.5	5,819.2	103,340.0	601.4	0.72	0.4	1.2
09/10/2023 18:00	4,275.6	1,556.9	5,832.5	103,340.0	602.7	0.72	0.4	1.2
09/10/2023 19:00	4,282.8	913.1	5,195.9	103,340.0	536.9	0.65	0.3	1.1
09/10/2023 20:00	4,189.9	110.0	4,219.6	103,340.0	436.1	0.53	0.3	0.9
09/10/2023 21:00	4,340.7	519.8	4,844.9	103,340.0	500.7	0.60	0.3	1.0
09/10/2023 22:00	4,295.9	511.5	4,689.8	103,340.0	484.6	0.60	0.3	1.0
09/10/2023 23:00	3,422.3	0.0	3,422.3	103,340.0	353.7	0.42	0.2	0.7
Average/Sum#:	3,868.5	221.5	4,076.2	103,340.0	421.2	0.51	0.2	0.8
Minimum:	3,393.2	0.0	3,393.2	103,340.0	350.7	0.42	0.2	0.7
Maximum:	4,340.7	1,556.9	5,832.5	103,340.0	602.7	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2023 00:00	3,388.9	0.0	3,388.9	103,340.0	350.2	0.42	0.2	0.7
09/11/2023 01:00	3,385.8	0.0	3,385.8	103,340.0	349.9	0.42	0.2	0.7
09/11/2023 02:00	3,392.8	0.0	3,392.8	103,340.0	350.6	0.42	0.2	0.7
09/11/2023 03:00	3,402.6	0.0	3,402.6	103,340.0	351.6	0.42	0.2	0.7
09/11/2023 04:00	3,453.4	0.0	3,453.4	103,340.0	356.9	0.43	0.2	0.7
09/11/2023 05:00	3,469.3	0.0	3,469.3	103,340.0	358.5	0.43	0.2	0.7
09/11/2023 06:00	4,226.4	0.0	4,226.4	103,340.0	436.8	0.53	0.3	0.9
09/11/2023 07:00	3,790.1	0.0	3,790.1	103,340.0	391.7	0.47	0.2	0.8
09/11/2023 08:00	3,399.2	0.0	3,399.2	103,340.0	351.3	0.42	0.2	0.7
09/11/2023 09:00	3,389.7	0.0	3,389.7	103,340.0	350.3	0.42	0.2	0.7
09/11/2023 10:00	3,386.0	0.0	3,386.0	103,340.0	349.9	0.42	0.2	0.7
09/11/2023 11:00	3,467.6	0.0	3,467.6	103,340.0	358.3	0.43	0.2	0.7
09/11/2023 12:00	3,828.7	0.0	3,828.7	103,340.0	395.7	0.47	0.2	0.8
09/11/2023 13:00	3,762.6	0.0	3,762.6	103,340.0	388.8	0.47	0.2	0.8
09/11/2023 14:00	3,982.4	0.0	3,982.4	103,340.0	411.5	0.49	0.2	0.8
09/11/2023 15:00	3,799.7	0.0	3,799.7	103,340.0	392.7	0.47	0.2	0.8
09/11/2023 16:00	3,797.8	0.0	3,797.8	103,340.0	392.5	0.47	0.2	0.8
09/11/2023 17:00	3,628.7	0.0	3,628.7	103,340.0	375.0	0.45	0.2	0.7
09/11/2023 18:00	3,890.1	0.0	3,890.1	103,340.0	402.0	0.48	0.2	0.8
09/11/2023 19:00	3,434.2	0.0	3,434.2	103,340.0	354.9	0.43	0.2	0.7
09/11/2023 20:00	3,601.3	0.0	3,601.3	103,340.0	372.2	0.45	0.2	0.7
09/11/2023 21:00	3,846.6	0.0	3,846.6	103,340.0	397.5	0.48	0.2	0.8
09/11/2023 22:00	3,506.2	0.0	3,506.2	103,340.0	362.3	0.44	0.2	0.7
09/11/2023 23:00	3,383.1	0.0	3,383.1	103,340.0	349.6	0.42	0.2	0.7
Average/Sum#:	3,608.9	0.0	3,608.9	103,340.0	372.9	0.45	0.2	0.7
Minimum:	3,383.1	0.0	3,383.1	103,340.0	349.6	0.42	0.2	0.7
Maximum:	4,226.4	0.0	4,226.4	103,340.0	436.8	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2023 00:00	3,389.1	0.0	3,389.1	103,340.0	350.2	0.42	0.2	0.7
09/12/2023 01:00	3,660.7	0.0	3,660.7	103,340.0	378.3	0.45	0.2	0.8
09/12/2023 02:00	3,957.4	0.0	3,957.4	103,340.0	409.0	0.49	0.2	0.8
09/12/2023 03:00	4,255.6	0.0	4,255.6	103,340.0	439.8	0.53	0.3	0.9
09/12/2023 04:00	4,633.2	0.0	4,633.2	103,340.0	478.8	0.57	0.3	1.0
09/12/2023 05:00	4,456.7	0.0	4,456.7	103,340.0	460.6	0.55	0.3	0.9
09/12/2023 06:00	4,555.1	0.0	4,555.1	103,340.0	470.7	0.57	0.3	0.9
09/12/2023 07:00	3,709.7	0.0	3,709.7	103,340.0	383.4	0.46	0.2	0.8
09/12/2023 08:00	3,396.3	0.0	3,396.3	103,340.0	351.0	0.42	0.2	0.7
09/12/2023 09:00	3,373.4	0.0	3,373.4	103,340.0	348.6	0.42	0.2	0.7
09/12/2023 10:00	3,384.0	0.0	3,384.0	103,340.0	349.7	0.42	0.2	0.7
09/12/2023 11:00	3,395.0	0.0	3,395.0	103,340.0	350.8	0.42	0.2	0.7
09/12/2023 12:00	3,400.9	0.0	3,400.9	103,340.0	351.4	0.42	0.2	0.7
09/12/2023 13:00	3,394.4	0.0	3,394.4	103,340.0	350.8	0.42	0.2	0.7
09/12/2023 14:00	3,436.4	0.0	3,436.4	103,340.0	355.1	0.43	0.2	0.7
09/12/2023 15:00	3,435.1	0.0	3,435.1	103,340.0	355.0	0.43	0.2	0.7
09/12/2023 16:00	3,378.0	0.0	3,378.0	103,340.0	349.1	0.42	0.2	0.7
09/12/2023 17:00	3,374.5	0.0	3,374.5	103,340.0	348.7	0.42	0.2	0.7
09/12/2023 18:00	3,373.7	0.0	3,373.7	103,340.0	348.6	0.42	0.2	0.7
09/12/2023 19:00	3,841.2	127.9	3,877.0	103,340.0	400.6	0.49	0.2	0.8
09/12/2023 20:00	4,305.8	467.6	4,773.4	103,340.0	493.3	0.59	0.3	1.0
09/12/2023 21:00	3,583.9	1.8	3,583.9	103,340.0	370.4	0.45	0.2	0.7
09/12/2023 22:00	3,368.5	0.0	3,368.5	103,340.0	348.1	0.42	0.2	0.7
09/12/2023 23:00	3,368.3	0.0	3,368.3	103,340.0	348.1	0.42	0.2	0.7
Average/Sum#:	3,684.5	24.9	3,705.4	103,340.0	382.9	0.46	0.2	0.8
Minimum:	3,368.3	0.0	3,368.3	103,340.0	348.1	0.42	0.2	0.7
Maximum:	4,633.2	467.6	4,773.4	103,340.0	493.3	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2023 00:00	3,370.0	0.0	3,370.0	103,340.0	348.3	0.42	0.2	0.7
09/13/2023 01:00	3,370.8	0.0	3,370.8	103,340.0	348.3	0.42	0.2	0.7
09/13/2023 02:00	3,374.5	0.0	3,374.5	103,340.0	348.7	0.42	0.2	0.7
09/13/2023 03:00	3,378.3	0.0	3,378.3	103,340.0	349.1	0.42	0.2	0.7
09/13/2023 04:00	3,385.4	0.0	3,385.4	103,340.0	349.8	0.42	0.2	0.7
09/13/2023 05:00	3,389.4	0.0	3,389.4	103,340.0	350.3	0.42	0.2	0.7
09/13/2023 06:00	3,387.6	0.0	3,387.6	103,340.0	350.1	0.42	0.2	0.7
09/13/2023 07:00	3,394.1	0.0	3,394.1	103,340.0	350.7	0.42	0.2	0.7
09/13/2023 08:00	3,394.0	0.0	3,394.0	103,340.0	350.7	0.42	0.2	0.7
09/13/2023 09:00	3,394.7	0.0	3,394.7	103,340.0	350.8	0.42	0.2	0.7
09/13/2023 10:00	3,392.5	0.0	3,392.5	103,340.0	350.6	0.42	0.2	0.7
09/13/2023 11:00	3,637.0	0.0	3,637.0	103,340.0	375.8	0.45	0.2	0.8
09/13/2023 12:00	4,276.2	503.2	4,769.3	103,340.0	492.9	0.59	0.3	1.0
09/13/2023 13:00	3,826.1	127.6	3,860.6	103,340.0	399.0	0.49	0.2	0.8
09/13/2023 14:00	4,037.0	15.3	4,038.1	103,340.0	417.3	0.50	0.3	0.8
09/13/2023 15:00	4,244.7	594.3	4,839.0	103,340.0	500.1	0.60	0.3	1.0
09/13/2023 16:00	4,235.2	613.9	4,849.1	103,340.0	501.1	0.60	0.3	1.0
09/13/2023 17:00	4,229.6	667.1	4,896.7	103,340.0	506.0	0.61	0.3	1.0
09/13/2023 18:00	4,228.1	647.5	4,875.6	103,340.0	503.8	0.60	0.3	1.0
09/13/2023 19:00	4,242.2	580.6	4,822.8	103,340.0	498.4	0.60	0.3	1.0
09/13/2023 20:00	4,266.9	539.7	4,806.6	103,340.0	496.7	0.60	0.3	1.0
09/13/2023 21:00	3,995.7	251.6	4,126.5	103,340.0	426.4	0.53	0.3	0.9
09/13/2023 22:00	3,373.3	0.0	3,373.3	103,340.0	348.6	0.42	0.2	0.7
09/13/2023 23:00	3,378.0	0.0	3,378.0	103,340.0	349.1	0.42	0.2	0.7
Average/Sum#:	3,716.7	189.2	3,896.0	103,340.0	402.6	0.48	0.2	0.8
Minimum:	3,370.0	0.0	3,370.0	103,340.0	348.3	0.42	0.2	0.7
Maximum:	4,276.2	667.1	4,896.7	103,340.0	506.0	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2023 00:00	3,451.7	0.0	3,451.7	103,340.0	356.7	0.43	0.2	0.7
09/14/2023 01:00	3,444.4	0.0	3,444.4	103,340.0	355.9	0.43	0.2	0.7
09/14/2023 02:00	3,943.3	0.0	3,943.3	103,340.0	407.5	0.49	0.2	0.8
09/14/2023 03:00	3,379.6	0.0	3,379.6	103,340.0	349.2	0.42	0.2	0.7
09/14/2023 04:00	3,381.6	0.0	3,381.6	103,340.0	349.5	0.42	0.2	0.7
09/14/2023 05:00	3,469.2	0.0	3,469.2	103,340.0	358.5	0.43	0.2	0.7
09/14/2023 06:00	4,003.0	0.0	4,003.0	103,340.0	413.7	0.49	0.2	0.8
09/14/2023 07:00	3,691.7	0.0	3,691.7	103,340.0	381.5	0.46	0.2	0.8
09/14/2023 08:00	3,457.2	0.0	3,457.2	103,340.0	357.3	0.43	0.2	0.7
09/14/2023 09:00	3,889.9	0.0	3,889.9	103,340.0	402.0	0.48	0.2	0.8
09/14/2023 10:00	4,146.3	0.0	4,146.3	103,340.0	428.5	0.51	0.3	0.9
09/14/2023 11:00	4,174.4	117.0	4,200.1	103,340.0	434.0	0.53	0.3	0.9
09/14/2023 12:00	4,288.8	521.4	4,810.2	103,340.0	497.1	0.60	0.3	1.0
09/14/2023 13:00	4,169.7	2.2	4,169.7	103,340.0	430.9	0.52	0.3	0.9
09/14/2023 14:00	4,155.9	0.0	4,155.9	103,340.0	429.5	0.52	0.3	0.9
09/14/2023 15:00	4,202.9	479.5	4,552.9	103,340.0	470.5	0.58	0.3	1.0
09/14/2023 16:00	4,203.0	851.9	5,054.9	103,340.0	522.4	0.63	0.3	1.0
09/14/2023 17:00	4,202.5	958.0	5,160.5	103,340.0	533.3	0.64	0.3	1.1
09/14/2023 18:00	4,206.5	864.7	5,071.2	103,340.0	524.1	0.63	0.3	1.0
09/14/2023 19:00	4,238.9	572.5	4,811.4	103,340.0	497.2	0.60	0.3	1.0
09/14/2023 20:00	4,270.0	505.1	4,775.1	103,340.0	493.5	0.59	0.3	1.0
09/14/2023 21:00	4,282.7	707.9	4,990.6	103,340.0	515.7	0.62	0.3	1.0
09/14/2023 22:00	4,250.3	419.9	4,573.6	103,340.0	472.6	0.58	0.3	1.0
09/14/2023 23:00	3,624.1	0.0	3,624.1	103,340.0	374.5	0.45	0.2	0.7
Average/Sum#:	3,938.7	250.0	4,175.3	103,340.0	431.5	0.52	0.3	0.9
Minimum:	3,379.6	0.0	3,379.6	103,340.0	349.2	0.42	0.2	0.7
Maximum:	4,288.8	958.0	5,160.5	103,340.0	533.3	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2023 00:00	3,570.2	0.0	3,570.2	103,340.0	368.9	0.44	0.2	0.7
09/15/2023 01:00	3,432.8	0.0	3,432.8	103,340.0	354.7	0.43	0.2	0.7
09/15/2023 02:00	3,413.6	0.0	3,413.6	103,340.0	352.8	0.43	0.2	0.7
09/15/2023 03:00	3,379.4	0.0	3,379.4	103,340.0	349.2	0.42	0.2	0.7
09/15/2023 04:00	3,442.6	0.0	3,442.6	103,340.0	355.8	0.43	0.2	0.7
09/15/2023 05:00	3,961.1	98.8	3,982.8	103,340.0	411.6	0.50	0.3	0.8
09/15/2023 06:00	4,361.5	1,186.0	5,547.5	103,340.0	573.3	0.69	0.3	1.1
09/15/2023 07:00	4,083.1	214.4	4,194.6	103,340.0	433.5	0.53	0.3	0.9
09/15/2023 08:00	3,449.1	0.0	3,449.1	103,340.0	356.4	0.43	0.2	0.7
09/15/2023 09:00	3,398.9	0.0	3,398.9	103,340.0	351.2	0.42	0.2	0.7
09/15/2023 10:00	3,396.2	0.0	3,396.2	103,340.0	351.0	0.42	0.2	0.7
09/15/2023 11:00	3,401.2	0.0	3,401.2	103,340.0	351.5	0.42	0.2	0.7
09/15/2023 12:00	3,446.7	0.0	3,446.7	103,340.0	356.2	0.42	0.2	0.7
09/15/2023 13:00	3,429.8	0.0	3,429.8	103,340.0	354.4	0.42	0.2	0.7
09/15/2023 14:00	3,604.8	0.0	3,604.8	103,340.0	372.5	0.45	0.2	0.7
09/15/2023 15:00	4,102.2	122.7	4,130.4	103,340.0	426.8	0.52	0.3	0.9
09/15/2023 16:00	4,250.6	943.2	5,193.8	103,340.0	536.7	0.64	0.3	1.1
09/15/2023 17:00	4,252.3	1,161.9	5,414.2	103,340.0	559.5	0.67	0.3	1.1
09/15/2023 18:00	4,258.5	1,404.8	5,663.3	103,340.0	585.2	0.70	0.4	1.2
09/15/2023 19:00	4,270.4	789.6	5,060.0	103,340.0	522.9	0.63	0.3	1.0
09/15/2023 20:00	4,294.4	943.1	5,237.5	103,340.0	541.2	0.65	0.3	1.1
09/15/2023 21:00	4,318.9	800.8	5,119.7	103,340.0	529.1	0.64	0.3	1.1
09/15/2023 22:00	4,333.7	655.7	4,989.4	103,340.0	515.6	0.62	0.3	1.0
09/15/2023 23:00	4,290.7	338.1	4,551.0	103,340.0	470.3	0.57	0.3	1.0
Average/Sum#:	3,839.3	360.8	4,185.4	103,340.0	432.5	0.52	0.3	0.9
Minimum:	3,379.4	0.0	3,379.4	103,340.0	349.2	0.42	0.2	0.7
Maximum:	4,361.5	1,404.8	5,663.3	103,340.0	585.2	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2023 00:00	3,749.1	0.0	3,749.1	103,340.0	387.4	0.47	0.2	0.8
09/16/2023 01:00	3,521.5	0.0	3,521.5	103,340.0	363.9	0.44	0.2	0.7
09/16/2023 02:00	3,457.2	0.0	3,457.2	103,340.0	357.3	0.43	0.2	0.7
09/16/2023 03:00	3,383.6	0.0	3,383.6	103,340.0	349.7	0.42	0.2	0.7
09/16/2023 04:00	3,387.8	0.0	3,387.8	103,340.0	350.1	0.42	0.2	0.7
09/16/2023 05:00	3,409.4	0.0	3,409.4	103,340.0	352.3	0.42	0.2	0.7
09/16/2023 06:00	3,392.5	0.0	3,392.5	103,340.0	350.6	0.42	0.2	0.7
09/16/2023 07:00	3,397.1	0.0	3,397.1	103,340.0	351.1	0.42	0.2	0.7
09/16/2023 08:00	3,413.5	0.0	3,413.5	103,340.0	352.8	0.42	0.2	0.7
09/16/2023 09:00	3,447.4	0.0	3,447.4	103,340.0	356.3	0.43	0.2	0.7
09/16/2023 10:00	3,553.7	0.0	3,553.7	103,340.0	367.2	0.44	0.2	0.7
09/16/2023 11:00	3,780.2	0.0	3,780.2	103,340.0	390.6	0.47	0.2	0.8
09/16/2023 12:00	4,087.7	0.0	4,087.7	103,340.0	422.4	0.50	0.3	0.8
09/16/2023 13:00	4,015.8	0.0	4,015.8	103,340.0	415.0	0.50	0.2	0.8
09/16/2023 14:00	3,712.4	0.0	3,712.4	103,340.0	383.6	0.46	0.2	0.8
09/16/2023 15:00	3,771.9	0.0	3,771.9	103,340.0	389.8	0.47	0.2	0.8
09/16/2023 16:00	3,385.9	0.0	3,385.9	103,340.0	349.9	0.42	0.2	0.7
09/16/2023 17:00	3,572.8	0.0	3,572.8	103,340.0	369.2	0.44	0.2	0.7
09/16/2023 18:00	3,451.9	0.0	3,451.9	103,340.0	356.7	0.43	0.2	0.7
09/16/2023 19:00	3,385.9	0.0	3,385.9	103,340.0	349.9	0.42	0.2	0.7
09/16/2023 20:00	3,379.3	0.0	3,379.3	103,340.0	349.2	0.42	0.2	0.7
09/16/2023 21:00	3,378.0	0.0	3,378.0	103,340.0	349.1	0.42	0.2	0.7
09/16/2023 22:00	3,379.6	0.0	3,379.6	103,340.0	349.2	0.42	0.2	0.7
09/16/2023 23:00	3,381.5	0.0	3,381.5	103,340.0	349.4	0.42	0.2	0.7
Average/Sum#:	3,533.2	0.0	3,533.2	103,340.0	365.1	0.44	0.2	0.7
Minimum:	3,378.0	0.0	3,378.0	103,340.0	349.1	0.42	0.2	0.7
Maximum:	4,087.7	0.0	4,087.7	103,340.0	422.4	0.50	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2023 00:00	3,382.3	0.0	3,382.3	103,340.0	349.5	0.42	0.2	0.7
09/17/2023 01:00	3,387.1	0.0	3,387.1	103,340.0	350.0	0.42	0.2	0.7
09/17/2023 02:00	3,389.5	0.0	3,389.5	103,340.0	350.3	0.42	0.2	0.7
09/17/2023 03:00	3,389.8	0.0	3,389.8	103,340.0	350.3	0.42	0.2	0.7
09/17/2023 04:00	3,390.1	0.0	3,390.1	103,340.0	350.3	0.42	0.2	0.7
09/17/2023 05:00	3,393.0	0.0	3,393.0	103,340.0	350.6	0.42	0.2	0.7
09/17/2023 06:00	3,393.4	0.0	3,393.4	103,340.0	350.7	0.42	0.2	0.7
09/17/2023 07:00	3,393.6	0.0	3,393.6	103,340.0	350.7	0.42	0.2	0.7
09/17/2023 08:00	3,397.4	0.0	3,397.4	103,340.0	351.1	0.42	0.2	0.7
09/17/2023 09:00	3,395.0	0.0	3,395.0	103,340.0	350.8	0.42	0.2	0.7
09/17/2023 10:00	3,392.4	0.0	3,392.4	103,340.0	350.6	0.42	0.2	0.7
09/17/2023 11:00	3,394.7	0.0	3,394.7	103,340.0	350.8	0.42	0.2	0.7
09/17/2023 12:00	3,394.7	0.0	3,394.7	103,340.0	350.8	0.42	0.2	0.7
09/17/2023 13:00	3,394.1	0.0	3,394.1	103,340.0	350.7	0.42	0.2	0.7
09/17/2023 14:00	3,386.8	0.0	3,386.8	103,340.0	350.0	0.42	0.2	0.7
09/17/2023 15:00	3,386.9	0.0	3,386.9	103,340.0	350.0	0.42	0.2	0.7
09/17/2023 16:00	3,385.4	0.0	3,385.4	103,340.0	349.8	0.42	0.2	0.7
09/17/2023 17:00	3,493.3	0.0	3,493.3	103,340.0	361.0	0.43	0.2	0.7
09/17/2023 18:00	3,429.5	0.0	3,429.5	103,340.0	354.4	0.43	0.2	0.7
09/17/2023 19:00	3,392.7	0.0	3,392.7	103,340.0	350.6	0.42	0.2	0.7
09/17/2023 20:00	3,489.7	0.0	3,489.7	103,340.0	360.6	0.43	0.2	0.7
09/17/2023 21:00	3,386.0	0.0	3,386.0	103,340.0	349.9	0.42	0.2	0.7
09/17/2023 22:00	3,387.9	0.0	3,387.9	103,340.0	350.1	0.42	0.2	0.7
09/17/2023 23:00	3,392.3	0.0	3,392.3	103,340.0	350.6	0.42	0.2	0.7
Average/Sum#:	3,400.7	0.0	3,400.7	103,340.0	351.4	0.42	0.2	0.7
Minimum:	3,382.3	0.0	3,382.3	103,340.0	349.5	0.42	0.2	0.7
Maximum:	3,493.3	0.0	3,493.3	103,340.0	361.0	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal1, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2023 00:00	3,396.4	0.0	3,396.4	103,340.0	351.0	0.42	0.2	0.7
09/18/2023 01:00	3,396.3	0.0	3,396.3	103,340.0	351.0	0.42	0.2	0.7
09/18/2023 02:00	3,396.0	0.0	3,396.0	103,340.0	350.9	0.42	0.2	0.7
09/18/2023 03:00	3,394.7	0.0	3,394.7	103,340.0	350.8	0.42	0.2	0.7
09/18/2023 04:00	3,395.0	0.0	3,395.0	103,340.0	350.8	0.42	0.2	0.7
09/18/2023 05:00	3,396.2	0.0	3,396.2	103,340.0	351.0	0.42	0.2	0.7
09/18/2023 06:00	3,395.9	0.0	3,395.9	103,340.0	350.9	0.42	0.2	0.7
09/18/2023 07:00	3,397.3	0.0	3,397.3	103,340.0	351.1	0.42	0.2	0.7
09/18/2023 08:00	3,399.7	0.0	3,399.7	103,340.0	351.3	0.42	0.2	0.7
09/18/2023 09:00	3,397.6	0.0	3,397.6	103,340.0	351.1	0.42	0.2	0.7
09/18/2023 10:00	3,399.7	0.0	3,399.7	103,340.0	351.3	0.42	0.2	0.7
09/18/2023 11:00	3,398.7	0.0	3,398.7	103,340.0	351.2	0.42	0.2	0.7
09/18/2023 12:00	3,395.7	0.0	3,395.7	103,340.0	350.9	0.42	0.2	0.7
09/18/2023 13:00	3,396.6	0.0	3,396.6	103,340.0	351.0	0.42	0.2	0.7
09/18/2023 14:00	3,389.0	0.0	3,389.0	103,340.0	350.2	0.42	0.2	0.7
09/18/2023 15:00	3,388.0	0.0	3,388.0	103,340.0	350.1	0.42	0.2	0.7
09/18/2023 16:00	3,390.6	0.0	3,390.6	103,340.0	350.4	0.42	0.2	0.7
09/18/2023 17:00	3,647.8	0.0	3,647.8	103,340.0	377.0	0.45	0.2	0.8
09/18/2023 18:00	3,901.7	0.0	3,901.7	103,340.0	403.2	0.48	0.2	0.8
09/18/2023 19:00	3,486.7	0.0	3,486.7	103,340.0	360.3	0.43	0.2	0.7
09/18/2023 20:00	3,404.1	0.0	3,404.1	103,340.0	351.8	0.42	0.2	0.7
09/18/2023 21:00	3,412.3	0.0	3,412.3	103,340.0	352.6	0.42	0.2	0.7
09/18/2023 22:00	3,407.2	0.0	3,407.2	103,340.0	352.1	0.42	0.2	0.7
09/18/2023 23:00	3,389.3	0.0	3,389.3	103,340.0	350.3	0.42	0.2	0.7
Average/Sum#:	3,432.2	0.0	3,432.2	103,340.0	354.7	0.42	0.2	0.7
Minimum:	3,388.0	0.0	3,388.0	103,340.0	350.1	0.42	0.2	0.7
Maximum:	3,901.7	0.0	3,901.7	103,340.0	403.2	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2023 00:00	3,389.6	0.0	3,389.6	103,340.0	350.3	0.42	0.2	0.7
09/19/2023 01:00	3,390.1	0.0	3,390.1	103,340.0	350.3	0.42	0.2	0.7
09/19/2023 02:00	3,393.0	0.0	3,393.0	103,340.0	350.6	0.42	0.2	0.7
09/19/2023 03:00	3,397.5	0.0	3,397.5	103,340.0	351.1	0.42	0.2	0.7
09/19/2023 04:00	3,403.8	0.0	3,403.8	103,340.0	351.7	0.42	0.2	0.7
09/19/2023 05:00	3,614.1	0.0	3,614.1	103,340.0	373.5	0.45	0.2	0.7
09/19/2023 06:00	4,029.7	0.0	4,029.7	103,340.0	416.4	0.50	0.2	0.8
09/19/2023 07:00	3,585.4	0.0	3,585.4	103,340.0	370.5	0.44	0.2	0.7
09/19/2023 08:00	3,398.9	0.0	3,398.9	103,340.0	351.2	0.42	0.2	0.7
09/19/2023 09:00	3,397.0	0.0	3,397.0	103,340.0	351.0	0.42	0.2	0.7
09/19/2023 10:00	3,398.2	0.0	3,398.2	103,340.0	351.2	0.42	0.2	0.7
09/19/2023 11:00	3,399.3	0.0	3,399.3	103,340.0	351.3	0.42	0.2	0.7
09/19/2023 12:00	3,398.4	0.0	3,398.4	103,340.0	351.2	0.42	0.2	0.7
09/19/2023 13:00	3,400.0	0.0	3,400.0	103,340.0	351.4	0.42	0.2	0.7
09/19/2023 14:00	3,390.1	0.0	3,390.1	103,340.0	350.3	0.42	0.2	0.7
09/19/2023 15:00	3,387.7	0.0	3,387.7	103,340.0	350.1	0.42	0.2	0.7
09/19/2023 16:00	3,385.0	0.0	3,385.0	103,340.0	349.8	0.42	0.2	0.7
09/19/2023 17:00	3,569.3	0.0	3,569.3	103,340.0	368.9	0.44	0.2	0.7
09/19/2023 18:00	3,716.1	0.0	3,716.1	103,340.0	384.0	0.46	0.2	0.8
09/19/2023 19:00	3,385.1	0.0	3,385.1	103,340.0	349.8	0.42	0.2	0.7
09/19/2023 20:00	3,389.6	0.0	3,389.6	103,340.0	350.3	0.42	0.2	0.7
09/19/2023 21:00	3,407.2	0.0	3,407.2	103,340.0	352.1	0.42	0.2	0.7
09/19/2023 22:00	3,380.3	0.0	3,380.3	103,340.0	349.3	0.42	0.2	0.7
09/19/2023 23:00	3,383.6	0.0	3,383.6	103,340.0	349.7	0.42	0.2	0.7
Average/Sum#:	3,457.9	0.0	3,457.9	103,340.0	357.3	0.43	0.2	0.7
Minimum:	3,380.3	0.0	3,380.3	103,340.0	349.3	0.42	0.2	0.7
Maximum:	4,029.7	0.0	4,029.7	103,340.0	416.4	0.50	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2023 00:00	3,389.9	0.0	3,389.9	103,340.0	350.3	0.42	0.2	0.7
09/20/2023 01:00	3,383.5	0.0	3,383.5	103,340.0	349.7	0.42	0.2	0.7
09/20/2023 02:00	3,382.0	0.0	3,382.0	103,340.0	349.5	0.42	0.2	0.7
09/20/2023 03:00	3,382.8	0.0	3,382.8	103,340.0	349.6	0.42	0.2	0.7
09/20/2023 04:00	3,389.7	0.0	3,389.7	103,340.0	350.3	0.42	0.2	0.7
09/20/2023 05:00	3,409.8	0.0	3,409.8	103,340.0	352.4	0.42	0.2	0.7
09/20/2023 06:00	3,448.5	0.0	3,448.5	103,340.0	356.4	0.43	0.2	0.7
09/20/2023 07:00	3,409.3	0.0	3,409.3	103,340.0	352.3	0.42	0.2	0.7
09/20/2023 08:00	3,392.5	0.0	3,392.5	103,340.0	350.6	0.42	0.2	0.7
09/20/2023 09:00	3,393.2	0.0	3,393.2	103,340.0	350.7	0.42	0.2	0.7
09/20/2023 10:00	3,393.3	0.0	3,393.3	103,340.0	350.7	0.42	0.2	0.7
09/20/2023 11:00	3,553.1	0.0	3,553.1	103,340.0	367.2	0.44	0.2	0.7
09/20/2023 12:00	3,459.2	0.0	3,459.2	103,340.0	357.5	0.43	0.2	0.7
09/20/2023 13:00	3,457.7	0.0	3,457.7	103,340.0	357.3	0.43	0.2	0.7
09/20/2023 14:00	3,452.7	0.0	3,452.7	103,340.0	356.8	0.43	0.2	0.7
09/20/2023 15:00	3,449.2	0.0	3,449.2	103,340.0	356.4	0.43	0.2	0.7
09/20/2023 16:00	3,450.2	0.0	3,450.2	103,340.0	356.5	0.43	0.2	0.7
09/20/2023 17:00	3,625.4	1.8	3,625.5	103,340.0	374.7	0.45	0.2	0.8
09/20/2023 18:00	3,879.3	0.0	3,879.3	103,340.0	400.9	0.48	0.2	0.8
09/20/2023 19:00	3,895.9	0.0	3,895.9	103,340.0	402.6	0.48	0.2	0.8
09/20/2023 20:00	3,439.7	0.0	3,439.7	103,340.0	355.5	0.43	0.2	0.7
09/20/2023 21:00	3,568.1	0.0	3,568.1	103,340.0	368.7	0.44	0.2	0.7
09/20/2023 22:00	3,522.9	0.0	3,522.9	103,340.0	364.1	0.44	0.2	0.7
09/20/2023 23:00	3,428.3	0.0	3,428.3	103,340.0	354.3	0.43	0.2	0.7
Average/Sum#:	3,481.5	0.1	3,481.5	103,340.0	359.8	0.43	0.2	0.7
Minimum:	3,382.0	0.0	3,382.0	103,340.0	349.5	0.42	0.2	0.7
Maximum:	3,895.9	1.8	3,895.9	103,340.0	402.6	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2023 00:00	3,425.6	0.0	3,425.6	103,340.0	354.0	0.42	0.2	0.7			
09/21/2023 01:00	3,444.1	0.0	3,444.1	103,340.0	355.9	0.43	0.2	0.7			
09/21/2023 02:00	3,456.8	0.0	3,456.8	103,340.0	357.2	0.43	0.2	0.7			
09/21/2023 03:00	3,449.3	0.0	3,449.3	103,340.0	356.5	0.43	0.2	0.7			
09/21/2023 04:00	3,453.9	0.0	3,453.9	103,340.0	356.9	0.43	0.2	0.7			
09/21/2023 05:00	3,461.9	0.0	3,461.9	103,340.0	357.8	0.43	0.2	0.7			
09/21/2023 06:00	4,243.8	0.0	4,243.8	103,340.0	438.6	0.53	0.3	0.9			
09/21/2023 07:00	3,926.8	0.0	3,926.8	103,340.0	405.8	0.49	0.2	0.8			
09/21/2023 08:00	3,748.1	0.0	3,748.1	103,340.0	387.3	0.47	0.2	0.8			
09/21/2023 09:00	3,542.4	0.0	3,542.4	103,340.0	366.1	0.44	0.2	0.7			
09/21/2023 10:00	3,769.5	0.0	3,769.5	103,340.0	389.5	0.47	0.2	0.8			
09/21/2023 11:00	3,653.7	0.0	3,653.7	103,340.0	377.6	0.45	0.2	0.8			
09/21/2023 12:00	3,458.2	0.0	3,458.2	103,340.0	357.4	0.43	0.2	0.7			
09/21/2023 13:00	3,862.1	0.0	3,862.1	103,340.0	399.1	0.48	0.2	0.8			
09/21/2023 14:00	4,272.4	0.0	4,272.4	103,340.0	441.5	0.53	0.3	0.9			
09/21/2023 15:00	4,124.6	0.0	4,124.6	103,340.0	426.2	0.51	0.3	0.9			
09/21/2023 16:00	3,941.6	0.0	3,941.6	103,340.0	407.3	0.49	0.2	0.8			
09/21/2023 17:00	3,762.2	0.0	3,762.2	103,340.0	388.8	0.47	0.2	0.8			
09/21/2023 18:00	4,214.2	0.0	4,214.2	103,340.0	435.5	0.52	0.3	0.9			
09/21/2023 19:00	3,536.6	0.0	3,536.6	103,340.0	365.5	0.44	0.2	0.7			
09/21/2023 20:00	3,458.2	0.0	3,458.2	103,340.0	357.4	0.43	0.2	0.7			
09/21/2023 21:00	3,651.5	0.0	3,651.5	103,340.0	377.3	0.45	0.2	0.8			
09/21/2023 22:00	3,463.5	0.0	3,463.5	103,340.0	357.9	0.43	0.2	0.7			
09/21/2023 23:00	3,461.8	0.0	3,461.8	103,340.0	357.7	0.43	0.2	0.7			
Average/Sum#:	3,699.3	0.0	3,699.3	103,340.0	382.3	0.46	0.2	0.8			
Minimum:	3,425.6	0.0	3,425.6	103,340.0	354.0	0.42	0.2	0.7			
Maximum:	4,272.4	0.0	4,272.4	103,340.0	441.5	0.53	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2023 00:00	3,456.8	0.0	3,456.8	103,340.0	357.2	0.43	0.2	0.7
09/22/2023 01:00	3,466.5	0.0	3,466.5	103,340.0	358.2	0.43	0.2	0.7
09/22/2023 02:00	3,465.3	0.0	3,465.3	103,340.0	358.1	0.43	0.2	0.7
09/22/2023 03:00	3,460.1	0.0	3,460.1	103,340.0	357.6	0.43	0.2	0.7
09/22/2023 04:00	3,467.8	0.0	3,467.8	103,340.0	358.4	0.43	0.2	0.7
09/22/2023 05:00	3,466.2	0.0	3,466.2	103,340.0	358.2	0.43	0.2	0.7
09/22/2023 06:00	3,729.2	0.0	3,729.2	103,340.0	385.4	0.46	0.2	0.8
09/22/2023 07:00	4,113.3	0.0	4,113.3	103,340.0	425.1	0.51	0.3	0.8
09/22/2023 08:00	3,777.4	0.0	3,777.4	103,340.0	390.4	0.47	0.2	0.8
09/22/2023 09:00	3,439.8	0.0	3,439.8	103,340.0	355.5	0.43	0.2	0.7
09/22/2023 10:00	3,438.3	0.0	3,438.3	103,340.0	355.3	0.43	0.2	0.7
09/22/2023 11:00	3,438.7	0.0	3,438.7	103,340.0	355.4	0.43	0.2	0.7
09/22/2023 12:00	3,453.9	0.0	3,453.9	103,340.0	356.9	0.43	0.2	0.7
09/22/2023 13:00	3,464.8	0.0	3,464.8	103,340.0	358.1	0.43	0.2	0.7
09/22/2023 14:00	3,617.6	0.0	3,617.6	103,340.0	373.8	0.45	0.2	0.7
09/22/2023 15:00	3,468.2	0.0	3,468.2	103,340.0	358.4	0.43	0.2	0.7
09/22/2023 16:00	3,868.7	0.0	3,868.7	103,340.0	399.8	0.48	0.2	0.8
09/22/2023 17:00	4,378.7	0.0	4,378.7	103,340.0	452.5	0.54	0.3	0.9
09/22/2023 18:00	4,383.3	0.0	4,383.3	103,340.0	453.0	0.54	0.3	0.9
09/22/2023 19:00	4,383.1	0.0	4,383.1	103,340.0	452.9	0.54	0.3	0.9
09/22/2023 20:00	4,192.2	0.0	4,192.2	103,340.0	433.2	0.52	0.3	0.9
09/22/2023 21:00	3,832.3	0.0	3,832.3	103,340.0	396.0	0.48	0.2	0.8
09/22/2023 22:00	3,442.0	0.0	3,442.0	103,340.0	355.7	0.43	0.2	0.7
09/22/2023 23:00	3,453.5	0.0	3,453.5	103,340.0	356.9	0.43	0.2	0.7
Average/Sum#:	3,694.1	0.0	3,694.1	103,340.0	381.8	0.46	0.2	0.8
Minimum:	3,438.3	0.0	3,438.3	103,340.0	355.3	0.43	0.2	0.7
Maximum:	4,383.3	0.0	4,383.3	103,340.0	453.0	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2023 00:00	3,468.9	0.0	3,468.9	103,340.0	358.5	0.43	0.2	0.7
09/23/2023 01:00	3,467.8	0.0	3,467.8	103,340.0	358.4	0.43	0.2	0.7
09/23/2023 02:00	3,471.4	0.0	3,471.4	103,340.0	358.7	0.43	0.2	0.7
09/23/2023 03:00	3,467.2	0.0	3,467.2	103,340.0	358.3	0.43	0.2	0.7
09/23/2023 04:00	3,459.8	0.0	3,459.8	103,340.0	357.5	0.43	0.2	0.7
09/23/2023 05:00	3,458.1	0.0	3,458.1	103,340.0	357.4	0.43	0.2	0.7
09/23/2023 06:00	3,470.7	0.0	3,470.7	103,340.0	358.7	0.43	0.2	0.7
09/23/2023 07:00	3,513.9	0.0	3,513.9	103,340.0	363.1	0.44	0.2	0.7
09/23/2023 08:00	3,518.9	0.0	3,518.9	103,340.0	363.6	0.44	0.2	0.7
09/23/2023 09:00	3,517.1	0.0	3,517.1	103,340.0	363.5	0.44	0.2	0.7
09/23/2023 10:00	3,506.0	0.0	3,506.0	103,340.0	362.3	0.44	0.2	0.7
09/23/2023 11:00	3,490.6	0.0	3,490.6	103,340.0	360.7	0.43	0.2	0.7
09/23/2023 12:00	3,470.6	0.0	3,470.6	103,340.0	358.7	0.43	0.2	0.7
09/23/2023 13:00	3,456.2	0.0	3,456.2	103,340.0	357.2	0.43	0.2	0.7
09/23/2023 14:00	3,458.0	0.0	3,458.0	103,340.0	357.3	0.43	0.2	0.7
09/23/2023 15:00	3,454.8	0.0	3,454.8	103,340.0	357.0	0.43	0.2	0.7
09/23/2023 16:00	3,452.6	0.0	3,452.6	103,340.0	356.8	0.43	0.2	0.7
09/23/2023 17:00	3,646.6	0.0	3,646.6	103,340.0	376.8	0.45	0.2	0.8
09/23/2023 18:00	3,693.3	0.0	3,693.3	103,340.0	381.7	0.46	0.2	0.8
09/23/2023 19:00	3,450.1	0.0	3,450.1	103,340.0	356.5	0.43	0.2	0.7
09/23/2023 20:00	3,438.1	0.0	3,438.1	103,340.0	355.3	0.43	0.2	0.7
09/23/2023 21:00	3,471.3	0.0	3,471.3	103,340.0	358.7	0.43	0.2	0.7
09/23/2023 22:00	3,705.6	0.0	3,705.6	103,340.0	382.9	0.46	0.2	0.8
09/23/2023 23:00	3,470.5	0.0	3,470.5	103,340.0	358.6	0.43	0.2	0.7
Average/Sum#:	3,499.1	0.0	3,499.1	103,340.0	361.6	0.44	0.2	0.7
Minimum:	3,438.1	0.0	3,438.1	103,340.0	355.3	0.43	0.2	0.7
Maximum:	3,705.6	0.0	3,705.6	103,340.0	382.9	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2023 00:00	3,473.4	0.0	3,473.4	103,340.0	358.9	0.43	0.2	0.7
09/24/2023 01:00	3,486.8	0.0	3,486.8	103,340.0	360.3	0.43	0.2	0.7
09/24/2023 02:00	3,488.6	0.0	3,488.6	103,340.0	360.5	0.43	0.2	0.7
09/24/2023 03:00	3,479.5	0.0	3,479.5	103,340.0	359.6	0.43	0.2	0.7
09/24/2023 04:00	3,485.4	0.0	3,485.4	103,340.0	360.2	0.43	0.2	0.7
09/24/2023 05:00	3,484.1	0.0	3,484.1	103,340.0	360.0	0.43	0.2	0.7
09/24/2023 06:00	3,488.7	0.0	3,488.7	103,340.0	360.5	0.43	0.2	0.7
09/24/2023 07:00	3,487.6	0.0	3,487.6	103,340.0	360.4	0.43	0.2	0.7
09/24/2023 08:00	3,485.2	0.0	3,485.2	103,340.0	360.2	0.43	0.2	0.7
09/24/2023 09:00	3,486.5	0.0	3,486.5	103,340.0	360.3	0.43	0.2	0.7
09/24/2023 10:00	3,495.3	0.0	3,495.3	103,340.0	361.2	0.43	0.2	0.7
09/24/2023 11:00	3,498.5	0.0	3,498.5	103,340.0	361.5	0.43	0.2	0.7
09/24/2023 12:00	3,502.4	0.0	3,502.4	103,340.0	361.9	0.43	0.2	0.7
09/24/2023 13:00	3,499.8	0.0	3,499.8	103,340.0	361.7	0.43	0.2	0.7
09/24/2023 14:00	3,503.3	0.0	3,503.3	103,340.0	362.0	0.43	0.2	0.7
09/24/2023 15:00	3,510.5	0.0	3,510.5	103,340.0	362.8	0.44	0.2	0.7
09/24/2023 16:00	3,468.0	0.0	3,468.0	103,340.0	358.4	0.43	0.2	0.7
09/24/2023 17:00	3,874.1	0.0	3,874.1	103,340.0	400.3	0.48	0.2	0.8
09/24/2023 18:00	4,377.6	0.0	4,377.6	103,340.0	452.4	0.54	0.3	0.9
09/24/2023 19:00	4,215.3	0.0	4,215.3	103,340.0	435.6	0.52	0.3	0.9
09/24/2023 20:00	3,971.2	0.0	3,971.2	103,340.0	410.4	0.49	0.2	0.8
09/24/2023 21:00	4,267.0	0.0	4,267.0	103,340.0	441.0	0.53	0.3	0.9
09/24/2023 22:00	3,590.8	0.0	3,590.8	103,340.0	371.1	0.45	0.2	0.7
09/24/2023 23:00	3,459.1	0.0	3,459.1	103,340.0	357.5	0.43	0.2	0.7
Average/Sum#:	3,628.3	0.0	3,628.3	103,340.0	374.9	0.45	0.2	0.7
Minimum:	3,459.1	0.0	3,459.1	103,340.0	357.5	0.43	0.2	0.7
Maximum:	4,377.6	0.0	4,377.6	103,340.0	452.4	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2023 00:00	3,484.6	0.0	3,484.6	103,340.0	360.1	0.43	0.2	0.7
09/25/2023 01:00	3,480.2	0.0	3,480.2	103,340.0	359.6	0.43	0.2	0.7
09/25/2023 02:00	3,466.4	0.0	3,466.4	103,340.0	358.2	0.43	0.2	0.7
09/25/2023 03:00	3,471.3	0.0	3,471.3	103,340.0	358.7	0.43	0.2	0.7
09/25/2023 04:00	3,478.0	0.0	3,478.0	103,340.0	359.4	0.43	0.2	0.7
09/25/2023 05:00	3,479.4	0.0	3,479.4	103,340.0	359.6	0.43	0.2	0.7
09/25/2023 06:00	4,003.5	0.0	4,003.5	103,340.0	413.7	0.49	0.2	0.8
09/25/2023 07:00	3,814.5	0.0	3,814.5	103,340.0	394.2	0.47	0.2	0.8
09/25/2023 08:00	3,473.1	0.0	3,473.1	103,340.0	358.9	0.43	0.2	0.7
09/25/2023 09:00	3,466.5	0.0	3,466.5	103,340.0	358.2	0.43	0.2	0.7
09/25/2023 10:00	3,478.3	0.0	3,478.3	103,340.0	359.4	0.43	0.2	0.7
09/25/2023 11:00	3,465.5	0.0	3,465.5	103,340.0	358.1	0.43	0.2	0.7
09/25/2023 12:00	3,471.3	0.0	3,471.3	103,340.0	358.7	0.43	0.2	0.7
09/25/2023 13:00	3,489.0	0.0	3,489.0	103,340.0	360.6	0.43	0.2	0.7
09/25/2023 14:00	3,480.3	0.0	3,480.3	103,340.0	359.7	0.43	0.2	0.7
09/25/2023 15:00	3,494.3	0.0	3,494.3	103,340.0	361.1	0.43	0.2	0.7
09/25/2023 16:00	3,509.3	0.0	3,509.3	103,340.0	362.7	0.44	0.2	0.7
09/25/2023 17:00	3,920.4	8.2	3,921.2	103,340.0	405.2	0.49	0.2	0.8
09/25/2023 18:00	3,467.2	0.0	3,467.2	103,340.0	358.3	0.43	0.2	0.7
09/25/2023 19:00	3,457.0	0.0	3,457.0	103,340.0	357.2	0.43	0.2	0.7
09/25/2023 20:00	3,452.1	0.0	3,452.1	103,340.0	356.7	0.43	0.2	0.7
09/25/2023 21:00	3,833.6	0.0	3,833.6	103,340.0	396.2	0.48	0.2	0.8
09/25/2023 22:00	3,754.2	0.0	3,754.2	103,340.0	388.0	0.47	0.2	0.8
09/25/2023 23:00	3,443.9	0.0	3,443.9	103,340.0	355.9	0.43	0.2	0.7
Average/Sum#:	3,555.6	0.3	3,555.6	103,340.0	367.4	0.44	0.2	0.7
Minimum:	3,443.9	0.0	3,443.9	103,340.0	355.9	0.43	0.2	0.7
Maximum:	4,003.5	8.2	4,003.5	103,340.0	413.7	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2023 00:00	3,447.6	0.0	3,447.6	103,340.0	356.3	0.43	0.2	0.7
09/26/2023 01:00	3,461.3	0.0	3,461.3	103,340.0	357.7	0.43	0.2	0.7
09/26/2023 02:00	3,470.8	0.0	3,470.8	103,340.0	358.7	0.43	0.2	0.7
09/26/2023 03:00	3,481.6	0.0	3,481.6	103,340.0	359.8	0.43	0.2	0.7
09/26/2023 04:00	3,484.2	0.0	3,484.2	103,340.0	360.1	0.43	0.2	0.7
09/26/2023 05:00	3,624.4	0.0	3,624.4	103,340.0	374.5	0.45	0.2	0.7
09/26/2023 06:00	3,951.8	0.0	3,951.8	103,340.0	408.4	0.49	0.2	0.8
09/26/2023 07:00	3,653.3	0.0	3,653.3	103,340.0	377.5	0.45	0.2	0.8
09/26/2023 08:00	4,239.5	0.7	4,239.5	103,340.0	438.1	0.53	0.3	0.9
09/26/2023 09:00	3,825.1	0.0	3,825.1	103,340.0	395.3	0.47	0.2	0.8
09/26/2023 10:00	3,462.4	0.0	3,462.4	103,340.0	357.8	0.43	0.2	0.7
09/26/2023 11:00	3,446.3	0.0	3,446.3	103,340.0	356.1	0.43	0.2	0.7
09/26/2023 12:00	3,440.6	0.0	3,440.6	103,340.0	355.6	0.43	0.2	0.7
09/26/2023 13:00	3,759.7	0.0	3,759.7	103,340.0	388.5	0.47	0.2	0.8
09/26/2023 14:00	3,481.5	0.0	3,481.5	103,340.0	359.8	0.43	0.2	0.7
09/26/2023 15:00	3,487.4	0.0	3,487.4	103,340.0	360.4	0.43	0.2	0.7
09/26/2023 16:00	3,482.3	0.0	3,482.3	103,340.0	359.9	0.43	0.2	0.7
09/26/2023 17:00	3,538.8	0.0	3,538.8	103,340.0	365.7	0.44	0.2	0.7
09/26/2023 18:00	3,836.7	19.9	3,841.1	103,340.0	396.9	0.48	0.2	0.8
09/26/2023 19:00	3,537.4	0.0	3,537.4	103,340.0	365.6	0.44	0.2	0.7
09/26/2023 20:00	3,474.0	0.0	3,474.0	103,340.0	359.0	0.43	0.2	0.7
09/26/2023 21:00	3,474.6	0.0	3,474.6	103,340.0	359.1	0.43	0.2	0.7
09/26/2023 22:00	3,582.9	0.0	3,582.9	103,340.0	370.3	0.45	0.2	0.7
09/26/2023 23:00	3,482.2	0.0	3,482.2	103,340.0	359.9	0.43	0.2	0.7
Average/Sum#:	3,588.6	0.9	3,588.8	103,340.0	370.9	0.45	0.2	0.7
Minimum:	3,440.6	0.0	3,440.6	103,340.0	355.6	0.43	0.2	0.7
Maximum:	4,239.5	19.9	4,239.5	103,340.0	438.1	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2023 00:00	3,504.9	0.0	3,504.9	103,340.0	362.2	0.43	0.2	0.7
09/27/2023 01:00	3,498.3	0.0	3,498.3	103,340.0	361.5	0.43	0.2	0.7
09/27/2023 02:00	3,494.3	0.0	3,494.3	103,340.0	361.1	0.43	0.2	0.7
09/27/2023 03:00	3,498.2	0.0	3,498.2	103,340.0	361.5	0.43	0.2	0.7
09/27/2023 04:00	3,496.9	0.0	3,496.9	103,340.0	361.4	0.43	0.2	0.7
09/27/2023 05:00	3,497.3	0.0	3,497.3	103,340.0	361.4	0.43	0.2	0.7
09/27/2023 06:00	3,496.3	0.0	3,496.3	103,340.0	361.3	0.43	0.2	0.7
09/27/2023 07:00	3,486.2	0.0	3,486.2	103,340.0	360.3	0.43	0.2	0.7
09/27/2023 08:00	3,489.2	0.0	3,489.2	103,340.0	360.6	0.43	0.2	0.7
09/27/2023 09:00	3,481.1	0.0	3,481.1	103,340.0	359.7	0.43	0.2	0.7
09/27/2023 10:00	3,466.4	0.0	3,466.4	103,340.0	358.2	0.43	0.2	0.7
09/27/2023 11:00	3,459.3	0.0	3,459.3	103,340.0	357.5	0.43	0.2	0.7
09/27/2023 12:00	3,464.1	0.0	3,464.1	103,340.0	358.0	0.43	0.2	0.7
09/27/2023 13:00	3,470.2	0.0	3,470.2	103,340.0	358.6	0.43	0.2	0.7
09/27/2023 14:00	3,463.1	0.0	3,463.1	103,340.0	357.9	0.43	0.2	0.7
09/27/2023 15:00	3,465.5	0.0	3,465.5	103,340.0	358.1	0.43	0.2	0.7
09/27/2023 16:00	3,463.3	0.0	3,463.3	103,340.0	357.9	0.43	0.2	0.7
09/27/2023 17:00	3,463.0	0.0	3,463.0	103,340.0	357.9	0.43	0.2	0.7
09/27/2023 18:00	3,462.7	0.0	3,462.7	103,340.0	357.8	0.43	0.2	0.7
09/27/2023 19:00	3,457.3	0.0	3,457.3	103,340.0	357.3	0.43	0.2	0.7
09/27/2023 20:00	3,455.9	0.0	3,455.9	103,340.0	357.1	0.43	0.2	0.7
09/27/2023 21:00	3,463.9	0.0	3,463.9	103,340.0	358.0	0.43	0.2	0.7
09/27/2023 22:00	3,452.9	0.0	3,452.9	103,340.0	356.8	0.43	0.2	0.7
09/27/2023 23:00	3,449.9	0.0	3,449.9	103,340.0	356.5	0.43	0.2	0.7
Average/Sum#:	3,475.0	0.0	3,475.0	103,340.0	359.1	0.43	0.2	0.7
Minimum:	3,449.9	0.0	3,449.9	103,340.0	356.5	0.43	0.2	0.7
Maximum:	3,504.9	0.0	3,504.9	103,340.0	362.2	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2023 00:00	3,442.3	0.0	3,442.3	103,340.0	355.7	0.43	0.2	0.7
09/28/2023 01:00	3,440.6	0.0	3,440.6	103,340.0	355.6	0.43	0.2	0.7
09/28/2023 02:00	3,451.1	0.0	3,451.1	103,340.0	356.6	0.43	0.2	0.7
09/28/2023 03:00	3,468.8	0.0	3,468.8	103,340.0	358.5	0.43	0.2	0.7
09/28/2023 04:00	3,471.6	0.0	3,471.6	103,340.0	358.8	0.43	0.2	0.7
09/28/2023 05:00	3,469.5	0.0	3,469.5	103,340.0	358.5	0.43	0.2	0.7
09/28/2023 06:00	3,690.1	0.9	3,690.1	103,340.0	381.3	0.46	0.2	0.8
09/28/2023 07:00	3,963.4	0.0	3,963.4	103,340.0	409.6	0.49	0.2	0.8
09/28/2023 08:00	3,464.6	0.0	3,464.6	103,340.0	358.0	0.43	0.2	0.7
09/28/2023 09:00	3,480.2	0.0	3,480.2	103,340.0	359.6	0.43	0.2	0.7
09/28/2023 10:00	3,481.2	0.0	3,481.2	103,340.0	359.7	0.43	0.2	0.7
09/28/2023 11:00	3,475.4	0.0	3,475.4	103,340.0	359.1	0.43	0.2	0.7
09/28/2023 12:00	3,466.2	0.0	3,466.2	103,340.0	358.2	0.43	0.2	0.7
09/28/2023 13:00	3,450.9	0.0	3,450.9	103,340.0	356.6	0.43	0.2	0.7
09/28/2023 14:00	3,443.4	0.0	3,443.4	103,340.0	355.8	0.43	0.2	0.7
09/28/2023 15:00	3,445.3	0.0	3,445.3	103,340.0	356.0	0.43	0.2	0.7
09/28/2023 16:00	3,449.0	0.0	3,449.0	103,340.0	356.4	0.43	0.2	0.7
09/28/2023 17:00	3,526.2	0.0	3,526.2	103,340.0	364.4	0.44	0.2	0.7
09/28/2023 18:00	3,447.3	0.0	3,447.3	103,340.0	356.2	0.43	0.2	0.7
09/28/2023 19:00	3,447.4	0.0	3,447.4	103,340.0	356.3	0.43	0.2	0.7
09/28/2023 20:00	3,447.6	0.0	3,447.6	103,340.0	356.3	0.43	0.2	0.7
09/28/2023 21:00	3,468.0	0.0	3,468.0	103,340.0	358.4	0.43	0.2	0.7
09/28/2023 22:00	3,467.2	0.0	3,467.2	103,340.0	358.3	0.43	0.2	0.7
09/28/2023 23:00	3,462.5	0.0	3,462.5	103,340.0	357.8	0.43	0.2	0.7
Average/Sum#:	3,492.5	0.0	3,492.5	103,340.0	360.9	0.43	0.2	0.7
Minimum:	3,440.6	0.0	3,440.6	103,340.0	355.6	0.43	0.2	0.7
Maximum:	3,963.4	0.9	3,963.4	103,340.0	409.6	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2023 00:00	3,459.1	0.0	3,459.1	103,340.0	357.5	0.43	0.2	0.7
09/29/2023 01:00	3,461.9	0.0	3,461.9	103,340.0	357.8	0.43	0.2	0.7
09/29/2023 02:00	3,459.2	0.0	3,459.2	103,340.0	357.5	0.43	0.2	0.7
09/29/2023 03:00	3,460.3	0.0	3,460.3	103,340.0	357.6	0.43	0.2	0.7
09/29/2023 04:00	3,462.7	0.0	3,462.7	103,340.0	357.8	0.43	0.2	0.7
09/29/2023 05:00	3,461.5	0.0	3,461.5	103,340.0	357.7	0.43	0.2	0.7
09/29/2023 06:00	3,465.5	0.0	3,465.5	103,340.0	358.1	0.43	0.2	0.7
09/29/2023 07:00	3,555.2	0.0	3,555.2	103,340.0	367.4	0.44	0.2	0.7
09/29/2023 08:00	3,461.6	0.0	3,461.6	103,340.0	357.7	0.43	0.2	0.7
09/29/2023 09:00	3,458.1	0.0	3,458.1	103,340.0	357.4	0.43	0.2	0.7
09/29/2023 10:00	3,455.6	0.0	3,455.6	103,340.0	357.1	0.43	0.2	0.7
09/29/2023 11:00	3,472.4	0.0	3,472.4	103,340.0	358.8	0.43	0.2	0.7
09/29/2023 12:00	3,477.3	0.0	3,477.3	103,340.0	359.3	0.43	0.2	0.7
09/29/2023 13:00	3,484.2	0.0	3,484.2	103,340.0	360.1	0.43	0.2	0.7
09/29/2023 14:00	3,490.6	0.0	3,490.6	103,340.0	360.7	0.43	0.2	0.7
09/29/2023 15:00	3,483.6	0.0	3,483.6	103,340.0	360.0	0.43	0.2	0.7
09/29/2023 16:00	3,471.0	0.0	3,471.0	103,340.0	358.7	0.43	0.2	0.7
09/29/2023 17:00	3,766.7	0.0	3,766.7	103,340.0	389.3	0.47	0.2	0.8
09/29/2023 18:00	3,449.0	0.0	3,449.0	103,340.0	356.4	0.43	0.2	0.7
09/29/2023 19:00	3,442.0	0.0	3,442.0	103,340.0	355.7	0.43	0.2	0.7
09/29/2023 20:00	3,445.6	0.0	3,445.6	103,340.0	356.1	0.43	0.2	0.7
09/29/2023 21:00	3,449.2	0.0	3,449.2	103,340.0	356.4	0.43	0.2	0.7
09/29/2023 22:00	3,446.4	0.0	3,446.4	103,340.0	356.2	0.43	0.2	0.7
09/29/2023 23:00	3,450.1	0.0	3,450.1	103,340.0	356.5	0.43	0.2	0.7
Average/Sum#:	3,478.7	0.0	3,478.7	103,340.0	359.5	0.43	0.2	0.7
Minimum:	3,442.0	0.0	3,442.0	103,340.0	355.7	0.43	0.2	0.7
Maximum:	3,766.7	0.0	3,766.7	103,340.0	389.3	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2023 00:00	3,452.3	0.0	3,452.3	103,340.0	356.8	0.43	0.2	0.7
09/30/2023 01:00	3,451.9	0.0	3,451.9	103,340.0	356.7	0.43	0.2	0.7
09/30/2023 02:00	3,457.3	0.0	3,457.3	103,340.0	357.3	0.43	0.2	0.7
09/30/2023 03:00	3,462.7	0.0	3,462.7	103,340.0	357.8	0.43	0.2	0.7
09/30/2023 04:00	3,460.4	0.0	3,460.4	103,340.0	357.6	0.43	0.2	0.7
09/30/2023 05:00	3,451.6	0.0	3,451.6	103,340.0	356.7	0.43	0.2	0.7
09/30/2023 06:00	3,450.2	0.0	3,450.2	103,340.0	356.5	0.43	0.2	0.7
09/30/2023 07:00	3,451.4	0.0	3,451.4	103,340.0	356.7	0.43	0.2	0.7
09/30/2023 08:00	3,456.3	0.0	3,456.3	103,340.0	357.2	0.43	0.2	0.7
09/30/2023 09:00	3,449.2	0.0	3,449.2	103,340.0	356.4	0.43	0.2	0.7
09/30/2023 10:00	3,447.3	0.0	3,447.3	103,340.0	356.2	0.43	0.2	0.7
09/30/2023 11:00	3,478.9	0.0	3,478.9	103,340.0	359.5	0.43	0.2	0.7
09/30/2023 12:00	3,464.1	0.0	3,464.1	103,340.0	358.0	0.43	0.2	0.7
09/30/2023 13:00	3,462.3	0.0	3,462.3	103,340.0	357.8	0.43	0.2	0.7
09/30/2023 14:00	3,461.4	0.0	3,461.4	103,340.0	357.7	0.43	0.2	0.7
09/30/2023 15:00	3,470.2	0.0	3,470.2	103,340.0	358.6	0.43	0.2	0.7
09/30/2023 16:00	3,471.4	0.0	3,471.4	103,340.0	358.7	0.43	0.2	0.7
09/30/2023 17:00	3,471.2	0.0	3,471.2	103,340.0	358.7	0.43	0.2	0.7
09/30/2023 18:00	3,469.1	0.0	3,469.1	103,340.0	358.5	0.43	0.2	0.7
09/30/2023 19:00	3,469.1	0.0	3,469.1	103,340.0	358.5	0.43	0.2	0.7
09/30/2023 20:00	3,469.5	0.0	3,469.5	103,340.0	358.5	0.43	0.2	0.7
09/30/2023 21:00	3,461.0	0.0	3,461.0	103,340.0	357.7	0.43	0.2	0.7
09/30/2023 22:00	3,457.6	0.0	3,457.6	103,340.0	357.3	0.43	0.2	0.7
09/30/2023 23:00	3,459.6	0.0	3,459.6	103,340.0	357.5	0.43	0.2	0.7
Average/Sum#:	3,460.7	0.0	3,460.7	103,340.0	357.6	0.43	0.2	0.7
Minimum:	3,447.3	0.0	3,447.3	103,340.0	356.2	0.43	0.2	0.7
Maximum:	3,478.9	0.0	3,478.9	103,340.0	359.5	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)			
07/01/2023 00:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 01:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 02:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 03:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 04:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 05:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 06:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 07:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 08:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 09:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 10:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 11:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 12:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 13:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 14:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 15:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 16:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 17:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 18:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 19:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 20:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 21:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 22:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2023 23:00	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/02/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/03/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/04/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/05/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/06/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 09:00	760.6	0.0	760.6	105,900.0	80.5	0.0	0.0	0.0
07/07/2023 10:00	918.1	0.0	918.1	105,900.0	97.2	0.0	0.0	0.0
07/07/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 12:00	925.5	0.0	925.5	105,900.0	98.0	0.0	0.0	0.0
07/07/2023 13:00	806.0	0.0	806.0	105,900.0	85.4	0.0	0.0	0.0
07/07/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 16:00	899.2	0.0	899.2	105,900.0	95.2	0.0	0.0	0.0
07/07/2023 17:00	807.4	0.0	807.4	105,900.0	85.5	0.0	0.0	0.0
07/07/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/07/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	852.8	0.0	852.8	105,900.0	90.3	0.0	0.0	0.0
Minimum:	760.6	0.0	760.6	105,900.0	80.5	0.0	0.0	0.0
Maximum:	925.5	0.0	925.5	105,900.0	98.0	0.0	0.0	0.0
%SI	75.00	75.00	75.00	0.00	75.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 09:00	917.4	0.0	917.4	105,900.0	97.2	0.0	0.0	0.0
07/08/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 17:00	742.5	0.0	742.5	105,900.0	78.6	0.0	0.0	0.0
07/08/2023 18:00	1,123.7	0.0	1,123.7	105,900.0	119.0	0.0	0.0	0.0
07/08/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/08/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	927.9	0.0	927.9	105,900.0	98.3	0.0	0.0	0.0
Minimum:	742.5	0.0	742.5	105,900.0	78.6	0.0	0.0	0.0
Maximum:	1,123.7	0.0	1,123.7	105,900.0	119.0	0.0	0.0	0.0
%SI	87.50	87.50	87.50	0.00	87.50	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 06:00	2,179.6	0.0	2,179.6	105,900.0	230.8	0.0	0.0	0.0
07/09/2023 07:00	4,454.8	0.0	4,454.8	105,900.0	471.8	0.0	0.0	0.0
07/09/2023 08:00	2,954.0	0.0	2,954.0	105,900.0	312.8	0.4	0.2	0.7
07/09/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/09/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,196.1	0.0	3,196.1	105,900.0	338.5	0.4	0.2	0.7
Minimum:	2,179.6	0.0	2,179.6	105,900.0	230.8	0.4	0.2	0.7
Maximum:	4,454.8	0.0	4,454.8	105,900.0	471.8	0.4	0.2	0.7
%SI	87.50	87.50	87.50	0.00	87.50	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/10/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/11/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/12/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 16:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 17:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 18:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 19:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 20:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 21:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 22:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/13/2023 23:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2023 00:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 01:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 02:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 03:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 04:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 05:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 06:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 07:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 08:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 09:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 10:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 11:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 12:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 13:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 14:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 15:00	0.0	0.0	0.0	105,900.0	0.0	0.0	0.0	0.0
07/14/2023 16:00	2,910.8	0.0	2,910.8	105,900.0	308.3	0.0	0.0	0.0
07/14/2023 17:00	4,045.1	171.9	4,079.5	105,900.0	432.0	0.5	0.3	0.9
07/14/2023 18:00	4,302.5	1,483.1	5,785.6	105,900.0	612.7	0.7	0.4	1.2
07/14/2023 19:00	4,259.6	1,832.0	6,091.6	105,900.0	645.1	0.8	0.4	1.3
07/14/2023 20:00	4,273.2	1,757.0	6,030.2	105,900.0	638.6	0.8	0.4	1.3
07/14/2023 21:00	4,403.5	1,404.0	5,807.5	105,900.0	615.0	0.7	0.4	1.2
07/14/2023 22:00	4,439.3	1,069.1	5,508.4	105,900.0	583.3	0.7	0.4	1.2
07/14/2023 23:00	4,141.1	6.7	4,141.3	105,900.0	438.6	0.5	0.3	0.9
Average/Sum#:	4,096.9	965.5	5,044.4	105,900.0	534.2	0.7	0.4	1.1
Minimum:	2,910.8	0.0	2,910.8	105,900.0	308.3	0.5	0.3	0.9
Maximum:	4,439.3	1,832.0	6,091.6	105,900.0	645.1	0.8	0.4	1.3
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2023 00:00	4,469.4	1.4	4,469.5	105,900.0	473.3	0.6	0.3	0.9
07/15/2023 01:00	4,310.2	0.0	4,310.2	105,900.0	456.5	0.5	0.3	0.9
07/15/2023 02:00	4,259.2	0.0	4,259.2	105,900.0	451.0	0.5	0.3	0.9
07/15/2023 03:00	4,382.5	0.0	4,382.5	105,900.0	464.1	0.6	0.3	0.9
07/15/2023 04:00	4,404.9	0.0	4,404.9	105,900.0	466.5	0.6	0.3	0.9
07/15/2023 05:00	4,411.0	0.0	4,411.0	105,900.0	467.1	0.6	0.3	0.9
07/15/2023 06:00	4,073.2	0.0	4,073.2	105,900.0	431.4	0.5	0.3	0.9
07/15/2023 07:00	3,639.4	0.0	3,639.4	105,900.0	385.4	0.5	0.2	0.8
07/15/2023 08:00	3,633.1	0.0	3,633.1	105,900.0	384.7	0.5	0.2	0.8
07/15/2023 09:00	3,622.5	0.0	3,622.5	105,900.0	383.6	0.5	0.2	0.8
07/15/2023 10:00	3,614.3	0.0	3,614.3	105,900.0	382.8	0.5	0.2	0.8
07/15/2023 11:00	3,608.3	0.0	3,608.3	105,900.0	382.1	0.5	0.2	0.8
07/15/2023 12:00	3,918.9	0.0	3,918.9	105,900.0	415.0	0.5	0.2	0.8
07/15/2023 13:00	4,224.7	0.0	4,224.7	105,900.0	447.4	0.5	0.3	0.9
07/15/2023 14:00	3,959.6	0.0	3,959.6	105,900.0	419.3	0.5	0.3	0.8
07/15/2023 15:00	3,989.8	663.5	4,341.5	105,900.0	459.8	0.6	0.3	1.0
07/15/2023 16:00	4,194.8	1,760.0	5,954.8	105,900.0	630.6	0.8	0.4	1.3
07/15/2023 17:00	4,150.4	1,745.3	5,895.7	105,900.0	624.4	0.7	0.4	1.2
07/15/2023 18:00	4,122.7	1,752.8	5,875.5	105,900.0	622.2	0.7	0.4	1.2
07/15/2023 19:00	4,136.8	1,763.4	5,900.2	105,900.0	624.8	0.8	0.4	1.3
07/15/2023 20:00	4,213.8	1,812.9	6,026.7	105,900.0	638.2	0.8	0.4	1.3
07/15/2023 21:00	4,288.2	1,844.6	6,132.8	105,900.0	649.5	0.8	0.4	1.3
07/15/2023 22:00	4,366.2	1,632.5	5,998.7	105,900.0	635.3	0.8	0.4	1.3
07/15/2023 23:00	4,424.2	833.1	5,257.3	105,900.0	556.7	0.7	0.3	1.1
Average/Sum#:	4,100.8	575.4	4,663.1	105,900.0	493.8	0.6	0.3	1.0
Minimum:	3,608.3	0.0	3,608.3	105,900.0	382.1	0.5	0.2	0.8
Maximum:	4,469.4	1,844.6	6,132.8	105,900.0	649.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2023 00:00	4,454.8	92.7	4,476.1	105,900.0	474.0	0.6	0.3	1.0
07/16/2023 01:00	4,477.2	0.0	4,477.2	105,900.0	474.1	0.6	0.3	0.9
07/16/2023 02:00	4,499.3	0.0	4,499.3	105,900.0	476.5	0.6	0.3	1.0
07/16/2023 03:00	4,489.9	0.0	4,489.9	105,900.0	475.5	0.6	0.3	1.0
07/16/2023 04:00	4,430.9	0.0	4,430.9	105,900.0	469.2	0.6	0.3	0.9
07/16/2023 05:00	4,505.7	0.0	4,505.7	105,900.0	477.2	0.6	0.3	1.0
07/16/2023 06:00	4,021.3	0.0	4,021.3	105,900.0	425.9	0.5	0.3	0.9
07/16/2023 07:00	3,631.0	0.0	3,631.0	105,900.0	384.5	0.5	0.2	0.8
07/16/2023 08:00	3,630.6	0.0	3,630.6	105,900.0	384.5	0.5	0.2	0.8
07/16/2023 09:00	3,622.4	0.0	3,622.4	105,900.0	383.6	0.5	0.2	0.8
07/16/2023 10:00	4,009.2	0.0	4,009.2	105,900.0	424.6	0.5	0.3	0.8
07/16/2023 11:00	4,125.2	0.0	4,125.2	105,900.0	436.9	0.5	0.3	0.9
07/16/2023 12:00	3,955.1	0.0	3,955.1	105,900.0	418.8	0.5	0.3	0.8
07/16/2023 13:00	4,191.9	7.1	4,192.3	105,900.0	444.0	0.5	0.3	0.9
07/16/2023 14:00	4,377.2	1,605.9	5,983.1	105,900.0	633.6	0.8	0.4	1.3
07/16/2023 15:00	4,358.9	1,891.5	6,250.4	105,900.0	661.9	0.8	0.4	1.3
07/16/2023 16:00	4,348.3	1,874.3	6,222.6	105,900.0	659.0	0.8	0.4	1.3
07/16/2023 17:00	4,348.1	1,894.9	6,243.0	105,900.0	661.1	0.8	0.4	1.3
07/16/2023 18:00	4,324.9	1,863.9	6,188.8	105,900.0	655.4	0.8	0.4	1.3
07/16/2023 19:00	4,374.0	1,845.9	6,219.9	105,900.0	658.7	0.8	0.4	1.3
07/16/2023 20:00	4,452.9	1,263.4	5,716.3	105,900.0	605.4	0.7	0.4	1.2
07/16/2023 21:00	4,511.3	1,118.9	5,630.2	105,900.0	596.2	0.7	0.4	1.2
07/16/2023 22:00	4,233.5	5.9	4,233.7	105,900.0	448.3	0.5	0.3	0.9
07/16/2023 23:00	3,927.2	0.0	3,927.2	105,900.0	415.9	0.5	0.2	0.8
Average/Sum#:	4,220.9	561.0	4,778.4	105,900.0	506.0	0.6	0.3	1.0
Minimum:	3,622.4	0.0	3,622.4	105,900.0	383.6	0.5	0.2	0.8
Maximum:	4,511.3	1,894.9	6,250.4	105,900.0	661.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2023 00:00	4,372.5	0.0	4,372.5	105,900.0	463.0	0.6	0.3	0.9
07/17/2023 01:00	4,330.2	0.0	4,330.2	105,900.0	458.6	0.6	0.3	0.9
07/17/2023 02:00	3,828.2	0.0	3,828.2	105,900.0	405.4	0.5	0.2	0.8
07/17/2023 03:00	3,645.1	0.0	3,645.1	105,900.0	386.0	0.5	0.2	0.8
07/17/2023 04:00	3,696.4	0.0	3,696.4	105,900.0	391.4	0.5	0.2	0.8
07/17/2023 05:00	4,276.4	0.0	4,276.4	105,900.0	452.9	0.5	0.3	0.9
07/17/2023 06:00	4,450.6	0.0	4,450.6	105,900.0	471.3	0.6	0.3	0.9
07/17/2023 07:00	3,713.4	0.0	3,713.4	105,900.0	393.2	0.5	0.2	0.8
07/17/2023 08:00	3,630.3	0.0	3,630.3	105,900.0	384.4	0.5	0.2	0.8
07/17/2023 09:00	3,619.1	0.0	3,619.1	105,900.0	383.3	0.5	0.2	0.8
07/17/2023 10:00	4,107.0	0.0	4,107.0	105,900.0	434.9	0.5	0.3	0.9
07/17/2023 11:00	4,297.0	0.0	4,297.0	105,900.0	455.1	0.5	0.3	0.9
07/17/2023 12:00	4,228.3	0.0	4,228.3	105,900.0	447.8	0.5	0.3	0.9
07/17/2023 13:00	4,450.9	0.0	4,450.9	105,900.0	471.4	0.6	0.3	0.9
07/17/2023 14:00	4,429.9	0.0	4,429.9	105,900.0	469.1	0.6	0.3	0.9
07/17/2023 15:00	4,418.4	549.8	4,682.3	105,900.0	495.9	0.6	0.3	1.1
07/17/2023 16:00	4,400.4	1,796.7	6,197.1	105,900.0	656.3	0.8	0.4	1.3
07/17/2023 17:00	4,440.1	904.8	5,344.9	105,900.0	566.0	0.7	0.3	1.1
07/17/2023 18:00	4,396.0	0.0	4,396.0	105,900.0	465.5	0.6	0.3	0.9
07/17/2023 19:00	4,341.0	0.0	4,341.0	105,900.0	459.7	0.6	0.3	0.9
07/17/2023 20:00	4,421.2	0.0	4,421.2	105,900.0	468.2	0.6	0.3	0.9
07/17/2023 21:00	4,473.5	0.0	4,473.5	105,900.0	473.7	0.6	0.3	0.9
07/17/2023 22:00	4,422.2	0.0	4,422.2	105,900.0	468.3	0.6	0.3	0.9
07/17/2023 23:00	4,397.1	0.0	4,397.1	105,900.0	465.7	0.6	0.3	0.9
Average/Sum#:	4,199.4	135.5	4,322.9	105,900.0	457.8	0.6	0.3	0.9
Minimum:	3,619.1	0.0	3,619.1	105,900.0	383.3	0.5	0.2	0.8
Maximum:	4,473.5	1,796.7	6,197.1	105,900.0	656.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2023 00:00	4,634.1	0.0	4,634.1	105,900.0	490.8	0.6	0.3	1.0
07/18/2023 01:00	4,646.2	0.0	4,646.2	105,900.0	492.0	0.6	0.3	1.0
07/18/2023 02:00	4,553.4	0.0	4,553.4	105,900.0	482.2	0.6	0.3	1.0
07/18/2023 03:00	4,454.0	0.0	4,454.0	105,900.0	471.7	0.6	0.3	0.9
07/18/2023 04:00	4,676.7	0.0	4,676.7	105,900.0	495.3	0.6	0.3	1.0
07/18/2023 05:00	4,710.8	0.0	4,710.8	105,900.0	498.9	0.6	0.3	1.0
07/18/2023 06:00	4,704.3	0.0	4,704.3	105,900.0	498.2	0.6	0.3	1.0
07/18/2023 07:00	3,984.7	0.0	3,984.7	105,900.0	422.0	0.5	0.3	0.8
07/18/2023 08:00	3,703.0	0.0	3,703.0	105,900.0	392.1	0.5	0.2	0.8
07/18/2023 09:00	3,950.6	0.0	3,950.6	105,900.0	418.4	0.5	0.3	0.8
07/18/2023 10:00	4,397.0	2.2	4,397.1	105,900.0	465.7	0.6	0.3	0.9
07/18/2023 11:00	4,552.2	0.0	4,552.2	105,900.0	482.1	0.6	0.3	1.0
07/18/2023 12:00	4,569.7	0.0	4,569.7	105,900.0	483.9	0.6	0.3	1.0
07/18/2023 13:00	4,543.4	0.0	4,543.4	105,900.0	481.1	0.6	0.3	1.0
07/18/2023 14:00	4,533.2	87.9	4,561.3	105,900.0	483.0	0.6	0.3	1.0
07/18/2023 15:00	4,513.3	1,117.0	5,630.3	105,900.0	596.2	0.7	0.4	1.2
07/18/2023 16:00	4,516.1	940.7	5,456.8	105,900.0	577.9	0.7	0.3	1.2
07/18/2023 17:00	4,519.5	650.3	5,169.8	105,900.0	547.5	0.7	0.3	1.1
07/18/2023 18:00	4,527.4	1,126.7	5,654.1	105,900.0	598.8	0.7	0.4	1.2
07/18/2023 19:00	4,559.4	1,864.9	6,424.3	105,900.0	680.3	0.8	0.4	1.4
07/18/2023 20:00	4,586.8	1,477.5	6,064.3	105,900.0	642.2	0.8	0.4	1.3
07/18/2023 21:00	4,624.9	1,368.9	5,993.8	105,900.0	634.7	0.8	0.4	1.3
07/18/2023 22:00	4,652.2	1,063.6	5,715.8	105,900.0	605.3	0.7	0.4	1.2
07/18/2023 23:00	4,679.8	789.9	5,469.7	105,900.0	579.2	0.7	0.3	1.2
Average/Sum#:	4,491.4	437.1	4,925.9	105,900.0	521.6	0.6	0.3	1.1
Minimum:	3,703.0	0.0	3,703.0	105,900.0	392.1	0.5	0.2	0.8
Maximum:	4,710.8	1,864.9	6,424.3	105,900.0	680.3	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2023 00:00	4,625.1	36.2	4,638.9	105,900.0	491.3	0.6	0.3	1.0
07/19/2023 01:00	4,543.4	0.0	4,543.4	105,900.0	481.1	0.6	0.3	1.0
07/19/2023 02:00	4,422.8	0.0	4,422.8	105,900.0	468.4	0.6	0.3	0.9
07/19/2023 03:00	4,287.4	0.0	4,287.4	105,900.0	454.0	0.5	0.3	0.9
07/19/2023 04:00	4,452.1	0.0	4,452.1	105,900.0	471.5	0.6	0.3	0.9
07/19/2023 05:00	4,598.1	0.0	4,598.1	105,900.0	486.9	0.6	0.3	1.0
07/19/2023 06:00	4,608.1	0.0	4,608.1	105,900.0	488.0	0.6	0.3	1.0
07/19/2023 07:00	4,165.7	0.0	4,165.7	105,900.0	441.1	0.5	0.3	0.9
07/19/2023 08:00	3,814.2	0.0	3,814.2	105,900.0	403.9	0.5	0.2	0.8
07/19/2023 09:00	4,063.6	0.0	4,063.6	105,900.0	430.3	0.5	0.3	0.9
07/19/2023 10:00	3,933.8	0.0	3,933.8	105,900.0	416.6	0.5	0.2	0.8
07/19/2023 11:00	4,366.6	0.0	4,366.6	105,900.0	462.4	0.6	0.3	0.9
07/19/2023 12:00	4,545.1	0.0	4,545.1	105,900.0	481.3	0.6	0.3	1.0
07/19/2023 13:00	4,556.0	405.4	4,750.6	105,900.0	503.1	0.6	0.3	1.1
07/19/2023 14:00	4,532.9	1,595.1	6,128.0	105,900.0	649.0	0.8	0.4	1.3
07/19/2023 15:00	4,512.2	1,742.4	6,254.6	105,900.0	662.4	0.8	0.4	1.3
07/19/2023 16:00	4,498.9	1,717.7	6,216.6	105,900.0	658.3	0.8	0.4	1.3
07/19/2023 17:00	4,503.0	1,626.4	6,129.4	105,900.0	649.1	0.8	0.4	1.3
07/19/2023 18:00	4,519.4	1,739.9	6,259.3	105,900.0	662.9	0.8	0.4	1.3
07/19/2023 19:00	4,542.1	1,881.5	6,423.6	105,900.0	680.3	0.8	0.4	1.4
07/19/2023 20:00	4,585.9	1,851.1	6,437.0	105,900.0	681.7	0.8	0.4	1.4
07/19/2023 21:00	4,616.5	1,649.7	6,266.2	105,900.0	663.6	0.8	0.4	1.3
07/19/2023 22:00	4,635.0	1,461.3	6,096.3	105,900.0	645.6	0.8	0.4	1.3
07/19/2023 23:00	4,660.1	937.5	5,597.6	105,900.0	592.8	0.7	0.4	1.2
Average/Sum#:	4,441.2	693.5	5,125.0	105,900.0	542.7	0.7	0.3	1.1
Minimum:	3,814.2	0.0	3,814.2	105,900.0	403.9	0.5	0.2	0.8
Maximum:	4,660.1	1,881.5	6,437.0	105,900.0	681.7	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2023 00:00	4,597.0	66.5	4,631.6	105,900.0	490.5	0.6	0.3	1.0
07/20/2023 01:00	4,464.8	0.0	4,464.8	105,900.0	472.8	0.6	0.3	0.9
07/20/2023 02:00	4,504.5	0.0	4,504.5	105,900.0	477.0	0.6	0.3	1.0
07/20/2023 03:00	4,446.6	0.0	4,446.6	105,900.0	470.9	0.6	0.3	0.9
07/20/2023 04:00	4,581.8	0.0	4,581.8	105,900.0	485.2	0.6	0.3	1.0
07/20/2023 05:00	4,612.8	0.0	4,612.8	105,900.0	488.5	0.6	0.3	1.0
07/20/2023 06:00	4,545.8	0.0	4,545.8	105,900.0	481.4	0.6	0.3	1.0
07/20/2023 07:00	3,797.4	0.0	3,797.4	105,900.0	402.1	0.5	0.2	0.8
07/20/2023 08:00	3,656.8	0.0	3,656.8	105,900.0	387.3	0.5	0.2	0.8
07/20/2023 09:00	3,715.9	0.0	3,715.9	105,900.0	393.5	0.5	0.2	0.8
07/20/2023 10:00	3,977.0	0.0	3,977.0	105,900.0	421.2	0.5	0.3	0.8
07/20/2023 11:00	4,279.6	0.0	4,279.6	105,900.0	453.2	0.5	0.3	0.9
07/20/2023 12:00	4,545.9	0.0	4,545.9	105,900.0	481.4	0.6	0.3	1.0
07/20/2023 13:00	4,530.3	0.0	4,530.3	105,900.0	479.8	0.6	0.3	1.0
07/20/2023 14:00	4,502.1	0.0	4,502.1	105,900.0	476.8	0.6	0.3	1.0
07/20/2023 15:00	4,499.6	1,119.6	5,395.3	105,900.0	571.4	0.7	0.4	1.2
07/20/2023 16:00	4,510.4	1,609.9	6,120.3	105,900.0	648.1	0.8	0.4	1.3
07/20/2023 17:00	4,508.7	1,587.9	6,096.6	105,900.0	645.6	0.8	0.4	1.3
07/20/2023 18:00	4,490.2	1,789.4	6,279.6	105,900.0	665.0	0.8	0.4	1.3
07/20/2023 19:00	4,488.9	1,947.7	6,436.6	105,900.0	681.6	0.8	0.4	1.4
07/20/2023 20:00	4,506.4	1,595.2	6,101.6	105,900.0	646.2	0.8	0.4	1.3
07/20/2023 21:00	4,544.3	1,329.6	5,873.9	105,900.0	622.0	0.7	0.4	1.2
07/20/2023 22:00	4,554.5	963.6	5,518.1	105,900.0	584.4	0.7	0.4	1.2
07/20/2023 23:00	4,426.8	414.6	4,683.9	105,900.0	496.0	0.6	0.3	1.0
Average/Sum#:	4,387.0	517.7	4,887.5	105,900.0	517.6	0.6	0.3	1.0
Minimum:	3,656.8	0.0	3,656.8	105,900.0	387.3	0.5	0.2	0.8
Maximum:	4,612.8	1,947.7	6,436.6	105,900.0	681.6	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2023 00:00	4,493.4	0.0	4,493.4	105,900.0	475.9	0.6	0.3	1.0
07/21/2023 01:00	4,491.1	0.0	4,491.1	105,900.0	475.6	0.6	0.3	1.0
07/21/2023 02:00	4,286.2	0.0	4,286.2	105,900.0	453.9	0.5	0.3	0.9
07/21/2023 03:00	4,185.9	0.0	4,185.9	105,900.0	443.3	0.5	0.3	0.9
07/21/2023 04:00	4,275.3	0.0	4,275.3	105,900.0	452.8	0.5	0.3	0.9
07/21/2023 05:00	4,247.3	0.0	4,247.3	105,900.0	449.8	0.5	0.3	0.9
07/21/2023 06:00	4,254.1	0.0	4,254.1	105,900.0	450.5	0.5	0.3	0.9
07/21/2023 07:00	3,736.2	0.0	3,736.2	105,900.0	395.7	0.5	0.2	0.8
07/21/2023 08:00	3,646.3	0.0	3,646.3	105,900.0	386.1	0.5	0.2	0.8
07/21/2023 09:00	3,643.2	0.0	3,643.2	105,900.0	385.8	0.5	0.2	0.8
07/21/2023 10:00	3,634.4	0.0	3,634.4	105,900.0	384.9	0.5	0.2	0.8
07/21/2023 11:00	4,033.8	16.0	4,035.1	105,900.0	427.3	0.5	0.3	0.9
07/21/2023 12:00	3,981.2	0.0	3,981.2	105,900.0	421.6	0.5	0.3	0.8
07/21/2023 13:00	4,369.8	0.0	4,369.8	105,900.0	462.8	0.6	0.3	0.9
07/21/2023 14:00	4,463.8	494.7	4,701.3	105,900.0	497.9	0.6	0.3	1.0
07/21/2023 15:00	4,457.7	1,389.1	5,846.8	105,900.0	619.2	0.7	0.4	1.2
07/21/2023 16:00	4,451.0	1,081.8	5,532.8	105,900.0	585.9	0.7	0.4	1.2
07/21/2023 17:00	4,428.5	807.3	5,235.8	105,900.0	554.5	0.7	0.3	1.1
07/21/2023 18:00	4,410.0	1,093.8	5,503.8	105,900.0	582.9	0.7	0.3	1.2
07/21/2023 19:00	4,397.4	1,869.7	6,267.1	105,900.0	663.7	0.8	0.4	1.3
07/21/2023 20:00	4,451.3	1,280.2	5,731.5	105,900.0	607.0	0.7	0.4	1.2
07/21/2023 21:00	4,479.9	730.2	5,210.1	105,900.0	551.7	0.7	0.3	1.1
07/21/2023 22:00	4,507.6	849.5	5,357.1	105,900.0	567.3	0.7	0.3	1.1
07/21/2023 23:00	4,532.6	687.9	5,220.5	105,900.0	552.9	0.7	0.3	1.1
Average/Sum#:	4,244.1	429.2	4,661.9	105,900.0	493.7	0.6	0.3	1.0
Minimum:	3,634.4	0.0	3,634.4	105,900.0	384.9	0.5	0.2	0.8
Maximum:	4,532.6	1,869.7	6,267.1	105,900.0	663.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2023 00:00	4,460.6	6.3	4,460.8	105,900.0	472.4	0.6	0.3	0.9
07/22/2023 01:00	4,279.6	0.0	4,279.6	105,900.0	453.2	0.5	0.3	0.9
07/22/2023 02:00	3,818.8	0.0	3,818.8	105,900.0	404.4	0.5	0.2	0.8
07/22/2023 03:00	3,841.0	0.0	3,841.0	105,900.0	406.8	0.5	0.2	0.8
07/22/2023 04:00	3,663.0	0.0	3,663.0	105,900.0	387.9	0.5	0.2	0.8
07/22/2023 05:00	3,857.0	0.0	3,857.0	105,900.0	408.5	0.5	0.2	0.8
07/22/2023 06:00	3,856.8	0.0	3,856.8	105,900.0	408.4	0.5	0.2	0.8
07/22/2023 07:00	3,632.8	0.0	3,632.8	105,900.0	384.7	0.5	0.2	0.8
07/22/2023 08:00	3,627.2	0.0	3,627.2	105,900.0	384.1	0.5	0.2	0.8
07/22/2023 09:00	3,623.4	0.0	3,623.4	105,900.0	383.7	0.5	0.2	0.8
07/22/2023 10:00	3,613.6	0.0	3,613.6	105,900.0	382.7	0.5	0.2	0.8
07/22/2023 11:00	3,661.9	0.0	3,661.9	105,900.0	387.8	0.5	0.2	0.8
07/22/2023 12:00	3,917.2	0.0	3,917.2	105,900.0	414.8	0.5	0.2	0.8
07/22/2023 13:00	3,973.9	0.0	3,973.9	105,900.0	420.8	0.5	0.3	0.8
07/22/2023 14:00	4,416.9	0.0	4,416.9	105,900.0	467.7	0.6	0.3	0.9
07/22/2023 15:00	4,369.5	0.0	4,369.5	105,900.0	462.7	0.6	0.3	0.9
07/22/2023 16:00	4,414.5	0.0	4,414.5	105,900.0	467.5	0.6	0.3	0.9
07/22/2023 17:00	4,395.7	957.0	5,180.4	105,900.0	548.6	0.7	0.3	1.1
07/22/2023 18:00	4,382.1	1,583.0	5,965.1	105,900.0	631.7	0.8	0.4	1.3
07/22/2023 19:00	4,399.6	1,854.1	6,253.7	105,900.0	662.3	0.8	0.4	1.3
07/22/2023 20:00	4,444.9	1,069.4	5,514.3	105,900.0	584.0	0.7	0.4	1.2
07/22/2023 21:00	4,471.9	1,013.2	5,485.1	105,900.0	580.9	0.7	0.3	1.2
07/22/2023 22:00	4,496.3	893.0	5,389.3	105,900.0	570.7	0.7	0.3	1.1
07/22/2023 23:00	4,435.6	169.7	4,532.3	105,900.0	480.0	0.6	0.3	1.0
Average/Sum#:	4,085.6	314.4	4,389.5	105,900.0	464.8	0.6	0.3	0.9
Minimum:	3,613.6	0.0	3,613.6	105,900.0	382.7	0.5	0.2	0.8
Maximum:	4,496.3	1,854.1	6,253.7	105,900.0	662.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2023 00:00	4,491.2	3.5	4,491.3	105,900.0	475.6	0.6	0.3	1.0
07/23/2023 01:00	4,491.3	0.0	4,491.3	105,900.0	475.6	0.6	0.3	1.0
07/23/2023 02:00	4,486.0	0.0	4,486.0	105,900.0	475.1	0.6	0.3	1.0
07/23/2023 03:00	4,495.9	0.0	4,495.9	105,900.0	476.1	0.6	0.3	1.0
07/23/2023 04:00	4,480.8	0.0	4,480.8	105,900.0	474.5	0.6	0.3	0.9
07/23/2023 05:00	4,291.6	0.0	4,291.6	105,900.0	454.5	0.5	0.3	0.9
07/23/2023 06:00	4,117.9	0.0	4,117.9	105,900.0	436.1	0.5	0.3	0.9
07/23/2023 07:00	3,682.1	0.0	3,682.1	105,900.0	389.9	0.5	0.2	0.8
07/23/2023 08:00	4,125.7	0.0	4,125.7	105,900.0	436.9	0.5	0.3	0.9
07/23/2023 09:00	4,513.7	0.0	4,513.7	105,900.0	478.0	0.6	0.3	1.0
07/23/2023 10:00	4,508.2	0.0	4,508.2	105,900.0	477.4	0.6	0.3	1.0
07/23/2023 11:00	4,499.3	0.0	4,499.3	105,900.0	476.5	0.6	0.3	1.0
07/23/2023 12:00	4,505.7	479.8	4,736.0	105,900.0	501.5	0.6	0.3	1.1
07/23/2023 13:00	4,479.6	812.9	5,292.5	105,900.0	560.5	0.7	0.3	1.1
07/23/2023 14:00	4,458.1	382.7	4,660.9	105,900.0	493.6	0.6	0.3	1.0
07/23/2023 15:00	4,428.4	0.0	4,428.4	105,900.0	469.0	0.6	0.3	0.9
07/23/2023 16:00	4,445.7	239.0	4,524.6	105,900.0	479.2	0.6	0.3	1.0
07/23/2023 17:00	4,453.4	1,835.0	6,288.4	105,900.0	665.9	0.8	0.4	1.3
07/23/2023 18:00	4,276.5	994.8	5,271.3	105,900.0	558.2	0.7	0.3	1.1
07/23/2023 19:00	4,319.0	1.3	4,319.0	105,900.0	457.4	0.5	0.3	0.9
07/23/2023 20:00	4,228.2	0.0	4,228.2	105,900.0	447.8	0.5	0.3	0.9
07/23/2023 21:00	4,341.8	0.0	4,341.8	105,900.0	459.8	0.6	0.3	0.9
07/23/2023 22:00	4,260.3	0.0	4,260.3	105,900.0	451.2	0.5	0.3	0.9
07/23/2023 23:00	4,080.1	0.0	4,080.1	105,900.0	432.1	0.5	0.3	0.9
Average/Sum#:	4,352.5	197.9	4,525.6	105,900.0	479.3	0.6	0.3	1.0
Minimum:	3,682.1	0.0	3,682.1	105,900.0	389.9	0.5	0.2	0.8
Maximum:	4,513.7	1,835.0	6,288.4	105,900.0	665.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2023 00:00	4,562.7	0.0	4,562.7	105,900.0	483.2	0.6	0.3	1.0
07/24/2023 01:00	4,482.6	0.0	4,482.6	105,900.0	474.7	0.6	0.3	0.9
07/24/2023 02:00	4,286.0	0.0	4,286.0	105,900.0	453.9	0.5	0.3	0.9
07/24/2023 03:00	4,351.6	0.0	4,351.6	105,900.0	460.8	0.6	0.3	0.9
07/24/2023 04:00	4,497.7	0.0	4,497.7	105,900.0	476.3	0.6	0.3	1.0
07/24/2023 05:00	4,498.6	0.0	4,498.6	105,900.0	476.4	0.6	0.3	1.0
07/24/2023 06:00	4,543.5	0.0	4,543.5	105,900.0	481.2	0.6	0.3	1.0
07/24/2023 07:00	3,948.7	0.0	3,948.7	105,900.0	418.2	0.5	0.3	0.8
07/24/2023 08:00	3,736.5	0.0	3,736.5	105,900.0	395.7	0.5	0.2	0.8
07/24/2023 09:00	3,650.1	0.0	3,650.1	105,900.0	386.5	0.5	0.2	0.8
07/24/2023 10:00	3,685.0	0.0	3,685.0	105,900.0	390.2	0.5	0.2	0.8
07/24/2023 11:00	3,691.0	0.0	3,691.0	105,900.0	390.9	0.5	0.2	0.8
07/24/2023 12:00	4,003.2	0.0	4,003.2	105,900.0	423.9	0.5	0.3	0.8
07/24/2023 13:00	4,538.6	0.0	4,538.6	105,900.0	480.6	0.6	0.3	1.0
07/24/2023 14:00	3,670.1	0.0	3,670.1	105,900.0	388.7	0.5	0.2	0.8
07/24/2023 15:00	3,626.1	0.0	3,626.1	105,900.0	384.0	0.5	0.2	0.8
07/24/2023 16:00	3,614.8	0.0	3,614.8	105,900.0	382.8	0.5	0.2	0.8
07/24/2023 17:00	3,614.5	0.0	3,614.5	105,900.0	382.8	0.5	0.2	0.8
07/24/2023 18:00	3,626.4	0.0	3,626.4	105,900.0	384.0	0.5	0.2	0.8
07/24/2023 19:00	3,710.1	0.0	3,710.1	105,900.0	392.9	0.5	0.2	0.8
07/24/2023 20:00	3,689.0	0.0	3,689.0	105,900.0	390.7	0.5	0.2	0.8
07/24/2023 21:00	4,118.8	0.0	4,118.8	105,900.0	436.2	0.5	0.3	0.9
07/24/2023 22:00	4,092.6	0.0	4,092.6	105,900.0	433.4	0.5	0.3	0.9
07/24/2023 23:00	4,250.6	0.0	4,250.6	105,900.0	450.1	0.5	0.3	0.9
Average/Sum#:	4,020.4	0.0	4,020.4	105,900.0	425.8	0.5	0.3	0.9
Minimum:	3,614.5	0.0	3,614.5	105,900.0	382.8	0.5	0.2	0.8
Maximum:	4,562.7	0.0	4,562.7	105,900.0	483.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2023 00:00	4,004.1	0.0	4,004.1	105,900.0	424.0	0.5	0.3	0.8
07/25/2023 01:00	3,677.7	0.0	3,677.7	105,900.0	389.5	0.5	0.2	0.8
07/25/2023 02:00	3,648.8	0.0	3,648.8	105,900.0	386.4	0.5	0.2	0.8
07/25/2023 03:00	3,650.0	0.0	3,650.0	105,900.0	386.5	0.5	0.2	0.8
07/25/2023 04:00	3,654.7	0.0	3,654.7	105,900.0	387.0	0.5	0.2	0.8
07/25/2023 05:00	3,934.0	0.0	3,934.0	105,900.0	416.6	0.5	0.2	0.8
07/25/2023 06:00	4,007.2	0.0	4,007.2	105,900.0	424.4	0.5	0.3	0.8
07/25/2023 07:00	3,718.9	0.0	3,718.9	105,900.0	393.8	0.5	0.2	0.8
07/25/2023 08:00	3,860.1	0.0	3,860.1	105,900.0	408.8	0.5	0.2	0.8
07/25/2023 09:00	3,659.3	0.0	3,659.3	105,900.0	387.5	0.5	0.2	0.8
07/25/2023 10:00	3,721.2	0.0	3,721.2	105,900.0	394.1	0.5	0.2	0.8
07/25/2023 11:00	3,654.0	0.0	3,654.0	105,900.0	387.0	0.5	0.2	0.8
07/25/2023 12:00	4,203.4	0.0	4,203.4	105,900.0	445.1	0.5	0.3	0.9
07/25/2023 13:00	4,256.3	0.0	4,256.3	105,900.0	450.7	0.5	0.3	0.9
07/25/2023 14:00	4,474.8	0.0	4,474.8	105,900.0	473.9	0.6	0.3	0.9
07/25/2023 15:00	4,266.2	0.0	4,266.2	105,900.0	451.8	0.5	0.3	0.9
07/25/2023 16:00	4,509.3	296.2	4,651.5	105,900.0	492.6	0.6	0.3	1.0
07/25/2023 17:00	4,540.0	868.7	5,408.7	105,900.0	572.8	0.7	0.3	1.1
07/25/2023 18:00	4,543.2	972.0	5,515.2	105,900.0	584.1	0.7	0.4	1.2
07/25/2023 19:00	4,550.2	1,826.2	6,376.4	105,900.0	675.3	0.8	0.4	1.4
07/25/2023 20:00	4,574.4	1,401.7	5,976.1	105,900.0	632.9	0.8	0.4	1.3
07/25/2023 21:00	4,602.7	786.9	5,389.6	105,900.0	570.8	0.7	0.3	1.1
07/25/2023 22:00	4,611.5	642.4	5,253.9	105,900.0	556.4	0.7	0.3	1.1
07/25/2023 23:00	4,455.0	2.7	4,455.1	105,900.0	471.8	0.6	0.3	0.9
Average/Sum#:	4,115.7	283.2	4,392.4	105,900.0	465.2	0.6	0.3	0.9
Minimum:	3,648.8	0.0	3,648.8	105,900.0	386.4	0.5	0.2	0.8
Maximum:	4,611.5	1,826.2	6,376.4	105,900.0	675.3	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2023 00:00	4,624.7	0.0	4,624.7	105,900.0	489.8	0.6	0.3	1.0
07/26/2023 01:00	4,313.8	0.0	4,313.8	105,900.0	456.8	0.5	0.3	0.9
07/26/2023 02:00	4,355.7	0.0	4,355.7	105,900.0	461.3	0.6	0.3	0.9
07/26/2023 03:00	4,399.9	0.0	4,399.9	105,900.0	465.9	0.6	0.3	0.9
07/26/2023 04:00	4,397.6	0.0	4,397.6	105,900.0	465.7	0.6	0.3	0.9
07/26/2023 05:00	4,598.0	0.0	4,598.0	105,900.0	486.9	0.6	0.3	1.0
07/26/2023 06:00	4,538.9	0.0	4,538.9	105,900.0	480.7	0.6	0.3	1.0
07/26/2023 07:00	4,212.7	0.0	4,212.7	105,900.0	446.1	0.5	0.3	0.9
07/26/2023 08:00	4,163.5	0.0	4,163.5	105,900.0	440.9	0.5	0.3	0.9
07/26/2023 09:00	4,437.1	0.0	4,437.1	105,900.0	469.9	0.6	0.3	0.9
07/26/2023 10:00	4,517.5	0.0	4,517.5	105,900.0	478.4	0.6	0.3	1.0
07/26/2023 11:00	4,592.2	0.0	4,592.2	105,900.0	486.3	0.6	0.3	1.0
07/26/2023 12:00	4,503.8	131.9	4,534.1	105,900.0	480.2	0.6	0.3	1.0
07/26/2023 13:00	4,555.3	1,695.3	6,250.6	105,900.0	661.9	0.8	0.4	1.3
07/26/2023 14:00	4,540.8	1,725.0	6,265.8	105,900.0	663.5	0.8	0.4	1.3
07/26/2023 15:00	4,536.8	1,536.2	6,073.0	105,900.0	643.1	0.8	0.4	1.3
07/26/2023 16:00	4,534.6	1,619.1	6,153.7	105,900.0	651.7	0.8	0.4	1.3
07/26/2023 17:00	4,547.2	1,614.2	6,161.4	105,900.0	652.5	0.8	0.4	1.3
07/26/2023 18:00	4,553.8	1,002.9	5,556.7	105,900.0	588.5	0.7	0.4	1.2
07/26/2023 19:00	4,567.2	1,501.7	6,068.9	105,900.0	642.7	0.8	0.4	1.3
07/26/2023 20:00	4,588.2	603.2	5,191.4	105,900.0	549.8	0.7	0.3	1.1
07/26/2023 21:00	4,625.5	785.9	5,411.4	105,900.0	573.1	0.7	0.3	1.1
07/26/2023 22:00	4,653.8	1,358.7	6,012.5	105,900.0	636.7	0.8	0.4	1.3
07/26/2023 23:00	4,676.6	881.8	5,558.4	105,900.0	588.6	0.7	0.4	1.2
Average/Sum#:	4,501.5	602.3	5,099.6	105,900.0	540.0	0.7	0.3	1.1
Minimum:	4,163.5	0.0	4,163.5	105,900.0	440.9	0.5	0.3	0.9
Maximum:	4,676.6	1,725.0	6,265.8	105,900.0	663.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2023 00:00	4,693.2	1,549.6	6,242.8	105,900.0	661.1	0.8	0.4	1.3
07/27/2023 01:00	4,611.7	321.4	4,778.8	105,900.0	506.1	0.6	0.3	1.0
07/27/2023 02:00	4,282.6	0.0	4,282.6	105,900.0	453.5	0.5	0.3	0.9
07/27/2023 03:00	3,941.2	0.0	3,941.2	105,900.0	417.4	0.5	0.3	0.8
07/27/2023 04:00	4,601.0	0.0	4,601.0	105,900.0	487.2	0.6	0.3	1.0
07/27/2023 05:00	4,686.0	0.0	4,686.0	105,900.0	496.2	0.6	0.3	1.0
07/27/2023 06:00	4,644.7	0.0	4,644.7	105,900.0	491.9	0.6	0.3	1.0
07/27/2023 07:00	3,788.3	0.0	3,788.3	105,900.0	401.2	0.5	0.2	0.8
07/27/2023 08:00	3,644.8	0.0	3,644.8	105,900.0	386.0	0.5	0.2	0.8
07/27/2023 09:00	3,642.2	0.0	3,642.2	105,900.0	385.7	0.5	0.2	0.8
07/27/2023 10:00	3,637.9	0.0	3,637.9	105,900.0	385.3	0.5	0.2	0.8
07/27/2023 11:00	3,753.9	0.0	3,753.9	105,900.0	397.5	0.5	0.2	0.8
07/27/2023 12:00	4,418.2	0.0	4,418.2	105,900.0	467.9	0.6	0.3	0.9
07/27/2023 13:00	4,477.0	0.0	4,477.0	105,900.0	474.1	0.6	0.3	0.9
07/27/2023 14:00	4,328.8	0.0	4,328.8	105,900.0	458.4	0.6	0.3	0.9
07/27/2023 15:00	4,253.2	0.0	4,253.2	105,900.0	450.4	0.5	0.3	0.9
07/27/2023 16:00	4,556.0	468.6	4,921.5	105,900.0	521.2	0.6	0.3	1.1
07/27/2023 17:00	4,583.3	589.2	5,172.5	105,900.0	547.8	0.7	0.3	1.1
07/27/2023 18:00	3,825.0	4.1	3,825.1	105,900.0	405.1	0.5	0.2	0.8
07/27/2023 19:00	3,647.2	0.0	3,647.2	105,900.0	386.2	0.5	0.2	0.8
07/27/2023 20:00	3,701.0	0.0	3,701.0	105,900.0	391.9	0.5	0.2	0.8
07/27/2023 21:00	3,636.3	0.0	3,636.3	105,900.0	385.1	0.5	0.2	0.8
07/27/2023 22:00	4,185.6	0.0	4,185.6	105,900.0	443.3	0.5	0.3	0.9
07/27/2023 23:00	4,425.5	0.0	4,425.5	105,900.0	468.7	0.6	0.3	0.9
Average/Sum#:	4,165.2	122.2	4,276.5	105,900.0	452.9	0.6	0.3	0.9
Minimum:	3,636.3	0.0	3,636.3	105,900.0	385.1	0.5	0.2	0.8
Maximum:	4,693.2	1,549.6	6,242.8	105,900.0	661.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2023 00:00	4,147.6	0.0	4,147.6	105,900.0	439.2	0.5	0.3	0.9
07/28/2023 01:00	4,347.5	0.0	4,347.5	105,900.0	460.4	0.6	0.3	0.9
07/28/2023 02:00	4,181.5	0.0	4,181.5	105,900.0	442.8	0.5	0.3	0.9
07/28/2023 03:00	4,114.9	0.0	4,114.9	105,900.0	435.8	0.5	0.3	0.9
07/28/2023 04:00	4,066.2	0.0	4,066.2	105,900.0	430.6	0.5	0.3	0.9
07/28/2023 05:00	4,268.3	0.0	4,268.3	105,900.0	452.0	0.5	0.3	0.9
07/28/2023 06:00	4,196.1	0.0	4,196.1	105,900.0	444.4	0.5	0.3	0.9
07/28/2023 07:00	3,811.5	0.0	3,811.5	105,900.0	403.6	0.5	0.2	0.8
07/28/2023 08:00	3,650.9	0.0	3,650.9	105,900.0	386.6	0.5	0.2	0.8
07/28/2023 09:00	3,648.3	0.0	3,648.3	105,900.0	386.4	0.5	0.2	0.8
07/28/2023 10:00	3,641.6	0.0	3,641.6	105,900.0	385.6	0.5	0.2	0.8
07/28/2023 11:00	3,639.4	0.0	3,639.4	105,900.0	385.4	0.5	0.2	0.8
07/28/2023 12:00	3,667.8	0.0	3,667.8	105,900.0	388.4	0.5	0.2	0.8
07/28/2023 13:00	4,339.2	0.0	4,339.2	105,900.0	459.5	0.6	0.3	0.9
07/28/2023 14:00	3,646.8	0.0	3,646.8	105,900.0	386.2	0.5	0.2	0.8
07/28/2023 15:00	4,121.4	155.5	4,164.9	105,900.0	441.1	0.5	0.3	0.9
07/28/2023 16:00	4,559.0	582.3	5,141.3	105,900.0	544.5	0.7	0.3	1.1
07/28/2023 17:00	4,565.0	568.0	5,133.0	105,900.0	543.6	0.7	0.3	1.1
07/28/2023 18:00	4,566.8	561.9	5,128.7	105,900.0	543.1	0.7	0.3	1.1
07/28/2023 19:00	4,588.0	518.3	5,106.3	105,900.0	540.8	0.6	0.3	1.1
07/28/2023 20:00	3,792.5	2.9	3,792.6	105,900.0	401.6	0.5	0.2	0.8
07/28/2023 21:00	3,834.2	0.0	3,834.2	105,900.0	406.0	0.5	0.2	0.8
07/28/2023 22:00	4,164.1	0.0	4,164.1	105,900.0	441.0	0.5	0.3	0.9
07/28/2023 23:00	4,398.0	0.0	4,398.0	105,900.0	465.7	0.6	0.3	0.9
Average/Sum#:	4,081.5	99.5	4,176.3	105,900.0	442.3	0.5	0.3	0.9
Minimum:	3,639.4	0.0	3,639.4	105,900.0	385.4	0.5	0.2	0.8
Maximum:	4,588.0	582.3	5,141.3	105,900.0	544.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2023 00:00	4,403.7	0.0	4,403.7	105,900.0	466.4	0.6	0.3	0.9
07/29/2023 01:00	3,758.4	0.0	3,758.4	105,900.0	398.0	0.5	0.2	0.8
07/29/2023 02:00	3,753.4	0.0	3,753.4	105,900.0	397.5	0.5	0.2	0.8
07/29/2023 03:00	3,764.9	0.0	3,764.9	105,900.0	398.7	0.5	0.2	0.8
07/29/2023 04:00	3,655.9	0.0	3,655.9	105,900.0	387.2	0.5	0.2	0.8
07/29/2023 05:00	3,672.1	0.0	3,672.1	105,900.0	388.9	0.5	0.2	0.8
07/29/2023 06:00	3,729.9	0.0	3,729.9	105,900.0	395.0	0.5	0.2	0.8
07/29/2023 07:00	3,652.2	0.0	3,652.2	105,900.0	386.8	0.5	0.2	0.8
07/29/2023 08:00	3,648.0	0.0	3,648.0	105,900.0	386.3	0.5	0.2	0.8
07/29/2023 09:00	3,641.5	0.0	3,641.5	105,900.0	385.6	0.5	0.2	0.8
07/29/2023 10:00	3,635.4	0.0	3,635.4	105,900.0	385.0	0.5	0.2	0.8
07/29/2023 11:00	3,627.8	0.0	3,627.8	105,900.0	384.2	0.5	0.2	0.8
07/29/2023 12:00	3,621.5	0.0	3,621.5	105,900.0	383.5	0.5	0.2	0.8
07/29/2023 13:00	3,617.4	0.0	3,617.4	105,900.0	383.1	0.5	0.2	0.8
07/29/2023 14:00	3,610.5	0.0	3,610.5	105,900.0	382.4	0.5	0.2	0.8
07/29/2023 15:00	3,605.7	0.0	3,605.7	105,900.0	381.8	0.5	0.2	0.8
07/29/2023 16:00	3,641.5	0.0	3,641.5	105,900.0	385.6	0.5	0.2	0.8
07/29/2023 17:00	3,605.7	0.0	3,605.7	105,900.0	381.8	0.5	0.2	0.8
07/29/2023 18:00	3,613.0	0.0	3,613.0	105,900.0	382.6	0.5	0.2	0.8
07/29/2023 19:00	3,618.7	0.0	3,618.7	105,900.0	383.2	0.5	0.2	0.8
07/29/2023 20:00	3,629.8	0.0	3,629.8	105,900.0	384.4	0.5	0.2	0.8
07/29/2023 21:00	3,635.2	0.0	3,635.2	105,900.0	385.0	0.5	0.2	0.8
07/29/2023 22:00	3,642.6	0.0	3,642.6	105,900.0	385.8	0.5	0.2	0.8
07/29/2023 23:00	3,776.7	0.0	3,776.7	105,900.0	400.0	0.5	0.2	0.8
Average/Sum#:	3,690.1	0.0	3,690.1	105,900.0	390.8	0.5	0.2	0.8
Minimum:	3,605.7	0.0	3,605.7	105,900.0	381.8	0.5	0.2	0.8
Maximum:	4,403.7	0.0	4,403.7	105,900.0	466.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2023 00:00	3,648.3	0.0	3,648.3	105,900.0	386.4	0.5	0.2	0.8
07/30/2023 01:00	3,649.2	0.0	3,649.2	105,900.0	386.5	0.5	0.2	0.8
07/30/2023 02:00	3,651.4	0.0	3,651.4	105,900.0	386.7	0.5	0.2	0.8
07/30/2023 03:00	3,652.4	0.0	3,652.4	105,900.0	386.8	0.5	0.2	0.8
07/30/2023 04:00	3,658.9	0.0	3,658.9	105,900.0	387.5	0.5	0.2	0.8
07/30/2023 05:00	3,718.1	0.0	3,718.1	105,900.0	393.7	0.5	0.2	0.8
07/30/2023 06:00	3,660.2	0.0	3,660.2	105,900.0	387.6	0.5	0.2	0.8
07/30/2023 07:00	3,658.3	0.0	3,658.3	105,900.0	387.4	0.5	0.2	0.8
07/30/2023 08:00	3,652.0	0.0	3,652.0	105,900.0	386.7	0.5	0.2	0.8
07/30/2023 09:00	3,645.1	0.0	3,645.1	105,900.0	386.0	0.5	0.2	0.8
07/30/2023 10:00	3,640.0	0.0	3,640.0	105,900.0	385.5	0.5	0.2	0.8
07/30/2023 11:00	3,633.2	0.0	3,633.2	105,900.0	384.8	0.5	0.2	0.8
07/30/2023 12:00	3,623.4	0.0	3,623.4	105,900.0	383.7	0.5	0.2	0.8
07/30/2023 13:00	3,617.3	0.0	3,617.3	105,900.0	383.1	0.5	0.2	0.8
07/30/2023 14:00	3,682.5	0.0	3,682.5	105,900.0	390.0	0.5	0.2	0.8
07/30/2023 15:00	3,610.2	0.0	3,610.2	105,900.0	382.3	0.5	0.2	0.8
07/30/2023 16:00	3,617.3	0.0	3,617.3	105,900.0	383.1	0.5	0.2	0.8
07/30/2023 17:00	3,712.3	0.0	3,712.3	105,900.0	393.1	0.5	0.2	0.8
07/30/2023 18:00	3,678.4	0.0	3,678.4	105,900.0	389.5	0.5	0.2	0.8
07/30/2023 19:00	3,620.2	0.0	3,620.2	105,900.0	383.4	0.5	0.2	0.8
07/30/2023 20:00	3,617.3	0.0	3,617.3	105,900.0	383.1	0.5	0.2	0.8
07/30/2023 21:00	3,653.4	0.0	3,653.4	105,900.0	386.9	0.5	0.2	0.8
07/30/2023 22:00	3,629.1	0.0	3,629.1	105,900.0	384.3	0.5	0.2	0.8
07/30/2023 23:00	3,632.7	0.0	3,632.7	105,900.0	384.7	0.5	0.2	0.8
Average/Sum#:	3,648.4	0.0	3,648.4	105,900.0	386.4	0.5	0.2	0.8
Minimum:	3,610.2	0.0	3,610.2	105,900.0	382.3	0.5	0.2	0.8
Maximum:	3,718.1	0.0	3,718.1	105,900.0	393.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2023 00:00	3,813.5	0.0	3,813.5	105,900.0	403.8	0.5	0.2	0.8
07/31/2023 01:00	3,642.3	0.0	3,642.3	105,900.0	385.7	0.5	0.2	0.8
07/31/2023 02:00	3,681.6	0.0	3,681.6	105,900.0	389.9	0.5	0.2	0.8
07/31/2023 03:00	3,642.8	0.0	3,642.8	105,900.0	385.8	0.5	0.2	0.8
07/31/2023 04:00	3,697.4	0.0	3,697.4	105,900.0	391.6	0.5	0.2	0.8
07/31/2023 05:00	3,863.4	0.0	3,863.4	105,900.0	409.1	0.5	0.2	0.8
07/31/2023 06:00	4,315.4	0.0	4,315.4	105,900.0	457.0	0.5	0.3	0.9
07/31/2023 07:00	3,725.8	0.0	3,725.8	105,900.0	394.6	0.5	0.2	0.8
07/31/2023 08:00	3,647.5	0.0	3,647.5	105,900.0	386.3	0.5	0.2	0.8
07/31/2023 09:00	3,642.1	0.0	3,642.1	105,900.0	385.7	0.5	0.2	0.8
07/31/2023 10:00	3,804.7	0.0	3,804.7	105,900.0	402.9	0.5	0.2	0.8
07/31/2023 11:00	4,655.2	0.0	4,655.2	105,900.0	493.0	0.6	0.3	1.0
07/31/2023 12:00	4,604.2	0.0	4,604.2	105,900.0	487.6	0.6	0.3	1.0
07/31/2023 13:00	4,579.4	1,344.1	5,923.5	105,900.0	627.3	0.8	0.4	1.3
07/31/2023 14:00	4,563.0	1,307.6	5,870.6	105,900.0	621.7	0.7	0.4	1.2
07/31/2023 15:00	4,562.5	1,126.1	5,688.6	105,900.0	602.4	0.7	0.4	1.2
07/31/2023 16:00	4,564.5	1,070.2	5,634.7	105,900.0	596.7	0.7	0.4	1.2
07/31/2023 17:00	4,553.4	736.0	5,289.4	105,900.0	560.1	0.7	0.3	1.1
07/31/2023 18:00	4,554.0	597.4	5,151.4	105,900.0	545.5	0.7	0.3	1.1
07/31/2023 19:00	4,579.2	655.2	5,234.4	105,900.0	554.3	0.7	0.3	1.1
07/31/2023 20:00	4,630.3	552.9	5,183.2	105,900.0	548.9	0.7	0.3	1.1
07/31/2023 21:00	4,581.2	374.3	4,869.4	105,900.0	515.7	0.6	0.3	1.0
07/31/2023 22:00	4,166.4	0.0	4,166.4	105,900.0	441.2	0.5	0.3	0.9
07/31/2023 23:00	4,464.7	0.0	4,464.7	105,900.0	472.8	0.6	0.3	0.9
Average/Sum#:	4,188.9	323.5	4,508.8	105,900.0	477.5	0.6	0.3	1.0
Minimum:	3,642.1	0.0	3,642.1	105,900.0	385.7	0.5	0.2	0.8
Maximum:	4,655.2	1,344.1	5,923.5	105,900.0	627.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2023 00:00	4,263.5	0.0	4,263.5	101,950.0	434.7	0.5	0.3	0.9
08/01/2023 01:00	4,042.2	0.0	4,042.2	101,950.0	412.1	0.5	0.2	0.8
08/01/2023 02:00	4,192.9	0.0	4,192.9	101,950.0	427.5	0.5	0.3	0.9
08/01/2023 03:00	4,136.7	0.0	4,136.7	101,950.0	421.7	0.5	0.3	0.8
08/01/2023 04:00	4,172.3	0.0	4,172.3	101,950.0	425.4	0.5	0.3	0.9
08/01/2023 05:00	4,462.3	0.0	4,462.3	101,950.0	454.9	0.5	0.3	0.9
08/01/2023 06:00	4,554.9	0.0	4,554.9	101,950.0	464.4	0.6	0.3	0.9
08/01/2023 07:00	4,111.4	0.0	4,111.4	101,950.0	419.2	0.5	0.3	0.8
08/01/2023 08:00	3,765.2	0.0	3,765.2	101,950.0	383.9	0.5	0.2	0.8
08/01/2023 09:00	4,384.5	0.0	4,384.5	101,950.0	447.0	0.5	0.3	0.9
08/01/2023 10:00	4,109.6	0.0	4,109.6	101,950.0	419.0	0.5	0.3	0.8
08/01/2023 11:00	4,443.5	0.0	4,443.5	101,950.0	453.0	0.5	0.3	0.9
08/01/2023 12:00	4,466.0	0.0	4,466.0	101,950.0	455.3	0.5	0.3	0.9
08/01/2023 13:00	4,466.3	0.0	4,466.3	101,950.0	455.3	0.5	0.3	0.9
08/01/2023 14:00	4,469.6	0.0	4,469.6	101,950.0	455.7	0.5	0.3	0.9
08/01/2023 15:00	4,373.7	0.0	4,373.7	101,950.0	445.9	0.5	0.3	0.9
08/01/2023 16:00	4,458.7	0.0	4,458.7	101,950.0	454.6	0.5	0.3	0.9
08/01/2023 17:00	4,367.9	0.0	4,367.9	101,950.0	445.3	0.5	0.3	0.9
08/01/2023 18:00	4,109.5	0.0	4,109.5	101,950.0	419.0	0.5	0.3	0.8
08/01/2023 19:00	4,356.0	0.0	4,356.0	101,950.0	444.1	0.5	0.3	0.9
08/01/2023 20:00	4,440.0	0.0	4,440.0	101,950.0	452.7	0.5	0.3	0.9
08/01/2023 21:00	4,412.4	0.0	4,412.4	101,950.0	449.8	0.5	0.3	0.9
08/01/2023 22:00	4,391.6	0.0	4,391.6	101,950.0	447.7	0.5	0.3	0.9
08/01/2023 23:00	3,799.7	0.0	3,799.7	101,950.0	387.4	0.5	0.2	0.8
Average/Sum#:	4,281.3	0.0	4,281.3	101,950.0	436.5	0.5	0.3	0.9
Minimum:	3,765.2	0.0	3,765.2	101,950.0	383.9	0.5	0.2	0.8
Maximum:	4,554.9	0.0	4,554.9	101,950.0	464.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2023 00:00	4,343.5	0.0	4,343.5	101,950.0	442.8	0.5	0.3	0.9
08/02/2023 01:00	4,341.0	0.0	4,341.0	101,950.0	442.6	0.5	0.3	0.9
08/02/2023 02:00	4,135.6	0.0	4,135.6	101,950.0	421.6	0.5	0.3	0.8
08/02/2023 03:00	4,384.3	0.0	4,384.3	101,950.0	447.0	0.5	0.3	0.9
08/02/2023 04:00	4,432.8	0.0	4,432.8	101,950.0	451.9	0.5	0.3	0.9
08/02/2023 05:00	4,464.2	0.0	4,464.2	101,950.0	455.1	0.5	0.3	0.9
08/02/2023 06:00	4,449.4	0.0	4,449.4	101,950.0	453.6	0.5	0.3	0.9
08/02/2023 07:00	3,807.7	0.0	3,807.7	101,950.0	388.2	0.5	0.2	0.8
08/02/2023 08:00	3,658.9	0.0	3,658.9	101,950.0	373.0	0.4	0.2	0.7
08/02/2023 09:00	3,654.5	0.0	3,654.5	101,950.0	372.6	0.4	0.2	0.7
08/02/2023 10:00	3,734.6	0.0	3,734.6	101,950.0	380.7	0.5	0.2	0.8
08/02/2023 11:00	3,636.3	0.0	3,636.3	101,950.0	370.7	0.4	0.2	0.7
08/02/2023 12:00	3,643.8	0.0	3,643.8	101,950.0	371.5	0.4	0.2	0.7
08/02/2023 13:00	4,161.7	0.0	4,161.7	101,950.0	424.3	0.5	0.3	0.8
08/02/2023 14:00	3,645.1	0.0	3,645.1	101,950.0	371.6	0.4	0.2	0.7
08/02/2023 15:00	3,640.6	0.0	3,640.6	101,950.0	371.2	0.4	0.2	0.7
08/02/2023 16:00	3,640.6	0.0	3,640.6	101,950.0	371.2	0.4	0.2	0.7
08/02/2023 17:00	3,816.3	0.0	3,816.3	101,950.0	389.1	0.5	0.2	0.8
08/02/2023 18:00	3,659.6	0.0	3,659.6	101,950.0	373.1	0.4	0.2	0.7
08/02/2023 19:00	4,042.6	0.0	4,042.6	101,950.0	412.1	0.5	0.2	0.8
08/02/2023 20:00	4,112.8	0.0	4,112.8	101,950.0	419.3	0.5	0.3	0.8
08/02/2023 21:00	4,111.3	0.0	4,111.3	101,950.0	419.1	0.5	0.3	0.8
08/02/2023 22:00	4,156.4	0.0	4,156.4	101,950.0	423.7	0.5	0.3	0.8
08/02/2023 23:00	3,657.1	0.0	3,657.1	101,950.0	372.8	0.4	0.2	0.7
Average/Sum#:	3,972.1	0.0	3,972.1	101,950.0	405.0	0.5	0.2	0.8
Minimum:	3,636.3	0.0	3,636.3	101,950.0	370.7	0.4	0.2	0.7
Maximum:	4,464.2	0.0	4,464.2	101,950.0	455.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2023 00:00	4,114.4	0.0	4,114.4	101,950.0	419.5	0.5	0.3	0.8
08/03/2023 01:00	3,902.4	0.0	3,902.4	101,950.0	397.8	0.5	0.2	0.8
08/03/2023 02:00	3,780.0	0.0	3,780.0	101,950.0	385.4	0.5	0.2	0.8
08/03/2023 03:00	3,859.9	0.0	3,859.9	101,950.0	393.5	0.5	0.2	0.8
08/03/2023 04:00	3,664.6	0.0	3,664.6	101,950.0	373.6	0.5	0.2	0.7
08/03/2023 05:00	4,064.8	0.0	4,064.8	101,950.0	414.4	0.5	0.2	0.8
08/03/2023 06:00	4,164.2	0.0	4,164.2	101,950.0	424.5	0.5	0.3	0.8
08/03/2023 07:00	3,654.4	0.0	3,654.4	101,950.0	372.6	0.4	0.2	0.7
08/03/2023 08:00	3,651.7	0.0	3,651.7	101,950.0	372.3	0.4	0.2	0.7
08/03/2023 09:00	3,649.0	0.0	3,649.0	101,950.0	372.0	0.4	0.2	0.7
08/03/2023 10:00	3,645.0	0.0	3,645.0	101,950.0	371.6	0.4	0.2	0.7
08/03/2023 11:00	3,641.0	0.0	3,641.0	101,950.0	371.2	0.4	0.2	0.7
08/03/2023 12:00	3,634.1	0.0	3,634.1	101,950.0	370.5	0.4	0.2	0.7
08/03/2023 13:00	3,628.5	0.0	3,628.5	101,950.0	369.9	0.4	0.2	0.7
08/03/2023 14:00	3,621.4	0.0	3,621.4	101,950.0	369.2	0.4	0.2	0.7
08/03/2023 15:00	3,619.3	0.0	3,619.3	101,950.0	369.0	0.4	0.2	0.7
08/03/2023 16:00	3,619.4	0.0	3,619.4	101,950.0	369.0	0.4	0.2	0.7
08/03/2023 17:00	3,615.4	0.0	3,615.4	101,950.0	368.6	0.4	0.2	0.7
08/03/2023 18:00	3,702.8	0.0	3,702.8	101,950.0	377.5	0.5	0.2	0.8
08/03/2023 19:00	3,904.4	0.0	3,904.4	101,950.0	398.1	0.5	0.2	0.8
08/03/2023 20:00	3,847.8	0.0	3,847.8	101,950.0	392.3	0.5	0.2	0.8
08/03/2023 21:00	3,838.0	0.0	3,838.0	101,950.0	391.3	0.5	0.2	0.8
08/03/2023 22:00	3,784.3	0.0	3,784.3	101,950.0	385.8	0.5	0.2	0.8
08/03/2023 23:00	3,644.4	0.0	3,644.4	101,950.0	371.5	0.4	0.2	0.7
Average/Sum#:	3,760.5	0.0	3,760.5	101,950.0	383.4	0.5	0.2	0.7
Minimum:	3,615.4	0.0	3,615.4	101,950.0	368.6	0.4	0.2	0.7
Maximum:	4,164.2	0.0	4,164.2	101,950.0	424.5	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2023 00:00	3,648.8	0.0	3,648.8	101,950.0	372.0	0.4	0.2	0.7
08/04/2023 01:00	3,650.4	0.0	3,650.4	101,950.0	372.2	0.4	0.2	0.7
08/04/2023 02:00	3,655.8	0.0	3,655.8	101,950.0	372.7	0.4	0.2	0.7
08/04/2023 03:00	3,658.3	0.0	3,658.3	101,950.0	373.0	0.4	0.2	0.7
08/04/2023 04:00	3,657.0	0.0	3,657.0	101,950.0	372.8	0.5	0.2	0.7
08/04/2023 05:00	3,759.4	0.0	3,759.4	101,950.0	383.3	0.5	0.2	0.8
08/04/2023 06:00	3,825.6	0.0	3,825.6	101,950.0	390.0	0.5	0.2	0.8
08/04/2023 07:00	3,654.7	0.0	3,654.7	101,950.0	372.6	0.5	0.2	0.7
08/04/2023 08:00	3,653.1	0.0	3,653.1	101,950.0	372.4	0.4	0.2	0.7
08/04/2023 09:00	3,645.8	0.0	3,645.8	101,950.0	371.7	0.4	0.2	0.7
08/04/2023 10:00	3,642.2	0.0	3,642.2	101,950.0	371.3	0.4	0.2	0.7
08/04/2023 11:00	3,637.8	0.0	3,637.8	101,950.0	370.9	0.4	0.2	0.7
08/04/2023 12:00	3,631.9	0.0	3,631.9	101,950.0	370.3	0.4	0.2	0.7
08/04/2023 13:00	3,626.2	0.0	3,626.2	101,950.0	369.7	0.4	0.2	0.7
08/04/2023 14:00	3,619.4	0.0	3,619.4	101,950.0	369.0	0.4	0.2	0.7
08/04/2023 15:00	3,615.8	0.0	3,615.8	101,950.0	368.6	0.4	0.2	0.7
08/04/2023 16:00	3,614.3	0.0	3,614.3	101,950.0	368.5	0.4	0.2	0.7
08/04/2023 17:00	3,693.9	0.0	3,693.9	101,950.0	376.6	0.5	0.2	0.8
08/04/2023 18:00	4,373.4	278.9	4,507.3	101,950.0	459.5	0.6	0.3	0.9
08/04/2023 19:00	4,565.6	606.0	5,171.6	101,950.0	527.2	0.6	0.3	1.1
08/04/2023 20:00	4,577.8	582.8	5,160.6	101,950.0	526.1	0.6	0.3	1.1
08/04/2023 21:00	4,560.0	535.6	4,972.4	101,950.0	506.9	0.6	0.3	1.0
08/04/2023 22:00	4,223.3	0.0	4,223.3	101,950.0	430.6	0.5	0.3	0.9
08/04/2023 23:00	3,853.7	0.0	3,853.7	101,950.0	392.9	0.5	0.2	0.8
Average/Sum#:	3,835.2	83.5	3,907.5	101,950.0	398.4	0.5	0.2	0.8
Minimum:	3,614.3	0.0	3,614.3	101,950.0	368.5	0.4	0.2	0.7
Maximum:	4,577.8	606.0	5,171.6	101,950.0	527.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2023 00:00	4,382.2	0.0	4,382.2	101,950.0	446.8	0.5	0.3	0.9
08/05/2023 01:00	4,323.9	0.0	4,323.9	101,950.0	440.8	0.5	0.3	0.9
08/05/2023 02:00	4,397.6	0.0	4,397.6	101,950.0	448.3	0.5	0.3	0.9
08/05/2023 03:00	4,371.1	0.0	4,371.1	101,950.0	445.6	0.5	0.3	0.9
08/05/2023 04:00	4,105.8	0.0	4,105.8	101,950.0	418.6	0.5	0.3	0.8
08/05/2023 05:00	3,752.9	0.0	3,752.9	101,950.0	382.6	0.5	0.2	0.8
08/05/2023 06:00	3,879.4	0.0	3,879.4	101,950.0	395.5	0.5	0.2	0.8
08/05/2023 07:00	3,641.6	0.0	3,641.6	101,950.0	371.3	0.4	0.2	0.7
08/05/2023 08:00	3,636.7	0.0	3,636.7	101,950.0	370.8	0.4	0.2	0.7
08/05/2023 09:00	3,631.2	0.0	3,631.2	101,950.0	370.2	0.4	0.2	0.7
08/05/2023 10:00	3,625.1	0.0	3,625.1	101,950.0	369.6	0.4	0.2	0.7
08/05/2023 11:00	3,619.5	0.0	3,619.5	101,950.0	369.0	0.4	0.2	0.7
08/05/2023 12:00	3,617.5	0.0	3,617.5	101,950.0	368.8	0.4	0.2	0.7
08/05/2023 13:00	3,616.1	0.0	3,616.1	101,950.0	368.7	0.4	0.2	0.7
08/05/2023 14:00	3,861.9	11.7	3,862.7	101,950.0	393.8	0.5	0.2	0.8
08/05/2023 15:00	4,015.3	0.0	4,015.3	101,950.0	409.4	0.5	0.2	0.8
08/05/2023 16:00	3,635.5	0.0	3,635.5	101,950.0	370.6	0.4	0.2	0.7
08/05/2023 17:00	4,098.3	137.7	4,130.0	101,950.0	421.1	0.5	0.3	0.9
08/05/2023 18:00	4,505.2	695.5	5,200.7	101,950.0	530.2	0.6	0.3	1.1
08/05/2023 19:00	4,499.6	802.5	5,302.1	101,950.0	540.5	0.6	0.3	1.1
08/05/2023 20:00	4,511.9	672.0	5,183.9	101,950.0	528.5	0.6	0.3	1.1
08/05/2023 21:00	4,484.3	508.6	4,881.0	101,950.0	497.6	0.6	0.3	1.0
08/05/2023 22:00	4,099.6	0.0	4,099.6	101,950.0	418.0	0.5	0.3	0.8
08/05/2023 23:00	3,918.1	0.0	3,918.1	101,950.0	399.5	0.5	0.2	0.8
Average/Sum#:	4,009.6	117.8	4,117.9	101,950.0	419.8	0.5	0.2	0.8
Minimum:	3,616.1	0.0	3,616.1	101,950.0	368.7	0.4	0.2	0.7
Maximum:	4,511.9	802.5	5,302.1	101,950.0	540.5	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2023 00:00	4,008.8	0.0	4,008.8	101,950.0	408.7	0.5	0.2	0.8
08/06/2023 01:00	3,835.8	0.0	3,835.8	101,950.0	391.1	0.5	0.2	0.8
08/06/2023 02:00	3,832.9	0.0	3,832.9	101,950.0	390.8	0.5	0.2	0.8
08/06/2023 03:00	3,648.5	0.0	3,648.5	101,950.0	372.0	0.4	0.2	0.7
08/06/2023 04:00	3,690.6	0.0	3,690.6	101,950.0	376.3	0.5	0.2	0.8
08/06/2023 05:00	3,948.9	0.0	3,948.9	101,950.0	402.6	0.5	0.2	0.8
08/06/2023 06:00	3,887.2	0.0	3,887.2	101,950.0	396.3	0.5	0.2	0.8
08/06/2023 07:00	3,639.7	0.0	3,639.7	101,950.0	371.1	0.4	0.2	0.7
08/06/2023 08:00	4,040.2	0.0	4,040.2	101,950.0	411.9	0.5	0.2	0.8
08/06/2023 09:00	3,621.7	0.0	3,621.7	101,950.0	369.2	0.4	0.2	0.7
08/06/2023 10:00	3,618.5	0.0	3,618.5	101,950.0	368.9	0.4	0.2	0.7
08/06/2023 11:00	3,611.9	0.0	3,611.9	101,950.0	368.2	0.4	0.2	0.7
08/06/2023 12:00	3,835.0	8.1	3,835.4	101,950.0	391.0	0.5	0.2	0.8
08/06/2023 13:00	4,295.2	0.0	4,295.2	101,950.0	437.9	0.5	0.3	0.9
08/06/2023 14:00	4,505.1	0.0	4,505.1	101,950.0	459.3	0.6	0.3	0.9
08/06/2023 15:00	4,445.4	0.0	4,445.4	101,950.0	453.2	0.5	0.3	0.9
08/06/2023 16:00	4,232.3	0.0	4,232.3	101,950.0	431.5	0.5	0.3	0.9
08/06/2023 17:00	4,337.4	190.4	4,390.7	101,950.0	447.6	0.6	0.3	0.9
08/06/2023 18:00	4,501.2	773.1	5,274.3	101,950.0	537.7	0.6	0.3	1.1
08/06/2023 19:00	4,496.9	989.8	5,486.7	101,950.0	559.4	0.7	0.3	1.1
08/06/2023 20:00	4,513.3	1,018.9	5,532.2	101,950.0	564.0	0.7	0.3	1.1
08/06/2023 21:00	4,516.3	689.0	5,053.7	101,950.0	515.2	0.6	0.3	1.1
08/06/2023 22:00	4,356.5	0.0	4,356.5	101,950.0	444.1	0.5	0.3	0.9
08/06/2023 23:00	3,942.4	0.0	3,942.4	101,950.0	401.9	0.5	0.2	0.8
Average/Sum#:	4,056.7	152.9	4,197.3	101,950.0	427.9	0.5	0.2	0.9
Minimum:	3,611.9	0.0	3,611.9	101,950.0	368.2	0.4	0.2	0.7
Maximum:	4,516.3	1,018.9	5,532.2	101,950.0	564.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2023 00:00	4,183.7	0.0	4,183.7	101,950.0	426.5	0.5	0.3	0.9
08/07/2023 01:00	3,844.0	0.0	3,844.0	101,950.0	391.9	0.5	0.2	0.8
08/07/2023 02:00	3,700.7	0.0	3,700.7	101,950.0	377.3	0.5	0.2	0.8
08/07/2023 03:00	3,633.0	0.0	3,633.0	101,950.0	370.4	0.4	0.2	0.7
08/07/2023 04:00	3,960.9	0.0	3,960.9	101,950.0	403.8	0.5	0.2	0.8
08/07/2023 05:00	4,415.5	0.0	4,415.5	101,950.0	450.2	0.5	0.3	0.9
08/07/2023 06:00	4,395.5	0.0	4,395.5	101,950.0	448.1	0.5	0.3	0.9
08/07/2023 07:00	3,746.9	0.0	3,746.9	101,950.0	382.0	0.5	0.2	0.8
08/07/2023 08:00	3,650.8	0.0	3,650.8	101,950.0	372.2	0.4	0.2	0.7
08/07/2023 09:00	4,066.7	0.0	4,066.7	101,950.0	414.6	0.5	0.2	0.8
08/07/2023 10:00	4,238.5	31.0	4,244.1	101,950.0	432.7	0.5	0.3	0.9
08/07/2023 11:00	4,434.3	216.6	4,568.6	101,950.0	465.8	0.6	0.3	0.9
08/07/2023 12:00	4,515.0	1,084.7	5,599.7	101,950.0	570.9	0.7	0.3	1.1
08/07/2023 13:00	4,438.3	7.3	4,438.5	101,950.0	452.5	0.5	0.3	0.9
08/07/2023 14:00	4,417.0	15.4	4,418.5	101,950.0	450.5	0.5	0.3	0.9
08/07/2023 15:00	4,440.7	0.0	4,440.7	101,950.0	452.7	0.5	0.3	0.9
08/07/2023 16:00	4,462.9	800.7	5,039.4	101,950.0	513.8	0.6	0.3	1.1
08/07/2023 17:00	4,467.7	984.2	5,451.9	101,950.0	555.8	0.7	0.3	1.1
08/07/2023 18:00	4,474.7	1,032.8	5,507.5	101,950.0	561.5	0.7	0.3	1.1
08/07/2023 19:00	4,502.3	1,554.9	6,057.2	101,950.0	617.5	0.7	0.4	1.2
08/07/2023 20:00	4,533.9	990.6	5,524.5	101,950.0	563.2	0.7	0.3	1.1
08/07/2023 21:00	4,569.6	951.0	5,520.6	101,950.0	562.8	0.7	0.3	1.1
08/07/2023 22:00	4,597.3	1,035.6	5,632.9	101,950.0	574.3	0.7	0.3	1.1
08/07/2023 23:00	4,217.7	2.5	4,217.8	101,950.0	430.0	0.5	0.3	0.9
Average/Sum#:	4,246.2	362.8	4,594.2	101,950.0	468.4	0.6	0.3	0.9
Minimum:	3,633.0	0.0	3,633.0	101,950.0	370.4	0.4	0.2	0.7
Maximum:	4,597.3	1,554.9	6,057.2	101,950.0	617.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2023 00:00	4,271.3	0.0	4,271.3	101,950.0	435.5	0.5	0.3	0.9
08/08/2023 01:00	4,228.8	0.0	4,228.8	101,950.0	431.1	0.5	0.3	0.9
08/08/2023 02:00	4,124.0	0.0	4,124.0	101,950.0	420.4	0.5	0.3	0.8
08/08/2023 03:00	4,039.9	0.0	4,039.9	101,950.0	411.9	0.5	0.2	0.8
08/08/2023 04:00	3,892.7	0.0	3,892.7	101,950.0	396.9	0.5	0.2	0.8
08/08/2023 05:00	4,315.3	0.0	4,315.3	101,950.0	439.9	0.5	0.3	0.9
08/08/2023 06:00	4,359.8	0.0	4,359.8	101,950.0	444.5	0.5	0.3	0.9
08/08/2023 07:00	3,653.4	0.0	3,653.4	101,950.0	372.5	0.4	0.2	0.7
08/08/2023 08:00	3,652.4	0.0	3,652.4	101,950.0	372.4	0.4	0.2	0.7
08/08/2023 09:00	3,651.1	0.0	3,651.1	101,950.0	372.2	0.4	0.2	0.7
08/08/2023 10:00	3,647.0	0.0	3,647.0	101,950.0	371.8	0.4	0.2	0.7
08/08/2023 11:00	3,639.6	0.0	3,639.6	101,950.0	371.1	0.4	0.2	0.7
08/08/2023 12:00	3,631.7	0.0	3,631.7	101,950.0	370.3	0.4	0.2	0.7
08/08/2023 13:00	3,625.1	0.0	3,625.1	101,950.0	369.6	0.4	0.2	0.7
08/08/2023 14:00	3,722.9	0.0	3,722.9	101,950.0	379.5	0.5	0.2	0.8
08/08/2023 15:00	3,644.8	0.0	3,644.8	101,950.0	371.6	0.4	0.2	0.7
08/08/2023 16:00	3,647.7	0.0	3,647.7	101,950.0	371.9	0.4	0.2	0.7
08/08/2023 17:00	3,704.9	0.0	3,704.9	101,950.0	377.7	0.5	0.2	0.8
08/08/2023 18:00	3,953.8	0.0	3,953.8	101,950.0	403.1	0.5	0.2	0.8
08/08/2023 19:00	4,544.9	0.0	4,544.9	101,950.0	463.4	0.6	0.3	0.9
08/08/2023 20:00	4,043.3	0.0	4,043.3	101,950.0	412.2	0.5	0.2	0.8
08/08/2023 21:00	3,869.9	0.0	3,869.9	101,950.0	394.5	0.5	0.2	0.8
08/08/2023 22:00	3,859.9	0.0	3,859.9	101,950.0	393.5	0.5	0.2	0.8
08/08/2023 23:00	3,650.1	0.0	3,650.1	101,950.0	372.1	0.4	0.2	0.7
Average/Sum#:	3,890.6	0.0	3,890.6	101,950.0	396.7	0.5	0.2	0.8
Minimum:	3,625.1	0.0	3,625.1	101,950.0	369.6	0.4	0.2	0.7
Maximum:	4,544.9	0.0	4,544.9	101,950.0	463.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2023 00:00	3,650.1	0.0	3,650.1	101,950.0	372.1	0.4	0.2	0.7
08/09/2023 01:00	3,653.2	0.0	3,653.2	101,950.0	372.4	0.4	0.2	0.7
08/09/2023 02:00	3,655.9	0.0	3,655.9	101,950.0	372.7	0.5	0.2	0.7
08/09/2023 03:00	3,655.4	0.0	3,655.4	101,950.0	372.7	0.4	0.2	0.7
08/09/2023 04:00	3,658.8	0.0	3,658.8	101,950.0	373.0	0.4	0.2	0.7
08/09/2023 05:00	3,711.6	0.0	3,711.6	101,950.0	378.4	0.5	0.2	0.8
08/09/2023 06:00	3,735.9	0.0	3,735.9	101,950.0	380.9	0.5	0.2	0.8
08/09/2023 07:00	3,659.0	0.0	3,659.0	101,950.0	373.0	0.4	0.2	0.7
08/09/2023 08:00	3,652.5	0.0	3,652.5	101,950.0	372.4	0.4	0.2	0.7
08/09/2023 09:00	3,647.1	0.0	3,647.1	101,950.0	371.8	0.4	0.2	0.7
08/09/2023 10:00	3,644.5	0.0	3,644.5	101,950.0	371.6	0.4	0.2	0.7
08/09/2023 11:00	3,639.3	0.0	3,639.3	101,950.0	371.0	0.4	0.2	0.7
08/09/2023 12:00	3,636.7	0.0	3,636.7	101,950.0	370.8	0.4	0.2	0.7
08/09/2023 13:00	3,869.3	0.0	3,869.3	101,950.0	394.5	0.5	0.2	0.8
08/09/2023 14:00	3,967.7	0.0	3,967.7	101,950.0	404.5	0.5	0.2	0.8
08/09/2023 15:00	4,207.9	0.0	4,207.9	101,950.0	429.0	0.5	0.3	0.9
08/09/2023 16:00	4,400.4	0.0	4,400.4	101,950.0	448.6	0.5	0.3	0.9
08/09/2023 17:00	4,051.1	0.0	4,051.1	101,950.0	413.0	0.5	0.2	0.8
08/09/2023 18:00	4,246.8	49.5	4,256.7	101,950.0	434.0	0.5	0.3	0.9
08/09/2023 19:00	4,601.9	533.8	5,135.7	101,950.0	523.6	0.6	0.3	1.0
08/09/2023 20:00	4,416.6	257.8	4,550.7	101,950.0	463.9	0.6	0.3	1.0
08/09/2023 21:00	4,183.8	0.0	4,183.8	101,950.0	426.5	0.5	0.3	0.9
08/09/2023 22:00	3,919.3	0.0	3,919.3	101,950.0	399.6	0.5	0.2	0.8
08/09/2023 23:00	3,633.7	0.0	3,633.7	101,950.0	370.5	0.4	0.2	0.7
Average/Sum#:	3,879.1	35.0	3,907.3	101,950.0	398.4	0.5	0.2	0.8
Minimum:	3,633.7	0.0	3,633.7	101,950.0	370.5	0.4	0.2	0.7
Maximum:	4,601.9	533.8	5,135.7	101,950.0	523.6	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2023 00:00	3,636.5	0.0	3,636.5	101,950.0	370.7	0.4	0.2	0.7
08/10/2023 01:00	3,641.6	0.0	3,641.6	101,950.0	371.3	0.4	0.2	0.7
08/10/2023 02:00	3,642.1	0.0	3,642.1	101,950.0	371.3	0.4	0.2	0.7
08/10/2023 03:00	3,647.7	0.0	3,647.7	101,950.0	371.9	0.4	0.2	0.7
08/10/2023 04:00	3,649.1	0.0	3,649.1	101,950.0	372.0	0.4	0.2	0.7
08/10/2023 05:00	3,676.2	0.0	3,676.2	101,950.0	374.8	0.5	0.2	0.8
08/10/2023 06:00	4,200.1	0.0	4,200.1	101,950.0	428.2	0.5	0.3	0.9
08/10/2023 07:00	3,771.5	0.0	3,771.5	101,950.0	384.5	0.5	0.2	0.8
08/10/2023 08:00	3,649.7	0.0	3,649.7	101,950.0	372.1	0.4	0.2	0.7
08/10/2023 09:00	3,646.6	0.0	3,646.6	101,950.0	371.8	0.4	0.2	0.7
08/10/2023 10:00	3,643.5	0.0	3,643.5	101,950.0	371.5	0.4	0.2	0.7
08/10/2023 11:00	3,638.2	0.0	3,638.2	101,950.0	370.9	0.4	0.2	0.7
08/10/2023 12:00	3,624.6	0.0	3,624.6	101,950.0	369.5	0.4	0.2	0.7
08/10/2023 13:00	3,764.5	0.0	3,764.5	101,950.0	383.8	0.5	0.2	0.8
08/10/2023 14:00	3,617.6	0.0	3,617.6	101,950.0	368.8	0.4	0.2	0.7
08/10/2023 15:00	3,993.7	1.3	3,993.7	101,950.0	407.2	0.5	0.2	0.8
08/10/2023 16:00	4,429.3	0.0	4,429.3	101,950.0	451.6	0.5	0.3	0.9
08/10/2023 17:00	3,720.6	0.0	3,720.6	101,950.0	379.3	0.5	0.2	0.8
08/10/2023 18:00	3,833.3	0.0	3,833.3	101,950.0	390.8	0.5	0.2	0.8
08/10/2023 19:00	3,703.2	0.0	3,703.2	101,950.0	377.5	0.5	0.2	0.8
08/10/2023 20:00	3,779.8	0.0	3,779.8	101,950.0	385.4	0.5	0.2	0.8
08/10/2023 21:00	3,752.1	0.0	3,752.1	101,950.0	382.5	0.5	0.2	0.8
08/10/2023 22:00	3,782.7	0.0	3,782.7	101,950.0	385.6	0.5	0.2	0.8
08/10/2023 23:00	4,039.8	0.0	4,039.8	101,950.0	411.9	0.5	0.2	0.8
Average/Sum#:	3,770.2	0.1	3,770.2	101,950.0	384.4	0.5	0.2	0.8
Minimum:	3,617.6	0.0	3,617.6	101,950.0	368.8	0.4	0.2	0.7
Maximum:	4,429.3	1.3	4,429.3	101,950.0	451.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2023 00:00	4,708.3	531.7	5,229.4	101,950.0	533.1	0.6	0.3	1.1
08/11/2023 01:00	4,628.3	2.5	4,628.4	101,950.0	471.9	0.6	0.3	0.9
08/11/2023 02:00	4,428.7	0.0	4,428.7	101,950.0	451.5	0.5	0.3	0.9
08/11/2023 03:00	4,269.7	0.0	4,269.7	101,950.0	435.3	0.5	0.3	0.9
08/11/2023 04:00	4,261.7	0.0	4,261.7	101,950.0	434.5	0.5	0.3	0.9
08/11/2023 05:00	4,298.4	0.0	4,298.4	101,950.0	438.2	0.5	0.3	0.9
08/11/2023 06:00	4,469.9	0.0	4,469.9	101,950.0	455.7	0.5	0.3	0.9
08/11/2023 07:00	4,642.9	4.8	4,643.0	101,950.0	473.4	0.6	0.3	0.9
08/11/2023 08:00	4,775.3	340.1	5,115.4	101,950.0	521.5	0.6	0.3	1.0
08/11/2023 09:00	4,732.4	914.7	5,647.1	101,950.0	575.7	0.7	0.3	1.2
08/11/2023 10:00	4,709.2	1,376.8	6,086.0	101,950.0	620.5	0.7	0.4	1.2
08/11/2023 11:00	4,681.9	1,820.0	6,501.9	101,950.0	662.9	0.8	0.4	1.3
08/11/2023 12:00	4,611.5	519.4	5,001.1	101,950.0	509.9	0.6	0.3	1.0
08/11/2023 13:00	3,650.9	0.0	3,650.9	101,950.0	372.2	0.4	0.2	0.7
08/11/2023 14:00	3,645.9	0.0	3,645.9	101,950.0	371.7	0.4	0.2	0.7
08/11/2023 15:00	3,641.0	0.0	3,641.0	101,950.0	371.2	0.4	0.2	0.7
08/11/2023 16:00	3,637.0	0.0	3,637.0	101,950.0	370.8	0.4	0.2	0.7
08/11/2023 17:00	3,739.5	0.0	3,739.5	101,950.0	381.2	0.5	0.2	0.8
08/11/2023 18:00	4,586.0	358.7	4,826.3	101,950.0	492.0	0.6	0.3	1.0
08/11/2023 19:00	4,608.5	520.7	5,129.2	101,950.0	522.9	0.6	0.3	1.0
08/11/2023 20:00	4,638.8	461.3	5,100.1	101,950.0	520.0	0.6	0.3	1.0
08/11/2023 21:00	4,645.4	444.6	5,090.0	101,950.0	518.9	0.6	0.3	1.0
08/11/2023 22:00	4,647.9	458.0	5,105.9	101,950.0	520.5	0.6	0.3	1.0
08/11/2023 23:00	4,666.0	422.0	5,088.0	101,950.0	518.7	0.6	0.3	1.0
Average/Sum#:	4,388.5	340.6	4,718.1	101,950.0	481.0	0.6	0.3	0.9
Minimum:	3,637.0	0.0	3,637.0	101,950.0	370.8	0.4	0.2	0.7
Maximum:	4,775.3	1,820.0	6,501.9	101,950.0	662.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2023 00:00	3,988.7	2.1	3,988.7	101,950.0	406.6	0.5	0.2	0.8
08/12/2023 01:00	3,681.2	0.0	3,681.2	101,950.0	375.3	0.5	0.2	0.8
08/12/2023 02:00	3,658.6	0.0	3,658.6	101,950.0	373.0	0.5	0.2	0.7
08/12/2023 03:00	3,658.0	0.0	3,658.0	101,950.0	372.9	0.5	0.2	0.7
08/12/2023 04:00	3,659.8	0.0	3,659.8	101,950.0	373.1	0.5	0.2	0.7
08/12/2023 05:00	3,659.5	0.0	3,659.5	101,950.0	373.1	0.5	0.2	0.7
08/12/2023 06:00	3,676.0	0.0	3,676.0	101,950.0	374.8	0.5	0.2	0.8
08/12/2023 07:00	3,663.3	0.0	3,663.3	101,950.0	373.5	0.5	0.2	0.7
08/12/2023 08:00	3,656.8	0.0	3,656.8	101,950.0	372.8	0.4	0.2	0.7
08/12/2023 09:00	3,656.9	0.0	3,656.9	101,950.0	372.8	0.4	0.2	0.7
08/12/2023 10:00	3,646.4	0.0	3,646.4	101,950.0	371.8	0.4	0.2	0.7
08/12/2023 11:00	3,810.5	0.0	3,810.5	101,950.0	388.5	0.5	0.2	0.8
08/12/2023 12:00	4,133.9	0.0	4,133.9	101,950.0	421.5	0.5	0.3	0.8
08/12/2023 13:00	4,226.2	0.0	4,226.2	101,950.0	430.9	0.5	0.3	0.9
08/12/2023 14:00	4,014.5	0.0	4,014.5	101,950.0	409.3	0.5	0.2	0.8
08/12/2023 15:00	3,966.7	0.0	3,966.7	101,950.0	404.4	0.5	0.2	0.8
08/12/2023 16:00	3,644.9	0.0	3,644.9	101,950.0	371.6	0.4	0.2	0.7
08/12/2023 17:00	3,642.6	0.0	3,642.6	101,950.0	371.4	0.4	0.2	0.7
08/12/2023 18:00	4,147.5	124.9	4,176.2	101,950.0	425.8	0.5	0.3	0.9
08/12/2023 19:00	4,584.3	566.8	5,151.1	101,950.0	525.2	0.6	0.3	1.1
08/12/2023 20:00	4,594.3	419.1	4,984.1	101,950.0	508.1	0.6	0.3	1.0
08/12/2023 21:00	4,138.9	0.0	4,138.9	101,950.0	422.0	0.5	0.3	0.8
08/12/2023 22:00	4,433.6	2.4	4,433.7	101,950.0	452.0	0.5	0.3	0.9
08/12/2023 23:00	3,882.0	0.0	3,882.0	101,950.0	395.8	0.5	0.2	0.8
Average/Sum#:	3,909.4	46.5	3,950.4	101,950.0	402.8	0.5	0.2	0.8
Minimum:	3,642.6	0.0	3,642.6	101,950.0	371.4	0.4	0.2	0.7
Maximum:	4,594.3	566.8	5,151.1	101,950.0	525.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2023 00:00	4,097.1	0.0	4,097.1	101,950.0	417.7	0.5	0.3	0.8
08/13/2023 01:00	4,094.7	0.0	4,094.7	101,950.0	417.5	0.5	0.3	0.8
08/13/2023 02:00	3,897.0	0.0	3,897.0	101,950.0	397.3	0.5	0.2	0.8
08/13/2023 03:00	4,225.0	0.0	4,225.0	101,950.0	430.7	0.5	0.3	0.9
08/13/2023 04:00	3,864.6	0.0	3,864.6	101,950.0	394.0	0.5	0.2	0.8
08/13/2023 05:00	3,803.9	0.0	3,803.9	101,950.0	387.8	0.5	0.2	0.8
08/13/2023 06:00	3,661.2	0.0	3,661.2	101,950.0	373.3	0.4	0.2	0.7
08/13/2023 07:00	3,636.8	0.0	3,636.8	101,950.0	370.8	0.4	0.2	0.7
08/13/2023 08:00	3,629.2	0.0	3,629.2	101,950.0	370.0	0.4	0.2	0.7
08/13/2023 09:00	3,628.8	0.0	3,628.8	101,950.0	370.0	0.4	0.2	0.7
08/13/2023 10:00	3,625.6	0.0	3,625.6	101,950.0	369.6	0.4	0.2	0.7
08/13/2023 11:00	3,629.9	0.0	3,629.9	101,950.0	370.1	0.4	0.2	0.7
08/13/2023 12:00	3,830.1	0.0	3,830.1	101,950.0	390.5	0.5	0.2	0.8
08/13/2023 13:00	3,780.0	0.0	3,780.0	101,950.0	385.4	0.5	0.2	0.8
08/13/2023 14:00	4,187.3	0.0	4,187.3	101,950.0	426.9	0.5	0.3	0.9
08/13/2023 15:00	4,344.7	0.0	4,344.7	101,950.0	442.9	0.5	0.3	0.9
08/13/2023 16:00	4,330.4	0.0	4,330.4	101,950.0	441.5	0.5	0.3	0.9
08/13/2023 17:00	4,090.3	0.0	4,090.3	101,950.0	417.0	0.5	0.3	0.8
08/13/2023 18:00	4,509.0	518.7	4,913.6	101,950.0	500.9	0.6	0.3	1.0
08/13/2023 19:00	4,526.6	672.7	5,199.3	101,950.0	530.1	0.6	0.3	1.1
08/13/2023 20:00	4,541.8	624.0	5,165.8	101,950.0	526.7	0.6	0.3	1.1
08/13/2023 21:00	4,555.0	588.9	5,143.9	101,950.0	524.4	0.6	0.3	1.0
08/13/2023 22:00	4,478.4	144.0	4,518.7	101,950.0	460.7	0.6	0.3	0.9
08/13/2023 23:00	4,226.2	0.0	4,226.2	101,950.0	430.9	0.5	0.3	0.9
Average/Sum#:	4,049.7	106.2	4,146.8	101,950.0	422.8	0.5	0.3	0.8
Minimum:	3,625.6	0.0	3,625.6	101,950.0	369.6	0.4	0.2	0.7
Maximum:	4,555.0	672.7	5,199.3	101,950.0	530.1	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2023 00:00	4,393.1	0.0	4,393.1	101,950.0	447.9	0.5	0.3	0.9
08/14/2023 01:00	4,379.6	0.0	4,379.6	101,950.0	446.5	0.5	0.3	0.9
08/14/2023 02:00	4,292.7	0.0	4,292.7	101,950.0	437.6	0.5	0.3	0.9
08/14/2023 03:00	4,226.9	0.0	4,226.9	101,950.0	430.9	0.5	0.3	0.9
08/14/2023 04:00	4,149.2	0.0	4,149.2	101,950.0	423.0	0.5	0.3	0.8
08/14/2023 05:00	4,396.5	0.0	4,396.5	101,950.0	448.2	0.5	0.3	0.9
08/14/2023 06:00	4,457.3	0.0	4,457.3	101,950.0	454.4	0.5	0.3	0.9
08/14/2023 07:00	3,861.8	0.0	3,861.8	101,950.0	393.7	0.5	0.2	0.8
08/14/2023 08:00	4,027.4	0.0	4,027.4	101,950.0	410.6	0.5	0.2	0.8
08/14/2023 09:00	4,398.2	0.0	4,398.2	101,950.0	448.4	0.5	0.3	0.9
08/14/2023 10:00	4,426.1	0.0	4,426.1	101,950.0	451.2	0.5	0.3	0.9
08/14/2023 11:00	4,510.9	373.8	4,709.0	101,950.0	480.1	0.6	0.3	1.0
08/14/2023 12:00	4,504.9	1,203.6	5,708.5	101,950.0	582.0	0.7	0.3	1.2
08/14/2023 13:00	4,490.0	1,131.2	5,621.2	101,950.0	573.1	0.7	0.3	1.1
08/14/2023 14:00	4,469.8	835.9	5,305.7	101,950.0	540.9	0.6	0.3	1.1
08/14/2023 15:00	4,452.7	1,342.1	5,794.8	101,950.0	590.8	0.7	0.4	1.2
08/14/2023 16:00	4,441.5	929.5	5,371.0	101,950.0	547.6	0.7	0.3	1.1
08/14/2023 17:00	4,432.1	851.4	5,283.5	101,950.0	538.7	0.6	0.3	1.1
08/14/2023 18:00	4,448.2	1,637.9	6,086.1	101,950.0	620.5	0.7	0.4	1.2
08/14/2023 19:00	4,478.7	1,904.2	6,382.9	101,950.0	650.7	0.8	0.4	1.3
08/14/2023 20:00	4,481.8	1,291.0	5,772.8	101,950.0	588.5	0.7	0.4	1.2
08/14/2023 21:00	4,495.6	1,150.1	5,645.7	101,950.0	575.6	0.7	0.3	1.2
08/14/2023 22:00	4,532.3	879.7	5,412.0	101,950.0	551.8	0.7	0.3	1.1
08/14/2023 23:00	4,509.0	456.1	4,864.8	101,950.0	496.0	0.6	0.3	1.0
Average/Sum#:	4,385.7	582.8	4,957.0	101,950.0	505.4	0.6	0.3	1.0
Minimum:	3,861.8	0.0	3,861.8	101,950.0	393.7	0.5	0.2	0.8
Maximum:	4,532.3	1,904.2	6,382.9	101,950.0	650.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2023 00:00	4,358.3	0.0	4,358.3	101,950.0	444.3	0.5	0.3	0.9
08/15/2023 01:00	4,352.1	0.0	4,352.1	101,950.0	443.7	0.5	0.3	0.9
08/15/2023 02:00	4,351.2	0.0	4,351.2	101,950.0	443.6	0.5	0.3	0.9
08/15/2023 03:00	4,341.8	0.0	4,341.8	101,950.0	442.6	0.5	0.3	0.9
08/15/2023 04:00	4,343.9	0.0	4,343.9	101,950.0	442.9	0.5	0.3	0.9
08/15/2023 05:00	4,457.4	0.0	4,457.4	101,950.0	454.4	0.5	0.3	0.9
08/15/2023 06:00	4,457.4	0.0	4,457.4	101,950.0	454.4	0.5	0.3	0.9
08/15/2023 07:00	3,911.9	0.0	3,911.9	101,950.0	398.8	0.5	0.2	0.8
08/15/2023 08:00	4,266.4	0.0	4,266.4	101,950.0	435.0	0.5	0.3	0.9
08/15/2023 09:00	4,332.5	0.0	4,332.5	101,950.0	441.7	0.5	0.3	0.9
08/15/2023 10:00	4,134.4	0.0	4,134.4	101,950.0	421.5	0.5	0.3	0.8
08/15/2023 11:00	4,131.9	0.0	4,131.9	101,950.0	421.2	0.5	0.3	0.8
08/15/2023 12:00	4,292.9	0.0	4,292.9	101,950.0	437.7	0.5	0.3	0.9
08/15/2023 13:00	4,422.8	0.0	4,422.8	101,950.0	450.9	0.5	0.3	0.9
08/15/2023 14:00	4,454.8	1,497.1	5,922.0	101,950.0	603.7	0.7	0.4	1.2
08/15/2023 15:00	4,455.7	1,939.9	6,395.6	101,950.0	652.0	0.8	0.4	1.3
08/15/2023 16:00	4,442.9	1,939.7	6,382.6	101,950.0	650.7	0.8	0.4	1.3
08/15/2023 17:00	4,418.2	1,910.2	6,328.4	101,950.0	645.2	0.8	0.4	1.3
08/15/2023 18:00	4,405.9	1,717.6	6,123.5	101,950.0	624.3	0.7	0.4	1.2
08/15/2023 19:00	4,437.4	1,843.6	6,281.0	101,950.0	640.3	0.8	0.4	1.3
08/15/2023 20:00	4,471.7	1,443.4	5,915.1	101,950.0	603.0	0.7	0.4	1.2
08/15/2023 21:00	4,508.6	886.5	5,395.1	101,950.0	550.0	0.7	0.3	1.1
08/15/2023 22:00	4,518.2	1,183.1	5,701.3	101,950.0	581.2	0.7	0.3	1.2
08/15/2023 23:00	4,408.5	368.7	4,603.9	101,950.0	469.4	0.6	0.3	1.0
Average/Sum#:	4,361.5	613.7	4,966.8	101,950.0	506.4	0.6	0.3	1.0
Minimum:	3,911.9	0.0	3,911.9	101,950.0	398.8	0.5	0.2	0.8
Maximum:	4,518.2	1,939.9	6,395.6	101,950.0	652.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2023 00:00	4,500.0	0.0	4,500.0	101,950.0	458.8	0.5	0.3	0.9
08/16/2023 01:00	4,347.8	0.0	4,347.8	101,950.0	443.3	0.5	0.3	0.9
08/16/2023 02:00	4,067.8	0.0	4,067.8	101,950.0	414.7	0.5	0.2	0.8
08/16/2023 03:00	4,063.9	0.0	4,063.9	101,950.0	414.3	0.5	0.2	0.8
08/16/2023 04:00	4,147.2	0.0	4,147.2	101,950.0	422.8	0.5	0.3	0.8
08/16/2023 05:00	4,465.8	0.0	4,465.8	101,950.0	455.3	0.5	0.3	0.9
08/16/2023 06:00	4,489.4	0.0	4,489.4	101,950.0	457.7	0.6	0.3	0.9
08/16/2023 07:00	4,279.6	0.0	4,279.6	101,950.0	436.3	0.5	0.3	0.9
08/16/2023 08:00	4,257.2	0.0	4,257.2	101,950.0	434.0	0.5	0.3	0.9
08/16/2023 09:00	4,114.6	0.0	4,114.6	101,950.0	419.5	0.5	0.3	0.8
08/16/2023 10:00	4,187.9	0.0	4,187.9	101,950.0	427.0	0.5	0.3	0.9
08/16/2023 11:00	4,329.6	5.9	4,329.9	101,950.0	441.4	0.5	0.3	0.9
08/16/2023 12:00	4,436.9	0.0	4,436.9	101,950.0	452.3	0.5	0.3	0.9
08/16/2023 13:00	4,436.9	176.6	4,477.5	101,950.0	456.5	0.6	0.3	0.9
08/16/2023 14:00	4,406.6	1,802.4	6,209.0	101,950.0	633.0	0.8	0.4	1.3
08/16/2023 15:00	4,407.5	1,891.7	6,299.2	101,950.0	642.2	0.8	0.4	1.3
08/16/2023 16:00	4,398.1	1,900.7	6,298.8	101,950.0	642.2	0.8	0.4	1.3
08/16/2023 17:00	4,380.7	1,890.0	6,270.7	101,950.0	639.3	0.8	0.4	1.3
08/16/2023 18:00	4,385.9	1,762.4	6,148.3	101,950.0	626.8	0.8	0.4	1.3
08/16/2023 19:00	4,413.9	1,828.8	6,242.7	101,950.0	636.4	0.8	0.4	1.3
08/16/2023 20:00	4,463.3	1,677.5	6,140.8	101,950.0	626.1	0.8	0.4	1.3
08/16/2023 21:00	4,466.0	1,399.9	5,865.9	101,950.0	598.0	0.7	0.4	1.2
08/16/2023 22:00	4,479.6	1,292.4	5,772.0	101,950.0	588.5	0.7	0.4	1.2
08/16/2023 23:00	4,344.4	6.6	4,344.6	101,950.0	442.9	0.5	0.3	0.9
Average/Sum#:	4,344.6	651.5	4,989.9	101,950.0	508.7	0.6	0.3	1.0
Minimum:	4,063.9	0.0	4,063.9	101,950.0	414.3	0.5	0.2	0.8
Maximum:	4,500.0	1,900.7	6,299.2	101,950.0	642.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2023 00:00	4,439.1	0.0	4,439.1	101,950.0	452.6	0.5	0.3	0.9
08/17/2023 01:00	4,374.9	0.0	4,374.9	101,950.0	446.0	0.5	0.3	0.9
08/17/2023 02:00	4,445.5	0.0	4,445.5	101,950.0	453.2	0.5	0.3	0.9
08/17/2023 03:00	4,477.9	0.0	4,477.9	101,950.0	456.5	0.5	0.3	0.9
08/17/2023 04:00	4,442.0	0.0	4,442.0	101,950.0	452.9	0.5	0.3	0.9
08/17/2023 05:00	4,482.0	0.0	4,482.0	101,950.0	456.9	0.5	0.3	0.9
08/17/2023 06:00	4,465.7	0.0	4,465.7	101,950.0	455.3	0.5	0.3	0.9
08/17/2023 07:00	3,809.2	0.0	3,809.2	101,950.0	388.3	0.5	0.2	0.8
08/17/2023 08:00	3,634.5	0.0	3,634.5	101,950.0	370.5	0.4	0.2	0.7
08/17/2023 09:00	3,629.0	0.0	3,629.0	101,950.0	370.0	0.4	0.2	0.7
08/17/2023 10:00	3,624.1	0.0	3,624.1	101,950.0	369.5	0.4	0.2	0.7
08/17/2023 11:00	3,689.0	0.0	3,689.0	101,950.0	376.1	0.4	0.2	0.8
08/17/2023 12:00	4,149.6	0.0	4,149.6	101,950.0	423.1	0.5	0.3	0.8
08/17/2023 13:00	4,371.3	0.0	4,371.3	101,950.0	445.7	0.5	0.3	0.9
08/17/2023 14:00	3,963.4	0.0	3,963.4	101,950.0	404.1	0.5	0.2	0.8
08/17/2023 15:00	3,700.5	0.0	3,700.5	101,950.0	377.3	0.5	0.2	0.8
08/17/2023 16:00	3,883.3	0.0	3,883.3	101,950.0	395.9	0.5	0.2	0.8
08/17/2023 17:00	4,083.8	165.3	4,121.8	101,950.0	420.2	0.5	0.3	0.9
08/17/2023 18:00	4,422.1	810.3	5,232.4	101,950.0	533.4	0.6	0.3	1.1
08/17/2023 19:00	4,447.3	775.9	5,223.2	101,950.0	532.5	0.6	0.3	1.1
08/17/2023 20:00	4,505.3	676.6	5,181.9	101,950.0	528.3	0.6	0.3	1.1
08/17/2023 21:00	3,906.0	5.4	3,906.2	101,950.0	398.2	0.5	0.2	0.8
08/17/2023 22:00	4,165.7	0.0	4,165.7	101,950.0	424.7	0.5	0.3	0.8
08/17/2023 23:00	4,080.8	0.0	4,080.8	101,950.0	416.0	0.5	0.2	0.8
Average/Sum#:	4,133.0	101.4	4,228.9	101,950.0	431.1	0.5	0.3	0.9
Minimum:	3,624.1	0.0	3,624.1	101,950.0	369.5	0.4	0.2	0.7
Maximum:	4,505.3	810.3	5,232.4	101,950.0	533.4	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2023 00:00	3,817.0	0.0	3,817.0	101,950.0	389.1	0.5	0.2	0.8
08/18/2023 01:00	3,628.4	0.0	3,628.4	101,950.0	369.9	0.4	0.2	0.7
08/18/2023 02:00	3,629.1	0.0	3,629.1	101,950.0	370.0	0.4	0.2	0.7
08/18/2023 03:00	3,632.7	0.0	3,632.7	101,950.0	370.4	0.4	0.2	0.7
08/18/2023 04:00	3,628.7	0.0	3,628.7	101,950.0	369.9	0.4	0.2	0.7
08/18/2023 05:00	3,645.3	0.0	3,645.3	101,950.0	371.6	0.4	0.2	0.7
08/18/2023 06:00	3,877.3	0.0	3,877.3	101,950.0	395.3	0.5	0.2	0.8
08/18/2023 07:00	3,670.3	0.0	3,670.3	101,950.0	374.2	0.5	0.2	0.7
08/18/2023 08:00	3,646.0	0.0	3,646.0	101,950.0	371.7	0.4	0.2	0.7
08/18/2023 09:00	3,641.6	0.0	3,641.6	101,950.0	371.3	0.4	0.2	0.7
08/18/2023 10:00	3,637.3	0.0	3,637.3	101,950.0	370.8	0.4	0.2	0.7
08/18/2023 11:00	3,631.0	0.0	3,631.0	101,950.0	370.2	0.4	0.2	0.7
08/18/2023 12:00	3,622.9	0.0	3,622.9	101,950.0	369.4	0.4	0.2	0.7
08/18/2023 13:00	3,640.2	0.0	3,640.2	101,950.0	371.1	0.4	0.2	0.7
08/18/2023 14:00	3,624.8	0.0	3,624.8	101,950.0	369.5	0.4	0.2	0.7
08/18/2023 15:00	3,607.7	0.0	3,607.7	101,950.0	367.8	0.4	0.2	0.7
08/18/2023 16:00	3,634.0	0.0	3,634.0	101,950.0	370.5	0.4	0.2	0.7
08/18/2023 17:00	3,651.3	0.0	3,651.3	101,950.0	372.3	0.4	0.2	0.7
08/18/2023 18:00	3,608.0	0.0	3,608.0	101,950.0	367.8	0.4	0.2	0.7
08/18/2023 19:00	3,604.8	0.0	3,604.8	101,950.0	367.5	0.4	0.2	0.7
08/18/2023 20:00	3,607.5	0.0	3,607.5	101,950.0	367.8	0.4	0.2	0.7
08/18/2023 21:00	3,613.9	0.0	3,613.9	101,950.0	368.4	0.4	0.2	0.7
08/18/2023 22:00	3,617.2	0.0	3,617.2	101,950.0	368.8	0.4	0.2	0.7
08/18/2023 23:00	3,631.0	0.0	3,631.0	101,950.0	370.2	0.4	0.2	0.7
Average/Sum#:	3,647.8	0.0	3,647.8	101,950.0	371.9	0.4	0.2	0.7
Minimum:	3,604.8	0.0	3,604.8	101,950.0	367.5	0.4	0.2	0.7
Maximum:	3,877.3	0.0	3,877.3	101,950.0	395.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2023 00:00	3,756.9	0.0	3,756.9	101,950.0	383.0	0.5	0.2	0.8
08/19/2023 01:00	3,628.0	0.0	3,628.0	101,950.0	369.9	0.4	0.2	0.7
08/19/2023 02:00	3,626.2	0.0	3,626.2	101,950.0	369.7	0.4	0.2	0.7
08/19/2023 03:00	3,628.3	0.0	3,628.3	101,950.0	369.9	0.4	0.2	0.7
08/19/2023 04:00	3,629.5	0.0	3,629.5	101,950.0	370.0	0.4	0.2	0.7
08/19/2023 05:00	3,630.5	0.0	3,630.5	101,950.0	370.1	0.4	0.2	0.7
08/19/2023 06:00	3,627.2	0.0	3,627.2	101,950.0	369.8	0.4	0.2	0.7
08/19/2023 07:00	3,627.0	0.0	3,627.0	101,950.0	369.8	0.4	0.2	0.7
08/19/2023 08:00	3,621.1	0.0	3,621.1	101,950.0	369.2	0.4	0.2	0.7
08/19/2023 09:00	3,614.9	0.0	3,614.9	101,950.0	368.5	0.4	0.2	0.7
08/19/2023 10:00	3,607.9	0.0	3,607.9	101,950.0	367.8	0.4	0.2	0.7
08/19/2023 11:00	3,618.3	0.0	3,618.3	101,950.0	368.9	0.4	0.2	0.7
08/19/2023 12:00	3,628.9	0.0	3,628.9	101,950.0	370.0	0.4	0.2	0.7
08/19/2023 13:00	3,628.5	0.0	3,628.5	101,950.0	369.9	0.4	0.2	0.7
08/19/2023 14:00	3,619.9	0.0	3,619.9	101,950.0	369.0	0.4	0.2	0.7
08/19/2023 15:00	3,621.4	0.0	3,621.4	101,950.0	369.2	0.4	0.2	0.7
08/19/2023 16:00	3,619.2	0.0	3,619.2	101,950.0	369.0	0.4	0.2	0.7
08/19/2023 17:00	3,596.2	0.0	3,596.2	101,950.0	366.6	0.4	0.2	0.7
08/19/2023 18:00	3,596.8	0.0	3,596.8	101,950.0	366.7	0.4	0.2	0.7
08/19/2023 19:00	3,604.9	0.0	3,604.9	101,950.0	367.5	0.4	0.2	0.7
08/19/2023 20:00	3,608.0	0.0	3,608.0	101,950.0	367.8	0.4	0.2	0.7
08/19/2023 21:00	3,608.9	0.0	3,608.9	101,950.0	367.9	0.4	0.2	0.7
08/19/2023 22:00	3,629.1	0.0	3,629.1	101,950.0	370.0	0.4	0.2	0.7
08/19/2023 23:00	3,729.2	0.0	3,729.2	101,950.0	380.2	0.5	0.2	0.8
Average/Sum#:	3,629.5	0.0	3,629.5	101,950.0	370.0	0.4	0.2	0.7
Minimum:	3,596.2	0.0	3,596.2	101,950.0	366.6	0.4	0.2	0.7
Maximum:	3,756.9	0.0	3,756.9	101,950.0	383.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2023 00:00	3,877.5	0.0	3,877.5	101,950.0	395.3	0.5	0.2	0.8
08/20/2023 01:00	3,758.2	0.0	3,758.2	101,950.0	383.1	0.5	0.2	0.8
08/20/2023 02:00	3,832.3	0.0	3,832.3	101,950.0	390.7	0.5	0.2	0.8
08/20/2023 03:00	3,839.4	0.0	3,839.4	101,950.0	391.4	0.5	0.2	0.8
08/20/2023 04:00	3,753.5	0.0	3,753.5	101,950.0	382.7	0.5	0.2	0.8
08/20/2023 05:00	3,626.1	0.0	3,626.1	101,950.0	369.7	0.4	0.2	0.7
08/20/2023 06:00	3,621.4	0.0	3,621.4	101,950.0	369.2	0.4	0.2	0.7
08/20/2023 07:00	3,618.7	0.0	3,618.7	101,950.0	368.9	0.4	0.2	0.7
08/20/2023 08:00	3,613.3	0.0	3,613.3	101,950.0	368.4	0.4	0.2	0.7
08/20/2023 09:00	3,610.9	0.0	3,610.9	101,950.0	368.1	0.4	0.2	0.7
08/20/2023 10:00	3,612.6	0.0	3,612.6	101,950.0	368.3	0.4	0.2	0.7
08/20/2023 11:00	3,608.8	0.0	3,608.8	101,950.0	367.9	0.4	0.2	0.7
08/20/2023 12:00	3,605.3	0.0	3,605.3	101,950.0	367.6	0.4	0.2	0.7
08/20/2023 13:00	3,610.6	0.0	3,610.6	101,950.0	368.1	0.4	0.2	0.7
08/20/2023 14:00	3,609.6	0.0	3,609.6	101,950.0	368.0	0.4	0.2	0.7
08/20/2023 15:00	3,612.7	0.0	3,612.7	101,950.0	368.3	0.4	0.2	0.7
08/20/2023 16:00	3,618.9	0.0	3,618.9	101,950.0	368.9	0.4	0.2	0.7
08/20/2023 17:00	3,607.3	0.0	3,607.3	101,950.0	367.8	0.4	0.2	0.7
08/20/2023 18:00	3,606.5	0.0	3,606.5	101,950.0	367.7	0.4	0.2	0.7
08/20/2023 19:00	3,605.7	0.0	3,605.7	101,950.0	367.6	0.4	0.2	0.7
08/20/2023 20:00	3,609.1	0.0	3,609.1	101,950.0	367.9	0.4	0.2	0.7
08/20/2023 21:00	3,609.5	0.0	3,609.5	101,950.0	368.0	0.4	0.2	0.7
08/20/2023 22:00	3,608.3	0.0	3,608.3	101,950.0	367.9	0.4	0.2	0.7
08/20/2023 23:00	3,609.3	0.0	3,609.3	101,950.0	368.0	0.4	0.2	0.7
Average/Sum#:	3,653.6	0.0	3,653.6	101,950.0	372.5	0.4	0.2	0.7
Minimum:	3,605.3	0.0	3,605.3	101,950.0	367.6	0.4	0.2	0.7
Maximum:	3,877.5	0.0	3,877.5	101,950.0	395.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2023 00:00	3,603.1	0.0	3,603.1	101,950.0	367.3	0.4	0.2	0.7
08/21/2023 01:00	3,597.9	0.0	3,597.9	101,950.0	366.8	0.4	0.2	0.7
08/21/2023 02:00	3,610.9	0.0	3,610.9	101,950.0	368.1	0.4	0.2	0.7
08/21/2023 03:00	3,612.3	0.0	3,612.3	101,950.0	368.3	0.4	0.2	0.7
08/21/2023 04:00	3,523.9	0.0	3,523.9	101,950.0	359.3	0.4	0.2	0.7
08/21/2023 05:00	1,337.0	0.0	1,337.0	101,950.0	136.3	0.0	0.0	0.0
08/21/2023 06:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 07:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 08:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 09:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 10:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 11:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 12:00	0.0	0.0	0.0	101,950.0	0.0	0.0	0.0	0.0
08/21/2023 13:00	2,752.7	0.0	2,752.7	101,950.0	280.6	0.0	0.0	0.0
08/21/2023 14:00	3,707.8	0.0	3,707.8	101,950.0	378.0	0.5	0.2	0.8
08/21/2023 15:00	3,675.0	0.0	3,675.0	101,950.0	374.7	0.5	0.2	0.8
08/21/2023 16:00	3,665.9	0.0	3,665.9	101,950.0	373.7	0.4	0.2	0.7
08/21/2023 17:00	3,612.8	0.0	3,612.8	101,950.0	368.3	0.4	0.2	0.7
08/21/2023 18:00	3,614.9	0.0	3,614.9	101,950.0	368.5	0.4	0.2	0.7
08/21/2023 19:00	3,622.3	0.0	3,622.3	101,950.0	369.3	0.4	0.2	0.7
08/21/2023 20:00	3,624.0	0.0	3,624.0	101,950.0	369.5	0.4	0.2	0.7
08/21/2023 21:00	3,628.9	0.0	3,628.9	101,950.0	370.0	0.4	0.2	0.7
08/21/2023 22:00	3,630.5	0.0	3,630.5	101,950.0	370.1	0.4	0.2	0.7
08/21/2023 23:00	3,630.2	0.0	3,630.2	101,950.0	370.1	0.4	0.2	0.7
Average/Sum#:	3,438.2	0.0	3,438.2	101,950.0	350.5	0.4	0.2	0.7
Minimum:	1,337.0	0.0	1,337.0	101,950.0	136.3	0.4	0.2	0.7
Maximum:	3,707.8	0.0	3,707.8	101,950.0	378.0	0.5	0.2	0.8
%SI	29.17	29.17	29.17	0.00	29.17	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2023 00:00	3,630.4	0.0	3,630.4	101,950.0	370.1	0.4	0.2	0.7
08/22/2023 01:00	3,631.4	0.0	3,631.4	101,950.0	370.2	0.4	0.2	0.7
08/22/2023 02:00	3,630.6	0.0	3,630.6	101,950.0	370.1	0.4	0.2	0.7
08/22/2023 03:00	3,632.1	0.0	3,632.1	101,950.0	370.3	0.4	0.2	0.7
08/22/2023 04:00	3,630.9	0.0	3,630.9	101,950.0	370.2	0.4	0.2	0.7
08/22/2023 05:00	3,634.8	0.0	3,634.8	101,950.0	370.6	0.4	0.2	0.7
08/22/2023 06:00	3,705.4	0.0	3,705.4	101,950.0	377.8	0.5	0.2	0.8
08/22/2023 07:00	3,634.3	0.0	3,634.3	101,950.0	370.5	0.4	0.2	0.7
08/22/2023 08:00	3,632.4	0.0	3,632.4	101,950.0	370.3	0.4	0.2	0.7
08/22/2023 09:00	3,628.3	0.0	3,628.3	101,950.0	369.9	0.4	0.2	0.7
08/22/2023 10:00	3,630.5	0.0	3,630.5	101,950.0	370.1	0.4	0.2	0.7
08/22/2023 11:00	3,626.9	0.0	3,626.9	101,950.0	369.8	0.4	0.2	0.7
08/22/2023 12:00	3,617.2	0.0	3,617.2	101,950.0	368.8	0.4	0.2	0.7
08/22/2023 13:00	3,614.9	0.0	3,614.9	101,950.0	368.5	0.4	0.2	0.7
08/22/2023 14:00	3,613.4	0.0	3,613.4	101,950.0	368.4	0.4	0.2	0.7
08/22/2023 15:00	3,609.2	0.0	3,609.2	101,950.0	368.0	0.4	0.2	0.7
08/22/2023 16:00	3,611.2	0.0	3,611.2	101,950.0	368.2	0.4	0.2	0.7
08/22/2023 17:00	3,687.9	0.0	3,687.9	101,950.0	376.0	0.5	0.2	0.8
08/22/2023 18:00	3,824.5	0.0	3,824.5	101,950.0	389.9	0.5	0.2	0.8
08/22/2023 19:00	4,297.0	2.1	4,297.1	101,950.0	438.1	0.5	0.3	0.9
08/22/2023 20:00	3,794.7	0.0	3,794.7	101,950.0	386.9	0.5	0.2	0.8
08/22/2023 21:00	4,046.9	0.0	4,046.9	101,950.0	412.6	0.5	0.2	0.8
08/22/2023 22:00	3,877.1	0.0	3,877.1	101,950.0	395.3	0.5	0.2	0.8
08/22/2023 23:00	3,713.7	0.0	3,713.7	101,950.0	378.6	0.5	0.2	0.8
Average/Sum#:	3,706.5	0.1	3,706.5	101,950.0	377.9	0.4	0.2	0.7
Minimum:	3,609.2	0.0	3,609.2	101,950.0	368.0	0.4	0.2	0.7
Maximum:	4,297.0	2.1	4,297.1	101,950.0	438.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2023 00:00	3,616.9	0.0	3,616.9	101,950.0	368.7	0.4	0.2	0.7
08/23/2023 01:00	3,618.7	0.0	3,618.7	101,950.0	368.9	0.4	0.2	0.7
08/23/2023 02:00	3,621.9	0.0	3,621.9	101,950.0	369.3	0.4	0.2	0.7
08/23/2023 03:00	3,623.6	0.0	3,623.6	101,950.0	369.4	0.4	0.2	0.7
08/23/2023 04:00	3,626.9	0.0	3,626.9	101,950.0	369.8	0.4	0.2	0.7
08/23/2023 05:00	3,795.7	0.0	3,795.7	101,950.0	387.0	0.5	0.2	0.8
08/23/2023 06:00	4,011.5	0.0	4,011.5	101,950.0	409.0	0.5	0.2	0.8
08/23/2023 07:00	3,668.9	0.0	3,668.9	101,950.0	374.0	0.4	0.2	0.7
08/23/2023 08:00	3,632.0	0.0	3,632.0	101,950.0	370.3	0.4	0.2	0.7
08/23/2023 09:00	3,627.0	0.0	3,627.0	101,950.0	369.8	0.4	0.2	0.7
08/23/2023 10:00	3,619.3	0.0	3,619.3	101,950.0	369.0	0.4	0.2	0.7
08/23/2023 11:00	3,611.8	0.0	3,611.8	101,950.0	368.2	0.4	0.2	0.7
08/23/2023 12:00	3,610.0	0.0	3,610.0	101,950.0	368.0	0.4	0.2	0.7
08/23/2023 13:00	3,603.0	0.0	3,603.0	101,950.0	367.3	0.4	0.2	0.7
08/23/2023 14:00	3,941.9	0.0	3,941.9	101,950.0	401.9	0.5	0.2	0.8
08/23/2023 15:00	4,482.1	0.0	4,482.1	101,950.0	457.0	0.5	0.3	0.9
08/23/2023 16:00	4,478.1	0.0	4,478.1	101,950.0	456.5	0.5	0.3	0.9
08/23/2023 17:00	4,352.0	288.6	4,490.5	101,950.0	457.8	0.6	0.3	0.9
08/23/2023 18:00	4,515.4	1,146.7	5,662.1	101,950.0	577.3	0.7	0.3	1.2
08/23/2023 19:00	4,527.7	1,401.1	5,928.8	101,950.0	604.4	0.7	0.4	1.2
08/23/2023 20:00	4,540.8	560.1	5,100.9	101,950.0	520.0	0.6	0.3	1.0
08/23/2023 21:00	4,532.8	419.2	4,855.6	101,950.0	495.0	0.6	0.3	1.0
08/23/2023 22:00	4,432.4	0.0	4,432.4	101,950.0	451.9	0.5	0.3	0.9
08/23/2023 23:00	4,142.4	0.0	4,142.4	101,950.0	422.3	0.5	0.3	0.8
Average/Sum#:	3,968.0	159.0	4,116.8	101,950.0	419.7	0.5	0.2	0.8
Minimum:	3,603.0	0.0	3,603.0	101,950.0	367.3	0.4	0.2	0.7
Maximum:	4,540.8	1,401.1	5,928.8	101,950.0	604.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2023 00:00	4,120.4	0.0	4,120.4	101,950.0	420.1	0.5	0.3	0.8
08/24/2023 01:00	3,634.1	0.0	3,634.1	101,950.0	370.5	0.4	0.2	0.7
08/24/2023 02:00	3,617.0	0.0	3,617.0	101,950.0	368.8	0.4	0.2	0.7
08/24/2023 03:00	3,617.4	0.0	3,617.4	101,950.0	368.8	0.4	0.2	0.7
08/24/2023 04:00	3,897.1	0.0	3,897.1	101,950.0	397.3	0.5	0.2	0.8
08/24/2023 05:00	4,155.7	0.0	4,155.7	101,950.0	423.7	0.5	0.3	0.8
08/24/2023 06:00	4,447.9	0.0	4,447.9	101,950.0	453.5	0.5	0.3	0.9
08/24/2023 07:00	3,849.6	0.0	3,849.6	101,950.0	392.5	0.5	0.2	0.8
08/24/2023 08:00	3,621.8	0.0	3,621.8	101,950.0	369.2	0.4	0.2	0.7
08/24/2023 09:00	3,614.8	0.0	3,614.8	101,950.0	368.5	0.4	0.2	0.7
08/24/2023 10:00	3,608.2	0.0	3,608.2	101,950.0	367.9	0.4	0.2	0.7
08/24/2023 11:00	3,607.6	0.0	3,607.6	101,950.0	367.8	0.4	0.2	0.7
08/24/2023 12:00	3,608.4	0.0	3,608.4	101,950.0	367.9	0.4	0.2	0.7
08/24/2023 13:00	3,605.2	0.0	3,605.2	101,950.0	367.6	0.4	0.2	0.7
08/24/2023 14:00	3,598.2	0.0	3,598.2	101,950.0	366.8	0.4	0.2	0.7
08/24/2023 15:00	3,597.8	0.0	3,597.8	101,950.0	366.8	0.4	0.2	0.7
08/24/2023 16:00	3,598.0	0.0	3,598.0	101,950.0	366.8	0.4	0.2	0.7
08/24/2023 17:00	3,595.8	0.0	3,595.8	101,950.0	366.6	0.4	0.2	0.7
08/24/2023 18:00	3,739.6	0.0	3,739.6	101,950.0	381.3	0.5	0.2	0.8
08/24/2023 19:00	3,702.4	0.0	3,702.4	101,950.0	377.5	0.5	0.2	0.8
08/24/2023 20:00	3,628.9	0.0	3,628.9	101,950.0	370.0	0.4	0.2	0.7
08/24/2023 21:00	3,863.5	0.0	3,863.5	101,950.0	393.9	0.5	0.2	0.8
08/24/2023 22:00	3,914.6	0.0	3,914.6	101,950.0	399.1	0.5	0.2	0.8
08/24/2023 23:00	3,657.4	0.0	3,657.4	101,950.0	372.9	0.4	0.2	0.7
Average/Sum#:	3,745.9	0.0	3,745.9	101,950.0	381.9	0.4	0.2	0.7
Minimum:	3,595.8	0.0	3,595.8	101,950.0	366.6	0.4	0.2	0.7
Maximum:	4,447.9	0.0	4,447.9	101,950.0	453.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2023 00:00	3,909.8	0.0	3,909.8	101,950.0	398.6	0.5	0.2	0.8
08/25/2023 01:00	3,701.1	0.0	3,701.1	101,950.0	377.3	0.5	0.2	0.8
08/25/2023 02:00	3,653.2	0.0	3,653.2	101,950.0	372.4	0.4	0.2	0.7
08/25/2023 03:00	3,642.0	0.0	3,642.0	101,950.0	371.3	0.4	0.2	0.7
08/25/2023 04:00	3,748.1	0.0	3,748.1	101,950.0	382.1	0.5	0.2	0.8
08/25/2023 05:00	4,393.4	0.0	4,393.4	101,950.0	447.9	0.5	0.3	0.9
08/25/2023 06:00	4,261.3	0.0	4,261.3	101,950.0	434.4	0.5	0.3	0.9
08/25/2023 07:00	3,659.3	0.0	3,659.3	101,950.0	373.1	0.4	0.2	0.7
08/25/2023 08:00	3,638.1	0.0	3,638.1	101,950.0	370.9	0.4	0.2	0.7
08/25/2023 09:00	3,635.7	0.0	3,635.7	101,950.0	370.7	0.4	0.2	0.7
08/25/2023 10:00	3,631.1	0.0	3,631.1	101,950.0	370.2	0.4	0.2	0.7
08/25/2023 11:00	3,627.8	0.0	3,627.8	101,950.0	369.9	0.4	0.2	0.7
08/25/2023 12:00	3,627.9	0.0	3,627.9	101,950.0	369.9	0.4	0.2	0.7
08/25/2023 13:00	3,622.6	0.0	3,622.6	101,950.0	369.3	0.4	0.2	0.7
08/25/2023 14:00	3,612.9	0.0	3,612.9	101,950.0	368.3	0.4	0.2	0.7
08/25/2023 15:00	3,609.7	0.0	3,609.7	101,950.0	368.0	0.4	0.2	0.7
08/25/2023 16:00	3,610.1	0.0	3,610.1	101,950.0	368.0	0.4	0.2	0.7
08/25/2023 17:00	3,606.1	0.0	3,606.1	101,950.0	367.6	0.4	0.2	0.7
08/25/2023 18:00	3,609.4	0.0	3,609.4	101,950.0	368.0	0.4	0.2	0.7
08/25/2023 19:00	3,614.0	0.0	3,614.0	101,950.0	368.4	0.4	0.2	0.7
08/25/2023 20:00	3,618.4	0.0	3,618.4	101,950.0	368.9	0.4	0.2	0.7
08/25/2023 21:00	3,643.2	0.0	3,643.2	101,950.0	371.4	0.4	0.2	0.7
08/25/2023 22:00	3,630.1	0.0	3,630.1	101,950.0	370.1	0.4	0.2	0.7
08/25/2023 23:00	3,640.0	0.0	3,640.0	101,950.0	371.1	0.4	0.2	0.7
Average/Sum#:	3,706.1	0.0	3,706.1	101,950.0	377.8	0.4	0.2	0.7
Minimum:	3,606.1	0.0	3,606.1	101,950.0	367.6	0.4	0.2	0.7
Maximum:	4,393.4	0.0	4,393.4	101,950.0	447.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2023 00:00	4,138.5	0.0	4,138.5	101,950.0	421.9	0.5	0.3	0.8
08/26/2023 01:00	4,174.5	0.0	4,174.5	101,950.0	425.6	0.5	0.3	0.9
08/26/2023 02:00	3,821.4	0.0	3,821.4	101,950.0	389.6	0.5	0.2	0.8
08/26/2023 03:00	3,918.1	0.0	3,918.1	101,950.0	399.5	0.5	0.2	0.8
08/26/2023 04:00	3,890.0	0.0	3,890.0	101,950.0	396.6	0.5	0.2	0.8
08/26/2023 05:00	4,139.2	0.0	4,139.2	101,950.0	422.0	0.5	0.3	0.8
08/26/2023 06:00	4,186.0	0.0	4,186.0	101,950.0	426.8	0.5	0.3	0.9
08/26/2023 07:00	3,651.4	0.0	3,651.4	101,950.0	372.3	0.4	0.2	0.7
08/26/2023 08:00	3,650.2	0.0	3,650.2	101,950.0	372.1	0.4	0.2	0.7
08/26/2023 09:00	3,646.2	0.0	3,646.2	101,950.0	371.7	0.4	0.2	0.7
08/26/2023 10:00	3,640.5	0.0	3,640.5	101,950.0	371.1	0.4	0.2	0.7
08/26/2023 11:00	3,634.9	0.0	3,634.9	101,950.0	370.6	0.4	0.2	0.7
08/26/2023 12:00	3,625.7	0.0	3,625.7	101,950.0	369.6	0.4	0.2	0.7
08/26/2023 13:00	3,619.2	0.0	3,619.2	101,950.0	369.0	0.4	0.2	0.7
08/26/2023 14:00	3,613.6	0.0	3,613.6	101,950.0	368.4	0.4	0.2	0.7
08/26/2023 15:00	3,608.1	0.0	3,608.1	101,950.0	367.8	0.4	0.2	0.7
08/26/2023 16:00	3,608.3	0.0	3,608.3	101,950.0	367.9	0.4	0.2	0.7
08/26/2023 17:00	3,799.1	0.0	3,799.1	101,950.0	387.3	0.5	0.2	0.8
08/26/2023 18:00	3,782.4	0.0	3,782.4	101,950.0	385.6	0.5	0.2	0.8
08/26/2023 19:00	3,645.9	0.0	3,645.9	101,950.0	371.7	0.4	0.2	0.7
08/26/2023 20:00	3,715.5	0.0	3,715.5	101,950.0	378.8	0.5	0.2	0.8
08/26/2023 21:00	3,713.3	0.0	3,713.3	101,950.0	378.6	0.5	0.2	0.8
08/26/2023 22:00	3,774.8	0.0	3,774.8	101,950.0	384.8	0.5	0.2	0.8
08/26/2023 23:00	3,782.9	0.0	3,782.9	101,950.0	385.7	0.5	0.2	0.8
Average/Sum#:	3,782.5	0.0	3,782.5	101,950.0	385.6	0.5	0.2	0.8
Minimum:	3,608.1	0.0	3,608.1	101,950.0	367.8	0.4	0.2	0.7
Maximum:	4,186.0	0.0	4,186.0	101,950.0	426.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2023 00:00	3,894.8	0.0	3,894.8	101,950.0	397.1	0.5	0.2	0.8
08/27/2023 01:00	3,756.3	0.0	3,756.3	101,950.0	383.0	0.5	0.2	0.8
08/27/2023 02:00	3,659.4	0.0	3,659.4	101,950.0	373.1	0.4	0.2	0.7
08/27/2023 03:00	3,724.5	0.0	3,724.5	101,950.0	379.7	0.5	0.2	0.8
08/27/2023 04:00	3,676.7	0.0	3,676.7	101,950.0	374.8	0.5	0.2	0.7
08/27/2023 05:00	3,982.1	0.0	3,982.1	101,950.0	406.0	0.5	0.2	0.8
08/27/2023 06:00	4,124.2	0.0	4,124.2	101,950.0	420.5	0.5	0.3	0.8
08/27/2023 07:00	3,647.1	0.0	3,647.1	101,950.0	371.8	0.4	0.2	0.7
08/27/2023 08:00	3,643.6	0.0	3,643.6	101,950.0	371.5	0.4	0.2	0.7
08/27/2023 09:00	3,636.8	0.0	3,636.8	101,950.0	370.8	0.4	0.2	0.7
08/27/2023 10:00	3,631.3	0.0	3,631.3	101,950.0	370.2	0.4	0.2	0.7
08/27/2023 11:00	3,624.0	0.0	3,624.0	101,950.0	369.5	0.4	0.2	0.7
08/27/2023 12:00	3,624.8	0.0	3,624.8	101,950.0	369.5	0.4	0.2	0.7
08/27/2023 13:00	3,639.4	0.0	3,639.4	101,950.0	371.0	0.4	0.2	0.7
08/27/2023 14:00	3,632.7	0.0	3,632.7	101,950.0	370.4	0.4	0.2	0.7
08/27/2023 15:00	3,688.9	0.0	3,688.9	101,950.0	376.1	0.5	0.2	0.8
08/27/2023 16:00	3,723.4	0.0	3,723.4	101,950.0	379.6	0.5	0.2	0.8
08/27/2023 17:00	3,957.1	0.0	3,957.1	101,950.0	403.4	0.5	0.2	0.8
08/27/2023 18:00	3,625.2	0.0	3,625.2	101,950.0	369.6	0.4	0.2	0.7
08/27/2023 19:00	3,978.0	0.0	3,978.0	101,950.0	405.6	0.5	0.2	0.8
08/27/2023 20:00	4,445.8	0.0	4,445.8	101,950.0	453.2	0.5	0.3	0.9
08/27/2023 21:00	4,451.8	0.0	4,451.8	101,950.0	453.9	0.5	0.3	0.9
08/27/2023 22:00	4,408.4	0.0	4,408.4	101,950.0	449.4	0.5	0.3	0.9
08/27/2023 23:00	4,015.3	0.0	4,015.3	101,950.0	409.4	0.5	0.2	0.8
Average/Sum#:	3,841.3	0.0	3,841.3	101,950.0	391.6	0.5	0.2	0.8
Minimum:	3,624.0	0.0	3,624.0	101,950.0	369.5	0.4	0.2	0.7
Maximum:	4,451.8	0.0	4,451.8	101,950.0	453.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2023 00:00	3,789.1	0.0	3,789.1	101,950.0	386.3	0.5	0.2	0.8
08/28/2023 01:00	3,626.6	0.0	3,626.6	101,950.0	369.7	0.4	0.2	0.7
08/28/2023 02:00	3,629.8	0.0	3,629.8	101,950.0	370.1	0.4	0.2	0.7
08/28/2023 03:00	3,631.3	0.0	3,631.3	101,950.0	370.2	0.4	0.2	0.7
08/28/2023 04:00	3,650.8	0.0	3,650.8	101,950.0	372.2	0.4	0.2	0.7
08/28/2023 05:00	4,284.4	0.0	4,284.4	101,950.0	436.8	0.5	0.3	0.9
08/28/2023 06:00	4,645.3	0.0	4,645.3	101,950.0	473.6	0.6	0.3	0.9
08/28/2023 07:00	3,968.4	0.0	3,968.4	101,950.0	404.6	0.5	0.2	0.8
08/28/2023 08:00	3,636.4	0.0	3,636.4	101,950.0	370.7	0.4	0.2	0.7
08/28/2023 09:00	3,634.3	0.0	3,634.3	101,950.0	370.5	0.4	0.2	0.7
08/28/2023 10:00	3,626.2	0.0	3,626.2	101,950.0	369.7	0.4	0.2	0.7
08/28/2023 11:00	3,633.2	0.0	3,633.2	101,950.0	370.4	0.4	0.2	0.7
08/28/2023 12:00	3,689.1	0.0	3,689.1	101,950.0	376.1	0.5	0.2	0.8
08/28/2023 13:00	4,014.6	0.0	4,014.6	101,950.0	409.3	0.5	0.2	0.8
08/28/2023 14:00	4,367.6	0.0	4,367.6	101,950.0	445.3	0.5	0.3	0.9
08/28/2023 15:00	4,407.8	0.0	4,407.8	101,950.0	449.4	0.5	0.3	0.9
08/28/2023 16:00	4,233.2	0.0	4,233.2	101,950.0	431.6	0.5	0.3	0.9
08/28/2023 17:00	3,615.6	0.0	3,615.6	101,950.0	368.6	0.4	0.2	0.7
08/28/2023 18:00	3,917.7	5.2	3,917.9	101,950.0	399.4	0.5	0.2	0.8
08/28/2023 19:00	4,538.2	589.5	5,127.7	101,950.0	522.8	0.6	0.3	1.0
08/28/2023 20:00	4,282.5	260.3	4,417.9	101,950.0	450.4	0.6	0.3	0.9
08/28/2023 21:00	3,835.2	0.0	3,835.2	101,950.0	391.0	0.5	0.2	0.8
08/28/2023 22:00	3,894.5	0.0	3,894.5	101,950.0	397.0	0.5	0.2	0.8
08/28/2023 23:00	3,720.3	0.0	3,720.3	101,950.0	379.3	0.5	0.2	0.8
Average/Sum#:	3,928.0	35.6	3,958.2	101,950.0	403.5	0.5	0.2	0.8
Minimum:	3,615.6	0.0	3,615.6	101,950.0	368.6	0.4	0.2	0.7
Maximum:	4,645.3	589.5	5,127.7	101,950.0	522.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2023 00:00	3,902.5	0.0	3,902.5	101,950.0	397.9	0.5	0.2	0.8
08/29/2023 01:00	4,236.6	0.0	4,236.6	101,950.0	431.9	0.5	0.3	0.9
08/29/2023 02:00	4,121.7	0.0	4,121.7	101,950.0	420.2	0.5	0.3	0.8
08/29/2023 03:00	4,026.2	0.0	4,026.2	101,950.0	410.5	0.5	0.2	0.8
08/29/2023 04:00	4,064.2	0.0	4,064.2	101,950.0	414.3	0.5	0.2	0.8
08/29/2023 05:00	4,357.7	0.0	4,357.7	101,950.0	444.3	0.5	0.3	0.9
08/29/2023 06:00	4,338.2	0.0	4,338.2	101,950.0	442.3	0.5	0.3	0.9
08/29/2023 07:00	4,761.1	93.4	4,831.2	101,950.0	492.5	0.6	0.3	1.0
08/29/2023 08:00	4,739.9	1,143.6	5,883.5	101,950.0	599.8	0.7	0.4	1.2
08/29/2023 09:00	4,721.8	1,474.0	6,195.8	101,950.0	631.7	0.8	0.4	1.3
08/29/2023 10:00	4,692.3	1,495.1	6,187.4	101,950.0	630.8	0.8	0.4	1.3
08/29/2023 11:00	4,665.5	1,532.7	6,198.2	101,950.0	631.9	0.8	0.4	1.3
08/29/2023 12:00	4,630.8	1,586.5	6,217.3	101,950.0	633.9	0.8	0.4	1.3
08/29/2023 13:00	4,599.5	1,637.9	6,237.4	101,950.0	635.9	0.8	0.4	1.3
08/29/2023 14:00	4,577.9	1,680.2	6,258.1	101,950.0	638.0	0.8	0.4	1.3
08/29/2023 15:00	4,553.0	1,706.6	6,259.6	101,950.0	638.2	0.8	0.4	1.3
08/29/2023 16:00	4,533.0	1,733.1	6,266.1	101,950.0	638.8	0.8	0.4	1.3
08/29/2023 17:00	4,508.7	300.3	4,703.9	101,950.0	479.6	0.6	0.3	1.0
08/29/2023 18:00	4,541.2	567.1	5,108.3	101,950.0	520.8	0.6	0.3	1.0
08/29/2023 19:00	4,288.2	290.4	4,477.0	101,950.0	456.4	0.6	0.3	0.9
08/29/2023 20:00	3,604.4	0.0	3,604.4	101,950.0	367.5	0.4	0.2	0.7
08/29/2023 21:00	3,603.6	0.0	3,603.6	101,950.0	367.4	0.4	0.2	0.7
08/29/2023 22:00	3,606.0	0.0	3,606.0	101,950.0	367.6	0.4	0.2	0.7
08/29/2023 23:00	3,611.1	0.0	3,611.1	101,950.0	368.2	0.4	0.2	0.7
Average/Sum#:	4,303.5	635.0	4,929.0	101,950.0	502.5	0.6	0.3	1.0
Minimum:	3,603.6	0.0	3,603.6	101,950.0	367.4	0.4	0.2	0.7
Maximum:	4,761.1	1,733.1	6,266.1	101,950.0	638.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2023 00:00	3,607.9	0.0	3,607.9	101,950.0	367.8	0.4	0.2	0.7
08/30/2023 01:00	3,609.0	0.0	3,609.0	101,950.0	367.9	0.4	0.2	0.7
08/30/2023 02:00	3,608.7	0.0	3,608.7	101,950.0	367.9	0.4	0.2	0.7
08/30/2023 03:00	3,611.6	0.0	3,611.6	101,950.0	368.2	0.4	0.2	0.7
08/30/2023 04:00	3,612.7	0.0	3,612.7	101,950.0	368.3	0.4	0.2	0.7
08/30/2023 05:00	3,619.1	0.0	3,619.1	101,950.0	369.0	0.4	0.2	0.7
08/30/2023 06:00	3,704.8	0.0	3,704.8	101,950.0	377.7	0.5	0.2	0.8
08/30/2023 07:00	3,887.4	0.0	3,887.4	101,950.0	396.3	0.5	0.2	0.8
08/30/2023 08:00	4,004.9	28.0	4,007.7	101,950.0	408.6	0.5	0.2	0.8
08/30/2023 09:00	4,685.6	1,519.9	6,205.5	101,950.0	632.7	0.8	0.4	1.3
08/30/2023 10:00	4,659.0	1,559.8	6,218.8	101,950.0	634.0	0.8	0.4	1.3
08/30/2023 11:00	4,625.3	1,610.9	6,236.2	101,950.0	635.8	0.8	0.4	1.3
08/30/2023 12:00	4,587.3	1,490.2	6,077.5	101,950.0	619.6	0.7	0.4	1.2
08/30/2023 13:00	4,554.2	548.5	5,102.7	101,950.0	520.2	0.6	0.3	1.0
08/30/2023 14:00	3,806.0	38.6	3,811.8	101,950.0	388.6	0.5	0.2	0.8
08/30/2023 15:00	3,587.7	0.0	3,587.7	101,950.0	365.8	0.4	0.2	0.7
08/30/2023 16:00	3,586.7	0.0	3,586.7	101,950.0	365.7	0.4	0.2	0.7
08/30/2023 17:00	3,580.5	0.0	3,580.5	101,950.0	365.0	0.4	0.2	0.7
08/30/2023 18:00	3,784.0	1.6	3,784.0	101,950.0	385.8	0.5	0.2	0.8
08/30/2023 19:00	3,599.8	0.0	3,599.8	101,950.0	367.0	0.4	0.2	0.7
08/30/2023 20:00	3,592.3	0.0	3,592.3	101,950.0	366.2	0.4	0.2	0.7
08/30/2023 21:00	3,595.5	0.0	3,595.5	101,950.0	366.6	0.4	0.2	0.7
08/30/2023 22:00	3,599.2	0.0	3,599.2	101,950.0	366.9	0.4	0.2	0.7
08/30/2023 23:00	3,599.2	0.0	3,599.2	101,950.0	366.9	0.4	0.2	0.7
Average/Sum#:	3,862.9	283.2	4,143.6	101,950.0	422.4	0.5	0.2	0.8
Minimum:	3,580.5	0.0	3,580.5	101,950.0	365.0	0.4	0.2	0.7
Maximum:	4,685.6	1,610.9	6,236.2	101,950.0	635.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2023 00:00	3,685.8	0.0	3,685.8	101,950.0	375.8	0.5	0.2	0.8
08/31/2023 01:00	3,603.1	0.0	3,603.1	101,950.0	367.3	0.4	0.2	0.7
08/31/2023 02:00	3,610.5	0.0	3,610.5	101,950.0	368.1	0.4	0.2	0.7
08/31/2023 03:00	3,603.4	0.0	3,603.4	101,950.0	367.4	0.4	0.2	0.7
08/31/2023 04:00	3,699.8	0.0	3,699.8	101,950.0	377.2	0.5	0.2	0.8
08/31/2023 05:00	4,093.7	0.0	4,093.7	101,950.0	417.4	0.5	0.3	0.8
08/31/2023 06:00	4,176.7	0.0	4,176.7	101,950.0	425.8	0.5	0.3	0.9
08/31/2023 07:00	3,681.0	0.0	3,681.0	101,950.0	375.3	0.4	0.2	0.8
08/31/2023 08:00	4,500.2	1,540.1	5,932.5	101,950.0	604.8	0.7	0.4	1.2
08/31/2023 09:00	4,505.6	1,777.9	6,283.5	101,950.0	640.6	0.8	0.4	1.3
08/31/2023 10:00	4,573.8	1,696.0	6,269.8	101,950.0	639.2	0.8	0.4	1.3
08/31/2023 11:00	4,546.9	1,716.2	6,263.1	101,950.0	638.5	0.8	0.4	1.3
08/31/2023 12:00	4,536.0	1,729.7	6,265.7	101,950.0	638.8	0.8	0.4	1.3
08/31/2023 13:00	4,507.7	1,771.7	6,279.4	101,950.0	640.2	0.8	0.4	1.3
08/31/2023 14:00	4,490.5	1,804.8	6,295.3	101,950.0	641.8	0.8	0.4	1.3
08/31/2023 15:00	4,482.8	1,806.2	6,289.0	101,950.0	641.2	0.8	0.4	1.3
08/31/2023 16:00	4,496.9	1,776.5	6,273.4	101,950.0	639.6	0.8	0.4	1.3
08/31/2023 17:00	4,500.1	621.6	5,078.2	101,950.0	517.7	0.6	0.3	1.0
08/31/2023 18:00	3,627.8	0.0	3,627.8	101,950.0	369.9	0.4	0.2	0.7
08/31/2023 19:00	3,596.4	0.0	3,596.4	101,950.0	366.7	0.4	0.2	0.7
08/31/2023 20:00	3,597.4	0.0	3,597.4	101,950.0	366.8	0.4	0.2	0.7
08/31/2023 21:00	3,604.8	0.0	3,604.8	101,950.0	367.5	0.4	0.2	0.7
08/31/2023 22:00	3,732.4	0.0	3,732.4	101,950.0	380.5	0.5	0.2	0.8
08/31/2023 23:00	3,616.4	0.0	3,616.4	101,950.0	368.7	0.4	0.2	0.7
Average/Sum#:	4,044.6	676.7	4,715.0	101,950.0	480.7	0.6	0.3	1.0
Minimum:	3,596.4	0.0	3,596.4	101,950.0	366.7	0.4	0.2	0.7
Maximum:	4,573.8	1,806.2	6,295.3	101,950.0	641.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2023 00:00	3,621.6	0.0	3,621.6	101,950.0	369.2	0.4	0.2	0.7
09/01/2023 01:00	3,619.6	0.0	3,619.6	101,950.0	369.0	0.4	0.2	0.7
09/01/2023 02:00	3,619.1	0.0	3,619.1	101,950.0	369.0	0.4	0.2	0.7
09/01/2023 03:00	3,621.6	0.0	3,621.6	101,950.0	369.2	0.4	0.2	0.7
09/01/2023 04:00	3,622.0	0.0	3,622.0	101,950.0	369.3	0.4	0.2	0.7
09/01/2023 05:00	3,693.3	0.0	3,693.3	101,950.0	376.5	0.4	0.2	0.8
09/01/2023 06:00	3,892.2	0.0	3,892.2	101,950.0	396.8	0.5	0.2	0.8
09/01/2023 07:00	3,974.2	0.0	3,974.2	101,950.0	405.2	0.5	0.2	0.8
09/01/2023 08:00	3,623.4	0.0	3,623.4	101,950.0	369.4	0.4	0.2	0.7
09/01/2023 09:00	3,635.2	0.0	3,635.2	101,950.0	370.6	0.4	0.2	0.7
09/01/2023 10:00	3,804.8	0.0	3,804.8	101,950.0	387.9	0.5	0.2	0.8
09/01/2023 11:00	3,621.3	0.0	3,621.3	101,950.0	369.2	0.4	0.2	0.7
09/01/2023 12:00	3,618.4	0.0	3,618.4	101,950.0	368.9	0.4	0.2	0.7
09/01/2023 13:00	3,615.0	0.0	3,615.0	101,950.0	368.5	0.4	0.2	0.7
09/01/2023 14:00	3,648.5	0.0	3,648.5	101,950.0	372.0	0.4	0.2	0.7
09/01/2023 15:00	3,943.0	0.0	3,943.0	101,950.0	402.0	0.5	0.2	0.8
09/01/2023 16:00	3,609.3	0.0	3,609.3	101,950.0	368.0	0.4	0.2	0.7
09/01/2023 17:00	3,604.8	0.0	3,604.8	101,950.0	367.5	0.4	0.2	0.7
09/01/2023 18:00	3,608.4	0.0	3,608.4	101,950.0	367.9	0.4	0.2	0.7
09/01/2023 19:00	3,612.3	0.0	3,612.3	101,950.0	368.3	0.4	0.2	0.7
09/01/2023 20:00	3,615.5	0.0	3,615.5	101,950.0	368.6	0.4	0.2	0.7
09/01/2023 21:00	3,629.9	0.0	3,629.9	101,950.0	370.1	0.4	0.2	0.7
09/01/2023 22:00	3,880.7	0.0	3,880.7	101,950.0	395.6	0.5	0.2	0.8
09/01/2023 23:00	3,790.0	0.0	3,790.0	101,950.0	386.4	0.5	0.2	0.8
Average/Sum#:	3,688.5	0.0	3,688.5	101,950.0	376.0	0.4	0.2	0.7
Minimum:	3,604.8	0.0	3,604.8	101,950.0	367.5	0.4	0.2	0.7
Maximum:	3,974.2	0.0	3,974.2	101,950.0	405.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2023 00:00	3,798.0	0.0	3,798.0	101,950.0	387.2	0.5	0.2	0.8
09/02/2023 01:00	3,674.9	0.0	3,674.9	101,950.0	374.7	0.4	0.2	0.7
09/02/2023 02:00	3,664.6	0.0	3,664.6	101,950.0	373.6	0.4	0.2	0.7
09/02/2023 03:00	3,693.6	0.0	3,693.6	101,950.0	376.6	0.5	0.2	0.8
09/02/2023 04:00	3,656.6	0.0	3,656.6	101,950.0	372.8	0.4	0.2	0.7
09/02/2023 05:00	3,848.5	0.0	3,848.5	101,950.0	392.4	0.5	0.2	0.8
09/02/2023 06:00	3,638.1	0.0	3,638.1	101,950.0	370.9	0.4	0.2	0.7
09/02/2023 07:00	3,644.2	0.0	3,644.2	101,950.0	371.5	0.4	0.2	0.7
09/02/2023 08:00	3,643.5	0.0	3,643.5	101,950.0	371.5	0.4	0.2	0.7
09/02/2023 09:00	3,688.0	0.0	3,688.0	101,950.0	376.0	0.5	0.2	0.8
09/02/2023 10:00	3,886.5	0.0	3,886.5	101,950.0	396.2	0.5	0.2	0.8
09/02/2023 11:00	4,216.2	0.0	4,216.2	101,950.0	429.8	0.5	0.3	0.9
09/02/2023 12:00	3,694.0	0.0	3,694.0	101,950.0	376.6	0.5	0.2	0.8
09/02/2023 13:00	3,854.7	0.0	3,854.7	101,950.0	393.0	0.5	0.2	0.8
09/02/2023 14:00	3,894.8	0.0	3,894.8	101,950.0	397.1	0.5	0.2	0.8
09/02/2023 15:00	4,403.4	0.0	4,403.4	101,950.0	448.9	0.5	0.3	0.9
09/02/2023 16:00	3,643.6	0.0	3,643.6	101,950.0	371.5	0.4	0.2	0.7
09/02/2023 17:00	3,718.2	0.0	3,718.2	101,950.0	379.1	0.5	0.2	0.8
09/02/2023 18:00	3,740.3	0.0	3,740.3	101,950.0	381.3	0.5	0.2	0.8
09/02/2023 19:00	3,657.9	0.0	3,657.9	101,950.0	372.9	0.4	0.2	0.7
09/02/2023 20:00	3,626.4	0.0	3,626.4	101,950.0	369.7	0.4	0.2	0.7
09/02/2023 21:00	3,676.0	0.0	3,676.0	101,950.0	374.8	0.4	0.2	0.7
09/02/2023 22:00	3,864.3	0.0	3,864.3	101,950.0	394.0	0.5	0.2	0.8
09/02/2023 23:00	3,626.6	0.0	3,626.6	101,950.0	369.7	0.4	0.2	0.7
Average/Sum#:	3,768.9	0.0	3,768.9	101,950.0	384.2	0.5	0.2	0.8
Minimum:	3,626.4	0.0	3,626.4	101,950.0	369.7	0.4	0.2	0.7
Maximum:	4,403.4	0.0	4,403.4	101,950.0	448.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2023 00:00	3,987.0	0.0	3,987.0	101,950.0	406.5	0.5	0.2	0.8
09/03/2023 01:00	3,723.4	0.0	3,723.4	101,950.0	379.6	0.5	0.2	0.8
09/03/2023 02:00	3,895.7	1.6	3,895.7	101,950.0	397.2	0.5	0.2	0.8
09/03/2023 03:00	3,718.2	0.0	3,718.2	101,950.0	379.1	0.5	0.2	0.8
09/03/2023 04:00	3,740.4	0.0	3,740.4	101,950.0	381.3	0.5	0.2	0.8
09/03/2023 05:00	3,732.8	0.0	3,732.8	101,950.0	380.6	0.5	0.2	0.8
09/03/2023 06:00	3,730.5	0.0	3,730.5	101,950.0	380.3	0.5	0.2	0.8
09/03/2023 07:00	3,759.4	0.0	3,759.4	101,950.0	383.3	0.5	0.2	0.8
09/03/2023 08:00	3,768.1	0.0	3,768.1	101,950.0	384.2	0.5	0.2	0.8
09/03/2023 09:00	3,814.6	0.0	3,814.6	101,950.0	388.9	0.5	0.2	0.8
09/03/2023 10:00	4,652.6	0.0	4,652.6	101,950.0	474.3	0.6	0.3	0.9
09/03/2023 11:00	4,262.5	1.9	4,262.6	101,950.0	434.6	0.5	0.3	0.9
09/03/2023 12:00	3,621.0	0.0	3,621.0	101,950.0	369.2	0.4	0.2	0.7
09/03/2023 13:00	3,620.5	0.0	3,620.5	101,950.0	369.1	0.4	0.2	0.7
09/03/2023 14:00	3,617.2	0.0	3,617.2	101,950.0	368.8	0.4	0.2	0.7
09/03/2023 15:00	3,615.6	0.0	3,615.6	101,950.0	368.6	0.4	0.2	0.7
09/03/2023 16:00	3,615.1	0.0	3,615.1	101,950.0	368.6	0.4	0.2	0.7
09/03/2023 17:00	3,614.6	0.0	3,614.6	101,950.0	368.5	0.4	0.2	0.7
09/03/2023 18:00	3,613.8	0.0	3,613.8	101,950.0	368.4	0.4	0.2	0.7
09/03/2023 19:00	3,618.1	0.0	3,618.1	101,950.0	368.9	0.4	0.2	0.7
09/03/2023 20:00	3,627.4	0.0	3,627.4	101,950.0	369.8	0.4	0.2	0.7
09/03/2023 21:00	3,765.1	0.0	3,765.1	101,950.0	383.9	0.5	0.2	0.8
09/03/2023 22:00	3,628.7	0.0	3,628.7	101,950.0	369.9	0.4	0.2	0.7
09/03/2023 23:00	3,630.5	0.0	3,630.5	101,950.0	370.1	0.4	0.2	0.7
Average/Sum#:	3,765.5	0.1	3,765.5	101,950.0	383.9	0.5	0.2	0.8
Minimum:	3,613.8	0.0	3,613.8	101,950.0	368.4	0.4	0.2	0.7
Maximum:	4,652.6	1.9	4,652.6	101,950.0	474.3	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2023 00:00	3,632.1	0.0	3,632.1	101,950.0	370.3	0.4	0.2	0.7
09/04/2023 01:00	3,638.6	0.0	3,638.6	101,950.0	371.0	0.4	0.2	0.7
09/04/2023 02:00	3,638.5	0.0	3,638.5	101,950.0	370.9	0.4	0.2	0.7
09/04/2023 03:00	3,640.7	0.0	3,640.7	101,950.0	371.2	0.4	0.2	0.7
09/04/2023 04:00	3,644.0	0.0	3,644.0	101,950.0	371.5	0.4	0.2	0.7
09/04/2023 05:00	3,646.5	0.0	3,646.5	101,950.0	371.8	0.4	0.2	0.7
09/04/2023 06:00	3,645.6	0.0	3,645.6	101,950.0	371.7	0.4	0.2	0.7
09/04/2023 07:00	3,644.8	0.0	3,644.8	101,950.0	371.6	0.4	0.2	0.7
09/04/2023 08:00	3,643.8	0.0	3,643.8	101,950.0	371.5	0.4	0.2	0.7
09/04/2023 09:00	3,642.1	0.0	3,642.1	101,950.0	371.3	0.4	0.2	0.7
09/04/2023 10:00	3,641.0	0.0	3,641.0	101,950.0	371.2	0.4	0.2	0.7
09/04/2023 11:00	3,636.1	0.0	3,636.1	101,950.0	370.7	0.4	0.2	0.7
09/04/2023 12:00	3,632.0	0.0	3,632.0	101,950.0	370.3	0.4	0.2	0.7
09/04/2023 13:00	3,629.2	0.0	3,629.2	101,950.0	370.0	0.4	0.2	0.7
09/04/2023 14:00	3,625.1	0.0	3,625.1	101,950.0	369.6	0.4	0.2	0.7
09/04/2023 15:00	3,617.3	0.0	3,617.3	101,950.0	368.8	0.4	0.2	0.7
09/04/2023 16:00	3,615.7	0.0	3,615.7	101,950.0	368.6	0.4	0.2	0.7
09/04/2023 17:00	3,704.4	0.0	3,704.4	101,950.0	377.7	0.5	0.2	0.8
09/04/2023 18:00	4,035.0	0.0	4,035.0	101,950.0	411.4	0.5	0.2	0.8
09/04/2023 19:00	4,500.8	231.5	4,611.9	101,950.0	470.2	0.6	0.3	1.0
09/04/2023 20:00	4,562.3	359.5	4,839.1	101,950.0	493.3	0.6	0.3	1.0
09/04/2023 21:00	4,065.2	0.0	4,065.2	101,950.0	414.4	0.5	0.2	0.8
09/04/2023 22:00	4,037.8	0.0	4,037.8	103,340.0	417.3	0.5	0.2	0.8
09/04/2023 23:00	3,722.0	0.0	3,722.0	103,340.0	384.6	0.5	0.2	0.8
Average/Sum#:	3,768.4	24.6	3,784.5	102,065.8	386.3	0.4	0.2	0.7
Minimum:	3,615.7	0.0	3,615.7	101,950.0	368.6	0.4	0.2	0.7
Maximum:	4,562.3	359.5	4,839.1	103,340.0	493.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2023 00:00	4,087.6	0.0	4,087.6	103,340.0	422.4	0.5	0.3	0.8
09/05/2023 01:00	3,722.8	0.0	3,722.8	103,340.0	384.7	0.5	0.2	0.8
09/05/2023 02:00	3,751.7	0.0	3,751.7	103,340.0	387.7	0.5	0.2	0.8
09/05/2023 03:00	3,858.8	0.0	3,858.8	103,340.0	398.8	0.5	0.2	0.8
09/05/2023 04:00	4,321.0	0.0	4,321.0	103,340.0	446.5	0.5	0.3	0.9
09/05/2023 05:00	4,442.3	0.0	4,442.3	103,340.0	459.1	0.6	0.3	0.9
09/05/2023 06:00	4,521.2	174.7	4,559.6	103,340.0	471.2	0.6	0.3	1.0
09/05/2023 07:00	4,701.0	1,641.4	6,342.4	103,340.0	655.4	0.8	0.4	1.3
09/05/2023 08:00	4,670.1	1,557.7	6,227.8	103,340.0	643.6	0.8	0.4	1.3
09/05/2023 09:00	4,588.0	298.6	4,743.3	103,340.0	490.2	0.6	0.3	1.0
09/05/2023 10:00	4,553.8	5.0	4,554.0	103,340.0	470.6	0.6	0.3	0.9
09/05/2023 11:00	4,504.0	1,201.8	5,705.8	103,340.0	589.6	0.7	0.4	1.2
09/05/2023 12:00	4,445.1	609.2	4,768.0	103,340.0	492.7	0.6	0.3	1.0
09/05/2023 13:00	4,515.4	0.0	4,515.4	103,340.0	466.6	0.6	0.3	0.9
09/05/2023 14:00	4,521.2	0.0	4,521.2	103,340.0	467.2	0.6	0.3	0.9
09/05/2023 15:00	4,520.3	0.0	4,520.3	103,340.0	467.1	0.6	0.3	0.9
09/05/2023 16:00	4,510.2	0.0	4,510.2	103,340.0	466.1	0.6	0.3	0.9
09/05/2023 17:00	4,117.3	0.0	4,117.3	103,340.0	425.5	0.5	0.3	0.9
09/05/2023 18:00	4,545.7	200.3	4,609.8	103,340.0	476.4	0.6	0.3	1.0
09/05/2023 19:00	4,558.4	684.7	5,243.1	103,340.0	541.8	0.6	0.3	1.1
09/05/2023 20:00	4,524.7	259.7	4,654.6	103,340.0	481.0	0.6	0.3	1.0
09/05/2023 21:00	4,508.7	0.0	4,508.7	103,340.0	465.9	0.6	0.3	0.9
09/05/2023 22:00	4,369.2	0.0	4,369.2	103,340.0	451.5	0.5	0.3	0.9
09/05/2023 23:00	4,219.6	0.0	4,219.6	103,340.0	436.1	0.5	0.3	0.9
Average/Sum#:	4,378.3	276.4	4,619.8	103,340.0	477.4	0.6	0.3	1.0
Minimum:	3,722.8	0.0	3,722.8	103,340.0	384.7	0.5	0.2	0.8
Maximum:	4,701.0	1,641.4	6,342.4	103,340.0	655.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2023 00:00	4,206.4	0.0	4,206.4	103,340.0	434.7	0.5	0.3	0.9
09/06/2023 01:00	3,946.1	0.0	3,946.1	103,340.0	407.8	0.5	0.2	0.8
09/06/2023 02:00	3,645.7	0.0	3,645.7	103,340.0	376.7	0.5	0.2	0.8
09/06/2023 03:00	3,706.1	0.0	3,706.1	103,340.0	383.0	0.5	0.2	0.8
09/06/2023 04:00	3,886.3	0.0	3,886.3	103,340.0	401.6	0.5	0.2	0.8
09/06/2023 05:00	4,410.3	0.0	4,410.3	103,340.0	455.8	0.5	0.3	0.9
09/06/2023 06:00	4,514.8	0.0	4,514.8	103,340.0	466.6	0.6	0.3	0.9
09/06/2023 07:00	3,979.5	0.0	3,979.5	103,340.0	411.2	0.5	0.2	0.8
09/06/2023 08:00	3,633.0	0.0	3,633.0	103,340.0	375.4	0.5	0.2	0.7
09/06/2023 09:00	3,631.1	0.0	3,631.1	103,340.0	375.2	0.5	0.2	0.8
09/06/2023 10:00	3,632.4	0.0	3,632.4	103,340.0	375.4	0.5	0.2	0.8
09/06/2023 11:00	3,625.5	0.0	3,625.5	103,340.0	374.7	0.5	0.2	0.7
09/06/2023 12:00	3,640.8	0.0	3,640.8	103,340.0	376.2	0.5	0.2	0.8
09/06/2023 13:00	3,613.1	0.0	3,613.1	103,340.0	373.4	0.5	0.2	0.7
09/06/2023 14:00	3,605.0	0.0	3,605.0	103,340.0	372.5	0.4	0.2	0.7
09/06/2023 15:00	3,600.9	0.0	3,600.9	103,340.0	372.1	0.4	0.2	0.7
09/06/2023 16:00	3,600.5	0.0	3,600.5	103,340.0	372.1	0.4	0.2	0.7
09/06/2023 17:00	3,877.5	0.0	3,877.5	103,340.0	400.7	0.5	0.2	0.8
09/06/2023 18:00	4,222.6	0.0	4,222.6	103,340.0	436.4	0.5	0.3	0.9
09/06/2023 19:00	3,905.9	0.0	3,905.9	103,340.0	403.6	0.5	0.2	0.8
09/06/2023 20:00	4,313.2	0.0	4,313.2	103,340.0	445.7	0.5	0.3	0.9
09/06/2023 21:00	4,152.0	0.0	4,152.0	103,340.0	429.1	0.5	0.3	0.9
09/06/2023 22:00	4,316.4	0.0	4,316.4	103,340.0	446.1	0.5	0.3	0.9
09/06/2023 23:00	3,933.1	0.0	3,933.1	103,340.0	406.4	0.5	0.2	0.8
Average/Sum#:	3,899.9	0.0	3,899.9	103,340.0	403.0	0.5	0.2	0.8
Minimum:	3,600.5	0.0	3,600.5	103,340.0	372.1	0.4	0.2	0.7
Maximum:	4,514.8	0.0	4,514.8	103,340.0	466.6	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2023 00:00	4,067.9	0.0	4,067.9	103,340.0	420.4	0.5	0.3	0.3	0.8	0.8
09/07/2023 01:00	3,668.1	0.0	3,668.1	103,340.0	379.1	0.5	0.2	0.2	0.8	0.8
09/07/2023 02:00	3,642.0	0.0	3,642.0	103,340.0	376.4	0.5	0.2	0.2	0.8	0.8
09/07/2023 03:00	3,644.4	0.0	3,644.4	103,340.0	376.6	0.5	0.2	0.2	0.8	0.8
09/07/2023 04:00	3,647.4	0.0	3,647.4	103,340.0	376.9	0.5	0.2	0.2	0.8	0.8
09/07/2023 05:00	4,054.2	0.0	4,054.2	103,340.0	419.0	0.5	0.3	0.3	0.8	0.8
09/07/2023 06:00	4,461.2	0.0	4,461.2	103,340.0	461.0	0.6	0.3	0.3	0.9	0.9
09/07/2023 07:00	3,884.7	0.0	3,884.7	103,340.0	401.4	0.5	0.2	0.2	0.8	0.8
09/07/2023 08:00	3,644.0	0.0	3,644.0	103,340.0	376.6	0.5	0.2	0.2	0.8	0.8
09/07/2023 09:00	4,046.6	0.0	4,046.6	103,340.0	418.2	0.5	0.3	0.3	0.8	0.8
09/07/2023 10:00	3,813.6	0.0	3,813.6	103,340.0	394.1	0.5	0.2	0.2	0.8	0.8
09/07/2023 11:00	3,845.3	0.0	3,845.3	103,340.0	397.4	0.5	0.2	0.2	0.8	0.8
09/07/2023 12:00	3,863.1	0.0	3,863.1	103,340.0	399.2	0.5	0.2	0.2	0.8	0.8
09/07/2023 13:00	3,722.9	0.0	3,722.9	103,340.0	384.7	0.5	0.2	0.2	0.8	0.8
09/07/2023 14:00	4,132.8	0.0	4,132.8	103,340.0	427.1	0.5	0.3	0.3	0.9	0.9
09/07/2023 15:00	4,274.4	0.0	4,274.4	103,340.0	441.7	0.5	0.3	0.3	0.9	0.9
09/07/2023 16:00	3,843.2	0.0	3,843.2	103,340.0	397.2	0.5	0.2	0.2	0.8	0.8
09/07/2023 17:00	4,075.0	0.0	4,075.0	103,340.0	421.1	0.5	0.3	0.3	0.8	0.8
09/07/2023 18:00	4,088.4	0.0	4,088.4	103,340.0	422.5	0.5	0.3	0.3	0.8	0.8
09/07/2023 19:00	3,819.0	0.0	3,819.0	103,340.0	394.7	0.5	0.2	0.2	0.8	0.8
09/07/2023 20:00	4,334.0	0.0	4,334.0	103,340.0	447.9	0.5	0.3	0.3	0.9	0.9
09/07/2023 21:00	4,431.1	0.0	4,431.1	103,340.0	457.9	0.5	0.3	0.3	0.9	0.9
09/07/2023 22:00	4,161.4	0.0	4,161.4	103,340.0	430.0	0.5	0.3	0.3	0.9	0.9
09/07/2023 23:00	3,874.0	0.0	3,874.0	103,340.0	400.3	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,959.9	0.0	3,959.9	103,340.0	409.2	0.5	0.2	0.2	0.8	0.8
Minimum:	3,642.0	0.0	3,642.0	103,340.0	376.4	0.5	0.2	0.2	0.8	0.8
Maximum:	4,461.2	0.0	4,461.2	103,340.0	461.0	0.6	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2023 00:00	3,678.5	0.0	3,678.5	103,340.0	380.1	0.5	0.2	0.8
09/08/2023 01:00	3,722.7	0.0	3,722.7	103,340.0	384.7	0.5	0.2	0.8
09/08/2023 02:00	3,709.0	0.0	3,709.0	103,340.0	383.3	0.5	0.2	0.8
09/08/2023 03:00	3,714.8	0.0	3,714.8	103,340.0	383.9	0.5	0.2	0.8
09/08/2023 04:00	3,720.4	0.0	3,720.4	103,340.0	384.5	0.5	0.2	0.8
09/08/2023 05:00	4,460.8	276.4	4,593.5	103,340.0	474.7	0.6	0.3	1.0
09/08/2023 06:00	4,688.3	546.6	5,234.9	103,340.0	541.0	0.7	0.3	1.1
09/08/2023 07:00	4,685.8	599.0	5,284.8	103,340.0	546.1	0.7	0.3	1.1
09/08/2023 08:00	4,398.2	314.7	4,565.0	103,340.0	471.7	0.6	0.3	1.0
09/08/2023 09:00	3,700.3	0.0	3,700.3	103,340.0	382.4	0.5	0.2	0.8
09/08/2023 10:00	3,696.9	0.0	3,696.9	103,340.0	382.0	0.5	0.2	0.8
09/08/2023 11:00	4,047.6	0.0	4,047.6	103,340.0	418.3	0.5	0.3	0.8
09/08/2023 12:00	3,988.5	0.0	3,988.5	103,340.0	412.2	0.5	0.2	0.8
09/08/2023 13:00	4,414.1	0.0	4,414.1	103,340.0	456.2	0.5	0.3	0.9
09/08/2023 14:00	4,548.6	0.0	4,548.6	103,340.0	470.1	0.6	0.3	0.9
09/08/2023 15:00	4,548.3	0.0	4,548.3	103,340.0	470.0	0.6	0.3	0.9
09/08/2023 16:00	4,521.6	455.7	4,763.1	103,340.0	492.2	0.6	0.3	1.0
09/08/2023 17:00	4,557.3	1,266.1	5,823.4	103,340.0	601.8	0.7	0.4	1.2
09/08/2023 18:00	4,571.8	1,841.2	6,413.0	103,340.0	662.7	0.8	0.4	1.3
09/08/2023 19:00	4,597.2	1,015.9	5,613.1	103,340.0	580.1	0.7	0.3	1.2
09/08/2023 20:00	4,648.1	1,260.0	5,908.1	103,340.0	610.5	0.7	0.4	1.2
09/08/2023 21:00	4,661.1	1,431.8	6,092.9	103,340.0	629.6	0.8	0.4	1.3
09/08/2023 22:00	4,668.0	954.8	5,622.8	103,340.0	581.1	0.7	0.3	1.2
09/08/2023 23:00	4,402.6	1.9	4,402.6	103,340.0	455.0	0.5	0.3	0.9
Average/Sum#:	4,264.6	415.2	4,658.6	103,340.0	481.4	0.6	0.3	1.0
Minimum:	3,678.5	0.0	3,678.5	103,340.0	380.1	0.5	0.2	0.8
Maximum:	4,688.3	1,841.2	6,413.0	103,340.0	662.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2023 00:00	4,487.0	0.0	4,487.0	103,340.0	463.7	0.6	0.3	0.9
09/09/2023 01:00	4,474.7	0.0	4,474.7	103,340.0	462.4	0.6	0.3	0.9
09/09/2023 02:00	4,152.4	0.0	4,152.4	103,340.0	429.1	0.5	0.3	0.9
09/09/2023 03:00	4,185.4	0.0	4,185.4	103,340.0	432.5	0.5	0.3	0.9
09/09/2023 04:00	4,480.4	0.0	4,480.4	103,340.0	463.0	0.6	0.3	0.9
09/09/2023 05:00	4,518.3	0.0	4,518.3	103,340.0	466.9	0.6	0.3	0.9
09/09/2023 06:00	4,519.4	0.0	4,519.4	103,340.0	467.0	0.6	0.3	0.9
09/09/2023 07:00	3,811.2	0.0	3,811.2	103,340.0	393.8	0.5	0.2	0.8
09/09/2023 08:00	4,490.3	0.0	4,490.3	103,340.0	464.0	0.6	0.3	0.9
09/09/2023 09:00	3,676.8	0.0	3,676.8	103,340.0	380.0	0.5	0.2	0.8
09/09/2023 10:00	3,626.4	0.0	3,626.4	103,340.0	374.8	0.5	0.2	0.7
09/09/2023 11:00	3,850.5	0.0	3,850.5	103,340.0	397.9	0.5	0.2	0.8
09/09/2023 12:00	4,209.6	21.0	4,212.3	103,340.0	435.3	0.5	0.3	0.9
09/09/2023 13:00	4,535.7	0.0	4,535.7	103,340.0	468.7	0.6	0.3	0.9
09/09/2023 14:00	3,896.8	0.0	3,896.8	103,340.0	402.7	0.5	0.2	0.8
09/09/2023 15:00	4,410.7	0.0	4,410.7	103,340.0	455.8	0.5	0.3	0.9
09/09/2023 16:00	4,075.1	0.0	4,075.1	103,340.0	421.1	0.5	0.3	0.8
09/09/2023 17:00	4,524.3	419.3	4,725.6	103,340.0	488.3	0.6	0.3	1.0
09/09/2023 18:00	4,580.3	1,389.2	5,969.5	103,340.0	616.9	0.7	0.4	1.2
09/09/2023 19:00	4,583.4	641.6	5,077.4	103,340.0	524.7	0.6	0.3	1.1
09/09/2023 20:00	4,493.0	0.0	4,493.0	103,340.0	464.3	0.6	0.3	0.9
09/09/2023 21:00	4,676.4	572.9	5,237.8	103,340.0	541.3	0.7	0.3	1.1
09/09/2023 22:00	4,638.3	375.0	4,927.1	103,340.0	509.2	0.6	0.3	1.0
09/09/2023 23:00	3,944.3	0.0	3,944.3	103,340.0	407.6	0.5	0.2	0.8
Average/Sum#:	4,285.0	142.5	4,407.4	103,340.0	455.5	0.6	0.3	0.9
Minimum:	3,626.4	0.0	3,626.4	103,340.0	374.8	0.5	0.2	0.7
Maximum:	4,676.4	1,389.2	5,969.5	103,340.0	616.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2023 00:00	4,227.6	0.0	4,227.6	103,340.0	436.9	0.5	0.3	0.9
09/10/2023 01:00	3,875.1	0.0	3,875.1	103,340.0	400.5	0.5	0.2	0.8
09/10/2023 02:00	3,781.1	0.0	3,781.1	103,340.0	390.7	0.5	0.2	0.8
09/10/2023 03:00	4,092.3	0.0	4,092.3	103,340.0	422.9	0.5	0.3	0.8
09/10/2023 04:00	3,685.9	0.0	3,685.9	103,340.0	380.9	0.5	0.2	0.8
09/10/2023 05:00	4,047.6	0.0	4,047.6	103,340.0	418.3	0.5	0.3	0.8
09/10/2023 06:00	4,307.4	0.0	4,307.4	103,340.0	445.1	0.5	0.3	0.9
09/10/2023 07:00	4,297.3	0.0	4,297.3	103,340.0	444.1	0.5	0.3	0.9
09/10/2023 08:00	4,544.0	0.0	4,544.0	103,340.0	469.6	0.6	0.3	0.9
09/10/2023 09:00	4,078.3	0.0	4,078.3	103,340.0	421.5	0.5	0.3	0.8
09/10/2023 10:00	3,900.8	0.0	3,900.8	103,340.0	403.1	0.5	0.2	0.8
09/10/2023 11:00	3,627.1	0.0	3,627.1	103,340.0	374.8	0.5	0.2	0.8
09/10/2023 12:00	3,622.0	0.0	3,622.0	103,340.0	374.3	0.5	0.2	0.7
09/10/2023 13:00	3,905.2	0.0	3,905.2	103,340.0	403.6	0.5	0.2	0.8
09/10/2023 14:00	4,154.8	0.0	4,154.8	103,340.0	429.4	0.5	0.3	0.9
09/10/2023 15:00	3,838.9	0.0	3,838.9	103,340.0	396.7	0.5	0.2	0.8
09/10/2023 16:00	4,176.7	159.9	4,219.9	103,340.0	436.1	0.5	0.3	0.9
09/10/2023 17:00	4,581.1	1,529.3	6,110.4	103,340.0	631.4	0.8	0.4	1.3
09/10/2023 18:00	4,581.3	1,544.2	6,125.5	103,340.0	633.0	0.8	0.4	1.3
09/10/2023 19:00	4,588.8	905.3	5,494.1	103,340.0	567.8	0.7	0.3	1.1
09/10/2023 20:00	4,485.7	110.0	4,515.4	103,340.0	466.6	0.6	0.3	1.0
09/10/2023 21:00	4,653.2	518.3	5,161.1	103,340.0	533.3	0.6	0.3	1.1
09/10/2023 22:00	4,613.3	509.1	5,005.3	103,340.0	517.2	0.6	0.3	1.1
09/10/2023 23:00	3,659.8	0.0	3,659.8	103,340.0	378.2	0.5	0.2	0.8
Average/Sum#:	4,138.6	219.8	4,344.9	103,340.0	449.0	0.6	0.3	0.9
Minimum:	3,622.0	0.0	3,622.0	103,340.0	374.3	0.5	0.2	0.7
Maximum:	4,653.2	1,544.2	6,125.5	103,340.0	633.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2023 00:00	3,633.3	0.0	3,633.3	103,340.0	375.5	0.5	0.2	0.8
09/11/2023 01:00	3,636.5	0.0	3,636.5	103,340.0	375.8	0.5	0.2	0.8
09/11/2023 02:00	3,642.7	0.0	3,642.7	103,340.0	376.4	0.5	0.2	0.8
09/11/2023 03:00	3,654.8	0.0	3,654.8	103,340.0	377.7	0.5	0.2	0.8
09/11/2023 04:00	3,712.2	0.0	3,712.2	103,340.0	383.6	0.5	0.2	0.8
09/11/2023 05:00	3,736.4	0.0	3,736.4	103,340.0	386.1	0.5	0.2	0.8
09/11/2023 06:00	4,542.3	0.0	4,542.3	103,340.0	469.4	0.6	0.3	0.9
09/11/2023 07:00	4,067.0	0.0	4,067.0	103,340.0	420.3	0.5	0.3	0.8
09/11/2023 08:00	3,644.0	0.0	3,644.0	103,340.0	376.6	0.5	0.2	0.8
09/11/2023 09:00	3,636.0	0.0	3,636.0	103,340.0	375.7	0.5	0.2	0.8
09/11/2023 10:00	3,625.9	0.0	3,625.9	103,340.0	374.7	0.5	0.2	0.7
09/11/2023 11:00	3,710.2	0.0	3,710.2	103,340.0	383.4	0.5	0.2	0.8
09/11/2023 12:00	4,076.6	0.0	4,076.6	103,340.0	421.3	0.5	0.3	0.8
09/11/2023 13:00	4,007.6	0.0	4,007.6	103,340.0	414.1	0.5	0.2	0.8
09/11/2023 14:00	4,250.4	0.0	4,250.4	103,340.0	439.2	0.5	0.3	0.9
09/11/2023 15:00	4,056.1	0.0	4,056.1	103,340.0	419.2	0.5	0.3	0.8
09/11/2023 16:00	4,053.2	0.0	4,053.2	103,340.0	418.9	0.5	0.3	0.8
09/11/2023 17:00	3,865.8	0.0	3,865.8	103,340.0	399.5	0.5	0.2	0.8
09/11/2023 18:00	4,152.6	0.0	4,152.6	103,340.0	429.1	0.5	0.3	0.9
09/11/2023 19:00	3,667.6	0.0	3,667.6	103,340.0	379.0	0.5	0.2	0.8
09/11/2023 20:00	3,847.4	0.0	3,847.4	103,340.0	397.6	0.5	0.2	0.8
09/11/2023 21:00	4,120.0	0.0	4,120.0	103,340.0	425.8	0.5	0.3	0.9
09/11/2023 22:00	3,753.3	0.0	3,753.3	103,340.0	387.9	0.5	0.2	0.8
09/11/2023 23:00	3,627.9	0.0	3,627.9	103,340.0	374.9	0.5	0.2	0.8
Average/Sum#:	3,863.3	0.0	3,863.3	103,340.0	399.2	0.5	0.2	0.8
Minimum:	3,625.9	0.0	3,625.9	103,340.0	374.7	0.5	0.2	0.7
Maximum:	4,542.3	0.0	4,542.3	103,340.0	469.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2023 00:00	3,629.9	0.0	3,629.9	103,340.0	375.1	0.5	0.2	0.8
09/12/2023 01:00	3,629.7	0.0	3,629.7	103,340.0	375.1	0.5	0.2	0.8
09/12/2023 02:00	3,630.9	0.0	3,630.9	103,340.0	375.2	0.5	0.2	0.8
09/12/2023 03:00	3,634.2	0.0	3,634.2	103,340.0	375.6	0.5	0.2	0.8
09/12/2023 04:00	3,636.8	0.0	3,636.8	103,340.0	375.8	0.5	0.2	0.8
09/12/2023 05:00	3,638.4	0.0	3,638.4	103,340.0	376.0	0.5	0.2	0.8
09/12/2023 06:00	3,637.9	0.0	3,637.9	103,340.0	375.9	0.5	0.2	0.8
09/12/2023 07:00	3,645.2	0.0	3,645.2	103,340.0	376.7	0.5	0.2	0.8
09/12/2023 08:00	3,642.5	0.0	3,642.5	103,340.0	376.4	0.5	0.2	0.8
09/12/2023 09:00	3,637.9	0.0	3,637.9	103,340.0	375.9	0.5	0.2	0.8
09/12/2023 10:00	3,635.2	0.0	3,635.2	103,340.0	375.7	0.5	0.2	0.7
09/12/2023 11:00	3,630.0	0.0	3,630.0	103,340.0	375.1	0.5	0.2	0.8
09/12/2023 12:00	3,625.1	0.0	3,625.1	103,340.0	374.6	0.5	0.2	0.7
09/12/2023 13:00	3,613.8	0.0	3,613.8	103,340.0	373.5	0.5	0.2	0.7
09/12/2023 14:00	3,670.9	0.0	3,670.9	103,340.0	379.4	0.5	0.2	0.8
09/12/2023 15:00	3,665.8	0.0	3,665.8	103,340.0	378.8	0.5	0.2	0.8
09/12/2023 16:00	3,599.5	0.0	3,599.5	103,340.0	372.0	0.4	0.2	0.7
09/12/2023 17:00	3,598.2	0.0	3,598.2	103,340.0	371.8	0.4	0.2	0.7
09/12/2023 18:00	3,596.0	0.0	3,596.0	103,340.0	371.6	0.4	0.2	0.7
09/12/2023 19:00	4,101.5	129.9	4,137.9	103,340.0	427.6	0.5	0.3	0.9
09/12/2023 20:00	4,606.3	464.1	5,070.4	103,340.0	524.0	0.6	0.3	1.0
09/12/2023 21:00	3,839.2	2.4	3,839.2	103,340.0	396.7	0.5	0.2	0.8
09/12/2023 22:00	3,617.7	0.0	3,617.7	103,340.0	373.9	0.4	0.2	0.7
09/12/2023 23:00	3,619.1	0.0	3,619.1	103,340.0	374.0	0.5	0.2	0.7
Average/Sum#:	3,699.2	24.9	3,720.1	103,340.0	384.4	0.5	0.2	0.8
Minimum:	3,596.0	0.0	3,596.0	103,340.0	371.6	0.4	0.2	0.7
Maximum:	4,606.3	464.1	5,070.4	103,340.0	524.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2023 00:00	3,620.0	0.0	3,620.0	103,340.0	374.1	0.5	0.2	0.7
09/13/2023 01:00	3,623.1	0.0	3,623.1	103,340.0	374.4	0.5	0.2	0.7
09/13/2023 02:00	3,625.5	0.0	3,625.5	103,340.0	374.7	0.5	0.2	0.8
09/13/2023 03:00	3,630.5	0.0	3,630.5	103,340.0	375.2	0.5	0.2	0.8
09/13/2023 04:00	3,639.4	0.0	3,639.4	103,340.0	376.1	0.5	0.2	0.8
09/13/2023 05:00	3,643.1	0.0	3,643.1	103,340.0	376.5	0.5	0.2	0.8
09/13/2023 06:00	3,641.3	0.0	3,641.3	103,340.0	376.3	0.5	0.2	0.8
09/13/2023 07:00	3,637.8	0.0	3,637.8	103,340.0	375.9	0.5	0.2	0.8
09/13/2023 08:00	3,639.8	0.0	3,639.8	103,340.0	376.1	0.5	0.2	0.8
09/13/2023 09:00	3,636.0	0.0	3,636.0	103,340.0	375.7	0.5	0.2	0.8
09/13/2023 10:00	3,631.9	0.0	3,631.9	103,340.0	375.3	0.5	0.2	0.8
09/13/2023 11:00	3,885.8	0.0	3,885.8	103,340.0	401.6	0.5	0.2	0.8
09/13/2023 12:00	4,555.5	506.7	5,052.1	103,340.0	522.1	0.6	0.3	1.0
09/13/2023 13:00	4,076.3	127.8	4,110.8	103,340.0	424.8	0.5	0.3	0.9
09/13/2023 14:00	4,308.7	18.2	4,310.0	103,340.0	445.4	0.5	0.3	0.9
09/13/2023 15:00	4,523.8	590.4	5,114.2	103,340.0	528.5	0.6	0.3	1.1
09/13/2023 16:00	4,507.3	608.7	5,116.0	103,340.0	528.7	0.6	0.3	1.1
09/13/2023 17:00	4,504.0	661.9	5,165.9	103,340.0	533.8	0.6	0.3	1.1
09/13/2023 18:00	4,514.7	641.9	5,156.6	103,340.0	532.9	0.6	0.3	1.1
09/13/2023 19:00	4,529.7	575.7	5,105.4	103,340.0	527.6	0.6	0.3	1.1
09/13/2023 20:00	4,561.6	535.2	5,096.8	103,340.0	526.7	0.6	0.3	1.1
09/13/2023 21:00	4,271.4	250.7	4,401.8	103,340.0	454.9	0.6	0.3	0.9
09/13/2023 22:00	3,613.0	0.0	3,613.0	103,340.0	373.4	0.5	0.2	0.7
09/13/2023 23:00	3,615.7	0.0	3,615.7	103,340.0	373.6	0.5	0.2	0.7
Average/Sum#:	3,976.5	188.2	4,154.7	103,340.0	429.3	0.5	0.2	0.9
Minimum:	3,613.0	0.0	3,613.0	103,340.0	373.4	0.5	0.2	0.7
Maximum:	4,561.6	661.9	5,165.9	103,340.0	533.8	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2023 00:00	3,700.7	0.0	3,700.7	103,340.0	382.4	0.5	0.2	0.8
09/14/2023 01:00	3,693.2	0.0	3,693.2	103,340.0	381.7	0.5	0.2	0.8
09/14/2023 02:00	4,226.0	0.0	4,226.0	103,340.0	436.7	0.5	0.3	0.9
09/14/2023 03:00	3,628.4	0.0	3,628.4	103,340.0	375.0	0.5	0.2	0.8
09/14/2023 04:00	3,632.0	0.0	3,632.0	103,340.0	375.3	0.5	0.2	0.8
09/14/2023 05:00	3,719.9	0.0	3,719.9	103,340.0	384.4	0.5	0.2	0.8
09/14/2023 06:00	4,308.5	0.0	4,308.5	103,340.0	445.2	0.5	0.3	0.9
09/14/2023 07:00	3,959.8	0.0	3,959.8	103,340.0	409.2	0.5	0.2	0.8
09/14/2023 08:00	3,705.5	0.0	3,705.5	103,340.0	382.9	0.5	0.2	0.8
09/14/2023 09:00	4,169.3	0.0	4,169.3	103,340.0	430.9	0.5	0.3	0.9
09/14/2023 10:00	4,436.9	0.0	4,436.9	103,340.0	458.5	0.5	0.3	0.9
09/14/2023 11:00	4,461.6	122.7	4,489.8	103,340.0	464.0	0.6	0.3	0.9
09/14/2023 12:00	4,569.4	517.2	5,086.6	103,340.0	525.6	0.6	0.3	1.1
09/14/2023 13:00	4,441.9	2.8	4,442.0	103,340.0	459.0	0.6	0.3	0.9
09/14/2023 14:00	4,437.3	0.0	4,437.3	103,340.0	458.6	0.6	0.3	0.9
09/14/2023 15:00	4,484.3	479.8	4,834.6	103,340.0	499.6	0.6	0.3	1.0
09/14/2023 16:00	4,482.6	845.1	5,327.7	103,340.0	550.6	0.7	0.3	1.1
09/14/2023 17:00	4,481.0	949.8	5,430.8	103,340.0	561.2	0.7	0.3	1.1
09/14/2023 18:00	4,486.8	857.7	5,344.5	103,340.0	552.3	0.7	0.3	1.1
09/14/2023 19:00	4,531.4	567.4	5,098.8	103,340.0	526.9	0.6	0.3	1.1
09/14/2023 20:00	4,571.4	500.9	5,072.3	103,340.0	524.2	0.6	0.3	1.0
09/14/2023 21:00	4,592.0	702.6	5,294.6	103,340.0	547.1	0.7	0.3	1.1
09/14/2023 22:00	4,570.4	417.8	4,892.1	103,340.0	505.5	0.6	0.3	1.0
09/14/2023 23:00	3,882.3	0.0	3,882.3	103,340.0	401.2	0.5	0.2	0.8
Average/Sum#:	4,215.5	248.5	4,450.6	103,340.0	459.9	0.6	0.3	0.9
Minimum:	3,628.4	0.0	3,628.4	103,340.0	375.0	0.5	0.2	0.8
Maximum:	4,592.0	949.8	5,430.8	103,340.0	561.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2023 00:00	3,825.5	0.0	3,825.5	103,340.0	395.3	0.5	0.2	0.8
09/15/2023 01:00	3,681.8	0.0	3,681.8	103,340.0	380.5	0.5	0.2	0.8
09/15/2023 02:00	3,666.0	0.0	3,666.0	103,340.0	378.8	0.5	0.2	0.8
09/15/2023 03:00	3,634.1	0.0	3,634.1	103,340.0	375.5	0.5	0.2	0.8
09/15/2023 04:00	3,703.5	0.0	3,703.5	103,340.0	382.7	0.5	0.2	0.8
09/15/2023 05:00	4,260.4	99.9	4,282.4	103,340.0	442.5	0.5	0.3	0.9
09/15/2023 06:00	4,709.3	1,176.9	5,886.2	103,340.0	608.3	0.7	0.4	1.2
09/15/2023 07:00	4,393.2	213.7	4,504.3	103,340.0	465.5	0.6	0.3	1.0
09/15/2023 08:00	3,698.0	0.0	3,698.0	103,340.0	382.2	0.5	0.2	0.8
09/15/2023 09:00	3,641.7	0.0	3,641.7	103,340.0	376.3	0.5	0.2	0.8
09/15/2023 10:00	3,638.3	0.0	3,638.3	103,340.0	376.0	0.5	0.2	0.8
09/15/2023 11:00	3,634.7	0.0	3,634.7	103,340.0	375.6	0.5	0.2	0.8
09/15/2023 12:00	3,659.7	0.0	3,659.7	103,340.0	378.2	0.5	0.2	0.8
09/15/2023 13:00	3,650.9	0.0	3,650.9	103,340.0	377.3	0.5	0.2	0.8
09/15/2023 14:00	3,851.0	0.0	3,851.0	103,340.0	398.0	0.5	0.2	0.8
09/15/2023 15:00	4,376.0	124.9	4,404.7	103,340.0	455.2	0.6	0.3	0.9
09/15/2023 16:00	4,533.9	935.2	5,469.1	103,340.0	565.2	0.7	0.3	1.1
09/15/2023 17:00	4,527.0	1,151.9	5,678.9	103,340.0	586.9	0.7	0.4	1.2
09/15/2023 18:00	4,553.7	1,392.6	5,946.3	103,340.0	614.5	0.7	0.4	1.2
09/15/2023 19:00	4,566.2	782.1	5,348.3	103,340.0	552.7	0.7	0.3	1.1
09/15/2023 20:00	4,593.0	935.1	5,528.1	103,340.0	571.3	0.7	0.3	1.1
09/15/2023 21:00	4,620.2	794.5	5,414.7	103,340.0	559.6	0.7	0.3	1.1
09/15/2023 22:00	4,641.2	650.7	5,291.9	103,340.0	546.9	0.7	0.3	1.1
09/15/2023 23:00	4,608.5	336.0	4,867.2	103,340.0	503.0	0.6	0.3	1.0
Average/Sum#:	4,111.2	358.1	4,454.5	103,340.0	460.3	0.6	0.3	0.9
Minimum:	3,634.1	0.0	3,634.1	103,340.0	375.5	0.5	0.2	0.8
Maximum:	4,709.3	1,392.6	5,946.3	103,340.0	614.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2023 00:00	4,021.0	0.0	4,021.0	103,340.0	415.5	0.5	0.2	0.8
09/16/2023 01:00	3,779.9	0.0	3,779.9	103,340.0	390.6	0.5	0.2	0.8
09/16/2023 02:00	3,713.9	0.0	3,713.9	103,340.0	383.8	0.5	0.2	0.8
09/16/2023 03:00	3,637.8	0.0	3,637.8	103,340.0	375.9	0.5	0.2	0.8
09/16/2023 04:00	3,642.0	0.0	3,642.0	103,340.0	376.4	0.5	0.2	0.8
09/16/2023 05:00	3,660.6	0.0	3,660.6	103,340.0	378.3	0.5	0.2	0.8
09/16/2023 06:00	3,646.3	0.0	3,646.3	103,340.0	376.8	0.5	0.2	0.8
09/16/2023 07:00	3,646.0	0.0	3,646.0	103,340.0	376.8	0.5	0.2	0.8
09/16/2023 08:00	3,661.0	0.0	3,661.0	103,340.0	378.3	0.5	0.2	0.8
09/16/2023 09:00	3,701.2	0.0	3,701.2	103,340.0	382.5	0.5	0.2	0.8
09/16/2023 10:00	3,813.8	0.0	3,813.8	103,340.0	394.1	0.5	0.2	0.8
09/16/2023 11:00	4,046.2	0.0	4,046.2	103,340.0	418.1	0.5	0.3	0.8
09/16/2023 12:00	4,364.5	0.0	4,364.5	103,340.0	451.0	0.5	0.3	0.9
09/16/2023 13:00	4,287.6	0.0	4,287.6	103,340.0	443.1	0.5	0.3	0.9
09/16/2023 14:00	3,967.8	0.0	3,967.8	103,340.0	410.0	0.5	0.2	0.8
09/16/2023 15:00	4,030.6	0.0	4,030.6	103,340.0	416.5	0.5	0.2	0.8
09/16/2023 16:00	3,611.5	0.0	3,611.5	103,340.0	373.2	0.5	0.2	0.7
09/16/2023 17:00	3,811.7	0.0	3,811.7	103,340.0	393.9	0.5	0.2	0.8
09/16/2023 18:00	3,684.4	0.0	3,684.4	103,340.0	380.7	0.5	0.2	0.8
09/16/2023 19:00	3,622.7	0.0	3,622.7	103,340.0	374.4	0.5	0.2	0.8
09/16/2023 20:00	3,621.1	0.0	3,621.1	103,340.0	374.2	0.5	0.2	0.7
09/16/2023 21:00	3,625.3	0.0	3,625.3	103,340.0	374.6	0.5	0.2	0.8
09/16/2023 22:00	3,626.2	0.0	3,626.2	103,340.0	374.7	0.5	0.2	0.7
09/16/2023 23:00	3,630.7	0.0	3,630.7	103,340.0	375.2	0.5	0.2	0.8
Average/Sum#:	3,785.6	0.0	3,785.6	103,340.0	391.2	0.5	0.2	0.8
Minimum:	3,611.5	0.0	3,611.5	103,340.0	373.2	0.5	0.2	0.7
Maximum:	4,364.5	0.0	4,364.5	103,340.0	451.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2023 00:00	3,635.4	0.0	3,635.4	103,340.0	375.7	0.5	0.2	0.8
09/17/2023 01:00	3,638.6	0.0	3,638.6	103,340.0	376.0	0.5	0.2	0.8
09/17/2023 02:00	3,641.1	0.0	3,641.1	103,340.0	376.3	0.5	0.2	0.8
09/17/2023 03:00	3,640.9	0.0	3,640.9	103,340.0	376.3	0.5	0.2	0.8
09/17/2023 04:00	3,643.1	0.0	3,643.1	103,340.0	376.5	0.5	0.2	0.8
09/17/2023 05:00	3,645.6	0.0	3,645.6	103,340.0	376.7	0.5	0.2	0.8
09/17/2023 06:00	3,645.7	0.0	3,645.7	103,340.0	376.7	0.5	0.2	0.8
09/17/2023 07:00	3,646.9	0.0	3,646.9	103,340.0	376.9	0.5	0.2	0.8
09/17/2023 08:00	3,647.6	0.0	3,647.6	103,340.0	376.9	0.5	0.2	0.8
09/17/2023 09:00	3,643.9	0.0	3,643.9	103,340.0	376.6	0.5	0.2	0.8
09/17/2023 10:00	3,639.4	0.0	3,639.4	103,340.0	376.1	0.5	0.2	0.8
09/17/2023 11:00	3,635.6	0.0	3,635.6	103,340.0	375.7	0.5	0.2	0.8
09/17/2023 12:00	3,628.5	0.0	3,628.5	103,340.0	375.0	0.5	0.2	0.7
09/17/2023 13:00	3,626.8	0.0	3,626.8	103,340.0	374.8	0.5	0.2	0.8
09/17/2023 14:00	3,624.4	0.0	3,624.4	103,340.0	374.5	0.5	0.2	0.7
09/17/2023 15:00	3,622.2	0.0	3,622.2	103,340.0	374.3	0.5	0.2	0.7
09/17/2023 16:00	3,617.2	0.0	3,617.2	103,340.0	373.8	0.4	0.2	0.7
09/17/2023 17:00	3,732.4	0.0	3,732.4	103,340.0	385.7	0.5	0.2	0.8
09/17/2023 18:00	3,663.6	0.0	3,663.6	103,340.0	378.6	0.5	0.2	0.8
09/17/2023 19:00	3,637.0	0.0	3,637.0	103,340.0	375.8	0.5	0.2	0.8
09/17/2023 20:00	3,743.0	0.0	3,743.0	103,340.0	386.8	0.5	0.2	0.8
09/17/2023 21:00	3,636.7	0.0	3,636.7	103,340.0	375.8	0.5	0.2	0.8
09/17/2023 22:00	3,641.4	0.0	3,641.4	103,340.0	376.3	0.5	0.2	0.8
09/17/2023 23:00	3,647.8	0.0	3,647.8	103,340.0	377.0	0.5	0.2	0.8
Average/Sum#:	3,646.9	0.0	3,646.9	103,340.0	376.9	0.5	0.2	0.8
Minimum:	3,617.2	0.0	3,617.2	103,340.0	373.8	0.4	0.2	0.7
Maximum:	3,743.0	0.0	3,743.0	103,340.0	386.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2023 00:00	3,650.8	0.0	3,650.8	103,340.0	377.3	0.5	0.2	0.8
09/18/2023 01:00	3,648.3	0.0	3,648.3	103,340.0	377.0	0.5	0.2	0.8
09/18/2023 02:00	3,648.3	0.0	3,648.3	103,340.0	377.0	0.5	0.2	0.8
09/18/2023 03:00	3,650.6	0.0	3,650.6	103,340.0	377.3	0.5	0.2	0.8
09/18/2023 04:00	3,651.2	0.0	3,651.2	103,340.0	377.3	0.5	0.2	0.8
09/18/2023 05:00	3,652.0	0.0	3,652.0	103,340.0	377.4	0.5	0.2	0.8
09/18/2023 06:00	3,654.3	0.0	3,654.3	103,340.0	377.6	0.5	0.2	0.8
09/18/2023 07:00	3,656.3	0.0	3,656.3	103,340.0	377.8	0.5	0.2	0.8
09/18/2023 08:00	3,652.5	0.0	3,652.5	103,340.0	377.4	0.5	0.2	0.8
09/18/2023 09:00	3,644.6	0.0	3,644.6	103,340.0	376.6	0.5	0.2	0.8
09/18/2023 10:00	3,644.2	0.0	3,644.2	103,340.0	376.6	0.5	0.2	0.8
09/18/2023 11:00	3,640.0	0.0	3,640.0	103,340.0	376.2	0.5	0.2	0.8
09/18/2023 12:00	3,632.2	0.0	3,632.2	103,340.0	375.4	0.5	0.2	0.8
09/18/2023 13:00	3,629.4	0.0	3,629.4	103,340.0	375.1	0.5	0.2	0.8
09/18/2023 14:00	3,626.7	0.0	3,626.7	103,340.0	374.8	0.5	0.2	0.8
09/18/2023 15:00	3,620.5	0.0	3,620.5	103,340.0	374.1	0.5	0.2	0.7
09/18/2023 16:00	3,620.7	0.0	3,620.7	103,340.0	374.2	0.4	0.2	0.7
09/18/2023 17:00	3,898.5	0.0	3,898.5	103,340.0	402.9	0.5	0.2	0.8
09/18/2023 18:00	4,175.2	0.0	4,175.2	103,340.0	431.5	0.5	0.3	0.9
09/18/2023 19:00	3,731.5	0.0	3,731.5	103,340.0	385.6	0.5	0.2	0.8
09/18/2023 20:00	3,645.6	0.0	3,645.6	103,340.0	376.7	0.5	0.2	0.8
09/18/2023 21:00	3,660.0	0.0	3,660.0	103,340.0	378.2	0.5	0.2	0.8
09/18/2023 22:00	3,653.6	0.0	3,653.6	103,340.0	377.6	0.5	0.2	0.8
09/18/2023 23:00	3,637.4	0.0	3,637.4	103,340.0	375.9	0.5	0.2	0.8
Average/Sum#:	3,680.2	0.0	3,680.2	103,340.0	380.3	0.5	0.2	0.8
Minimum:	3,620.5	0.0	3,620.5	103,340.0	374.1	0.4	0.2	0.7
Maximum:	4,175.2	0.0	4,175.2	103,340.0	431.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2023 00:00	3,641.0	0.0	3,641.0	103,340.0	376.3	0.5	0.2	0.8
09/19/2023 01:00	3,645.4	0.0	3,645.4	103,340.0	376.7	0.5	0.2	0.8
09/19/2023 02:00	3,648.3	0.0	3,648.3	103,340.0	377.0	0.5	0.2	0.8
09/19/2023 03:00	3,648.7	0.0	3,648.7	103,340.0	377.1	0.5	0.2	0.8
09/19/2023 04:00	3,659.2	0.0	3,659.2	103,340.0	378.1	0.5	0.2	0.8
09/19/2023 05:00	3,886.8	0.0	3,886.8	103,340.0	401.7	0.5	0.2	0.8
09/19/2023 06:00	4,328.1	0.0	4,328.1	103,340.0	447.3	0.5	0.3	0.9
09/19/2023 07:00	3,849.9	0.0	3,849.9	103,340.0	397.8	0.5	0.2	0.8
09/19/2023 08:00	3,653.0	0.0	3,653.0	103,340.0	377.5	0.5	0.2	0.8
09/19/2023 09:00	3,648.7	0.0	3,648.7	103,340.0	377.1	0.5	0.2	0.8
09/19/2023 10:00	3,646.3	0.0	3,646.3	103,340.0	376.8	0.5	0.2	0.8
09/19/2023 11:00	3,641.1	0.0	3,641.1	103,340.0	376.3	0.5	0.2	0.8
09/19/2023 12:00	3,636.3	0.0	3,636.3	103,340.0	375.8	0.5	0.2	0.8
09/19/2023 13:00	3,632.6	0.0	3,632.6	103,340.0	375.4	0.5	0.2	0.8
09/19/2023 14:00	3,625.2	0.0	3,625.2	103,340.0	374.6	0.5	0.2	0.7
09/19/2023 15:00	3,621.9	0.0	3,621.9	103,340.0	374.3	0.5	0.2	0.7
09/19/2023 16:00	3,615.4	0.0	3,615.4	103,340.0	373.6	0.5	0.2	0.7
09/19/2023 17:00	3,811.1	0.0	3,811.1	103,340.0	393.8	0.5	0.2	0.8
09/19/2023 18:00	3,967.4	0.0	3,967.4	103,340.0	410.0	0.5	0.2	0.8
09/19/2023 19:00	3,619.2	0.0	3,619.2	103,340.0	374.0	0.5	0.2	0.7
09/19/2023 20:00	3,626.3	0.0	3,626.3	103,340.0	374.7	0.5	0.2	0.7
09/19/2023 21:00	3,651.9	0.0	3,651.9	103,340.0	377.4	0.5	0.2	0.8
09/19/2023 22:00	3,631.7	0.0	3,631.7	103,340.0	375.3	0.5	0.2	0.8
09/19/2023 23:00	3,632.9	0.0	3,632.9	103,340.0	375.4	0.5	0.2	0.8
Average/Sum#:	3,707.0	0.0	3,707.0	103,340.0	383.1	0.5	0.2	0.8
Minimum:	3,615.4	0.0	3,615.4	103,340.0	373.6	0.5	0.2	0.7
Maximum:	4,328.1	0.0	4,328.1	103,340.0	447.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2023 00:00	3,638.9	0.0	3,638.9	103,340.0	376.0	0.5	0.2	0.8
09/20/2023 01:00	3,634.5	0.0	3,634.5	103,340.0	375.6	0.5	0.2	0.8
09/20/2023 02:00	3,639.1	0.0	3,639.1	103,340.0	376.1	0.5	0.2	0.8
09/20/2023 03:00	3,639.6	0.0	3,639.6	103,340.0	376.1	0.5	0.2	0.8
09/20/2023 04:00	3,641.9	0.0	3,641.9	103,340.0	376.4	0.5	0.2	0.8
09/20/2023 05:00	3,665.3	0.0	3,665.3	103,340.0	378.8	0.5	0.2	0.8
09/20/2023 06:00	3,710.7	0.0	3,710.7	103,340.0	383.5	0.5	0.2	0.8
09/20/2023 07:00	3,667.4	0.0	3,667.4	103,340.0	379.0	0.5	0.2	0.8
09/20/2023 08:00	3,644.2	0.0	3,644.2	103,340.0	376.6	0.5	0.2	0.8
09/20/2023 09:00	3,641.7	0.0	3,641.7	103,340.0	376.3	0.5	0.2	0.8
09/20/2023 10:00	3,637.5	0.0	3,637.5	103,340.0	375.9	0.5	0.2	0.8
09/20/2023 11:00	2,923.0	0.0	2,923.0	103,340.0	302.1	0.5	0.2	0.8
09/20/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/20/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,590.3	0.0	3,590.3	103,340.0	371.0	0.5	0.2	0.8
Minimum:	2,923.0	0.0	2,923.0	103,340.0	302.1	0.5	0.2	0.8
Maximum:	3,710.7	0.0	3,710.7	103,340.0	383.5	0.5	0.2	0.8
%SI	50.00	50.00	50.00	0.00	50.00	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/21/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/22/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/23/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/24/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/25/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 08:00	379.9	0.0	379.9	103,340.0	39.3	0.0	0.0	0.0
09/26/2023 09:00	3,741.3	0.0	3,741.3	103,340.0	386.6	0.5	0.2	0.8
09/26/2023 10:00	3,688.8	0.0	3,688.8	103,340.0	381.2	0.5	0.2	0.8
09/26/2023 11:00	3,658.7	0.0	3,658.7	103,340.0	378.1	0.5	0.2	0.8
09/26/2023 12:00	3,657.9	0.0	3,657.9	103,340.0	378.0	0.5	0.2	0.8
09/26/2023 13:00	3,207.6	0.0	3,207.6	103,340.0	331.5	0.5	0.2	0.8
09/26/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/26/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,055.7	0.0	3,055.7	103,340.0	315.8	0.5	0.2	0.8
Minimum:	379.9	0.0	379.9	103,340.0	39.3	0.5	0.2	0.8
Maximum:	3,741.3	0.0	3,741.3	103,340.0	386.6	0.5	0.2	0.8
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/27/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/28/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/29/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 01:58 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2023 00:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 01:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 02:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 03:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 04:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 05:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 06:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 07:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 08:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 09:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 10:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 11:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 12:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 13:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 14:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 15:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 16:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 17:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 18:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 19:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 20:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 21:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 22:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
09/30/2023 23:00	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,340.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Linearity Report

10/03/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT1_NOXDualRg_P_Instrum	Test End Date/Time:	08/08/2023	Scale: High
Performance Spec:	5 %	Test No.:	125	Highest Error 0.6
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0736	L	200.0	51.3	50.6		25.7
08/08/2023	0741	M	200.0	111.6	111.9		55.8
08/08/2023	0746	H	200.0	184.5	184.7		92.3
08/08/2023	0753	L	200.0	51.3	51.4		25.7
08/08/2023	0758	M	200.0	111.6	112.5		55.8
08/08/2023	0803	H	200.0	184.5	185.0		92.3
08/08/2023	0810	L	200.0	51.3	51.4		25.7
08/08/2023	0815	M	200.0	111.6	112.5		55.8
08/08/2023	0820	H	200.0	184.5	185.0		92.3

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	51.133	No	0.3
M	111.600	112.300	No	0.6
H	184.500	184.900	No	0.2

Linearity Report

10/03/2023

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
 EDR Site ID: CT002 Component ID: A21 ReasonForTest QA
 Component Type: NOXA Grace Period: 0
 Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 08/08/2023 Scale: High
 Performance Spec: 5 % Test No.: 127 Highest Error 1.0
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0838	L	200.0	51.6	51.0		25.8
08/08/2023	0842	M	200.0	111.3	112.2		55.7
08/08/2023	0848	H	200.0	184.8	185.1		92.4
08/08/2023	0855	L	200.0	51.6	51.3		25.8
08/08/2023	0900	M	200.0	111.3	112.4		55.7
08/08/2023	0905	H	200.0	184.8	185.4		92.4
08/08/2023	0912	L	200.0	51.6	51.5		25.8
08/08/2023	0917	M	200.0	111.3	112.6		55.7
08/08/2023	0922	H	200.0	184.8	185.2		92.4

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.600	51.267	No	0.6
M	111.300	112.400	No	1.0
H	184.800	185.233	No	0.2

Linearity Report

10/03/2023

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest QA
		Component Type:	O2D	Grace Period: 0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	08/08/2023	Scale: High
Performance Spec:	5 %	Test No.:	126	Highest Error 1.8
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0937	L	21.0	5.5	5.4		26.2
08/08/2023	0942	M	21.0	11.1	11.0		52.9
08/08/2023	0947	H	21.0	18.0	18.0		85.7
08/08/2023	0954	L	21.0	5.5	5.4		26.2
08/08/2023	0959	M	21.0	11.1	11.0		52.9
08/08/2023	1004	H	21.0	18.0	18.0		85.7
08/08/2023	1011	L	21.0	5.5	5.4		26.2
08/08/2023	1016	M	21.0	11.1	11.0		52.9
08/08/2023	1021	H	21.0	18.0	18.0		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	1.8
M	11.100	11.000	No	0.9
H	18.000	18.000	No	0.0

Linearity Report

10/03/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest QA
		Component Type:	O2D	Grace Period: 0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/08/2023	Scale: High
Performance Spec:	5 %	Test No.:	128	Highest Error 0.7
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	1036	L	21.0	5.0	5.0		23.8
08/08/2023	1041	M	21.0	11.2	11.2		53.3
08/08/2023	1046	H	21.0	18.0	18.0		85.7
08/08/2023	1054	L	21.0	5.0	5.0		23.8
08/08/2023	1059	M	21.0	11.2	11.2		53.3
08/08/2023	1104	H	21.0	18.0	18.0		85.7
08/08/2023	1111	L	21.0	5.0	5.1		23.8
08/08/2023	1116	M	21.0	11.2	11.2		53.3
08/08/2023	1121	H	21.0	18.0	18.0		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	0.7
M	11.200	11.200	No	0.0
H	18.000	18.000	No	0.0

AQ-36 thru AQ-38, AQ-41, & AQ-117

AQ-36 thru AQ-38, AQ-41, & AQ-117: PCAPCD notifications/
corrective action: breakdowns, excess emissions, CEMS inoperable, or a
negative declaration when no excess emissions occurred.

Verification: The Project owner shall include the identification of all
breakdowns, PCAPCD notification, resulting excess emission (if any) and
corrective actions taken (if any) as part of the Quarterly Air Quality
Report required in Condition of Certification AQ-SC6

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:05 Location: Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:05 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:06 Location: Roseville, CA

Tag Name: CT1_CO_SUSd_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:06 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:07 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:08 Location: Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:09 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:09 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:11 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:12 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,189.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 19.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,189.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:12 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:13 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:14 Location: Roseville, CA

Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:15 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:15 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:16 Location: Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:16 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:17 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:17 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2023 00:00 To: 09/30/2023 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/03/2023 02:18 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,639.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 569.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,639.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:00 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:02 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:03 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:03 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2023 00:00 **To:** 09/30/2023 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2023 02:04 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

10/03/2023

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	07:36	L	200	49.800	45.600	24.9
08/08/2023	07:41	M	200	109.200	107.900	54.6
08/08/2023	07:53	L	200	49.800	45.600	24.9
08/08/2023	07:58	M	200	109.200	107.800	54.6
08/08/2023	08:10	L	200	49.800	45.600	24.9
08/08/2023	08:15	M	200	109.200	107.600	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	45.600	Std	8.4
M	109.200	107.767	Std	1.3

Cylinder Gas Audit

10/03/2023

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	08:38	L	200	49.700	50.000	24.9
08/08/2023	08:42	M	200	109.100	113.600	54.6
08/08/2023	08:55	L	200	49.700	50.300	24.9
08/08/2023	09:00	M	200	109.100	113.800	54.6
08/08/2023	09:12	L	200	49.700	50.300	24.9
08/08/2023	09:17	M	200	109.100	113.600	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.700	50.200	Std	1.0
M	109.100	113.667	Std	4.2

Cylinder Gas Audit

10/03/2023

Page 3

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	11:35	L	10	2.400	2.200	24.0
08/08/2023	11:40	M	10	5.700	5.600	57.0
08/08/2023	11:47	L	10	2.400	2.200	24.0
08/08/2023	11:52	M	10	5.700	5.600	57.0
08/08/2023	11:59	L	10	2.400	2.200	24.0
08/08/2023	12:04	M	10	5.700	5.600	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.200	Std	8.3
M	5.700		5.600	Std	1.8

Cylinder Gas Audit

10/03/2023

Page 4

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 08/08/2023

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/08/2023	12:39	L	10	2.400	2.300	24.0
08/08/2023	12:43	M	10	5.700	5.800	57.0
08/08/2023	12:51	L	10	2.400	2.300	24.0
08/08/2023	12:56	M	10	5.700	5.700	57.0
08/08/2023	13:03	L	10	2.400	2.300	24.0
08/08/2023	13:08	M	10	5.700	5.800	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.300	Std	4.2
M	5.700		5.767	Std	1.2

Linearity Report

10/03/2023

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT1_NOXDualRg_P_Instrum	Test End Date/Time:	08/08/2023	Scale: High
Performance Spec:	5 %	Test No.:	125	Highest Error 0.6
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0736	L	200.0	51.3	50.6		25.7
08/08/2023	0741	M	200.0	111.6	111.9		55.8
08/08/2023	0746	H	200.0	184.5	184.7		92.3
08/08/2023	0753	L	200.0	51.3	51.4		25.7
08/08/2023	0758	M	200.0	111.6	112.5		55.8
08/08/2023	0803	H	200.0	184.5	185.0		92.3
08/08/2023	0810	L	200.0	51.3	51.4		25.7
08/08/2023	0815	M	200.0	111.6	112.5		55.8
08/08/2023	0820	H	200.0	184.5	185.0		92.3

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	51.133	No	0.3
M	111.600	112.300	No	0.6
H	184.500	184.900	No	0.2

Linearity Report

10/03/2023

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
 EDR Site ID: CT002 Component ID: A21 ReasonForTest QA
 Component Type: NOXA Grace Period: 0
 Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 08/08/2023 Scale: High
 Performance Spec: 5 % Test No.: 127 Highest Error 1.0
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0838	L	200.0	51.6	51.0		25.8
08/08/2023	0842	M	200.0	111.3	112.2		55.7
08/08/2023	0848	H	200.0	184.8	185.1		92.4
08/08/2023	0855	L	200.0	51.6	51.3		25.8
08/08/2023	0900	M	200.0	111.3	112.4		55.7
08/08/2023	0905	H	200.0	184.8	185.4		92.4
08/08/2023	0912	L	200.0	51.6	51.5		25.8
08/08/2023	0917	M	200.0	111.3	112.6		55.7
08/08/2023	0922	H	200.0	184.8	185.2		92.4

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.600	51.267	No	0.6
M	111.300	112.400	No	1.0
H	184.800	185.233	No	0.2

Linearity Report

10/03/2023

Page 3

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A16 ReasonForTest QA
Component Type: O2D Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 08/08/2023 Scale: High
Performance Spec: 5 % Test No.: 126 Highest Error 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	0937	L	21.0	5.5	5.4		26.2
08/08/2023	0942	M	21.0	11.1	11.0		52.9
08/08/2023	0947	H	21.0	18.0	18.0		85.7
08/08/2023	0954	L	21.0	5.5	5.4		26.2
08/08/2023	0959	M	21.0	11.1	11.0		52.9
08/08/2023	1004	H	21.0	18.0	18.0		85.7
08/08/2023	1011	L	21.0	5.5	5.4		26.2
08/08/2023	1016	M	21.0	11.1	11.0		52.9
08/08/2023	1021	H	21.0	18.0	18.0		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	1.8
M	11.100	11.000	No	0.9
H	18.000	18.000	No	0.0

Linearity Report

10/03/2023

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest QA
		Component Type:	O2D	Grace Period: 0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/08/2023	Scale: High
Performance Spec:	5 %	Test No.:	128	Highest Error 0.7
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/08/2023	1036	L	21.0	5.0	5.0		23.8
08/08/2023	1041	M	21.0	11.2	11.2		53.3
08/08/2023	1046	H	21.0	18.0	18.0		85.7
08/08/2023	1054	L	21.0	5.0	5.0		23.8
08/08/2023	1059	M	21.0	11.2	11.2		53.3
08/08/2023	1104	H	21.0	18.0	18.0		85.7
08/08/2023	1111	L	21.0	5.0	5.1		23.8
08/08/2023	1116	M	21.0	11.2	11.2		53.3
08/08/2023	1121	H	21.0	18.0	18.0		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	0.7
M	11.200	11.200	No	0.0
H	18.000	18.000	No	0.0