

DOCKETED

Docket Number:	22-BSTD-01
Project Title:	2025 Energy Code Pre-Rulemaking
TN #:	253244
Document Title:	Matthew Friedlander Comments - Please adopt ASHRAE 622 2022
Description:	N/A
Filer:	System
Organization:	Matthew Friedlander
Submitter Role:	Other Interested Person
Submission Date:	11/17/2023 4:53:21 PM
Docketed Date:	11/17/2023

Comment Received From: Matthew Friedlander
Submitted On: 11/17/2023
Docket Number: 22-BSTD-01

Please adopt ASHRAE 622 2022

The most recent version of ASHRAE 62.2 is 2022 with addenda d, e, i, k, and m. This version contains numerous clarifications, including: (1) requirements for ventilation rate, control, and operation are now easier to follow, enforce, and maintain over time; (2) new definition of "readily accessible" and "accessible" is consistent with 2020 NEC and less ambiguous; (3) clarifies the requirements for installation and operation; (4) requires a supply or balanced mechanical ventilation system where new multifamily dwelling units are accessed by an enclosed common corridor; (5) removes the option of providing an operable window in place of mechanical exhaust within toilet rooms for new construction, consistent with new understandings of hazardous bioaerosols from human waste; (6) sets ozone emission limits for air cleaners.