DOCKETED			
Docket Number:	23-SPPE-01		
Project Title:	STACK SVY03A Data Center Campus		
TN #:	254766		
Document Title:	SVY03A Campus Supplemental Data Responses Set 1 DR-9		
Description:	N/A		
Filer:	Scott Galati		
Organization:	DayZenLLC		
Submitter Role:	Applicant Representative		
Submission Date:	3/1/2024 11:39:00 AM		
Docketed Date:	3/1/2024		

SUPPLEMENTAL RESPONSE TO CEC STAFF DATA REQUEST SET 1 (DR-9)

STACK SVY03A Campus (23-SPPE-01)

SUBMITTED TO: CALIFORNIA ENERGY COMMISSION SUBMITTED BY: **STACK Infrastructure**

March 2024



INTRODUCTION

Attached is STACK Infrastructure's (STACK) supplemental response to California Energy Commission (CEC) Staff Data Request number 9 (CC Staff Set No. 1) for the SVY03A Data Center Campus (SVY03A Campus) Application for Small Power Plant Exemption (SPPE) (23-SPPE-01).

AIR QUALITY AND GREENHOUSE EMISSIONS

BACKGROUND: Insulative Gas Used in Circuit Breakers and Transformers

On page 31 of Part 1 of the application, the PG&E switchyard and the project substation will not use sulfur hexafluoride (SF6) unless the short circuit current rating is greater than 63kA to align with California Air Resources Board (CARB) requirements.

DATA REQUEST

9. Please discuss the alternative that will be used instead of SF6 and quantify the GHG emissions associated with the alternative.

RESPONSE TO DATA REQUEST 9

There are two alternatives under consideration for equipment that will not use SF6. However, the actual alternative will not be selected until the design of the SVY03 Campus progresses. One alternative from Siemens uses N2 and O2 and therefore would not have any GHG emissions from leakage.

The other alternative is from Hitachi/ABB. The gas mixture used in this equipment is C4-FN and an estimate of the associated GHG emissions from potential leakage.

CO2e Emissions Calculations for C4F7N Gas

Substance	Mol%	Mol Wt.	Wt%
C4F7N	5	195	19.504
CO2	82	44	72.174
O2	13	32	8.322 (not a GHG, not further considered)

System Capacity: 500 kg which equals 1102.3 lbs

C4F7N = 214.99 lbs

CO2 = 795.57 lbs

Annual Leak Rate of System: 0.3% wt which equals 0.003 (wt fraction)

Leakage GWP

C4F7N = 0.645 lbs/yr 2750

CO2 = 2.39 lbs/yr 1

Total CO2e Emissions

C4F7N = 1773.75 lbs/yr

CO2 = 2.39 lbs/yr

= 1776.1 lbs CO2e/yr

= 0.89 tons CO2e/yr