

DOCKETED	
Docket Number:	21-AFC-02
Project Title:	Willow Rock Energy Storage Center
TN #:	254809
Document Title:	Willow Rock Energy Storage Center SAFC Volume II-Appendix 515A-Part I
Description:	N/A
Filer:	Amanda Cooley
Organization:	Ellison Schneider Harris & Donlan LLP
Submitter Role:	Applicant Representative
Submission Date:	3/1/2024 5:20:21 PM
Docketed Date:	3/4/2024

APPENDIX 15.5A

**Antelope Valley-East Kern Water Agency
2022 Annual Water Quality Summary Table –
Kern County System**

Antelope Valley-East Kern Water Agency
2022 Annual Water Quality Report - Kern County System

The Antelope Valley-East Kern Water Agency provides treated surface water and treated groundwater as our sources of drinking water.

Treatment technique: Conventional

EPA Turbidity Performance Standards: Turbidity of the filtered water must:

1. Be less than or equal to 0.30 NTU in 95% of measurements in a month.
2. Not exceed 1 NTU at any time.

Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1: **100%**

Highest single turbidity measurement during the year: **0.19 NTU**

Percentage of samples < 0.30 NTU: **100%**

The number of violations of any surface water treatment requirements: **NONE**

Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

The Antelope Valley-East Kern Water Agency also provides chlorinated groundwater as an alternative source of drinking water.

Treatment technique: Chlorination

EPA Groundwater Rule: AVEK meets the requirements of the Groundwater Rule by providing a minimum of 4-log reduction of viruses by continuously providing a minimum free chlorine residual of 0.5 mg/L leaving the clearwell.

Lowest single free chlorine residual measurement during the year: **0.89**

Number of violations of the Groundwater Rule: **NONE**

MICROBIOLOGICAL CONTAMINANTS

<u>Type of Sample(s)</u>	<u>Parameter</u>	<u>Sampling Frequency</u>	<u>MCL</u>	<u>No. of Months in Violation</u>	<u>System Results</u>	
					<u>Range</u>	<u>Average</u>
Distribution	Total Coliform Bacteria	56 - 70 / mo	5% positive	None	0%	0%
Distribution	E. coli	56 - 70 / mo	1 pos. with 2 TC pos.	None	0%	0%

INORGANIC CONTAMINANTS

					RESULTS							
					Rosamond Plant				Water Bank			
<u>Parameter</u>	<u>Units</u>	<u>MCL</u>	<u>DLR</u>	<u>PHG</u>	<u>Plant Effluent (CWR)</u>		<u>Raw Influent (Sources)</u>		<u>Effluent (CWR)</u>		<u>Wells</u>	
					<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>
Aluminum	µg/L	1000	50	600	93-250	130	ND	ND				
Antimony	µg/L	6	6	1		ND	ND	ND				
Arsenic	µg/L	10	2	0.004		3.6	3.2-8.1	5.0	2.5-7.3	5.5	2.2-12	5.2
Barium	µg/L	1000	100	2000		58	30-58	44				
Beryllium	µg/L	4	1	1		ND	ND	ND				
Cadmium	µg/L	5	1	0.04		ND	ND	ND				
Chromium (Total)	µg/L	50	10			5.1	5.1-15	11				
Chromium (Hexavalent)	µg/L	*	1	0.02		5.8	5.4-14	8.6				
Cyanide	µg/L	150	100	150		ND	ND	ND				
Fluoride	mg/L	2	0.1	1		0.28	0.29-0.36	0.32				
Mercury	µg/L	2	1	1.2		ND	ND	ND				
Nickel	µg/L	100	10	12		ND	ND	ND				
Nitrate (as N)	mg/L	10	0.4	10		2.5	1.2-2.5	1.9			1.2-4.5	2.5
Nitrite (as N)	mg/L	1	0.4	1		ND	ND	ND			ND	ND
Nitrate+Nitrite (as N)	mg/L	10		10		2.5	ND-2.5	0.83			1.5-3.4	2.2
Perchlorate	µg/L	6	2	1		ND	ND	ND			ND	ND
Selenium	µg/L	50	5	30		ND	ND	ND				
Thallium	µg/L	2	1	0.1		ND	ND	ND				

*There is currently no MCL for hexavalent chromium. The previous MCL of 0.010 mg/L was withdrawn on September 11, 2017.

Antelope Valley-East Kern Water Agency
2022 Annual Water Quality Report - Kern County System

GENERAL PHYSICAL AND SECONDARY STANDARDS

Parameter	Units	MCL	DLR	RESULTS							
				Rosamond Plant		Water Bank		Effluent (CWR)		Wells	
				Plant Effluent (CWR)	Raw Influent (Sources)	Plant Effluent (CWR)	Raw Influent (Sources)	Effluent (CWR)	Raw Influent (Sources)	Effluent (CWR)	Raw Influent (Sources)
				Range	Average	Range	Average	Range	Average	Range	Average
Aluminum	µg/L	1000	50	93-250	140	ND	ND				
Calcium	mg/L	no standard			63	63-97	74				
Chloride	mg/L	250			54	40-53	47				
Color	Units	15		<5	<5	<5	<5				
Copper	µg/L	1000	50		ND	ND	ND				
Foaming Agents (MBAS)	mg/L	0.5			ND	ND	ND				
Hardness (Total) as CaCO ₃	mg/L	no standard			200	91-200	140				
Iron	µg/L	300	100		ND	ND	ND				
Magnesium	mg/L	no standard			9.7	5.7-9.7	8.3				
Manganese	µg/L	50	20		ND	ND	ND				
Odor @ 60 C	Units	3	1	<1	<1	<1	<1				
pH	Units	no standard		7.3-7.9	7.6	7.7-8.6	8.0				
Silver	µg/L	100	10			ND	ND				
Sodium	mg/L	no standard			46	ND-44	15				
Specific Conductance	µmhos	900			580	420-580	500				
Sulfate	mg/L	250	0.5		60	47-58	53				
Thiobencarb (Bolero)	µg/L	1	1		ND	ND	ND				
Methyl tert-Butyl Ether (MTBE)	µg/L	5	3		ND	ND	ND				
Total Dissolved Solids	mg/L	500			330	240-320	290				
Turbidity	Units	5		0.01-0.20	0.05	0.02-1.1	0.10				
Zinc	µg/L	5000	50		450	ND	ND				
Total Alkalinity (as CaCO ₃)	mg/L	no standard			140	120-150	140				
Bicarbonate Alkalinity(as HCO ₃)	mg/L	no standard			140	ND-150	50				
Carbonate (as CO ₃)	mg/L	no standard			ND	ND	ND				
Hydroxide (as OH)	mg/L	no standard			ND	ND	ND				

RADIOLOGICAL CONTAMINANTS

Parameter	Units	MCL	DLR	PHG	RESULTS			
					Rosamond Plant		Water Bank	
					Raw Influent Sources	Wells	Raw Influent Sources	Wells
					Range	Average	Range	Average
Gross Alpha	pCi/L	15	3					
Gross Beta	pCi/L	50	4			ND		
Strontium 90	pCi/L	8	2	0.35				
Tritium	pCi/L	20,000	1,000	400				
Uranium	pCi/L	20	1	0.43		3.5		
Radium 228	pCi/L		1	0.019		ND		
Radium 226	pCi/L		1	0.05		ND		

VOLATILE ORGANIC CONTAMINANTS

Parameter	Units	MCL	DLR	PHG	RESULTS			
					Rosamond Plant		Water Bank	
					Raw Influent (Sources)	Wells	Raw Influent (Sources)	Wells
					Range	Average	Range	Average
1,1,1-Trichloroethane (1,1,1-TCA)	µg/L	200	0.5	1000	ND	ND	ND	ND
1,1,2,2-Tetrachloroethane	µg/L	1	0.5	0.1	ND	ND	ND	ND
1,1,2-Trichloroethane (1,1,2-TCA)	µg/L	5	0.5	0.3	ND	ND	ND	ND
1,1-Dichloroethane (1,1-DCA)	µg/L	5	0.5	3	ND	ND	ND	ND
1,1-Dichloroethylene (1,1-DCE)	µg/L	6	0.5	10	ND	ND	ND	ND
1,2,4-Trichlorobenzene	µg/L	5	0.5	5	ND	ND	ND	ND
1,2-Dichlorobenzene (o-DCB)	µg/L	600	0.5	600	ND	ND	ND	ND

Antelope Valley-East Kern Water Agency
2022 Annual Water Quality Report - Kern County System

<u>Parameter</u>	<u>Units</u>	<u>MCL</u>	<u>DLR</u>	<u>PHG</u>	<u>Rosamond Plant</u>		<u>Water Bank Wells</u>	
					<u>Raw Influent (Sources)</u>			
					<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>
1,2-Dichloroethane (1,2-DCA)	µg/L	0.5	0.5	0.4	ND	ND	ND	ND
1,2-Dichloropropane	µg/L	5	0.5	0.5	ND	ND	ND	ND
1,3-Dichloropropene (Total)	µg/L	0.5	0.5	0.2	ND	ND	ND	ND
1,4-Dichlorobenzene (p-DCB)	µg/L	5	0.5	6	ND	ND	ND	ND
Benzene	µg/L	1	0.5	0.15	ND	ND	ND	ND
Carbon tetrachloride	µg/L	0.5	0.5	0.1	ND	ND	ND	ND
cis-1,2-Dichloroethylene (c-1,2-DCE)	µg/L	6	0.5	100	ND	ND	ND	ND
cis-1,3-Dichloropropene	µg/L				ND	ND	ND	ND
Dichloromethane (Methylene Chloride)	µg/L	5	0.5	4	ND	ND	ND	ND
Ethylbenzene	µg/L	300	0.5	300	ND	ND	ND	ND
Methyl-tert-butyl ether (MTBE)	µg/L	13	3	13	ND	ND	ND	ND
Monochlorobenzene (Chlorobenzene)	µg/L	70	0.5	70	ND	ND	ND	ND
Styrene	µg/L	100	0.5	0.5	ND	ND	ND	ND
Tetrachloroethylene (PCE)	µg/L	5	0.5	0.06	ND	ND	ND	ND
Toluene	µg/L	150	0.5	150	ND	ND	ND	ND
trans-1,2-Dichloroethylene (t-1,2-DCE)	µg/L	10	0.5	60	ND	ND	ND	ND
trans-1,3-Dichloropropene	µg/L				ND	ND	ND	ND
Trichloroethylene (TCE)	µg/L	5	0.5	1.7	ND	ND	ND	ND
Trichlorofluoromethane (Freon11)	µg/L	150	5	1300	ND	ND	ND	ND
Trichlorotrifluoroethane (Freon 113)	µg/L	1200	10	4000	ND	ND	ND	ND
Vinyl Chloride (VC)	µg/L	0.5	0.5	0.05	ND	ND	ND	ND
Xylenes (Total)	µg/L	1750	0.5	1800	ND	ND	ND	ND

SYNTHETIC ORGANIC CHEMICALS

RESULTS

<u>Parameter</u>	<u>Units</u>	<u>MCL</u>	<u>DLR (DL)</u>	<u>PHG</u>	<u>Raw Influent (Sources)</u>		<u>Water Bank Wells</u>	
					<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>
Alachlor	µg/L	2	1	4	ND	ND		
Atrazine	µg/L	1	0.5	0.15	ND	ND		
Bentazon	µg/L	18	2	200	ND	ND		
Benzo(a)pyrene	µg/L	0.2	0.1	0.007	ND	ND		
Carbofuran	µg/L	18	5	0.7	ND	ND		
Chlordane	µg/L	0.1	0.1	0.03	ND	ND		
2,4-D	µg/L	70	10	20	ND	ND		
Dalapon	µg/L	200	10	790	ND	ND		
Dibromochloropropane (DBCP)	µg/L	0.2	0.01	0.0017	ND	ND		
Di(2-ethylhexyl)adipate	µg/L	400	5	200	ND	ND		
Di(2-ethylhexyl)phthalate	µg/L	4	3	12	ND	ND		
Dinoseb	µg/L	7	2	14	ND	ND		
Diquat	µg/L	20	4	6	ND	ND		
Endothall	µg/L	100	45	94	ND	ND		
Endrin	µg/L	2	0.1	0.3	ND	ND		
Ethylene Dibromide (EDB)	µg/L	0.05	0.02	0.01	ND	ND		
Glyphosate	µg/L	700	25	900	ND	ND		
Heptachlor	µg/L	0.01	0.01	0.008	ND	ND		
Heptachlor Epoxide	µg/L	0.01	0.01	0.006	ND	ND		
Hexachlorobenzene	µg/L	1	0.5	0.03	ND	ND		
Hexachlorocyclopentadiene	µg/L	50	1	2	ND	ND		
Lindane	µg/L	0.2	0.2	0.032	ND	ND		
Methoxychlor	µg/L	30	10	0.09	ND	ND		
Molinate	µg/L	20	2	1	ND	ND		
Oxamyl	µg/L	50	20	26	ND	ND		
Pentachlorophenol	µg/L	1	0.2	0.3	ND	ND		
Picloram	µg/L	500	1	166	ND	ND		

Antelope Valley-East Kern Water Agency
2022 Annual Water Quality Report - Kern County System

<u>Parameter</u>	<u>Units</u>	<u>MCL</u>	<u>DLR (DL)</u>	<u>PHG</u>	<u>Raw Influent (Sources)</u>		<u>Water Bank Wells</u>	
					<u>Range</u>	<u>Average</u>	<u>Range</u>	<u>Average</u>
Polychlorinated Biphenyls	µg/L	0.5	0.5	0.09	ND	ND		
Simazine	µg/L	4	1	4	ND	ND		
Thiobencarb (Bolero)	µg/L	70	1	42	ND	ND		
Toxaphene	µg/L	3	1	0.03	ND	ND		
2,3,7,8-TCDD (Dioxin)	pg/L	30	5	0.05	ND	ND		
2,4,5-TP (Silvex)	µg/L	50	1	3	ND	ND		
1,2,3-Trichloropropane	µg/L	0.005	0.005	0.0007	ND	ND		

DISINFECTION RESIDUAL, PRECURSORS, and BYPRODUCTS

<u>Type of Sample(s)</u>	<u>Parameter</u>	<u>Units</u>	<u>MCL/MRDL</u>	<u>DLR</u>	<u>MRDLG</u>	<u>RESULTS</u>	
						<u>Range</u>	<u>Average</u>
Distribution	Chlorine (as total Cl ₂)	mg/L	4.0**		4	0.26-1.48	1.07
Treated Water	Total Organic Carbon (TOC)	mg/L	Treatment Requirement	0.3		0.4-0.9	0.6
Source Water	Total Organic Carbon (TOC)	mg/L	Treatment Requirement	0.3		0.5-0.9	0.6
Distribution	Stage 2 D/DBP Rule Total Trihalomethanes	µg/L	80**			14-25	20 #
Distribution	Stage 2 D/DBP Rule Total Haloacetic Acids	µg/L	60**			2.2-7.2	2.1 #
Treated Water	Bromate	µg/L	10*	1.0		ND	ND

** Running Annual Average of distribution system samples. The MCLs are based upon Running Annual Averages.

Stage 2 D/DBP Rule Total THMs and Total HAAs compliance is based upon Locational Running Annual Averages.

Location with the highest TTHM average

* Compliance is based on the running annual average computed quarterly, of monthly samples, collected at the entrance to the distribution system.

DEFINITIONS and FOOTNOTES:

Plant Effluent, CWR, is finished, treated drinking water.

Raw Water is the Source Water, the California Aqueduct or wells, prior to treatment.

Units: mg/L = milligrams per liter, parts per million (ppm)

µg/L = micrograms per liter, parts per billion (ppb)

pg/L = picograms per liter, parts per quadrillion (ppq)

µmhos = micromhos, a measure of specific conductance

pCi/L = pico Curies per liter

< = less than

> = greater than

ND = none detected above the DLR

NTU = nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set by the US Environmental Protection Agency or the State Water Resources Control Board as close to the PHGs and MCLGs as is economically or technologically feasible.

MRDL: Maximum Residual Disinfectant Level. The level of a disinfectant added for water treatment that may not exceeded at the consumer's tap.

DLR: Detection Limit for purposes of Reporting.

(DL): Detection limit determined by the Laboratory when no DLR has been established.

MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

MRDLG: Maximum Residual Disinfectant Level Goal. The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the US Environmental Protection Agency.

PHG: Public Health Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Office of Environmental Health Hazard


Primary Drinking Water Standard: Primary MCLs, specific treatment techniques adopted in lieu of primary MCLs, and monitoring and reporting requirements for MCLs that are specified in regulations. Assessment.

Secondary Standards: Aesthetic standards established by the State Water Resources Control Board.

All analyses performed by ELAP certified laboratories: AVEK Water Agency, Eurofins Eaton Analytical Laboratories, or Eurofins subcontract lab.

APPENDIX 15.5B

**Grading and Drainage Plan,
Stormwater Basin Design
Drawings, and Supporting
Calculations**





- NOTES:
1. POND DETAIL
RESERVOIR BERM ELEV: 2570.00
RESERVOIR BERM EXTERIOR SLOPE MIN. TOE ELEV: 2564.00
TOP OF WORKING RESERVOIR / MAX POOL: 2566.00
BOTTOM OF SUMP: 2512.00
WORKING RESERVOIR STORAGE VOLUME: 188 MG
MAX POOL SURFACE AREA: 21.4 AC
- NOTES:
1. PRELIMINARY EARTHWORK QUANTITIES:
SITE
CUT= 99,810 CY
FILL= 72,940 CY
BERM
CUT = 18,785 CY
FILL = 199,793 CY
 2. BALANCE VOLUMES ARE FROM EXISTING GROUND TO MASS GRADE.
 3. REFER TO PLOT PLAN (PP-001) FOR EQUIPMENT LAYOUT.

- PRELIMINARY -
NOT FOR CONSTRUCTION

0	ISSUED FOR A/C	R. PILES	01-05-24
REV	A. ROSS DESIGN BY	CHECKED BY	DATE
HYDROSTOR WILLOW ROCK ENERGY STORAGE CENTER			
HYDROSTOR			
Kiewit			
GRADING PLAN OPERATIONS PHASE - WITH BERM			
ENGINEER/DESIGN ORIGINATOR LEAD ENG ENG MGR PROJ MGR	A. ROSS R. PILES S. GAMER J. LUNDQUIST	DRAWING NUMBER	20045352-CG-001



SS:ISSUEDNESS
SS:ISSUEDNESS
SS:ISSUEDNESS
SS:ISSUEDNESS





- NOTES:
1. POND DETAIL
RESERVOIR BERM ELEV: 2570.00
RESERVOIR BERM EXTERIOR SLOPE MIN. TOE ELEV: 2564.00
TOP OF WORKING RESERVOIR / MAX POOL: 2566.00
BOTTOM OF WORKING RESERVOIR: 2526.00
BOTTOM OF SUMP: 2512.00
WORKING RESERVOIR STORAGE VOLUME: 188 MG
MAX POOL SURFACE AREA: 21.4 AC
 1. PRELIMINARY EARTHWORK QUANTITIES:
SITE
BEDROCK CUT = 1,539 CY
CUT = 957,665 CY
FILL = 1,200,790 CY
BERM
SAND STRIP = 537,784 CY
CUT = 4,044 CY
FILL = 1,250,472 CY
 2. BALANCE VOLUMES ARE FROM EXISTING GROUND TO MASS GRADE.
 3. REFER TO PLOT PLAN (PP-001) FOR EQUIPMENT LAYOUT.

- PRELIMINARY -
NOT FOR CONSTRUCTION

0	ISSUED FOR A/C	R. PILES	01-05-24
REV	A. ROSS DESIGN BY	CHECKED BY	DATE
HYDROSTOR WILLOW ROCK ENERGY STORAGE CENTER			
 			
GRADING PLAN CONSTRUCTION PHASE - WITH BERM			
ENGINEER/DESIGN ORIGINATOR LEAD ENG ENG MGR PROJ MGR	A. ROSS R. PILES S. GAMER J. LUNDQUIST	DRAWING NUMBER	20045352-CG-002



SS:USERMANESS
SS:USERMANESS
SS:TIMESS
SS:DATESS