

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	258132
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2024 - Part 4 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public
Submission Date:	7/29/2024 1:55:31 PM
Docketed Date:	7/29/2024

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:27 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2024	0.00	0.00	0.00	0.00	0.00
04/02/2024	264.20	23.52	1.27	2.55	4.22
04/03/2024	0.00	0.00	0.00	0.00	0.00
04/04/2024	67.06	60.47	4.96	9.97	16.60
04/05/2024	15.68	55.70	6.09	12.20	20.34
04/06/2024	15.28	49.60	5.41	10.86	18.09
04/07/2024	15.58	48.94	5.30	10.59	17.63
04/08/2024	15.56	49.71	5.51	10.98	18.25
04/09/2024	55.92	72.05	6.75	13.42	22.39
04/10/2024	61.97	73.23	6.91	13.79	22.96
04/11/2024	41.90	52.91	5.50	10.98	18.25
04/12/2024	14.83	48.15	5.28	10.56	17.55
04/13/2024	15.74	47.62	5.28	10.56	17.52
04/14/2024	15.65	46.83	5.32	10.63	17.66
04/15/2024	15.22	46.23	5.28	10.56	17.54
04/16/2024	15.50	46.08	5.28	10.51	17.49
04/17/2024	15.09	47.62	5.28	10.56	17.55
04/18/2024	14.45	47.17	5.28	10.56	17.62
04/19/2024	13.71	47.27	5.29	10.53	17.51
04/20/2024	13.64	47.05	5.28	10.54	17.55
04/21/2024	14.03	46.92	5.38	10.76	17.90
04/22/2024	14.84	47.89	5.49	10.98	18.29
04/23/2024	14.22	50.12	5.71	11.37	18.92
04/24/2024	13.93	48.21	5.43	10.86	18.10
04/25/2024	14.32	48.19	5.45	10.91	18.20
04/26/2024	13.91	47.66	5.28	10.57	17.69
04/27/2024	14.41	48.59	5.40	10.82	18.07
04/28/2024	14.17	49.23	5.56	11.13	18.55
04/29/2024	14.42	47.48	5.41	10.83	18.01
04/30/2024	14.65	50.22	5.65	11.28	18.80
Monthly Avg/Sum:	829.88 sum	1,394.66 sum	150.03 sum	299.86 sum	499.25 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	264.20	73.23	6.91	13.79	22.96
Apr 2024 - Apr 2024	829.88 sum	1,394.66 sum	150.03 sum	299.86 sum	499.25 sum
QTD:	829.88 sum	1,394.66 sum	150.03 sum	299.86 sum	499.25 sum
YTD 2024:	2,447.68 sum	5,381.90 sum	576.91 sum	1,152.82 sum	1,920.78 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:27 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2024	15.04	51.23	6.03	12.20	20.06
05/02/2024	14.38	48.09	5.61	11.17	18.65
05/03/2024	13.92	46.92	5.48	10.84	18.09
05/04/2024	58.55	55.65	5.75	11.47	19.05
05/05/2024	14.76	46.16	5.26	10.45	17.41
05/06/2024	14.57	46.60	5.28	10.34	17.30
05/07/2024	14.92	45.59	5.28	10.34	17.31
05/08/2024	13.67	45.12	5.30	10.49	17.51
05/09/2024	15.12	76.95	5.61	11.08	18.66
05/10/2024	14.87	45.28	5.41	10.72	17.87
05/11/2024	14.73	47.38	5.62	11.19	18.66
05/12/2024	14.63	44.89	5.29	10.51	17.50
05/13/2024	14.54	45.97	5.36	10.61	17.69
05/14/2024	16.98	50.69	5.68	11.35	18.79
05/15/2024	14.31	45.40	5.37	10.64	17.72
05/16/2024	42.72	54.46	6.86	13.63	22.77
05/17/2024	13.99	45.83	5.39	10.79	17.97
05/18/2024	12.41	41.24	5.28	10.54	17.51
05/19/2024	13.73	44.76	5.28	10.49	17.45
05/20/2024	54.89	60.15	5.73	11.31	18.89
05/21/2024	24.10	138.29	15.16	30.42	50.64
05/22/2024	20.78	147.88	16.17	32.35	53.88
05/23/2024	37.29	96.97	9.96	19.95	33.25
05/24/2024	15.33	53.25	5.61	11.40	18.92
05/25/2024	15.12	52.74	5.59	11.27	18.76
05/26/2024	15.25	52.17	5.52	11.17	18.61
05/27/2024	95.73	88.59	8.01	16.12	26.84
05/28/2024	15.23	52.96	5.61	11.41	18.97
05/29/2024	36.19	83.07	7.95	15.34	26.49
05/30/2024	58.41	69.35	5.17	9.98	17.27
05/31/2024	14.81	53.12	5.71	11.50	19.15
Monthly Avg/Sum:	750.97 sum	1,876.75 sum	201.33 sum	401.07 sum	669.64 sum
Daily Min:	12.41	41.24	5.17	9.98	17.27
Daily Max:	95.73	147.88	16.17	32.35	53.88
Apr 2024 - May 2024	1,580.85 sum	3,271.41 sum	351.36 sum	700.93 sum	1,168.89 sum
QTD:	1,580.85 sum	3,271.41 sum	351.36 sum	700.93 sum	1,168.89 sum
YTD 2024:	3,198.65 sum	7,258.65 sum	778.24 sum	1,553.89 sum	2,590.42 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:27 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2024	15.10	52.25	5.60	11.25	18.77
06/02/2024	70.49	80.50	7.30	14.76	24.54
06/03/2024	14.35	51.65	5.52	11.12	18.56
06/04/2024	14.41	51.96	5.71	11.41	19.06
06/05/2024	97.86	78.68	8.64	17.33	28.89
06/06/2024	14.24	53.34	5.76	11.68	19.40
06/07/2024	13.92	53.07	5.72	11.49	19.12
06/08/2024	14.02	52.38	5.59	11.28	18.75
06/09/2024	14.21	52.29	5.57	11.26	18.71
06/10/2024	16.17	58.13	6.24	12.57	20.93
06/11/2024	17.11	64.21	6.99	14.05	23.37
06/12/2024	17.04	55.96	6.94	13.94	23.22
06/13/2024	95.04	81.81	7.83	15.65	26.08
06/14/2024	176.73	81.25	6.19	12.34	20.51
06/15/2024	35.75	52.66	5.55	11.17	18.63
06/16/2024	21.86	52.33	5.75	11.50	19.16
06/17/2024	37.53	55.49	6.02	12.15	20.22
06/18/2024	31.96	54.92	6.23	12.41	20.70
06/19/2024	111.40	74.25	6.66	13.31	22.19
06/20/2024	27.60	67.73	7.18	14.20	23.91
06/21/2024	69.74	93.45	9.62	19.28	32.14
06/22/2024	34.17	48.61	5.55	11.08	18.44
06/23/2024	32.21	74.42	7.30	14.58	24.25
06/24/2024	90.70	95.39	8.93	17.88	29.79
06/25/2024	30.15	123.91	13.94	27.88	46.38
06/26/2024	30.06	97.48	11.22	22.29	37.18
06/27/2024	30.56	96.17	10.85	21.54	35.96
06/28/2024	31.29	94.38	10.71	21.34	35.56
06/29/2024	30.94	92.97	10.59	21.30	35.42
06/30/2024	31.68	92.72	10.56	21.13	35.26
Monthly Avg/Sum:	1,268.29 sum	2,134.36 sum	226.26 sum	453.17 sum	755.10 sum
Daily Min:	13.92	48.61	5.52	11.08	18.44
Daily Max:	176.73	123.91	13.94	27.88	46.38
Apr 2024 - Jun 2024	2,849.14 sum	5,405.77 sum	577.62 sum	1,154.10 sum	1,923.99 sum
QTD:	2,849.14 sum	5,405.77 sum	577.62 sum	1,154.10 sum	1,923.99 sum
YTD 2024:	4,466.94 sum	9,393.01 sum	1,004.50 sum	2,007.06 sum	3,345.52 sum

Monthly Summary By Day Report



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2024	38.0	0.0	0.0	0.0
04/02/2024	49.5	0.0	76.3	14.4
04/03/2024	42.1	0.0	0.0	0.0
04/04/2024	79.2	24.5	0.0	0.0
04/05/2024	0.0	0.0	0.0	0.0
04/06/2024	0.0	0.0	0.0	0.0
04/07/2024	0.0	0.0	0.0	0.0
04/08/2024	0.0	0.0	0.0	0.0
04/09/2024	0.0	0.0	29.3	12.5
04/10/2024	0.0	0.0	39.4	13.1
04/11/2024	0.0	0.0	11.6	2.2
04/12/2024	0.0	0.0	0.0	0.0
04/13/2024	0.0	0.0	0.0	0.0
04/14/2024	0.0	0.0	0.0	0.0
04/15/2024	0.0	0.0	0.0	0.0
04/16/2024	0.0	0.0	0.0	0.0
04/17/2024	0.0	0.0	0.0	0.0
04/18/2024	0.0	0.0	0.0	0.0
04/19/2024	0.0	0.0	0.0	0.0
04/20/2024	0.0	0.0	0.0	0.0
04/21/2024	0.0	0.0	0.0	0.0
04/22/2024	0.0	0.0	0.0	0.0
04/23/2024	0.0	0.0	0.0	0.0
04/24/2024	0.0	0.0	0.0	0.0
04/25/2024	0.0	0.0	0.0	0.0
04/26/2024	0.0	0.0	0.0	0.0
04/27/2024	0.0	0.0	0.0	0.0
04/28/2024	0.0	0.0	0.0	0.0
04/29/2024	0.0	0.0	0.0	0.0
04/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	208.8 sum	24.5 sum	156.6 sum	42.2 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	79.2	24.5	76.3	14.4
Apr 2024 - Apr 2024	208.8 sum	24.5 sum	156.6 sum	42.2 sum
QTD:	208.8 sum	24.5 sum	156.6 sum	42.2 sum
YTD 2024:	441.5 sum	28.4 sum	369.8 sum	94.0 sum

Monthly Summary By Day Report



From: 04/01/2024 00:00 To: 06/30/2024 23:59

Generated: 07/03/2024 23:26

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
05/01/2024	0.0	0.0	0.0	0.0
05/02/2024	0.0	0.0	0.0	0.0
05/03/2024	0.0	0.0	0.0	0.0
05/04/2024	0.0	0.0	41.4	4.5
05/05/2024	0.0	0.0	0.0	0.0
05/06/2024	0.0	0.0	0.0	0.0
05/07/2024	0.0	0.0	0.0	0.0
05/08/2024	0.0	0.0	0.0	0.0
05/09/2024	0.0	0.0	0.0	0.0
05/10/2024	0.0	0.0	0.0	0.0
05/11/2024	0.0	0.0	0.0	0.0
05/12/2024	0.0	0.0	0.0	0.0
05/13/2024	0.0	0.0	0.0	0.0
05/14/2024	0.0	0.0	0.0	0.0
05/15/2024	0.0	0.0	0.0	0.0
05/16/2024	0.0	0.0	11.7	2.1
05/17/2024	0.0	0.0	0.0	0.0
05/18/2024	0.0	0.0	0.0	0.0
05/19/2024	0.0	0.0	0.0	0.0
05/20/2024	0.0	0.0	38.4	13.8
05/21/2024	0.0	0.0	0.0	0.0
05/22/2024	0.0	0.0	0.0	0.0
05/23/2024	23.9	1.9	0.0	0.0
05/24/2024	0.0	0.0	0.0	0.0
05/25/2024	0.0	0.0	0.0	0.0
05/26/2024	0.0	0.0	0.0	0.0
05/27/2024	93.0	18.9	0.0	0.0
05/28/2024	0.0	0.0	0.0	0.0
05/29/2024	0.0	0.0	10.1	2.4
05/30/2024	0.0	0.0	31.3	12.8
05/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	116.9 sum	20.8 sum	132.9 sum	35.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	93.0	18.9	41.4	13.8
Apr 2024 - May 2024	325.7 sum	45.3 sum	289.5 sum	77.8 sum
QTD:	325.7 sum	45.3 sum	289.5 sum	77.8 sum
YTD 2024:	558.4 sum	49.2 sum	502.7 sum	129.6 sum

Monthly Summary By Day Report



From:

04/01/2024 00:00

To:

06/30/2024 23:59

Facility Name:

ROSEVILLE ENERGY

Generated:

07/03/2024 23:26

Location:

Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
06/01/2024	0.0	0.0	0.0	0.0
06/02/2024	78.9	17.9	0.0	0.0
06/03/2024	0.0	0.0	0.0	0.0
06/04/2024	0.0	0.0	0.0	0.0
06/05/2024	86.4	14.5	0.0	0.0
06/06/2024	0.0	0.0	0.0	0.0
06/07/2024	0.0	0.0	0.0	0.0
06/08/2024	0.0	0.0	0.0	0.0
06/09/2024	0.0	0.0	0.0	0.0
06/10/2024	0.0	0.0	0.0	0.0
06/11/2024	0.0	0.0	0.0	0.0
06/12/2024	0.0	0.0	0.0	0.0
06/13/2024	60.4	12.0	0.0	0.1
06/14/2024	91.7	12.1	17.2	12.4
06/15/2024	11.9	1.2	2.3	6.1
06/16/2024	0.0	0.0	0.1	0.4
06/17/2024	0.0	0.0	0.0	0.0
06/18/2024	0.0	0.0	0.0	0.0
06/19/2024	60.2	13.2	11.7	2.2
06/20/2024	0.0	0.0	0.0	0.0
06/21/2024	0.0	0.0	39.4	12.4
06/22/2024	0.0	0.0	10.1	2.1
06/23/2024	0.0	0.0	12.7	13.7
06/24/2024	68.0	16.3	0.0	0.0
06/25/2024	0.0	0.0	0.0	0.0
06/26/2024	0.0	0.0	0.0	0.0
06/27/2024	0.0	0.0	0.0	0.0
06/28/2024	0.0	0.0	0.0	0.0
06/29/2024	0.0	0.0	0.0	0.0
06/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	457.5 sum	87.2 sum	93.5 sum	49.4 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	91.7	17.9	39.4	13.7
Apr 2024 - Jun 2024	783.2 sum	132.5 sum	383.0 sum	127.2 sum
QTD:	783.2 sum	132.5 sum	383.0 sum	127.2 sum
YTD 2024:	1,015.9 sum	136.4 sum	596.2 sum	179.0 sum

Load Summary Report

CT1 / CT2 / CT5 / CT6 Load Summary



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:32 Location: Roseville, CA

* = Excess Emission

Date	Unit CT1 Load, _CT, MWe		Unit CT1 Load_Total, MWe		Unit CT2 Load, _CT, MWe		Unit CT2 Load_Total, MWe		Unit CT5 Load, MWe		Unit CT6 Load, MWe	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Avg	Rolling Avg
Apr 2024	20,882.0	140,990.9	29,528	209,851	575.1	87,982.6	785	136,735	0.0	0.0	0.0	0.0
May 2024	18,073.6	158,714.0	26,263	235,736	8,730.2	96,712.8	12,951	149,686	538.7	538.7	0.7	0.3
Jun 2024	10,129.6	167,267.9	15,079	248,420	20,697.6	117,410.4	30,619	180,305	62.5	601.2	0.1	0.2
Sum/Avg	167,267.9		248,420		117,410.4		180,305		601.2		0.2	
Limit Value												

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/01/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/02/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/03/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/04/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 04:00	0.0	0.0	0	0.32	0.15900	0.53
04/04/2024 05:00	0.0	0.0	0	0.51	0.25326	0.84
04/04/2024 06:00	1.0	0.7	1	0.54	0.26970	0.90
04/04/2024 07:00	1.0	0.9	1	0.45	0.22374	0.75
04/04/2024 08:00	0.8	1.3	0	0.45	0.22524	0.75
04/04/2024 09:00	0.7	1.5	1	0.45	0.22434	0.75
04/04/2024 10:00	0.7	1.5	1	0.46	0.22998	0.77
04/04/2024 11:00	0.6	1.5	1	0.57	0.28392	0.95
04/04/2024 12:00	0.7	1.5	1	0.58	0.28806	0.96
04/04/2024 13:00	0.6	1.5	1	0.57	0.28506	0.95
04/04/2024 14:00	0.6	1.5	1	0.56	0.28116	0.94
04/04/2024 15:00	0.7	1.5	1	0.49	0.24630	0.82
04/04/2024 16:00	0.7	1.5	0	0.52	0.25896	0.86
04/04/2024 17:00	0.7	1.5	1	0.47	0.23334	0.78
04/04/2024 18:00	0.7	1.5	1	0.49	0.24252	0.81
04/04/2024 19:00	0.7	1.5	1	0.50	0.24888	0.83
04/04/2024 20:00	0.6	1.5	1	0.56	0.28236	0.94
04/04/2024 21:00	0.6	1.5	1	0.57	0.28374	0.95
04/04/2024 22:00	0.6	1.5	1	0.57	0.28374	0.95
04/04/2024 23:00	0.8	1.4	1	0.48	0.24210	0.81
Average/Sum#:	0.6	1.3	1	0.51	0.25227	0.84
Minimum:	0.0	0.0	0	0.32	0.15900	0.53
Maximum:	1.0	1.5	1	0.58	0.28806	0.96
%SI	16.67	16.67	25.00	16.67	16.67	16.67

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/05/2024 00:00	0.6	1.5	1	0.57	0.28254	0.94
04/05/2024 01:00	0.6	1.5	1	0.56	0.28122	0.94
04/05/2024 02:00	0.8	1.4	1	0.44	0.22158	0.74
04/05/2024 03:00	0.8	1.5	1	0.48	0.24120	0.80
04/05/2024 04:00	0.7	1.5	1	0.48	0.24060	0.80
04/05/2024 05:00	0.6	1.5	1	0.57	0.28344	0.94
04/05/2024 06:00	0.6	1.5	1	0.57	0.28254	0.94
04/05/2024 07:00	0.6	1.5	1	0.57	0.28308	0.94
04/05/2024 08:00	0.7	1.5	1	0.53	0.26358	0.88
04/05/2024 09:00	0.7	1.5	1	0.49	0.24582	0.82
04/05/2024 10:00	0.6	1.5	1	0.57	0.28422	0.95
04/05/2024 11:00	0.6	1.5	1	0.51	0.25596	0.85
04/05/2024 12:00	0.7	1.5	1	0.44	0.22170	0.74
04/05/2024 13:00	0.6	1.5	0	0.54	0.27216	0.91
04/05/2024 14:00	0.7	1.5	1	0.47	0.23526	0.78
04/05/2024 15:00	0.7	1.5	1	0.44	0.22044	0.73
04/05/2024 16:00	0.7	1.5	1	0.44	0.22110	0.74
04/05/2024 17:00	0.7	1.5	1	0.49	0.24534	0.82
04/05/2024 18:00	0.6	1.5	1	0.54	0.27138	0.90
04/05/2024 19:00	0.6	1.5	1	0.56	0.28128	0.94
04/05/2024 20:00	0.6	1.5	1	0.56	0.28074	0.94
04/05/2024 21:00	0.7	1.5	1	0.48	0.24246	0.81
04/05/2024 22:00	0.8	1.5	1	0.45	0.22590	0.75
04/05/2024 23:00	0.8	1.5	1	0.45	0.22302	0.74
Average/Sum#:	0.7	1.5	1	0.51	0.25444	0.85
Minimum:	0.6	1.4	0	0.44	0.22044	0.73
Maximum:	0.8	1.5	1	0.57	0.28422	0.95
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/06/2024 00:00	0.8	1.5	1	0.45	0.22296	0.74
04/06/2024 01:00	0.9	1.5	1	0.44	0.22164	0.74
04/06/2024 02:00	0.8	1.4	1	0.44	0.22170	0.74
04/06/2024 03:00	0.9	1.5	1	0.44	0.22200	0.74
04/06/2024 04:00	0.7	1.5	1	0.53	0.26268	0.88
04/06/2024 05:00	0.7	1.5	1	0.57	0.28434	0.95
04/06/2024 06:00	0.8	1.4	1	0.48	0.23856	0.80
04/06/2024 07:00	0.8	1.5	1	0.44	0.22194	0.74
04/06/2024 08:00	0.7	1.5	1	0.44	0.22170	0.74
04/06/2024 09:00	0.7	1.5	1	0.44	0.22200	0.74
04/06/2024 10:00	0.7	1.4	1	0.44	0.22230	0.74
04/06/2024 11:00	0.7	1.5	0	0.45	0.22326	0.74
04/06/2024 12:00	0.7	1.5	0	0.44	0.22182	0.74
04/06/2024 13:00	0.7	1.5	1	0.44	0.21936	0.73
04/06/2024 14:00	0.7	1.5	1	0.44	0.21876	0.73
04/06/2024 15:00	0.7	1.5	1	0.44	0.21852	0.73
04/06/2024 16:00	0.7	1.5	1	0.44	0.21858	0.73
04/06/2024 17:00	0.7	1.4	1	0.46	0.22818	0.76
04/06/2024 18:00	0.7	1.5	1	0.44	0.21918	0.73
04/06/2024 19:00	0.7	1.5	1	0.44	0.21798	0.73
04/06/2024 20:00	0.7	1.5	1	0.44	0.21762	0.73
04/06/2024 21:00	0.8	1.5	1	0.44	0.21924	0.73
04/06/2024 22:00	0.8	1.5	1	0.44	0.21948	0.73
04/06/2024 23:00	0.8	1.5	1	0.44	0.22032	0.73
Average/Sum#:	0.7	1.5	1	0.45	0.22601	0.75
Minimum:	0.7	1.4	0	0.44	0.21762	0.73
Maximum:	0.9	1.5	1	0.57	0.28434	0.95
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/07/2024 00:00	0.9	1.5	1	0.44	0.22038	0.73
04/07/2024 01:00	0.8	1.5	1	0.44	0.22026	0.73
04/07/2024 02:00	0.8	1.6	1	0.44	0.22014	0.73
04/07/2024 03:00	0.9	1.5	1	0.44	0.21942	0.73
04/07/2024 04:00	0.8	1.5	1	0.44	0.21954	0.73
04/07/2024 05:00	0.8	1.5	1	0.44	0.21948	0.73
04/07/2024 06:00	0.8	1.5	1	0.44	0.21954	0.73
04/07/2024 07:00	0.8	1.5	1	0.44	0.22014	0.73
04/07/2024 08:00	0.8	1.5	1	0.44	0.22020	0.73
04/07/2024 09:00	0.8	1.5	1	0.44	0.21846	0.73
04/07/2024 10:00	0.7	1.5	1	0.44	0.21834	0.73
04/07/2024 11:00	0.7	1.5	1	0.44	0.21924	0.73
04/07/2024 12:00	0.7	1.5	1	0.44	0.21966	0.73
04/07/2024 13:00	0.7	1.5	1	0.44	0.21912	0.73
04/07/2024 14:00	0.7	1.4	1	0.44	0.21870	0.73
04/07/2024 15:00	0.7	1.5	1	0.44	0.21870	0.73
04/07/2024 16:00	0.7	1.4	1	0.44	0.21960	0.73
04/07/2024 17:00	0.7	1.5	0	0.47	0.23676	0.79
04/07/2024 18:00	0.7	1.4	0	0.44	0.22038	0.73
04/07/2024 19:00	0.8	1.4	0	0.44	0.22140	0.74
04/07/2024 20:00	0.9	1.5	1	0.44	0.22140	0.74
04/07/2024 21:00	0.9	1.5	1	0.44	0.22110	0.74
04/07/2024 22:00	0.8	1.5	1	0.44	0.22092	0.74
04/07/2024 23:00	0.9	1.5	1	0.44	0.22056	0.74
Average/Sum#:	0.8	1.5	1	0.44	0.22056	0.73
Minimum:	0.7	1.4	0	0.44	0.21834	0.73
Maximum:	0.9	1.6	1	0.47	0.23676	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/08/2024 00:00	0.9	1.4	1	0.44	0.21924	0.73
04/08/2024 01:00	0.8	1.5	1	0.44	0.21894	0.73
04/08/2024 02:00	0.8	1.6	1	0.44	0.21948	0.73
04/08/2024 03:00	0.9	1.5	1	0.45	0.22296	0.74
04/08/2024 04:00	0.8	1.6	1	0.51	0.25548	0.85
04/08/2024 05:00	0.7	1.5	1	0.56	0.28236	0.94
04/08/2024 06:00	0.8	1.5	1	0.49	0.24714	0.82
04/08/2024 07:00	0.8	1.4	1	0.44	0.22026	0.73
04/08/2024 08:00	0.8	1.4	0	0.44	0.21960	0.73
04/08/2024 09:00	0.7	1.5	0	0.44	0.21942	0.73
04/08/2024 10:00	0.7	1.5	0	0.50	0.24828	0.83
04/08/2024 11:00	0.7	1.5	0	0.43	0.21672	0.72
04/08/2024 12:00	0.7	1.4	0	0.44	0.21822	0.73
04/08/2024 13:00	0.7	1.4	0	0.44	0.21798	0.73
04/08/2024 14:00	0.7	1.5	1	0.44	0.21774	0.73
04/08/2024 15:00	0.7	1.5	1	0.44	0.21804	0.73
04/08/2024 16:00	0.7	1.5	1	0.44	0.21774	0.73
04/08/2024 17:00	0.7	1.4	1	0.45	0.22584	0.75
04/08/2024 18:00	0.7	1.5	1	0.44	0.21930	0.73
04/08/2024 19:00	0.7	1.5	1	0.44	0.21864	0.73
04/08/2024 20:00	0.7	1.5	1	0.44	0.21822	0.73
04/08/2024 21:00	0.8	1.5	1	0.43	0.21714	0.72
04/08/2024 22:00	0.7	1.5	1	0.44	0.21774	0.73
04/08/2024 23:00	0.7	1.5	0	0.56	0.27792	0.93
Average/Sum#:	0.7	1.5	1	0.46	0.22810	0.76
Minimum:	0.7	1.4	0	0.43	0.21672	0.72
Maximum:	0.9	1.6	1	0.56	0.28236	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/09/2024 00:00	0.8	1.5	1	0.56	0.27930	0.93
04/09/2024 01:00	0.9	1.5	1	0.56	0.27930	0.93
04/09/2024 02:00	0.8	1.5	0	0.56	0.27936	0.93
04/09/2024 03:00	0.8	1.5	1	0.55	0.27684	0.92
04/09/2024 04:00	0.8	1.5	1	0.48	0.24222	0.81
04/09/2024 05:00	0.7	1.5	1	0.56	0.28224	0.94
04/09/2024 06:00	0.8	1.4	1	0.47	0.23706	0.79
04/09/2024 07:00	0.8	1.5	0	0.44	0.22020	0.73
04/09/2024 08:00	0.8	1.5	0	0.48	0.24162	0.81
04/09/2024 09:00	0.8	1.4	0	0.44	0.21792	0.73
04/09/2024 10:00	0.8	1.4	0	0.44	0.21822	0.73
04/09/2024 11:00	0.7	1.4	0	0.44	0.21942	0.73
04/09/2024 12:00	0.7	1.4	0	0.44	0.21990	0.73
04/09/2024 13:00	0.7	1.4	0	0.44	0.21930	0.73
04/09/2024 14:00	0.7	1.4	0	0.43	0.21684	0.72
04/09/2024 15:00	0.7	1.5	1	0.43	0.21678	0.72
04/09/2024 16:00	0.7	1.5	1	0.43	0.21708	0.72
04/09/2024 17:00	0.7	1.5	1	0.43	0.21486	0.72
04/09/2024 18:00	0.8	1.5	1	0.43	0.21462	0.72
04/09/2024 19:00	0.8	1.5	1	0.43	0.21426	0.71
04/09/2024 20:00	0.8	1.5	1	0.43	0.21432	0.71
04/09/2024 21:00	0.8	1.4	0	0.43	0.21618	0.72
04/09/2024 22:00	0.9	1.5	0	0.43	0.21666	0.72
04/09/2024 23:00	0.9	1.5	0	0.44	0.21792	0.73
Average/Sum#:	0.8	1.5	1	0.47	0.23302	0.78
Minimum:	0.7	1.4	0	0.43	0.21426	0.71
Maximum:	0.9	1.5	1	0.56	0.28224	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/10/2024 00:00	0.9	1.4	0	0.44	0.21834	0.73
04/10/2024 01:00	0.9	1.5	0	0.44	0.21798	0.73
04/10/2024 02:00	0.8	1.4	0	0.44	0.21798	0.73
04/10/2024 03:00	0.9	1.5	1	0.44	0.21828	0.73
04/10/2024 04:00	0.8	1.5	1	0.44	0.21870	0.73
04/10/2024 05:00	0.8	1.5	1	0.44	0.21840	0.73
04/10/2024 06:00	0.9	1.5	1	0.44	0.21858	0.73
04/10/2024 07:00	0.9	1.4	0	0.44	0.21852	0.73
04/10/2024 08:00	0.8	1.4	0	0.44	0.21924	0.73
04/10/2024 09:00	0.8	1.4	0	0.44	0.21960	0.73
04/10/2024 10:00	0.7	1.4	0	0.44	0.21972	0.73
04/10/2024 11:00	0.7	1.5	1	0.44	0.22068	0.74
04/10/2024 12:00	0.7	1.5	1	0.44	0.22104	0.74
04/10/2024 13:00	0.7	1.5	1	0.44	0.22032	0.73
04/10/2024 14:00	0.7	1.5	1	0.44	0.21894	0.73
04/10/2024 15:00	0.7	1.5	1	0.44	0.21906	0.73
04/10/2024 16:00	0.7	1.4	0	0.44	0.21972	0.73
04/10/2024 17:00	0.8	1.4	0	0.44	0.22056	0.74
04/10/2024 18:00	0.7	1.5	1	0.43	0.21444	0.71
04/10/2024 19:00	0.8	1.5	1	0.43	0.21432	0.71
04/10/2024 20:00	0.8	1.5	1	0.43	0.21480	0.72
04/10/2024 21:00	0.8	1.5	1	0.43	0.21480	0.72
04/10/2024 22:00	0.9	1.5	1	0.43	0.21504	0.72
04/10/2024 23:00	0.9	1.5	1	0.43	0.21462	0.72
Average/Sum#:	0.8	1.5	1	0.44	0.21807	0.73
Minimum:	0.7	1.4	0	0.43	0.21432	0.71
Maximum:	0.9	1.5	1	0.44	0.22104	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/11/2024 00:00	0.8	1.5	0	0.46	0.23142	0.77
04/11/2024 01:00	0.9	1.4	0	0.44	0.21828	0.73
04/11/2024 02:00	0.8	1.8	1	0.44	0.21768	0.73
04/11/2024 03:00	0.9	1.5	1	0.44	0.21870	0.73
04/11/2024 04:00	0.8	1.5	1	0.45	0.22470	0.75
04/11/2024 05:00	0.8	1.5	0	0.49	0.24630	0.82
04/11/2024 06:00	0.8	1.5	0	0.44	0.21954	0.73
04/11/2024 07:00	0.8	1.4	0	0.44	0.21972	0.73
04/11/2024 08:00	0.8	1.4	0	0.44	0.21978	0.73
04/11/2024 09:00	0.7	1.5	1	0.44	0.22020	0.73
04/11/2024 10:00	0.7	1.5	1	0.44	0.22014	0.73
04/11/2024 11:00	0.7	1.5	1	0.44	0.21948	0.73
04/11/2024 12:00	0.7	1.5	1	0.44	0.21954	0.73
04/11/2024 13:00	0.7	1.5	1	0.44	0.21870	0.73
04/11/2024 14:00	0.7	1.5	0	0.44	0.21816	0.73
04/11/2024 15:00	0.7	1.5	1	0.44	0.21798	0.73
04/11/2024 16:00	0.7	1.5	0	0.44	0.21774	0.73
04/11/2024 17:00	0.7	1.5	0	0.44	0.21828	0.73
04/11/2024 18:00	0.7	1.5	0	0.44	0.21786	0.73
04/11/2024 19:00	0.7	1.5	1	0.43	0.21636	0.72
04/11/2024 20:00	0.8	1.5	1	0.43	0.21672	0.72
04/11/2024 21:00	0.8	1.5	1	0.44	0.21840	0.73
04/11/2024 22:00	0.8	1.5	1	0.44	0.21900	0.73
04/11/2024 23:00	0.8	1.5	1	0.44	0.21864	0.73
Average/Sum#:	0.8	1.5	1	0.44	0.22056	0.74
Minimum:	0.7	1.4	0	0.43	0.21636	0.72
Maximum:	0.9	1.8	1	0.49	0.24630	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/12/2024 00:00	0.8	1.5	1	0.44	0.21804	0.73
04/12/2024 01:00	0.8	1.5	1	0.44	0.21780	0.73
04/12/2024 02:00	0.8	1.5	1	0.44	0.21774	0.73
04/12/2024 03:00	0.9	1.5	1	0.44	0.21774	0.73
04/12/2024 04:00	0.8	1.5	1	0.44	0.21804	0.73
04/12/2024 05:00	0.8	1.5	1	0.44	0.22002	0.73
04/12/2024 06:00	0.8	1.5	1	0.44	0.21978	0.73
04/12/2024 07:00	0.7	1.5	1	0.44	0.21990	0.73
04/12/2024 08:00	0.7	1.5	1	0.44	0.22002	0.73
04/12/2024 09:00	0.7	1.5	1	0.44	0.21804	0.73
04/12/2024 10:00	0.7	1.5	1	0.44	0.21750	0.73
04/12/2024 11:00	0.7	1.5	1	0.44	0.21864	0.73
04/12/2024 12:00	0.7	1.5	1	0.44	0.21900	0.73
04/12/2024 13:00	0.7	1.5	0	0.44	0.22122	0.74
04/12/2024 14:00	0.7	1.5	1	0.44	0.21852	0.73
04/12/2024 15:00	0.7	1.5	1	0.44	0.21852	0.73
04/12/2024 16:00	0.7	1.5	1	0.44	0.21810	0.73
04/12/2024 17:00	0.7	1.5	1	0.44	0.21792	0.73
04/12/2024 18:00	0.7	1.5	1	0.44	0.21810	0.73
04/12/2024 19:00	0.8	1.5	1	0.44	0.21756	0.73
04/12/2024 20:00	0.7	1.5	1	0.44	0.21894	0.73
04/12/2024 21:00	0.7	1.5	1	0.44	0.22026	0.73
04/12/2024 22:00	0.7	1.5	1	0.44	0.22062	0.74
04/12/2024 23:00	0.8	1.4	0	0.44	0.22050	0.74
Average/Sum#:	0.7	1.5	1	0.44	0.21886	0.73
Minimum:	0.7	1.4	0	0.44	0.21750	0.73
Maximum:	0.9	1.5	1	0.44	0.22122	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/13/2024 00:00	0.8	1.4	0	0.44	0.22008	0.73
04/13/2024 01:00	0.8	1.4	0	0.44	0.22014	0.73
04/13/2024 02:00	0.8	1.4	0	0.44	0.21996	0.73
04/13/2024 03:00	0.9	1.4	0	0.44	0.21912	0.73
04/13/2024 04:00	0.8	1.4	0	0.44	0.21900	0.73
04/13/2024 05:00	0.8	1.4	0	0.44	0.21834	0.73
04/13/2024 06:00	0.8	1.5	1	0.44	0.21930	0.73
04/13/2024 07:00	0.8	1.5	1	0.44	0.21888	0.73
04/13/2024 08:00	0.8	1.5	1	0.44	0.21906	0.73
04/13/2024 09:00	0.8	1.5	1	0.44	0.21924	0.73
04/13/2024 10:00	0.8	1.5	1	0.44	0.21918	0.73
04/13/2024 11:00	0.8	1.5	1	0.44	0.21888	0.73
04/13/2024 12:00	0.8	1.5	1	0.44	0.21822	0.73
04/13/2024 13:00	0.8	1.5	1	0.44	0.21774	0.73
04/13/2024 14:00	0.8	1.5	1	0.44	0.21834	0.73
04/13/2024 15:00	0.8	1.5	1	0.44	0.21864	0.73
04/13/2024 16:00	0.8	1.5	1	0.44	0.21900	0.73
04/13/2024 17:00	0.8	1.5	1	0.44	0.21966	0.73
04/13/2024 18:00	0.8	1.5	1	0.44	0.22008	0.73
04/13/2024 19:00	0.8	1.5	1	0.44	0.21978	0.73
04/13/2024 20:00	0.8	1.5	1	0.44	0.22026	0.73
04/13/2024 21:00	0.8	1.5	1	0.44	0.21996	0.73
04/13/2024 22:00	0.8	1.5	1	0.44	0.21984	0.73
04/13/2024 23:00	0.8	1.5	1	0.44	0.21918	0.73
Average/Sum#:	0.8	1.5	1	0.44	0.21925	0.73
Minimum:	0.8	1.4	0	0.44	0.21774	0.73
Maximum:	0.9	1.5	1	0.44	0.22026	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/14/2024 00:00	0.8	1.4	1	0.44	0.21936	0.73
04/14/2024 01:00	0.8	1.5	1	0.44	0.21918	0.73
04/14/2024 02:00	0.9	1.4	1	0.44	0.21918	0.73
04/14/2024 03:00	0.9	1.5	1	0.44	0.21918	0.73
04/14/2024 04:00	0.8	1.5	1	0.44	0.21924	0.73
04/14/2024 05:00	0.8	1.4	1	0.44	0.21978	0.73
04/14/2024 06:00	0.8	1.5	1	0.44	0.21954	0.73
04/14/2024 07:00	0.8	1.5	1	0.44	0.22002	0.73
04/14/2024 08:00	1.0	1.4	1	0.52	0.25884	0.86
04/14/2024 09:00	0.8	1.4	1	0.44	0.22020	0.73
04/14/2024 10:00	0.7	1.4	0	0.44	0.22092	0.74
04/14/2024 11:00	0.7	1.4	0	0.44	0.22140	0.74
04/14/2024 12:00	0.7	1.4	0	0.44	0.22002	0.73
04/14/2024 13:00	0.7	1.4	0	0.44	0.21894	0.73
04/14/2024 14:00	0.7	1.5	0	0.44	0.21882	0.73
04/14/2024 15:00	0.7	1.4	0	0.44	0.21870	0.73
04/14/2024 16:00	0.7	1.4	1	0.44	0.21846	0.73
04/14/2024 17:00	0.7	1.4	0	0.44	0.21960	0.73
04/14/2024 18:00	0.7	1.4	0	0.44	0.21954	0.73
04/14/2024 19:00	0.8	1.4	0	0.43	0.21744	0.72
04/14/2024 20:00	0.8	1.5	0	0.44	0.21912	0.73
04/14/2024 21:00	0.9	1.5	0	0.44	0.22020	0.73
04/14/2024 22:00	0.9	1.4	1	0.44	0.21948	0.73
04/14/2024 23:00	0.8	1.5	0	0.44	0.21978	0.73
Average/Sum#:	0.8	1.4	1	0.44	0.22112	0.74
Minimum:	0.7	1.4	0	0.43	0.21744	0.72
Maximum:	1.0	1.5	1	0.52	0.25884	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/15/2024 00:00	0.8	1.4	0	0.44	0.21966	0.73
04/15/2024 01:00	0.8	1.4	1	0.44	0.21984	0.73
04/15/2024 02:00	0.9	1.4	0	0.44	0.22014	0.73
04/15/2024 03:00	0.9	1.4	0	0.44	0.22038	0.73
04/15/2024 04:00	0.8	1.4	0	0.44	0.22026	0.73
04/15/2024 05:00	0.8	1.5	0	0.44	0.22044	0.73
04/15/2024 06:00	0.8	1.5	1	0.44	0.22092	0.74
04/15/2024 07:00	0.8	1.5	0	0.44	0.22062	0.74
04/15/2024 08:00	0.8	1.4	0	0.44	0.21978	0.73
04/15/2024 09:00	0.8	1.4	0	0.44	0.21816	0.73
04/15/2024 10:00	0.7	1.4	0	0.44	0.21816	0.73
04/15/2024 11:00	0.7	1.4	0	0.44	0.21888	0.73
04/15/2024 12:00	0.7	1.4	0	0.44	0.21930	0.73
04/15/2024 13:00	0.7	1.4	0	0.44	0.21900	0.73
04/15/2024 14:00	0.7	1.4	0	0.44	0.21930	0.73
04/15/2024 15:00	0.7	1.4	0	0.44	0.21978	0.73
04/15/2024 16:00	0.7	1.4	0	0.44	0.21912	0.73
04/15/2024 17:00	0.7	1.4	0	0.44	0.21954	0.73
04/15/2024 18:00	0.7	1.4	0	0.44	0.21918	0.73
04/15/2024 19:00	0.7	1.4	0	0.44	0.21858	0.73
04/15/2024 20:00	0.7	1.4	0	0.44	0.21888	0.73
04/15/2024 21:00	0.8	1.4	0	0.44	0.21822	0.73
04/15/2024 22:00	0.8	1.5	0	0.44	0.21804	0.73
04/15/2024 23:00	0.9	1.4	0	0.44	0.21804	0.73
Average/Sum#:	0.8	1.4	0	0.44	0.21934	0.73
Minimum:	0.7	1.4	0	0.44	0.21804	0.73
Maximum:	0.9	1.5	1	0.44	0.22092	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/16/2024 00:00	0.9	1.4	0	0.44	0.21792	0.73
04/16/2024 01:00	0.8	1.4	0	0.44	0.21786	0.73
04/16/2024 02:00	0.8	1.4	0	0.44	0.21822	0.73
04/16/2024 03:00	0.9	1.5	1	0.44	0.21804	0.73
04/16/2024 04:00	0.8	1.4	0	0.44	0.22008	0.73
04/16/2024 05:00	0.8	1.4	1	0.44	0.22044	0.73
04/16/2024 06:00	0.8	1.4	0	0.44	0.22080	0.74
04/16/2024 07:00	0.8	1.4	0	0.44	0.22116	0.74
04/16/2024 08:00	0.8	1.4	0	0.44	0.21978	0.73
04/16/2024 09:00	0.9	1.1	1	0.44	0.21888	0.73
04/16/2024 10:00	0.8	1.4	0	0.44	0.21924	0.73
04/16/2024 11:00	0.7	1.5	1	0.44	0.22026	0.73
04/16/2024 12:00	0.7	1.5	1	0.44	0.22020	0.73
04/16/2024 13:00	0.7	1.7	1	0.44	0.21978	0.73
04/16/2024 14:00	0.7	1.5	1	0.44	0.21984	0.73
04/16/2024 15:00	0.7	1.5	1	0.44	0.21996	0.73
04/16/2024 16:00	0.7	1.5	1	0.44	0.21960	0.73
04/16/2024 17:00	0.7	1.5	1	0.44	0.21954	0.73
04/16/2024 18:00	0.7	1.5	1	0.44	0.21792	0.73
04/16/2024 19:00	0.7	1.5	1	0.43	0.21600	0.72
04/16/2024 20:00	0.8	1.5	1	0.43	0.21624	0.72
04/16/2024 21:00	0.8	1.5	1	0.43	0.21654	0.72
04/16/2024 22:00	0.9	1.5	1	0.43	0.21612	0.72
04/16/2024 23:00	0.9	1.5	1	0.43	0.21624	0.72
Average/Sum#:	0.8	1.5	1	0.44	0.21878	0.73
Minimum:	0.7	1.1	0	0.43	0.21600	0.72
Maximum:	0.9	1.7	1	0.44	0.22116	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/17/2024 00:00	0.9	1.5	1	0.44	0.21762	0.73
04/17/2024 01:00	0.8	1.5	1	0.44	0.21888	0.73
04/17/2024 02:00	0.8	1.5	1	0.44	0.21918	0.73
04/17/2024 03:00	0.9	1.5	1	0.44	0.21918	0.73
04/17/2024 04:00	0.8	1.5	1	0.44	0.21888	0.73
04/17/2024 05:00	0.8	1.5	1	0.44	0.21852	0.73
04/17/2024 06:00	0.8	1.5	1	0.44	0.21846	0.73
04/17/2024 07:00	0.8	1.5	1	0.44	0.21834	0.73
04/17/2024 08:00	0.8	1.5	1	0.44	0.21888	0.73
04/17/2024 09:00	0.8	1.5	1	0.44	0.21924	0.73
04/17/2024 10:00	0.7	1.4	1	0.44	0.21960	0.73
04/17/2024 11:00	0.7	1.5	1	0.44	0.22056	0.74
04/17/2024 12:00	0.7	1.5	1	0.44	0.22050	0.74
04/17/2024 13:00	0.7	1.5	1	0.44	0.22032	0.73
04/17/2024 14:00	0.7	1.5	1	0.44	0.22020	0.73
04/17/2024 15:00	0.7	1.5	0	0.44	0.22002	0.73
04/17/2024 16:00	0.6	1.5	0	0.44	0.21978	0.73
04/17/2024 17:00	0.6	1.5	1	0.44	0.22026	0.73
04/17/2024 18:00	0.6	1.5	1	0.44	0.21984	0.73
04/17/2024 19:00	0.7	1.5	1	0.44	0.21798	0.73
04/17/2024 20:00	0.7	1.5	1	0.44	0.21984	0.73
04/17/2024 21:00	0.8	1.5	1	0.44	0.22050	0.74
04/17/2024 22:00	0.8	1.5	1	0.44	0.22014	0.73
04/17/2024 23:00	0.8	1.5	1	0.44	0.22014	0.73
Average/Sum#:	0.8	1.5	1	0.44	0.21945	0.73
Minimum:	0.6	1.4	0	0.44	0.21762	0.73
Maximum:	0.9	1.5	1	0.44	0.22056	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/18/2024 00:00	0.8	1.5	1	0.44	0.22044	0.73
04/18/2024 01:00	0.8	1.5	1	0.44	0.22002	0.73
04/18/2024 02:00	0.9	1.5	1	0.44	0.21990	0.73
04/18/2024 03:00	1.0	1.5	1	0.44	0.21966	0.73
04/18/2024 04:00	0.9	1.5	1	0.44	0.21954	0.73
04/18/2024 05:00	0.8	1.5	1	0.44	0.21918	0.73
04/18/2024 06:00	0.9	1.5	1	0.44	0.21960	0.73
04/18/2024 07:00	0.8	1.5	1	0.44	0.22020	0.73
04/18/2024 08:00	0.8	1.5	1	0.44	0.22032	0.73
04/18/2024 09:00	0.7	1.4	0	0.44	0.22050	0.74
04/18/2024 10:00	0.6	1.5	0	0.44	0.22110	0.74
04/18/2024 11:00	0.6	1.4	0	0.44	0.22182	0.74
04/18/2024 12:00	0.6	1.5	0	0.44	0.22242	0.74
04/18/2024 13:00	0.6	1.6	1	0.44	0.22218	0.74
04/18/2024 14:00	0.6	1.0	0	0.44	0.22104	0.74
04/18/2024 15:00	0.6	1.5	0	0.44	0.22032	0.73
04/18/2024 16:00	0.6	1.5	1	0.44	0.22014	0.73
04/18/2024 17:00	0.6	1.4	0	0.44	0.22086	0.74
04/18/2024 18:00	0.6	1.4	0	0.44	0.21780	0.73
04/18/2024 19:00	0.6	1.5	0	0.44	0.22056	0.74
04/18/2024 20:00	0.6	1.5	1	0.44	0.22050	0.74
04/18/2024 21:00	0.7	1.5	0	0.44	0.22020	0.73
04/18/2024 22:00	0.7	1.4	0	0.44	0.22062	0.74
04/18/2024 23:00	0.7	1.5	0	0.44	0.22032	0.73
Average/Sum#:	0.7	1.5	1	0.44	0.22039	0.73
Minimum:	0.6	1.0	0	0.44	0.21780	0.73
Maximum:	1.0	1.6	1	0.44	0.22242	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/19/2024 00:00	0.7	1.5	0	0.44	0.22008	0.73
04/19/2024 01:00	0.7	1.5	1	0.44	0.21996	0.73
04/19/2024 02:00	0.7	1.5	1	0.44	0.21918	0.73
04/19/2024 03:00	0.8	1.5	1	0.44	0.21888	0.73
04/19/2024 04:00	0.8	1.5	1	0.44	0.21858	0.73
04/19/2024 05:00	0.8	1.5	1	0.44	0.21888	0.73
04/19/2024 06:00	0.8	1.5	1	0.44	0.22002	0.73
04/19/2024 07:00	0.8	1.5	1	0.44	0.21984	0.73
04/19/2024 08:00	0.7	1.5	1	0.44	0.21876	0.73
04/19/2024 09:00	0.6	1.5	1	0.44	0.21978	0.73
04/19/2024 10:00	0.6	1.5	0	0.44	0.21906	0.73
04/19/2024 11:00	0.6	1.5	0	0.44	0.21894	0.73
04/19/2024 12:00	0.6	1.5	0	0.44	0.21930	0.73
04/19/2024 13:00	0.6	1.5	0	0.44	0.21978	0.73
04/19/2024 14:00	0.6	1.4	0	0.44	0.21942	0.73
04/19/2024 15:00	0.6	1.4	0	0.44	0.21918	0.73
04/19/2024 16:00	0.6	1.4	0	0.44	0.21834	0.73
04/19/2024 17:00	0.6	1.4	0	0.46	0.22992	0.77
04/19/2024 18:00	0.6	1.5	0	0.43	0.21732	0.72
04/19/2024 19:00	0.6	1.4	0	0.43	0.21678	0.72
04/19/2024 20:00	0.7	1.5	0	0.43	0.21660	0.72
04/19/2024 21:00	0.7	1.5	0	0.43	0.21672	0.72
04/19/2024 22:00	0.7	1.5	1	0.43	0.21678	0.72
04/19/2024 23:00	0.7	1.5	1	0.44	0.21786	0.73
Average/Sum#:	0.7	1.5	0	0.44	0.21917	0.73
Minimum:	0.6	1.4	0	0.43	0.21660	0.72
Maximum:	0.8	1.5	1	0.46	0.22992	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/20/2024 00:00	0.7	1.5	0	0.44	0.21792	0.73
04/20/2024 01:00	0.7	1.5	1	0.44	0.21804	0.73
04/20/2024 02:00	0.8	1.5	1	0.44	0.21774	0.73
04/20/2024 03:00	0.8	1.5	1	0.44	0.21762	0.73
04/20/2024 04:00	0.7	1.5	1	0.44	0.21750	0.73
04/20/2024 05:00	0.7	1.5	1	0.44	0.21804	0.73
04/20/2024 06:00	0.7	1.5	1	0.44	0.21828	0.73
04/20/2024 07:00	0.7	1.5	1	0.44	0.21816	0.73
04/20/2024 08:00	0.7	1.5	1	0.44	0.21852	0.73
04/20/2024 09:00	0.7	1.5	1	0.44	0.21912	0.73
04/20/2024 10:00	0.7	1.5	0	0.44	0.21984	0.73
04/20/2024 11:00	0.6	1.5	0	0.44	0.22080	0.74
04/20/2024 12:00	0.6	1.5	0	0.44	0.22146	0.74
04/20/2024 13:00	0.6	1.4	0	0.44	0.22188	0.74
04/20/2024 14:00	0.6	1.4	0	0.44	0.22200	0.74
04/20/2024 15:00	0.6	1.4	0	0.44	0.22140	0.74
04/20/2024 16:00	0.6	1.4	0	0.44	0.21906	0.73
04/20/2024 17:00	0.6	1.4	0	0.44	0.21924	0.73
04/20/2024 18:00	0.6	1.4	0	0.44	0.21876	0.73
04/20/2024 19:00	0.6	1.5	0	0.44	0.21792	0.73
04/20/2024 20:00	0.7	1.4	1	0.43	0.21690	0.72
04/20/2024 21:00	0.7	1.4	0	0.43	0.21732	0.72
04/20/2024 22:00	0.7	1.5	0	0.44	0.21882	0.73
04/20/2024 23:00	0.7	1.5	1	0.44	0.21924	0.73
Average/Sum#:	0.7	1.5	0	0.44	0.21898	0.73
Minimum:	0.6	1.4	0	0.43	0.21690	0.72
Maximum:	0.8	1.5	1	0.44	0.22200	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/21/2024 00:00	0.7	1.5	1	0.44	0.21936	0.73
04/21/2024 01:00	0.7	1.5	1	0.44	0.21918	0.73
04/21/2024 02:00	0.7	1.5	1	0.44	0.21888	0.73
04/21/2024 03:00	0.8	1.5	1	0.44	0.21822	0.73
04/21/2024 04:00	0.8	1.5	1	0.44	0.21834	0.73
04/21/2024 05:00	0.8	1.5	1	0.44	0.21822	0.73
04/21/2024 06:00	0.7	1.5	1	0.44	0.21930	0.73
04/21/2024 07:00	0.8	1.4	1	0.44	0.21924	0.73
04/21/2024 08:00	0.8	1.4	0	0.44	0.21978	0.73
04/21/2024 09:00	0.6	1.5	0	0.44	0.22008	0.73
04/21/2024 10:00	0.6	1.5	0	0.44	0.22008	0.73
04/21/2024 11:00	0.6	1.4	0	0.44	0.22128	0.74
04/21/2024 12:00	0.6	1.4	0	0.44	0.22200	0.74
04/21/2024 13:00	0.6	1.4	0	0.44	0.22212	0.74
04/21/2024 14:00	0.6	1.4	0	0.44	0.22020	0.73
04/21/2024 15:00	0.6	1.5	0	0.44	0.21900	0.73
04/21/2024 16:00	0.6	1.4	0	0.44	0.21864	0.73
04/21/2024 17:00	0.6	1.3	0	0.48	0.23754	0.79
04/21/2024 18:00	0.6	1.4	0	0.45	0.22662	0.76
04/21/2024 19:00	0.7	1.3	0	0.47	0.23598	0.79
04/21/2024 20:00	0.7	1.4	0	0.48	0.24102	0.80
04/21/2024 21:00	0.7	1.4	0	0.51	0.25266	0.84
04/21/2024 22:00	0.7	1.5	0	0.44	0.21996	0.73
04/21/2024 23:00	0.7	1.4	0	0.45	0.22494	0.75
Average/Sum#:	0.7	1.4	0	0.45	0.22386	0.75
Minimum:	0.6	1.3	0	0.44	0.21822	0.73
Maximum:	0.8	1.5	1	0.51	0.25266	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/22/2024 00:00	0.7	1.5	0	0.44	0.22116	0.74
04/22/2024 01:00	0.7	1.4	1	0.45	0.22494	0.75
04/22/2024 02:00	0.7	1.4	0	0.44	0.22056	0.74
04/22/2024 03:00	0.9	1.5	1	0.44	0.22074	0.74
04/22/2024 04:00	0.8	1.4	1	0.44	0.22188	0.74
04/22/2024 05:00	1.0	1.5	1	0.50	0.25242	0.84
04/22/2024 06:00	0.9	1.5	0	0.50	0.24876	0.83
04/22/2024 07:00	0.8	1.5	0	0.44	0.22038	0.73
04/22/2024 08:00	0.7	1.5	0	0.44	0.22020	0.73
04/22/2024 09:00	0.7	1.5	0	0.44	0.21942	0.73
04/22/2024 10:00	0.7	1.4	0	0.44	0.21882	0.73
04/22/2024 11:00	0.6	1.4	0	0.44	0.21942	0.73
04/22/2024 12:00	0.6	1.4	0	0.44	0.21942	0.73
04/22/2024 13:00	0.6	1.4	0	0.44	0.21960	0.73
04/22/2024 14:00	0.6	1.4	0	0.44	0.21936	0.73
04/22/2024 15:00	0.6	1.3	0	0.44	0.21876	0.73
04/22/2024 16:00	0.6	1.3	0	0.44	0.21852	0.73
04/22/2024 17:00	0.6	1.4	0	0.47	0.23634	0.79
04/22/2024 18:00	0.6	1.4	0	0.52	0.25860	0.86
04/22/2024 19:00	0.6	1.4	0	0.52	0.25806	0.86
04/22/2024 20:00	0.6	1.4	0	0.51	0.25482	0.85
04/22/2024 21:00	0.7	1.4	0	0.47	0.23556	0.79
04/22/2024 22:00	0.7	1.5	1	0.44	0.21780	0.73
04/22/2024 23:00	0.7	1.5	1	0.44	0.21774	0.73
Average/Sum#:	0.7	1.4	0	0.46	0.22847	0.76
Minimum:	0.6	1.3	0	0.44	0.21774	0.73
Maximum:	1.0	1.5	1	0.52	0.25860	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/23/2024 00:00	0.7	1.5	1	0.43	0.21720	0.72
04/23/2024 01:00	0.7	1.5	1	0.44	0.21786	0.73
04/23/2024 02:00	0.7	1.6	1	0.44	0.21780	0.73
04/23/2024 03:00	0.8	1.5	1	0.43	0.21744	0.72
04/23/2024 04:00	0.7	1.5	1	0.44	0.21762	0.73
04/23/2024 05:00	0.7	1.5	1	0.44	0.21810	0.73
04/23/2024 06:00	0.7	1.5	1	0.44	0.21990	0.73
04/23/2024 07:00	0.7	1.5	1	0.46	0.22980	0.77
04/23/2024 08:00	0.7	1.5	1	0.44	0.21822	0.73
04/23/2024 09:00	0.7	1.4	1	0.44	0.21834	0.73
04/23/2024 10:00	0.7	1.1	0	0.48	0.24006	0.80
04/23/2024 11:00	0.7	1.3	0	0.44	0.21972	0.73
04/23/2024 12:00	0.6	1.5	0	0.46	0.23202	0.77
04/23/2024 13:00	0.6	1.4	0	0.47	0.23532	0.78
04/23/2024 14:00	0.6	1.4	0	0.55	0.27546	0.92
04/23/2024 15:00	0.6	1.5	0	0.55	0.27666	0.92
04/23/2024 16:00	0.7	1.5	0	0.44	0.22002	0.73
04/23/2024 17:00	0.6	1.4	0	0.48	0.23808	0.79
04/23/2024 18:00	0.6	1.5	0	0.56	0.27834	0.93
04/23/2024 19:00	0.6	1.5	0	0.56	0.27912	0.93
04/23/2024 20:00	0.6	1.5	0	0.56	0.28092	0.94
04/23/2024 21:00	0.6	1.4	0	0.51	0.25266	0.84
04/23/2024 22:00	0.7	1.5	1	0.44	0.21912	0.73
04/23/2024 23:00	0.7	1.4	1	0.47	0.23604	0.79
Average/Sum#:	0.7	1.5	1	0.47	0.23649	0.79
Minimum:	0.6	1.1	0	0.43	0.21720	0.72
Maximum:	0.8	1.6	1	0.56	0.28092	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/24/2024 00:00	0.7	1.5	1	0.44	0.21894	0.73
04/24/2024 01:00	0.7	1.5	1	0.44	0.21900	0.73
04/24/2024 02:00	0.7	1.4	0	0.44	0.21840	0.73
04/24/2024 03:00	0.8	1.5	1	0.44	0.21798	0.73
04/24/2024 04:00	0.7	1.4	1	0.44	0.22182	0.74
04/24/2024 05:00	0.6	1.4	0	0.50	0.25164	0.84
04/24/2024 06:00	0.7	1.5	1	0.45	0.22302	0.74
04/24/2024 07:00	0.6	1.5	0	0.56	0.28116	0.94
04/24/2024 08:00	0.6	1.4	1	0.50	0.25116	0.84
04/24/2024 09:00	0.7	1.5	1	0.44	0.21894	0.73
04/24/2024 10:00	0.7	1.5	1	0.44	0.21930	0.73
04/24/2024 11:00	0.7	1.4	0	0.44	0.21972	0.73
04/24/2024 12:00	0.7	1.4	0	0.44	0.22020	0.73
04/24/2024 13:00	0.6	1.5	0	0.44	0.22062	0.74
04/24/2024 14:00	0.6	1.5	1	0.44	0.22068	0.74
04/24/2024 15:00	0.6	1.4	1	0.44	0.22050	0.74
04/24/2024 16:00	0.6	1.5	1	0.44	0.21960	0.73
04/24/2024 17:00	0.6	1.4	0	0.47	0.23634	0.79
04/24/2024 18:00	0.7	1.4	1	0.44	0.22032	0.73
04/24/2024 19:00	0.6	1.4	0	0.46	0.22842	0.76
04/24/2024 20:00	0.7	1.5	1	0.44	0.21828	0.73
04/24/2024 21:00	0.7	1.5	1	0.44	0.21840	0.73
04/24/2024 22:00	0.7	1.5	1	0.44	0.21948	0.73
04/24/2024 23:00	0.8	1.4	1	0.44	0.22134	0.74
Average/Sum#:	0.7	1.5	1	0.45	0.22605	0.75
Minimum:	0.6	1.4	0	0.44	0.21798	0.73
Maximum:	0.8	1.5	1	0.56	0.28116	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/25/2024 00:00	0.8	1.5	1	0.44	0.22062	0.74
04/25/2024 01:00	0.8	1.5	1	0.44	0.21894	0.73
04/25/2024 02:00	0.7	1.5	1	0.44	0.21810	0.73
04/25/2024 03:00	0.8	1.5	1	0.44	0.21810	0.73
04/25/2024 04:00	0.8	1.5	1	0.44	0.22170	0.74
04/25/2024 05:00	0.8	1.5	0	0.49	0.24480	0.82
04/25/2024 06:00	0.6	1.4	0	0.54	0.27096	0.90
04/25/2024 07:00	0.6	1.4	0	0.52	0.25992	0.87
04/25/2024 08:00	0.7	1.4	0	0.48	0.24096	0.80
04/25/2024 09:00	0.7	1.5	1	0.44	0.21930	0.73
04/25/2024 10:00	0.7	1.5	1	0.44	0.21948	0.73
04/25/2024 11:00	0.7	1.5	1	0.44	0.22050	0.74
04/25/2024 12:00	0.7	1.4	0	0.44	0.22032	0.73
04/25/2024 13:00	0.6	1.5	0	0.44	0.22026	0.73
04/25/2024 14:00	0.6	1.4	0	0.44	0.21990	0.73
04/25/2024 15:00	0.6	1.4	0	0.45	0.22416	0.75
04/25/2024 16:00	0.6	1.4	0	0.44	0.21990	0.73
04/25/2024 17:00	0.6	1.4	0	0.45	0.22746	0.76
04/25/2024 18:00	0.6	1.5	0	0.44	0.22074	0.74
04/25/2024 19:00	0.6	1.3	0	0.49	0.24588	0.82
04/25/2024 20:00	0.7	1.4	1	0.44	0.21936	0.73
04/25/2024 21:00	0.7	1.4	1	0.45	0.22290	0.74
04/25/2024 22:00	0.7	1.5	1	0.44	0.22074	0.74
04/25/2024 23:00	0.7	1.4	1	0.44	0.22146	0.74
Average/Sum#:	0.7	1.4	1	0.45	0.22735	0.76
Minimum:	0.6	1.3	0	0.44	0.21810	0.73
Maximum:	0.8	1.5	1	0.54	0.27096	0.90
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/26/2024 00:00	0.7	1.5	1	0.44	0.22116	0.74
04/26/2024 01:00	0.7	1.5	1	0.44	0.22140	0.74
04/26/2024 02:00	0.7	1.5	1	0.44	0.22146	0.74
04/26/2024 03:00	0.8	1.6	1	0.44	0.22158	0.74
04/26/2024 04:00	0.7	1.5	1	0.44	0.22110	0.74
04/26/2024 05:00	0.7	1.5	1	0.44	0.22068	0.74
04/26/2024 06:00	0.7	1.5	1	0.44	0.22074	0.74
04/26/2024 07:00	0.7	1.5	1	0.44	0.22110	0.74
04/26/2024 08:00	0.7	1.5	1	0.44	0.22218	0.74
04/26/2024 09:00	0.7	1.4	1	0.45	0.22278	0.74
04/26/2024 10:00	0.6	1.5	0	0.44	0.22110	0.74
04/26/2024 11:00	0.6	1.4	1	0.44	0.22110	0.74
04/26/2024 12:00	0.6	1.5	0	0.44	0.22176	0.74
04/26/2024 13:00	0.6	1.4	1	0.44	0.22164	0.74
04/26/2024 14:00	0.6	1.5	0	0.44	0.22164	0.74
04/26/2024 15:00	0.6	1.4	0	0.44	0.22092	0.74
04/26/2024 16:00	0.6	1.4	1	0.44	0.22044	0.73
04/26/2024 17:00	0.7	1.5	1	0.44	0.21882	0.73
04/26/2024 18:00	0.7	1.5	1	0.44	0.22080	0.74
04/26/2024 19:00	0.7	1.5	1	0.44	0.21960	0.73
04/26/2024 20:00	0.7	1.5	1	0.44	0.21876	0.73
04/26/2024 21:00	0.7	1.5	1	0.44	0.21942	0.73
04/26/2024 22:00	0.8	1.5	1	0.44	0.21882	0.73
04/26/2024 23:00	0.8	1.5	1	0.44	0.21828	0.73
Average/Sum#:	0.7	1.5	1	0.44	0.22072	0.74
Minimum:	0.6	1.4	0	0.44	0.21828	0.73
Maximum:	0.8	1.6	1	0.45	0.22278	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/27/2024 00:00	0.8	1.5	1	0.44	0.21876	0.73
04/27/2024 01:00	0.8	1.5	1	0.44	0.22044	0.73
04/27/2024 02:00	0.8	1.5	1	0.44	0.21882	0.73
04/27/2024 03:00	0.8	1.5	1	0.44	0.21996	0.73
04/27/2024 04:00	0.8	1.5	1	0.44	0.22098	0.74
04/27/2024 05:00	0.8	1.4	1	0.44	0.22104	0.74
04/27/2024 06:00	0.8	1.4	1	0.44	0.22182	0.74
04/27/2024 07:00	0.7	1.5	1	0.44	0.22182	0.74
04/27/2024 08:00	0.7	1.5	1	0.44	0.22056	0.74
04/27/2024 09:00	0.7	1.5	1	0.44	0.21990	0.73
04/27/2024 10:00	0.7	1.5	1	0.44	0.22020	0.73
04/27/2024 11:00	0.7	1.5	1	0.44	0.22128	0.74
04/27/2024 12:00	0.6	1.4	0	0.44	0.22158	0.74
04/27/2024 13:00	0.6	1.5	0	0.44	0.22176	0.74
04/27/2024 14:00	0.6	1.5	0	0.44	0.22146	0.74
04/27/2024 15:00	0.6	1.5	0	0.44	0.22092	0.74
04/27/2024 16:00	0.6	1.5	0	0.44	0.22080	0.74
04/27/2024 17:00	0.6	1.4	0	0.45	0.22380	0.75
04/27/2024 18:00	0.6	1.4	0	0.45	0.22446	0.75
04/27/2024 19:00	0.7	1.4	1	0.44	0.21816	0.73
04/27/2024 20:00	0.7	1.4	1	0.44	0.21954	0.73
04/27/2024 21:00	0.7	1.4	0	0.44	0.21984	0.73
04/27/2024 22:00	0.6	1.5	0	0.56	0.27798	0.93
04/27/2024 23:00	0.6	1.5	0	0.56	0.27930	0.93
Average/Sum#:	0.7	1.5	1	0.45	0.22563	0.75
Minimum:	0.6	1.4	0	0.44	0.21816	0.73
Maximum:	0.8	1.5	1	0.56	0.27930	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/28/2024 00:00	0.6	1.5	0	0.56	0.28086	0.94
04/28/2024 01:00	0.6	1.4	0	0.54	0.27162	0.91
04/28/2024 02:00	0.6	1.4	0	0.54	0.27054	0.90
04/28/2024 03:00	0.7	1.5	1	0.55	0.27276	0.91
04/28/2024 04:00	0.6	1.4	0	0.54	0.27168	0.91
04/28/2024 05:00	0.7	1.5	1	0.48	0.23832	0.79
04/28/2024 06:00	0.8	1.4	0	0.44	0.21930	0.73
04/28/2024 07:00	0.7	1.4	0	0.44	0.21984	0.73
04/28/2024 08:00	0.7	1.4	0	0.44	0.21966	0.73
04/28/2024 09:00	0.7	1.4	0	0.44	0.21972	0.73
04/28/2024 10:00	0.7	1.4	0	0.44	0.22020	0.73
04/28/2024 11:00	0.6	1.4	1	0.44	0.22110	0.74
04/28/2024 12:00	0.6	1.4	0	0.44	0.22164	0.74
04/28/2024 13:00	0.6	1.4	0	0.44	0.22188	0.74
04/28/2024 14:00	0.6	1.4	0	0.44	0.22098	0.74
04/28/2024 15:00	0.6	1.5	0	0.44	0.21906	0.73
04/28/2024 16:00	0.6	1.5	0	0.44	0.21864	0.73
04/28/2024 17:00	0.6	1.5	0	0.44	0.21936	0.73
04/28/2024 18:00	0.6	1.4	0	0.44	0.22092	0.74
04/28/2024 19:00	0.6	1.4	0	0.44	0.21954	0.73
04/28/2024 20:00	0.7	1.5	0	0.44	0.21972	0.73
04/28/2024 21:00	0.7	1.5	0	0.44	0.21966	0.73
04/28/2024 22:00	0.7	1.5	1	0.44	0.21978	0.73
04/28/2024 23:00	0.7	1.5	1	0.44	0.21942	0.73
Average/Sum#:	0.7	1.4	0	0.46	0.23193	0.77
Minimum:	0.6	1.4	0	0.44	0.21864	0.73
Maximum:	0.8	1.5	1	0.56	0.28086	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/29/2024 00:00	0.7	1.5	1	0.44	0.21900	0.73
04/29/2024 01:00	0.7	1.5	1	0.44	0.21894	0.73
04/29/2024 02:00	0.8	1.5	1	0.44	0.21888	0.73
04/29/2024 03:00	0.8	1.5	1	0.44	0.21858	0.73
04/29/2024 04:00	0.8	1.5	0	0.45	0.22716	0.76
04/29/2024 05:00	0.7	1.5	1	0.47	0.23448	0.78
04/29/2024 06:00	0.7	1.4	0	0.44	0.21936	0.73
04/29/2024 07:00	0.7	1.4	0	0.44	0.21954	0.73
04/29/2024 08:00	0.7	1.4	0	0.44	0.21954	0.73
04/29/2024 09:00	0.7	1.4	0	0.44	0.21906	0.73
04/29/2024 10:00	0.7	1.4	0	0.44	0.21966	0.73
04/29/2024 11:00	0.6	1.4	0	0.44	0.21990	0.73
04/29/2024 12:00	0.6	1.5	1	0.44	0.22050	0.74
04/29/2024 13:00	0.6	1.4	1	0.44	0.22038	0.73
04/29/2024 14:00	0.6	1.4	1	0.44	0.22074	0.74
04/29/2024 15:00	0.6	1.4	0	0.44	0.22002	0.73
04/29/2024 16:00	0.6	1.5	0	0.44	0.21948	0.73
04/29/2024 17:00	0.6	1.4	0	0.48	0.24072	0.80
04/29/2024 18:00	0.6	1.4	0	0.53	0.26700	0.89
04/29/2024 19:00	0.6	1.5	0	0.53	0.26310	0.88
04/29/2024 20:00	0.8	1.4	0	0.45	0.22320	0.74
04/29/2024 21:00	0.9	1.4	0	0.44	0.21798	0.73
04/29/2024 22:00	0.8	1.4	0	0.44	0.21816	0.73
04/29/2024 23:00	0.7	1.4	0	0.44	0.21864	0.73
Average/Sum#:	0.7	1.4	0	0.45	0.22517	0.75
Minimum:	0.6	1.4	0	0.44	0.21798	0.73
Maximum:	0.9	1.5	1	0.53	0.26700	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/30/2024 00:00	0.7	1.4	0	0.44	0.21864	0.73
04/30/2024 01:00	0.8	1.4	0	0.44	0.21774	0.73
04/30/2024 02:00	0.8	1.6	0	0.44	0.21816	0.73
04/30/2024 03:00	0.9	1.5	1	0.45	0.22278	0.74
04/30/2024 04:00	0.8	1.5	1	0.46	0.22758	0.76
04/30/2024 05:00	0.7	1.4	0	0.49	0.24636	0.82
04/30/2024 06:00	0.8	1.5	1	0.44	0.22236	0.74
04/30/2024 07:00	0.7	1.5	1	0.44	0.22026	0.73
04/30/2024 08:00	0.7	1.4	0	0.44	0.21792	0.73
04/30/2024 09:00	0.7	1.4	0	0.43	0.21708	0.72
04/30/2024 10:00	0.7	1.4	0	0.44	0.21798	0.73
04/30/2024 11:00	0.7	1.4	0	0.44	0.21948	0.73
04/30/2024 12:00	0.6	1.5	1	0.44	0.22074	0.74
04/30/2024 13:00	0.6	1.4	0	0.44	0.21972	0.73
04/30/2024 14:00	0.6	1.4	0	0.44	0.22104	0.74
04/30/2024 15:00	0.6	1.4	1	0.44	0.22062	0.74
04/30/2024 16:00	0.6	1.4	1	0.44	0.21756	0.73
04/30/2024 17:00	0.6	1.4	0	0.48	0.23922	0.80
04/30/2024 18:00	0.6	1.4	0	0.51	0.25410	0.85
04/30/2024 19:00	0.7	1.5	0	0.54	0.27216	0.91
04/30/2024 20:00	0.7	1.4	0	0.53	0.26670	0.89
04/30/2024 21:00	0.6	1.5	0	0.55	0.27702	0.92
04/30/2024 22:00	0.6	1.5	0	0.56	0.27864	0.93
04/30/2024 23:00	0.6	1.5	0	0.56	0.27768	0.93
Average/Sum#:	0.7	1.4	0	0.47	0.23465	0.78
Minimum:	0.6	1.4	0	0.43	0.21708	0.72
Maximum:	0.9	1.6	1	0.56	0.27864	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/01/2024 00:00	0.7	1.4	0	0.49	0.24432	0.81
05/01/2024 01:00	0.7	1.4	0	0.44	0.21768	0.73
05/01/2024 02:00	0.7	1.4	0	0.44	0.21810	0.73
05/01/2024 03:00	0.8	1.4	0	0.46	0.22800	0.76
05/01/2024 04:00	0.7	1.4	0	0.47	0.23466	0.78
05/01/2024 05:00	0.7	1.5	1	0.52	0.25758	0.86
05/01/2024 06:00	0.7	1.4	0	0.45	0.22284	0.74
05/01/2024 07:00	0.7	1.4	0	0.45	0.22254	0.74
05/01/2024 08:00	0.7	1.4	0	0.44	0.22116	0.74
05/01/2024 09:00	0.6	1.4	0	0.44	0.22128	0.74
05/01/2024 10:00	0.6	1.4	0	0.44	0.22194	0.74
05/01/2024 11:00	0.6	1.4	0	0.44	0.22170	0.74
05/01/2024 12:00	0.6	1.4	1	0.44	0.21918	0.73
05/01/2024 13:00	0.6	1.4	0	0.44	0.21948	0.73
05/01/2024 14:00	0.6	1.4	0	0.44	0.21954	0.73
05/01/2024 15:00	0.6	1.4	0	0.44	0.21756	0.73
05/01/2024 16:00	0.6	1.4	0	0.43	0.21636	0.72
05/01/2024 17:00	0.6	1.4	1	0.44	0.22014	0.73
05/01/2024 18:00	0.6	1.4	1	0.43	0.21708	0.72
05/01/2024 19:00	0.6	1.4	1	0.43	0.21738	0.72
05/01/2024 20:00	0.6	1.5	1	0.44	0.21750	0.73
05/01/2024 21:00	0.6	1.5	0	0.43	0.21666	0.72
05/01/2024 22:00	0.6	1.5	1	0.43	0.21666	0.72
05/01/2024 23:00	0.7	1.5	1	0.43	0.21684	0.72
Average/Sum#:	0.6	1.4	0	0.45	0.22276	0.74
Minimum:	0.6	1.4	0	0.43	0.21636	0.72
Maximum:	0.8	1.5	1	0.52	0.25758	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/02/2024 00:00	0.7	1.5	1	0.43	0.21660	0.72
05/02/2024 01:00	0.7	1.4	0	0.43	0.21612	0.72
05/02/2024 02:00	0.7	1.3	0	0.43	0.21582	0.72
05/02/2024 03:00	0.8	1.4	1	0.43	0.21564	0.72
05/02/2024 04:00	0.7	1.4	0	0.46	0.23022	0.77
05/02/2024 05:00	0.7	1.4	0	0.52	0.25878	0.86
05/02/2024 06:00	0.7	1.4	0	0.50	0.25224	0.84
05/02/2024 07:00	0.7	1.5	0	0.48	0.24210	0.81
05/02/2024 08:00	0.6	1.4	0	0.52	0.26040	0.87
05/02/2024 09:00	0.7	1.4	0	0.54	0.27036	0.90
05/02/2024 10:00	0.7	1.4	0	0.54	0.26928	0.90
05/02/2024 11:00	0.6	1.4	0	0.50	0.25062	0.84
05/02/2024 12:00	0.6	1.3	0	0.45	0.22458	0.75
05/02/2024 13:00	0.6	1.4	0	0.47	0.23442	0.78
05/02/2024 14:00	0.6	1.4	0	0.44	0.22122	0.74
05/02/2024 15:00	0.6	1.4	0	0.44	0.21948	0.73
05/02/2024 16:00	0.6	1.4	0	0.44	0.21828	0.73
05/02/2024 17:00	0.6	1.4	0	0.46	0.22848	0.76
05/02/2024 18:00	0.6	1.4	0	0.50	0.24864	0.83
05/02/2024 19:00	0.7	1.4	0	0.46	0.23094	0.77
05/02/2024 20:00	0.7	1.4	1	0.43	0.21702	0.72
05/02/2024 21:00	0.7	1.4	1	0.43	0.21678	0.72
05/02/2024 22:00	0.7	1.3	0	0.43	0.21642	0.72
05/02/2024 23:00	0.7	1.4	0	0.44	0.21750	0.73
Average/Sum#:	0.7	1.4	0	0.47	0.23300	0.78
Minimum:	0.6	1.3	0	0.43	0.21564	0.72
Maximum:	0.8	1.5	1	0.54	0.27036	0.90
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/03/2024 00:00	0.7	1.4	0	0.43	0.21702	0.72
05/03/2024 01:00	0.8	1.4	0	0.43	0.21720	0.72
05/03/2024 02:00	0.7	1.4	0	0.44	0.21792	0.73
05/03/2024 03:00	0.8	1.4	0	0.44	0.22044	0.73
05/03/2024 04:00	0.7	1.4	1	0.49	0.24708	0.82
05/03/2024 05:00	0.7	1.4	0	0.49	0.24648	0.82
05/03/2024 06:00	0.7	1.4	0	0.44	0.21750	0.73
05/03/2024 07:00	0.7	1.4	0	0.44	0.21750	0.73
05/03/2024 08:00	0.7	1.4	0	0.44	0.21762	0.73
05/03/2024 09:00	0.6	1.5	0	0.53	0.26568	0.89
05/03/2024 10:00	0.6	1.4	0	0.51	0.25470	0.85
05/03/2024 11:00	0.6	1.4	0	0.44	0.21786	0.73
05/03/2024 12:00	0.6	1.4	0	0.45	0.22620	0.75
05/03/2024 13:00	0.6	1.4	0	0.43	0.21660	0.72
05/03/2024 14:00	0.6	1.4	0	0.43	0.21744	0.72
05/03/2024 15:00	0.6	1.4	0	0.49	0.24426	0.81
05/03/2024 16:00	0.6	1.3	0	0.47	0.23646	0.79
05/03/2024 17:00	0.6	1.3	0	0.47	0.23376	0.78
05/03/2024 18:00	0.7	1.4	0	0.43	0.21726	0.72
05/03/2024 19:00	0.7	1.4	1	0.43	0.21684	0.72
05/03/2024 20:00	0.7	1.3	0	0.43	0.21726	0.72
05/03/2024 21:00	0.7	1.4	0	0.43	0.21654	0.72
05/03/2024 22:00	0.7	1.4	0	0.43	0.21570	0.72
05/03/2024 23:00	0.7	1.5	0	0.43	0.21540	0.72
Average/Sum#:	0.7	1.4	0	0.45	0.22628	0.75
Minimum:	0.6	1.3	0	0.43	0.21540	0.72
Maximum:	0.8	1.5	1	0.53	0.26568	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/04/2024 00:00	0.7	1.5	1	0.44	0.21756	0.73
05/04/2024 01:00	0.7	1.5	1	0.44	0.21798	0.73
05/04/2024 02:00	0.7	1.6	1	0.44	0.21798	0.73
05/04/2024 03:00	0.8	1.5	1	0.44	0.21822	0.73
05/04/2024 04:00	0.7	1.4	0	0.44	0.21846	0.73
05/04/2024 05:00	0.7	1.4	0	0.44	0.21840	0.73
05/04/2024 06:00	0.7	1.4	0	0.43	0.21636	0.72
05/04/2024 07:00	0.8	1.4	1	0.43	0.21540	0.72
05/04/2024 08:00	0.6	1.4	0	0.54	0.26772	0.89
05/04/2024 09:00	0.6	1.5	1	0.55	0.27540	0.92
05/04/2024 10:00	0.6	1.5	1	0.56	0.27978	0.93
05/04/2024 11:00	0.6	1.5	1	0.56	0.28008	0.93
05/04/2024 12:00	0.6	1.5	1	0.56	0.28008	0.93
05/04/2024 13:00	0.6	1.5	1	0.56	0.27990	0.93
05/04/2024 14:00	0.6	1.5	1	0.56	0.27966	0.93
05/04/2024 15:00	0.7	1.4	0	0.46	0.23028	0.77
05/04/2024 16:00	0.7	1.4	0	0.43	0.21636	0.72
05/04/2024 17:00	0.7	1.4	0	0.44	0.21762	0.73
05/04/2024 18:00	0.7	1.4	0	0.44	0.21804	0.73
05/04/2024 19:00	0.7	1.4	0	0.44	0.21762	0.73
05/04/2024 20:00	0.7	1.4	1	0.44	0.21792	0.73
05/04/2024 21:00	0.7	1.5	1	0.49	0.24342	0.81
05/04/2024 22:00	0.7	1.5	1	0.46	0.22920	0.76
05/04/2024 23:00	0.8	1.5	1	0.44	0.21780	0.73
Average/Sum#:	0.7	1.5	1	0.48	0.23714	0.79
Minimum:	0.6	1.4	0	0.43	0.21540	0.72
Maximum:	0.8	1.6	1	0.56	0.28008	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/05/2024 00:00	0.8	1.5	1	0.44	0.21786	0.73
05/05/2024 01:00	0.8	1.5	1	0.44	0.21768	0.73
05/05/2024 02:00	0.8	1.3	0	0.44	0.21792	0.73
05/05/2024 03:00	0.9	1.4	1	0.44	0.21762	0.73
05/05/2024 04:00	0.8	1.5	1	0.44	0.21750	0.73
05/05/2024 05:00	0.9	1.5	1	0.45	0.22284	0.74
05/05/2024 06:00	0.8	1.5	1	0.44	0.21858	0.73
05/05/2024 07:00	0.8	1.5	1	0.44	0.21786	0.73
05/05/2024 08:00	0.7	1.5	1	0.43	0.21732	0.72
05/05/2024 09:00	0.7	1.5	1	0.43	0.21726	0.72
05/05/2024 10:00	0.7	1.5	1	0.44	0.21918	0.73
05/05/2024 11:00	0.7	1.5	1	0.44	0.21906	0.73
05/05/2024 12:00	0.7	1.5	1	0.44	0.21834	0.73
05/05/2024 13:00	0.7	1.4	1	0.44	0.21804	0.73
05/05/2024 14:00	0.7	1.4	0	0.43	0.21744	0.72
05/05/2024 15:00	0.7	1.3	0	0.43	0.21690	0.72
05/05/2024 16:00	0.7	1.5	1	0.43	0.21678	0.72
05/05/2024 17:00	0.8	1.5	1	0.43	0.21696	0.72
05/05/2024 18:00	0.7	1.5	1	0.43	0.21600	0.72
05/05/2024 19:00	0.7	1.4	0	0.43	0.21540	0.72
05/05/2024 20:00	0.7	1.5	1	0.43	0.21462	0.72
05/05/2024 21:00	0.7	1.5	1	0.43	0.21450	0.72
05/05/2024 22:00	0.7	1.5	1	0.43	0.21552	0.72
05/05/2024 23:00	0.8	1.5	1	0.43	0.21684	0.72
Average/Sum#:	0.8	1.5	1	0.44	0.21742	0.73
Minimum:	0.7	1.3	0	0.43	0.21450	0.72
Maximum:	0.9	1.5	1	0.45	0.22284	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/06/2024 00:00	0.8	1.5	1	0.43	0.21666	0.72
05/06/2024 01:00	0.8	1.5	1	0.43	0.21660	0.72
05/06/2024 02:00	0.8	1.5	1	0.43	0.21654	0.72
05/06/2024 03:00	0.9	1.5	1	0.43	0.21660	0.72
05/06/2024 04:00	0.8	1.5	1	0.43	0.21660	0.72
05/06/2024 05:00	0.8	1.5	1	0.43	0.21534	0.72
05/06/2024 06:00	0.8	1.5	1	0.43	0.21582	0.72
05/06/2024 07:00	0.8	1.5	1	0.43	0.21690	0.72
05/06/2024 08:00	0.7	1.5	1	0.43	0.21732	0.72
05/06/2024 09:00	0.7	1.5	1	0.44	0.21780	0.73
05/06/2024 10:00	0.7	1.4	0	0.43	0.21510	0.72
05/06/2024 11:00	0.7	1.4	0	0.43	0.21522	0.72
05/06/2024 12:00	0.7	1.4	1	0.43	0.21708	0.72
05/06/2024 13:00	0.7	1.4	0	0.43	0.21720	0.72
05/06/2024 14:00	0.6	1.4	0	0.44	0.21768	0.73
05/06/2024 15:00	0.6	1.4	1	0.43	0.21726	0.72
05/06/2024 16:00	0.6	1.4	1	0.43	0.21570	0.72
05/06/2024 17:00	0.7	1.4	1	0.43	0.21642	0.72
05/06/2024 18:00	0.7	1.4	1	0.43	0.21672	0.72
05/06/2024 19:00	0.7	1.5	0	0.43	0.21624	0.72
05/06/2024 20:00	0.7	1.4	1	0.43	0.21636	0.72
05/06/2024 21:00	0.8	1.5	1	0.43	0.21636	0.72
05/06/2024 22:00	0.8	1.5	1	0.43	0.21612	0.72
05/06/2024 23:00	0.8	1.5	1	0.43	0.21612	0.72
Average/Sum#:	0.7	1.5	1	0.43	0.21649	0.72
Minimum:	0.6	1.4	0	0.43	0.21510	0.72
Maximum:	0.9	1.5	1	0.44	0.21780	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/07/2024 00:00	0.8	1.4	1	0.43	0.21600	0.72
05/07/2024 01:00	0.8	1.5	1	0.43	0.21630	0.72
05/07/2024 02:00	0.8	1.6	1	0.43	0.21618	0.72
05/07/2024 03:00	0.9	1.5	1	0.43	0.21600	0.72
05/07/2024 04:00	0.8	1.5	1	0.43	0.21600	0.72
05/07/2024 05:00	0.8	1.5	1	0.43	0.21594	0.72
05/07/2024 06:00	0.8	1.4	1	0.43	0.21624	0.72
05/07/2024 07:00	0.9	1.4	0	0.43	0.21612	0.72
05/07/2024 08:00	0.8	1.3	0	0.43	0.21732	0.72
05/07/2024 09:00	0.8	1.4	0	0.43	0.21516	0.72
05/07/2024 10:00	0.7	1.4	0	0.43	0.21564	0.72
05/07/2024 11:00	0.7	1.4	0	0.43	0.21732	0.72
05/07/2024 12:00	0.7	1.4	0	0.43	0.21690	0.72
05/07/2024 13:00	0.7	1.4	0	0.44	0.21780	0.73
05/07/2024 14:00	0.7	1.4	1	0.43	0.21678	0.72
05/07/2024 15:00	0.7	1.4	1	0.43	0.21546	0.72
05/07/2024 16:00	0.7	1.4	1	0.43	0.21582	0.72
05/07/2024 17:00	0.7	1.4	1	0.43	0.21612	0.72
05/07/2024 18:00	0.6	1.4	0	0.43	0.21678	0.72
05/07/2024 19:00	0.7	1.4	0	0.43	0.21738	0.72
05/07/2024 20:00	0.7	1.5	0	0.44	0.22068	0.74
05/07/2024 21:00	0.7	1.4	1	0.43	0.21642	0.72
05/07/2024 22:00	0.8	1.4	0	0.43	0.21552	0.72
05/07/2024 23:00	0.8	1.4	0	0.43	0.21552	0.72
Average/Sum#:	0.8	1.4	1	0.43	0.21648	0.72
Minimum:	0.6	1.3	0	0.43	0.21516	0.72
Maximum:	0.9	1.6	1	0.44	0.22068	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/08/2024 00:00	0.7	1.5	1	0.43	0.21504	0.72
05/08/2024 01:00	0.7	1.4	1	0.43	0.21630	0.72
05/08/2024 02:00	0.7	1.3	0	0.43	0.21570	0.72
05/08/2024 03:00	0.8	1.4	1	0.43	0.21552	0.72
05/08/2024 04:00	0.7	1.4	1	0.46	0.22926	0.76
05/08/2024 05:00	0.7	1.5	1	0.50	0.24834	0.83
05/08/2024 06:00	0.7	1.4	0	0.43	0.21606	0.72
05/08/2024 07:00	0.7	1.4	0	0.43	0.21522	0.72
05/08/2024 08:00	0.7	1.4	1	0.43	0.21474	0.72
05/08/2024 09:00	0.7	1.5	1	0.43	0.21396	0.71
05/08/2024 10:00	0.6	1.4	0	0.43	0.21588	0.72
05/08/2024 11:00	0.6	1.4	0	0.44	0.21768	0.73
05/08/2024 12:00	0.6	1.4	0	0.44	0.21762	0.73
05/08/2024 13:00	0.6	1.4	1	0.44	0.21762	0.73
05/08/2024 14:00	0.6	1.3	0	0.44	0.21774	0.73
05/08/2024 15:00	0.6	1.3	0	0.43	0.21738	0.72
05/08/2024 16:00	0.6	1.4	0	0.43	0.21708	0.72
05/08/2024 17:00	0.6	1.4	0	0.45	0.22416	0.75
05/08/2024 18:00	0.7	1.4	0	0.43	0.21660	0.72
05/08/2024 19:00	0.7	1.4	0	0.44	0.22224	0.74
05/08/2024 20:00	0.7	1.5	1	0.43	0.21582	0.72
05/08/2024 21:00	0.7	1.4	1	0.43	0.21588	0.72
05/08/2024 22:00	0.7	1.4	1	0.43	0.21594	0.72
05/08/2024 23:00	0.7	1.5	1	0.43	0.21570	0.72
Average/Sum#:	0.7	1.4	1	0.44	0.21865	0.73
Minimum:	0.6	1.3	0	0.43	0.21396	0.71
Maximum:	0.8	1.5	1	0.50	0.24834	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/09/2024 00:00	0.7	1.4	1	0.43	0.21552	0.72
05/09/2024 01:00	0.7	1.5	1	0.43	0.21558	0.72
05/09/2024 02:00	0.7	1.5	1	0.43	0.21534	0.72
05/09/2024 03:00	0.8	1.5	1	0.43	0.21576	0.72
05/09/2024 04:00	0.8	1.5	1	0.43	0.21540	0.72
05/09/2024 05:00	0.8	1.5	1	0.43	0.21570	0.72
05/09/2024 06:00	0.7	1.5	1	0.43	0.21672	0.72
05/09/2024 07:00	0.7	1.5	1	0.43	0.21684	0.72
05/09/2024 08:00	0.7	1.4	1	0.43	0.21618	0.72
05/09/2024 09:00	0.6	1.4	0	0.43	0.21642	0.72
05/09/2024 10:00	0.6	1.4	0	0.43	0.21654	0.72
05/09/2024 11:00	0.6	1.4	0	0.44	0.21768	0.73
05/09/2024 12:00	0.6	1.3	0	0.44	0.21816	0.73
05/09/2024 13:00	0.7	1.4	0	0.44	0.21900	0.73
05/09/2024 14:00	0.6	1.4	0	0.44	0.21876	0.73
05/09/2024 15:00	0.6	1.3	0	0.43	0.21642	0.72
05/09/2024 16:00	0.6	1.4	0	0.43	0.21534	0.72
05/09/2024 17:00	0.6	1.3	0	0.45	0.22290	0.74
05/09/2024 18:00	0.6	1.4	0	0.43	0.21666	0.72
05/09/2024 19:00	0.6	1.4	0	0.43	0.21462	0.72
05/09/2024 20:00	0.7	1.4	0	0.43	0.21474	0.72
05/09/2024 21:00	0.7	1.4	0	0.43	0.21444	0.71
05/09/2024 22:00	0.7	1.4	0	0.43	0.21516	0.72
05/09/2024 23:00	0.7	1.4	0	0.43	0.21462	0.72
Average/Sum#:	0.7	1.4	0	0.43	0.21644	0.72
Minimum:	0.6	1.3	0	0.43	0.21444	0.71
Maximum:	0.8	1.5	1	0.45	0.22290	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/10/2024 00:00	0.8	1.4	0	0.44	0.21798	0.73
05/10/2024 01:00	0.7	1.5	1	0.43	0.21648	0.72
05/10/2024 02:00	0.7	1.4	0	0.43	0.21630	0.72
05/10/2024 03:00	1.0	1.4	0	0.43	0.21600	0.72
05/10/2024 04:00	0.9	1.4	1	0.43	0.21624	0.72
05/10/2024 05:00	0.9	1.5	1	0.43	0.21588	0.72
05/10/2024 06:00	1.1	1.4	1	0.43	0.21684	0.72
05/10/2024 07:00	0.8	1.5	0	0.44	0.21786	0.73
05/10/2024 08:00	0.7	1.4	0	0.44	0.21780	0.73
05/10/2024 09:00	0.7	1.4	0	0.44	0.21804	0.73
05/10/2024 10:00	0.7	1.4	0	0.44	0.22038	0.73
05/10/2024 11:00	0.6	1.3	0	0.43	0.21696	0.72
05/10/2024 12:00	0.6	1.4	0	0.43	0.21684	0.72
05/10/2024 13:00	0.6	1.3	0	0.43	0.21672	0.72
05/10/2024 14:00	0.7	1.3	0	0.45	0.22608	0.75
05/10/2024 15:00	0.7	1.4	0	0.51	0.25644	0.85
05/10/2024 16:00	0.6	1.3	0	0.44	0.21930	0.73
05/10/2024 17:00	0.6	1.4	0	0.46	0.22770	0.76
05/10/2024 18:00	0.6	1.3	0	0.51	0.25494	0.85
05/10/2024 19:00	0.7	1.4	0	0.46	0.23094	0.77
05/10/2024 20:00	0.7	1.4	0	0.44	0.21906	0.73
05/10/2024 21:00	0.7	1.4	0	0.46	0.23010	0.77
05/10/2024 22:00	0.7	1.3	0	0.49	0.24414	0.81
05/10/2024 23:00	0.8	1.4	0	0.43	0.21558	0.72
Average/Sum#:	0.7	1.4	0	0.45	0.22353	0.74
Minimum:	0.6	1.3	0	0.43	0.21558	0.72
Maximum:	1.1	1.5	1	0.51	0.25644	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/11/2024 00:00	0.8	1.4	0	0.43	0.21594	0.72
05/11/2024 01:00	0.8	1.5	0	0.43	0.21690	0.72
05/11/2024 02:00	0.7	1.4	0	0.44	0.21756	0.73
05/11/2024 03:00	0.8	1.4	0	0.44	0.21750	0.73
05/11/2024 04:00	0.8	1.4	0	0.43	0.21732	0.72
05/11/2024 05:00	0.8	1.4	0	0.43	0.21714	0.72
05/11/2024 06:00	0.9	1.4	0	0.43	0.21726	0.72
05/11/2024 07:00	0.8	1.4	0	0.44	0.21810	0.73
05/11/2024 08:00	0.7	1.4	0	0.44	0.21834	0.73
05/11/2024 09:00	0.7	1.3	0	0.44	0.21834	0.73
05/11/2024 10:00	0.7	1.4	0	0.43	0.21714	0.72
05/11/2024 11:00	0.6	1.4	0	0.51	0.25572	0.85
05/11/2024 12:00	0.6	1.4	0	0.44	0.21840	0.73
05/11/2024 13:00	0.6	1.3	0	0.50	0.25122	0.84
05/11/2024 14:00	0.6	1.3	0	0.51	0.25374	0.85
05/11/2024 15:00	0.6	1.4	0	0.53	0.26328	0.88
05/11/2024 16:00	0.6	1.4	0	0.45	0.22470	0.75
05/11/2024 17:00	0.6	1.4	0	0.47	0.23358	0.78
05/11/2024 18:00	0.6	1.3	0	0.48	0.23904	0.80
05/11/2024 19:00	0.6	1.4	0	0.43	0.21732	0.72
05/11/2024 20:00	0.6	1.4	0	0.53	0.26292	0.88
05/11/2024 21:00	0.7	1.3	0	0.53	0.26718	0.89
05/11/2024 22:00	0.6	1.4	0	0.53	0.26670	0.89
05/11/2024 23:00	0.7	1.4	0	0.50	0.25038	0.83
Average/Sum#:	0.7	1.4	0	0.47	0.23316	0.78
Minimum:	0.6	1.3	0	0.43	0.21594	0.72
Maximum:	0.9	1.5	0	0.53	0.26718	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/12/2024 00:00	0.8	1.3	0	0.45	0.22278	0.74
05/12/2024 01:00	0.8	1.3	0	0.45	0.22386	0.75
05/12/2024 02:00	0.8	1.5	0	0.43	0.21744	0.72
05/12/2024 03:00	0.9	1.4	0	0.43	0.21732	0.72
05/12/2024 04:00	0.8	1.4	0	0.43	0.21744	0.72
05/12/2024 05:00	0.8	1.4	0	0.44	0.21768	0.73
05/12/2024 06:00	0.8	1.4	0	0.44	0.21822	0.73
05/12/2024 07:00	0.8	1.4	0	0.44	0.21954	0.73
05/12/2024 08:00	0.8	1.5	0	0.44	0.21912	0.73
05/12/2024 09:00	0.7	1.3	0	0.44	0.21888	0.73
05/12/2024 10:00	0.7	1.4	0	0.44	0.21834	0.73
05/12/2024 11:00	0.7	1.4	0	0.44	0.21918	0.73
05/12/2024 12:00	0.7	1.4	0	0.44	0.21960	0.73
05/12/2024 13:00	0.6	1.4	0	0.44	0.22038	0.73
05/12/2024 14:00	0.6	1.4	0	0.44	0.22020	0.73
05/12/2024 15:00	0.7	1.4	0	0.44	0.21960	0.73
05/12/2024 16:00	0.6	1.4	0	0.44	0.21954	0.73
05/12/2024 17:00	0.6	1.4	0	0.45	0.22680	0.76
05/12/2024 18:00	0.7	1.4	0	0.44	0.21834	0.73
05/12/2024 19:00	0.7	1.4	0	0.43	0.21660	0.72
05/12/2024 20:00	0.7	1.4	0	0.43	0.21654	0.72
05/12/2024 21:00	0.7	1.4	0	0.43	0.21618	0.72
05/12/2024 22:00	0.8	1.4	0	0.43	0.21600	0.72
05/12/2024 23:00	0.8	1.4	0	0.43	0.21696	0.72
Average/Sum#:	0.7	1.4	0	0.44	0.21902	0.73
Minimum:	0.6	1.3	0	0.43	0.21600	0.72
Maximum:	0.9	1.5	0	0.45	0.22680	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/13/2024 00:00	0.8	1.5	0	0.43	0.21726	0.72
05/13/2024 01:00	0.8	1.4	1	0.43	0.21690	0.72
05/13/2024 02:00	0.8	1.5	0	0.43	0.21678	0.72
05/13/2024 03:00	0.9	1.5	0	0.43	0.21648	0.72
05/13/2024 04:00	0.8	1.4	1	0.43	0.21648	0.72
05/13/2024 05:00	0.8	1.4	0	0.44	0.21972	0.73
05/13/2024 06:00	0.8	1.4	1	0.43	0.21684	0.72
05/13/2024 07:00	0.8	1.5	0	0.43	0.21744	0.72
05/13/2024 08:00	0.8	1.4	0	0.43	0.21726	0.72
05/13/2024 09:00	0.8	1.4	0	0.44	0.21756	0.73
05/13/2024 10:00	0.7	1.4	0	0.43	0.21678	0.72
05/13/2024 11:00	0.7	1.4	0	0.43	0.21702	0.72
05/13/2024 12:00	0.7	1.4	0	0.44	0.21834	0.73
05/13/2024 13:00	0.6	1.4	0	0.44	0.21858	0.73
05/13/2024 14:00	0.6	1.4	0	0.44	0.21846	0.73
05/13/2024 15:00	0.6	1.4	0	0.44	0.21816	0.73
05/13/2024 16:00	0.6	1.3	0	0.44	0.22146	0.74
05/13/2024 17:00	0.6	1.3	0	0.50	0.25044	0.83
05/13/2024 18:00	0.7	1.4	0	0.50	0.24972	0.83
05/13/2024 19:00	0.7	1.4	0	0.49	0.24276	0.81
05/13/2024 20:00	0.7	1.4	0	0.43	0.21606	0.72
05/13/2024 21:00	0.7	1.4	0	0.43	0.21738	0.72
05/13/2024 22:00	0.7	1.4	0	0.44	0.21810	0.73
05/13/2024 23:00	0.7	1.4	0	0.44	0.21834	0.73
Average/Sum#:	0.7	1.4	0	0.44	0.22143	0.74
Minimum:	0.6	1.3	0	0.43	0.21606	0.72
Maximum:	0.9	1.5	1	0.50	0.25044	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/14/2024 00:00	0.7	1.4	0	0.44	0.21828	0.73
05/14/2024 01:00	0.7	1.4	0	0.43	0.21738	0.72
05/14/2024 02:00	0.8	1.5	0	0.43	0.21726	0.72
05/14/2024 03:00	0.9	1.5	1	0.43	0.21696	0.72
05/14/2024 04:00	0.8	1.4	0	0.43	0.21708	0.72
05/14/2024 05:00	0.8	1.4	0	0.43	0.21696	0.72
05/14/2024 06:00	0.8	1.4	0	0.44	0.21798	0.73
05/14/2024 07:00	0.8	1.4	0	0.44	0.21900	0.73
05/14/2024 08:00	0.7	1.4	0	0.44	0.21894	0.73
05/14/2024 09:00	0.7	1.4	0	0.44	0.21948	0.73
05/14/2024 10:00	0.7	1.4	0	0.44	0.21942	0.73
05/14/2024 11:00	0.7	1.4	0	0.44	0.21870	0.73
05/14/2024 12:00	0.6	1.3	0	0.44	0.21984	0.73
05/14/2024 13:00	0.6	1.4	0	0.44	0.21984	0.73
05/14/2024 14:00	0.7	1.4	0	0.44	0.22002	0.73
05/14/2024 15:00	0.7	1.4	0	0.44	0.21882	0.73
05/14/2024 16:00	0.7	1.3	0	0.47	0.23388	0.78
05/14/2024 17:00	0.6	1.3	0	0.48	0.24240	0.81
05/14/2024 18:00	0.7	1.4	0	0.43	0.21636	0.72
05/14/2024 19:00	0.7	1.4	0	0.43	0.21576	0.72
05/14/2024 20:00	0.7	1.4	0	0.43	0.21708	0.72
05/14/2024 21:00	0.7	1.4	0	0.43	0.21642	0.72
05/14/2024 22:00	0.7	1.4	0	0.43	0.21576	0.72
05/14/2024 23:00	0.7	1.4	0	0.43	0.21552	0.72
Average/Sum#:	0.7	1.4	0	0.44	0.21955	0.73
Minimum:	0.6	1.3	0	0.43	0.21552	0.72
Maximum:	0.9	1.5	1	0.48	0.24240	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/15/2024 00:00	0.8	1.4	0	0.43	0.21552	0.72
05/15/2024 01:00	0.8	1.4	0	0.43	0.21522	0.72
05/15/2024 02:00	0.8	1.4	0	0.43	0.21576	0.72
05/15/2024 03:00	0.8	1.5	0	0.43	0.21726	0.72
05/15/2024 04:00	0.8	1.4	1	0.43	0.21738	0.72
05/15/2024 05:00	0.8	1.4	1	0.43	0.21708	0.72
05/15/2024 06:00	0.8	1.4	1	0.44	0.21780	0.73
05/15/2024 07:00	0.8	1.4	0	0.43	0.21738	0.72
05/15/2024 08:00	0.8	1.4	0	0.44	0.21762	0.73
05/15/2024 09:00	0.7	1.4	0	0.43	0.21732	0.72
05/15/2024 10:00	0.7	1.4	0	0.43	0.21678	0.72
05/15/2024 11:00	0.7	1.4	0	0.44	0.21804	0.73
05/15/2024 12:00	0.6	1.4	0	0.44	0.21876	0.73
05/15/2024 13:00	0.6	1.4	0	0.44	0.21888	0.73
05/15/2024 14:00	0.6	1.4	0	0.44	0.21924	0.73
05/15/2024 15:00	0.6	1.4	0	0.44	0.21876	0.73
05/15/2024 16:00	0.6	1.4	0	0.44	0.21786	0.73
05/15/2024 17:00	0.6	1.3	0	0.45	0.22740	0.76
05/15/2024 18:00	0.6	1.3	0	0.48	0.23796	0.79
05/15/2024 19:00	0.7	1.3	0	0.45	0.22470	0.75
05/15/2024 20:00	0.7	1.4	0	0.45	0.22602	0.75
05/15/2024 21:00	0.7	1.4	0	0.44	0.21828	0.73
05/15/2024 22:00	0.6	1.4	0	0.54	0.26766	0.89
05/15/2024 23:00	0.7	1.4	0	0.44	0.21876	0.73
Average/Sum#:	0.7	1.4	0	0.44	0.22156	0.74
Minimum:	0.6	1.3	0	0.43	0.21522	0.72
Maximum:	0.8	1.5	1	0.54	0.26766	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/16/2024 00:00	0.7	1.4	0	0.43	0.21738	0.72
05/16/2024 01:00	0.7	1.4	1	0.43	0.21720	0.72
05/16/2024 02:00	0.7	1.2	0	0.43	0.21708	0.72
05/16/2024 03:00	0.7	1.4	0	0.49	0.24564	0.82
05/16/2024 04:00	0.6	1.4	0	0.53	0.26646	0.89
05/16/2024 05:00	0.7	1.4	1	0.48	0.24210	0.81
05/16/2024 06:00	0.7	1.4	1	0.44	0.21930	0.73
05/16/2024 07:00	0.7	1.5	1	0.43	0.21696	0.72
05/16/2024 08:00	0.7	1.4	0	0.43	0.21654	0.72
05/16/2024 09:00	0.7	1.4	0	0.43	0.21714	0.72
05/16/2024 10:00	0.7	1.4	0	0.44	0.21822	0.73
05/16/2024 11:00	0.7	1.4	0	0.44	0.21966	0.73
05/16/2024 12:00	0.7	1.4	0	0.44	0.22044	0.73
05/16/2024 13:00	0.6	1.4	0	0.44	0.22140	0.74
05/16/2024 14:00	0.6	1.4	0	0.44	0.22164	0.74
05/16/2024 15:00	0.6	1.3	0	0.44	0.22134	0.74
05/16/2024 16:00	0.6	1.4	0	0.45	0.22404	0.75
05/16/2024 17:00	0.6	1.4	0	0.52	0.26040	0.87
05/16/2024 18:00	0.6	1.4	0	0.51	0.25746	0.86
05/16/2024 19:00	0.6	1.4	0	0.54	0.27084	0.90
05/16/2024 20:00	0.7	1.4	0	0.46	0.22920	0.76
05/16/2024 21:00	0.6	1.4	0	0.53	0.26700	0.89
05/16/2024 22:00	0.6	1.4	0	0.53	0.26274	0.88
05/16/2024 23:00	0.6	1.4	0	0.53	0.26724	0.89
Average/Sum#:	0.7	1.4	0	0.47	0.23489	0.78
Minimum:	0.6	1.2	0	0.43	0.21654	0.72
Maximum:	0.7	1.5	1	0.54	0.27084	0.90
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/17/2024 00:00	0.6	1.4	0	0.54	0.26772	0.89
05/17/2024 01:00	0.7	1.4	0	0.49	0.24336	0.81
05/17/2024 02:00	0.6	1.4	0	0.52	0.25776	0.86
05/17/2024 03:00	0.8	1.3	0	0.44	0.22236	0.74
05/17/2024 04:00	0.7	1.3	0	0.45	0.22410	0.75
05/17/2024 05:00	0.7	1.4	1	0.44	0.21828	0.73
05/17/2024 06:00	0.7	1.4	1	0.44	0.21864	0.73
05/17/2024 07:00	0.8	1.4	1	0.44	0.21852	0.73
05/17/2024 08:00	0.8	1.4	0	0.44	0.21882	0.73
05/17/2024 09:00	0.7	1.4	0	0.44	0.21942	0.73
05/17/2024 10:00	0.7	1.4	0	0.44	0.22014	0.73
05/17/2024 11:00	0.7	1.4	0	0.44	0.22158	0.74
05/17/2024 12:00	0.7	1.4	0	0.44	0.22200	0.74
05/17/2024 13:00	0.6	1.3	0	0.44	0.22134	0.74
05/17/2024 14:00	0.6	1.4	0	0.44	0.22110	0.74
05/17/2024 15:00	0.6	1.4	0	0.44	0.22068	0.74
05/17/2024 16:00	0.6	1.4	0	0.44	0.22116	0.74
05/17/2024 17:00	0.6	1.4	0	0.44	0.21924	0.73
05/17/2024 18:00	0.6	1.4	0	0.44	0.21840	0.73
05/17/2024 19:00	0.7	1.4	0	0.44	0.21828	0.73
05/17/2024 20:00	0.7	1.4	0	0.44	0.21774	0.73
05/17/2024 21:00	0.7	1.4	0	0.44	0.21750	0.73
05/17/2024 22:00	0.7	1.4	0	0.43	0.21726	0.72
05/17/2024 23:00	0.7	1.4	0	0.44	0.21762	0.73
Average/Sum#:	0.7	1.4	0	0.45	0.22429	0.75
Minimum:	0.6	1.3	0	0.43	0.21726	0.72
Maximum:	0.8	1.4	1	0.54	0.26772	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/18/2024 00:00	0.7	1.4	0	0.44	0.21846	0.73
05/18/2024 01:00	0.7	1.4	1	0.44	0.21852	0.73
05/18/2024 02:00	0.7	1.4	1	0.44	0.21828	0.73
05/18/2024 03:00	0.9	1.4	1	0.44	0.21816	0.73
05/18/2024 04:00	0.8	1.4	1	0.44	0.21780	0.73
05/18/2024 05:00	0.7	1.3	1	0.44	0.21774	0.73
05/18/2024 06:00	0.7	1.4	1	0.44	0.21786	0.73
05/18/2024 07:00	0.0	0.0	0	0.44	0.21828	0.73
05/18/2024 08:00	0.0	0.0	0	0.44	0.21840	0.73
05/18/2024 09:00	0.7	1.4	0	0.44	0.21918	0.73
05/18/2024 10:00	0.7	1.4	0	0.44	0.22020	0.73
05/18/2024 11:00	0.6	1.4	0	0.44	0.21978	0.73
05/18/2024 12:00	0.6	1.4	0	0.44	0.21984	0.73
05/18/2024 13:00	0.6	1.4	0	0.44	0.21990	0.73
05/18/2024 14:00	0.6	1.4	0	0.44	0.22092	0.74
05/18/2024 15:00	0.6	1.4	0	0.44	0.21972	0.73
05/18/2024 16:00	0.6	1.4	0	0.44	0.21966	0.73
05/18/2024 17:00	0.6	1.4	0	0.44	0.21948	0.73
05/18/2024 18:00	0.6	1.4	0	0.44	0.21846	0.73
05/18/2024 19:00	0.7	1.4	0	0.43	0.21744	0.72
05/18/2024 20:00	0.7	1.4	0	0.43	0.21744	0.72
05/18/2024 21:00	0.7	1.4	1	0.44	0.21858	0.73
05/18/2024 22:00	0.7	1.4	1	0.44	0.21900	0.73
05/18/2024 23:00	0.7	1.4	1	0.44	0.21894	0.73
Average/Sum#:	0.7	1.4	0	0.44	0.21884	0.73
Minimum:	0.6	1.3	0	0.43	0.21744	0.72
Maximum:	0.9	1.4	1	0.44	0.22092	0.74
%SI	8.33	8.33	8.33	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/19/2024 00:00	0.7	1.4	1	0.44	0.21846	0.73
05/19/2024 01:00	0.7	1.4	1	0.44	0.21786	0.73
05/19/2024 02:00	0.7	1.6	1	0.44	0.21912	0.73
05/19/2024 03:00	0.8	1.4	1	0.44	0.21900	0.73
05/19/2024 04:00	0.8	1.4	1	0.44	0.21870	0.73
05/19/2024 05:00	0.7	1.4	1	0.44	0.21924	0.73
05/19/2024 06:00	0.7	1.4	1	0.44	0.21948	0.73
05/19/2024 07:00	0.7	1.4	1	0.44	0.22032	0.73
05/19/2024 08:00	0.7	1.4	1	0.44	0.21978	0.73
05/19/2024 09:00	0.7	1.4	0	0.44	0.21924	0.73
05/19/2024 10:00	0.7	1.4	1	0.44	0.21990	0.73
05/19/2024 11:00	0.7	1.4	0	0.44	0.22002	0.73
05/19/2024 12:00	0.6	1.4	0	0.44	0.21996	0.73
05/19/2024 13:00	0.6	1.4	0	0.44	0.22044	0.73
05/19/2024 14:00	0.6	1.4	0	0.44	0.22020	0.73
05/19/2024 15:00	0.6	1.3	0	0.44	0.21996	0.73
05/19/2024 16:00	0.6	1.3	0	0.44	0.21852	0.73
05/19/2024 17:00	0.6	1.4	0	0.43	0.21708	0.72
05/19/2024 18:00	0.6	1.4	0	0.43	0.21606	0.72
05/19/2024 19:00	0.7	1.4	0	0.43	0.21546	0.72
05/19/2024 20:00	0.7	1.4	0	0.43	0.21738	0.72
05/19/2024 21:00	0.7	1.4	0	0.43	0.21726	0.72
05/19/2024 22:00	0.7	1.4	1	0.43	0.21582	0.72
05/19/2024 23:00	0.7	1.4	1	0.43	0.21510	0.72
Average/Sum#:	0.7	1.4	1	0.44	0.21852	0.73
Minimum:	0.6	1.3	0	0.43	0.21510	0.72
Maximum:	0.8	1.6	1	0.44	0.22044	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/20/2024 00:00	0.8	1.4	1	0.43	0.21504	0.72
05/20/2024 01:00	0.8	1.4	1	0.43	0.21546	0.72
05/20/2024 02:00	0.8	1.3	0	0.43	0.21564	0.72
05/20/2024 03:00	0.9	1.5	1	0.43	0.21438	0.71
05/20/2024 04:00	0.8	1.5	1	0.43	0.21366	0.71
05/20/2024 05:00	0.9	1.5	1	0.43	0.21522	0.72
05/20/2024 06:00	0.9	1.4	1	0.43	0.21552	0.72
05/20/2024 07:00	0.8	1.4	1	0.43	0.21618	0.72
05/20/2024 08:00	0.7	1.3	0	0.43	0.21570	0.72
05/20/2024 09:00	0.7	1.4	0	0.43	0.21516	0.72
05/20/2024 10:00	0.6	1.4	1	0.43	0.21618	0.72
05/20/2024 11:00	0.6	1.4	0	0.44	0.21756	0.73
05/20/2024 12:00	0.6	1.4	1	0.44	0.21804	0.73
05/20/2024 13:00	0.6	1.4	0	0.44	0.21750	0.73
05/20/2024 14:00	0.6	1.4	0	0.43	0.21696	0.72
05/20/2024 15:00	0.6	1.4	1	0.43	0.21654	0.72
05/20/2024 16:00	0.6	1.4	0	0.43	0.21672	0.72
05/20/2024 17:00	0.6	1.4	0	0.44	0.22026	0.73
05/20/2024 18:00	0.7	1.4	0	0.49	0.24576	0.82
05/20/2024 19:00	0.7	1.4	0	0.51	0.25710	0.86
05/20/2024 20:00	0.7	1.3	0	0.49	0.24582	0.82
05/20/2024 21:00	0.7	1.3	0	0.48	0.23952	0.80
05/20/2024 22:00	0.7	1.4	0	0.49	0.24498	0.82
05/20/2024 23:00	0.8	1.3	0	0.43	0.21318	0.71
Average/Sum#:	0.7	1.4	0	0.44	0.22242	0.74
Minimum:	0.6	1.3	0	0.43	0.21318	0.71
Maximum:	0.9	1.5	1	0.51	0.25710	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/21/2024 00:00	0.9	1.4	0	0.42	0.21120	0.70
05/21/2024 01:00	1.0	1.4	0	0.42	0.21204	0.71
05/21/2024 02:00	0.8	1.4	0	0.43	0.21282	0.71
05/21/2024 03:00	0.9	1.4	0	0.43	0.21282	0.71
05/21/2024 04:00	0.8	1.4	0	0.43	0.21270	0.71
05/21/2024 05:00	0.8	1.4	1	0.43	0.21450	0.72
05/21/2024 06:00	1.2	1.4	1	0.57	0.28296	0.94
05/21/2024 07:00	0.4	1.5	1	0.73	0.36582	1.22
05/21/2024 08:00	0.3	1.5	1	0.73	0.36498	1.22
05/21/2024 09:00	0.3	1.5	1	0.73	0.36402	1.21
05/21/2024 10:00	0.3	1.5	1	0.73	0.36378	1.21
05/21/2024 11:00	0.3	1.5	1	0.73	0.36630	1.22
05/21/2024 12:00	0.1	1.5	1	0.75	0.37344	1.24
05/21/2024 13:00	0.1	1.5	1	0.75	0.37398	1.25
05/21/2024 14:00	0.2	1.5	1	0.75	0.37392	1.25
05/21/2024 15:00	0.1	1.5	1	0.75	0.37320	1.24
05/21/2024 16:00	0.1	1.5	1	0.75	0.37308	1.24
05/21/2024 17:00	0.1	1.5	1	0.75	0.37278	1.24
05/21/2024 18:00	0.1	1.5	1	0.74	0.37080	1.24
05/21/2024 19:00	0.2	1.5	1	0.74	0.36798	1.23
05/21/2024 20:00	1.0	1.5	1	0.64	0.31758	1.06
05/21/2024 21:00	1.0	1.4	0	0.56	0.27984	0.93
05/21/2024 22:00	0.8	1.4	0	0.44	0.21816	0.73
05/21/2024 23:00	0.8	1.4	0	0.43	0.21606	0.72
Average/Sum#:	0.5	1.5	1	0.62	0.30812	1.03
Minimum:	0.1	1.4	0	0.42	0.21120	0.70
Maximum:	1.2	1.5	1	0.75	0.37398	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/22/2024 00:00	0.7	1.4	0	0.43	0.21522	0.72
05/22/2024 01:00	0.7	1.4	0	0.44	0.21780	0.73
05/22/2024 02:00	0.7	1.4	0	0.43	0.21510	0.72
05/22/2024 03:00	0.8	1.4	0	0.46	0.23238	0.77
05/22/2024 04:00	0.9	1.5	1	0.50	0.24756	0.83
05/22/2024 05:00	0.3	1.5	1	0.75	0.37320	1.24
05/22/2024 06:00	0.3	1.5	1	0.75	0.37308	1.24
05/22/2024 07:00	0.3	1.5	1	0.75	0.37482	1.25
05/22/2024 08:00	0.3	1.5	1	0.75	0.37332	1.24
05/22/2024 09:00	0.2	1.5	1	0.75	0.37440	1.25
05/22/2024 10:00	0.2	1.5	1	0.75	0.37578	1.25
05/22/2024 11:00	0.2	1.5	1	0.75	0.37728	1.26
05/22/2024 12:00	0.2	1.5	1	0.76	0.37878	1.26
05/22/2024 13:00	0.2	1.5	1	0.76	0.37866	1.26
05/22/2024 14:00	0.1	1.5	1	0.76	0.37800	1.26
05/22/2024 15:00	0.1	1.5	1	0.75	0.37476	1.25
05/22/2024 16:00	1.1	1.4	0	0.61	0.30432	1.01
05/22/2024 17:00	0.6	1.5	1	0.57	0.28470	0.95
05/22/2024 18:00	0.2	1.5	1	0.75	0.37446	1.25
05/22/2024 19:00	0.2	1.5	1	0.74	0.37176	1.24
05/22/2024 20:00	0.2	1.5	1	0.74	0.37026	1.23
05/22/2024 21:00	0.2	1.5	1	0.74	0.36882	1.23
05/22/2024 22:00	1.1	1.4	1	0.61	0.30744	1.02
05/22/2024 23:00	0.8	1.4	0	0.43	0.21456	0.72
Average/Sum#:	0.4	1.5	1	0.66	0.32735	1.09
Minimum:	0.1	1.4	0	0.43	0.21456	0.72
Maximum:	1.1	1.5	1	0.76	0.37878	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/23/2024 00:00	0.7	1.4	1	0.43	0.21522	0.72
05/23/2024 01:00	0.7	1.4	1	0.43	0.21480	0.72
05/23/2024 02:00	0.8	1.4	0	0.43	0.21456	0.72
05/23/2024 03:00	0.8	1.3	0	0.43	0.21444	0.71
05/23/2024 04:00	0.7	1.4	0	0.43	0.21396	0.71
05/23/2024 05:00	0.7	1.5	1	0.43	0.21690	0.72
05/23/2024 06:00	0.8	1.3	0	0.43	0.21504	0.72
05/23/2024 07:00	0.9	1.4	0	0.49	0.24564	0.82
05/23/2024 08:00	0.2	1.5	1	0.75	0.37434	1.25
05/23/2024 09:00	0.1	1.5	2	0.75	0.37542	1.25
05/23/2024 10:00	0.1	1.5	2	0.75	0.37734	1.26
05/23/2024 11:00	0.6	1.4	1	0.64	0.32124	1.07
05/23/2024 12:00	0.8	1.2	1	0.33	0.16662	0.56
05/23/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.4	1	0.52	0.25889	0.86
Minimum:	0.1	1.2	0	0.33	0.16662	0.56
Maximum:	0.9	1.5	2	0.75	0.37734	1.26
%SI	45.83	45.83	45.83	45.83	45.83	45.83

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/24/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/25/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/26/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/27/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2024 16:00	0.0	0.0	0	0.05	0.02730	0.09
05/27/2024 17:00	0.0	0.0	0	0.37	0.18714	0.62
05/27/2024 18:00	0.6	1.5	1	0.65	0.32388	1.08
05/27/2024 19:00	0.5	1.5	1	0.73	0.36372	1.21
05/27/2024 20:00	0.9	1.5	1	0.64	0.32214	1.07
05/27/2024 21:00	1.3	1.4	0	0.62	0.31164	1.04
05/27/2024 22:00	0.8	1.3	0	0.47	0.23466	0.78
05/27/2024 23:00	0.7	1.3	0	0.45	0.22272	0.74
Average/Sum#:	0.6	1.1	1	0.50	0.24915	0.83
Minimum:	0.0	0.0	0	0.05	0.02730	0.09
Maximum:	1.3	1.5	1	0.73	0.36372	1.21
%SI	66.67	66.67	75.00	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/28/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/29/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/30/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/31/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/01/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/02/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 14:00	0.0	0.0	0	0.38	0.18894	0.63
06/02/2024 15:00	0.6	1.5	1	0.67	0.33306	1.11
06/02/2024 16:00	0.6	1.5	1	0.72	0.35934	1.20
06/02/2024 17:00	1.0	1.3	0	0.52	0.26172	0.87
06/02/2024 18:00	0.6	1.3	0	0.43	0.21492	0.72
06/02/2024 19:00	0.6	1.4	0	0.36	0.17862	0.60
06/02/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.2	0	0.51	0.25610	0.86
Minimum:	0.0	0.0	0	0.36	0.17862	0.60
Maximum:	1.0	1.5	1	0.72	0.35934	1.20
%SI	75.00	75.00	79.17	75.00	75.00	75.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/03/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/04/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/05/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 11:00	0.0	0.0	0	0.12	0.05760	0.19
06/05/2024 12:00	1.0	1.5	1	0.46	0.22824	0.76
06/05/2024 13:00	0.8	1.4	0	0.63	0.31326	1.04
06/05/2024 14:00	0.9	0.9	1	0.52	0.25986	0.87
06/05/2024 15:00	0.6	0.6	1	0.61	0.30336	1.01
06/05/2024 16:00	0.7	0.5	2	0.45	0.22470	0.75
06/05/2024 17:00	0.8	0.4	1	0.50	0.25164	0.84
06/05/2024 18:00	0.7	0.4	1	0.52	0.26184	0.87
06/05/2024 19:00	0.6	0.4	1	0.52	0.26244	0.87
06/05/2024 20:00	0.6	0.4	1	0.50	0.24816	0.83
06/05/2024 21:00	0.7	0.4	1	0.41	0.20478	0.68
06/05/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	0.6	1	0.48	0.23781	0.79
Minimum:	0.0	0.0	0	0.12	0.05760	0.19
Maximum:	1.0	1.5	2	0.63	0.31326	1.04
%SI	54.17	54.17	58.33	54.17	54.17	54.17

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/06/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/07/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/08/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/09/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/10/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/11/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/11/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/12/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/12/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/13/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 13:00	0.0	0.0	0	0.07	0.03672	0.12
06/13/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 15:00	0.0	0.0	0	0.25	0.12630	0.42
06/13/2024 16:00	0.8	1.2	1	0.44	0.22062	0.74
06/13/2024 17:00	0.7	1.2	0	0.43	0.21720	0.72
06/13/2024 18:00	1.0	1.3	0	0.53	0.26448	0.88
06/13/2024 19:00	1.1	1.4	1	0.59	0.29646	0.99
06/13/2024 20:00	1.0	1.4	1	0.52	0.26094	0.87
06/13/2024 21:00	0.8	1.4	1	0.38	0.19092	0.64
06/13/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/13/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.0	1	0.40	0.20171	0.67
Minimum:	0.0	0.0	0	0.07	0.03672	0.12
Maximum:	1.1	1.4	1	0.59	0.29646	0.99
%SI	66.67	66.67	75.00	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/14/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/14/2024 16:00	0.0	0.0	0	0.27	0.13524	0.45
06/14/2024 17:00	0.6	1.3	1	0.50	0.24966	0.83
06/14/2024 18:00	0.7	1.4	1	0.44	0.22014	0.73
06/14/2024 19:00	0.6	1.3	0	0.52	0.25926	0.86
06/14/2024 20:00	1.4	1.5	1	0.56	0.27966	0.93
06/14/2024 21:00	0.8	1.4	1	0.45	0.22458	0.75
06/14/2024 22:00	0.7	1.4	1	0.43	0.21510	0.72
06/14/2024 23:00	0.7	1.4	1	0.43	0.21492	0.72
Average/Sum#:	0.7	1.2	1	0.45	0.22482	0.75
Minimum:	0.0	0.0	0	0.27	0.13524	0.45
Maximum:	1.4	1.5	1	0.56	0.27966	0.93
%SI	66.67	66.67	70.83	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/15/2024 00:00	0.7	1.4	1	0.43	0.21486	0.72
06/15/2024 01:00	0.7	1.4	1	0.43	0.21486	0.72
06/15/2024 02:00	0.8	1.5	1	0.38	0.19038	0.63
06/15/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/15/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.4	1	0.41	0.20670	0.69
Minimum:	0.7	1.4	1	0.38	0.19038	0.63
Maximum:	0.8	1.5	1	0.43	0.21486	0.72
%SI	87.50	87.50	87.50	87.50	87.50	87.50

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/16/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/16/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/17/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/17/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/18/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/18/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/19/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2024 08:00	0.0	0.0	0	0.38	0.19200	0.64
06/19/2024 09:00	0.7	1.4	1	0.48	0.24102	0.80
06/19/2024 10:00	0.9	1.4	1	0.56	0.27906	0.93
06/19/2024 11:00	0.7	1.4	1	0.44	0.22098	0.74
06/19/2024 12:00	0.7	1.4	1	0.44	0.22134	0.74
06/19/2024 13:00	0.6	1.4	1	0.44	0.22128	0.74
06/19/2024 14:00	0.6	1.4	1	0.44	0.22104	0.74
06/19/2024 15:00	0.6	1.4	1	0.44	0.22086	0.74
06/19/2024 16:00	0.6	1.4	1	0.44	0.22110	0.74
06/19/2024 17:00	0.9	1.4	1	0.52	0.25884	0.86
06/19/2024 18:00	0.7	1.5	1	0.64	0.31878	1.06
06/19/2024 19:00	0.8	1.4	1	0.63	0.31518	1.05
06/19/2024 20:00	0.6	1.5	1	0.63	0.31602	1.05
06/19/2024 21:00	0.6	1.5	1	0.64	0.31758	1.06
06/19/2024 22:00	0.7	1.5	1	0.63	0.31416	1.05
06/19/2024 23:00	0.8	1.4	1	0.63	0.31392	1.05
Average/Sum#:	0.7	1.3	1	0.52	0.26207	0.87
Minimum:	0.0	0.0	1	0.38	0.19200	0.64
Maximum:	0.9	1.5	1	0.64	0.31878	1.06
%SI	33.33	33.33	37.50	33.33	33.33	33.33

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/20/2024 00:00	0.9	1.5	1	0.63	0.31332	1.04
06/20/2024 01:00	0.9	1.5	1	0.63	0.31254	1.04
06/20/2024 02:00	1.0	1.4	1	0.62	0.31230	1.04
06/20/2024 03:00	1.1	1.4	1	0.62	0.31188	1.04
06/20/2024 04:00	1.0	1.4	1	0.62	0.31182	1.04
06/20/2024 05:00	1.0	1.5	1	0.62	0.31170	1.04
06/20/2024 06:00	0.9	1.4	1	0.51	0.25338	0.84
06/20/2024 07:00	0.7	1.4	1	0.44	0.21948	0.73
06/20/2024 08:00	0.7	1.4	1	0.44	0.22014	0.73
06/20/2024 09:00	0.7	1.4	1	0.44	0.22056	0.74
06/20/2024 10:00	0.7	1.4	1	0.44	0.21936	0.73
06/20/2024 11:00	0.7	1.4	1	0.44	0.21864	0.73
06/20/2024 12:00	0.7	1.4	1	0.44	0.21912	0.73
06/20/2024 13:00	0.7	1.3	0	0.44	0.21912	0.73
06/20/2024 14:00	0.7	1.4	0	0.44	0.21888	0.73
06/20/2024 15:00	0.7	1.4	0	0.44	0.21870	0.73
06/20/2024 16:00	0.7	1.3	0	0.44	0.21870	0.73
06/20/2024 17:00	0.8	1.4	1	0.56	0.28206	0.94
06/20/2024 18:00	0.7	1.4	1	0.63	0.31740	1.06
06/20/2024 19:00	0.7	1.4	1	0.63	0.31548	1.05
06/20/2024 20:00	0.7	1.4	1	0.63	0.31500	1.05
06/20/2024 21:00	0.8	1.4	1	0.63	0.31464	1.05
06/20/2024 22:00	0.9	1.4	1	0.62	0.31236	1.04
06/20/2024 23:00	1.0	1.4	1	0.62	0.31020	1.03
Average/Sum#:	0.8	1.4	1	0.54	0.27028	0.90
Minimum:	0.7	1.3	0	0.44	0.21864	0.73
Maximum:	1.1	1.5	1	0.63	0.31740	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/21/2024 00:00	1.0	1.4	1	0.62	0.30882	1.03
06/21/2024 01:00	1.1	1.5	1	0.62	0.30816	1.03
06/21/2024 02:00	1.1	1.5	1	0.62	0.31074	1.04
06/21/2024 03:00	1.1	1.5	1	0.62	0.31158	1.04
06/21/2024 04:00	1.1	1.4	1	0.62	0.31182	1.04
06/21/2024 05:00	1.0	1.5	1	0.63	0.31434	1.05
06/21/2024 06:00	1.0	1.4	1	0.55	0.27642	0.92
06/21/2024 07:00	0.8	1.4	1	0.44	0.21774	0.73
06/21/2024 08:00	0.7	1.4	1	0.44	0.21852	0.73
06/21/2024 09:00	0.7	1.4	1	0.44	0.22128	0.74
06/21/2024 10:00	0.7	1.3	1	0.48	0.23940	0.80
06/21/2024 11:00	0.7	1.4	1	0.43	0.21474	0.72
06/21/2024 12:00	0.7	1.3	0	0.43	0.21480	0.72
06/21/2024 13:00	0.7	1.3	0	0.43	0.21468	0.72
06/21/2024 14:00	0.7	1.2	0	0.43	0.21456	0.72
06/21/2024 15:00	0.7	1.3	0	0.43	0.21420	0.71
06/21/2024 16:00	0.7	1.2	0	0.44	0.21888	0.73
06/21/2024 17:00	0.7	1.3	0	0.48	0.23952	0.80
06/21/2024 18:00	0.7	1.4	0	0.53	0.26490	0.88
06/21/2024 19:00	0.7	1.3	0	0.53	0.26418	0.88
06/21/2024 20:00	0.7	1.3	0	0.53	0.26430	0.88
06/21/2024 21:00	0.7	1.4	0	0.53	0.26472	0.88
06/21/2024 22:00	0.7	1.3	0	0.53	0.26640	0.89
06/21/2024 23:00	0.7	1.3	1	0.51	0.25650	0.86
Average/Sum#:	0.8	1.4	1	0.51	0.25630	0.86
Minimum:	0.7	1.2	0	0.43	0.21420	0.71
Maximum:	1.1	1.5	1	0.63	0.31434	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/22/2024 00:00	0.7	1.3	1	0.44	0.21888	0.73
06/22/2024 01:00	0.7	1.4	1	0.44	0.21816	0.73
06/22/2024 02:00	0.7	1.5	1	0.44	0.21882	0.73
06/22/2024 03:00	0.8	1.4	1	0.43	0.21744	0.72
06/22/2024 04:00	0.8	1.4	1	0.43	0.21672	0.72
06/22/2024 05:00	0.9	1.4	1	0.44	0.21852	0.73
06/22/2024 06:00	0.9	1.4	1	0.44	0.21876	0.73
06/22/2024 07:00	0.8	1.4	1	0.44	0.22050	0.74
06/22/2024 08:00	0.7	1.3	1	0.44	0.21882	0.73
06/22/2024 09:00	0.7	1.2	0	0.44	0.21828	0.73
06/22/2024 10:00	0.7	1.3	0	0.44	0.21768	0.73
06/22/2024 11:00	0.7	1.3	0	0.44	0.21750	0.73
06/22/2024 12:00	0.7	1.4	0	0.43	0.21744	0.72
06/22/2024 13:00	0.7	1.3	0	0.44	0.21774	0.73
06/22/2024 14:00	0.7	1.4	0	0.44	0.21786	0.73
06/22/2024 15:00	0.7	1.4	1	0.44	0.21936	0.73
06/22/2024 16:00	0.7	1.3	0	0.48	0.24156	0.81
06/22/2024 17:00	0.7	1.3	0	0.48	0.24042	0.80
06/22/2024 18:00	0.7	1.3	0	0.50	0.24960	0.83
06/22/2024 19:00	0.7	1.3	0	0.52	0.26076	0.87
06/22/2024 20:00	0.6	1.3	0	0.52	0.25956	0.87
06/22/2024 21:00	0.7	1.4	1	0.44	0.21852	0.73
06/22/2024 22:00	0.8	1.4	1	0.44	0.21960	0.73
06/22/2024 23:00	0.7	1.4	1	0.44	0.21870	0.73
Average/Sum#:	0.7	1.4	1	0.45	0.22505	0.75
Minimum:	0.6	1.2	0	0.43	0.21672	0.72
Maximum:	0.9	1.5	1	0.52	0.26076	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/23/2024 00:00	0.7	1.4	1	0.44	0.21792	0.73
06/23/2024 01:00	0.7	1.4	1	0.44	0.21804	0.73
06/23/2024 02:00	0.7	1.2	0	0.44	0.21930	0.73
06/23/2024 03:00	0.8	1.4	1	0.44	0.21924	0.73
06/23/2024 04:00	0.7	1.4	1	0.44	0.21840	0.73
06/23/2024 05:00	0.7	1.4	1	0.44	0.21972	0.73
06/23/2024 06:00	0.7	1.4	1	0.44	0.22014	0.73
06/23/2024 07:00	0.7	1.3	0	0.44	0.21960	0.73
06/23/2024 08:00	0.7	1.3	0	0.44	0.22092	0.74
06/23/2024 09:00	0.7	1.3	0	0.44	0.21942	0.73
06/23/2024 10:00	0.7	1.3	0	0.44	0.21798	0.73
06/23/2024 11:00	0.7	1.3	0	0.44	0.21930	0.73
06/23/2024 12:00	0.7	1.3	0	0.44	0.21966	0.73
06/23/2024 13:00	0.7	1.3	0	0.48	0.23754	0.79
06/23/2024 14:00	0.7	1.3	0	0.51	0.25536	0.85
06/23/2024 15:00	0.7	1.4	0	0.53	0.26646	0.89
06/23/2024 16:00	0.7	1.4	0	0.53	0.26646	0.89
06/23/2024 17:00	0.7	1.3	0	0.53	0.26532	0.88
06/23/2024 18:00	0.6	1.4	0	0.49	0.24624	0.82
06/23/2024 19:00	0.7	1.3	0	0.53	0.26388	0.88
06/23/2024 20:00	0.7	1.4	0	0.53	0.26424	0.88
06/23/2024 21:00	0.7	1.3	0	0.53	0.26436	0.88
06/23/2024 22:00	0.7	1.3	0	0.50	0.24756	0.83
06/23/2024 23:00	0.7	1.4	1	0.46	0.23214	0.77
Average/Sum#:	0.7	1.3	0	0.47	0.23580	0.79
Minimum:	0.6	1.2	0	0.44	0.21792	0.73
Maximum:	0.8	1.4	1	0.53	0.26646	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/24/2024 00:00	0.7	1.4	1	0.43	0.21354	0.71
06/24/2024 01:00	0.7	1.4	1	0.43	0.21330	0.71
06/24/2024 02:00	0.7	1.3	1	0.44	0.21756	0.73
06/24/2024 03:00	0.8	1.4	1	0.43	0.21432	0.71
06/24/2024 04:00	0.7	1.4	0	0.49	0.24402	0.81
06/24/2024 05:00	0.7	1.3	1	0.50	0.24834	0.83
06/24/2024 06:00	0.8	1.4	1	0.38	0.19092	0.64
06/24/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 14:00	0.0	0.0	0	0.07	0.03396	0.11
06/24/2024 15:00	0.0	0.0	0	0.08	0.03756	0.13
06/24/2024 16:00	0.0	0.0	0	0.08	0.04038	0.13
06/24/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2024 19:00	0.0	0.0	0	0.30	0.15228	0.51
06/24/2024 20:00	0.7	1.4	1	0.50	0.24762	0.83
06/24/2024 21:00	0.7	1.4	0	0.54	0.26790	0.89
06/24/2024 22:00	0.7	1.4	0	0.53	0.26730	0.89
06/24/2024 23:00	0.7	1.4	0	0.54	0.26814	0.89
Average/Sum#:	0.5	1.0	1	0.38	0.19048	0.63
Minimum:	0.0	0.0	0	0.07	0.03396	0.11
Maximum:	0.8	1.4	1	0.54	0.26814	0.89
%SI	37.50	37.50	54.17	37.50	37.50	37.50

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/25/2024 00:00	0.6	1.4	0	0.54	0.26754	0.89
06/25/2024 01:00	0.6	1.4	0	0.54	0.26790	0.89
06/25/2024 02:00	0.6	1.3	0	0.53	0.26658	0.89
06/25/2024 03:00	0.7	1.3	1	0.53	0.26328	0.88
06/25/2024 04:00	0.6	1.4	0	0.53	0.26364	0.88
06/25/2024 05:00	0.6	1.4	1	0.52	0.26028	0.87
06/25/2024 06:00	0.7	1.4	1	0.47	0.23550	0.79
06/25/2024 07:00	0.7	1.4	1	0.43	0.21552	0.72
06/25/2024 08:00	0.6	1.3	0	0.51	0.25272	0.84
06/25/2024 09:00	0.6	1.4	0	0.53	0.26628	0.89
06/25/2024 10:00	0.6	1.4	0	0.54	0.27072	0.90
06/25/2024 11:00	0.6	1.4	0	0.54	0.27084	0.90
06/25/2024 12:00	0.7	1.3	0	0.54	0.26946	0.90
06/25/2024 13:00	0.7	1.4	0	0.54	0.26820	0.89
06/25/2024 14:00	0.6	1.4	0	0.54	0.26826	0.89
06/25/2024 15:00	0.7	1.3	0	0.50	0.25026	0.83
06/25/2024 16:00	0.7	1.4	0	0.53	0.26268	0.88
06/25/2024 17:00	0.7	1.3	0	0.54	0.27006	0.90
06/25/2024 18:00	0.3	1.5	2	0.76	0.37884	1.26
06/25/2024 19:00	0.2	1.5	2	0.78	0.38886	1.30
06/25/2024 20:00	0.2	1.5	1	0.74	0.37086	1.24
06/25/2024 21:00	0.2	1.5	1	0.72	0.35790	1.19
06/25/2024 22:00	0.7	1.4	1	0.61	0.30318	1.01
06/25/2024 23:00	0.7	1.3	1	0.47	0.23688	0.79
Average/Sum#:	0.6	1.4	1	0.56	0.28026	0.93
Minimum:	0.2	1.3	0	0.43	0.21552	0.72
Maximum:	0.7	1.5	2	0.78	0.38886	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/26/2024 00:00	0.7	1.3	1	0.46	0.22890	0.76
06/26/2024 01:00	0.6	1.3	0	0.49	0.24426	0.81
06/26/2024 02:00	0.6	1.1	0	0.47	0.23316	0.78
06/26/2024 03:00	0.7	1.5	1	0.52	0.25770	0.86
06/26/2024 04:00	0.7	1.4	1	0.54	0.27162	0.91
06/26/2024 05:00	0.7	1.4	1	0.47	0.23442	0.78
06/26/2024 06:00	0.7	1.4	1	0.43	0.21498	0.72
06/26/2024 07:00	0.7	1.4	1	0.43	0.21552	0.72
06/26/2024 08:00	0.7	1.4	1	0.43	0.21522	0.72
06/26/2024 09:00	0.7	1.4	1	0.43	0.21474	0.72
06/26/2024 10:00	0.7	1.4	1	0.43	0.21462	0.72
06/26/2024 11:00	0.7	1.3	0	0.43	0.21558	0.72
06/26/2024 12:00	0.7	1.3	0	0.43	0.21564	0.72
06/26/2024 13:00	0.7	1.3	0	0.43	0.21558	0.72
06/26/2024 14:00	0.7	1.3	0	0.43	0.21552	0.72
06/26/2024 15:00	0.7	1.3	0	0.43	0.21522	0.72
06/26/2024 16:00	0.7	1.2	0	0.43	0.21546	0.72
06/26/2024 17:00	0.6	1.3	0	0.44	0.22044	0.73
06/26/2024 18:00	0.6	1.4	1	0.48	0.23820	0.79
06/26/2024 19:00	0.7	1.4	1	0.44	0.21768	0.73
06/26/2024 20:00	0.7	1.4	1	0.43	0.21450	0.72
06/26/2024 21:00	0.7	1.4	1	0.43	0.21432	0.71
06/26/2024 22:00	0.7	1.4	1	0.43	0.21450	0.72
06/26/2024 23:00	0.7	1.4	1	0.43	0.21444	0.71
Average/Sum#:	0.7	1.4	1	0.45	0.22384	0.75
Minimum:	0.6	1.1	0	0.43	0.21432	0.71
Maximum:	0.7	1.5	1	0.54	0.27162	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/27/2024 00:00	0.7	1.4	1	0.43	0.21444	0.71
06/27/2024 01:00	0.7	1.4	1	0.43	0.21444	0.71
06/27/2024 02:00	0.7	1.5	1	0.43	0.21462	0.72
06/27/2024 03:00	0.8	1.4	1	0.43	0.21504	0.72
06/27/2024 04:00	0.8	1.4	1	0.43	0.21492	0.72
06/27/2024 05:00	0.8	1.4	1	0.43	0.21510	0.72
06/27/2024 06:00	0.8	1.4	1	0.43	0.21516	0.72
06/27/2024 07:00	0.8	1.4	1	0.43	0.21564	0.72
06/27/2024 08:00	0.8	1.4	1	0.43	0.21528	0.72
06/27/2024 09:00	0.7	1.4	1	0.43	0.21522	0.72
06/27/2024 10:00	0.7	1.4	1	0.43	0.21510	0.72
06/27/2024 11:00	0.7	1.4	1	0.43	0.21606	0.72
06/27/2024 12:00	0.6	1.4	1	0.43	0.21624	0.72
06/27/2024 13:00	0.7	1.3	1	0.43	0.21630	0.72
06/27/2024 14:00	0.6	1.4	1	0.43	0.21594	0.72
06/27/2024 15:00	0.7	1.3	1	0.43	0.21540	0.72
06/27/2024 16:00	0.7	1.3	0	0.43	0.21534	0.72
06/27/2024 17:00	0.7	1.3	0	0.44	0.21768	0.73
06/27/2024 18:00	0.7	1.4	0	0.48	0.24030	0.80
06/27/2024 19:00	0.7	1.4	1	0.43	0.21684	0.72
06/27/2024 20:00	0.7	1.4	1	0.43	0.21450	0.72
06/27/2024 21:00	0.7	1.4	1	0.43	0.21444	0.71
06/27/2024 22:00	0.7	1.4	1	0.43	0.21396	0.71
06/27/2024 23:00	0.7	1.4	1	0.43	0.21396	0.71
Average/Sum#:	0.7	1.4	1	0.43	0.21633	0.72
Minimum:	0.6	1.3	0	0.43	0.21396	0.71
Maximum:	0.8	1.5	1	0.48	0.24030	0.80
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/28/2024 00:00	0.8	1.4	1	0.43	0.21414	0.71
06/28/2024 01:00	0.8	1.4	1	0.43	0.21366	0.71
06/28/2024 02:00	0.8	1.4	1	0.43	0.21384	0.71
06/28/2024 03:00	0.9	1.4	1	0.43	0.21378	0.71
06/28/2024 04:00	0.8	1.4	1	0.43	0.21420	0.71
06/28/2024 05:00	0.8	1.4	1	0.43	0.21462	0.72
06/28/2024 06:00	0.8	1.4	1	0.43	0.21504	0.72
06/28/2024 07:00	0.8	1.4	1	0.43	0.21522	0.72
06/28/2024 08:00	0.8	1.4	1	0.43	0.21450	0.72
06/28/2024 09:00	0.7	1.4	1	0.43	0.21450	0.72
06/28/2024 10:00	0.7	1.4	1	0.43	0.21444	0.71
06/28/2024 11:00	0.7	1.4	1	0.43	0.21540	0.72
06/28/2024 12:00	0.7	1.3	0	0.43	0.21552	0.72
06/28/2024 13:00	0.7	1.3	0	0.43	0.21504	0.72
06/28/2024 14:00	0.7	1.3	0	0.43	0.21462	0.72
06/28/2024 15:00	0.7	1.3	0	0.43	0.21414	0.71
06/28/2024 16:00	0.7	1.3	0	0.43	0.21432	0.71
06/28/2024 17:00	0.7	1.3	0	0.44	0.21780	0.73
06/28/2024 18:00	0.7	1.4	1	0.43	0.21552	0.72
06/28/2024 19:00	0.7	1.4	1	0.43	0.21426	0.71
06/28/2024 20:00	0.7	1.4	1	0.43	0.21276	0.71
06/28/2024 21:00	0.7	1.4	1	0.42	0.21198	0.71
06/28/2024 22:00	0.8	1.4	1	0.42	0.21174	0.71
06/28/2024 23:00	0.8	1.4	1	0.42	0.21180	0.71
Average/Sum#:	0.8	1.4	1	0.43	0.21429	0.72
Minimum:	0.7	1.3	0	0.42	0.21174	0.71
Maximum:	0.9	1.4	1	0.44	0.21780	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/29/2024 00:00	0.8	1.4	1	0.42	0.21210	0.71
06/29/2024 01:00	0.8	1.4	1	0.42	0.21174	0.71
06/29/2024 02:00	0.8	1.3	1	0.42	0.21162	0.71
06/29/2024 03:00	0.8	1.4	1	0.42	0.21198	0.71
06/29/2024 04:00	0.8	1.4	1	0.42	0.21240	0.71
06/29/2024 05:00	0.8	1.4	1	0.43	0.21288	0.71
06/29/2024 06:00	0.7	1.4	1	0.43	0.21294	0.71
06/29/2024 07:00	0.8	1.3	1	0.43	0.21312	0.71
06/29/2024 08:00	0.7	1.4	1	0.43	0.21306	0.71
06/29/2024 09:00	0.7	1.4	1	0.43	0.21288	0.71
06/29/2024 10:00	0.7	1.4	1	0.43	0.21300	0.71
06/29/2024 11:00	0.7	1.3	1	0.43	0.21372	0.71
06/29/2024 12:00	0.7	1.3	0	0.43	0.21378	0.71
06/29/2024 13:00	0.7	1.3	0	0.43	0.21378	0.71
06/29/2024 14:00	0.7	1.2	0	0.43	0.21372	0.71
06/29/2024 15:00	0.7	1.3	0	0.43	0.21306	0.71
06/29/2024 16:00	0.7	1.3	0	0.43	0.21270	0.71
06/29/2024 17:00	0.7	1.3	0	0.44	0.21888	0.73
06/29/2024 18:00	0.7	1.3	0	0.45	0.22356	0.75
06/29/2024 19:00	0.7	1.3	0	0.42	0.21198	0.71
06/29/2024 20:00	0.7	1.4	1	0.42	0.21180	0.71
06/29/2024 21:00	0.8	1.4	1	0.42	0.21144	0.70
06/29/2024 22:00	0.8	1.4	1	0.42	0.21132	0.70
06/29/2024 23:00	0.8	1.4	1	0.42	0.21150	0.71
Average/Sum#:	0.7	1.4	1	0.43	0.21329	0.71
Minimum:	0.7	1.2	0	0.42	0.21132	0.70
Maximum:	0.8	1.4	1	0.45	0.22356	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/30/2024 00:00	0.8	1.4	1	0.42	0.21150	0.71
06/30/2024 01:00	0.8	1.4	1	0.42	0.21198	0.71
06/30/2024 02:00	1.0	1.4	1	0.42	0.21162	0.71
06/30/2024 03:00	1.0	1.4	1	0.42	0.21144	0.70
06/30/2024 04:00	0.9	1.4	1	0.42	0.21186	0.71
06/30/2024 05:00	0.9	1.4	1	0.42	0.21216	0.71
06/30/2024 06:00	0.8	1.3	1	0.42	0.21240	0.71
06/30/2024 07:00	0.8	1.4	1	0.43	0.21258	0.71
06/30/2024 08:00	0.8	1.4	1	0.42	0.21228	0.71
06/30/2024 09:00	0.8	1.4	1	0.42	0.21198	0.71
06/30/2024 10:00	0.7	1.3	1	0.42	0.21198	0.71
06/30/2024 11:00	0.7	1.3	0	0.43	0.21324	0.71
06/30/2024 12:00	0.7	1.2	0	0.43	0.21342	0.71
06/30/2024 13:00	0.7	1.3	0	0.43	0.21330	0.71
06/30/2024 14:00	0.7	1.4	0	0.43	0.21312	0.71
06/30/2024 15:00	0.7	1.3	0	0.43	0.21276	0.71
06/30/2024 16:00	0.7	1.3	0	0.43	0.21276	0.71
06/30/2024 17:00	0.7	1.3	0	0.43	0.21258	0.71
06/30/2024 18:00	0.7	1.2	0	0.42	0.21210	0.71
06/30/2024 19:00	0.7	1.3	0	0.42	0.21174	0.71
06/30/2024 20:00	0.7	1.4	1	0.42	0.21198	0.71
06/30/2024 21:00	0.7	1.4	1	0.42	0.21174	0.71
06/30/2024 22:00	0.8	1.4	1	0.42	0.21126	0.70
06/30/2024 23:00	0.7	1.4	1	0.42	0.21174	0.71
Average/Sum#:	0.8	1.4	1	0.42	0.21223	0.71
Minimum:	0.7	1.2	0	0.42	0.21126	0.70
Maximum:	1.0	1.4	1	0.43	0.21342	0.71
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/01/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/02/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 06:00	0.0	0.0	0	0.20	0.09906	0.33
04/02/2024 07:00	1.0	0.0	0	0.51	0.25314	0.84
04/02/2024 08:00	0.9	0.0	0	0.61	0.30336	1.01
04/02/2024 09:00	0.8	0.0	0	0.60	0.30030	1.00
04/02/2024 10:00	184.9	0.0	0	0.39	0.19614	0.65
04/02/2024 11:00	218.5	0.0	0	0.38	0.18882	0.63
04/02/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	67.7	0.0	0	0.45	0.22347	0.74
Minimum:	0.0	0.0	0	0.20	0.09906	0.33
Maximum:	218.5	0.0	0	0.61	0.30336	1.01
%SI	75.00	100.00	79.17	75.00	75.00	75.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/03/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/04/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2024 06:00	0.0	0.7	0	0.00	0.00000	0.00
04/04/2024 07:00	0.0	0.9	0	0.00	0.00000	0.00
04/04/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
04/04/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/04/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	16.67	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/05/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/05/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/05/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/06/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/06/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/06/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/06/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/06/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/06/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/07/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
04/07/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/07/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/07/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/07/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/07/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/07/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/08/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
04/08/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 04:00	0.0	1.6	0	0.00	0.00000	0.00
04/08/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/08/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/08/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/09/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/09/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 16:00	0.0	1.5	0	0.33	0.16494	0.55
04/09/2024 17:00	0.9	1.5	0	0.47	0.23256	0.78
04/09/2024 18:00	0.9	1.5	-1	0.46	0.23166	0.77
04/09/2024 19:00	0.9	1.5	-1	0.46	0.23196	0.77
04/09/2024 20:00	0.9	1.5	-1	0.46	0.23208	0.77
04/09/2024 21:00	0.9	1.4	-1	0.42	0.20916	0.70
04/09/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/09/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.8	1.5	-1	0.43	0.21706	0.72
Minimum:	0.0	1.4	-1	0.33	0.16494	0.55
Maximum:	0.9	1.5	0	0.47	0.23256	0.78
%SI	75.00	0.00	79.17	75.00	75.00	75.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/10/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/10/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/10/2024 16:00	0.0	1.4	0	0.18	0.08898	0.30
04/10/2024 17:00	0.8	1.4	0	0.47	0.23250	0.78
04/10/2024 18:00	0.8	1.5	0	0.46	0.23172	0.77
04/10/2024 19:00	0.9	1.5	-1	0.46	0.23178	0.77
04/10/2024 20:00	0.9	1.5	-1	0.46	0.23214	0.77
04/10/2024 21:00	0.9	1.5	-1	0.46	0.23226	0.77
04/10/2024 22:00	0.9	1.5	-1	0.47	0.23250	0.78
04/10/2024 23:00	0.9	1.5	-1	0.46	0.23244	0.77
Average/Sum#:	0.8	1.5	-1	0.43	0.21429	0.71
Minimum:	0.0	1.4	-1	0.18	0.08898	0.30
Maximum:	0.9	1.5	0	0.47	0.23250	0.78
%SI	66.67	0.00	70.83	66.67	66.67	66.67

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/11/2024 00:00	0.9	1.5	-1	0.42	0.21168	0.71
04/11/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/11/2024 02:00	0.0	1.8	0	0.00	0.00000	0.00
04/11/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/11/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/11/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/11/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.9	1.5	-1	0.42	0.21168	0.71
Minimum:	0.9	1.4	-1	0.42	0.21168	0.71
Maximum:	0.9	1.8	-1	0.42	0.21168	0.71
%SI	95.83	0.00	95.83	95.83	95.83	95.83

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/12/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/12/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/13/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/13/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/13/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/14/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/14/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
04/14/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/15/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/15/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/15/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/15/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/15/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/15/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/16/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 09:00	0.0	1.1	0	0.00	0.00000	0.00
04/16/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/16/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 13:00	0.0	1.7	0	0.00	0.00000	0.00
04/16/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/16/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.1	0	0.00	0.00000	0.00
Maximum:	0.0	1.7	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/17/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/17/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/17/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/18/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/18/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/18/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 13:00	0.0	1.6	0	0.00	0.00000	0.00
04/18/2024 14:00	0.0	1.0	0	0.00	0.00000	0.00
04/18/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/18/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/18/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/18/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
04/18/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.0	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/19/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/19/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/19/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/19/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/19/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/19/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/19/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/20/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/20/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/20/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/21/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
04/21/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
04/21/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/21/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/21/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/22/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
04/22/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
04/22/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/22/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/22/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/23/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
04/23/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/23/2024 10:00	0.0	1.1	0	0.00	0.00000	0.00
04/23/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
04/23/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/23/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/23/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/23/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/23/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/23/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.1	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/24/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/24/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/24/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/25/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
04/25/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/25/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/25/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/26/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 03:00	0.0	1.6	0	0.00	0.00000	0.00
04/26/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/26/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/26/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/26/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/26/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/26/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/26/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/27/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/27/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/27/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/28/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
04/28/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/28/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/29/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/29/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
04/29/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/30/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
04/30/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
04/30/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
04/30/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/01/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/01/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/01/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
05/01/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
05/01/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
05/01/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/02/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/02/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
05/02/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/02/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
05/02/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/02/2024 22:00	0.0	1.3	0	0.00	0.00000	0.00
05/02/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/03/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
05/03/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
05/03/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
05/03/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
05/03/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/03/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/04/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
05/04/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 10:00	0.0	1.5	0	0.15	0.07398	0.25
05/04/2024 11:00	0.0	1.5	0	0.06	0.03018	0.10
05/04/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/04/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
05/04/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.11	0.05208	0.18
Minimum:	0.0	1.4	0	0.06	0.03018	0.10
Maximum:	0.0	1.6	0	0.15	0.07398	0.25
%SI	91.67	0.00	100.00	91.67	91.67	91.67

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/05/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
05/05/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/05/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/05/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/05/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
05/05/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/05/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
05/05/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/06/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/06/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
05/06/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/07/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/07/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
05/07/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/07/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
05/07/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/07/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
05/07/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
05/07/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/07/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/08/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/08/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
05/08/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/08/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
05/08/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
05/08/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
05/08/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
05/08/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/08/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/09/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/09/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
05/09/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
05/09/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
05/09/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/09/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/10/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/10/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/10/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/10/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/10/2024 22:00	0.0	1.3	0	0.00	0.00000	0.00
05/10/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/11/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
05/11/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
05/11/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
05/11/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
05/11/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
05/11/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
05/11/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/11/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/12/2024 00:00	0.0	1.3	0	0.00	0.00000	0.00
05/12/2024 01:00	0.0	1.3	0	0.00	0.00000	0.00
05/12/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
05/12/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
05/12/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
05/12/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/12/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/13/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
05/13/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
05/13/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/13/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/13/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
05/13/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
05/13/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/13/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/14/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
05/14/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/14/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
05/14/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
05/14/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
05/14/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/14/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/15/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/15/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
05/15/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
05/15/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
05/15/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/15/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/16/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 02:00	0.0	1.2	0	0.00	0.00000	0.00
05/16/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
05/16/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
05/16/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/16/2024 17:00	0.0	1.4	0	0.29	0.14580	0.49
05/16/2024 18:00	0.0	1.4	0	0.55	0.27582	0.92
05/16/2024 19:00	0.0	1.4	0	0.58	0.28998	0.97
05/16/2024 20:00	0.6	1.4	0	0.50	0.24780	0.83
05/16/2024 21:00	0.6	1.4	0	0.58	0.28878	0.96
05/16/2024 22:00	0.7	1.4	0	0.30	0.15216	0.51
05/16/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.4	0	0.47	0.23339	0.78
Minimum:	0.6	1.2	0	0.29	0.14580	0.49
Maximum:	0.7	1.5	0	0.58	0.28998	0.97
%SI	87.50	0.00	87.50	75.00	75.00	75.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/17/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 03:00	0.0	1.3	0	0.00	0.00000	0.00
05/17/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
05/17/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
05/17/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/17/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/18/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
05/18/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/18/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	8.33	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/19/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 02:00	0.0	1.6	0	0.00	0.00000	0.00
05/19/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
05/19/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
05/19/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
05/19/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.6	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/20/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
05/20/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
05/20/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
05/20/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
05/20/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
05/20/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
05/20/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
05/20/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
05/20/2024 22:00	0.0	1.4	0	0.33	0.16746	0.56
05/20/2024 23:00	0.7	1.3	0	0.46	0.23214	0.77
Average/Sum#:	0.4	1.4	0	0.40	0.19980	0.67
Minimum:	0.0	1.3	0	0.33	0.16746	0.56
Maximum:	0.7	1.5	0	0.46	0.23214	0.77
%SI	91.67	0.00	95.83	91.67	91.67	91.67

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/21/2024 00:00	0.9	1.4	0	0.46	0.22908	0.76
05/21/2024 01:00	0.9	1.4	0	0.46	0.23034	0.77
05/21/2024 02:00	0.7	1.4	0	0.46	0.23094	0.77
05/21/2024 03:00	0.8	1.4	0	0.46	0.23112	0.77
05/21/2024 04:00	0.8	1.4	0	0.46	0.23130	0.77
05/21/2024 05:00	0.7	1.4	0	0.47	0.23262	0.78
05/21/2024 06:00	0.9	1.4	0	0.59	0.29262	0.98
05/21/2024 07:00	0.3	1.5	1	0.77	0.38658	1.29
05/21/2024 08:00	0.2	1.5	1	0.77	0.38514	1.28
05/21/2024 09:00	0.2	1.5	1	0.77	0.38352	1.28
05/21/2024 10:00	0.2	1.5	1	0.76	0.38244	1.27
05/21/2024 11:00	0.1	1.5	1	0.77	0.38322	1.28
05/21/2024 12:00	0.1	1.5	1	0.78	0.38958	1.30
05/21/2024 13:00	0.1	1.5	1	0.78	0.38988	1.30
05/21/2024 14:00	0.1	1.5	1	0.78	0.38976	1.30
05/21/2024 15:00	0.1	1.5	1	0.78	0.38940	1.30
05/21/2024 16:00	0.1	1.5	1	0.78	0.38928	1.30
05/21/2024 17:00	0.1	1.5	1	0.78	0.38940	1.30
05/21/2024 18:00	0.1	1.5	1	0.78	0.38850	1.30
05/21/2024 19:00	0.1	1.5	1	0.77	0.38670	1.29
05/21/2024 20:00	0.8	1.5	0	0.64	0.32022	1.07
05/21/2024 21:00	0.8	1.4	0	0.58	0.28908	0.96
05/21/2024 22:00	0.7	1.4	0	0.47	0.23568	0.79
05/21/2024 23:00	0.7	1.4	0	0.47	0.23370	0.78
Average/Sum#:	0.4	1.5	1	0.65	0.32459	1.08
Minimum:	0.1	1.4	0	0.46	0.22908	0.76
Maximum:	0.9	1.5	1	0.78	0.38988	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/22/2024 00:00	0.7	1.4	0	0.47	0.23310	0.78
05/22/2024 01:00	0.7	1.4	0	0.47	0.23568	0.79
05/22/2024 02:00	0.7	1.4	0	0.47	0.23298	0.78
05/22/2024 03:00	0.7	1.4	0	0.50	0.25188	0.84
05/22/2024 04:00	0.8	1.5	0	0.52	0.25956	0.87
05/22/2024 05:00	0.2	1.5	1	0.79	0.39426	1.31
05/22/2024 06:00	0.2	1.5	1	0.79	0.39414	1.31
05/22/2024 07:00	0.1	1.5	1	0.79	0.39486	1.32
05/22/2024 08:00	0.1	1.5	1	0.79	0.39384	1.31
05/22/2024 09:00	0.2	1.5	1	0.79	0.39414	1.31
05/22/2024 10:00	0.1	1.5	1	0.79	0.39444	1.31
05/22/2024 11:00	0.1	1.5	1	0.79	0.39420	1.31
05/22/2024 12:00	0.1	1.5	1	0.79	0.39540	1.32
05/22/2024 13:00	0.1	1.5	1	0.79	0.39528	1.32
05/22/2024 14:00	0.1	1.5	1	0.79	0.39456	1.32
05/22/2024 15:00	0.1	1.5	1	0.78	0.39162	1.31
05/22/2024 16:00	0.7	1.4	0	0.57	0.28662	0.96
05/22/2024 17:00	0.2	1.5	1	0.75	0.37638	1.25
05/22/2024 18:00	0.1	1.5	1	0.78	0.39234	1.31
05/22/2024 19:00	0.1	1.5	1	0.78	0.39078	1.30
05/22/2024 20:00	0.1	1.5	1	0.78	0.38982	1.30
05/22/2024 21:00	0.1	1.5	1	0.78	0.38904	1.30
05/22/2024 22:00	0.7	1.4	0	0.60	0.29766	0.99
05/22/2024 23:00	0.7	1.4	0	0.47	0.23262	0.78
Average/Sum#:	0.3	1.5	1	0.69	0.34605	1.15
Minimum:	0.1	1.4	0	0.47	0.23262	0.78
Maximum:	0.8	1.5	1	0.79	0.39540	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/23/2024 00:00	0.7	1.4	0	0.47	0.23316	0.78
05/23/2024 01:00	0.7	1.4	0	0.47	0.23262	0.78
05/23/2024 02:00	0.7	1.4	0	0.46	0.23238	0.77
05/23/2024 03:00	0.8	1.3	0	0.46	0.23190	0.77
05/23/2024 04:00	0.7	1.4	0	0.46	0.23190	0.77
05/23/2024 05:00	0.7	1.5	0	0.47	0.23466	0.78
05/23/2024 06:00	0.8	1.3	0	0.46	0.23244	0.77
05/23/2024 07:00	0.8	1.4	0	0.51	0.25716	0.86
05/23/2024 08:00	0.2	1.5	2	0.79	0.39312	1.31
05/23/2024 09:00	0.1	1.5	2	0.79	0.39258	1.31
05/23/2024 10:00	0.1	1.5	2	0.79	0.39396	1.31
05/23/2024 11:00	0.4	1.4	1	0.67	0.33618	1.12
05/23/2024 12:00	0.6	1.2	0	0.51	0.25488	0.85
05/23/2024 13:00	0.6	0.0	0	0.47	0.23262	0.78
05/23/2024 14:00	0.6	0.0	0	0.47	0.23256	0.78
05/23/2024 15:00	0.6	0.0	0	0.47	0.23250	0.78
05/23/2024 16:00	0.6	0.0	0	0.47	0.23256	0.78
05/23/2024 17:00	0.7	0.0	0	0.50	0.25092	0.84
05/23/2024 18:00	0.7	0.0	0	0.55	0.27666	0.92
05/23/2024 19:00	0.6	0.0	0	0.57	0.28464	0.95
05/23/2024 20:00	0.6	0.0	0	0.54	0.26826	0.89
05/23/2024 21:00	0.7	0.0	0	0.47	0.23436	0.78
05/23/2024 22:00	0.8	0.0	0	0.47	0.23382	0.78
05/23/2024 23:00	0.7	0.0	0	0.47	0.23442	0.78
Average/Sum#:	0.6	1.4	0	0.53	0.26543	0.89
Minimum:	0.1	1.2	0	0.46	0.23190	0.77
Maximum:	0.8	1.5	2	0.79	0.39396	1.31
%SI	0.00	45.83	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/24/2024 00:00	0.7	0.0	0	0.47	0.23424	0.78
05/24/2024 01:00	0.7	0.0	0	0.47	0.23418	0.78
05/24/2024 02:00	0.7	0.0	0	0.47	0.23406	0.78
05/24/2024 03:00	0.8	0.0	0	0.47	0.23334	0.78
05/24/2024 04:00	0.8	0.0	0	0.47	0.23286	0.78
05/24/2024 05:00	0.8	0.0	0	0.48	0.23760	0.79
05/24/2024 06:00	0.8	0.0	0	0.47	0.23472	0.78
05/24/2024 07:00	0.8	0.0	0	0.47	0.23538	0.78
05/24/2024 08:00	0.7	0.0	0	0.47	0.23328	0.78
05/24/2024 09:00	0.7	0.0	0	0.47	0.23286	0.78
05/24/2024 10:00	0.7	0.0	0	0.47	0.23250	0.78
05/24/2024 11:00	0.7	0.0	0	0.47	0.23268	0.78
05/24/2024 12:00	0.7	0.0	0	0.47	0.23346	0.78
05/24/2024 13:00	0.7	0.0	0	0.47	0.23310	0.78
05/24/2024 14:00	0.6	0.0	0	0.47	0.23328	0.78
05/24/2024 15:00	0.6	0.0	0	0.47	0.23346	0.78
05/24/2024 16:00	0.7	0.0	0	0.47	0.23316	0.78
05/24/2024 17:00	0.7	0.0	0	0.47	0.23304	0.78
05/24/2024 18:00	0.7	0.0	0	0.47	0.23322	0.78
05/24/2024 19:00	0.7	0.0	0	0.47	0.23280	0.78
05/24/2024 20:00	0.7	0.0	0	0.47	0.23430	0.78
05/24/2024 21:00	0.7	0.0	0	0.55	0.27420	0.91
05/24/2024 22:00	0.7	0.0	0	0.48	0.24132	0.80
05/24/2024 23:00	0.7	0.0	0	0.49	0.24618	0.82
Average/Sum#:	0.7	0.0	0	0.48	0.23622	0.79
Minimum:	0.6	0.0	0	0.47	0.23250	0.78
Maximum:	0.8	0.0	0	0.55	0.27420	0.91
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/25/2024 00:00	0.7	0.0	0	0.48	0.24192	0.81
05/25/2024 01:00	0.7	0.0	0	0.47	0.23292	0.78
05/25/2024 02:00	0.8	0.0	0	0.47	0.23442	0.78
05/25/2024 03:00	0.8	0.0	0	0.47	0.23472	0.78
05/25/2024 04:00	0.8	0.0	0	0.47	0.23478	0.78
05/25/2024 05:00	0.8	0.0	0	0.47	0.23514	0.78
05/25/2024 06:00	0.7	0.0	0	0.47	0.23514	0.78
05/25/2024 07:00	0.7	0.0	0	0.47	0.23544	0.78
05/25/2024 08:00	0.7	0.0	0	0.47	0.23634	0.79
05/25/2024 09:00	0.7	0.0	0	0.47	0.23640	0.79
05/25/2024 10:00	0.7	0.0	0	0.47	0.23640	0.79
05/25/2024 11:00	0.6	0.0	0	0.47	0.23310	0.78
05/25/2024 12:00	0.7	0.0	0	0.47	0.23310	0.78
05/25/2024 13:00	0.6	0.0	0	0.47	0.23382	0.78
05/25/2024 14:00	0.6	0.0	0	0.47	0.23388	0.78
05/25/2024 15:00	0.6	0.0	0	0.47	0.23400	0.78
05/25/2024 16:00	0.6	0.0	0	0.47	0.23412	0.78
05/25/2024 17:00	0.7	0.0	0	0.47	0.23370	0.78
05/25/2024 18:00	0.7	0.0	0	0.46	0.23202	0.77
05/25/2024 19:00	0.7	0.0	0	0.46	0.23124	0.77
05/25/2024 20:00	0.7	0.0	0	0.47	0.23280	0.78
05/25/2024 21:00	0.7	0.0	0	0.47	0.23304	0.78
05/25/2024 22:00	0.8	0.0	0	0.47	0.23322	0.78
05/25/2024 23:00	0.8	0.0	0	0.47	0.23292	0.78
Average/Sum#:	0.7	0.0	0	0.47	0.23436	0.78
Minimum:	0.6	0.0	0	0.46	0.23124	0.77
Maximum:	0.8	0.0	0	0.48	0.24192	0.81
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/26/2024 00:00	0.8	0.0	0	0.47	0.23322	0.78
05/26/2024 01:00	0.8	0.0	0	0.47	0.23298	0.78
05/26/2024 02:00	0.8	0.0	0	0.47	0.23310	0.78
05/26/2024 03:00	0.8	0.0	0	0.47	0.23304	0.78
05/26/2024 04:00	0.8	0.0	0	0.47	0.23292	0.78
05/26/2024 05:00	0.8	0.0	0	0.47	0.23298	0.78
05/26/2024 06:00	0.8	0.0	0	0.47	0.23274	0.78
05/26/2024 07:00	0.8	0.0	0	0.47	0.23268	0.78
05/26/2024 08:00	0.8	0.0	0	0.47	0.23292	0.78
05/26/2024 09:00	0.7	0.0	0	0.47	0.23268	0.78
05/26/2024 10:00	0.7	0.0	0	0.46	0.23130	0.77
05/26/2024 11:00	0.6	0.0	0	0.46	0.23130	0.77
05/26/2024 12:00	0.7	0.0	-1	0.46	0.23130	0.77
05/26/2024 13:00	0.6	0.0	-1	0.46	0.23130	0.77
05/26/2024 14:00	0.6	0.0	-1	0.46	0.23130	0.77
05/26/2024 15:00	0.6	0.0	-1	0.46	0.23076	0.77
05/26/2024 16:00	0.6	0.0	-1	0.46	0.23082	0.77
05/26/2024 17:00	0.6	0.0	0	0.47	0.23478	0.78
05/26/2024 18:00	0.7	0.0	0	0.46	0.23154	0.77
05/26/2024 19:00	0.7	0.0	0	0.46	0.23160	0.77
05/26/2024 20:00	0.7	0.0	0	0.46	0.23136	0.77
05/26/2024 21:00	0.7	0.0	0	0.46	0.23214	0.77
05/26/2024 22:00	0.7	0.0	0	0.47	0.23388	0.78
05/26/2024 23:00	0.7	0.0	0	0.47	0.23382	0.78
Average/Sum#:	0.7	0.0	0	0.47	0.23235	0.78
Minimum:	0.6	0.0	-1	0.46	0.23076	0.77
Maximum:	0.8	0.0	0	0.47	0.23478	0.78
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/27/2024 00:00	0.7	0.0	0	0.47	0.23364	0.78
05/27/2024 01:00	0.7	0.0	0	0.47	0.23400	0.78
05/27/2024 02:00	0.7	0.0	0	0.47	0.23334	0.78
05/27/2024 03:00	0.9	0.0	0	0.47	0.23352	0.78
05/27/2024 04:00	0.8	0.0	0	0.47	0.23388	0.78
05/27/2024 05:00	0.8	0.0	0	0.49	0.24378	0.81
05/27/2024 06:00	0.8	0.0	0	0.47	0.23352	0.78
05/27/2024 07:00	0.7	0.0	0	0.47	0.23346	0.78
05/27/2024 08:00	0.7	0.0	0	0.47	0.23346	0.78
05/27/2024 09:00	0.7	0.0	0	0.47	0.23418	0.78
05/27/2024 10:00	0.7	0.0	0	0.47	0.23310	0.78
05/27/2024 11:00	0.6	0.0	0	0.46	0.23154	0.77
05/27/2024 12:00	0.6	0.0	-1	0.46	0.23130	0.77
05/27/2024 13:00	0.6	0.0	-1	0.46	0.23010	0.77
05/27/2024 14:00	0.6	0.0	-1	0.46	0.22956	0.77
05/27/2024 15:00	0.6	0.0	-1	0.46	0.23052	0.77
05/27/2024 16:00	0.7	0.0	0	0.50	0.24864	0.83
05/27/2024 17:00	0.7	0.0	0	0.49	0.24432	0.81
05/27/2024 18:00	0.6	1.5	1	0.68	0.33900	1.13
05/27/2024 19:00	0.3	1.5	1	0.76	0.38202	1.27
05/27/2024 20:00	0.6	1.5	0	0.68	0.34236	1.14
05/27/2024 21:00	0.9	1.4	0	0.62	0.31194	1.04
05/27/2024 22:00	0.7	1.3	0	0.50	0.25068	0.84
05/27/2024 23:00	0.7	1.3	0	0.52	0.26004	0.87
Average/Sum#:	0.7	1.1	0	0.51	0.25466	0.85
Minimum:	0.3	0.0	-1	0.46	0.22956	0.77
Maximum:	0.9	1.5	1	0.76	0.38202	1.27
%SI	0.00	66.67	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/28/2024 00:00	0.8	0.0	0	0.47	0.23298	0.78
05/28/2024 01:00	0.7	0.0	0	0.47	0.23430	0.78
05/28/2024 02:00	0.8	0.0	0	0.47	0.23484	0.78
05/28/2024 03:00	0.8	0.0	0	0.47	0.23454	0.78
05/28/2024 04:00	0.8	0.0	0	0.47	0.23496	0.78
05/28/2024 05:00	0.7	0.0	0	0.47	0.23478	0.78
05/28/2024 06:00	0.8	0.0	0	0.47	0.23460	0.78
05/28/2024 07:00	0.7	0.0	0	0.47	0.23484	0.78
05/28/2024 08:00	0.7	0.0	0	0.47	0.23460	0.78
05/28/2024 09:00	0.7	0.0	0	0.47	0.23460	0.78
05/28/2024 10:00	0.7	0.0	0	0.47	0.23382	0.78
05/28/2024 11:00	0.7	0.0	0	0.47	0.23448	0.78
05/28/2024 12:00	0.6	0.0	-1	0.47	0.23424	0.78
05/28/2024 13:00	0.7	0.0	0	0.47	0.23394	0.78
05/28/2024 14:00	0.7	0.0	0	0.47	0.23334	0.78
05/28/2024 15:00	0.6	0.0	0	0.46	0.23202	0.77
05/28/2024 16:00	0.7	0.0	-1	0.46	0.23088	0.77
05/28/2024 17:00	0.7	0.0	0	0.51	0.25452	0.85
05/28/2024 18:00	0.7	0.0	0	0.54	0.26892	0.90
05/28/2024 19:00	0.7	0.0	0	0.53	0.26340	0.88
05/28/2024 20:00	0.7	0.0	0	0.46	0.23232	0.77
05/28/2024 21:00	0.7	0.0	0	0.46	0.23244	0.77
05/28/2024 22:00	0.7	0.0	0	0.47	0.23358	0.78
05/28/2024 23:00	0.7	0.0	0	0.47	0.23418	0.78
Average/Sum#:	0.7	0.0	0	0.48	0.23738	0.79
Minimum:	0.6	0.0	-1	0.46	0.23088	0.77
Maximum:	0.8	0.0	0	0.54	0.26892	0.90
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/29/2024 00:00	0.7	0.0	0	0.47	0.23454	0.78
05/29/2024 01:00	0.7	0.0	0	0.47	0.23448	0.78
05/29/2024 02:00	0.7	0.0	0	0.47	0.23406	0.78
05/29/2024 03:00	0.7	0.0	0	0.47	0.23394	0.78
05/29/2024 04:00	0.8	0.0	0	0.47	0.23442	0.78
05/29/2024 05:00	0.9	0.0	0	0.47	0.23442	0.78
05/29/2024 06:00	0.7	0.0	0	0.47	0.23436	0.78
05/29/2024 07:00	0.7	0.0	0	0.47	0.23424	0.78
05/29/2024 08:00	0.7	0.0	0	0.48	0.23952	0.80
05/29/2024 09:00	0.7	0.0	0	0.47	0.23718	0.79
05/29/2024 10:00	0.7	0.0	0	0.57	0.28326	0.94
05/29/2024 11:00	0.7	0.0	0	0.51	0.25494	0.85
05/29/2024 12:00	0.7	0.0	0	0.49	0.24378	0.81
05/29/2024 13:00	0.6	0.0	0	0.59	0.29376	0.98
05/29/2024 14:00	0.6	0.0	0	0.58	0.29202	0.97
05/29/2024 15:00	0.7	0.0	1	0.52	0.26184	0.87
05/29/2024 16:00	0.6	0.0	0	0.54	0.26820	0.89
05/29/2024 17:00	0.6	0.0	0	0.53	0.26580	0.89
05/29/2024 18:00	0.6	0.0	0	0.53	0.26598	0.89
05/29/2024 19:00	0.6	0.0	0	0.53	0.26724	0.89
05/29/2024 20:00	0.7	0.0	0	0.53	0.26730	0.89
05/29/2024 21:00	0.7	0.0	0	0.53	0.26712	0.89
05/29/2024 22:00	0.7	0.0	0	0.53	0.26616	0.89
05/29/2024 23:00	0.0	0.0	0	0.30	0.14886	0.50
Average/Sum#:	0.7	0.0	0	0.50	0.24989	0.83
Minimum:	0.0	0.0	0	0.30	0.14886	0.50
Maximum:	0.9	0.0	1	0.59	0.29376	0.98
%SI	0.00	100.00	4.17	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/30/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2024 10:00	0.0	0.0	0	0.08	0.03864	0.13
05/30/2024 11:00	0.6	0.0	0	0.51	0.25716	0.86
05/30/2024 12:00	0.6	0.0	0	0.57	0.28668	0.96
05/30/2024 13:00	0.6	0.0	0	0.58	0.29130	0.97
05/30/2024 14:00	0.7	0.0	0	0.51	0.25392	0.85
05/30/2024 15:00	0.6	0.0	0	0.47	0.23304	0.78
05/30/2024 16:00	0.6	0.0	0	0.47	0.23370	0.78
05/30/2024 17:00	0.6	0.0	-1	0.49	0.24666	0.82
05/30/2024 18:00	0.6	0.0	0	0.54	0.26916	0.90
05/30/2024 19:00	0.6	0.0	0	0.50	0.24876	0.83
05/30/2024 20:00	0.7	0.0	0	0.47	0.23382	0.78
05/30/2024 21:00	0.7	0.0	0	0.47	0.23412	0.78
05/30/2024 22:00	0.8	0.0	0	0.47	0.23406	0.78
05/30/2024 23:00	0.7	0.0	0	0.47	0.23376	0.78
Average/Sum#:	0.6	0.0	0	0.47	0.23534	0.79
Minimum:	0.0	0.0	-1	0.08	0.03864	0.13
Maximum:	0.8	0.0	0	0.58	0.29130	0.97
%SI	41.67	100.00	45.83	41.67	41.67	41.67

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/31/2024 00:00	0.7	0.0	0	0.47	0.23358	0.78
05/31/2024 01:00	0.7	0.0	0	0.47	0.23328	0.78
05/31/2024 02:00	0.7	0.0	0	0.47	0.23334	0.78
05/31/2024 03:00	0.7	0.0	0	0.47	0.23352	0.78
05/31/2024 04:00	0.7	0.0	0	0.47	0.23502	0.78
05/31/2024 05:00	0.8	0.0	0	0.48	0.24006	0.80
05/31/2024 06:00	0.7	0.0	0	0.47	0.23316	0.78
05/31/2024 07:00	0.7	0.0	0	0.47	0.23334	0.78
05/31/2024 08:00	0.7	0.0	-1	0.47	0.23334	0.78
05/31/2024 09:00	0.7	0.0	-1	0.47	0.23364	0.78
05/31/2024 10:00	0.7	0.0	-1	0.47	0.23358	0.78
05/31/2024 11:00	0.6	0.0	-1	0.47	0.23250	0.78
05/31/2024 12:00	0.6	0.0	-1	0.46	0.23124	0.77
05/31/2024 13:00	0.7	0.0	-1	0.46	0.23112	0.77
05/31/2024 14:00	0.7	0.0	-1	0.46	0.23070	0.77
05/31/2024 15:00	0.7	0.0	-1	0.46	0.23034	0.77
05/31/2024 16:00	0.7	0.0	-1	0.47	0.23670	0.79
05/31/2024 17:00	0.7	0.0	0	0.49	0.24558	0.82
05/31/2024 18:00	0.6	0.0	0	0.57	0.28410	0.95
05/31/2024 19:00	0.6	0.0	0	0.54	0.27234	0.91
05/31/2024 20:00	0.6	0.0	0	0.50	0.24858	0.83
05/31/2024 21:00	0.7	0.0	0	0.50	0.25020	0.83
05/31/2024 22:00	0.7	0.0	-1	0.47	0.23514	0.78
05/31/2024 23:00	0.7	0.0	0	0.47	0.23466	0.78
Average/Sum#:	0.7	0.0	0	0.48	0.23913	0.80
Minimum:	0.6	0.0	-1	0.46	0.23034	0.77
Maximum:	0.8	0.0	0	0.57	0.28410	0.95
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/01/2024 00:00	0.7	0.0	0	0.47	0.23424	0.78
06/01/2024 01:00	0.7	0.0	0	0.47	0.23448	0.78
06/01/2024 02:00	0.7	0.0	0	0.47	0.23598	0.79
06/01/2024 03:00	0.7	0.0	0	0.47	0.23652	0.79
06/01/2024 04:00	0.7	0.0	0	0.47	0.23640	0.79
06/01/2024 05:00	0.7	0.0	0	0.47	0.23640	0.79
06/01/2024 06:00	0.7	0.0	0	0.47	0.23592	0.79
06/01/2024 07:00	0.7	0.0	0	0.47	0.23562	0.79
06/01/2024 08:00	0.7	0.0	0	0.47	0.23586	0.79
06/01/2024 09:00	0.7	0.0	0	0.47	0.23424	0.78
06/01/2024 10:00	0.7	0.0	0	0.47	0.23436	0.78
06/01/2024 11:00	0.7	0.0	0	0.47	0.23394	0.78
06/01/2024 12:00	0.7	0.0	-1	0.47	0.23388	0.78
06/01/2024 13:00	0.7	0.0	-1	0.47	0.23394	0.78
06/01/2024 14:00	0.7	0.0	-1	0.47	0.23358	0.78
06/01/2024 15:00	0.7	0.0	-1	0.46	0.23154	0.77
06/01/2024 16:00	0.7	0.0	-1	0.46	0.23130	0.77
06/01/2024 17:00	0.7	0.0	0	0.47	0.23628	0.79
06/01/2024 18:00	0.7	0.0	0	0.46	0.23184	0.77
06/01/2024 19:00	0.7	0.0	-1	0.47	0.23298	0.78
06/01/2024 20:00	0.7	0.0	-1	0.47	0.23304	0.78
06/01/2024 21:00	0.7	0.0	0	0.47	0.23406	0.78
06/01/2024 22:00	0.7	0.0	0	0.47	0.23436	0.78
06/01/2024 23:00	0.7	0.0	0	0.47	0.23424	0.78
Average/Sum#:	0.7	0.0	0	0.47	0.23438	0.78
Minimum:	0.7	0.0	-1	0.46	0.23130	0.77
Maximum:	0.7	0.0	0	0.47	0.23652	0.79
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/02/2024 00:00	0.7	0.0	0	0.47	0.23352	0.78
06/02/2024 01:00	0.7	0.0	0	0.47	0.23304	0.78
06/02/2024 02:00	0.7	0.0	0	0.47	0.23328	0.78
06/02/2024 03:00	0.8	0.0	0	0.47	0.23292	0.78
06/02/2024 04:00	0.8	0.0	0	0.47	0.23304	0.78
06/02/2024 05:00	0.7	0.0	0	0.47	0.23256	0.78
06/02/2024 06:00	0.7	0.0	0	0.48	0.24018	0.80
06/02/2024 07:00	0.7	0.0	0	0.47	0.23406	0.78
06/02/2024 08:00	0.7	0.0	0	0.47	0.23496	0.78
06/02/2024 09:00	0.7	0.0	-1	0.48	0.23892	0.80
06/02/2024 10:00	0.7	0.0	-1	0.47	0.23448	0.78
06/02/2024 11:00	0.7	0.0	-1	0.47	0.23322	0.78
06/02/2024 12:00	0.6	0.0	-1	0.47	0.23274	0.78
06/02/2024 13:00	0.7	0.0	0	0.50	0.24798	0.83
06/02/2024 14:00	0.6	0.0	0	0.53	0.26382	0.88
06/02/2024 15:00	0.6	1.5	0	0.69	0.34602	1.15
06/02/2024 16:00	0.3	1.5	1	0.75	0.37542	1.25
06/02/2024 17:00	0.7	1.3	0	0.49	0.24618	0.82
06/02/2024 18:00	0.6	1.3	0	0.46	0.23016	0.77
06/02/2024 19:00	0.6	1.4	0	0.48	0.24090	0.80
06/02/2024 20:00	0.7	0.0	-1	0.47	0.23334	0.78
06/02/2024 21:00	0.7	0.0	-1	0.47	0.23262	0.78
06/02/2024 22:00	0.7	0.0	-1	0.47	0.23298	0.78
06/02/2024 23:00	0.7	0.0	-1	0.47	0.23292	0.78
Average/Sum#:	0.7	1.2	0	0.50	0.24705	0.83
Minimum:	0.3	0.0	-1	0.46	0.23016	0.77
Maximum:	0.8	1.5	1	0.75	0.37542	1.25
%SI	0.00	75.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/03/2024 00:00	0.7	0.0	-1	0.47	0.23346	0.78
06/03/2024 01:00	0.7	0.0	0	0.47	0.23292	0.78
06/03/2024 02:00	0.7	0.0	-1	0.47	0.23262	0.78
06/03/2024 03:00	0.8	0.0	-1	0.46	0.23232	0.77
06/03/2024 04:00	0.7	0.0	-1	0.47	0.23262	0.78
06/03/2024 05:00	0.7	0.0	-1	0.46	0.23208	0.77
06/03/2024 06:00	0.7	0.0	-1	0.47	0.23310	0.78
06/03/2024 07:00	0.7	0.0	-1	0.47	0.23358	0.78
06/03/2024 08:00	0.7	0.0	-1	0.47	0.23358	0.78
06/03/2024 09:00	0.7	0.0	-1	0.46	0.23214	0.77
06/03/2024 10:00	0.6	0.0	-1	0.46	0.23226	0.77
06/03/2024 11:00	0.6	0.0	-1	0.46	0.23184	0.77
06/03/2024 12:00	0.6	0.0	-1	0.46	0.23244	0.77
06/03/2024 13:00	0.6	0.0	-1	0.46	0.23238	0.77
06/03/2024 14:00	0.6	0.0	-1	0.47	0.23268	0.78
06/03/2024 15:00	0.6	0.0	-1	0.46	0.23238	0.77
06/03/2024 16:00	0.6	0.0	-1	0.46	0.23124	0.77
06/03/2024 17:00	0.6	0.0	-1	0.46	0.22950	0.77
06/03/2024 18:00	0.6	0.0	-1	0.46	0.23094	0.77
06/03/2024 19:00	0.7	0.0	-1	0.46	0.23130	0.77
06/03/2024 20:00	0.7	0.0	-1	0.46	0.23100	0.77
06/03/2024 21:00	0.7	0.0	0	0.46	0.23148	0.77
06/03/2024 22:00	0.7	0.0	0	0.46	0.23034	0.77
06/03/2024 23:00	0.7	0.0	-1	0.46	0.22992	0.77
Average/Sum#:	0.7	0.0	-1	0.46	0.23201	0.77
Minimum:	0.6	0.0	-1	0.46	0.22950	0.77
Maximum:	0.8	0.0	0	0.47	0.23358	0.78
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/04/2024 00:00	0.7	0.0	-1	0.46	0.23022	0.77
06/04/2024 01:00	0.7	0.0	0	0.46	0.23028	0.77
06/04/2024 02:00	0.7	0.0	0	0.46	0.23022	0.77
06/04/2024 03:00	0.7	0.0	0	0.46	0.23010	0.77
06/04/2024 04:00	0.8	0.0	0	0.46	0.23046	0.77
06/04/2024 05:00	0.9	0.0	0	0.46	0.23046	0.77
06/04/2024 06:00	0.8	0.0	0	0.46	0.23052	0.77
06/04/2024 07:00	0.7	0.0	-1	0.46	0.23064	0.77
06/04/2024 08:00	0.7	0.0	-1	0.46	0.23052	0.77
06/04/2024 09:00	0.7	0.0	-1	0.46	0.22986	0.77
06/04/2024 10:00	0.7	0.0	-1	0.46	0.22968	0.77
06/04/2024 11:00	0.6	0.0	-1	0.46	0.22902	0.76
06/04/2024 12:00	0.6	0.0	0	0.46	0.23100	0.77
06/04/2024 13:00	0.6	0.0	0	0.46	0.23154	0.77
06/04/2024 14:00	0.6	0.0	0	0.46	0.23136	0.77
06/04/2024 15:00	0.6	0.0	0	0.46	0.23184	0.77
06/04/2024 16:00	0.6	0.0	0	0.51	0.25638	0.85
06/04/2024 17:00	0.6	0.0	-1	0.56	0.27918	0.93
06/04/2024 18:00	0.6	0.0	0	0.53	0.26724	0.89
06/04/2024 19:00	0.6	0.0	0	0.55	0.27420	0.91
06/04/2024 20:00	0.6	0.0	0	0.49	0.24372	0.81
06/04/2024 21:00	0.6	0.0	0	0.47	0.23466	0.78
06/04/2024 22:00	0.6	0.0	0	0.47	0.23598	0.79
06/04/2024 23:00	0.7	0.0	0	0.47	0.23622	0.79
Average/Sum#:	0.7	0.0	0	0.48	0.23814	0.79
Minimum:	0.6	0.0	-1	0.46	0.22902	0.76
Maximum:	0.9	0.0	0	0.56	0.27918	0.93
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/05/2024 00:00	0.6	0.0	0	0.53	0.26742	0.89
06/05/2024 01:00	0.7	0.0	0	0.53	0.26298	0.88
06/05/2024 02:00	0.7	0.0	0	0.47	0.23556	0.79
06/05/2024 03:00	0.7	0.0	0	0.47	0.23484	0.78
06/05/2024 04:00	0.7	0.0	0	0.48	0.24198	0.81
06/05/2024 05:00	0.7	0.0	0	0.50	0.25002	0.83
06/05/2024 06:00	0.7	0.0	0	0.47	0.23514	0.78
06/05/2024 07:00	0.7	0.0	0	0.47	0.23484	0.78
06/05/2024 08:00	0.6	0.0	0	0.47	0.23400	0.78
06/05/2024 09:00	0.6	0.0	0	0.47	0.23286	0.78
06/05/2024 10:00	0.6	0.0	0	0.47	0.23292	0.78
06/05/2024 11:00	0.6	0.0	0	0.53	0.26280	0.88
06/05/2024 12:00	0.7	1.5	0	0.50	0.25050	0.84
06/05/2024 13:00	0.6	1.4	0	0.66	0.33150	1.11
06/05/2024 14:00	0.8	0.9	0	0.55	0.27336	0.91
06/05/2024 15:00	0.6	0.6	0	0.64	0.32220	1.07
06/05/2024 16:00	0.7	0.5	0	0.48	0.23916	0.80
06/05/2024 17:00	0.7	0.4	0	0.54	0.26808	0.89
06/05/2024 18:00	0.7	0.4	0	0.56	0.28224	0.94
06/05/2024 19:00	0.6	0.4	0	0.57	0.28284	0.94
06/05/2024 20:00	0.6	0.4	0	0.53	0.26652	0.89
06/05/2024 21:00	0.8	0.4	0	0.51	0.25734	0.86
06/05/2024 22:00	0.7	0.0	0	0.48	0.24174	0.81
06/05/2024 23:00	1.0	0.0	0	0.50	0.25200	0.84
Average/Sum#:	0.7	0.6	0	0.52	0.25804	0.86
Minimum:	0.6	0.0	0	0.47	0.23286	0.78
Maximum:	1.0	1.5	0	0.66	0.33150	1.11
%SI	0.00	54.17	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/06/2024 00:00	0.7	0.0	0	0.47	0.23418	0.78
06/06/2024 01:00	0.7	0.0	-1	0.47	0.23394	0.78
06/06/2024 02:00	0.7	0.0	-1	0.47	0.23406	0.78
06/06/2024 03:00	0.7	0.0	0	0.47	0.23358	0.78
06/06/2024 04:00	0.7	0.0	-1	0.47	0.23382	0.78
06/06/2024 05:00	0.7	0.0	-1	0.47	0.23406	0.78
06/06/2024 06:00	0.7	0.0	-1	0.47	0.23442	0.78
06/06/2024 07:00	0.7	0.0	0	0.47	0.23442	0.78
06/06/2024 08:00	0.6	0.0	0	0.47	0.23478	0.78
06/06/2024 09:00	0.6	0.0	0	0.47	0.23430	0.78
06/06/2024 10:00	0.6	0.0	0	0.47	0.23370	0.78
06/06/2024 11:00	0.6	0.0	0	0.47	0.23394	0.78
06/06/2024 12:00	0.6	0.0	0	0.49	0.24402	0.81
06/06/2024 13:00	0.6	0.0	0	0.51	0.25284	0.84
06/06/2024 14:00	0.6	0.0	0	0.50	0.24900	0.83
06/06/2024 15:00	0.6	0.0	0	0.49	0.24444	0.81
06/06/2024 16:00	0.6	0.0	0	0.51	0.25698	0.86
06/06/2024 17:00	0.6	0.0	0	0.52	0.26244	0.87
06/06/2024 18:00	0.6	0.0	0	0.57	0.28518	0.95
06/06/2024 19:00	0.6	0.0	0	0.55	0.27726	0.92
06/06/2024 20:00	0.6	0.0	0	0.49	0.24258	0.81
06/06/2024 21:00	0.6	0.0	-1	0.47	0.23436	0.78
06/06/2024 22:00	0.6	0.0	-1	0.47	0.23436	0.78
06/06/2024 23:00	0.6	0.0	-1	0.47	0.23394	0.78
Average/Sum#:	0.6	0.0	0	0.49	0.24278	0.81
Minimum:	0.6	0.0	-1	0.47	0.23358	0.78
Maximum:	0.7	0.0	0	0.57	0.28518	0.95
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/07/2024 00:00	0.7	0.0	-1	0.47	0.23340	0.78
06/07/2024 01:00	0.7	0.0	-1	0.47	0.23322	0.78
06/07/2024 02:00	0.7	0.0	-1	0.47	0.23322	0.78
06/07/2024 03:00	0.6	0.0	0	0.47	0.23544	0.78
06/07/2024 04:00	0.7	0.0	0	0.47	0.23520	0.78
06/07/2024 05:00	0.6	0.0	0	0.50	0.24888	0.83
06/07/2024 06:00	0.7	0.0	-1	0.47	0.23550	0.79
06/07/2024 07:00	0.6	0.0	-1	0.47	0.23550	0.79
06/07/2024 08:00	0.7	0.0	-1	0.47	0.23490	0.78
06/07/2024 09:00	0.6	0.0	0	0.47	0.23376	0.78
06/07/2024 10:00	0.6	0.0	-1	0.47	0.23412	0.78
06/07/2024 11:00	0.6	0.0	0	0.47	0.23490	0.78
06/07/2024 12:00	0.6	0.0	0	0.47	0.23526	0.78
06/07/2024 13:00	0.6	0.0	0	0.47	0.23556	0.79
06/07/2024 14:00	0.6	0.0	0	0.47	0.23736	0.79
06/07/2024 15:00	0.6	0.0	0	0.47	0.23388	0.78
06/07/2024 16:00	0.6	0.0	0	0.47	0.23382	0.78
06/07/2024 17:00	0.6	0.0	0	0.49	0.24384	0.81
06/07/2024 18:00	0.6	0.0	0	0.54	0.26760	0.89
06/07/2024 19:00	0.6	0.0	0	0.53	0.26736	0.89
06/07/2024 20:00	0.6	0.0	0	0.50	0.25140	0.84
06/07/2024 21:00	0.6	0.0	0	0.47	0.23280	0.78
06/07/2024 22:00	0.6	0.0	0	0.47	0.23340	0.78
06/07/2024 23:00	0.6	0.0	0	0.47	0.23478	0.78
Average/Sum#:	0.6	0.0	0	0.48	0.23896	0.80
Minimum:	0.6	0.0	-1	0.47	0.23280	0.78
Maximum:	0.7	0.0	0	0.54	0.26760	0.89
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/08/2024 00:00	0.7	0.0	0	0.47	0.23466	0.78
06/08/2024 01:00	0.7	0.0	0	0.47	0.23430	0.78
06/08/2024 02:00	0.7	0.0	0	0.47	0.23478	0.78
06/08/2024 03:00	0.7	0.0	0	0.47	0.23640	0.79
06/08/2024 04:00	0.7	0.0	0	0.47	0.23556	0.79
06/08/2024 05:00	0.7	0.0	0	0.47	0.23508	0.78
06/08/2024 06:00	0.7	0.0	0	0.47	0.23502	0.78
06/08/2024 07:00	0.7	0.0	0	0.47	0.23514	0.78
06/08/2024 08:00	0.6	0.0	-1	0.47	0.23586	0.79
06/08/2024 09:00	0.6	0.0	-1	0.47	0.23412	0.78
06/08/2024 10:00	0.6	0.0	-1	0.47	0.23370	0.78
06/08/2024 11:00	0.6	0.0	-1	0.47	0.23352	0.78
06/08/2024 12:00	0.6	0.0	-1	0.47	0.23376	0.78
06/08/2024 13:00	0.6	0.0	0	0.47	0.23424	0.78
06/08/2024 14:00	0.6	0.0	-1	0.47	0.23382	0.78
06/08/2024 15:00	0.6	0.0	-1	0.47	0.23376	0.78
06/08/2024 16:00	0.6	0.0	-1	0.47	0.23406	0.78
06/08/2024 17:00	0.6	0.0	-1	0.47	0.23448	0.78
06/08/2024 18:00	0.6	0.0	-1	0.47	0.23400	0.78
06/08/2024 19:00	0.6	0.0	0	0.47	0.23406	0.78
06/08/2024 20:00	0.6	0.0	0	0.47	0.23442	0.78
06/08/2024 21:00	0.6	0.0	0	0.47	0.23514	0.78
06/08/2024 22:00	0.7	0.0	0	0.47	0.23490	0.78
06/08/2024 23:00	0.6	0.0	0	0.47	0.23472	0.78
Average/Sum#:	0.6	0.0	0	0.47	0.23456	0.78
Minimum:	0.6	0.0	-1	0.47	0.23352	0.78
Maximum:	0.7	0.0	0	0.47	0.23640	0.79
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/09/2024 00:00	0.7	0.0	0	0.47	0.23484	0.78
06/09/2024 01:00	0.7	0.0	0	0.47	0.23508	0.78
06/09/2024 02:00	0.7	0.0	0	0.47	0.23538	0.78
06/09/2024 03:00	0.7	0.0	0	0.47	0.23532	0.78
06/09/2024 04:00	0.7	0.0	0	0.47	0.23466	0.78
06/09/2024 05:00	0.7	0.0	0	0.47	0.23448	0.78
06/09/2024 06:00	0.7	0.0	0	0.47	0.23448	0.78
06/09/2024 07:00	0.7	0.0	0	0.47	0.23466	0.78
06/09/2024 08:00	0.7	0.0	0	0.47	0.23532	0.78
06/09/2024 09:00	0.6	0.0	0	0.47	0.23550	0.79
06/09/2024 10:00	0.6	0.0	-1	0.47	0.23460	0.78
06/09/2024 11:00	0.6	0.0	-1	0.47	0.23340	0.78
06/09/2024 12:00	0.6	0.0	-1	0.47	0.23364	0.78
06/09/2024 13:00	0.6	0.0	-1	0.47	0.23286	0.78
06/09/2024 14:00	0.6	0.0	-1	0.47	0.23274	0.78
06/09/2024 15:00	0.6	0.0	-1	0.47	0.23322	0.78
06/09/2024 16:00	0.6	0.0	-1	0.47	0.23256	0.78
06/09/2024 17:00	0.6	0.0	-1	0.46	0.23238	0.77
06/09/2024 18:00	0.6	0.0	-1	0.47	0.23262	0.78
06/09/2024 19:00	0.6	0.0	-1	0.46	0.23232	0.77
06/09/2024 20:00	0.6	0.0	-1	0.47	0.23364	0.78
06/09/2024 21:00	0.7	0.0	0	0.47	0.23424	0.78
06/09/2024 22:00	0.6	0.0	0	0.47	0.23430	0.78
06/09/2024 23:00	0.7	0.0	0	0.47	0.23454	0.78
Average/Sum#:	0.6	0.0	0	0.47	0.23403	0.78
Minimum:	0.6	0.0	-1	0.46	0.23232	0.77
Maximum:	0.7	0.0	0	0.47	0.23550	0.79
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/10/2024 00:00	0.7	0.0	0	0.47	0.23478	0.78
06/10/2024 01:00	0.7	0.0	0	0.47	0.23472	0.78
06/10/2024 02:00	0.7	0.0	0	0.47	0.23460	0.78
06/10/2024 03:00	0.7	0.0	0	0.47	0.23454	0.78
06/10/2024 04:00	0.7	0.0	0	0.47	0.23490	0.78
06/10/2024 05:00	0.7	0.0	0	0.47	0.23460	0.78
06/10/2024 06:00	0.7	0.0	0	0.47	0.23520	0.78
06/10/2024 07:00	0.7	0.0	0	0.47	0.23520	0.78
06/10/2024 08:00	0.6	0.0	-1	0.47	0.23502	0.78
06/10/2024 09:00	0.7	0.0	-1	0.47	0.23364	0.78
06/10/2024 10:00	0.6	0.0	-1	0.47	0.23322	0.78
06/10/2024 11:00	0.6	0.0	-1	0.47	0.23286	0.78
06/10/2024 12:00	0.6	0.0	-1	0.47	0.23298	0.78
06/10/2024 13:00	0.6	0.0	-1	0.46	0.23196	0.77
06/10/2024 14:00	0.6	0.0	0	0.46	0.23142	0.77
06/10/2024 15:00	0.6	0.0	0	0.46	0.23118	0.77
06/10/2024 16:00	0.6	0.0	0	0.46	0.23196	0.77
06/10/2024 17:00	0.7	0.0	0	0.60	0.29856	1.00
06/10/2024 18:00	0.5	0.0	0	0.68	0.33774	1.13
06/10/2024 19:00	0.6	0.0	0	0.67	0.33576	1.12
06/10/2024 20:00	0.7	0.0	0	0.67	0.33462	1.12
06/10/2024 21:00	0.7	0.0	0	0.67	0.33450	1.12
06/10/2024 22:00	0.8	0.0	0	0.67	0.33294	1.11
06/10/2024 23:00	0.8	0.0	0	0.66	0.33186	1.11
Average/Sum#:	0.7	0.0	0	0.52	0.26162	0.87
Minimum:	0.5	0.0	-1	0.46	0.23118	0.77
Maximum:	0.8	0.0	0	0.68	0.33774	1.13
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/11/2024 00:00	0.9	0.0	0	0.66	0.33114	1.10
06/11/2024 01:00	0.9	0.0	0	0.66	0.33126	1.10
06/11/2024 02:00	0.9	0.0	0	0.67	0.33270	1.11
06/11/2024 03:00	0.9	0.0	0	0.66	0.33198	1.11
06/11/2024 04:00	1.0	0.0	0	0.66	0.33054	1.10
06/11/2024 05:00	1.0	0.0	0	0.62	0.31188	1.04
06/11/2024 06:00	0.7	0.0	-1	0.47	0.23544	0.78
06/11/2024 07:00	0.7	0.0	-1	0.47	0.23640	0.79
06/11/2024 08:00	0.7	0.0	-1	0.47	0.23562	0.79
06/11/2024 09:00	0.7	0.0	-1	0.47	0.23466	0.78
06/11/2024 10:00	0.7	0.0	-1	0.47	0.23436	0.78
06/11/2024 11:00	0.7	0.0	-1	0.47	0.23430	0.78
06/11/2024 12:00	0.7	0.0	0	0.47	0.23334	0.78
06/11/2024 13:00	0.7	0.0	0	0.47	0.23358	0.78
06/11/2024 14:00	0.6	0.0	-1	0.47	0.23376	0.78
06/11/2024 15:00	0.7	0.0	-1	0.46	0.23238	0.77
06/11/2024 16:00	0.6	0.0	0	0.58	0.28752	0.96
06/11/2024 17:00	0.4	0.0	0	0.69	0.34296	1.14
06/11/2024 18:00	0.1	0.0	1	0.77	0.38538	1.28
06/11/2024 19:00	0.3	0.0	0	0.70	0.34938	1.16
06/11/2024 20:00	0.5	0.0	0	0.68	0.33858	1.13
06/11/2024 21:00	0.5	0.0	0	0.67	0.33444	1.11
06/11/2024 22:00	0.5	0.0	0	0.67	0.33258	1.11
06/11/2024 23:00	0.6	0.0	0	0.67	0.33354	1.11
Average/Sum#:	0.7	0.0	0	0.59	0.29241	0.97
Minimum:	0.1	0.0	-1	0.46	0.23238	0.77
Maximum:	1.0	0.0	1	0.77	0.38538	1.28
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/12/2024 00:00	0.6	0.0	0	0.67	0.33396	1.11
06/12/2024 01:00	0.6	0.0	0	0.67	0.33390	1.11
06/12/2024 02:00	0.7	0.0	0	0.66	0.33192	1.11
06/12/2024 03:00	0.8	0.0	0	0.66	0.32988	1.10
06/12/2024 04:00	0.8	0.0	0	0.66	0.33036	1.10
06/12/2024 05:00	0.8	0.0	0	0.66	0.33174	1.11
06/12/2024 06:00	0.8	0.0	0	0.53	0.26262	0.88
06/12/2024 07:00	0.7	0.0	0	0.46	0.23088	0.77
06/12/2024 08:00	0.7	0.0	0	0.46	0.23154	0.77
06/12/2024 09:00	0.7	0.0	0	0.47	0.23250	0.78
06/12/2024 10:00	0.7	0.0	0	0.46	0.23136	0.77
06/12/2024 11:00	0.7	0.0	-1	0.46	0.23112	0.77
06/12/2024 12:00	0.0	0.0	0	0.46	0.23112	0.77
06/12/2024 13:00	0.0	0.0	0	0.46	0.23124	0.77
06/12/2024 14:00	0.6	0.0	1	0.46	0.23082	0.77
06/12/2024 15:00	0.6	0.0	0	0.46	0.23094	0.77
06/12/2024 16:00	0.7	0.0	0	0.57	0.28296	0.94
06/12/2024 17:00	0.4	0.0	0	0.69	0.34326	1.14
06/12/2024 18:00	0.4	0.0	0	0.70	0.35058	1.17
06/12/2024 19:00	0.6	0.0	0	0.68	0.33912	1.13
06/12/2024 20:00	0.8	0.0	0	0.66	0.32838	1.09
06/12/2024 21:00	0.8	0.0	0	0.66	0.32874	1.10
06/12/2024 22:00	0.9	0.0	0	0.66	0.32760	1.09
06/12/2024 23:00	0.9	0.0	0	0.66	0.32898	1.10
Average/Sum#:	0.7	0.0	0	0.58	0.29023	0.97
Minimum:	0.4	0.0	-1	0.46	0.23082	0.77
Maximum:	0.9	0.0	1	0.70	0.35058	1.17
%SI	8.33	100.00	8.33	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/13/2024 00:00	0.9	0.0	0	0.66	0.32910	1.10
06/13/2024 01:00	0.9	0.0	0	0.66	0.32868	1.10
06/13/2024 02:00	0.9	0.0	0	0.66	0.32856	1.10
06/13/2024 03:00	1.0	0.0	0	0.66	0.32826	1.09
06/13/2024 04:00	1.0	0.0	0	0.66	0.32784	1.09
06/13/2024 05:00	1.0	0.0	0	0.66	0.32760	1.09
06/13/2024 06:00	0.9	0.0	0	0.53	0.26268	0.88
06/13/2024 07:00	0.8	0.0	0	0.46	0.23184	0.77
06/13/2024 08:00	0.7	0.0	0	0.46	0.23226	0.77
06/13/2024 09:00	0.7	0.0	-1	0.46	0.23220	0.77
06/13/2024 10:00	0.6	0.0	-1	0.47	0.23256	0.78
06/13/2024 11:00	0.6	0.0	-1	0.46	0.23118	0.77
06/13/2024 12:00	0.6	0.0	-1	0.46	0.23070	0.77
06/13/2024 13:00	0.6	0.0	-1	0.47	0.23400	0.78
06/13/2024 14:00	0.8	0.0	0	0.50	0.25176	0.84
06/13/2024 15:00	0.6	0.0	0	0.48	0.24162	0.81
06/13/2024 16:00	0.6	1.2	0	0.47	0.23544	0.78
06/13/2024 17:00	0.6	1.2	-1	0.46	0.23226	0.77
06/13/2024 18:00	0.9	1.3	0	0.56	0.28230	0.94
06/13/2024 19:00	1.0	1.4	0	0.64	0.31812	1.06
06/13/2024 20:00	0.9	1.4	0	0.56	0.27954	0.93
06/13/2024 21:00	0.7	1.4	0	0.49	0.24360	0.81
06/13/2024 22:00	0.7	0.0	0	0.47	0.23424	0.78
06/13/2024 23:00	0.7	0.0	0	0.47	0.23670	0.79
Average/Sum#:	0.8	1.0	0	0.53	0.26721	0.89
Minimum:	0.6	0.0	-1	0.46	0.23070	0.77
Maximum:	1.0	1.4	0	0.66	0.32910	1.10
%SI	0.00	66.67	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/14/2024 00:00	0.7	0.0	0	0.48	0.23760	0.79
06/14/2024 01:00	0.7	0.0	0	0.48	0.23754	0.79
06/14/2024 02:00	0.7	0.0	0	0.47	0.23712	0.79
06/14/2024 03:00	0.7	0.0	0	0.47	0.23532	0.78
06/14/2024 04:00	0.7	0.0	0	0.47	0.23526	0.78
06/14/2024 05:00	0.7	0.0	0	0.47	0.23490	0.78
06/14/2024 06:00	0.7	0.0	0	0.47	0.23526	0.78
06/14/2024 07:00	0.7	0.0	0	0.47	0.23508	0.78
06/14/2024 08:00	0.7	0.0	0	0.47	0.23484	0.78
06/14/2024 09:00	0.6	0.0	-1	0.47	0.23442	0.78
06/14/2024 10:00	0.6	0.0	-1	0.47	0.23502	0.78
06/14/2024 11:00	0.6	0.0	-1	0.47	0.23490	0.78
06/14/2024 12:00	0.6	0.0	-1	0.47	0.23406	0.78
06/14/2024 13:00	0.6	0.0	-1	0.46	0.23166	0.77
06/14/2024 14:00	0.6	0.0	-1	0.46	0.23088	0.77
06/14/2024 15:00	0.6	0.0	-1	0.46	0.23022	0.77
06/14/2024 16:00	0.6	0.0	0	0.34	0.16878	0.56
06/14/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
06/14/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
06/14/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
06/14/2024 20:00	0.0	1.5	0	0.03	0.01704	0.06
06/14/2024 21:00	0.6	1.4	0	0.43	0.21288	0.71
06/14/2024 22:00	0.6	1.4	0	0.46	0.23106	0.77
06/14/2024 23:00	0.6	1.4	0	0.46	0.23100	0.77
Average/Sum#:	0.6	1.2	0	0.44	0.21975	0.73
Minimum:	0.0	0.0	-1	0.03	0.01704	0.06
Maximum:	0.7	1.5	0	0.48	0.23760	0.79
%SI	12.50	66.67	16.67	12.50	12.50	12.50

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/15/2024 00:00	0.6	1.4	0	0.46	0.23112	0.77
06/15/2024 01:00	0.7	1.4	0	0.46	0.23142	0.77
06/15/2024 02:00	0.7	1.5	0	0.48	0.23976	0.80
06/15/2024 03:00	0.7	0.0	0	0.47	0.23358	0.78
06/15/2024 04:00	0.7	0.0	0	0.47	0.23442	0.78
06/15/2024 05:00	0.7	0.0	0	0.47	0.23472	0.78
06/15/2024 06:00	0.7	0.0	0	0.47	0.23460	0.78
06/15/2024 07:00	0.7	0.0	0	0.47	0.23496	0.78
06/15/2024 08:00	0.7	0.0	0	0.47	0.23562	0.79
06/15/2024 09:00	0.7	0.0	0	0.47	0.23652	0.79
06/15/2024 10:00	0.6	0.0	0	0.47	0.23490	0.78
06/15/2024 11:00	0.6	0.0	0	0.47	0.23376	0.78
06/15/2024 12:00	0.6	0.0	0	0.47	0.23358	0.78
06/15/2024 13:00	0.6	0.0	0	0.47	0.23322	0.78
06/15/2024 14:00	0.7	0.0	0	0.47	0.23250	0.78
06/15/2024 15:00	0.7	0.0	0	0.46	0.23220	0.77
06/15/2024 16:00	0.7	0.0	0	0.46	0.23184	0.77
06/15/2024 17:00	0.7	0.0	0	0.46	0.23136	0.77
06/15/2024 18:00	0.7	0.0	0	0.53	0.26658	0.89
06/15/2024 19:00	0.8	0.0	0	0.51	0.25494	0.85
06/15/2024 20:00	1.1	0.0	0	0.49	0.24588	0.82
06/15/2024 21:00	1.1	0.0	0	0.47	0.23418	0.78
06/15/2024 22:00	1.2	0.0	0	0.47	0.23490	0.78
06/15/2024 23:00	1.2	0.0	0	0.47	0.23640	0.79
Average/Sum#:	0.8	1.4	0	0.47	0.23679	0.79
Minimum:	0.6	1.4	0	0.46	0.23112	0.77
Maximum:	1.2	1.5	0	0.53	0.26658	0.89
%SI	0.00	87.50	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/16/2024 00:00	0.8	0.0	0	0.57	0.28602	0.95
06/16/2024 01:00	1.2	0.0	0	0.47	0.23346	0.78
06/16/2024 02:00	1.2	0.0	0	0.47	0.23418	0.78
06/16/2024 03:00	1.2	0.0	0	0.47	0.23574	0.79
06/16/2024 04:00	1.2	0.0	0	0.47	0.23610	0.79
06/16/2024 05:00	1.1	0.0	0	0.47	0.23586	0.79
06/16/2024 06:00	1.0	0.0	0	0.47	0.23508	0.78
06/16/2024 07:00	0.9	0.0	0	0.47	0.23472	0.78
06/16/2024 08:00	0.8	0.0	0	0.47	0.23424	0.78
06/16/2024 09:00	0.8	0.0	0	0.47	0.23508	0.78
06/16/2024 10:00	0.7	0.0	0	0.47	0.23316	0.78
06/16/2024 11:00	0.7	0.0	0	0.47	0.23274	0.78
06/16/2024 12:00	0.7	0.0	0	0.46	0.23214	0.77
06/16/2024 13:00	0.7	0.0	0	0.46	0.23178	0.77
06/16/2024 14:00	0.7	0.0	0	0.46	0.23190	0.77
06/16/2024 15:00	0.7	0.0	0	0.46	0.23190	0.77
06/16/2024 16:00	0.7	0.0	0	0.47	0.23274	0.78
06/16/2024 17:00	0.9	0.0	0	0.51	0.25518	0.85
06/16/2024 18:00	0.7	0.0	0	0.58	0.28896	0.96
06/16/2024 19:00	1.9	0.0	0	0.53	0.26742	0.89
06/16/2024 20:00	0.9	0.0	0	0.49	0.24552	0.82
06/16/2024 21:00	1.2	0.0	0	0.47	0.23316	0.78
06/16/2024 22:00	2.1	0.0	0	0.47	0.23304	0.78
06/16/2024 23:00	1.3	0.0	0	0.47	0.23298	0.78
Average/Sum#:	1.0	0.0	0	0.48	0.24096	0.80
Minimum:	0.7	0.0	0	0.46	0.23178	0.77
Maximum:	2.1	0.0	0	0.58	0.28896	0.96
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/17/2024 00:00	1.5	0.0	0	0.47	0.23298	0.78
06/17/2024 01:00	2.0	0.0	0	0.56	0.28236	0.94
06/17/2024 02:00	1.7	0.0	0	0.52	0.25854	0.86
06/17/2024 03:00	1.5	0.0	0	0.51	0.25344	0.84
06/17/2024 04:00	1.4	0.0	0	0.53	0.26724	0.89
06/17/2024 05:00	1.4	0.0	0	0.52	0.26196	0.87
06/17/2024 06:00	3.6	0.0	0	0.47	0.23460	0.78
06/17/2024 07:00	3.3	0.0	0	0.47	0.23400	0.78
06/17/2024 08:00	2.2	0.0	0	0.47	0.23472	0.78
06/17/2024 09:00	1.6	0.0	0	0.47	0.23556	0.79
06/17/2024 10:00	1.6	0.0	0	0.47	0.23508	0.78
06/17/2024 11:00	1.6	0.0	0	0.47	0.23418	0.78
06/17/2024 12:00	1.1	0.0	0	0.47	0.23388	0.78
06/17/2024 13:00	1.0	0.0	0	0.47	0.23352	0.78
06/17/2024 14:00	1.0	0.0	0	0.47	0.23328	0.78
06/17/2024 15:00	1.2	0.0	0	0.47	0.23256	0.78
06/17/2024 16:00	1.4	0.0	0	0.47	0.23274	0.78
06/17/2024 17:00	5.5	0.0	0	0.51	0.25296	0.84
06/17/2024 18:00	0.7	0.0	0	0.59	0.29304	0.98
06/17/2024 19:00	0.7	0.0	0	0.58	0.29142	0.97
06/17/2024 20:00	0.7	0.0	0	0.58	0.29088	0.97
06/17/2024 21:00	0.8	0.0	0	0.57	0.28356	0.95
06/17/2024 22:00	1.2	0.0	0	0.52	0.26154	0.87
06/17/2024 23:00	1.3	0.0	0	0.52	0.25956	0.87
Average/Sum#:	1.7	0.0	0	0.51	0.25265	0.84
Minimum:	0.7	0.0	0	0.47	0.23256	0.78
Maximum:	5.5	0.0	0	0.59	0.29304	0.98
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/18/2024 00:00	1.2	0.0	0	0.52	0.25968	0.87
06/18/2024 01:00	1.3	0.0	0	0.52	0.25920	0.86
06/18/2024 02:00	1.3	0.0	0	0.52	0.25920	0.86
06/18/2024 03:00	1.2	0.0	0	0.52	0.25902	0.86
06/18/2024 04:00	1.2	0.0	0	0.53	0.26412	0.88
06/18/2024 05:00	1.2	0.0	0	0.55	0.27318	0.91
06/18/2024 06:00	4.8	0.0	0	0.47	0.23652	0.79
06/18/2024 07:00	4.1	0.0	0	0.48	0.24240	0.81
06/18/2024 08:00	0.9	0.0	0	0.52	0.25980	0.87
06/18/2024 09:00	0.8	0.0	0	0.52	0.25878	0.86
06/18/2024 10:00	0.8	0.0	0	0.51	0.25746	0.86
06/18/2024 11:00	0.8	0.0	0	0.51	0.25704	0.86
06/18/2024 12:00	0.8	0.0	0	0.52	0.25782	0.86
06/18/2024 13:00	0.8	0.0	0	0.52	0.25782	0.86
06/18/2024 14:00	0.0	0.0	0	0.52	0.25776	0.86
06/18/2024 15:00	0.8	0.0	0	0.52	0.25770	0.86
06/18/2024 16:00	0.8	0.0	0	0.51	0.25698	0.86
06/18/2024 17:00	0.8	0.0	0	0.52	0.25956	0.87
06/18/2024 18:00	3.7	0.0	0	0.57	0.28290	0.94
06/18/2024 19:00	1.7	0.0	0	0.52	0.25800	0.86
06/18/2024 20:00	0.9	0.0	0	0.51	0.25692	0.86
06/18/2024 21:00	0.9	0.0	0	0.51	0.25722	0.86
06/18/2024 22:00	1.0	0.0	0	0.51	0.25704	0.86
06/18/2024 23:00	1.6	0.0	0	0.51	0.25704	0.86
Average/Sum#:	1.5	0.0	0	0.52	0.25847	0.86
Minimum:	0.8	0.0	0	0.47	0.23652	0.79
Maximum:	4.8	0.0	0	0.57	0.28290	0.94
%SI	4.17	100.00	4.17	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/19/2024 00:00	1.6	0.0	0	0.51	0.25656	0.86
06/19/2024 01:00	1.5	0.0	0	0.51	0.25668	0.86
06/19/2024 02:00	1.6	0.0	0	0.51	0.25626	0.85
06/19/2024 03:00	1.5	0.0	0	0.52	0.25848	0.86
06/19/2024 04:00	1.5	0.0	0	0.52	0.25932	0.86
06/19/2024 05:00	1.5	0.0	0	0.52	0.25956	0.87
06/19/2024 06:00	1.3	0.0	0	0.52	0.25944	0.86
06/19/2024 07:00	1.0	0.0	0	0.53	0.26298	0.88
06/19/2024 08:00	3.1	0.0	0	0.53	0.26430	0.88
06/19/2024 09:00	4.5	1.4	0	0.44	0.21942	0.73
06/19/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
06/19/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
06/19/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
06/19/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
06/19/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
06/19/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	1.9	1.3	0	0.51	0.25530	0.85
Minimum:	1.0	0.0	0	0.44	0.21942	0.73
Maximum:	4.5	1.5	0	0.53	0.26430	0.88
%SI	58.33	33.33	58.33	58.33	58.33	58.33

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/20/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
06/20/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
06/20/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
06/20/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
06/20/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
06/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
06/20/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/21/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
06/21/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
06/21/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
06/21/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
06/21/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
06/21/2024 10:00	0.0	1.3	0	0.37	0.18264	0.61
06/21/2024 11:00	0.7	1.4	0	0.46	0.23034	0.77
06/21/2024 12:00	0.7	1.3	-1	0.46	0.22944	0.76
06/21/2024 13:00	0.7	1.3	-1	0.46	0.22920	0.76
06/21/2024 14:00	0.7	1.2	-1	0.46	0.22896	0.76
06/21/2024 15:00	0.7	1.3	-1	0.46	0.22884	0.76
06/21/2024 16:00	0.7	1.2	-1	0.47	0.23358	0.78
06/21/2024 17:00	0.7	1.3	0	0.51	0.25662	0.86
06/21/2024 18:00	0.6	1.4	0	0.57	0.28452	0.95
06/21/2024 19:00	0.6	1.3	0	0.57	0.28446	0.95
06/21/2024 20:00	0.6	1.3	0	0.57	0.28440	0.95
06/21/2024 21:00	0.7	1.4	0	0.57	0.28632	0.95
06/21/2024 22:00	0.6	1.3	0	0.58	0.28806	0.96
06/21/2024 23:00	0.7	1.3	0	0.55	0.27672	0.92
Average/Sum#:	0.6	1.4	0	0.50	0.25172	0.84
Minimum:	0.0	1.2	-1	0.37	0.18264	0.61
Maximum:	0.7	1.5	0	0.58	0.28806	0.96
%SI	41.67	0.00	45.83	41.67	41.67	41.67

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/22/2024 00:00	0.7	1.3	-1	0.41	0.20460	0.68
06/22/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
06/22/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 09:00	0.0	1.2	0	0.00	0.00000	0.00
06/22/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
06/22/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
06/22/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.4	-1	0.41	0.20460	0.68
Minimum:	0.7	1.2	-1	0.41	0.20460	0.68
Maximum:	0.7	1.5	-1	0.41	0.20460	0.68
%SI	95.83	0.00	95.83	95.83	95.83	95.83

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/23/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 02:00	0.0	1.2	0	0.00	0.00000	0.00
06/23/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
06/23/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
06/23/2024 17:00	0.0	1.3	0	0.05	0.02730	0.09
06/23/2024 18:00	0.6	1.4	0	0.49	0.24438	0.81
06/23/2024 19:00	0.6	1.3	0	0.57	0.28368	0.95
06/23/2024 20:00	0.6	1.4	0	0.57	0.28464	0.95
06/23/2024 21:00	0.6	1.3	0	0.57	0.28476	0.95
06/23/2024 22:00	0.7	1.3	0	0.53	0.26658	0.89
06/23/2024 23:00	0.7	1.4	0	0.50	0.25020	0.83
Average/Sum#:	0.5	1.3	0	0.47	0.23451	0.78
Minimum:	0.0	1.2	0	0.05	0.02730	0.09
Maximum:	0.7	1.4	0	0.57	0.28476	0.95
%SI	70.83	0.00	75.00	70.83	70.83	70.83

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/24/2024 00:00	0.7	1.4	0	0.46	0.23028	0.77
06/24/2024 01:00	0.7	1.4	0	0.46	0.23034	0.77
06/24/2024 02:00	0.7	1.3	0	0.47	0.23484	0.78
06/24/2024 03:00	0.7	1.4	0	0.46	0.23160	0.77
06/24/2024 04:00	0.7	1.4	0	0.53	0.26370	0.88
06/24/2024 05:00	0.7	1.3	0	0.54	0.26772	0.89
06/24/2024 06:00	0.7	1.4	0	0.49	0.24426	0.81
06/24/2024 07:00	0.7	0.0	0	0.47	0.23430	0.78
06/24/2024 08:00	0.7	0.0	0	0.47	0.23358	0.78
06/24/2024 09:00	0.7	0.0	0	0.47	0.23592	0.79
06/24/2024 10:00	0.7	0.0	0	0.52	0.25764	0.86
06/24/2024 11:00	0.6	0.0	0	0.56	0.28194	0.94
06/24/2024 12:00	0.7	0.0	0	0.56	0.28152	0.94
06/24/2024 13:00	0.6	0.0	0	0.57	0.28494	0.95
06/24/2024 14:00	0.7	0.0	0	0.57	0.28698	0.96
06/24/2024 15:00	0.7	0.0	0	0.57	0.28662	0.96
06/24/2024 16:00	0.7	0.0	0	0.57	0.28668	0.96
06/24/2024 17:00	0.7	0.0	0	0.55	0.27738	0.92
06/24/2024 18:00	0.7	0.0	0	0.58	0.28902	0.96
06/24/2024 19:00	0.6	0.0	0	0.54	0.27012	0.90
06/24/2024 20:00	0.7	1.4	0	0.53	0.26736	0.89
06/24/2024 21:00	0.7	1.4	0	0.58	0.28830	0.96
06/24/2024 22:00	0.6	1.4	0	0.57	0.28728	0.96
06/24/2024 23:00	0.6	1.4	0	0.58	0.28830	0.96
Average/Sum#:	0.7	1.0	0	0.53	0.26419	0.88
Minimum:	0.6	0.0	0	0.46	0.23028	0.77
Maximum:	0.7	1.4	0	0.58	0.28902	0.96
%SI	0.00	37.50	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/25/2024 00:00	0.7	1.4	0	0.58	0.28794	0.96
06/25/2024 01:00	0.6	1.4	0	0.58	0.28842	0.96
06/25/2024 02:00	0.6	1.3	0	0.57	0.28668	0.96
06/25/2024 03:00	0.7	1.3	0	0.57	0.28362	0.95
06/25/2024 04:00	0.7	1.4	0	0.57	0.28422	0.95
06/25/2024 05:00	0.7	1.4	0	0.56	0.28014	0.93
06/25/2024 06:00	0.7	1.4	0	0.51	0.25344	0.84
06/25/2024 07:00	0.7	1.4	0	0.46	0.23190	0.77
06/25/2024 08:00	0.7	1.3	0	0.54	0.27150	0.91
06/25/2024 09:00	0.6	1.4	0	0.57	0.28614	0.95
06/25/2024 10:00	0.7	1.4	0	0.58	0.29112	0.97
06/25/2024 11:00	0.6	1.4	0	0.58	0.29100	0.97
06/25/2024 12:00	0.6	1.3	0	0.58	0.28878	0.96
06/25/2024 13:00	0.6	1.4	0	0.58	0.28758	0.96
06/25/2024 14:00	0.7	1.4	0	0.58	0.28758	0.96
06/25/2024 15:00	0.7	1.3	0	0.54	0.26754	0.89
06/25/2024 16:00	0.7	1.4	0	0.56	0.28212	0.94
06/25/2024 17:00	0.8	1.3	0	0.58	0.28914	0.96
06/25/2024 18:00	0.3	1.5	1	0.80	0.39816	1.33
06/25/2024 19:00	0.2	1.5	2	0.82	0.40848	1.36
06/25/2024 20:00	0.2	1.5	1	0.78	0.39120	1.30
06/25/2024 21:00	0.3	1.5	1	0.76	0.37920	1.26
06/25/2024 22:00	0.7	1.4	0	0.64	0.32226	1.07
06/25/2024 23:00	0.7	1.3	0	0.51	0.25512	0.85
Average/Sum#:	0.6	1.4	0	0.60	0.29972	1.00
Minimum:	0.2	1.3	0	0.46	0.23190	0.77
Maximum:	0.8	1.5	2	0.82	0.40848	1.36
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/26/2024 00:00	0.7	1.3	0	0.49	0.24672	0.82
06/26/2024 01:00	0.7	1.3	0	0.53	0.26346	0.88
06/26/2024 02:00	0.7	1.1	0	0.50	0.25116	0.84
06/26/2024 03:00	0.7	1.5	0	0.56	0.27810	0.93
06/26/2024 04:00	0.7	1.4	0	0.59	0.29370	0.98
06/26/2024 05:00	0.8	1.4	0	0.51	0.25296	0.84
06/26/2024 06:00	0.8	1.4	0	0.46	0.23208	0.77
06/26/2024 07:00	0.8	1.4	0	0.46	0.23202	0.77
06/26/2024 08:00	0.8	1.4	0	0.46	0.23178	0.77
06/26/2024 09:00	0.7	1.4	0	0.46	0.23136	0.77
06/26/2024 10:00	0.7	1.4	0	0.46	0.23070	0.77
06/26/2024 11:00	0.7	1.3	-1	0.46	0.23022	0.77
06/26/2024 12:00	0.7	1.3	-1	0.46	0.23010	0.77
06/26/2024 13:00	0.7	1.3	-1	0.46	0.22986	0.77
06/26/2024 14:00	0.7	1.3	-1	0.46	0.22980	0.77
06/26/2024 15:00	0.7	1.3	-1	0.46	0.22980	0.77
06/26/2024 16:00	0.7	1.2	-1	0.46	0.22974	0.77
06/26/2024 17:00	0.7	1.3	-1	0.47	0.23544	0.78
06/26/2024 18:00	0.7	1.4	0	0.51	0.25578	0.85
06/26/2024 19:00	0.7	1.4	-1	0.47	0.23442	0.78
06/26/2024 20:00	0.8	1.4	0	0.46	0.23130	0.77
06/26/2024 21:00	0.7	1.4	0	0.46	0.23124	0.77
06/26/2024 22:00	0.7	1.4	0	0.46	0.23166	0.77
06/26/2024 23:00	0.7	1.4	0	0.46	0.23196	0.77
Average/Sum#:	0.7	1.4	0	0.48	0.24064	0.80
Minimum:	0.7	1.1	-1	0.46	0.22974	0.77
Maximum:	0.8	1.5	0	0.59	0.29370	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/27/2024 00:00	0.7	1.4	0	0.46	0.23184	0.77
06/27/2024 01:00	0.8	1.4	0	0.46	0.23220	0.77
06/27/2024 02:00	0.8	1.5	0	0.46	0.23220	0.77
06/27/2024 03:00	0.8	1.4	0	0.47	0.23250	0.78
06/27/2024 04:00	0.8	1.4	0	0.47	0.23292	0.78
06/27/2024 05:00	0.8	1.4	0	0.47	0.23286	0.78
06/27/2024 06:00	0.8	1.4	0	0.47	0.23274	0.78
06/27/2024 07:00	0.8	1.4	0	0.47	0.23256	0.78
06/27/2024 08:00	0.8	1.4	0	0.46	0.23232	0.77
06/27/2024 09:00	0.8	1.4	0	0.46	0.23232	0.77
06/27/2024 10:00	0.7	1.4	0	0.46	0.23154	0.77
06/27/2024 11:00	0.7	1.4	-1	0.46	0.23136	0.77
06/27/2024 12:00	0.7	1.4	-1	0.46	0.23112	0.77
06/27/2024 13:00	0.7	1.3	-1	0.46	0.23088	0.77
06/27/2024 14:00	0.7	1.4	-1	0.46	0.23058	0.77
06/27/2024 15:00	0.7	1.3	-1	0.46	0.23034	0.77
06/27/2024 16:00	0.7	1.3	-1	0.46	0.23022	0.77
06/27/2024 17:00	0.7	1.3	-1	0.47	0.23286	0.78
06/27/2024 18:00	0.7	1.4	0	0.51	0.25746	0.86
06/27/2024 19:00	0.8	1.4	-1	0.47	0.23310	0.78
06/27/2024 20:00	0.7	1.4	-1	0.46	0.23112	0.77
06/27/2024 21:00	0.8	1.4	0	0.46	0.23118	0.77
06/27/2024 22:00	0.8	1.4	0	0.46	0.23124	0.77
06/27/2024 23:00	0.8	1.4	0	0.46	0.23142	0.77
Average/Sum#:	0.8	1.4	0	0.47	0.23287	0.78
Minimum:	0.7	1.3	-1	0.46	0.23022	0.77
Maximum:	0.8	1.5	0	0.51	0.25746	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/28/2024 00:00	0.8	1.4	0	0.46	0.23142	0.77
06/28/2024 01:00	0.8	1.4	0	0.46	0.23160	0.77
06/28/2024 02:00	0.8	1.4	0	0.46	0.23154	0.77
06/28/2024 03:00	0.9	1.4	0	0.46	0.23166	0.77
06/28/2024 04:00	0.8	1.4	0	0.46	0.23196	0.77
06/28/2024 05:00	0.8	1.4	0	0.46	0.23202	0.77
06/28/2024 06:00	0.9	1.4	0	0.46	0.23196	0.77
06/28/2024 07:00	0.8	1.4	0	0.46	0.23172	0.77
06/28/2024 08:00	0.8	1.4	0	0.46	0.23112	0.77
06/28/2024 09:00	0.8	1.4	-1	0.46	0.23088	0.77
06/28/2024 10:00	0.8	1.4	-1	0.46	0.23058	0.77
06/28/2024 11:00	0.7	1.4	-1	0.46	0.23022	0.77
06/28/2024 12:00	0.8	1.3	-1	0.46	0.22986	0.77
06/28/2024 13:00	0.7	1.3	-1	0.46	0.22926	0.76
06/28/2024 14:00	0.7	1.3	-1	0.46	0.22878	0.76
06/28/2024 15:00	0.7	1.3	-1	0.46	0.22860	0.76
06/28/2024 16:00	0.7	1.3	-1	0.46	0.22866	0.76
06/28/2024 17:00	0.7	1.3	-1	0.46	0.23244	0.77
06/28/2024 18:00	0.7	1.4	0	0.46	0.23046	0.77
06/28/2024 19:00	0.7	1.4	0	0.46	0.22986	0.77
06/28/2024 20:00	0.8	1.4	-1	0.46	0.22854	0.76
06/28/2024 21:00	0.8	1.4	-1	0.46	0.22830	0.76
06/28/2024 22:00	0.8	1.4	-1	0.46	0.22830	0.76
06/28/2024 23:00	0.8	1.4	0	0.46	0.22854	0.76
Average/Sum#:	0.8	1.4	-1	0.46	0.23035	0.77
Minimum:	0.7	1.3	-1	0.46	0.22830	0.76
Maximum:	0.9	1.4	0	0.46	0.23244	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/29/2024 00:00	0.8	1.4	0	0.46	0.22866	0.76
06/29/2024 01:00	0.8	1.4	0	0.46	0.22890	0.76
06/29/2024 02:00	0.8	1.3	0	0.46	0.22908	0.76
06/29/2024 03:00	0.9	1.4	0	0.46	0.22944	0.76
06/29/2024 04:00	0.8	1.4	0	0.46	0.22992	0.77
06/29/2024 05:00	0.8	1.4	0	0.46	0.23010	0.77
06/29/2024 06:00	0.8	1.4	0	0.46	0.23004	0.77
06/29/2024 07:00	0.8	1.3	0	0.46	0.22968	0.77
06/29/2024 08:00	0.8	1.4	-1	0.46	0.22944	0.76
06/29/2024 09:00	0.7	1.4	-1	0.46	0.22902	0.76
06/29/2024 10:00	0.7	1.4	-1	0.46	0.22884	0.76
06/29/2024 11:00	0.7	1.3	-1	0.46	0.22854	0.76
06/29/2024 12:00	0.7	1.3	-1	0.46	0.22818	0.76
06/29/2024 13:00	0.7	1.3	-1	0.46	0.22806	0.76
06/29/2024 14:00	0.7	1.2	-1	0.46	0.22800	0.76
06/29/2024 15:00	0.7	1.3	-1	0.45	0.22746	0.76
06/29/2024 16:00	0.7	1.3	-1	0.45	0.22680	0.76
06/29/2024 17:00	0.7	1.3	-1	0.47	0.23286	0.78
06/29/2024 18:00	0.8	1.3	0	0.48	0.23868	0.80
06/29/2024 19:00	0.7	1.3	-1	0.46	0.22758	0.76
06/29/2024 20:00	0.8	1.4	-1	0.46	0.22788	0.76
06/29/2024 21:00	0.8	1.4	-1	0.46	0.22776	0.76
06/29/2024 22:00	0.8	1.4	-1	0.46	0.22788	0.76
06/29/2024 23:00	0.8	1.4	0	0.46	0.22812	0.76
Average/Sum#:	0.8	1.4	-1	0.46	0.22921	0.76
Minimum:	0.7	1.2	-1	0.45	0.22680	0.76
Maximum:	0.9	1.4	0	0.48	0.23868	0.80
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 03:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/30/2024 00:00	0.8	1.4	0	0.46	0.22824	0.76
06/30/2024 01:00	0.8	1.4	0	0.46	0.22866	0.76
06/30/2024 02:00	0.9	1.4	-1	0.46	0.22860	0.76
06/30/2024 03:00	1.0	1.4	-1	0.46	0.22884	0.76
06/30/2024 04:00	0.9	1.4	0	0.46	0.22872	0.76
06/30/2024 05:00	0.9	1.4	0	0.46	0.22890	0.76
06/30/2024 06:00	0.9	1.3	-1	0.46	0.22908	0.76
06/30/2024 07:00	0.8	1.4	-1	0.46	0.22878	0.76
06/30/2024 08:00	0.8	1.4	-1	0.46	0.22842	0.76
06/30/2024 09:00	0.8	1.4	-1	0.46	0.22818	0.76
06/30/2024 10:00	0.8	1.3	-1	0.46	0.22794	0.76
06/30/2024 11:00	0.7	1.3	-1	0.46	0.22776	0.76
06/30/2024 12:00	0.8	1.2	-1	0.46	0.22770	0.76
06/30/2024 13:00	0.7	1.3	-1	0.45	0.22740	0.76
06/30/2024 14:00	0.7	1.4	-1	0.45	0.22734	0.76
06/30/2024 15:00	0.7	1.3	-1	0.45	0.22716	0.76
06/30/2024 16:00	0.7	1.3	-1	0.45	0.22686	0.76
06/30/2024 17:00	0.7	1.3	-1	0.45	0.22668	0.76
06/30/2024 18:00	0.7	1.2	0	0.45	0.22716	0.76
06/30/2024 19:00	0.7	1.3	-1	0.45	0.22740	0.76
06/30/2024 20:00	0.8	1.4	-1	0.46	0.22800	0.76
06/30/2024 21:00	0.8	1.4	-1	0.46	0.22788	0.76
06/30/2024 22:00	0.8	1.4	-1	0.46	0.22806	0.76
06/30/2024 23:00	0.8	1.4	0	0.46	0.22836	0.76
Average/Sum#:	0.8	1.4	-1	0.46	0.22801	0.76
Minimum:	0.7	1.2	-1	0.45	0.22668	0.76
Maximum:	1.0	1.4	0	0.46	0.22908	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

CT1 SUSD EVENT 1

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/04/24 4:22	0			0			0			1.61			0			0	
04/04/24 4:23	0			0			0			1.61			0			0	
04/04/24 4:24	0			0			0			1.61			0			0	
04/04/24 4:25	0			0			0			1.61			0			0	
04/04/24 4:26	0			0			0			1.61			0			0	
04/04/24 4:27	0			11.8			0			1.61			0			1	
04/04/24 4:28	2200.7			11.8			0			1.67			0			1	
04/04/24 4:29	21146.7			1072.8			5.9			200.04			1.81			1	
04/04/24 4:30	39873.1			1146.4			8.85			264.33			3.36			1	
04/04/24 4:31	55191.6			729.1			15.53			194.38			6.81			1	
04/04/24 4:32	83864.6			462.4			20.79			154.55			11.44			1	
04/04/24 4:33	130022.2			327.6			25.14			145.11			18.33			1	
04/04/24 4:34	141233.8			233.2			35.18			109.45			27.18			1	
04/04/24 4:35	150238.9			969.7			39.87			475.61			32.18			1	
04/04/24 4:36	166614.4			1843.8			37.66			975.66			32.79			1	
04/04/24 4:37	187934.4			1694.3			44.17			981.51			42.11			1	
04/04/24 4:38	211247.1			849.5			53.94			538.69			56.3			1	
04/04/24 4:39	232076.1			70			57.87			47.85			65.07			1	
04/04/24 4:40	255562.1			8.5			63.68			6.25			77.39			1	
04/04/24 4:41	280440.2			6.1			89.31			4.87			117.17			1	
04/04/24 4:42	305220.1			5.9			59.37			5.05			83.58			1	
04/04/24 4:43	325742.9			6			30.53			5.41			45.4			1	
04/04/24 4:44	342586.3			6.2			17.78			5.88			27.61			1	
04/04/24 4:45	348986.3			6.7			15.37			6.45			24.25			1	
04/04/24 4:46	349731.4			8.2			14.54			7.9			22.98			1	
04/04/24 4:47	349858.5			12.4			13.38			11.89			21.15			1	
04/04/24 4:48	349558.2			14.9			12.55			14.28			19.82			1	
04/04/24 4:49	349477.3			15.3			11.63			14.67			18.37			1	
04/04/24 4:50	351475.9			11.8			10.7			11.38			16.99			1	
04/04/24 4:51	360146			8.6			9.44			8.47			15.3			1	
04/04/24 4:52	362883.9			8			8.47			7.97			13.81			1	
04/04/24 4:53	364212.4			7.5			8.21			7.48			13.43			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/04/24 4:54	364495.4			6.1			7.35			6.04			12.04			1	
04/04/24 4:55	365748.8			5			7.29			5.02			11.97			1	
04/04/24 4:56	366597.9			4.3			6.51			4.25			10.71			1	
04/04/24 4:57	367372			3.6			6.42			3.56			10.58			1	
04/04/24 4:58	367060			3.1			5.99			3.13			9.86			1	
04/04/24 4:59	363975.5			2.8			6.16			2.8			10.07			1	
04/04/24 5:00	362612.4			2.7			6.16			2.66			10.04			1	
04/04/24 5:01	360712			2.6			5.99			2.57			9.72			1	
04/04/24 5:02	358759.7			2.5			5.9			2.47			9.53			1	
04/04/24 5:03	357916.3			2.2			5.9			2.18			9.51			1	
04/04/24 5:04	355894.7			2.1			6.07			2.03			9.74			1	
04/04/24 5:05	357517.8			1.9			6.16			1.87			9.92			1	
04/04/24 5:06	359759			1.7			6.16			1.71			9.97			1	
04/04/24 5:07	360556.1			1.6			6.16			1.62			9.99			1	
04/04/24 5:08	362133			1.6			6.25			1.55			10.17			1	
04/04/24 5:09	363080.3			1.6			6.33			1.55			10.33			1	
04/04/24 5:10	363305.5			1.6			6.33			1.55			10.34			1	
04/04/24 5:11	364795.8			1.6			6.42			1.55			10.52			1	
04/04/24 5:12	365257.9			1.6			6.59			1.56			10.82			1	
04/04/24 5:13	361948.1			1.6			7.2			1.54			11.72			1	
04/04/24 5:14	361052.8			1.6			7.2			1.54			11.69			1	
04/04/24 5:15	360359.7			1.5			7.2			1.45			11.68			1	
04/04/24 5:16	359291.1			1.5			7.2			1.45			11.65			1	
04/04/24 5:17	357968.3			1.5			7.29			1.44			11.75			1	
04/04/24 5:18	357327.1			1.5			7.46			1.44			12.01			1	
04/04/24 5:19	357471.6			1.6			7.64			1.53			12.29			1	
04/04/24 5:20	355663.6			1.5			7.64			1.44			12.24			1	
04/04/24 5:21	355028.3			1.5			7.72			1.43			12.36			1	
04/04/24 5:22	358026.1			1.5			7.38			1.45			11.89			1	
04/04/24 5:23	366592.2			1.5			7.55			1.47			12.42			1	
04/04/24 5:24	383487.5			1.5			6.77			1.53			11.58			1	
04/04/24 5:25	392579.3			1.4			5.63			1.52			9.83			1	
04/04/24 5:26	395721.5			1.3			5.63			1.43			9.9			1	
04/04/24 5:27	396686.2			1.2			5.72			1.32			10.09			1	
04/04/24 5:28	405079			1.2			5.9			1.34			10.59			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/04/24 5:29	421529.6			1.2			5.55			1.39			10.31			1	
04/04/24 5:30	430540.5			1.2			5.54			1.36			10.48			1	
04/04/24 5:31	433884.9			1.2			6.17			1.35			11.76			1	
04/04/24 5:32	434872.6			1.2			6.26			1.35			11.95			1	
04/04/24 5:33	435097.9			1.2			6.44			1.35			12.3			1	
04/04/24 5:34	436449.5			1.2			6.62			1.35			12.67			1	
04/04/24 5:35	437460.3			1.2			6.7			1.36			12.87			1	
04/04/24 5:36	438124.6			1.2			6.7			1.36			12.89			1	
04/04/24 5:37	438523.2			1.2			6.79			1.36			13.07			1	
04/04/24 5:38	438656			1.1			6.88			1.25			13.25			1	
04/04/24 5:39	438656			1.1			6.97			1.25			13.42			1	
04/04/24 5:40	436438			1.1			7.24			1.25			13.87			1	
04/04/24 5:41	434993.9			1.1			7.22			1.23			13.8			1	
04/04/24 5:42	433122.4			1.1			7.13			1.22			13.57			1	
04/04/24 5:43	432019.1			1.1			6.87			1.22			13.04			1	
04/04/24 5:44	431551.3			1.1			5.37			1.22			10.19			1	
04/04/24 5:45	431378			1.1			4.14			1.22			7.85			1	
04/04/24 5:46	430921.7			1.1			3.79			1.22			7.17			1	
04/04/24 5:47	433232.2			1.1			3.04			1.24			5.79			1	
04/04/24 5:48	434404.8			1.1			2.95			1.24			5.63			1	
04/04/24 5:49	436149.1			1			2.95			1.14			5.65			1	
04/04/24 5:50	437512.4			1.1			2.77			1.25			5.32			1	
04/04/24 5:51	439661.1			1.1			2.68			1.26			5.17			1	
04/04/24 5:52	439973			1			2.59			1.15			5			1	
04/04/24 5:53	436588.1			1			2.5			1.15			4.8			1	
04/04/24 5:54	434936.1			1			2.03			1.12			3.87			1	
04/04/24 5:55	432879.8			1			1.52			1.14			2.89			1	
04/04/24 5:56	431811.2			1			1.43			1.13			2.71			1	
04/04/24 5:57	429841.5			1			1.23			1.11			2.33			1	
04/04/24 5:58	428674.8			1.1			1.06			1.21			1.99			1	
04/04/24 5:59	427120.9			1.1			0.88			1.21			1.66			1	
04/04/24 6:00	430760			1			0.8			1.13			1.52			1	
04/04/24 6:01	432053.8			1			0.72			1.13			1.36			1	
04/04/24 6:02	432406.2			1			0.63			1.14			1.19			1	
04/04/24 6:03	432954.9			1			0.62			1.12			1.17			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/04/24 6:04	433157			1			0.8			1.14			1.53			1	
04/04/24 6:05	434872.6			1			0.88			1.12			1.68			0	
04/04/24 6:06	435450.2			1			0.72			1.14			1.37			0	
04/04/24 6:07	435941.2			1			0.72			1.14			1.37			0	
04/04/24 6:08	436374.4			1			0.72			1.14			1.37			0	
04/04/24 6:09	438153.5			1			0.72			1.15			1.37			0	

CT1 SUSD EVENT 2

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/23/24	354901.1			0.9			1.27			0.87			2.01			0	
05/23/24	344400			0.8			1.36			0.77			2.1			0	
05/23/24	341581.3			0.8			1.34			0.75			2.05			0	
05/23/24	340951.6			0.7			1.18			0.67			1.8			0	
05/23/24	340703.3			0.7			1.09			0.67			1.66			0	
05/23/24	340645.5			0.7			1			0.67			1.52			1	
05/23/24	335493.1			0.7			1.09			0.66			1.64			1	
05/23/24	316166			0.7			1.09			0.63			1.56			1	
05/23/24	294083.6			0.7			1.27			0.59			1.71			1	
05/23/24	271862.5			0.7			1.75			0.57			2.21			1	
05/23/24	251172.2			0.7			2			0.48			2.36			1	
05/23/24	228593			0.6			4.26			0.39			4.66			1	
05/23/24	206031.2			0.4			14.08			0.25			14.2			1	
05/23/24	181182			1.2			21.63			0.64			19.76			1	
05/23/24	161184.8			61.5			24.91			31.25			20.83			1	
05/23/24	142597			493			28.14			229			21.51			1	
05/23/24	69851.6			1661			27.76			488.94			13.45			1	
05/23/24	39434.1			0			31.61			682			11.62			0	
05/23/24	39676.7			0			0.2			0			0			0	
05/23/24	39896.2			0			0.1			0			0			0	
05/23/24	39688.3			0			0.1			0			0			0	
05/23/24	39474.5			0			0.1			0			0			0	

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/27/24	36915.7			0			0			0			0			0	
05/27/24	36765.5			0			0			0			0			0	
05/27/24	36707.7			0			0			0			0			0	
05/27/24	36800.2			0			0			0			0			0	
05/27/24	67327.4			0			0			0			0			0	
05/27/24	43558.3			0			0			0			0			1	
05/27/24	44933			0			0			0			0			1	
05/27/24	50524.4			3.6			0.1			0			0			1	
05/27/24	58403.1			1479.2			21.07			391.05			9.17			1	
05/27/24	68055.2			941.1			15.86			270.05			7.49			1	
05/27/24	79636.4			471.4			21.43			148.15			11.08			1	
05/27/24	110261.9			228.8			26.01			88.23			16.51			1	
05/27/24	144052.6			129.8			35.89			60.35			27.46			1	
05/27/24	143440.3			82			48.58			38			37.04			1	
05/27/24	154189.8			1521.3			39.09			743.38			31.43			1	
05/27/24	170761.7			1899.6			38.26			1001.83			33.21			1	
05/27/24	193144.5			1409.9			49.59			817.11			47.3			1	
05/27/24	216555.4			161.3			62.09			102.3			64.82			1	
05/27/24	237563.5			9.7			64.41			6.64			72.44			1	
05/27/24	261823.5			2.1			88.61			1.57			107.95			1	
05/27/24	285979.5			1.8			74.44			1.41			97.6			1	
05/27/24	307259.1			1.7			31.2			1.44			43.46			1	
05/27/24	326436			1.8			16.03			1.65			23.51			1	
05/27/24	343227.5			1.8			13.56			1.72			20.77			1	
05/27/24	348489.6			1.7			11.1			1.58			17.22			1	
05/27/24	349321.3			1.5			10.1			1.44			15.71			1	
05/27/24	348917			1.4			9.03			1.35			14.03			1	
05/27/24	348639.8			1.3			8.4			1.18			13.05			1	
05/27/24	348628.2			1.2			7.6			1.1			11.8			1	
05/27/24	347438.3			1.1			7.15			1.01			11.07			1	
05/27/24	346641.2			1			6.72			0.94			10.38			1	
05/27/24	346173.3			1			6.63			0.94			10.23			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/27/24	345387.7			0.9			6.54			0.85			10.06			1	
05/27/24	345295.3			0.9			6.44			0.85			9.92			1	
05/27/24	344608			0.9			6.26			0.85			9.63			1	
05/27/24	344238.3			0.8			6.17			0.76			9.48			1	
05/27/24	344463.6			0.8			6.08			0.76			9.34			1	
05/27/24	343949.5			0.8			6.08			0.76			9.33			1	
05/27/24	343770.4			0.8			5.99			0.76			9.19			1	
05/27/24	343672.2			0.7			5.99			0.68			9.19			1	
05/27/24	343291			0.7			5.99			0.68			9.18			1	
05/27/24	343077.3			0.7			5.99			0.68			9.17			1	
05/27/24	343169.7			0.7			6.08			0.68			9.31			1	
05/27/24	343008			0.7			6.17			0.68			9.45			1	
05/27/24	342886.6			0.7			6.36			0.69			9.74			1	
05/27/24	342545.9			0.7			6.35			0.67			9.72			1	
05/27/24	342863.6			0.7			6.55			0.69			10.02			1	
05/27/24	342378.3			0.7			6.18			0.68			9.44			1	
05/27/24	341829.6			0.7			4.7			0.68			7.18			1	
05/27/24	341367.5			0.7			3.69			0.68			5.62			1	
05/27/24	341598.6			0.7			4.24			0.68			6.47			1	
05/27/24	342066.4			0.7			4.9			0.67			7.49			1	
05/27/24	341621.7			0.7			4.61			0.68			7.03			1	
05/27/24	341887.4			0.7			3.13			0.68			4.79			1	
05/27/24	341771.8			0.7			2.54			0.67			3.88			1	
05/27/24	342199.3			0.7			2.86			0.68			4.37			1	
05/27/24	342118.4			0.7			3.5			0.68			5.35			1	
05/27/24	342124.2			0.7			3.6			0.68			5.49			1	
05/27/24	341540.8			0.7			2.95			0.68			4.5			1	
05/27/24	343227.4			0.7			2.58			0.69			3.95			1	
05/27/24	358170.5			0.7			2.4			0.71			3.81			1	
05/27/24	378352.5			0.7			1.69			0.66			2.81			1	
05/27/24	389512.1			0.7			1.43			0.69			2.44			1	
05/27/24	393128			0.6			1.52			0.6			2.62			1	
05/27/24	402964.9			0.6			1.71			0.61			3.02			1	
05/27/24	419415.5			0.6			2			0.63			3.65			1	
05/27/24	414904.3			0.6			2.76			0.63			4.99			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/27/24	413708.7			0.7			2.53			0.72			4.56			1	
05/27/24	413674			0.7			1.71			0.73			3.09			1	
05/27/24	413778			0.7			1.62			0.73			2.92			1	
05/27/24	414846.5			0.7			1.52			0.73			2.75			1	
05/27/24	414979.4			0.7			1.52			0.73			2.75			1	
05/27/24	415666.8			0.7			1.59			0.72			2.88			1	
05/27/24	423222			0.7			1.62			0.74			2.98			1	
05/27/24	427444.4			0.7			1.52			0.75			2.83			1	
05/27/24	429142.6			0.6			1.4			0.64			2.62			1	
05/27/24	429945.5			0.6			1.38			0.74			2.62			1	
05/27/24	430846.6			1.1			1.36			1.31			2.69			1	
05/27/24	431331.8			1.7			1.35			2.06			2.72			0	
05/27/24	431782.4			1.7			1.44			2.03			2.86			0	
05/27/24	432458.2			1.1			1.59			1.34			3.14			0	
05/27/24	432175.2			0.8			1.64			0.98			3.22			0	
05/27/24	432065.3			0.9			1.56			1.07			3.04			0	

CT1 SUSD EVENT 4

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/27/24	340963.2			0.8			0.97			0.74			1.48			0	
05/27/24	340506.9			0.8			0.97			0.74			1.48			0	
05/27/24	340732.2			0.8			1.07			0.75			1.64			0	
05/27/24	339871.5			0.8			1.07			0.75			1.64			0	
05/27/24	339420.9			0.8			1.07			0.74			1.63			0	
05/27/24	339663.5			0.8			1.25			0.75			1.91			1	
05/27/24	329659.2			0.8			1.43			0.73			2.13			1	
05/27/24	309540.7			0.8			1.76			0.68			2.48			1	
05/27/24	285055.4			0.8			2.29			0.63			3.01			1	
05/27/24	264313			0.7			2.63			0.54			3.25			1	
05/27/24	240209			0.7			3.65			0.45			4.17			1	
05/27/24	219432			0.5			9.44			0.32			10.02			1	
05/27/24	194600.1			0.3			17.16			0.19			16.58			1	
05/27/24	171934.3			28.9			19.87			15.43			17.46			1	
05/27/24	153872.1			341.8			22.78			168.09			18.43			1	
05/27/24	134752.9			1346.6			23.13			601.96			17.02			1	
05/27/24	13845.5			1897.5			24.32			312.19			6.58			1	
05/27/24	13533.6			0			28.32			767.4			7.64			0	
05/27/24	13175.5			0			0.2			0			0			0	
05/27/24	13094.6			0			0.2			0			0			0	
05/27/24	12291.7			0			0.2			0			0			0	
05/27/24	13695.4			0			0.2			0			0			0	

CT1 SUSD EVENT 5

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/02/24	40075.3			0			0			0			0			0	
06/02/24	40040.6			0			0			0			0			0	
06/02/24	39925.1			0			0			0			0			0	
06/02/24	39902			0			0			0			0			0	
06/02/24	41837			0			0			0			0			0	
06/02/24	44332.3			0			0			0			0			1	
06/02/24	48866.6			0			0			0			0			1	
06/02/24	55723			1634.3			29.5			423.27			12.57			1	
06/02/24	64323.7			1222.7			15.43			341.02			7.08			1	
06/02/24	74218.4			737.2			19.44			222.6			9.66			1	
06/02/24	92043.7			353.4			23.9			121.51			13.52			1	
06/02/24	132494.4			197.4			28.43			86.51			20.51			1	
06/02/24	144895.9			112.1			41.3			52.39			31.77			1	
06/02/24	153225.2			545.6			44.8			265.5			35.88			1	
06/02/24	170917.7			1959			36.88			1034.45			32.05			1	
06/02/24	193092.5			1495			47.86			867.08			45.68			1	
06/02/24	216780.7			205.1			60.3			130.27			63.04			1	
06/02/24	237401.8			12.9			62.93			8.82			70.78			1	
06/02/24	262175.8			2			85.27			1.49			104.01			1	
06/02/24	286233.7			1.7			76.1			1.36			99.89			1	
06/02/24	308108.2			1.6			33.04			1.39			46.14			1	
06/02/24	327181.2			1.8			16.56			1.57			24.33			1	
06/02/24	344769.7			1.7			13.8			1.62			21.21			1	
06/02/24	351060			1.7			11.54			1.59			18.01			1	
06/02/24	352088.1			1.5			10.19			1.45			15.96			1	
06/02/24	351909.1			1.3			9.21			1.28			14.41			1	
06/02/24	351678			1.3			8.4			1.19			13.14			1	
06/02/24	351319.9			1.2			7.6			1.1			11.87			1	
06/02/24	350880.9			1.1			7.24			1.02			11.3			1	
06/02/24	349887.4			1			6.72			0.94			10.46			1	
06/02/24	349055.7			1			6.54			0.94			10.15			1	
06/02/24	348657.1			0.9			6.44			0.86			10			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/02/24	348443.3			0.9			6.26			0.86			9.72			1	
06/02/24	347646.3			0.9			6.17			0.85			9.56			1	
06/02/24	347519.2			0.8			6.08			0.77			9.41			1	
06/02/24	347345.9			0.8			5.9			0.77			9.13			1	
06/02/24	346993.5			0.8			5.9			0.77			9.12			1	
06/02/24	346843.4			0.8			5.9			0.77			9.12			1	
06/02/24	346930			0.8			5.9			0.77			9.12			1	
06/02/24	346652.8			0.7			5.9			0.69			9.11			1	
06/02/24	346127.1			0.7			5.99			0.69			9.24			1	
06/02/24	346075.2			0.7			5.99			0.69			9.24			1	
06/02/24	351637.6			0.7			6.08			0.7			9.51			1	
06/02/24	357887.5			0.7			5.44			0.71			8.63			1	
06/02/24	357096.1			0.7			4.59			0.63			7.27			1	
06/02/24	351972.6			0.6			4.98			0.61			7.79			1	
06/02/24	349783.4			0.7			4.79			0.7			7.46			1	
06/02/24	349142.3			0.7			3.69			0.7			5.73			1	
06/02/24	349067.2			0.7			3.5			0.7			5.44			1	
06/02/24	348680.2			0.7			3.5			0.7			5.44			1	
06/02/24	348789.9			0.7			3.69			0.7			5.73			1	
06/02/24	348714.8			0.7			3.87			0.7			6.01			1	
06/02/24	348397.2			0.7			3.23			0.7			5.01			1	
06/02/24	347501.8			0.7			2.49			0.69			3.85			1	
06/02/24	347501.9			0.6			2.67			0.61			4.14			1	
06/02/24	347455.7			0.6			3.41			0.61			5.28			1	
06/02/24	348951.7			0.6			2.95			0.61			4.58			1	
06/02/24	355646.3			0.6			2.21			0.62			3.49			1	
06/02/24	354283.1			0.7			1.31			0.63			2.06			1	
06/02/24	351187			0.6			1.36			0.6			2.13			1	
06/02/24	358707.7			0.6			2.09			0.61			3.32			1	
06/02/24	378075.3			0.6			2.12			0.65			3.53			1	
06/02/24	399920.9			0.7			1.5			0.7			2.62			1	
06/02/24	423990.3			0.6			1.5			0.63			2.76			1	
06/02/24	437148.4			0.6			1.52			0.66			2.88			1	
06/02/24	432296.4			0.6			1.84			0.63			3.46			1	
06/02/24	432515.9			0.6			1.66			0.74			3.11			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/02/24	431811.3			0.7			1.5			0.75			2.81			1	
06/02/24	432446.6			0.7			1.22			0.75			2.28			1	
06/02/24	433555.7			0.6			1.12			0.64			2.11			1	
06/02/24	433931.1			0.6			1.03			0.64			1.94			1	
06/02/24	434248.8			0.6			1.03			0.64			1.94			1	
06/02/24	434335.4			0.6			1.01			0.75			1.94			1	
06/02/24	434052.4			1.1			0.98			1.29			1.95			1	
06/02/24	433896.5			1.6			1.1			1.97			2.22			1	
06/02/24	432931.9			1.6			1.12			1.94			2.23			1	
06/02/24	432949.1			1			1.28			1.26			2.54			0	
06/02/24	433521			0.8			1.37			0.98			2.74			0	
06/02/24	433318.8			0.8			1.37			0.98			2.73			0	
06/02/24	433705.8			0.8			1.37			0.97			2.72			0	
06/02/24	433942.7			0.8			1.39			0.98			2.74			0	

CT1 SUSD EVENT 6

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/02/24	342089.6			0.6			1.48			0.6			2.25			0	
06/02/24	341945.1			0.6			1.48			0.6			2.25			0	
06/02/24	341974			0.6			1.48			0.6			2.25			0	
06/02/24	342193.5			0.6			1.48			0.6			2.25			0	
06/02/24	342182			0.6			1.48			0.6			2.25			0	
06/02/24	339675.1			0.6			1.48			0.6			2.24			1	
06/02/24	323738.6			0.6			1.48			0.57			2.15			1	
06/02/24	302181.8			0.7			1.72			0.61			2.37			1	
06/02/24	280116.7			0.7			2.27			0.57			2.93			1	
06/02/24	258022.8			0.7			2.21			0.54			2.66			1	
06/02/24	235149			0.6			2.57			0.39			2.87			1	
06/02/24	214100.5			0.5			6			0.31			6.21			1	
06/02/24	189078.1			0.3			15.62			0.19			14.68			1	
06/02/24	166920.6			19.1			18.68			9.89			15.95			1	
06/02/24	149464.9			291.5			21.49			139.37			16.91			1	
06/02/24	108713.8			1294.8			22.01			495.91			13.87			1	
06/02/24	37759			0			22.97			486.12			8.21			0	
06/02/24	37701.2			0			0.4			0			0			0	
06/02/24	37562.6			0			0.2			0			0			0	
06/02/24	37273.8			0			0.2			0			0			0	
06/02/24	37123.6			0			0.1			0			0			0	

CT1 SUSD EVENT 7

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/05/24	38082.5			0			0			0			0			0	
06/05/24	38151.8			0			0			0			0			0	
06/05/24	38065.1			0			0			0			0			0	
06/05/24	38261.5			0			0			0			0			0	
06/05/24	38255.8			0			0			0			0			0	
06/05/24	41865.9			0.1			0			0			0			1	
06/05/24	43985.7			0.1			0			0			0			1	
06/05/24	50905.6			23.2			0.6			0			0			1	
06/05/24	59639.2			1221.3			14.26			325.87			6.26			1	
06/05/24	69684			813.9			17.35			236.28			8.29			1	
06/05/24	83783.7			378.8			22.72			122.52			12.09			1	
06/05/24	121918.2			186.2			27.7			76.91			18.83			1	
06/05/24	143255.5			100.3			40.85			46.45			31.13			1	
06/05/24	147581.9			227.9			52.18			107.84			40.64			1	
06/05/24	153889.5			1834.4			45.23			895.14			36.33			1	
06/05/24	169745.1			1843.8			52.75			968.23			45.59			1	
06/05/24	191937.3			1320.2			64.58			761.84			61.33			1	
06/05/24	215723.7			144.5			63.25			91.46			65.9			1	
06/05/24	236997.4			8.8			59.6			6			66.99			1	
06/05/24	261904.4			2.1			82.49			1.59			100.65			1	
06/05/24	285413.5			1.8			57.94			1.46			75.94			1	
06/05/24	306802.8			1.8			23.33			1.51			32.51			1	
06/05/24	326193.4			1.8			11.71			1.65			17.19			1	
06/05/24	342603.7			1.8			10.39			1.64			15.91			1	
06/05/24	348235.4			1.7			7.93			1.58			12.31			1	
06/05/24	348865			1.5			5.99			1.44			9.32			1	
06/05/24	349119.2			1.3			5.36			1.27			8.35			1	
06/05/24	348859.3			1.2			4.74			1.1			7.37			1	
06/05/24	348691.8			1.1			4.65			1.01			7.23			1	
06/05/24	347577			1.1			4.27			1.03			6.62			1	
06/05/24	346664.3			1			3.9			0.94			6.04			1	
06/05/24	346196.5			0.9			3.81			0.85			5.89			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/05/24	345584.2			0.9			3.72			0.85			5.74			1	
06/05/24	345416.7			0.9			3.63			0.85			5.6			1	
06/05/24	344700.4			0.8			3.54			0.76			5.45			1	
06/05/24	344359.6			0.8			3.54			0.76			5.44			1	
06/05/24	344082.3			0.8			3.45			0.76			5.3			1	
06/05/24	343937.9			0.8			3.5			0.77			5.38			1	
06/05/24	343886			0.7			3.41			0.69			5.24			1	
06/05/24	343441.2			0.7			3.41			0.69			5.23			1	
06/05/24	343412.3			0.7			3.41			0.69			5.23			1	
06/05/24	343129.3			0.7			3.41			0.69			5.23			1	
06/05/24	342984.9			0.7			3.5			0.69			5.37			1	
06/05/24	342620.9			0.7			3.5			0.69			5.36			1	
06/05/24	342655.6			0.7			3.5			0.69			5.37			1	
06/05/24	346554.6			0.7			3.5			0.69			5.42			1	
06/05/24	355224.6			0.7			3.09			0.72			4.88			1	
06/05/24	356195			0.7			2.62			0.63			4.15			1	
06/05/24	350459.3			0.7			3.18			0.62			4.97			1	
06/05/24	346000			0.6			3.41			0.61			5.27			1	
06/05/24	343008			0.6			2.58			0.6			3.96			1	
06/05/24	341881.6			0.6			2.12			0.6			3.24			1	
06/05/24	341621.7			0.6			2.03			0.6			3.1			1	
06/05/24	342355.2			0.6			2.03			0.6			3.11			1	
06/05/24	354716.3			0.7			2.21			0.71			3.49			1	
06/05/24	375834.1			0.7			2.43			0.76			4.04			1	
06/05/24	384983.6			0.7			2.66			0.69			4.52			1	
06/05/24	382950.4			0.7			3			0.67			5.06			1	
06/05/24	382072.4			0.7			1.97			0.67			3.31			1	
06/05/24	390592.3			0.7			1.33			0.69			2.29			1	
06/05/24	405234.9			0.6			1.14			0.62			2.03			1	
06/05/24	413789.5			0.6			1.05			0.63			1.89			1	
06/05/24	417249.4			0.6			1.5			0.62			2.73			1	
06/05/24	417694.2			0.6			1.87			0.62			3.41			1	
06/05/24	418237.2			0.6			1.78			0.62			3.24			1	
06/05/24	418283.3			0.6			1.66			0.72			3.03			1	
06/05/24	419149.8			0.7			1.5			0.73			2.74			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/05/24	418791.7			0.6			1.38			0.73			2.58			1	
06/05/24	419016.9			1.3			1.34			1.58			2.6			1	
06/05/24	419016.9			1.7			1.33			1.99			2.62			0	
06/05/24	419715.8			1.5			1.44			1.82			2.84			0	
06/05/24	420039.3			0.9			1.51			1.06			3.02			0	
06/05/24	419883.4			0.7			1.57			0.85			3.13			0	
06/05/24	420016.3			0.6			1.57			0.76			3.11			0	

CT1 SUSD EVENT 8

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/05/24	344076.6			0.7			0.36			0.58			0.48			0	
06/05/24	340587.8			0.8			0.35			0.63			0.46			0	
06/05/24	339698.2			0.8			0.45			0.64			0.59			0	
06/05/24	339565.3			0.8			0.45			0.64			0.59			0	
06/05/24	339322.8			0.8			0.45			0.64			0.59			0	
06/05/24	339241.9			0.8			0.45			0.64			0.59			1	
06/05/24	328475			0.7			0.45			0.55			0.57			1	
06/05/24	308160.2			0.8			0.44			0.57			0.52			1	
06/05/24	285939.1			0.8			0.53			0.53			0.58			1	
06/05/24	264047.3			0.8			0.54			0.51			0.56			1	
06/05/24	241110.1			0.7			0.56			0.37			0.52			1	
06/05/24	219859.4			0.6			1.16			0.3			0.99			1	
06/05/24	195535.9			0.4			4			0.19			3.02			1	
06/05/24	172194.2			9.5			5.09			3.83			3.38			1	
06/05/24	153924.1			193.4			6.03			69.82			3.59			1	
06/05/24	130622.9			1068.7			7.14			327.49			3.6			1	
06/05/24	35725.8			1899.6			7.87			159.03			1.08			1	
06/05/24	35425.4			0			17.7			935.61			2.42			0	
06/05/24	35234.8			0			0.1			0			0			0	
06/05/24	34980.7			0			0.1			0			0			0	
06/05/24	34830.5			0			0			0			0			0	
06/05/24	34570.5			0			0			0			0			0	

CT1 SUSD EVENT 9

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/13/24	37164.1			0			0			0			0			0	
06/13/24	36840.6			0			0			0			0			0	
06/13/24	36742.4			0			0			0			0			0	
06/13/24	36725.1			0			0			0			0			0	
06/13/24	45666.6			0			0			0			0			0	
06/13/24	43870.2			0.1			0			0			0			1	
06/13/24	46452.2			0.1			0			0			0			1	
06/13/24	52938.9			28.9			0.8			0			0			1	
06/13/24	61493.4			1441.7			16.63			229.14			4.35			1	
06/13/24	71272.5			913			19.18			165.75			5.73			1	
06/13/24	74050.9			464.2			24.53			87.6			7.62			1	
06/13/24	41103.4			0			30.06			28.63			5.5			0	
06/13/24	41115			0			20.45			13.97			3.74			0	
06/13/24	40970.6			0			0.5			0			0			0	
06/13/24	40993.7			0			0.4			0			0			0	
06/13/24	40860.8			0			0.3			0			0			0	

CT1 SUSD EVENT 10

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/13/24	37164.1			0			0			0			0			0	
06/13/24	36840.6			0			0			0			0			0	
06/13/24	36742.4			0			0			0			0			0	
06/13/24	36725.1			0			0			0			0			0	
06/13/24	45666.6			0			0			0			0			0	
06/13/24	43870.2			0.1			0			0			0			1	
06/13/24	46452.2			0.1			0			0			0			1	
06/13/24	52938.9			28.9			0.8			0			0			1	
06/13/24	61493.4			1441.7			16.63			229.14			4.35			1	
06/13/24	71272.5			913			19.18			165.75			5.73			1	
06/13/24	74050.9			464.2			24.53			87.6			7.62			1	
06/13/24	41103.4			0			30.06			28.63			5.5			0	
06/13/24	41115			0			20.45			13.97			3.74			0	
06/13/24	40970.6			0			0.5			0			0			0	
06/13/24	40993.7			0			0.4			0			0			0	
06/13/24	40860.8			0			0.3			0			0			0	

CT1 SUSD EVENT 11

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/13/24	38215.3			0			0			0			0			0	
06/13/24	37874.5			0			0			0			0			0	
06/13/24	37579.9			0			0			0			0			0	
06/13/24	37406.7			0			0			0			0			0	
06/13/24	37395.1			0			0			0			0			0	
06/13/24	40508.5			0.2			0			0			0			1	
06/13/24	43055.8			0.1			0			0			0			1	
06/13/24	50091.2			20.5			0.7			0			0			1	
06/13/24	58934.5			1109.2			21.14			168.09			5.27			1	
06/13/24	69118			748.3			22.21			131.15			6.41			1	
06/13/24	83749.1			362.6			27.44			75.88			9.45			1	
06/13/24	122316.8			199.8			32.99			59.84			16.26			1	
06/13/24	143371			116.8			46.26			40.72			26.53			1	
06/13/24	150117.6			258.6			57.48			94.26			34.47			1	
06/13/24	163986.3			1840.1			47.56			729.06			31.01			1	
06/13/24	183919.9			1680.5			57.53			746.34			42.05			1	
06/13/24	207596.6			400.6			66.23			200.42			54.53			1	
06/13/24	228408.2			26.3			63.1			14.47			57.14			1	
06/13/24	251709.4			2.5			73.52			1.51			73.13			1	
06/13/24	277627.2			1.7			79.24			1.15			86.76			1	
06/13/24	298952.9			1.7			35.68			1.19			41.95			1	
06/13/24	318430.3			1.8			15.41			1.34			19.28			1	
06/13/24	337018.1			1.8			10.21			1.42			13.51			1	
06/13/24	346381.3			1.7			8.45			1.38			11.47			1	
06/13/24	347790.7			1.6			6.26			1.33			8.53			1	
06/13/24	347987.1			1.4			5.18			1.19			7.07			1	
06/13/24	347842.7			1.3			4.29			1.11			5.85			1	
06/13/24	347998.6			1.3			3.93			1.04			5.36			1	
06/13/24	347172.6			1.1			3.31			0.89			4.5			1	
06/13/24	346514.1			1.1			3.22			0.88			4.36			1	
06/13/24	345399.3			1			3.09			0.82			4.16			1	
06/13/24	345122			1			2.9			0.82			3.92			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/13/24	345722.8			0.9			2.72			0.75			3.69			1	
06/13/24	358892.5			0.9			2.63			0.77			3.7			1	
06/13/24	377139.5			0.8			2.03			0.74			2.99			1	
06/13/24	383926.5			0.7			1.69			0.68			2.53			1	
06/13/24	385786.5			0.7			1.78			0.69			2.69			1	
06/13/24	386277.5			0.7			1.78			0.69			2.69			1	
06/13/24	386514.3			0.7			1.78			0.69			2.69			1	
06/13/24	388813.2			0.7			1.78			0.69			2.71			1	
06/13/24	389887.6			0.7			1.81			0.62			2.76			1	
06/13/24	389373.5			0.7			1.81			0.62			2.75			1	
06/13/24	380478.2			0.7			1.87			0.59			2.78			1	
06/13/24	374135.9			0.7			1.97			0.58			2.87			1	
06/13/24	367920.7			0.7			2.12			0.65			3.06			1	
06/13/24	363109.1			0.7			2.12			0.64			3.02			1	
06/13/24	358349.5			0.7			1.48			0.63			2.07			1	
06/13/24	351984.2			0.7			1.11			0.62			1.53			1	
06/13/24	345803.6			0.7			1			0.6			1.35			1	
06/13/24	343002.2			0.7			0.91			0.59			1.22			1	
06/13/24	341847			0.7			0.82			0.59			1.09			1	
06/13/24	341506.2			0.7			0.82			0.59			1.09			1	
06/13/24	341431.1			0.7			0.83			0.6			1.11			1	
06/13/24	341442.6			0.7			0.74			0.6			0.99			1	
06/13/24	341558.2			0.7			0.74			0.6			0.99			1	
06/13/24	341454.2			0.7			0.74			0.6			0.99			1	
06/13/24	341667.9			0.7			0.83			0.6			1.11			0	
06/13/24	341656.3			0.7			0.83			0.6			1.11			0	
06/13/24	341846.9			0.7			0.83			0.6			1.11			0	
06/13/24	341766.1			0.7			0.83			0.6			1.11			0	
06/13/24	341950.9			0.7			0.92			0.6			1.24			0	

CT1 SUSD EVENT 12

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/13/24	342459.3			0.7			1.43			0.59			1.93			0	
06/13/24	342285.9			0.8			1.34			0.66			1.81			0	
06/13/24	342262.8			0.8			1.34			0.66			1.81			0	
06/13/24	342401.4			0.8			1.34			0.66			1.81			0	
06/13/24	342441.9			0.8			1.34			0.66			1.81			0	
06/13/24	337254.8			0.7			1.34			0.58			1.78			1	
06/13/24	318823			0.8			1.34			0.62			1.69			1	
06/13/24	295966.6			0.8			1.85			0.56			2.17			1	
06/13/24	273722.5			0.8			1.97			0.53			2.14			1	
06/13/24	251524.5			0.7			2.77			0.45			2.77			1	
06/13/24	228702.8			0.6			4.85			0.32			4.43			1	
06/13/24	205788.6			0.4			13.15			0.21			10.82			1	
06/13/24	181338			4.3			17.24			1.9			12.56			1	
06/13/24	161600.7			122.9			19.67			48.73			12.84			1	
06/13/24	143053.3			789.7			21.39			278.77			12.43			1	
06/13/24	58668.8			1773			21.58			274.65			5.5			1	
06/13/24	21597.2			0			23.99			198.72			2.7			0	
06/13/24	21493.2			0			0.2			0			0			0	
06/13/24	21348.8			0			0.2			0			0			0	
06/13/24	21291.1			0			0.2			0			0			0	
06/13/24	21019.6			0			0.2			0			0			0	

CT1 SUSD EVENT 13

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	41802.3			0			0			0			0			0	
06/14/24	41773.5			0			0			0			0			0	
06/14/24	41802.3			0			0			0			0			0	
06/14/24	41964.1			0			0			0			0			0	
06/14/24	41993			0			0			0			0			0	
06/14/24	44592.3			0.1			0			0			0			1	
06/14/24	45886.1			0.1			0			0			0			1	
06/14/24	50553.3			8.3			0.4			0			0			1	
06/14/24	59673.9			1143.4			18.29			163.3			4.3			1	
06/14/24	68517.3			771.5			18.74			126.07			5.04			1	
06/14/24	80237.2			374.1			25.37			72.51			8.09			1	
06/14/24	111116.7			191.2			32.72			51.45			14.49			1	
06/14/24	144497.4			101.2			45.55			35.08			25.98			1	
06/14/24	147801.4			75.9			63.76			27.11			37.46			1	
06/14/24	151041.8			1539.7			55.78			558.35			33.29			1	
06/14/24	150412.2			1843.8			53.97			666.54			32.11			1	
06/14/24	149297.4			1843.8			53.79			657.87			31.59			1	
06/14/24	148673.6			1843.8			52.58			649.62			30.49			1	
06/14/24	148402.1			1899.6			51.85			665.05			29.87			1	
06/14/24	158654.8			1899.6			47.02			713.95			29.08			1	
06/14/24	177912.7			1843.8			45.29			771.37			31.18			1	
06/14/24	202178.5			596.8			44.78			284.69			35.15			1	
06/14/24	223850.8			41.3			45.23			21.81			39.31			1	
06/14/24	247313.7			4.7			54.84			2.75			52.36			1	
06/14/24	273531.8			2.9			66.56			1.86			70.37			1	
06/14/24	294620.8			2.8		X	12.07		X	1.95		X	13.74		X	1	
06/14/24	313820.8			2.4		X	11.17		X	1.78		X	13.53		X	1	
06/14/24	333685.2			1.9		X	9.48		X	1.47		X	12.21		X	1	
06/14/24	349292.5			1.7		X	7.96		X	1.39		X	10.73		X	1	
06/14/24	368059.3			2.9			8.69			2.5			12.35			1	
06/14/24	390702			1.4			5.16			1.27			7.79			1	
06/14/24	409682.6			1.2			4.87			1.17			7.7			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	404784.4			1			5.62			0.98			8.78			1	
06/14/24	402323.8			1			5.15			0.97			8			1	
06/14/24	402231.3			0.9			4.78			0.88			7.42			1	
06/14/24	403126.7			1			4.47			0.9			6.96			1	
06/14/24	405229.2			0.8			4.4			0.8			6.89			1	
06/14/24	406141.8			0.8			4.31			0.8			6.75			1	
06/14/24	406748.3			0.7			4.4			0.71			6.91			1	
06/14/24	407441.5			0.7			4.4			0.72			6.92			1	
06/14/24	404911.5			0.7			4.59			0.71			7.17			1	
06/14/24	413610.4			0.7			4.12			0.73			6.58			1	
06/14/24	423418.4			0.7			3.52			0.66			5.76			1	
06/14/24	425555.6			0.7			4.38			0.67			7.19			1	
06/14/24	426734			0.7			4.5			0.66			7.41			1	
06/14/24	426300.8			0.6			4.15			0.65			6.83			1	
06/14/24	426011.9			0.7			3.47			0.66			5.7			1	
06/14/24	426092.8			0.7			3.18			0.66			5.24			1	
06/14/24	425931			0.7			3.18			0.66			5.24			1	
06/14/24	426612.6			0.7			3.18			0.66			5.24			1	
06/14/24	427305.8			0.7			3.28			0.66			5.41			1	
06/14/24	427323.1			0.6			2.86			0.65			4.71			1	
06/14/24	426976.5			0.7			2.34			0.66			3.86			1	
06/14/24	427825.7			0.7			2.25			0.66			3.71			1	
06/14/24	428524.6			0.7			2.25			0.66			3.72			1	
06/14/24	428824.9			0.7			2.34			0.66			3.88			1	
06/14/24	428316.6			0.6			2.49			0.65			4.12			1	
06/14/24	428368.6			0.6			2.49			0.65			4.12			1	
06/14/24	428258.9			0.6			2.3			0.65			3.81			1	
06/14/24	428767.2			0.6			2.03			0.65			3.36			1	
06/14/24	429916.7			0.7			1.87			0.66			3.11			1	
06/14/24	420952			0.6			1.66			0.64			2.7			1	
06/14/24	402121.6			0.6			1.66			0.61			2.58			1	
06/14/24	390852.2			0.6			1.75			0.59			2.64			1	
06/14/24	386058			0.6			1.72			0.58			2.57			1	
06/14/24	384613.9			0.7			1.72			0.66			2.56			1	
06/14/24	384492.6			0.6			1.63			0.57			2.43			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	384232.7			0.6			1.63			0.57			2.42			1	
06/14/24	383915			0.6			1.54			0.57			2.29			1	
06/14/24	382118.6			0.6			1.54			0.57			2.28			1	
06/14/24	381159.7			0.6			1.54			0.57			2.27			0	
06/14/24	380888.3			0.6			1.54			0.57			2.27			0	
06/14/24	381217.5			0.6			1.54			0.57			2.27			0	
06/14/24	383597.3			0.6			1.54			0.57			2.29			0	
06/14/24	384798.8			0.6			1.54			0.57			2.29			0	

CT1 SUSD EVENT 14

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/15/24 2:17	341916.2			0.7			1.43			0.58			1.93			0	
06/15/24 2:18	341950.9			0.7			1.43			0.58			1.92			0	
06/15/24 2:19	341471.5			0.7			1.43			0.58			1.92			0	
06/15/24 2:20	341471.5			0.7			1.43			0.58			1.92			0	
06/15/24 2:21	341927.8			0.7			1.43			0.58			1.92			0	
06/15/24 2:22	341852.7			0.8			1.43			0.66			1.92			1	
06/15/24 2:23	336625.3			0.8			1.43			0.65			1.9			1	
06/15/24 2:24	317280.8			0.8			1.41			0.6			1.76			1	
06/15/24 2:25	294077.8			0.8			1.85			0.56			2.15			1	
06/15/24 2:26	271920.3			0.8			2.15			0.53			2.31			1	
06/15/24 2:27	249202.5			0.7			3.32			0.44			3.28			1	
06/15/24 2:28	227102.8			0.6			6			0.32			5.41			1	
06/15/24 2:29	203830.5			0.4			14.33			0.21			11.63			1	
06/15/24 2:30	179841.9			6.9			17.01			3.03			12.24			1	
06/15/24 2:31	160116.2			163.9			19.54			64.02			12.56			1	
06/15/24 2:32	141765.2			960.8			22.09			334.22			12.64			1	
06/15/24 2:33	54637.1			1843.6			21.34			264.11			5.03			1	
06/15/24 2:34	0			0			25.08			45.81			0.64			0	
06/15/24 2:35	0			0			0.2			0			0			0	
06/15/24 2:36	0			0			0.2			0			0			0	
06/15/24 2:37	0			0			0.1			0			0			0	
06/15/24 2:38	0			0			0.1			0			0			0	

CT1 SUSD EVENT 15

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/19/24 8:05	0			0			0			0			0			0	
06/19/24 8:06	0			0			0			0			0			0	
06/19/24 8:07	0			0			0			0			0			0	
06/19/24 8:08	0			0			0			0			0			0	
06/19/24 8:09	13158.2			0			0			0			0			0	
06/19/24 8:10	23763.3			0.1			0			0			0			1	
06/19/24 8:11	33328.7			0.9			0			0			0			1	
06/19/24 8:12	44476.7			1313.7			20.65			157.92			4.09			1	
06/19/24 8:13	56127.3			1073			15.73			159.01			3.84			1	
06/19/24 8:14	68713.6			604.8			20.65			107.76			6.06			1	
06/19/24 8:15	97970.1			332.1			24.72			81.99			10.05			1	
06/19/24 8:16	138461.2			205			32.58			70.2			18.36			1	
06/19/24 8:17	143238.2			129.6			46.99			45.4			27.09			1	
06/19/24 8:18	148569.6			1256.7			39.64			455.72			23.66			1	
06/19/24 8:19	151365.3			1899.6			37.19			702.04			22.62			1	
06/19/24 8:20	166100.3			1843.8			40.78			746.19			27.16			1	
06/19/24 8:21	186086			1741.3			55.23			786.98			41.08			1	
06/19/24 8:22	209525.8			451.4			69.47			228.33			57.84			1	
06/19/24 8:23	230048.6			36.2			66.95			20.05			61.1			1	
06/19/24 8:24	254077.6			3.9			73.52			2.36			73.89			1	
06/19/24 8:25	280521.1			2.4			81.56			1.6			90.17			1	
06/19/24 8:26	302464.8			2.1			38.35			1.53			45.65			1	
06/19/24 8:27	321913.3			2.1			17.79			1.6			22.49			1	
06/19/24 8:28	340316.2			2.1			12.23			1.69			16.35			1	
06/19/24 8:29	351175.5			2			9.89			1.67			13.64			1	
06/19/24 8:30	364847.8			1.8			8.54			1.61			12.22			1	
06/19/24 8:31	383608.9			1.6			6.52			1.45			9.79			1	
06/19/24 8:32	390430.5			1.5			5.08			1.35			7.77			1	
06/19/24 8:33	391447.2			1.3			5.01			1.17			7.68			1	
06/19/24 8:34	391556.9			1.1			4.92			1			7.55			1	
06/19/24 8:35	391568.4			1.1			4.74			1			7.27			1	
06/19/24 8:36	391990.2			1			4.47			0.92			6.87			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/19/24 8:37	404657.3			0.9			4.08			0.88			6.48			1	
06/19/24 8:38	425012.7			0.9			3.5			0.93			5.84			1	
06/19/24 8:39	445801.2			0.8			3.47			0.9			6.06			1	
06/19/24 8:40	441832.9			0.7			4.33			0.78			7.51			1	
06/19/24 8:41	440048.1			0.7			4.18			0.76			7.2			1	
06/19/24 8:42	439938.3			0.8			4.15			0.87			7.16			1	
06/19/24 8:43	438546.3			0.7			4.06			0.77			6.97			1	
06/19/24 8:44	424775.8			0.7			4.06			0.75			6.76			1	
06/19/24 8:45	404946.1			0.7			3.96			0.71			6.3			1	
06/19/24 8:46	392706.4			0.7			4.36			0.68			6.72			1	
06/19/24 8:47	388686.1			0.8			4.2			0.75			6.41			1	
06/19/24 8:48	386751.1			0.8			4.18			0.75			6.34			1	
06/19/24 8:49	386323.7			0.7			4.08			0.67			6.19			1	
06/19/24 8:50	386069.5			0.7			3.81			0.67			5.78			1	
06/19/24 8:51	378624			0.7			2.9			0.66			4.32			1	
06/19/24 8:52	370785.7			0.7			2.95			0.63			4.3			1	
06/19/24 8:53	365771.9			0.7			3.13			0.62			4.5			1	
06/19/24 8:54	358967.6			0.8			3.04			0.69			4.29			1	
06/19/24 8:55	353699.7			0.8			2.95			0.68			4.1			1	
06/19/24 8:56	349223.2			0.8			2.82			0.66			3.88			1	
06/19/24 8:57	345566.8			0.8			1.94			0.66			2.64			1	
06/19/24 8:58	343834			0.8			1.76			0.65			2.39			1	
06/19/24 8:59	343406.5			0.8			1.79			0.66			2.42			1	
06/19/24 9:00	342776.9			0.8			1.97			0.66			2.65			1	
06/19/24 9:01	343135			0.8			2.06			0.66			2.77			1	
06/19/24 9:02	343135			0.8			2.32			0.66			3.14			1	
06/19/24 9:03	343250.6			0.7			2.41			0.59			3.26			1	
06/19/24 9:04	343493.1			0.7			2.41			0.59			3.26			1	
06/19/24 9:05	343314.1			0.7			2.23			0.59			3.02			1	
06/19/24 9:06	343556.7			0.8			2.06			0.66			2.78			1	
06/19/24 9:07	343343			0.8			1.97			0.66			2.66			1	
06/19/24 9:08	343631.8			0.8			1.79			0.66			2.42			1	
06/19/24 9:09	343319.9			0.8			1.7			0.66			2.29			1	
06/19/24 9:10	343464.3			0.8			1.61			0.66			2.17			1	
06/19/24 9:11	343735.8			0.8			1.61			0.66			2.17			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/19/24 9:12	343533.6			0.8			1.61			0.66			2.17			1	
06/19/24 9:13	343510.5			0.8			1.61			0.66			2.17			1	
06/19/24 9:14	343302.6			0.8			1.61			0.66			2.17			1	
06/19/24 9:15	343239			0.8			1.52			0.66			2.05			1	
06/19/24 9:16	343649.2			0.7			1.52			0.59			2.05			1	
06/19/24 9:17	343325.7			0.7			1.52			0.59			2.05			0	
06/19/24 9:18	343146.6			0.7			1.52			0.59			2.05			0	
06/19/24 9:19	343389.2			0.7			1.52			0.59			2.05			0	
06/19/24 9:20	343487.4			0.7			1.52			0.59			2.05			0	
06/19/24 9:21	343019.5			0.8			1.52			0.66			2.05			0	

CT1 SUSD EVENT 16

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24 6:16	340489.5			0.7			1.27			0.58			1.68			0	
06/24/24 6:17	340593.5			0.7			1.27			0.58			1.68			0	
06/24/24 6:18	340570.4			0.7			1.27			0.58			1.67			0	
06/24/24 6:19	340639.7			0.8			1.27			0.66			1.68			0	
06/24/24 6:20	340714.8			0.7			1.27			0.58			1.68			0	
06/24/24 6:21	339028.2			0.7			1.36			0.58			1.79			1	
06/24/24 6:22	324206.4			0.8			1.36			0.62			1.71			1	
06/24/24 6:23	303233.1			0.8			1.45			0.58			1.71			1	
06/24/24 6:24	280076.3			0.8			1.97			0.53			2.15			1	
06/24/24 6:25	258900.8			0.7			2.12			0.45			2.14			1	
06/24/24 6:26	235253			0.7			2.76			0.37			2.53			1	
06/24/24 6:27	214129.5			0.5			7.38			0.25			6.18			1	
06/24/24 6:28	188962.6			0.4			16.28			0.2			11.98			1	
06/24/24 6:29	166874.3			21.1			19.42			8.44			12.76			1	
06/24/24 6:30	148841.1			268			21.82			95.07			12.74			1	
06/24/24 6:31	104872.6			1267.7			23.12			320.09			9.61			1	
06/24/24 6:32	25305.5			0			23.6			140.32			2.61			0	
06/24/24 6:33	25213.1			0			0.6			0			0			0	
06/24/24 6:34	25218.9			0			0.2			0			0			0	
06/24/24 6:35	25270.9			0			0.1			0			0			0	
06/24/24 6:36	25346			0			0.1			0			0			0	

CT1 SUSD EVENT 17

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	43956.9			0			0			0			0			0	
06/24/24	43887.6			0			0			0			0			0	
06/24/24	44083.9			0			0			0			0			0	
06/24/24	44055.1			0			0			0			0			0	
06/24/24	44494.1			0			0			0			0			0	
06/24/24	46394.4			-0.1			0			0			0			1	
06/24/24	51246.4			0			0			0			0			1	
06/24/24	58229.9			840.2			15.34			125.63			3.78			1	
06/24/24	66853.7			660.4			9.05			111.17			2.51			1	
06/24/24	55803.9			266.8			13.44			38.1			3.16			1	
06/24/24	45089			0			15.34			11.67			2.97			0	
06/24/24	45077.4			0			7.59			5.89			1.48			0	
06/24/24	45083.2			0			0.1			0			0			0	
06/24/24	44950.4			0			0.1			0			0			0	
06/24/24	45048.6			0			0			0			0			0	

CT1 SUSD EVENT 18

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	43956.9			0			0			0			0			0	
06/24/24	43887.6			0			0			0			0			0	
06/24/24	44083.9			0			0			0			0			0	
06/24/24	44055.1			0			0			0			0			0	
06/24/24	44494.1			0			0			0			0			0	
06/24/24	46394.4			-0.1			0			0			0			1	
06/24/24	51246.4			0			0			0			0			1	
06/24/24	58229.9			840.2			15.34			125.63			3.78			1	
06/24/24	66853.7			660.4			9.05			111.17			2.51			1	
06/24/24	55803.9			266.8			13.44			38.1			3.16			1	
06/24/24	45089			0			15.34			11.67			2.97			0	
06/24/24	45077.4			0			7.59			5.89			1.48			0	
06/24/24	45083.2			0			0.1			0			0			0	
06/24/24	44950.4			0			0.1			0			0			0	
06/24/24	45048.6			0			0			0			0			0	

CT1 SUSD EVENT 19

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	45377.8			0			0			0			0			0	
06/24/24	45302.7			0			0			0			0			0	
06/24/24	45377.8			0			0			0			0			0	
06/24/24	45447.1			0			0			0			0			0	
06/24/24	45481.8			0			0			0			0			0	
06/24/24	47930.9			0			0			0			0			1	
06/24/24	51338.8			0			0			0			0			1	
06/24/24	57767.8			1126.9			23.6			166.49			5.74			1	
06/24/24	65825.6			802			12.19			132.67			3.32			1	
06/24/24	60413.3			458.9			18.36			70.47			4.64			1	
06/24/24	45262.3			0			23.6			20.82			4.5			0	
06/24/24	44927.3			0			9.65			9.7			1.84			0	
06/24/24	44482.5			0			0.2			0			0			0	
06/24/24	44147.5			0			0.1			0			0			0	
06/24/24	44095.5			0			0.1			0			0			0	

CT1 SUSD EVENT 20

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	45377.8			0			0			0			0			0	
06/24/24	45302.7			0			0			0			0			0	
06/24/24	45377.8			0			0			0			0			0	
06/24/24	45447.1			0			0			0			0			0	
06/24/24	45481.8			0			0			0			0			0	
06/24/24	47930.9			0			0			0			0			1	
06/24/24	51338.8			0			0			0			0			1	
06/24/24	57767.8			1126.9			23.6			166.49			5.74			1	
06/24/24	65825.6			802			12.19			132.67			3.32			1	
06/24/24	60413.3			458.9			18.36			70.47			4.64			1	
06/24/24	45262.3			0			23.6			20.82			4.5			0	
06/24/24	44927.3			0			9.65			9.7			1.84			0	
06/24/24	44482.5			0			0.2			0			0			0	
06/24/24	44147.5			0			0.1			0			0			0	
06/24/24	44095.5			0			0.1			0			0			0	

CT1 SUSD EVENT 21

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	43754.7			0			0			0			0			0	
06/24/24	43720			0			0			0			0			0	
06/24/24	43662.3			0			0			0			0			0	
06/24/24	43633.4			0			0			0			0			0	
06/24/24	43627.6			0			0			0			0			0	
06/24/24	45620.4			0			0			0			0			1	
06/24/24	48086.8			0			0			0			0			1	
06/24/24	54013.2			20.9			0.7			0			0			1	
06/24/24	61938.2			949.9			20.65			138.85			4.97			1	
06/24/24	71359.1			586.5			24.29			101.36			6.91			1	
06/24/24	84424.9			242.5			31.57			48.69			10.43			1	
06/24/24	47642.1			115.3			37.81			13.53			7.3			1	
06/24/24	42587.9			0			30.43			6.11			5.38			0	
06/24/24	42108.5			0			29.5			10.06			5.17			0	
06/24/24	41877.4			0			0.3			0			0			0	
06/24/24	41692.6			0			0.2			0			0			0	
06/24/24	41600.2			0			0.2			0			0			0	

CT1 SUSD EVENT 22

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	43754.7			0			0			0			0			0	
06/24/24	43720			0			0			0			0			0	
06/24/24	43662.3			0			0			0			0			0	
06/24/24	43633.4			0			0			0			0			0	
06/24/24	43627.6			0			0			0			0			0	
06/24/24	45620.4			0			0			0			0			1	
06/24/24	48086.8			0			0			0			0			1	
06/24/24	54013.2			20.9			0.7			0			0			1	
06/24/24	61938.2			949.9			20.65			138.85			4.97			1	
06/24/24	71359.1			586.5			24.29			101.36			6.91			1	
06/24/24	84424.9			242.5			31.57			48.69			10.43			1	
06/24/24	47642.1			115.3			37.81			13.53			7.3			1	
06/24/24	42587.9			0			30.43			6.11			5.38			0	
06/24/24	42108.5			0			29.5			10.06			5.17			0	
06/24/24	41877.4			0			0.3			0			0			0	
06/24/24	41692.6			0			0.2			0			0			0	
06/24/24	41600.2			0			0.2			0			0			0	

CT1 SUSD EVENT 23

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	45325.8			0			0			0			0			0	
06/24/24	45389.4			0			0			0			0			0	
06/24/24	45348.9			0			0			0			0			0	
06/24/24	45221.8			0			0			0			0			0	
06/24/24	45308.5			0			0			0			0			0	
06/24/24	47595.9			0			0			0			0			1	
06/24/24	51708.5			0			0			0			0			1	
06/24/24	58489.8			2106.3			64.9			306.47			15.54			1	
06/24/24	66819.1			877			24.02			140.76			6.35			1	
06/24/24	76632.8			446.8			29.83			81.6			8.97			1	
06/24/24	96497.1			180.7			36.24			41.21			13.61			1	
06/24/24	51928			90.3			44.38			11			8.89			1	
06/24/24	46296.2			0			34.81			5.09			6.22			0	
06/24/24	46122.9			0			0.7			0			0			0	
06/24/24	46163.4			0			0.4			0			0			0	
06/24/24	45909.2			0			0.3			0			0			0	
06/24/24	45932.3			0			0.3			0			0			0	

CT1 SUSD EVENT 24

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	45325.8			0			0			0			0			0	
06/24/24	45389.4			0			0			0			0			0	
06/24/24	45348.9			0			0			0			0			0	
06/24/24	45221.8			0			0			0			0			0	
06/24/24	45308.5			0			0			0			0			0	
06/24/24	47595.9			0			0			0			0			1	
06/24/24	51708.5			0			0			0			0			1	
06/24/24	58489.8			2106.3			64.9			306.47			15.54			1	
06/24/24	66819.1			877			24.02			140.76			6.35			1	
06/24/24	76632.8			446.8			29.83			81.6			8.97			1	
06/24/24	96497.1			180.7			36.24			41.21			13.61			1	
06/24/24	51928			90.3			44.38			11			8.89			1	
06/24/24	46296.2			0			34.81			5.09			6.22			0	
06/24/24	46122.9			0			0.7			0			0			0	
06/24/24	46163.4			0			0.4			0			0			0	
06/24/24	45909.2			0			0.3			0			0			0	
06/24/24	45932.3			0			0.3			0			0			0	

CT1 SUSD EVENT 25

Date/Time Mod	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	30509.9			0			0			0			0			0	
06/24/24	30544.5			0			0			0			0			0	
06/24/24	30469.4			0			0			0			0			0	
06/24/24	30209.5			0			0			0			0			0	
06/24/24	30284.6			0			0			0			0			0	
06/24/24	33652.1			0			0			0			0			1	
06/24/24	38550.3			0			0			0			0			1	
06/24/24	46810.3			3363			106.2			412.53			21.44			1	
06/24/24	56531.6			922.9			22.76			134.29			5.45			1	
06/24/24	67512.2			546.6			30.19			93.85			8.53			1	
06/24/24	87116.6			235.1			35.99			51.16			12.89			1	
06/24/24	128387.6			123.9			44.52			38.97			23.04			1	
06/24/24	142146.5			67.5			60.09			23.37			34.23			1	
06/24/24	155194.9			599.8			66.93			226.09			41.52			1	
06/24/24	174337.2			1621.2			61.86			684.09			42.96			1	
06/24/24	197540.2			416.7			63.81			198.69			50.07			1	
06/24/24	219680.4			33.9			61.95			17.94			53.93			1	
06/24/24	242559.9			2.4			68.2			1.37			65.38			1	
06/24/24	267518.8			1.4			88.93			0.89			93.8			1	
06/24/24	289485.7			1.3			47.49			0.92			54.11			1	
06/24/24	309985.4			1.4			20.83			1.06			25.37			1	
06/24/24	329780.5			1.5			12.07			1.2			15.63			1	
06/24/24	342892.5			1.4			10.82			1.17			14.56			1	
06/24/24	346739.3			1.4			8.44			1.13			11.48			1	
06/24/24	346710.5			1.2			6.44			0.98			8.77			1	
06/24/24	346375.5			1.1			5.9			0.9			8.02			1	
06/24/24	346467.9			1			5.54			0.82			7.53			1	
06/24/24	345792.1			0.9			5.44			0.76			7.38			1	
06/24/24	344636.9			0.8			5.07			0.68			6.86			1	
06/24/24	344209.4			0.8			4.61			0.68			6.23			1	
06/24/24	343510.5			0.7			4.52			0.6			6.09			1	
06/24/24	343013.8			0.7			4.43			0.6			5.95			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	342823.1			0.7			4.33			0.6			5.82			1	
06/24/24	342228.2			0.7			4.24			0.6			5.69			1	
06/24/24	342078			0.6			4.24			0.53			5.69			1	
06/24/24	341945.2			0.6			4.06			0.52			5.43			1	
06/24/24	341818.1			0.6			4.06			0.53			5.44			1	
06/24/24	341679.4			0.6			3.96			0.53			5.31			1	
06/24/24	341165.4			0.6			3.96			0.52			5.31			1	
06/24/24	340853.4			0.6			4.06			0.52			5.42			1	
06/24/24	340772.6			0.7			4.12			0.53			5.51			1	
06/24/24	340888.1			0.6			4.06			0.52			5.42			1	
06/24/24	340547.3			0.7			4.12			0.53			5.51			1	
06/24/24	340177.6			0.6			3.69			0.52			4.92			1	
06/24/24	340478			0.7			3			0.53			4.01			1	
06/24/24	340125.7			0.6			2.86			0.52			3.82			1	
06/24/24	340166.1			0.6			2.86			0.52			3.82			1	
06/24/24	339553.8			0.7			3.28			0.53			4.37			1	
06/24/24	339813.7			0.6			2.95			0.52			3.94			1	
06/24/24	339438.3			0.7			2.34			0.53			3.12			1	
06/24/24	339958.1			0.7			2.15			0.53			2.88			1	
06/24/24	339640.4			0.6			2.12			0.52			2.83			1	
06/24/24	339865.7			0.6			2.21			0.52			2.95			1	
06/24/24	339611.6			0.6			2.4			0.52			3.2			1	
06/24/24	349673.7			0.7			2.43			0.55			3.34			1	
06/24/24	367966.9			0.7			1.87			0.57			2.7			1	
06/24/24	378826.2			0.7			1.62			0.6			2.4			1	
06/24/24	381460.1			0.7			1.62			0.61			2.42			1	
06/24/24	388391.5			0.6			2.28			0.53			3.48			1	
06/24/24	407614.8			0.6			2.09			0.55			3.34			1	
06/24/24	424746.9			0.6			1.55			0.59			2.57			1	
06/24/24	420824.9			0.6			2.34			0.56			3.86			1	
06/24/24	419987.3			0.6			2.15			0.56			3.54			1	
06/24/24	422107.2			0.7			1.5			0.66			2.48			1	
06/24/24	423222			0.6			1.4			0.57			2.33			1	
06/24/24	423216.3			0.6			1.4			0.57			2.33			1	
06/24/24	424036.5			0.7			1.5			0.66			2.49			1	

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/24/24	424255.9			0.7			1.59			0.66			2.64			1	
06/24/24	424100			0.7			1.69			0.66			2.8			1	
06/24/24	425105.1			0.7			1.69			0.66			2.81			1	
06/24/24	424989.5			0.7			1.69			0.66			2.81			1	
06/24/24	425382.3			0.7			1.69			0.66			2.81			1	
06/24/24	424960.6			0.7			1.59			0.66			2.65			1	
06/24/24	426641.5			0.7			1.5			0.67			2.5			0	
06/24/24	426289.3			0.7			1.5			0.66			2.5			0	
06/24/24	426734			0.7			1.5			0.67			2.5			0	
06/24/24	425440			0.7			1.5			0.66			2.5			0	
06/24/24	425804			0.7			1.5			0.66			2.5			0	

Monthly Summary By Day Report

Unit CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/04/2024 02:52 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
04/01/2024	0.00	0.00	0.0	0.00	0.00
04/02/2024	0.00	0.00	0.0	0.00	0.00
04/03/2024	0.00	0.00	0.0	0.00	0.00
04/04/2024	67.06	60.47	4.9	9.97	16.60
04/05/2024	15.68	55.70	6.0	12.20	20.34
04/06/2024	15.28	49.60	5.0	10.86	18.09
04/07/2024	15.58	48.94	4.8	10.59	17.63
04/08/2024	15.56	49.71	5.1	10.98	18.25
04/09/2024	16.68	50.26	5.3	11.17	18.63
04/10/2024	15.76	46.93	4.8	10.50	17.47
04/11/2024	15.43	48.05	4.8	10.62	17.65
04/12/2024	14.83	48.15	4.8	10.56	17.55
04/13/2024	15.74	47.62	4.8	10.56	17.52
04/14/2024	15.65	46.83	4.9	10.63	17.66
04/15/2024	15.22	46.23	4.8	10.56	17.54
04/16/2024	15.50	46.08	4.8	10.51	17.49
04/17/2024	15.09	47.62	4.8	10.56	17.55
04/18/2024	14.45	47.17	4.8	10.56	17.62
04/19/2024	13.71	47.27	4.8	10.53	17.51
04/20/2024	13.64	47.05	4.8	10.54	17.55
04/21/2024	14.03	46.92	4.9	10.76	17.90
04/22/2024	14.84	47.89	5.2	10.98	18.29
04/23/2024	14.22	50.12	5.4	11.37	18.92
04/24/2024	13.93	48.21	5.1	10.86	18.10
04/25/2024	14.32	48.19	5.0	10.91	18.20
04/26/2024	13.91	47.66	4.8	10.57	17.69
04/27/2024	14.41	48.59	5.0	10.82	18.07
04/28/2024	14.17	49.23	5.3	11.13	18.55
04/29/2024	14.42	47.48	5.0	10.83	18.01
04/30/2024	14.65	50.22	5.4	11.28	18.80
Monthly Avg/Sum:	453.76 sum	1,318.19 sum	135.1 sum	291.41 sum	485.18 sum
Daily Min:	13.64	46.08	4.8	9.97	16.60
Daily Max:	67.06	60.47	6.0	12.20	20.34
Apr 2024 - Apr 2024	453.76 sum	1,318.19 sum	135.1 sum	291.41 sum	485.18 sum
QTD:	453.76 sum	1,318.19 sum	135.1 sum	291.41 sum	485.18 sum
YTD 2024:	1,323.49 sum	3,766.18 sum	393.2 sum	818.13 sum	1,363.06 sum

Monthly Summary By Day Report

Unit CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/04/2024 02:52 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
05/01/2024	13.53	46.84	4.9	10.70	17.81
05/02/2024	14.38	48.09	5.4	11.17	18.65
05/03/2024	13.92	46.92	5.0	10.84	18.09
05/04/2024	14.79	50.89	5.5	11.43	18.99
05/05/2024	14.76	46.16	4.8	10.45	17.41
05/06/2024	14.57	46.60	4.8	10.34	17.30
05/07/2024	14.92	45.59	4.8	10.34	17.31
05/08/2024	13.67	45.12	4.8	10.49	17.51
05/09/2024	13.54	44.90	4.8	10.38	17.33
05/10/2024	14.87	45.28	5.0	10.72	17.87
05/11/2024	14.73	47.38	5.6	11.19	18.66
05/12/2024	14.63	44.89	4.8	10.51	17.50
05/13/2024	14.54	45.97	4.9	10.61	17.69
05/14/2024	14.40	45.27	4.8	10.52	17.54
05/15/2024	14.31	45.40	4.9	10.64	17.72
05/16/2024	14.23	47.96	5.5	11.23	18.78
05/17/2024	13.99	45.83	5.0	10.79	17.97
05/18/2024	12.41	41.24	4.8	10.54	17.51
05/19/2024	13.73	44.76	4.8	10.49	17.45
05/20/2024	14.42	45.51	4.9	10.67	17.81
05/21/2024	12.83	66.62	7.7	14.83	24.65
05/22/2024	11.57	71.36	8.1	15.73	26.18
05/23/2024	20.12	30.24	3.1	6.48	10.83
05/24/2024	0.00	0.00	0.0	0.00	0.00
05/25/2024	0.00	0.00	0.0	0.00	0.00
05/26/2024	0.00	0.00	0.0	0.00	0.00
05/27/2024	79.99	31.70	1.9	3.88	6.45
05/28/2024	0.00	0.00	0.0	0.00	0.00
05/29/2024	0.00	0.00	0.0	0.00	0.00
05/30/2024	0.00	0.00	0.0	0.00	0.00
05/31/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	408.85 sum	1,120.52 sum	120.6 sum	254.97 sum	425.01 sum
Daily Min:	11.57	30.24	1.9	3.88	6.45
Daily Max:	79.99	71.36	8.1	15.73	26.18
Apr 2024 - May 2024	862.61 sum	2,438.71 sum	255.7 sum	546.38 sum	910.19 sum
QTD:	862.61 sum	2,438.71 sum	255.7 sum	546.38 sum	910.19 sum
YTD 2024:	1,732.34 sum	4,886.70 sum	513.8 sum	1,073.10 sum	1,788.07 sum

Monthly Summary By Day Report

Unit CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/04/2024 02:52 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
06/01/2024	0.00	0.00	0.0	0.00	0.00
06/02/2024	55.53	25.63	1.5	2.85	4.74
06/03/2024	0.00	0.00	0.0	0.00	0.00
06/04/2024	0.00	0.00	0.0	0.00	0.00
06/05/2024	81.96	22.59	2.5	4.95	8.23
06/06/2024	0.00	0.00	0.0	0.00	0.00
06/07/2024	0.00	0.00	0.0	0.00	0.00
06/08/2024	0.00	0.00	0.0	0.00	0.00
06/09/2024	0.00	0.00	0.0	0.00	0.00
06/10/2024	0.00	0.00	0.0	0.00	0.00
06/11/2024	0.00	0.00	0.0	0.00	0.00
06/12/2024	0.00	0.00	0.0	0.00	0.00
06/13/2024	75.45	22.83	1.4	2.83	4.73
06/14/2024	142.23	29.08	1.7	3.47	5.77
06/15/2024	21.80	6.09	0.5	1.08	1.80
06/16/2024	0.00	0.00	0.0	0.00	0.00
06/17/2024	0.00	0.00	0.0	0.00	0.00
06/18/2024	0.00	0.00	0.0	0.00	0.00
06/19/2024	78.34	48.75	4.0	8.32	13.88
06/20/2024	20.11	56.11	6.2	12.97	21.61
06/21/2024	19.24	51.60	6.1	12.31	20.54
06/22/2024	14.99	44.73	5.0	10.83	18.03
06/23/2024	14.80	46.17	5.5	11.34	18.86
06/24/2024	74.70	36.94	2.5	5.21	8.65
06/25/2024	14.14	57.71	7.3	13.48	22.42
06/26/2024	13.92	43.93	5.0	10.76	17.93
06/27/2024	14.36	44.46	4.8	10.38	17.32
06/28/2024	14.80	43.24	4.8	10.30	17.16
06/29/2024	14.80	42.06	4.8	10.25	17.08
06/30/2024	15.00	41.87	4.8	10.16	17.02
Monthly Avg/Sum:	686.17 sum	663.79 sum	68.4 sum	141.49 sum	235.77 sum
Daily Min:	13.92	6.09	0.5	1.08	1.80
Daily Max:	142.23	57.71	7.3	13.48	22.42
Apr 2024 - Jun 2024	1,548.78 sum	3,102.50 sum	324.1 sum	687.87 sum	1,145.96 sum
QTD:	1,548.78 sum	3,102.50 sum	324.1 sum	687.87 sum	1,145.96 sum
YTD 2024:	2,418.51 sum	5,550.49 sum	582.2 sum	1,214.59 sum	2,023.84 sum

Startup / Shutdown Events

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:29 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
04/01/2024 00:00	04/04/2024 03:00	76
05/23/2024 13:00	05/27/2024 15:00	99
05/28/2024 00:00	06/02/2024 13:00	134
06/02/2024 20:00	06/05/2024 10:00	63
06/05/2024 22:00	06/13/2024 12:00	183
06/13/2024 14:00	06/13/2024 14:00	1
06/13/2024 22:00	06/14/2024 15:00	18
06/15/2024 03:00	06/19/2024 07:00	101
06/24/2024 07:00	06/24/2024 13:00	7
06/24/2024 17:00	06/24/2024 18:00	2

Startup / Shutdown Events

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:29 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	684.00 Hour(s)
Offline Percentage:	31.32 %
Total Online:	1,500.00 Hour(s)
Online Percentage:	68.68 %

Startup / Shutdown Events

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:29 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	04/04/2024 04:27	04/04/2024 06:04	Cold Startup	98
2	05/23/2024 12:05	05/23/2024 12:16	Shutdown	12
3	05/27/2024 16:59	05/27/2024 18:11	Cold Startup	73
4	05/27/2024 23:41	05/27/2024 23:52	Shutdown	12
5	06/02/2024 14:00	06/02/2024 15:10	Cold Startup	71
6	06/02/2024 19:10	06/02/2024 19:20	Shutdown	11
7	06/05/2024 11:50	06/05/2024 12:53	Cold Startup	64
8	06/05/2024 21:20	06/05/2024 21:31	Shutdown	12
9	06/13/2024 13:44	06/13/2024 13:49	Cold Startup	6
10	06/13/2024 13:49	06/13/2024 13:49	Shutdown	1
11	06/13/2024 15:38	06/13/2024 16:28	Cold Startup	51
12	06/13/2024 21:23	06/13/2024 21:33	Shutdown	11
13	06/14/2024 16:30	06/14/2024 17:34	Cold Startup	65
14	06/15/2024 02:22	06/15/2024 02:33	Shutdown	12
15	06/19/2024 08:10	06/19/2024 09:16	Cold Startup	67
16	06/24/2024 06:21	06/24/2024 06:31	Shutdown	11
17	06/24/2024 14:39	06/24/2024 14:43	Cold Startup	5
18	06/24/2024 14:43	06/24/2024 14:43	Shutdown	1
19	06/24/2024 14:58	06/24/2024 15:02	Cold Startup	5
20	06/24/2024 15:02	06/24/2024 15:02	Shutdown	1
21	06/24/2024 15:28	06/24/2024 15:34	Cold Startup	7
22	06/24/2024 15:34	06/24/2024 15:34	Shutdown	1

Startup / Shutdown Events

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:29 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	06/24/2024 16:44	06/24/2024 16:50	Cold Startup	7
24	06/24/2024 16:50	06/24/2024 16:50	Shutdown	1
25	06/24/2024 19:30	06/24/2024 20:37	Cold Startup	68

Startup / Shutdown Events

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:29 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	13	587	0.66
Warm Startup	0		0.00
Shutdown	12	86	0.10
Total Process Events:	25	673	0.75

Total Report Time:	2,183.98 Hour(s)
Total Operating Time:	1,489.15 Hour(s)
Total Startup Time:	587 Minute(s)
Total Shutdown Time:	86 Minute(s)
Total Startup/Shutdown Time:	673 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.75 %

CT2 SUSD EVENT 1

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/02/24 6:38	0			0			0			0			0			0	
04/02/24 6:39	0			0			0			0			0			0	
04/02/24 6:40	0			0			0			0			0			0	
04/02/24 6:41	0			0			0			0			0			0	
04/02/24 6:42	4135.8			0			0			0			0			0	
04/02/24 6:43	5920.6			0.1			0			0			0			1	
04/02/24 6:44	18443.4			0.1			0			0			0			1	
04/02/24 6:45	33455.7			1280.3			5.9			100.88			0.77			1	
04/02/24 6:46	48260.1			1403.1			6.97			159.56			1.3			1	
04/02/24 6:47	58628.4			1042.8			11.8			144.03			2.68			1	
04/02/24 6:48	71174.3			643.1			16.15			107.82			4.46			1	
04/02/24 6:49	100869.8			477.6			19.67			113.43			7.69			1	
04/02/24 6:50	148662			359.6			25.4			125.91			14.63			1	
04/02/24 6:51	158764.6			251.6			39.19			94.05			24.11			1	
04/02/24 6:52	171056.3			1085			40.75			437.19			27.02			1	
04/02/24 6:53	192387.8			1810.8			41.3			820.39			30.79			1	
04/02/24 6:54	215359.8			1000.8			47.51			507.65			39.66			1	
04/02/24 6:55	238880.4			277.8			54.06			156.3			50.05			1	
04/02/24 6:56	262458.8			28.8			55.56			17.78			56.51			1	
04/02/24 6:57	288365.1			4.6			59.22			3.1			66.19			1	
04/02/24 6:58	316010			4.2			47.51			3.1			58.17			1	
04/02/24 6:59	339727.1			3.8			25.96			3.05			34.18			1	
04/02/24 7:00	360885.3			3.8			19.32			3.2			27.03			1	
04/02/24 7:01	381812.5			3.8			15.99			3.46			23.66			1	
04/02/24 7:02	401827			3.6			12.91			3.4			20.11			1	
04/02/24 7:03	422991			3.3			9.46			3.28			15.5			1	
04/02/24 7:04	445703			2.8			7.66			2.96			13.23			1	
04/02/24 7:05	470650.4			2.4			6.63			2.62			12.09			1	
04/02/24 7:06	493477.9			1.9			5.9			2.25			11.28			1	
04/02/24 7:07	490618.7			1.6			6.35			1.89			12.08			1	
04/02/24 7:08	490942.2			1.5			5.9			1.68			11.23			1	
04/02/24 7:09	489544.4			1.4			5.54			1.57			10.5			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/02/24 7:10	491358			1.4			5.45			1.58			10.37			1	
04/02/24 7:11	489879.3			1.4			5.45			1.57			10.34			1	
04/02/24 7:12	489157.3			1.2			5.45			1.36			10.32			1	
04/02/24 7:13	487545.8			1.1			5.45			1.25			10.29			1	
04/02/24 7:14	487181.8			1			5.45			1.15			10.28			1	
04/02/24 7:15	488735.6			1			5.53			1.17			10.48			1	
04/02/24 7:16	486511.8			1.1			5.53			1.27			10.43			1	
04/02/24 7:17	488221.6			1.1			5.45			1.25			10.3			1	
04/02/24 7:18	480972.5			1.1			5.62			1.25			10.48			1	
04/02/24 7:19	459745			0.9			5.62			1			10.02			1	
04/02/24 7:20	436628.5			0.9			5.81			0.95			9.83			1	
04/02/24 7:21	409220.6			0.9			6.35			0.86			10.07			1	
04/02/24 7:22	387178.5			1			5.46			0.88			8.19			1	
04/02/24 7:23	363230.4			1.1			2.38			0.98			3.35			1	
04/02/24 7:24	338132.8			1.2			1.56			0.97			2.05			1	
04/02/24 7:25	314219.4			1.4			1.94			1.04			2.36			1	
04/02/24 7:26	289439.5			1.5			2.36			0.99			2.65			1	
04/02/24 7:27	265214.1			1.5			4.21			0.94			4.33			1	
04/02/24 7:28	241231.4			1.5			11.6			0.84			10.85			1	
04/02/24 7:29	215619.7			1.7			17.26			0.89			14.42			1	
04/02/24 7:30	192047			37.3			13.33			16.86			9.92			1	
04/02/24 7:31	175561.8			295.5			9.79			122.19			6.66			1	
04/02/24 7:32	173823.1			721.8			7.14			295.52			4.81			1	
04/02/24 7:33	180148.1			745			6.52			316			4.55			1	
04/02/24 7:34	202149.6			593.7			6.54			282.66			5.12			1	
04/02/24 7:35	228044.3			192.5			7.77			103.4			6.87			1	
04/02/24 7:36	251969.3			24.2			8.08			14.39			7.89			1	
04/02/24 7:37	277176.6			2.3			8.33			1.51			8.95			1	
04/02/24 7:38	304954.3			1.9			5.16			1.36			6.1			1	
04/02/24 7:39	330877.9			1.6			1.78			1.24			2.28			1	
04/02/24 7:40	351187			1.5			1.16			1.26			1.58			1	
04/02/24 7:41	372859.3			1.5			0.79			1.31			1.15			1	
04/02/24 7:42	392417.5			1.6			0.79			1.46			1.21			1	
04/02/24 7:43	414107.2			1.5			0.63			1.48			1			1	
04/02/24 7:44	436969.4			1.3			0.54			1.31			0.92			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/02/24 7:45	462702.3			1.1			0.45			1.19			0.81			1	
04/02/24 7:46	478101.7			1			0.46			1.14			0.85			1	
04/02/24 7:47	483935.6			0.9			0.47			1.07			0.88			1	
04/02/24 7:48	485518.3			1			0.55			1.16			1.04			1	
04/02/24 7:49	483918.3			1.1			0.55			1.26			1.04			1	
04/02/24 7:50	483843.3			1			0.65			1.16			1.21			0	
04/02/24 7:51	484114.8			0.9			0.65			1.05			1.21			0	
04/02/24 7:52	481665.6			0.9			0.65			1.05			1.2			0	
04/02/24 7:53	484288			1			0.65			1.16			1.21			0	
04/02/24 7:54	482381.8			1			0.74			1.15			1.38			0	

CT2 SUSD EVENT 2

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/02/24	465867.7			0.9			0.37			1.03			0.68			0	
04/02/24	465786.8			0.8			0.37			0.91			0.67			0	
04/02/24	468657.6			0.9			0.37			1.03			0.68			0	
04/02/24	467074.9			0.8			0.37			0.93			0.68			0	
04/02/24	469928.4			0.7			0.37			0.83			0.68			0	
04/02/24	468825.1			0.8			0.37			0.93			0.68			1	
04/02/24	468293.8			0.8			0.47			0.93			0.85			1	
04/02/24	453760.8			0.7			0.47			0.8			0.82			1	
04/02/24	431949.8			0.7			0.47			0.76			0.78			1	
04/02/24	407580			0.8			0.46			0.8			0.73			1	
04/02/24	384827.6			0.8			0.54			0.74			0.81			1	
04/02/24	362098.3			0.8			0.54			0.69			0.75			1	
04/02/24	335077.3			0.9			0.54			0.71			0.7			1	
04/02/24	311204.2			1			0.63			0.72			0.75			1	
04/02/24	287521.8			0.9			0.65			0.62			0.72			1	
04/02/24	265260.3			0.8			0.86			0.48			0.88			1	
04/02/24	239417.6			0.6			1.97			0.33			1.83			1	
04/02/24	215053.6			0.5			6.64			0.27			5.53			1	
04/02/24	190262.2			13			10.6			5.83			7.81			1	
04/02/24	168254.9			202.6			12.47			80.28			8.13			1	
04/02/24	147720.5			755.2			15.13			262.7			8.66			1	
04/02/24	67835.7			1309.8			16.83			209.34			4.43			1	
04/02/24	0			0			18.03			0			0			0	
04/02/24	0			0			11.8			0			0			0	
04/02/24	0			0			0.2			0			0			0	
04/02/24	0			0			0.1			0			0			0	
04/02/24	0			0			0.1			0			0			0	

CT2 SUSD EVENT 3

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/09/24	0			0			0			0			0			0	
04/09/24	0			0			0			0			0			0	
04/09/24	0			0			0			0			0			0	
04/09/24	0			0			0			0			0			0	
04/09/24	0			0			0			0			0			0	
04/09/24	16375.5			0.2			0			0			0			1	
04/09/24	27974.1			1.6			0			0			0			1	
04/09/24	40993.7			1368			12.64			131.98			2.01			1	
04/09/24	52644.3			1059.1			13.28			131.33			2.71			1	
04/09/24	64237.1			632.5			17.39			95.72			4.33			1	
04/09/24	84927.4			425.6			20.23			85.08			6.65			1	
04/09/24	132615.7			289.4			23.34			90.36			12			1	
04/09/24	157938.6			193.2			35.84			71.87			21.94			1	
04/09/24	198984.2			449.7			40.23			210.67			31.02			1	
04/09/24	230054.4			420			53.25			227.5			47.47			1	
04/09/24	256295.7			21.1			55.07			12.76			54.69			1	
04/09/24	281069.8			1.6			57.25			1.08			62.37			1	
04/09/24	308194.8			1.3			41.79			0.93			49.91			1	
04/09/24	333355.9			1.3			24.85			1.05			32.11			1	
04/09/24	354167.6			1.6			19.96			1.3			27.39			1	
04/09/24	373968.4			1.7			17.96			1.53			26.06			1	
04/09/24	379403.8			1.7			12.93			1.55			19.01			1	
04/09/24	378889.7			1.6			10.67			1.39			15.67			1	
04/09/24	378485.4			1.5			8.94			1.31			13.11			1	
04/09/24	378063.7			1.4			7.66			1.25			11.22			1	
04/09/24	377052.9			1.4			6.43			1.25			9.39			1	
04/09/24	375909.2			1.3			5.46			1.17			7.95			1	
04/09/24	375429.8			1.3			5.01			1.11			7.28			1	
04/09/24	374332.3			1.1			4.47			0.95			6.48			1	
04/09/24	375331.5			1.1			4.11			0.95			5.98			1	
04/09/24	374973.4			1.1			4.02			0.95			5.85			1	
04/09/24	374297.6			1.1			3.93			0.95			5.71			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/09/24	372969.1			1.1			3.75			0.94			5.43			1	
04/09/24	373240.6			1.1			3.58			0.94			5.17			1	
04/09/24	372905.6			1.1			3.49			0.94			5.04			1	
04/09/24	372680.3			1			3.54			0.88			5.11			1	
04/09/24	372911.3			1			3.54			0.88			5.12			1	
04/09/24	371392.2			1			3.45			0.87			4.96			1	
04/09/24	371109.1			0.9			3.45			0.79			4.96			1	
04/09/24	371802.3			0.9			3.54			0.79			5.1			1	
04/09/24	371767.6			0.8			3.54			0.72			5.1			1	
04/09/24	371992.9			0.8			3.63			0.72			5.23			1	
04/09/24	371917.8			0.9			3.63			0.8			5.23			1	
04/09/24	369260.8			0.9			3.63			0.79			5.2			1	
04/09/24	369618.9			0.9			3.63			0.79			5.2			1	
04/09/24	368983.5			0.9			3.72			0.79			5.32			1	
04/09/24	369861.5			0.9			3.72			0.79			5.33			1	
04/09/24	368642.7			0.9			3			0.79			4.28			1	
04/09/24	369116.4			0.9			2.18			0.79			3.12			1	
04/09/24	368354			0.8			2.09			0.71			2.98			1	
04/09/24	369844.2			0.8			2			0.71			2.86			1	
04/09/24	367585.7			0.8			2.09			0.71			2.97			1	
04/09/24	367707			0.8			2.09			0.71			2.97			1	
04/09/24	367707			0.8			2.18			0.71			3.1			1	
04/09/24	367551			0.9			2.18			0.79			3.1			1	
04/09/24	367782.1			0.9			2.18			0.79			3.11			1	
04/09/24	367926.5			0.8			2.09			0.71			2.98			1	
04/09/24	368313.5			0.6			2			0.55			2.85			1	
04/09/24	368174.9			0.6			2			0.55			2.85			1	
04/09/24	367146.7			0.7			1.91			0.63			2.71			1	
04/09/24	367314.2			0.9			1.82			0.79			2.58			1	
04/09/24	367112			0.9			1.82			0.78			2.58			1	
04/09/24	367787.9			0.9			1.72			0.79			2.46			1	
04/09/24	366863.7			0.9			1.72			0.78			2.45			1	
04/09/24	368833.3			0.9			1.72			0.79			2.47			1	
04/09/24	368463.7			0.9			1.63			0.79			2.33			1	
04/09/24	367458.6			0.9			1.63			0.79			2.33			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/09/24	367568.4			0.9			1.63			0.79			2.33			1	
04/09/24	367181.4			0.9			1.63			0.78			2.33			0	
04/09/24	366557.5			0.9			1.63			0.78			2.32			0	
04/09/24	367320			1			1.54			0.86			2.2			0	
04/09/24	367227.6			1			1.54			0.86			2.2			0	
04/09/24	366956.1			1			1.54			0.86			2.19			0	

CT2 SUSD EVENT 4

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/09/24	367787.9			0.9			1.54			0.79			2.2			0	
04/09/24	368585			0.9			1.52			0.78			2.17			0	
04/09/24	368775.6			0.9			1.52			0.78			2.17			0	
04/09/24	367672.3			0.9			1.52			0.77			2.17			0	
04/09/24	368463.7			1			1.52			0.85			2.17			0	
04/09/24	364131.5			1			1.52			0.84			2.14			1	
04/09/24	344700.4			1			1.52			0.8			2.03			1	
04/09/24	320399.9			1			2.06			0.74			2.55			1	
04/09/24	297098.8			0.9			2.63			0.63			3.03			1	
04/09/24	274461.8			0.8			3.56			0.54			3.78			1	
04/09/24	248942.6			0.8			6.77			0.45			6.53			1	
04/09/24	225456.6			0.7			20.49			0.38			17.91			1	
04/09/24	199359.7			4			33.13			1.86			25.59			1	
04/09/24	175983.4			108.9			38.22			45.12			26.06			1	
04/09/24	156148			618.5			42.45			227.47			25.69			1	
04/09/24	124985.4			1274.1			43.59			375.03			21.12			1	
04/09/24	0			0			46.15			0			0			0	
04/09/24	0			0			47.2			0			0			0	
04/09/24	0			0			0.5			0			0			0	
04/09/24	0			0			0.5			0			0			0	
04/09/24	0			0			0.4			0			0			0	

CT2 SUSD EVENT 5

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/10/24	0			0			0			0			0			0	
04/10/24	0			0			0			0			0			0	
04/10/24	0			0			0			0			0			0	
04/10/24	0			0			0			0			0			0	
04/10/24	7179.8			0			0			0			0			0	
04/10/24	12164.7			0.2			0			0			0			1	
04/10/24	27292.5			7.9			0.3			0			0			1	
04/10/24	40982.1			1341.1			14.16			129.38			2.25			1	
04/10/24	53042.8			967.9			15.27			120.9			3.14			1	
04/10/24	65034.2			568.2			21.54			86.99			5.43			1	
04/10/24	89883.4			387.8			27.35			82.12			9.53			1	
04/10/24	137121.2			253.2			36.63			81.79			19.47			1	
04/10/24	148355.9			167.2			52.69			58.44			30.3			1	
04/10/24	155437.5			784.9			54.89			287.26			33.06			1	
04/10/24	170519.1			1738.5			55.6			698.16			36.75			1	
04/10/24	191388.5			1197.4			57.03			539.54			42.3			1	
04/10/24	217017.5			393.3			58.86			200.98			49.5			1	
04/10/24	243027.8			47.1			60.67			26.94			57.15			1	
04/10/24	266883.5			3.5			58.09			2.21			60.09			1	
04/10/24	296018.6			2.1			49.13			1.49			56.36			1	
04/10/24	320001.3			1.9			22.13			1.46			27.44			1	
04/10/24	342580.5			1.9			14.35			1.56			19.06			1	
04/10/24	365084.6			1.9			12.5			1.67			17.69			1	
04/10/24	376475.3			1.8			10.67			1.62			15.57			1	
04/10/24	377642			1.6			8.98			1.41			13.15			1	
04/10/24	379207.4			1.4			8.19			1.26			12.03			1	
04/10/24	377243.5			1.4			8.1			1.25			11.85			1	
04/10/24	374967.7			1.3			7.66			1.17			11.13			1	
04/10/24	373627.6			1.3			7.33			1.1			10.62			1	
04/10/24	372408.8			1.3			7.15			1.1			10.32			1	
04/10/24	372628.3			1.2			6.97			1.02			10.07			1	
04/10/24	372587.8			1.2			6.79			1.02			9.81			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/10/24	372131.6			1			6.62			0.86			9.54			1	
04/10/24	371992.9			1			6.44			0.86			9.28			1	
04/10/24	371317.1			0.9			6.54			0.79			9.4			1	
04/10/24	371848.5			0.9			6.44			0.79			9.29			1	
04/10/24	370312			0.9			6.44			0.79			9.25			1	
04/10/24	371247.8			1			6.35			0.87			9.14			1	
04/10/24	370756.8			1			6.35			0.87			9.13			1	
04/10/24	370970.5			1			6.35			0.87			9.14			1	
04/10/24	369422.5			0.9			6.35			0.79			9.1			1	
04/10/24	368908.4			0.9			6.26			0.79			8.95			1	
04/10/24	368637			0.9			6.26			0.79			8.95			1	
04/10/24	369601.5			0.8			6.26			0.71			8.97			1	
04/10/24	369480.3			0.8			4.45			0.71			6.37			1	
04/10/24	368036.2			0.9			2.72			0.79			3.88			1	
04/10/24	369052.8			0.9			2.63			0.79			3.76			1	
04/10/24	368267.3			0.9			2.54			0.79			3.63			1	
04/10/24	368943.1			0.8			2.72			0.71			3.89			1	
04/10/24	368030.4			0.8			3			0.71			4.27			1	
04/10/24	368677.4			0.9			3.27			0.79			4.67			1	
04/10/24	368042			0.9			3.45			0.79			4.92			1	
04/10/24	367487.5			0.9			3.54			0.79			5.04			1	
04/10/24	367972.7			0.9			3.36			0.79			4.79			1	
04/10/24	367065.8			0.8			2.54			0.71			3.62			1	
04/10/24	368400.2			0.8			2.36			0.71			3.37			1	
04/10/24	368943.1			0.9			2.27			0.79			3.24			1	
04/10/24	368117.1			0.9			2.18			0.79			3.11			1	
04/10/24	368463.7			0.9			2.18			0.79			3.11			1	
04/10/24	368533			0.9			2.18			0.79			3.11			1	
04/10/24	366574.8			0.8			2.18			0.71			3.09			1	
04/10/24	368180.7			0.8			2.18			0.71			3.11			1	
04/10/24	368694.7			0.7			2.09			0.63			2.98			1	
04/10/24	368377			0.7			2.09			0.63			2.98			1	
04/10/24	367747.5			0.8			2			0.71			2.85			1	
04/10/24	368498.3			0.9			2			0.79			2.85			1	
04/10/24	368434.8			0.9			1.91			0.79			2.72			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/10/24	367487.5			0.9			1.82			0.79			2.59			1	
04/10/24	368844.9			0.9			1.72			0.79			2.47			1	
04/10/24	366696.1			0.8			1.63			0.71			2.32			1	
04/10/24	367972.7			0.7			1.63			0.63			2.33			1	
04/10/24	367366.2			0.7			1.63			0.63			2.33			1	
04/10/24	366112.8			0.8			1.63			0.7			2.32			1	
04/10/24	368065.1			0.8			1.54			0.71			2.2			1	
04/10/24	366707.7			0.8			1.54			0.71			2.19			0	
04/10/24	367955.4			0.8			1.54			0.71			2.2			0	
04/10/24	368862.3			0.9			1.54			0.79			2.21			0	
04/10/24	367689.6			0.9			1.54			0.79			2.2			0	
04/10/24	366026.1			0.8			1.54			0.7			2.19			0	

CT2 SUSD EVENT 6

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
04/11/24 0:34	368590.8			0.8			1.52			0.7			2.17			0	
04/11/24 0:35	368504.1			0.9			1.52			0.78			2.17			0	
04/11/24 0:36	368677.4			0.9			1.52			0.78			2.17			0	
04/11/24 0:37	367764.7			0.9			1.52			0.77			2.17			0	
04/11/24 0:38	368873.8			0.9			1.52			0.78			2.17			0	
04/11/24 0:39	364391.5			0.9			1.52			0.77			2.15			1	
04/11/24 0:40	345965.4			0.9			1.52			0.73			2.04			1	
04/11/24 0:41	321786.2			0.9			2.06			0.68			2.56			1	
04/11/24 0:42	298381.1			0.9			2.63			0.64			3.04			1	
04/11/24 0:43	274045.9			0.9			3.5			0.59			3.72			1	
04/11/24 0:44	249266			0.9			6.47			0.5			6.25			1	
04/11/24 0:45	225710.7			0.7			21.22			0.39			18.56			1	
04/11/24 0:46	200081.7			4.9			32.56			2.3			25.25			1	
04/11/24 0:47	176324.2			118.4			36.28			49.15			24.79			1	
04/11/24 0:48	156587			659.2			41.59			243.04			25.23			1	
04/11/24 0:49	127550			1315.5			42.61			395.19			21.07			1	
04/11/24 0:50	0			1458.7			44.05			0			0			1	
04/11/24 0:51	0			0			82.6			0			0			0	
04/11/24 0:52	0			0			0.5			0			0			0	
04/11/24 0:53	0			0			0.4			0			0			0	
04/11/24 0:54	0			0			0.4			0			0			0	
04/11/24 0:55	0			0			0.3			0			0			0	

CT2 SUSD EVENT 7

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	2553.1			0			0			0			0			0	
05/04/24	0			0			0			0			0			1	
05/04/24	22636.9			0			0			0			0			1	
05/04/24	32219.6			8.7			0.1			0			0			1	
05/04/24	45435.6			1576.6			11.8			167.28			2.06			1	
05/04/24	57403.9			1110.3			14.38			148.87			3.17			1	
05/04/24	69297			684.7			18.01			110.81			4.8			1	
05/04/24	96734			495.9			20.79			112.11			7.74			1	
05/04/24	144324.1			396.4			27.09			133.71			15.04			1	
05/04/24	169317.7			264.4			37.09			104.66			24.15			1	
05/04/24	190244.9			877.8			40.93			390.24			29.95			1	
05/04/24	207140.2			814.8			42.7			394.52			34.02			1	
05/04/24	216387.9			324.8			45.14			164.23			37.57			1	
05/04/24	194409.5			68.9			48.2			31.32			36.05			1	
05/04/24	173043.3			337.3			50.87			136.45			33.86			1	
05/04/24	153213.6			1100.4			55.17			394.09			32.52			1	
05/04/24	48167.7			1775.9			57.31			199.96			10.62			1	
05/04/24	0			0			79.28			0			0			0	
05/04/24	0			0			660.8			0			0			0	
05/04/24	0			0			649			0			0			0	
05/04/24	0			0			578.2			0			0			0	
05/04/24	0			0			519.2			0			0			0	

CT2 SUSD EVENT 8

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	0			0			0			0			0			0	
05/04/24	2553.1			0			0			0			0			0	
05/04/24	0			0			0			0			0			1	
05/04/24	22636.9			0			0			0			0			1	
05/04/24	32219.6			8.7			0.1			0			0			1	
05/04/24	45435.6			1576.6			11.8			167.28			2.06			1	
05/04/24	57403.9			1110.3			14.38			148.87			3.17			1	
05/04/24	69297			684.7			18.01			110.81			4.8			1	
05/04/24	96734			495.9			20.79			112.11			7.74			1	
05/04/24	144324.1			396.4			27.09			133.71			15.04			1	
05/04/24	169317.7			264.4			37.09			104.66			24.15			1	
05/04/24	190244.9			877.8			40.93			390.24			29.95			1	
05/04/24	207140.2			814.8			42.7			394.52			34.02			1	
05/04/24	216387.9			324.8			45.14			164.23			37.57			1	
05/04/24	194409.5			68.9			48.2			31.32			36.05			1	
05/04/24	173043.3			337.3			50.87			136.45			33.86			1	
05/04/24	153213.6			1100.4			55.17			394.09			32.52			1	
05/04/24	48167.7			1775.9			57.31			199.96			10.62			1	
05/04/24	0			0			79.28			0			0			0	
05/04/24	0			0			660.8			0			0			0	
05/04/24	0			0			649			0			0			0	
05/04/24	0			0			578.2			0			0			0	
05/04/24	0			0			519.2			0			0			0	

CT2 SUSD EVENT 9

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/16/24	0			0	X		0	X		0	X		0	X		0	
05/16/24	0			0	X		0	X		0	X		0	X		0	
05/16/24	0			0	X		0	X		0	X		0	X		0	
05/16/24	0			0	X		0	X		0	X		0	X		0	
05/16/24	0			0	X		0	X		0	X		0	X		0	
05/16/24	12979.1			-0.2	X		0	X		0	X		0	X		1	
05/16/24	28187.8			3.4	X		0	X		0	X		0	X		1	
05/16/24	42408.8			1423.4	X		14.75	X		141.15	X		2.41	X		1	
05/16/24	53799.5			1049.5	X		14.75	X		132.02	X		3.05	X		1	
05/16/24	65565.6			627.6	X		18.32	X		96.23	X		4.62	X		1	
05/16/24	90894.3			405.2	X		20.38	X		86.08	X		7.13	X		1	
05/16/24	137479.3			274	X		27.7	X		88	X		14.65	X		1	
05/16/24	150342.9			182.7	X		22.34	X		64.2	X		12.92	X		1	
05/16/24	166036.8			732.3	X		18.95	X		284.08	X		12.1	X		1	
05/16/24	186888.9			1441.5	X		18.39	X		629.54	X		13.22	X		1	
05/16/24	212679.6			591.7	X		16.04	X		294.02	X		13.11	X		1	
05/16/24	238204.6			90.9	X		13.9	X		50.58	X		12.73	X		1	
05/16/24	261165			5.1	X		12.26	X		3.11	X		12.32	X		1	
05/16/24	290681.4			1.7	X		11.17	X		1.15	X		12.49	X		1	
05/16/24	315813.6			1.5	X		10.09	X		1.12	X		12.25	X		1	
05/16/24	336186.3			1.5	X		9.33	X		1.18	X		12.07	X		1	
05/16/24	340657			1.6	X		9.2	X		1.31	X		12.05	X		1	
05/16/24	348628.2			1.6	X		9.2	X		1.27	X		12.33	X		1	
05/16/24	357367.6			1.6	X		9.2	X		1.3	X		12.64	X		1	
05/16/24	366973.4			1.5	X		9.2	X		1.26	X		12.98	X		1	
05/16/24	376417.5			1.5	X		9.33	X		1.32	X		13.51	X		1	
05/16/24	384856.5			1.3	X		9.07	X		1.19	X		13.43	X		1	
05/16/24	404518.6			1.3	X		7.78	X		1.18	X		12.1	X		1	
05/16/24	417024.2			1.1	X		6.99	X		1.06	X		11.21	X		1	
05/16/24	419796.8			0.9	X		6.91	X		0.9	X		11.16	X		1	
05/16/24	419005.4			0.8	X		6.82	X		0.81	X		10.99	X		1	
05/16/24	419571.5			0.7	X		6.64	X		0.72	X		10.71	X		1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/16/24	418144.8			0.7	X		6.55	X		0.72	X		10.53	X		1	
05/16/24	416897			0.7	X		6.36	X		0.72	X		10.2	X		1	
05/16/24	418225.6			0.7	X		6.27	X		0.72	X		10.08	X		1	
05/16/24	419975.8			0.6	X		6.18	X		0.63	X		9.98	X		1	
05/16/24	419005.4			0.6	X		6.08	X		0.63	X		9.8	X		1	
05/16/24	425082			0.6	X		5.99	X		0.64	X		9.8	X		1	
05/16/24	445830			0.7	X		5.81	X		0.68	X		9.96	X		1	
05/16/24	449082.1			0.7	X		5.9	X		0.69	X		10.19	X		1	
05/16/24	449578.8			0.7	X		6.74	X		0.69	X		11.66	X		1	
05/16/24	451433			0.7	X		6.46	X		0.69	X		11.22	X		1	
05/16/24	448146.3			0.6	X		6.56	X		0.59	X		11.3	X		1	
05/16/24	450699.4			0.6	X		6.65	X		0.59	X		11.53	X		1	
05/16/24	451716			0.7	X		6.65	X		0.69	X		11.55	X		1	
05/16/24	454147.8			0.7	X		6.09	X		0.7	X		10.63	X		1	
05/16/24	458104.5			0.7	X		6.18	X		0.7	X		10.89	X		1	
05/16/24	460773.1			0.7	X		6.27	X		0.71	X		11.12	X		1	
05/16/24	460553.6			0.6	X		6.27	X		0.69	X		11.1	X		1	
05/16/24	459698.7			0.6	X		6.36	X		0.69	X		11.25	X		1	
05/16/24	460790.4			0.6	X		6.08	X		0.69	X		10.78	X		1	
05/16/24	461067.7			0.6	X		5.16	X		0.7	X		9.16	X		1	
05/16/24	460339.8			0.6	X		4.89	X		0.69	X		8.65	X		1	
05/16/24	461113.9			0.6	X		4.33	X		0.7	X		7.68	X		1	
05/16/24	461102.3			0.6	X		4.15	X		0.6	X		7.36	X		1	
05/16/24	461911			0.6	X		4.12	X		0.61	X		7.32	X		1	
05/16/24	460183.9			0.6	X		3.87	X		0.59	X		6.85	X		1	
05/16/24	461396.9			0.6	X		3.78	X		0.7	X		6.71	X		1	
05/16/24	462298			0.6	X		3.6	X		0.6	X		6.39	X		1	
05/16/24	461333.4			0.6	X		3.6	X		0.6	X		6.38	X		1	
05/16/24	458670.5			0.5	X		3.6	X		0.49	X		6.34	X		1	
05/16/24	461506.6			0.6	X		3.5	X		0.6	X		6.22	X		1	
05/16/24	461945.7			0.6	X		3.41	X		0.7	X		6.06	X		1	
05/16/24	461506.7			0.6	X		3.23	X		0.7	X		5.73	X		1	
05/16/24	462633			0.6	X		2.49	X		0.7	X		4.43	X		1	
05/16/24	462904.5			0.6	X		2.21	X		0.7	X		3.94	X		1	
05/16/24	463476.3			0.6	X		2.03	X		0.7	X		3.62	X		1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/16/24	462205.5			0.6	X		1.75	X		0.7	X		3.11	X		1	
05/16/24	462563.7			0.6	X		1.57	X		0.6	X		2.79	X		1	
05/16/24	461212.1			0.6	X		1.48	X		0.6	X		2.62	X		1	
05/16/24	460363			0.6	X		1.29	X		0.6	X		2.29	X		1	
05/16/24	460391.9			0.6	X		1.22	X		0.6	X		2.16	X		1	
05/16/24	459629.4			0.6	X		1.03	X		0.6	X		1.82	X		1	
05/16/24	459259.8			0.6	X		0.94	X		0.6	X		1.65	X		1	
05/16/24	458815			0.6	X		0.94	X		0.6	X		1.65	X		1	
05/16/24	459438.8			0.6	X		0.84	X		0.6	X		1.49	X		1	
05/16/24	459693			0.6	X		0.84	X		0.6	X		1.49	X		1	
05/16/24	450612.8			0.6	X		0.75	X		0.59	X		1.3	X		0	
05/16/24	430967.9			0.6	X		0.75	X		0.57	X		1.24	X		0	
05/16/24	412339.7			0.6	X		0.74	X		0.53	X		1.17	X		0	
05/16/24	409601.8			0.6	X		0.64	X		0.61	X		1	X		0	
05/16/24	409416.9			0.6	X		0.64	X		0.61	X		1	X		0	

CT2 SUSD EVENT 10

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/16/24	391938.1			0.7			1.59			0.65			2.39			0	
05/16/24	389593			0.7			1.59			0.64			2.37			0	
05/16/24	382066.6			0.6			1.5			0.55			2.2			0	
05/16/24	370057.9			0.6			1.41			0.53			2.01			0	
05/16/24	369376.3			0.7			1.41			0.61			2			0	
05/16/24	365783.5			0.8			1.41			0.68			1.98			1	
05/16/24	347721.3			0.8			1.41			0.64			1.88			1	
05/16/24	324056.3			0.7			1.85			0.53			2.3			1	
05/16/24	300506.7			0.7			2.32			0.5			2.69			1	
05/16/24	277673.4			0.6			3.13			0.42			3.35			1	
05/16/24	251004.7			0.6			5.8			0.33			5.6			1	
05/16/24	228766.3			0.5			18.92			0.27			16.65			1	
05/16/24	201930.1			5.1			29.05			2.42			22.56			1	
05/16/24	179616.7			113.6			33.52			47.68			23.15			1	
05/16/24	159244			576			39.29			214.31			24.05			1	
05/16/24	141488			1214.3			42.12			401.46			22.92			1	
05/16/24	11176.9			1351.3			43.96			35.39			1.89			1	
05/16/24	0			0			63.72			0			0			0	
05/16/24	0			0			0.5			0			0			0	
05/16/24	0			0			0.4			0			0			0	
05/16/24	0			0			0.4			0			0			0	
05/16/24	0			0			0.4			0			0			0	

CT2 SUSD EVENT 11

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/20/24	0			0			0			0			0			0	
05/20/24	0			0			0			0			0			0	
05/20/24	0			0			0			0			0			0	
05/20/24	10322.1			0			0			0			0			0	
05/20/24	0			0			0			0			0			0	
05/20/24	15266.5			-0.1			0			0			0			1	
05/20/24	28355.4			1.7			0			0			0			1	
05/20/24	41767.7			1644.1			15.73			160.46			2.53			1	
05/20/24	53476			1107.6			14.16			138.35			2.91			1	
05/20/24	65068.9			665.7			19.01			101.18			4.76			1	
05/20/24	88115.9			446.2			21.63			91.88			7.33			1	
05/20/24	135578.9			311.4			27.45			98.64			14.31			1	
05/20/24	150296.7			210.2			39.77			73.83			22.99			1	
05/20/24	162340			704.5			43.51			267.3			27.17			1	
05/20/24	182366.1			1745.5			40.94			743.94			28.72			1	
05/20/24	205476.7			942.7			50.71			452.65			40.07			1	
05/20/24	230886.2			219.1			63.21			118.22			56.12			1	
05/20/24	252552.7			16.6			64.41			9.8			62.57			1	
05/20/24	279354.3			2.3			59.33			1.5			63.73			1	
05/20/24	307322.6			1.8			43.4			1.29			51.29			1	
05/20/24	330479.4			1.6			21.97			1.26			27.92			1	
05/20/24	351701.1			1.6			15.36			1.36			20.77			1	
05/20/24	368775.5			1.7			14.58			1.5			20.67			1	
05/20/24	375504.9			1.6			10.69			1.43			15.44			1	
05/20/24	375539.5			1.6			10.06			1.37			14.54			1	
05/20/24	374540.2			1.5			10.41			1.29			15			1	
05/20/24	373454.3			1.4			9.2			1.21			13.21			1	
05/20/24	372200.8			1.2			9.16			1.07			13.11			1	
05/20/24	371138			1.1			8.37			0.92			11.94			1	
05/20/24	371790.8			1.1			8.01			0.92			11.46			1	
05/20/24	370641.3			1.1			7.93			0.92			11.3			1	
05/20/24	371686.8			1.1			7.75			0.92			11.08			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/20/24	368891.1			1.1			7.57			0.91			10.74			1	
05/20/24	369289.7			1			7.4			0.84			10.51			1	
05/20/24	369099.1			1			7.33			0.85			10.4			1	
05/20/24	369584.3			0.9			7.24			0.77			10.29			1	
05/20/24	369878.8			0.9			7.15			0.77			10.17			1	
05/20/24	368706.3			0.8			7.06			0.69			10.01			1	
05/20/24	375857.2			0.8			6.97			0.71			10.08			1	
05/20/24	393775			0.7			6.44			0.66			9.75			1	
05/20/24	409422.7			0.7			5.81			0.71			9.14			1	
05/20/24	413350.5			0.7			6.08			0.71			9.67			1	
05/20/24	410774.3			0.7			6.36			0.71			10.05			1	
05/20/24	403819.8			0.7			6.64			0.7			10.31			1	
05/20/24	400619.8			0.7			6.63			0.68			10.21			1	
05/20/24	396940.3			0.7			6.73			0.68			10.27			1	
05/20/24	392434.9			0.7			6.72			0.67			10.14			1	
05/20/24	385520.8			0.6			6.08			0.57			9.02			1	
05/20/24	377930.8			0.6			3.13			0.55			4.55			1	
05/20/24	372351			0.7			2.23			0.62			3.2			1	
05/20/24	368267.3			0.7			2.32			0.62			3.29			1	
05/20/24	365795			0.7			2.5			0.61			3.52			1	
05/20/24	365922.1			0.8			3.22			0.69			4.53			1	
05/20/24	365194.4			0.7			3.4			0.61			4.77			1	
05/20/24	364489.6			0.7			3.49			0.61			4.89			1	
05/20/24	364108.4			0.7			3.75			0.61			5.26			1	
05/20/24	364154.6			0.7			3.75			0.61			5.26			1	
05/20/24	364905.5			0.7			2.9			0.62			4.08			1	
05/20/24	363906.3			0.8			2.63			0.69			3.68			1	
05/20/24	365575.6			0.8			2.45			0.7			3.45			1	
05/20/24	364345.3			0.8			2.27			0.7			3.18			1	
05/20/24	364697.6			0.8			2.27			0.7			3.18			1	
05/20/24	365512			0.8			2.36			0.7			3.32			1	
05/20/24	364639.8			0.7			2.32			0.61			3.26			1	
05/20/24	364940.2			0.7			2.41			0.61			3.39			1	
05/20/24	365171.3			0.8			2.36			0.7			3.31			1	
05/20/24	365327.2			0.8			2.18			0.7			3.06			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/20/24	365229			0.8			2			0.7			2.81			1	
05/20/24	364420.3			0.8			1.79			0.69			2.51			1	
05/20/24	365148.1			0.9			1.61			0.76			2.26			1	
05/20/24	364732.2			0.9			1.52			0.76			2.13			1	
05/20/24	363848.5			0.9			1.54			0.77			2.16			1	
05/20/24	364351			0.8			1.63			0.7			2.29			1	
05/20/24	363900.5			0.8			1.63			0.69			2.29			1	
05/20/24	365125			0.8			1.61			0.69			2.26			1	
05/20/24	364148.8			0.8			1.7			0.68			2.38			1	
05/20/24	364911.3			0.8			1.72			0.7			2.42			1	
05/20/24	363808			0.8			1.72			0.69			2.41			0	
05/20/24	363652.1			0.7			1.72			0.62			2.41			0	
05/20/24	364039.1			0.8			1.72			0.7			2.41			0	
05/20/24	364056.4			0.8			1.63			0.7			2.29			0	
05/20/24	365356.1			0.7			1.52			0.61			2.14			0	

CT2 SUSD EVENT 12

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/29/24	428247.3			0.8			1.45			0.82			2.39			0	
05/29/24	428836.5			0.7			1.45			0.73			2.4			0	
05/29/24	430320.9			0.7			1.45			0.73			2.4			0	
05/29/24	428495.7			0.6			1.45			0.64			2.39			0	
05/29/24	427300			0.6			1.54			0.63			2.54			0	
05/29/24	425076.2			0.8			1.54			0.81			2.52			1	
05/29/24	414719.5			0.8			1.54			0.79			2.46			1	
05/29/24	393359.1			0.7			1.63			0.67			2.47			1	
05/29/24	369688.3			0.7			2.15			0.62			3.05			1	
05/29/24	347438.3			0.8			2.29			0.64			3.06			1	
05/29/24	321029.5			0.9			2.47			0.66			3.04			1	
05/29/24	298485			0.9			3.45			0.63			3.96			1	
05/29/24	274918.1			0.7			4.15			0.47			4.39			1	
05/29/24	249144.7			0.6			7.23			0.33			6.93			1	
05/29/24	226542.5			0.5			21.32			0.27			18.58			1	
05/29/24	199677.4			3.4			33.13			1.59			25.45			1	
05/29/24	175769.7			104.7			37.71			42.99			25.49			1	
05/29/24	156153.7			576.6			42.02			210.39			25.23			1	
05/29/24	127538.5			1169.3			42.94			348.66			21.07			1	
05/29/24	0			0			48.46			0			0			0	
05/29/24	0			0			76.7			0			0			0	
05/29/24	0			0			0.3			0			0			0	
05/29/24	0			0			0.3			0			0			0	
05/29/24	0			0			11.8			0			0			0	

CT2 SUSD EVENT 13

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/30/24	0			0			0			0			0			0	
05/30/24	0			0			0			0			0			0	
05/30/24	0			0			0			0			0			0	
05/30/24	0			0			0			0			0			0	
05/30/24	0			0			0			0			0			0	
05/30/24	14382.7			-0.1			0			0			0			1	
05/30/24	28257.2			8.5			0.4			0			0			1	
05/30/24	43610.3			1347.6			21.24			137.25			3.56			1	
05/30/24	54238.5			993.4			21.02			125.86			4.38			1	
05/30/24	65958.4			558.4			25.37			86.13			6.44			1	
05/30/24	88560.7			376.3			29.5			77.91			10.05			1	
05/30/24	136745.7			243.6			36.63			77.87			19.27			1	
05/30/24	153693.1			155.4			50.66			55.84			29.95			1	
05/30/24	165014.4			756.9			59.18			291.91			37.57			1	
05/30/24	186328.6			1479			56.74			643.92			40.66			1	
05/30/24	210721.5			593.5			57.49			292.27			46.59			1	
05/30/24	235795.9			92			58.06			50.69			52.66			1	
05/30/24	258334.7			5.2			56.88			3.13			56.51			1	
05/30/24	287013.5			1.6			57.28			1.08			63.23			1	
05/30/24	311787.6			1.3			30.18			0.92			36.32			1	
05/30/24	337283.8			1.3			16.63			1.06			21.7			1	
05/30/24	357517.8			1.5			12.59			1.26			17.47			1	
05/30/24	375256.5			1.5			11.71			1.3			17.04			1	
05/30/24	377699.8			1.4			9.25			1.25			13.49			1	
05/30/24	378572			1.1			8.63			1.02			12.67			1	
05/30/24	377226.2			1.1			8.63			0.94			12.65			1	
05/30/24	375060.1			1			8.1			0.86			11.8			1	
05/30/24	376481			1			7.51			0.88			11.02			1	
05/30/24	378785.7			1			7.6			0.88			11.22			1	
05/30/24	396963.4			1			6.79			0.92			10.5			1	
05/30/24	419161.4			0.9			6.18			0.91			10.08			1	
05/30/24	443773.7			0.7			6.09			0.79			10.52			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/30/24	449128.3			0.7			6.37			0.8			11.13			1	
05/30/24	433145.5			0.7			6.93			0.77			11.68			1	
05/30/24	430032.2			0.8			6.28			0.78			10.52			1	
05/30/24	430667.5			0.7			6.18			0.76			10.35			1	
05/30/24	434179.5			0.7			6.18			0.77			10.44			1	
05/30/24	434809.1			0.7			6.27			0.67			10.62			1	
05/30/24	436212.7			0.7			6.28			0.69			10.66			1	
05/30/24	438367.2			0.8			6.09			0.79			10.38			1	
05/30/24	439626.4			0.7			4.09			0.69			7			1	
05/30/24	441486.4			0.7			2.81			0.68			4.83			1	
05/30/24	442312.4			0.6			2.85			0.6			4.91			1	
05/30/24	443271.2			0.6			2.95			0.6			5.09			1	
05/30/24	446835.1			0.6			3.28			0.59			5.7			1	
05/30/24	448192.5			0.6			3.56			0.6			6.21			1	
05/30/24	451248.1			0.6			3.75			0.6			6.57			1	
05/30/24	452634.4			0.6			3.75			0.6			6.6			1	
05/30/24	457139.9			0.6			2.9			0.61			5.17			1	
05/30/24	459843.1			0.6			2.53			0.61			4.53			1	
05/30/24	462003.4			0.6			2.53			0.61			4.55			1	
05/30/24	464856.8			0.7			2.53			0.72			4.57			1	
05/30/24	466693.7			0.6			2.72			0.62			4.93			1	
05/30/24	467202			0.6			2.95			0.71			5.37			1	
05/30/24	466630.2			0.6			2.77			0.71			5.02			1	
05/30/24	465879.3			0.6			2.12			0.71			3.85			1	
05/30/24	467727.6			0.6			1.94			0.71			3.52			1	
05/30/24	467848.9			0.6			1.84			0.71			3.36			1	
05/30/24	467461.9			0.6			1.84			0.71			3.36			1	
05/30/24	466757.2			0.7			1.94			0.81			3.52			1	
05/30/24	466815			0.6			1.94			0.71			3.52			1	
05/30/24	466393.3			0.6			2.03			0.71			3.68			1	
05/30/24	466763			0.6			1.94			0.61			3.52			1	
05/30/24	466867			0.6			1.94			0.71			3.52			1	
05/30/24	466901.6			0.6			1.84			0.71			3.35			1	
05/30/24	466815			0.7			1.75			0.81			3.18			1	
05/30/24	467467.7			0.6			1.66			0.71			3.01			0	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
05/30/24	467964.5			0.6			1.57			0.61			2.85			0	
05/30/24	467427.3			0.6			1.57			0.61			2.84			0	
05/30/24	464943.5			0.6			1.57			0.61			2.83			0	
05/30/24	464810.7			0.6			1.57			0.71			2.83			0	

CT2 SUSD EVENT 14

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	364732.3			-0.2	X		1.42	X		-0.2	X		1.99	X		0	
06/14/24	366338			0.1	X		3.46	X		0.09	X		4.89	X		0	
06/14/24	367233.3			0.4	X		3.6	X		0.32	X		5.1	X		0	
06/14/24	366494			0.6	X		3.69	X		0.55	X		5.22	X		0	
06/14/24	365639.1			0.6			3.96			0.55			5.6			0	
06/14/24	358112.7			0.7			4.06			0.62			5.61			1	
06/14/24	339392.1			0.6			4.33			0.51			5.68			1	
06/14/24	315438.2			0.7			4.81			0.54			5.86			1	
06/14/24	292044.5			0.6			5.07			0.44			5.72			1	
06/14/24	267778.8			0.7			6.28			0.42			6.49			1	
06/14/24	244581.5			0.5			9.44			0.28			8.91			1	
06/14/24	219755.4			0.3			24.41			0.16			20.71			1	
06/14/24	192913.5			0.4			42.97			0.2			32.01			1	
06/14/24	168260.6			46.3			47.45			18.28			30.82			1	
06/14/24	148760.2			457.6			48.21			159.69			27.69			1	
06/14/24	110931.9			1312.7			50.07			341.73			21.45			1	
06/14/24	0			0			53.1			0			0			0	
06/14/24	0			0			70.8			0			0			0	
06/14/24	0			0			0.3			0			0			0	
06/14/24	0			0			0.3			0			0			0	
06/14/24	0			0			0.2			0			0			0	

CT2 SUSD EVENT 15

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	0			0			0			0			0			0	
06/14/24	0			0			0			0			0			0	
06/14/24	0			0			0			0			0			0	
06/14/24	0			0			0			0			0			0	
06/14/24	0			0			0			0			0			0	
06/14/24	12505.5			-0.1			0			0			0			1	
06/14/24	27552.5			29.5			5.9			1.91			0.63			1	
06/14/24	41346			309.8			17.11			30.02			2.73			1	
06/14/24	53198.8			303.5			18.44			37.91			3.79			1	
06/14/24	64156.2			173.3			22.98			26.06			5.69			1	
06/14/24	86186.6			119.4			27.81			24.14			9.25			1	
06/14/24	132933.4			94.7			34.63			29.52			17.77			1	
06/14/24	159573.3			83.4			50.57			31.23			31.15			1	
06/14/24	209485.4			428.2			58.46			210.39			47.28			1	
06/14/24	238620.5			170.5			61.25			95.47			56.43			1	
06/14/24	262181.6			4.1			57.23			2.54			57.94			1	
06/14/24	290404.1			0.7			52.78			0.5			59.17			1	
06/14/24	316951.5			0.9			24.46			0.64			29.93			1	
06/14/24	338993.5			0.7			16.29			0.56			21.32			1	
06/14/24	357927.9			0.8			12.84			0.66			17.74			1	
06/14/24	373702.7			1			12.15			0.84			17.52			1	
06/14/24	378092.6			1			9.98			0.85			14.56			1	
06/14/24	376689			0.9			10.13			0.78			14.73			1	
06/14/24	378479.6			0.8			9.95			0.7			14.54			1	
06/14/24	376394.4			0.7			9.69			0.62			14.08			1	
06/14/24	374702			0.8			8.67			0.71			12.54			1	
06/14/24	374707.8			0.8			7.06			0.71			10.22			1	
06/14/24	373026.8			0.8			5.99			0.7			8.63			1	
06/14/24	376105.6			0.7			5.63			0.63			8.18			1	
06/14/24	382315			0.7			4.72			0.65			6.97			1	
06/14/24	379634.8			0.6			4.36			0.57			6.39			1	
06/14/24	373962.6			0.6			4.72			0.56			6.81			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/14/24	371461.5			0.7			4.72			0.63			6.77			1	
06/14/24	370641.3			0.6			4.36			0.55			6.23			1	
06/14/24	371016.8			0.6			4.36			0.55			6.24			1	
06/14/24	371455.7			0.6			4.45			0.55			6.38			1	
06/14/24	370889.7			0.6			4.54			0.55			6.5			1	
06/14/24	370751			0.6			4.63			0.55			6.63			1	
06/14/24	368596.5			0.5			4.72			0.47			6.72			1	
06/14/24	369699.8			0.6			4.81			0.55			6.87			1	
06/14/24	368492.6			0.6			4.9			0.55			6.97			1	
06/14/24	368925.8			0.6			5.07			0.48			7.22			1	
06/14/24	370271.6			0.6			3.41			0.48			4.88			1	
06/14/24	369058.6			0.5			1.27			0.47			1.81			1	
06/14/24	369289.7			0.6			1.01			0.48			1.45			1	
06/14/24	367753.2			0.5			0.82			0.47			1.16			1	
06/14/24	369653.6			0.5			0.54			0.47			0.78			1	
06/14/24	368613.8			0.6			0.46			0.48			0.66			1	
06/14/24	368631.2			0.6			0.36			0.55			0.52			1	
06/14/24	368423.3			0.6			0.27			0.55			0.39			1	
06/14/24	369584.3			0.7			0.28			0.64			0.39			1	
06/14/24	368203.8			0.7			0.28			0.64			0.39			1	
06/14/24	368255.8			0.7			0.27			0.63			0.39			1	
06/14/24	368255.7			0.7			0.18			0.63			0.26			0	
06/14/24	368758.3			0.6			0.18			0.56			0.26			0	
06/14/24	368273			0.6			0.18			0.56			0.26			0	
06/14/24	367106.3			0.7			0.18			0.63			0.26			0	
06/14/24	367389.3			0.7			0.18			0.64			0.26			0	

CT2 SUSD EVENT 16

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/19/24 9:26	404957.7			0.9			1.69			0.89			2.64			0	
06/19/24 9:27	406719.5			0.8			1.59			0.8			2.5			0	
06/19/24 9:28	405720.1			0.8			1.5			0.8			2.35			0	
06/19/24 9:29	404784.4			1			1.52			0.9			2.38			0	
06/19/24 9:30	404559.1			0.9			1.4			0.89			2.19			0	
06/19/24 9:31	402826.3			0.9			1.4			0.89			2.18			1	
06/19/24 9:32	387733.1			0.9			1.5			0.85			2.24			1	
06/19/24 9:33	366938.8			0.8			1.94			0.71			2.74			1	
06/19/24 9:34	342413			0.8			2.45			0.66			3.24			1	
06/19/24 9:35	317610			0.9			2.54			0.68			3.12			1	
06/19/24 9:36	294268.4			1.1			3.13			0.76			3.56			1	
06/19/24 9:37	270609.1			1			3.81			0.67			3.99			1	
06/19/24 9:38	246193.1			0.8			6.48			0.45			6.17			1	
06/19/24 9:39	221881.1			0.5			19.56			0.27			16.81			1	
06/19/24 9:40	195946			3			31.66			1.38			24.35			1	
06/19/24 9:41	171189.2			88.9			36.17			36.11			24.18			1	
06/19/24 9:42	151821.6			575.6			39.86			208.35			23.75			1	
06/19/24 9:43	124188.2			1344.5			39.33			401.8			19.34			1	
06/19/24 9:44	0			0			45.73			13.71			0.59			0	
06/19/24 9:45	0			0			47.2			25.31			0.49			0	
06/19/24 9:46	0			0			11.8			0.93			0.08			0	
06/19/24 9:47	0			0			0.2			0			0			0	
06/19/24 9:48	0			0			0.2			0			0			0	

CT2 SUSD EVENT 17

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/21/24	0			0			0			0			0			0	
06/21/24	0			0			0			0			0			0	
06/21/24	0			0			0			0			0			0	
06/21/24	0			0			0			0			0			0	
06/21/24	0			0			0			0			0			0	
06/21/24	6556			0.1			0			0			0			1	
06/21/24	19367.6			0			0			0			0			1	
06/21/24	33704.1			896.8			17.7			82.71			2.69			1	
06/21/24	46683.2			1219.9			14.52			148.83			2.92			1	
06/21/24	58599.5			890.9			17.7			134.01			4.38			1	
06/21/24	71145.4			528.3			20.95			94.97			6.2			1	
06/21/24	104942			372.2			24.67			96.82			10.56			1	
06/21/24	146917.6			228			32.57			81.55			19.17			1	
06/21/24	148662			157.1			47.2			57.02			28.19			1	
06/21/24	162692.4			1312.9			44.8			519.31			29.16			1	
06/21/24	183197.9			1524.1			47.89			676.87			35.01			1	
06/21/24	206845.7			701.2			57.6			350.32			47.36			1	
06/21/24	234057.3			126.6			59.27			71.29			54.93			1	
06/21/24	257306.5			8			58.76			4.96			59.79			1	
06/21/24	283894.3			2			56.85			1.39			63.63			1	
06/21/24	309719.8			1.9			32.4			1.43			39.55			1	
06/21/24	334239.7			1.8			18.68			1.43			24.56			1	
06/21/24	355975.5			1.8			14.53			1.57			20.32			1	
06/21/24	372894			2			13.1			1.78			19.18			1	
06/21/24	376827.6			1.8			9.46			1.64			14			1	
06/21/24	376879.6			1.8			9.25			1.58			13.68			1	
06/21/24	375943.8			1.5			8.54			1.34			12.61			1	
06/21/24	374361.1			1.3			7.93			1.18			11.65			1	
06/21/24	374713.5			1.2			7.4			1.1			10.88			1	
06/21/24	374274.5			1.1			6.97			0.96			10.24			1	
06/21/24	372714.9			1.1			6.7			0.95			9.81			1	
06/21/24	373182.8			1			6.44			0.87			9.42			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/21/24	372114.2			1			6.26			0.87			9.15			1	
06/21/24	371490.4			1			6.26			0.89			9.14			1	
06/21/24	372033.3			1			5.99			0.87			8.74			1	
06/21/24	371322.9			1			5.9			0.88			8.6			1	
06/21/24	370283.2			1			5.9			0.88			8.58			1	
06/21/24	370843.5			0.9			5.81			0.8			8.45			1	
06/21/24	369815.3			0.8			5.81			0.72			8.43			1	
06/21/24	370404.5			0.8			5.81			0.72			8.43			1	
06/21/24	368481			0.8			5.81			0.72			8.39			1	
06/21/24	368631.2			0.8			5.81			0.72			8.41			1	
06/21/24	370069.5			0.8			5.72			0.72			8.31			1	
06/21/24	370283.2			0.7			5.72			0.64			8.33			1	
06/21/24	369578.5			0.7			5.81			0.64			8.45			1	
06/21/24	368082.5			0.7			5.9			0.64			8.55			1	
06/21/24	368146			0.7			5.9			0.64			8.55			1	
06/21/24	368198			0.7			4.45			0.64			6.44			1	
06/21/24	368896.9			0.8			2.81			0.72			4.08			1	
06/21/24	368047.8			0.8			2.63			0.72			3.81			1	
06/21/24	368769.8			0.8			2.54			0.72			3.69			1	
06/21/24	368781.3			0.7			2.63			0.64			3.82			1	
06/21/24	367614.6			0.7			2.81			0.64			4.07			1	
06/21/24	367181.3			0.6			2.9			0.56			4.2			1	
06/21/24	367787.9			0.7			3.09			0.64			4.46			1	
06/21/24	366869.4			0.8			2.45			0.72			3.54			1	
06/21/24	366470.9			0.8			1.91			0.72			2.75			1	
06/21/24	368122.9			0.8			1.82			0.72			2.62			1	
06/21/24	368151.8			0.7			1.54			0.64			2.23			1	
06/21/24	366909.9			0.7			1.27			0.64			1.83			1	
06/21/24	366361.2			0.7			1.09			0.64			1.57			1	
06/21/24	365881.7			0.8			1.01			0.73			1.46			1	
06/21/24	366933			0.8			0.83			0.73			1.2			1	
06/21/24	367065.8			0.7			0.73			0.64			1.05			1	
06/21/24	366800.1			0.7			0.65			0.65			0.93			1	
06/21/24	367735.9			0.7			0.64			0.64			0.92			1	
06/21/24	366909.9			0.8			0.54			0.72			0.79			0	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/21/24	366938.8			0.8			0.54			0.72			0.79			0	
06/21/24	365090.3			0.7			0.45			0.63			0.65			0	
06/21/24	366361.1			0.7			0.45			0.64			0.65			0	
06/21/24	366101.2			0.7			0.46			0.65			0.66			0	

CT2 SUSD EVENT 18

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/22/24 0:19	366736.6			0.7			1.54			0.62			2.18			0	
06/22/24 0:20	367331.5			0.7			1.54			0.63			2.19			0	
06/22/24 0:21	366892.5			0.7			1.54			0.62			2.19			0	
06/22/24 0:22	366361.1			0.8			1.54			0.7			2.18			0	
06/22/24 0:23	367839.9			0.7			1.54			0.63			2.19			0	
06/22/24 0:24	367759			0.7			1.54			0.63			2.19			1	
06/22/24 0:25	354935.8			0.6			1.54			0.53			2.11			1	
06/22/24 0:26	332581.9			0.7			1.52			0.56			1.95			1	
06/22/24 0:27	308108.2			0.8			2.06			0.58			2.45			1	
06/22/24 0:28	284420			0.8			2.58			0.55			2.83			1	
06/22/24 0:29	261950.6			0.7			3.71			0.41			3.75			1	
06/22/24 0:30	235310.8			0.5			7.38			0.27			6.7			1	
06/22/24 0:31	211241.3			0.5			25.29			0.26			20.62			1	
06/22/24 0:32	186080.2			15.1			33.63			6.59			24.16			1	
06/22/24 0:33	164055.6			220.2			38.62			84.72			24.46			1	
06/22/24 0:34	144439.6			840.2			42.06			284.75			23.46			1	
06/22/24 0:35	67067.4			1434.7			42.69			225.78			11.06			1	
06/22/24 0:36	0			0			46.16			0			0			0	
06/22/24 0:37	0			0			23.6			0			0			0	
06/22/24 0:38	0			0			0.3			0			0			0	
06/22/24 0:39	0			0			0.3			0			0			0	
06/22/24 0:40	0			0			0.2			0			0			0	

CT2 SUSD EVENT 19

Date/Time Mod	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/23/24	0			0			0			0			0			0	
06/23/24	0			0			0			0			0			0	
06/23/24	0			0			0			0			0			0	
06/23/24	0			0			0			0			0			0	
06/23/24	0			0			0			0			0			0	
06/23/24	3511.9			-0.1			0			0			0			1	
06/23/24	23370.5			0.3			0			0			0			1	
06/23/24	38319.3			1244.9			22.62			112.02			3.35			1	
06/23/24	50420.4			942.2			16.96			111.35			3.3			1	
06/23/24	62088.3			506.8			20.95			73.85			5.02			1	
06/23/24	82645.8			287.2			26.55			55.68			8.47			1	
06/23/24	129369.5			171.1			33.43			51.93			16.7			1	
06/23/24	152301			98.8			52.68			35.31			30.97			1	
06/23/24	193831.9			333.5			60.21			151.63			45.05			1	
06/23/24	194305.5			234.7			71.1			106.95			53.33			1	
06/23/24	211385.7			35.5			66.08			17.62			53.92			1	
06/23/24	233572.1			11.4			65.9			6.26			59.43			1	
06/23/24	256590.3			1.1			66.6			0.68			65.98			1	
06/23/24	285465.5			0.8			56.83			0.55			62.64			1	
06/23/24	312388.3			0.8			26.6			0.62			32.08			1	
06/23/24	334857.7			1.1			14.48			0.84			18.72			1	
06/23/24	354468			1.3			11.53			1.04			15.78			1	
06/23/24	371681			1.3			10.13			1.15			14.53			1	
06/23/24	374846.4			1.3			9.12			1.18			13.19			1	
06/23/24	373870.2			1.4			9.08			1.19			13.1			1	
06/23/24	375909.2			1.2			8.26			1.04			11.99			1	
06/23/24	380686.1			1.1			7.9			0.97			11.61			1	
06/23/24	398673.1			1			6.91			0.95			10.64			1	
06/23/24	398528.8			0.9			7.56			0.86			11.63			1	
06/23/24	396258.8			0.9			7.38			0.86			11.28			1	
06/23/24	396345.4			1			7.3			0.96			11.18			1	
06/23/24	396449.3			0.9			7.21			0.87			11.04			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/23/24	396772.8			0.8			7.12			0.78			10.9			1	
06/23/24	395115.1			0.8			7.02			0.78			10.72			1	
06/23/24	395790.9			0.8			6.93			0.78			10.59			1	
06/23/24	395351.8			0.8			6.84			0.78			10.43			1	
06/23/24	395866			0.8			6.74			0.78			10.31			1	
06/23/24	397073.2			0.8			6.74			0.79			10.34			1	
06/23/24	395513.6			0.7			6.74			0.7			10.3			1	
06/23/24	395594.5			0.7			6.65			0.7			10.16			1	
06/23/24	398702.1			0.7			6.56			0.61			10.09			1	
06/23/24	397084.7			0.7			7.12			0.7			10.91			1	
06/23/24	402075.3			0.7			5.99			0.71			9.3			1	
06/23/24	394687.6			0.8			4.95			0.7			7.54			1	
06/23/24	396611.1			0.7			5.15			0.7			7.89			1	
06/23/24	414748.3			0.7			4.61			0.72			7.38			1	
06/23/24	437258.2			0.6			3.87			0.66			6.54			1	
06/23/24	444432.2			0.6			3.75			0.59			6.43			1	
06/23/24	447164.4			0.6			4.03			0.59			6.95			1	
06/23/24	448036.5			0.6			4.21			0.59			7.29			1	
06/23/24	448388.9			0.7			3.37			0.69			5.84			1	
06/23/24	448192.5			0.7			2.81			0.69			4.86			1	
06/23/24	448585.3			0.7			2.81			0.69			4.87			1	
06/23/24	449405.5			0.6			3.18			0.59			5.52			1	
06/23/24	448475.6			0.6			3.37			0.59			5.84			1	
06/23/24	449792.5			0.7			2.81			0.69			4.88			1	
06/23/24	449249.6			0.7			2.15			0.79			3.74			1	
06/23/24	449186			0.7			2.06			0.69			3.57			1	
06/23/24	449971.6			0.7			1.97			0.69			3.42			1	
06/23/24	450069.8			0.7			1.97			0.69			3.42			1	
06/23/24	450664.8			0.6			1.87			0.59			3.26			1	
06/23/24	451600.5			0.6			1.78			0.6			3.1			1	
06/23/24	449786.8			0.7			1.59			0.69			2.76			1	
06/23/24	450017.8			0.7			1.4			0.79			2.44			1	
06/23/24	450595.5			0.7			1.31			0.69			2.28			1	
06/23/24	451548.5			0.6			1.29			0.59			2.25			1	
06/23/24	451612			0.6			1.29			0.68			2.25			1	

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M	
Date/Time Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI
06/23/24	451219.3			0.6			1.29			0.68			2.25			1	
06/23/24	450699.4			0.7			1.31			0.69			2.28			0	
06/23/24	449128.3			0.6			1.38			0.58			2.4			0	
06/23/24	450687.8			0.6			1.38			0.58			2.41			0	
06/23/24	449584.6			0.6			1.38			0.58			2.4			0	
06/23/24	450884.2			0.6			1.48			0.59			2.57			0	

Monthly Summary By Day Report

Unit CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/04/2024 02:55 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
04/01/2024	0.00	0.00	0.0	0.00	0.00
04/02/2024	264.20	23.52	1.3	2.55	4.22
04/03/2024	0.00	0.00	0.0	0.00	0.00
04/04/2024	0.00	0.00	0.0	0.00	0.00
04/05/2024	0.00	0.00	0.0	0.00	0.00
04/06/2024	0.00	0.00	0.0	0.00	0.00
04/07/2024	0.00	0.00	0.0	0.00	0.00
04/08/2024	0.00	0.00	0.0	0.00	0.00
04/09/2024	39.24	21.79	1.0	2.25	3.76
04/10/2024	46.21	26.30	1.4	3.29	5.49
04/11/2024	26.47	4.86	0.2	0.36	0.60
04/12/2024	0.00	0.00	0.0	0.00	0.00
04/13/2024	0.00	0.00	0.0	0.00	0.00
04/14/2024	0.00	0.00	0.0	0.00	0.00
04/15/2024	0.00	0.00	0.0	0.00	0.00
04/16/2024	0.00	0.00	0.0	0.00	0.00
04/17/2024	0.00	0.00	0.0	0.00	0.00
04/18/2024	0.00	0.00	0.0	0.00	0.00
04/19/2024	0.00	0.00	0.0	0.00	0.00
04/20/2024	0.00	0.00	0.0	0.00	0.00
04/21/2024	0.00	0.00	0.0	0.00	0.00
04/22/2024	0.00	0.00	0.0	0.00	0.00
04/23/2024	0.00	0.00	0.0	0.00	0.00
04/24/2024	0.00	0.00	0.0	0.00	0.00
04/25/2024	0.00	0.00	0.0	0.00	0.00
04/26/2024	0.00	0.00	0.0	0.00	0.00
04/27/2024	0.00	0.00	0.0	0.00	0.00
04/28/2024	0.00	0.00	0.0	0.00	0.00
04/29/2024	0.00	0.00	0.0	0.00	0.00
04/30/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	376.12 sum	76.47 sum	3.9 sum	8.45 sum	14.07 sum
Daily Min:	26.47	4.86	0.2	0.36	0.60
Daily Max:	264.20	26.30	1.4	3.29	5.49
Apr 2024 - Apr 2024	376.12 sum	76.47 sum	3.9 sum	8.45 sum	14.07 sum
QTD:	376.12 sum	76.47 sum	3.9 sum	8.45 sum	14.07 sum
YTD 2024:	1,100.94 sum	1,615.72 sum	163.8 sum	334.69 sum	557.72 sum

Monthly Summary By Day Report

Unit CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/04/2024 02:55 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
05/01/2024	0.00	0.00	0.0	0.00	0.00
05/02/2024	0.00	0.00	0.0	0.00	0.00
05/03/2024	0.00	0.00	0.0	0.00	0.00
05/04/2024	43.76	4.76	0.0	0.04	0.06
05/05/2024	0.00	0.00	0.0	0.00	0.00
05/06/2024	0.00	0.00	0.0	0.00	0.00
05/07/2024	0.00	0.00	0.0	0.00	0.00
05/08/2024	0.00	0.00	0.0	0.00	0.00
05/09/2024	0.00	0.00	0.0	0.00	0.00
05/10/2024	0.00	0.00	0.0	0.00	0.00
05/11/2024	0.00	0.00	0.0	0.00	0.00
05/12/2024	0.00	0.00	0.0	0.00	0.00
05/13/2024	0.00	0.00	0.0	0.00	0.00
05/14/2024	0.00	0.00	0.0	0.00	0.00
05/15/2024	0.00	0.00	0.0	0.00	0.00
05/16/2024	21.04	6.50	1.2	2.40	3.99
05/17/2024	0.00	0.00	0.0	0.00	0.00
05/18/2024	0.00	0.00	0.0	0.00	0.00
05/19/2024	0.00	0.00	0.0	0.00	0.00
05/20/2024	40.47	14.64	0.3	0.64	1.08
05/21/2024	11.27	71.67	7.7	15.59	25.99
05/22/2024	9.21	76.52	8.4	16.62	27.70
05/23/2024	14.07	58.93	6.1	12.76	21.24
05/24/2024	15.33	53.25	4.9	11.40	18.92
05/25/2024	15.12	52.74	4.8	11.27	18.76
05/26/2024	15.25	52.17	4.8	11.17	18.61
05/27/2024	15.74	56.89	5.5	12.24	20.39
05/28/2024	15.23	52.96	5.1	11.41	18.97
05/29/2024	27.19	56.55	5.8	11.74	19.57
05/30/2024	46.49	42.68	3.1	6.53	10.89
05/31/2024	14.81	53.12	5.1	11.50	19.15
Monthly Avg/Sum:	304.98 sum	653.38 sum	62.8 sum	135.31 sum	225.32 sum
Daily Min:	9.21	4.76	0.0	0.04	0.06
Daily Max:	46.49	76.52	8.4	16.62	27.70
Apr 2024 - May 2024	681.10 sum	729.85 sum	66.7 sum	143.76 sum	239.39 sum
QTD:	681.10 sum	729.85 sum	66.7 sum	143.76 sum	239.39 sum
YTD 2024:	1,405.92 sum	2,269.10 sum	226.6 sum	470.00 sum	783.04 sum

Monthly Summary By Day Report

Unit CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/04/2024 02:55 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
06/01/2024	15.10	52.25	4.8	11.25	18.77
06/02/2024	14.96	54.87	5.2	11.91	19.80
06/03/2024	14.35	51.65	4.8	11.12	18.56
06/04/2024	14.41	51.96	5.2	11.41	19.06
06/05/2024	15.90	56.09	6.2	12.38	20.66
06/06/2024	14.24	53.34	5.3	11.68	19.40
06/07/2024	13.92	53.07	5.1	11.49	19.12
06/08/2024	14.02	52.38	4.8	11.28	18.75
06/09/2024	14.21	52.29	4.8	11.26	18.71
06/10/2024	16.17	58.13	5.5	12.57	20.93
06/11/2024	17.11	64.21	6.3	14.05	23.37
06/12/2024	17.04	55.96	6.4	13.94	23.22
06/13/2024	19.59	58.98	5.9	12.82	21.35
06/14/2024	34.50	52.17	3.8	8.87	14.74
06/15/2024	13.95	46.57	4.4	10.09	16.83
06/16/2024	21.86	52.33	5.2	11.50	19.16
06/17/2024	37.53	55.49	6.0	12.15	20.22
06/18/2024	31.96	54.92	7.0	12.41	20.70
06/19/2024	33.06	25.50	2.9	4.99	8.31
06/20/2024	0.00	0.00	0.0	0.00	0.00
06/21/2024	50.50	41.85	3.4	6.97	11.60
06/22/2024	19.18	3.88	0.1	0.25	0.41
06/23/2024	17.41	28.25	1.7	3.24	5.39
06/24/2024	16.00	58.45	6.4	12.67	21.14
06/25/2024	16.01	66.20	7.5	14.40	23.96
06/26/2024	16.14	53.55	5.4	11.53	19.25
06/27/2024	16.20	51.71	4.9	11.16	18.64
06/28/2024	16.49	51.14	4.8	11.04	18.40
06/29/2024	16.14	50.91	4.8	11.05	18.34
06/30/2024	16.68	50.85	4.8	10.97	18.24
Monthly Avg/Sum:	574.63 sum	1,458.95 sum	143.4 sum	310.45 sum	517.03 sum
Daily Min:	13.92	3.88	0.1	0.25	0.41
Daily Max:	50.50	66.20	7.5	14.40	23.96
Apr 2024 - Jun 2024	1,255.73 sum	2,188.80 sum	210.1 sum	454.21 sum	756.42 sum
QTD:	1,255.73 sum	2,188.80 sum	210.1 sum	454.21 sum	756.42 sum
YTD 2024:	1,980.55 sum	3,728.05 sum	370.0 sum	780.45 sum	1,300.07 sum

Startup / Shutdown Events

CT2



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:30 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
04/01/2024 00:00	04/02/2024 05:00	30
04/02/2024 12:00	04/09/2024 15:00	172
04/09/2024 22:00	04/10/2024 15:00	18
04/11/2024 01:00	05/04/2024 09:00	561
05/04/2024 12:00	05/16/2024 16:00	293
05/16/2024 23:00	05/20/2024 21:00	95
05/30/2024 00:00	05/30/2024 09:00	10
06/14/2024 17:00	06/14/2024 19:00	3
06/19/2024 10:00	06/21/2024 09:00	48
06/22/2024 01:00	06/23/2024 16:00	40

Startup / Shutdown Events

CT2



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:30 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	1,270.00 Hour(s)
Offline Percentage:	58.15 %
Total Online:	914.00 Hour(s)
Online Percentage:	41.85 %

Startup / Shutdown Events

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:30 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	04/02/2024 06:43	04/02/2024 07:49	cold Startup	67
2	04/02/2024 11:43	04/02/2024 11:59	Shutdown	17
3	04/09/2024 16:33	04/09/2024 17:35	cold Startup	63
4	04/09/2024 21:25	04/09/2024 21:35	Shutdown	11
5	04/10/2024 16:45	04/10/2024 17:53	cold Startup	69
6	04/11/2024 00:39	04/11/2024 00:50	Shutdown	12
7	05/04/2024 10:45	05/04/2024 11:00	cold Startup	16
8	05/04/2024 10:56	05/04/2024 11:00	Shutdown	5
9	05/16/2024 17:36	05/16/2024 18:47	cold Startup	72
10	05/16/2024 22:01	05/16/2024 22:12	Shutdown	12
11	05/20/2024 22:27	05/20/2024 23:38	cold Startup	72
12	05/29/2024 22:56	05/29/2024 23:09	Shutdown	14
13	05/30/2024 10:53	05/30/2024 11:53	cold Startup	61
14	06/14/2024 16:03	06/14/2024 16:13	Shutdown	11
15	06/14/2024 20:57	06/14/2024 21:44	warm Startup	48
16	06/19/2024 09:31	06/19/2024 09:43	Shutdown	13
17	06/21/2024 10:14	06/21/2024 11:14	cold Startup	61
18	06/22/2024 00:24	06/22/2024 00:35	Shutdown	12
19	06/23/2024 17:54	06/23/2024 18:56	cold Startup	63

Startup / Shutdown Events

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/03/2024 23:30 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	9	544	1.01
Warm Startup	1	48	0.09
Shutdown	9	107	0.20
Total Process Events:	19	699	1.29

Total Report Time:	2,183.98 Hour(s)
Total Operating Time:	899.63 Hour(s)
Total Startup Time:	592 Minute(s)
Total Shutdown Time:	107 Minute(s)
Total Startup/Shutdown Time:	699 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.29 %

Replace the dates with the ones you need

4/1/2024 0:00
6/30/2024 0:00

1D

TOWER AVG.

519-AIT-9504-1 3125

4/1/24 0:00	1389.7
4/2/24 0:00	1401.3
4/3/24 0:00	1786.9
4/4/24 0:00	1536.5
4/5/24 0:00	1799.1
4/6/24 0:00	2359.9
4/7/24 0:00	2184.9
4/8/24 0:00	2298.7
4/9/24 0:00	2983.7
4/10/24 0:00	2801.9
4/11/24 0:00	3276.3
4/12/24 0:00	3251.2
4/13/24 0:00	3343.3
4/14/24 0:00	3411.7
4/15/24 0:00	3198.9
4/16/24 0:00	3284.7
4/17/24 0:00	3598.0
4/18/24 0:00	3451.8
4/19/24 0:00	3323.5
4/20/24 0:00	3409.2
4/21/24 0:00	3063.2
4/22/24 0:00	3288.6
4/23/24 0:00	2968.3
4/24/24 0:00	2860.6
4/25/24 0:00	3177.7
4/26/24 0:00	2922.3
4/27/24 0:00	3079.8
4/28/24 0:00	2690.5
4/29/24 0:00	2731.7
4/30/24 0:00	2814.1
5/1/24 0:00	2895.1
5/2/24 0:00	2976.0
5/3/24 0:00	2789.6
5/4/24 0:00	2908.9
5/5/24 0:00	2794.4
5/6/24 0:00	2784.0
5/7/24 0:00	2623.8
5/8/24 0:00	2690.2
5/9/24 0:00	2985.4
5/10/24 0:00	2776.0
5/11/24 0:00	2933.3
5/12/24 0:00	2974.1
5/13/24 0:00	2540.3
5/14/24 0:00	3277.9
5/15/24 0:00	2571.5
5/16/24 0:00	2522.8
5/17/24 0:00	2502.9
5/18/24 0:00	2623.5
5/19/24 0:00	2533.0

5/20/24 0:00	2934.5
5/21/24 0:00	2808.3
5/22/24 0:00	3068.9
5/23/24 0:00	3219.4
5/24/24 0:00	3270.9
5/25/24 0:00	3629.7
5/26/24 0:00	3253.8
5/27/24 0:00	3781.8
5/28/24 0:00	3412.7
5/29/24 0:00	3175.1
5/30/24 0:00	3299.3
5/31/24 0:00	2924.9
6/1/24 0:00	3235.6
6/2/24 0:00	3047.7
6/3/24 0:00	3199.5
6/4/24 0:00	3306.9
6/5/24 0:00	3536.7
6/6/24 0:00	3471.2
6/7/24 0:00	3294.0
6/8/24 0:00	3047.1
6/9/24 0:00	3627.0
6/10/24 0:00	3555.0
6/11/24 0:00	3400.8
6/12/24 0:00	3868.3
6/13/24 0:00	3610.2
6/14/24 0:00	3731.6
6/15/24 0:00	3585.8
6/16/24 0:00	3448.0
6/17/24 0:00	3482.7
6/18/24 0:00	3862.4
6/19/24 0:00	3505.3
6/20/24 0:00	3462.3
6/21/24 0:00	3864.9
6/22/24 0:00	3537.4
6/23/24 0:00	4297.8
6/24/24 0:00	3556.1
6/25/24 0:00	3824.6
6/26/24 0:00	3448.7
6/27/24 0:00	4177.6
6/28/24 0:00	4447.8
6/29/24 0:00	4161.7
6/30/24 0:00	4635.3

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3125	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.002	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.46
----------------------	-------------

91	Days in quarter
----	-----------------

PM-10 pounds this quarter	587	2Q24
---------------------------	------------	-------------