

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	258128
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2024 - Part 5 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public
Submission Date:	7/29/2024 1:55:31 PM
Docketed Date:	7/29/2024

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

4/1/2024 0:00

6/30/2024 0:00

1D

TOWER AVG.

519-AIT-9504-1

3125

4/1/24 0:00	1389.7
4/2/24 0:00	1401.3
4/3/24 0:00	1786.9
4/4/24 0:00	1536.5
4/5/24 0:00	1799.1
4/6/24 0:00	2359.9
4/7/24 0:00	2184.9
4/8/24 0:00	2298.7
4/9/24 0:00	2983.7
4/10/24 0:00	2801.9
4/11/24 0:00	3276.3
4/12/24 0:00	3251.2
4/13/24 0:00	3343.3
4/14/24 0:00	3411.7
4/15/24 0:00	3198.9
4/16/24 0:00	3284.7
4/17/24 0:00	3598.0
4/18/24 0:00	3451.8
4/19/24 0:00	3323.5
4/20/24 0:00	3409.2
4/21/24 0:00	3063.2
4/22/24 0:00	3288.6
4/23/24 0:00	2968.3
4/24/24 0:00	2860.6
4/25/24 0:00	3177.7
4/26/24 0:00	2922.3
4/27/24 0:00	3079.8
4/28/24 0:00	2690.5
4/29/24 0:00	2731.7
4/30/24 0:00	2814.1
5/1/24 0:00	2895.1
5/2/24 0:00	2976.0
5/3/24 0:00	2789.6
5/4/24 0:00	2908.9
5/5/24 0:00	2794.4
5/6/24 0:00	2784.0
5/7/24 0:00	2623.8
5/8/24 0:00	2690.2
5/9/24 0:00	2985.4
5/10/24 0:00	2776.0
5/11/24 0:00	2933.3
5/12/24 0:00	2974.1
5/13/24 0:00	2540.3
5/14/24 0:00	3277.9
5/15/24 0:00	2571.5
5/16/24 0:00	2522.8
5/17/24 0:00	2502.9
5/18/24 0:00	2623.5
5/19/24 0:00	2533.0

5/20/24 0:00	2934.5
5/21/24 0:00	2808.3
5/22/24 0:00	3068.9
5/23/24 0:00	3219.4
5/24/24 0:00	3270.9
5/25/24 0:00	3629.7
5/26/24 0:00	3253.8
5/27/24 0:00	3781.8
5/28/24 0:00	3412.7
5/29/24 0:00	3175.1
5/30/24 0:00	3299.3
5/31/24 0:00	2924.9
6/1/24 0:00	3235.6
6/2/24 0:00	3047.7
6/3/24 0:00	3199.5
6/4/24 0:00	3306.9
6/5/24 0:00	3536.7
6/6/24 0:00	3471.2
6/7/24 0:00	3294.0
6/8/24 0:00	3047.1
6/9/24 0:00	3627.0
6/10/24 0:00	3555.0
6/11/24 0:00	3400.8
6/12/24 0:00	3868.3
6/13/24 0:00	3610.2
6/14/24 0:00	3731.6
6/15/24 0:00	3585.8
6/16/24 0:00	3448.0
6/17/24 0:00	3482.7
6/18/24 0:00	3862.4
6/19/24 0:00	3505.3
6/20/24 0:00	3462.3
6/21/24 0:00	3864.9
6/22/24 0:00	3537.4
6/23/24 0:00	4297.8
6/24/24 0:00	3556.1
6/25/24 0:00	3824.6
6/26/24 0:00	3448.7
6/27/24 0:00	4177.6
6/28/24 0:00	4447.8
6/29/24 0:00	4161.7
6/30/24 0:00	4635.3

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3125	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.002	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.46
----------------------	-------------

91	Days in quarter
----	-----------------

PM-10 pounds this quarter	587		2Q24
---------------------------	------------	--	-------------

III. Emissions Deviations

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/02/24 08:48	200.0	0.0		R-A /Span * 100	0.0
	High	04/02/24 08:58	200.0	179.4	181.5	R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/02/24 08:48	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/02/24 08:53	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/02/24 08:48	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	04/02/24 08:58	200.0	181.7	180.7	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/02/24 08:48	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/02/24 08:53	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/02/24 08:48	21.0	18.0	18.0	R-A	0.0
	Zero	04/02/24 08:53	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/04/24 07:42	200.0	0.0	1.0	R-A /Span * 100	0.5
	High	04/04/24 07:52	200.0	180.2	180.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/04/24 07:42	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/04/24 07:47	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/04/24 07:42	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/04/24 07:52	200.0	180.6	181.7	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/04/24 07:42	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/04/24 07:47	10.0	9.4	9.4	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/04/24 07:42	18.0	18.0	18.0	R-A	0.0
	Zero	04/04/24 07:47	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/04/24 08:38	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/04/24 08:48	200.0	180.6	181.2	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/04/24 08:38	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	04/04/24 08:43	30.0	21.2	21.1	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/05/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/05/24 02:24	200.0	180.6	177.6	R-A /Span * 100	1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/05/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/05/24 02:19	30.0	21.2	20.0	>1x Alert R-A /Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/05/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/05/24 03:24	200.0	180.2	179.9	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/05/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/05/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/05/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/05/24 03:24	200.0	180.6	180.4	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/05/24 03:19	10.0	9.4	9.3	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/05/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	04/05/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/06/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/06/24 02:24	200.0	180.6	176.6	R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/06/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	04/06/24 02:19	30.0	21.2	20.0	>1x Alert R-A /Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/06/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	04/06/24 03:24	200.0	180.2	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/06/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/06/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/06/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/06/24 03:24	200.0	180.6	179.0	R-A /Span * 100	0.8

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/06/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/06/24 03:19	10.0	9.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/06/24 03:14	18.0	18.0		R-A	0.0
	Zero	04/06/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/07/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/07/24 02:24	200.0	180.6		R-A /Span * 100	2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/07/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/07/24 02:19	30.0	21.2		R-A /Span * 100	4.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/07/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	04/07/24 03:24	200.0	180.2		R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/07/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	04/07/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/07/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/07/24 03:24	200.0	180.6		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/07/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/07/24 03:19	10.0	9.4		R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/07/24 03:14	18.0	18.0		R-A	0.0
	Zero	04/07/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/08/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/08/24 02:24	200.0	180.6		R-A /Span * 100	1.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/08/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/08/24 02:19	30.0	21.2		R-A /Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/08/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	04/08/24 03:24	200.0	180.2		R-A /Span * 100	0.5

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/08/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/08/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/08/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/08/24 03:24	200.0	180.6	178.9	R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/08/24 03:19	10.0	9.4	9.1	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/08/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/08/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/09/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/09/24 02:24	200.0	180.6	180.2	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/09/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/09/24 02:19	30.0	21.2	20.9	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/09/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/09/24 03:24	200.0	180.2	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/09/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/09/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/09/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/09/24 03:24	200.0	180.6	180.3	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/09/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/09/24 03:19	10.0	9.4	9.3	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/09/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/09/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/09/24 18:38	200.0	0.0	-0.2	R-A /Span * 100	0.1
	High	04/09/24 18:48	200.0	179.4	181.1	R-A /Span * 100	0.9

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/09/24 18:38	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/09/24 18:43	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/09/24 18:38	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	04/09/24 18:48	200.0	181.7	180.7	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/09/24 18:38	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/09/24 18:43	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/09/24 18:38	21.0	18.0	18.0	R-A	0.0
	Zero	04/09/24 18:43	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/10/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/10/24 02:24	200.0	180.6	180.1	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/10/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/10/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/10/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/10/24 03:24	200.0	180.2	179.2	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/10/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/10/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/10/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/10/24 03:24	200.0	180.6	180.0	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/10/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/10/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/10/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/10/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/10/24 18:50	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/10/24 19:00	200.0	179.4	183.4	R-A /Span * 100	2.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/10/24 18:50	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	04/10/24 18:55	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/10/24 18:50	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/10/24 19:00	200.0	181.7	180.2	R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/10/24 18:50	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/10/24 18:55	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/10/24 18:50	21.0	18.0	18.0	R-A	0.0
	Zero	04/10/24 18:55	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/11/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/11/24 02:24	200.0	180.6	179.6	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/11/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/11/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/11/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/11/24 03:24	200.0	180.2	179.2	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/11/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/11/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/11/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/11/24 03:24	200.0	180.6	180.3	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/11/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/11/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/11/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/11/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/12/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/12/24 02:24	200.0	180.6	180.4	R-A /Span * 100	0.1

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/12/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/12/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/12/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/12/24 03:24	200.0	180.2	180.7	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/12/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/12/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/12/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/12/24 03:24	200.0	180.6	180.7	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/12/24 03:19	10.0	9.4	9.3	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/12/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/12/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/13/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/13/24 02:24	200.0	180.6	180.3	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/13/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/13/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	04/13/24 03:24	200.0	180.2	179.8	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/13/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/13/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/13/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/13/24 03:24	200.0	180.6	180.3	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/13/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/13/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/13/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/14/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/14/24 02:24	200.0	180.6	179.9	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/14/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/14/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/14/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/14/24 03:24	200.0	180.2	179.2	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/14/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/14/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/14/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/14/24 03:24	200.0	180.6	180.3	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/14/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/14/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/14/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/14/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/15/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/15/24 02:24	200.0	180.6	179.5	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/15/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/15/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	04/15/24 03:24	200.0	180.2	179.1	R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/15/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/15/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/15/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/15/24 03:24	200.0	180.6		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/15/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/15/24 03:19	10.0	9.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/15/24 03:14	18.0	18.0		R-A	0.1
	Zero	04/15/24 03:19	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/16/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/16/24 02:24	200.0	180.6		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/16/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/16/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/16/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	04/16/24 03:24	200.0	180.2		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/16/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	04/16/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/16/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/16/24 03:24	200.0	180.6		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/16/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/16/24 03:19	10.0	9.4		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/16/24 03:14	18.0	18.0		R-A	0.1
	Zero	04/16/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/17/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/17/24 02:24	200.0	179.7		R-A /Span * 100	1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/17/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/17/24 02:19	30.0	21.2		R-A /Span * 100	1.0

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/17/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/17/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/17/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/17/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/17/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/17/24 03:24	200.0	179.7	177.3	R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/17/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/17/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/17/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/17/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/18/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/18/24 02:24	200.0	179.7	177.1	R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/18/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/18/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/18/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	04/18/24 03:24	200.0	177.6	179.5	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/18/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	04/18/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/18/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/18/24 03:24	200.0	179.7	177.7	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/18/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/18/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/18/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	04/18/24 03:19	18.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/19/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/19/24 02:24	200.0	179.7	182.1	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/19/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/19/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/19/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	04/19/24 03:24	200.0	177.6	181.4	R-A /Span * 100	1.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/19/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/19/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/19/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/19/24 03:24	200.0	179.7	181.5	R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/19/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/19/24 03:19	10.0	9.4	9.2	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/19/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/19/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/20/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/20/24 02:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/20/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/20/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/20/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	04/20/24 03:24	200.0	177.6	180.9	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/20/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/20/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/20/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/20/24 03:24	200.0	179.7	180.1	R-A /Span * 100	0.2

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/20/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/20/24 03:19	10.0	9.6		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/20/24 03:14	18.0	18.0		R-A	0.0
	Zero	04/20/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/21/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/21/24 02:24	200.0	179.7		R-A /Span * 100	1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/21/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/21/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/21/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	04/21/24 03:24	200.0	177.6		R-A /Span * 100	1.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/21/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/21/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/21/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/21/24 03:24	200.0	179.7		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/21/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/21/24 03:19	10.0	9.6	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/21/24 03:14	18.0	18.0		R-A	0.0
	Zero	04/21/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/22/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/22/24 02:24	200.0	179.7		R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/22/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/22/24 02:19	30.0	21.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/22/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	04/22/24 03:24	200.0	177.6		R-A /Span * 100	1.7

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/22/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/22/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/22/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/22/24 03:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/22/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/22/24 03:19	10.0	9.6	9.9	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/22/24 03:14	18.0	18.0		R-A	0.0
	Zero	04/22/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/23/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/23/24 02:24	200.0	179.7	181.5	R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/23/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/23/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	04/23/24 03:24	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/23/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/23/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/23/24 03:24	200.0	179.7	181.9	R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/23/24 03:19	10.0	9.6	9.9	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/23/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/23/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/24/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/24/24 02:24	200.0	179.7	181.5	R-A /Span * 100	0.9

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/24/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/24/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	04/24/24 03:24	200.0	177.6	179.3	R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/24/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 03:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 03:19	10.0	9.6	10.0	R-A /Span * 100	4.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/24/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/24/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	04/24/24 04:49	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 04:54	50.0	43.9	0.0	>4x R-A /Span * 100	87.8
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	04/24/24 04:49	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 04:54	50.0	43.8	0.0	>4x R-A /Span * 100	87.6
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Pass
	Zero	04/24/24 10:23	1,000.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 10:33	1,000.0	918.0	920.0	R-A /Span * 100	0.2
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	High	04/24/24 10:18	20.0	18.1	18.1	R-A /Span * 100	0.0
	Zero	04/24/24 10:23	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	04/24/24 10:18	500.0	0.0	0.4	off R-A /Span * 100	0.1
	High	04/24/24 10:28	500.0	464.0	464.9	off R-A /Span * 100	0.2
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	04/24/24 10:18	10.0	0.0	0.3	off R-A /Span * 100	3.0
	High	04/24/24 10:23	10.0	9.0	9.2	off R-A /Span * 100	2.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	04/24/24 10:18	25.0	22.5	22.5	off	R-A 0.0
	Zero	04/24/24 10:23	25.0	0.0	0.0	off	R-A 0.0
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	04/24/24 10:59	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 11:04	50.0	43.8	0.0	>4x R-A /Span * 100	87.6
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	04/24/24 11:59	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 12:04	50.0	43.8	0.0	>4x R-A /Span * 100	87.6
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Pass
	Zero	04/24/24 12:23	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/24/24 12:28	50.0	43.8	43.9	R-A /Span * 100	0.2
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	04/24/24 13:06	1,000.0	0.0	-0.1	R-A /Span * 100	0.0
	High	04/24/24 13:16	1,000.0	900.0	900.0	R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	High	04/24/24 13:01	20.0	18.1	18.1	R-A /Span * 100	0.0
	Zero	04/24/24 13:06	20.0	0.0	-0.1	R-A /Span * 100	0.5
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	04/24/24 13:01	500.0	0.0	-0.4	off R-A /Span * 100	0.1
	High	04/24/24 13:11	500.0	456.1	456.1	off R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	04/24/24 13:01	10.0	0.0	-0.5	off R-A /Span * 100	5.0
	High	04/24/24 13:06	10.0	9.6	10.0	off R-A /Span * 100	4.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	04/24/24 13:01	25.0	22.5	22.5	off R-A	0.0
	Zero	04/24/24 13:06	25.0	0.0	0.1	off R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/25/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/25/24 02:24	200.0	179.7	181.6	R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/25/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/25/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	04/25/24 03:24	200.0	177.6	179.3	R-A /Span * 100	0.9

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/25/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/25/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/25/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/25/24 03:24	200.0	179.7		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/25/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/25/24 03:19	10.0	9.6	>1x Alert	R-A /Span * 100	4.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/25/24 03:14	18.0	18.0		R-A	0.1
	Zero	04/25/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/26/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/26/24 02:24	200.0	179.7		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/26/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/26/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/26/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	04/26/24 03:24	200.0	177.6		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/26/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/26/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/26/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/26/24 03:24	200.0	179.7		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	04/26/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/26/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	04/26/24 03:14	18.0	18.0		R-A	0.1
	Zero	04/26/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	04/27/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	04/27/24 02:24	200.0	179.7		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:52

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/27/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/27/24 02:19	30.0	21.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/27/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	04/27/24 03:24	200.0	177.6		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/27/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/27/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/27/24 03:24	200.0	179.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/27/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/27/24 03:14	18.0	18.0		R-A	0.1
	Zero	04/27/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/28/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/28/24 02:24	200.0	179.7		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/28/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	04/28/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/28/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	04/28/24 03:24	200.0	177.6		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/28/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/28/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/28/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	04/28/24 03:24	200.0	179.7		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/28/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	04/28/24 03:19	10.0	9.6		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/28/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/28/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/29/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/29/24 02:24	200.0	179.7	181.5	R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/29/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/29/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/29/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	04/29/24 03:24	200.0	177.6	177.6	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/29/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/29/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/29/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/29/24 03:24	200.0	179.7	179.2	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/29/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/29/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	04/29/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/29/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/30/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/30/24 02:24	200.0	179.7	182.8	R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/30/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/30/24 02:19	30.0	21.2	21.4	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	04/30/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	04/30/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	04/30/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/30/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	Zero	04/30/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	04/30/24 03:24	200.0	179.7	178.9	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online		Pass
	Zero	04/30/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	04/30/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	High	04/30/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	04/30/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	Zero	05/01/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 02:24	200.0	179.7	183.0	R-A /Span * 100	1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online		Pass
	Zero	05/01/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	Zero	05/01/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	05/01/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online		Pass
	Zero	05/01/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	Zero	05/01/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/01/24 03:24	200.0	179.7	178.9	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online		Pass
	Zero	05/01/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Pass
	High	05/01/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/01/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online		Fail
	Zero	05/01/24 09:00	1,000.0	0.0	0.1	R-A /Span * 100	0.0
	High	05/01/24 09:10	1,000.0		855.8	R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online		Pass
	High	05/01/24 08:55	20.0	18.1	16.1	>1x Alert R-A /Span * 100	10.0
	Zero	05/01/24 09:00	20.0	0.0	0.0	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/01/24 08:55	500.0	0.0	-0.4	R-A /Span * 100	0.1
	High	05/01/24 09:05	500.0	456.1	458.1	R-A /Span * 100	0.4
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/01/24 08:55	10.0	0.0	-0.5	>1x Alert R-A /Span * 100	5.0
	High	05/01/24 09:00	10.0	9.6	10.0	>1x Alert R-A /Span * 100	4.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/01/24 08:55	25.0	22.5	22.5	R-A	0.0
	Zero	05/01/24 09:00	25.0	0.0	0.1	R-A	0.1
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Fail
	Zero	05/01/24 09:15	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 09:20	50.0	43.9	0.0	>4x R-A /Span * 100	87.8
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/01/24 12:32	1,000.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/01/24 12:42	1,000.0	918.0	914.9	R-A /Span * 100	0.3
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	High	05/01/24 12:27	20.0	18.1	18.1	R-A /Span * 100	0.0
	Zero	05/01/24 12:32	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/01/24 12:27	500.0	0.0	1.0	R-A /Span * 100	0.2
	High	05/01/24 12:37	500.0	464.0	466.2	R-A /Span * 100	0.4
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/01/24 12:27	10.0	0.0	1.0	R-A	1.0
	High	05/01/24 12:32	10.0	9.0	9.3	>1x Alert R-A /Span * 100	3.0
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/01/24 12:27	25.0	22.5	22.5	R-A	0.0
	Zero	05/01/24 12:32	25.0	0.0	0.1	R-A	0.1
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/01/24 12:47	50.0	0.0	0.4	R-A /Span * 100	0.8
	High	05/01/24 12:52	50.0	43.8	44.4	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/02/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/02/24 02:24	200.0	179.7	182.6	R-A /Span * 100	1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/02/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/02/24 02:19	30.0	21.2	21.4	R-A /Span * 100	0.7

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/02/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	05/02/24 03:24	200.0	177.6	178.8	R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/02/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/02/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/02/24 03:24	200.0	179.7	178.5	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/02/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/02/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/02/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/03/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/03/24 02:24	200.0	179.7	182.4	R-A /Span * 100	1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/03/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/03/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/03/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	05/03/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/03/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/03/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/03/24 03:24	200.0	179.7	179.2	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/03/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/03/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	05/03/24 03:19	18.0	0.0	-0.1	R-A	0.1

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/04/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/04/24 02:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/04/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/04/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/04/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	05/04/24 03:24	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/04/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/04/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/04/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/04/24 03:24	200.0	179.7	179.6	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/04/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/04/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/04/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/04/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/05/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/05/24 02:24	200.0	179.7	182.1	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/05/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/05/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/05/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	05/05/24 03:24	200.0	177.6	179.6	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/05/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/05/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/05/24 03:24	200.0	179.7	180.1	R-A /Span * 100	0.2

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/05/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/05/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/05/24 03:14	18.0	18.0		R-A	0.0
	Zero	05/05/24 03:19	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/06/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	05/06/24 02:24	200.0	179.7	182.0	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/06/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/06/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/06/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	05/06/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/06/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/06/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/06/24 03:24	200.0	179.7	179.8	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/06/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/06/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/06/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/07/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/07/24 02:24	200.0	179.7	181.0	R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/07/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/07/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/07/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	05/07/24 03:24	200.0	177.6	177.9	R-A /Span * 100	0.2

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/07/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/07/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/07/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/07/24 03:24	200.0	179.7		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/07/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/07/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/07/24 03:14	18.0	18.0		R-A	0.1
	Zero	05/07/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/08/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/08/24 02:24	200.0	179.7		R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/08/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/08/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/08/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	05/08/24 03:24	200.0	177.6		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/08/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/08/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/08/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/08/24 03:24	200.0	179.7		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/08/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/08/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/08/24 03:14	18.0	18.0		R-A	0.0
	Zero	05/08/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	05/09/24 02:24	200.0	179.7		R-A /Span * 100	1.6

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/09/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/09/24 02:19	30.0	21.2		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	05/09/24 03:24	200.0	177.6		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/09/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/09/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/09/24 03:24	200.0	179.7		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/09/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/09/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/09/24 03:14	18.0	18.0		R-A	0.0
	Zero	05/09/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 08:32	1,000.0	0.0		R-A /Span * 100	0.0
	High	05/09/24 08:42	1,000.0	918.0		R-A /Span * 100	0.1
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	High	05/09/24 08:27	20.0	18.1		R-A /Span * 100	0.5
	Zero	05/09/24 08:32	20.0	0.0		R-A /Span * 100	0.5
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 08:27	500.0	0.0		R-A /Span * 100	0.2
	High	05/09/24 08:37	500.0	464.0		R-A /Span * 100	0.9
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/09/24 08:27	10.0	0.0		R-A	1.1
	High	05/09/24 08:32	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/09/24 08:27	25.0	22.5		R-A	0.0
	Zero	05/09/24 08:32	25.0	0.0		R-A	0.1
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/09/24 08:47	50.0	0.0		R-A /Span * 100	1.0
	High	05/09/24 08:52	50.0	43.8		R-A /Span * 100	1.4

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/10/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/10/24 02:24	200.0	179.7		R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/10/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/10/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/10/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	05/10/24 03:24	200.0	177.6		R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/10/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/10/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/10/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/10/24 03:24	200.0	179.7		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/10/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/10/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/10/24 03:14	18.0	18.0		R-A	0.0
	Zero	05/10/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/11/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	05/11/24 02:24	200.0	179.7		R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/11/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/11/24 02:19	30.0	21.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/11/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	05/11/24 03:24	200.0	177.6		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/11/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/11/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/11/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	05/11/24 03:24	200.0	179.7		R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/11/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/11/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/11/24 03:14	18.0	18.0		R-A	0.0
	Zero	05/11/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/12/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/12/24 02:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/12/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	05/12/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/12/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/12/24 03:24	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/12/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/12/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/12/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/12/24 03:24	200.0	179.7	180.1	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/12/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/12/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/12/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/13/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/13/24 02:24	200.0	179.7	182.1	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/13/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/13/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/13/24 03:24	200.0	177.6	179.4	R-A /Span * 100	0.9

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/13/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/13/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/13/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/13/24 03:24	200.0	179.7	180.7	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/13/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/13/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/13/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/14/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 02:24	200.0	179.7	182.0	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/14/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/14/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/14/24 03:24	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/14/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/14/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/14/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/14/24 03:24	200.0	179.7	180.7	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/14/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/14/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/14/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Fail	
	Zero	05/14/24 06:32	1,000.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 06:42	1,000.0		902.2	R-A /Span * 100	0.0

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	High	05/14/24 06:27	20.0	18.1	18.0	R-A /Span * 100	0.5
	Zero	05/14/24 06:32	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/14/24 06:27	500.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 06:37	500.0	456.1	456.6	R-A /Span * 100	0.1
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/14/24 06:27	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 06:32	10.0	9.6	9.9	>1x Alert R-A /Span * 100	3.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/14/24 06:27	25.0	22.5	22.5	R-A	0.0
	Zero	05/14/24 06:32	25.0	0.0	0.1	R-A	0.1
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Warning
	Zero	05/14/24 06:47	50.0	0.0	0.3	R-A /Span * 100	0.6
	High	05/14/24 06:52	50.0	43.9	46.9	>2x R-A /Span * 100	6.0
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/14/24 07:31	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/14/24 07:36	50.0	43.9	43.9	R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/15/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/15/24 02:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/15/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/15/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	05/15/24 03:24	200.0	177.6	178.9	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/15/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/15/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/15/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/15/24 03:24	200.0	179.7	180.6	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/15/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/15/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/15/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	05/15/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/16/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/16/24 02:24	200.0	179.7	180.3	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/16/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/16/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	05/16/24 03:24	200.0	177.6	180.0	R-A /Span * 100	1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/16/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/16/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 03:24	200.0	179.7	181.2	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/16/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/16/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/16/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/16/24 19:41	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	05/16/24 19:51	200.0	179.4	180.6	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/16/24 19:41	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 19:46	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/16/24 19:41	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	05/16/24 19:51	200.0	181.7	180.7	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/16/24 19:41	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/16/24 19:46	10.0	9.5	8.9	R-A	0.6

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/16/24 19:41	21.0	18.0		R-A	0.0
	Zero	05/16/24 19:46	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/17/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/17/24 02:24	200.0	179.7	180.5	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/17/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/17/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/17/24 03:14	200.0	0.0	1.0	R-A /Span * 100	0.5
	High	05/17/24 03:24	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/17/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/17/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/17/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/17/24 03:24	200.0	179.7	181.2	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/17/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/17/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/17/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/17/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/18/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/18/24 02:24	200.0	179.7	180.2	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/18/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/18/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/18/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	05/18/24 03:24	200.0	177.6	180.1	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/18/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/18/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/18/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/18/24 03:24	200.0	179.7	181.6	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/18/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/18/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/18/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/18/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/18/24 08:46	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/18/24 08:56	200.0	177.6	179.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/18/24 08:46	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/18/24 08:51	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/18/24 08:46	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/18/24 08:56	200.0	179.7	181.5	R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/18/24 08:46	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/18/24 08:51	10.0	9.6	9.7	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/18/24 08:46	18.0	18.0	18.0	R-A	0.0
	Zero	05/18/24 08:51	18.0	0.0	0.0	R-A	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	05/18/24 09:44	1,000.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/18/24 09:54	1,000.0		906.4	R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	High	05/18/24 09:39	20.0	18.1	18.1	R-A /Span * 100	0.0
	Zero	05/18/24 09:44	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	05/18/24 09:39	500.0	0.0	0.1	off R-A /Span * 100	0.0
	High	05/18/24 09:49	500.0	456.1	456.2	off R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	05/18/24 09:39	10.0	0.0	0.1	off R-A /Span * 100	1.0
	High	05/18/24 09:44	10.0	9.6	10.0	off R-A /Span * 100	4.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	05/18/24 09:39	25.0	22.5	22.5	off	R-A 0.0
	Zero	05/18/24 09:44	25.0	0.0	0.1	off	R-A 0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/19/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/19/24 02:24	200.0	181.1	180.2	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/19/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/19/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/19/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/19/24 03:24	200.0	177.6	180.0	R-A /Span * 100	1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/19/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/19/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/19/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/19/24 03:24	200.0	181.1	181.9	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/19/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/19/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/19/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/19/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/20/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/20/24 02:24	200.0	181.1	181.9	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/20/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/20/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/20/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/20/24 03:24	200.0	177.6	180.0	R-A /Span * 100	1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/20/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/20/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/20/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	05/20/24 03:24	200.0	181.1	182.3	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/20/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/20/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/20/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/20/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/21/24 00:12	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	05/21/24 00:22	200.0	179.4	178.7	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/21/24 00:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 00:17	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/21/24 00:12	200.0	0.0	-0.2	R-A /Span * 100	0.1
	High	05/21/24 00:22	200.0	181.7	180.4	R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/21/24 00:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 00:17	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/21/24 00:12	21.0	18.0	18.0	R-A	0.0
	Zero	05/21/24 00:17	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/21/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 02:24	200.0	181.1	182.1	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/21/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/21/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/21/24 02:24	200.0	181.7	179.5	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/21/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	05/21/24 02:19	30.0	21.2	20.7	R-A /Span * 100	1.7

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	05/21/24 03:24	200.0	177.6	180.0	R-A /Span * 100	1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/21/24 03:24	200.0	181.1	182.2	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/21/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/21/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 03:24	200.0	179.4	179.4	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	200.0	0.0	-0.3	R-A /Span * 100	0.2
	High	05/21/24 03:24	200.0	181.7	180.8	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/21/24 03:19	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/21/24 03:14	21.0	18.0	17.9	R-A	0.1
	Zero	05/21/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/22/24 02:24	200.0	181.1	183.1	R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/22/24 02:24	200.0	181.7	176.4	>1x Alert R-A /Span * 100	2.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	05/22/24 02:19	30.0	21.2	20.1	>1x Alert R-A /Span * 100	3.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/22/24 03:24	200.0	177.6	180.1	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/22/24 03:24	200.0	181.1	181.8	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/22/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/22/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 03:24	200.0	179.4	181.1	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 03:19	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/22/24 03:24	200.0	181.7	179.8	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/22/24 03:19	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/22/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/22/24 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/23/24 02:24	200.0	181.1	182.4	R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/23/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/23/24 02:24	200.0	181.7	174.5	>1x Alert R-A /Span * 100	3.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	05/23/24 02:19	30.0	21.2	19.9	>1x Alert R-A /Span * 100	4.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	05/23/24 03:24	200.0	177.6	179.9	R-A /Span * 100	1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/23/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/23/24 03:24	200.0	181.1	181.9	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/23/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/23/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	05/23/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/23/24 03:24	200.0	179.4	180.1	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/23/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	05/23/24 03:24	200.0	181.7	178.4	R-A /Span * 100	1.7

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	05/23/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/23/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/23/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Fail
	Zero	05/23/24 06:36	1,000.0	0.0	0.1	R-A /Span * 100	0.0
	High	05/23/24 06:46	1,000.0		898.0	R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	High	05/23/24 06:31	20.0	18.1	18.3	R-A /Span * 100	1.0
	Zero	05/23/24 06:36	20.0	0.0	0.1	R-A /Span * 100	0.5
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 06:31	500.0	0.0	0.1	R-A /Span * 100	0.0
	High	05/23/24 06:41	500.0	456.1	454.0	R-A /Span * 100	0.4
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/23/24 06:31	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/23/24 06:36	10.0	9.6	9.8	R-A /Span * 100	2.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/23/24 06:31	25.0	22.5	22.5	R-A	0.0
	Zero	05/23/24 06:36	25.0	0.0	0.1	R-A	0.1
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/23/24 06:51	50.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/23/24 06:56	50.0	43.9	43.2	R-A /Span * 100	1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/24/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/24/24 02:24	200.0	181.7	174.5	>1x Alert R-A /Span * 100	3.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/24/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	05/24/24 02:19	30.0	21.2	19.8	>1x Alert R-A /Span * 100	4.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/24/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/24/24 03:24	200.0	179.4	178.6	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/24/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	05/24/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/24/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/24/24 03:24	200.0	181.7	178.2	R-A /Span * 100	1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/24/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/24/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/24/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/25/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/25/24 02:24	200.0	181.7	180.6	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/25/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/25/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/25/24 03:24	200.0	179.4	181.1	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/25/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/25/24 03:19	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/25/24 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	05/25/24 03:24	200.0	181.7	177.9	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/25/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/25/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/25/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/25/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/26/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/26/24 02:24	200.0	181.7	180.5	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/26/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/26/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/26/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/26/24 03:24	200.0	179.4	179.8	R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/26/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/26/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/26/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/26/24 03:24	200.0	181.7	178.8	R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/26/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/26/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/26/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/26/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/27/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/27/24 02:24	200.0	181.7	181.8	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/27/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/27/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/27/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/27/24 03:24	200.0	179.4	181.4	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/27/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/27/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/27/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/27/24 03:24	200.0	181.7	178.2	R-A /Span * 100	1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/27/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/27/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/27/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/27/24 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/27/24 19:04	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	05/27/24 19:14	200.0	177.6	179.2	R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/27/24 19:04	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/27/24 19:09	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/27/24 19:04	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/27/24 19:14	200.0	181.1	181.2	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/27/24 19:04	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/27/24 19:09	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/27/24 19:04	18.0	18.0	18.0	R-A	0.0
	Zero	05/27/24 19:09	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/28/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/28/24 02:24	200.0	181.7	181.0	R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/28/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/28/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/28/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/28/24 03:24	200.0	179.4	180.2	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/28/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/28/24 03:19	10.0	9.1	8.8	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/28/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/28/24 03:24	200.0	181.7	178.0	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/28/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/28/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/28/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/28/24 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/29/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/29/24 02:24	200.0	181.7	181.6	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/29/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/29/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/29/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/29/24 03:24	200.0	179.4	180.5	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/29/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/29/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/29/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/29/24 03:24	200.0	181.7	179.3	R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/29/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/29/24 03:19	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/29/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/29/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Fail	
	Zero	05/29/24 06:34	1,000.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/29/24 06:44	1,000.0		897.9	R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	High	05/29/24 06:29	20.0	18.1	18.2	R-A /Span * 100	0.5
	Zero	05/29/24 06:34	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/29/24 06:29	500.0	0.0	0.1	R-A /Span * 100	0.0
	High	05/29/24 06:39	500.0	456.1	451.5	R-A /Span * 100	0.9
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/29/24 06:29	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	05/29/24 06:34	10.0	9.6	9.8	R-A /Span * 100	2.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/29/24 06:29	25.0	22.5	22.5	R-A	0.0
	Zero	05/29/24 06:34	25.0	0.0	0.1	R-A	0.1

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/29/24 06:49	50.0	0.0		R-A /Span * 100	0.0
	High	05/29/24 06:54	50.0	43.9		R-A /Span * 100	1.8
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/30/24 06:32	1,000.0	0.7		R-A /Span * 100	0.1
	High	05/30/24 06:42	1,000.0	918.0		R-A /Span * 100	2.4
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	High	05/30/24 06:27	20.0	19.5	>1x Alert	R-A /Span * 100	7.0
	Zero	05/30/24 06:32	20.0	0.7		R-A /Span * 100	3.5
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/30/24 06:27	500.0	1.1		R-A /Span * 100	0.2
	High	05/30/24 06:37	500.0	447.5	>1x Alert	R-A /Span * 100	3.3
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/30/24 06:27	10.0	1.1		R-A	1.1
	High	05/30/24 06:32	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/30/24 06:27	25.0	22.5		R-A	0.0
	Zero	05/30/24 06:32	25.0	0.1		R-A	0.1
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/30/24 06:47	50.0	0.5		R-A /Span * 100	1.0
	High	05/30/24 06:52	50.0	43.8		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/30/24 12:58	200.0	-0.1		R-A /Span * 100	0.1
	High	05/30/24 13:08	200.0	179.4		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/30/24 12:58	10.0	0.0		R-A /Span * 100	0.0
	High	05/30/24 13:03	10.0	8.9		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	05/30/24 12:58	200.0	0.0		R-A /Span * 100	0.0
	High	05/30/24 13:08	200.0	181.7		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	05/30/24 12:58	10.0	0.0		R-A /Span * 100	0.0
	High	05/30/24 13:03	10.0	9.5		R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	05/30/24 12:58	21.0	18.0		R-A	0.0
	Zero	05/30/24 13:03	21.0	0.0		R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/31/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	05/31/24 02:24	200.0	181.7	181.2	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/31/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/31/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/31/24 03:14	200.0	0.0	-0.2	R-A /Span * 100	0.1
	High	05/31/24 03:24	200.0	179.4	180.4	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/31/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/31/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	05/31/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	05/31/24 03:24	200.0	181.7	178.3	R-A /Span * 100	1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	05/31/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	05/31/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	05/31/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	05/31/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/01/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/01/24 02:24	200.0	181.7	181.3	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/01/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/01/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/01/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/01/24 03:24	200.0	179.4	181.1	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/01/24 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	06/01/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/01/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/01/24 03:24	200.0	181.7	179.0	R-A /Span * 100	1.4

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/01/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/01/24 03:19	10.0	9.5		R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/01/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/01/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/02/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/02/24 02:24	200.0	181.7		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/02/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/02/24 02:19	30.0	21.2		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/02/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/02/24 03:24	200.0	179.4		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/02/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/02/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/02/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	06/02/24 03:24	200.0	181.7		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/02/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/02/24 03:19	10.0	9.5		R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/02/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/02/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/02/24 16:05	200.0	0.0		R-A /Span * 100	0.4
	High	06/02/24 16:15	200.0	177.6		R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/02/24 16:05	10.0	0.0		R-A /Span * 100	1.0
	High	06/02/24 16:10	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/02/24 16:05	200.0	0.0		R-A /Span * 100	0.1
	High	06/02/24 16:15	200.0	181.1		R-A /Span * 100	0.5

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/02/24 16:05	10.0	0.0		R-A /Span * 100	0.0
	High	06/02/24 16:10	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/02/24 16:05	18.0	18.0		R-A	0.1
	Zero	06/02/24 16:10	18.0	-0.1		R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/03/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/03/24 02:24	200.0	181.7	180.5	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/03/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/03/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/03/24 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	06/03/24 03:24	200.0	179.4	180.5	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/03/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/03/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/03/24 03:24	200.0	181.7	179.2	R-A /Span * 100	1.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/03/24 03:19	10.0	9.5	8.9	R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/03/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/03/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/04/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/04/24 02:24	200.0	181.7	181.4	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/04/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/04/24 02:19	30.0	21.2	21.2	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/04/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/04/24 03:24	200.0	179.4	179.9	R-A /Span * 100	0.3

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/04/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/04/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/04/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/04/24 03:24	200.0	181.7		R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/04/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/04/24 03:19	10.0	9.5		R-A	0.6
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/04/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/04/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/05/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/05/24 02:24	200.0	181.7		R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/05/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/05/24 02:19	30.0	21.2		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/05/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/05/24 03:24	200.0	179.4		R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/05/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/05/24 03:19	10.0	9.1		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/05/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/05/24 03:24	200.0	181.7		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/05/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/05/24 03:19	10.0	9.5		R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/05/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/05/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/05/24 13:55	200.0	0.0		R-A /Span * 100	0.4
	High	06/05/24 14:05	200.0	177.6		R-A /Span * 100	0.8

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/05/24 13:55	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/05/24 14:00	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/05/24 13:55	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/05/24 14:05	200.0	181.1	181.3	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/05/24 13:55	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/05/24 14:00	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/05/24 13:55	18.0	18.0	18.0	R-A	0.0
	Zero	06/05/24 14:00	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/06/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/06/24 02:24	200.0	181.7	180.2	R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/06/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/06/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/06/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/06/24 03:24	200.0	179.4	180.4	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/06/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/06/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/06/24 03:24	200.0	181.7	177.2	R-A /Span * 100	2.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/06/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/06/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/06/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/07/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/07/24 02:24	200.0	181.7	181.2	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/07/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/07/24 02:19	30.0	21.2	21.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/07/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/07/24 03:24	200.0	178.7	179.5	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/07/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/07/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/07/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/07/24 03:24	200.0	181.7	177.9	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/07/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/07/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/07/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/07/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/08/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/08/24 02:24	200.0	181.7	181.2	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/08/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/08/24 02:19	30.0	21.0	21.2	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/08/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/08/24 03:24	200.0	178.7	179.3	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/08/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/08/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/08/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/08/24 03:24	200.0	181.7	178.6	R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/08/24 03:19	10.0	9.5	8.8	R-A	0.7

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/08/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/08/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/09/24 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/09/24 02:24	200.0	181.7		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/09/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/09/24 02:19	30.0	21.0		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/09/24 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/09/24 03:24	200.0	178.7		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/09/24 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	06/09/24 03:19	10.0	9.1		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/09/24 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/09/24 03:24	200.0	181.7		R-A /Span * 100	1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/09/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/09/24 03:19	10.0	9.5		R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/09/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/09/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/10/24 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/10/24 02:24	200.0	181.7		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/10/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/10/24 02:19	30.0	21.0		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/10/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/10/24 03:24	200.0	178.7		R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/10/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/10/24 03:19	10.0	9.1		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/10/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/10/24 03:24	200.0	181.7		R-A /Span * 100	1.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/10/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/10/24 03:19	10.0	9.5		R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/10/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/10/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/11/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/11/24 02:24	200.0	181.7		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/11/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/11/24 02:19	30.0	21.0		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/11/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/11/24 03:24	200.0	178.7		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/11/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/11/24 03:19	10.0	9.1		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/11/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/11/24 03:24	200.0	181.7		R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/11/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/11/24 03:19	10.0	9.5		R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/11/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/11/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/12/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/12/24 02:24	200.0	181.7		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/12/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/12/24 02:19	30.0	21.0		R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/12/24 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	06/12/24 03:24	200.0	178.7	180.2	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/12/24 03:14	10.0	0.0	-0.2	R-A /Span * 100	2.0
	High	06/12/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/12/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/12/24 03:24	200.0	181.7	177.9	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/12/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/12/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/12/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/13/24 02:24	200.0	181.7	180.3	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 02:19	30.0	21.0	21.0	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 03:24	200.0	178.7	180.2	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/13/24 03:19	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/13/24 03:24	200.0	181.7	177.8	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/13/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/13/24 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 16:39	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/13/24 16:49	200.0	177.6	176.9	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 16:39	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/13/24 16:44	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 16:39	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 16:49	200.0	181.1	182.2	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 16:39	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 16:44	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/13/24 16:39	18.0	18.0	18.0	R-A	0.0
	Zero	06/13/24 16:44	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/13/24 17:07	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 17:17	200.0	181.1	183.2	R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/13/24 17:07	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/13/24 17:12	30.0	21.2	21.5	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/14/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/14/24 02:24	200.0	180.1	179.4	R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/14/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/14/24 02:19	30.0	21.0	21.0	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/14/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/14/24 03:24	200.0	178.1	179.6	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/14/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/14/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/14/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/14/24 03:24	200.0	180.1	177.9	R-A /Span * 100	1.1

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/14/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/14/24 03:19	10.0	9.5	8.8	R-A	0.7
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/14/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/14/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/14/24 20:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/14/24 20:24	200.0	177.6	176.9	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/14/24 20:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/14/24 20:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/14/24 20:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/14/24 20:24	200.0	181.1	182.0	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/14/24 20:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/14/24 20:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/14/24 20:14	18.0	18.0	18.0	R-A	0.0
	Zero	06/14/24 20:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/15/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/15/24 02:24	200.0	181.1	181.5	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/15/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/15/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/15/24 02:24	200.0	180.1	182.1	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/15/24 02:19	30.0	21.0	21.4	R-A /Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/15/24 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	06/15/24 03:24	200.0	178.1	178.9	R-A /Span * 100	0.4

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/15/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/15/24 03:19	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/15/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/15/24 03:24	200.0	180.1	179.9	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/15/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/15/24 03:19	10.0	9.5	9.0	>1x Alert R-A /Span * 100	5.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/15/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/15/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/16/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/16/24 02:24	200.0	180.1	180.6	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/16/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/16/24 02:19	30.0	21.0	21.1	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/16/24 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	06/16/24 03:24	200.0	178.1	177.7	R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/16/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/16/24 03:19	10.0	9.1	8.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/16/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/16/24 03:24	200.0	180.1	179.9	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/16/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/16/24 03:19	10.0	9.5	9.0	>1x Alert R-A /Span * 100	5.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/16/24 03:14	21.0	18.0	17.9	R-A	0.1
	Zero	06/16/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/17/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/17/24 02:24	200.0	180.1	179.7	R-A /Span * 100	0.2

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/17/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/17/24 02:19	30.0	21.0		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/17/24 03:14	200.0	-0.1		R-A /Span * 100	0.1
	High	06/17/24 03:24	200.0	178.1		R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/17/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/17/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/17/24 03:14	200.0	0.3		R-A /Span * 100	0.2
	High	06/17/24 03:24	200.0	180.1		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/17/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/17/24 03:19	10.0	9.5	>1x Alert	R-A /Span * 100	5.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/17/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/17/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/18/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/18/24 02:24	200.0	180.1		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/18/24 02:14	30.0	0.0		R-A /Span * 100	0.3
	High	06/18/24 02:19	30.0	21.0		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/18/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/18/24 03:24	200.0	178.1		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/18/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/18/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/18/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/18/24 03:24	200.0	180.1		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/18/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/18/24 03:19	10.0	9.5	>1x Alert	R-A /Span * 100	5.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/18/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/18/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/19/24 02:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/19/24 02:24	200.0	180.1		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/19/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 02:19	30.0	21.0		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/19/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 03:24	200.0	178.1		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/19/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/19/24 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	06/19/24 03:24	200.0	180.1		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/19/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/19/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/19/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/19/24 10:15	200.0	0.8		R-A /Span * 100	0.4
	High	06/19/24 10:25	200.0	177.6		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/19/24 10:15	10.0	0.1		R-A /Span * 100	1.0
	High	06/19/24 10:20	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/19/24 10:15	200.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 10:25	200.0	181.1		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/19/24 10:15	10.0	0.0		R-A /Span * 100	0.0
	High	06/19/24 10:20	10.0	9.6		R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/19/24 10:15	18.0	18.0		R-A	0.0
	Zero	06/19/24 10:20	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/20/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 02:24	200.0	181.1		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/20/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 02:19	30.0	21.2		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/20/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	06/20/24 03:24	200.0	177.6		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/20/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/20/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/20/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 03:24	200.0	181.1		R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/20/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/20/24 03:14	18.0	18.0		R-A	0.0
	Zero	06/20/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Fail	
	Zero	06/20/24 08:32	1,000.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 08:42	1,000.0	894.1		R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	High	06/20/24 08:27	20.0	18.1		R-A /Span * 100	0.5
	Zero	06/20/24 08:32	20.0	0.0		R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/20/24 08:27	500.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 08:37	500.0	456.1		R-A /Span * 100	1.2
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/20/24 08:27	10.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 08:32	10.0	9.6		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/20/24 08:27	25.0	22.5		R-A	0.0
	Zero	06/20/24 08:32	25.0	0.0		R-A	0.1
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/20/24 08:32	1,000.0	0.0		R-A /Span * 100	0.2
	High	06/20/24 08:42	1,000.0	918.0		R-A /Span * 100	4.9
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Warning
	High	06/20/24 08:27	20.0	18.1	>2x	R-A /Span * 100	15.0
	Zero	06/20/24 08:32	20.0	0.0	>1x	R-A /Span * 100	9.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/20/24 08:27	500.0	0.0		R-A /Span * 100	0.2
	High	06/20/24 08:37	500.0	464.0	>1x Alert	R-A /Span * 100	3.5
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/20/24 08:27	10.0	0.0		R-A	1.1
	High	06/20/24 08:32	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/20/24 08:27	25.0	22.5		R-A	0.0
	Zero	06/20/24 08:32	25.0	0.0		R-A	0.1
Part 60	CT5_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/20/24 08:47	50.0	0.0		R-A /Span * 100	0.0
	High	06/20/24 08:52	50.0	43.9		R-A /Span * 100	1.8
Part 60	CT6_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/20/24 08:47	50.0	0.0		R-A /Span * 100	0.8
	High	06/20/24 08:52	50.0	43.8		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/21/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/21/24 02:24	200.0	181.1		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/21/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/21/24 02:19	30.0	21.2		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/21/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	06/21/24 03:24	200.0	177.6		R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/21/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/21/24 03:19	10.0	9.1		R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/21/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/21/24 03:24	200.0	181.1	182.4	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/21/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/21/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	06/21/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/21/24 12:19	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/21/24 12:29	200.0	178.1	179.3	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/21/24 12:19	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/21/24 12:24	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/21/24 12:19	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/21/24 12:29	200.0	180.1	179.0	R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/21/24 12:19	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/21/24 12:24	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/21/24 12:19	21.0	18.0	18.0	R-A	0.0
	Zero	06/21/24 12:24	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/22/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/22/24 02:24	200.0	181.1	181.2	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/22/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/22/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/22/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/22/24 03:24	200.0	177.6	178.3	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/22/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/22/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/22/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/22/24 03:24	200.0	181.1	182.0	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/22/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/22/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	06/22/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/23/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/23/24 02:24	200.0	181.1	180.7	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/23/24 02:19	30.0	21.2	20.9	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/23/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/23/24 03:24	200.0	177.6	177.8	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/23/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/23/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/23/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/23/24 03:24	200.0	181.1	181.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/23/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/23/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	06/23/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/23/24 19:17	21.0	18.0	18.0	R-A	0.0
	Zero	06/23/24 19:22	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/23/24 19:41	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/23/24 19:51	200.0	178.1	179.6	R-A /Span * 100	0.8

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/23/24 19:41	10.0	0.0		R-A /Span * 100	0.0
	High	06/23/24 19:46	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/23/24 19:41	200.0	0.0		R-A /Span * 100	0.1
	High	06/23/24 19:51	200.0	180.1	179.7	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/23/24 19:41	10.0	0.0		R-A /Span * 100	0.0
	High	06/23/24 19:46	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/23/24 19:41	21.0	18.0	18.0	R-A	0.0
	Zero	06/23/24 19:46	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/24/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/24/24 02:24	200.0	181.1	180.8	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/24/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/24/24 02:19	30.0	21.2	20.9	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/24/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/24/24 02:24	200.0	180.1	182.2	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/24/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/24/24 02:19	30.0	21.0	21.5	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/24/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	06/24/24 03:24	200.0	177.6	177.9	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/24/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/24/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/24/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/24/24 03:24	200.0	181.1	181.8	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/24/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/24/24 03:14	18.0	18.0		R-A	0.0
	Zero	06/24/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/24/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/24/24 03:24	200.0	178.1		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/24/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/24/24 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/24/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/24/24 03:24	200.0	180.1		R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/24/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/24/24 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/24/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/24/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Fail
	Zero	06/24/24 07:18	1,000.0	0.0		R-A /Span * 100	0.0
	High	06/24/24 07:28	1,000.0	903.0		R-A /Span * 100	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	High	06/24/24 07:13	20.0	18.1		R-A /Span * 100	0.0
	Zero	06/24/24 07:18	20.0	0.0		R-A /Span * 100	0.5
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	06/24/24 07:13	500.0	0.0		off R-A /Span * 100	0.0
	High	06/24/24 07:23	500.0	456.1		off R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	06/24/24 07:13	10.0	0.0		off R-A /Span * 100	1.0
	High	06/24/24 07:18	10.0	9.6		off R-A /Span * 100	1.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	06/24/24 07:13	25.0	22.5		off R-A	0.0
	Zero	06/24/24 07:18	25.0	0.0		off R-A	0.1
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Pass
	Zero	06/24/24 10:04	1,000.0	0.0		R-A /Span * 100	0.0
	High	06/24/24 10:14	1,000.0	918.0		R-A /Span * 100	0.1

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	High	06/24/24 09:59	20.0	18.1	18.0	R-A /Span * 100	0.5
	Zero	06/24/24 10:04	20.0	0.0	0.0	R-A /Span * 100	0.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	06/24/24 09:59	500.0	0.0	0.0	off R-A /Span * 100	0.0
	High	06/24/24 10:09	500.0	464.0	465.6	off R-A /Span * 100	0.3
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	06/24/24 09:59	10.0	0.0	0.0	off R-A /Span * 100	0.0
	High	06/24/24 10:04	10.0	9.0	9.3	off R-A /Span * 100	3.0
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	06/24/24 09:59	25.0	22.5	22.5	off R-A	0.0
	Zero	06/24/24 10:04	25.0	0.0	0.1	off R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/25/24 02:24	200.0	181.1	182.6	R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/25/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/25/24 02:24	200.0	180.1	182.2	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/25/24 02:19	30.0	21.0	21.3	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/25/24 03:24	200.0	177.6	177.6	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/25/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/25/24 03:24	200.0	181.1	181.3	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/25/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/25/24 03:14	18.0	18.0		R-A	0.0
	Zero	06/25/24 03:19	18.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/25/24 03:24	200.0	178.1		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	10.0	-0.1		R-A /Span * 100	1.0
	High	06/25/24 03:19	10.0	9.2		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	200.0	0.2		R-A /Span * 100	0.1
	High	06/25/24 03:24	200.0	180.1		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/25/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/25/24 03:19	10.0	9.2		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/25/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/25/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/26/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/26/24 02:24	200.0	181.1		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/26/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/26/24 02:19	30.0	21.2		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/26/24 02:14	200.0	0.2		R-A /Span * 100	0.1
	High	06/26/24 02:24	200.0	180.1		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/26/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/26/24 02:19	30.0	21.0		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/26/24 03:14	200.0	0.7		R-A /Span * 100	0.4
	High	06/26/24 03:24	200.0	177.6		R-A /Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/26/24 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	06/26/24 03:19	10.0	9.1		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/26/24 03:24	200.0	181.1	181.7	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/26/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/26/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	06/26/24 03:19	18.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/26/24 03:24	200.0	178.1	179.9	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/26/24 03:19	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	06/26/24 03:24	200.0	180.1	180.0	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/26/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/26/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/26/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/26/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/27/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 02:24	200.0	181.1	181.2	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/27/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 02:19	30.0	21.2	21.0	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/27/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/27/24 02:24	200.0	180.1	180.3	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/27/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 02:19	30.0	21.0	21.1	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/27/24 03:24	200.0	177.6	176.8	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/27/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 03:24	200.0	181.1	181.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/27/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	06/27/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	06/27/24 03:24	200.0	178.1	179.5	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/27/24 03:19	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/27/24 03:24	200.0	180.1	180.3	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/27/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/27/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/27/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/27/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/28/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 02:24	200.0	181.1	181.4	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/28/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 02:19	30.0	21.2	21.1	R-A /Span * 100	0.3

Daily Calibration Results

All Units



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/28/24 02:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	06/28/24 02:24	200.0	180.1	181.1	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/28/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 02:19	30.0	21.0	21.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	06/28/24 03:24	200.0	177.6	177.2	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	06/28/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 03:24	200.0	181.1	181.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/28/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	06/28/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 03:24	200.0	178.1	180.8	R-A /Span * 100	1.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	06/28/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/28/24 03:24	200.0	180.1	180.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/28/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/28/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/28/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/28/24 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:52

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 02:24	200.0	181.1		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/29/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 02:19	30.0	21.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/29/24 02:24	200.0	180.1		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/29/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 02:19	30.0	21.0		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	06/29/24 03:24	200.0	177.6		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	06/29/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 03:24	200.0	181.1		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	06/29/24 03:14	18.0	18.1		R-A	0.0
	Zero	06/29/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/29/24 03:24	200.0	178.1		R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	06/29/24 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	06/29/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/29/24 03:24	200.0	180.1		R-A /Span * 100	0.2

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:52

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/29/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/29/24 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/29/24 03:14	21.0	18.0		R-A	0.0
	Zero	06/29/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/30/24 02:24	200.0	181.1		R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/30/24 02:19	30.0	21.2		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/30/24 02:24	200.0	180.1		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	06/30/24 02:19	30.0	21.0		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	06/30/24 03:24	200.0	177.6		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	06/30/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	06/30/24 03:24	200.0	181.1		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	06/30/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/30/24 03:14	18.0	18.1		R-A	0.0
	Zero	06/30/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	06/30/24 03:24	200.0	178.1		R-A /Span * 100	0.4

Daily Calibration Results

All Units

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:52 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	06/30/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	06/30/24 03:24	200.0	180.1	179.4	R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	06/30/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	06/30/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	06/30/24 03:14	21.0	18.0	18.0	R-A	0.0
	Zero	06/30/24 03:19	21.0	0.0	0.0	R-A	0.0

Load Summary Report

CT1 / CT2 / CT5 / CT6 Load Summary



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:32 Location: Roseville, CA

* = Excess Emission

Date	Unit CT1 Load, _CT, MWe		Unit CT1 Load_Total, MWe		Unit CT2 Load, _CT, MWe		Unit CT2 Load_Total, MWe		Unit CT5 Load, MWe		Unit CT6 Load, MWe	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Avg	Rolling Avg
Apr 2024	20,882.0	140,990.9	29,528	209,851	575.1	87,982.6	785	136,735	0.0	0.0	0.0	0.0
May 2024	18,073.6	158,714.0	26,263	235,736	8,730.2	96,712.8	12,951	149,686	538.7	538.7	0.7	0.3
Jun 2024	10,129.6	167,267.9	15,079	248,420	20,697.6	117,410.4	30,619	180,305	62.5	601.2	0.1	0.2
Sum/Avg	167,267.9		248,420		117,410.4		180,305		601.2		0.2	
Limit Value												

Monthly Summary Report

Units CT1 / CT2 / CT5 / CT6



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:51 Location: Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr		Unit CT5 OperatingTime, Hr		Unit CT6 OperatingTime, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Apr 24	643.55	643.55	0.40	0.40	18.43	18.43	0.00	0.00	0.00	0.00	0.00	0.00
May 24	547.18	1,190.73	40.62	41.02	258.73	277.16	40.78	40.78	18.69	18.69	16.58	16.58
Jun 24	298.43	1,489.16	40.06	81.08	622.53	899.69	53.62	94.40	2.25	20.94	2.23	18.81
Sum/Avg	1,489.16		81.08		899.69		94.40		20.94		18.81	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2024 00:00	0	0	0
04/01/2024 01:00	0	0	0
04/01/2024 02:00	0	0	0
04/01/2024 03:00	0	0	0
04/01/2024 04:00	0	0	0
04/01/2024 05:00	0	0	0
04/01/2024 06:00	0	0	0
04/01/2024 07:00	0	0	0
04/01/2024 08:00	0	0	0
04/01/2024 09:00	0	0	0
04/01/2024 10:00	0	0	0
04/01/2024 11:00	0	0	0
04/01/2024 12:00	0	0	0
04/01/2024 13:00	0	0	0
04/01/2024 14:00	0	0	0
04/01/2024 15:00	0	0	0
04/01/2024 16:00	0	0	0
04/01/2024 17:00	0	0	0
04/01/2024 18:00	0	0	0
04/01/2024 19:00	0	0	0
04/01/2024 20:00	0	0	0
04/01/2024 21:00	0	0	0
04/01/2024 22:00	0	0	0
04/01/2024 23:00	0	0	0
Average/Sum#:	0 #	0	0
Minimum:	0	0	0
Maximum:	0	0	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2024 00:00	0	0	0	
04/02/2024 01:00	0	0	0	
04/02/2024 02:00	0	0	0	
04/02/2024 03:00	0	0	0	
04/02/2024 04:00	0	0	0	
04/02/2024 05:00	0	0	0	
04/02/2024 06:00	1	0	2	
04/02/2024 07:00	1	0	13	
04/02/2024 08:00	1	0	28	
04/02/2024 09:00	1	0	40	
04/02/2024 10:00	1	0	37	
04/02/2024 11:00	1	0	30	
04/02/2024 12:00	0	0	15	
04/02/2024 13:00	0	0	7	
04/02/2024 14:00	0	0	0	
04/02/2024 15:00	0	0	0	
04/02/2024 16:00	0	0	0	
04/02/2024 17:00	0	0	0	
04/02/2024 18:00	0	0	0	
04/02/2024 19:00	0	0	0	
04/02/2024 20:00	0	0	0	
04/02/2024 21:00	0	0	0	
04/02/2024 22:00	0	0	0	
04/02/2024 23:00	0	0	0	
Average/Sum#:	6 #	0	7	
Minimum:	0	0	0	
Maximum:	1	0	40	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2024 00:00	0	0	0	0
04/03/2024 01:00	0	0	0	0
04/03/2024 02:00	0	0	0	0
04/03/2024 03:00	0	0	0	0
04/03/2024 04:00	0	0	0	0
04/03/2024 05:00	0	0	0	0
04/03/2024 06:00	0	0	0	0
04/03/2024 07:00	0	0	0	0
04/03/2024 08:00	0	0	0	0
04/03/2024 09:00	0	0	0	0
04/03/2024 10:00	0	0	0	0
04/03/2024 11:00	0	0	0	0
04/03/2024 12:00	0	0	0	0
04/03/2024 13:00	0	0	0	0
04/03/2024 14:00	0	0	0	0
04/03/2024 15:00	0	0	0	0
04/03/2024 16:00	0	0	0	0
04/03/2024 17:00	0	0	0	0
04/03/2024 18:00	0	0	0	0
04/03/2024 19:00	0	0	0	0
04/03/2024 20:00	0	0	0	0
04/03/2024 21:00	0	0	0	0
04/03/2024 22:00	0	0	0	0
04/03/2024 23:00	0	0	0	0
Average/Sum#:	0 #	0	0	0
Minimum:	0	0	0	0
Maximum:	0	0	0	0
%SI	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2024 00:00	0	0	0	0
04/04/2024 01:00	0	0	0	0
04/04/2024 02:00	0	0	0	0
04/04/2024 03:00	0	0	0	0
04/04/2024 04:00	1	6	0	0
04/04/2024 05:00	1	19	0	0
04/04/2024 06:00	1	33	0	0
04/04/2024 07:00	1	41	0	0
04/04/2024 08:00	1	44	0	0
04/04/2024 09:00	1	44	0	0
04/04/2024 10:00	1	45	0	0
04/04/2024 11:00	1	50	0	0
04/04/2024 12:00	1	56	0	0
04/04/2024 13:00	1	61	0	0
04/04/2024 14:00	1	61	0	0
04/04/2024 15:00	1	58	0	0
04/04/2024 16:00	1	56	0	0
04/04/2024 17:00	1	52	0	0
04/04/2024 18:00	1	51	0	0
04/04/2024 19:00	1	51	0	0
04/04/2024 20:00	1	55	0	0
04/04/2024 21:00	1	58	0	0
04/04/2024 22:00	1	61	0	0
04/04/2024 23:00	1	58	0	0
Average/Sum#:	20 #	40	0	0
Minimum:	0	0	0	0
Maximum:	1	61	0	0
%SI	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2024 00:00	1	58	0	
04/05/2024 01:00	1	57	0	
04/05/2024 02:00	1	55	0	
04/05/2024 03:00	1	52	0	
04/05/2024 04:00	1	48	0	
04/05/2024 05:00	1	54	0	
04/05/2024 06:00	1	57	0	
04/05/2024 07:00	1	61	0	
04/05/2024 08:00	1	59	0	
04/05/2024 09:00	1	56	0	
04/05/2024 10:00	1	56	0	
04/05/2024 11:00	1	55	0	
04/05/2024 12:00	1	53	0	
04/05/2024 13:00	1	52	0	
04/05/2024 14:00	1	51	0	
04/05/2024 15:00	1	50	0	
04/05/2024 16:00	1	46	0	
04/05/2024 17:00	1	46	0	
04/05/2024 18:00	1	51	0	
04/05/2024 19:00	1	56	0	
04/05/2024 20:00	1	59	0	
04/05/2024 21:00	1	57	0	
04/05/2024 22:00	1	52	0	
04/05/2024 23:00	1	47	0	
Average/Sum#:	24 #	54	0	
Minimum:	1	46	0	
Maximum:	1	61	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2024 00:00	1	45	0	
04/06/2024 01:00	1	45	0	
04/06/2024 02:00	1	45	0	
04/06/2024 03:00	1	45	0	
04/06/2024 04:00	1	48	0	
04/06/2024 05:00	1	54	0	
04/06/2024 06:00	1	55	0	
04/06/2024 07:00	1	52	0	
04/06/2024 08:00	1	46	0	
04/06/2024 09:00	1	45	0	
04/06/2024 10:00	1	45	0	
04/06/2024 11:00	1	45	0	
04/06/2024 12:00	1	45	0	
04/06/2024 13:00	1	45	0	
04/06/2024 14:00	1	45	0	
04/06/2024 15:00	1	44	0	
04/06/2024 16:00	1	44	0	
04/06/2024 17:00	1	45	0	
04/06/2024 18:00	1	45	0	
04/06/2024 19:00	1	45	0	
04/06/2024 20:00	1	44	0	
04/06/2024 21:00	1	44	0	
04/06/2024 22:00	1	44	0	
04/06/2024 23:00	1	44	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	55	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2024 00:00	1	44	0	
04/07/2024 01:00	1	44	0	
04/07/2024 02:00	1	44	0	
04/07/2024 03:00	1	44	0	
04/07/2024 04:00	1	44	0	
04/07/2024 05:00	1	44	0	
04/07/2024 06:00	1	44	0	
04/07/2024 07:00	1	44	0	
04/07/2024 08:00	1	44	0	
04/07/2024 09:00	1	44	0	
04/07/2024 10:00	1	44	0	
04/07/2024 11:00	1	44	0	
04/07/2024 12:00	1	44	0	
04/07/2024 13:00	1	44	0	
04/07/2024 14:00	1	44	0	
04/07/2024 15:00	1	44	0	
04/07/2024 16:00	1	44	0	
04/07/2024 17:00	1	46	0	
04/07/2024 18:00	1	46	0	
04/07/2024 19:00	1	46	0	
04/07/2024 20:00	1	45	0	
04/07/2024 21:00	1	45	0	
04/07/2024 22:00	1	45	0	
04/07/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	46	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2024 00:00	1	44	0	
04/08/2024 01:00	1	44	0	
04/08/2024 02:00	1	44	0	
04/08/2024 03:00	1	44	0	
04/08/2024 04:00	1	48	0	
04/08/2024 05:00	1	53	0	
04/08/2024 06:00	1	55	0	
04/08/2024 07:00	1	52	0	
04/08/2024 08:00	1	46	0	
04/08/2024 09:00	1	44	0	
04/08/2024 10:00	1	47	0	
04/08/2024 11:00	1	47	0	
04/08/2024 12:00	1	47	0	
04/08/2024 13:00	1	44	0	
04/08/2024 14:00	1	44	0	
04/08/2024 15:00	1	44	0	
04/08/2024 16:00	1	44	0	
04/08/2024 17:00	1	45	0	
04/08/2024 18:00	1	45	0	
04/08/2024 19:00	1	45	0	
04/08/2024 20:00	1	44	0	
04/08/2024 21:00	1	44	0	
04/08/2024 22:00	1	44	0	
04/08/2024 23:00	1	49	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	55	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2024 00:00	1	55	0	
04/09/2024 01:00	1	60	0	
04/09/2024 02:00	1	60	0	
04/09/2024 03:00	1	60	0	
04/09/2024 04:00	1	57	0	
04/09/2024 05:00	1	57	0	
04/09/2024 06:00	1	53	0	
04/09/2024 07:00	1	51	0	
04/09/2024 08:00	1	48	0	
04/09/2024 09:00	1	46	0	
04/09/2024 10:00	1	46	0	
04/09/2024 11:00	1	44	0	
04/09/2024 12:00	1	44	0	
04/09/2024 13:00	1	44	0	
04/09/2024 14:00	1	44	0	
04/09/2024 15:00	1	44	0	
04/09/2024 16:00	1	43	7	
04/09/2024 17:00	1	43	22	
04/09/2024 18:00	1	43	37	
04/09/2024 19:00	1	45	46	
04/09/2024 20:00	1	46	47	
04/09/2024 21:00	1	46	44	
04/09/2024 22:00	1	45	28	
04/09/2024 23:00	1	45	12	
Average/Sum#:	24 #	49	10	
Minimum:	1	43	0	
Maximum:	1	60	47	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2024 00:00	1	44	0	
04/10/2024 01:00	1	44	0	
04/10/2024 02:00	1	44	0	
04/10/2024 03:00	1	44	0	
04/10/2024 04:00	1	44	0	
04/10/2024 05:00	1	44	0	
04/10/2024 06:00	1	44	0	
04/10/2024 07:00	1	44	0	
04/10/2024 08:00	1	44	0	
04/10/2024 09:00	1	44	0	
04/10/2024 10:00	1	44	0	
04/10/2024 11:00	1	44	0	
04/10/2024 12:00	1	44	0	
04/10/2024 13:00	1	44	0	
04/10/2024 14:00	1	44	0	
04/10/2024 15:00	1	44	0	
04/10/2024 16:00	1	44	2	
04/10/2024 17:00	1	43	16	
04/10/2024 18:00	1	44	32	
04/10/2024 19:00	1	44	45	
04/10/2024 20:00	1	45	47	
04/10/2024 21:00	1	45	47	
04/10/2024 22:00	1	46	47	
04/10/2024 23:00	1	46	47	
Average/Sum#:	24 #	44	12	
Minimum:	1	43	0	
Maximum:	1	46	47	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2024 00:00	1	47	45	
04/11/2024 01:00	1	47	29	
04/11/2024 02:00	1	47	13	
04/11/2024 03:00	1	45	0	
04/11/2024 04:00	1	45	0	
04/11/2024 05:00	1	47	0	
04/11/2024 06:00	1	47	0	
04/11/2024 07:00	1	46	0	
04/11/2024 08:00	1	44	0	
04/11/2024 09:00	1	44	0	
04/11/2024 10:00	1	44	0	
04/11/2024 11:00	1	44	0	
04/11/2024 12:00	1	44	0	
04/11/2024 13:00	1	44	0	
04/11/2024 14:00	1	44	0	
04/11/2024 15:00	1	44	0	
04/11/2024 16:00	1	44	0	
04/11/2024 17:00	1	44	0	
04/11/2024 18:00	1	44	0	
04/11/2024 19:00	1	44	0	
04/11/2024 20:00	1	44	0	
04/11/2024 21:00	1	44	0	
04/11/2024 22:00	1	44	0	
04/11/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	4	
Minimum:	1	44	0	
Maximum:	1	47	45	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2024 00:00	1	44	0	
04/12/2024 01:00	1	44	0	
04/12/2024 02:00	1	44	0	
04/12/2024 03:00	1	44	0	
04/12/2024 04:00	1	44	0	
04/12/2024 05:00	1	44	0	
04/12/2024 06:00	1	44	0	
04/12/2024 07:00	1	44	0	
04/12/2024 08:00	1	44	0	
04/12/2024 09:00	1	44	0	
04/12/2024 10:00	1	44	0	
04/12/2024 11:00	1	44	0	
04/12/2024 12:00	1	44	0	
04/12/2024 13:00	1	44	0	
04/12/2024 14:00	1	44	0	
04/12/2024 15:00	1	44	0	
04/12/2024 16:00	1	44	0	
04/12/2024 17:00	1	44	0	
04/12/2024 18:00	1	44	0	
04/12/2024 19:00	1	44	0	
04/12/2024 20:00	1	44	0	
04/12/2024 21:00	1	44	0	
04/12/2024 22:00	1	44	0	
04/12/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2024 00:00	1	44	0	
04/13/2024 01:00	1	44	0	
04/13/2024 02:00	1	44	0	
04/13/2024 03:00	1	44	0	
04/13/2024 04:00	1	44	0	
04/13/2024 05:00	1	44	0	
04/13/2024 06:00	1	44	0	
04/13/2024 07:00	1	44	0	
04/13/2024 08:00	1	44	0	
04/13/2024 09:00	1	44	0	
04/13/2024 10:00	1	44	0	
04/13/2024 11:00	1	44	0	
04/13/2024 12:00	1	44	0	
04/13/2024 13:00	1	44	0	
04/13/2024 14:00	1	44	0	
04/13/2024 15:00	1	44	0	
04/13/2024 16:00	1	44	0	
04/13/2024 17:00	1	44	0	
04/13/2024 18:00	1	44	0	
04/13/2024 19:00	1	44	0	
04/13/2024 20:00	1	44	0	
04/13/2024 21:00	1	44	0	
04/13/2024 22:00	1	44	0	
04/13/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, Mwe		Load_Total_, 3Hr, Mwe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2024 00:00	1	44	0	
04/14/2024 01:00	1	44	0	
04/14/2024 02:00	1	44	0	
04/14/2024 03:00	1	44	0	
04/14/2024 04:00	1	44	0	
04/14/2024 05:00	1	44	0	
04/14/2024 06:00	1	44	0	
04/14/2024 07:00	1	44	0	
04/14/2024 08:00	1	47	0	
04/14/2024 09:00	1	47	0	
04/14/2024 10:00	1	47	0	
04/14/2024 11:00	1	44	0	
04/14/2024 12:00	1	44	0	
04/14/2024 13:00	1	44	0	
04/14/2024 14:00	1	44	0	
04/14/2024 15:00	1	44	0	
04/14/2024 16:00	1	44	0	
04/14/2024 17:00	1	44	0	
04/14/2024 18:00	1	44	0	
04/14/2024 19:00	1	44	0	
04/14/2024 20:00	1	44	0	
04/14/2024 21:00	1	44	0	
04/14/2024 22:00	1	44	0	
04/14/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	47	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2024 00:00	1	44	0	
04/15/2024 01:00	1	44	0	
04/15/2024 02:00	1	44	0	
04/15/2024 03:00	1	44	0	
04/15/2024 04:00	1	44	0	
04/15/2024 05:00	1	44	0	
04/15/2024 06:00	1	44	0	
04/15/2024 07:00	1	44	0	
04/15/2024 08:00	1	44	0	
04/15/2024 09:00	1	44	0	
04/15/2024 10:00	1	44	0	
04/15/2024 11:00	1	44	0	
04/15/2024 12:00	1	44	0	
04/15/2024 13:00	1	44	0	
04/15/2024 14:00	1	44	0	
04/15/2024 15:00	1	44	0	
04/15/2024 16:00	1	44	0	
04/15/2024 17:00	1	44	0	
04/15/2024 18:00	1	44	0	
04/15/2024 19:00	1	44	0	
04/15/2024 20:00	1	44	0	
04/15/2024 21:00	1	44	0	
04/15/2024 22:00	1	44	0	
04/15/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2024 00:00	1	44	0	
04/16/2024 01:00	1	44	0	
04/16/2024 02:00	1	44	0	
04/16/2024 03:00	1	44	0	
04/16/2024 04:00	1	44	0	
04/16/2024 05:00	1	44	0	
04/16/2024 06:00	1	44	0	
04/16/2024 07:00	1	44	0	
04/16/2024 08:00	1	44	0	
04/16/2024 09:00	1	44	0	
04/16/2024 10:00	1	44	0	
04/16/2024 11:00	1	44	0	
04/16/2024 12:00	1	44	0	
04/16/2024 13:00	1	44	0	
04/16/2024 14:00	1	44	0	
04/16/2024 15:00	1	44	0	
04/16/2024 16:00	1	44	0	
04/16/2024 17:00	1	44	0	
04/16/2024 18:00	1	44	0	
04/16/2024 19:00	1	44	0	
04/16/2024 20:00	1	44	0	
04/16/2024 21:00	1	44	0	
04/16/2024 22:00	1	44	0	
04/16/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2024 00:00	1	44	0	
04/17/2024 01:00	1	44	0	
04/17/2024 02:00	1	44	0	
04/17/2024 03:00	1	44	0	
04/17/2024 04:00	1	44	0	
04/17/2024 05:00	1	44	0	
04/17/2024 06:00	1	44	0	
04/17/2024 07:00	1	44	0	
04/17/2024 08:00	1	44	0	
04/17/2024 09:00	1	44	0	
04/17/2024 10:00	1	44	0	
04/17/2024 11:00	1	44	0	
04/17/2024 12:00	1	44	0	
04/17/2024 13:00	1	44	0	
04/17/2024 14:00	1	44	0	
04/17/2024 15:00	1	44	0	
04/17/2024 16:00	1	44	0	
04/17/2024 17:00	1	44	0	
04/17/2024 18:00	1	44	0	
04/17/2024 19:00	1	44	0	
04/17/2024 20:00	1	44	0	
04/17/2024 21:00	1	44	0	
04/17/2024 22:00	1	44	0	
04/17/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2024 00:00	1	44	0	
04/18/2024 01:00	1	44	0	
04/18/2024 02:00	1	44	0	
04/18/2024 03:00	1	44	0	
04/18/2024 04:00	1	44	0	
04/18/2024 05:00	1	44	0	
04/18/2024 06:00	1	44	0	
04/18/2024 07:00	1	44	0	
04/18/2024 08:00	1	44	0	
04/18/2024 09:00	1	44	0	
04/18/2024 10:00	1	44	0	
04/18/2024 11:00	1	44	0	
04/18/2024 12:00	1	44	0	
04/18/2024 13:00	1	44	0	
04/18/2024 14:00	1	44	0	
04/18/2024 15:00	1	45	0	
04/18/2024 16:00	1	45	0	
04/18/2024 17:00	1	45	0	
04/18/2024 18:00	1	45	0	
04/18/2024 19:00	1	45	0	
04/18/2024 20:00	1	45	0	
04/18/2024 21:00	1	44	0	
04/18/2024 22:00	1	44	0	
04/18/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2024 00:00	1	44	0	
04/19/2024 01:00	1	44	0	
04/19/2024 02:00	1	44	0	
04/19/2024 03:00	1	44	0	
04/19/2024 04:00	1	44	0	
04/19/2024 05:00	1	44	0	
04/19/2024 06:00	1	44	0	
04/19/2024 07:00	1	44	0	
04/19/2024 08:00	1	44	0	
04/19/2024 09:00	1	44	0	
04/19/2024 10:00	1	44	0	
04/19/2024 11:00	1	44	0	
04/19/2024 12:00	1	44	0	
04/19/2024 13:00	1	44	0	
04/19/2024 14:00	1	44	0	
04/19/2024 15:00	1	44	0	
04/19/2024 16:00	1	44	0	
04/19/2024 17:00	1	45	0	
04/19/2024 18:00	1	45	0	
04/19/2024 19:00	1	45	0	
04/19/2024 20:00	1	44	0	
04/19/2024 21:00	1	44	0	
04/19/2024 22:00	1	44	0	
04/19/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2024 00:00	1	44	0	
04/20/2024 01:00	1	44	0	
04/20/2024 02:00	1	44	0	
04/20/2024 03:00	1	44	0	
04/20/2024 04:00	1	44	0	
04/20/2024 05:00	1	44	0	
04/20/2024 06:00	1	44	0	
04/20/2024 07:00	1	44	0	
04/20/2024 08:00	1	44	0	
04/20/2024 09:00	1	44	0	
04/20/2024 10:00	1	44	0	
04/20/2024 11:00	1	44	0	
04/20/2024 12:00	1	44	0	
04/20/2024 13:00	1	44	0	
04/20/2024 14:00	1	44	0	
04/20/2024 15:00	1	44	0	
04/20/2024 16:00	1	44	0	
04/20/2024 17:00	1	44	0	
04/20/2024 18:00	1	44	0	
04/20/2024 19:00	1	44	0	
04/20/2024 20:00	1	44	0	
04/20/2024 21:00	1	44	0	
04/20/2024 22:00	1	44	0	
04/20/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2024 00:00	1	44	0	
04/21/2024 01:00	1	44	0	
04/21/2024 02:00	1	44	0	
04/21/2024 03:00	1	44	0	
04/21/2024 04:00	1	44	0	
04/21/2024 05:00	1	44	0	
04/21/2024 06:00	1	44	0	
04/21/2024 07:00	1	44	0	
04/21/2024 08:00	1	44	0	
04/21/2024 09:00	1	44	0	
04/21/2024 10:00	1	44	0	
04/21/2024 11:00	1	44	0	
04/21/2024 12:00	1	44	0	
04/21/2024 13:00	1	44	0	
04/21/2024 14:00	1	44	0	
04/21/2024 15:00	1	44	0	
04/21/2024 16:00	1	44	0	
04/21/2024 17:00	1	46	0	
04/21/2024 18:00	1	46	0	
04/21/2024 19:00	1	48	0	
04/21/2024 20:00	1	48	0	
04/21/2024 21:00	1	51	0	
04/21/2024 22:00	1	49	0	
04/21/2024 23:00	1	48	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	51	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2024 00:00	1	45	0	
04/22/2024 01:00	1	46	0	
04/22/2024 02:00	1	45	0	
04/22/2024 03:00	1	45	0	
04/22/2024 04:00	1	45	0	
04/22/2024 05:00	1	48	0	
04/22/2024 06:00	1	50	0	
04/22/2024 07:00	1	50	0	
04/22/2024 08:00	1	47	0	
04/22/2024 09:00	1	45	0	
04/22/2024 10:00	1	44	0	
04/22/2024 11:00	1	44	0	
04/22/2024 12:00	1	44	0	
04/22/2024 13:00	1	44	0	
04/22/2024 14:00	1	44	0	
04/22/2024 15:00	1	44	0	
04/22/2024 16:00	1	44	0	
04/22/2024 17:00	1	46	0	
04/22/2024 18:00	1	49	0	
04/22/2024 19:00	1	53	0	
04/22/2024 20:00	1	55	0	
04/22/2024 21:00	1	53	0	
04/22/2024 22:00	1	49	0	
04/22/2024 23:00	1	46	0	
Average/Sum#:	24 #	47	0	
Minimum:	1	44	0	
Maximum:	1	55	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2024 00:00	1	44	0	
04/23/2024 01:00	1	44	0	
04/23/2024 02:00	1	44	0	
04/23/2024 03:00	1	44	0	
04/23/2024 04:00	1	44	0	
04/23/2024 05:00	1	44	0	
04/23/2024 06:00	1	44	0	
04/23/2024 07:00	1	44	0	
04/23/2024 08:00	1	44	0	
04/23/2024 09:00	1	44	0	
04/23/2024 10:00	1	46	0	
04/23/2024 11:00	1	46	0	
04/23/2024 12:00	1	47	0	
04/23/2024 13:00	1	47	0	
04/23/2024 14:00	1	52	0	
04/23/2024 15:00	1	56	0	
04/23/2024 16:00	1	55	0	
04/23/2024 17:00	1	51	0	
04/23/2024 18:00	1	51	0	
04/23/2024 19:00	1	56	0	
04/23/2024 20:00	1	60	0	
04/23/2024 21:00	1	58	0	
04/23/2024 22:00	1	52	0	
04/23/2024 23:00	1	48	0	
Average/Sum#:	24 #	49	0	
Minimum:	1	44	0	
Maximum:	1	60	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2024 00:00	1	45	0	
04/24/2024 01:00	1	45	0	
04/24/2024 02:00	1	44	0	
04/24/2024 03:00	1	44	0	
04/24/2024 04:00	1	44	0	
04/24/2024 05:00	1	47	0	
04/24/2024 06:00	1	48	0	
04/24/2024 07:00	1	53	0	
04/24/2024 08:00	1	53	0	
04/24/2024 09:00	1	52	0	
04/24/2024 10:00	1	47	0	
04/24/2024 11:00	1	44	0	
04/24/2024 12:00	1	44	0	
04/24/2024 13:00	1	44	0	
04/24/2024 14:00	1	44	0	
04/24/2024 15:00	1	44	0	
04/24/2024 16:00	1	44	0	
04/24/2024 17:00	1	46	0	
04/24/2024 18:00	1	46	0	
04/24/2024 19:00	1	47	0	
04/24/2024 20:00	1	45	0	
04/24/2024 21:00	1	45	0	
04/24/2024 22:00	1	44	0	
04/24/2024 23:00	1	44	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	53	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2024 00:00	1	44	0	
04/25/2024 01:00	1	44	0	
04/25/2024 02:00	1	44	0	
04/25/2024 03:00	1	44	0	
04/25/2024 04:00	1	44	0	
04/25/2024 05:00	1	47	0	
04/25/2024 06:00	1	51	0	
04/25/2024 07:00	1	55	0	
04/25/2024 08:00	1	54	0	
04/25/2024 09:00	1	50	0	
04/25/2024 10:00	1	46	0	
04/25/2024 11:00	1	44	0	
04/25/2024 12:00	1	44	0	
04/25/2024 13:00	1	44	0	
04/25/2024 14:00	1	44	0	
04/25/2024 15:00	1	44	0	
04/25/2024 16:00	1	45	0	
04/25/2024 17:00	1	46	0	
04/25/2024 18:00	1	46	0	
04/25/2024 19:00	1	48	0	
04/25/2024 20:00	1	47	0	
04/25/2024 21:00	1	47	0	
04/25/2024 22:00	1	45	0	
04/25/2024 23:00	1	45	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	55	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2024 00:00	1	44	44	0
04/26/2024 01:00	1	44	44	0
04/26/2024 02:00	1	44	44	0
04/26/2024 03:00	1	45	45	0
04/26/2024 04:00	1	45	45	0
04/26/2024 05:00	1	44	44	0
04/26/2024 06:00	1	44	44	0
04/26/2024 07:00	1	44	44	0
04/26/2024 08:00	1	44	44	0
04/26/2024 09:00	1	44	44	0
04/26/2024 10:00	1	44	44	0
04/26/2024 11:00	1	44	44	0
04/26/2024 12:00	1	44	44	0
04/26/2024 13:00	1	44	44	0
04/26/2024 14:00	1	44	44	0
04/26/2024 15:00	1	44	44	0
04/26/2024 16:00	1	44	44	0
04/26/2024 17:00	1	44	44	0
04/26/2024 18:00	1	44	44	0
04/26/2024 19:00	1	44	44	0
04/26/2024 20:00	1	44	44	0
04/26/2024 21:00	1	44	44	0
04/26/2024 22:00	1	44	44	0
04/26/2024 23:00	1	44	44	0
Average/Sum#:	24 #	44	44	0
Minimum:	1	44	44	0
Maximum:	1	45	45	0
%SI	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2024 00:00	1	44	0	
04/27/2024 01:00	1	44	0	
04/27/2024 02:00	1	44	0	
04/27/2024 03:00	1	44	0	
04/27/2024 04:00	1	44	0	
04/27/2024 05:00	1	44	0	
04/27/2024 06:00	1	44	0	
04/27/2024 07:00	1	44	0	
04/27/2024 08:00	1	44	0	
04/27/2024 09:00	1	44	0	
04/27/2024 10:00	1	44	0	
04/27/2024 11:00	1	44	0	
04/27/2024 12:00	1	44	0	
04/27/2024 13:00	1	44	0	
04/27/2024 14:00	1	44	0	
04/27/2024 15:00	1	44	0	
04/27/2024 16:00	1	44	0	
04/27/2024 17:00	1	44	0	
04/27/2024 18:00	1	45	0	
04/27/2024 19:00	1	45	0	
04/27/2024 20:00	1	45	0	
04/27/2024 21:00	1	44	0	
04/27/2024 22:00	1	49	0	
04/27/2024 23:00	1	55	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	55	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2024 00:00	1	60	0	
04/28/2024 01:00	1	59	0	
04/28/2024 02:00	1	59	0	
04/28/2024 03:00	1	58	0	
04/28/2024 04:00	1	58	0	
04/28/2024 05:00	1	55	0	
04/28/2024 06:00	1	50	0	
04/28/2024 07:00	1	46	0	
04/28/2024 08:00	1	44	0	
04/28/2024 09:00	1	44	0	
04/28/2024 10:00	1	44	0	
04/28/2024 11:00	1	44	0	
04/28/2024 12:00	1	44	0	
04/28/2024 13:00	1	44	0	
04/28/2024 14:00	1	44	0	
04/28/2024 15:00	1	44	0	
04/28/2024 16:00	1	44	0	
04/28/2024 17:00	1	44	0	
04/28/2024 18:00	1	44	0	
04/28/2024 19:00	1	44	0	
04/28/2024 20:00	1	44	0	
04/28/2024 21:00	1	44	0	
04/28/2024 22:00	1	44	0	
04/28/2024 23:00	1	44	0	
Average/Sum#:	24 #	48	0	
Minimum:	1	44	0	
Maximum:	1	60	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2024 00:00	1	44	0	
04/29/2024 01:00	1	44	0	
04/29/2024 02:00	1	44	0	
04/29/2024 03:00	1	44	0	
04/29/2024 04:00	1	45	0	
04/29/2024 05:00	1	46	0	
04/29/2024 06:00	1	46	0	
04/29/2024 07:00	1	45	0	
04/29/2024 08:00	1	44	0	
04/29/2024 09:00	1	44	0	
04/29/2024 10:00	1	44	0	
04/29/2024 11:00	1	44	0	
04/29/2024 12:00	1	44	0	
04/29/2024 13:00	1	44	0	
04/29/2024 14:00	1	44	0	
04/29/2024 15:00	1	44	0	
04/29/2024 16:00	1	44	0	
04/29/2024 17:00	1	46	0	
04/29/2024 18:00	1	50	0	
04/29/2024 19:00	1	54	0	
04/29/2024 20:00	1	53	0	
04/29/2024 21:00	1	49	0	
04/29/2024 22:00	1	45	0	
04/29/2024 23:00	1	44	0	
<hr/>				
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	54	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2024 00:00	1	44	0	
04/30/2024 01:00	1	44	0	
04/30/2024 02:00	1	44	0	
04/30/2024 03:00	1	44	0	
04/30/2024 04:00	1	45	0	
04/30/2024 05:00	1	48	0	
04/30/2024 06:00	1	48	0	
04/30/2024 07:00	1	47	0	
04/30/2024 08:00	1	44	0	
04/30/2024 09:00	1	44	0	
04/30/2024 10:00	1	44	0	
04/30/2024 11:00	1	44	0	
04/30/2024 12:00	1	44	0	
04/30/2024 13:00	1	44	0	
04/30/2024 14:00	1	44	0	
04/30/2024 15:00	1	44	0	
04/30/2024 16:00	1	44	0	
04/30/2024 17:00	1	46	0	
04/30/2024 18:00	1	49	0	
04/30/2024 19:00	1	54	0	
04/30/2024 20:00	1	56	0	
04/30/2024 21:00	1	58	0	
04/30/2024 22:00	1	58	0	
04/30/2024 23:00	1	59	0	
Average/Sum#:	24 #	48	0	
Minimum:	1	44	0	
Maximum:	1	59	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2024 00:00	1	56	0	
05/01/2024 01:00	1	52	0	
05/01/2024 02:00	1	47	0	
05/01/2024 03:00	1	46	0	
05/01/2024 04:00	1	47	0	
05/01/2024 05:00	1	49	0	
05/01/2024 06:00	1	48	0	
05/01/2024 07:00	1	47	0	
05/01/2024 08:00	1	44	0	
05/01/2024 09:00	1	44	0	
05/01/2024 10:00	1	44	0	
05/01/2024 11:00	1	44	0	
05/01/2024 12:00	1	44	0	
05/01/2024 13:00	1	44	0	
05/01/2024 14:00	1	44	0	
05/01/2024 15:00	1	44	0	
05/01/2024 16:00	1	44	0	
05/01/2024 17:00	1	44	0	
05/01/2024 18:00	1	44	0	
05/01/2024 19:00	1	44	0	
05/01/2024 20:00	1	44	0	
05/01/2024 21:00	1	44	0	
05/01/2024 22:00	1	44	0	
05/01/2024 23:00	1	44	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	56	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2024 00:00	1	44	0	
05/02/2024 01:00	1	44	0	
05/02/2024 02:00	1	44	0	
05/02/2024 03:00	1	44	0	
05/02/2024 04:00	1	45	0	
05/02/2024 05:00	1	49	0	
05/02/2024 06:00	1	52	0	
05/02/2024 07:00	1	53	0	
05/02/2024 08:00	1	54	0	
05/02/2024 09:00	1	55	0	
05/02/2024 10:00	1	57	0	
05/02/2024 11:00	1	56	0	
05/02/2024 12:00	1	52	0	
05/02/2024 13:00	1	49	0	
05/02/2024 14:00	1	46	0	
05/02/2024 15:00	1	46	0	
05/02/2024 16:00	1	44	0	
05/02/2024 17:00	1	45	0	
05/02/2024 18:00	1	48	0	
05/02/2024 19:00	1	50	0	
05/02/2024 20:00	1	49	0	
05/02/2024 21:00	1	46	0	
05/02/2024 22:00	1	44	0	
05/02/2024 23:00	1	44	0	
Average/Sum#:	24 #	48	0	
Minimum:	1	44	0	
Maximum:	1	57	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2024 00:00	1	44	0	
05/03/2024 01:00	1	44	0	
05/03/2024 02:00	1	44	0	
05/03/2024 03:00	1	44	0	
05/03/2024 04:00	1	47	0	
05/03/2024 05:00	1	50	0	
05/03/2024 06:00	1	49	0	
05/03/2024 07:00	1	47	0	
05/03/2024 08:00	1	44	0	
05/03/2024 09:00	1	49	0	
05/03/2024 10:00	1	52	0	
05/03/2024 11:00	1	53	0	
05/03/2024 12:00	1	49	0	
05/03/2024 13:00	1	45	0	
05/03/2024 14:00	1	45	0	
05/03/2024 15:00	1	47	0	
05/03/2024 16:00	1	49	0	
05/03/2024 17:00	1	50	0	
05/03/2024 18:00	1	48	0	
05/03/2024 19:00	1	46	0	
05/03/2024 20:00	1	44	0	
05/03/2024 21:00	1	44	0	
05/03/2024 22:00	1	44	0	
05/03/2024 23:00	1	44	0	
Average/Sum#:	24 #	47	0	
Minimum:	1	44	0	
Maximum:	1	53	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2024 00:00	1	44	0	
05/04/2024 01:00	1	44	0	
05/04/2024 02:00	1	44	0	
05/04/2024 03:00	1	44	0	
05/04/2024 04:00	1	44	0	
05/04/2024 05:00	1	44	0	
05/04/2024 06:00	1	44	0	
05/04/2024 07:00	1	45	0	
05/04/2024 08:00	1	49	0	
05/04/2024 09:00	1	54	0	
05/04/2024 10:00	1	59	1	
05/04/2024 11:00	1	60	1	
05/04/2024 12:00	1	61	1	
05/04/2024 13:00	1	61	0	
05/04/2024 14:00	1	61	0	
05/04/2024 15:00	1	57	0	
05/04/2024 16:00	1	51	0	
05/04/2024 17:00	1	46	0	
05/04/2024 18:00	1	44	0	
05/04/2024 19:00	1	44	0	
05/04/2024 20:00	1	44	0	
05/04/2024 21:00	1	47	0	
05/04/2024 22:00	1	48	0	
05/04/2024 23:00	1	48	0	
Average/Sum#:	24 #	49	0	
Minimum:	1	44	0	
Maximum:	1	61	1	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2024 00:00	1	46	0	
05/05/2024 01:00	1	45	0	
05/05/2024 02:00	1	45	0	
05/05/2024 03:00	1	45	0	
05/05/2024 04:00	1	45	0	
05/05/2024 05:00	1	45	0	
05/05/2024 06:00	1	45	0	
05/05/2024 07:00	1	45	0	
05/05/2024 08:00	1	45	0	
05/05/2024 09:00	1	45	0	
05/05/2024 10:00	1	45	0	
05/05/2024 11:00	1	45	0	
05/05/2024 12:00	1	45	0	
05/05/2024 13:00	1	45	0	
05/05/2024 14:00	1	45	0	
05/05/2024 15:00	1	44	0	
05/05/2024 16:00	1	44	0	
05/05/2024 17:00	1	44	0	
05/05/2024 18:00	1	44	0	
05/05/2024 19:00	1	44	0	
05/05/2024 20:00	1	44	0	
05/05/2024 21:00	1	44	0	
05/05/2024 22:00	1	44	0	
05/05/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	46	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2024 00:00	1	44	0	
05/06/2024 01:00	1	44	0	
05/06/2024 02:00	1	44	0	
05/06/2024 03:00	1	44	0	
05/06/2024 04:00	1	44	0	
05/06/2024 05:00	1	44	0	
05/06/2024 06:00	1	44	0	
05/06/2024 07:00	1	44	0	
05/06/2024 08:00	1	44	0	
05/06/2024 09:00	1	44	0	
05/06/2024 10:00	1	44	0	
05/06/2024 11:00	1	44	0	
05/06/2024 12:00	1	44	0	
05/06/2024 13:00	1	44	0	
05/06/2024 14:00	1	44	0	
05/06/2024 15:00	1	44	0	
05/06/2024 16:00	1	44	0	
05/06/2024 17:00	1	44	0	
05/06/2024 18:00	1	44	0	
05/06/2024 19:00	1	44	0	
05/06/2024 20:00	1	44	0	
05/06/2024 21:00	1	44	0	
05/06/2024 22:00	1	44	0	
05/06/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	44	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2024 00:00	1	44	0	
05/07/2024 01:00	1	44	0	
05/07/2024 02:00	1	44	0	
05/07/2024 03:00	1	44	0	
05/07/2024 04:00	1	44	0	
05/07/2024 05:00	1	44	0	
05/07/2024 06:00	1	44	0	
05/07/2024 07:00	1	44	0	
05/07/2024 08:00	1	44	0	
05/07/2024 09:00	1	44	0	
05/07/2024 10:00	1	44	0	
05/07/2024 11:00	1	44	0	
05/07/2024 12:00	1	44	0	
05/07/2024 13:00	1	44	0	
05/07/2024 14:00	1	44	0	
05/07/2024 15:00	1	44	0	
05/07/2024 16:00	1	44	0	
05/07/2024 17:00	1	44	0	
05/07/2024 18:00	1	44	0	
05/07/2024 19:00	1	44	0	
05/07/2024 20:00	1	45	0	
05/07/2024 21:00	1	45	0	
05/07/2024 22:00	1	44	0	
05/07/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2024 00:00	1	44	0	
05/08/2024 01:00	1	44	0	
05/08/2024 02:00	1	44	0	
05/08/2024 03:00	1	44	0	
05/08/2024 04:00	1	45	0	
05/08/2024 05:00	1	48	0	
05/08/2024 06:00	1	48	0	
05/08/2024 07:00	1	47	0	
05/08/2024 08:00	1	44	0	
05/08/2024 09:00	1	44	0	
05/08/2024 10:00	1	44	0	
05/08/2024 11:00	1	44	0	
05/08/2024 12:00	1	44	0	
05/08/2024 13:00	1	44	0	
05/08/2024 14:00	1	44	0	
05/08/2024 15:00	1	44	0	
05/08/2024 16:00	1	44	0	
05/08/2024 17:00	1	45	0	
05/08/2024 18:00	1	45	0	
05/08/2024 19:00	1	46	0	
05/08/2024 20:00	1	45	0	
05/08/2024 21:00	1	45	0	
05/08/2024 22:00	1	44	0	
05/08/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	48	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2024 00:00	1	44	0	
05/09/2024 01:00	1	44	0	
05/09/2024 02:00	1	44	0	
05/09/2024 03:00	1	44	0	
05/09/2024 04:00	1	44	0	
05/09/2024 05:00	1	44	0	
05/09/2024 06:00	1	44	0	
05/09/2024 07:00	1	44	0	
05/09/2024 08:00	1	44	0	
05/09/2024 09:00	1	44	0	
05/09/2024 10:00	1	44	0	
05/09/2024 11:00	1	44	0	
05/09/2024 12:00	1	44	0	
05/09/2024 13:00	1	44	0	
05/09/2024 14:00	1	44	0	
05/09/2024 15:00	1	44	0	
05/09/2024 16:00	1	44	0	
05/09/2024 17:00	1	45	0	
05/09/2024 18:00	1	45	0	
05/09/2024 19:00	1	45	0	
05/09/2024 20:00	1	44	0	
05/09/2024 21:00	1	44	0	
05/09/2024 22:00	1	44	0	
05/09/2024 23:00	1	44	0	
Average/Sum#:	24 #	44	0	
Minimum:	1	44	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2024 00:00	1	44	0	
05/10/2024 01:00	1	44	0	
05/10/2024 02:00	1	44	0	
05/10/2024 03:00	1	44	0	
05/10/2024 04:00	1	44	0	
05/10/2024 05:00	1	44	0	
05/10/2024 06:00	1	44	0	
05/10/2024 07:00	1	44	0	
05/10/2024 08:00	1	44	0	
05/10/2024 09:00	1	44	0	
05/10/2024 10:00	1	45	0	
05/10/2024 11:00	1	45	0	
05/10/2024 12:00	1	45	0	
05/10/2024 13:00	1	44	0	
05/10/2024 14:00	1	45	0	
05/10/2024 15:00	1	49	0	
05/10/2024 16:00	1	49	0	
05/10/2024 17:00	1	49	0	
05/10/2024 18:00	1	49	0	
05/10/2024 19:00	1	50	0	
05/10/2024 20:00	1	49	0	
05/10/2024 21:00	1	47	0	
05/10/2024 22:00	1	48	0	
05/10/2024 23:00	1	48	0	
Average/Sum#:	24 #	46	0	
Minimum:	1	44	0	
Maximum:	1	50	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2024 00:00	1	47	0	
05/11/2024 01:00	1	44	0	
05/11/2024 02:00	1	44	0	
05/11/2024 03:00	1	44	0	
05/11/2024 04:00	1	44	0	
05/11/2024 05:00	1	44	0	
05/11/2024 06:00	1	44	0	
05/11/2024 07:00	1	44	0	
05/11/2024 08:00	1	44	0	
05/11/2024 09:00	1	44	0	
05/11/2024 10:00	1	44	0	
05/11/2024 11:00	1	48	0	
05/11/2024 12:00	1	47	0	
05/11/2024 13:00	1	50	0	
05/11/2024 14:00	1	50	0	
05/11/2024 15:00	1	55	0	
05/11/2024 16:00	1	52	0	
05/11/2024 17:00	1	50	0	
05/11/2024 18:00	1	48	0	
05/11/2024 19:00	1	47	0	
05/11/2024 20:00	1	50	0	
05/11/2024 21:00	1	52	0	
05/11/2024 22:00	1	57	0	
05/11/2024 23:00	1	56	0	
Average/Sum#:	24 #	48	0	
Minimum:	1	44	0	
Maximum:	1	57	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2024 00:00	1	52	0	
05/12/2024 01:00	1	48	0	
05/12/2024 02:00	1	45	0	
05/12/2024 03:00	1	45	0	
05/12/2024 04:00	1	44	0	
05/12/2024 05:00	1	44	0	
05/12/2024 06:00	1	44	0	
05/12/2024 07:00	1	44	0	
05/12/2024 08:00	1	44	0	
05/12/2024 09:00	1	45	0	
05/12/2024 10:00	1	45	0	
05/12/2024 11:00	1	45	0	
05/12/2024 12:00	1	45	0	
05/12/2024 13:00	1	45	0	
05/12/2024 14:00	1	45	0	
05/12/2024 15:00	1	44	0	
05/12/2024 16:00	1	44	0	
05/12/2024 17:00	1	45	0	
05/12/2024 18:00	1	45	0	
05/12/2024 19:00	1	45	0	
05/12/2024 20:00	1	44	0	
05/12/2024 21:00	1	44	0	
05/12/2024 22:00	1	44	0	
05/12/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	52	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2024 00:00	1	44	0	
05/13/2024 01:00	1	44	0	
05/13/2024 02:00	1	44	0	
05/13/2024 03:00	1	44	0	
05/13/2024 04:00	1	44	0	
05/13/2024 05:00	1	44	0	
05/13/2024 06:00	1	44	0	
05/13/2024 07:00	1	44	0	
05/13/2024 08:00	1	44	0	
05/13/2024 09:00	1	44	0	
05/13/2024 10:00	1	44	0	
05/13/2024 11:00	1	44	0	
05/13/2024 12:00	1	44	0	
05/13/2024 13:00	1	44	0	
05/13/2024 14:00	1	44	0	
05/13/2024 15:00	1	44	0	
05/13/2024 16:00	1	44	0	
05/13/2024 17:00	1	47	0	
05/13/2024 18:00	1	50	0	
05/13/2024 19:00	1	53	0	
05/13/2024 20:00	1	50	0	
05/13/2024 21:00	1	47	0	
05/13/2024 22:00	1	44	0	
05/13/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	53	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2024 00:00	1	45	0	
05/14/2024 01:00	1	45	0	
05/14/2024 02:00	1	45	0	
05/14/2024 03:00	1	45	0	
05/14/2024 04:00	1	45	0	
05/14/2024 05:00	1	45	0	
05/14/2024 06:00	1	45	0	
05/14/2024 07:00	1	45	0	
05/14/2024 08:00	1	45	0	
05/14/2024 09:00	1	45	0	
05/14/2024 10:00	1	45	0	
05/14/2024 11:00	1	44	0	
05/14/2024 12:00	1	44	0	
05/14/2024 13:00	1	45	0	
05/14/2024 14:00	1	45	0	
05/14/2024 15:00	1	44	0	
05/14/2024 16:00	1	45	0	
05/14/2024 17:00	1	48	0	
05/14/2024 18:00	1	48	0	
05/14/2024 19:00	1	46	0	
05/14/2024 20:00	1	44	0	
05/14/2024 21:00	1	44	0	
05/14/2024 22:00	1	44	0	
05/14/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	48	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2024 00:00	1	44	0	
05/15/2024 01:00	1	44	0	
05/15/2024 02:00	1	44	0	
05/15/2024 03:00	1	44	0	
05/15/2024 04:00	1	44	0	
05/15/2024 05:00	1	44	0	
05/15/2024 06:00	1	44	0	
05/15/2024 07:00	1	44	0	
05/15/2024 08:00	1	44	0	
05/15/2024 09:00	1	44	0	
05/15/2024 10:00	1	44	0	
05/15/2024 11:00	1	44	0	
05/15/2024 12:00	1	44	0	
05/15/2024 13:00	1	44	0	
05/15/2024 14:00	1	44	0	
05/15/2024 15:00	1	44	0	
05/15/2024 16:00	1	44	0	
05/15/2024 17:00	1	45	0	
05/15/2024 18:00	1	47	0	
05/15/2024 19:00	1	48	0	
05/15/2024 20:00	1	48	0	
05/15/2024 21:00	1	46	0	
05/15/2024 22:00	1	50	0	
05/15/2024 23:00	1	49	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	50	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2024 00:00	1	49	0	
05/16/2024 01:00	1	44	0	
05/16/2024 02:00	1	44	0	
05/16/2024 03:00	1	47	0	
05/16/2024 04:00	1	51	0	
05/16/2024 05:00	1	53	0	
05/16/2024 06:00	1	51	0	
05/16/2024 07:00	1	47	0	
05/16/2024 08:00	1	44	0	
05/16/2024 09:00	1	44	0	
05/16/2024 10:00	1	44	0	
05/16/2024 11:00	1	44	0	
05/16/2024 12:00	1	44	0	
05/16/2024 13:00	1	44	0	
05/16/2024 14:00	1	44	0	
05/16/2024 15:00	1	44	0	
05/16/2024 16:00	1	44	0	
05/16/2024 17:00	1	47	6	
05/16/2024 18:00	1	49	23	
05/16/2024 19:00	1	54	43	
05/16/2024 20:00	1	53	54	
05/16/2024 21:00	1	56	57	
05/16/2024 22:00	1	55	43	
05/16/2024 23:00	1	58	26	
Average/Sum#:	24 #	48	11	
Minimum:	1	44	0	
Maximum:	1	58	57	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2024 00:00	1	58	6	
05/17/2024 01:00	1	56	0	
05/17/2024 02:00	1	55	0	
05/17/2024 03:00	1	51	0	
05/17/2024 04:00	1	49	0	
05/17/2024 05:00	1	46	0	
05/17/2024 06:00	1	45	0	
05/17/2024 07:00	1	45	0	
05/17/2024 08:00	1	45	0	
05/17/2024 09:00	1	45	0	
05/17/2024 10:00	1	45	0	
05/17/2024 11:00	1	45	0	
05/17/2024 12:00	1	44	0	
05/17/2024 13:00	1	45	0	
05/17/2024 14:00	1	45	0	
05/17/2024 15:00	1	45	0	
05/17/2024 16:00	1	45	0	
05/17/2024 17:00	1	45	0	
05/17/2024 18:00	1	44	0	
05/17/2024 19:00	1	44	0	
05/17/2024 20:00	1	44	0	
05/17/2024 21:00	1	45	0	
05/17/2024 22:00	1	45	0	
05/17/2024 23:00	1	45	0	
Average/Sum#:	24 #	47	0	
Minimum:	1	44	0	
Maximum:	1	58	6	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2024 00:00	1	45	0	
05/18/2024 01:00	1	45	0	
05/18/2024 02:00	1	45	0	
05/18/2024 03:00	1	45	0	
05/18/2024 04:00	1	45	0	
05/18/2024 05:00	1	45	0	
05/18/2024 06:00	1	45	0	
05/18/2024 07:00	1	45	0	
05/18/2024 08:00	1	45	0	
05/18/2024 09:00	1	45	0	
05/18/2024 10:00	1	45	0	
05/18/2024 11:00	1	45	0	
05/18/2024 12:00	1	45	0	
05/18/2024 13:00	1	45	0	
05/18/2024 14:00	1	45	0	
05/18/2024 15:00	1	45	0	
05/18/2024 16:00	1	45	0	
05/18/2024 17:00	1	45	0	
05/18/2024 18:00	1	45	0	
05/18/2024 19:00	1	45	0	
05/18/2024 20:00	1	45	0	
05/18/2024 21:00	1	45	0	
05/18/2024 22:00	1	45	0	
05/18/2024 23:00	1	45	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	45	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2024 00:00	1	45	0	
05/19/2024 01:00	1	45	0	
05/19/2024 02:00	1	45	0	
05/19/2024 03:00	1	45	0	
05/19/2024 04:00	1	45	0	
05/19/2024 05:00	1	45	0	
05/19/2024 06:00	1	45	0	
05/19/2024 07:00	1	45	0	
05/19/2024 08:00	1	45	0	
05/19/2024 09:00	1	45	0	
05/19/2024 10:00	1	45	0	
05/19/2024 11:00	1	45	0	
05/19/2024 12:00	1	45	0	
05/19/2024 13:00	1	44	0	
05/19/2024 14:00	1	44	0	
05/19/2024 15:00	1	44	0	
05/19/2024 16:00	1	44	0	
05/19/2024 17:00	1	44	0	
05/19/2024 18:00	1	44	0	
05/19/2024 19:00	1	44	0	
05/19/2024 20:00	1	44	0	
05/19/2024 21:00	1	44	0	
05/19/2024 22:00	1	44	0	
05/19/2024 23:00	1	44	0	
Average/Sum#:	24 #	45	0	
Minimum:	1	44	0	
Maximum:	1	45	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2024 00:00	1	44	0	
05/20/2024 01:00	1	44	0	
05/20/2024 02:00	1	45	0	
05/20/2024 03:00	1	45	0	
05/20/2024 04:00	1	44	0	
05/20/2024 05:00	1	44	0	
05/20/2024 06:00	1	44	0	
05/20/2024 07:00	1	44	0	
05/20/2024 08:00	1	44	0	
05/20/2024 09:00	1	45	0	
05/20/2024 10:00	1	45	0	
05/20/2024 11:00	1	45	0	
05/20/2024 12:00	1	45	0	
05/20/2024 13:00	1	45	0	
05/20/2024 14:00	1	44	0	
05/20/2024 15:00	1	44	0	
05/20/2024 16:00	1	44	0	
05/20/2024 17:00	1	44	0	
05/20/2024 18:00	1	47	0	
05/20/2024 19:00	1	51	0	
05/20/2024 20:00	1	54	0	
05/20/2024 21:00	1	53	0	
05/20/2024 22:00	1	51	7	
05/20/2024 23:00	1	48	23	
Average/Sum#:	24 #	46	1	
Minimum:	1	44	0	
Maximum:	1	54	23	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2024 00:00	1	47	38	
05/21/2024 01:00	1	46	47	
05/21/2024 02:00	1	46	47	
05/21/2024 03:00	1	46	47	
05/21/2024 04:00	1	46	47	
05/21/2024 05:00	1	46	47	
05/21/2024 06:00	1	51	52	
05/21/2024 07:00	1	61	62	
05/21/2024 08:00	1	71	72	
05/21/2024 09:00	1	76	78	
05/21/2024 10:00	1	76	77	
05/21/2024 11:00	1	76	77	
05/21/2024 12:00	1	76	77	
05/21/2024 13:00	1	77	78	
05/21/2024 14:00	1	77	78	
05/21/2024 15:00	1	77	78	
05/21/2024 16:00	1	77	78	
05/21/2024 17:00	1	77	78	
05/21/2024 18:00	1	77	78	
05/21/2024 19:00	1	77	78	
05/21/2024 20:00	1	73	74	
05/21/2024 21:00	1	68	69	
05/21/2024 22:00	1	58	59	
05/21/2024 23:00	1	51	52	
Average/Sum#:	24 #	65	65	
Minimum:	1	46	38	
Maximum:	1	77	78	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2024 00:00	1	46	47	
05/22/2024 01:00	1	46	47	
05/22/2024 02:00	1	46	47	
05/22/2024 03:00	1	48	49	
05/22/2024 04:00	1	50	51	
05/22/2024 05:00	1	60	61	
05/22/2024 06:00	1	68	70	
05/22/2024 07:00	1	76	78	
05/22/2024 08:00	1	76	78	
05/22/2024 09:00	1	76	78	
05/22/2024 10:00	1	76	78	
05/22/2024 11:00	1	77	78	
05/22/2024 12:00	1	77	78	
05/22/2024 13:00	1	77	78	
05/22/2024 14:00	1	77	78	
05/22/2024 15:00	1	77	78	
05/22/2024 16:00	1	72	72	
05/22/2024 17:00	1	68	71	
05/22/2024 18:00	1	68	71	
05/22/2024 19:00	1	72	77	
05/22/2024 20:00	1	77	78	
05/22/2024 21:00	1	76	78	
05/22/2024 22:00	1	73	73	
05/22/2024 23:00	1	63	63	
Average/Sum#:	24 #	68	69	
Minimum:	1	46	47	
Maximum:	1	77	78	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2024 00:00	1	53	52	
05/23/2024 01:00	1	46	47	
05/23/2024 02:00	1	46	47	
05/23/2024 03:00	1	46	47	
05/23/2024 04:00	1	46	47	
05/23/2024 05:00	1	46	47	
05/23/2024 06:00	1	46	47	
05/23/2024 07:00	1	48	49	
05/23/2024 08:00	1	58	59	
05/23/2024 09:00	1	69	69	
05/23/2024 10:00	1	77	78	
05/23/2024 11:00	1	74	75	
05/23/2024 12:00	1	56	65	
05/23/2024 13:00	1	31	54	
05/23/2024 14:00	1	8	47	
05/23/2024 15:00	1	0	45	
05/23/2024 16:00	1	0	45	
05/23/2024 17:00	1	0	47	
05/23/2024 18:00	1	0	50	
05/23/2024 19:00	1	0	54	
05/23/2024 20:00	1	0	55	
05/23/2024 21:00	1	0	52	
05/23/2024 22:00	1	0	48	
05/23/2024 23:00	1	0	45	
Average/Sum#:	24 #	31	53	
Minimum:	1	0	45	
Maximum:	1	77	78	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2024 00:00	1	0	45	
05/24/2024 01:00	1	0	45	
05/24/2024 02:00	1	0	45	
05/24/2024 03:00	1	0	45	
05/24/2024 04:00	1	0	44	
05/24/2024 05:00	1	0	44	
05/24/2024 06:00	1	0	44	
05/24/2024 07:00	1	0	44	
05/24/2024 08:00	1	0	44	
05/24/2024 09:00	1	0	44	
05/24/2024 10:00	1	0	44	
05/24/2024 11:00	1	0	44	
05/24/2024 12:00	1	0	44	
05/24/2024 13:00	1	0	44	
05/24/2024 14:00	1	0	44	
05/24/2024 15:00	1	0	44	
05/24/2024 16:00	1	0	44	
05/24/2024 17:00	1	0	44	
05/24/2024 18:00	1	0	44	
05/24/2024 19:00	1	0	44	
05/24/2024 20:00	1	0	44	
05/24/2024 21:00	1	0	48	
05/24/2024 22:00	1	0	48	
05/24/2024 23:00	1	0	49	
Average/Sum#:	24 #	0	45	
Minimum:	1	0	44	
Maximum:	1	0	49	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2024 00:00	1	0	46	
05/25/2024 01:00	1	0	46	
05/25/2024 02:00	1	0	45	
05/25/2024 03:00	1	0	44	
05/25/2024 04:00	1	0	44	
05/25/2024 05:00	1	0	44	
05/25/2024 06:00	1	0	44	
05/25/2024 07:00	1	0	44	
05/25/2024 08:00	1	0	44	
05/25/2024 09:00	1	0	44	
05/25/2024 10:00	1	0	44	
05/25/2024 11:00	1	0	44	
05/25/2024 12:00	1	0	44	
05/25/2024 13:00	1	0	44	
05/25/2024 14:00	1	0	44	
05/25/2024 15:00	1	0	44	
05/25/2024 16:00	1	0	44	
05/25/2024 17:00	1	0	44	
05/25/2024 18:00	1	0	44	
05/25/2024 19:00	1	0	44	
05/25/2024 20:00	1	0	44	
05/25/2024 21:00	1	0	44	
05/25/2024 22:00	1	0	44	
05/25/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	44	
Minimum:	1	0	44	
Maximum:	1	0	46	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2024 00:00	1	0	44	
05/26/2024 01:00	1	0	44	
05/26/2024 02:00	1	0	44	
05/26/2024 03:00	1	0	44	
05/26/2024 04:00	1	0	44	
05/26/2024 05:00	1	0	44	
05/26/2024 06:00	1	0	44	
05/26/2024 07:00	1	0	44	
05/26/2024 08:00	1	0	44	
05/26/2024 09:00	1	0	44	
05/26/2024 10:00	1	0	44	
05/26/2024 11:00	1	0	44	
05/26/2024 12:00	1	0	44	
05/26/2024 13:00	1	0	44	
05/26/2024 14:00	1	0	44	
05/26/2024 15:00	1	0	44	
05/26/2024 16:00	1	0	44	
05/26/2024 17:00	1	0	44	
05/26/2024 18:00	1	0	44	
05/26/2024 19:00	1	0	44	
05/26/2024 20:00	1	0	44	
05/26/2024 21:00	1	0	44	
05/26/2024 22:00	1	0	44	
05/26/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	44	
Minimum:	1	0	44	
Maximum:	1	0	44	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2024 00:00	1	0	44	
05/27/2024 01:00	1	0	44	
05/27/2024 02:00	1	0	44	
05/27/2024 03:00	1	0	44	
05/27/2024 04:00	1	0	44	
05/27/2024 05:00	1	0	45	
05/27/2024 06:00	1	0	45	
05/27/2024 07:00	1	0	45	
05/27/2024 08:00	1	0	44	
05/27/2024 09:00	1	0	44	
05/27/2024 10:00	1	0	44	
05/27/2024 11:00	1	0	44	
05/27/2024 12:00	1	0	44	
05/27/2024 13:00	1	0	44	
05/27/2024 14:00	1	0	44	
05/27/2024 15:00	1	0	44	
05/27/2024 16:00	1	0	46	
05/27/2024 17:00	1	11	46	
05/27/2024 18:00	1	33	54	
05/27/2024 19:00	1	58	62	
05/27/2024 20:00	1	69	71	
05/27/2024 21:00	1	69	69	
05/27/2024 22:00	1	61	61	
05/27/2024 23:00	1	54	56	
Average/Sum#:	24 #	15	49	
Minimum:	1	0	44	
Maximum:	1	69	71	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2024 00:00	1	33	50	
05/28/2024 01:00	1	16	47	
05/28/2024 02:00	1	0	44	
05/28/2024 03:00	1	0	44	
05/28/2024 04:00	1	0	45	
05/28/2024 05:00	1	0	45	
05/28/2024 06:00	1	0	45	
05/28/2024 07:00	1	0	45	
05/28/2024 08:00	1	0	44	
05/28/2024 09:00	1	0	44	
05/28/2024 10:00	1	0	45	
05/28/2024 11:00	1	0	45	
05/28/2024 12:00	1	0	45	
05/28/2024 13:00	1	0	45	
05/28/2024 14:00	1	0	45	
05/28/2024 15:00	1	0	44	
05/28/2024 16:00	1	0	44	
05/28/2024 17:00	1	0	46	
05/28/2024 18:00	1	0	49	
05/28/2024 19:00	1	0	52	
05/28/2024 20:00	1	0	50	
05/28/2024 21:00	1	0	47	
05/28/2024 22:00	1	0	44	
05/28/2024 23:00	1	0	44	
Average/Sum#:	24 #	2	46	
Minimum:	1	0	44	
Maximum:	1	33	52	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2024 00:00	1	0	44	
05/29/2024 01:00	1	0	44	
05/29/2024 02:00	1	0	44	
05/29/2024 03:00	1	0	44	
05/29/2024 04:00	1	0	44	
05/29/2024 05:00	1	0	44	
05/29/2024 06:00	1	0	44	
05/29/2024 07:00	1	0	44	
05/29/2024 08:00	1	0	44	
05/29/2024 09:00	1	0	44	
05/29/2024 10:00	1	0	43	
05/29/2024 11:00	1	0	40	
05/29/2024 12:00	1	0	36	
05/29/2024 13:00	1	0	37	
05/29/2024 14:00	1	0	39	
05/29/2024 15:00	1	0	40	
05/29/2024 16:00	1	0	39	
05/29/2024 17:00	1	0	37	
05/29/2024 18:00	1	0	38	
05/29/2024 19:00	1	0	38	
05/29/2024 20:00	1	0	38	
05/29/2024 21:00	1	0	38	
05/29/2024 22:00	1	0	38	
05/29/2024 23:00	1	0	30	
Average/Sum#:	24 #	0	40	
Minimum:	1	0	30	
Maximum:	1	0	44	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/30/2024 00:00	0	0	17	
05/30/2024 01:00	0	0	5	
05/30/2024 02:00	0	0	0	
05/30/2024 03:00	0	0	0	
05/30/2024 04:00	0	0	0	
05/30/2024 05:00	1	0	0	
05/30/2024 06:00	1	0	0	
05/30/2024 07:00	1	0	0	
05/30/2024 08:00	1	0	0	
05/30/2024 09:00	1	0	0	
05/30/2024 10:00	1	0	0	
05/30/2024 11:00	1	0	12	
05/30/2024 12:00	1	0	28	
05/30/2024 13:00	1	0	47	
05/30/2024 14:00	1	0	52	
05/30/2024 15:00	1	0	50	
05/30/2024 16:00	1	0	46	
05/30/2024 17:00	1	0	45	
05/30/2024 18:00	1	0	48	
05/30/2024 19:00	1	0	50	
05/30/2024 20:00	1	0	49	
05/30/2024 21:00	1	0	46	
05/30/2024 22:00	1	0	45	
05/30/2024 23:00	1	0	44	
Average/Sum#:	19 #	0	24	
Minimum:	0	0	0	
Maximum:	1	0	52	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2024 00:00	1	0	44	
05/31/2024 01:00	1	0	44	
05/31/2024 02:00	1	0	44	
05/31/2024 03:00	1	0	44	
05/31/2024 04:00	1	0	44	
05/31/2024 05:00	1	0	45	
05/31/2024 06:00	1	0	45	
05/31/2024 07:00	1	0	45	
05/31/2024 08:00	1	0	44	
05/31/2024 09:00	1	0	44	
05/31/2024 10:00	1	0	44	
05/31/2024 11:00	1	0	44	
05/31/2024 12:00	1	0	44	
05/31/2024 13:00	1	0	44	
05/31/2024 14:00	1	0	44	
05/31/2024 15:00	1	0	44	
05/31/2024 16:00	1	0	45	
05/31/2024 17:00	1	0	46	
05/31/2024 18:00	1	0	50	
05/31/2024 19:00	1	0	53	
05/31/2024 20:00	1	0	53	
05/31/2024 21:00	1	0	50	
05/31/2024 22:00	1	0	47	
05/31/2024 23:00	1	0	46	
Average/Sum#:	24 #	0	46	
Minimum:	1	0	44	
Maximum:	1	0	53	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2024 00:00	1	0	45	
06/01/2024 01:00	1	0	45	
06/01/2024 02:00	1	0	45	
06/01/2024 03:00	1	0	45	
06/01/2024 04:00	1	0	45	
06/01/2024 05:00	1	0	45	
06/01/2024 06:00	1	0	45	
06/01/2024 07:00	1	0	45	
06/01/2024 08:00	1	0	45	
06/01/2024 09:00	1	0	45	
06/01/2024 10:00	1	0	45	
06/01/2024 11:00	1	0	45	
06/01/2024 12:00	1	0	45	
06/01/2024 13:00	1	0	45	
06/01/2024 14:00	1	0	45	
06/01/2024 15:00	1	0	45	
06/01/2024 16:00	1	0	45	
06/01/2024 17:00	1	0	45	
06/01/2024 18:00	1	0	45	
06/01/2024 19:00	1	0	45	
06/01/2024 20:00	1	0	44	
06/01/2024 21:00	1	0	44	
06/01/2024 22:00	1	0	44	
06/01/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	45	
Minimum:	1	0	44	
Maximum:	1	0	45	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2024 00:00	1	0	44	
06/02/2024 01:00	1	0	44	
06/02/2024 02:00	1	0	44	
06/02/2024 03:00	1	0	44	
06/02/2024 04:00	1	0	44	
06/02/2024 05:00	1	0	44	
06/02/2024 06:00	1	0	45	
06/02/2024 07:00	1	0	45	
06/02/2024 08:00	1	0	45	
06/02/2024 09:00	1	0	44	
06/02/2024 10:00	1	0	44	
06/02/2024 11:00	1	0	44	
06/02/2024 12:00	1	0	44	
06/02/2024 13:00	1	0	45	
06/02/2024 14:00	1	11	47	
06/02/2024 15:00	1	34	56	
06/02/2024 16:00	1	58	65	
06/02/2024 17:00	1	65	65	
06/02/2024 18:00	1	58	57	
06/02/2024 19:00	1	43	48	
06/02/2024 20:00	1	25	46	
06/02/2024 21:00	1	10	46	
06/02/2024 22:00	1	0	45	
06/02/2024 23:00	1	0	45	
Average/Sum#:	24 #	13	48	
Minimum:	1	0	44	
Maximum:	1	65	65	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2024 00:00	1	0	45	
06/03/2024 01:00	1	0	45	
06/03/2024 02:00	1	0	45	
06/03/2024 03:00	1	0	45	
06/03/2024 04:00	1	0	45	
06/03/2024 05:00	1	0	45	
06/03/2024 06:00	1	0	45	
06/03/2024 07:00	1	0	44	
06/03/2024 08:00	1	0	44	
06/03/2024 09:00	1	0	44	
06/03/2024 10:00	1	0	44	
06/03/2024 11:00	1	0	44	
06/03/2024 12:00	1	0	45	
06/03/2024 13:00	1	0	45	
06/03/2024 14:00	1	0	45	
06/03/2024 15:00	1	0	45	
06/03/2024 16:00	1	0	45	
06/03/2024 17:00	1	0	45	
06/03/2024 18:00	1	0	44	
06/03/2024 19:00	1	0	44	
06/03/2024 20:00	1	0	44	
06/03/2024 21:00	1	0	44	
06/03/2024 22:00	1	0	44	
06/03/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	45	
Minimum:	1	0	44	
Maximum:	1	0	45	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2024 00:00	1	0	44	
06/04/2024 01:00	1	0	44	
06/04/2024 02:00	1	0	44	
06/04/2024 03:00	1	0	44	
06/04/2024 04:00	1	0	44	
06/04/2024 05:00	1	0	44	
06/04/2024 06:00	1	0	44	
06/04/2024 07:00	1	0	44	
06/04/2024 08:00	1	0	44	
06/04/2024 09:00	1	0	44	
06/04/2024 10:00	1	0	44	
06/04/2024 11:00	1	0	44	
06/04/2024 12:00	1	0	44	
06/04/2024 13:00	1	0	44	
06/04/2024 14:00	1	0	44	
06/04/2024 15:00	1	0	44	
06/04/2024 16:00	1	0	46	
06/04/2024 17:00	1	0	50	
06/04/2024 18:00	1	0	52	
06/04/2024 19:00	1	0	54	
06/04/2024 20:00	1	0	51	
06/04/2024 21:00	1	0	49	
06/04/2024 22:00	1	0	46	
06/04/2024 23:00	1	0	45	
Average/Sum#:	24 #	0	46	
Minimum:	1	0	44	
Maximum:	1	0	54	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2024 00:00	1	0	47	
06/05/2024 01:00	1	0	49	
06/05/2024 02:00	1	0	49	
06/05/2024 03:00	1	0	47	
06/05/2024 04:00	1	0	45	
06/05/2024 05:00	1	0	46	
06/05/2024 06:00	1	0	46	
06/05/2024 07:00	1	0	46	
06/05/2024 08:00	1	0	44	
06/05/2024 09:00	1	0	44	
06/05/2024 10:00	1	0	44	
06/05/2024 11:00	1	0	46	
06/05/2024 12:00	1	15	47	
06/05/2024 13:00	1	36	55	
06/05/2024 14:00	1	55	57	
06/05/2024 15:00	1	62	64	
06/05/2024 16:00	1	57	58	
06/05/2024 17:00	1	57	58	
06/05/2024 18:00	1	55	56	
06/05/2024 19:00	1	58	59	
06/05/2024 20:00	1	57	59	
06/05/2024 21:00	1	50	56	
06/05/2024 22:00	1	31	51	
06/05/2024 23:00	1	13	49	
Average/Sum#:	24 #	23	51	
Minimum:	1	0	44	
Maximum:	1	62	64	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2024 00:00	1	0	47	
06/06/2024 01:00	1	0	46	
06/06/2024 02:00	1	0	45	
06/06/2024 03:00	1	0	45	
06/06/2024 04:00	1	0	45	
06/06/2024 05:00	1	0	45	
06/06/2024 06:00	1	0	44	
06/06/2024 07:00	1	0	44	
06/06/2024 08:00	1	0	44	
06/06/2024 09:00	1	0	45	
06/06/2024 10:00	1	0	45	
06/06/2024 11:00	1	0	45	
06/06/2024 12:00	1	0	45	
06/06/2024 13:00	1	0	47	
06/06/2024 14:00	1	0	48	
06/06/2024 15:00	1	0	48	
06/06/2024 16:00	1	0	49	
06/06/2024 17:00	1	0	50	
06/06/2024 18:00	1	0	53	
06/06/2024 19:00	1	0	55	
06/06/2024 20:00	1	0	53	
06/06/2024 21:00	1	0	49	
06/06/2024 22:00	1	0	45	
06/06/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	47	
Minimum:	1	0	44	
Maximum:	1	0	55	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2024 00:00	1	0	44	
06/07/2024 01:00	1	0	44	
06/07/2024 02:00	1	0	44	
06/07/2024 03:00	1	0	44	
06/07/2024 04:00	1	0	44	
06/07/2024 05:00	1	0	45	
06/07/2024 06:00	1	0	45	
06/07/2024 07:00	1	0	45	
06/07/2024 08:00	1	0	44	
06/07/2024 09:00	1	0	44	
06/07/2024 10:00	1	0	44	
06/07/2024 11:00	1	0	44	
06/07/2024 12:00	1	0	44	
06/07/2024 13:00	1	0	44	
06/07/2024 14:00	1	0	44	
06/07/2024 15:00	1	0	45	
06/07/2024 16:00	1	0	45	
06/07/2024 17:00	1	0	45	
06/07/2024 18:00	1	0	48	
06/07/2024 19:00	1	0	51	
06/07/2024 20:00	1	0	52	
06/07/2024 21:00	1	0	49	
06/07/2024 22:00	1	0	46	
06/07/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	45	
Minimum:	1	0	44	
Maximum:	1	0	52	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2024 00:00	1	0	44	
06/08/2024 01:00	1	0	44	
06/08/2024 02:00	1	0	44	
06/08/2024 03:00	1	0	44	
06/08/2024 04:00	1	0	44	
06/08/2024 05:00	1	0	44	
06/08/2024 06:00	1	0	44	
06/08/2024 07:00	1	0	44	
06/08/2024 08:00	1	0	44	
06/08/2024 09:00	1	0	44	
06/08/2024 10:00	1	0	44	
06/08/2024 11:00	1	0	44	
06/08/2024 12:00	1	0	44	
06/08/2024 13:00	1	0	44	
06/08/2024 14:00	1	0	44	
06/08/2024 15:00	1	0	44	
06/08/2024 16:00	1	0	44	
06/08/2024 17:00	1	0	44	
06/08/2024 18:00	1	0	44	
06/08/2024 19:00	1	0	44	
06/08/2024 20:00	1	0	44	
06/08/2024 21:00	1	0	44	
06/08/2024 22:00	1	0	44	
06/08/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	44	
Minimum:	1	0	44	
Maximum:	1	0	44	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2024 00:00	1	0	44	
06/09/2024 01:00	1	0	44	
06/09/2024 02:00	1	0	44	
06/09/2024 03:00	1	0	44	
06/09/2024 04:00	1	0	44	
06/09/2024 05:00	1	0	44	
06/09/2024 06:00	1	0	44	
06/09/2024 07:00	1	0	44	
06/09/2024 08:00	1	0	44	
06/09/2024 09:00	1	0	44	
06/09/2024 10:00	1	0	44	
06/09/2024 11:00	1	0	44	
06/09/2024 12:00	1	0	44	
06/09/2024 13:00	1	0	44	
06/09/2024 14:00	1	0	44	
06/09/2024 15:00	1	0	44	
06/09/2024 16:00	1	0	44	
06/09/2024 17:00	1	0	44	
06/09/2024 18:00	1	0	44	
06/09/2024 19:00	1	0	44	
06/09/2024 20:00	1	0	44	
06/09/2024 21:00	1	0	44	
06/09/2024 22:00	1	0	44	
06/09/2024 23:00	1	0	44	
Average/Sum#:	24 #	0	44	
Minimum:	1	0	44	
Maximum:	1	0	44	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2024 00:00	1	0	44	
06/10/2024 01:00	1	0	44	
06/10/2024 02:00	1	0	44	
06/10/2024 03:00	1	0	44	
06/10/2024 04:00	1	0	44	
06/10/2024 05:00	1	0	44	
06/10/2024 06:00	1	0	44	
06/10/2024 07:00	1	0	44	
06/10/2024 08:00	1	0	44	
06/10/2024 09:00	1	0	44	
06/10/2024 10:00	1	0	44	
06/10/2024 11:00	1	0	44	
06/10/2024 12:00	1	0	44	
06/10/2024 13:00	1	0	44	
06/10/2024 14:00	1	0	44	
06/10/2024 15:00	1	0	44	
06/10/2024 16:00	1	0	44	
06/10/2024 17:00	1	0	49	
06/10/2024 18:00	1	0	57	
06/10/2024 19:00	1	0	64	
06/10/2024 20:00	1	0	66	
06/10/2024 21:00	1	0	66	
06/10/2024 22:00	1	0	66	
06/10/2024 23:00	1	0	66	
Average/Sum#:	24 #	0	49	
Minimum:	1	0	44	
Maximum:	1	0	66	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2024 00:00	1	0	66	
06/11/2024 01:00	1	0	66	
06/11/2024 02:00	1	0	66	
06/11/2024 03:00	1	0	66	
06/11/2024 04:00	1	0	66	
06/11/2024 05:00	1	0	65	
06/11/2024 06:00	1	0	58	
06/11/2024 07:00	1	0	51	
06/11/2024 08:00	1	0	45	
06/11/2024 09:00	1	0	45	
06/11/2024 10:00	1	0	45	
06/11/2024 11:00	1	0	45	
06/11/2024 12:00	1	0	45	
06/11/2024 13:00	1	0	44	
06/11/2024 14:00	1	0	44	
06/11/2024 15:00	1	0	44	
06/11/2024 16:00	1	0	49	
06/11/2024 17:00	1	0	56	
06/11/2024 18:00	1	0	66	
06/11/2024 19:00	1	0	69	
06/11/2024 20:00	1	0	69	
06/11/2024 21:00	1	0	67	
06/11/2024 22:00	1	0	66	
06/11/2024 23:00	1	0	66	
Average/Sum#:	24 #	0	57	
Minimum:	1	0	44	
Maximum:	1	0	69	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2024 00:00	1	0	66	
06/12/2024 01:00	1	0	66	
06/12/2024 02:00	1	0	66	
06/12/2024 03:00	1	0	66	
06/12/2024 04:00	1	0	66	
06/12/2024 05:00	1	0	66	
06/12/2024 06:00	1	0	62	
06/12/2024 07:00	1	0	54	
06/12/2024 08:00	1	0	47	
06/12/2024 09:00	1	0	44	
06/12/2024 10:00	1	0	45	
06/12/2024 11:00	1	0	45	
06/12/2024 12:00	1	0	45	
06/12/2024 13:00	1	0	45	
06/12/2024 14:00	1	0	45	
06/12/2024 15:00	1	0	45	
06/12/2024 16:00	1	0	49	
06/12/2024 17:00	1	0	57	
06/12/2024 18:00	1	0	64	
06/12/2024 19:00	1	0	67	
06/12/2024 20:00	1	0	67	
06/12/2024 21:00	1	0	66	
06/12/2024 22:00	1	0	66	
06/12/2024 23:00	1	0	66	
Average/Sum#:	24 #	0	57	
Minimum:	1	0	44	
Maximum:	1	0	67	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2024 00:00	1	0	66	66
06/13/2024 01:00	1	0	66	66
06/13/2024 02:00	1	0	66	66
06/13/2024 03:00	1	0	66	66
06/13/2024 04:00	1	0	66	66
06/13/2024 05:00	1	0	66	66
06/13/2024 06:00	1	0	61	61
06/13/2024 07:00	1	0	54	54
06/13/2024 08:00	1	0	47	47
06/13/2024 09:00	1	0	44	44
06/13/2024 10:00	1	0	44	44
06/13/2024 11:00	1	0	44	44
06/13/2024 12:00	1	0	44	44
06/13/2024 13:00	1	0	44	44
06/13/2024 14:00	1	0	46	46
06/13/2024 15:00	1	5	46	46
06/13/2024 16:00	1	19	46	46
06/13/2024 17:00	1	35	45	45
06/13/2024 18:00	1	50	51	51
06/13/2024 19:00	1	57	58	58
06/13/2024 20:00	1	61	62	62
06/13/2024 21:00	1	52	58	58
06/13/2024 22:00	1	31	50	50
06/13/2024 23:00	1	11	45	45
Average/Sum#:	24 #	13	54	54
Minimum:	1	0	44	44
Maximum:	1	61	66	66
%SI	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2024 00:00	1	0	44	
06/14/2024 01:00	1	0	44	
06/14/2024 02:00	1	0	44	
06/14/2024 03:00	1	0	44	
06/14/2024 04:00	1	0	44	
06/14/2024 05:00	1	0	44	
06/14/2024 06:00	1	0	44	
06/14/2024 07:00	1	0	44	
06/14/2024 08:00	1	0	44	
06/14/2024 09:00	1	0	44	
06/14/2024 10:00	1	0	44	
06/14/2024 11:00	1	0	44	
06/14/2024 12:00	1	0	44	
06/14/2024 13:00	1	0	44	
06/14/2024 14:00	1	0	44	
06/14/2024 15:00	1	0	44	
06/14/2024 16:00	1	4	37	
06/14/2024 17:00	1	19	22	
06/14/2024 18:00	1	33	7	
06/14/2024 19:00	1	47	0	
06/14/2024 20:00	1	53	0	
06/14/2024 21:00	1	54	13	
06/14/2024 22:00	1	51	29	
06/14/2024 23:00	1	46	44	
Average/Sum#:	24 #	13	36	
Minimum:	1	0	0	
Maximum:	1	54	44	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2024 00:00	1	46	47	
06/15/2024 01:00	1	46	47	
06/15/2024 02:00	1	42	47	
06/15/2024 03:00	1	27	46	
06/15/2024 04:00	1	12	45	
06/15/2024 05:00	1	0	44	
06/15/2024 06:00	1	0	44	
06/15/2024 07:00	1	0	44	
06/15/2024 08:00	1	0	44	
06/15/2024 09:00	1	0	44	
06/15/2024 10:00	1	0	45	
06/15/2024 11:00	1	0	45	
06/15/2024 12:00	1	0	45	
06/15/2024 13:00	1	0	45	
06/15/2024 14:00	1	0	45	
06/15/2024 15:00	1	0	45	
06/15/2024 16:00	1	0	45	
06/15/2024 17:00	1	0	44	
06/15/2024 18:00	1	0	47	
06/15/2024 19:00	1	0	49	
06/15/2024 20:00	1	0	50	
06/15/2024 21:00	1	0	47	
06/15/2024 22:00	1	0	45	
06/15/2024 23:00	1	0	45	
Average/Sum#:	24 #	7	46	
Minimum:	1	0	44	
Maximum:	1	46	50	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2024 00:00	1	0	49	
06/16/2024 01:00	1	0	49	
06/16/2024 02:00	1	0	48	
06/16/2024 03:00	1	0	44	
06/16/2024 04:00	1	0	44	
06/16/2024 05:00	1	0	44	
06/16/2024 06:00	1	0	44	
06/16/2024 07:00	1	0	44	
06/16/2024 08:00	1	0	44	
06/16/2024 09:00	1	0	44	
06/16/2024 10:00	1	0	44	
06/16/2024 11:00	1	0	44	
06/16/2024 12:00	1	0	44	
06/16/2024 13:00	1	0	44	
06/16/2024 14:00	1	0	44	
06/16/2024 15:00	1	0	44	
06/16/2024 16:00	1	0	44	
06/16/2024 17:00	1	0	46	
06/16/2024 18:00	1	0	50	
06/16/2024 19:00	1	0	53	
06/16/2024 20:00	1	0	52	
06/16/2024 21:00	1	0	48	
06/16/2024 22:00	1	0	45	
06/16/2024 23:00	1	0	44	
<hr/>				
Average/Sum#:	24 #	0	46	
Minimum:	1	0	44	
Maximum:	1	0	53	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2024 00:00	1	0	44	
06/17/2024 01:00	1	0	48	
06/17/2024 02:00	1	0	50	
06/17/2024 03:00	1	0	52	
06/17/2024 04:00	1	0	50	
06/17/2024 05:00	1	0	51	
06/17/2024 06:00	1	0	49	
06/17/2024 07:00	1	0	46	
06/17/2024 08:00	1	0	44	
06/17/2024 09:00	1	0	44	
06/17/2024 10:00	1	0	44	
06/17/2024 11:00	1	0	44	
06/17/2024 12:00	1	0	44	
06/17/2024 13:00	1	0	44	
06/17/2024 14:00	1	0	44	
06/17/2024 15:00	1	0	44	
06/17/2024 16:00	1	0	44	
06/17/2024 17:00	1	0	46	
06/17/2024 18:00	1	0	51	
06/17/2024 19:00	1	0	55	
06/17/2024 20:00	1	0	58	
06/17/2024 21:00	1	0	58	
06/17/2024 22:00	1	0	55	
06/17/2024 23:00	1	0	53	
Average/Sum#:	24 #	0	48	
Minimum:	1	0	44	
Maximum:	1	0	58	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2024 00:00	1	0	50	
06/18/2024 01:00	1	0	50	
06/18/2024 02:00	1	0	50	
06/18/2024 03:00	1	0	50	
06/18/2024 04:00	1	0	50	
06/18/2024 05:00	1	0	52	
06/18/2024 06:00	1	0	50	
06/18/2024 07:00	1	0	48	
06/18/2024 08:00	1	0	47	
06/18/2024 09:00	1	0	49	
06/18/2024 10:00	1	0	50	
06/18/2024 11:00	1	0	50	
06/18/2024 12:00	1	0	50	
06/18/2024 13:00	1	0	50	
06/18/2024 14:00	1	0	50	
06/18/2024 15:00	1	0	50	
06/18/2024 16:00	1	0	50	
06/18/2024 17:00	1	0	50	
06/18/2024 18:00	1	0	52	
06/18/2024 19:00	1	0	53	
06/18/2024 20:00	1	0	52	
06/18/2024 21:00	1	0	50	
06/18/2024 22:00	1	0	50	
06/18/2024 23:00	1	0	50	
Average/Sum#:	24 #	0	50	
Minimum:	1	0	47	
Maximum:	1	0	53	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2024 00:00	1	0	50	
06/19/2024 01:00	1	0	50	
06/19/2024 02:00	1	0	50	
06/19/2024 03:00	1	0	50	
06/19/2024 04:00	1	0	50	
06/19/2024 05:00	1	0	50	
06/19/2024 06:00	1	0	50	
06/19/2024 07:00	1	0	50	
06/19/2024 08:00	1	11	49	
06/19/2024 09:00	1	28	46	
06/19/2024 10:00	1	48	29	
06/19/2024 11:00	1	52	13	
06/19/2024 12:00	1	50	0	
06/19/2024 13:00	1	45	0	
06/19/2024 14:00	1	45	0	
06/19/2024 15:00	1	45	0	
06/19/2024 16:00	1	45	0	
06/19/2024 17:00	1	48	0	
06/19/2024 18:00	1	55	0	
06/19/2024 19:00	1	62	0	
06/19/2024 20:00	1	66	0	
06/19/2024 21:00	1	66	0	
06/19/2024 22:00	1	66	0	
06/19/2024 23:00	1	66	0	
Average/Sum#:	24 #	33	22	
Minimum:	1	0	0	
Maximum:	1	66	50	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2024 00:00	1	66	0	
06/20/2024 01:00	1	66	0	
06/20/2024 02:00	1	66	0	
06/20/2024 03:00	1	66	0	
06/20/2024 04:00	1	66	0	
06/20/2024 05:00	1	66	0	
06/20/2024 06:00	1	62	0	
06/20/2024 07:00	1	55	0	
06/20/2024 08:00	1	48	0	
06/20/2024 09:00	1	45	0	
06/20/2024 10:00	1	45	0	
06/20/2024 11:00	1	45	0	
06/20/2024 12:00	1	45	0	
06/20/2024 13:00	1	44	0	
06/20/2024 14:00	1	44	0	
06/20/2024 15:00	1	44	0	
06/20/2024 16:00	1	44	0	
06/20/2024 17:00	1	49	0	
06/20/2024 18:00	1	56	0	
06/20/2024 19:00	1	64	0	
06/20/2024 20:00	1	66	0	
06/20/2024 21:00	1	66	0	
06/20/2024 22:00	1	66	0	
06/20/2024 23:00	1	66	0	
Average/Sum#:	24 #	56	0	
Minimum:	1	44	0	
Maximum:	1	66	0	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2024 00:00	1	65	0	
06/21/2024 01:00	1	65	0	
06/21/2024 02:00	1	66	0	
06/21/2024 03:00	1	66	0	
06/21/2024 04:00	1	66	0	
06/21/2024 05:00	1	66	0	
06/21/2024 06:00	1	64	0	
06/21/2024 07:00	1	57	0	
06/21/2024 08:00	1	50	0	
06/21/2024 09:00	1	45	0	
06/21/2024 10:00	1	46	9	
06/21/2024 11:00	1	46	24	
06/21/2024 12:00	1	46	40	
06/21/2024 13:00	1	46	47	
06/21/2024 14:00	1	46	47	
06/21/2024 15:00	1	46	47	
06/21/2024 16:00	1	46	47	
06/21/2024 17:00	1	48	49	
06/21/2024 18:00	1	53	54	
06/21/2024 19:00	1	57	58	
06/21/2024 20:00	1	59	60	
06/21/2024 21:00	1	59	60	
06/21/2024 22:00	1	59	61	
06/21/2024 23:00	1	59	60	
<hr/>				
Average/Sum#:	24 #	55	28	
Minimum:	1	45	0	
Maximum:	1	66	61	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2024 00:00	1	55	52	
06/22/2024 01:00	1	50	31	
06/22/2024 02:00	1	45	12	
06/22/2024 03:00	1	44	0	
06/22/2024 04:00	1	44	0	
06/22/2024 05:00	1	44	0	
06/22/2024 06:00	1	44	0	
06/22/2024 07:00	1	44	0	
06/22/2024 08:00	1	44	0	
06/22/2024 09:00	1	44	0	
06/22/2024 10:00	1	44	0	
06/22/2024 11:00	1	44	0	
06/22/2024 12:00	1	44	0	
06/22/2024 13:00	1	44	0	
06/22/2024 14:00	1	44	0	
06/22/2024 15:00	1	44	0	
06/22/2024 16:00	1	46	0	
06/22/2024 17:00	1	48	0	
06/22/2024 18:00	1	51	0	
06/22/2024 19:00	1	53	0	
06/22/2024 20:00	1	54	0	
06/22/2024 21:00	1	52	0	
06/22/2024 22:00	1	48	0	
06/22/2024 23:00	1	45	0	
Average/Sum#:	24 #	47	4	
Minimum:	1	44	0	
Maximum:	1	55	52	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitID, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2024 00:00	1	45	0	
06/23/2024 01:00	1	45	0	
06/23/2024 02:00	1	45	0	
06/23/2024 03:00	1	45	0	
06/23/2024 04:00	1	45	0	
06/23/2024 05:00	1	45	0	
06/23/2024 06:00	1	45	0	
06/23/2024 07:00	1	45	0	
06/23/2024 08:00	1	45	0	
06/23/2024 09:00	1	45	0	
06/23/2024 10:00	1	45	0	
06/23/2024 11:00	1	45	0	
06/23/2024 12:00	1	45	0	
06/23/2024 13:00	1	46	0	
06/23/2024 14:00	1	49	0	
06/23/2024 15:00	1	53	0	
06/23/2024 16:00	1	55	0	
06/23/2024 17:00	1	56	0	
06/23/2024 18:00	1	54	15	
06/23/2024 19:00	1	55	35	
06/23/2024 20:00	1	56	55	
06/23/2024 21:00	1	59	60	
06/23/2024 22:00	1	58	59	
06/23/2024 23:00	1	55	56	
Average/Sum#:	24 #	49	12	
Minimum:	1	45	0	
Maximum:	1	59	60	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2024 00:00	1	50	51	
06/24/2024 01:00	1	47	48	
06/24/2024 02:00	1	46	47	
06/24/2024 03:00	1	46	47	
06/24/2024 04:00	1	49	50	
06/24/2024 05:00	1	51	53	
06/24/2024 06:00	1	47	54	
06/24/2024 07:00	1	30	50	
06/24/2024 08:00	1	11	47	
06/24/2024 09:00	1	0	45	
06/24/2024 10:00	1	0	47	
06/24/2024 11:00	1	0	51	
06/24/2024 12:00	1	0	54	
06/24/2024 13:00	1	0	56	
06/24/2024 14:00	1	0	57	
06/24/2024 15:00	1	0	57	
06/24/2024 16:00	1	0	57	
06/24/2024 17:00	1	0	56	
06/24/2024 18:00	1	0	57	
06/24/2024 19:00	1	7	54	
06/24/2024 20:00	1	25	54	
06/24/2024 21:00	1	45	55	
06/24/2024 22:00	1	58	59	
06/24/2024 23:00	1	60	61	
Average/Sum#:	24 #	24	53	
Minimum:	1	0	45	
Maximum:	1	60	61	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2024 00:00	1	60	61	
06/25/2024 01:00	1	60	61	
06/25/2024 02:00	1	60	61	
06/25/2024 03:00	1	60	61	
06/25/2024 04:00	1	59	60	
06/25/2024 05:00	1	59	60	
06/25/2024 06:00	1	56	57	
06/25/2024 07:00	1	52	53	
06/25/2024 08:00	1	51	52	
06/25/2024 09:00	1	54	55	
06/25/2024 10:00	1	58	60	
06/25/2024 11:00	1	60	62	
06/25/2024 12:00	1	60	62	
06/25/2024 13:00	1	60	61	
06/25/2024 14:00	1	60	61	
06/25/2024 15:00	1	58	59	
06/25/2024 16:00	1	58	59	
06/25/2024 17:00	1	58	59	
06/25/2024 18:00	1	65	67	
06/25/2024 19:00	1	72	73	
06/25/2024 20:00	1	77	79	
06/25/2024 21:00	1	76	78	
06/25/2024 22:00	1	72	74	
06/25/2024 23:00	1	64	66	
Average/Sum#:	24 #	61	63	
Minimum:	1	51	52	
Maximum:	1	77	79	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2024 00:00	1	56	57	
06/26/2024 01:00	1	51	52	
06/26/2024 02:00	1	51	52	
06/26/2024 03:00	1	53	55	
06/26/2024 04:00	1	56	57	
06/26/2024 05:00	1	56	57	
06/26/2024 06:00	1	53	54	
06/26/2024 07:00	1	48	49	
06/26/2024 08:00	1	46	47	
06/26/2024 09:00	1	46	47	
06/26/2024 10:00	1	45	47	
06/26/2024 11:00	1	45	47	
06/26/2024 12:00	1	45	46	
06/26/2024 13:00	1	45	46	
06/26/2024 14:00	1	45	46	
06/26/2024 15:00	1	46	47	
06/26/2024 16:00	1	46	47	
06/26/2024 17:00	1	46	47	
06/26/2024 18:00	1	48	49	
06/26/2024 19:00	1	48	50	
06/26/2024 20:00	1	48	49	
06/26/2024 21:00	1	46	47	
06/26/2024 22:00	1	45	47	
06/26/2024 23:00	1	45	47	
Average/Sum#:	24 #	48	50	
Minimum:	1	45	46	
Maximum:	1	56	57	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2024 00:00	1	46	47	
06/27/2024 01:00	1	46	47	
06/27/2024 02:00	1	46	47	
06/27/2024 03:00	1	46	47	
06/27/2024 04:00	1	46	47	
06/27/2024 05:00	1	46	47	
06/27/2024 06:00	1	46	47	
06/27/2024 07:00	1	46	47	
06/27/2024 08:00	1	46	47	
06/27/2024 09:00	1	46	47	
06/27/2024 10:00	1	46	47	
06/27/2024 11:00	1	46	47	
06/27/2024 12:00	1	46	47	
06/27/2024 13:00	1	46	47	
06/27/2024 14:00	1	46	47	
06/27/2024 15:00	1	46	47	
06/27/2024 16:00	1	46	47	
06/27/2024 17:00	1	46	47	
06/27/2024 18:00	1	48	49	
06/27/2024 19:00	1	48	49	
06/27/2024 20:00	1	48	49	
06/27/2024 21:00	1	46	47	
06/27/2024 22:00	1	45	47	
06/27/2024 23:00	1	45	47	
Average/Sum#:	24 #	46	47	
Minimum:	1	45	47	
Maximum:	1	48	49	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/07/2024 02:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2024 00:00	1	45	47	
06/28/2024 01:00	1	45	47	
06/28/2024 02:00	1	45	47	
06/28/2024 03:00	1	45	47	
06/28/2024 04:00	1	45	47	
06/28/2024 05:00	1	46	47	
06/28/2024 06:00	1	46	47	
06/28/2024 07:00	1	46	47	
06/28/2024 08:00	1	46	47	
06/28/2024 09:00	1	46	47	
06/28/2024 10:00	1	46	47	
06/28/2024 11:00	1	46	47	
06/28/2024 12:00	1	46	47	
06/28/2024 13:00	1	46	47	
06/28/2024 14:00	1	46	47	
06/28/2024 15:00	1	46	47	
06/28/2024 16:00	1	46	47	
06/28/2024 17:00	1	46	47	
06/28/2024 18:00	1	46	47	
06/28/2024 19:00	1	46	47	
06/28/2024 20:00	1	46	47	
06/28/2024 21:00	1	46	47	
06/28/2024 22:00	1	46	47	
06/28/2024 23:00	1	46	47	
Average/Sum#:	24 #	46	47	
Minimum:	1	45	47	
Maximum:	1	46	47	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2024 00:00	1	46	47	
06/29/2024 01:00	1	46	47	
06/29/2024 02:00	1	46	47	
06/29/2024 03:00	1	46	47	
06/29/2024 04:00	1	46	47	
06/29/2024 05:00	1	46	47	
06/29/2024 06:00	1	45	47	
06/29/2024 07:00	1	45	47	
06/29/2024 08:00	1	45	47	
06/29/2024 09:00	1	45	47	
06/29/2024 10:00	1	45	47	
06/29/2024 11:00	1	45	47	
06/29/2024 12:00	1	46	47	
06/29/2024 13:00	1	46	47	
06/29/2024 14:00	1	46	46	
06/29/2024 15:00	1	45	46	
06/29/2024 16:00	1	46	47	
06/29/2024 17:00	1	46	47	
06/29/2024 18:00	1	47	48	
06/29/2024 19:00	1	47	48	
06/29/2024 20:00	1	47	48	
06/29/2024 21:00	1	46	47	
06/29/2024 22:00	1	46	47	
06/29/2024 23:00	1	46	47	
Average/Sum#:	24 #	46	47	
Minimum:	1	45	46	
Maximum:	1	47	48	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/07/2024 02:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe		Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2024 00:00	1	46	47	
06/30/2024 01:00	1	46	47	
06/30/2024 02:00	1	46	47	
06/30/2024 03:00	1	45	47	
06/30/2024 04:00	1	45	47	
06/30/2024 05:00	1	46	47	
06/30/2024 06:00	1	46	47	
06/30/2024 07:00	1	46	47	
06/30/2024 08:00	1	46	47	
06/30/2024 09:00	1	46	47	
06/30/2024 10:00	1	46	47	
06/30/2024 11:00	1	46	47	
06/30/2024 12:00	1	46	47	
06/30/2024 13:00	1	46	47	
06/30/2024 14:00	1	46	47	
06/30/2024 15:00	1	46	47	
06/30/2024 16:00	1	46	47	
06/30/2024 17:00	1	46	47	
06/30/2024 18:00	1	46	47	
06/30/2024 19:00	1	46	47	
06/30/2024 20:00	1	46	47	
06/30/2024 21:00	1	46	47	
06/30/2024 22:00	1	46	47	
06/30/2024 23:00	1	46	47	
Average/Sum#:	24 #	46	47	
Minimum:	1	45	47	
Maximum:	1	46	47	
%SI	0.00	0.00	0.00	

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
06/28/2024 17:00	cro-operator	LH	UNIT 1 O2 BOTTLE CHANGE 18.08% ID# 225104093 EXP 2/4/32		
06/25/2024 09:00	cro-operator	BRB	REPLACED XC0004590B 22.5 O2 & 18.10 CO WITH CC93726 22.5 O2 & 18.06 CO IN THE DAHS AND IN THE FIELD FOR RPEAK 5		
06/24/2024 13:28	cro-operator	BRB	SPANNED GASSES, RAN HANDS OFF DAILY, AND PERFORMED CGAS ON BOTH RPEAK 5 & 6.	CGAS 2ND QUARTER 2024	
06/18/2024 23:11	cro-operator	krb	cylinder change out rep CT 2 low nox 9.025 co 9.014 cylinder # 2257001152		
06/13/2024 12:36	cro-operator	JB	CHANGED CT2 HIGH NOX/CO BOTTLE 180.1 PPM NOX, 178.1 PPM CO CYLINDER # EB0102637. EXP. 02/13/2032		
06/12/2024 15:16	cro-operator	RG	PERFORMED LINEARITY AND CGA TESTING CT2		
06/07/2024 15:15	cro-operator	DE	REPLACE UNIT 2 INLET NOX DAILY CEMS CALIBRATION BOTTLE CYLINDER NUMBER 225701155. CONCENTRATION 21.03 PPM.		
06/06/2024 14:21	cro-operator	KRB	6-6-24 REPLACE O2 CYCL# 214503056 -18.01		
06/04/2024 13:45	cro-operator	DE	UPDATED FUEL FACTOR GCV CONSTANTS FOR CT1, CT2, CT5, CT6 AND GCV_GAS FOR THE MONTH OF JUNE TO 104800.		
05/24/2024 16:16	cro-operator	RG	MANUALLY CALIBRATED INLET NOX ANALYZER ON CT2. FOR 1X ALERT. LOW RANGE AND HIGH RANGE.		
05/18/2024 22:14	cro-operator	RC	HIGH NOX BOTTLE CHANGE UNIT-1 CEMS P12023 225104096 181.1PPM		
05/18/2024 11:20	cro-operator	RG	CT5 BENCH TEMP FAULT. REPLACED THERMOCOUPLE IN BENCH. PERFORMED HANDS OFF CALIBRATION.		
05/18/2024 11:19	cro-operator	RG	CT1 CO ANALYZER FAULT. REPLACED IR SOURCE ASSEMBLY. PERFORMED HANDS OFF CALIBRATION.		
05/07/2024 10:00	cro-operator	RG	PERFORMED MONTHLY MAINTENANCE ON CT1 CEMS.		
05/06/2024 15:04	cro-operator	LHR	CHANGED ALL 5 GCV VALUES FOR APRIL TO 105200, AND CHANGED ALL 5 GCV VALUES FOR MAY TO 104400.		
05/03/2024 17:42	cro-operator	LH	CHANGED UNIT 1 O2 BOTTLE 18.0% CYLINDER# CC52527 EXP 2/13/32		
05/02/2024 17:03	cro-operator	LHR	CHANGED CT2 INLET NOX LOW 21.20PPM, CYL# 225702028, EXP 10/31/24		
04/25/2024 15:23	cro-operator	BRB	Performed Span gasses on CT1 due to the 1X alert on Stack.		

Cylinder Gas Audit

07/04/2024

Page 1

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / High

Test Date: 06/12/2024
 Test: **Pass**

Instrument: CT2_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/12/2024	11:57	L	200	49.900	49.800	25.0
06/12/2024	12:02	M	200	109.100	113.700	54.6
06/12/2024	12:14	L	200	49.900	50.500	25.0
06/12/2024	12:19	M	200	109.100	112.100	54.6
06/12/2024	12:31	L	200	49.900	50.900	25.0
06/12/2024	12:36	M	200	109.100	112.700	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	50.400	Std	1.0
M	109.100	112.833	Std	3.4

Cylinder Gas Audit

07/04/2024

Page 2

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / Low

Test Date: 06/12/2024
 Test: **Pass**

Instrument: CT2_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/12/2024	14:08	L	10	2.600	2.200	26.0
06/12/2024	14:13	M	10	5.600	5.600	56.0
06/12/2024	14:20	L	10	2.600	2.300	26.0
06/12/2024	14:25	M	10	5.600	5.700	56.0
06/12/2024	14:32	L	10	2.600	2.200	26.0
06/12/2024	14:37	M	10	5.600	5.800	56.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.233	Std	14.1
M	5.600		5.700	Std	1.8

Cylinder Gas Audit

07/04/2024

Page 3

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT1
 Parameter/Scale: CO / High

Test Date: 04/16/2024
 Test: **Pass**

Instrument: CT1_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
04/16/2024	08:41	L	200	49.800	47.300	24.9
04/16/2024	08:46	M	200	109.200	109.200	54.6
04/16/2024	08:57	L	200	49.800	47.300	24.9
04/16/2024	09:02	M	200	109.200	109.200	54.6
04/16/2024	09:13	L	200	49.800	47.300	24.9
04/16/2024	09:18	M	200	109.200	108.800	54.6

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	47.300	Std	5.0
M	109.200	109.067	Std	0.1

Cylinder Gas Audit

07/04/2024

Page 4

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT1
 Parameter/Scale: CO / Low

Test Date: 04/16/2024
 Test: **Pass**

Instrument: CT1_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
04/16/2024	10:40	L	10	2.400	2.300	24.0
04/16/2024	10:45	M	10	5.700	5.800	57.0
04/16/2024	10:52	L	10	2.400	2.300	24.0
04/16/2024	10:57	M	10	5.700	5.800	57.0
04/16/2024	11:04	L	10	2.400	2.300	24.0
04/16/2024	11:09	M	10	5.700	5.800	57.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.300	Std	4.2
M	5.700		5.800	Std	1.8

Cylinder Gas Audit

07/04/2024

Page 5

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT5
 Parameter/Scale: CO / Low

Test Date: 06/24/2024
 Test: **Pass**

Instrument: CT5_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/24/2024	07:50	L	20	5.100	5.000	25.5
06/24/2024	07:55	M	20	11.100	11.100	55.5
06/24/2024	08:07	L	20	5.100	5.000	25.5
06/24/2024	08:12	M	20	11.100	11.100	55.5
06/24/2024	08:24	L	20	5.100	5.000	25.5
06/24/2024	08:29	M	20	11.100	11.100	55.5

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.100		5.000	Std	2.0
M	11.100		11.100	Std	0.0

Cylinder Gas Audit

07/04/2024

Page 6

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT5
 Parameter/Scale: CO / High

Test Date: 06/24/2024
 Test: **Pass**

Instrument: CT5_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/24/2024	10:17	L	1000	245.400	258.600	24.5
06/24/2024	10:22	M	1000	559.500	559.600	56.0
06/24/2024	10:29	L	1000	245.400	258.300	24.5
06/24/2024	10:34	M	1000	559.500	559.700	56.0
06/24/2024	10:41	L	1000	245.400	258.700	24.5
06/24/2024	10:46	M	1000	559.500	561.700	56.0

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	245.400	258.533	Std	5.4
M	559.500	560.333	Std	0.1

Cylinder Gas Audit

07/04/2024

Page 7

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT6
 Parameter/Scale: CO / Low

Test Date: 06/24/2024
 Test: **Pass**

Instrument: CT6_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/24/2024	12:10	L	20	5.000	5.000	25.0
06/24/2024	12:15	M	20	11.200	11.200	56.0
06/24/2024	12:27	L	20	5.000	5.000	25.0
06/24/2024	12:32	M	20	11.200	11.200	56.0
06/24/2024	12:44	L	20	5.000	5.000	25.0
06/24/2024	12:49	M	20	11.200	11.100	56.0

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.000		5.000	Std	0.0
M	11.200		11.167	Std	0.3

Cylinder Gas Audit

07/04/2024

Page 8

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT6
 Parameter/Scale: CO / High

Test Date: 06/24/2024
 Test: **Pass**

Instrument: CT6_CODualRg_P_Instr
 Performance: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct
06/24/2024	13:20	L	1000	250.000	257.300	25.0
06/24/2024	13:25	M	1000	571.000	577.000	57.1
06/24/2024	13:32	L	1000	250.000	257.200	25.0
06/24/2024	13:37	M	1000	571.000	575.300	57.1
06/24/2024	13:44	L	1000	250.000	257.400	25.0
06/24/2024	13:49	M	1000	571.000	575.100	57.1

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	250.000	257.300	Std	2.9
M	571.000	575.800	Std	0.8

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/01/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/02/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
04/03/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/03/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/04/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/04/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/04/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/04/2024 04:00	2,519.0	580.5	2,519.0	105,200.0	265.0	0.00	0.0	0.0
04/04/2024 05:00	4,012.3	579.6	4,012.3	105,200.0	422.1	0.00	0.0	0.0
04/04/2024 06:00	4,273.1	579.1	4,273.1	105,200.0	449.5	0.61	0.3	1.0
04/04/2024 07:00	3,544.6	578.0	3,544.6	105,200.0	372.9	0.52	0.3	0.9
04/04/2024 08:00	3,568.7	575.1	3,568.7	105,200.0	375.4	0.52	0.3	0.9
04/04/2024 09:00	3,554.1	576.3	3,554.1	105,200.0	373.9	0.52	0.3	0.9
04/04/2024 10:00	3,643.7	578.8	3,643.7	105,200.0	383.3	0.53	0.3	0.9
04/04/2024 11:00	4,498.3	579.2	4,498.3	105,200.0	473.2	0.64	0.3	1.1
04/04/2024 12:00	4,515.9	593.8	4,563.4	105,200.0	480.1	0.64	0.3	1.1
04/04/2024 13:00	4,504.8	581.0	4,516.4	105,200.0	475.1	0.64	0.3	1.1
04/04/2024 14:00	4,454.5	581.7	4,454.5	105,200.0	468.6	0.64	0.3	1.1
04/04/2024 15:00	3,901.9	581.1	3,901.9	105,200.0	410.5	0.57	0.3	0.9
04/04/2024 16:00	4,102.7	581.6	4,102.7	105,200.0	431.6	0.59	0.3	1.0
04/04/2024 17:00	3,697.2	580.6	3,697.2	105,200.0	388.9	0.54	0.3	0.9
04/04/2024 18:00	3,842.0	580.4	3,842.0	105,200.0	404.2	0.56	0.3	0.9
04/04/2024 19:00	3,943.4	580.2	3,943.4	105,200.0	414.8	0.57	0.3	1.0
04/04/2024 20:00	4,473.4	581.7	4,473.4	105,200.0	470.6	0.64	0.3	1.1
04/04/2024 21:00	4,495.0	583.1	4,495.0	105,200.0	472.9	0.64	0.3	1.1
04/04/2024 22:00	4,495.1	584.5	4,495.1	105,200.0	472.9	0.64	0.3	1.1
04/04/2024 23:00	3,836.0	585.2	3,836.0	105,200.0	403.5	0.56	0.3	0.9
Average/Sum#:	3,993.8	581.1	3,996.7	105,200.0	420.5	0.59	0.3	1.0
Minimum:	2,519.0	575.1	2,519.0	105,200.0	265.0	0.52	0.3	0.9
Maximum:	4,515.9	593.8	4,563.4	105,200.0	480.1	0.64	0.3	1.1
%SI	16.67	16.67	16.67	0.00	16.67	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2024 00:00	4,475.8	585.9	4,475.8	105,200.0	470.9	0.64	0.3	1.1
04/05/2024 01:00	4,455.3	586.4	4,455.3	105,200.0	468.7	0.64	0.3	1.1
04/05/2024 02:00	3,510.7	586.0	3,510.7	105,200.0	369.3	0.52	0.3	0.9
04/05/2024 03:00	3,821.7	586.0	3,821.7	105,200.0	402.0	0.56	0.3	0.9
04/05/2024 04:00	3,811.9	585.4	3,811.9	105,200.0	401.0	0.56	0.3	0.9
04/05/2024 05:00	4,490.3	584.2	4,490.3	105,200.0	472.4	0.64	0.3	1.1
04/05/2024 06:00	4,476.0	585.1	4,476.0	105,200.0	470.9	0.64	0.3	1.1
04/05/2024 07:00	4,484.5	583.9	4,484.5	105,200.0	471.8	0.64	0.3	1.1
04/05/2024 08:00	4,175.5	582.7	4,175.5	105,200.0	439.3	0.60	0.3	1.0
04/05/2024 09:00	3,894.5	581.7	3,894.5	105,200.0	409.7	0.57	0.3	0.9
04/05/2024 10:00	4,502.9	580.1	4,502.9	105,200.0	473.7	0.64	0.3	1.1
04/05/2024 11:00	4,055.0	577.0	4,055.0	105,200.0	426.6	0.58	0.3	1.0
04/05/2024 12:00	3,512.5	570.7	3,512.5	105,200.0	369.5	0.52	0.3	0.9
04/05/2024 13:00	4,311.7	572.2	4,311.7	105,200.0	453.6	0.62	0.3	1.0
04/05/2024 14:00	3,727.0	570.2	3,727.0	105,200.0	392.1	0.54	0.3	0.9
04/05/2024 15:00	3,492.4	570.7	3,492.4	105,200.0	367.4	0.51	0.3	0.9
04/05/2024 16:00	3,502.5	570.1	3,502.5	105,200.0	368.5	0.51	0.3	0.9
04/05/2024 17:00	3,886.5	571.4	3,886.5	105,200.0	408.9	0.56	0.3	0.9
04/05/2024 18:00	4,299.8	574.9	4,299.8	105,200.0	452.3	0.62	0.3	1.0
04/05/2024 19:00	4,456.5	576.6	4,456.5	105,200.0	468.8	0.63	0.3	1.1
04/05/2024 20:00	4,448.0	578.0	4,448.0	105,200.0	467.9	0.63	0.3	1.1
04/05/2024 21:00	3,840.9	579.1	3,840.9	105,200.0	404.1	0.56	0.3	0.9
04/05/2024 22:00	3,579.0	579.8	3,579.0	105,200.0	376.5	0.53	0.3	0.9
04/05/2024 23:00	3,533.7	580.7	3,533.7	105,200.0	371.7	0.52	0.3	0.9
Average/Sum#:	4,031.0	579.1	4,031.0	105,200.0	424.1	0.58	0.3	1.0
Minimum:	3,492.4	570.1	3,492.4	105,200.0	367.4	0.51	0.3	0.9
Maximum:	4,502.9	586.4	4,502.9	105,200.0	473.7	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2024 00:00	3,532.4	581.1	3,532.4	105,200.0	371.6	0.52	0.3	0.9
04/06/2024 01:00	3,511.1	582.4	3,511.1	105,200.0	369.4	0.52	0.3	0.9
04/06/2024 02:00	3,512.6	583.3	3,512.6	105,200.0	369.5	0.52	0.3	0.9
04/06/2024 03:00	3,517.2	583.4	3,517.2	105,200.0	370.0	0.52	0.3	0.9
04/06/2024 04:00	4,161.2	583.4	4,161.2	105,200.0	437.8	0.60	0.3	1.0
04/06/2024 05:00	4,504.9	583.9	4,504.9	105,200.0	473.9	0.64	0.3	1.1
04/06/2024 06:00	3,779.3	583.1	3,779.3	105,200.0	397.6	0.55	0.3	0.9
04/06/2024 07:00	3,516.3	579.7	3,516.3	105,200.0	369.9	0.52	0.3	0.9
04/06/2024 08:00	3,511.9	576.9	3,511.9	105,200.0	369.5	0.52	0.3	0.9
04/06/2024 09:00	3,517.3	573.9	3,517.3	105,200.0	370.0	0.52	0.3	0.9
04/06/2024 10:00	3,521.5	571.7	3,521.5	105,200.0	370.5	0.52	0.3	0.9
04/06/2024 11:00	3,536.6	569.9	3,536.6	105,200.0	372.1	0.52	0.3	0.9
04/06/2024 12:00	3,513.8	565.3	3,513.8	105,200.0	369.7	0.51	0.3	0.9
04/06/2024 13:00	3,474.9	568.2	3,474.9	105,200.0	365.6	0.51	0.3	0.9
04/06/2024 14:00	3,465.4	566.6	3,465.4	105,200.0	364.6	0.51	0.3	0.8
04/06/2024 15:00	3,462.3	564.7	3,462.3	105,200.0	364.2	0.51	0.3	0.8
04/06/2024 16:00	3,462.6	564.9	3,462.6	105,200.0	364.3	0.51	0.3	0.8
04/06/2024 17:00	3,614.9	566.0	3,614.9	105,200.0	380.3	0.53	0.3	0.9
04/06/2024 18:00	3,472.3	567.8	3,472.3	105,200.0	365.3	0.51	0.3	0.9
04/06/2024 19:00	3,453.5	570.3	3,453.5	105,200.0	363.3	0.51	0.3	0.8
04/06/2024 20:00	3,448.0	572.3	3,448.0	105,200.0	362.7	0.51	0.3	0.8
04/06/2024 21:00	3,473.7	574.4	3,473.7	105,200.0	365.4	0.51	0.3	0.9
04/06/2024 22:00	3,477.4	577.5	3,477.4	105,200.0	365.8	0.51	0.3	0.9
04/06/2024 23:00	3,490.3	579.5	3,490.3	105,200.0	367.2	0.51	0.3	0.9
Average/Sum#:	3,580.5	574.6	3,580.5	105,200.0	376.7	0.53	0.3	0.9
Minimum:	3,448.0	564.7	3,448.0	105,200.0	362.7	0.51	0.3	0.8
Maximum:	4,504.9	583.9	4,504.9	105,200.0	473.9	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2024 00:00	3,491.1	579.9	3,491.1	105,200.0	367.3	0.51	0.3	0.9
04/07/2024 01:00	3,489.8	580.3	3,489.8	105,200.0	367.1	0.51	0.3	0.9
04/07/2024 02:00	3,488.1	581.5	3,488.1	105,200.0	366.9	0.51	0.3	0.9
04/07/2024 03:00	3,476.0	582.5	3,476.0	105,200.0	365.7	0.51	0.3	0.9
04/07/2024 04:00	3,478.5	582.9	3,478.5	105,200.0	365.9	0.51	0.3	0.9
04/07/2024 05:00	3,477.6	583.5	3,477.6	105,200.0	365.8	0.51	0.3	0.9
04/07/2024 06:00	3,478.1	582.9	3,478.1	105,200.0	365.9	0.51	0.3	0.9
04/07/2024 07:00	3,488.0	579.8	3,488.0	105,200.0	366.9	0.51	0.3	0.9
04/07/2024 08:00	3,488.2	578.4	3,488.2	105,200.0	367.0	0.51	0.3	0.9
04/07/2024 09:00	3,460.7	575.1	3,460.7	105,200.0	364.1	0.51	0.3	0.8
04/07/2024 10:00	3,459.3	572.9	3,459.3	105,200.0	363.9	0.51	0.3	0.8
04/07/2024 11:00	3,473.4	570.4	3,473.4	105,200.0	365.4	0.51	0.3	0.9
04/07/2024 12:00	3,479.7	564.4	3,479.7	105,200.0	366.1	0.51	0.3	0.9
04/07/2024 13:00	3,471.2	568.9	3,471.2	105,200.0	365.2	0.51	0.3	0.9
04/07/2024 14:00	3,464.9	566.4	3,464.9	105,200.0	364.5	0.51	0.3	0.8
04/07/2024 15:00	3,464.4	565.5	3,464.4	105,200.0	364.5	0.51	0.3	0.8
04/07/2024 16:00	3,479.1	565.2	3,479.1	105,200.0	366.0	0.51	0.3	0.9
04/07/2024 17:00	3,750.9	566.8	3,750.9	105,200.0	394.6	0.55	0.3	0.9
04/07/2024 18:00	3,491.7	567.7	3,491.7	105,200.0	367.3	0.51	0.3	0.9
04/07/2024 19:00	3,507.8	570.3	3,507.8	105,200.0	369.0	0.51	0.3	0.9
04/07/2024 20:00	3,507.2	573.4	3,507.2	105,200.0	369.0	0.51	0.3	0.9
04/07/2024 21:00	3,503.1	575.4	3,503.1	105,200.0	368.5	0.51	0.3	0.9
04/07/2024 22:00	3,499.6	576.9	3,499.6	105,200.0	368.2	0.51	0.3	0.9
04/07/2024 23:00	3,494.4	578.4	3,494.4	105,200.0	367.6	0.51	0.3	0.9
Average/Sum#:	3,494.3	574.6	3,494.3	105,200.0	367.6	0.51	0.3	0.9
Minimum:	3,459.3	564.4	3,459.3	105,200.0	363.9	0.51	0.3	0.8
Maximum:	3,750.9	583.5	3,750.9	105,200.0	394.6	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2024 00:00	3,473.4	579.6	3,473.4	105,200.0	365.4	0.51	0.3	0.9
04/08/2024 01:00	3,469.1	580.7	3,469.1	105,200.0	364.9	0.51	0.3	0.9
04/08/2024 02:00	3,477.4	582.0	3,477.4	105,200.0	365.8	0.51	0.3	0.9
04/08/2024 03:00	3,532.1	583.1	3,532.1	105,200.0	371.6	0.52	0.3	0.9
04/08/2024 04:00	4,047.8	583.1	4,047.8	105,200.0	425.8	0.58	0.3	1.0
04/08/2024 05:00	4,473.4	584.0	4,473.4	105,200.0	470.6	0.64	0.3	1.1
04/08/2024 06:00	3,915.0	581.7	3,915.0	105,200.0	411.9	0.57	0.3	0.9
04/08/2024 07:00	3,489.4	579.6	3,489.4	105,200.0	367.1	0.51	0.3	0.9
04/08/2024 08:00	3,479.4	576.2	3,479.4	105,200.0	366.0	0.51	0.3	0.9
04/08/2024 09:00	3,476.5	571.7	3,476.5	105,200.0	365.7	0.51	0.3	0.9
04/08/2024 10:00	3,933.0	569.8	3,933.0	105,200.0	413.8	0.57	0.3	0.9
04/08/2024 11:00	3,433.1	566.5	3,433.1	105,200.0	361.2	0.50	0.3	0.8
04/08/2024 12:00	3,457.0	560.7	3,457.0	105,200.0	363.7	0.51	0.3	0.8
04/08/2024 13:00	3,453.3	564.4	3,453.3	105,200.0	363.3	0.51	0.3	0.8
04/08/2024 14:00	3,449.7	559.8	3,449.7	105,200.0	362.9	0.51	0.3	0.8
04/08/2024 15:00	3,454.4	559.8	3,454.4	105,200.0	363.4	0.51	0.3	0.8
04/08/2024 16:00	3,449.4	561.0	3,449.4	105,200.0	362.9	0.51	0.3	0.8
04/08/2024 17:00	3,577.9	563.2	3,577.9	105,200.0	376.4	0.52	0.3	0.9
04/08/2024 18:00	3,474.0	564.9	3,474.0	105,200.0	365.5	0.51	0.3	0.9
04/08/2024 19:00	3,463.5	564.4	3,463.5	105,200.0	364.4	0.51	0.3	0.8
04/08/2024 20:00	3,456.9	566.5	3,456.9	105,200.0	363.7	0.51	0.3	0.8
04/08/2024 21:00	3,440.0	570.1	3,440.0	105,200.0	361.9	0.51	0.3	0.8
04/08/2024 22:00	3,449.6	570.2	3,449.6	105,200.0	362.9	0.51	0.3	0.8
04/08/2024 23:00	4,403.2	573.4	4,403.2	105,200.0	463.2	0.63	0.3	1.0
Average/Sum#:	3,613.7	571.5	3,613.7	105,200.0	380.2	0.53	0.3	0.9
Minimum:	3,433.1	559.8	3,433.1	105,200.0	361.2	0.50	0.3	0.8
Maximum:	4,473.4	584.0	4,473.4	105,200.0	470.6	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2024 00:00	4,425.0	576.2	4,425.0	105,200.0	465.5	0.63	0.3	1.1
04/09/2024 01:00	4,424.6	578.0	4,424.6	105,200.0	465.5	0.63	0.3	1.1
04/09/2024 02:00	4,426.2	578.4	4,426.2	105,200.0	465.6	0.63	0.3	1.1
04/09/2024 03:00	4,386.0	578.9	4,386.0	105,200.0	461.4	0.63	0.3	1.0
04/09/2024 04:00	3,837.8	579.4	3,837.8	105,200.0	403.7	0.56	0.3	0.9
04/09/2024 05:00	4,471.8	580.6	4,471.8	105,200.0	470.4	0.64	0.3	1.1
04/09/2024 06:00	3,755.5	576.7	3,755.5	105,200.0	395.1	0.55	0.3	0.9
04/09/2024 07:00	3,488.4	572.9	3,488.4	105,200.0	367.0	0.51	0.3	0.9
04/09/2024 08:00	3,817.0	568.9	3,828.4	105,200.0	402.7	0.55	0.3	0.9
04/09/2024 09:00	3,452.9	565.5	3,452.9	105,200.0	363.2	0.51	0.3	0.8
04/09/2024 10:00	3,457.0	563.3	3,457.0	105,200.0	363.7	0.51	0.3	0.8
04/09/2024 11:00	3,475.9	560.9	3,475.9	105,200.0	365.7	0.51	0.3	0.8
04/09/2024 12:00	3,483.9	555.3	3,483.9	105,200.0	366.5	0.51	0.3	0.9
04/09/2024 13:00	3,474.7	560.0	3,474.7	105,200.0	365.5	0.51	0.3	0.8
04/09/2024 14:00	3,435.7	556.0	3,435.7	105,200.0	361.4	0.50	0.3	0.8
04/09/2024 15:00	3,434.5	555.8	3,434.5	105,200.0	361.3	0.50	0.3	0.8
04/09/2024 16:00	3,438.8	556.7	3,438.8	105,200.0	361.8	0.50	0.3	0.8
04/09/2024 17:00	3,403.7	558.9	3,403.7	105,200.0	358.1	0.50	0.3	0.8
04/09/2024 18:00	3,400.0	560.4	3,400.0	105,200.0	357.7	0.50	0.2	0.8
04/09/2024 19:00	3,394.6	562.2	3,394.6	105,200.0	357.1	0.50	0.2	0.8
04/09/2024 20:00	3,395.0	564.4	3,395.0	105,200.0	357.2	0.50	0.2	0.8
04/09/2024 21:00	3,424.5	565.5	3,424.5	105,200.0	360.3	0.50	0.3	0.8
04/09/2024 22:00	3,432.7	567.5	3,432.7	105,200.0	361.1	0.50	0.3	0.8
04/09/2024 23:00	3,452.5	569.5	3,452.5	105,200.0	363.2	0.51	0.3	0.8
Average/Sum#:	3,691.2	567.2	3,691.7	105,200.0	388.4	0.54	0.3	0.9
Minimum:	3,394.6	555.3	3,394.6	105,200.0	357.1	0.50	0.2	0.8
Maximum:	4,471.8	580.6	4,471.8	105,200.0	470.4	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2024 00:00	3,459.6	570.3	3,459.6	105,200.0	363.9	0.51	0.3	0.8
04/10/2024 01:00	3,453.6	571.9	3,453.6	105,200.0	363.3	0.51	0.3	0.8
04/10/2024 02:00	3,453.0	573.4	3,453.0	105,200.0	363.3	0.51	0.3	0.8
04/10/2024 03:00	3,458.2	573.9	3,458.2	105,200.0	363.8	0.51	0.3	0.8
04/10/2024 04:00	3,464.4	575.0	3,464.4	105,200.0	364.5	0.51	0.3	0.9
04/10/2024 05:00	3,460.0	574.9	3,460.0	105,200.0	364.0	0.51	0.3	0.8
04/10/2024 06:00	3,463.0	574.2	3,463.0	105,200.0	364.3	0.51	0.3	0.8
04/10/2024 07:00	3,462.3	572.4	3,462.3	105,200.0	364.2	0.51	0.3	0.8
04/10/2024 08:00	3,473.3	569.0	3,473.3	105,200.0	365.4	0.51	0.3	0.9
04/10/2024 09:00	3,478.7	564.0	3,478.7	105,200.0	366.0	0.51	0.3	0.9
04/10/2024 10:00	3,480.6	561.6	3,480.6	105,200.0	366.2	0.51	0.3	0.9
04/10/2024 11:00	3,496.5	558.9	3,496.5	105,200.0	367.8	0.51	0.3	0.9
04/10/2024 12:00	3,501.5	554.0	3,501.5	105,200.0	368.4	0.51	0.3	0.9
04/10/2024 13:00	3,490.1	557.3	3,490.1	105,200.0	367.2	0.51	0.3	0.9
04/10/2024 14:00	3,468.9	554.3	3,468.9	105,200.0	364.9	0.51	0.3	0.8
04/10/2024 15:00	3,470.7	554.0	3,470.7	105,200.0	365.1	0.51	0.3	0.8
04/10/2024 16:00	3,481.4	555.0	3,481.4	105,200.0	366.2	0.51	0.3	0.8
04/10/2024 17:00	3,494.2	556.8	3,494.2	105,200.0	367.6	0.51	0.3	0.9
04/10/2024 18:00	3,397.6	558.7	3,397.6	105,200.0	357.4	0.50	0.2	0.8
04/10/2024 19:00	3,395.5	561.0	3,395.5	105,200.0	357.2	0.50	0.2	0.8
04/10/2024 20:00	3,402.8	563.2	3,402.8	105,200.0	358.0	0.50	0.3	0.8
04/10/2024 21:00	3,403.4	565.1	3,403.4	105,200.0	358.0	0.50	0.3	0.8
04/10/2024 22:00	3,407.2	567.2	3,407.2	105,200.0	358.4	0.50	0.3	0.8
04/10/2024 23:00	3,400.3	568.1	3,400.3	105,200.0	357.7	0.50	0.3	0.8
Average/Sum#:	3,454.9	564.8	3,454.9	105,200.0	363.5	0.51	0.3	0.8
Minimum:	3,395.5	554.0	3,395.5	105,200.0	357.2	0.50	0.2	0.8
Maximum:	3,501.5	575.0	3,501.5	105,200.0	368.4	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2024 00:00	3,666.4	569.3	3,666.4	105,200.0	385.7	0.53	0.3	0.9
04/11/2024 01:00	3,457.9	569.8	3,457.9	105,200.0	363.8	0.51	0.3	0.8
04/11/2024 02:00	3,448.4	570.1	3,448.4	105,200.0	362.8	0.51	0.3	0.8
04/11/2024 03:00	3,465.3	570.6	3,465.3	105,200.0	364.5	0.51	0.3	0.8
04/11/2024 04:00	3,559.5	572.8	3,559.5	105,200.0	374.5	0.52	0.3	0.9
04/11/2024 05:00	3,902.3	574.0	3,902.3	105,200.0	410.5	0.56	0.3	0.9
04/11/2024 06:00	3,478.4	573.1	3,478.4	105,200.0	365.9	0.51	0.3	0.9
04/11/2024 07:00	3,480.7	567.5	3,480.7	105,200.0	366.2	0.51	0.3	0.9
04/11/2024 08:00	3,481.8	565.2	3,481.8	105,200.0	366.3	0.51	0.3	0.9
04/11/2024 09:00	3,488.4	560.5	3,488.4	105,200.0	367.0	0.51	0.3	0.9
04/11/2024 10:00	3,487.7	557.6	3,487.7	105,200.0	366.9	0.51	0.3	0.9
04/11/2024 11:00	3,476.9	553.8	3,476.9	105,200.0	365.8	0.51	0.3	0.8
04/11/2024 12:00	3,477.7	549.1	3,477.7	105,200.0	365.9	0.51	0.3	0.8
04/11/2024 13:00	3,464.9	552.4	3,464.9	105,200.0	364.5	0.51	0.3	0.8
04/11/2024 14:00	3,456.2	548.2	3,456.2	105,200.0	363.6	0.51	0.3	0.8
04/11/2024 15:00	3,453.1	546.5	3,453.1	105,200.0	363.3	0.50	0.3	0.8
04/11/2024 16:00	3,449.3	547.0	3,449.3	105,200.0	362.9	0.50	0.3	0.8
04/11/2024 17:00	3,458.0	548.3	3,458.0	105,200.0	363.8	0.51	0.3	0.8
04/11/2024 18:00	3,451.8	551.4	3,451.8	105,200.0	363.1	0.51	0.3	0.8
04/11/2024 19:00	3,428.1	554.8	3,428.1	105,200.0	360.6	0.50	0.3	0.8
04/11/2024 20:00	3,433.4	557.4	3,433.4	105,200.0	361.2	0.50	0.3	0.8
04/11/2024 21:00	3,459.8	560.0	3,459.8	105,200.0	364.0	0.51	0.3	0.8
04/11/2024 22:00	3,469.9	561.8	3,469.9	105,200.0	365.0	0.51	0.3	0.8
04/11/2024 23:00	3,463.8	563.7	3,463.8	105,200.0	364.4	0.51	0.3	0.8
Average/Sum#:	3,494.2	560.2	3,494.2	105,200.0	367.6	0.51	0.3	0.8
Minimum:	3,428.1	546.5	3,428.1	105,200.0	360.6	0.50	0.3	0.8
Maximum:	3,902.3	574.0	3,902.3	105,200.0	410.5	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2024 00:00	3,454.0	564.7	3,454.0	105,200.0	363.4	0.51	0.3	0.8
04/12/2024 01:00	3,450.7	566.3	3,450.7	105,200.0	363.0	0.51	0.3	0.8
04/12/2024 02:00	3,450.0	567.7	3,450.0	105,200.0	362.9	0.51	0.3	0.8
04/12/2024 03:00	3,449.7	567.9	3,449.7	105,200.0	362.9	0.51	0.3	0.8
04/12/2024 04:00	3,454.4	567.9	3,454.4	105,200.0	363.4	0.51	0.3	0.8
04/12/2024 05:00	3,486.2	569.0	3,486.2	105,200.0	366.7	0.51	0.3	0.9
04/12/2024 06:00	3,482.4	567.5	3,482.4	105,200.0	366.3	0.51	0.3	0.9
04/12/2024 07:00	3,484.2	565.1	3,484.2	105,200.0	366.5	0.51	0.3	0.9
04/12/2024 08:00	3,486.2	563.1	3,486.2	105,200.0	366.7	0.51	0.3	0.9
04/12/2024 09:00	3,454.5	560.2	3,454.5	105,200.0	363.4	0.51	0.3	0.8
04/12/2024 10:00	3,445.5	558.0	3,445.5	105,200.0	362.5	0.51	0.3	0.8
04/12/2024 11:00	3,463.6	555.4	3,463.6	105,200.0	364.4	0.51	0.3	0.8
04/12/2024 12:00	3,469.4	553.1	3,469.4	105,200.0	365.0	0.51	0.3	0.8
04/12/2024 13:00	3,505.2	557.3	3,505.2	105,200.0	368.7	0.51	0.3	0.9
04/12/2024 14:00	3,462.3	555.3	3,462.3	105,200.0	364.2	0.51	0.3	0.8
04/12/2024 15:00	3,462.2	556.0	3,462.2	105,200.0	364.2	0.51	0.3	0.8
04/12/2024 16:00	3,455.5	557.6	3,455.5	105,200.0	363.5	0.51	0.3	0.8
04/12/2024 17:00	3,452.6	560.5	3,452.6	105,200.0	363.2	0.51	0.3	0.8
04/12/2024 18:00	3,455.4	563.5	3,455.4	105,200.0	363.5	0.51	0.3	0.8
04/12/2024 19:00	3,446.4	565.6	3,446.4	105,200.0	362.6	0.51	0.3	0.8
04/12/2024 20:00	3,468.5	566.9	3,468.5	105,200.0	364.9	0.51	0.3	0.8
04/12/2024 21:00	3,489.1	567.4	3,489.1	105,200.0	367.1	0.51	0.3	0.9
04/12/2024 22:00	3,495.6	568.3	3,495.6	105,200.0	367.7	0.51	0.3	0.9
04/12/2024 23:00	3,493.1	568.8	3,493.1	105,200.0	367.5	0.51	0.3	0.9
Average/Sum#:	3,467.4	563.0	3,467.4	105,200.0	364.8	0.51	0.3	0.8
Minimum:	3,445.5	553.1	3,445.5	105,200.0	362.5	0.51	0.3	0.8
Maximum:	3,505.2	569.0	3,505.2	105,200.0	368.7	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2024 00:00	3,486.6	569.9	3,486.6	105,200.0	366.8	0.51	0.3	0.9
04/13/2024 01:00	3,487.8	570.5	3,487.8	105,200.0	366.9	0.51	0.3	0.9
04/13/2024 02:00	3,484.8	570.8	3,484.8	105,200.0	366.6	0.51	0.3	0.9
04/13/2024 03:00	3,471.7	570.8	3,471.7	105,200.0	365.2	0.51	0.3	0.9
04/13/2024 04:00	3,469.2	567.9	3,469.2	105,200.0	365.0	0.51	0.3	0.8
04/13/2024 05:00	3,459.2	565.9	3,459.2	105,200.0	363.9	0.51	0.3	0.8
04/13/2024 06:00	3,474.2	569.6	3,474.2	105,200.0	365.5	0.51	0.3	0.9
04/13/2024 07:00	3,467.9	573.5	3,467.9	105,200.0	364.8	0.51	0.3	0.9
04/13/2024 08:00	3,470.6	575.7	3,470.6	105,200.0	365.1	0.51	0.3	0.9
04/13/2024 09:00	3,473.1	577.2	3,473.1	105,200.0	365.4	0.51	0.3	0.9
04/13/2024 10:00	3,472.4	578.4	3,472.4	105,200.0	365.3	0.51	0.3	0.9
04/13/2024 11:00	3,467.6	578.8	3,467.6	105,200.0	364.8	0.51	0.3	0.9
04/13/2024 12:00	3,457.3	579.3	3,457.3	105,200.0	363.7	0.51	0.3	0.8
04/13/2024 13:00	3,449.2	579.2	3,449.2	105,200.0	362.9	0.51	0.3	0.8
04/13/2024 14:00	3,459.3	579.2	3,459.3	105,200.0	363.9	0.51	0.3	0.8
04/13/2024 15:00	3,463.8	579.2	3,463.8	105,200.0	364.4	0.51	0.3	0.9
04/13/2024 16:00	3,469.9	578.8	3,469.9	105,200.0	365.0	0.51	0.3	0.9
04/13/2024 17:00	3,480.1	577.8	3,480.1	105,200.0	366.1	0.51	0.3	0.9
04/13/2024 18:00	3,486.8	577.3	3,486.8	105,200.0	366.8	0.51	0.3	0.9
04/13/2024 19:00	3,482.2	576.9	3,482.2	105,200.0	366.3	0.51	0.3	0.9
04/13/2024 20:00	3,489.9	577.5	3,489.9	105,200.0	367.1	0.51	0.3	0.9
04/13/2024 21:00	3,485.0	577.7	3,485.0	105,200.0	366.6	0.51	0.3	0.9
04/13/2024 22:00	3,482.7	578.2	3,482.7	105,200.0	366.4	0.51	0.3	0.9
04/13/2024 23:00	3,472.5	578.2	3,472.5	105,200.0	365.3	0.51	0.3	0.9
Average/Sum#:	3,473.5	575.3	3,473.5	105,200.0	365.4	0.51	0.3	0.9
Minimum:	3,449.2	565.9	3,449.2	105,200.0	362.9	0.51	0.3	0.8
Maximum:	3,489.9	579.3	3,489.9	105,200.0	367.1	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2024 00:00	3,475.3	578.4	3,475.3	105,200.0	365.6	0.51	0.3	0.9
04/14/2024 01:00	3,472.6	579.2	3,472.6	105,200.0	365.3	0.51	0.3	0.9
04/14/2024 02:00	3,472.7	580.0	3,472.7	105,200.0	365.3	0.51	0.3	0.9
04/14/2024 03:00	3,472.3	580.4	3,472.3	105,200.0	365.3	0.51	0.3	0.9
04/14/2024 04:00	3,473.8	580.1	3,473.8	105,200.0	365.4	0.51	0.3	0.9
04/14/2024 05:00	3,482.3	578.5	3,482.3	105,200.0	366.3	0.51	0.3	0.9
04/14/2024 06:00	3,477.8	578.4	3,477.8	105,200.0	365.9	0.51	0.3	0.9
04/14/2024 07:00	3,486.1	577.8	3,486.1	105,200.0	366.7	0.51	0.3	0.9
04/14/2024 08:00	3,931.7	602.9	4,100.5	105,200.0	431.4	0.57	0.3	1.0
04/14/2024 09:00	3,488.4	572.3	3,488.4	105,200.0	367.0	0.51	0.3	0.9
04/14/2024 10:00	3,499.9	567.7	3,499.9	105,200.0	368.2	0.51	0.3	0.9
04/14/2024 11:00	3,508.0	567.0	3,508.0	105,200.0	369.0	0.51	0.3	0.9
04/14/2024 12:00	3,486.1	564.8	3,486.1	105,200.0	366.7	0.51	0.3	0.9
04/14/2024 13:00	3,468.7	564.2	3,468.7	105,200.0	364.9	0.51	0.3	0.8
04/14/2024 14:00	3,466.5	562.9	3,466.5	105,200.0	364.7	0.51	0.3	0.8
04/14/2024 15:00	3,464.5	563.0	3,464.5	105,200.0	364.5	0.51	0.3	0.8
04/14/2024 16:00	3,461.1	563.3	3,461.1	105,200.0	364.1	0.51	0.3	0.8
04/14/2024 17:00	3,478.9	564.1	3,478.9	105,200.0	366.0	0.51	0.3	0.9
04/14/2024 18:00	3,477.9	567.2	3,477.9	105,200.0	365.9	0.51	0.3	0.9
04/14/2024 19:00	3,445.2	571.0	3,445.2	105,200.0	362.4	0.51	0.3	0.8
04/14/2024 20:00	3,471.9	571.8	3,471.9	105,200.0	365.2	0.51	0.3	0.9
04/14/2024 21:00	3,488.7	572.6	3,488.7	105,200.0	367.0	0.51	0.3	0.9
04/14/2024 22:00	3,476.8	573.2	3,476.8	105,200.0	365.8	0.51	0.3	0.9
04/14/2024 23:00	3,482.3	573.6	3,482.3	105,200.0	366.3	0.51	0.3	0.9
Average/Sum#:	3,496.2	573.1	3,503.3	105,200.0	368.5	0.51	0.3	0.9
Minimum:	3,445.2	562.9	3,445.2	105,200.0	362.4	0.51	0.3	0.8
Maximum:	3,931.7	602.9	4,100.5	105,200.0	431.4	0.57	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2024 00:00	3,479.6	574.1	3,479.6	105,200.0	366.1	0.51	0.3	0.9
04/15/2024 01:00	3,482.6	574.7	3,482.6	105,200.0	366.4	0.51	0.3	0.9
04/15/2024 02:00	3,487.8	574.9	3,487.8	105,200.0	366.9	0.51	0.3	0.9
04/15/2024 03:00	3,491.1	574.6	3,491.1	105,200.0	367.3	0.51	0.3	0.9
04/15/2024 04:00	3,490.0	574.7	3,490.0	105,200.0	367.1	0.51	0.3	0.9
04/15/2024 05:00	3,492.8	574.8	3,492.8	105,200.0	367.4	0.51	0.3	0.9
04/15/2024 06:00	3,500.2	572.4	3,500.2	105,200.0	368.2	0.51	0.3	0.9
04/15/2024 07:00	3,495.2	569.6	3,495.2	105,200.0	367.7	0.51	0.3	0.9
04/15/2024 08:00	3,481.5	569.4	3,481.5	105,200.0	366.3	0.51	0.3	0.9
04/15/2024 09:00	3,456.5	568.4	3,456.5	105,200.0	363.6	0.51	0.3	0.8
04/15/2024 10:00	3,456.5	565.6	3,456.5	105,200.0	363.6	0.51	0.3	0.8
04/15/2024 11:00	3,467.8	562.0	3,467.8	105,200.0	364.8	0.51	0.3	0.8
04/15/2024 12:00	3,473.9	560.1	3,473.9	105,200.0	365.5	0.51	0.3	0.8
04/15/2024 13:00	3,469.5	562.3	3,469.5	105,200.0	365.0	0.51	0.3	0.8
04/15/2024 14:00	3,474.0	559.3	3,474.0	105,200.0	365.5	0.51	0.3	0.8
04/15/2024 15:00	3,481.7	558.5	3,481.7	105,200.0	366.3	0.51	0.3	0.9
04/15/2024 16:00	3,471.1	559.2	3,471.1	105,200.0	365.2	0.51	0.3	0.8
04/15/2024 17:00	3,478.6	560.0	3,478.6	105,200.0	365.9	0.51	0.3	0.8
04/15/2024 18:00	3,472.7	560.9	3,472.7	105,200.0	365.3	0.51	0.3	0.8
04/15/2024 19:00	3,462.7	563.1	3,462.7	105,200.0	364.3	0.51	0.3	0.8
04/15/2024 20:00	3,467.7	564.3	3,467.7	105,200.0	364.8	0.51	0.3	0.8
04/15/2024 21:00	3,457.5	567.2	3,457.5	105,200.0	363.7	0.51	0.3	0.8
04/15/2024 22:00	3,454.4	569.9	3,454.4	105,200.0	363.4	0.51	0.3	0.8
04/15/2024 23:00	3,454.8	571.7	3,454.8	105,200.0	363.4	0.51	0.3	0.8
Average/Sum#:	3,475.0	567.2	3,475.0	105,200.0	365.6	0.51	0.3	0.8
Minimum:	3,454.4	558.5	3,454.4	105,200.0	363.4	0.51	0.3	0.8
Maximum:	3,500.2	574.9	3,500.2	105,200.0	368.2	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2024 00:00	3,452.9	573.2	3,452.9	105,200.0	363.2	0.51	0.3	0.8
04/16/2024 01:00	3,451.1	572.9	3,451.1	105,200.0	363.1	0.51	0.3	0.8
04/16/2024 02:00	3,457.0	572.8	3,457.0	105,200.0	363.7	0.51	0.3	0.8
04/16/2024 03:00	3,454.2	572.9	3,454.2	105,200.0	363.4	0.51	0.3	0.8
04/16/2024 04:00	3,486.4	573.8	3,486.4	105,200.0	366.8	0.51	0.3	0.9
04/16/2024 05:00	3,492.2	575.2	3,492.2	105,200.0	367.4	0.51	0.3	0.9
04/16/2024 06:00	3,497.9	569.9	3,497.9	105,200.0	368.0	0.51	0.3	0.9
04/16/2024 07:00	3,504.2	569.5	3,504.2	105,200.0	368.6	0.51	0.3	0.9
04/16/2024 08:00	3,482.1	564.7	3,482.1	105,200.0	366.3	0.51	0.3	0.9
04/16/2024 09:00	3,467.6	562.8	3,467.6	105,200.0	364.8	0.51	0.3	0.8
04/16/2024 10:00	3,473.1	560.7	3,473.1	105,200.0	365.4	0.51	0.3	0.8
04/16/2024 11:00	3,489.8	555.9	3,489.8	105,200.0	367.1	0.51	0.3	0.9
04/16/2024 12:00	3,488.9	552.5	3,488.9	105,200.0	367.0	0.51	0.3	0.9
04/16/2024 13:00	3,481.9	554.4	3,481.9	105,200.0	366.3	0.51	0.3	0.8
04/16/2024 14:00	3,482.5	553.2	3,482.5	105,200.0	366.4	0.51	0.3	0.8
04/16/2024 15:00	3,484.4	552.6	3,484.4	105,200.0	366.6	0.51	0.3	0.8
04/16/2024 16:00	3,479.5	553.2	3,479.5	105,200.0	366.0	0.51	0.3	0.8
04/16/2024 17:00	3,477.9	555.1	3,477.9	105,200.0	365.9	0.51	0.3	0.8
04/16/2024 18:00	3,452.0	557.7	3,452.0	105,200.0	363.2	0.51	0.3	0.8
04/16/2024 19:00	3,422.5	559.4	3,422.5	105,200.0	360.0	0.50	0.3	0.8
04/16/2024 20:00	3,425.8	562.6	3,425.8	105,200.0	360.4	0.50	0.3	0.8
04/16/2024 21:00	3,430.8	564.6	3,430.8	105,200.0	360.9	0.50	0.3	0.8
04/16/2024 22:00	3,424.1	565.7	3,424.1	105,200.0	360.2	0.50	0.3	0.8
04/16/2024 23:00	3,425.7	567.5	3,425.7	105,200.0	360.4	0.50	0.3	0.8
Average/Sum#:	3,466.0	563.5	3,466.0	105,200.0	364.6	0.51	0.3	0.8
Minimum:	3,422.5	552.5	3,422.5	105,200.0	360.0	0.50	0.3	0.8
Maximum:	3,504.2	575.2	3,504.2	105,200.0	368.6	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2024 00:00	3,447.8	569.4	3,447.8	105,200.0	362.7	0.51	0.3	0.8
04/17/2024 01:00	3,468.0	570.0	3,468.0	105,200.0	364.8	0.51	0.3	0.9
04/17/2024 02:00	3,472.1	570.6	3,472.1	105,200.0	365.3	0.51	0.3	0.9
04/17/2024 03:00	3,472.5	572.2	3,472.5	105,200.0	365.3	0.51	0.3	0.9
04/17/2024 04:00	3,467.6	572.5	3,467.6	105,200.0	364.8	0.51	0.3	0.9
04/17/2024 05:00	3,461.8	571.4	3,461.8	105,200.0	364.2	0.51	0.3	0.8
04/17/2024 06:00	3,461.0	568.5	3,461.0	105,200.0	364.1	0.51	0.3	0.8
04/17/2024 07:00	3,459.6	567.6	3,459.6	105,200.0	363.9	0.51	0.3	0.8
04/17/2024 08:00	3,468.1	563.9	3,468.1	105,200.0	364.8	0.51	0.3	0.8
04/17/2024 09:00	3,473.6	560.7	3,473.6	105,200.0	365.4	0.51	0.3	0.8
04/17/2024 10:00	3,479.4	559.1	3,479.4	105,200.0	366.0	0.51	0.3	0.9
04/17/2024 11:00	3,494.3	553.7	3,494.3	105,200.0	367.6	0.51	0.3	0.9
04/17/2024 12:00	3,493.5	551.1	3,493.5	105,200.0	367.5	0.51	0.3	0.9
04/17/2024 13:00	3,490.3	552.4	3,490.3	105,200.0	367.2	0.51	0.3	0.9
04/17/2024 14:00	3,488.4	550.6	3,488.4	105,200.0	367.0	0.51	0.3	0.9
04/17/2024 15:00	3,486.0	549.6	3,486.0	105,200.0	366.7	0.51	0.3	0.8
04/17/2024 16:00	3,482.4	549.9	3,482.4	105,200.0	366.3	0.51	0.3	0.8
04/17/2024 17:00	3,489.6	552.0	3,489.6	105,200.0	367.1	0.51	0.3	0.9
04/17/2024 18:00	3,482.7	553.2	3,482.7	105,200.0	366.4	0.51	0.3	0.8
04/17/2024 19:00	3,453.1	555.8	3,453.1	105,200.0	363.3	0.51	0.3	0.8
04/17/2024 20:00	3,483.2	559.5	3,483.2	105,200.0	366.4	0.51	0.3	0.9
04/17/2024 21:00	3,492.9	562.2	3,492.9	105,200.0	367.5	0.51	0.3	0.9
04/17/2024 22:00	3,487.8	564.0	3,487.8	105,200.0	366.9	0.51	0.3	0.9
04/17/2024 23:00	3,487.4	565.9	3,487.4	105,200.0	366.9	0.51	0.3	0.9
Average/Sum#:	3,476.8	561.1	3,476.8	105,200.0	365.8	0.51	0.3	0.9
Minimum:	3,447.8	549.6	3,447.8	105,200.0	362.7	0.51	0.3	0.8
Maximum:	3,494.3	572.5	3,494.3	105,200.0	367.6	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2024 00:00	3,492.8	567.5	3,492.8	105,200.0	367.4	0.51	0.3	0.9
04/18/2024 01:00	3,485.9	568.8	3,485.9	105,200.0	366.7	0.51	0.3	0.9
04/18/2024 02:00	3,483.7	570.1	3,483.7	105,200.0	366.5	0.51	0.3	0.9
04/18/2024 03:00	3,479.6	570.5	3,479.6	105,200.0	366.1	0.51	0.3	0.9
04/18/2024 04:00	3,478.4	570.7	3,478.4	105,200.0	365.9	0.51	0.3	0.9
04/18/2024 05:00	3,472.4	571.2	3,472.4	105,200.0	365.3	0.51	0.3	0.9
04/18/2024 06:00	3,479.4	566.1	3,479.4	105,200.0	366.0	0.51	0.3	0.9
04/18/2024 07:00	3,488.5	566.1	3,488.5	105,200.0	367.0	0.51	0.3	0.9
04/18/2024 08:00	3,490.4	561.2	3,490.4	105,200.0	367.2	0.51	0.3	0.9
04/18/2024 09:00	3,493.7	558.4	3,493.7	105,200.0	367.5	0.51	0.3	0.9
04/18/2024 10:00	3,503.3	556.6	3,503.3	105,200.0	368.5	0.51	0.3	0.9
04/18/2024 11:00	3,514.2	550.7	3,514.2	105,200.0	369.7	0.51	0.3	0.9
04/18/2024 12:00	3,523.5	548.4	3,523.5	105,200.0	370.7	0.51	0.3	0.9
04/18/2024 13:00	3,519.9	551.7	3,519.9	105,200.0	370.3	0.51	0.3	0.9
04/18/2024 14:00	3,501.7	549.9	3,501.7	105,200.0	368.4	0.51	0.3	0.9
04/18/2024 15:00	3,490.5	549.4	3,490.5	105,200.0	367.2	0.51	0.3	0.9
04/18/2024 16:00	3,487.6	548.7	3,487.6	105,200.0	366.9	0.51	0.3	0.8
04/18/2024 17:00	3,498.8	551.3	3,498.8	105,200.0	368.1	0.51	0.3	0.9
04/18/2024 18:00	3,450.6	553.6	3,450.6	105,200.0	363.0	0.51	0.3	0.8
04/18/2024 19:00	3,494.6	556.1	3,494.6	105,200.0	367.6	0.51	0.3	0.9
04/18/2024 20:00	3,493.3	557.7	3,493.3	105,200.0	367.5	0.51	0.3	0.9
04/18/2024 21:00	3,488.4	560.3	3,488.4	105,200.0	367.0	0.51	0.3	0.9
04/18/2024 22:00	3,495.1	561.0	3,495.1	105,200.0	367.7	0.51	0.3	0.9
04/18/2024 23:00	3,490.7	562.0	3,490.7	105,200.0	367.2	0.51	0.3	0.9
Average/Sum#:	3,491.5	559.5	3,491.5	105,200.0	367.3	0.51	0.3	0.9
Minimum:	3,450.6	548.4	3,450.6	105,200.0	363.0	0.51	0.3	0.8
Maximum:	3,523.5	571.2	3,523.5	105,200.0	370.7	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2024 00:00	3,487.1	563.2	3,487.1	105,200.0	366.8	0.51	0.3	0.9
04/19/2024 01:00	3,485.0	564.3	3,485.0	105,200.0	366.6	0.51	0.3	0.9
04/19/2024 02:00	3,472.9	565.6	3,472.9	105,200.0	365.3	0.51	0.3	0.8
04/19/2024 03:00	3,467.8	566.8	3,467.8	105,200.0	364.8	0.51	0.3	0.8
04/19/2024 04:00	3,462.9	568.3	3,462.9	105,200.0	364.3	0.51	0.3	0.8
04/19/2024 05:00	3,467.9	568.9	3,467.9	105,200.0	364.8	0.51	0.3	0.8
04/19/2024 06:00	3,486.0	567.1	3,486.0	105,200.0	366.7	0.51	0.3	0.9
04/19/2024 07:00	3,482.6	563.4	3,482.6	105,200.0	366.4	0.51	0.3	0.9
04/19/2024 08:00	3,465.9	560.3	3,465.9	105,200.0	364.6	0.51	0.3	0.8
04/19/2024 09:00	3,482.0	555.9	3,482.0	105,200.0	366.3	0.51	0.3	0.8
04/19/2024 10:00	3,470.9	553.8	3,470.9	105,200.0	365.1	0.51	0.3	0.8
04/19/2024 11:00	3,469.0	547.2	3,469.0	105,200.0	364.9	0.51	0.3	0.8
04/19/2024 12:00	3,474.3	545.6	3,474.3	105,200.0	365.5	0.51	0.3	0.8
04/19/2024 13:00	3,482.0	549.7	3,482.0	105,200.0	366.3	0.51	0.3	0.8
04/19/2024 14:00	3,476.5	547.0	3,476.5	105,200.0	365.7	0.51	0.3	0.8
04/19/2024 15:00	3,472.8	546.6	3,472.8	105,200.0	365.3	0.51	0.3	0.8
04/19/2024 16:00	3,458.7	546.1	3,458.7	105,200.0	363.9	0.51	0.3	0.8
04/19/2024 17:00	3,642.8	547.9	3,642.8	105,200.0	383.2	0.53	0.3	0.9
04/19/2024 18:00	3,443.3	549.9	3,443.3	105,200.0	362.2	0.50	0.3	0.8
04/19/2024 19:00	3,434.3	553.5	3,434.3	105,200.0	361.3	0.50	0.3	0.8
04/19/2024 20:00	3,432.0	557.3	3,432.0	105,200.0	361.0	0.50	0.3	0.8
04/19/2024 21:00	3,433.0	559.9	3,433.0	105,200.0	361.2	0.50	0.3	0.8
04/19/2024 22:00	3,434.2	561.9	3,434.2	105,200.0	361.3	0.50	0.3	0.8
04/19/2024 23:00	3,451.5	563.4	3,451.5	105,200.0	363.1	0.51	0.3	0.8
Average/Sum#:	3,472.3	557.2	3,472.3	105,200.0	365.3	0.51	0.3	0.8
Minimum:	3,432.0	545.6	3,432.0	105,200.0	361.0	0.50	0.3	0.8
Maximum:	3,642.8	568.9	3,642.8	105,200.0	383.2	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2024 00:00	3,452.8	564.8	3,452.8	105,200.0	363.2	0.51	0.3	0.8
04/20/2024 01:00	3,454.5	565.6	3,454.5	105,200.0	363.4	0.51	0.3	0.8
04/20/2024 02:00	3,449.8	566.8	3,449.8	105,200.0	362.9	0.51	0.3	0.8
04/20/2024 03:00	3,447.7	567.5	3,447.7	105,200.0	362.7	0.51	0.3	0.8
04/20/2024 04:00	3,445.8	568.3	3,445.8	105,200.0	362.5	0.51	0.3	0.8
04/20/2024 05:00	3,454.2	567.8	3,454.2	105,200.0	363.4	0.51	0.3	0.8
04/20/2024 06:00	3,458.6	567.4	3,458.6	105,200.0	363.8	0.51	0.3	0.8
04/20/2024 07:00	3,456.6	564.2	3,456.6	105,200.0	363.6	0.51	0.3	0.8
04/20/2024 08:00	3,462.1	560.8	3,462.1	105,200.0	364.2	0.51	0.3	0.8
04/20/2024 09:00	3,471.7	557.9	3,471.7	105,200.0	365.2	0.51	0.3	0.8
04/20/2024 10:00	3,483.2	555.0	3,483.2	105,200.0	366.4	0.51	0.3	0.9
04/20/2024 11:00	3,498.5	548.5	3,498.5	105,200.0	368.0	0.51	0.3	0.9
04/20/2024 12:00	3,509.0	546.8	3,509.0	105,200.0	369.1	0.51	0.3	0.9
04/20/2024 13:00	3,514.8	550.7	3,514.8	105,200.0	369.8	0.51	0.3	0.9
04/20/2024 14:00	3,517.4	548.7	3,517.4	105,200.0	370.0	0.51	0.3	0.9
04/20/2024 15:00	3,508.0	547.9	3,508.0	105,200.0	369.0	0.51	0.3	0.9
04/20/2024 16:00	3,470.3	547.9	3,470.3	105,200.0	365.1	0.51	0.3	0.8
04/20/2024 17:00	3,473.6	550.2	3,473.6	105,200.0	365.4	0.51	0.3	0.8
04/20/2024 18:00	3,466.1	551.1	3,466.1	105,200.0	364.6	0.51	0.3	0.8
04/20/2024 19:00	3,452.3	553.2	3,452.3	105,200.0	363.2	0.51	0.3	0.8
04/20/2024 20:00	3,436.7	556.3	3,436.7	105,200.0	361.5	0.50	0.3	0.8
04/20/2024 21:00	3,443.2	557.9	3,443.2	105,200.0	362.2	0.51	0.3	0.8
04/20/2024 22:00	3,466.6	559.3	3,466.6	105,200.0	364.7	0.51	0.3	0.8
04/20/2024 23:00	3,473.6	561.8	3,473.6	105,200.0	365.4	0.51	0.3	0.8
Average/Sum#:	3,469.5	557.8	3,469.5	105,200.0	365.0	0.51	0.3	0.8
Minimum:	3,436.7	546.8	3,436.7	105,200.0	361.5	0.50	0.3	0.8
Maximum:	3,517.4	568.3	3,517.4	105,200.0	370.0	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2024 00:00	3,475.4	563.6	3,475.4	105,200.0	365.6	0.51	0.3	0.8
04/21/2024 01:00	3,472.8	565.0	3,472.8	105,200.0	365.3	0.51	0.3	0.9
04/21/2024 02:00	3,467.3	565.7	3,467.3	105,200.0	364.8	0.51	0.3	0.8
04/21/2024 03:00	3,457.4	566.3	3,457.4	105,200.0	363.7	0.51	0.3	0.8
04/21/2024 04:00	3,459.1	568.8	3,459.1	105,200.0	363.9	0.51	0.3	0.8
04/21/2024 05:00	3,456.8	569.8	3,456.8	105,200.0	363.7	0.51	0.3	0.8
04/21/2024 06:00	3,474.2	566.7	3,474.2	105,200.0	365.5	0.51	0.3	0.9
04/21/2024 07:00	3,473.7	562.5	3,473.7	105,200.0	365.4	0.51	0.3	0.8
04/21/2024 08:00	3,481.8	558.9	3,481.8	105,200.0	366.3	0.51	0.3	0.9
04/21/2024 09:00	3,486.9	555.1	3,486.9	105,200.0	366.8	0.51	0.3	0.8
04/21/2024 10:00	3,486.6	552.8	3,486.6	105,200.0	366.8	0.51	0.3	0.9
04/21/2024 11:00	3,505.4	547.1	3,505.4	105,200.0	368.8	0.51	0.3	0.9
04/21/2024 12:00	3,517.2	546.4	3,517.2	105,200.0	370.0	0.51	0.3	0.9
04/21/2024 13:00	3,519.0	550.2	3,519.0	105,200.0	370.2	0.51	0.3	0.9
04/21/2024 14:00	3,488.6	547.4	3,488.6	105,200.0	367.0	0.51	0.3	0.8
04/21/2024 15:00	3,469.8	546.8	3,469.8	105,200.0	365.0	0.51	0.3	0.8
04/21/2024 16:00	3,464.0	546.6	3,464.0	105,200.0	364.4	0.51	0.3	0.8
04/21/2024 17:00	3,762.9	549.1	3,762.9	105,200.0	395.9	0.54	0.3	0.9
04/21/2024 18:00	3,590.1	550.2	3,590.1	105,200.0	377.7	0.52	0.3	0.9
04/21/2024 19:00	3,738.5	552.1	3,738.5	105,200.0	393.3	0.54	0.3	0.9
04/21/2024 20:00	3,818.6	554.7	3,818.6	105,200.0	401.7	0.55	0.3	0.9
04/21/2024 21:00	4,002.7	557.1	4,002.7	105,200.0	421.1	0.58	0.3	1.0
04/21/2024 22:00	3,484.4	559.5	3,484.4	105,200.0	366.6	0.51	0.3	0.9
04/21/2024 23:00	3,563.6	562.6	3,563.6	105,200.0	374.9	0.52	0.3	0.9
Average/Sum#:	3,546.5	556.9	3,546.5	105,200.0	373.1	0.52	0.3	0.9
Minimum:	3,456.8	546.4	3,456.8	105,200.0	363.7	0.51	0.3	0.8
Maximum:	4,002.7	569.8	4,002.7	105,200.0	421.1	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2024 00:00	3,503.5	562.7	3,503.5	105,200.0	368.6	0.51	0.3	0.9
04/22/2024 01:00	3,563.3	564.6	3,563.3	105,200.0	374.9	0.52	0.3	0.9
04/22/2024 02:00	3,494.7	566.1	3,494.7	105,200.0	367.6	0.51	0.3	0.9
04/22/2024 03:00	3,496.8	567.3	3,496.8	105,200.0	367.9	0.51	0.3	0.9
04/22/2024 04:00	3,515.0	569.4	3,515.0	105,200.0	369.8	0.51	0.3	0.9
04/22/2024 05:00	3,999.1	569.9	3,999.1	105,200.0	420.7	0.58	0.3	1.0
04/22/2024 06:00	3,941.3	567.0	3,941.3	105,200.0	414.6	0.57	0.3	0.9
04/22/2024 07:00	3,491.1	561.9	3,491.1	105,200.0	367.3	0.51	0.3	0.9
04/22/2024 08:00	3,489.0	558.0	3,489.0	105,200.0	367.0	0.51	0.3	0.9
04/22/2024 09:00	3,476.6	553.6	3,476.6	105,200.0	365.7	0.51	0.3	0.8
04/22/2024 10:00	3,466.3	550.6	3,466.3	105,200.0	364.7	0.51	0.3	0.8
04/22/2024 11:00	3,476.0	545.9	3,476.0	105,200.0	365.7	0.51	0.3	0.8
04/22/2024 12:00	3,476.2	543.0	3,476.2	105,200.0	365.7	0.51	0.3	0.8
04/22/2024 13:00	3,479.0	547.8	3,479.0	105,200.0	366.0	0.51	0.3	0.8
04/22/2024 14:00	3,475.6	545.4	3,475.6	105,200.0	365.6	0.51	0.3	0.8
04/22/2024 15:00	3,465.8	545.8	3,465.8	105,200.0	364.6	0.51	0.3	0.8
04/22/2024 16:00	3,462.2	545.0	3,462.2	105,200.0	364.2	0.51	0.3	0.8
04/22/2024 17:00	3,743.9	546.2	3,743.9	105,200.0	393.9	0.54	0.3	0.9
04/22/2024 18:00	4,097.4	549.6	4,097.4	105,200.0	431.0	0.59	0.3	1.0
04/22/2024 19:00	4,088.3	553.7	4,088.3	105,200.0	430.1	0.59	0.3	1.0
04/22/2024 20:00	4,037.4	557.7	4,037.4	105,200.0	424.7	0.58	0.3	1.0
04/22/2024 21:00	3,732.3	560.9	3,732.3	105,200.0	392.6	0.54	0.3	0.9
04/22/2024 22:00	3,450.3	561.7	3,450.3	105,200.0	363.0	0.51	0.3	0.8
04/22/2024 23:00	3,449.4	562.6	3,449.4	105,200.0	362.9	0.51	0.3	0.8
Average/Sum#:	3,619.6	556.5	3,619.6	105,200.0	380.8	0.53	0.3	0.9
Minimum:	3,449.4	543.0	3,449.4	105,200.0	362.9	0.51	0.3	0.8
Maximum:	4,097.4	569.9	4,097.4	105,200.0	431.0	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2024 00:00	3,441.1	563.6	3,441.1	105,200.0	362.0	0.51	0.3	0.8
04/23/2024 01:00	3,451.1	565.0	3,451.1	105,200.0	363.1	0.51	0.3	0.8
04/23/2024 02:00	3,451.0	566.0	3,451.0	105,200.0	363.0	0.51	0.3	0.8
04/23/2024 03:00	3,444.5	566.8	3,444.5	105,200.0	362.4	0.51	0.3	0.8
04/23/2024 04:00	3,447.6	567.6	3,447.6	105,200.0	362.7	0.51	0.3	0.8
04/23/2024 05:00	3,455.0	568.2	3,455.0	105,200.0	363.5	0.51	0.3	0.8
04/23/2024 06:00	3,483.4	566.8	3,483.4	105,200.0	366.5	0.51	0.3	0.9
04/23/2024 07:00	3,481.5	564.1	3,481.5	110,000.0	383.0	0.51	0.3	0.9
04/23/2024 08:00	3,457.3	561.8	3,457.3	105,200.0	363.7	0.51	0.3	0.8
04/23/2024 09:00	3,459.4	560.4	3,459.4	105,200.0	363.9	0.51	0.3	0.8
04/23/2024 10:00	3,802.8	557.6	3,802.8	105,200.0	400.1	0.55	0.3	0.9
04/23/2024 11:00	3,481.0	554.3	3,481.0	105,200.0	366.2	0.51	0.3	0.8
04/23/2024 12:00	3,675.6	553.9	3,675.6	105,200.0	386.7	0.53	0.3	0.9
04/23/2024 13:00	3,728.0	554.8	3,728.0	105,200.0	392.2	0.54	0.3	0.9
04/23/2024 14:00	4,363.7	552.8	4,363.7	105,200.0	459.1	0.62	0.3	1.0
04/23/2024 15:00	4,382.8	552.9	4,382.8	105,200.0	461.1	0.62	0.3	1.0
04/23/2024 16:00	3,485.7	553.9	3,485.7	105,200.0	366.7	0.51	0.3	0.9
04/23/2024 17:00	3,772.3	556.0	3,772.3	105,200.0	396.8	0.55	0.3	0.9
04/23/2024 18:00	4,410.1	558.2	4,410.1	105,200.0	463.9	0.63	0.3	1.0
04/23/2024 19:00	4,422.4	561.0	4,422.4	105,200.0	465.2	0.63	0.3	1.0
04/23/2024 20:00	4,450.4	563.3	4,450.4	105,200.0	468.2	0.63	0.3	1.1
04/23/2024 21:00	4,002.7	565.2	4,002.7	105,200.0	421.1	0.58	0.3	1.0
04/23/2024 22:00	3,471.5	566.7	3,471.5	105,200.0	365.2	0.51	0.3	0.8
04/23/2024 23:00	3,739.1	567.2	3,739.1	105,200.0	393.4	0.54	0.3	0.9
Average/Sum#:	3,740.0	561.2	3,740.0	105,400.0	394.2	0.54	0.3	0.9
Minimum:	3,441.1	552.8	3,441.1	105,200.0	362.0	0.51	0.3	0.8
Maximum:	4,450.4	568.2	4,450.4	110,000.0	468.2	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2024 00:00	3,469.0	567.1	3,469.0	105,200.0	364.9	0.51	0.3	0.8
04/24/2024 01:00	3,469.8	567.2	3,469.8	105,200.0	365.0	0.51	0.3	0.9
04/24/2024 02:00	3,460.4	567.7	3,460.4	105,200.0	364.0	0.51	0.3	0.8
04/24/2024 03:00	3,453.1	568.6	3,453.1	105,200.0	363.3	0.51	0.3	0.8
04/24/2024 04:00	3,514.1	568.1	3,514.1	105,200.0	369.7	0.52	0.3	0.9
04/24/2024 05:00	3,986.5	567.9	3,986.5	105,200.0	419.4	0.57	0.3	1.0
04/24/2024 06:00	3,533.0	567.0	3,533.0	105,200.0	371.7	0.52	0.3	0.9
04/24/2024 07:00	4,454.7	564.7	4,454.7	105,200.0	468.6	0.63	0.3	1.1
04/24/2024 08:00	3,978.9	562.2	3,978.9	105,200.0	418.6	0.57	0.3	1.0
04/24/2024 09:00	3,468.7	560.7	3,468.7	105,200.0	364.9	0.51	0.3	0.8
04/24/2024 10:00	3,474.1	558.9	3,474.1	105,200.0	365.5	0.51	0.3	0.8
04/24/2024 11:00	3,481.1	556.8	3,481.1	105,200.0	366.2	0.51	0.3	0.8
04/24/2024 12:00	3,488.8	554.3	3,488.8	105,200.0	367.0	0.51	0.3	0.9
04/24/2024 13:00	3,495.1	555.5	3,495.1	105,200.0	367.7	0.51	0.3	0.9
04/24/2024 14:00	3,496.5	552.3	3,496.5	105,200.0	367.8	0.51	0.3	0.9
04/24/2024 15:00	3,492.9	552.2	3,492.9	105,200.0	367.5	0.51	0.3	0.9
04/24/2024 16:00	3,479.4	553.5	3,479.4	105,200.0	366.0	0.51	0.3	0.8
04/24/2024 17:00	3,744.0	556.8	3,744.0	105,200.0	393.9	0.54	0.3	0.9
04/24/2024 18:00	3,490.8	559.4	3,490.8	105,200.0	367.2	0.51	0.3	0.9
04/24/2024 19:00	3,618.8	560.8	3,618.8	105,200.0	380.7	0.53	0.3	0.9
04/24/2024 20:00	3,458.5	563.2	3,458.5	105,200.0	363.8	0.51	0.3	0.8
04/24/2024 21:00	3,460.3	565.2	3,460.3	105,200.0	364.0	0.51	0.3	0.8
04/24/2024 22:00	3,477.3	567.0	3,477.3	105,200.0	365.8	0.51	0.3	0.9
04/24/2024 23:00	3,506.5	567.7	3,506.5	105,200.0	368.9	0.51	0.3	0.9
Average/Sum#:	3,581.3	561.9	3,581.3	105,200.0	376.8	0.52	0.3	0.9
Minimum:	3,453.1	552.2	3,453.1	105,200.0	363.3	0.51	0.3	0.8
Maximum:	4,454.7	568.6	4,454.7	105,200.0	468.6	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2024 00:00	3,494.8	568.1	3,494.8	105,200.0	367.7	0.51	0.3	0.9
04/25/2024 01:00	3,468.5	568.7	3,468.5	105,200.0	364.9	0.51	0.3	0.8
04/25/2024 02:00	3,455.3	570.0	3,455.3	105,200.0	363.5	0.51	0.3	0.8
04/25/2024 03:00	3,455.6	570.8	3,455.6	105,200.0	363.5	0.51	0.3	0.8
04/25/2024 04:00	3,512.5	570.6	3,512.5	105,200.0	369.5	0.52	0.3	0.9
04/25/2024 05:00	3,878.7	571.0	3,878.7	105,200.0	408.0	0.56	0.3	0.9
04/25/2024 06:00	4,292.8	568.1	4,292.8	105,200.0	451.6	0.61	0.3	1.0
04/25/2024 07:00	4,118.3	566.4	4,118.3	105,200.0	433.2	0.59	0.3	1.0
04/25/2024 08:00	3,817.1	562.4	3,817.1	105,200.0	401.6	0.55	0.3	0.9
04/25/2024 09:00	3,474.2	561.3	3,474.2	105,200.0	365.5	0.51	0.3	0.8
04/25/2024 10:00	3,477.4	558.1	3,477.4	105,200.0	365.8	0.51	0.3	0.8
04/25/2024 11:00	3,493.4	553.3	3,493.4	105,200.0	367.5	0.51	0.3	0.9
04/25/2024 12:00	3,490.7	553.2	3,490.7	105,200.0	367.2	0.51	0.3	0.9
04/25/2024 13:00	3,489.8	553.4	3,489.8	105,200.0	367.1	0.51	0.3	0.9
04/25/2024 14:00	3,483.7	552.2	3,483.7	105,200.0	366.5	0.51	0.3	0.8
04/25/2024 15:00	3,551.6	552.6	3,551.6	105,200.0	373.6	0.52	0.3	0.9
04/25/2024 16:00	3,484.3	555.9	3,484.3	105,200.0	366.5	0.51	0.3	0.9
04/25/2024 17:00	3,604.0	558.0	3,604.0	105,200.0	379.1	0.53	0.3	0.9
04/25/2024 18:00	3,497.1	560.1	3,497.1	105,200.0	367.9	0.51	0.3	0.9
04/25/2024 19:00	3,895.8	562.1	3,895.8	105,200.0	409.8	0.56	0.3	0.9
04/25/2024 20:00	3,475.5	563.3	3,475.5	105,200.0	365.6	0.51	0.3	0.8
04/25/2024 21:00	3,531.5	564.6	3,531.5	105,200.0	371.5	0.52	0.3	0.9
04/25/2024 22:00	3,497.2	565.2	3,497.2	105,200.0	367.9	0.51	0.3	0.9
04/25/2024 23:00	3,508.4	566.1	3,508.4	105,200.0	369.1	0.51	0.3	0.9
Average/Sum#:	3,602.0	562.3	3,602.0	105,200.0	378.9	0.53	0.3	0.9
Minimum:	3,455.3	552.2	3,455.3	105,200.0	363.5	0.51	0.3	0.8
Maximum:	4,292.8	571.0	4,292.8	105,200.0	451.6	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2024 00:00	3,504.1	566.4	3,504.1	105,200.0	368.6	0.51	0.3	0.9
04/26/2024 01:00	3,507.3	567.1	3,507.3	105,200.0	369.0	0.51	0.3	0.9
04/26/2024 02:00	3,508.5	568.5	3,508.5	105,200.0	369.1	0.51	0.3	0.9
04/26/2024 03:00	3,510.4	569.0	3,510.4	105,200.0	369.3	0.51	0.3	0.9
04/26/2024 04:00	3,503.2	568.9	3,503.2	105,200.0	368.5	0.51	0.3	0.9
04/26/2024 05:00	3,496.2	568.5	3,496.2	105,200.0	367.8	0.51	0.3	0.9
04/26/2024 06:00	3,496.8	567.0	3,496.8	105,200.0	367.9	0.51	0.3	0.9
04/26/2024 07:00	3,503.1	564.8	3,503.1	105,200.0	368.5	0.51	0.3	0.9
04/26/2024 08:00	3,519.9	562.6	3,519.9	105,200.0	370.3	0.52	0.3	0.9
04/26/2024 09:00	3,529.1	560.1	3,529.1	105,200.0	371.3	0.52	0.3	0.9
04/26/2024 10:00	3,502.9	558.7	3,502.9	105,200.0	368.5	0.51	0.3	0.9
04/26/2024 11:00	3,503.2	556.4	3,503.2	105,200.0	368.5	0.51	0.3	0.9
04/26/2024 12:00	3,512.9	554.7	3,512.9	105,200.0	369.6	0.51	0.3	0.9
04/26/2024 13:00	3,511.6	555.8	3,511.6	105,200.0	369.4	0.51	0.3	0.9
04/26/2024 14:00	3,511.7	552.8	3,511.7	105,200.0	369.4	0.51	0.3	0.9
04/26/2024 15:00	3,500.0	553.5	3,500.0	105,200.0	368.2	0.51	0.3	0.9
04/26/2024 16:00	3,492.8	556.4	3,492.8	105,200.0	367.4	0.51	0.3	0.9
04/26/2024 17:00	3,466.4	565.9	3,466.4	105,200.0	364.7	0.51	0.3	0.8
04/26/2024 18:00	3,498.4	569.8	3,498.4	105,200.0	368.0	0.51	0.3	0.9
04/26/2024 19:00	3,479.4	569.8	3,479.4	105,200.0	366.0	0.51	0.3	0.9
04/26/2024 20:00	3,466.1	570.1	3,466.1	105,200.0	364.6	0.51	0.3	0.8
04/26/2024 21:00	3,476.0	569.5	3,476.0	105,200.0	365.7	0.51	0.3	0.9
04/26/2024 22:00	3,466.7	570.7	3,466.7	105,200.0	364.7	0.51	0.3	0.8
04/26/2024 23:00	3,458.5	572.0	3,458.5	105,200.0	363.8	0.51	0.3	0.8
Average/Sum#:	3,496.9	564.1	3,496.9	105,200.0	367.9	0.51	0.3	0.9
Minimum:	3,458.5	552.8	3,458.5	105,200.0	363.8	0.51	0.3	0.8
Maximum:	3,529.1	572.0	3,529.1	105,200.0	371.3	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2024 00:00	3,466.2	572.4	3,466.2	105,200.0	364.6	0.51	0.3	0.8
04/27/2024 01:00	3,492.8	573.5	3,492.8	105,200.0	367.4	0.51	0.3	0.9
04/27/2024 02:00	3,466.5	574.2	3,466.5	105,200.0	364.7	0.51	0.3	0.9
04/27/2024 03:00	3,484.9	575.1	3,484.9	105,200.0	366.6	0.51	0.3	0.9
04/27/2024 04:00	3,501.1	575.8	3,501.1	105,200.0	368.3	0.51	0.3	0.9
04/27/2024 05:00	3,501.5	576.1	3,501.5	105,200.0	368.4	0.52	0.3	0.9
04/27/2024 06:00	3,513.8	577.3	3,513.8	105,200.0	369.7	0.52	0.3	0.9
04/27/2024 07:00	3,513.9	570.0	3,513.9	105,200.0	369.7	0.52	0.3	0.9
04/27/2024 08:00	3,494.6	564.5	3,494.6	105,200.0	367.6	0.51	0.3	0.9
04/27/2024 09:00	3,484.2	560.8	3,484.2	105,200.0	366.5	0.51	0.3	0.9
04/27/2024 10:00	3,489.0	557.8	3,489.0	105,200.0	367.0	0.51	0.3	0.9
04/27/2024 11:00	3,505.3	554.0	3,505.3	105,200.0	368.8	0.51	0.3	0.9
04/27/2024 12:00	3,510.7	551.8	3,510.7	105,200.0	369.3	0.51	0.3	0.9
04/27/2024 13:00	3,513.0	553.9	3,513.0	105,200.0	369.6	0.51	0.3	0.9
04/27/2024 14:00	3,508.2	551.5	3,508.2	105,200.0	369.1	0.51	0.3	0.9
04/27/2024 15:00	3,499.9	551.4	3,499.9	105,200.0	368.2	0.51	0.3	0.9
04/27/2024 16:00	3,498.3	551.1	3,498.3	105,200.0	368.0	0.51	0.3	0.9
04/27/2024 17:00	3,546.0	553.0	3,546.0	105,200.0	373.0	0.52	0.3	0.9
04/27/2024 18:00	3,556.4	555.8	3,556.4	105,200.0	374.1	0.52	0.3	0.9
04/27/2024 19:00	3,456.2	558.5	3,456.2	105,200.0	363.6	0.51	0.3	0.8
04/27/2024 20:00	3,478.2	560.8	3,478.2	105,200.0	365.9	0.51	0.3	0.9
04/27/2024 21:00	3,482.8	563.1	3,482.8	105,200.0	366.4	0.51	0.3	0.9
04/27/2024 22:00	4,404.0	564.7	4,404.0	105,200.0	463.3	0.63	0.3	1.0
04/27/2024 23:00	4,424.7	566.1	4,424.7	105,200.0	465.5	0.63	0.3	1.1
Average/Sum#:	3,574.7	563.1	3,574.7	105,200.0	376.1	0.52	0.3	0.9
Minimum:	3,456.2	551.1	3,456.2	105,200.0	363.6	0.51	0.3	0.8
Maximum:	4,424.7	577.3	4,424.7	105,200.0	465.5	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2024 00:00	4,449.7	567.6	4,449.7	105,200.0	468.1	0.63	0.3	1.1
04/28/2024 01:00	4,302.9	568.5	4,302.9	105,200.0	452.7	0.62	0.3	1.0
04/28/2024 02:00	4,285.8	568.7	4,285.8	105,200.0	450.9	0.61	0.3	1.0
04/28/2024 03:00	4,321.5	570.1	4,321.5	105,200.0	454.6	0.62	0.3	1.0
04/28/2024 04:00	4,304.6	571.7	4,304.6	105,200.0	452.8	0.62	0.3	1.0
04/28/2024 05:00	3,776.0	572.1	3,776.0	105,200.0	397.2	0.55	0.3	0.9
04/28/2024 06:00	3,474.8	569.0	3,474.8	105,200.0	365.5	0.51	0.3	0.9
04/28/2024 07:00	3,482.5	563.7	3,482.5	105,200.0	366.4	0.51	0.3	0.9
04/28/2024 08:00	3,480.0	558.6	3,480.0	105,200.0	366.1	0.51	0.3	0.8
04/28/2024 09:00	3,481.0	557.9	3,481.0	105,200.0	366.2	0.51	0.3	0.9
04/28/2024 10:00	3,488.9	554.8	3,488.9	105,200.0	367.0	0.51	0.3	0.9
04/28/2024 11:00	3,502.4	550.3	3,502.4	105,200.0	368.5	0.51	0.3	0.9
04/28/2024 12:00	3,511.7	548.2	3,511.7	105,200.0	369.4	0.51	0.3	0.9
04/28/2024 13:00	3,514.9	551.1	3,514.9	105,200.0	369.8	0.51	0.3	0.9
04/28/2024 14:00	3,501.2	548.9	3,501.2	105,200.0	368.3	0.51	0.3	0.9
04/28/2024 15:00	3,470.2	548.7	3,470.2	105,200.0	365.1	0.51	0.3	0.8
04/28/2024 16:00	3,464.1	548.6	3,464.1	105,200.0	364.4	0.51	0.3	0.8
04/28/2024 17:00	3,475.2	550.9	3,475.2	105,200.0	365.6	0.51	0.3	0.8
04/28/2024 18:00	3,500.2	552.9	3,500.2	105,200.0	368.2	0.51	0.3	0.9
04/28/2024 19:00	3,477.9	555.9	3,477.9	105,200.0	365.9	0.51	0.3	0.8
04/28/2024 20:00	3,480.9	559.1	3,480.9	105,200.0	366.2	0.51	0.3	0.9
04/28/2024 21:00	3,480.1	560.9	3,480.1	105,200.0	366.1	0.51	0.3	0.9
04/28/2024 22:00	3,481.6	562.2	3,481.6	105,200.0	366.3	0.51	0.3	0.9
04/28/2024 23:00	3,475.8	564.1	3,475.8	105,200.0	365.7	0.51	0.3	0.9
Average/Sum#:	3,674.3	559.4	3,674.3	105,200.0	386.5	0.53	0.3	0.9
Minimum:	3,464.1	548.2	3,464.1	105,200.0	364.4	0.51	0.3	0.8
Maximum:	4,449.7	572.1	4,449.7	105,200.0	468.1	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2024 00:00	3,469.8	566.0	3,469.8	105,200.0	365.0	0.51	0.3	0.8
04/29/2024 01:00	3,468.9	567.4	3,468.9	105,200.0	364.9	0.51	0.3	0.8
04/29/2024 02:00	3,468.0	568.4	3,468.0	105,200.0	364.8	0.51	0.3	0.8
04/29/2024 03:00	3,462.8	570.6	3,462.8	105,200.0	364.3	0.51	0.3	0.8
04/29/2024 04:00	3,599.0	569.5	3,599.0	105,200.0	378.6	0.53	0.3	0.9
04/29/2024 05:00	3,715.2	571.4	3,715.2	105,200.0	390.8	0.54	0.3	0.9
04/29/2024 06:00	3,475.7	567.8	3,475.7	105,200.0	365.6	0.51	0.3	0.9
04/29/2024 07:00	3,478.4	562.3	3,478.4	105,200.0	365.9	0.51	0.3	0.9
04/29/2024 08:00	3,477.9	558.6	3,477.9	105,200.0	365.9	0.51	0.3	0.8
04/29/2024 09:00	3,470.2	558.8	3,470.2	105,200.0	365.1	0.51	0.3	0.8
04/29/2024 10:00	3,479.7	556.3	3,479.7	105,200.0	366.1	0.51	0.3	0.8
04/29/2024 11:00	3,484.3	552.5	3,484.3	105,200.0	366.5	0.51	0.3	0.8
04/29/2024 12:00	3,493.3	551.6	3,493.3	105,200.0	367.5	0.51	0.3	0.9
04/29/2024 13:00	3,491.0	553.9	3,491.0	105,200.0	367.3	0.51	0.3	0.9
04/29/2024 14:00	3,496.9	550.3	3,496.9	105,200.0	367.9	0.51	0.3	0.9
04/29/2024 15:00	3,485.8	551.4	3,485.8	105,200.0	366.7	0.51	0.3	0.8
04/29/2024 16:00	3,477.6	551.5	3,477.6	105,200.0	365.8	0.51	0.3	0.8
04/29/2024 17:00	3,813.9	555.2	3,813.9	105,200.0	401.2	0.55	0.3	0.9
04/29/2024 18:00	4,229.8	557.5	4,229.8	105,200.0	445.0	0.60	0.3	1.0
04/29/2024 19:00	4,168.5	560.5	4,168.5	105,200.0	438.5	0.60	0.3	1.0
04/29/2024 20:00	3,536.5	563.4	3,536.5	105,200.0	372.0	0.52	0.3	0.9
04/29/2024 21:00	3,453.0	564.1	3,453.0	105,200.0	363.3	0.51	0.3	0.8
04/29/2024 22:00	3,456.3	566.3	3,456.3	105,200.0	363.6	0.51	0.3	0.8
04/29/2024 23:00	3,464.1	568.2	3,464.1	105,200.0	364.4	0.51	0.3	0.8
Average/Sum#:	3,567.4	561.0	3,567.4	105,200.0	375.3	0.52	0.3	0.9
Minimum:	3,453.0	550.3	3,453.0	105,200.0	363.3	0.51	0.3	0.8
Maximum:	4,229.8	571.4	4,229.8	105,200.0	445.0	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2024 00:00	3,463.8	569.7	3,463.8	105,200.0	364.4	0.51	0.3	0.8
04/30/2024 01:00	3,449.8	571.5	3,449.8	105,200.0	362.9	0.51	0.3	0.8
04/30/2024 02:00	3,456.5	573.2	3,456.5	105,200.0	363.6	0.51	0.3	0.8
04/30/2024 03:00	3,529.8	574.9	3,529.8	105,200.0	371.3	0.52	0.3	0.9
04/30/2024 04:00	3,605.4	576.3	3,605.4	105,200.0	379.3	0.53	0.3	0.9
04/30/2024 05:00	3,902.8	576.4	3,902.8	105,200.0	410.6	0.57	0.3	0.9
04/30/2024 06:00	3,523.1	573.5	3,523.1	105,200.0	370.6	0.52	0.3	0.9
04/30/2024 07:00	3,489.7	567.8	3,489.7	105,200.0	367.1	0.51	0.3	0.9
04/30/2024 08:00	3,452.3	563.2	3,452.3	105,200.0	363.2	0.51	0.3	0.8
04/30/2024 09:00	3,438.7	560.8	3,438.7	105,200.0	361.8	0.50	0.3	0.8
04/30/2024 10:00	3,453.8	557.3	3,453.8	105,200.0	363.3	0.51	0.3	0.8
04/30/2024 11:00	3,477.6	552.0	3,477.6	105,200.0	365.8	0.51	0.3	0.8
04/30/2024 12:00	3,497.0	551.8	3,497.0	105,200.0	367.9	0.51	0.3	0.9
04/30/2024 13:00	3,481.1	554.1	3,481.1	105,200.0	366.2	0.51	0.3	0.8
04/30/2024 14:00	3,502.1	551.4	3,502.1	105,200.0	368.4	0.51	0.3	0.9
04/30/2024 15:00	3,495.7	551.3	3,495.7	105,200.0	367.7	0.51	0.3	0.9
04/30/2024 16:00	3,446.7	551.6	3,446.7	105,200.0	362.6	0.50	0.3	0.8
04/30/2024 17:00	3,790.3	554.9	3,790.3	105,200.0	398.7	0.55	0.3	0.9
04/30/2024 18:00	4,025.5	555.8	4,025.5	105,200.0	423.5	0.58	0.3	1.0
04/30/2024 19:00	4,312.1	557.5	4,312.1	105,200.0	453.6	0.61	0.3	1.0
04/30/2024 20:00	4,224.9	560.2	4,224.9	105,200.0	444.5	0.61	0.3	1.0
04/30/2024 21:00	4,388.7	563.5	4,388.7	105,200.0	461.7	0.63	0.3	1.0
04/30/2024 22:00	4,414.5	565.5	4,414.5	105,200.0	464.4	0.63	0.3	1.0
04/30/2024 23:00	4,398.8	567.4	4,398.8	105,200.0	462.8	0.63	0.3	1.0
Average/Sum#:	3,717.5	562.6	3,717.5	105,200.0	391.1	0.54	0.3	0.9
Minimum:	3,438.7	551.3	3,438.7	105,200.0	361.8	0.50	0.3	0.8
Maximum:	4,414.5	576.4	4,414.5	105,200.0	464.4	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2024 00:00	3,900.4	568.1	3,900.4	104,400.0	407.2	0.56	0.3	0.9
05/01/2024 01:00	3,474.7	569.7	3,474.7	104,400.0	362.8	0.51	0.3	0.8
05/01/2024 02:00	3,481.7	571.4	3,481.7	104,400.0	363.5	0.51	0.3	0.8
05/01/2024 03:00	3,639.8	572.9	3,639.8	104,400.0	380.0	0.53	0.3	0.9
05/01/2024 04:00	3,745.9	573.9	3,745.9	104,400.0	391.1	0.54	0.3	0.9
05/01/2024 05:00	4,112.4	574.7	4,112.4	104,400.0	429.3	0.59	0.3	1.0
05/01/2024 06:00	3,557.1	572.1	3,557.1	104,400.0	371.4	0.52	0.3	0.9
05/01/2024 07:00	3,552.6	567.0	3,552.6	104,400.0	370.9	0.52	0.3	0.9
05/01/2024 08:00	3,530.6	562.0	3,530.6	104,400.0	368.6	0.51	0.3	0.9
05/01/2024 09:00	3,533.0	559.3	3,533.0	104,400.0	368.8	0.51	0.3	0.9
05/01/2024 10:00	3,543.5	556.1	3,543.5	104,400.0	369.9	0.51	0.3	0.9
05/01/2024 11:00	3,539.5	551.0	3,539.5	104,400.0	369.5	0.51	0.3	0.9
05/01/2024 12:00	3,498.6	550.7	3,498.6	104,400.0	365.3	0.51	0.3	0.8
05/01/2024 13:00	3,503.6	552.7	3,503.6	104,400.0	365.8	0.51	0.3	0.8
05/01/2024 14:00	3,504.5	550.7	3,504.5	104,400.0	365.9	0.51	0.3	0.8
05/01/2024 15:00	3,472.8	549.8	3,472.8	104,400.0	362.6	0.50	0.3	0.8
05/01/2024 16:00	3,454.1	550.6	3,454.1	104,400.0	360.6	0.50	0.3	0.8
05/01/2024 17:00	3,514.5	553.5	3,514.5	104,400.0	366.9	0.51	0.3	0.8
05/01/2024 18:00	3,465.3	555.5	3,465.3	104,400.0	361.8	0.50	0.3	0.8
05/01/2024 19:00	3,470.4	556.5	3,470.4	104,400.0	362.3	0.50	0.3	0.8
05/01/2024 20:00	3,472.6	556.7	3,472.6	104,400.0	362.5	0.50	0.3	0.8
05/01/2024 21:00	3,458.9	558.0	3,458.9	104,400.0	361.1	0.50	0.3	0.8
05/01/2024 22:00	3,458.6	562.1	3,458.6	104,400.0	361.1	0.50	0.3	0.8
05/01/2024 23:00	3,461.3	565.2	3,461.3	104,400.0	361.4	0.50	0.3	0.8
Average/Sum#:	3,556.1	560.8	3,556.1	104,400.0	371.3	0.52	0.3	0.8
Minimum:	3,454.1	549.8	3,454.1	104,400.0	360.6	0.50	0.3	0.8
Maximum:	4,112.4	574.7	4,112.4	104,400.0	429.3	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2024 00:00	3,458.2	566.1	3,458.2	104,400.0	361.0	0.50	0.3	0.8
05/02/2024 01:00	3,450.5	566.7	3,450.5	104,400.0	360.2	0.50	0.3	0.8
05/02/2024 02:00	3,445.5	567.9	3,445.5	104,400.0	359.7	0.50	0.3	0.8
05/02/2024 03:00	3,442.6	570.9	3,442.6	104,400.0	359.4	0.50	0.3	0.8
05/02/2024 04:00	3,675.1	570.3	3,675.1	104,400.0	383.7	0.53	0.3	0.9
05/02/2024 05:00	4,131.5	570.7	4,131.5	104,400.0	431.3	0.59	0.3	1.0
05/02/2024 06:00	4,027.1	568.7	4,027.1	104,400.0	420.4	0.58	0.3	1.0
05/02/2024 07:00	3,865.3	562.5	3,865.3	104,400.0	403.5	0.56	0.3	0.9
05/02/2024 08:00	4,156.8	558.0	4,156.8	104,400.0	434.0	0.59	0.3	1.0
05/02/2024 09:00	4,316.4	556.9	4,316.4	104,400.0	450.6	0.61	0.3	1.0
05/02/2024 10:00	4,298.8	553.6	4,298.8	104,400.0	448.8	0.61	0.3	1.0
05/02/2024 11:00	4,001.2	547.5	4,001.2	104,400.0	417.7	0.57	0.3	0.9
05/02/2024 12:00	3,584.8	547.2	3,584.8	104,400.0	374.3	0.52	0.3	0.9
05/02/2024 13:00	3,742.3	550.6	3,742.3	104,400.0	390.7	0.54	0.3	0.9
05/02/2024 14:00	3,531.5	550.9	3,531.5	104,400.0	368.7	0.51	0.3	0.9
05/02/2024 15:00	3,504.3	549.9	3,504.3	104,400.0	365.8	0.51	0.3	0.8
05/02/2024 16:00	3,485.0	550.2	3,485.0	104,400.0	363.8	0.51	0.3	0.8
05/02/2024 17:00	3,647.3	553.6	3,647.3	104,400.0	380.8	0.53	0.3	0.9
05/02/2024 18:00	3,968.9	555.7	3,968.9	104,400.0	414.4	0.57	0.3	0.9
05/02/2024 19:00	3,687.2	556.2	3,687.2	104,400.0	384.9	0.53	0.3	0.9
05/02/2024 20:00	3,464.4	558.0	3,464.4	104,400.0	361.7	0.50	0.3	0.8
05/02/2024 21:00	3,460.5	559.6	3,460.5	104,400.0	361.3	0.50	0.3	0.8
05/02/2024 22:00	3,454.9	561.9	3,454.9	104,400.0	360.7	0.50	0.3	0.8
05/02/2024 23:00	3,472.0	565.0	3,472.0	104,400.0	362.5	0.51	0.3	0.8
Average/Sum#:	3,719.7	559.1	3,719.7	104,400.0	388.3	0.54	0.3	0.9
Minimum:	3,442.6	547.2	3,442.6	104,400.0	359.4	0.50	0.3	0.8
Maximum:	4,316.4	570.9	4,316.4	104,400.0	450.6	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2024 00:00	3,464.4	567.2	3,464.4	104,400.0	361.7	0.51	0.3	0.8
05/03/2024 01:00	3,467.3	567.7	3,467.3	104,400.0	362.0	0.51	0.3	0.8
05/03/2024 02:00	3,479.4	567.6	3,479.4	104,400.0	363.2	0.51	0.3	0.8
05/03/2024 03:00	3,519.5	568.0	3,519.5	104,400.0	367.4	0.51	0.3	0.9
05/03/2024 04:00	3,944.0	570.6	3,944.0	104,400.0	411.8	0.57	0.3	0.9
05/03/2024 05:00	3,934.6	569.9	3,934.6	104,400.0	410.8	0.56	0.3	0.9
05/03/2024 06:00	3,472.6	566.1	3,472.6	104,400.0	362.5	0.51	0.3	0.8
05/03/2024 07:00	3,471.9	563.2	3,471.9	104,400.0	362.5	0.51	0.3	0.8
05/03/2024 08:00	3,474.0	559.2	3,474.0	104,400.0	362.7	0.50	0.3	0.8
05/03/2024 09:00	4,241.8	558.3	4,241.8	104,400.0	442.8	0.60	0.3	1.0
05/03/2024 10:00	4,066.5	555.6	4,066.5	104,400.0	424.5	0.58	0.3	1.0
05/03/2024 11:00	3,478.4	549.2	3,478.4	104,400.0	363.1	0.50	0.3	0.8
05/03/2024 12:00	3,611.1	547.8	3,611.1	104,400.0	377.0	0.52	0.3	0.9
05/03/2024 13:00	3,458.3	551.3	3,458.3	104,400.0	361.0	0.50	0.3	0.8
05/03/2024 14:00	3,471.5	550.0	3,471.5	104,400.0	362.4	0.50	0.3	0.8
05/03/2024 15:00	3,899.4	549.1	3,899.4	104,400.0	407.1	0.56	0.3	0.9
05/03/2024 16:00	3,774.7	549.0	3,774.7	104,400.0	394.1	0.54	0.3	0.9
05/03/2024 17:00	3,731.7	552.1	3,731.7	104,400.0	389.6	0.54	0.3	0.9
05/03/2024 18:00	3,468.6	554.9	3,468.6	104,400.0	362.1	0.50	0.3	0.8
05/03/2024 19:00	3,461.3	557.8	3,461.3	104,400.0	361.4	0.50	0.3	0.8
05/03/2024 20:00	3,468.6	560.5	3,468.6	104,400.0	362.1	0.51	0.3	0.8
05/03/2024 21:00	3,457.3	562.5	3,457.3	104,400.0	360.9	0.50	0.3	0.8
05/03/2024 22:00	3,443.4	563.7	3,443.4	104,400.0	359.5	0.50	0.3	0.8
05/03/2024 23:00	3,438.3	564.2	3,438.3	104,400.0	359.0	0.50	0.3	0.8
Average/Sum#:	3,612.4	559.4	3,612.4	104,400.0	377.1	0.52	0.3	0.8
Minimum:	3,438.3	547.8	3,438.3	104,400.0	359.0	0.50	0.3	0.8
Maximum:	4,241.8	570.6	4,241.8	104,400.0	442.8	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2024 00:00	3,472.9	566.6	3,472.9	104,400.0	362.6	0.51	0.3	0.8
05/04/2024 01:00	3,479.8	568.1	3,479.8	104,400.0	363.3	0.51	0.3	0.8
05/04/2024 02:00	3,480.3	568.0	3,480.3	104,400.0	363.3	0.51	0.3	0.8
05/04/2024 03:00	3,484.0	567.7	3,484.0	104,400.0	363.7	0.51	0.3	0.8
05/04/2024 04:00	3,488.0	567.8	3,488.0	104,400.0	364.1	0.51	0.3	0.8
05/04/2024 05:00	3,486.2	569.5	3,486.2	104,400.0	364.0	0.51	0.3	0.8
05/04/2024 06:00	3,454.2	570.4	3,454.2	104,400.0	360.6	0.50	0.3	0.8
05/04/2024 07:00	3,438.7	570.3	3,438.7	104,400.0	359.0	0.50	0.3	0.8
05/04/2024 08:00	4,273.6	570.5	4,273.6	104,400.0	446.2	0.61	0.3	1.0
05/04/2024 09:00	4,396.1	570.6	4,396.1	104,400.0	459.0	0.62	0.3	1.0
05/04/2024 10:00	4,466.2	572.6	4,466.2	104,400.0	466.3	0.63	0.3	1.1
05/04/2024 11:00	4,471.4	573.3	4,471.4	104,400.0	466.8	0.63	0.3	1.1
05/04/2024 12:00	4,470.9	573.8	4,470.9	104,400.0	466.8	0.63	0.3	1.1
05/04/2024 13:00	4,468.5	574.7	4,468.5	104,400.0	466.5	0.63	0.3	1.1
05/04/2024 14:00	4,464.1	572.2	4,464.1	104,400.0	466.1	0.63	0.3	1.1
05/04/2024 15:00	3,675.8	569.7	3,675.8	104,400.0	383.8	0.53	0.3	0.9
05/04/2024 16:00	3,453.9	569.2	3,453.9	104,400.0	360.6	0.50	0.3	0.8
05/04/2024 17:00	3,473.7	569.6	3,473.7	104,400.0	362.7	0.51	0.3	0.8
05/04/2024 18:00	3,480.9	570.2	3,480.9	104,400.0	363.4	0.51	0.3	0.8
05/04/2024 19:00	3,474.6	570.5	3,474.6	104,400.0	362.7	0.51	0.3	0.8
05/04/2024 20:00	3,479.1	572.0	3,479.1	104,400.0	363.2	0.51	0.3	0.8
05/04/2024 21:00	3,886.3	573.5	3,886.3	104,400.0	405.7	0.56	0.3	0.9
05/04/2024 22:00	3,659.4	574.3	3,659.4	104,400.0	382.0	0.53	0.3	0.9
05/04/2024 23:00	3,477.1	575.2	3,477.1	104,400.0	363.0	0.51	0.3	0.8
Average/Sum#:	3,785.7	570.8	3,785.7	104,400.0	395.2	0.55	0.3	0.9
Minimum:	3,438.7	566.6	3,438.7	104,400.0	359.0	0.50	0.3	0.8
Maximum:	4,471.4	575.2	4,471.4	104,400.0	466.8	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2024 00:00	3,477.8	575.7	3,477.8	104,400.0	363.1	0.51	0.3	0.8
05/05/2024 01:00	3,474.8	576.0	3,474.8	104,400.0	362.8	0.51	0.3	0.8
05/05/2024 02:00	3,479.3	576.0	3,479.3	104,400.0	363.2	0.51	0.3	0.8
05/05/2024 03:00	3,474.3	576.4	3,474.3	104,400.0	362.7	0.51	0.3	0.8
05/05/2024 04:00	3,471.8	576.9	3,471.8	104,400.0	362.5	0.51	0.3	0.8
05/05/2024 05:00	3,557.5	577.1	3,557.5	104,400.0	371.4	0.52	0.3	0.9
05/05/2024 06:00	3,489.6	573.1	3,489.6	104,400.0	364.3	0.51	0.3	0.8
05/05/2024 07:00	3,478.2	568.7	3,478.2	104,400.0	363.1	0.51	0.3	0.8
05/05/2024 08:00	3,469.4	566.0	3,469.4	104,400.0	362.2	0.51	0.3	0.8
05/05/2024 09:00	3,468.4	565.4	3,468.4	104,400.0	362.1	0.51	0.3	0.8
05/05/2024 10:00	3,499.2	563.8	3,499.2	104,400.0	365.3	0.51	0.3	0.8
05/05/2024 11:00	3,496.8	559.8	3,496.8	104,400.0	365.1	0.51	0.3	0.8
05/05/2024 12:00	3,485.4	557.8	3,485.4	104,400.0	363.9	0.51	0.3	0.8
05/05/2024 13:00	3,481.2	560.8	3,481.2	104,400.0	363.4	0.51	0.3	0.8
05/05/2024 14:00	3,471.2	560.3	3,471.2	104,400.0	362.4	0.50	0.3	0.8
05/05/2024 15:00	3,462.5	560.5	3,462.5	104,400.0	361.5	0.50	0.3	0.8
05/05/2024 16:00	3,460.7	560.5	3,460.7	104,400.0	361.3	0.50	0.3	0.8
05/05/2024 17:00	3,463.2	562.9	3,463.2	104,400.0	361.6	0.50	0.3	0.8
05/05/2024 18:00	3,448.7	564.3	3,448.7	104,400.0	360.0	0.50	0.3	0.8
05/05/2024 19:00	3,438.3	565.1	3,438.3	104,400.0	359.0	0.50	0.3	0.8
05/05/2024 20:00	3,425.8	567.9	3,425.8	104,400.0	357.7	0.50	0.3	0.8
05/05/2024 21:00	3,424.1	569.5	3,424.1	104,400.0	357.5	0.50	0.3	0.8
05/05/2024 22:00	3,440.4	571.3	3,440.4	104,400.0	359.2	0.50	0.3	0.8
05/05/2024 23:00	3,462.0	572.1	3,462.0	104,400.0	361.4	0.51	0.3	0.8
Average/Sum#:	3,470.9	567.8	3,470.9	104,400.0	362.4	0.51	0.3	0.8
Minimum:	3,424.1	557.8	3,424.1	104,400.0	357.5	0.50	0.3	0.8
Maximum:	3,557.5	577.1	3,557.5	104,400.0	371.4	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2024 00:00	3,458.6	572.3	3,458.6	104,400.0	361.1	0.50	0.3	0.8
05/06/2024 01:00	3,457.6	573.1	3,457.6	104,400.0	361.0	0.50	0.3	0.8
05/06/2024 02:00	3,457.0	574.0	3,457.0	104,400.0	360.9	0.51	0.3	0.8
05/06/2024 03:00	3,458.0	575.1	3,458.0	104,400.0	361.0	0.50	0.3	0.8
05/06/2024 04:00	3,458.1	575.7	3,458.1	104,400.0	361.0	0.51	0.3	0.8
05/06/2024 05:00	3,437.8	575.5	3,437.8	104,400.0	358.9	0.50	0.3	0.8
05/06/2024 06:00	3,445.4	570.3	3,445.4	104,400.0	359.7	0.50	0.3	0.8
05/06/2024 07:00	3,462.9	566.1	3,462.9	104,400.0	361.5	0.50	0.3	0.8
05/06/2024 08:00	3,469.6	563.6	3,469.6	104,400.0	362.2	0.51	0.3	0.8
05/06/2024 09:00	3,477.0	563.0	3,477.0	104,400.0	363.0	0.51	0.3	0.8
05/06/2024 10:00	3,434.0	560.3	3,434.0	104,400.0	358.5	0.50	0.3	0.8
05/06/2024 11:00	3,435.7	553.7	3,435.7	104,400.0	358.7	0.50	0.2	0.8
05/06/2024 12:00	3,465.1	552.9	3,465.1	104,400.0	361.8	0.50	0.3	0.8
05/06/2024 13:00	3,467.0	557.2	3,467.0	104,400.0	362.0	0.51	0.3	0.8
05/06/2024 14:00	3,475.2	556.4	3,475.2	104,400.0	362.8	0.51	0.3	0.8
05/06/2024 15:00	3,468.1	555.8	3,468.1	104,400.0	362.1	0.50	0.3	0.8
05/06/2024 16:00	3,443.4	555.4	3,443.4	104,400.0	359.5	0.50	0.3	0.8
05/06/2024 17:00	3,455.4	558.0	3,455.4	104,400.0	360.7	0.50	0.3	0.8
05/06/2024 18:00	3,459.3	560.1	3,459.3	104,400.0	361.2	0.50	0.3	0.8
05/06/2024 19:00	3,452.1	562.3	3,452.1	104,400.0	360.4	0.50	0.3	0.8
05/06/2024 20:00	3,454.2	564.7	3,454.2	104,400.0	360.6	0.50	0.3	0.8
05/06/2024 21:00	3,454.2	566.7	3,454.2	104,400.0	360.6	0.50	0.3	0.8
05/06/2024 22:00	3,450.5	568.4	3,450.5	104,400.0	360.2	0.50	0.3	0.8
05/06/2024 23:00	3,450.4	569.1	3,450.4	104,400.0	360.2	0.50	0.3	0.8
Average/Sum#:	3,456.1	564.6	3,456.1	104,400.0	360.8	0.50	0.3	0.8
Minimum:	3,434.0	552.9	3,434.0	104,400.0	358.5	0.50	0.2	0.8
Maximum:	3,477.0	575.7	3,477.0	104,400.0	363.0	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2024 00:00	3,448.7	568.6	3,448.7	104,400.0	360.0	0.50	0.3	0.8
05/07/2024 01:00	3,453.0	569.7	3,453.0	104,400.0	360.5	0.50	0.3	0.8
05/07/2024 02:00	3,451.4	570.6	3,451.4	104,400.0	360.3	0.50	0.3	0.8
05/07/2024 03:00	3,448.1	571.4	3,448.1	104,400.0	360.0	0.50	0.3	0.8
05/07/2024 04:00	3,448.0	572.0	3,448.0	104,400.0	360.0	0.50	0.3	0.8
05/07/2024 05:00	3,446.9	572.5	3,446.9	104,400.0	359.9	0.50	0.3	0.8
05/07/2024 06:00	3,451.9	568.9	3,451.9	104,400.0	360.4	0.50	0.3	0.8
05/07/2024 07:00	3,450.3	566.0	3,450.3	104,400.0	360.2	0.50	0.3	0.8
05/07/2024 08:00	3,469.7	564.0	3,469.7	104,400.0	362.2	0.51	0.3	0.8
05/07/2024 09:00	3,434.9	563.9	3,434.9	104,400.0	358.6	0.50	0.3	0.8
05/07/2024 10:00	3,442.9	560.7	3,442.9	104,400.0	359.4	0.50	0.3	0.8
05/07/2024 11:00	3,469.1	555.3	3,469.1	104,400.0	362.2	0.50	0.3	0.8
05/07/2024 12:00	3,462.9	555.2	3,462.9	104,400.0	361.5	0.50	0.3	0.8
05/07/2024 13:00	3,477.1	558.0	3,477.1	104,400.0	363.0	0.51	0.3	0.8
05/07/2024 14:00	3,460.7	557.2	3,460.7	104,400.0	361.3	0.50	0.3	0.8
05/07/2024 15:00	3,439.6	556.3	3,439.6	104,400.0	359.1	0.50	0.3	0.8
05/07/2024 16:00	3,445.4	556.7	3,445.4	104,400.0	359.7	0.50	0.3	0.8
05/07/2024 17:00	3,450.4	559.4	3,450.4	104,400.0	360.2	0.50	0.3	0.8
05/07/2024 18:00	3,461.1	559.9	3,461.1	104,400.0	361.3	0.50	0.3	0.8
05/07/2024 19:00	3,470.0	561.2	3,470.0	104,400.0	362.3	0.50	0.3	0.8
05/07/2024 20:00	3,522.8	563.8	3,522.8	104,400.0	367.8	0.51	0.3	0.9
05/07/2024 21:00	3,455.1	564.1	3,455.1	104,400.0	360.7	0.50	0.3	0.8
05/07/2024 22:00	3,440.8	566.1	3,440.8	104,400.0	359.2	0.50	0.3	0.8
05/07/2024 23:00	3,440.3	569.1	3,440.3	104,400.0	359.2	0.50	0.3	0.8
Average/Sum#:	3,455.9	563.8	3,455.9	104,400.0	360.8	0.50	0.3	0.8
Minimum:	3,434.9	555.2	3,434.9	104,400.0	358.6	0.50	0.3	0.8
Maximum:	3,522.8	572.5	3,522.8	104,400.0	367.8	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:53 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2024 00:00	3,433.3	568.2	3,433.3	104,400.0	358.4	0.50	0.3	0.8
05/08/2024 01:00	3,453.2	568.9	3,453.2	104,400.0	360.5	0.50	0.3	0.8
05/08/2024 02:00	3,443.4	570.5	3,443.4	104,400.0	359.5	0.50	0.3	0.8
05/08/2024 03:00	3,440.5	571.7	3,440.5	104,400.0	359.2	0.50	0.3	0.8
05/08/2024 04:00	3,660.3	572.9	3,660.3	104,400.0	382.1	0.53	0.3	0.9
05/08/2024 05:00	3,964.4	571.9	3,964.4	104,400.0	413.9	0.57	0.3	0.9
05/08/2024 06:00	3,449.7	567.0	3,449.7	104,400.0	360.1	0.50	0.3	0.8
05/08/2024 07:00	3,436.2	563.6	3,436.2	104,400.0	358.7	0.50	0.3	0.8
05/08/2024 08:00	3,428.3	560.7	3,428.3	104,400.0	357.9	0.50	0.2	0.8
05/08/2024 09:00	3,415.4	560.2	3,415.4	104,400.0	356.6	0.50	0.2	0.8
05/08/2024 10:00	3,446.1	556.8	3,446.1	104,400.0	359.8	0.50	0.3	0.8
05/08/2024 11:00	3,475.3	553.0	3,475.3	104,400.0	362.8	0.50	0.3	0.8
05/08/2024 12:00	3,474.6	553.1	3,474.6	104,400.0	362.7	0.50	0.3	0.8
05/08/2024 13:00	3,474.6	555.8	3,474.6	104,400.0	362.7	0.50	0.3	0.8
05/08/2024 14:00	3,476.1	554.8	3,476.1	104,400.0	362.9	0.50	0.3	0.8
05/08/2024 15:00	3,470.1	553.6	3,470.1	104,400.0	362.3	0.50	0.3	0.8
05/08/2024 16:00	3,465.1	553.3	3,465.1	104,400.0	361.8	0.50	0.3	0.8
05/08/2024 17:00	3,579.0	556.2	3,579.0	104,400.0	373.6	0.52	0.3	0.9
05/08/2024 18:00	3,457.4	557.9	3,457.4	104,400.0	361.0	0.50	0.3	0.8
05/08/2024 19:00	3,547.5	560.4	3,547.5	104,400.0	370.4	0.51	0.3	0.9
05/08/2024 20:00	3,445.5	563.4	3,445.5	104,400.0	359.7	0.50	0.3	0.8
05/08/2024 21:00	3,446.6	565.1	3,446.6	104,400.0	359.8	0.50	0.3	0.8
05/08/2024 22:00	3,447.2	565.3	3,447.2	104,400.0	359.9	0.50	0.3	0.8
05/08/2024 23:00	3,443.7	566.2	3,443.7	104,400.0	359.5	0.50	0.3	0.8
Average/Sum#:	3,490.6	562.1	3,490.6	104,400.0	364.4	0.51	0.3	0.8
Minimum:	3,415.4	553.0	3,415.4	104,400.0	356.6	0.50	0.2	0.8
Maximum:	3,964.4	572.9	3,964.4	104,400.0	413.9	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2024 00:00	3,440.2	566.3	3,440.2	104,400.0	359.2	0.50	0.3	0.8
05/09/2024 01:00	3,441.4	567.3	3,441.4	104,400.0	359.3	0.50	0.3	0.8
05/09/2024 02:00	3,438.1	568.9	3,438.1	104,400.0	358.9	0.50	0.3	0.8
05/09/2024 03:00	3,444.3	569.9	3,444.3	104,400.0	359.6	0.50	0.3	0.8
05/09/2024 04:00	3,439.0	571.2	3,439.0	104,400.0	359.0	0.50	0.3	0.8
05/09/2024 05:00	3,443.1	570.2	3,443.1	104,400.0	359.5	0.50	0.3	0.8
05/09/2024 06:00	3,459.8	564.6	3,459.8	104,400.0	361.2	0.50	0.3	0.8
05/09/2024 07:00	3,461.8	560.2	3,461.8	104,400.0	361.4	0.50	0.3	0.8
05/09/2024 08:00	3,451.4	556.3	3,451.4	104,400.0	360.3	0.50	0.3	0.8
05/09/2024 09:00	3,454.8	555.4	3,454.8	104,400.0	360.7	0.50	0.3	0.8
05/09/2024 10:00	3,456.6	552.1	3,456.6	104,400.0	360.9	0.50	0.3	0.8
05/09/2024 11:00	3,475.0	546.0	3,475.0	104,400.0	362.8	0.50	0.3	0.8
05/09/2024 12:00	3,483.2	546.8	3,483.2	104,400.0	363.6	0.51	0.3	0.8
05/09/2024 13:00	3,496.2	549.5	3,496.2	104,400.0	365.0	0.51	0.3	0.8
05/09/2024 14:00	3,491.9	548.8	3,491.9	104,400.0	364.6	0.51	0.3	0.8
05/09/2024 15:00	3,454.6	547.7	3,454.6	104,400.0	360.7	0.50	0.3	0.8
05/09/2024 16:00	3,437.4	547.4	3,437.4	104,400.0	358.9	0.50	0.2	0.8
05/09/2024 17:00	3,558.6	550.4	3,558.6	104,400.0	371.5	0.51	0.3	0.9
05/09/2024 18:00	3,458.9	551.0	3,458.9	104,400.0	361.1	0.50	0.3	0.8
05/09/2024 19:00	3,426.6	553.5	3,426.6	104,400.0	357.7	0.50	0.2	0.8
05/09/2024 20:00	3,428.1	557.2	3,428.1	104,400.0	357.9	0.50	0.2	0.8
05/09/2024 21:00	3,423.8	558.3	3,423.8	104,400.0	357.4	0.50	0.2	0.8
05/09/2024 22:00	3,435.0	560.5	3,435.0	104,400.0	358.6	0.50	0.3	0.8
05/09/2024 23:00	3,426.3	562.8	3,426.3	104,400.0	357.7	0.50	0.2	0.8
Average/Sum#:	3,455.3	557.6	3,455.3	104,400.0	360.7	0.50	0.3	0.8
Minimum:	3,423.8	546.0	3,423.8	104,400.0	357.4	0.50	0.2	0.8
Maximum:	3,558.6	571.2	3,558.6	104,400.0	371.5	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2024 00:00	3,480.0	563.6	3,480.0	104,400.0	363.3	0.51	0.3	0.8
05/10/2024 01:00	3,455.7	564.2	3,455.7	104,400.0	360.8	0.50	0.3	0.8
05/10/2024 02:00	3,453.3	566.4	3,453.3	104,400.0	360.5	0.50	0.3	0.8
05/10/2024 03:00	3,448.2	567.6	3,448.2	104,400.0	360.0	0.50	0.3	0.8
05/10/2024 04:00	3,452.1	568.6	3,452.1	104,400.0	360.4	0.50	0.3	0.8
05/10/2024 05:00	3,446.5	568.1	3,446.5	104,400.0	359.8	0.50	0.3	0.8
05/10/2024 06:00	3,461.3	563.5	3,461.3	104,400.0	361.4	0.50	0.3	0.8
05/10/2024 07:00	3,477.8	559.0	3,477.8	104,400.0	363.1	0.51	0.3	0.8
05/10/2024 08:00	3,476.9	553.4	3,476.9	104,400.0	363.0	0.51	0.3	0.8
05/10/2024 09:00	3,481.2	552.2	3,481.2	104,400.0	363.4	0.50	0.3	0.8
05/10/2024 10:00	3,518.0	548.4	3,518.0	104,400.0	367.3	0.51	0.3	0.8
05/10/2024 11:00	3,463.7	544.0	3,463.7	104,400.0	361.6	0.50	0.3	0.8
05/10/2024 12:00	3,461.7	544.4	3,461.7	104,400.0	361.4	0.50	0.3	0.8
05/10/2024 13:00	3,459.6	546.9	3,459.6	104,400.0	361.2	0.50	0.3	0.8
05/10/2024 14:00	3,609.1	545.5	3,609.1	104,400.0	376.8	0.52	0.3	0.9
05/10/2024 15:00	4,094.3	545.1	4,094.3	104,400.0	427.4	0.58	0.3	1.0
05/10/2024 16:00	3,501.2	544.3	3,501.2	104,400.0	365.5	0.51	0.3	0.8
05/10/2024 17:00	3,634.6	546.9	3,634.6	104,400.0	379.5	0.52	0.3	0.9
05/10/2024 18:00	4,069.5	547.9	4,069.5	104,400.0	424.9	0.58	0.3	1.0
05/10/2024 19:00	3,686.9	548.8	3,686.9	104,400.0	384.9	0.53	0.3	0.9
05/10/2024 20:00	3,496.7	552.0	3,496.7	104,400.0	365.1	0.51	0.3	0.8
05/10/2024 21:00	3,673.6	553.8	3,673.6	104,400.0	383.5	0.53	0.3	0.9
05/10/2024 22:00	3,897.5	555.8	3,897.5	104,400.0	406.9	0.56	0.3	0.9
05/10/2024 23:00	3,441.2	558.8	3,441.2	104,400.0	359.3	0.50	0.3	0.8
Average/Sum#:	3,568.4	554.6	3,568.4	104,400.0	372.5	0.52	0.3	0.8
Minimum:	3,441.2	544.0	3,441.2	104,400.0	359.3	0.50	0.3	0.8
Maximum:	4,094.3	568.6	4,094.3	104,400.0	427.4	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2024 00:00	3,447.3	559.2	3,447.3	104,400.0	359.9	0.50	0.3	0.8
05/11/2024 01:00	3,462.7	561.4	3,462.7	104,400.0	361.5	0.50	0.3	0.8
05/11/2024 02:00	3,473.3	561.5	3,473.3	104,400.0	362.6	0.51	0.3	0.8
05/11/2024 03:00	3,471.9	562.6	3,471.9	104,400.0	362.5	0.51	0.3	0.8
05/11/2024 04:00	3,469.2	564.3	3,469.2	104,400.0	362.2	0.50	0.3	0.8
05/11/2024 05:00	3,466.9	563.9	3,466.9	104,400.0	361.9	0.51	0.3	0.8
05/11/2024 06:00	3,468.4	559.8	3,468.4	104,400.0	362.1	0.50	0.3	0.8
05/11/2024 07:00	3,481.7	555.1	3,481.7	104,400.0	363.5	0.51	0.3	0.8
05/11/2024 08:00	3,485.7	552.5	3,485.7	104,400.0	363.9	0.51	0.3	0.8
05/11/2024 09:00	3,485.8	552.2	3,485.8	104,400.0	363.9	0.51	0.3	0.8
05/11/2024 10:00	3,466.9	547.2	3,466.9	104,400.0	361.9	0.50	0.3	0.8
05/11/2024 11:00	4,082.1	542.0	4,082.1	104,400.0	426.2	0.58	0.3	1.0
05/11/2024 12:00	3,486.2	540.5	3,486.2	104,400.0	364.0	0.50	0.3	0.8
05/11/2024 13:00	4,010.9	544.8	4,010.9	104,400.0	418.7	0.57	0.3	1.0
05/11/2024 14:00	4,051.1	542.8	4,051.1	104,400.0	422.9	0.58	0.3	1.0
05/11/2024 15:00	4,203.5	541.5	4,203.5	104,400.0	438.8	0.59	0.3	1.0
05/11/2024 16:00	3,587.0	541.4	3,587.0	104,400.0	374.5	0.52	0.3	0.9
05/11/2024 17:00	3,729.3	543.8	3,729.3	104,400.0	389.3	0.53	0.3	0.9
05/11/2024 18:00	3,816.1	545.9	3,816.1	104,400.0	398.4	0.55	0.3	0.9
05/11/2024 19:00	3,469.5	547.4	3,469.5	104,400.0	362.2	0.50	0.3	0.8
05/11/2024 20:00	4,197.1	548.8	4,197.1	104,400.0	438.2	0.59	0.3	1.0
05/11/2024 21:00	4,265.0	553.3	4,265.0	104,400.0	445.3	0.60	0.3	1.0
05/11/2024 22:00	4,257.9	555.2	4,257.9	104,400.0	444.5	0.60	0.3	1.0
05/11/2024 23:00	3,997.3	556.4	3,997.3	104,400.0	417.3	0.57	0.3	1.0
Average/Sum#:	3,722.2	551.8	3,722.2	104,400.0	388.6	0.54	0.3	0.9
Minimum:	3,447.3	540.5	3,447.3	104,400.0	359.9	0.50	0.3	0.8
Maximum:	4,265.0	564.3	4,265.0	104,400.0	445.3	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2024 00:00	3,556.8	557.9	3,556.8	104,400.0	371.3	0.52	0.3	0.9
05/12/2024 01:00	3,573.7	558.6	3,573.7	104,400.0	373.1	0.52	0.3	0.9
05/12/2024 02:00	3,470.9	560.1	3,470.9	104,400.0	362.4	0.51	0.3	0.8
05/12/2024 03:00	3,469.5	561.7	3,469.5	104,400.0	362.2	0.51	0.3	0.8
05/12/2024 04:00	3,471.3	563.3	3,471.3	104,400.0	362.4	0.51	0.3	0.8
05/12/2024 05:00	3,475.2	562.8	3,475.2	104,400.0	362.8	0.51	0.3	0.8
05/12/2024 06:00	3,484.0	558.8	3,484.0	104,400.0	363.7	0.51	0.3	0.8
05/12/2024 07:00	3,505.1	555.1	3,505.1	104,400.0	365.9	0.51	0.3	0.8
05/12/2024 08:00	3,498.1	552.8	3,498.1	104,400.0	365.2	0.51	0.3	0.8
05/12/2024 09:00	3,494.3	553.4	3,494.3	104,400.0	364.8	0.51	0.3	0.8
05/12/2024 10:00	3,485.9	548.9	3,485.9	104,400.0	363.9	0.51	0.3	0.8
05/12/2024 11:00	3,498.6	542.4	3,498.6	104,400.0	365.3	0.51	0.3	0.8
05/12/2024 12:00	3,505.7	542.5	3,505.7	104,400.0	366.0	0.51	0.3	0.8
05/12/2024 13:00	3,518.0	546.9	3,518.0	104,400.0	367.3	0.51	0.3	0.8
05/12/2024 14:00	3,515.4	544.9	3,515.4	104,400.0	367.0	0.51	0.3	0.8
05/12/2024 15:00	3,506.1	543.2	3,506.1	104,400.0	366.0	0.51	0.3	0.8
05/12/2024 16:00	3,504.5	541.7	3,504.5	104,400.0	365.9	0.51	0.3	0.8
05/12/2024 17:00	3,620.6	544.1	3,620.6	104,400.0	378.0	0.52	0.3	0.9
05/12/2024 18:00	3,485.3	546.2	3,485.3	104,400.0	363.9	0.50	0.3	0.8
05/12/2024 19:00	3,457.8	549.7	3,457.8	104,400.0	361.0	0.50	0.3	0.8
05/12/2024 20:00	3,457.3	552.8	3,457.3	104,400.0	360.9	0.50	0.3	0.8
05/12/2024 21:00	3,450.9	555.4	3,450.9	104,400.0	360.3	0.50	0.3	0.8
05/12/2024 22:00	3,448.3	557.1	3,448.3	104,400.0	360.0	0.50	0.3	0.8
05/12/2024 23:00	3,463.3	557.7	3,463.3	104,400.0	361.6	0.50	0.3	0.8
Average/Sum#:	3,496.5	552.4	3,496.5	104,400.0	365.0	0.51	0.3	0.8
Minimum:	3,448.3	541.7	3,448.3	104,400.0	360.0	0.50	0.3	0.8
Maximum:	3,620.6	563.3	3,620.6	104,400.0	378.0	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2024 00:00	3,468.3	559.5	3,468.3	104,400.0	362.1	0.50	0.3	0.8
05/13/2024 01:00	3,462.2	561.1	3,462.2	104,400.0	361.5	0.50	0.3	0.8
05/13/2024 02:00	3,460.9	562.3	3,460.9	104,400.0	361.3	0.50	0.3	0.8
05/13/2024 03:00	3,456.0	563.5	3,456.0	104,400.0	360.8	0.50	0.3	0.8
05/13/2024 04:00	3,455.9	565.3	3,455.9	104,400.0	360.8	0.50	0.3	0.8
05/13/2024 05:00	3,507.8	564.9	3,507.8	104,400.0	366.2	0.51	0.3	0.9
05/13/2024 06:00	3,461.6	561.0	3,461.6	104,400.0	361.4	0.50	0.3	0.8
05/13/2024 07:00	3,470.8	556.8	3,470.8	104,400.0	362.4	0.50	0.3	0.8
05/13/2024 08:00	3,468.1	554.1	3,468.1	104,400.0	362.1	0.50	0.3	0.8
05/13/2024 09:00	3,473.1	553.8	3,473.1	104,400.0	362.6	0.50	0.3	0.8
05/13/2024 10:00	3,460.4	548.5	3,460.4	104,400.0	361.3	0.50	0.3	0.8
05/13/2024 11:00	3,464.2	542.4	3,464.2	104,400.0	361.7	0.50	0.3	0.8
05/13/2024 12:00	3,485.7	543.7	3,485.7	104,400.0	363.9	0.50	0.3	0.8
05/13/2024 13:00	3,489.6	546.9	3,489.6	104,400.0	364.3	0.51	0.3	0.8
05/13/2024 14:00	3,487.4	546.6	3,487.4	104,400.0	364.1	0.51	0.3	0.8
05/13/2024 15:00	3,483.2	544.8	3,483.2	104,400.0	363.6	0.50	0.3	0.8
05/13/2024 16:00	3,535.2	544.4	3,535.2	104,400.0	369.1	0.51	0.3	0.9
05/13/2024 17:00	3,998.3	545.7	3,998.3	104,400.0	417.4	0.57	0.3	0.9
05/13/2024 18:00	3,986.9	548.2	3,986.9	104,400.0	416.2	0.57	0.3	0.9
05/13/2024 19:00	3,875.8	552.3	3,875.8	104,400.0	404.6	0.55	0.3	0.9
05/13/2024 20:00	3,449.1	555.7	3,449.1	104,400.0	360.1	0.50	0.3	0.8
05/13/2024 21:00	3,470.5	557.3	3,470.5	104,400.0	362.3	0.50	0.3	0.8
05/13/2024 22:00	3,481.5	557.5	3,481.5	104,400.0	363.5	0.51	0.3	0.8
05/13/2024 23:00	3,485.6	559.3	3,485.6	104,400.0	363.9	0.51	0.3	0.8
Average/Sum#:	3,534.9	554.0	3,534.9	104,400.0	369.1	0.51	0.3	0.8
Minimum:	3,449.1	542.4	3,449.1	104,400.0	360.1	0.50	0.3	0.8
Maximum:	3,998.3	565.3	3,998.3	104,400.0	417.4	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2024 00:00	3,485.1	560.3	3,485.1	104,400.0	363.8	0.51	0.3	0.8
05/14/2024 01:00	3,470.2	562.0	3,470.2	104,400.0	362.3	0.50	0.3	0.8
05/14/2024 02:00	3,468.4	563.4	3,468.4	104,400.0	362.1	0.51	0.3	0.8
05/14/2024 03:00	3,463.6	565.0	3,463.6	104,400.0	361.6	0.50	0.3	0.8
05/14/2024 04:00	3,465.6	566.4	3,465.6	104,400.0	361.8	0.51	0.3	0.8
05/14/2024 05:00	3,463.7	565.7	3,463.7	104,400.0	361.6	0.50	0.3	0.8
05/14/2024 06:00	3,480.1	561.2	3,480.1	104,400.0	363.3	0.51	0.3	0.8
05/14/2024 07:00	3,495.8	557.9	3,495.8	104,400.0	365.0	0.51	0.3	0.8
05/14/2024 08:00	3,494.8	552.7	3,494.8	104,400.0	364.9	0.51	0.3	0.8
05/14/2024 09:00	3,503.8	552.8	3,503.8	104,400.0	365.8	0.51	0.3	0.8
05/14/2024 10:00	3,503.0	548.3	3,503.0	104,400.0	365.7	0.51	0.3	0.8
05/14/2024 11:00	3,491.7	542.1	3,491.7	104,400.0	364.5	0.51	0.3	0.8
05/14/2024 12:00	3,509.2	542.0	3,509.2	104,400.0	366.4	0.51	0.3	0.8
05/14/2024 13:00	3,509.6	546.8	3,509.6	104,400.0	366.4	0.51	0.3	0.8
05/14/2024 14:00	3,512.5	546.7	3,512.5	104,400.0	366.7	0.51	0.3	0.8
05/14/2024 15:00	3,492.9	545.4	3,492.9	104,400.0	364.7	0.51	0.3	0.8
05/14/2024 16:00	3,733.9	544.6	3,733.9	104,400.0	389.8	0.54	0.3	0.9
05/14/2024 17:00	3,869.5	545.7	3,869.5	104,400.0	404.0	0.55	0.3	0.9
05/14/2024 18:00	3,454.0	547.5	3,454.0	104,400.0	360.6	0.50	0.3	0.8
05/14/2024 19:00	3,444.4	550.6	3,444.4	104,400.0	359.6	0.50	0.3	0.8
05/14/2024 20:00	3,465.7	553.1	3,465.7	104,400.0	361.8	0.50	0.3	0.8
05/14/2024 21:00	3,455.2	554.9	3,455.2	104,400.0	360.7	0.50	0.3	0.8
05/14/2024 22:00	3,444.4	556.4	3,444.4	104,400.0	359.6	0.50	0.3	0.8
05/14/2024 23:00	3,440.7	558.3	3,440.7	104,400.0	359.2	0.50	0.3	0.8
Average/Sum#:	3,504.9	553.7	3,504.9	104,400.0	365.9	0.51	0.3	0.8
Minimum:	3,440.7	542.0	3,440.7	104,400.0	359.2	0.50	0.3	0.8
Maximum:	3,869.5	566.4	3,869.5	104,400.0	404.0	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2024 00:00	3,441.0	559.2	3,441.0	104,400.0	359.2	0.50	0.3	0.8
05/15/2024 01:00	3,436.1	560.9	3,436.1	104,400.0	358.7	0.50	0.3	0.8
05/15/2024 02:00	3,444.8	562.4	3,444.8	104,400.0	359.6	0.50	0.3	0.8
05/15/2024 03:00	3,468.4	563.6	3,468.4	104,400.0	362.1	0.51	0.3	0.8
05/15/2024 04:00	3,470.3	564.8	3,470.3	104,400.0	362.3	0.51	0.3	0.8
05/15/2024 05:00	3,465.4	564.3	3,465.4	104,400.0	361.8	0.50	0.3	0.8
05/15/2024 06:00	3,477.1	559.5	3,477.1	104,400.0	363.0	0.51	0.3	0.8
05/15/2024 07:00	3,470.5	555.9	3,470.5	104,400.0	362.3	0.50	0.3	0.8
05/15/2024 08:00	3,474.2	552.2	3,474.2	104,400.0	362.7	0.50	0.3	0.8
05/15/2024 09:00	3,469.0	552.1	3,469.0	104,400.0	362.2	0.50	0.3	0.8
05/15/2024 10:00	3,460.4	547.3	3,460.4	104,400.0	361.3	0.50	0.3	0.8
05/15/2024 11:00	3,480.4	543.7	3,480.4	104,400.0	363.4	0.50	0.3	0.8
05/15/2024 12:00	3,492.4	542.6	3,492.4	104,400.0	364.6	0.51	0.3	0.8
05/15/2024 13:00	3,494.3	546.3	3,494.3	104,400.0	364.8	0.51	0.3	0.8
05/15/2024 14:00	3,500.2	543.8	3,500.2	104,400.0	365.4	0.51	0.3	0.8
05/15/2024 15:00	3,492.3	541.7	3,492.3	104,400.0	364.6	0.51	0.3	0.8
05/15/2024 16:00	3,477.9	540.1	3,477.9	104,400.0	363.1	0.50	0.3	0.8
05/15/2024 17:00	3,630.7	543.3	3,630.7	104,400.0	379.0	0.52	0.3	0.9
05/15/2024 18:00	3,798.9	546.7	3,798.9	104,400.0	396.6	0.54	0.3	0.9
05/15/2024 19:00	3,587.3	549.5	3,587.3	104,400.0	374.5	0.52	0.3	0.9
05/15/2024 20:00	3,608.7	552.1	3,608.7	104,400.0	376.7	0.52	0.3	0.9
05/15/2024 21:00	3,484.9	554.7	3,484.9	104,400.0	363.8	0.51	0.3	0.8
05/15/2024 22:00	4,272.9	557.3	4,272.9	104,400.0	446.1	0.61	0.3	1.0
05/15/2024 23:00	3,492.6	559.4	3,492.6	104,400.0	364.6	0.51	0.3	0.8
Average/Sum#:	3,537.1	552.6	3,537.1	104,400.0	369.3	0.51	0.3	0.8
Minimum:	3,436.1	540.1	3,436.1	104,400.0	358.7	0.50	0.3	0.8
Maximum:	4,272.9	564.8	4,272.9	104,400.0	446.1	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2024 00:00	3,470.0	561.2	3,470.0	104,400.0	362.3	0.51	0.3	0.8
05/16/2024 01:00	3,467.4	563.1	3,467.4	104,400.0	362.0	0.50	0.3	0.8
05/16/2024 02:00	3,465.6	564.5	3,465.6	104,400.0	361.8	0.50	0.3	0.8
05/16/2024 03:00	3,921.1	566.1	3,921.1	104,400.0	409.4	0.56	0.3	0.9
05/16/2024 04:00	4,254.2	565.1	4,254.2	104,400.0	444.1	0.60	0.3	1.0
05/16/2024 05:00	3,864.7	563.8	3,864.7	104,400.0	403.5	0.56	0.3	0.9
05/16/2024 06:00	3,501.3	559.5	3,501.3	104,400.0	365.5	0.51	0.3	0.8
05/16/2024 07:00	3,463.9	556.4	3,463.9	104,400.0	361.6	0.50	0.3	0.8
05/16/2024 08:00	3,456.7	554.7	3,456.7	104,400.0	360.9	0.50	0.3	0.8
05/16/2024 09:00	3,466.3	556.4	3,466.3	104,400.0	361.9	0.50	0.3	0.8
05/16/2024 10:00	3,483.5	551.4	3,483.5	104,400.0	363.7	0.51	0.3	0.8
05/16/2024 11:00	3,506.5	547.1	3,506.5	104,400.0	366.1	0.51	0.3	0.8
05/16/2024 12:00	3,519.1	546.4	3,519.1	104,400.0	367.4	0.51	0.3	0.8
05/16/2024 13:00	3,534.5	550.5	3,534.5	104,400.0	369.0	0.51	0.3	0.9
05/16/2024 14:00	3,538.4	550.0	3,538.4	104,400.0	369.4	0.51	0.3	0.9
05/16/2024 15:00	3,534.0	548.7	3,534.0	104,400.0	368.9	0.51	0.3	0.9
05/16/2024 16:00	3,576.2	548.6	3,576.2	104,400.0	373.4	0.52	0.3	0.9
05/16/2024 17:00	4,157.1	552.8	4,157.1	104,400.0	434.0	0.59	0.3	1.0
05/16/2024 18:00	4,110.2	554.6	4,110.2	104,400.0	429.1	0.58	0.3	1.0
05/16/2024 19:00	4,323.5	557.0	4,323.5	104,400.0	451.4	0.61	0.3	1.0
05/16/2024 20:00	3,658.8	559.5	3,658.8	104,400.0	382.0	0.53	0.3	0.9
05/16/2024 21:00	4,262.4	561.9	4,262.4	104,400.0	445.0	0.60	0.3	1.0
05/16/2024 22:00	4,194.7	563.9	4,194.7	104,400.0	437.9	0.60	0.3	1.0
05/16/2024 23:00	4,266.1	564.8	4,266.1	104,400.0	445.4	0.61	0.3	1.0
Average/Sum#:	3,749.8	557.0	3,749.8	104,400.0	391.5	0.54	0.3	0.9
Minimum:	3,456.7	546.4	3,456.7	104,400.0	360.9	0.50	0.3	0.8
Maximum:	4,323.5	566.1	4,323.5	104,400.0	451.4	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2024 00:00	4,273.6	567.2	4,273.6	104,400.0	446.2	0.61	0.3	1.0
05/17/2024 01:00	3,885.4	567.8	3,885.4	104,400.0	405.6	0.56	0.3	0.9
05/17/2024 02:00	4,114.9	566.8	4,114.9	104,400.0	429.6	0.59	0.3	1.0
05/17/2024 03:00	3,549.7	566.6	3,549.7	104,400.0	370.6	0.52	0.3	0.9
05/17/2024 04:00	3,577.7	567.3	3,577.7	104,400.0	373.5	0.52	0.3	0.9
05/17/2024 05:00	3,484.5	567.4	3,484.5	104,400.0	363.8	0.51	0.3	0.8
05/17/2024 06:00	3,490.8	566.7	3,490.8	104,400.0	364.4	0.51	0.3	0.8
05/17/2024 07:00	3,488.4	562.7	3,488.4	104,400.0	364.2	0.51	0.3	0.8
05/17/2024 08:00	3,492.9	558.5	3,492.9	104,400.0	364.7	0.51	0.3	0.8
05/17/2024 09:00	3,503.0	558.9	3,503.0	104,400.0	365.7	0.51	0.3	0.8
05/17/2024 10:00	3,514.4	553.7	3,514.4	104,400.0	366.9	0.51	0.3	0.8
05/17/2024 11:00	3,537.3	547.9	3,537.3	104,400.0	369.3	0.51	0.3	0.9
05/17/2024 12:00	3,544.5	546.5	3,544.5	104,400.0	370.0	0.51	0.3	0.9
05/17/2024 13:00	3,533.7	552.1	3,533.7	104,400.0	368.9	0.51	0.3	0.9
05/17/2024 14:00	3,529.3	549.8	3,529.3	104,400.0	368.5	0.51	0.3	0.9
05/17/2024 15:00	3,523.4	548.1	3,523.4	104,400.0	367.8	0.51	0.3	0.9
05/17/2024 16:00	3,531.0	545.8	3,531.0	104,400.0	368.6	0.51	0.3	0.9
05/17/2024 17:00	3,499.6	547.5	3,499.6	104,400.0	365.4	0.51	0.3	0.8
05/17/2024 18:00	3,487.0	549.1	3,487.0	104,400.0	364.0	0.51	0.3	0.8
05/17/2024 19:00	3,484.9	553.2	3,484.9	104,400.0	363.8	0.51	0.3	0.8
05/17/2024 20:00	3,476.5	556.5	3,476.5	104,400.0	362.9	0.51	0.3	0.8
05/17/2024 21:00	3,472.0	558.6	3,472.0	104,400.0	362.5	0.50	0.3	0.8
05/17/2024 22:00	3,468.7	560.6	3,468.7	104,400.0	362.1	0.50	0.3	0.8
05/17/2024 23:00	3,474.2	562.2	3,474.2	104,400.0	362.7	0.51	0.3	0.8
Average/Sum#:	3,580.7	557.6	3,580.7	104,400.0	373.8	0.52	0.3	0.9
Minimum:	3,468.7	545.8	3,468.7	104,400.0	362.1	0.50	0.3	0.8
Maximum:	4,273.6	567.8	4,273.6	104,400.0	446.2	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2024 00:00	3,488.0	563.0	3,488.0	104,400.0	364.1	0.51	0.3	0.8
05/18/2024 01:00	3,488.2	564.0	3,488.2	104,400.0	364.2	0.51	0.3	0.8
05/18/2024 02:00	3,484.3	565.1	3,484.3	104,400.0	363.8	0.51	0.3	0.8
05/18/2024 03:00	3,483.1	566.5	3,483.1	104,400.0	363.6	0.51	0.3	0.8
05/18/2024 04:00	3,477.3	568.9	3,477.3	104,400.0	363.0	0.51	0.3	0.8
05/18/2024 05:00	3,475.6	568.2	3,475.6	104,400.0	362.9	0.51	0.3	0.8
05/18/2024 06:00	3,478.3	564.0	3,478.3	104,400.0	363.1	0.51	0.3	0.8
05/18/2024 07:00	3,484.2	559.6	3,484.2	104,400.0	363.8	0.51	0.3	0.8
05/18/2024 08:00	3,486.5	556.9	3,486.5	104,400.0	364.0	0.51	0.3	0.8
05/18/2024 09:00	3,499.5	557.2	3,499.5	104,400.0	365.3	0.51	0.3	0.8
05/18/2024 10:00	3,515.8	552.2	3,515.8	104,400.0	367.0	0.51	0.3	0.8
05/18/2024 11:00	3,508.5	547.9	3,508.5	104,400.0	366.3	0.51	0.3	0.8
05/18/2024 12:00	3,509.6	547.4	3,509.6	104,400.0	366.4	0.51	0.3	0.8
05/18/2024 13:00	3,510.4	550.9	3,510.4	104,400.0	366.5	0.51	0.3	0.8
05/18/2024 14:00	3,527.1	549.1	3,527.1	104,400.0	368.2	0.51	0.3	0.9
05/18/2024 15:00	3,507.4	547.9	3,507.4	104,400.0	366.2	0.51	0.3	0.8
05/18/2024 16:00	3,506.9	547.9	3,506.9	104,400.0	366.1	0.51	0.3	0.8
05/18/2024 17:00	3,503.4	552.6	3,503.4	104,400.0	365.8	0.51	0.3	0.8
05/18/2024 18:00	3,487.5	555.4	3,487.5	104,400.0	364.1	0.51	0.3	0.8
05/18/2024 19:00	3,470.9	558.8	3,470.9	104,400.0	362.4	0.50	0.3	0.8
05/18/2024 20:00	3,471.4	561.8	3,471.4	104,400.0	362.4	0.51	0.3	0.8
05/18/2024 21:00	3,489.8	564.1	3,489.8	104,400.0	364.3	0.51	0.3	0.8
05/18/2024 22:00	3,496.3	566.0	3,496.3	104,400.0	365.0	0.51	0.3	0.8
05/18/2024 23:00	3,495.3	567.7	3,495.3	104,400.0	364.9	0.51	0.3	0.8
Average/Sum#:	3,493.6	558.5	3,493.6	104,400.0	364.7	0.51	0.3	0.8
Minimum:	3,470.9	547.4	3,470.9	104,400.0	362.4	0.50	0.3	0.8
Maximum:	3,527.1	568.9	3,527.1	104,400.0	368.2	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2024 00:00	3,487.6	568.6	3,487.6	104,400.0	364.1	0.51	0.3	0.8
05/19/2024 01:00	3,478.0	569.2	3,478.0	104,400.0	363.1	0.51	0.3	0.8
05/19/2024 02:00	3,497.9	569.5	3,497.9	104,400.0	365.2	0.51	0.3	0.8
05/19/2024 03:00	3,495.9	569.1	3,495.9	104,400.0	365.0	0.51	0.3	0.8
05/19/2024 04:00	3,491.8	568.1	3,491.8	104,400.0	364.5	0.51	0.3	0.8
05/19/2024 05:00	3,500.2	567.7	3,500.2	104,400.0	365.4	0.51	0.3	0.8
05/19/2024 06:00	3,504.2	565.1	3,504.2	104,400.0	365.8	0.51	0.3	0.9
05/19/2024 07:00	3,517.6	562.0	3,517.6	104,400.0	367.2	0.51	0.3	0.9
05/19/2024 08:00	3,508.5	558.1	3,508.5	104,400.0	366.3	0.51	0.3	0.8
05/19/2024 09:00	3,499.6	557.6	3,499.6	104,400.0	365.4	0.51	0.3	0.8
05/19/2024 10:00	3,510.1	553.1	3,510.1	104,400.0	366.5	0.51	0.3	0.8
05/19/2024 11:00	3,512.6	549.2	3,512.6	104,400.0	366.7	0.51	0.3	0.8
05/19/2024 12:00	3,511.2	547.3	3,511.2	104,400.0	366.6	0.51	0.3	0.8
05/19/2024 13:00	3,518.9	551.9	3,518.9	104,400.0	367.4	0.51	0.3	0.8
05/19/2024 14:00	3,515.1	550.3	3,515.1	104,400.0	367.0	0.51	0.3	0.8
05/19/2024 15:00	3,511.2	549.1	3,511.2	104,400.0	366.6	0.51	0.3	0.8
05/19/2024 16:00	3,488.9	547.6	3,488.9	104,400.0	364.2	0.51	0.3	0.8
05/19/2024 17:00	3,465.4	549.8	3,465.4	104,400.0	361.8	0.50	0.3	0.8
05/19/2024 18:00	3,449.1	552.2	3,449.1	104,400.0	360.1	0.50	0.3	0.8
05/19/2024 19:00	3,440.1	554.4	3,440.1	104,400.0	359.1	0.50	0.3	0.8
05/19/2024 20:00	3,470.1	558.7	3,470.1	104,400.0	362.3	0.51	0.3	0.8
05/19/2024 21:00	3,468.1	560.6	3,468.1	104,400.0	362.1	0.50	0.3	0.8
05/19/2024 22:00	3,445.6	562.7	3,445.6	104,400.0	359.7	0.50	0.3	0.8
05/19/2024 23:00	3,434.0	564.0	3,434.0	104,400.0	358.5	0.50	0.3	0.8
Average/Sum#:	3,488.4	558.6	3,488.4	104,400.0	364.2	0.51	0.3	0.8
Minimum:	3,434.0	547.3	3,434.0	104,400.0	358.5	0.50	0.3	0.8
Maximum:	3,518.9	569.5	3,518.9	104,400.0	367.4	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2024 00:00	3,433.1	565.2	3,433.1	104,400.0	358.4	0.50	0.3	0.8
05/20/2024 01:00	3,439.9	567.0	3,439.9	104,400.0	359.1	0.50	0.3	0.8
05/20/2024 02:00	3,442.6	568.1	3,442.6	104,400.0	359.4	0.50	0.3	0.8
05/20/2024 03:00	3,422.1	569.9	3,422.1	104,400.0	357.3	0.50	0.3	0.8
05/20/2024 04:00	3,410.6	572.0	3,410.6	104,400.0	356.1	0.50	0.2	0.8
05/20/2024 05:00	3,436.0	571.0	3,436.0	104,400.0	358.7	0.50	0.3	0.8
05/20/2024 06:00	3,440.3	564.6	3,440.3	104,400.0	359.2	0.50	0.3	0.8
05/20/2024 07:00	3,450.7	559.8	3,450.7	104,400.0	360.3	0.50	0.3	0.8
05/20/2024 08:00	3,443.9	557.8	3,443.9	104,400.0	359.5	0.50	0.3	0.8
05/20/2024 09:00	3,434.6	556.9	3,434.6	104,400.0	358.6	0.50	0.3	0.8
05/20/2024 10:00	3,451.2	552.4	3,451.2	104,400.0	360.3	0.50	0.3	0.8
05/20/2024 11:00	3,473.1	549.5	3,473.1	104,400.0	362.6	0.50	0.3	0.8
05/20/2024 12:00	3,480.9	550.0	3,480.9	104,400.0	363.4	0.51	0.3	0.8
05/20/2024 13:00	3,472.6	552.4	3,472.6	104,400.0	362.5	0.50	0.3	0.8
05/20/2024 14:00	3,464.0	550.6	3,464.0	104,400.0	361.6	0.50	0.3	0.8
05/20/2024 15:00	3,456.8	550.1	3,456.8	104,400.0	360.9	0.50	0.3	0.8
05/20/2024 16:00	3,459.8	548.6	3,459.8	104,400.0	361.2	0.50	0.3	0.8
05/20/2024 17:00	3,516.4	553.6	3,516.4	104,400.0	367.1	0.51	0.3	0.8
05/20/2024 18:00	3,922.9	554.9	3,922.9	104,400.0	409.6	0.56	0.3	0.9
05/20/2024 19:00	4,104.0	556.1	4,104.0	104,400.0	428.5	0.58	0.3	1.0
05/20/2024 20:00	3,924.3	557.5	3,924.3	104,400.0	409.7	0.56	0.3	0.9
05/20/2024 21:00	3,823.3	558.8	3,823.3	104,400.0	399.2	0.55	0.3	0.9
05/20/2024 22:00	3,911.1	560.6	3,911.1	104,400.0	408.3	0.56	0.3	0.9
05/20/2024 23:00	3,403.5	563.6	3,403.5	104,400.0	355.3	0.50	0.2	0.8
Average/Sum#:	3,550.7	558.8	3,550.7	104,400.0	370.7	0.51	0.3	0.8
Minimum:	3,403.5	548.6	3,403.5	104,400.0	355.3	0.50	0.2	0.8
Maximum:	4,104.0	572.0	4,104.0	104,400.0	428.5	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2024 00:00	3,371.9	565.4	3,371.9	104,400.0	352.0	0.49	0.2	0.8
05/21/2024 01:00	3,384.6	568.2	3,384.6	104,400.0	353.4	0.50	0.2	0.8
05/21/2024 02:00	3,397.9	568.7	3,397.9	104,400.0	354.7	0.50	0.2	0.8
05/21/2024 03:00	3,397.4	570.6	3,397.4	104,400.0	354.7	0.50	0.2	0.8
05/21/2024 04:00	3,395.4	572.6	3,395.4	104,400.0	354.5	0.50	0.2	0.8
05/21/2024 05:00	3,423.9	571.1	3,423.9	104,400.0	357.5	0.50	0.3	0.8
05/21/2024 06:00	4,175.2	600.3	4,517.4	104,400.0	471.6	0.60	0.3	1.0
05/21/2024 07:00	4,467.0	1,372.7	5,839.7	104,400.0	609.7	0.73	0.4	1.2
05/21/2024 08:00	4,439.1	1,387.8	5,826.9	104,400.0	608.3	0.73	0.4	1.2
05/21/2024 09:00	4,423.4	1,387.7	5,811.1	104,400.0	606.7	0.73	0.4	1.2
05/21/2024 10:00	4,424.9	1,382.4	5,807.3	104,400.0	606.3	0.73	0.4	1.2
05/21/2024 11:00	4,429.0	1,418.3	5,847.3	104,400.0	610.5	0.73	0.4	1.2
05/21/2024 12:00	4,416.3	1,545.7	5,962.0	104,400.0	622.4	0.75	0.4	1.2
05/21/2024 13:00	4,411.5	1,558.4	5,969.9	104,400.0	623.3	0.75	0.4	1.2
05/21/2024 14:00	4,408.4	1,561.0	5,969.4	104,400.0	623.2	0.75	0.4	1.2
05/21/2024 15:00	4,390.4	1,567.2	5,957.6	104,400.0	622.0	0.75	0.4	1.2
05/21/2024 16:00	4,393.9	1,562.1	5,956.0	104,400.0	621.8	0.75	0.4	1.2
05/21/2024 17:00	4,395.6	1,555.9	5,951.5	104,400.0	621.3	0.75	0.4	1.2
05/21/2024 18:00	4,384.0	1,535.2	5,919.2	104,400.0	618.0	0.74	0.4	1.2
05/21/2024 19:00	4,384.3	1,490.6	5,874.9	104,400.0	613.3	0.74	0.4	1.2
05/21/2024 20:00	4,393.3	676.6	5,069.9	104,400.0	529.3	0.64	0.3	1.1
05/21/2024 21:00	4,190.7	576.1	4,467.2	104,400.0	466.4	0.60	0.3	1.0
05/21/2024 22:00	3,482.8	563.1	3,482.8	104,400.0	363.6	0.51	0.3	0.8
05/21/2024 23:00	3,449.0	561.9	3,449.0	104,400.0	360.1	0.50	0.3	0.8
Average/Sum#:	4,059.6	1,071.7	4,918.8	104,400.0	513.5	0.64	0.3	1.0
Minimum:	3,371.9	561.9	3,371.9	104,400.0	352.0	0.49	0.2	0.8
Maximum:	4,467.0	1,567.2	5,969.9	104,400.0	623.3	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2024 00:00	3,435.4	562.3	3,435.4	104,400.0	358.7	0.50	0.3	0.8
05/22/2024 01:00	3,477.1	563.2	3,477.1	104,400.0	363.0	0.51	0.3	0.8
05/22/2024 02:00	3,433.8	565.5	3,433.8	104,400.0	358.5	0.50	0.3	0.8
05/22/2024 03:00	3,709.8	565.4	3,709.8	104,400.0	387.3	0.54	0.3	0.9
05/22/2024 04:00	3,802.8	595.7	3,951.7	104,400.0	412.6	0.55	0.3	0.9
05/22/2024 05:00	4,433.0	1,525.0	5,958.0	104,400.0	622.0	0.75	0.4	1.2
05/22/2024 06:00	4,477.6	1,478.5	5,956.1	104,400.0	621.8	0.75	0.4	1.2
05/22/2024 07:00	4,467.7	1,515.9	5,983.6	104,400.0	624.7	0.75	0.4	1.2
05/22/2024 08:00	4,437.6	1,522.5	5,960.1	104,400.0	622.2	0.75	0.4	1.2
05/22/2024 09:00	4,419.2	1,557.7	5,976.9	104,400.0	624.0	0.75	0.4	1.2
05/22/2024 10:00	4,424.5	1,574.7	5,999.2	104,400.0	626.3	0.75	0.4	1.3
05/22/2024 11:00	4,413.7	1,609.0	6,022.7	104,400.0	628.8	0.75	0.4	1.3
05/22/2024 12:00	4,391.1	1,655.6	6,046.7	104,400.0	631.3	0.76	0.4	1.3
05/22/2024 13:00	4,384.0	1,661.0	6,045.0	104,400.0	631.1	0.76	0.4	1.3
05/22/2024 14:00	4,386.2	1,648.7	6,034.9	104,400.0	630.0	0.76	0.4	1.3
05/22/2024 15:00	4,371.4	1,611.2	5,982.6	104,400.0	624.6	0.75	0.4	1.2
05/22/2024 16:00	4,289.7	646.1	4,858.3	104,400.0	507.2	0.62	0.3	1.0
05/22/2024 17:00	4,047.9	955.8	4,544.9	104,400.0	474.5	0.63	0.3	1.0
05/22/2024 18:00	4,364.6	1,613.8	5,978.4	104,400.0	624.1	0.75	0.4	1.2
05/22/2024 19:00	4,383.2	1,551.2	5,934.4	104,400.0	619.6	0.74	0.4	1.2
05/22/2024 20:00	4,399.6	1,511.5	5,911.1	104,400.0	617.1	0.74	0.4	1.2
05/22/2024 21:00	4,398.9	1,488.9	5,887.8	104,400.0	614.7	0.74	0.4	1.2
05/22/2024 22:00	4,314.5	674.9	4,908.4	104,400.0	512.4	0.63	0.3	1.0
05/22/2024 23:00	3,424.9	567.2	3,424.9	104,400.0	357.6	0.50	0.3	0.8
Average/Sum#:	4,170.3	1,217.6	5,225.9	104,400.0	545.6	0.68	0.4	1.1
Minimum:	3,424.9	562.3	3,424.9	104,400.0	357.6	0.50	0.3	0.8
Maximum:	4,477.6	1,661.0	6,046.7	104,400.0	631.3	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2024 00:00	3,435.5	566.3	3,435.5	104,400.0	358.7	0.50	0.3	0.8
05/23/2024 01:00	3,429.2	567.1	3,429.2	104,400.0	358.0	0.50	0.3	0.8
05/23/2024 02:00	3,425.0	568.7	3,425.0	104,400.0	357.6	0.50	0.3	0.8
05/23/2024 03:00	3,423.8	567.8	3,423.8	104,400.0	357.4	0.50	0.3	0.8
05/23/2024 04:00	3,415.8	565.0	3,415.8	104,400.0	356.6	0.50	0.2	0.8
05/23/2024 05:00	3,462.2	564.5	3,462.2	104,400.0	361.5	0.50	0.3	0.8
05/23/2024 06:00	3,432.7	562.1	3,432.7	104,400.0	358.4	0.50	0.3	0.8
05/23/2024 07:00	3,783.8	597.1	3,921.1	104,400.0	409.4	0.55	0.3	0.9
05/23/2024 08:00	4,352.1	1,624.3	5,976.4	104,400.0	623.9	0.75	0.4	1.2
05/23/2024 09:00	4,323.5	1,669.5	5,993.0	104,400.0	625.7	0.75	0.4	1.3
05/23/2024 10:00	4,283.3	1,740.6	6,023.9	104,400.0	628.9	0.76	0.4	1.3
05/23/2024 11:00	4,250.5	923.6	5,127.9	104,400.0	535.4	0.65	0.3	1.1
05/23/2024 12:00	2,659.6	563.4	2,659.6	104,400.0	277.7	0.50	0.3	0.8
05/23/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/23/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,667.5	852.3	4,132.8	104,400.0	431.5	0.57	0.3	0.9
Minimum:	2,659.6	562.1	2,659.6	104,400.0	277.7	0.50	0.2	0.8
Maximum:	4,352.1	1,740.6	6,023.9	104,400.0	628.9	0.76	0.4	1.3
%SI	45.83	45.83	45.83	0.00	45.83	45.83	45.83	45.83

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/24/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/24/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/25/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/26/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/26/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/27/2024 16:00	435.6	544.2	435.6	104,400.0	45.5	0.00	0.0	0.0
05/27/2024 17:00	2,987.3	549.7	2,987.3	104,400.0	311.9	0.00	0.0	0.0
05/27/2024 18:00	4,307.9	1,039.2	5,170.4	104,400.0	539.8	0.69	0.3	1.1
05/27/2024 19:00	4,348.7	1,458.0	5,806.7	104,400.0	606.2	0.73	0.4	1.2
05/27/2024 20:00	4,363.7	779.0	5,142.7	104,400.0	536.9	0.64	0.3	1.1
05/27/2024 21:00	4,378.8	596.3	4,975.1	104,400.0	519.4	0.62	0.3	1.0
05/27/2024 22:00	3,728.8	566.3	3,745.8	104,400.0	391.1	0.54	0.3	0.9
05/27/2024 23:00	3,555.9	566.1	3,555.9	104,400.0	371.2	0.57	0.3	0.9
Average/Sum#:	3,513.3	762.4	3,977.4	104,400.0	415.3	0.63	0.3	1.0
Minimum:	435.6	544.2	435.6	104,400.0	45.5	0.54	0.3	0.9
Maximum:	4,378.8	1,458.0	5,806.7	104,400.0	606.2	0.73	0.4	1.2
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/28/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/28/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/29/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/29/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/30/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/30/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
05/31/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
05/31/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/01/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/01/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/02/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 14:00	3,015.9	549.6	3,015.9	104,400.0	314.9	0.00	0.0	0.0
06/02/2024 15:00	4,352.7	1,071.2	5,316.8	104,400.0	555.1	0.69	0.3	1.2
06/02/2024 16:00	4,359.3	1,377.1	5,736.4	104,400.0	598.9	0.72	0.4	1.2
06/02/2024 17:00	3,919.9	574.8	4,178.6	104,400.0	436.2	0.56	0.3	0.9
06/02/2024 18:00	3,431.5	553.1	3,431.5	104,400.0	358.2	0.50	0.2	0.8
06/02/2024 19:00	2,851.8	551.5	2,851.8	104,400.0	297.7	0.50	0.2	0.8
06/02/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/02/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,655.2	779.6	4,088.5	104,400.0	426.8	0.59	0.3	1.0
Minimum:	2,851.8	549.6	2,851.8	104,400.0	297.7	0.50	0.2	0.8
Maximum:	4,359.3	1,377.1	5,736.4	104,400.0	598.9	0.72	0.4	1.2
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/03/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/03/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
06/04/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/04/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 11:00	916.5	541.1	916.5	104,800.0	96.0	0.00	0.0	0.0
06/05/2024 12:00	3,542.1	586.0	3,630.0	104,800.0	380.4	0.64	0.3	1.1
06/05/2024 13:00	4,186.2	795.9	4,982.1	104,800.0	522.1	0.63	0.3	1.0
06/05/2024 14:00	3,934.8	411.6	4,132.4	104,800.0	433.1	0.55	0.3	0.9
06/05/2024 15:00	4,171.4	652.6	4,824.0	104,800.0	505.6	0.61	0.3	1.0
06/05/2024 16:00	3,567.5	90.0	3,573.8	104,800.0	374.5	0.46	0.2	0.8
06/05/2024 17:00	3,884.1	295.4	4,002.3	104,800.0	419.4	0.53	0.3	0.9
06/05/2024 18:00	4,157.5	52.8	4,163.8	104,800.0	436.4	0.53	0.3	0.9
06/05/2024 19:00	4,173.6	0.0	4,173.6	104,800.0	437.4	0.53	0.3	0.9
06/05/2024 20:00	3,946.5	0.0	3,946.5	104,800.0	413.6	0.50	0.2	0.8
06/05/2024 21:00	3,256.7	0.0	3,256.7	104,800.0	341.3	0.49	0.2	0.8
06/05/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/05/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,612.4	311.4	3,782.0	104,800.0	396.3	0.55	0.3	0.9
Minimum:	916.5	0.0	916.5	104,800.0	96.0	0.46	0.2	0.8
Maximum:	4,186.2	795.9	4,982.1	104,800.0	522.1	0.64	0.3	1.1
%SI	54.17	54.17	54.17	0.00	54.17	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/06/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/07/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/08/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/09/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/09/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/10/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/10/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/11/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/11/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/12/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/12/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 13:00	583.5	64.2	583.5	104,800.0	61.2	0.00	0.0	0.0
06/13/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 15:00	2,008.6	55.4	2,008.6	104,800.0	210.5	0.00	0.0	0.0
06/13/2024 16:00	3,508.3	57.1	3,508.3	104,800.0	367.7	0.44	0.2	0.7
06/13/2024 17:00	3,454.6	63.3	3,454.6	104,800.0	362.0	0.44	0.2	0.7
06/13/2024 18:00	4,054.2	265.8	4,205.7	104,800.0	440.8	0.54	0.3	0.9
06/13/2024 19:00	4,353.1	361.2	4,714.3	104,800.0	494.1	0.59	0.3	1.0
06/13/2024 20:00	4,091.1	155.2	4,150.1	104,800.0	434.9	0.53	0.3	0.9
06/13/2024 21:00	3,035.9	75.0	3,035.9	104,800.0	318.2	0.44	0.2	0.7
06/13/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/13/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,136.2	137.2	3,207.6	104,800.0	336.2	0.50	0.3	0.8
Minimum:	583.5	55.4	583.5	104,800.0	61.2	0.44	0.2	0.7
Maximum:	4,353.1	361.2	4,714.3	104,800.0	494.1	0.59	0.3	1.0
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/14/2024 16:00	2,151.1	12.5	2,151.1	104,800.0	225.4	0.00	0.0	0.0
06/14/2024 17:00	3,970.5	14.4	3,970.5	104,800.0	416.1	0.47	0.2	0.8
06/14/2024 18:00	3,501.1	54.5	3,501.1	104,800.0	366.9	0.45	0.2	0.7
06/14/2024 19:00	4,123.1	53.6	4,123.1	104,800.0	432.1	0.52	0.3	0.9
06/14/2024 20:00	4,387.2	134.1	4,447.5	104,800.0	466.1	0.57	0.3	0.9
06/14/2024 21:00	3,563.8	73.2	3,571.1	104,800.0	374.3	0.46	0.2	0.8
06/14/2024 22:00	3,420.7	62.5	3,420.7	104,800.0	358.5	0.44	0.2	0.7
06/14/2024 23:00	3,418.3	63.0	3,418.3	104,800.0	358.2	0.44	0.2	0.7
Average/Sum#:	3,567.0	58.5	3,575.4	104,800.0	374.7	0.48	0.2	0.8
Minimum:	2,151.1	12.5	2,151.1	104,800.0	225.4	0.44	0.2	0.7
Maximum:	4,387.2	134.1	4,447.5	104,800.0	466.1	0.57	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2024 00:00	3,416.6	65.2	3,416.6	104,800.0	358.1	0.44	0.2	0.7
06/15/2024 01:00	3,417.0	65.6	3,417.0	104,800.0	358.1	0.44	0.2	0.7
06/15/2024 02:00	3,028.0	65.7	3,028.0	104,800.0	317.3	0.44	0.2	0.7
06/15/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/15/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,287.2	65.5	3,287.2	104,800.0	344.5	0.44	0.2	0.7
Minimum:	3,028.0	65.2	3,028.0	104,800.0	317.3	0.44	0.2	0.7
Maximum:	3,417.0	65.7	3,417.0	104,800.0	358.1	0.44	0.2	0.7
%SI	87.50	87.50	87.50	0.00	87.50	87.50	87.50	87.50

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/16/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/16/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/17/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/17/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
06/18/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/18/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/19/2024 08:00	3,053.9	64.6	3,053.9	104,800.0	320.0	0.00	0.0	0.0
06/19/2024 09:00	3,765.3	269.2	3,832.6	104,800.0	401.7	0.53	0.3	0.9
06/19/2024 10:00	4,202.4	373.6	4,437.8	104,800.0	465.1	0.58	0.3	1.0
06/19/2024 11:00	3,514.7	42.0	3,514.7	104,800.0	368.3	0.45	0.2	0.7
06/19/2024 12:00	3,519.8	20.7	3,519.8	104,800.0	368.9	0.45	0.2	0.7
06/19/2024 13:00	3,519.4	72.5	3,519.4	104,800.0	368.8	0.45	0.2	0.8
06/19/2024 14:00	3,514.9	78.8	3,514.9	104,800.0	368.4	0.45	0.2	0.8
06/19/2024 15:00	3,512.8	68.4	3,512.8	104,800.0	368.1	0.45	0.2	0.8
06/19/2024 16:00	3,516.1	70.7	3,516.1	104,800.0	368.5	0.45	0.2	0.8
06/19/2024 17:00	3,991.6	278.1	4,116.7	104,800.0	431.4	0.54	0.3	0.9
06/19/2024 18:00	4,350.9	718.9	5,069.8	104,800.0	531.3	0.64	0.3	1.1
06/19/2024 19:00	4,353.4	658.8	5,012.2	104,800.0	525.3	0.63	0.3	1.1
06/19/2024 20:00	4,277.1	748.3	5,025.4	104,800.0	526.7	0.63	0.3	1.1
06/19/2024 21:00	4,291.8	758.7	5,050.5	104,800.0	529.3	0.64	0.3	1.1
06/19/2024 22:00	4,331.3	664.5	4,995.8	104,800.0	523.6	0.63	0.3	1.0
06/19/2024 23:00	4,366.2	626.4	4,992.6	104,800.0	523.2	0.63	0.3	1.0
Average/Sum#:	3,880.1	344.6	4,167.8	104,800.0	436.8	0.54	0.3	0.9
Minimum:	3,053.9	20.7	3,053.9	104,800.0	320.0	0.45	0.2	0.7
Maximum:	4,366.2	758.7	5,069.8	104,800.0	531.3	0.64	0.3	1.1
%SI	33.33	33.33	33.33	0.00	33.33	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2024 00:00	4,385.9	597.0	4,982.9	104,800.0	522.2	0.63	0.3	1.0
06/20/2024 01:00	4,403.3	567.3	4,970.6	104,800.0	520.9	0.63	0.3	1.0
06/20/2024 02:00	4,417.4	549.0	4,966.4	104,800.0	520.5	0.62	0.3	1.0
06/20/2024 03:00	4,428.1	531.5	4,959.6	104,800.0	519.8	0.62	0.3	1.0
06/20/2024 04:00	4,434.6	523.9	4,958.5	104,800.0	519.7	0.62	0.3	1.0
06/20/2024 05:00	4,436.1	521.2	4,957.3	104,800.0	519.5	0.62	0.3	1.0
06/20/2024 06:00	3,959.9	187.9	4,029.4	104,800.0	422.3	0.52	0.3	0.9
06/20/2024 07:00	3,490.0	71.0	3,490.0	104,800.0	365.8	0.45	0.2	0.7
06/20/2024 08:00	3,500.7	64.6	3,500.7	104,800.0	366.9	0.45	0.2	0.7
06/20/2024 09:00	3,507.2	62.9	3,507.2	104,800.0	367.6	0.45	0.2	0.7
06/20/2024 10:00	3,488.1	74.1	3,488.1	104,800.0	365.6	0.45	0.2	0.7
06/20/2024 11:00	3,477.2	71.5	3,477.2	104,800.0	364.4	0.45	0.2	0.7
06/20/2024 12:00	3,484.3	57.8	3,484.3	104,800.0	365.2	0.45	0.2	0.7
06/20/2024 13:00	3,484.6	76.3	3,484.6	104,800.0	365.2	0.45	0.2	0.7
06/20/2024 14:00	3,480.8	78.6	3,480.8	104,800.0	364.8	0.45	0.2	0.7
06/20/2024 15:00	3,478.3	68.2	3,478.3	104,800.0	364.5	0.45	0.2	0.7
06/20/2024 16:00	3,477.7	62.1	3,477.7	104,800.0	364.5	0.45	0.2	0.7
06/20/2024 17:00	4,107.4	518.4	4,485.8	104,800.0	470.1	0.58	0.3	1.0
06/20/2024 18:00	4,303.0	744.8	5,047.8	104,800.0	529.0	0.63	0.3	1.1
06/20/2024 19:00	4,315.0	702.4	5,017.4	104,800.0	525.8	0.63	0.3	1.1
06/20/2024 20:00	4,326.1	683.0	5,009.1	104,800.0	525.0	0.63	0.3	1.1
06/20/2024 21:00	4,340.1	663.4	5,003.5	104,800.0	524.4	0.63	0.3	1.0
06/20/2024 22:00	4,362.8	604.9	4,967.7	104,800.0	520.6	0.62	0.3	1.0
06/20/2024 23:00	4,383.6	549.8	4,933.4	104,800.0	517.0	0.62	0.3	1.0
Average/Sum#:	3,978.0	359.7	4,298.3	104,800.0	450.5	0.55	0.3	0.9
Minimum:	3,477.2	57.8	3,477.2	104,800.0	364.4	0.45	0.2	0.7
Maximum:	4,436.1	744.8	5,047.8	104,800.0	529.0	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2024 00:00	4,402.3	508.8	4,911.1	104,800.0	514.7	0.62	0.3	1.0
06/21/2024 01:00	4,418.0	482.4	4,900.4	104,800.0	513.6	0.62	0.3	1.0
06/21/2024 02:00	4,425.8	516.4	4,942.2	104,800.0	517.9	0.62	0.3	1.0
06/21/2024 03:00	4,435.3	520.3	4,955.6	104,800.0	519.3	0.62	0.3	1.0
06/21/2024 04:00	4,443.9	515.4	4,959.3	104,800.0	519.7	0.62	0.3	1.0
06/21/2024 05:00	4,439.6	559.1	4,998.7	104,800.0	523.9	0.63	0.3	1.0
06/21/2024 06:00	4,242.1	290.6	4,396.1	104,800.0	460.7	0.57	0.3	1.0
06/21/2024 07:00	3,463.2	69.8	3,463.2	104,800.0	362.9	0.44	0.2	0.7
06/21/2024 08:00	3,475.4	64.2	3,475.4	104,800.0	364.2	0.45	0.2	0.7
06/21/2024 09:00	3,518.9	63.4	3,518.9	104,800.0	368.8	0.45	0.2	0.8
06/21/2024 10:00	3,807.6	65.9	3,807.6	104,800.0	399.0	0.49	0.2	0.8
06/21/2024 11:00	3,414.9	42.6	3,414.9	104,800.0	357.9	0.44	0.2	0.7
06/21/2024 12:00	3,415.6	45.6	3,415.6	104,800.0	358.0	0.44	0.2	0.7
06/21/2024 13:00	3,414.1	61.5	3,414.1	104,800.0	357.8	0.44	0.2	0.7
06/21/2024 14:00	3,411.8	51.3	3,411.8	104,800.0	357.6	0.44	0.2	0.7
06/21/2024 15:00	3,406.1	14.8	3,406.1	104,800.0	357.0	0.43	0.2	0.7
06/21/2024 16:00	3,480.5	1.3	3,480.5	104,800.0	364.8	0.44	0.2	0.7
06/21/2024 17:00	3,809.5	0.7	3,809.5	104,800.0	399.2	0.48	0.2	0.8
06/21/2024 18:00	4,213.0	26.8	4,213.0	104,800.0	441.5	0.53	0.3	0.9
06/21/2024 19:00	4,201.8	56.4	4,201.8	104,800.0	440.3	0.54	0.3	0.9
06/21/2024 20:00	4,203.3	50.1	4,203.3	104,800.0	440.5	0.54	0.3	0.9
06/21/2024 21:00	4,209.7	53.1	4,209.7	104,800.0	441.2	0.54	0.3	0.9
06/21/2024 22:00	4,236.6	53.5	4,236.6	104,800.0	444.0	0.54	0.3	0.9
06/21/2024 23:00	4,078.8	54.9	4,078.8	104,800.0	427.5	0.52	0.3	0.9
Average/Sum#:	3,940.3	173.7	4,076.0	104,800.0	427.2	0.52	0.3	0.9
Minimum:	3,406.1	0.7	3,406.1	104,800.0	357.0	0.43	0.2	0.7
Maximum:	4,443.9	559.1	4,998.7	104,800.0	523.9	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2024 00:00	3,481.2	59.1	3,481.2	104,800.0	364.8	0.44	0.2	0.7
06/22/2024 01:00	3,469.5	61.6	3,469.5	104,800.0	363.6	0.44	0.2	0.7
06/22/2024 02:00	3,479.5	63.9	3,479.5	104,800.0	364.7	0.45	0.2	0.7
06/22/2024 03:00	3,457.7	69.6	3,457.7	104,800.0	362.4	0.44	0.2	0.7
06/22/2024 04:00	3,446.4	71.9	3,446.4	104,800.0	361.2	0.44	0.2	0.7
06/22/2024 05:00	3,475.0	59.5	3,475.0	104,800.0	364.2	0.44	0.2	0.7
06/22/2024 06:00	3,479.2	54.9	3,479.2	104,800.0	364.6	0.44	0.2	0.7
06/22/2024 07:00	3,506.8	40.1	3,506.8	104,800.0	367.5	0.45	0.2	0.7
06/22/2024 08:00	3,479.7	71.0	3,479.7	104,800.0	364.7	0.45	0.2	0.7
06/22/2024 09:00	3,471.4	75.5	3,471.4	104,800.0	363.8	0.45	0.2	0.7
06/22/2024 10:00	3,461.9	80.1	3,461.9	104,800.0	362.8	0.45	0.2	0.7
06/22/2024 11:00	3,459.0	69.9	3,459.0	104,800.0	362.5	0.44	0.2	0.7
06/22/2024 12:00	3,457.6	62.9	3,457.6	104,800.0	362.4	0.44	0.2	0.7
06/22/2024 13:00	3,462.4	65.9	3,462.4	104,800.0	362.9	0.44	0.2	0.7
06/22/2024 14:00	3,464.9	65.0	3,464.9	104,800.0	363.1	0.44	0.2	0.7
06/22/2024 15:00	3,488.2	50.5	3,488.2	104,800.0	365.6	0.44	0.2	0.7
06/22/2024 16:00	3,841.7	50.7	3,841.7	104,800.0	402.6	0.49	0.2	0.8
06/22/2024 17:00	3,823.5	54.9	3,823.5	104,800.0	400.7	0.49	0.2	0.8
06/22/2024 18:00	3,969.0	60.0	3,969.0	104,800.0	416.0	0.51	0.3	0.8
06/22/2024 19:00	4,146.6	60.1	4,146.6	104,800.0	434.6	0.53	0.3	0.9
06/22/2024 20:00	4,127.5	65.3	4,127.5	104,800.0	432.6	0.53	0.3	0.9
06/22/2024 21:00	3,475.1	67.1	3,475.1	104,800.0	364.2	0.45	0.2	0.7
06/22/2024 22:00	3,492.4	65.0	3,492.4	104,800.0	366.0	0.45	0.2	0.7
06/22/2024 23:00	3,478.5	64.2	3,478.5	104,800.0	364.5	0.45	0.2	0.7
Average/Sum#:	3,578.9	62.9	3,578.9	104,800.0	375.1	0.46	0.2	0.7
Minimum:	3,446.4	40.1	3,446.4	104,800.0	361.2	0.44	0.2	0.7
Maximum:	4,146.6	80.1	4,146.6	104,800.0	434.6	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2024 00:00	3,466.1	67.6	3,466.1	104,800.0	363.2	0.44	0.2	0.7
06/23/2024 01:00	3,467.9	70.3	3,467.9	104,800.0	363.4	0.45	0.2	0.7
06/23/2024 02:00	3,487.6	70.4	3,487.6	104,800.0	365.5	0.45	0.2	0.7
06/23/2024 03:00	3,487.0	69.6	3,487.0	104,800.0	365.4	0.45	0.2	0.7
06/23/2024 04:00	3,473.5	73.5	3,473.5	104,800.0	364.0	0.45	0.2	0.7
06/23/2024 05:00	3,494.6	55.1	3,494.6	104,800.0	366.2	0.45	0.2	0.7
06/23/2024 06:00	3,501.4	39.0	3,501.4	104,800.0	366.9	0.45	0.2	0.7
06/23/2024 07:00	3,492.7	51.5	3,492.7	104,800.0	366.0	0.45	0.2	0.7
06/23/2024 08:00	3,513.2	66.0	3,513.2	104,800.0	368.2	0.45	0.2	0.8
06/23/2024 09:00	3,489.9	81.4	3,489.9	104,800.0	365.7	0.45	0.2	0.7
06/23/2024 10:00	3,466.9	69.0	3,466.9	104,800.0	363.3	0.44	0.2	0.7
06/23/2024 11:00	3,487.9	49.8	3,487.9	104,800.0	365.5	0.45	0.2	0.7
06/23/2024 12:00	3,493.1	50.5	3,493.1	104,800.0	366.1	0.45	0.2	0.7
06/23/2024 13:00	3,777.2	62.1	3,777.2	104,800.0	395.9	0.48	0.2	0.8
06/23/2024 14:00	4,060.7	68.7	4,060.7	104,800.0	425.6	0.52	0.3	0.9
06/23/2024 15:00	4,237.3	52.9	4,237.3	104,800.0	444.1	0.54	0.3	0.9
06/23/2024 16:00	4,237.4	53.0	4,237.4	104,800.0	444.1	0.54	0.3	0.9
06/23/2024 17:00	4,219.3	55.2	4,219.3	104,800.0	442.2	0.54	0.3	0.9
06/23/2024 18:00	3,916.2	63.2	3,916.2	104,800.0	410.4	0.50	0.3	0.8
06/23/2024 19:00	4,196.6	64.7	4,196.6	104,800.0	439.8	0.54	0.3	0.9
06/23/2024 20:00	4,202.1	63.2	4,202.1	104,800.0	440.4	0.54	0.3	0.9
06/23/2024 21:00	4,203.9	61.1	4,203.9	104,800.0	440.6	0.54	0.3	0.9
06/23/2024 22:00	3,937.3	55.7	3,937.3	104,800.0	412.6	0.50	0.3	0.8
06/23/2024 23:00	3,692.1	58.3	3,692.1	104,800.0	386.9	0.47	0.2	0.8
Average/Sum#:	3,750.1	61.3	3,750.1	104,800.0	393.0	0.48	0.2	0.8
Minimum:	3,466.1	39.0	3,466.1	104,800.0	363.2	0.44	0.2	0.7
Maximum:	4,237.4	81.4	4,237.4	104,800.0	444.1	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2024 00:00	3,395.9	67.5	3,395.9	104,800.0	355.9	0.44	0.2	0.7
06/24/2024 01:00	3,392.2	66.2	3,392.2	104,800.0	355.5	0.44	0.2	0.7
06/24/2024 02:00	3,459.6	68.6	3,459.6	104,800.0	362.6	0.45	0.2	0.7
06/24/2024 03:00	3,408.7	69.1	3,408.7	104,800.0	357.2	0.44	0.2	0.7
06/24/2024 04:00	3,880.6	67.8	3,880.6	104,800.0	406.7	0.50	0.2	0.8
06/24/2024 05:00	3,949.5	34.3	3,949.5	104,800.0	413.9	0.50	0.3	0.8
06/24/2024 06:00	3,035.9	11.7	3,035.9	104,800.0	318.2	0.43	0.2	0.7
06/24/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 14:00	539.7	53.2	539.7	104,800.0	56.6	0.00	0.0	0.0
06/24/2024 15:00	597.1	22.8	597.1	104,800.0	62.6	0.00	0.0	0.0
06/24/2024 16:00	642.4	18.6	642.4	104,800.0	67.3	0.00	0.0	0.0
06/24/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
06/24/2024 19:00	2,421.4	55.8	2,421.4	104,800.0	253.8	0.00	0.0	0.0
06/24/2024 20:00	3,938.0	58.4	3,938.0	104,800.0	412.7	0.54	0.3	0.9
06/24/2024 21:00	4,260.5	49.2	4,260.5	104,800.0	446.5	0.54	0.3	0.9
06/24/2024 22:00	4,250.7	48.3	4,250.7	104,800.0	445.5	0.54	0.3	0.9
06/24/2024 23:00	4,263.9	56.4	4,263.9	104,800.0	446.9	0.54	0.3	0.9
Average/Sum#:	3,029.1	49.9	3,029.1	104,800.0	317.5	0.49	0.2	0.8
Minimum:	539.7	11.7	539.7	104,800.0	56.6	0.43	0.2	0.7
Maximum:	4,263.9	69.1	4,263.9	104,800.0	446.9	0.54	0.3	0.9
%SI	37.50	37.50	37.50	0.00	37.50	54.17	54.17	54.17

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2024 00:00	4,255.2	56.3	4,255.2	104,800.0	445.9	0.54	0.3	0.9
06/25/2024 01:00	4,260.1	61.0	4,260.1	104,800.0	446.5	0.54	0.3	0.9
06/25/2024 02:00	4,239.3	60.3	4,239.3	104,800.0	444.3	0.54	0.3	0.9
06/25/2024 03:00	4,187.0	60.0	4,187.0	104,800.0	438.8	0.53	0.3	0.9
06/25/2024 04:00	4,192.8	58.4	4,192.8	104,800.0	439.4	0.53	0.3	0.9
06/25/2024 05:00	4,139.4	54.3	4,139.4	104,800.0	433.8	0.53	0.3	0.9
06/25/2024 06:00	3,745.3	47.3	3,745.3	104,800.0	392.5	0.48	0.2	0.8
06/25/2024 07:00	3,427.1	14.0	3,427.1	104,800.0	359.2	0.43	0.2	0.7
06/25/2024 08:00	4,018.9	39.6	4,018.9	104,800.0	421.2	0.51	0.3	0.9
06/25/2024 09:00	4,235.1	63.5	4,235.1	104,800.0	443.8	0.54	0.3	0.9
06/25/2024 10:00	4,304.9	68.1	4,304.9	104,800.0	451.2	0.55	0.3	0.9
06/25/2024 11:00	4,307.3	59.7	4,307.3	104,800.0	451.4	0.55	0.3	0.9
06/25/2024 12:00	4,285.0	61.1	4,285.0	104,800.0	449.1	0.55	0.3	0.9
06/25/2024 13:00	4,265.3	58.7	4,265.3	104,800.0	447.0	0.54	0.3	0.9
06/25/2024 14:00	4,266.6	53.3	4,266.6	104,800.0	447.1	0.54	0.3	0.9
06/25/2024 15:00	3,980.3	44.5	3,980.3	104,800.0	417.1	0.51	0.3	0.8
06/25/2024 16:00	4,177.9	58.7	4,177.9	104,800.0	437.8	0.53	0.3	0.9
06/25/2024 17:00	4,253.2	181.6	4,295.0	104,800.0	450.1	0.56	0.3	0.9
06/25/2024 18:00	4,274.6	1,750.2	6,024.8	104,800.0	631.4	0.76	0.4	1.3
06/25/2024 19:00	4,285.1	1,899.2	6,184.3	104,800.0	648.1	0.78	0.4	1.3
06/25/2024 20:00	4,296.3	1,601.5	5,897.8	104,800.0	618.1	0.74	0.4	1.2
06/25/2024 21:00	4,311.7	1,379.8	5,691.5	104,800.0	596.5	0.72	0.4	1.2
06/25/2024 22:00	4,308.7	640.5	4,821.1	104,800.0	505.3	0.62	0.3	1.0
06/25/2024 23:00	3,766.9	75.8	3,766.9	104,800.0	394.8	0.48	0.2	0.8
Average/Sum#:	4,157.7	352.0	4,457.0	104,800.0	467.1	0.57	0.3	0.9
Minimum:	3,427.1	14.0	3,427.1	104,800.0	359.2	0.43	0.2	0.7
Maximum:	4,311.7	1,899.2	6,184.3	104,800.0	648.1	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2024 00:00	3,640.4	75.2	3,640.4	104,800.0	381.5	0.47	0.2	0.8
06/26/2024 01:00	3,884.3	75.6	3,884.3	104,800.0	407.1	0.50	0.2	0.8
06/26/2024 02:00	3,707.7	77.1	3,707.7	104,800.0	388.6	0.48	0.2	0.8
06/26/2024 03:00	4,097.9	81.7	4,097.9	104,800.0	429.5	0.53	0.3	0.9
06/26/2024 04:00	4,319.6	81.3	4,319.6	104,800.0	452.7	0.55	0.3	0.9
06/26/2024 05:00	3,728.3	72.2	3,728.3	104,800.0	390.7	0.48	0.2	0.8
06/26/2024 06:00	3,419.3	53.2	3,419.3	104,800.0	358.3	0.44	0.2	0.7
06/26/2024 07:00	3,427.1	42.8	3,427.1	104,800.0	359.2	0.44	0.2	0.7
06/26/2024 08:00	3,422.7	73.2	3,422.7	104,800.0	358.7	0.44	0.2	0.7
06/26/2024 09:00	3,415.4	70.6	3,415.4	104,800.0	357.9	0.44	0.2	0.7
06/26/2024 10:00	3,413.3	66.5	3,413.3	104,800.0	357.7	0.44	0.2	0.7
06/26/2024 11:00	3,428.4	48.0	3,428.4	104,800.0	359.3	0.44	0.2	0.7
06/26/2024 12:00	3,429.3	27.2	3,429.3	104,800.0	359.4	0.44	0.2	0.7
06/26/2024 13:00	3,428.8	56.5	3,428.8	104,800.0	359.3	0.44	0.2	0.7
06/26/2024 14:00	3,427.9	53.3	3,427.9	104,800.0	359.2	0.44	0.2	0.7
06/26/2024 15:00	3,423.0	8.1	3,423.0	104,800.0	358.7	0.43	0.2	0.7
06/26/2024 16:00	3,426.6	3.7	3,426.6	104,800.0	359.1	0.43	0.2	0.7
06/26/2024 17:00	3,506.0	23.1	3,506.0	104,800.0	367.4	0.44	0.2	0.7
06/26/2024 18:00	3,788.0	58.8	3,788.0	104,800.0	397.0	0.48	0.2	0.8
06/26/2024 19:00	3,461.9	59.5	3,461.9	104,800.0	362.8	0.44	0.2	0.7
06/26/2024 20:00	3,411.6	61.4	3,411.6	104,800.0	357.5	0.44	0.2	0.7
06/26/2024 21:00	3,408.5	59.2	3,408.5	104,800.0	357.2	0.44	0.2	0.7
06/26/2024 22:00	3,411.0	64.3	3,411.0	104,800.0	357.5	0.44	0.2	0.7
06/26/2024 23:00	3,410.5	66.0	3,410.5	104,800.0	357.4	0.44	0.2	0.7
Average/Sum#:	3,559.9	56.6	3,559.9	104,800.0	373.1	0.46	0.2	0.7
Minimum:	3,408.5	3.7	3,408.5	104,800.0	357.2	0.43	0.2	0.7
Maximum:	4,319.6	81.7	4,319.6	104,800.0	452.7	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2024 00:00	3,410.0	68.0	3,410.0	104,800.0	357.4	0.44	0.2	0.7
06/27/2024 01:00	3,410.0	68.5	3,410.0	104,800.0	357.4	0.44	0.2	0.7
06/27/2024 02:00	3,412.7	71.5	3,412.7	104,800.0	357.7	0.44	0.2	0.7
06/27/2024 03:00	3,420.2	77.0	3,420.2	104,800.0	358.4	0.44	0.2	0.7
06/27/2024 04:00	3,417.9	77.8	3,417.9	104,800.0	358.2	0.44	0.2	0.7
06/27/2024 05:00	3,421.1	62.1	3,421.1	104,800.0	358.5	0.44	0.2	0.7
06/27/2024 06:00	3,422.1	45.0	3,422.1	104,800.0	358.6	0.44	0.2	0.7
06/27/2024 07:00	3,429.4	64.5	3,429.4	104,800.0	359.4	0.44	0.2	0.7
06/27/2024 08:00	3,423.7	68.6	3,423.7	104,800.0	358.8	0.44	0.2	0.7
06/27/2024 09:00	3,423.0	70.4	3,423.0	104,800.0	358.7	0.44	0.2	0.7
06/27/2024 10:00	3,420.9	76.2	3,420.9	104,800.0	358.5	0.44	0.2	0.7
06/27/2024 11:00	3,435.6	43.6	3,435.6	104,800.0	360.1	0.44	0.2	0.7
06/27/2024 12:00	3,439.3	45.1	3,439.3	104,800.0	360.4	0.44	0.2	0.7
06/27/2024 13:00	3,439.6	69.3	3,439.6	104,800.0	360.5	0.44	0.2	0.7
06/27/2024 14:00	3,433.8	77.6	3,433.8	104,800.0	359.9	0.44	0.2	0.7
06/27/2024 15:00	3,425.9	71.0	3,425.9	104,800.0	359.0	0.44	0.2	0.7
06/27/2024 16:00	3,424.4	68.3	3,424.4	104,800.0	358.9	0.44	0.2	0.7
06/27/2024 17:00	3,462.1	64.1	3,462.1	104,800.0	362.8	0.44	0.2	0.7
06/27/2024 18:00	3,821.4	70.7	3,821.4	104,800.0	400.5	0.49	0.2	0.8
06/27/2024 19:00	3,448.1	75.0	3,448.1	104,800.0	361.4	0.44	0.2	0.7
06/27/2024 20:00	3,411.7	79.1	3,411.7	104,800.0	357.5	0.44	0.2	0.7
06/27/2024 21:00	3,410.3	80.7	3,410.3	104,800.0	357.4	0.44	0.2	0.7
06/27/2024 22:00	3,402.3	80.1	3,402.3	104,800.0	356.6	0.44	0.2	0.7
06/27/2024 23:00	3,402.8	78.0	3,402.8	104,800.0	356.6	0.44	0.2	0.7
Average/Sum#:	3,440.3	68.8	3,440.3	104,800.0	360.6	0.44	0.2	0.7
Minimum:	3,402.3	43.6	3,402.3	104,800.0	356.6	0.44	0.2	0.7
Maximum:	3,821.4	80.7	3,821.4	104,800.0	400.5	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2024 00:00	3,406.0	79.5	3,406.0	104,800.0	356.9	0.44	0.2	0.7
06/28/2024 01:00	3,398.0	81.1	3,398.0	104,800.0	356.1	0.44	0.2	0.7
06/28/2024 02:00	3,400.9	80.2	3,400.9	104,800.0	356.4	0.44	0.2	0.7
06/28/2024 03:00	3,399.4	81.9	3,399.4	104,800.0	356.3	0.44	0.2	0.7
06/28/2024 04:00	3,406.2	84.0	3,406.2	104,800.0	357.0	0.44	0.2	0.7
06/28/2024 05:00	3,413.6	74.4	3,413.6	104,800.0	357.7	0.44	0.2	0.7
06/28/2024 06:00	3,419.4	66.4	3,419.4	104,800.0	358.4	0.44	0.2	0.7
06/28/2024 07:00	3,422.4	55.9	3,422.4	104,800.0	358.7	0.44	0.2	0.7
06/28/2024 08:00	3,411.0	67.1	3,411.0	104,800.0	357.5	0.44	0.2	0.7
06/28/2024 09:00	3,410.8	65.8	3,410.8	104,800.0	357.5	0.44	0.2	0.7
06/28/2024 10:00	3,410.7	76.5	3,410.7	104,800.0	357.4	0.44	0.2	0.7
06/28/2024 11:00	3,425.8	63.4	3,425.8	104,800.0	359.0	0.44	0.2	0.7
06/28/2024 12:00	3,427.6	63.6	3,427.6	104,800.0	359.2	0.44	0.2	0.7
06/28/2024 13:00	3,419.9	67.4	3,419.9	104,800.0	358.4	0.44	0.2	0.7
06/28/2024 14:00	3,413.2	71.5	3,413.2	104,800.0	357.7	0.44	0.2	0.7
06/28/2024 15:00	3,405.5	65.0	3,405.5	104,800.0	356.9	0.44	0.2	0.7
06/28/2024 16:00	3,408.8	56.7	3,408.8	104,800.0	357.2	0.44	0.2	0.7
06/28/2024 17:00	3,463.4	52.8	3,463.4	104,800.0	363.0	0.44	0.2	0.7
06/28/2024 18:00	3,427.1	65.9	3,427.1	104,800.0	359.2	0.44	0.2	0.7
06/28/2024 19:00	3,407.2	69.5	3,407.2	104,800.0	357.1	0.44	0.2	0.7
06/28/2024 20:00	3,383.4	67.9	3,383.4	104,800.0	354.6	0.43	0.2	0.7
06/28/2024 21:00	3,371.6	71.1	3,371.6	104,800.0	353.3	0.43	0.2	0.7
06/28/2024 22:00	3,367.8	74.6	3,367.8	104,800.0	352.9	0.43	0.2	0.7
06/28/2024 23:00	3,368.1	78.6	3,368.1	104,800.0	353.0	0.43	0.2	0.7
Average/Sum#:	3,407.8	70.0	3,407.8	104,800.0	357.1	0.44	0.2	0.7
Minimum:	3,367.8	52.8	3,367.8	104,800.0	352.9	0.43	0.2	0.7
Maximum:	3,463.4	84.0	3,463.4	104,800.0	363.0	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/03/2024 23:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2024 00:00	3,373.5	79.0	3,373.5	104,800.0	353.5	0.43	0.2	0.7
06/29/2024 01:00	3,366.9	80.6	3,366.9	104,800.0	352.9	0.43	0.2	0.7
06/29/2024 02:00	3,365.9	76.0	3,365.9	104,800.0	352.7	0.43	0.2	0.7
06/29/2024 03:00	3,370.9	76.0	3,370.9	104,800.0	353.3	0.43	0.2	0.7
06/29/2024 04:00	3,377.9	75.8	3,377.9	104,800.0	354.0	0.43	0.2	0.7
06/29/2024 05:00	3,385.7	71.1	3,385.7	104,800.0	354.8	0.43	0.2	0.7
06/29/2024 06:00	3,386.9	69.9	3,386.9	104,800.0	354.9	0.43	0.2	0.7
06/29/2024 07:00	3,389.5	71.5	3,389.5	104,800.0	355.2	0.44	0.2	0.7
06/29/2024 08:00	3,388.4	80.2	3,388.4	104,800.0	355.1	0.44	0.2	0.7
06/29/2024 09:00	3,385.6	85.2	3,385.6	104,800.0	354.8	0.44	0.2	0.7
06/29/2024 10:00	3,387.8	84.4	3,387.8	104,800.0	355.0	0.44	0.2	0.7
06/29/2024 11:00	3,399.3	73.2	3,399.3	104,800.0	356.2	0.44	0.2	0.7
06/29/2024 12:00	3,399.6	68.7	3,399.6	104,800.0	356.3	0.44	0.2	0.7
06/29/2024 13:00	3,400.0	68.3	3,400.0	104,800.0	356.3	0.44	0.2	0.7
06/29/2024 14:00	3,399.2	69.8	3,399.2	104,800.0	356.2	0.44	0.2	0.7
06/29/2024 15:00	3,387.9	62.7	3,387.9	104,800.0	355.1	0.43	0.2	0.7
06/29/2024 16:00	3,382.2	59.5	3,382.2	104,800.0	354.5	0.43	0.2	0.7
06/29/2024 17:00	3,480.5	60.7	3,480.5	104,800.0	364.8	0.44	0.2	0.7
06/29/2024 18:00	3,555.2	68.9	3,555.2	104,800.0	372.6	0.45	0.2	0.8
06/29/2024 19:00	3,371.1	68.6	3,371.1	104,800.0	353.3	0.43	0.2	0.7
06/29/2024 20:00	3,368.7	70.9	3,368.7	104,800.0	353.0	0.43	0.2	0.7
06/29/2024 21:00	3,362.5	71.2	3,362.5	104,800.0	352.4	0.43	0.2	0.7
06/29/2024 22:00	3,360.3	77.8	3,360.3	104,800.0	352.2	0.43	0.2	0.7
06/29/2024 23:00	3,363.9	78.7	3,363.9	104,800.0	352.5	0.43	0.2	0.7
Average/Sum#:	3,392.1	72.9	3,392.1	104,800.0	355.5	0.43	0.2	0.7
Minimum:	3,360.3	59.5	3,360.3	104,800.0	352.2	0.43	0.2	0.7
Maximum:	3,555.2	85.2	3,555.2	104,800.0	372.6	0.45	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2024 00:00	3,363.8	78.9	3,363.8	104,800.0	352.5	0.43	0.2	0.7
06/30/2024 01:00	3,370.9	79.8	3,370.9	104,800.0	353.3	0.43	0.2	0.7
06/30/2024 02:00	3,365.6	82.3	3,365.6	104,800.0	352.7	0.43	0.2	0.7
06/30/2024 03:00	3,362.4	76.6	3,362.4	104,800.0	352.4	0.43	0.2	0.7
06/30/2024 04:00	3,369.5	71.7	3,369.5	104,800.0	353.1	0.43	0.2	0.7
06/30/2024 05:00	3,374.5	71.1	3,374.5	104,800.0	353.6	0.43	0.2	0.7
06/30/2024 06:00	3,377.9	33.9	3,377.9	104,800.0	354.0	0.43	0.2	0.7
06/30/2024 07:00	3,380.8	69.6	3,380.8	104,800.0	354.3	0.43	0.2	0.7
06/30/2024 08:00	3,375.6	63.4	3,375.6	104,800.0	353.8	0.43	0.2	0.7
06/30/2024 09:00	3,371.1	71.7	3,371.1	104,800.0	353.3	0.43	0.2	0.7
06/30/2024 10:00	3,371.6	64.2	3,371.6	104,800.0	353.3	0.43	0.2	0.7
06/30/2024 11:00	3,391.2	35.7	3,391.2	104,800.0	355.4	0.43	0.2	0.7
06/30/2024 12:00	3,394.1	19.5	3,394.1	104,800.0	355.7	0.43	0.2	0.7
06/30/2024 13:00	3,392.0	49.7	3,392.0	104,800.0	355.5	0.43	0.2	0.7
06/30/2024 14:00	3,389.0	67.5	3,389.0	104,800.0	355.2	0.43	0.2	0.7
06/30/2024 15:00	3,383.6	55.6	3,383.6	104,800.0	354.6	0.43	0.2	0.7
06/30/2024 16:00	3,383.3	49.4	3,383.3	104,800.0	354.6	0.43	0.2	0.7
06/30/2024 17:00	3,380.6	39.4	3,380.6	104,800.0	354.3	0.43	0.2	0.7
06/30/2024 18:00	3,373.2	61.3	3,373.2	104,800.0	353.5	0.43	0.2	0.7
06/30/2024 19:00	3,367.4	62.7	3,367.4	104,800.0	352.9	0.43	0.2	0.7
06/30/2024 20:00	3,371.5	67.5	3,371.5	104,800.0	353.3	0.43	0.2	0.7
06/30/2024 21:00	3,367.0	70.9	3,367.0	104,800.0	352.9	0.43	0.2	0.7
06/30/2024 22:00	3,359.8	68.5	3,359.8	104,800.0	352.1	0.43	0.2	0.7
06/30/2024 23:00	3,367.3	68.1	3,367.3	104,800.0	352.9	0.43	0.2	0.7
Average/Sum#:	3,375.2	61.6	3,375.2	104,800.0	353.7	0.43	0.2	0.7
Minimum:	3,359.8	19.5	3,359.8	104,800.0	352.1	0.43	0.2	0.7
Maximum:	3,394.1	82.3	3,394.1	104,800.0	355.7	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 06:00	1,569.7	0.0	1,569.7	105,200.0	165.1	0.0	0.0	0.0
04/02/2024 07:00	4,010.6	0.0	4,010.6	105,200.0	421.9	0.6	0.3	1.0
04/02/2024 08:00	4,805.9	0.3	4,805.9	105,200.0	505.6	0.6	0.3	1.0
04/02/2024 09:00	4,758.0	0.0	4,758.0	105,200.0	500.5	0.6	0.3	1.0
04/02/2024 10:00	3,107.0	0.0	3,107.0	105,200.0	326.9	0.4	0.2	0.7
04/02/2024 11:00	2,991.5	0.0	2,991.5	105,200.0	314.7	0.4	0.2	0.6
04/02/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,540.5	0.1	3,540.5	105,200.0	372.5	0.5	0.3	0.9
Minimum:	1,569.7	0.0	1,569.7	105,200.0	165.1	0.4	0.2	0.6
Maximum:	4,805.9	0.3	4,805.9	105,200.0	505.6	0.6	0.3	1.0
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/03/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/04/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/05/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/06/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/08/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/08/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 16:00	2,613.3	0.1	2,613.3	105,200.0	274.9	0.0	0.0	0.0
04/09/2024 17:00	3,684.3	0.1	3,684.3	105,200.0	387.6	0.5	0.2	0.8
04/09/2024 18:00	3,670.6	0.0	3,670.6	105,200.0	386.1	0.5	0.2	0.8
04/09/2024 19:00	3,675.2	0.0	3,675.2	105,200.0	386.6	0.5	0.2	0.8
04/09/2024 20:00	3,676.5	0.0	3,676.5	105,200.0	386.8	0.5	0.2	0.8
04/09/2024 21:00	3,313.8	0.0	3,313.8	105,200.0	348.6	0.5	0.2	0.8
04/09/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/09/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,439.0	0.0	3,439.0	105,200.0	361.8	0.5	0.2	0.8
Minimum:	2,613.3	0.0	2,613.3	105,200.0	274.9	0.5	0.2	0.8
Maximum:	3,684.3	0.1	3,684.3	105,200.0	387.6	0.5	0.2	0.8
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/10/2024 16:00	1,409.4	0.0	1,409.4	105,200.0	148.3	0.0	0.0	0.0
04/10/2024 17:00	3,683.3	0.0	3,683.3	105,200.0	387.5	0.5	0.2	0.8
04/10/2024 18:00	3,671.4	12.4	3,671.4	105,200.0	386.2	0.5	0.2	0.8
04/10/2024 19:00	3,672.4	77.5	3,672.4	105,200.0	386.3	0.5	0.2	0.8
04/10/2024 20:00	3,677.5	74.4	3,677.5	105,200.0	386.9	0.5	0.2	0.8
04/10/2024 21:00	3,679.4	73.0	3,679.4	105,200.0	387.1	0.5	0.2	0.8
04/10/2024 22:00	3,683.0	12.3	3,683.0	105,200.0	387.5	0.5	0.2	0.8
04/10/2024 23:00	3,682.2	0.0	3,682.2	105,200.0	387.4	0.5	0.2	0.8
Average/Sum#:	3,394.8	31.2	3,394.8	105,200.0	357.2	0.5	0.2	0.8
Minimum:	1,409.4	0.0	1,409.4	105,200.0	148.3	0.5	0.2	0.8
Maximum:	3,683.3	77.5	3,683.3	105,200.0	387.5	0.5	0.2	0.8
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2024 00:00	3,353.4	0.0	3,353.4	105,200.0	352.8	0.5	0.2	0.8
04/11/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/11/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,353.4	0.0	3,353.4	105,200.0	352.8	0.5	0.2	0.8
Minimum:	3,353.4	0.0	3,353.4	105,200.0	352.8	0.5	0.2	0.8
Maximum:	3,353.4	0.0	3,353.4	105,200.0	352.8	0.5	0.2	0.8
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/12/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/13/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/14/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/14/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/15/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/15/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/16/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/16/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/17/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/17/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/19/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/21/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/22/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/22/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/23/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/23/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	4.17	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/25/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/26/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
04/27/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/27/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:54 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2024 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/30/2024 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/01/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/02/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/03/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/03/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 10:00	1,181.2	0.0	1,181.2	104,400.0	123.3	0.0	0.0	0.0
05/04/2024 11:00	481.7	0.0	481.7	104,400.0	50.3	0.0	0.0	0.0
05/04/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/04/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	831.5	0.0	831.5	104,400.0	86.8	0.0	0.0	0.0
Minimum:	481.7	0.0	481.7	104,400.0	50.3	0.0	0.0	0.0
Maximum:	1,181.2	0.0	1,181.2	104,400.0	123.3	0.0	0.0	0.0
%SI	91.67	91.67	91.67	0.00	91.67	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/05/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/06/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/07/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/08/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/09/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/10/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/10/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/11/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/11/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/12/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/12/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/13/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/13/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/14/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/15/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/16/2024 17:00	2,327.4	0.0	2,327.4	104,400.0	243.0	0.0	0.0	0.0
05/16/2024 18:00	4,403.6	0.0	4,403.6	104,400.0	459.7	0.5	0.2	0.8
05/16/2024 19:00	4,629.7	0.0	4,629.7	104,400.0	483.3	0.6	0.3	1.0
05/16/2024 20:00	3,956.1	0.0	3,956.1	104,400.0	413.0	0.5	0.2	0.8
05/16/2024 21:00	4,610.0	0.0	4,610.0	104,400.0	481.3	0.6	0.3	1.0
05/16/2024 22:00	2,429.5	0.0	2,429.5	104,400.0	253.6	0.5	0.2	0.8
05/16/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,726.1	0.0	3,726.1	104,400.0	389.0	0.5	0.2	0.9
Minimum:	2,327.4	0.0	2,327.4	104,400.0	243.0	0.5	0.2	0.8
Maximum:	4,629.7	0.0	4,629.7	104,400.0	483.3	0.6	0.3	1.0
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/17/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/18/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/19/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/19/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/20/2024 22:00	2,673.1	0.0	2,673.1	104,400.0	279.1	0.0	0.0	0.0
05/20/2024 23:00	3,705.9	0.0	3,705.9	104,400.0	386.9	0.5	0.2	0.8
Average/Sum#:	3,189.5	0.0	3,189.5	104,400.0	333.0	0.5	0.2	0.8
Minimum:	2,673.1	0.0	2,673.1	104,400.0	279.1	0.5	0.2	0.8
Maximum:	3,705.9	0.0	3,705.9	104,400.0	386.9	0.5	0.2	0.8
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2024 00:00	3,657.1	0.0	3,657.1	104,400.0	381.8	0.5	0.2	0.8
05/21/2024 01:00	3,677.1	0.0	3,677.1	104,400.0	383.9	0.5	0.2	0.8
05/21/2024 02:00	3,686.9	0.0	3,686.9	104,400.0	384.9	0.5	0.2	0.8
05/21/2024 03:00	3,689.2	0.0	3,689.2	104,400.0	385.2	0.5	0.2	0.8
05/21/2024 04:00	3,692.1	0.0	3,692.1	104,400.0	385.5	0.5	0.2	0.8
05/21/2024 05:00	3,713.8	0.0	3,713.8	104,400.0	387.7	0.5	0.2	0.8
05/21/2024 06:00	4,502.7	259.4	4,671.3	104,400.0	487.7	0.6	0.3	1.0
05/21/2024 07:00	4,795.2	1,376.4	6,171.6	104,400.0	644.3	0.8	0.4	1.3
05/21/2024 08:00	4,767.5	1,381.3	6,148.8	104,400.0	641.9	0.8	0.4	1.3
05/21/2024 09:00	4,742.1	1,380.6	6,122.7	104,400.0	639.2	0.8	0.4	1.3
05/21/2024 10:00	4,728.5	1,376.8	6,105.3	104,400.0	637.4	0.8	0.4	1.3
05/21/2024 11:00	4,702.3	1,415.3	6,117.6	104,400.0	638.7	0.8	0.4	1.3
05/21/2024 12:00	4,687.6	1,531.8	6,219.4	104,400.0	649.3	0.8	0.4	1.3
05/21/2024 13:00	4,680.0	1,544.1	6,224.1	104,400.0	649.8	0.8	0.4	1.3
05/21/2024 14:00	4,675.3	1,546.8	6,222.1	104,400.0	649.6	0.8	0.4	1.3
05/21/2024 15:00	4,663.3	1,552.9	6,216.2	104,400.0	649.0	0.8	0.4	1.3
05/21/2024 16:00	4,667.2	1,547.7	6,214.9	104,400.0	648.8	0.8	0.4	1.3
05/21/2024 17:00	4,674.9	1,541.5	6,216.4	104,400.0	649.0	0.8	0.4	1.3
05/21/2024 18:00	4,680.8	1,521.4	6,202.2	104,400.0	647.5	0.8	0.4	1.3
05/21/2024 19:00	4,697.2	1,476.5	6,173.7	104,400.0	644.5	0.8	0.4	1.3
05/21/2024 20:00	4,707.7	476.0	5,112.3	104,400.0	533.7	0.6	0.3	1.1
05/21/2024 21:00	4,512.4	214.0	4,615.1	104,400.0	481.8	0.6	0.3	1.0
05/21/2024 22:00	3,762.6	0.0	3,762.6	104,400.0	392.8	0.5	0.2	0.8
05/21/2024 23:00	3,731.2	0.0	3,731.2	104,400.0	389.5	0.5	0.2	0.8
Average/Sum#:	4,353.9	839.3	5,181.8	104,400.0	541.0	0.7	0.3	1.1
Minimum:	3,657.1	0.0	3,657.1	104,400.0	381.8	0.5	0.2	0.8
Maximum:	4,795.2	1,552.9	6,224.1	104,400.0	649.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2024 00:00	3,721.3	0.0	3,721.3	104,400.0	388.5	0.5	0.2	0.8
05/22/2024 01:00	3,762.8	0.0	3,762.8	104,400.0	392.8	0.5	0.2	0.8
05/22/2024 02:00	3,719.5	0.0	3,719.5	104,400.0	388.3	0.5	0.2	0.8
05/22/2024 03:00	4,021.0	0.0	4,021.0	104,400.0	419.8	0.5	0.3	0.8
05/22/2024 04:00	4,115.8	112.0	4,143.8	104,400.0	432.6	0.5	0.3	0.9
05/22/2024 05:00	4,769.6	1,524.4	6,294.0	104,400.0	657.1	0.8	0.4	1.3
05/22/2024 06:00	4,826.6	1,465.3	6,291.9	104,400.0	656.9	0.8	0.4	1.3
05/22/2024 07:00	4,801.7	1,502.1	6,303.8	104,400.0	658.1	0.8	0.4	1.3
05/22/2024 08:00	4,778.5	1,508.7	6,287.2	104,400.0	656.4	0.8	0.4	1.3
05/22/2024 09:00	4,748.5	1,543.5	6,292.0	104,400.0	656.9	0.8	0.4	1.3
05/22/2024 10:00	4,737.0	1,560.0	6,297.0	104,400.0	657.4	0.8	0.4	1.3
05/22/2024 11:00	4,699.0	1,594.2	6,293.2	104,400.0	657.0	0.8	0.4	1.3
05/22/2024 12:00	4,671.4	1,640.5	6,311.9	104,400.0	659.0	0.8	0.4	1.3
05/22/2024 13:00	4,665.0	1,645.7	6,310.7	104,400.0	658.8	0.8	0.4	1.3
05/22/2024 14:00	4,664.8	1,633.7	6,298.5	104,400.0	657.6	0.8	0.4	1.3
05/22/2024 15:00	4,656.2	1,595.5	6,251.7	104,400.0	652.7	0.8	0.4	1.3
05/22/2024 16:00	4,368.2	363.7	4,575.5	104,400.0	477.7	0.6	0.3	1.0
05/22/2024 17:00	4,660.2	1,348.8	6,009.0	104,400.0	627.3	0.8	0.4	1.3
05/22/2024 18:00	4,664.5	1,599.2	6,263.7	104,400.0	653.9	0.8	0.4	1.3
05/22/2024 19:00	4,701.3	1,536.8	6,238.1	104,400.0	651.3	0.8	0.4	1.3
05/22/2024 20:00	4,725.9	1,497.5	6,223.4	104,400.0	649.7	0.8	0.4	1.3
05/22/2024 21:00	4,735.9	1,474.6	6,210.5	104,400.0	648.4	0.8	0.4	1.3
05/22/2024 22:00	4,518.5	389.4	4,752.1	104,400.0	496.1	0.6	0.3	1.0
05/22/2024 23:00	3,713.6	0.0	3,713.6	104,400.0	387.7	0.5	0.2	0.8
Average/Sum#:	4,477.0	1,064.0	5,524.4	104,400.0	576.8	0.7	0.4	1.2
Minimum:	3,713.6	0.0	3,713.6	104,400.0	387.7	0.5	0.2	0.8
Maximum:	4,826.6	1,645.7	6,311.9	104,400.0	659.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2024 00:00	3,722.1	0.0	3,722.1	104,400.0	388.6	0.5	0.2	0.8
05/23/2024 01:00	3,713.7	0.0	3,713.7	104,400.0	387.7	0.5	0.2	0.8
05/23/2024 02:00	3,709.5	0.0	3,709.5	104,400.0	387.3	0.5	0.2	0.8
05/23/2024 03:00	3,702.3	0.0	3,702.3	104,400.0	386.5	0.5	0.2	0.8
05/23/2024 04:00	3,701.8	0.0	3,701.8	104,400.0	386.5	0.5	0.2	0.8
05/23/2024 05:00	3,746.1	0.0	3,746.1	104,400.0	391.1	0.5	0.2	0.8
05/23/2024 06:00	3,710.7	0.0	3,710.7	104,400.0	387.4	0.5	0.2	0.8
05/23/2024 07:00	4,078.7	115.9	4,105.4	104,400.0	428.6	0.5	0.3	0.9
05/23/2024 08:00	4,659.8	1,616.0	6,275.8	104,400.0	655.2	0.8	0.4	1.3
05/23/2024 09:00	4,613.2	1,654.3	6,267.5	104,400.0	654.3	0.8	0.4	1.3
05/23/2024 10:00	4,564.4	1,724.6	6,289.0	104,400.0	656.6	0.8	0.4	1.3
05/23/2024 11:00	4,521.4	871.5	5,366.8	104,400.0	560.3	0.7	0.3	1.1
05/23/2024 12:00	4,068.9	49.8	4,068.9	104,400.0	424.8	0.5	0.3	0.9
05/23/2024 13:00	3,713.2	24.8	3,713.2	104,400.0	387.7	0.5	0.2	0.8
05/23/2024 14:00	3,713.1	0.0	3,713.1	104,400.0	387.6	0.5	0.2	0.8
05/23/2024 15:00	3,712.0	0.0	3,712.0	104,400.0	387.5	0.5	0.2	0.8
05/23/2024 16:00	3,712.4	0.0	3,712.4	104,400.0	387.6	0.5	0.2	0.8
05/23/2024 17:00	3,995.9	58.6	4,005.9	104,400.0	418.2	0.5	0.3	0.8
05/23/2024 18:00	4,416.6	4.3	4,416.7	104,400.0	461.1	0.6	0.3	0.9
05/23/2024 19:00	4,543.7	0.0	4,543.7	104,400.0	474.4	0.6	0.3	0.9
05/23/2024 20:00	4,282.3	0.0	4,282.3	104,400.0	447.1	0.5	0.3	0.9
05/23/2024 21:00	3,741.8	0.1	3,741.8	104,400.0	390.6	0.5	0.2	0.8
05/23/2024 22:00	3,732.3	0.0	3,732.3	104,400.0	389.7	0.5	0.2	0.8
05/23/2024 23:00	3,742.7	0.0	3,742.7	104,400.0	390.7	0.5	0.2	0.8
Average/Sum#:	3,992.4	255.0	4,237.3	104,400.0	442.4	0.6	0.3	0.9
Minimum:	3,701.8	0.0	3,701.8	104,400.0	386.5	0.5	0.2	0.8
Maximum:	4,659.8	1,724.6	6,289.0	104,400.0	656.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2024 00:00	3,739.4	0.0	3,739.4	104,400.0	390.4	0.5	0.2	0.8
05/24/2024 01:00	3,738.6	0.0	3,738.6	104,400.0	390.3	0.5	0.2	0.8
05/24/2024 02:00	3,736.8	0.0	3,736.8	104,400.0	390.1	0.5	0.2	0.8
05/24/2024 03:00	3,725.1	0.0	3,725.1	104,400.0	388.9	0.5	0.2	0.8
05/24/2024 04:00	3,717.9	0.0	3,717.9	104,400.0	388.1	0.5	0.2	0.8
05/24/2024 05:00	3,793.0	0.0	3,793.0	104,400.0	396.0	0.5	0.2	0.8
05/24/2024 06:00	3,746.9	0.0	3,746.9	104,400.0	391.2	0.5	0.2	0.8
05/24/2024 07:00	3,757.5	0.2	3,757.5	104,400.0	392.3	0.5	0.2	0.8
05/24/2024 08:00	3,723.9	0.0	3,723.9	104,400.0	388.8	0.5	0.2	0.8
05/24/2024 09:00	3,717.8	0.0	3,717.8	104,400.0	388.1	0.5	0.2	0.8
05/24/2024 10:00	3,712.0	0.0	3,712.0	104,400.0	387.5	0.5	0.2	0.8
05/24/2024 11:00	3,714.5	46.7	3,714.5	104,400.0	387.8	0.5	0.2	0.8
05/24/2024 12:00	3,727.0	33.2	3,727.0	104,400.0	389.1	0.5	0.2	0.8
05/24/2024 13:00	3,721.5	7.6	3,721.5	104,400.0	388.5	0.5	0.2	0.8
05/24/2024 14:00	3,723.7	0.0	3,723.7	104,400.0	388.8	0.5	0.2	0.8
05/24/2024 15:00	3,726.8	0.0	3,726.8	104,400.0	389.1	0.5	0.2	0.8
05/24/2024 16:00	3,722.6	0.0	3,722.6	104,400.0	388.6	0.5	0.2	0.8
05/24/2024 17:00	3,720.5	0.0	3,720.5	104,400.0	388.4	0.5	0.2	0.8
05/24/2024 18:00	3,723.4	0.1	3,723.4	104,400.0	388.7	0.5	0.2	0.8
05/24/2024 19:00	3,716.5	0.0	3,716.5	104,400.0	388.0	0.5	0.2	0.8
05/24/2024 20:00	3,740.4	0.0	3,740.4	104,400.0	390.5	0.5	0.2	0.8
05/24/2024 21:00	4,377.4	0.0	4,377.4	104,400.0	457.0	0.5	0.3	0.9
05/24/2024 22:00	3,852.3	0.0	3,852.3	104,400.0	402.2	0.5	0.2	0.8
05/24/2024 23:00	3,929.9	0.0	3,929.9	104,400.0	410.3	0.5	0.2	0.8
Average/Sum#:	3,771.1	3.7	3,771.1	104,400.0	393.7	0.5	0.2	0.8
Minimum:	3,712.0	0.0	3,712.0	104,400.0	387.5	0.5	0.2	0.8
Maximum:	4,377.4	46.7	4,377.4	104,400.0	457.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2024 00:00	3,862.4	0.0	3,862.4	104,400.0	403.2	0.5	0.2	0.8
05/25/2024 01:00	3,718.8	0.0	3,718.8	104,400.0	388.2	0.5	0.2	0.8
05/25/2024 02:00	3,742.6	0.0	3,742.6	104,400.0	390.7	0.5	0.2	0.8
05/25/2024 03:00	3,747.5	0.0	3,747.5	104,400.0	391.2	0.5	0.2	0.8
05/25/2024 04:00	3,748.0	0.0	3,748.0	104,400.0	391.3	0.5	0.2	0.8
05/25/2024 05:00	3,754.3	0.0	3,754.3	104,400.0	391.9	0.5	0.2	0.8
05/25/2024 06:00	3,754.1	0.0	3,754.1	104,400.0	391.9	0.5	0.2	0.8
05/25/2024 07:00	3,758.3	0.0	3,758.3	104,400.0	392.4	0.5	0.2	0.8
05/25/2024 08:00	3,773.2	0.0	3,773.2	104,400.0	393.9	0.5	0.2	0.8
05/25/2024 09:00	3,774.0	0.0	3,774.0	104,400.0	394.0	0.5	0.2	0.8
05/25/2024 10:00	3,774.4	0.1	3,774.4	104,400.0	394.0	0.5	0.2	0.8
05/25/2024 11:00	3,721.6	1.1	3,721.6	104,400.0	388.5	0.5	0.2	0.8
05/25/2024 12:00	3,721.1	9.2	3,721.1	104,400.0	388.5	0.5	0.2	0.8
05/25/2024 13:00	3,732.9	13.3	3,732.9	104,400.0	389.7	0.5	0.2	0.8
05/25/2024 14:00	3,734.0	0.0	3,734.0	104,400.0	389.8	0.5	0.2	0.8
05/25/2024 15:00	3,735.6	0.0	3,735.6	104,400.0	390.0	0.5	0.2	0.8
05/25/2024 16:00	3,737.5	0.0	3,737.5	104,400.0	390.2	0.5	0.2	0.8
05/25/2024 17:00	3,730.8	0.0	3,730.8	104,400.0	389.5	0.5	0.2	0.8
05/25/2024 18:00	3,703.6	0.0	3,703.6	104,400.0	386.7	0.5	0.2	0.8
05/25/2024 19:00	3,692.0	0.1	3,692.0	104,400.0	385.4	0.5	0.2	0.8
05/25/2024 20:00	3,716.5	0.0	3,716.5	104,400.0	388.0	0.5	0.2	0.8
05/25/2024 21:00	3,720.3	0.0	3,720.3	104,400.0	388.4	0.5	0.2	0.8
05/25/2024 22:00	3,722.8	0.0	3,722.8	104,400.0	388.7	0.5	0.2	0.8
05/25/2024 23:00	3,718.6	0.0	3,718.6	104,400.0	388.2	0.5	0.2	0.8
Average/Sum#:	3,741.5	1.0	3,741.5	104,400.0	390.6	0.5	0.2	0.8
Minimum:	3,692.0	0.0	3,692.0	104,400.0	385.4	0.5	0.2	0.8
Maximum:	3,862.4	13.3	3,862.4	104,400.0	403.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2024 00:00	3,723.5	0.0	3,723.5	104,400.0	388.7	0.5	0.2	0.8
05/26/2024 01:00	3,719.3	0.0	3,719.3	104,400.0	388.3	0.5	0.2	0.8
05/26/2024 02:00	3,721.0	0.0	3,721.0	104,400.0	388.5	0.5	0.2	0.8
05/26/2024 03:00	3,720.7	0.0	3,720.7	104,400.0	388.4	0.5	0.2	0.8
05/26/2024 04:00	3,718.6	0.0	3,718.6	104,400.0	388.2	0.5	0.2	0.8
05/26/2024 05:00	3,718.9	0.0	3,718.9	104,400.0	388.3	0.5	0.2	0.8
05/26/2024 06:00	3,715.4	0.0	3,715.4	104,400.0	387.9	0.5	0.2	0.8
05/26/2024 07:00	3,715.0	0.7	3,715.0	104,400.0	387.8	0.5	0.2	0.8
05/26/2024 08:00	3,718.3	3.1	3,718.3	104,400.0	388.2	0.5	0.2	0.8
05/26/2024 09:00	3,714.1	0.6	3,714.1	104,400.0	387.8	0.5	0.2	0.8
05/26/2024 10:00	3,692.4	2.8	3,692.4	104,400.0	385.5	0.5	0.2	0.8
05/26/2024 11:00	3,692.1	44.6	3,692.1	104,400.0	385.5	0.5	0.2	0.8
05/26/2024 12:00	3,692.9	55.8	3,692.9	104,400.0	385.5	0.5	0.2	0.8
05/26/2024 13:00	3,692.6	29.3	3,692.6	104,400.0	385.5	0.5	0.2	0.8
05/26/2024 14:00	3,692.8	0.3	3,692.8	104,400.0	385.5	0.5	0.2	0.8
05/26/2024 15:00	3,683.5	0.0	3,683.5	104,400.0	384.6	0.5	0.2	0.8
05/26/2024 16:00	3,684.8	0.0	3,684.8	104,400.0	384.7	0.5	0.2	0.8
05/26/2024 17:00	3,748.1	0.0	3,748.1	104,400.0	391.3	0.5	0.2	0.8
05/26/2024 18:00	3,696.1	0.0	3,696.1	104,400.0	385.9	0.5	0.2	0.8
05/26/2024 19:00	3,697.3	0.0	3,697.3	104,400.0	386.0	0.5	0.2	0.8
05/26/2024 20:00	3,693.4	0.0	3,693.4	104,400.0	385.6	0.5	0.2	0.8
05/26/2024 21:00	3,706.3	0.0	3,706.3	104,400.0	386.9	0.5	0.2	0.8
05/26/2024 22:00	3,733.7	0.0	3,733.7	104,400.0	389.8	0.5	0.2	0.8
05/26/2024 23:00	3,733.2	0.0	3,733.2	104,400.0	389.7	0.5	0.2	0.8
Average/Sum#:	3,709.3	5.7	3,709.3	104,400.0	387.3	0.5	0.2	0.8
Minimum:	3,683.5	0.0	3,683.5	104,400.0	384.6	0.5	0.2	0.8
Maximum:	3,748.1	55.8	3,748.1	104,400.0	391.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2024 00:00	3,729.9	0.0	3,729.9	104,400.0	389.4	0.5	0.2	0.8
05/27/2024 01:00	3,735.5	0.0	3,735.5	104,400.0	390.0	0.5	0.2	0.8
05/27/2024 02:00	3,724.7	0.0	3,724.7	104,400.0	388.9	0.5	0.2	0.8
05/27/2024 03:00	3,727.7	0.0	3,727.7	104,400.0	389.2	0.5	0.2	0.8
05/27/2024 04:00	3,733.6	0.0	3,733.6	104,400.0	389.8	0.5	0.2	0.8
05/27/2024 05:00	3,891.5	0.6	3,891.5	104,400.0	406.3	0.5	0.2	0.8
05/27/2024 06:00	3,727.5	0.2	3,727.5	104,400.0	389.2	0.5	0.2	0.8
05/27/2024 07:00	3,726.6	0.0	3,726.6	104,400.0	389.1	0.5	0.2	0.8
05/27/2024 08:00	3,727.3	6.6	3,727.3	104,400.0	389.1	0.5	0.2	0.8
05/27/2024 09:00	3,738.1	13.5	3,738.1	104,400.0	390.3	0.5	0.2	0.8
05/27/2024 10:00	3,721.0	30.7	3,721.0	104,400.0	388.5	0.5	0.2	0.8
05/27/2024 11:00	3,696.4	77.6	3,696.4	104,400.0	385.9	0.5	0.2	0.8
05/27/2024 12:00	3,692.5	75.8	3,692.5	104,400.0	385.5	0.5	0.2	0.8
05/27/2024 13:00	3,673.7	42.7	3,673.7	104,400.0	383.5	0.5	0.2	0.8
05/27/2024 14:00	3,665.2	0.3	3,665.2	104,400.0	382.6	0.5	0.2	0.8
05/27/2024 15:00	3,679.9	0.0	3,679.9	104,400.0	384.2	0.5	0.2	0.8
05/27/2024 16:00	3,953.3	70.0	3,969.4	104,400.0	414.4	0.5	0.3	0.8
05/27/2024 17:00	3,899.8	10.5	3,900.1	104,400.0	407.2	0.5	0.2	0.8
05/27/2024 18:00	4,648.2	898.2	5,411.7	104,400.0	565.0	0.7	0.3	1.2
05/27/2024 19:00	4,670.7	1,428.3	6,099.0	104,400.0	636.7	0.8	0.4	1.3
05/27/2024 20:00	4,705.0	760.8	5,465.8	104,400.0	570.6	0.7	0.3	1.1
05/27/2024 21:00	4,635.5	420.4	4,980.2	104,400.0	519.9	0.6	0.3	1.1
05/27/2024 22:00	4,002.1	0.0	4,002.1	104,400.0	417.8	0.5	0.3	0.8
05/27/2024 23:00	4,151.8	0.0	4,151.8	104,400.0	433.4	0.5	0.3	0.9
Average/Sum#:	3,927.4	159.8	4,065.5	104,400.0	424.4	0.5	0.2	0.9
Minimum:	3,665.2	0.0	3,665.2	104,400.0	382.6	0.5	0.2	0.8
Maximum:	4,705.0	1,428.3	6,099.0	104,400.0	636.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2024 00:00	3,719.0	0.0	3,719.0	104,400.0	388.3	0.5	0.2	0.8
05/28/2024 01:00	3,740.3	0.0	3,740.3	104,400.0	390.5	0.5	0.2	0.8
05/28/2024 02:00	3,748.6	0.0	3,748.6	104,400.0	391.4	0.5	0.2	0.8
05/28/2024 03:00	3,744.3	0.0	3,744.3	104,400.0	390.9	0.5	0.2	0.8
05/28/2024 04:00	3,750.7	0.0	3,750.7	104,400.0	391.6	0.5	0.2	0.8
05/28/2024 05:00	3,748.4	0.0	3,748.4	104,400.0	391.3	0.5	0.2	0.8
05/28/2024 06:00	3,745.5	0.0	3,745.5	104,400.0	391.0	0.5	0.2	0.8
05/28/2024 07:00	3,749.1	0.2	3,749.1	104,400.0	391.4	0.5	0.2	0.8
05/28/2024 08:00	3,745.5	0.1	3,745.5	104,400.0	391.0	0.5	0.2	0.8
05/28/2024 09:00	3,745.3	11.5	3,745.3	104,400.0	391.0	0.5	0.2	0.8
05/28/2024 10:00	3,732.4	35.4	3,732.4	104,400.0	389.7	0.5	0.2	0.8
05/28/2024 11:00	3,742.9	74.5	3,742.9	104,400.0	390.8	0.5	0.2	0.8
05/28/2024 12:00	3,739.6	67.0	3,739.6	104,400.0	390.4	0.5	0.2	0.8
05/28/2024 13:00	3,734.3	38.8	3,734.3	104,400.0	389.9	0.5	0.2	0.8
05/28/2024 14:00	3,725.2	0.0	3,725.2	104,400.0	388.9	0.5	0.2	0.8
05/28/2024 15:00	3,704.2	0.0	3,704.2	104,400.0	386.7	0.5	0.2	0.8
05/28/2024 16:00	3,685.8	0.0	3,685.8	104,400.0	384.8	0.5	0.2	0.8
05/28/2024 17:00	4,063.2	1.7	4,063.3	104,400.0	424.2	0.5	0.3	0.8
05/28/2024 18:00	4,292.7	0.0	4,292.7	104,400.0	448.2	0.5	0.3	0.9
05/28/2024 19:00	4,204.8	0.0	4,204.8	104,400.0	439.0	0.5	0.3	0.9
05/28/2024 20:00	3,708.4	0.2	3,708.4	104,400.0	387.2	0.5	0.2	0.8
05/28/2024 21:00	3,711.0	0.0	3,711.0	104,400.0	387.4	0.5	0.2	0.8
05/28/2024 22:00	3,729.4	0.0	3,729.4	104,400.0	389.3	0.5	0.2	0.8
05/28/2024 23:00	3,738.7	0.0	3,738.7	104,400.0	390.3	0.5	0.2	0.8
Average/Sum#:	3,789.6	9.6	3,789.6	104,400.0	395.6	0.5	0.2	0.8
Minimum:	3,685.8	0.0	3,685.8	104,400.0	384.8	0.5	0.2	0.8
Maximum:	4,292.7	74.5	4,292.7	104,400.0	448.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2024 00:00	3,744.5	0.0	3,744.5	104,400.0	390.9	0.5	0.2	0.8
05/29/2024 01:00	3,743.5	0.0	3,743.5	104,400.0	390.8	0.5	0.2	0.8
05/29/2024 02:00	3,737.0	0.0	3,737.0	104,400.0	390.1	0.5	0.2	0.8
05/29/2024 03:00	3,735.0	0.0	3,735.0	104,400.0	389.9	0.5	0.2	0.8
05/29/2024 04:00	3,742.2	0.0	3,742.2	104,400.0	390.7	0.5	0.2	0.8
05/29/2024 05:00	3,742.2	0.0	3,742.2	104,400.0	390.7	0.5	0.2	0.8
05/29/2024 06:00	3,741.2	0.8	3,741.2	104,400.0	390.6	0.5	0.2	0.8
05/29/2024 07:00	3,739.5	0.0	3,739.5	104,400.0	390.4	0.5	0.2	0.8
05/29/2024 08:00	3,823.4	0.0	3,823.4	104,400.0	399.2	0.5	0.2	0.8
05/29/2024 09:00	3,786.1	0.0	3,786.1	104,400.0	395.3	0.5	0.2	0.8
05/29/2024 10:00	4,522.5	0.1	4,522.5	104,400.0	472.1	0.6	0.3	0.9
05/29/2024 11:00	4,070.4	13.5	4,070.4	104,400.0	424.9	0.5	0.3	0.9
05/29/2024 12:00	3,891.3	4.7	3,891.3	104,400.0	406.3	0.5	0.2	0.8
05/29/2024 13:00	4,689.8	0.1	4,689.8	104,400.0	489.6	0.6	0.3	1.0
05/29/2024 14:00	4,662.0	0.0	4,662.0	104,400.0	486.7	0.6	0.3	1.0
05/29/2024 15:00	4,179.9	0.0	4,179.9	104,400.0	436.4	0.5	0.3	0.9
05/29/2024 16:00	4,281.6	0.0	4,281.6	104,400.0	447.0	0.5	0.3	0.9
05/29/2024 17:00	4,243.2	0.0	4,243.2	104,400.0	443.0	0.5	0.3	0.9
05/29/2024 18:00	4,246.6	0.0	4,246.6	104,400.0	443.3	0.5	0.3	0.9
05/29/2024 19:00	4,266.0	0.0	4,266.0	104,400.0	445.4	0.5	0.3	0.9
05/29/2024 20:00	4,266.9	0.0	4,266.9	104,400.0	445.5	0.5	0.3	0.9
05/29/2024 21:00	4,264.4	0.2	4,264.4	104,400.0	445.2	0.5	0.3	0.9
05/29/2024 22:00	4,249.1	0.1	4,249.1	104,400.0	443.6	0.5	0.3	0.9
05/29/2024 23:00	2,376.7	0.0	2,376.7	104,400.0	248.1	0.0	0.0	0.0
Average/Sum#:	3,989.4	0.8	3,989.4	104,400.0	416.5	0.5	0.3	0.9
Minimum:	2,376.7	0.0	2,376.7	104,400.0	248.1	0.5	0.2	0.8
Maximum:	4,689.8	13.5	4,689.8	104,400.0	489.6	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
05/30/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
05/30/2024 10:00	616.8	0.0	616.8	104,400.0	64.4	0.0	0.0	0.0
05/30/2024 11:00	4,105.8	43.4	4,105.8	104,400.0	428.6	0.6	0.3	1.0
05/30/2024 12:00	4,576.9	32.3	4,576.9	104,400.0	477.8	0.6	0.3	1.0
05/30/2024 13:00	4,650.2	1.0	4,650.2	104,400.0	485.5	0.6	0.3	1.0
05/30/2024 14:00	4,053.9	0.0	4,053.9	104,400.0	423.2	0.5	0.3	0.8
05/30/2024 15:00	3,720.1	0.0	3,720.1	104,400.0	388.4	0.5	0.2	0.8
05/30/2024 16:00	3,731.2	0.0	3,731.2	104,400.0	389.5	0.5	0.2	0.8
05/30/2024 17:00	3,937.9	0.0	3,937.9	104,400.0	411.1	0.5	0.2	0.8
05/30/2024 18:00	4,297.4	0.0	4,297.4	104,400.0	448.6	0.5	0.3	0.9
05/30/2024 19:00	3,971.1	0.0	3,971.1	104,400.0	414.6	0.5	0.2	0.8
05/30/2024 20:00	3,733.2	0.0	3,733.2	104,400.0	389.7	0.5	0.2	0.8
05/30/2024 21:00	3,737.6	0.0	3,737.6	104,400.0	390.2	0.5	0.2	0.8
05/30/2024 22:00	3,736.5	0.0	3,736.5	104,400.0	390.1	0.5	0.2	0.8
05/30/2024 23:00	3,731.4	0.0	3,731.4	104,400.0	389.6	0.5	0.2	0.8
Average/Sum#:	3,757.1	5.5	3,757.1	104,400.0	392.2	0.5	0.2	0.9
Minimum:	616.8	0.0	616.8	104,400.0	64.4	0.5	0.2	0.8
Maximum:	4,650.2	43.4	4,650.2	104,400.0	485.5	0.6	0.3	1.0
%SI	41.67	41.67	41.67	0.00	41.67	45.83	45.83	45.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2024 00:00	3,728.9	0.0	3,728.9	104,400.0	389.3	0.5	0.2	0.8
05/31/2024 01:00	3,724.1	0.0	3,724.1	104,400.0	388.8	0.5	0.2	0.8
05/31/2024 02:00	3,725.4	0.0	3,725.4	104,400.0	388.9	0.5	0.2	0.8
05/31/2024 03:00	3,727.7	0.0	3,727.7	104,400.0	389.2	0.5	0.2	0.8
05/31/2024 04:00	3,751.9	0.0	3,751.9	104,400.0	391.7	0.5	0.2	0.8
05/31/2024 05:00	3,832.8	0.0	3,832.8	104,400.0	400.1	0.5	0.2	0.8
05/31/2024 06:00	3,722.0	0.1	3,722.0	104,400.0	388.6	0.5	0.2	0.8
05/31/2024 07:00	3,724.9	0.0	3,724.9	104,400.0	388.9	0.5	0.2	0.8
05/31/2024 08:00	3,725.0	0.0	3,725.0	104,400.0	388.9	0.5	0.2	0.8
05/31/2024 09:00	3,729.9	0.6	3,729.9	104,400.0	389.4	0.5	0.2	0.8
05/31/2024 10:00	3,728.6	32.0	3,728.6	104,400.0	389.3	0.5	0.2	0.8
05/31/2024 11:00	3,711.6	60.2	3,711.6	104,400.0	387.5	0.5	0.2	0.8
05/31/2024 12:00	3,691.6	56.2	3,691.6	104,400.0	385.4	0.5	0.2	0.8
05/31/2024 13:00	3,689.7	24.0	3,689.7	104,400.0	385.2	0.5	0.2	0.8
05/31/2024 14:00	3,683.4	0.0	3,683.4	104,400.0	384.5	0.5	0.2	0.8
05/31/2024 15:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
05/31/2024 16:00	3,778.3	0.0	3,778.3	104,400.0	394.5	0.5	0.2	0.8
05/31/2024 17:00	3,920.5	0.0	3,920.5	104,400.0	409.3	0.5	0.2	0.8
05/31/2024 18:00	4,535.4	0.0	4,535.4	104,400.0	473.5	0.6	0.3	0.9
05/31/2024 19:00	4,347.7	0.0	4,347.7	104,400.0	453.9	0.5	0.3	0.9
05/31/2024 20:00	3,968.0	0.0	3,968.0	104,400.0	414.3	0.5	0.2	0.8
05/31/2024 21:00	3,993.9	0.0	3,993.9	104,400.0	417.0	0.5	0.3	0.8
05/31/2024 22:00	3,753.8	0.0	3,753.8	104,400.0	391.9	0.5	0.2	0.8
05/31/2024 23:00	3,746.5	0.0	3,746.5	104,400.0	391.1	0.5	0.2	0.8
Average/Sum#:	3,817.5	7.2	3,817.5	104,400.0	398.5	0.5	0.2	0.8
Minimum:	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
Maximum:	4,535.4	60.2	4,535.4	104,400.0	473.5	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2024 00:00	3,739.7	0.0	3,739.7	104,400.0	390.4	0.5	0.2	0.8
06/01/2024 01:00	3,743.1	0.0	3,743.1	104,400.0	390.8	0.5	0.2	0.8
06/01/2024 02:00	3,767.1	0.0	3,767.1	104,400.0	393.3	0.5	0.2	0.8
06/01/2024 03:00	3,776.0	0.0	3,776.0	104,400.0	394.2	0.5	0.2	0.8
06/01/2024 04:00	3,773.6	0.0	3,773.6	104,400.0	394.0	0.5	0.2	0.8
06/01/2024 05:00	3,774.4	0.0	3,774.4	104,400.0	394.0	0.5	0.2	0.8
06/01/2024 06:00	3,766.6	0.1	3,766.6	104,400.0	393.2	0.5	0.2	0.8
06/01/2024 07:00	3,761.7	0.0	3,761.7	104,400.0	392.7	0.5	0.2	0.8
06/01/2024 08:00	3,765.2	0.0	3,765.2	104,400.0	393.1	0.5	0.2	0.8
06/01/2024 09:00	3,739.7	0.0	3,739.7	104,400.0	390.4	0.5	0.2	0.8
06/01/2024 10:00	3,741.4	28.2	3,741.4	104,400.0	390.6	0.5	0.2	0.8
06/01/2024 11:00	3,734.5	50.1	3,734.5	104,400.0	389.9	0.5	0.2	0.8
06/01/2024 12:00	3,733.6	54.4	3,733.6	104,400.0	389.8	0.5	0.2	0.8
06/01/2024 13:00	3,734.8	16.3	3,734.8	104,400.0	389.9	0.5	0.2	0.8
06/01/2024 14:00	3,729.1	0.0	3,729.1	104,400.0	389.3	0.5	0.2	0.8
06/01/2024 15:00	3,696.8	0.0	3,696.8	104,400.0	385.9	0.5	0.2	0.8
06/01/2024 16:00	3,692.7	0.0	3,692.7	104,400.0	385.5	0.5	0.2	0.8
06/01/2024 17:00	3,771.6	0.0	3,771.6	104,400.0	393.8	0.5	0.2	0.8
06/01/2024 18:00	3,701.2	0.0	3,701.2	104,400.0	386.4	0.5	0.2	0.8
06/01/2024 19:00	3,719.1	0.0	3,719.1	104,400.0	388.3	0.5	0.2	0.8
06/01/2024 20:00	3,720.2	0.0	3,720.2	104,400.0	388.4	0.5	0.2	0.8
06/01/2024 21:00	3,736.2	0.0	3,736.2	104,400.0	390.1	0.5	0.2	0.8
06/01/2024 22:00	3,741.7	0.0	3,741.7	104,400.0	390.6	0.5	0.2	0.8
06/01/2024 23:00	3,739.5	0.0	3,739.5	104,400.0	390.4	0.5	0.2	0.8
Average/Sum#:	3,741.6	6.2	3,741.6	104,400.0	390.6	0.5	0.2	0.8
Minimum:	3,692.7	0.0	3,692.7	104,400.0	385.5	0.5	0.2	0.8
Maximum:	3,776.0	54.4	3,776.0	104,400.0	394.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2024 00:00	3,728.0	0.0	3,728.0	104,400.0	389.2	0.5	0.2	0.8
06/02/2024 01:00	3,719.9	0.0	3,719.9	104,400.0	388.4	0.5	0.2	0.8
06/02/2024 02:00	3,724.5	0.0	3,724.5	104,400.0	388.8	0.5	0.2	0.8
06/02/2024 03:00	3,718.1	0.0	3,718.1	104,400.0	388.2	0.5	0.2	0.8
06/02/2024 04:00	3,720.4	0.0	3,720.4	104,400.0	388.4	0.5	0.2	0.8
06/02/2024 05:00	3,712.5	0.0	3,712.5	104,400.0	387.6	0.5	0.2	0.8
06/02/2024 06:00	3,834.1	0.0	3,834.1	104,400.0	400.3	0.5	0.2	0.8
06/02/2024 07:00	3,736.9	0.0	3,736.9	104,400.0	390.1	0.5	0.2	0.8
06/02/2024 08:00	3,751.2	0.0	3,751.2	104,400.0	391.6	0.5	0.2	0.8
06/02/2024 09:00	3,814.3	1.5	3,814.3	104,400.0	398.2	0.5	0.2	0.8
06/02/2024 10:00	3,743.7	30.1	3,743.7	104,400.0	390.8	0.5	0.2	0.8
06/02/2024 11:00	3,722.9	65.3	3,722.9	104,400.0	388.7	0.5	0.2	0.8
06/02/2024 12:00	3,715.1	47.9	3,715.1	104,400.0	387.9	0.5	0.2	0.8
06/02/2024 13:00	3,958.8	21.1	3,958.8	104,400.0	413.3	0.5	0.2	0.8
06/02/2024 14:00	4,211.3	0.0	4,211.3	104,400.0	439.7	0.5	0.3	0.9
06/02/2024 15:00	4,655.7	965.2	5,524.4	104,400.0	576.7	0.7	0.4	1.2
06/02/2024 16:00	4,655.4	1,337.5	5,992.9	104,400.0	625.7	0.8	0.4	1.3
06/02/2024 17:00	3,923.4	51.4	3,929.6	104,400.0	410.3	0.5	0.2	0.8
06/02/2024 18:00	3,674.1	0.0	3,674.1	104,400.0	383.6	0.5	0.2	0.8
06/02/2024 19:00	3,845.7	0.0	3,845.7	104,400.0	401.5	0.5	0.2	0.8
06/02/2024 20:00	3,725.3	0.0	3,725.3	104,400.0	388.9	0.5	0.2	0.8
06/02/2024 21:00	3,713.2	0.0	3,713.2	104,400.0	387.7	0.5	0.2	0.8
06/02/2024 22:00	3,719.2	0.1	3,719.2	104,400.0	388.3	0.5	0.2	0.8
06/02/2024 23:00	3,718.2	0.0	3,718.2	104,400.0	388.2	0.5	0.2	0.8
Average/Sum#:	3,851.7	105.0	3,943.9	104,400.0	411.8	0.5	0.2	0.8
Minimum:	3,674.1	0.0	3,674.1	104,400.0	383.6	0.5	0.2	0.8
Maximum:	4,655.7	1,337.5	5,992.9	104,400.0	625.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2024 00:00	3,727.2	0.0	3,727.2	104,400.0	389.1	0.5	0.2	0.8
06/03/2024 01:00	3,718.4	0.0	3,718.4	104,400.0	388.2	0.5	0.2	0.8
06/03/2024 02:00	3,713.9	0.0	3,713.9	104,400.0	387.7	0.5	0.2	0.8
06/03/2024 03:00	3,708.6	0.0	3,708.6	104,400.0	387.2	0.5	0.2	0.8
06/03/2024 04:00	3,713.2	0.0	3,713.2	104,400.0	387.7	0.5	0.2	0.8
06/03/2024 05:00	3,705.2	0.0	3,705.2	104,400.0	386.8	0.5	0.2	0.8
06/03/2024 06:00	3,721.5	0.0	3,721.5	104,400.0	388.5	0.5	0.2	0.8
06/03/2024 07:00	3,729.3	0.0	3,729.3	104,400.0	389.3	0.5	0.2	0.8
06/03/2024 08:00	3,729.0	0.0	3,729.0	104,400.0	389.3	0.5	0.2	0.8
06/03/2024 09:00	3,705.8	0.0	3,705.8	104,400.0	386.9	0.5	0.2	0.8
06/03/2024 10:00	3,707.8	0.0	3,707.8	104,400.0	387.1	0.5	0.2	0.8
06/03/2024 11:00	3,701.2	1.4	3,701.2	104,400.0	386.4	0.5	0.2	0.8
06/03/2024 12:00	3,710.7	0.0	3,710.7	104,400.0	387.4	0.5	0.2	0.8
06/03/2024 13:00	3,709.9	0.1	3,709.9	104,400.0	387.3	0.5	0.2	0.8
06/03/2024 14:00	3,714.2	0.0	3,714.2	104,400.0	387.8	0.5	0.2	0.8
06/03/2024 15:00	3,709.3	0.0	3,709.3	104,400.0	387.3	0.5	0.2	0.8
06/03/2024 16:00	3,691.7	0.0	3,691.7	104,400.0	385.4	0.5	0.2	0.8
06/03/2024 17:00	3,663.5	0.0	3,663.5	104,400.0	382.5	0.5	0.2	0.8
06/03/2024 18:00	3,686.9	0.0	3,686.9	104,400.0	384.9	0.5	0.2	0.8
06/03/2024 19:00	3,693.0	0.0	3,693.0	104,400.0	385.5	0.5	0.2	0.8
06/03/2024 20:00	3,688.0	0.0	3,688.0	104,400.0	385.0	0.5	0.2	0.8
06/03/2024 21:00	3,695.2	0.0	3,695.2	104,400.0	385.8	0.5	0.2	0.8
06/03/2024 22:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
06/03/2024 23:00	3,670.8	0.0	3,670.8	104,400.0	383.2	0.5	0.2	0.8
Average/Sum#:	3,703.8	0.1	3,703.8	104,400.0	386.7	0.5	0.2	0.8
Minimum:	3,663.5	0.0	3,663.5	104,400.0	382.5	0.5	0.2	0.8
Maximum:	3,729.3	1.4	3,729.3	104,400.0	389.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2024 00:00	3,675.5	0.0	3,675.5	104,400.0	383.7	0.5	0.2	0.8
06/04/2024 01:00	3,676.5	0.0	3,676.5	104,400.0	383.8	0.5	0.2	0.8
06/04/2024 02:00	3,675.3	0.0	3,675.3	104,400.0	383.7	0.5	0.2	0.8
06/04/2024 03:00	3,673.3	0.0	3,673.3	104,400.0	383.5	0.5	0.2	0.8
06/04/2024 04:00	3,679.3	0.0	3,679.3	104,400.0	384.1	0.5	0.2	0.8
06/04/2024 05:00	3,678.8	0.0	3,678.8	104,400.0	384.1	0.5	0.2	0.8
06/04/2024 06:00	3,679.9	0.0	3,679.9	104,400.0	384.2	0.5	0.2	0.8
06/04/2024 07:00	3,682.3	0.0	3,682.3	104,400.0	384.4	0.5	0.2	0.8
06/04/2024 08:00	3,679.6	0.0	3,679.6	104,400.0	384.2	0.5	0.2	0.8
06/04/2024 09:00	3,669.1	0.1	3,669.1	104,400.0	383.1	0.5	0.2	0.8
06/04/2024 10:00	3,666.2	1.3	3,666.2	104,400.0	382.8	0.5	0.2	0.8
06/04/2024 11:00	3,655.7	2.1	3,655.7	104,400.0	381.7	0.5	0.2	0.8
06/04/2024 12:00	3,673.4	2.6	3,673.4	104,800.0	385.0	0.5	0.2	0.8
06/04/2024 13:00	3,681.9	0.1	3,681.9	104,800.0	385.9	0.5	0.2	0.8
06/04/2024 14:00	3,679.3	0.0	3,679.3	104,800.0	385.6	0.5	0.2	0.8
06/04/2024 15:00	3,686.7	0.0	3,686.7	104,800.0	386.4	0.5	0.2	0.8
06/04/2024 16:00	4,077.1	0.0	4,077.1	104,800.0	427.3	0.5	0.3	0.9
06/04/2024 17:00	4,439.7	0.0	4,439.7	104,800.0	465.3	0.6	0.3	0.9
06/04/2024 18:00	4,250.3	0.0	4,250.3	104,800.0	445.4	0.5	0.3	0.9
06/04/2024 19:00	4,360.5	0.0	4,360.5	104,800.0	457.0	0.5	0.3	0.9
06/04/2024 20:00	3,875.8	0.0	3,875.8	104,800.0	406.2	0.5	0.2	0.8
06/04/2024 21:00	3,731.6	0.0	3,731.6	104,800.0	391.1	0.5	0.2	0.8
06/04/2024 22:00	3,752.8	0.0	3,752.8	104,800.0	393.3	0.5	0.2	0.8
06/04/2024 23:00	3,756.5	0.0	3,756.5	104,800.0	393.7	0.5	0.2	0.8
Average/Sum#:	3,794.0	0.3	3,794.0	104,600.0	396.9	0.5	0.2	0.8
Minimum:	3,655.7	0.0	3,655.7	104,400.0	381.7	0.5	0.2	0.8
Maximum:	4,439.7	2.6	4,439.7	104,800.0	465.3	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2024 00:00	4,252.4	0.0	4,252.4	104,800.0	445.7	0.5	0.3	0.9
06/05/2024 01:00	4,182.2	0.0	4,182.2	104,800.0	438.3	0.5	0.3	0.9
06/05/2024 02:00	3,746.2	0.0	3,746.2	104,800.0	392.6	0.5	0.2	0.8
06/05/2024 03:00	3,734.9	0.0	3,734.9	104,800.0	391.4	0.5	0.2	0.8
06/05/2024 04:00	3,848.1	0.2	3,848.1	104,800.0	403.3	0.5	0.2	0.8
06/05/2024 05:00	3,976.3	0.1	3,976.3	104,800.0	416.7	0.5	0.3	0.8
06/05/2024 06:00	3,739.6	0.0	3,739.6	104,800.0	391.9	0.5	0.2	0.8
06/05/2024 07:00	3,734.7	2.4	3,734.7	104,800.0	391.4	0.5	0.2	0.8
06/05/2024 08:00	3,721.3	23.6	3,721.3	104,800.0	390.0	0.5	0.2	0.8
06/05/2024 09:00	3,703.1	43.9	3,703.1	104,800.0	388.1	0.5	0.2	0.8
06/05/2024 10:00	3,704.2	56.4	3,704.2	104,800.0	388.2	0.5	0.2	0.8
06/05/2024 11:00	4,179.0	72.2	4,179.0	104,800.0	438.0	0.5	0.3	0.9
06/05/2024 12:00	3,961.7	144.4	3,983.4	104,800.0	417.5	0.5	0.3	0.9
06/05/2024 13:00	4,485.4	786.7	5,272.1	104,800.0	552.5	0.7	0.3	1.1
06/05/2024 14:00	4,209.6	287.8	4,347.7	104,800.0	455.6	0.6	0.3	0.9
06/05/2024 15:00	4,477.8	646.6	5,124.4	104,800.0	537.0	0.6	0.3	1.1
06/05/2024 16:00	3,802.5	16.9	3,803.7	104,800.0	398.6	0.5	0.2	0.8
06/05/2024 17:00	4,165.3	245.9	4,263.7	104,800.0	446.8	0.6	0.3	0.9
06/05/2024 18:00	4,482.0	53.0	4,488.4	104,800.0	470.4	0.6	0.3	0.9
06/05/2024 19:00	4,497.9	0.0	4,497.9	104,800.0	471.4	0.6	0.3	0.9
06/05/2024 20:00	4,238.5	0.0	4,238.5	104,800.0	444.2	0.5	0.3	0.9
06/05/2024 21:00	4,092.7	3.8	4,092.9	104,800.0	428.9	0.5	0.3	0.9
06/05/2024 22:00	3,844.5	0.0	3,844.5	104,800.0	402.9	0.5	0.2	0.8
06/05/2024 23:00	4,005.0	19.0	4,007.3	104,800.0	420.0	0.5	0.3	0.8
Average/Sum#:	4,032.7	100.1	4,103.6	104,800.0	430.1	0.5	0.3	0.9
Minimum:	3,703.1	0.0	3,703.1	104,800.0	388.1	0.5	0.2	0.8
Maximum:	4,497.9	786.7	5,272.1	104,800.0	552.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2024 00:00	3,724.5	0.0	3,724.5	104,800.0	390.3	0.5	0.2	0.8
06/06/2024 01:00	3,720.1	0.0	3,720.1	104,800.0	389.9	0.5	0.2	0.8
06/06/2024 02:00	3,722.4	0.0	3,722.4	104,800.0	390.1	0.5	0.2	0.8
06/06/2024 03:00	3,715.0	0.0	3,715.0	104,800.0	389.3	0.5	0.2	0.8
06/06/2024 04:00	3,718.6	0.0	3,718.6	104,800.0	389.7	0.5	0.2	0.8
06/06/2024 05:00	3,722.8	0.0	3,722.8	104,800.0	390.1	0.5	0.2	0.8
06/06/2024 06:00	3,728.5	0.0	3,728.5	104,800.0	390.7	0.5	0.2	0.8
06/06/2024 07:00	3,727.8	10.5	3,727.8	104,800.0	390.7	0.5	0.2	0.8
06/06/2024 08:00	3,733.8	36.4	3,733.8	104,800.0	391.3	0.5	0.2	0.8
06/06/2024 09:00	3,726.4	64.5	3,726.4	104,800.0	390.5	0.5	0.2	0.8
06/06/2024 10:00	3,716.8	89.6	3,716.8	104,800.0	389.5	0.5	0.2	0.8
06/06/2024 11:00	3,720.1	90.2	3,720.1	104,800.0	389.9	0.5	0.2	0.8
06/06/2024 12:00	3,880.9	84.3	3,880.9	104,800.0	406.7	0.5	0.2	0.8
06/06/2024 13:00	4,021.1	48.7	4,021.1	104,800.0	421.4	0.5	0.3	0.9
06/06/2024 14:00	3,960.1	1.8	3,960.1	104,800.0	415.0	0.5	0.2	0.8
06/06/2024 15:00	3,887.4	0.0	3,887.4	104,800.0	407.4	0.5	0.2	0.8
06/06/2024 16:00	4,087.2	0.1	4,087.2	104,800.0	428.3	0.5	0.3	0.9
06/06/2024 17:00	4,173.8	0.0	4,173.8	104,800.0	437.4	0.5	0.3	0.9
06/06/2024 18:00	4,534.9	0.0	4,534.9	104,800.0	475.3	0.6	0.3	1.0
06/06/2024 19:00	4,409.8	0.0	4,409.8	104,800.0	462.1	0.6	0.3	0.9
06/06/2024 20:00	3,858.2	0.0	3,858.2	104,800.0	404.3	0.5	0.2	0.8
06/06/2024 21:00	3,726.8	0.0	3,726.8	104,800.0	390.6	0.5	0.2	0.8
06/06/2024 22:00	3,726.8	0.0	3,726.8	104,800.0	390.6	0.5	0.2	0.8
06/06/2024 23:00	3,720.5	0.0	3,720.5	104,800.0	389.9	0.5	0.2	0.8
Average/Sum#:	3,861.0	17.8	3,861.0	104,800.0	404.6	0.5	0.2	0.8
Minimum:	3,715.0	0.0	3,715.0	104,800.0	389.3	0.5	0.2	0.8
Maximum:	4,534.9	90.2	4,534.9	104,800.0	475.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2024 00:00	3,711.9	0.0	3,711.9	104,800.0	389.0	0.5	0.2	0.8
06/07/2024 01:00	3,709.3	0.0	3,709.3	104,800.0	388.7	0.5	0.2	0.8
06/07/2024 02:00	3,709.1	0.0	3,709.1	104,800.0	388.7	0.5	0.2	0.8
06/07/2024 03:00	3,744.5	0.0	3,744.5	104,800.0	392.4	0.5	0.2	0.8
06/07/2024 04:00	3,740.0	0.0	3,740.0	104,800.0	392.0	0.5	0.2	0.8
06/07/2024 05:00	3,957.6	0.0	3,957.6	104,800.0	414.8	0.5	0.2	0.8
06/07/2024 06:00	3,745.1	0.0	3,745.1	104,800.0	392.5	0.5	0.2	0.8
06/07/2024 07:00	3,744.8	0.0	3,744.8	104,800.0	392.5	0.5	0.2	0.8
06/07/2024 08:00	3,735.3	0.0	3,735.3	104,800.0	391.5	0.5	0.2	0.8
06/07/2024 09:00	3,717.5	29.7	3,717.5	104,800.0	389.6	0.5	0.2	0.8
06/07/2024 10:00	3,723.3	74.3	3,723.3	104,800.0	390.2	0.5	0.2	0.8
06/07/2024 11:00	3,735.4	81.8	3,735.4	104,800.0	391.5	0.5	0.2	0.8
06/07/2024 12:00	3,741.0	76.4	3,741.0	104,800.0	392.1	0.5	0.2	0.8
06/07/2024 13:00	3,746.0	50.5	3,746.0	104,800.0	392.6	0.5	0.2	0.8
06/07/2024 14:00	3,774.8	0.9	3,774.8	104,800.0	395.6	0.5	0.2	0.8
06/07/2024 15:00	3,719.8	0.0	3,719.8	104,800.0	389.8	0.5	0.2	0.8
06/07/2024 16:00	3,718.3	0.0	3,718.3	104,800.0	389.7	0.5	0.2	0.8
06/07/2024 17:00	3,877.5	0.0	3,877.5	104,800.0	406.4	0.5	0.2	0.8
06/07/2024 18:00	4,255.4	0.0	4,255.4	104,800.0	446.0	0.5	0.3	0.9
06/07/2024 19:00	4,251.7	0.0	4,251.7	104,800.0	445.6	0.5	0.3	0.9
06/07/2024 20:00	3,998.4	0.0	3,998.4	104,800.0	419.0	0.5	0.3	0.8
06/07/2024 21:00	3,702.0	0.0	3,702.0	104,800.0	388.0	0.5	0.2	0.8
06/07/2024 22:00	3,712.0	0.0	3,712.0	104,800.0	389.0	0.5	0.2	0.8
06/07/2024 23:00	3,733.4	0.0	3,733.4	104,800.0	391.3	0.5	0.2	0.8
Average/Sum#:	3,800.2	13.1	3,800.2	104,800.0	398.3	0.5	0.2	0.8
Minimum:	3,702.0	0.0	3,702.0	104,800.0	388.0	0.5	0.2	0.8
Maximum:	4,255.4	81.8	4,255.4	104,800.0	446.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2024 00:00	3,731.8	0.0	3,731.8	104,800.0	391.1	0.5	0.2	0.8
06/08/2024 01:00	3,725.9	0.0	3,725.9	104,800.0	390.5	0.5	0.2	0.8
06/08/2024 02:00	3,733.8	0.0	3,733.8	104,800.0	391.3	0.5	0.2	0.8
06/08/2024 03:00	3,759.7	0.0	3,759.7	104,800.0	394.0	0.5	0.2	0.8
06/08/2024 04:00	3,746.6	0.0	3,746.6	104,800.0	392.6	0.5	0.2	0.8
06/08/2024 05:00	3,738.2	0.0	3,738.2	104,800.0	391.8	0.5	0.2	0.8
06/08/2024 06:00	3,737.6	0.0	3,737.6	104,800.0	391.7	0.5	0.2	0.8
06/08/2024 07:00	3,739.6	0.0	3,739.6	104,800.0	391.9	0.5	0.2	0.8
06/08/2024 08:00	3,750.8	0.0	3,750.8	104,800.0	393.1	0.5	0.2	0.8
06/08/2024 09:00	3,723.3	0.0	3,723.3	104,800.0	390.2	0.5	0.2	0.8
06/08/2024 10:00	3,716.9	31.0	3,716.9	104,800.0	389.5	0.5	0.2	0.8
06/08/2024 11:00	3,714.1	54.3	3,714.1	104,800.0	389.2	0.5	0.2	0.8
06/08/2024 12:00	3,717.1	16.8	3,717.1	104,800.0	389.6	0.5	0.2	0.8
06/08/2024 13:00	3,725.4	0.0	3,725.4	104,800.0	390.4	0.5	0.2	0.8
06/08/2024 14:00	3,718.8	0.0	3,718.8	104,800.0	389.7	0.5	0.2	0.8
06/08/2024 15:00	3,717.2	0.0	3,717.2	104,800.0	389.6	0.5	0.2	0.8
06/08/2024 16:00	3,722.1	0.0	3,722.1	104,800.0	390.1	0.5	0.2	0.8
06/08/2024 17:00	3,729.1	0.0	3,729.1	104,800.0	390.8	0.5	0.2	0.8
06/08/2024 18:00	3,721.2	0.0	3,721.2	104,800.0	390.0	0.5	0.2	0.8
06/08/2024 19:00	3,722.6	0.0	3,722.6	104,800.0	390.1	0.5	0.2	0.8
06/08/2024 20:00	3,728.2	0.0	3,728.2	104,800.0	390.7	0.5	0.2	0.8
06/08/2024 21:00	3,739.1	0.0	3,739.1	104,800.0	391.9	0.5	0.2	0.8
06/08/2024 22:00	3,735.4	0.0	3,735.4	104,800.0	391.5	0.5	0.2	0.8
06/08/2024 23:00	3,732.4	0.0	3,732.4	104,800.0	391.2	0.5	0.2	0.8
Average/Sum#:	3,730.3	4.3	3,730.3	104,800.0	390.9	0.5	0.2	0.8
Minimum:	3,714.1	0.0	3,714.1	104,800.0	389.2	0.5	0.2	0.8
Maximum:	3,759.7	54.3	3,759.7	104,800.0	394.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2024 00:00	3,734.9	0.0	3,734.9	104,800.0	391.4	0.5	0.2	0.8
06/09/2024 01:00	3,739.0	0.0	3,739.0	104,800.0	391.8	0.5	0.2	0.8
06/09/2024 02:00	3,743.6	0.0	3,743.6	104,800.0	392.3	0.5	0.2	0.8
06/09/2024 03:00	3,742.2	0.0	3,742.2	104,800.0	392.2	0.5	0.2	0.8
06/09/2024 04:00	3,732.0	0.0	3,732.0	104,800.0	391.1	0.5	0.2	0.8
06/09/2024 05:00	3,729.4	0.0	3,729.4	104,800.0	390.8	0.5	0.2	0.8
06/09/2024 06:00	3,728.8	0.0	3,728.8	104,800.0	390.8	0.5	0.2	0.8
06/09/2024 07:00	3,732.1	0.0	3,732.1	104,800.0	391.1	0.5	0.2	0.8
06/09/2024 08:00	3,742.4	0.0	3,742.4	104,800.0	392.2	0.5	0.2	0.8
06/09/2024 09:00	3,745.5	5.1	3,745.5	104,800.0	392.5	0.5	0.2	0.8
06/09/2024 10:00	3,730.7	53.9	3,730.7	104,800.0	391.0	0.5	0.2	0.8
06/09/2024 11:00	3,711.4	72.7	3,711.4	104,800.0	389.0	0.5	0.2	0.8
06/09/2024 12:00	3,716.1	69.0	3,716.1	104,800.0	389.4	0.5	0.2	0.8
06/09/2024 13:00	3,703.7	32.5	3,703.7	104,800.0	388.1	0.5	0.2	0.8
06/09/2024 14:00	3,701.6	0.0	3,701.6	104,800.0	387.9	0.5	0.2	0.8
06/09/2024 15:00	3,709.3	0.0	3,709.3	104,800.0	388.7	0.5	0.2	0.8
06/09/2024 16:00	3,698.9	0.0	3,698.9	104,800.0	387.6	0.5	0.2	0.8
06/09/2024 17:00	3,695.6	0.0	3,695.6	104,800.0	387.3	0.5	0.2	0.8
06/09/2024 18:00	3,699.2	0.0	3,699.2	104,800.0	387.7	0.5	0.2	0.8
06/09/2024 19:00	3,694.5	0.0	3,694.5	104,800.0	387.2	0.5	0.2	0.8
06/09/2024 20:00	3,715.6	0.0	3,715.6	104,800.0	389.4	0.5	0.2	0.8
06/09/2024 21:00	3,725.0	0.0	3,725.0	104,800.0	390.4	0.5	0.2	0.8
06/09/2024 22:00	3,726.2	0.0	3,726.2	104,800.0	390.5	0.5	0.2	0.8
06/09/2024 23:00	3,729.8	0.0	3,729.8	104,800.0	390.9	0.5	0.2	0.8
Average/Sum#:	3,722.0	9.7	3,722.0	104,800.0	390.1	0.5	0.2	0.8
Minimum:	3,694.5	0.0	3,694.5	104,800.0	387.2	0.5	0.2	0.8
Maximum:	3,745.5	72.7	3,745.5	104,800.0	392.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2024 00:00	3,733.9	0.0	3,733.9	104,800.0	391.3	0.5	0.2	0.8
06/10/2024 01:00	3,733.0	0.0	3,733.0	104,800.0	391.2	0.5	0.2	0.8
06/10/2024 02:00	3,730.5	0.0	3,730.5	104,800.0	391.0	0.5	0.2	0.8
06/10/2024 03:00	3,730.1	0.0	3,730.1	104,800.0	390.9	0.5	0.2	0.8
06/10/2024 04:00	3,735.5	0.0	3,735.5	104,800.0	391.5	0.5	0.2	0.8
06/10/2024 05:00	3,731.3	0.0	3,731.3	104,800.0	391.0	0.5	0.2	0.8
06/10/2024 06:00	3,740.5	0.0	3,740.5	104,800.0	392.0	0.5	0.2	0.8
06/10/2024 07:00	3,740.1	0.0	3,740.1	104,800.0	392.0	0.5	0.2	0.8
06/10/2024 08:00	3,737.4	0.0	3,737.4	104,800.0	391.7	0.5	0.2	0.8
06/10/2024 09:00	3,715.3	5.0	3,715.3	104,800.0	389.4	0.5	0.2	0.8
06/10/2024 10:00	3,708.5	54.6	3,708.5	104,800.0	388.7	0.5	0.2	0.8
06/10/2024 11:00	3,703.7	70.2	3,703.7	104,800.0	388.1	0.5	0.2	0.8
06/10/2024 12:00	3,705.1	62.7	3,705.1	104,800.0	388.3	0.5	0.2	0.8
06/10/2024 13:00	3,689.0	28.7	3,689.0	104,800.0	386.6	0.5	0.2	0.8
06/10/2024 14:00	3,680.2	0.0	3,680.2	104,800.0	385.7	0.5	0.2	0.8
06/10/2024 15:00	3,676.8	0.0	3,676.8	104,800.0	385.3	0.5	0.2	0.8
06/10/2024 16:00	3,688.5	0.0	3,688.5	104,800.0	386.6	0.5	0.2	0.8
06/10/2024 17:00	4,383.6	506.8	4,748.5	104,800.0	497.6	0.6	0.3	1.0
06/10/2024 18:00	4,547.9	823.6	5,371.5	104,800.0	562.9	0.7	0.3	1.1
06/10/2024 19:00	4,578.8	761.0	5,339.8	104,800.0	559.6	0.7	0.3	1.1
06/10/2024 20:00	4,615.7	705.8	5,321.5	104,800.0	557.7	0.7	0.3	1.1
06/10/2024 21:00	4,645.3	674.6	5,319.9	104,800.0	557.5	0.7	0.3	1.1
06/10/2024 22:00	4,662.1	632.6	5,294.7	104,800.0	554.9	0.7	0.3	1.1
06/10/2024 23:00	4,670.2	607.5	5,277.7	104,800.0	553.1	0.7	0.3	1.1
Average/Sum#:	3,970.1	205.5	4,160.5	104,800.0	436.0	0.6	0.2	0.9
Minimum:	3,676.8	0.0	3,676.8	104,800.0	385.3	0.5	0.2	0.8
Maximum:	4,670.2	823.6	5,371.5	104,800.0	562.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2024 00:00	4,695.4	570.4	5,265.8	104,800.0	551.9	0.7	0.3	1.1
06/11/2024 01:00	4,715.6	552.4	5,268.0	104,800.0	552.1	0.7	0.3	1.1
06/11/2024 02:00	4,733.6	557.3	5,290.9	104,800.0	554.5	0.7	0.3	1.1
06/11/2024 03:00	4,746.9	532.8	5,279.7	104,800.0	553.3	0.7	0.3	1.1
06/11/2024 04:00	4,765.6	491.3	5,256.9	104,800.0	550.9	0.7	0.3	1.1
06/11/2024 05:00	4,694.9	344.1	4,959.9	104,800.0	519.8	0.6	0.3	1.1
06/11/2024 06:00	3,744.7	0.0	3,744.7	104,800.0	392.4	0.5	0.2	0.8
06/11/2024 07:00	3,759.6	0.0	3,759.6	104,800.0	394.0	0.5	0.2	0.8
06/11/2024 08:00	3,747.0	0.0	3,747.0	104,800.0	392.7	0.5	0.2	0.8
06/11/2024 09:00	3,731.4	3.0	3,731.4	104,800.0	391.1	0.5	0.2	0.8
06/11/2024 10:00	3,727.5	45.3	3,727.5	104,800.0	390.6	0.5	0.2	0.8
06/11/2024 11:00	3,726.1	65.9	3,726.1	104,800.0	390.5	0.5	0.2	0.8
06/11/2024 12:00	3,711.2	72.5	3,711.2	104,800.0	388.9	0.5	0.2	0.8
06/11/2024 13:00	3,714.5	39.3	3,714.5	104,800.0	389.3	0.5	0.2	0.8
06/11/2024 14:00	3,717.6	0.3	3,717.6	104,800.0	389.6	0.5	0.2	0.8
06/11/2024 15:00	3,695.6	0.0	3,695.6	104,800.0	387.3	0.5	0.2	0.8
06/11/2024 16:00	4,335.2	447.6	4,572.4	104,800.0	479.2	0.6	0.3	1.0
06/11/2024 17:00	4,487.0	966.9	5,453.9	104,800.0	571.6	0.7	0.3	1.1
06/11/2024 18:00	4,473.4	1,655.1	6,128.5	104,800.0	642.3	0.8	0.4	1.3
06/11/2024 19:00	4,473.3	1,083.4	5,556.7	104,800.0	582.3	0.7	0.3	1.2
06/11/2024 20:00	4,473.8	911.2	5,385.0	104,800.0	564.3	0.7	0.3	1.1
06/11/2024 21:00	4,472.3	846.7	5,319.0	104,800.0	557.4	0.7	0.3	1.1
06/11/2024 22:00	4,479.5	809.4	5,288.9	104,800.0	554.3	0.7	0.3	1.1
06/11/2024 23:00	4,503.3	800.7	5,304.0	104,800.0	555.9	0.7	0.3	1.1
Average/Sum#:	4,221.9	449.8	4,650.2	104,800.0	487.3	0.6	0.3	1.0
Minimum:	3,695.6	0.0	3,695.6	104,800.0	387.3	0.5	0.2	0.8
Maximum:	4,765.6	1,655.1	6,128.5	104,800.0	642.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2024 00:00	4,534.0	777.2	5,311.2	104,800.0	556.6	0.7	0.3	1.1
06/12/2024 01:00	4,557.4	752.8	5,310.2	104,800.0	556.5	0.7	0.3	1.1
06/12/2024 02:00	4,590.6	688.4	5,279.0	104,800.0	553.2	0.7	0.3	1.1
06/12/2024 03:00	4,613.1	633.4	5,246.5	104,800.0	549.8	0.7	0.3	1.1
06/12/2024 04:00	4,630.1	623.7	5,253.8	104,800.0	550.6	0.7	0.3	1.1
06/12/2024 05:00	4,652.0	623.6	5,275.6	104,800.0	552.9	0.7	0.3	1.1
06/12/2024 06:00	4,133.0	156.6	4,176.8	104,800.0	437.7	0.5	0.3	0.9
06/12/2024 07:00	3,672.0	1.4	3,672.0	104,800.0	384.8	0.5	0.2	0.8
06/12/2024 08:00	3,682.6	13.7	3,682.6	104,800.0	385.9	0.5	0.2	0.8
06/12/2024 09:00	3,697.7	41.7	3,697.7	104,800.0	387.5	0.5	0.2	0.8
06/12/2024 10:00	3,679.3	79.8	3,679.3	104,800.0	385.6	0.5	0.2	0.8
06/12/2024 11:00	3,675.5	92.3	3,675.5	104,800.0	385.2	0.5	0.2	0.8
06/12/2024 12:00	3,675.6	87.0	3,675.6	104,800.0	385.2	0.5	0.2	0.8
06/12/2024 13:00	3,677.4	44.1	3,677.4	104,800.0	385.4	0.5	0.2	0.8
06/12/2024 14:00	3,670.9	4.8	3,670.9	104,800.0	384.7	0.5	0.2	0.8
06/12/2024 15:00	3,672.4	0.0	3,672.4	104,800.0	384.9	0.5	0.2	0.8
06/12/2024 16:00	4,312.6	390.2	4,499.9	104,800.0	471.6	0.6	0.3	1.0
06/12/2024 17:00	4,506.8	951.7	5,458.5	104,800.0	572.1	0.7	0.3	1.1
06/12/2024 18:00	4,563.6	1,012.0	5,575.6	104,800.0	584.3	0.7	0.4	1.2
06/12/2024 19:00	4,609.7	783.2	5,392.9	104,800.0	565.2	0.7	0.3	1.1
06/12/2024 20:00	4,649.3	572.8	5,222.1	104,800.0	547.3	0.7	0.3	1.1
06/12/2024 21:00	4,691.8	536.5	5,228.3	104,800.0	547.9	0.7	0.3	1.1
06/12/2024 22:00	4,714.8	495.0	5,209.8	104,800.0	546.0	0.7	0.3	1.1
06/12/2024 23:00	4,734.6	497.3	5,231.9	104,800.0	548.3	0.7	0.3	1.1
Average/Sum#:	4,233.2	410.8	4,615.6	104,800.0	483.7	0.6	0.3	1.0
Minimum:	3,670.9	0.0	3,670.9	104,800.0	384.7	0.5	0.2	0.8
Maximum:	4,734.6	1,012.0	5,575.6	104,800.0	584.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2024 00:00	4,748.9	484.6	5,233.5	104,800.0	548.5	0.7	0.3	1.1
06/13/2024 01:00	4,752.6	474.5	5,227.1	104,800.0	547.8	0.7	0.3	1.1
06/13/2024 02:00	4,762.4	463.1	5,225.5	104,800.0	547.6	0.7	0.3	1.1
06/13/2024 03:00	4,766.1	453.9	5,220.0	104,800.0	547.1	0.7	0.3	1.1
06/13/2024 04:00	4,775.5	438.3	5,213.8	104,800.0	546.4	0.7	0.3	1.1
06/13/2024 05:00	4,782.8	427.0	5,209.8	104,800.0	546.0	0.7	0.3	1.1
06/13/2024 06:00	4,150.8	100.4	4,177.9	104,800.0	437.8	0.5	0.3	0.9
06/13/2024 07:00	3,686.9	0.0	3,686.9	104,800.0	386.4	0.5	0.2	0.8
06/13/2024 08:00	3,693.4	0.0	3,693.4	104,800.0	387.1	0.5	0.2	0.8
06/13/2024 09:00	3,693.0	0.5	3,693.0	104,800.0	387.0	0.5	0.2	0.8
06/13/2024 10:00	3,698.0	60.5	3,698.0	104,800.0	387.6	0.5	0.2	0.8
06/13/2024 11:00	3,676.4	74.8	3,676.4	104,800.0	385.3	0.5	0.2	0.8
06/13/2024 12:00	3,668.8	71.5	3,668.8	104,800.0	384.5	0.5	0.2	0.8
06/13/2024 13:00	3,721.2	55.7	3,721.2	104,800.0	390.0	0.5	0.2	0.8
06/13/2024 14:00	3,996.9	39.5	4,003.6	104,800.0	419.6	0.5	0.3	0.8
06/13/2024 15:00	3,842.5	0.0	3,842.5	104,800.0	402.7	0.5	0.2	0.8
06/13/2024 16:00	3,744.3	0.0	3,744.3	104,800.0	392.4	0.5	0.2	0.8
06/13/2024 17:00	3,693.7	0.0	3,693.7	104,800.0	387.1	0.5	0.2	0.8
06/13/2024 18:00	4,355.9	234.0	4,489.3	104,800.0	470.5	0.6	0.3	1.0
06/13/2024 19:00	4,702.0	357.4	5,059.4	104,800.0	530.2	0.6	0.3	1.1
06/13/2024 20:00	4,408.3	100.8	4,445.6	104,800.0	465.9	0.6	0.3	0.9
06/13/2024 21:00	3,874.0	0.0	3,874.0	104,800.0	406.0	0.5	0.2	0.8
06/13/2024 22:00	3,725.4	0.0	3,725.4	104,800.0	390.4	0.5	0.2	0.8
06/13/2024 23:00	3,764.0	0.0	3,764.0	104,800.0	394.5	0.5	0.2	0.8
Average/Sum#:	4,111.8	159.9	4,249.5	104,800.0	445.4	0.6	0.2	0.9
Minimum:	3,668.8	0.0	3,668.8	104,800.0	384.5	0.5	0.2	0.8
Maximum:	4,782.8	484.6	5,233.5	104,800.0	548.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2024 00:00	3,778.3	0.0	3,778.3	104,800.0	396.0	0.5	0.2	0.8
06/14/2024 01:00	3,777.9	0.0	3,777.9	104,800.0	395.9	0.5	0.2	0.8
06/14/2024 02:00	3,770.8	0.0	3,770.8	104,800.0	395.2	0.5	0.2	0.8
06/14/2024 03:00	3,742.6	0.0	3,742.6	104,800.0	392.2	0.5	0.2	0.8
06/14/2024 04:00	3,741.6	0.0	3,741.6	104,800.0	392.1	0.5	0.2	0.8
06/14/2024 05:00	3,735.6	0.0	3,735.6	104,800.0	391.5	0.5	0.2	0.8
06/14/2024 06:00	3,741.8	0.0	3,741.8	104,800.0	392.1	0.5	0.2	0.8
06/14/2024 07:00	3,738.4	0.0	3,738.4	104,800.0	391.8	0.5	0.2	0.8
06/14/2024 08:00	3,735.2	0.0	3,735.2	104,800.0	391.4	0.5	0.2	0.8
06/14/2024 09:00	3,728.3	9.0	3,728.3	104,800.0	390.7	0.5	0.2	0.8
06/14/2024 10:00	3,737.6	64.3	3,737.6	104,800.0	391.7	0.5	0.2	0.8
06/14/2024 11:00	3,735.4	76.9	3,735.4	104,800.0	391.5	0.5	0.2	0.8
06/14/2024 12:00	3,722.5	79.7	3,722.5	104,800.0	390.1	0.5	0.2	0.8
06/14/2024 13:00	3,683.7	50.7	3,683.7	104,800.0	386.1	0.5	0.2	0.8
06/14/2024 14:00	3,671.8	0.0	3,671.8	104,800.0	384.8	0.5	0.2	0.8
06/14/2024 15:00	3,661.5	0.0	3,661.5	104,800.0	383.7	0.5	0.2	0.8
06/14/2024 16:00	2,683.8	0.0	2,683.8	104,800.0	281.3	0.5	0.2	0.8
06/14/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/14/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/14/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/14/2024 20:00	271.3	0.0	271.3	104,800.0	28.4	0.0	0.0	0.0
06/14/2024 21:00	3,385.3	0.0	3,385.3	104,800.0	354.8	0.5	0.2	0.8
06/14/2024 22:00	3,675.0	0.0	3,675.0	104,800.0	385.1	0.5	0.2	0.8
06/14/2024 23:00	3,673.7	0.0	3,673.7	104,800.0	385.0	0.5	0.2	0.8
Average/Sum#:	3,494.9	13.4	3,494.9	104,800.0	366.3	0.5	0.2	0.8
Minimum:	271.3	0.0	271.3	104,800.0	28.4	0.5	0.2	0.8
Maximum:	3,778.3	79.7	3,778.3	104,800.0	396.0	0.5	0.2	0.8
%SI	12.50	12.50	12.50	0.00	12.50	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2024 00:00	3,675.7	0.0	3,675.7	104,800.0	385.2	0.5	0.2	0.8
06/15/2024 01:00	3,680.8	0.0	3,680.8	104,800.0	385.7	0.5	0.2	0.8
06/15/2024 02:00	3,813.1	0.0	3,813.1	104,800.0	399.6	0.5	0.2	0.8
06/15/2024 03:00	3,714.4	0.0	3,714.4	104,800.0	389.3	0.5	0.2	0.8
06/15/2024 04:00	3,727.7	0.0	3,727.7	104,800.0	390.7	0.5	0.2	0.8
06/15/2024 05:00	3,733.0	0.0	3,733.0	104,800.0	391.2	0.5	0.2	0.8
06/15/2024 06:00	3,731.1	0.0	3,731.1	104,800.0	391.0	0.5	0.2	0.8
06/15/2024 07:00	3,736.5	0.0	3,736.5	104,800.0	391.6	0.5	0.2	0.8
06/15/2024 08:00	3,747.6	0.2	3,747.6	104,800.0	392.7	0.5	0.2	0.8
06/15/2024 09:00	3,761.6	3.3	3,761.6	104,800.0	394.2	0.5	0.2	0.8
06/15/2024 10:00	3,735.3	9.2	3,735.3	104,800.0	391.5	0.5	0.2	0.8
06/15/2024 11:00	3,717.5	27.4	3,717.5	104,800.0	389.6	0.5	0.2	0.8
06/15/2024 12:00	3,715.1	42.8	3,715.1	104,800.0	389.3	0.5	0.2	0.8
06/15/2024 13:00	3,709.0	6.1	3,709.0	104,800.0	388.7	0.5	0.2	0.8
06/15/2024 14:00	3,697.8	0.0	3,697.8	104,800.0	387.5	0.5	0.2	0.8
06/15/2024 15:00	3,693.1	0.0	3,693.1	104,800.0	387.0	0.5	0.2	0.8
06/15/2024 16:00	3,686.6	0.0	3,686.6	104,800.0	386.4	0.5	0.2	0.8
06/15/2024 17:00	3,679.5	0.0	3,679.5	104,800.0	385.6	0.5	0.2	0.8
06/15/2024 18:00	4,239.5	0.0	4,239.5	104,800.0	444.3	0.5	0.3	0.9
06/15/2024 19:00	4,054.3	0.0	4,054.3	104,800.0	424.9	0.5	0.3	0.8
06/15/2024 20:00	3,910.6	0.0	3,910.6	104,800.0	409.8	0.5	0.2	0.8
06/15/2024 21:00	3,724.0	0.0	3,724.0	104,800.0	390.3	0.5	0.2	0.8
06/15/2024 22:00	3,735.9	0.0	3,735.9	104,800.0	391.5	0.5	0.2	0.8
06/15/2024 23:00	3,760.0	0.0	3,760.0	104,800.0	394.0	0.5	0.2	0.8
Average/Sum#:	3,765.8	3.7	3,765.8	104,800.0	394.7	0.5	0.2	0.8
Minimum:	3,675.7	0.0	3,675.7	104,800.0	385.2	0.5	0.2	0.8
Maximum:	4,239.5	42.8	4,239.5	104,800.0	444.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2024 00:00	4,549.0	0.0	4,549.0	104,800.0	476.7	0.6	0.3	1.0
06/16/2024 01:00	3,712.7	0.0	3,712.7	104,800.0	389.1	0.5	0.2	0.8
06/16/2024 02:00	3,724.0	0.0	3,724.0	104,800.0	390.3	0.5	0.2	0.8
06/16/2024 03:00	3,748.7	0.0	3,748.7	104,800.0	392.9	0.5	0.2	0.8
06/16/2024 04:00	3,754.7	0.0	3,754.7	104,800.0	393.5	0.5	0.2	0.8
06/16/2024 05:00	3,750.7	0.0	3,750.7	104,800.0	393.1	0.5	0.2	0.8
06/16/2024 06:00	3,738.3	0.0	3,738.3	104,800.0	391.8	0.5	0.2	0.8
06/16/2024 07:00	3,732.6	0.0	3,732.6	104,800.0	391.2	0.5	0.2	0.8
06/16/2024 08:00	3,725.3	0.0	3,725.3	104,800.0	390.4	0.5	0.2	0.8
06/16/2024 09:00	3,738.6	2.5	3,738.6	104,800.0	391.8	0.5	0.2	0.8
06/16/2024 10:00	3,708.0	14.2	3,708.0	104,800.0	388.6	0.5	0.2	0.8
06/16/2024 11:00	3,701.2	3.3	3,701.2	104,800.0	387.9	0.5	0.2	0.8
06/16/2024 12:00	3,692.2	44.0	3,692.2	104,800.0	386.9	0.5	0.2	0.8
06/16/2024 13:00	3,686.3	10.6	3,686.3	104,800.0	386.3	0.5	0.2	0.8
06/16/2024 14:00	3,688.3	0.0	3,688.3	104,800.0	386.5	0.5	0.2	0.8
06/16/2024 15:00	3,688.3	0.0	3,688.3	104,800.0	386.5	0.5	0.2	0.8
06/16/2024 16:00	3,701.6	0.0	3,701.6	104,800.0	387.9	0.5	0.2	0.8
06/16/2024 17:00	4,058.0	0.0	4,058.0	104,800.0	425.3	0.5	0.3	0.9
06/16/2024 18:00	4,595.5	0.0	4,595.5	104,800.0	481.6	0.6	0.3	1.0
06/16/2024 19:00	4,252.6	0.0	4,252.6	104,800.0	445.7	0.5	0.3	0.9
06/16/2024 20:00	3,904.6	0.0	3,904.6	104,800.0	409.2	0.5	0.2	0.8
06/16/2024 21:00	3,708.0	0.0	3,708.0	104,800.0	388.6	0.5	0.2	0.8
06/16/2024 22:00	3,706.0	0.0	3,706.0	104,800.0	388.4	0.5	0.2	0.8
06/16/2024 23:00	3,704.8	0.0	3,704.8	104,800.0	388.3	0.5	0.2	0.8
Average/Sum#:	3,832.1	3.1	3,832.1	104,800.0	401.6	0.5	0.2	0.8
Minimum:	3,686.3	0.0	3,686.3	104,800.0	386.3	0.5	0.2	0.8
Maximum:	4,595.5	44.0	4,595.5	104,800.0	481.6	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2024 00:00	3,705.1	0.0	3,705.1	104,800.0	388.3	0.5	0.2	0.8
06/17/2024 01:00	4,490.1	0.0	4,490.1	104,800.0	470.6	0.6	0.3	0.9
06/17/2024 02:00	4,111.7	0.0	4,111.7	104,800.0	430.9	0.5	0.3	0.9
06/17/2024 03:00	4,030.1	0.0	4,030.1	104,800.0	422.4	0.5	0.3	0.8
06/17/2024 04:00	4,249.6	0.0	4,249.6	104,800.0	445.4	0.5	0.3	0.9
06/17/2024 05:00	4,166.2	0.0	4,166.2	104,800.0	436.6	0.5	0.3	0.9
06/17/2024 06:00	3,730.8	0.0	3,730.8	104,800.0	391.0	0.5	0.2	0.8
06/17/2024 07:00	3,721.3	0.0	3,721.3	104,800.0	390.0	0.5	0.2	0.8
06/17/2024 08:00	3,732.7	0.0	3,732.7	104,800.0	391.2	0.5	0.2	0.8
06/17/2024 09:00	3,746.4	0.0	3,746.4	104,800.0	392.6	0.5	0.2	0.8
06/17/2024 10:00	3,738.8	0.0	3,738.8	104,800.0	391.8	0.5	0.2	0.8
06/17/2024 11:00	3,724.7	0.0	3,724.7	104,800.0	390.3	0.5	0.2	0.8
06/17/2024 12:00	3,719.0	0.0	3,719.0	104,800.0	389.8	0.5	0.2	0.8
06/17/2024 13:00	3,713.3	0.0	3,713.3	104,800.0	389.2	0.5	0.2	0.8
06/17/2024 14:00	3,710.4	0.0	3,710.4	104,800.0	388.8	0.5	0.2	0.8
06/17/2024 15:00	3,698.6	0.0	3,698.6	104,800.0	387.6	0.5	0.2	0.8
06/17/2024 16:00	3,701.0	0.0	3,701.0	104,800.0	387.9	0.5	0.2	0.8
06/17/2024 17:00	4,022.5	0.0	4,022.5	104,800.0	421.6	0.5	0.3	0.8
06/17/2024 18:00	4,660.0	0.0	4,660.0	104,800.0	488.4	0.6	0.3	1.0
06/17/2024 19:00	4,634.5	0.0	4,634.5	104,800.0	485.7	0.6	0.3	1.0
06/17/2024 20:00	4,626.1	0.0	4,626.1	104,800.0	484.8	0.6	0.3	1.0
06/17/2024 21:00	4,509.8	0.0	4,509.8	104,800.0	472.6	0.6	0.3	0.9
06/17/2024 22:00	4,159.8	0.0	4,159.8	104,800.0	435.9	0.5	0.3	0.9
06/17/2024 23:00	4,128.0	0.0	4,128.0	104,800.0	432.6	0.5	0.3	0.9
Average/Sum#:	4,017.9	0.0	4,017.9	104,800.0	421.1	0.5	0.3	0.9
Minimum:	3,698.6	0.0	3,698.6	104,800.0	387.6	0.5	0.2	0.8
Maximum:	4,660.0	0.0	4,660.0	104,800.0	488.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2024 00:00	4,129.5	0.0	4,129.5	104,800.0	432.8	0.5	0.3	0.9
06/18/2024 01:00	4,122.6	0.0	4,122.6	104,800.0	432.0	0.5	0.3	0.9
06/18/2024 02:00	4,122.2	0.0	4,122.2	104,800.0	432.0	0.5	0.3	0.9
06/18/2024 03:00	4,118.8	0.0	4,118.8	104,800.0	431.7	0.5	0.3	0.9
06/18/2024 04:00	4,200.0	0.0	4,200.0	104,800.0	440.2	0.5	0.3	0.9
06/18/2024 05:00	4,344.3	0.0	4,344.3	104,800.0	455.3	0.5	0.3	0.9
06/18/2024 06:00	3,761.6	0.2	3,761.6	104,800.0	394.2	0.5	0.2	0.8
06/18/2024 07:00	3,854.5	0.0	3,854.5	104,800.0	404.0	0.5	0.2	0.8
06/18/2024 08:00	4,131.7	0.0	4,131.7	104,800.0	433.0	0.5	0.3	0.9
06/18/2024 09:00	4,115.0	0.3	4,115.0	104,800.0	431.3	0.5	0.3	0.9
06/18/2024 10:00	4,094.5	19.6	4,094.5	104,800.0	429.1	0.5	0.3	0.9
06/18/2024 11:00	4,088.1	54.8	4,088.1	104,800.0	428.4	0.5	0.3	0.9
06/18/2024 12:00	4,100.3	15.1	4,100.3	104,800.0	429.7	0.5	0.3	0.9
06/18/2024 13:00	4,099.9	18.7	4,099.9	104,800.0	429.7	0.5	0.3	0.9
06/18/2024 14:00	4,099.7	0.0	4,099.7	104,800.0	429.6	0.5	0.3	0.9
06/18/2024 15:00	4,098.5	0.0	4,098.5	104,800.0	429.5	0.5	0.3	0.9
06/18/2024 16:00	4,086.9	0.0	4,086.9	104,800.0	428.3	0.5	0.3	0.9
06/18/2024 17:00	4,121.4	48.2	4,127.7	104,800.0	432.6	0.5	0.3	0.9
06/18/2024 18:00	4,445.8	102.6	4,499.2	104,800.0	471.5	0.6	0.3	1.0
06/18/2024 19:00	4,103.2	0.0	4,103.2	104,800.0	430.0	0.5	0.3	0.9
06/18/2024 20:00	4,085.5	0.0	4,085.5	104,800.0	428.2	0.5	0.3	0.9
06/18/2024 21:00	4,090.7	0.0	4,090.7	104,800.0	428.7	0.5	0.3	0.9
06/18/2024 22:00	4,087.4	0.0	4,087.4	104,800.0	428.4	0.5	0.3	0.9
06/18/2024 23:00	4,088.2	0.0	4,088.2	104,800.0	428.4	0.5	0.3	0.9
Average/Sum#:	4,107.9	10.8	4,110.4	104,800.0	430.8	0.5	0.3	0.9
Minimum:	3,761.6	0.0	3,761.6	104,800.0	394.2	0.5	0.2	0.8
Maximum:	4,445.8	102.6	4,499.2	104,800.0	471.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2024 00:00	4,079.8	0.0	4,079.8	104,800.0	427.6	0.5	0.3	0.9
06/19/2024 01:00	4,081.6	0.0	4,081.6	104,800.0	427.8	0.5	0.3	0.9
06/19/2024 02:00	4,075.4	0.0	4,075.4	104,800.0	427.1	0.5	0.3	0.9
06/19/2024 03:00	4,111.1	0.0	4,111.1	104,800.0	430.8	0.5	0.3	0.9
06/19/2024 04:00	4,124.1	0.0	4,124.1	104,800.0	432.2	0.5	0.3	0.9
06/19/2024 05:00	4,128.0	0.0	4,128.0	104,800.0	432.6	0.5	0.3	0.9
06/19/2024 06:00	4,125.9	0.0	4,125.9	104,800.0	432.4	0.5	0.3	0.9
06/19/2024 07:00	4,182.6	3.1	4,182.7	104,800.0	438.3	0.5	0.3	0.9
06/19/2024 08:00	4,149.8	144.9	4,203.4	104,800.0	440.5	0.5	0.3	0.9
06/19/2024 09:00	3,489.5	2.9	3,489.5	104,800.0	365.7	0.5	0.2	0.8
06/19/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/19/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,054.8	15.1	4,060.2	104,800.0	425.5	0.5	0.3	0.9
Minimum:	3,489.5	0.0	3,489.5	104,800.0	365.7	0.5	0.2	0.8
Maximum:	4,182.6	144.9	4,203.4	104,800.0	440.5	0.5	0.3	0.9
%SI	58.33	58.33	58.33	0.00	58.33	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
06/20/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/20/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/21/2024 10:00	2,904.7	62.0	2,904.7	104,800.0	304.4	0.0	0.0	0.0
06/21/2024 11:00	3,662.8	73.7	3,662.8	104,800.0	383.9	0.5	0.2	0.8
06/21/2024 12:00	3,648.7	70.0	3,648.7	104,800.0	382.4	0.5	0.2	0.8
06/21/2024 13:00	3,645.4	54.4	3,645.4	104,800.0	382.0	0.5	0.2	0.8
06/21/2024 14:00	3,641.4	0.0	3,641.4	104,800.0	381.6	0.5	0.2	0.8
06/21/2024 15:00	3,639.4	0.0	3,639.4	104,800.0	381.4	0.5	0.2	0.8
06/21/2024 16:00	3,715.0	0.0	3,715.0	104,800.0	389.3	0.5	0.2	0.8
06/21/2024 17:00	4,081.3	0.0	4,081.3	104,800.0	427.7	0.5	0.3	0.9
06/21/2024 18:00	4,525.0	0.0	4,525.0	104,800.0	474.2	0.6	0.3	0.9
06/21/2024 19:00	4,523.6	0.0	4,523.6	104,800.0	474.1	0.6	0.3	0.9
06/21/2024 20:00	4,522.6	0.0	4,522.6	104,800.0	474.0	0.6	0.3	0.9
06/21/2024 21:00	4,553.1	0.0	4,553.1	104,800.0	477.2	0.6	0.3	1.0
06/21/2024 22:00	4,581.3	0.0	4,581.3	104,800.0	480.1	0.6	0.3	1.0
06/21/2024 23:00	4,400.8	0.0	4,400.8	104,800.0	461.2	0.6	0.3	0.9
Average/Sum#:	4,003.2	18.6	4,003.2	104,800.0	419.5	0.5	0.3	0.9
Minimum:	2,904.7	0.0	2,904.7	104,800.0	304.4	0.5	0.2	0.8
Maximum:	4,581.3	73.7	4,581.3	104,800.0	480.1	0.6	0.3	1.0
%SI	41.67	41.67	41.67	0.00	41.67	45.83	45.83	45.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2024 00:00	3,254.1	0.0	3,254.1	104,800.0	341.0	0.5	0.2	0.8
06/22/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/22/2024 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,254.1	0.0	3,254.1	104,800.0	341.0	0.5	0.2	0.8
Minimum:	3,254.1	0.0	3,254.1	104,800.0	341.0	0.5	0.2	0.8
Maximum:	3,254.1	0.0	3,254.1	104,800.0	341.0	0.5	0.2	0.8
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2024 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
06/23/2024 17:00	433.9	0.0	433.9	104,800.0	45.5	0.0	0.0	0.0
06/23/2024 18:00	3,886.4	0.0	3,886.4	104,800.0	407.3	0.6	0.3	0.9
06/23/2024 19:00	4,511.3	0.0	4,511.3	104,800.0	472.8	0.6	0.3	0.9
06/23/2024 20:00	4,526.5	0.0	4,526.5	104,800.0	474.4	0.6	0.3	0.9
06/23/2024 21:00	4,529.1	0.0	4,529.1	104,800.0	474.6	0.6	0.3	0.9
06/23/2024 22:00	4,239.4	0.0	4,239.4	104,800.0	444.3	0.5	0.3	0.9
06/23/2024 23:00	3,978.6	0.0	3,978.6	104,800.0	417.0	0.5	0.3	0.8
Average/Sum#:	3,729.3	0.0	3,729.3	104,800.0	390.8	0.6	0.3	0.9
Minimum:	433.9	0.0	433.9	104,800.0	45.5	0.5	0.3	0.8
Maximum:	4,529.1	0.0	4,529.1	104,800.0	474.6	0.6	0.3	0.9
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2024 00:00	3,662.4	0.0	3,662.4	104,800.0	383.8	0.5	0.2	0.8
06/24/2024 01:00	3,663.6	0.0	3,663.6	104,800.0	383.9	0.5	0.2	0.8
06/24/2024 02:00	3,735.0	0.0	3,735.0	104,800.0	391.4	0.5	0.2	0.8
06/24/2024 03:00	3,683.0	0.0	3,683.0	104,800.0	386.0	0.5	0.2	0.8
06/24/2024 04:00	4,193.4	0.0	4,193.4	104,800.0	439.5	0.5	0.3	0.9
06/24/2024 05:00	4,258.0	0.0	4,258.0	104,800.0	446.2	0.5	0.3	0.9
06/24/2024 06:00	3,884.8	0.0	3,884.8	104,800.0	407.1	0.5	0.2	0.8
06/24/2024 07:00	3,726.5	3.5	3,726.5	104,800.0	390.5	0.5	0.2	0.8
06/24/2024 08:00	3,714.8	45.3	3,714.8	104,800.0	389.3	0.5	0.2	0.8
06/24/2024 09:00	3,751.9	64.8	3,751.9	104,800.0	393.2	0.5	0.2	0.8
06/24/2024 10:00	4,097.3	87.4	4,097.3	104,800.0	429.4	0.5	0.3	0.9
06/24/2024 11:00	4,483.8	99.5	4,483.8	104,800.0	469.9	0.6	0.3	1.0
06/24/2024 12:00	4,477.4	97.1	4,477.4	104,800.0	469.2	0.6	0.3	1.0
06/24/2024 13:00	4,531.7	77.2	4,531.7	104,800.0	474.9	0.6	0.3	1.0
06/24/2024 14:00	4,563.7	9.2	4,563.7	104,800.0	478.3	0.6	0.3	1.0
06/24/2024 15:00	4,557.8	2.3	4,557.8	104,800.0	477.7	0.6	0.3	1.0
06/24/2024 16:00	4,558.8	11.3	4,558.8	104,800.0	477.8	0.6	0.3	1.0
06/24/2024 17:00	4,411.5	0.8	4,411.5	104,800.0	462.3	0.6	0.3	0.9
06/24/2024 18:00	4,596.4	0.0	4,596.4	104,800.0	481.7	0.6	0.3	1.0
06/24/2024 19:00	4,296.0	0.0	4,296.0	104,800.0	450.2	0.5	0.3	0.9
06/24/2024 20:00	4,251.7	0.0	4,251.7	104,800.0	445.6	0.5	0.3	0.9
06/24/2024 21:00	4,584.6	0.0	4,584.6	104,800.0	480.5	0.6	0.3	1.0
06/24/2024 22:00	4,568.8	0.0	4,568.8	104,800.0	478.8	0.6	0.3	1.0
06/24/2024 23:00	4,584.5	0.0	4,584.5	104,800.0	480.5	0.6	0.3	1.0
Average/Sum#:	4,201.6	20.8	4,201.6	104,800.0	440.3	0.5	0.3	0.9
Minimum:	3,662.4	0.0	3,662.4	104,800.0	383.8	0.5	0.2	0.8
Maximum:	4,596.4	99.5	4,596.4	104,800.0	481.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2024 00:00	4,579.5	0.0	4,579.5	104,800.0	479.9	0.6	0.3	1.0
06/25/2024 01:00	4,587.1	0.0	4,587.1	104,800.0	480.7	0.6	0.3	1.0
06/25/2024 02:00	4,558.9	0.0	4,558.9	104,800.0	477.8	0.6	0.3	1.0
06/25/2024 03:00	4,510.4	0.0	4,510.4	104,800.0	472.7	0.6	0.3	0.9
06/25/2024 04:00	4,520.5	0.0	4,520.5	104,800.0	473.7	0.6	0.3	0.9
06/25/2024 05:00	4,455.1	0.0	4,455.1	104,800.0	466.9	0.6	0.3	0.9
06/25/2024 06:00	4,030.7	0.0	4,030.7	104,800.0	422.4	0.5	0.3	0.8
06/25/2024 07:00	3,687.7	12.3	3,687.7	104,800.0	386.5	0.5	0.2	0.8
06/25/2024 08:00	4,318.1	40.0	4,318.1	104,800.0	452.5	0.5	0.3	0.9
06/25/2024 09:00	4,550.7	54.0	4,550.7	104,800.0	476.9	0.6	0.3	1.0
06/25/2024 10:00	4,630.0	54.2	4,630.0	104,800.0	485.2	0.6	0.3	1.0
06/25/2024 11:00	4,628.2	35.2	4,628.2	104,800.0	485.0	0.6	0.3	1.0
06/25/2024 12:00	4,592.8	99.4	4,592.8	104,800.0	481.3	0.6	0.3	1.0
06/25/2024 13:00	4,573.3	30.0	4,573.3	104,800.0	479.3	0.6	0.3	1.0
06/25/2024 14:00	4,573.9	10.8	4,573.9	104,800.0	479.3	0.6	0.3	1.0
06/25/2024 15:00	4,255.1	0.6	4,255.1	104,800.0	445.9	0.5	0.3	0.9
06/25/2024 16:00	4,486.3	0.0	4,486.3	104,800.0	470.2	0.6	0.3	0.9
06/25/2024 17:00	4,567.7	133.7	4,598.5	104,800.0	481.9	0.6	0.3	1.0
06/25/2024 18:00	4,605.6	1,726.0	6,331.6	104,800.0	663.6	0.8	0.4	1.3
06/25/2024 19:00	4,613.7	1,882.2	6,495.9	104,800.0	680.8	0.8	0.4	1.4
06/25/2024 20:00	4,634.8	1,587.0	6,221.8	104,800.0	652.0	0.8	0.4	1.3
06/25/2024 21:00	4,664.1	1,366.8	6,030.9	104,800.0	632.0	0.8	0.4	1.3
06/25/2024 22:00	4,652.6	613.6	5,125.1	104,800.0	537.1	0.7	0.3	1.1
06/25/2024 23:00	4,057.2	0.0	4,057.2	104,800.0	425.2	0.5	0.3	0.9
Average/Sum#:	4,472.3	318.6	4,766.6	104,800.0	499.5	0.6	0.3	1.0
Minimum:	3,687.7	0.0	3,687.7	104,800.0	386.5	0.5	0.2	0.8
Maximum:	4,664.1	1,882.2	6,495.9	104,800.0	680.8	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2024 00:00	3,923.8	0.0	3,923.8	104,800.0	411.2	0.5	0.2	0.8
06/26/2024 01:00	4,190.0	0.0	4,190.0	104,800.0	439.1	0.5	0.3	0.9
06/26/2024 02:00	3,994.5	0.0	3,994.5	104,800.0	418.6	0.5	0.3	0.8
06/26/2024 03:00	4,422.4	0.0	4,422.4	104,800.0	463.5	0.6	0.3	0.9
06/26/2024 04:00	4,670.4	0.0	4,670.4	104,800.0	489.5	0.6	0.3	1.0
06/26/2024 05:00	4,022.5	0.0	4,022.5	104,800.0	421.6	0.5	0.3	0.8
06/26/2024 06:00	3,691.0	0.0	3,691.0	104,800.0	386.8	0.5	0.2	0.8
06/26/2024 07:00	3,689.5	0.0	3,689.5	104,800.0	386.7	0.5	0.2	0.8
06/26/2024 08:00	3,686.0	0.2	3,686.0	104,800.0	386.3	0.5	0.2	0.8
06/26/2024 09:00	3,679.2	33.1	3,679.2	104,800.0	385.6	0.5	0.2	0.8
06/26/2024 10:00	3,669.2	66.7	3,669.2	104,800.0	384.5	0.5	0.2	0.8
06/26/2024 11:00	3,661.2	87.1	3,661.2	104,800.0	383.7	0.5	0.2	0.8
06/26/2024 12:00	3,658.9	87.6	3,658.9	104,800.0	383.5	0.5	0.2	0.8
06/26/2024 13:00	3,655.6	60.8	3,655.6	104,800.0	383.1	0.5	0.2	0.8
06/26/2024 14:00	3,655.0	1.9	3,655.0	104,800.0	383.0	0.5	0.2	0.8
06/26/2024 15:00	3,655.0	0.0	3,655.0	104,800.0	383.0	0.5	0.2	0.8
06/26/2024 16:00	3,653.4	1.2	3,653.4	104,800.0	382.9	0.5	0.2	0.8
06/26/2024 17:00	3,744.3	0.0	3,744.3	104,800.0	392.4	0.5	0.2	0.8
06/26/2024 18:00	4,067.5	0.0	4,067.5	104,800.0	426.3	0.5	0.3	0.9
06/26/2024 19:00	3,728.0	0.0	3,728.0	104,800.0	390.7	0.5	0.2	0.8
06/26/2024 20:00	3,678.7	0.0	3,678.7	104,800.0	385.5	0.5	0.2	0.8
06/26/2024 21:00	3,677.6	0.0	3,677.6	104,800.0	385.4	0.5	0.2	0.8
06/26/2024 22:00	3,683.8	0.0	3,683.8	104,800.0	386.1	0.5	0.2	0.8
06/26/2024 23:00	3,688.7	0.0	3,688.7	104,800.0	386.6	0.5	0.2	0.8
Average/Sum#:	3,826.9	14.1	3,826.9	104,800.0	401.1	0.5	0.2	0.8
Minimum:	3,653.4	0.0	3,653.4	104,800.0	382.9	0.5	0.2	0.8
Maximum:	4,670.4	87.6	4,670.4	104,800.0	489.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2024 00:00	3,687.3	0.0	3,687.3	104,800.0	386.4	0.5	0.2	0.8
06/27/2024 01:00	3,692.8	0.0	3,692.8	104,800.0	387.0	0.5	0.2	0.8
06/27/2024 02:00	3,692.8	0.0	3,692.8	104,800.0	387.0	0.5	0.2	0.8
06/27/2024 03:00	3,697.4	0.0	3,697.4	104,800.0	387.5	0.5	0.2	0.8
06/27/2024 04:00	3,704.0	0.0	3,704.0	104,800.0	388.2	0.5	0.2	0.8
06/27/2024 05:00	3,703.6	0.0	3,703.6	104,800.0	388.1	0.5	0.2	0.8
06/27/2024 06:00	3,701.5	0.0	3,701.5	104,800.0	387.9	0.5	0.2	0.8
06/27/2024 07:00	3,698.8	0.0	3,698.8	104,800.0	387.6	0.5	0.2	0.8
06/27/2024 08:00	3,694.3	1.7	3,694.3	104,800.0	387.2	0.5	0.2	0.8
06/27/2024 09:00	3,694.7	51.8	3,694.7	104,800.0	387.2	0.5	0.2	0.8
06/27/2024 10:00	3,682.3	78.6	3,682.3	104,800.0	385.9	0.5	0.2	0.8
06/27/2024 11:00	3,679.3	87.2	3,679.3	104,800.0	385.6	0.5	0.2	0.8
06/27/2024 12:00	3,675.4	70.6	3,675.4	104,800.0	385.2	0.5	0.2	0.8
06/27/2024 13:00	3,672.1	55.5	3,672.1	104,800.0	384.8	0.5	0.2	0.8
06/27/2024 14:00	3,667.3	0.5	3,667.3	104,800.0	384.3	0.5	0.2	0.8
06/27/2024 15:00	3,662.7	0.0	3,662.7	104,800.0	383.9	0.5	0.2	0.8
06/27/2024 16:00	3,661.6	0.0	3,661.6	104,800.0	383.7	0.5	0.2	0.8
06/27/2024 17:00	3,703.1	0.0	3,703.1	104,800.0	388.1	0.5	0.2	0.8
06/27/2024 18:00	4,094.3	0.0	4,094.3	104,800.0	429.1	0.5	0.3	0.9
06/27/2024 19:00	3,707.3	0.0	3,707.3	104,800.0	388.5	0.5	0.2	0.8
06/27/2024 20:00	3,675.4	0.0	3,675.4	104,800.0	385.2	0.5	0.2	0.8
06/27/2024 21:00	3,676.3	0.0	3,676.3	104,800.0	385.3	0.5	0.2	0.8
06/27/2024 22:00	3,677.6	0.0	3,677.6	104,800.0	385.4	0.5	0.2	0.8
06/27/2024 23:00	3,680.2	0.0	3,680.2	104,800.0	385.7	0.5	0.2	0.8
Average/Sum#:	3,703.4	14.4	3,703.4	104,800.0	388.1	0.5	0.2	0.8
Minimum:	3,661.6	0.0	3,661.6	104,800.0	383.7	0.5	0.2	0.8
Maximum:	4,094.3	87.2	4,094.3	104,800.0	429.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2024 00:00	3,680.8	0.0	3,680.8	104,800.0	385.7	0.5	0.2	0.8
06/28/2024 01:00	3,683.4	0.0	3,683.4	104,800.0	386.0	0.5	0.2	0.8
06/28/2024 02:00	3,682.3	0.0	3,682.3	104,800.0	385.9	0.5	0.2	0.8
06/28/2024 03:00	3,683.7	0.0	3,683.7	104,800.0	386.1	0.5	0.2	0.8
06/28/2024 04:00	3,688.7	0.0	3,688.7	104,800.0	386.6	0.5	0.2	0.8
06/28/2024 05:00	3,689.6	0.0	3,689.6	104,800.0	386.7	0.5	0.2	0.8
06/28/2024 06:00	3,688.5	0.0	3,688.5	104,800.0	386.6	0.5	0.2	0.8
06/28/2024 07:00	3,684.7	0.0	3,684.7	104,800.0	386.2	0.5	0.2	0.8
06/28/2024 08:00	3,675.7	0.6	3,675.7	104,800.0	385.2	0.5	0.2	0.8
06/28/2024 09:00	3,671.7	56.3	3,671.7	104,800.0	384.8	0.5	0.2	0.8
06/28/2024 10:00	3,666.8	72.6	3,666.8	104,800.0	384.3	0.5	0.2	0.8
06/28/2024 11:00	3,661.2	77.9	3,661.2	104,800.0	383.7	0.5	0.2	0.8
06/28/2024 12:00	3,656.0	78.4	3,656.0	104,800.0	383.1	0.5	0.2	0.8
06/28/2024 13:00	3,646.2	67.2	3,646.2	104,800.0	382.1	0.5	0.2	0.8
06/28/2024 14:00	3,638.1	9.5	3,638.1	104,800.0	381.3	0.5	0.2	0.8
06/28/2024 15:00	3,635.1	0.0	3,635.1	104,800.0	381.0	0.5	0.2	0.8
06/28/2024 16:00	3,636.5	5.6	3,636.5	104,800.0	381.1	0.5	0.2	0.8
06/28/2024 17:00	3,696.7	0.0	3,696.7	104,800.0	387.4	0.5	0.2	0.8
06/28/2024 18:00	3,665.5	0.0	3,665.5	104,800.0	384.1	0.5	0.2	0.8
06/28/2024 19:00	3,656.0	0.0	3,656.0	104,800.0	383.1	0.5	0.2	0.8
06/28/2024 20:00	3,634.2	0.0	3,634.2	104,800.0	380.9	0.5	0.2	0.8
06/28/2024 21:00	3,630.4	0.0	3,630.4	104,800.0	380.5	0.5	0.2	0.8
06/28/2024 22:00	3,630.8	0.0	3,630.8	104,800.0	380.5	0.5	0.2	0.8
06/28/2024 23:00	3,634.9	0.0	3,634.9	104,800.0	380.9	0.5	0.2	0.8
Average/Sum#:	3,663.2	15.3	3,663.2	104,800.0	383.9	0.5	0.2	0.8
Minimum:	3,630.4	0.0	3,630.4	104,800.0	380.5	0.5	0.2	0.8
Maximum:	3,696.7	78.4	3,696.7	104,800.0	387.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2024 00:00	3,636.8	0.0	3,636.8	104,800.0	381.1	0.5	0.2	0.8
06/29/2024 01:00	3,640.7	0.1	3,640.7	104,800.0	381.5	0.5	0.2	0.8
06/29/2024 02:00	3,643.6	0.0	3,643.6	104,800.0	381.8	0.5	0.2	0.8
06/29/2024 03:00	3,648.9	0.0	3,648.9	104,800.0	382.4	0.5	0.2	0.8
06/29/2024 04:00	3,656.5	0.0	3,656.5	104,800.0	383.2	0.5	0.2	0.8
06/29/2024 05:00	3,659.6	0.0	3,659.6	104,800.0	383.5	0.5	0.2	0.8
06/29/2024 06:00	3,658.1	0.0	3,658.1	104,800.0	383.4	0.5	0.2	0.8
06/29/2024 07:00	3,652.8	0.4	3,652.8	104,800.0	382.8	0.5	0.2	0.8
06/29/2024 08:00	3,648.6	13.4	3,648.6	104,800.0	382.4	0.5	0.2	0.8
06/29/2024 09:00	3,642.0	55.4	3,642.0	104,800.0	381.7	0.5	0.2	0.8
06/29/2024 10:00	3,639.0	85.5	3,639.0	104,800.0	381.4	0.5	0.2	0.8
06/29/2024 11:00	3,634.3	96.1	3,634.3	104,800.0	380.9	0.5	0.2	0.8
06/29/2024 12:00	3,628.8	94.9	3,628.8	104,800.0	380.3	0.5	0.2	0.8
06/29/2024 13:00	3,626.8	60.0	3,626.8	104,800.0	380.1	0.5	0.2	0.8
06/29/2024 14:00	3,626.2	10.4	3,626.2	104,800.0	380.0	0.5	0.2	0.8
06/29/2024 15:00	3,617.3	0.0	3,617.3	104,800.0	379.1	0.5	0.2	0.8
06/29/2024 16:00	3,607.0	8.4	3,607.0	104,800.0	378.0	0.5	0.2	0.8
06/29/2024 17:00	3,703.7	0.0	3,703.7	104,800.0	388.1	0.5	0.2	0.8
06/29/2024 18:00	3,795.8	0.0	3,795.8	104,800.0	397.8	0.5	0.2	0.8
06/29/2024 19:00	3,619.1	0.0	3,619.1	104,800.0	379.3	0.5	0.2	0.8
06/29/2024 20:00	3,623.7	0.0	3,623.7	104,800.0	379.8	0.5	0.2	0.8
06/29/2024 21:00	3,622.0	0.0	3,622.0	104,800.0	379.6	0.5	0.2	0.8
06/29/2024 22:00	3,624.0	0.0	3,624.0	104,800.0	379.8	0.5	0.2	0.8
06/29/2024 23:00	3,627.6	0.0	3,627.6	104,800.0	380.2	0.5	0.2	0.8
Average/Sum#:	3,645.1	17.7	3,645.1	104,800.0	382.0	0.5	0.2	0.8
Minimum:	3,607.0	0.0	3,607.0	104,800.0	378.0	0.5	0.2	0.8
Maximum:	3,795.8	96.1	3,795.8	104,800.0	397.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2024 00:00 To: 06/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/03/2024 23:55 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2024 00:00	3,629.9	0.0	3,629.9	104,800.0	380.4	0.5	0.2	0.8
06/30/2024 01:00	3,636.3	0.0	3,636.3	104,800.0	381.1	0.5	0.2	0.8
06/30/2024 02:00	3,635.9	0.0	3,635.9	104,800.0	381.0	0.5	0.2	0.8
06/30/2024 03:00	3,639.5	0.0	3,639.5	104,800.0	381.4	0.5	0.2	0.8
06/30/2024 04:00	3,637.8	0.0	3,637.8	104,800.0	381.2	0.5	0.2	0.8
06/30/2024 05:00	3,640.7	0.0	3,640.7	104,800.0	381.5	0.5	0.2	0.8
06/30/2024 06:00	3,643.4	1.0	3,643.4	104,800.0	381.8	0.5	0.2	0.8
06/30/2024 07:00	3,638.7	0.0	3,638.7	104,800.0	381.3	0.5	0.2	0.8
06/30/2024 08:00	3,632.4	1.6	3,632.4	104,800.0	380.7	0.5	0.2	0.8
06/30/2024 09:00	3,629.1	10.8	3,629.1	104,800.0	380.3	0.5	0.2	0.8
06/30/2024 10:00	3,624.9	63.0	3,624.9	104,800.0	379.9	0.5	0.2	0.8
06/30/2024 11:00	3,622.5	78.7	3,622.5	104,800.0	379.6	0.5	0.2	0.8
06/30/2024 12:00	3,621.0	73.2	3,621.0	104,800.0	379.5	0.5	0.2	0.8
06/30/2024 13:00	3,616.7	62.0	3,616.7	104,800.0	379.0	0.5	0.2	0.8
06/30/2024 14:00	3,615.7	7.1	3,615.7	104,800.0	378.9	0.5	0.2	0.8
06/30/2024 15:00	3,612.2	0.0	3,612.2	104,800.0	378.6	0.5	0.2	0.8
06/30/2024 16:00	3,607.5	2.2	3,607.5	104,800.0	378.1	0.5	0.2	0.8
06/30/2024 17:00	3,605.2	0.0	3,605.2	104,800.0	377.8	0.5	0.2	0.8
06/30/2024 18:00	3,612.4	0.0	3,612.4	104,800.0	378.6	0.5	0.2	0.8
06/30/2024 19:00	3,616.6	0.0	3,616.6	104,800.0	379.0	0.5	0.2	0.8
06/30/2024 20:00	3,625.8	0.0	3,625.8	104,800.0	380.0	0.5	0.2	0.8
06/30/2024 21:00	3,624.0	0.0	3,624.0	104,800.0	379.8	0.5	0.2	0.8
06/30/2024 22:00	3,626.5	0.0	3,626.5	104,800.0	380.1	0.5	0.2	0.8
06/30/2024 23:00	3,632.0	0.0	3,632.0	104,800.0	380.6	0.5	0.2	0.8
Average/Sum#:	3,626.1	12.5	3,626.1	104,800.0	380.0	0.5	0.2	0.8
Minimum:	3,605.2	0.0	3,605.2	104,800.0	377.8	0.5	0.2	0.8
Maximum:	3,643.4	78.7	3,643.4	104,800.0	381.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Linearity Report

07/04/2024

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTes	QA
		Component Type:	NOXA	Grace	0
Instrument Name:	CT2_NOXDualRg_P_Instr	Test End	06/12/2024	Scale:	High
Performance Spec:	5 %	Test No.:	133	Highest	1.9
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
06/12/2024	1157	L	200.0	51.1	49.9		25.6
06/12/2024	1202	M	200.0	111.3	110.2		55.7
06/12/2024	1207	H	200.0	181.6	178.4		90.8
06/12/2024	1214	L	200.0	51.1	50.2		25.6
06/12/2024	1219	M	200.0	111.3	110.4		55.7
06/12/2024	1224	H	200.0	181.6	178.4		90.8
06/12/2024	1231	L	200.0	51.1	50.3		25.6
06/12/2024	1236	M	200.0	111.3	110.4		55.7
06/12/2024	1241	H	200.0	181.7	178.4		90.9

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.133	No	1.9
M	111.300	110.333	No	0.9

Linearity Report

07/04/2024

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A22	ReasonForTes	QA
		Component Type:	O2D	Grace	0
Instrument Name:	CT2_O2D_P_Instrument	Test End	06/12/2024	Scale:	High
Performance Spec:	5 %	Test No.:	134	Highest	0.3
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
06/12/2024	1312	L	21.0	5.0	5.0		23.8
06/12/2024	1317	M	21.0	11.1	11.0		52.9
06/12/2024	1322	H	21.0	18.0	18.0		85.7
06/12/2024	1329	L	21.0	5.0	5.0		23.8
06/12/2024	1334	M	21.0	11.1	11.1		52.9
06/12/2024	1339	H	21.0	18.0	18.0		85.7
06/12/2024	1346	L	21.0	5.0	5.0		23.8
06/12/2024	1351	M	21.0	11.1	11.1		52.9
06/12/2024	1356	H	21.0	18.0	18.0		85.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.100	11.067	No	0.3

Linearity Report

07/04/2024

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A15	ReasonForTes	QA
		Component Type:	NOXA	Grace	0
Instrument Name:	CT1_NOXDualRg_P_Instr	Test End	04/16/2024	Scale:	High
Performance Spec:	5 %	Test No.:	129	Highest	2.3
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/16/2024	0841	L	200.0	51.3	49.6		25.7
04/16/2024	0846	M	200.0	111.6	110.0		55.8
04/16/2024	0851	H	200.0	180.6	180.4		90.3
04/16/2024	0857	L	200.0	51.3	50.3		25.7
04/16/2024	0902	M	200.0	111.6	110.6		55.8
04/16/2024	0907	H	200.0	180.6	180.9		90.3
04/16/2024	0913	L	200.0	51.3	50.4		25.7
04/16/2024	0918	M	200.0	111.6	110.6		55.8
04/16/2024	0923	H	200.0	181.4	180.9		90.7

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300	50.100	No	2.3
M	111.600	110.400	No	1.1

Linearity Report

07/04/2024

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT001	Component ID:	A16
		Component Type:	O2D
Instrument Name:	CT1_O2D_P_Instrument	Test End:	04/16/2024
Performance Spec:	5 %	Test No.:	130
		Status:	Passed
		ReasonForTes Grace:	QA 0
		Scale:	High
		Highest:	3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
04/16/2024	1236	L	18.0	5.5	5.3		30.6
04/16/2024	1241	M	18.0	11.2	11.1		62.2
04/16/2024	1246	H	18.0	18.0	18.1		100.0
04/16/2024	1253	L	18.0	5.5	5.3		30.6
04/16/2024	1258	M	18.0	11.2	11.1		62.2
04/16/2024	1303	H	18.0	18.0	18.1		100.0
04/16/2024	1310	L	18.0	5.5	5.3		30.6
04/16/2024	1315	M	18.0	11.2	11.1		62.2
04/16/2024	1320	H	18.0	18.0	18.1		100.0

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.200	11.100	No	0.9