DOCKETED					
Docket Number:	23-SB-100				
Project Title:	SB 100 Joint Agency Report				
TN #:	258330				
Document Title:	SB 100 Demand Scenarios Demand Flexibility Resource Potential				
Description:	N/A				
Filer:	J Padilla				
Organization:	California Energy Commission				
Submitter Role:	Commission Staff				
Submission Date:	8/6/2024 1:36:10 PM				
Docketed Date:	8/6/2024				

SB 100 Demand Scenarios: Demand Flexibility (DF) Resource Potential



Ingrid Neumann, Ph.D. Decarbonization Principal, Advanced Electrification Analysis Branch August 7, 2024



- Purpose and Context
- Overview of Current Work
- Methodology and Sources
- Inputs for Production Cost Modeling
- Demand Flexibility Potential Results



- AAEE Additional Achievable Energy Efficiency
- AAFS Additional Achievable Fuel Substitution
- TE Transportation Electrification
- **CAISO** California Independent System Operator
- CARB California Air Resources Board
- **CEC** California Energy Commission
- **CPUC** California Public Utilities Commission
- BTM Behind the meter
- **DF** Demand Flexibility

DS – Demand Scenario
PCM – Production Cost Model
LSG - Load Shift Goal
LBNL - Lawrence Berkeley National Lab
SF = Single Family
MF = Multi-Family
HHU = High Hydrogen Use



Keeping the lights on and emissions low!

- In 2020, the CEC engaged Guidehouse to develop a tool with which to estimate statewide potential for demand flexibility.
- First iteration of the D-Flex Tool customized for setting California's LSG under Senate Bill 846 in 2023
- CEC facilitated an interagency working group to use the D-Flex tool for analysis of load shift potential and development of policy recommendations



- Generate <u>potentials</u> for each hour of the year for use in the PCM
- Establish operation parameters (e.g., limited flex events in a day)
- Cost estimates for D-Flex options
- Not directly comparable to a load modifier

D-Flex Tool Basics

- Shed/Shift across multiple technologies
 - Four Sectors
 - > 34 building types/segments
 - DERs such as EVs and BTM storage
- Draws on existing research from LBNL (supported by CPUC)



Note potential estimates are only for event-based, economically-dispatched programmatic interventions, not dynamic rates/CalFUSE

DF Tool Functionality Overview

1. Hourly Gross Load and Capacity Estimates

Estimate magnitude of resource that can be leveraged for DF:

- **Gross building load** by end use, including EV charging
- Available capacity from BTM battery and EV V2X resources

2. Apply DF Parameters and Assumptions

Calculate **hourly load reduction potential** for 34 DF options using:

- Eligibility/Capability Percentage
- Participation Percentage
- Unit Impacts Load
 Dispatch

3. Group and Simplify Results for use in PCM

Simplify DF tool outputs for use in the PCM:

- Group 34 DF options into 7 resources
- Group resources into PAs
- Develop average 24-hour profiles by month



- DF potentials represent availability estimates of load reduction or load shifting that could be realized in future programmatic constructs.
 - By itself, it does not contain any predictions about when or to what extent DF resources are dispatched or utilized.
- DF resources are one component of the resource mix in the PCM for the SB 100 modeling.
- The final SB 100 analysis will likely contain only a portion of the potential load shed/shift resources as selected by the PCM.









LBNL Phase 4 Potential Study

End Use	DR Measure
HVAC	Programmable communicating thermostat
HVAC	HVAC Direct Load Control Switch
HVAC	Manual thermostat adjustment
Dishwasher	Internal connection for remote control
Dishwasher	Manual delay cycle
Washer	Internet connection for remote control
Washer	Manual delay cycle
Dryer	Internet connection for remote control
Dryer	Manual delay cycle
Refrigeration	Internet connection for remote control
Refrigeration, Freezer	Smart power outlet

- List of end use and enabling technology DF options & eligibility assumptions
- Shed fractions (unit impacts)
- Participation rates
- Cost assumptions

*Gerke, B, et al. The California Demand Response Potential Study, Phase 4: Report on Shed and Shift Resources Through 2050. May 2024. Lawrence Berkeley National Laboratory. Report Number LBNL-2001596. <u>https://eta-publications.lbl.gov/publications/california-demand-response-0</u>.

BTM Existing Battery Availability

• The DF potential analysis considers potential only from **existing** BTM battery resources that are expected to be installed for **customer needs**, such as **daily TOU arbitrage**, **back-up**, or **resiliency**.



- Battery capacity that is not used for pre-existing customer needs within a given hour, according to the baseline charging and discharging profiles, is considered available for grid dispatch.
- Battery energy that is not used for pre-existing customer needs within a given day is considered available for grid dispatch, subject to a reserve margin of 25%. The reserve margin assumes that customers will be unwilling to fully discharge the full extent of their battery nameplate energy capacity for operational, degradation, and backup purposes.





EVs [times] Charger Power [minus] EV Charging Load at Hour

Functional V2X Dispatch Potential at Hour



% EV Drivers Participating in V2G Program



% EVs/Sites with Technical Capabilities





% EVs

Plugged In

% EVs at Suitable V2G Site at Hour





Results of Potentials Are Summarized and Grouped for PCM Use









- Limited customer willingness to curtail/shift
- Dispatch constraints based on physical characteristics of technologies

Option	Max Hours per Dispatch	Max Dispatches per Day	Max Dispatches per Month or Year	Load Shift Timing	
Ag Pumping	6	1	10/month, 30/year	Up to 8 hours before dispatch	
BTM Battery (Res)	4	2	50/season, 100/year	Up to 6 hours after dispatch	
BTM Battery (Nonres)	4	2	50/season, 100/year	Up to 6 hours after dispatch	
EV Charging	4	2	50/season, 100/year	Up to 6 hours after dispatch	
EV V2X	4	1	50/season, 100/year	Up to 6 hours after dispatch	
HVAC	4	1 (Summer) 2 (Winter)	25/season, 50/year	2-hour pre-cool, 6-hour snapback	
Other	6	1	72/year	Up to 4 hours before and after dispatch	

Example Demand Flex and "Recharge" Event



Reference Scenario September Day, 2040

In earlier hours of the day, there is less EV potential, leading to less EV flexibility during winter peaks



	Input	Policy Scenario (Moderate DF)	Policy Scenario with High DER & High DF Augmentation	HHU Policy Scenario (Moderate DF)
Demand Scenario Inputs	AAEE 3 Adjustment	AAEE 3	AAEE 4 (res/com) AAEE 3 (all other)	AAEE 3
	AAFS Adjustment	AAFS 4	AAFS 4	AAFS 4
	TE Adjustment	Policy Scenario TE	Policy Scenario TE	Policy Scenario with HFS
	BTM Battery Forecast	2023 IEPR	Augmented Forecast	2023 IEPR
Demand Flexibility Inputs	EV V2X LD Applicability	SF Only	SF + MF + Commercial Fleet	SF Only
	EV V2X Plugged-In Factor	50%	65%	50%



Average Potential Across 4PM - 9PM Hours









Large hourly dispatch shape change between summer and winter for HVAC.

Average potential, Policy Scenario with DF, 2045

—Winter (January) —Summer (August)





The primary driver of differences between scenarios are in the **BTM Battery** and **Electric Vehicle (Managed Charging and V2X)** Options

Average across August 4-9 pm hours



BTM Battery Scenario Comparison

Scenarios with **DER Augmentation** include a higher forecast of installed BTM batteries, primarily from the residential sector.

Policy Scenario with DF 1,400 Policy Scenario with High Hydrogen Use Dispatch Potential (MW) ,200 Policy Scenario with DF and DER Augmentation 1,000 800 600 400 200 0 2035 ¦ 2040 2045 2030 2050 2025 SB100 target years Years

Battery average across August 4-9 pm hours



EV average across August 4-9 pm hours





- The expanded D-Flex tool allows for full 8760 load flex potentials for a given demand scenario
- D-Flex tool outputs are <u>potentials</u>, not actual load or load modifiers
- The "realization" of potentials depends on PCM selections and resource mixes.
- The largest contributor to potential is the EV category
- Seasonal factors play a role
 - Summer hours 12-19 have high HVAC potential
 - Winter hours 6-10 have lower total potential, critical hours of expected heating loads in the demand scenarios





Thank You!

Ingrid.Neumann@energy.ca.gov



SEC. 4. Section 25302.7 is added to the Public Resources Code, to read:

25302.7. By June 1, 2023, the commission, in consultation with the Public Utilities Commission and the Independent System Operator, shall adopt a goal for load shifting to reduce net peak electrical demand and shall adjust this target in each biennial integrated energy policy report prepared pursuant to Section 25302 thereafter. In developing this target, the commission shall consider the findings of the 2020 Lawrence Berkeley National Laboratory report on the Shift Resource through 2030 and other relevant research. The commission, in consultation with the Public Utilities Commission and the Independent System Operator, shall recommend policies to increase demand response and load shifting that do not increase greenhouse gas emissions or increase electric rates.