

<b>DOCKETED</b>	
<b>Docket Number:</b>	01-AFC-25C
<b>Project Title:</b>	Malburg Generating Station-Compliance
<b>TN #:</b>	259770
<b>Document Title:</b>	Malburg Generating Station Quarterly Compliance Report Q3 2024
<b>Description:</b>	N/A
<b>Filer:</b>	Elyse Engel
<b>Organization:</b>	Jacobs Engineering Group Inc.
<b>Submitter Role:</b>	Applicant
<b>Submission Date:</b>	10/30/2024 8:54:00 AM
<b>Docketed Date:</b>	10/30/2024



October 30, 2024

**NOTICE OF INTENT TO FILE  
2024 Q3 Compliance Report for the  
Malburg Generating Station (01-AFC-25C)**

Dear Dr. Ali:

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of July 1, 2024, through September 30, 2024. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019, by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at [MRichards@cityofvernon.org](mailto:MRichards@cityofvernon.org) or (323) 583-8811 x378.

Thank you,

Todd Dusenberry  
General Manager of Vernon Public Utilities

Copies: Lisa Umeda  
Matt Richards  
Richard Corbi  
Document Control

Enclosure: MGS 2024 Q3 Compliance Report




# Malburg Generating Station Quarterly Compliance Report (Third Quarter 2024)

*Submitted to*  
California Energy Commission

*Submitted by*  
City of Vernon, Public Utilities Department

Document no: 241025155417\_3c96b3ad

October 30, 2024



## Contents

<b>1. Introduction .....</b>	<b>1</b>
1.1 Project Location and Description .....	1
1.2 Organization of the Quarterly Compliance Report .....	1
<b>2. Required Quarterly Compliance Report Documentation .....</b>	<b>1</b>

## Appendices

- A MGS Emission Calculations
- B Cooling Tower Blowdown Reports
- C Operation Logs
- D Diesel Fuel Oil Purchase Records
- E Excess Emission Report

## Table

Table 2-1. Required Quarterly Compliance Report Documentation .....	1
---	---

## Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COC	Conditions of Certification
CTGs	combustion turbine generators
DAHS	data acquisition and handling system
gr/scf	grain per standard cubic foot
HRSGs	heat recovery steam generators
lb/day	pounds per day
lb/hr	pounds per hour
MGS	Malburg Generating Station
NH <sub>3</sub>	ammonia
NO <sub>x</sub>	nitrogen oxides
PM <sub>10</sub>	particulate matter with aerodynamic diameter less than or equal to 10 microns
PM <sub>2.5</sub>	particulate matter with aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SCAQMD	South Coast Air Quality Management District
SO <sub>x</sub>	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

## 1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

### 1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

### 1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

## 2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Table 2-1. Required Quarterly Compliance Report Documentation

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the third quarter of 2024 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM <sub>10</sub> ) emissions from cooling tower operation during the third quarter of 2024 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the third quarter of 2024 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the third quarter of 2024, including the duration and date of occurrence, are provided in Appendix C, Table 1.

Malburg Generating Station Quarterly Compliance Report (Third Quarter 2024)

Condition of Certification	Response
AQ-C11	All ammonia (NH <sub>3</sub> ), nitrogen oxides (NO <sub>x</sub> ), sulfur oxides (SO <sub>x</sub> ), carbon monoxide (CO), PM <sub>10</sub> , and volatile organic compound (VOC) emissions from MGS operation during the third quarter of 2024 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on March 20, 2024. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.
AQ-5	Monthly emissions of CO, PM <sub>10</sub> , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns (PM <sub>2.5</sub> ), VOC, and SO <sub>x</sub> from CTG and duct burner operation during the third quarter of 2024 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NO <sub>x</sub> excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO <sub>x</sub> emissions concentration for either CTG exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for either CTG exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for either CTG exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual or quarterly source testing. The most recent NH <sub>3</sub> compliance source testing for CTG 1 and CTG 2 was performed on March 13 and 14, 2024. The test report with results was submitted to the CEC on May 1, 2024, and indicated compliance with the emission limit (0.9 ppm). NH <sub>3</sub> emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH <sub>3</sub> concentration limit of 5 ppm.

Malburg Generating Station Quarterly Compliance Report (Third Quarter 2024)

---

Condition of Certification	Response
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source test, performed in July 2022, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.67 lb/hr and 0.0003 gr/scf for CTG 1 and 1.83 lb/hr and 0.0007 gr/scf for CTG 2).
AQ-14	See the response for COC AQ-2.
AQ-15	Year-to-date hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the year-to-date 2024 hours for maintenance and testing did not exceed 50 hours and the total operational hours did not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair did not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COCs AQ-5 and AQ-6.

# Appendix A

## MGS Emission Calculations



Malburg Generating Station  
 Quarterly Compliance Report  
 Appendix A, Table 1

Reporting Period: **Quarter 3 2024**

Table 1. Quarterly Emissions - July 1, 2024 through September 30, 2024

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub>
CTG 1 & Duct Burner	6,959	1,524	968	175	3,774	5,793
CTG 2 & Duct Burner	5,237	1,374	802	145.1	3,130	4,657
Cooling Tower	--	--	--	--	115	--
Diesel Firewater Pump	33.6	1.0	0.2	0.0	0.2	0.1
<b>Total</b>	<b>12,230</b>	<b>2,899</b>	<b>1,769</b>	<b>321</b>	<b>7,019</b>	<b>10,450</b>

Malburg Generating Station  
 Quarterly Compliance Report  
 Appendix A, Table 2

Reporting Period: **Quarter 3 2024**

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results <sup>[1]</sup>

Sampling Period		TDS (ppm)
Start Date	End Date	
6/30/2024	7/6/2024	4,470
7/7/2024	7/13/2024	3,860
7/14/2024	7/20/2024	3,380
7/21/2024	7/27/2024	3,480
7/28/2024	8/3/2024	3,200
8/4/2024	8/10/2024	3,980
8/11/2024	8/17/2024	4,000
8/18/2024	8/24/2024	3,980
8/25/2024	8/31/2024	4,440
9/1/2024	9/7/2024	4,060
9/8/2024	9/14/2024	3,860
9/15/2024	9/21/2024	4,140
9/22/2024	9/28/2024	3,360
9/29/2024	10/5/2024	4,120

<sup>[1]</sup> Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 3

Reporting Period: July 2024

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period		TDS (ppm)
	Start Date	End Date	
7/2/2024	6/30/2024	7/6/2024	4,470
7/9/2024	7/7/2024	7/13/2024	3,860
7/17/2024	7/14/2024	7/20/2024	3,380
7/22/2024	7/21/2024	7/27/2024	3,480
7/29/2024	7/28/2024	8/3/2024	3,200

**Methodology (per Condition of Certification [COC] AQ-C7)**

$PM_{10}$  Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>[1]</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>[2]</sup>	0.0005
Correction Factor (unitless) <sup>[3]</sup>	0.2

<sup>[1]</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>[2]</sup> Per COC AQ-C4.

<sup>[3]</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

### Cooling Tower Daily PM<sub>10</sub> Emissions

Date	Circulation Rate (gal/day) <sup>[1]</sup>	TDS (ppm)	PM <sub>10</sub> Emissions (lb/day)	Above 6.2 lb/day PM <sub>10</sub> Limit? <sup>[2]</sup>
7/1/2024	38,880,000	4,470	1.45	No
7/2/2024	38,880,000	4,470	1.45	No
7/3/2024	38,880,000	4,470	1.45	No
7/4/2024	38,880,000	4,470	1.45	No
7/5/2024	38,880,000	4,470	1.45	No
7/6/2024	38,880,000	4,470	1.45	No
7/7/2024	38,880,000	3,860	1.25	No
7/8/2024	38,880,000	3,860	1.25	No
7/9/2024	38,880,000	3,860	1.25	No
7/10/2024	38,880,000	3,860	1.25	No
7/11/2024	38,880,000	3,860	1.25	No
7/12/2024	38,880,000	3,860	1.25	No
7/13/2024	38,880,000	3,860	1.25	No
7/14/2024	38,880,000	3,380	1.10	No
7/15/2024	38,880,000	3,380	1.10	No
7/16/2024	38,880,000	3,380	1.10	No
7/17/2024	38,880,000	3,380	1.10	No
7/18/2024	38,880,000	3,380	1.10	No
7/19/2024	38,880,000	3,380	1.10	No
7/20/2024	38,880,000	3,380	1.10	No
7/21/2024	38,880,000	3,480	1.13	No
7/22/2024	38,880,000	3,480	1.13	No
7/23/2024	38,880,000	3,480	1.13	No
7/24/2024	38,880,000	3,480	1.13	No
7/25/2024	38,880,000	3,480	1.13	No
7/26/2024	38,880,000	3,480	1.13	No
7/27/2024	38,880,000	3,480	1.13	No
7/28/2024	38,880,000	3,200	1.04	No
7/29/2024	38,880,000	3,200	1.04	No
7/30/2024	38,880,000	3,200	1.04	No
7/31/2024	38,880,000	3,200	1.04	No

<sup>[1]</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>[2]</sup> Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 4**

**Reporting Period:** August 2024

**Cooling Tower Total Dissolved Solids (TDS) Sampling Results**  
Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date <sup>[1]</sup>	Period		TDS (ppm)
	Start Date	End Date	
7/29/2024	7/28/2024	8/3/2024	3,200
8/6/2024	8/4/2024	8/10/2024	3,980
8/13/2024	8/11/2024	8/17/2024	4,000
8/20/2024	8/18/2024	8/24/2024	3,980
8/26/2024	8/25/2024	8/31/2024	4,440

**Methodology (per Condition of Certification [COC] AQ-C7)**

$$PM_{10} \text{ Emissions (lb/day)} = \text{Circulation Rate (gal/day)} \times \text{Density of Water (lb/gal)} \times \text{Total Dissolved Solids (ppm)} / 1,000,000 \times \text{Drift Factor (\%)} / 100 \times \text{Correction Factor}$$

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>[1]</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>[2]</sup>	0.0005
Correction Factor (unitless) <sup>[3]</sup>	0.2

<sup>[1]</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>[2]</sup> Per COC AQ-C4.

<sup>[3]</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

**Cooling Tower Daily PM<sub>10</sub> Emissions**

<b>Date</b>	<b>Circulation Rate (gal/day) <sup>[1]</sup></b>	<b>TDS (ppm)</b>	<b>PM<sub>10</sub> Emissions (lb/day)</b>	<b>Above 6.2 lb/day PM<sub>10</sub> Limit? <sup>[2]</sup></b>
8/1/2024	38,880,000	3,200	1.04	No
8/2/2024	38,880,000	3,200	1.04	No
8/3/2024	38,880,000	3,200	1.04	No
8/4/2024	38,880,000	3,980	1.29	No
8/5/2024	38,880,000	3,980	1.29	No
8/6/2024	38,880,000	3,980	1.29	No
8/7/2024	38,880,000	3,980	1.29	No
8/8/2024	38,880,000	3,980	1.29	No
8/9/2024	38,880,000	3,980	1.29	No
8/10/2024	38,880,000	3,980	1.29	No
8/11/2024	38,880,000	4,000	1.30	No
8/12/2024	38,880,000	4,000	1.30	No
8/13/2024	38,880,000	4,000	1.30	No
8/14/2024	38,880,000	4,000	1.30	No
8/15/2024	38,880,000	4,000	1.30	No
8/16/2024	38,880,000	4,000	1.30	No
8/17/2024	38,880,000	4,000	1.30	No
8/18/2024	38,880,000	3,980	1.29	No
8/19/2024	38,880,000	3,980	1.29	No
8/20/2024	38,880,000	3,980	1.29	No
8/21/2024	38,880,000	3,980	1.29	No
8/22/2024	38,880,000	3,980	1.29	No
8/23/2024	38,880,000	3,980	1.29	No
8/24/2024	38,880,000	3,980	1.29	No
8/25/2024	38,880,000	4,440	1.44	No
8/26/2024	38,880,000	4,440	1.44	No
8/27/2024	38,880,000	4,440	1.44	No
8/28/2024	38,880,000	4,440	1.44	No
8/29/2024	38,880,000	4,440	1.44	No
8/30/2024	38,880,000	4,440	1.44	No
8/31/2024	38,880,000	4,440	1.44	No

<sup>[1]</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>[2]</sup> Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Table 5**

**Reporting Period:** September 2024

**Cooling Tower Total Dissolved Solids (TDS) Sampling Results**

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period		TDS (ppm)
	Start Date	End Date	
9/4/2024	9/1/2024	9/7/2024	4,060
9/9/2024	9/8/2024	9/14/2024	3,860
9/17/2024	9/15/2024	9/21/2024	4,140
9/23/2024	9/22/2024	9/28/2024	3,360
9/30/2024	9/29/2024	10/5/2024	4,120

**Methodology (per Condition of Certification [COC] AQ-C7)**

$PM_{10}$  Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

**Constants**

Parameter	Value
Circulation Rate per Pump (gal/min) <sup>[1]</sup>	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) <sup>[2]</sup>	0.0005
Correction Factor (unitless) <sup>[3]</sup>	0.2

<sup>[1]</sup> Source: M3-10 Main Circulating Water System P&ID.

<sup>[2]</sup> Per COC AQ-C4.

<sup>[3]</sup> Source: SPX Cooling Technologies' Cooling Tower Drift Mass

Cooling Tower Daily PM<sub>10</sub> Emissions

Date	Circulation Rate (gal/day) <sup>[1]</sup>	TDS (ppm)	PM <sub>10</sub> Emissions (lb/day)	Above 6.2 lb/day PM <sub>10</sub> Limit? <sup>[2]</sup>
9/1/2024	38,880,000	4,060	1.32	No
9/2/2024	38,880,000	4,060	1.32	No
9/3/2024	38,880,000	4,060	1.32	No
9/4/2024	38,880,000	4,060	1.32	No
9/5/2024	38,880,000	4,060	1.32	No
9/6/2024	38,880,000	4,060	1.32	No
9/7/2024	38,880,000	4,060	1.32	No
9/8/2024	38,880,000	3,860	1.25	No
9/9/2024	38,880,000	3,860	1.25	No
9/10/2024	38,880,000	3,860	1.25	No
9/11/2024	38,880,000	3,860	1.25	No
9/12/2024	38,880,000	3,860	1.25	No
9/13/2024	38,880,000	3,860	1.25	No
9/14/2024	38,880,000	3,860	1.25	No
9/15/2024	38,880,000	4,140	1.34	No
9/16/2024	38,880,000	4,140	1.34	No
9/17/2024	38,880,000	4,140	1.34	No
9/18/2024	38,880,000	4,140	1.34	No
9/19/2024	38,880,000	4,140	1.34	No
9/20/2024	38,880,000	4,140	1.34	No
9/21/2024	38,880,000	4,140	1.34	No
9/22/2024	38,880,000	3,360	1.09	No
9/23/2024	38,880,000	3,360	1.09	No
9/24/2024	38,880,000	3,360	1.09	No
9/25/2024	38,880,000	3,360	1.09	No
9/26/2024	38,880,000	3,360	1.09	No
9/27/2024	38,880,000	3,360	1.09	No
9/28/2024	38,880,000	3,360	1.09	No
9/29/2024	38,880,000	4,120	1.33	No
9/30/2024	38,880,000	4,120	1.33	No

<sup>[1]</sup> Maximum daily circulation rate conservatively used to estimate PM<sub>10</sub> emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

<sup>[2]</sup> Daily emissions limit established in COC AQ-C7.

Malburg Generating Station  
Quarterly Compliance Report  
Appendix A, Tables 6, 7, 8, & 9

Reporting Period: **Quarter 3 2024**

Table 6. Monthly Turbine-Duct Burner Fuel Flow

Source	July		August		September	
	Fuel Flow (MMscf/month) <sup>[1]</sup>	Above 405 MMscf/month Limit? <sup>[2]</sup>	Fuel Flow (MMscf/month) <sup>[1]</sup>	Above 405 MMscf/month Limit? <sup>[2]</sup>	Fuel Flow (MMscf/month) <sup>[1]</sup>	Above 405 MMscf/month Limit? <sup>[2]</sup>
CTG 1	202		206		210.2	
CTG 1 Duct Burner	2.43		3.05		3.87	
<b>Total CTG 1 &amp; Duct Burner</b>	<b>204</b>	<b>No</b>	<b>209</b>	<b>No</b>	<b>214.0</b>	<b>No</b>
CTG 2	175.69		222.15		96	
CTG 2 Duct Burner	2.37		3.14		3.67	
<b>Total CTG 2 &amp; Duct Burner</b>	<b>178.06</b>	<b>No</b>	<b>225.29</b>	<b>No</b>	<b>99</b>	<b>No</b>

<sup>[1]</sup> CTG and Duct Burner fuel flow data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' and 'ALL\_12MonthSummary\_GasUsage' RegPerfect Reports.

<sup>[2]</sup> Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - July 2024

Source	Monthly Emissions (lb/month) <sup>[1]</sup>					
	NO <sub>x</sub> <sup>[2]</sup>	CO	VOC	SO <sub>x</sub>	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>[3]</sup>
CTG 1 & Duct Burner	3,921	489	315	57	1,227	1,878
CTG 2 & Duct Burner	2,888	483	291	53	1,136	1,641
Monthly Emission Limits <sup>[4]</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>[1]</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>[2]</sup> Monthly NO<sub>x</sub> emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>[3]</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020.

The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>[4]</sup> Monthly emission limits are per COC AQ-5.

**Table 8. Monthly Emissions - August 2024**

Source	Monthly Emissions (lb/month) <sup>[1]</sup>					
	NO <sub>x</sub> <sup>[2]</sup>	CO	VOC	SO <sub>x</sub>	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>[3]</sup>
CTG 1 & Duct Burner	1,500	496	323	59	1,259	1,932
CTG 2 & Duct Burner	1,583	556	358	65	1,395	2,078
Monthly Emission Limits <sup>[4]</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>[1]</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>[2]</sup> Monthly NO<sub>x</sub> emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>[3]</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020.

The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>[4]</sup> Monthly emission limits are per COC AQ-5.

**Table 9. Monthly Emissions - September 2024**

Source	Monthly Emissions (lb/month) <sup>[1]</sup>					
	NO <sub>x</sub> <sup>[2]</sup>	CO	VOC	SO <sub>x</sub>	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub> <sup>[3]</sup>
CTG 1 & Duct Burner	1,538	539	330	60	1,287	1,982
CTG 2 & Duct Burner	766	334	153	28	598	937
Monthly Emission Limits <sup>[4]</sup>	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

<sup>[1]</sup> Unless otherwise noted, monthly emissions data obtained from 'U1/U2\_MonthlySummary\_MassEmissionsAndFuel' RegPerfect Report.

<sup>[2]</sup> Monthly NO<sub>x</sub> emissions are as submitted to SCAQMD, based on the 'U1\_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

<sup>[3]</sup> Monthly NH<sub>3</sub> emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020.

The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

<sup>[4]</sup> Monthly emission limits are per COC AQ-5.

Malburg Generating Station  
 Quarterly Compliance Report  
 Appendix A, Table 10

Reporting Period: **Quarter 3 2024**

**Methodology**

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

**Emission Factors**

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICEs given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM <sub>10</sub> /PM <sub>2.5</sub>	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
NH <sub>3</sub>	0.80	Default for diesel combustion equipment without an SNCR or SCR given in the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Reporting Procedures - June 2020.

**Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions**

Month	Monthly Hours of Operation <sup>[1]</sup>			Fuel Usage (gal/month) <sup>[2]</sup>	Monthly Emissions (lb/month)					
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM <sub>10</sub> /PM <sub>2.5</sub>	NH <sub>3</sub>
January	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
February	0.0	1.5	0.0	16.8	7.9	0.23	0.06	0.00	0.05	0.01
March	0.0	2.6	0.0	29.1	13.7	0.40	0.10	0.01	0.09	0.02
April	0.0	2.6	0.0	29.1	13.7	0.40	0.10	0.01	0.09	0.02
May	0.0	1.7	0.0	19.0	8.9	0.26	0.06	0.00	0.06	0.02
June	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
July	0.0	2.4	0.0	26.9	12.6	0.37	0.09	0.01	0.08	0.02
August	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
September	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
<b>Q3 Total</b>	<b>0.0</b>	<b>6.4</b>	<b>0.0</b>	<b>71.7</b>	<b>33.6</b>	<b>1.0</b>	<b>0.24</b>	<b>0.02</b>	<b>0.22</b>	<b>0.06</b>
Annual Limit for Maintenance and Testing <sup>[3]</sup>			50							
Total Annual Limit <sup>[3]</sup>			200							
Exceeds Limits?			No							

<sup>[1]</sup> Monthly hours of operation calculated from Device 385/403 run timer readings.

<sup>[2]</sup> Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

<sup>[3]</sup> Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

# **Appendix B**

## **Cooling Tower Blowdown Reports**





781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

July 10, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2407013  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 02, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #: 74548  
 Report Date: 07/10/24  
 Submitted: 07/02/24  
**PLS Report No.: 2407013**

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2407013-01) Sampled: 07/02/24 08:00 Received: 07/02/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4470</b>		1	mg/L	5.0	SM 2540C	07/08/24	07/09/24	jks	BG40913

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BG40913 - -</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
<b>Duplicate</b>										
<b>Source: 2407029-01</b>										
Total Dissolved Solids	4050	5.0	mg/L		3860			4.59	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-22-24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2407013

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.9°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.9°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED								SAMPLE CONDITIONS/ CONTAINER/COMMENTS					
				WATER	SOIL	SLUDGE	OTHER		#	TYPE															
	<u>7-22-24</u>	<u>0800</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X														

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> John Barie	Date: <u>7-22-24</u>	Time: <u>0800</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 7-22-24 11/10



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

July 10, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2407029  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 08, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 07/10/24  
 Submitted: 07/08/24  
**PLS Report No.: 2407029**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2407029-01) Sampled: 07/08/24 07:20 Received: 07/08/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>3860</b>		1	mg/L	5.0	- SM 2540C	07/08/24	07/09/24	jks	BG40913

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BG40913 - -</b>										
<b>Blank</b>										
Prepared: 07/08/24 Analyzed: 07/09/24										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 07/08/24 Analyzed: 07/09/24										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
<b>Duplicate</b>										
Source: 2407029-01 Prepared: 07/08/24 Analyzed: 07/09/24										
Total Dissolved Solids	4050	5.0	mg/L		3860			4.59	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Parker*  
 Authorized Signature(s)



### CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 7.8.24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2407029

CLIENT NAME: CITY OF VERNON		PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY		P.O.NO.		AIRBILL NO:												
ADDRESS: 4963 SOTO ST. VERNON CA 90058				ANALYSES REQUESTED				OBSERVED TEMP <u>0.0°C</u>										
PROJECT MANAGER MATT RICHARDS		PHONE NO:		FAX NO:		CORRECTED TEMP: <u>1.0°C</u>												
SAMPLER NAME: JOHN BARIE		SIGNATURE: <u>[Signature]</u>				THERMO ID: <u>60</u>												
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal																		
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																		
UST PROJECT: Y N GLOBAL ID#: -----																		
SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>7.8.24</u>	<u>0720</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>7.8.24</u>	Time: <u>0720</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 7.8.24 [Signature]



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

July 24, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2407097  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 17, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 07/24/24  
 Submitted: 07/17/24  
**PLS Report No.: 2407097**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Sample ID: Cooling Tower Blowdown Water (2407097-01) Sampled: 07/17/24 08:00 Received: 07/17/24</b>										
<b>Total Dissolved Solids</b>	<b>3380</b>		1	mg/L	5.0	- SM 2540C	07/18/24	07/19/24	ss	BG41905

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BG41905 - -</b>										
<b>Blank</b>	<b>Prepared: 07/18/24 Analyzed: 07/19/24</b>									
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>	<b>Prepared: 07/18/24 Analyzed: 07/19/24</b>									
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
<b>Duplicate</b>	<b>Source: 2407097-01 Prepared: 07/18/24 Analyzed: 07/19/24</b>									
Total Dissolved Solids	3270	5.0	mg/L		3380			3.22	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

*Rick Owen Parlein*  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-17-24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2407097

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 03°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 13°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>7-17-24</u>	<u>0300</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>7-17-24</u>	Time: <u>0300</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 7-17-24 0840



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

July 29, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2407120  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 22, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 07/29/24  
 Submitted: 07/22/24  
**PLS Report No.: 2407120**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2407120-01) Sampled: 07/22/24 08:00 Received: 07/22/24											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
<b>Total Dissolved Solids</b>	<b>3480</b>		1	mg/L	5.0	-	SM 2540C	07/25/24	07/26/24	ss	BG42613

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BG42613 - -</b>									
<b>Blank</b>									
Prepared: 07/25/24 Analyzed: 07/26/24									
Total Dissolved Solids	ND	5.0	mg/L						
<b>LCS</b>									
Prepared: 07/25/24 Analyzed: 07/26/24									
Total Dissolved Solids	57.0	5.0	mg/L	50.00		114 80-120			
<b>Duplicate</b>									
Source: 2407142-05 Prepared: 07/25/24 Analyzed: 07/26/24									
Total Dissolved Solids	3970	5.0	mg/L		4060		2.33	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Rick Owen Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 7.22.24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 240712D

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.1°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.1°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>7.22.24</u>	<u>0825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i>	Date: <u>7.22.24</u>	Time: <u>0825</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 7.22.24 0825



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

August 06, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2407189  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 29, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

### Certificate of Analysis

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #: 74548  
 Report Date: 08/06/24  
 Submitted: 07/29/24  
**PLS Report No.: 2407189**

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2407189-01) Sampled: 07/29/24 08:15 Received: 07/29/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>3200</b>	B	1	mg/L	5.0	- SM 2540C	08/01/24	08/02/24	mv	BH40603

### Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	RPD Limit	Qualifier
<b>Batch BH40603 - -</b>									
<b>Blank</b>									
Total Dissolved Solids	16.0	5.0	mg/L						B
<b>LCS</b>									
Total Dissolved Solids	55.0	5.0	mg/L	50.00		110	80-120		B
<b>Duplicate</b>									
<b>Source: 2407189-01</b>		<b>Prepared: 08/01/24 Analyzed: 08/02/24</b>							
Total Dissolved Solids	3160	5.0	mg/L		3200		1.41	5	B

### Notes and Definitions

- B Analyte present in the blank (CLP B-flag).
- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

*Rick Owen Parker*

Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 [213] 745-5312 FAX [213] 745-6372

DATE: 7-29-21 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2407189

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. \_\_\_\_\_ AIRBILL NO: \_\_\_\_\_

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: \_\_\_\_\_ FAX NO: \_\_\_\_\_ OBSERVED TEMP: 20.0°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] CORRECTED TEMP: 1.0°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>7-29-21</u>	<u>0815</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>7-29-21</u>	Time: <u>0815</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 7-29-21 0940



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

August 12, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2408021  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 06, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #: 74548  
 Report Date: 08/12/24  
 Submitted: 08/06/24  
**PLS Report No.: 2408021**

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2408021-01) Sampled: 08/06/24 08:15 Received: 08/06/24											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	3980		1	mg/L	5.0	- SM 2540C	08/08/24	08/09/24	ss	BH41208	

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
<b>Batch BH41208 - -</b>											
<b>Blank</b> Prepared: 08/08/24 Analyzed: 08/09/24											
Total Dissolved Solids	ND	5.0	mg/L								
<b>LCS</b> Prepared: 08/08/24 Analyzed: 08/09/24											
Total Dissolved Solids	56.0	5.0	mg/L	50.00		112	80-120				
<b>Duplicate</b> Source: 2408021-01 Prepared: 08/08/24 Analyzed: 08/09/24											
Total Dissolved Solids	4020	5.0	mg/L		3980			0.874	5		

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

*Fick Area Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)



# CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/6/15 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2408021

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. \_\_\_\_\_ AIRBILL NO: \_\_\_\_\_

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED \_\_\_\_\_ OBSERVED TEMP: 0.7°C

PROJECT MANAGER **MATT RICHARDS** PHONE NO: \_\_\_\_\_ FAX NO: \_\_\_\_\_ CORRECTED TEMP: 1.7°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>8/6/15</u>	<u>0815</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>John Tom Barie</u>	Date: <u>8-6-15</u>	Time: <u>0815</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 8/6/15 1020



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

August 16, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2408079  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 13, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 08/16/24  
 Submitted: 08/13/24  
**PLS Report No.: 2408079**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2408079-01) Sampled: 08/13/24 08:05 Received: 08/13/24										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4000</b>		1	mg/L	5.0	- SM 2540C	08/15/24	08/16/24	ss	BH41617

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BH41617 - -</b>										
<b>Blank</b>										
Prepared: 08/15/24 Analyzed: 08/16/24										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 08/15/24 Analyzed: 08/16/24										
Total Dissolved Solids	41.0	5.0	mg/L	50.00		82.0	80-120			
<b>Duplicate</b>										
Source: 2408079-01 Prepared: 08/15/24 Analyzed: 08/16/24										
Total Dissolved Solids	4030	5.0	mg/L		4000			0.955	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE 8-13-24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2408079

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. \_\_\_\_\_ AIRBILL NO: \_\_\_\_\_

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: \_\_\_\_\_ FAX NO: \_\_\_\_\_ OBSERVED TEMP: 02°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: *[Signature]* CORRECTED TEMP: 12°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>8-13-24</u>	<u>0805</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i>	Date: <u>8-13-24</u>	Time: <u>0805</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 8-13-24 1015



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

August 26, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2408118  
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 20, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager

**Certificate of Analysis**

Page 2 of 2

 City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

 File #:74548  
 Report Date: 08/26/24  
 Submitted: 08/20/24  
**PLS Report No.: 2408118**
**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2408118-01) Sampled: 08/20/24 07:10 Received: 08/20/24										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>3980</b>		1	mg/L	5.0	- SM 2540C	08/22/24	08/23/24	ss	BH42321

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BH42321 - -</b>										
<b>Blank</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120			
<b>Duplicate</b> Source: 2408118-01 Prepared: 08/22/24 Analyzed: 08/23/24										
Total Dissolved Solids	3910	5.0	mg/L		3980			1.56	5	

**Notes and Definitions**

NA Not Applicable  
 ND Analyte NOT DETECTED at or above the reported limit(s)  
 NR Not Reported  
 MDL Method Detection Limit  
 PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131



Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/20/24 PAGE: 1 of 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2408118

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. \_\_\_\_\_ AIRBILL NO: \_\_\_\_\_

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: \_\_\_\_\_ FAX NO: \_\_\_\_\_ OBSERVED TEMP: 0.8°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: CORRECTED TEMP: 1.8°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 68

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>8/20/24</u>	<u>0710</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): 	Received by (Signature & Name): 	Date: <u>8/20/24</u>	Time: <u>0710</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 8/20/24 0135



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

September 03, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2408163  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 26, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager

**Certificate of Analysis**

Page 2 of 2

 City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

File #:74548

Report Date: 09/03/24

Submitted: 08/26/24

**PLS Report No.: 2408163**
**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2408163-01) Sampled: 08/26/24 09:30 Received: 08/26/24										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4440</b>		1	mg/L	5.0	-	SM 2540C	08/29/24	08/30/24	ss BH43014

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BH43014 --</b>										
<b>Blank</b>										
Prepared: 08/29/24 Analyzed: 08/30/24										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 08/29/24 Analyzed: 08/30/24										
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
<b>Duplicate</b>										
Source: 2408190-01 Prepared: 08/29/24 Analyzed: 08/30/24										
Total Dissolved Solids	1170	5.0	mg/L		1150			1.44	5	

**Notes and Definitions**

NA Not Applicable  
 ND Analyte NOT DETECTED at or above the reported limit(s)  
 NR Not Reported  
 MDL Method Detection Limit  
 PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131



Authorized Signature(s)



### CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/26/24 PAGE: 1 of 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2408163

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 0.10C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.10C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>8/26/24</u>	<u>0930</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>8/26/24</u>	Time: <u>0930</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 8/26/24 1000



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

September 09, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2409010  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 04, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager

**Certificate of Analysis**

Page 2 of 2

 City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

File #:74548

Report Date: 09/09/24

Submitted: 09/04/24

**PLS Report No.: 2409010**
**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2409010-01) Sampled: 09/04/24 08:35 Received: 09/04/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4060</b>		1	mg/L	5.0	- SM 2540C	09/05/24	09/06/24	ss	BI40614

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
<b>Batch BI40614 - -</b>										
<b>Blank</b>										
Prepared: 09/05/24 Analyzed: 09/06/24										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 09/05/24 Analyzed: 09/06/24										
Total Dissolved Solids	51.0	5.0	mg/L	50.00		102	80-120			
<b>Duplicate</b>										
Source: 2409010-01 Prepared: 09/05/24 Analyzed: 09/06/24										
Total Dissolved Solids	4030	5.0	mg/L		4060			0.718	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138



Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 9.4.24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2409010

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. \_\_\_\_\_ AIRBILL NO: \_\_\_\_\_

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: \_\_\_\_\_ FAX NO: \_\_\_\_\_ OBSERVED TEMP: 0.7°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] CORRECTED TEMP: 1.7°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>9.4.24</u>	<u>0835</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	SAMPLE DISPOSITION
<u>MA</u>	<u>[Signature]</u>	<u>9.4.24</u>	<u>0835</u>	1. Samples returned to client? Yes No
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	2. Samples will not be stored over 30 days, unless additional storage time is requested
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	3. Storage time requested: _____ days, By: _____ Date: _____

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 9.4.24 0900



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

September 16, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2409046  
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 09, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 09/16/24  
 Submitted: 09/09/24  
**PLS Report No.: 2409046**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2409046-01) Sampled: 09/09/24 07:50 Received: 09/09/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>3860</b>		1	mg/L	5.0	- SM 2540C	09/12/24	09/13/24	ss	BI41313

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	------	-------------	-----	-----------	-----------

**Batch BI41313 - -**

<b>Blank</b>	<b>Prepared: 09/12/24 Analyzed: 09/13/24</b>									
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>	<b>Prepared: 09/12/24 Analyzed: 09/13/24</b>									
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
<b>Duplicate</b>	<b>Source: 2409084-01 Prepared: 09/12/24 Analyzed: 09/13/24</b>									
Total Dissolved Solids	9850	5.0	mg/L		9940			0.825	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

*Pick Owen Parkin*  
 \_\_\_\_\_  
 Authorized Signature(s)





781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

September 23, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2409106  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 17, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 09/23/24  
 Submitted: 09/17/24  
**PLS Report No.: 2409106**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2409106-01) Sampled: 09/17/24 09:15 Received: 09/17/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>4140</b>		1	mg/L	5.0	- SM 2540C	09/19/24	09/20/24	ss	BI42016

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	Limit	Qualifier
<b>Batch BI42016 - -</b>										
<b>Blank</b>										
Prepared: 09/19/24 Analyzed: 09/20/24										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
Prepared: 09/19/24 Analyzed: 09/20/24										
Total Dissolved Solids	50.0	5.0	mg/L	50.00		100	80-120			
<b>Duplicate</b>										
Source: 2409106-01 Prepared: 09/19/24 Analyzed: 09/20/24										
Total Dissolved Solids	4050	5.0	mg/L		4140			2.30	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

*Rick Owen Parker*

Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 9-17-24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2409106

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.4°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.4°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 61

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>9-17-24</u>	<u>0915</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>9-17-24</u>	Time: <u>0915</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

**SPECIAL INSTRUCTION:**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 9-17-24 9:50



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

September 30, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2409145  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 23, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 09/30/24  
 Submitted: 09/23/24  
**PLS Report No.: 2409145**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

**Sample ID: Cooling Tower Blowdown Water (2409145-01) Sampled: 09/23/24 07:40 Received: 09/23/24**

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
<b>Total Dissolved Solids</b>	<b>3360</b>		1	mg/L	5.0	- SM 2540C	09/26/24	09/27/24	mv	BI43006

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	Limit	Qualifier
<b>Batch BI43006 - -</b>										
<b>Blank</b>										
<b>Prepared: 09/26/24 Analyzed: 09/27/24</b>										
Total Dissolved Solids	ND	5.0	mg/L							
<b>LCS</b>										
<b>Prepared &amp; Analyzed: 09/27/24</b>										
Total Dissolved Solids	52.0	5.0	mg/L	50.00		104	80-120			
<b>Duplicate</b>										
<b>Source: 2409148-01 Prepared: 09/26/24 Analyzed: 09/27/24</b>										
Total Dissolved Solids	340	5.0	mg/L		415			19.9	5	

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

*Rick Owen Parker*  
 \_\_\_\_\_  
 Authorized Signature(s)



## CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 9-23-24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2409145

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 0.0°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.0°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>9/23/24</u>	<u>0740</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	SAMPLE DISPOSITION
<i>MA</i>	<i>[Signature]</i> John Barie	<u>9-23-24</u>	<u>0740</u>	1. Samples returned to client? Yes No
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	2. Samples will not be stored over 30 days, unless additional storage time is requested
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	3. Storage time requested: _____ days,
				By: _____ Date: _____

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 9-23-24 09 25



781 East Washington Blvd., Los Angeles, CA 90021  
(213) 745-5312 FAX (213) 745-6372

October 07, 2024

Matt Richards  
City of Vernon  
4963 Soto St.  
Vernon, CA 90058

Report No.: 2409182  
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 30, 2024.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

  
Project Manager



781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

**Certificate of Analysis**

Page 2 of 2

City of Vernon  
 4963 Soto St.  
 Vernon, CA 90058

File #:74548  
 Report Date: 10/07/24  
 Submitted: 09/30/24  
**PLS Report No.: 2409182**

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2409182-01) Sampled: 09/30/24 07:35 Received: 09/30/24											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
<b>Total Dissolved Solids</b>	<b>4120</b>		1	mg/L	5.0	- SM 2540C	10/03/24	10/04/24	ss	BJ40407	

**Quality Control Data**

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
<b>Batch BJ40407 --</b>											
<b>Blank</b>											
Total Dissolved Solids	ND	5.0	mg/L								
<b>LCS</b>											
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120				
<b>Duplicate Source: 2409182-01 Prepared &amp; Analyzed: 10/04/24</b>											
Total Dissolved Solids	4170	5.0	mg/L		4120			1.13	5		

**Notes and Definitions**

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

*Rick Owen Parlier*  
 \_\_\_\_\_  
 Authorized Signature(s)



# CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021  
 (213) 745-5312 FAX (213) 745-6372

DATE: 9/30/24 PAGE: 1 OF 1

FILE NO.: \_\_\_\_\_ LAB NO.: 2409182

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 20°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 10°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	9/30/24	0735	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>9/30/24</u>	Time: <u>0735</u>	<b>SAMPLE DISPOSITION</b> 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 9/30/24 0915

**Appendix C**  
**Operation Logs**



**Malburg Generating Station**  
**Appendix C, Table 1**  
**Combustion Turbine Generator (CTG) Startup and Shutdown Events**  
**During Quarter 3, 2024**

**CTG 1**

Date	Event Type <sup>[1]</sup>	Event Start	Event End	Duration (hrs:min)
7/5/2024	Stop	21:52	22:00	0:08
7/9/2024	Cold Start	15:29	17:15	1:46
8/9/2024	Stop	23:57	00:05	0:08
8/12/2024	Cold Start	15:28	16:51	1:23
9/6/2024	Hot Start	18:13	19:29	1:16
9/11/2024	Stop	23:51	00:00	0:09
9/13/2024	Warm Start	20:35	22:18	1:43

**CTG 2**

Date	Event Type <sup>[1]</sup>	Event Start	Event End	Duration (hrs:min)
7/5/2024	Cold Start	15:30	17:01	1:31
7/15/2024	Stop	23:52	23:59	0:07
7/17/2024	Warm Start	15:32	16:57	1:25
8/9/2024	Stop	23:57	00:05	0:08
8/9/2024 <sup>[2]</sup>	Warm Start	21:13	--	--
8/9/2024	Stop	22:09	22:13	0:04
8/9/2024	Hot Start	22:58	00:02	0:51
9/6/2024	Hot Start	16:59	17:42	0:43
9/17/2024	Hot Start	07:29	08:57	1:28
9/17/2024	Stop	16:58	17:05	0:07

<sup>[1]</sup> A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

<sup>[2]</sup> CTG2 was dispatched to Startup by ADS; however, unable to complete startup due to high HP steam pressure before bypass unlocked.

Malburg Generating Station  
Appendix C, Table 2  
Diesel Firewater Pump Testing Times  
During Quarter 3, 2024

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
7/2/2024	7:57	394.1	394.6	Testing	0.5
7/9/2024 <sup>[1]</sup>	0:00	394.6	395.1	Testing	0.5
7/16/2024	2:08	395.1	395.5	Testing	0.4
7/23/2024	12:53	395.5	396.0	Testing	0.5
7/30/2024	12:23	396.0	396.5	Testing	0.5
8/6/2024	11:21	396.5	397.0	Testing	0.5
8/13/2024	9:19	397.0	397.5	Testing	0.5
8/20/2024	12:27	397.5	398.0	Testing	0.5
8/27/2024	10:12	398.0	398.5	Testing	0.5
9/3/2024	11:20	398.5	399.0	Testing	0.5
9/11/2024	2:18	399.0	399.5	Testing	0.5
9/17/2024	2:26	399.5	400.0	Testing	0.5
9/24/2024	10:36	400.0	400.5	Testing	0.5

<sup>[1]</sup> The time stamp of the engine start and end hours was not recorded on 7/9/2024 as the handheld's battery went dead and deleted the data before it could be uploaded. The time stamp was neither recorded nor commented by the operator during this run.

# **Appendix D**

## **Diesel Fuel Oil Purchase Records**





**SALES QUOTE**

**ORDER NUMBER: 2607075**

SC Commercial, LLC, DBA SC Fuels  
 1800 West Katella Ave., Suite 400  
 P.O. Box 14237, Orange, CA 92863-4159

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext. 6017

DATE: 3/20/2024

TERMS: N30  
 SALES REP: Todd Cripps  
 PHONE: 714-938-5714

**PO#: 00240083**

SHIP DATE: 12/31/5999

ROM:

SHIP VIA:

WHSE: 101

**ACCT NO (Bill-to):** 01-0001045

**ACCT NO (Ship-to):** 01-0001045 103L

CITY OF VERNON  
 4305 SANTA FE AVE  
 ATTN: DEPARTMENT D  
 VERNON, CA 90058  
 (323) 583-8811

CITY OF VERNON-SOTO ST-L  
 4963 SOTO ST  
 VERNON, CA 90058

HM	ITEM CODE	ITEM DESCRIPTION	QTY ORDERED	QTY DEL	PACKAGE DESC	EXTENDED QTY	UNIT PRICE	EXT PRICE	
	O:TODD/POC:ROB 323-583-8811 X257/HRS:8A-2P								
X	NA1993	DIESEL FUEL, 3 PG III / CARGO TANK							
	693D055	R99 DYED RENEWABLE CARB DIESEL MAXIMUM 15 PPM SULFUR, DIESEL FUEL #2. MEETS ALL CARB DIESEL SPECS. For use in State of California NON TAXABLE USE ONLY PENALTY FOR TAXABLE USE.	2.00		55 G DR	110.00 GALS	6.06	666.86	
	Federal Lust					0.00100		0.11	
						6.06340		666.97	
	CH253090981D055	CH GST ADVANTAGE EP 32 250054981 REPLACES-GST 2300 ISO 32 253090981	1.00		55 G DR	55.00 GALS	25.24	1,388.20	
	DRUMDEPOSITC001	DRUM DEPOSIT FEE	3.00		MISC CHRG	3.00 EACH	25.00	75.00	
	/FUELCHLUBE	FUEL SURCHARGE LUBES						9.92	
	/RCFLUBE	REG COMPLIANCE FEE LUBES						12.95	
	**Prices quoted are <u>not</u> firm and are subject to change based upon product availability, quantity delivered and market fluctuations						Net Order:		2,153.04
						Less Discount:		0.00	
						Freight:		0.00	
						Sales Tax:		212.99	
						<b>Order Total:</b>		<b>2,366.03</b>	

# Appendix E

## Excess Emission Report



# Startup/Shutdown Excess Emissions Report

## U1 CO Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:08 **Location:** Vernon, California

**Tag Name:** U1\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 CO Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:08 **Location:** Vernon, California

**Tag Name:** U1\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 NOx Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:09 **Location:** Vernon, California

**Tag Name:** U1\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 NOx Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:09 **Location:** Vernon, California

**Tag Name:** U1\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 VOC Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:10 **Location:** Vernon, California

**Tag Name:** U1\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U1 VOC Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:10 **Location:** Vernon, California

**Tag Name:** U1\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,981.30 Hours

Non-Operating Time: 226.70 Hours Report Time: 2,208.00 Hours



No invalid events were found in the reporting period.

# Excess Emission Report

## Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:11 Location: Vernon, California



Tag Name: U1\_CONormal\_Ppmvdc\_1H

Total Operating Time: 1,988.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 220.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,988.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:13 Location: Vernon, California



Tag Name: U1\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 1,988.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 220.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,988.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:13 Location: Vernon, California



Tag Name: U1\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 1,988.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 220.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,988.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:14 Location: Vernon, California



Tag Name: U1\_CO\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 1,988.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 220.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,988.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Quad K Excess Emissions Report

## U1 NOX 4-Hour Events

From: 07/01/2024 00:00 To: 09/30/2024 23:59  
Generated: 10/10/2024 22:17

Facility Name: Malburg Generating Station  
Location: Vernon, California



Tag Name: U1\_NOx4H\_Ppmvdc\_1H

Total Operating Time: 1,988.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 220.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,988.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## U2 CO Startup/Shutdown Events



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:18 **Location:** Vernon, California

**Tag Name:** U2\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours

Non-Operating Time: 613.68 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## U2 CO Startup/Shutdown Events



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:18

**Location:** Vernon, California

**Tag Name:** U2\_CO\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours

Non-Operating Time: 613.68 Hours

Report Time: 2,208.00 Hours

--	--	--

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/08/2024 22:36 08/08/2024 23:05	30		
08/09/2024 20:25 08/09/2024 21:13	49		
08/09/2024 21:11 09/06/2024 13:23	39853		
08/09/2024 22:11 08/09/2024 23:41	91		

<b>Total CMS Downtime</b>	<b>40023</b>	<b>Minute(s)</b>
<b>Total Downtime as a percentage of operating time</b>	<b>41.84</b>	<b>%</b>
<b>Total Availability as a percentage of operating time</b>	<b>58.16</b>	<b>%</b>

# Startup/Shutdown Excess Emissions Report

## U2 NOx Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:24 **Location:** Vernon, California

**Tag Name:** U2\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours

Non-Operating Time: 613.68 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Excess Emissions Report

## U2 NOx Startup/Shutdown



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:24 **Location:** Vernon, California

**Tag Name:** U2\_NOXRECLM\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours

Non-Operating Time: 613.68 Hours Report Time: 2,208.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/08/2024 22:36 08/08/2024 23:05	30		
08/09/2024 20:25 08/09/2024 21:13	49		
08/09/2024 21:11 09/06/2024 13:23	39853		
08/09/2024 22:11 08/09/2024 23:41	91		

<b>Total CMS Downtime</b>	<b>40023</b>	<b>Minute(s)</b>
<b>Total Downtime as a percentage of operating time</b>	<b>41.84</b>	<b>%</b>
<b>Total Availability as a percentage of operating time</b>	<b>58.16</b>	<b>%</b>

# Startup/Shutdown Event Report

## U2 VOC Startup/Shutdown Events



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:25 **Location:** Vernon, California

**Tag Name:** U2\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours

Non-Operating Time: 613.68 Hours Report Time: 2,208.00 Hours

### Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## U2 VOC Startup/Shutdown Events



**From:** 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** Malburg Generating Station

**Generated:** 10/10/2024 22:25 **Location:** Vernon, California

**Tag Name:** U2\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 1,594.32 Hours  
 Non-Operating Time: 613.68 Hours **Report Time:** 2,208.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/08/2024 22:36 08/08/2024 23:05	30		
08/09/2024 20:25 08/09/2024 21:13	49		
08/09/2024 21:11 09/06/2024 13:23	39853		
08/09/2024 22:11 08/09/2024 23:41	91		

<b>Total CMS Downtime</b>	<b>40023</b>	<b>Minute(s)</b>
<b>Total Downtime as a percentage of operating time</b>	<b>41.84</b>	<b>%</b>
<b>Total Availability as a percentage of operating time</b>	<b>58.16</b>	<b>%</b>

# Excess Emission Report

## Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:27 Location: Vernon, California



Tag Name: U2\_CONormal\_Ppmvdc\_1H

Total Operating Time: 1,603.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 605.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,603.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:28 Location: Vernon, California



Tag Name: U2\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 1,603.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 605.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,603.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:28 Location: Vernon, California



Tag Name: U2\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 1,603.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 605.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,603.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Excess Emission Report

## Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: Malburg Generating Station  
Generated: 10/10/2024 22:29 Location: Vernon, California



Tag Name: U2\_CO\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 1,603.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 605.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,603.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Quad K Excess Emissions Report

## U2 NOX 4-Hour Events

From: 07/01/2024 00:00 To: 09/30/2024 23:59  
Generated: 10/10/2024 22:27

Facility Name: Malburg Generating Station  
Location: Vernon, California



Tag Name: U2\_NOx4H\_Ppmvdc\_1H

Total Operating Time: 1,603.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 605.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,603.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %