DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	259793
Document Title:	Q3 2024 - QUARTERLY OPERATING REPORT
Description:	Q3 2024 - QUARTERLY OPERATING REPORT
Filer:	Anwar Ali
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	10/30/2024 4:02:44 PM
Docketed Date:	10/30/2024

Pacific Gas and Electric Company®

Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS24-L-12

October 28, 2024

Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Electronically submitted to anwar.ali@energy.ca.gov

Dear Mr. Ali:

Attached is the Third Quarter 2024 Operating Report for the Colusa Generating Station.

The QOR includes the following attachments:

Attachment 1: Complaints

Attachment 2: Fuel Quality Data

Attachment 3: 40 CFR 60 Section KKKK Information

Attachment 4: Excess Emissions / Downtime Report / EDS / CMS Reports

Attachment 5: Hourly Emissions – VOC

Attachment 6: Hourly Emissions – NOx

Attachment 7: Hourly Emissions – CO

Attachment 8: Hourly Emissions – NH3

Attachment 9: Quarterly / Annual Emissions (Fuel Use, Hours of Operation, and NH3 Injection)

Attachment 10: Maximum Emissions

Attachment 11: Linearity

Attachment 12: Startup / Shutdown Emissions

Attachment 13: Water Bath Heater Operations

Attachment 14: Certification Report

If you have any questions regarding this submittal, please contact me at (530) 393-2926.

Sincerely,

TJ Gomez
Senior Environmental Field Specialist

cc: Josh Harris, PG&E
Sam Garcia, PG&E

ATTACHMENT 1
Complaints (AQ-5)

During the 3rd quarter of 2024, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #3

2024 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per Standard Cubic Foot

Month	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24	Avg
Gr/100SCF	0.113	0.289	0.270	Outage	0.1408	0.079	0.147	0.082	0.098				0.158

Permit Limits:

.75 Grains/100SCF per Month (PSD Condition X.I.4); .3 Grains/100SCF Annual Average (Title V # 17)

CLIENT	: PG&E Colusa Generating Station
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 241661
REPORT DATE	: 07/31/2024

On July 17th 2024, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-July-A	241661-61190	728.1

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Colusa Generating Station | **SAMPLING DATE : 07/16/2024**

PROJECT NO. : 241661 | **ANALYSIS DATE : 07/24-29/2024**

	Client ID:	CPP-GS-July-A			
	AAC ID:	241661-61190			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 2.05	2.05	< 0.002	0.002
	O_2	0.749	0.205	1.35	0.003
	N_2	3.49	0.205	5.50	0.003
	CO	< 0.205	0.205	< 0.003	0.003
	CO_2	0.876	0.205	2.17	0.005
	CH_4	88.8	0.00010	80.3	0.008
	He	NM	NM	NM	NM
	Ar	< 0.205	0.205	< 0.004	0.004
HYDROCARBONS	C_2 (as Ethane)	5.67	0.00010	9.60	0.0002
	C_3 (as Propane)	0.340	0.00010	0.844	0.0002
	C_4 (as Butane)	0.0620	0.00010	0.203	0.0003
	C_5 (as Pentane)	0.0124	0.00010	0.0505	0.0004
	C_6 (as Hexane)	0.00348	0.00010	0.0169	0.0005
	C_{6+} (as Hexane)	0.00293	0.00010	0.0142	0.0005
TRS	Total Reduced Sulfur	0.000232	0.0000021	0.000446	0.000004
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	21559
Carbon (C)	69.3	*LHV Btu/lb*	19441
Hydrogen (H)	22.3	*HHV Btu/dscf*	1009
Oxygen (O)	2.93	*LHV Btu/dscf*	910
Nitrogen (N)	5.50	*F-Factor*	8654
Helium (He)	0.00	*Relative Density*	0.613
Argon (Ar)	0.00	*C2-C6+ Weight %*	0.00
Sulfur (S)	0.00	*MW lb/lb-mole*	17.8
Motor Octane Number	127	*Methane Number*	87.9
		Wobbe Number	1288.2

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 241661
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 07/16/2024
ANALYSIS DATE : 07/22/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-July-A
AAC ID	241661-61190
Canister Dil. Fac.	2.05
Analyte	Result
Hydrogen Sulfide	**0.500**
COS / SO2	**0.777**
Methyl Mercaptan	**0.156**
Ethyl Mercaptan	< 0.103
Dimethyl Sulfide	< 0.103
Carbon Disulfide	< 0.103
Isopropyl Mercaptan	< 0.103
tert-Butyl Mercaptan	**1.10**
n-Propyl Mercaptan	< 0.103
Methylethylsulfide	< 0.103
sec-Butyl Mercaptan / Thiophene	< 0.103
iso-Butyl Mercaptan	< 0.103
Diethyl Sulfide	< 0.103
n-Butyl Mercaptan	< 0.103
Dimethyl Disulfide	< 0.103
2-Methylthiophene	< 0.103
3-Methylthiophene	< 0.103
Tetrahydrothiophene	**0.670**
Bromothiophene	< 0.103
Thiophenol	< 0.103
Diethyl Disulfide	< 0.103
Total Unidentified Sulfur	< 0.103
Total Reduced Sulfurs	**2.43**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 241661
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 07/16/2024
ANALYSIS DATE : 07/22/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-July-A
AAC ID	241661-61190
Canister Dil. Fac.	2.05
Analyte	Result
Hydrogen Sulfide	**0.03047**
COS / SO2	**0.04733**
Methyl Mercaptan	**0.00949**
Ethyl Mercaptan	< 0.00624
Dimethyl Sulfide	< 0.00624
Carbon Disulfide	< 0.00624
Isopropyl Mercaptan	< 0.00624
tert-Butyl Mercaptan	**0.06707**
n-Propyl Mercaptan	< 0.00624
Methylethylsulfide	< 0.00624
sec-Butyl Mercaptan / Thiophene	< 0.00624
iso-Butyl Mercaptan	< 0.00624
Diethyl Sulfide	< 0.00624
n-Butyl Mercaptan	< 0.00624
Dimethyl Disulfide	< 0.00624
2-Methylthiophene	< 0.00624
3-Methylthiophene	< 0.00624
Tetrahydrothiophene	**0.04084**
Bromothiophene	< 0.00624
Thiophenol	< 0.00624
Diethyl Disulfide	< 0.00624
Total Unidentified Sulfur	< 0.00624
Total Reduced Sulfurs	**0.14787**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 07/29/2024
Analyst : DM/NR
Units : %

Instrument ID : TCD #1
Calb Date : 09/26/23
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.2	10.4	22.5	10.0	9.3	9.9
	% Rec *	102.0	104.6	113.2	100.3	92.5	99.4

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	LCS Result	10.1	10.2	22.7	10.2	9.5	9.9
	LCSD Result	10.1	10.8	22.3	10.2	9.4	9.9
	LCS % Rec *	100.7	102.6	113.8	102.7	94.5	99.9
	LCSD % Rec *	100.9	108.6	112.0	102.5	94.3	99.6
	% RPD ***	0.2	5.6	1.6	0.2	0.3	0.3

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
241595-60900	Sample	0.0	11.2	47.7	0.0	0.0	0.2
	Sample Dup	0.0	11.2	48.2	0.0	0.0	0.2
	Mean	0.0	11.2	47.9	0.0	0.0	0.2
	% RPD ***	0.0	0.0	1.0	0.0	0.0	0.5

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
241595-60900	Sample Conc	0.0	24.0	0.0	0.0	0.1
	Spike Conc	10.0	10.0	10.0	10.0	10.0
	MS Result	10.1	35.4	9.9	9.3	9.8
	MSD Result	10.2	34.6	10.2	9.4	10.0
	MS % Rec **	100.7	114.5	99.8	92.5	97.3
	MSD % Rec **	102.1	107.4	102.3	94.2	99.6
	% RPD ***	1.4	6.4	2.4	1.9	2.4

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.6	10.0	22.5	10.7	9.9	10.3
	% Rec *	105.4	100.7	112.8	107.3	98.8	103.9

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 07/24/2024
Analyst : DM/NR
Units : ppmv

Instrument ID : FID #3
Calb Date : 11/28/23
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	96.6	94.7	97.7	98.6	102.5	99.2
	% Rec *	96.9	96.4	97.8	99.1	102.6	99.1

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	LCS Result	92.8	91.8	95.6	95.4	99.8	97.0
	LCSD Result	98.0	95.0	97.9	97.7	103.1	100.1
	LCS % Rec *	93.1	93.5	95.6	95.8	100.0	96.9
	LCSD % Rec *	98.3	96.7	98.0	98.1	103.2	100.0
	% RPD ***	5.4	3.4	2.4	2.4	3.2	3.1

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
232634-52690	Sample	0.6	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.5	0.0	0.0	0.0	0.0	0.0
	Mean	0.6	0.0	0.0	0.0	0.0	0.0
	% RPD ***	12.5	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
232634-52690	Sample Conc	0.3	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.8	49.1	50.0	49.8	49.9	50.0
	MS Result	52.2	50.5	48.4	52.6	54.8	54.0
	MSD Result	51.3	49.5	50.9	51.7	54.5	53.8
	MS % Rec **	104.2	102.8	96.9	105.6	109.7	108.0
	MSD % Rec **	102.4	100.8	101.9	103.8	109.2	107.5
	% RPD ***	1.7	2.0	5.0	1.8	0.5	0.4

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	95.1	92.4	95.3	93.7	98.4	94.1
	% Rec *	95.4	94.1	95.3	94.1	98.5	94.0

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 7/22/2024
Analyst: CM/KM
Units: ppmV

Instrument ID : SCD-BTU
Calb. Date: : 01/25/2024

Opening Calibration Verification Standard

0.511 ppbV H2S (GC-110223-01)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	11079	0.514	100.5	2.0
Duplicate	11312	0.524	102.6	0.0
Triplicate	11534	0.535	104.7	2.0

0.502 ppbV H2S (GC-110223-01)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	8978	0.484	96.5	2.4
Duplicate	9212	0.497	99.0	0.2
Triplicate	9401	0.507	101.0	2.2

0.497 ppbV H2S (GC-110223-01)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	11916	0.494	99.5	3.0
Duplicate	12390	0.514	103.5	0.8
Triplicate	12557	0.521	104.8	2.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID 231800-48643**

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.000	0.0
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate **Sample ID x2**

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	0.256	0.258	0.250	101.0	97.8	3.1
MeSH	<PQL	0.251	0.259	0.248	103.2	98.8	4.3
DMS	<PQL	0.249	0.268	0.270	107.8	108.7	0.7

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.511	0.555	108.6
MeSH	0.502	0.552	110.0
DMS	0.497	0.546	109.9

**** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.***

PQL = 50.0 ppbV
MDL = 1.1 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

241661

Fuel Gas Sampling

Client: PG&E Colusa Generating Station			Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd			Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA	Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:			Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504 - grains/dscf	Preparation and Analysis: BTU
CPP-GS-July-A	61190	16-Jul-2024	0900	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: TJ Gomez	Date: 16-Jul-2024	Time: 1500 HRS	1. Received By:	Date: 7/17/24	Time: 1156
2. Relinquished By:	Date:	Time:	2. Received By:	Date:	Time:
3. Relinquished By:	Date:	Time:	3. Received By:	Date:	Time:

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS - 1x 1.4C can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E Colusa Generating Station
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 241863
REPORT DATE	: 08/20/2024

On August 7th 2024, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-L Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-AUG-A	241863-62386	737.6

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 241863

SAMPLING DATE : 08/06/2024
ANALYSIS DATE : 08/13-16/2024

	Client ID:	CPP-GS-AUG-A			
	AAC ID:	241863-62386			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 2.10	2.10	< 0.002	0.002
	O_2	0.431	0.210	0.781	0.003
	N_2	2.37	0.210	3.76	0.003
	CO	< 0.210	0.210	< 0.003	0.003
	CO_2	0.791	0.210	1.97	0.005
	CH_4	89.9	0.00010	81.7	0.009
	He	NM	NM	NM	NM
	Ar	< 0.210	0.210	< 0.004	0.004
HYDROCARBONS	C_2 (as Ethane)	5.88	0.00010	10.0	0.0002
	C_3 (as Propane)	0.502	0.00010	1.25	0.0002
	C_4 (as Butane)	0.109	0.00010	0.360	0.0003
	C_5 (as Pentane)	0.0206	0.00010	0.0842	0.0004
	C_6 (as Hexane)	0.00558	0.00010	0.0273	0.0005
	C_{6+} (as Hexane)	0.00811	0.00010	0.0396	0.0005
TRS	Total Reduced Sulfur	0.000133	0.0000021	0.000256	0.000004
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	22136
Carbon (C)	71.2	*LHV Btu/lb*	19960
Hydrogen (H)	22.9	*HHV Btu/dscf*	1030
Oxygen (O)	2.22	*LHV Btu/dscf*	929
Nitrogen (N)	3.76	*F-Factor*	8656
Helium (He)	0.00	*Relative Density*	0.609
Argon (Ar)	0.00	*C2-C6+ Weight %*	11.8
Sulfur (S)	0.00	*MW lb/lb-mole*	17.6
Motor Octane Number	127	*Methane Number*	87.1
		Wobbe Number	1319

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 241863
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 08/06/2024
ANALYSIS DATE : 08/08/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-AUG-A**
AAC ID	**241863-62386**
Canister Dil. Fac.	**2.1**
Analyte	**Result**
Hydrogen Sulfide	**0.172**
COS / SO2	**0.509**
Methyl Mercaptan	**0.107**
Ethyl Mercaptan	< 0.105
Dimethyl Sulfide	< 0.105
Carbon Disulfide	< 0.105
Isopropyl Mercaptan	< 0.105
tert-Butyl Mercaptan	**0.411**
n-Propyl Mercaptan	< 0.105
Methylethylsulfide	< 0.105
sec-Butyl Mercaptan / Thiophene	< 0.105
iso-Butyl Mercaptan	< 0.105
Diethyl Sulfide	< 0.105
n-Butyl Mercaptan	< 0.105
Dimethyl Disulfide	< 0.105
2-Methylthiophene	< 0.105
3-Methylthiophene	< 0.105
Tetrahydrothiophene	**0.658**
Bromothiophene	< 0.105
Thiophenol	< 0.105
Diethyl Disulfide	< 0.105
Total Unidentified Sulfur	< 0.105
Total Reduced Sulfurs	**1.35**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 241863
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 08/06/2024
ANALYSIS DATE : 08/08/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-AUG-A
AAC ID	241863-62386
Canister Dil. Fac.	2.1
Analyte	Result
Hydrogen Sulfide	**0.01046**
COS / SO2	**0.03101**
Methyl Mercaptan	**0.00651**
Ethyl Mercaptan	< 0.00638
Dimethyl Sulfide	< 0.00638
Carbon Disulfide	< 0.00638
Isopropyl Mercaptan	< 0.00638
tert-Butyl Mercaptan	**0.02501**
n-Propyl Mercaptan	< 0.00638
Methylethylsulfide	< 0.00638
sec-Butyl Mercaptan / Thiophene	< 0.00638
iso-Butyl Mercaptan	< 0.00638
Diethyl Sulfide	< 0.00638
n-Butyl Mercaptan	< 0.00638
Dimethyl Disulfide	< 0.00638
2-Methylthiophene	< 0.00638
3-Methylthiophene	< 0.00638
Tetrahydrothiophene	**0.04007**
Bromothiophene	< 0.00638
Thiophenol	< 0.00638
Diethyl Disulfide	< 0.00638
Total Unidentified Sulfur	< 0.00638
Total Reduced Sulfurs	**0.08206**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 8/8/2024
Analyst: CM/KM
Units: ppmV

Instrument ID : SCD-BTU
Calb. Date: : 01/25/2024

Opening Calibration Verification Standard

0.511 ppbV H2S (GC-110223-01)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	10700	0.496	97.1	1.2
Duplicate	10508	0.487	95.3	0.7
Triplicate	10525	0.488	95.5	0.5

0.502 ppbV H2S (GC-110223-01)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	9095	0.491	97.7	0.2
Duplicate	9007	0.486	96.8	0.8
Triplicate	9141	0.493	98.2	0.7

0.497 ppbV H2S (GC-110223-01)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	12502	0.519	104.4	0.5
Duplicate	12269	0.509	102.4	1.3
Triplicate	12532	0.520	104.6	0.8

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID 231800-48643**

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.000	0.0
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate **Sample ID x2**

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	0.256	0.267	0.245	104.5	95.9	8.6
MeSH	<PQL	0.251	0.273	0.257	108.8	102.4	6.0
DMS	<PQL	0.249	0.271	0.262	109.1	105.4	3.4

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.511	0.492	96.3
MeSH	0.502	0.478	95.2
DMS	0.497	0.498	100.2

**** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.***

PQL = 50.0 ppbV
MDL = 1.1 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report

Date Analyzed : 08/13/2024
Analyst : DM/NR
Units : %

Instrument ID : TCD #1
Calb Date : 09/26/23
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.7	9.9	22.5	10.8	10.0	10.5
	% Rec *	106.3	99.9	113.0	108.7	100.1	105.8

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	LCS Result	10.8	10.2	22.8	10.7	9.9	10.5
	LCSD Result	10.8	10.6	22.8	10.6	9.8	10.3
	LCS % Rec *	107.2	102.3	114.3	107.8	99.3	105.1
	LCSD % Rec *	107.2	106.2	114.5	106.6	98.1	103.6
	% RPD ***	0.1	3.8	0.2	1.1	1.2	1.5

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
241839-62166	Sample	0.0	12.9	47.9	0.0	0.0	0.2
	Sample Dup	0.0	12.7	47.7	0.0	0.0	0.2
	Mean	0.0	12.8	47.8	0.0	0.0	0.2
	% RPD ***	0.0	1.7	0.4	0.0	0.0	0.6

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
241839-62166	Sample Conc	0.0	23.9	0.0	0.0	0.1
	Spike Conc	10.0	10.0	10.0	10.0	10.0
	MS Result	10.0	35.5	9.9	9.2	9.7
	MSD Result	10.4	35.0	10.4	9.6	10.1
	MS % Rec **	99.8	116.1	99.9	92.0	96.7
	MSD % Rec **	103.6	111.0	104.1	95.7	100.9
	% RPD ***	3.8	4.6	4.1	4.0	4.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.9	9.9	22.4	10.7	9.9	10.4
	% Rec *	108.7	99.8	112.7	107.8	99.3	104.6

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report

Date Analyzed : 08/16/2024
Analyst : DM/NR
Units : ppmv

Instrument ID : FID #3
Calb Date : 11/28/23
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	104.2	103.1	107.0	108.2	112.9	108.6
	% Rec *	104.6	105.0	107.0	108.6	113.0	108.5

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	LCS Result	102.5	102.5	108.0	109.0	114.8	109.9
	LCSD Result	96.3	95.2	98.7	100.0	102.9	99.7
	LCS % Rec *	102.9	104.3	108.1	109.4	114.9	109.8
	LCSD % Rec *	96.6	96.9	98.7	100.5	103.0	99.6
	% RPD ***	6.3	7.4	9.1	8.5	11.0	9.7

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
241301-59356	Sample	2.3	0.0	1.0	0.0	0.0	0.0
	Sample Dup	2.3	0.0	1.0	0.0	0.0	0.0
	Mean	2.3	0.0	1.0	0.0	0.0	0.0
	% RPD ***	0.9	0.0	0.7	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
241301-59356	Sample Conc	1.2	0.0	0.5	0.0	0.0	0.0
	Spike Conc	49.8	49.1	50.0	49.8	49.9	50.0
	MS Result	56.9	54.5	57.7	57.7	60.0	58.2
	MSD Result	54.8	53.7	54.8	56.7	59.5	58.0
	MS % Rec **	111.8	110.9	114.5	115.9	120.2	116.4
	MSD % Rec **	107.6	109.4	108.7	113.8	119.1	115.9
	% RPD ***	3.8	1.3	5.2	1.8	0.9	0.4

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	100.7	100.0	104.0	106.5	112.4	110.4
	% Rec *	101.0	101.8	104.1	106.9	112.5	110.4

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

241863

Fuel Gas Sampling

Client: PG&E Colusa Generating Station			Project Manager: TJ Gomez		Date:
Address: 4780 Dirks Rd			Telephone Number: 530-393-2926	Email: AJGU@pge.com	Laboratory: AAC Labs
City: Maxwell	State: CA	Zip: 95955	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: TJ Gomez 530-393-2926		Laboratory Fax:
Contract Number, PO Number:			Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504 - grains/dscf	BTU
CPP-GS-AUG-A		6-Aug-2024	0830	Gas	1 liter	cyl	1	None		X	X
62386											

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.com)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: TJ Gomez	6-Aug-2024	1500 HRS	1. Received By:	8/7/24	1057
2. Relinquished By:	Date	Time	2. Received By:	Date	Time
3. Relinquished By:	Date	Time	3. Received By:	Date	Time

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS - 1x 1.4L can

Atmospheric Analysis & Consulting, Inc

CLIENT	: PG&E Colusa Generating Station
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 242147
REPORT DATE	: 09/23/2024

On September 10th 2024, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-SEPT-A	242147-63856	724.2

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 8 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 242147

SAMPLING DATE : 09/09/2024
ANALYSIS DATE : 09/18-19/2024

	Client ID:	CPP-GS-SEPT-A			
	AAC ID:	242147-63856			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 2.12	2.12	< 0.002	0.002
	O_2	0.403	0.212	0.734	0.004
	N_2	2.16	0.212	3.45	0.003
	CO	< 0.212	0.212	< 0.003	0.003
	CO_2	0.747	0.212	1.87	0.005
	CH_4	90.4	0.00011	82.5	0.009
	He	NM	NM	NM	NM
	Ar	< 0.212	0.212	< 0.004	0.004
HYDROCARBONS	C_2 (as Ethane)	5.60	0.00011	9.57	0.0002
	C_3 (as Propane)	0.523	0.00011	1.31	0.0002
	C_4 (as Butane)	0.116	0.00011	0.385	0.0003
	C_5 (as Pentane)	0.0218	0.00011	0.0894	0.0004
	C_6 (as Hexane)	0.00485	0.00011	0.0238	0.0005
	C_{6+} (as Hexane)	0.00409	0.00011	0.0201	0.0005
TRS	Total Reduced Sulfur	0.000159	0.0000021	0.000308	0.000004
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	22253
Carbon (C)	71.5	*LHV Btu/lb*	20063
Hydrogen (H)	23.0	*HHV Btu/dscf*	1031
Oxygen (O)	2.10	*LHV Btu/dscf*	930
Nitrogen (N)	3.45	*F-Factor*	8654
Helium (He)	0.00	*Relative Density*	0.607
Argon (Ar)	0.00	*C2-C6+ Weight %*	11.4
Sulfur (S)	0.00	*MW lb/lb-mole*	17.6
Motor Octane Number	127	*Methane Number*	87.8
		Wobbe Number	1323

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 242147
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 09/09/2024
ANALYSIS DATE : 09/11/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-SEPT-A
AAC ID	242147-63856
Canister Dil. Fac.	2.12
Analyte	Result
Hydrogen Sulfide	**0.293**
COS / SO2	**0.257**
Methyl Mercaptan	**0.127**
Ethyl Mercaptan	< 0.106
Dimethyl Sulfide	< 0.106
Carbon Disulfide	< 0.106
Isopropyl Mercaptan	< 0.106
tert-Butyl Mercaptan	**0.614**
n-Propyl Mercaptan	< 0.106
Methylethylsulfide	< 0.106
sec-Butyl Mercaptan / Thiophene	< 0.106
iso-Butyl Mercaptan	< 0.106
Diethyl Sulfide	< 0.106
n-Butyl Mercaptan	< 0.106
Dimethyl Disulfide	< 0.106
2-Methylthiophene	< 0.106
3-Methylthiophene	< 0.106
Tetrahydrothiophene	**0.578**
Bromothiophene	< 0.106
Thiophenol	< 0.106
Diethyl Disulfide	< 0.106
Total Unidentified Sulfur	< 0.106
Total Reduced Sulfurs	**1.61**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Colusa Generating Station
PROJECT NO. : 242147
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 09/09/2024
ANALYSIS DATE : 09/11/2024

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-SEPT-A
AAC ID	242147-63856
Canister Dil. Fac.	2.12
Analyte	Result
Hydrogen Sulfide	**0.01785**
COS / SO2	**0.01566**
Methyl Mercaptan	**0.00776**
Ethyl Mercaptan	< 0.00647
Dimethyl Sulfide	< 0.00647
Carbon Disulfide	< 0.00647
Isopropyl Mercaptan	< 0.00647
tert-Butyl Mercaptan	**0.03739**
n-Propyl Mercaptan	< 0.00647
Methylethylsulfide	< 0.00647
sec-Butyl Mercaptan / Thiophene	< 0.00647
iso-Butyl Mercaptan	< 0.00647
Diethyl Sulfide	< 0.00647
n-Butyl Mercaptan	< 0.00647
Dimethyl Disulfide	< 0.00647
2-Methylthiophene	< 0.00647
3-Methylthiophene	< 0.00647
Tetrahydrothiophene	**0.03519**
Bromothiophene	< 0.00647
Thiophenol	< 0.00647
Diethyl Disulfide	< 0.00647
Total Unidentified Sulfur	< 0.00647
Total Reduced Sulfurs	**0.09820**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

Quality Control/Quality Assurance Report

Date Analyzed : 09/19/2024
Analyst : RSF
Units : %

Instrument ID : TCD #1
Calb Date : 09/26/23
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.5	10.0	22.3	10.6	9.8	10.3
	% Rec *	105.0	100.6	111.8	106.2	97.5	103.2

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	LCS Result	10.6	10.1	21.9	10.7	9.9	10.5
	LCSD Result	10.3	10.0	21.9	10.3	9.5	10.1
	LCS % Rec *	106.0	101.9	110.0	107.6	98.9	105.2
	LCSD % Rec *	102.2	100.6	109.8	103.6	95.4	101.2
	% RPD ***	3.6	1.3	0.2	3.8	3.6	3.9

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
242217-64185	Sample	0.0	14.1	77.3	0.0	0.0	4.6
	Sample Dup	0.0	14.2	77.7	0.0	0.0	4.6
	Mean	0.0	14.1	77.5	0.0	0.0	4.6
	% RPD ***	0.0	0.7	0.5	0.0	0.0	0.2

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
242217-64185	Sample Conc	0.0	38.7	0.0	0.0	2.3
	Spike Conc	10.0	10.0	10.0	10.0	10.0
	MS Result	10.8	49.3	10.7	9.9	12.7
	MSD Result	10.5	49.4	10.8	9.9	12.7
	MS % Rec **	107.3	106.2	108.0	99.3	104.4
	MSD % Rec **	104.4	107.5	108.1	99.4	104.4
	% RPD ***	2.7	1.1	0.1	0.1	0.0

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.4	10.0	21.5	10.7	9.9	10.4
	% Rec *	103.3	100.6	108.0	107.5	99.0	104.8

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report

Date Analyzed : 09/18/2024
Analyst : RSF
Units : ppmv

Instrument ID : FID #3
Calb Date : 11/28/23
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	94.5	93.1	97.7	98.1	102.4	102.0
	% Rec *	94.8	94.8	97.8	98.5	102.5	101.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	LCS Result	102.6	102.7	107.4	109.3	110.7	112.4
	LCSD Result	107.4	106.4	110.8	114.6	113.3	114.4
	LCS % Rec *	102.9	104.5	107.4	109.8	110.8	112.3
	LCSD % Rec *	107.7	108.3	110.8	115.1	113.4	114.4
	% RPD ***	4.6	3.6	3.1	4.7	2.3	1.8

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
231409-46862	Sample	1.1	0.0	0.0	0.0	0.0	0.0
	Sample Dup	1.0	0.0	0.0	0.0	0.0	0.0
	Mean	1.1	0.0	0.0	0.0	0.0	0.0
	% RPD ***	6.5	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
231409-46862	Sample Conc	0.5	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.8	49.1	50.0	49.8	49.9	50.0
	MS Result	54.4	52.7	55.4	56.7	57.7	57.1
	MSD Result	52.7	50.5	53.3	53.4	54.8	51.6
	MS % Rec **	108.1	107.2	110.8	113.9	115.6	114.2
	MSD % Rec **	104.7	102.8	106.7	107.3	109.8	103.2
	% RPD ***	3.2	4.3	3.8	6.0	5.1	10.1

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	98.2	100.0	99.6	99.9	100.1
	Result	98.9	97.4	102.1	104.1	110.8	110.6
	% Rec *	99.2	99.1	102.1	104.5	110.9	110.5

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 9/11/2024
Analyst: NR/DM
Units: ppmV

Instrument ID : SCD-BTU
Calb. Date: : 01/25/2024

Opening Calibration Verification Standard

0.511 ppbV H2S (GC-110223-01)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	10624	0.493	96.4	0.1
Duplicate	10661	0.494	96.7	0.3
Triplicate	10606	0.492	96.2	0.2

0.502 ppbV H2S (GC-110223-01)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	9264	0.500	99.6	0.9
Duplicate	9336	0.504	100.3	1.7
Triplicate	8944	0.483	96.1	2.6

0.497 ppbV H2S (GC-110223-01)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	12031	0.499	100.4	0.0
Duplicate	11829	0.491	98.8	1.7
Triplicate	12232	0.508	102.1	1.7

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID 240745-56259**

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.000	0.0
MeSH	<PQL	<PQL	0.000	0.0
DMS	<PQL	<PQL	0.000	0.0

Matrix Spike & Duplicate **Sample ID x2**

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	0.256	0.236	0.232	92.4	90.8	1.7
MeSH	<PQL	0.251	0.235	0.259	93.6	103.2	9.7
DMS	<PQL	0.249	0.257	0.259	103.4	104.2	0.8

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	0.511	0.475	93.0
MeSH	0.502	0.482	96.0
DMS	0.497	0.494	99.4

Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, * Must be < 5% RPD from Mean result.***

PQL = 50.0 ppbV
MDL = 1.1 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

242147

Fuel Gas Sampling

| | | |

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD:	AQ-13
Title V:	#8,9, 24, 26, 29

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 PPMVDC @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 PPMVDC @ 15%; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005. Therefore, this subpart applies to these gas turbines. The KKKK compliance summaries for the stationary natural gas turbines is summarized below and are based on the following applicable sections of the KKKK performance standards. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement
60.4305	CGS Turbines/HRSGs are rated at larger than 10 mmbtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.
60.4310	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.
60.4320	NOx emissions limit: 15 ppmv @15%O_2
60.4330	SO2 emissions limit: 0.90 lbs SO2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO2/MMBtu (heat input).
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. . (CGS QAP applies here)
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). . (CGS QAP applies here)
60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. . (CGS QAP applies here)
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.
60.4365	Exemption for fuel sulfur monitoring, if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lbs SO_2/MMBtu, Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395). In compliance.
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)
60.4400	Initial and annual NO_X performance tests not required if CEMS used

	per 60.4340(b)(1)
60.4405	If NO_x CEMS used, use 60.4405 (a-d) procedures in lieu of performance test.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments.

Section	Compliance
60.4305	KKKK is applicable to the facility. In compliance
60.4310	No exemptions apply.
60.4315	NO_x and SO_2 are in compliance with the KKKK emission standards and monitoring requirements.
60.4320	NO_x emissions limit: 9 ppmv @15%O_2 (See attached GE data sheet). In compliance.
60.4330	SO_2 emissions limit: CT1 172 MW 1.283 lb/hr (SO_2 source test date: 2010) CT2 172 MW 1.649 lb/hr (SO_2 source test date: 2010) CT1 - 1.283/172 = 0.0075 lb/MWh CT2 - 1.649/172 = 0.0096 lb/MWh In compliance with SO2 emission limits. The project will only use pipe quality natural gas with sulfur limits less than 0.06 lbs/MMBtu. See attached natural gas fuel analysis. In compliance with limits based on monthly fuel sampling.
60.4333	The facility will operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. In compliance.
60.4340(b)(1)	CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. In addition, Part 75 applies and NO_x is monitored per Appendix E of Part 75. See attached Quality Assurance Plan (attached). In compliance.
60.4345	In compliance. .
60.4350	In compliance
60.4355	In compliance
60.4360	In compliance through exemption per 60.4365.
60.4365	Requesting exemption (a) and (b) for sulfur monitoring. The fuel used is pipeline quality natural gas with an average grain loading less than 0.30 gr/100 SCF which converts to 0.0008 lb/MMBtu of SO_2. See fuel

	analysis Attachment 2. Annual compliance based on PG&E supplied fuel analysis data.
60.4375	No excess emissions during this reporting period. In compliance.
60.4380(b)	No excess emissions or monitor downtime, per (b) (1-3). In compliance.
60.4400	In compliance. NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC will be tested annually.
60.4405	In compliance. See QAP for CEMs certification.
60.4415	In compliance. Initial SO_2 source test results and QAP are available upon request. Future compliance under this requirement may be determined using one of three methods summarized in 60.4415.

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/01/2024 00:00	2	2
07/01/2024 01:00	2	2
07/01/2024 02:00	2	2
07/01/2024 03:00	2	2
07/01/2024 04:00	2	2
07/01/2024 05:00	2	2
07/01/2024 06:00	2	2
07/01/2024 07:00	2	2
07/01/2024 08:00	9	2
07/01/2024 09:00	11	2
07/01/2024 10:00	11	2
07/01/2024 11:00	11	2
07/01/2024 12:00	4	2
07/01/2024 13:00	1	14
07/01/2024 14:00	1	16
07/01/2024 15:00	1	16
07/01/2024 16:00	1	16
07/01/2024 17:00	1	4
07/01/2024 18:00	1	1
07/01/2024 19:00	1	1
07/01/2024 20:00	1	1
07/01/2024 21:00	1	1
07/01/2024 22:00	1	1
07/01/2024 23:00	2	2
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	11	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/02/2024 00:00	2	2
07/02/2024 01:00	2	2
07/02/2024 02:00	2	2
07/02/2024 03:00	2	2
07/02/2024 04:00	2	2
07/02/2024 05:00	2	2
07/02/2024 06:00	2	2
07/02/2024 07:00	2	2
07/02/2024 08:00	2	2
07/02/2024 09:00	2	2
07/02/2024 10:00	15	2
07/02/2024 11:00	21	2
07/02/2024 12:00	23	2
07/02/2024 13:00	22	2
07/02/2024 14:00	8	2
07/02/2024 15:00	3	11
07/02/2024 16:00	1	19
07/02/2024 17:00	1	19
07/02/2024 18:00	1	19
07/02/2024 19:00	1	9
07/02/2024 20:00	1	1
07/02/2024 21:00	1	1
07/02/2024 22:00	1	1
07/02/2024 23:00	1	1
Average/Sum#:	5	5
Minimum:	1	1
Maximum:	23	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/03/2024 00:00	1	1
07/03/2024 01:00	1	1
07/03/2024 02:00	1	1
07/03/2024 03:00	1	1
07/03/2024 04:00	1	1
07/03/2024 05:00	1	1
07/03/2024 06:00	1	1
07/03/2024 07:00	1	1
07/03/2024 08:00	1	1
07/03/2024 09:00	1	1
07/03/2024 10:00	1	1
07/03/2024 11:00	1	1
07/03/2024 12:00	1	1
07/03/2024 13:00	1	1
07/03/2024 14:00	1	1
07/03/2024 15:00	1	1
07/03/2024 16:00	1	1
07/03/2024 17:00	1	1
07/03/2024 18:00	1	1
07/03/2024 19:00	1	1
07/03/2024 20:00	1	1
07/03/2024 21:00	1	1
07/03/2024 22:00	1	1
07/03/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/04/2024 00:00	1	1
07/04/2024 01:00	1	1
07/04/2024 02:00	2	2
07/04/2024 03:00	2	2
07/04/2024 04:00	2	2
07/04/2024 05:00	2	2
07/04/2024 06:00	2	2
07/04/2024 07:00	2	2
07/04/2024 08:00	2	2
07/04/2024 09:00	7	2
07/04/2024 10:00	8	2
07/04/2024 11:00	8	2
07/04/2024 12:00	8	2
07/04/2024 13:00	2	13
07/04/2024 14:00	1	15
07/04/2024 15:00	1	15
07/04/2024 16:00	1	15
07/04/2024 17:00	1	4
07/04/2024 18:00	1	1
07/04/2024 19:00	1	1
07/04/2024 20:00	1	1
07/04/2024 21:00	1	1
07/04/2024 22:00	1	1
07/04/2024 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	8	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/05/2024 00:00	1	1
07/05/2024 01:00	1	1
07/05/2024 02:00	1	1
07/05/2024 03:00	1	1
07/05/2024 04:00	1	1
07/05/2024 05:00	1	1
07/05/2024 06:00	1	1
07/05/2024 07:00	1	1
07/05/2024 08:00	1	1
07/05/2024 09:00	1	1
07/05/2024 10:00	1	1
07/05/2024 11:00	1	1
07/05/2024 12:00	1	1
07/05/2024 13:00	1	1
07/05/2024 14:00	1	1
07/05/2024 15:00	1	1
07/05/2024 16:00	1	1
07/05/2024 17:00	1	1
07/05/2024 18:00	1	1
07/05/2024 19:00	1	1
07/05/2024 20:00	1	1
07/05/2024 21:00	1	1
07/05/2024 22:00	1	1
07/05/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/06/2024 00:00	1	1
07/06/2024 01:00	1	1
07/06/2024 02:00	1	1
07/06/2024 03:00	1	1
07/06/2024 04:00	1	1
07/06/2024 05:00	1	1
07/06/2024 06:00	1	1
07/06/2024 07:00	1	1
07/06/2024 08:00	1	1
07/06/2024 09:00	1	1
07/06/2024 10:00	2	1
07/06/2024 11:00	2	1
07/06/2024 12:00	2	1
07/06/2024 13:00	2	1
07/06/2024 14:00	1	4
07/06/2024 15:00	1	3
07/06/2024 16:00	1	3
07/06/2024 17:00	1	3
07/06/2024 18:00	1	1
07/06/2024 19:00	1	1
07/06/2024 20:00	1	1
07/06/2024 21:00	1	1
07/06/2024 22:00	1	1
07/06/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/07/2024 00:00	1	1
07/07/2024 01:00	1	1
07/07/2024 02:00	1	1
07/07/2024 03:00	2	1
07/07/2024 04:00	2	1
07/07/2024 05:00	2	1
07/07/2024 06:00	2	1
07/07/2024 07:00	2	1
07/07/2024 08:00	2	1
07/07/2024 09:00	2	1
07/07/2024 10:00	2	1
07/07/2024 11:00	2	1
07/07/2024 12:00	2	6
07/07/2024 13:00	2	6
07/07/2024 14:00	2	6
07/07/2024 15:00	9	6
07/07/2024 16:00	13	1
07/07/2024 17:00	12	1
07/07/2024 18:00	12	1
07/07/2024 19:00	5	1
07/07/2024 20:00	1	1
07/07/2024 21:00	1	1
07/07/2024 22:00	1	1
07/07/2024 23:00	1	1
Average/Sum#:	3	2
Minimum:	1	1
Maximum:	13	6
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/08/2024 00:00	1	1
07/08/2024 01:00	1	1
07/08/2024 02:00	1	1
07/08/2024 03:00	1	1
07/08/2024 04:00	1	1
07/08/2024 05:00	1	1
07/08/2024 06:00	1	1
07/08/2024 07:00	1	1
07/08/2024 08:00	1	1
07/08/2024 09:00	1	1
07/08/2024 10:00	1	1
07/08/2024 11:00	1	1
07/08/2024 12:00	1	1
07/08/2024 13:00	1	1
07/08/2024 14:00	1	1
07/08/2024 15:00	1	1
07/08/2024 16:00	1	1
07/08/2024 17:00	1	1
07/08/2024 18:00	1	1
07/08/2024 19:00	1	1
07/08/2024 20:00	1	1
07/08/2024 21:00	1	1
07/08/2024 22:00	1	1
07/08/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/09/2024 00:00	1	1
07/09/2024 01:00	1	1
07/09/2024 02:00	1	1
07/09/2024 03:00	1	1
07/09/2024 04:00	1	1
07/09/2024 05:00	1	1
07/09/2024 06:00	1	1
07/09/2024 07:00	1	1
07/09/2024 08:00	1	1
07/09/2024 09:00	1	0
07/09/2024 10:00	0	0
07/09/2024 11:00	0	0
07/09/2024 12:00	0	0
07/09/2024 13:00	0	0
07/09/2024 14:00	1	1
07/09/2024 15:00	1	1
07/09/2024 16:00	1	1
07/09/2024 17:00	1	1
07/09/2024 18:00	1	1
07/09/2024 19:00	1	1
07/09/2024 20:00	1	1
07/09/2024 21:00	1	1
07/09/2024 22:00	1	1
07/09/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	16.67	20.83

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/10/2024 00:00	1	1
07/10/2024 01:00	1	1
07/10/2024 02:00	1	1
07/10/2024 03:00	1	1
07/10/2024 04:00	1	1
07/10/2024 05:00	1	1
07/10/2024 06:00	1	1
07/10/2024 07:00	1	1
07/10/2024 08:00	1	1
07/10/2024 09:00	1	1
07/10/2024 10:00	1	1
07/10/2024 11:00	1	1
07/10/2024 12:00	1	1
07/10/2024 13:00	1	1
07/10/2024 14:00	1	1
07/10/2024 15:00	1	1
07/10/2024 16:00	1	1
07/10/2024 17:00	1	1
07/10/2024 18:00	1	1
07/10/2024 19:00	1	1
07/10/2024 20:00	1	1
07/10/2024 21:00	1	1
07/10/2024 22:00	1	1
07/10/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/11/2024 00:00	1	1
07/11/2024 01:00	1	1
07/11/2024 02:00	1	1
07/11/2024 03:00	1	1
07/11/2024 04:00	1	1
07/11/2024 05:00	1	1
07/11/2024 06:00	1	1
07/11/2024 07:00	1	1
07/11/2024 08:00	1	1
07/11/2024 09:00	1	1
07/11/2024 10:00	1	1
07/11/2024 11:00	1	1
07/11/2024 12:00	1	1
07/11/2024 13:00	1	1
07/11/2024 14:00	1	1
07/11/2024 15:00	1	1
07/11/2024 16:00	1	1
07/11/2024 17:00	1	1
07/11/2024 18:00	1	1
07/11/2024 19:00	1	1
07/11/2024 20:00	1	1
07/11/2024 21:00	1	1
07/11/2024 22:00	1	1
07/11/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/12/2024 00:00	1	1
07/12/2024 01:00	1	1
07/12/2024 02:00	1	1
07/12/2024 03:00	1	1
07/12/2024 04:00	1	1
07/12/2024 05:00	1	1
07/12/2024 06:00	1	1
07/12/2024 07:00	1	1
07/12/2024 08:00	1	1
07/12/2024 09:00	1	1
07/12/2024 10:00	1	1
07/12/2024 11:00	1	1
07/12/2024 12:00	1	1
07/12/2024 13:00	1	1
07/12/2024 14:00	1	1
07/12/2024 15:00	1	1
07/12/2024 16:00	1	1
07/12/2024 17:00	1	1
07/12/2024 18:00	1	1
07/12/2024 19:00	1	1
07/12/2024 20:00	1	1
07/12/2024 21:00	1	1
07/12/2024 22:00	1	1
07/12/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/13/2024 00:00	1	1
07/13/2024 01:00	1	1
07/13/2024 02:00	1	1
07/13/2024 03:00	1	1
07/13/2024 04:00	1	1
07/13/2024 05:00	1	1
07/13/2024 06:00	1	1
07/13/2024 07:00	1	1
07/13/2024 08:00	1	1
07/13/2024 09:00	1	1
07/13/2024 10:00	1	1
07/13/2024 11:00	1	1
07/13/2024 12:00	1	1
07/13/2024 13:00	1	1
07/13/2024 14:00	1	1
07/13/2024 15:00	1	1
07/13/2024 16:00	1	1
07/13/2024 17:00	1	1
07/13/2024 18:00	1	1
07/13/2024 19:00	1	1
07/13/2024 20:00	1	1
07/13/2024 21:00	1	1
07/13/2024 22:00	1	1
07/13/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/14/2024 00:00	1	1
07/14/2024 01:00	1	1
07/14/2024 02:00	1	1
07/14/2024 03:00	1	1
07/14/2024 04:00	1	1
07/14/2024 05:00	1	1
07/14/2024 06:00	1	1
07/14/2024 07:00	1	1
07/14/2024 08:00	1	1
07/14/2024 09:00	1	1
07/14/2024 10:00	9	1
07/14/2024 11:00	12	1
07/14/2024 12:00	12	1
07/14/2024 13:00	12	1
07/14/2024 14:00	4	12
07/14/2024 15:00	1	14
07/14/2024 16:00	1	14
07/14/2024 17:00	1	14
07/14/2024 18:00	1	3
07/14/2024 19:00	1	1
07/14/2024 20:00	1	1
07/14/2024 21:00	1	1
07/14/2024 22:00	1	1
07/14/2024 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	12	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/15/2024 00:00	1	1
07/15/2024 01:00	1	1
07/15/2024 02:00	1	1
07/15/2024 03:00	1	1
07/15/2024 04:00	1	1
07/15/2024 05:00	1	1
07/15/2024 06:00	1	1
07/15/2024 07:00	1	1
07/15/2024 08:00	1	1
07/15/2024 09:00	1	1
07/15/2024 10:00	1	1
07/15/2024 11:00	1	1
07/15/2024 12:00	1	1
07/15/2024 13:00	1	1
07/15/2024 14:00	1	1
07/15/2024 15:00	1	1
07/15/2024 16:00	1	1
07/15/2024 17:00	1	1
07/15/2024 18:00	1	1
07/15/2024 19:00	1	1
07/15/2024 20:00	1	1
07/15/2024 21:00	1	1
07/15/2024 22:00	1	1
07/15/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/16/2024 00:00	1	1
07/16/2024 01:00	1	1
07/16/2024 02:00	1	1
07/16/2024 03:00	1	1
07/16/2024 04:00	1	1
07/16/2024 05:00	1	1
07/16/2024 06:00	1	1
07/16/2024 07:00	1	1
07/16/2024 08:00	1	1
07/16/2024 09:00	1	1
07/16/2024 10:00	1	1
07/16/2024 11:00	1	1
07/16/2024 12:00	1	1
07/16/2024 13:00	1	1
07/16/2024 14:00	1	1
07/16/2024 15:00	1	1
07/16/2024 16:00	1	1
07/16/2024 17:00	1	1
07/16/2024 18:00	1	1
07/16/2024 19:00	1	1
07/16/2024 20:00	1	1
07/16/2024 21:00	1	1
07/16/2024 22:00	1	1
07/16/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/17/2024 00:00	1	1
07/17/2024 01:00	1	1
07/17/2024 02:00	1	1
07/17/2024 03:00	1	1
07/17/2024 04:00	1	1
07/17/2024 05:00	1	1
07/17/2024 06:00	1	1
07/17/2024 07:00	1	1
07/17/2024 08:00	1	1
07/17/2024 09:00	1	1
07/17/2024 10:00	1	1
07/17/2024 11:00	1	1
07/17/2024 12:00	1	1
07/17/2024 13:00	1	1
07/17/2024 14:00	1	1
07/17/2024 15:00	1	1
07/17/2024 16:00	1	1
07/17/2024 17:00	1	1
07/17/2024 18:00	1	1
07/17/2024 19:00	1	1
07/17/2024 20:00	1	1
07/17/2024 21:00	1	1
07/17/2024 22:00	1	1
07/17/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/18/2024 00:00	1	1
07/18/2024 01:00	1	1
07/18/2024 02:00	1	1
07/18/2024 03:00	1	1
07/18/2024 04:00	1	1
07/18/2024 05:00	1	1
07/18/2024 06:00	1	1
07/18/2024 07:00	1	1
07/18/2024 08:00	1	1
07/18/2024 09:00	1	1
07/18/2024 10:00	1	1
07/18/2024 11:00	1	1
07/18/2024 12:00	1	1
07/18/2024 13:00	1	1
07/18/2024 14:00	1	1
07/18/2024 15:00	1	1
07/18/2024 16:00	1	1
07/18/2024 17:00	1	1
07/18/2024 18:00	1	1
07/18/2024 19:00	1	1
07/18/2024 20:00	1	1
07/18/2024 21:00	1	1
07/18/2024 22:00	1	1
07/18/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/19/2024 00:00	1	1
07/19/2024 01:00	1	1
07/19/2024 02:00	1	1
07/19/2024 03:00	1	1
07/19/2024 04:00	1	1
07/19/2024 05:00	1	1
07/19/2024 06:00	1	1
07/19/2024 07:00	1	1
07/19/2024 08:00	1	1
07/19/2024 09:00	1	1
07/19/2024 10:00	1	1
07/19/2024 11:00	1	1
07/19/2024 12:00	1	1
07/19/2024 13:00	1	1
07/19/2024 14:00	1	1
07/19/2024 15:00	1	1
07/19/2024 16:00	1	1
07/19/2024 17:00	1	1
07/19/2024 18:00	1	1
07/19/2024 19:00	1	1
07/19/2024 20:00	1	1
07/19/2024 21:00	1	1
07/19/2024 22:00	1	1
07/19/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/20/2024 00:00	1	1
07/20/2024 01:00	1	1
07/20/2024 02:00	1	1
07/20/2024 03:00	1	1
07/20/2024 04:00	1	1
07/20/2024 05:00	1	1
07/20/2024 06:00	1	1
07/20/2024 07:00	1	1
07/20/2024 08:00	1	1
07/20/2024 09:00	1	1
07/20/2024 10:00	1	1
07/20/2024 11:00	1	1
07/20/2024 12:00	1	1
07/20/2024 13:00	1	1
07/20/2024 14:00	1	1
07/20/2024 15:00	1	1
07/20/2024 16:00	1	1
07/20/2024 17:00	1	1
07/20/2024 18:00	1	1
07/20/2024 19:00	1	1
07/20/2024 20:00	1	1
07/20/2024 21:00	1	1
07/20/2024 22:00	1	1
07/20/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/21/2024 00:00	1	1
07/21/2024 01:00	1	1
07/21/2024 02:00	1	1
07/21/2024 03:00	1	1
07/21/2024 04:00	1	1
07/21/2024 05:00	1	1
07/21/2024 06:00	1	1
07/21/2024 07:00	1	1
07/21/2024 08:00	1	1
07/21/2024 09:00	1	1
07/21/2024 10:00	2	1
07/21/2024 11:00	3	1
07/21/2024 12:00	3	1
07/21/2024 13:00	3	1
07/21/2024 14:00	3	1
07/21/2024 15:00	1	1
07/21/2024 16:00	1	1
07/21/2024 17:00	1	1
07/21/2024 18:00	1	1
07/21/2024 19:00	1	1
07/21/2024 20:00	1	1
07/21/2024 21:00	1	1
07/21/2024 22:00	1	1
07/21/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	3	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/22/2024 00:00	1	1
07/22/2024 01:00	1	1
07/22/2024 02:00	1	1
07/22/2024 03:00	1	10
07/22/2024 04:00	1	11
07/22/2024 05:00	1	11
07/22/2024 06:00	1	11
07/22/2024 07:00	1	2
07/22/2024 08:00	1	1
07/22/2024 09:00	1	1
07/22/2024 10:00	1	1
07/22/2024 11:00	1	1
07/22/2024 12:00	1	1
07/22/2024 13:00	1	1
07/22/2024 14:00	1	1
07/22/2024 15:00	1	1
07/22/2024 16:00	1	1
07/22/2024 17:00	1	1
07/22/2024 18:00	1	1
07/22/2024 19:00	1	1
07/22/2024 20:00	1	1
07/22/2024 21:00	1	1
07/22/2024 22:00	1	1
07/22/2024 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/23/2024 00:00	1	1
07/23/2024 01:00	1	1
07/23/2024 02:00	1	1
07/23/2024 03:00	1	1
07/23/2024 04:00	1	1
07/23/2024 05:00	1	1
07/23/2024 06:00	1	1
07/23/2024 07:00	1	1
07/23/2024 08:00	1	1
07/23/2024 09:00	1	1
07/23/2024 10:00	1	1
07/23/2024 11:00	1	1
07/23/2024 12:00	1	1
07/23/2024 13:00	1	1
07/23/2024 14:00	1	1
07/23/2024 15:00	1	1
07/23/2024 16:00	1	1
07/23/2024 17:00	1	1
07/23/2024 18:00	1	1
07/23/2024 19:00	1	1
07/23/2024 20:00	1	1
07/23/2024 21:00	1	1
07/23/2024 22:00	1	1
07/23/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/24/2024 00:00	1	1
07/24/2024 01:00	1	1
07/24/2024 02:00	1	1
07/24/2024 03:00	1	1
07/24/2024 04:00	1	1
07/24/2024 05:00	1	1
07/24/2024 06:00	1	1
07/24/2024 07:00	1	1
07/24/2024 08:00	1	1
07/24/2024 09:00	1	1
07/24/2024 10:00	1	1
07/24/2024 11:00	1	1
07/24/2024 12:00	1	1
07/24/2024 13:00	1	1
07/24/2024 14:00	1	1
07/24/2024 15:00	1	1
07/24/2024 16:00	1	1
07/24/2024 17:00	1	1
07/24/2024 18:00	1	1
07/24/2024 19:00	1	1
07/24/2024 20:00	1	1
07/24/2024 21:00	1	1
07/24/2024 22:00	1	1
07/24/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/25/2024 00:00	1	1
07/25/2024 01:00	1	1
07/25/2024 02:00	1	1
07/25/2024 03:00	1	1
07/25/2024 04:00	1	1
07/25/2024 05:00	1	1
07/25/2024 06:00	1	1
07/25/2024 07:00	1	1
07/25/2024 08:00	1	1
07/25/2024 09:00	1	1
07/25/2024 10:00	1	1
07/25/2024 11:00	1	1
07/25/2024 12:00	1	1
07/25/2024 13:00	1	1
07/25/2024 14:00	1	1
07/25/2024 15:00	1	1
07/25/2024 16:00	1	1
07/25/2024 17:00	1	1
07/25/2024 18:00	1	1
07/25/2024 19:00	1	1
07/25/2024 20:00	1	1
07/25/2024 21:00	1	1
07/25/2024 22:00	1	1
07/25/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/26/2024 00:00	1	1
07/26/2024 01:00	1	1
07/26/2024 02:00	1	1
07/26/2024 03:00	1	1
07/26/2024 04:00	1	1
07/26/2024 05:00	1	1
07/26/2024 06:00	1	1
07/26/2024 07:00	1	1
07/26/2024 08:00	1	1
07/26/2024 09:00	1	1
07/26/2024 10:00	1	1
07/26/2024 11:00	1	1
07/26/2024 12:00	1	1
07/26/2024 13:00	1	1
07/26/2024 14:00	1	1
07/26/2024 15:00	1	1
07/26/2024 16:00	1	1
07/26/2024 17:00	1	1
07/26/2024 18:00	1	1
07/26/2024 19:00	1	1
07/26/2024 20:00	1	1
07/26/2024 21:00	1	1
07/26/2024 22:00	1	1
07/26/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/27/2024 00:00	1	1
07/27/2024 01:00	1	1
07/27/2024 02:00	1	1
07/27/2024 03:00	1	1
07/27/2024 04:00	1	1
07/27/2024 05:00	1	1
07/27/2024 06:00	2	1
07/27/2024 07:00	2	1
07/27/2024 08:00	2	1
07/27/2024 09:00	2	1
07/27/2024 10:00	2	1
07/27/2024 11:00	2	1
07/27/2024 12:00	3	1
07/27/2024 13:00	3	1
07/27/2024 14:00	3	1
07/27/2024 15:00	3	15
07/27/2024 16:00	1	19
07/27/2024 17:00	1	19
07/27/2024 18:00	1	14
07/27/2024 19:00	1	4
07/27/2024 20:00	1	1
07/27/2024 21:00	1	1
07/27/2024 22:00	1	1
07/27/2024 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	3	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/28/2024 00:00	1	1
07/28/2024 01:00	1	1
07/28/2024 02:00	1	1
07/28/2024 03:00	1	1
07/28/2024 04:00	1	1
07/28/2024 05:00	1	1
07/28/2024 06:00	1	1
07/28/2024 07:00	2	4
07/28/2024 08:00	2	4
07/28/2024 09:00	2	4
07/28/2024 10:00	2	4
07/28/2024 11:00	2	4
07/28/2024 12:00	2	4
07/28/2024 13:00	2	4
07/28/2024 14:00	2	10
07/28/2024 15:00	2	12
07/28/2024 16:00	2	12
07/28/2024 17:00	2	9
07/28/2024 18:00	2	3
07/28/2024 19:00	2	1
07/28/2024 20:00	2	1
07/28/2024 21:00	2	1
07/28/2024 22:00	2	1
07/28/2024 23:00	2	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	2	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/29/2024 00:00	2	1
07/29/2024 01:00	2	1
07/29/2024 02:00	2	1
07/29/2024 03:00	2	1
07/29/2024 04:00	2	1
07/29/2024 05:00	2	1
07/29/2024 06:00	2	1
07/29/2024 07:00	2	1
07/29/2024 08:00	2	1
07/29/2024 09:00	2	1
07/29/2024 10:00	15	1
07/29/2024 11:00	18	1
07/29/2024 12:00	19	1
07/29/2024 13:00	18	1
07/29/2024 14:00	6	1
07/29/2024 15:00	3	9
07/29/2024 16:00	1	10
07/29/2024 17:00	1	10
07/29/2024 18:00	1	10
07/29/2024 19:00	1	2
07/29/2024 20:00	1	1
07/29/2024 21:00	1	1
07/29/2024 22:00	1	1
07/29/2024 23:00	2	1
Average/Sum#:	5	3
Minimum:	1	1
Maximum:	19	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/30/2024 00:00	2	1
07/30/2024 01:00	2	1
07/30/2024 02:00	2	1
07/30/2024 03:00	2	1
07/30/2024 04:00	2	1
07/30/2024 05:00	2	1
07/30/2024 06:00	2	1
07/30/2024 07:00	2	1
07/30/2024 08:00	2	1
07/30/2024 09:00	2	1
07/30/2024 10:00	12	1
07/30/2024 11:00	15	1
07/30/2024 12:00	18	1
07/30/2024 13:00	16	1
07/30/2024 14:00	6	1
07/30/2024 15:00	4	11
07/30/2024 16:00	1	13
07/30/2024 17:00	1	13
07/30/2024 18:00	1	12
07/30/2024 19:00	1	3
07/30/2024 20:00	1	1
07/30/2024 21:00	1	1
07/30/2024 22:00	1	1
07/30/2024 23:00	1	1
Average/Sum#:	4	3
Minimum:	1	1
Maximum:	18	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/31/2024 00:00	1	1
07/31/2024 01:00	1	1
07/31/2024 02:00	1	1
07/31/2024 03:00	1	1
07/31/2024 04:00	1	1
07/31/2024 05:00	1	1
07/31/2024 06:00	1	1
07/31/2024 07:00	1	1
07/31/2024 08:00	1	1
07/31/2024 09:00	1	1
07/31/2024 10:00	1	1
07/31/2024 11:00	1	1
07/31/2024 12:00	1	1
07/31/2024 13:00	1	1
07/31/2024 14:00	1	1
07/31/2024 15:00	1	1
07/31/2024 16:00	1	1
07/31/2024 17:00	1	1
07/31/2024 18:00	1	1
07/31/2024 19:00	1	1
07/31/2024 20:00	1	1
07/31/2024 21:00	1	1
07/31/2024 22:00	1	1
07/31/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/01/2024 00:00	1	1
08/01/2024 01:00	1	1
08/01/2024 02:00	1	1
08/01/2024 03:00	1	1
08/01/2024 04:00	1	1
08/01/2024 05:00	1	1
08/01/2024 06:00	1	1
08/01/2024 07:00	1	1
08/01/2024 08:00	1	1
08/01/2024 09:00	1	1
08/01/2024 10:00	1	1
08/01/2024 11:00	1	1
08/01/2024 12:00	1	1
08/01/2024 13:00	1	1
08/01/2024 14:00	1	1
08/01/2024 15:00	1	1
08/01/2024 16:00	1	1
08/01/2024 17:00	1	1
08/01/2024 18:00	1	1
08/01/2024 19:00	1	1
08/01/2024 20:00	1	1
08/01/2024 21:00	1	1
08/01/2024 22:00	1	1
08/01/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/02/2024 00:00	1	1
08/02/2024 01:00	1	1
08/02/2024 02:00	1	1
08/02/2024 03:00	1	1
08/02/2024 04:00	1	1
08/02/2024 05:00	1	1
08/02/2024 06:00	1	1
08/02/2024 07:00	1	1
08/02/2024 08:00	1	1
08/02/2024 09:00	1	1
08/02/2024 10:00	1	1
08/02/2024 11:00	1	1
08/02/2024 12:00	1	1
08/02/2024 13:00	1	1
08/02/2024 14:00	1	1
08/02/2024 15:00	1	1
08/02/2024 16:00	1	1
08/02/2024 17:00	1	1
08/02/2024 18:00	1	1
08/02/2024 19:00	1	1
08/02/2024 20:00	1	1
08/02/2024 21:00	1	1
08/02/2024 22:00	1	1
08/02/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/03/2024 00:00	1	1
08/03/2024 01:00	1	1
08/03/2024 02:00	1	1
08/03/2024 03:00	1	1
08/03/2024 04:00	1	1
08/03/2024 05:00	1	1
08/03/2024 06:00	1	1
08/03/2024 07:00	1	1
08/03/2024 08:00	1	1
08/03/2024 09:00	1	1
08/03/2024 10:00	1	1
08/03/2024 11:00	1	1
08/03/2024 12:00	1	1
08/03/2024 13:00	1	1
08/03/2024 14:00	1	1
08/03/2024 15:00	1	1
08/03/2024 16:00	1	1
08/03/2024 17:00	1	1
08/03/2024 18:00	1	1
08/03/2024 19:00	1	1
08/03/2024 20:00	1	1
08/03/2024 21:00	1	1
08/03/2024 22:00	1	1
08/03/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/04/2024 00:00	1	1
08/04/2024 01:00	1	1
08/04/2024 02:00	1	1
08/04/2024 03:00	1	1
08/04/2024 04:00	1	1
08/04/2024 05:00	1	1
08/04/2024 06:00	1	1
08/04/2024 07:00	1	1
08/04/2024 08:00	1	1
08/04/2024 09:00	1	1
08/04/2024 10:00	1	1
08/04/2024 11:00	1	1
08/04/2024 12:00	1	1
08/04/2024 13:00	1	1
08/04/2024 14:00	1	1
08/04/2024 15:00	1	1
08/04/2024 16:00	1	1
08/04/2024 17:00	1	1
08/04/2024 18:00	1	1
08/04/2024 19:00	1	1
08/04/2024 20:00	1	1
08/04/2024 21:00	1	1
08/04/2024 22:00	1	1
08/04/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/05/2024 00:00	1	1
08/05/2024 01:00	1	1
08/05/2024 02:00	1	1
08/05/2024 03:00	1	1
08/05/2024 04:00	1	1
08/05/2024 05:00	1	1
08/05/2024 06:00	1	1
08/05/2024 07:00	1	1
08/05/2024 08:00	1	1
08/05/2024 09:00	1	1
08/05/2024 10:00	1	1
08/05/2024 11:00	1	1
08/05/2024 12:00	1	1
08/05/2024 13:00	1	1
08/05/2024 14:00	1	1
08/05/2024 15:00	1	1
08/05/2024 16:00	1	1
08/05/2024 17:00	1	1
08/05/2024 18:00	1	1
08/05/2024 19:00	1	1
08/05/2024 20:00	1	1
08/05/2024 21:00	1	1
08/05/2024 22:00	1	1
08/05/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/06/2024 00:00	1	1
08/06/2024 01:00	1	1
08/06/2024 02:00	1	1
08/06/2024 03:00	1	1
08/06/2024 04:00	1	1
08/06/2024 05:00	1	1
08/06/2024 06:00	1	1
08/06/2024 07:00	1	1
08/06/2024 08:00	1	1
08/06/2024 09:00	1	1
08/06/2024 10:00	1	1
08/06/2024 11:00	1	1
08/06/2024 12:00	1	1
08/06/2024 13:00	1	1
08/06/2024 14:00	1	1
08/06/2024 15:00	1	1
08/06/2024 16:00	1	1
08/06/2024 17:00	1	1
08/06/2024 18:00	1	1
08/06/2024 19:00	1	1
08/06/2024 20:00	1	1
08/06/2024 21:00	1	1
08/06/2024 22:00	1	1
08/06/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/07/2024 00:00	1	1
08/07/2024 01:00	1	1
08/07/2024 02:00	1	1
08/07/2024 03:00	1	1
08/07/2024 04:00	1	1
08/07/2024 05:00	1	1
08/07/2024 06:00	1	1
08/07/2024 07:00	1	1
08/07/2024 08:00	1	1
08/07/2024 09:00	1	1
08/07/2024 10:00	1	1
08/07/2024 11:00	1	1
08/07/2024 12:00	1	1
08/07/2024 13:00	1	1
08/07/2024 14:00	1	1
08/07/2024 15:00	1	1
08/07/2024 16:00	1	1
08/07/2024 17:00	1	1
08/07/2024 18:00	1	1
08/07/2024 19:00	1	1
08/07/2024 20:00	1	1
08/07/2024 21:00	1	1
08/07/2024 22:00	1	1
08/07/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/08/2024 00:00	1	1
08/08/2024 01:00	1	1
08/08/2024 02:00	1	1
08/08/2024 03:00	1	1
08/08/2024 04:00	1	1
08/08/2024 05:00	1	1
08/08/2024 06:00	1	1
08/08/2024 07:00	1	1
08/08/2024 08:00	1	1
08/08/2024 09:00	1	1
08/08/2024 10:00	1	1
08/08/2024 11:00	1	1
08/08/2024 12:00	1	1
08/08/2024 13:00	1	1
08/08/2024 14:00	1	1
08/08/2024 15:00	1	1
08/08/2024 16:00	1	1
08/08/2024 17:00	1	1
08/08/2024 18:00	1	1
08/08/2024 19:00	1	1
08/08/2024 20:00	1	1
08/08/2024 21:00	1	1
08/08/2024 22:00	1	1
08/08/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/09/2024 00:00	1	1
08/09/2024 01:00	1	1
08/09/2024 02:00	1	1
08/09/2024 03:00	1	1
08/09/2024 04:00	1	1
08/09/2024 05:00	1	1
08/09/2024 06:00	1	1
08/09/2024 07:00	1	1
08/09/2024 08:00	1	1
08/09/2024 09:00	1	1
08/09/2024 10:00	1	1
08/09/2024 11:00	1	1
08/09/2024 12:00	1	1
08/09/2024 13:00	1	1
08/09/2024 14:00	1	1
08/09/2024 15:00	1	1
08/09/2024 16:00	1	1
08/09/2024 17:00	1	1
08/09/2024 18:00	1	1
08/09/2024 19:00	1	1
08/09/2024 20:00	1	1
08/09/2024 21:00	1	2
08/09/2024 22:00	1	2
08/09/2024 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/10/2024 00:00	1	2
08/10/2024 01:00	1	2
08/10/2024 02:00	1	2
08/10/2024 03:00	1	2
08/10/2024 04:00	1	2
08/10/2024 05:00	1	2
08/10/2024 06:00	1	2
08/10/2024 07:00	1	2
08/10/2024 08:00	1	2
08/10/2024 09:00	1	2
08/10/2024 10:00	1	2
08/10/2024 11:00	1	2
08/10/2024 12:00	1	2
08/10/2024 13:00	1	13
08/10/2024 14:00	1	17
08/10/2024 15:00	1	19
08/10/2024 16:00	1	18
08/10/2024 17:00	1	7
08/10/2024 18:00	1	3
08/10/2024 19:00	1	1
08/10/2024 20:00	1	1
08/10/2024 21:00	1	1
08/10/2024 22:00	1	1
08/10/2024 23:00	1	1
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/11/2024 00:00	1	1
08/11/2024 01:00	1	1
08/11/2024 02:00	1	1
08/11/2024 03:00	1	1
08/11/2024 04:00	1	1
08/11/2024 05:00	1	1
08/11/2024 06:00	1	1
08/11/2024 07:00	1	1
08/11/2024 08:00	1	1
08/11/2024 09:00	1	1
08/11/2024 10:00	1	1
08/11/2024 11:00	1	1
08/11/2024 12:00	1	1
08/11/2024 13:00	1	1
08/11/2024 14:00	1	1
08/11/2024 15:00	1	1
08/11/2024 16:00	1	1
08/11/2024 17:00	1	1
08/11/2024 18:00	1	1
08/11/2024 19:00	1	1
08/11/2024 20:00	1	1
08/11/2024 21:00	1	1
08/11/2024 22:00	1	1
08/11/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/12/2024 00:00	1	1
08/12/2024 01:00	1	1
08/12/2024 02:00	1	1
08/12/2024 03:00	1	1
08/12/2024 04:00	1	1
08/12/2024 05:00	1	1
08/12/2024 06:00	1	1
08/12/2024 07:00	1	1
08/12/2024 08:00	1	1
08/12/2024 09:00	1	1
08/12/2024 10:00	1	1
08/12/2024 11:00	1	1
08/12/2024 12:00	1	1
08/12/2024 13:00	14	1
08/12/2024 14:00	19	1
08/12/2024 15:00	20	1
08/12/2024 16:00	19	1
08/12/2024 17:00	7	1
08/12/2024 18:00	2	11
08/12/2024 19:00	1	17
08/12/2024 20:00	1	17
08/12/2024 21:00	1	17
08/12/2024 22:00	1	7
08/12/2024 23:00	1	2
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	20	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/13/2024 00:00	1	1
08/13/2024 01:00	1	1
08/13/2024 02:00	2	2
08/13/2024 03:00	2	2
08/13/2024 04:00	2	2
08/13/2024 05:00	2	2
08/13/2024 06:00	2	2
08/13/2024 07:00	2	2
08/13/2024 08:00	2	2
08/13/2024 09:00	2	2
08/13/2024 10:00	2	2
08/13/2024 11:00	2	2
08/13/2024 12:00	2	2
08/13/2024 13:00	2	2
08/13/2024 14:00	2	2
08/13/2024 15:00	2	2
08/13/2024 16:00	2	14
08/13/2024 17:00	2	17
08/13/2024 18:00	2	20
08/13/2024 19:00	2	19
08/13/2024 20:00	2	6
08/13/2024 21:00	2	3
08/13/2024 22:00	2	1
08/13/2024 23:00	2	1
Average/Sum#:	2	5
Minimum:	1	1
Maximum:	2	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/14/2024 00:00	2	1
08/14/2024 01:00	2	1
08/14/2024 02:00	2	1
08/14/2024 03:00	2	1
08/14/2024 04:00	2	1
08/14/2024 05:00	2	1
08/14/2024 06:00	2	1
08/14/2024 07:00	2	1
08/14/2024 08:00	2	1
08/14/2024 09:00	2	1
08/14/2024 10:00	2	14
08/14/2024 11:00	2	18
08/14/2024 12:00	2	18
08/14/2024 13:00	2	18
08/14/2024 14:00	2	5
08/14/2024 15:00	2	1
08/14/2024 16:00	2	1
08/14/2024 17:00	2	1
08/14/2024 18:00	2	1
08/14/2024 19:00	2	1
08/14/2024 20:00	2	1
08/14/2024 21:00	2	1
08/14/2024 22:00	2	1
08/14/2024 23:00	2	1
Average/Sum#:	2	4
Minimum:	2	1
Maximum:	2	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/15/2024 00:00	2	1
08/15/2024 01:00	2	1
08/15/2024 02:00	2	1
08/15/2024 03:00	2	1
08/15/2024 04:00	2	1
08/15/2024 05:00	2	1
08/15/2024 06:00	2	1
08/15/2024 07:00	2	1
08/15/2024 08:00	2	1
08/15/2024 09:00	2	1
08/15/2024 10:00	2	1
08/15/2024 11:00	2	1
08/15/2024 12:00	2	12
08/15/2024 13:00	2	15
08/15/2024 14:00	2	18
08/15/2024 15:00	2	18
08/15/2024 16:00	2	7
08/15/2024 17:00	15	4
08/15/2024 18:00	16	1
08/15/2024 19:00	16	1
08/15/2024 20:00	15	1
08/15/2024 21:00	2	1
08/15/2024 22:00	1	1
08/15/2024 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	16	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/16/2024 00:00	1	1
08/16/2024 01:00	1	1
08/16/2024 02:00	1	1
08/16/2024 03:00	1	1
08/16/2024 04:00	1	1
08/16/2024 05:00	1	1
08/16/2024 06:00	1	1
08/16/2024 07:00	1	1
08/16/2024 08:00	2	1
08/16/2024 09:00	5	1
08/16/2024 10:00	5	1
08/16/2024 11:00	4	1
08/16/2024 12:00	4	7
08/16/2024 13:00	1	9
08/16/2024 14:00	1	9
08/16/2024 15:00	1	9
08/16/2024 16:00	1	3
08/16/2024 17:00	1	1
08/16/2024 18:00	1	1
08/16/2024 19:00	1	1
08/16/2024 20:00	1	1
08/16/2024 21:00	1	1
08/16/2024 22:00	1	1
08/16/2024 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	5	9
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/17/2024 00:00	1	1
08/17/2024 01:00	1	1
08/17/2024 02:00	1	1
08/17/2024 03:00	1	1
08/17/2024 04:00	1	1
08/17/2024 05:00	1	1
08/17/2024 06:00	1	1
08/17/2024 07:00	1	1
08/17/2024 08:00	1	1
08/17/2024 09:00	1	1
08/17/2024 10:00	1	1
08/17/2024 11:00	1	1
08/17/2024 12:00	1	1
08/17/2024 13:00	1	1
08/17/2024 14:00	1	5
08/17/2024 15:00	1	13
08/17/2024 16:00	1	13
08/17/2024 17:00	1	10
08/17/2024 18:00	1	7
08/17/2024 19:00	1	1
08/17/2024 20:00	1	1
08/17/2024 21:00	1	1
08/17/2024 22:00	1	1
08/17/2024 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/18/2024 00:00	1	1
08/18/2024 01:00	1	1
08/18/2024 02:00	1	1
08/18/2024 03:00	1	1
08/18/2024 04:00	1	1
08/18/2024 05:00	1	1
08/18/2024 06:00	1	1
08/18/2024 07:00	1	1
08/18/2024 08:00	1	1
08/18/2024 09:00	12	1
08/18/2024 10:00	15	1
08/18/2024 11:00	17	1
08/18/2024 12:00	17	1
08/18/2024 13:00	6	1
08/18/2024 14:00	4	13
08/18/2024 15:00	1	16
08/18/2024 16:00	1	16
08/18/2024 17:00	1	16
08/18/2024 18:00	1	4
08/18/2024 19:00	1	1
08/18/2024 20:00	1	1
08/18/2024 21:00	1	1
08/18/2024 22:00	1	1
08/18/2024 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	17	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/19/2024 00:00	2	2
08/19/2024 01:00	2	2
08/19/2024 02:00	2	2
08/19/2024 03:00	2	2
08/19/2024 04:00	2	2
08/19/2024 05:00	2	2
08/19/2024 06:00	2	2
08/19/2024 07:00	2	8
08/19/2024 08:00	2	8
08/19/2024 09:00	2	8
08/19/2024 10:00	2	7
08/19/2024 11:00	2	1
08/19/2024 12:00	11	1
08/19/2024 13:00	13	1
08/19/2024 14:00	14	1
08/19/2024 15:00	13	1
08/19/2024 16:00	4	1
08/19/2024 17:00	1	1
08/19/2024 18:00	1	1
08/19/2024 19:00	1	1
08/19/2024 20:00	1	1
08/19/2024 21:00	1	1
08/19/2024 22:00	1	1
08/19/2024 23:00	1	1
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	14	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/20/2024 00:00	1	1
08/20/2024 01:00	2	2
08/20/2024 02:00	2	2
08/20/2024 03:00	2	2
08/20/2024 04:00	2	2
08/20/2024 05:00	2	2
08/20/2024 06:00	2	2
08/20/2024 07:00	2	2
08/20/2024 08:00	2	2
08/20/2024 09:00	9	2
08/20/2024 10:00	12	2
08/20/2024 11:00	12	2
08/20/2024 12:00	11	2
08/20/2024 13:00	4	10
08/20/2024 14:00	1	13
08/20/2024 15:00	1	13
08/20/2024 16:00	1	13
08/20/2024 17:00	1	4
08/20/2024 18:00	1	1
08/20/2024 19:00	1	1
08/20/2024 20:00	1	1
08/20/2024 21:00	1	1
08/20/2024 22:00	1	1
08/20/2024 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	12	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/21/2024 00:00	1	1
08/21/2024 01:00	1	1
08/21/2024 02:00	1	1
08/21/2024 03:00	1	1
08/21/2024 04:00	1	1
08/21/2024 05:00	1	1
08/21/2024 06:00	1	1
08/21/2024 07:00	1	1
08/21/2024 08:00	1	1
08/21/2024 09:00	1	1
08/21/2024 10:00	1	1
08/21/2024 11:00	1	1
08/21/2024 12:00	1	1
08/21/2024 13:00	1	1
08/21/2024 14:00	1	1
08/21/2024 15:00	1	1
08/21/2024 16:00	1	1
08/21/2024 17:00	1	1
08/21/2024 18:00	1	1
08/21/2024 19:00	1	1
08/21/2024 20:00	1	1
08/21/2024 21:00	1	1
08/21/2024 22:00	1	1
08/21/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/22/2024 00:00	1	1
08/22/2024 01:00	1	1
08/22/2024 02:00	1	1
08/22/2024 03:00	1	1
08/22/2024 04:00	1	1
08/22/2024 05:00	1	1
08/22/2024 06:00	2	1
08/22/2024 07:00	2	1
08/22/2024 08:00	2	1
08/22/2024 09:00	2	1
08/22/2024 10:00	2	1
08/22/2024 11:00	2	1
08/22/2024 12:00	2	1
08/22/2024 13:00	2	1
08/22/2024 14:00	11	1
08/22/2024 15:00	13	1
08/22/2024 16:00	13	1
08/22/2024 17:00	12	1
08/22/2024 18:00	3	1
08/22/2024 19:00	1	1
08/22/2024 20:00	1	1
08/22/2024 21:00	1	1
08/22/2024 22:00	1	1
08/22/2024 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	13	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/23/2024 00:00	1	1
08/23/2024 01:00	1	1
08/23/2024 02:00	1	1
08/23/2024 03:00	1	1
08/23/2024 04:00	1	1
08/23/2024 05:00	1	1
08/23/2024 06:00	1	1
08/23/2024 07:00	3	1
08/23/2024 08:00	3	1
08/23/2024 09:00	3	1
08/23/2024 10:00	3	1
08/23/2024 11:00	3	1
08/23/2024 12:00	3	1
08/23/2024 13:00	3	1
08/23/2024 14:00	3	1
08/23/2024 15:00	3	1
08/23/2024 16:00	3	1
08/23/2024 17:00	3	1
08/23/2024 18:00	3	1
08/23/2024 19:00	3	1
08/23/2024 20:00	3	1
08/23/2024 21:00	3	1
08/23/2024 22:00	3	1
08/23/2024 23:00	3	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	3	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/24/2024 00:00	3	1
08/24/2024 01:00	3	1
08/24/2024 02:00	3	1
08/24/2024 03:00	3	1
08/24/2024 04:00	3	1
08/24/2024 05:00	3	1
08/24/2024 06:00	3	1
08/24/2024 07:00	3	1
08/24/2024 08:00	3	1
08/24/2024 09:00	3	1
08/24/2024 10:00	3	1
08/24/2024 11:00	3	1
08/24/2024 12:00	3	1
08/24/2024 13:00	3	1
08/24/2024 14:00	3	1
08/24/2024 15:00	3	1
08/24/2024 16:00	3	1
08/24/2024 17:00	3	1
08/24/2024 18:00	3	1
08/24/2024 19:00	3	1
08/24/2024 20:00	3	1
08/24/2024 21:00	3	1
08/24/2024 22:00	3	1
08/24/2024 23:00	3	1
Average/Sum#:	3	1
Minimum:	3	1
Maximum:	3	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/25/2024 00:00	3	1
08/25/2024 01:00	3	1
08/25/2024 02:00	3	1
08/25/2024 03:00	3	1
08/25/2024 04:00	3	1
08/25/2024 05:00	3	1
08/25/2024 06:00	3	1
08/25/2024 07:00	3	1
08/25/2024 08:00	3	1
08/25/2024 09:00	3	1
08/25/2024 10:00	3	1
08/25/2024 11:00	3	1
08/25/2024 12:00	3	1
08/25/2024 13:00	18	1
08/25/2024 14:00	26	1
08/25/2024 15:00	27	1
08/25/2024 16:00	26	1
08/25/2024 17:00	10	1
08/25/2024 18:00	3	1
08/25/2024 19:00	1	1
08/25/2024 20:00	1	1
08/25/2024 21:00	1	1
08/25/2024 22:00	1	1
08/25/2024 23:00	1	1
Average/Sum#:	6	1
Minimum:	1	1
Maximum:	27	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/26/2024 00:00	1	11
08/26/2024 01:00	1	11
08/26/2024 02:00	1	11
08/26/2024 03:00	1	11
08/26/2024 04:00	1	11
08/26/2024 05:00	1	11
08/26/2024 06:00	1	11
08/26/2024 07:00	1	28
08/26/2024 08:00	1	0
08/26/2024 09:00	1	28
08/26/2024 10:00	1	18
08/26/2024 11:00	1	1
08/26/2024 12:00	1	1
08/26/2024 13:00	1	1
08/26/2024 14:00	1	1
08/26/2024 15:00	1	1
08/26/2024 16:00	1	1
08/26/2024 17:00	1	1
08/26/2024 18:00	1	1
08/26/2024 19:00	1	1
08/26/2024 20:00	1	1
08/26/2024 21:00	1	1
08/26/2024 22:00	1	1
08/26/2024 23:00	1	1
Average/Sum#:	1	7
Minimum:	1	1
Maximum:	1	28
%SI	0.00	4.17

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/27/2024 00:00	1	1
08/27/2024 01:00	1	1
08/27/2024 02:00	1	1
08/27/2024 03:00	1	1
08/27/2024 04:00	1	1
08/27/2024 05:00	1	1
08/27/2024 06:00	1	1
08/27/2024 07:00	1	1
08/27/2024 08:00	1	1
08/27/2024 09:00	1	1
08/27/2024 10:00	1	1
08/27/2024 11:00	1	1
08/27/2024 12:00	1	1
08/27/2024 13:00	1	1
08/27/2024 14:00	1	1
08/27/2024 15:00	1	1
08/27/2024 16:00	1	1
08/27/2024 17:00	1	1
08/27/2024 18:00	1	1
08/27/2024 19:00	1	1
08/27/2024 20:00	1	1
08/27/2024 21:00	1	1
08/27/2024 22:00	1	1
08/27/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/28/2024 00:00	1	1
08/28/2024 01:00	1	1
08/28/2024 02:00	1	1
08/28/2024 03:00	1	1
08/28/2024 04:00	1	1
08/28/2024 05:00	1	1
08/28/2024 06:00	1	1
08/28/2024 07:00	1	1
08/28/2024 08:00	1	1
08/28/2024 09:00	1	1
08/28/2024 10:00	1	1
08/28/2024 11:00	1	1
08/28/2024 12:00	1	1
08/28/2024 13:00	1	1
08/28/2024 14:00	1	1
08/28/2024 15:00	1	1
08/28/2024 16:00	1	1
08/28/2024 17:00	1	1
08/28/2024 18:00	1	1
08/28/2024 19:00	1	1
08/28/2024 20:00	1	1
08/28/2024 21:00	1	1
08/28/2024 22:00	1	1
08/28/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/29/2024 00:00	1	1
08/29/2024 01:00	1	1
08/29/2024 02:00	1	1
08/29/2024 03:00	1	1
08/29/2024 04:00	1	1
08/29/2024 05:00	1	1
08/29/2024 06:00	1	1
08/29/2024 07:00	1	1
08/29/2024 08:00	1	1
08/29/2024 09:00	1	1
08/29/2024 10:00	1	1
08/29/2024 11:00	1	1
08/29/2024 12:00	1	1
08/29/2024 13:00	1	1
08/29/2024 14:00	1	1
08/29/2024 15:00	1	1
08/29/2024 16:00	1	1
08/29/2024 17:00	1	1
08/29/2024 18:00	1	1
08/29/2024 19:00	1	1
08/29/2024 20:00	1	1
08/29/2024 21:00	1	1
08/29/2024 22:00	1	1
08/29/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/30/2024 00:00	1	1
08/30/2024 01:00	1	1
08/30/2024 02:00	1	1
08/30/2024 03:00	1	1
08/30/2024 04:00	1	1
08/30/2024 05:00	1	1
08/30/2024 06:00	1	1
08/30/2024 07:00	1	1
08/30/2024 08:00	1	1
08/30/2024 09:00	1	1
08/30/2024 10:00	1	1
08/30/2024 11:00	1	1
08/30/2024 12:00	1	1
08/30/2024 13:00	1	1
08/30/2024 14:00	1	1
08/30/2024 15:00	1	1
08/30/2024 16:00	1	1
08/30/2024 17:00	1	1
08/30/2024 18:00	1	1
08/30/2024 19:00	1	1
08/30/2024 20:00	1	1
08/30/2024 21:00	1	1
08/30/2024 22:00	1	1
08/30/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/31/2024 00:00	1	1
08/31/2024 01:00	1	1
08/31/2024 02:00	1	1
08/31/2024 03:00	1	1
08/31/2024 04:00	1	1
08/31/2024 05:00	1	1
08/31/2024 06:00	2	2
08/31/2024 07:00	2	2
08/31/2024 08:00	2	2
08/31/2024 09:00	2	2
08/31/2024 10:00	2	2
08/31/2024 11:00	2	4
08/31/2024 12:00	2	4
08/31/2024 13:00	2	3
08/31/2024 14:00	10	3
08/31/2024 15:00	11	1
08/31/2024 16:00	11	1
08/31/2024 17:00	10	1
08/31/2024 18:00	3	1
08/31/2024 19:00	1	1
08/31/2024 20:00	1	1
08/31/2024 21:00	1	1
08/31/2024 22:00	1	1
08/31/2024 23:00	1	1
Average/Sum#:	3	2
Minimum:	1	1
Maximum:	11	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/01/2024 00:00	1	1
09/01/2024 01:00	1	1
09/01/2024 02:00	1	1
09/01/2024 03:00	1	1
09/01/2024 04:00	1	1
09/01/2024 05:00	1	1
09/01/2024 06:00	2	2
09/01/2024 07:00	2	2
09/01/2024 08:00	2	2
09/01/2024 09:00	2	2
09/01/2024 10:00	2	2
09/01/2024 11:00	4	2
09/01/2024 12:00	4	2
09/01/2024 13:00	3	2
09/01/2024 14:00	3	9
09/01/2024 15:00	1	11
09/01/2024 16:00	1	11
09/01/2024 17:00	1	10
09/01/2024 18:00	1	3
09/01/2024 19:00	1	1
09/01/2024 20:00	1	1
09/01/2024 21:00	1	1
09/01/2024 22:00	1	1
09/01/2024 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/02/2024 00:00	1	1
09/02/2024 01:00	1	1
09/02/2024 02:00	1	1
09/02/2024 03:00	1	1
09/02/2024 04:00	1	1
09/02/2024 05:00	1	1
09/02/2024 06:00	1	1
09/02/2024 07:00	2	2
09/02/2024 08:00	2	2
09/02/2024 09:00	2	2
09/02/2024 10:00	2	2
09/02/2024 11:00	4	2
09/02/2024 12:00	4	2
09/02/2024 13:00	3	2
09/02/2024 14:00	2	9
09/02/2024 15:00	1	12
09/02/2024 16:00	1	12
09/02/2024 17:00	1	11
09/02/2024 18:00	1	3
09/02/2024 19:00	1	1
09/02/2024 20:00	1	1
09/02/2024 21:00	1	1
09/02/2024 22:00	1	1
09/02/2024 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/03/2024 00:00	1	1
09/03/2024 01:00	1	1
09/03/2024 02:00	1	1
09/03/2024 03:00	1	1
09/03/2024 04:00	1	1
09/03/2024 05:00	1	1
09/03/2024 06:00	1	1
09/03/2024 07:00	1	1
09/03/2024 08:00	1	1
09/03/2024 09:00	1	1
09/03/2024 10:00	1	1
09/03/2024 11:00	1	1
09/03/2024 12:00	1	1
09/03/2024 13:00	1	1
09/03/2024 14:00	1	1
09/03/2024 15:00	1	1
09/03/2024 16:00	1	1
09/03/2024 17:00	1	1
09/03/2024 18:00	1	1
09/03/2024 19:00	1	1
09/03/2024 20:00	1	1
09/03/2024 21:00	1	1
09/03/2024 22:00	1	1
09/03/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/04/2024 00:00	1	1
09/04/2024 01:00	1	1
09/04/2024 02:00	1	1
09/04/2024 03:00	1	1
09/04/2024 04:00	1	1
09/04/2024 05:00	1	1
09/04/2024 06:00	1	1
09/04/2024 07:00	1	1
09/04/2024 08:00	1	1
09/04/2024 09:00	1	1
09/04/2024 10:00	1	1
09/04/2024 11:00	1	1
09/04/2024 12:00	1	1
09/04/2024 13:00	1	1
09/04/2024 14:00	1	1
09/04/2024 15:00	1	1
09/04/2024 16:00	1	1
09/04/2024 17:00	1	1
09/04/2024 18:00	1	1
09/04/2024 19:00	1	1
09/04/2024 20:00	1	1
09/04/2024 21:00	1	1
09/04/2024 22:00	1	1
09/04/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/05/2024 00:00	1	1
09/05/2024 01:00	1	1
09/05/2024 02:00	1	1
09/05/2024 03:00	1	1
09/05/2024 04:00	1	1
09/05/2024 05:00	1	1
09/05/2024 06:00	1	1
09/05/2024 07:00	1	1
09/05/2024 08:00	1	1
09/05/2024 09:00	1	1
09/05/2024 10:00	1	1
09/05/2024 11:00	1	1
09/05/2024 12:00	1	1
09/05/2024 13:00	1	1
09/05/2024 14:00	1	1
09/05/2024 15:00	1	1
09/05/2024 16:00	1	1
09/05/2024 17:00	1	1
09/05/2024 18:00	1	1
09/05/2024 19:00	1	1
09/05/2024 20:00	1	1
09/05/2024 21:00	1	1
09/05/2024 22:00	1	1
09/05/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/06/2024 00:00	1	1
09/06/2024 01:00	1	1
09/06/2024 02:00	1	1
09/06/2024 03:00	1	1
09/06/2024 04:00	1	1
09/06/2024 05:00	1	1
09/06/2024 06:00	1	1
09/06/2024 07:00	1	1
09/06/2024 08:00	1	1
09/06/2024 09:00	1	1
09/06/2024 10:00	1	1
09/06/2024 11:00	1	1
09/06/2024 12:00	1	1
09/06/2024 13:00	1	1
09/06/2024 14:00	1	1
09/06/2024 15:00	1	1
09/06/2024 16:00	1	1
09/06/2024 17:00	1	1
09/06/2024 18:00	1	1
09/06/2024 19:00	1	1
09/06/2024 20:00	1	1
09/06/2024 21:00	1	1
09/06/2024 22:00	1	1
09/06/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/07/2024 00:00	1	1
09/07/2024 01:00	1	1
09/07/2024 02:00	1	1
09/07/2024 03:00	1	1
09/07/2024 04:00	1	1
09/07/2024 05:00	1	1
09/07/2024 06:00	1	1
09/07/2024 07:00	1	1
09/07/2024 08:00	1	1
09/07/2024 09:00	1	1
09/07/2024 10:00	1	1
09/07/2024 11:00	1	1
09/07/2024 12:00	1	1
09/07/2024 13:00	1	1
09/07/2024 14:00	1	1
09/07/2024 15:00	1	1
09/07/2024 16:00	1	1
09/07/2024 17:00	1	1
09/07/2024 18:00	1	1
09/07/2024 19:00	1	1
09/07/2024 20:00	1	1
09/07/2024 21:00	1	1
09/07/2024 22:00	1	1
09/07/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/08/2024 00:00	1	1
09/08/2024 01:00	1	1
09/08/2024 02:00	1	1
09/08/2024 03:00	1	1
09/08/2024 04:00	1	1
09/08/2024 05:00	1	1
09/08/2024 06:00	1	1
09/08/2024 07:00	1	1
09/08/2024 08:00	1	1
09/08/2024 09:00	1	1
09/08/2024 10:00	1	1
09/08/2024 11:00	1	1
09/08/2024 12:00	1	1
09/08/2024 13:00	1	1
09/08/2024 14:00	1	1
09/08/2024 15:00	1	1
09/08/2024 16:00	1	1
09/08/2024 17:00	1	1
09/08/2024 18:00	1	1
09/08/2024 19:00	1	1
09/08/2024 20:00	1	1
09/08/2024 21:00	1	1
09/08/2024 22:00	1	1
09/08/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/09/2024 00:00	1	1
09/09/2024 01:00	1	1
09/09/2024 02:00	1	1
09/09/2024 03:00	1	1
09/09/2024 04:00	1	1
09/09/2024 05:00	1	1
09/09/2024 06:00	1	1
09/09/2024 07:00	1	1
09/09/2024 08:00	1	1
09/09/2024 09:00	1	1
09/09/2024 10:00	1	1
09/09/2024 11:00	1	1
09/09/2024 12:00	1	1
09/09/2024 13:00	1	1
09/09/2024 14:00	1	1
09/09/2024 15:00	1	1
09/09/2024 16:00	1	1
09/09/2024 17:00	1	1
09/09/2024 18:00	1	1
09/09/2024 19:00	1	1
09/09/2024 20:00	1	1
09/09/2024 21:00	1	1
09/09/2024 22:00	1	1
09/09/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/10/2024 00:00	1	1
09/10/2024 01:00	1	1
09/10/2024 02:00	1	1
09/10/2024 03:00	1	1
09/10/2024 04:00	1	1
09/10/2024 05:00	1	1
09/10/2024 06:00	1	1
09/10/2024 07:00	1	1
09/10/2024 08:00	1	1
09/10/2024 09:00	1	1
09/10/2024 10:00	1	1
09/10/2024 11:00	1	1
09/10/2024 12:00	1	1
09/10/2024 13:00	1	1
09/10/2024 14:00	1	1
09/10/2024 15:00	1	1
09/10/2024 16:00	1	1
09/10/2024 17:00	1	1
09/10/2024 18:00	1	1
09/10/2024 19:00	1	1
09/10/2024 20:00	1	1
09/10/2024 21:00	1	1
09/10/2024 22:00	1	1
09/10/2024 23:00	2	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/11/2024 00:00	2	2
09/11/2024 01:00	2	2
09/11/2024 02:00	2	2
09/11/2024 03:00	2	2
09/11/2024 04:00	2	2
09/11/2024 05:00	2	2
09/11/2024 06:00	2	2
09/11/2024 07:00	2	2
09/11/2024 08:00	2	2
09/11/2024 09:00	2	2
09/11/2024 10:00	2	2
09/11/2024 11:00	2	2
09/11/2024 12:00	2	2
09/11/2024 13:00	2	2
09/11/2024 14:00	2	2
09/11/2024 15:00	2	2
09/11/2024 16:00	2	2
09/11/2024 17:00	2	2
09/11/2024 18:00	2	2
09/11/2024 19:00	2	2
09/11/2024 20:00	2	2
09/11/2024 21:00	2	2
09/11/2024 22:00	2	2
09/11/2024 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/12/2024 00:00	2	2
09/12/2024 01:00	2	2
09/12/2024 02:00	2	2
09/12/2024 03:00	2	2
09/12/2024 04:00	2	2
09/12/2024 05:00	2	2
09/12/2024 06:00	2	2
09/12/2024 07:00	2	2
09/12/2024 08:00	2	2
09/12/2024 09:00	2	2
09/12/2024 10:00	2	2
09/12/2024 11:00	2	2
09/12/2024 12:00	2	2
09/12/2024 13:00	2	2
09/12/2024 14:00	2	2
09/12/2024 15:00	2	2
09/12/2024 16:00	2	2
09/12/2024 17:00	16	2
09/12/2024 18:00	22	2
09/12/2024 19:00	26	2
09/12/2024 20:00	25	2
09/12/2024 21:00	11	2
09/12/2024 22:00	5	2
09/12/2024 23:00	1	2
Average/Sum#:	6	2
Minimum:	1	2
Maximum:	26	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/13/2024 00:00	1	2
09/13/2024 01:00	1	2
09/13/2024 02:00	1	2
09/13/2024 03:00	1	2
09/13/2024 04:00	1	2
09/13/2024 05:00	1	2
09/13/2024 06:00	1	2
09/13/2024 07:00	1	2
09/13/2024 08:00	1	2
09/13/2024 09:00	1	2
09/13/2024 10:00	1	2
09/13/2024 11:00	1	2
09/13/2024 12:00	1	2
09/13/2024 13:00	12	2
09/13/2024 14:00	14	2
09/13/2024 15:00	14	2
09/13/2024 16:00	14	2
09/13/2024 17:00	4	2
09/13/2024 18:00	1	14
09/13/2024 19:00	1	20
09/13/2024 20:00	1	20
09/13/2024 21:00	1	18
09/13/2024 22:00	1	7
09/13/2024 23:00	1	1
Average/Sum#:	3	5
Minimum:	1	1
Maximum:	14	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/14/2024 00:00	1	1
09/14/2024 01:00	1	1
09/14/2024 02:00	1	1
09/14/2024 03:00	1	1
09/14/2024 04:00	1	1
09/14/2024 05:00	1	1
09/14/2024 06:00	1	1
09/14/2024 07:00	1	1
09/14/2024 08:00	1	1
09/14/2024 09:00	1	1
09/14/2024 10:00	1	1
09/14/2024 11:00	1	1
09/14/2024 12:00	1	1
09/14/2024 13:00	1	1
09/14/2024 14:00	1	1
09/14/2024 15:00	1	1
09/14/2024 16:00	9	1
09/14/2024 17:00	12	1
09/14/2024 18:00	13	1
09/14/2024 19:00	13	1
09/14/2024 20:00	4	1
09/14/2024 21:00	2	1
09/14/2024 22:00	1	1
09/14/2024 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	13	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/15/2024 00:00	1	1
09/15/2024 01:00	1	1
09/15/2024 02:00	1	1
09/15/2024 03:00	1	1
09/15/2024 04:00	1	1
09/15/2024 05:00	1	1
09/15/2024 06:00	1	1
09/15/2024 07:00	1	1
09/15/2024 08:00	1	1
09/15/2024 09:00	1	1
09/15/2024 10:00	1	1
09/15/2024 11:00	1	1
09/15/2024 12:00	1	1
09/15/2024 13:00	1	1
09/15/2024 14:00	1	1
09/15/2024 15:00	1	1
09/15/2024 16:00	1	1
09/15/2024 17:00	13	1
09/15/2024 18:00	17	1
09/15/2024 19:00	20	1
09/15/2024 20:00	19	1
09/15/2024 21:00	8	1
09/15/2024 22:00	4	1
09/15/2024 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	1
Maximum:	20	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/16/2024 00:00	1	1
09/16/2024 01:00	1	1
09/16/2024 02:00	1	1
09/16/2024 03:00	1	1
09/16/2024 04:00	1	1
09/16/2024 05:00	1	1
09/16/2024 06:00	1	1
09/16/2024 07:00	1	1
09/16/2024 08:00	1	1
09/16/2024 09:00	1	1
09/16/2024 10:00	1	1
09/16/2024 11:00	1	1
09/16/2024 12:00	1	1
09/16/2024 13:00	1	1
09/16/2024 14:00	1	1
09/16/2024 15:00	1	1
09/16/2024 16:00	1	1
09/16/2024 17:00	1	1
09/16/2024 18:00	1	1
09/16/2024 19:00	1	1
09/16/2024 20:00	1	1
09/16/2024 21:00	1	1
09/16/2024 22:00	1	1
09/16/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/17/2024 00:00	1	1
09/17/2024 01:00	1	1
09/17/2024 02:00	1	1
09/17/2024 03:00	1	1
09/17/2024 04:00	1	1
09/17/2024 05:00	1	1
09/17/2024 06:00	1	1
09/17/2024 07:00	1	1
09/17/2024 08:00	1	1
09/17/2024 09:00	1	1
09/17/2024 10:00	1	1
09/17/2024 11:00	1	1
09/17/2024 12:00	1	1
09/17/2024 13:00	1	1
09/17/2024 14:00	1	1
09/17/2024 15:00	1	1
09/17/2024 16:00	1	1
09/17/2024 17:00	1	1
09/17/2024 18:00	1	1
09/17/2024 19:00	1	1
09/17/2024 20:00	13	1
09/17/2024 21:00	16	1
09/17/2024 22:00	18	1
09/17/2024 23:00	18	1
Average/Sum#:	4	1
Minimum:	1	1
Maximum:	18	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/18/2024 00:00	6	1
09/18/2024 01:00	4	13
09/18/2024 02:00	1	16
09/18/2024 03:00	1	16
09/18/2024 04:00	1	16
09/18/2024 05:00	1	4
09/18/2024 06:00	1	1
09/18/2024 07:00	1	1
09/18/2024 08:00	1	1
09/18/2024 09:00	1	1
09/18/2024 10:00	1	1
09/18/2024 11:00	1	1
09/18/2024 12:00	1	1
09/18/2024 13:00	1	1
09/18/2024 14:00	1	1
09/18/2024 15:00	1	1
09/18/2024 16:00	1	1
09/18/2024 17:00	1	1
09/18/2024 18:00	1	1
09/18/2024 19:00	1	1
09/18/2024 20:00	1	1
09/18/2024 21:00	1	1
09/18/2024 22:00	1	1
09/18/2024 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	6	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/19/2024 00:00	1	1
09/19/2024 01:00	1	1
09/19/2024 02:00	1	1
09/19/2024 03:00	1	1
09/19/2024 04:00	1	1
09/19/2024 05:00	1	1
09/19/2024 06:00	1	1
09/19/2024 07:00	2	1
09/19/2024 08:00	2	1
09/19/2024 09:00	2	1
09/19/2024 10:00	2	1
09/19/2024 11:00	2	1
09/19/2024 12:00	2	1
09/19/2024 13:00	2	1
09/19/2024 14:00	2	1
09/19/2024 15:00	2	1
09/19/2024 16:00	2	1
09/19/2024 17:00	2	1
09/19/2024 18:00	2	1
09/19/2024 19:00	2	1
09/19/2024 20:00	2	1
09/19/2024 21:00	2	1
09/19/2024 22:00	2	1
09/19/2024 23:00	2	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/20/2024 00:00	2	1
09/20/2024 01:00	2	1
09/20/2024 02:00	2	1
09/20/2024 03:00	2	1
09/20/2024 04:00	2	1
09/20/2024 05:00	2	1
09/20/2024 06:00	2	1
09/20/2024 07:00	2	1
09/20/2024 08:00	2	1
09/20/2024 09:00	2	1
09/20/2024 10:00	2	1
09/20/2024 11:00	2	1
09/20/2024 12:00	2	1
09/20/2024 13:00	2	1
09/20/2024 14:00	2	1
09/20/2024 15:00	2	1
09/20/2024 16:00	2	1
09/20/2024 17:00	2	1
09/20/2024 18:00	2	1
09/20/2024 19:00	2	1
09/20/2024 20:00	2	1
09/20/2024 21:00	2	1
09/20/2024 22:00	2	1
09/20/2024 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/21/2024 00:00	2	1
09/21/2024 01:00	2	1
09/21/2024 02:00	2	1
09/21/2024 03:00	2	1
09/21/2024 04:00	2	1
09/21/2024 05:00	2	1
09/21/2024 06:00	2	1
09/21/2024 07:00	2	1
09/21/2024 08:00	2	1
09/21/2024 09:00	2	1
09/21/2024 10:00	2	1
09/21/2024 11:00	2	1
09/21/2024 12:00	2	1
09/21/2024 13:00	2	1
09/21/2024 14:00	2	1
09/21/2024 15:00	2	1
09/21/2024 16:00	2	1
09/21/2024 17:00	2	1
09/21/2024 18:00	2	1
09/21/2024 19:00	2	1
09/21/2024 20:00	2	14
09/21/2024 21:00	2	20
09/21/2024 22:00	2	22
09/21/2024 23:00	2	22
Average/Sum#:	2	4
Minimum:	2	1
Maximum:	2	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/22/2024 00:00	2	10
09/22/2024 01:00	2	4
09/22/2024 02:00	2	1
09/22/2024 03:00	2	1
09/22/2024 04:00	2	1
09/22/2024 05:00	2	1
09/22/2024 06:00	2	1
09/22/2024 07:00	2	2
09/22/2024 08:00	2	2
09/22/2024 09:00	2	2
09/22/2024 10:00	2	4
09/22/2024 11:00	2	7
09/22/2024 12:00	2	7
09/22/2024 13:00	2	6
09/22/2024 14:00	18	4
09/22/2024 15:00	21	1
09/22/2024 16:00	21	1
09/22/2024 17:00	20	1
09/22/2024 18:00	4	1
09/22/2024 19:00	1	1
09/22/2024 20:00	1	1
09/22/2024 21:00	1	1
09/22/2024 22:00	1	1
09/22/2024 23:00	1	1
Average/Sum#:	5	3
Minimum:	1	1
Maximum:	21	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/23/2024 00:00	1	1
09/23/2024 01:00	1	1
09/23/2024 02:00	1	1
09/23/2024 03:00	1	1
09/23/2024 04:00	1	1
09/23/2024 05:00	1	1
09/23/2024 06:00	1	1
09/23/2024 07:00	1	1
09/23/2024 08:00	1	1
09/23/2024 09:00	1	1
09/23/2024 10:00	1	1
09/23/2024 11:00	1	1
09/23/2024 12:00	1	1
09/23/2024 13:00	1	1
09/23/2024 14:00	1	1
09/23/2024 15:00	1	1
09/23/2024 16:00	1	1
09/23/2024 17:00	1	1
09/23/2024 18:00	1	1
09/23/2024 19:00	1	1
09/23/2024 20:00	1	1
09/23/2024 21:00	1	1
09/23/2024 22:00	1	1
09/23/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/24/2024 00:00	1	1
09/24/2024 01:00	1	1
09/24/2024 02:00	1	1
09/24/2024 03:00	1	1
09/24/2024 04:00	1	1
09/24/2024 05:00	1	1
09/24/2024 06:00	1	1
09/24/2024 07:00	1	1
09/24/2024 08:00	1	1
09/24/2024 09:00	1	1
09/24/2024 10:00	1	1
09/24/2024 11:00	1	1
09/24/2024 12:00	1	1
09/24/2024 13:00	1	1
09/24/2024 14:00	1	1
09/24/2024 15:00	1	1
09/24/2024 16:00	1	1
09/24/2024 17:00	1	1
09/24/2024 18:00	1	1
09/24/2024 19:00	1	1
09/24/2024 20:00	1	1
09/24/2024 21:00	1	1
09/24/2024 22:00	1	1
09/24/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/25/2024 00:00	1	1
09/25/2024 01:00	1	1
09/25/2024 02:00	1	1
09/25/2024 03:00	1	1
09/25/2024 04:00	1	1
09/25/2024 05:00	1	1
09/25/2024 06:00	1	1
09/25/2024 07:00	2	1
09/25/2024 08:00	2	1
09/25/2024 09:00	2	1
09/25/2024 10:00	2	1
09/25/2024 11:00	2	1
09/25/2024 12:00	2	1
09/25/2024 13:00	2	1
09/25/2024 14:00	6	1
09/25/2024 15:00	8	1
09/25/2024 16:00	8	1
09/25/2024 17:00	7	1
09/25/2024 18:00	3	1
09/25/2024 19:00	1	7
09/25/2024 20:00	1	7
09/25/2024 21:00	1	6
09/25/2024 22:00	1	7
09/25/2024 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	8	7
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/26/2024 00:00	1	1
09/26/2024 01:00	1	1
09/26/2024 02:00	1	1
09/26/2024 03:00	1	1
09/26/2024 04:00	1	1
09/26/2024 05:00	1	1
09/26/2024 06:00	1	1
09/26/2024 07:00	1	1
09/26/2024 08:00	2	2
09/26/2024 09:00	2	2
09/26/2024 10:00	2	2
09/26/2024 11:00	2	2
09/26/2024 12:00	2	2
09/26/2024 13:00	2	2
09/26/2024 14:00	5	2
09/26/2024 15:00	8	2
09/26/2024 16:00	8	2
09/26/2024 17:00	7	2
09/26/2024 18:00	4	2
09/26/2024 19:00	1	2
09/26/2024 20:00	1	2
09/26/2024 21:00	1	2
09/26/2024 22:00	1	2
09/26/2024 23:00	1	2
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	8	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/27/2024 00:00	1	2
09/27/2024 01:00	1	2
09/27/2024 02:00	1	2
09/27/2024 03:00	1	2
09/27/2024 04:00	1	2
09/27/2024 05:00	1	2
09/27/2024 06:00	1	2
09/27/2024 07:00	1	2
09/27/2024 08:00	1	2
09/27/2024 09:00	13	2
09/27/2024 10:00	17	2
09/27/2024 11:00	17	2
09/27/2024 12:00	17	2
09/27/2024 13:00	5	15
09/27/2024 14:00	1	19
09/27/2024 15:00	1	19
09/27/2024 16:00	1	18
09/27/2024 17:00	1	5
09/27/2024 18:00	1	1
09/27/2024 19:00	1	1
09/27/2024 20:00	1	1
09/27/2024 21:00	1	1
09/27/2024 22:00	1	1
09/27/2024 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	17	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/28/2024 00:00	1	1
09/28/2024 01:00	1	1
09/28/2024 02:00	1	1
09/28/2024 03:00	1	1
09/28/2024 04:00	1	1
09/28/2024 05:00	1	1
09/28/2024 06:00	1	1
09/28/2024 07:00	3	2
09/28/2024 08:00	3	2
09/28/2024 09:00	3	2
09/28/2024 10:00	3	2
09/28/2024 11:00	3	2
09/28/2024 12:00	3	2
09/28/2024 13:00	3	2
09/28/2024 14:00	3	2
09/28/2024 15:00	7	2
09/28/2024 16:00	7	2
09/28/2024 17:00	7	2
09/28/2024 18:00	6	2
09/28/2024 19:00	1	2
09/28/2024 20:00	1	2
09/28/2024 21:00	1	2
09/28/2024 22:00	1	2
09/28/2024 23:00	1	2
Average/Sum#:	3	2
Minimum:	1	1
Maximum:	7	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/29/2024 00:00	1	2
09/29/2024 01:00	1	2
09/29/2024 02:00	2	2
09/29/2024 03:00	2	2
09/29/2024 04:00	2	2
09/29/2024 05:00	2	2
09/29/2024 06:00	2	2
09/29/2024 07:00	2	2
09/29/2024 08:00	2	2
09/29/2024 09:00	2	2
09/29/2024 10:00	14	2
09/29/2024 11:00	18	2
09/29/2024 12:00	18	2
09/29/2024 13:00	17	2
09/29/2024 14:00	5	14
09/29/2024 15:00	1	17
09/29/2024 16:00	1	17
09/29/2024 17:00	1	17
09/29/2024 18:00	1	4
09/29/2024 19:00	1	1
09/29/2024 20:00	1	1
09/29/2024 21:00	1	1
09/29/2024 22:00	1	1
09/29/2024 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	18	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 09:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/30/2024 00:00	1	1
09/30/2024 01:00	1	1
09/30/2024 02:00	1	1
09/30/2024 03:00	1	1
09/30/2024 04:00	1	1
09/30/2024 05:00	1	1
09/30/2024 06:00	1	1
09/30/2024 07:00	1	1
09/30/2024 08:00	1	1
09/30/2024 09:00	1	1
09/30/2024 10:00	1	1
09/30/2024 11:00	1	1
09/30/2024 12:00	1	1
09/30/2024 13:00	1	1
09/30/2024 14:00	1	1
09/30/2024 15:00	1	1
09/30/2024 16:00	1	1
09/30/2024 17:00	1	1
09/30/2024 18:00	1	1
09/30/2024 19:00	1	1
09/30/2024 20:00	1	1
09/30/2024 21:00	1	1
09/30/2024 22:00	1	1
09/30/2024 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 04/01/2024 00:00 **To:** 06/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:24 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 30.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 61.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**30.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:24 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4

EDS-CMS Reports
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #28

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:56 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,655.00 Hour(s)
Operating time for CMS: 1,655.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.18
4. Total Availability as a percentage of operating time	99.82

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:56 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,655.00 Hour(s)
Operating time for CMS: 1,655.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.18
4. Total Availability as a percentage of operating time	99.82

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:56 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,655.00 Hour(s)
Operating time for CMS: 1,655.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.30
4. Total Availability as a percentage of operating time	99.70

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:57 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,655.00 Hour(s)
Operating time for CMS: 1,655.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.30
4. Total Availability as a percentage of operating time	99.70

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:57 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,555.00 Hour(s)
Operating time for CMS: 1,555.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	9
e. Unknown causes	0
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.58
4. Total Availability as a percentage of operating time	99.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:57 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,555.00 Hour(s)
Operating time for CMS: 1,555.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	9
e. Unknown causes	0
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.58
4. Total Availability as a percentage of operating time	99.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:58 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,555.00 Hour(s)
Operating time for CMS: 1,555.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	8
e. Unknown causes	0	e. Unknown causes	1
2. Upset Conditions	0	2. Total CMS Downtime	9
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	0.58
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	99.42
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:58 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,555.00 Hour(s)
Operating time for CMS: 1,555.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	8
e. Unknown causes	1
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.58
4. Total Availability as a percentage of operating time	99.42

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:59 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:59 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 09:59 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:00 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:01 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:02 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:02 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:05 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,655.00 Hour(s)
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/09/2024 09:00	07/09/2024 11:59	3	4 - Other known causes	4 - Quarterly linearity/cga

Total Operating Time:	**1,655.00 Hour(s)**
Total Monitor Downtime (Online only):	**3.00 Hour(s)**
Percent Monitor Availability:	**99.82 %**
Percent Monitor Downtime:	**0.18 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	3	100.00
4	Action	Quarterly linearity/cga	3	100.00

Invalid Data Report

CT1 - Stack NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:11 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,655.00 Hour(s)
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/09/2024 09:00	07/09/2024 11:59	3	4 - Other known causes	4 - Quarterly linearity/cga
2	08/06/2024 05:00	08/06/2024 05:59	1	4 - Other known causes	3 - Performed manual calibration
3	09/05/2024 05:00	09/05/2024 05:59	1	4 - Other known causes	3 - Performed manual calibration

Total Operating Time:	**1,655.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.70 %**
Percent Monitor Downtime:	**0.30 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	5	100.00
3	Action	Performed manual calibration	2	40.00
4	Action	Quarterly linearity/cga	3	60.00

Invalid Data Report

CT2 - Stack CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:13 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,555.00 Hour(s)
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/06/2024 06:00	07/06/2024 06:59	1	4 - Other known causes	1 - Investigated alarm, no problem found
2	07/09/2024 08:00	07/09/2024 11:59	4	4 - Other known causes	4 - Quarterly linearity/cga
3	07/27/2024 06:00	07/27/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
4	08/17/2024 06:00	08/17/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
5	08/22/2024 06:00	08/22/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
6	08/26/2024 08:00	08/26/2024 08:59	1	9 - CEMS failed calibration	3 - Performed manual calibration

Total Operating Time:	**1,555.00 Hour(s)**
Total Monitor Downtime (Online only):	**9.00 Hour(s)**
Percent Monitor Availability:	**99.42 %**
Percent Monitor Downtime:	**0.58 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	1	11.11
4	Reason	Other known causes	8	88.89
1	Action	Investigated alarm, no problem found	1	11.11
3	Action	Performed manual calibration	4	44.44
4	Action	Quarterly linearity/cga	4	44.44

Invalid Data Report

CT2 - Stack NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:13 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,555.00 Hour(s)
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/06/2024 06:00	07/06/2024 06:59	1	5 - Unknown causes	1 - Investigated alarm, no problem found
2	07/09/2024 08:00	07/09/2024 11:59	4	4 - Other known causes	4 - Quarterly linearity/cga
3	07/27/2024 06:00	07/27/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
4	08/17/2024 06:00	08/17/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
5	08/22/2024 06:00	08/22/2024 06:59	1	4 - Other known causes	3 - Performed manual calibration
6	08/26/2024 08:00	08/26/2024 08:59	1	9 - CEMS failed calibration	3 - Performed manual calibration

Total Operating Time:	**1,555.00 Hour(s)**
Total Monitor Downtime (Online only):	**9.00 Hour(s)**
Percent Monitor Availability:	**99.42 %**
Percent Monitor Downtime:	**0.58 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	1	11.11
4	Reason	Other known causes	7	77.78
5	Reason	Unknown causes	1	11.11
1	Action	Investigated alarm, no problem found	1	11.11
3	Action	Performed manual calibration	4	44.44
4	Action	Quarterly linearity/cga	4	44.44

ATTACHMENT 5
Hourly Emissions VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2024 00:00	0.0	15.4	618.6	0.0	0.4	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 08:00	0.0	17.4	351.7	0.0	0.2	1	0	0
07/01/2024 09:00	0.0	15.5	797.9	0.0	0.6	1	0	0
07/01/2024 10:00	0.6	13.7	1,590.9	0.6	1.1	1	1	0
07/01/2024 11:00	0.6	13.7	1,478.8	0.6	1.0	1	1	0
07/01/2024 12:00	0.6	13.8	1,412.5	0.6	1.0	1	1	0
07/01/2024 13:00	0.6	13.7	1,639.2	0.6	1.1	1	1	0
07/01/2024 14:00	0.6	13.7	1,543.8	0.6	1.1	1	1	0
07/01/2024 15:00	0.6	13.9	1,339.5	0.6	0.9	1	1	0
07/01/2024 16:00	0.7	13.6	1,559.1	0.7	1.1	1	1	1
07/01/2024 17:00	0.7	11.7	2,129.1	0.7	1.5	1	1	1
07/01/2024 18:00	0.7	11.4	2,189.3	0.7	1.5	1	1	1
07/01/2024 19:00	0.7	11.5	2,181.9	0.7	1.5	1	1	1
07/01/2024 20:00	0.7	11.5	2,172.0	0.7	1.5	1	1	1
07/01/2024 21:00	0.7	12.0	2,078.8	0.7	1.5	1	1	1
07/01/2024 22:00	0.7	12.1	2,065.8	0.7	1.4	1	1	1
07/01/2024 23:00	0.0	15.6	606.5	0.0	0.4	1	0	0
Average/Sum#:	0.5	13.5	1,515.0	0.5	1.0	17 #	13 #	7 #
Minimum:	0.0	11.4	351.7	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,189.3	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 10:00	0.0	17.5	331.6	0.0	0.2	1	0	0
07/02/2024 11:00	0.0	16.9	423.8	0.0	0.3	1	0	0
07/02/2024 12:00	0.0	15.0	986.6	0.0	0.7	1	0	0
07/02/2024 13:00	0.6	13.7	1,659.3	0.6	1.2	1	1	0
07/02/2024 14:00	0.6	13.7	1,576.4	0.6	1.1	1	1	0
07/02/2024 15:00	0.6	13.6	1,668.0	0.6	1.2	1	1	0
07/02/2024 16:00	0.6	13.7	1,581.8	0.6	1.1	1	1	0
07/02/2024 17:00	0.6	13.7	1,636.5	0.6	1.1	1	1	0
07/02/2024 18:00	0.7	12.6	1,852.2	0.7	1.3	1	1	1
07/02/2024 19:00	0.7	11.5	2,194.8	0.7	1.5	1	1	1
07/02/2024 20:00	0.7	11.5	2,184.0	0.7	1.5	1	1	1
07/02/2024 21:00	0.7	11.5	2,182.6	0.7	1.5	1	1	1
07/02/2024 22:00	0.7	11.9	2,127.1	0.7	1.5	1	1	1
07/02/2024 23:00	0.7	11.5	2,208.0	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.5	1,615.2	0.5	1.1	14 #	11 #	6 #
Minimum:	0.0	11.5	331.6	0.0	0.2	0	0	0
Maximum:	0.7	17.5	2,208.0	0.7	1.5	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2024 00:00	0.7	11.5	2,201.3	0.7	1.5	1	1	1
07/03/2024 01:00	0.7	12.0	2,096.1	0.7	1.5	1	1	1
07/03/2024 02:00	0.7	12.2	2,062.5	0.7	1.4	1	1	1
07/03/2024 03:00	0.7	12.3	2,042.7	0.7	1.4	1	1	1
07/03/2024 04:00	0.7	12.2	2,053.8	0.7	1.4	1	1	1
07/03/2024 05:00	0.7	12.2	2,058.8	0.7	1.4	1	1	1
07/03/2024 06:00	0.7	12.1	2,070.2	0.7	1.4	1	1	1
07/03/2024 07:00	0.7	12.1	2,078.1	0.7	1.5	1	1	1
07/03/2024 08:00	0.7	12.1	2,084.4	0.7	1.5	1	1	1
07/03/2024 09:00	0.7	12.0	2,092.0	0.7	1.5	1	1	1
07/03/2024 10:00	0.7	12.0	2,098.8	0.7	1.5	1	1	1
07/03/2024 11:00	0.7	12.0	2,085.2	0.7	1.5	1	1	1
07/03/2024 12:00	0.7	11.9	2,092.6	0.7	1.5	1	1	1
07/03/2024 13:00	0.7	11.8	2,091.2	0.7	1.5	1	1	1
07/03/2024 14:00	0.7	11.8	2,093.7	0.7	1.5	1	1	1
07/03/2024 15:00	0.7	11.8	2,103.4	0.7	1.5	1	1	1
07/03/2024 16:00	0.7	12.0	2,045.5	0.7	1.4	1	1	1
07/03/2024 17:00	0.7	12.0	2,046.1	0.7	1.4	1	1	1
07/03/2024 18:00	0.7	11.9	2,060.8	0.7	1.4	1	1	1
07/03/2024 19:00	0.7	11.9	2,080.4	0.7	1.5	1	1	1
07/03/2024 20:00	0.7	11.9	2,077.8	0.7	1.5	1	1	1
07/03/2024 21:00	0.7	12.0	2,070.5	0.7	1.4	1	1	1
07/03/2024 22:00	0.7	12.1	2,065.4	0.7	1.4	1	1	1
07/03/2024 23:00	0.7	12.1	2,052.6	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.0	2,079.3	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.5	2,042.7	0.7	1.4	1	1	1
Maximum:	0.7	12.3	2,201.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2024 00:00	0.7	12.4	2,015.8	0.7	1.4	1	1	1
07/04/2024 01:00	0.7	12.4	1,983.5	0.7	1.4	1	1	1
07/04/2024 02:00	0.0	15.4	660.6	0.0	0.5	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 09:00	0.0	17.4	344.7	0.0	0.2	1	0	0
07/04/2024 10:00	0.0	14.9	1,019.5	0.0	0.7	1	0	0
07/04/2024 11:00	0.6	13.7	1,605.0	0.6	1.1	1	1	0
07/04/2024 12:00	0.6	13.7	1,595.7	0.6	1.1	1	1	0
07/04/2024 13:00	0.6	13.7	1,553.2	0.6	1.1	1	1	0
07/04/2024 14:00	0.6	13.8	1,453.0	0.6	1.0	1	1	0
07/04/2024 15:00	0.6	13.7	1,524.6	0.6	1.1	1	1	0
07/04/2024 16:00	0.6	13.5	1,694.9	0.6	1.2	1	1	0
07/04/2024 17:00	0.7	12.6	1,830.7	0.7	1.3	1	1	1
07/04/2024 18:00	0.7	11.5	2,157.8	0.7	1.5	1	1	1
07/04/2024 19:00	0.7	11.7	2,124.4	0.7	1.5	1	1	1
07/04/2024 20:00	0.7	11.9	2,071.3	0.7	1.4	1	1	1
07/04/2024 21:00	0.7	12.0	2,062.4	0.7	1.4	1	1	1
07/04/2024 22:00	0.7	12.1	2,043.0	0.7	1.4	1	1	1
07/04/2024 23:00	0.7	12.2	2,010.4	0.7	1.4	1	1	1
Average/Sum#:	0.6	13.3	1,652.8	0.6	1.2	18 #	15 #	9 #
Minimum:	0.0	11.5	344.7	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,157.8	0.7	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2024 00:00	0.6	13.6	1,719.5	0.6	1.2	1	1	0
07/05/2024 01:00	0.6	13.6	1,712.9	0.6	1.2	1	1	0
07/05/2024 02:00	0.6	13.6	1,705.4	0.6	1.2	1	1	0
07/05/2024 03:00	0.6	13.6	1,730.6	0.6	1.2	1	1	0
07/05/2024 04:00	0.6	13.7	1,619.1	0.6	1.1	1	1	0
07/05/2024 05:00	0.6	13.6	1,652.1	0.6	1.2	1	1	0
07/05/2024 06:00	0.6	13.5	1,747.9	0.6	1.2	1	1	0
07/05/2024 07:00	0.6	13.5	1,746.9	0.6	1.2	1	1	0
07/05/2024 08:00	0.6	13.5	1,751.1	0.6	1.2	1	1	0
07/05/2024 09:00	0.6	13.4	1,750.7	0.6	1.2	1	1	0
07/05/2024 10:00	0.6	13.4	1,736.4	0.6	1.2	1	1	0
07/05/2024 11:00	0.6	13.5	1,730.8	0.6	1.2	1	1	0
07/05/2024 12:00	0.6	13.6	1,557.8	0.6	1.1	1	1	0
07/05/2024 13:00	0.7	12.6	1,816.1	0.7	1.3	1	1	1
07/05/2024 14:00	0.7	11.3	2,142.7	0.7	1.5	1	1	1
07/05/2024 15:00	0.7	11.4	2,122.2	0.7	1.5	1	1	1
07/05/2024 16:00	0.7	11.4	2,121.9	0.7	1.5	1	1	1
07/05/2024 17:00	0.7	11.4	2,122.1	0.7	1.5	1	1	1
07/05/2024 18:00	0.7	11.5	2,117.9	0.7	1.5	1	1	1
07/05/2024 19:00	0.7	11.5	2,126.4	0.7	1.5	1	1	1
07/05/2024 20:00	0.7	11.6	2,122.8	0.7	1.5	1	1	1
07/05/2024 21:00	0.7	11.5	2,178.0	0.7	1.5	1	1	1
07/05/2024 22:00	0.7	11.5	2,133.1	0.7	1.5	1	1	1
07/05/2024 23:00	0.7	12.0	2,062.9	0.7	1.4	1	1	1
Average/Sum#:	0.6	12.7	1,884.5	0.6	1.3	24 #	24 #	11 #
Minimum:	0.6	11.3	1,557.8	0.6	1.1	1	1	0
Maximum:	0.7	13.7	2,178.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2024 00:00	0.7	12.2	2,034.0	0.7	1.4	1	1	1
07/06/2024 01:00	0.7	12.3	2,018.6	0.7	1.4	1	1	1
07/06/2024 02:00	0.7	12.3	2,018.6	0.7	1.4	1	1	1
07/06/2024 03:00	0.7	12.3	2,023.5	0.7	1.4	1	1	1
07/06/2024 04:00	0.7	12.4	2,017.8	0.7	1.4	1	1	1
07/06/2024 05:00	0.7	12.2	2,010.1	0.7	1.4	1	1	1
07/06/2024 06:00	0.0	15.4	620.4	0.0	0.4	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 09:00	0.0	18.5	172.5	0.0	0.1	1	0	0
07/06/2024 10:00	0.0	15.3	859.8	0.0	0.6	1	0	0
07/06/2024 11:00	0.6	13.7	1,588.0	0.6	1.1	1	1	0
07/06/2024 12:00	0.6	13.6	1,610.6	0.6	1.1	1	1	0
07/06/2024 13:00	0.6	13.6	1,589.9	0.6	1.1	1	1	0
07/06/2024 14:00	0.6	13.7	1,452.7	0.6	1.0	1	1	0
07/06/2024 15:00	0.6	13.8	1,443.1	0.6	1.0	1	1	0
07/06/2024 16:00	0.7	13.6	1,555.0	0.7	1.1	1	1	1
07/06/2024 17:00	0.7	11.7	2,101.9	0.7	1.5	1	1	1
07/06/2024 18:00	0.7	11.4	2,123.7	0.7	1.5	1	1	1
07/06/2024 19:00	0.7	11.4	2,114.9	0.7	1.5	1	1	1
07/06/2024 20:00	0.7	11.5	2,116.9	0.7	1.5	1	1	1
07/06/2024 21:00	0.7	11.6	2,114.7	0.7	1.5	1	1	1
07/06/2024 22:00	0.7	11.6	2,111.9	0.7	1.5	1	1	1
07/06/2024 23:00	0.7	11.4	2,159.0	0.7	1.5	1	1	1
Average/Sum#:	0.6	13.0	1,720.8	0.6	1.2	22 #	19 #	14 #
Minimum:	0.0	11.4	172.5	0.0	0.1	0	0	0
Maximum:	0.7	18.5	2,159.0	0.7	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2024 00:00	0.7	11.9	2,078.6	0.7	1.5	1	1	1
07/07/2024 01:00	0.7	12.1	2,025.5	0.7	1.4	1	1	1
07/07/2024 02:00	0.7	12.1	2,005.2	0.7	1.4	1	1	1
07/07/2024 03:00	0.0	15.5	610.6	0.0	0.4	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 15:00	0.0	17.8	271.0	0.0	0.2	1	0	0
07/07/2024 16:00	0.0	15.6	735.6	0.0	0.5	1	0	0
07/07/2024 17:00	0.6	13.7	1,377.6	0.6	1.0	1	1	0
07/07/2024 18:00	0.7	13.0	1,701.9	0.7	1.2	1	1	1
07/07/2024 19:00	0.7	11.3	2,119.6	0.7	1.5	1	1	1
07/07/2024 20:00	0.7	11.3	2,143.1	0.7	1.5	1	1	1
07/07/2024 21:00	0.7	11.7	2,063.9	0.7	1.4	1	1	1
07/07/2024 22:00	0.7	11.9	2,039.6	0.7	1.4	1	1	1
07/07/2024 23:00	0.7	11.7	2,103.3	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.0	1,636.6	0.5	1.1	13 #	10 #	9 #
Minimum:	0.0	11.3	271.0	0.0	0.2	0	0	0
Maximum:	0.7	17.8	2,143.1	0.7	1.5	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2024 00:00	0.6	13.5	1,717.6	0.6	1.2	1	1	0
07/08/2024 01:00	0.6	13.6	1,702.2	0.6	1.2	1	1	0
07/08/2024 02:00	0.6	13.6	1,705.4	0.6	1.2	1	1	0
07/08/2024 03:00	0.6	13.6	1,706.4	0.6	1.2	1	1	0
07/08/2024 04:00	0.6	13.5	1,731.9	0.6	1.2	1	1	0
07/08/2024 05:00	0.6	13.5	1,749.9	0.6	1.2	1	1	0
07/08/2024 06:00	0.6	13.5	1,731.8	0.6	1.2	1	1	0
07/08/2024 07:00	0.6	13.5	1,719.5	0.6	1.2	1	1	0
07/08/2024 08:00	0.6	13.5	1,722.0	0.6	1.2	1	1	0
07/08/2024 09:00	0.6	13.5	1,716.9	0.6	1.2	1	1	0
07/08/2024 10:00	0.6	13.4	1,732.5	0.6	1.2	1	1	0
07/08/2024 11:00	0.6	13.4	1,727.4	0.6	1.2	1	1	0
07/08/2024 12:00	0.6	13.4	1,709.4	0.6	1.2	1	1	0
07/08/2024 13:00	0.6	13.6	1,598.9	0.6	1.1	1	1	0
07/08/2024 14:00	0.6	13.5	1,650.3	0.6	1.2	1	1	0
07/08/2024 15:00	0.6	13.5	1,681.4	0.6	1.2	1	1	0
07/08/2024 16:00	0.7	13.5	1,591.2	0.7	1.1	1	1	1
07/08/2024 17:00	0.7	11.5	2,114.4	0.7	1.5	1	1	1
07/08/2024 18:00	0.7	11.3	2,147.5	0.7	1.5	1	1	1
07/08/2024 19:00	0.7	11.3	2,158.8	0.7	1.5	1	1	1
07/08/2024 20:00	0.7	11.4	2,166.7	0.7	1.5	1	1	1
07/08/2024 21:00	0.7	11.4	2,175.4	0.7	1.5	1	1	1
07/08/2024 22:00	0.7	11.5	2,170.3	0.7	1.5	1	1	1
07/08/2024 23:00	0.7	11.4	2,194.7	0.7	1.5	1	1	1
Average/Sum#:	0.6	12.9	1,834.3	0.6	1.3	24 #	24 #	8 #
Minimum:	0.6	11.3	1,591.2	0.6	1.1	1	1	0
Maximum:	0.7	13.6	2,194.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2024 00:00	0.7	11.4	2,201.1	0.7	1.5	1	1	1
07/09/2024 01:00	0.7	11.4	2,209.0	0.7	1.5	1	1	1
07/09/2024 02:00	0.7	11.5	2,212.1	0.7	1.5	1	1	1
07/09/2024 03:00	0.7	11.5	2,210.7	0.7	1.5	1	1	1
07/09/2024 04:00	0.7	11.4	2,223.5	0.7	1.6	1	1	1
07/09/2024 05:00	0.7	11.5	2,209.9	0.7	1.5	1	1	1
07/09/2024 06:00	0.7	12.2	2,046.0	0.7	1.4	1	1	1
07/09/2024 07:00	0.7	12.3	2,016.4	0.7	1.4	1	1	1
07/09/2024 08:00	0.7	11.7	2,152.5	0.7	1.5	1	1	1
07/09/2024 09:00	0.7	0.0	2,124.2	0.7	1.5	1	1	1
07/09/2024 10:00	0.7	0.0	2,136.7	0.7	1.5	1	1	1
07/09/2024 11:00	0.7	0.0	2,175.7	0.7	1.5	1	1	1
07/09/2024 12:00	0.7	11.4	2,173.4	0.7	1.5	1	1	1
07/09/2024 13:00	0.7	11.4	2,169.4	0.7	1.5	1	1	1
07/09/2024 14:00	0.7	11.4	2,159.9	0.7	1.5	1	1	1
07/09/2024 15:00	0.7	11.4	2,161.0	0.7	1.5	1	1	1
07/09/2024 16:00	0.7	11.4	2,164.4	0.7	1.5	1	1	1
07/09/2024 17:00	0.7	11.4	2,160.6	0.7	1.5	1	1	1
07/09/2024 18:00	0.7	11.5	2,139.0	0.7	1.5	1	1	1
07/09/2024 19:00	0.7	11.3	2,162.4	0.7	1.5	1	1	1
07/09/2024 20:00	0.7	11.3	2,172.2	0.7	1.5	1	1	1
07/09/2024 21:00	0.7	11.4	2,179.5	0.7	1.5	1	1	1
07/09/2024 22:00	0.7	11.5	2,167.2	0.7	1.5	1	1	1
07/09/2024 23:00	0.7	11.9	2,082.2	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.5	2,158.7	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.3	2,016.4	0.7	1.4	1	1	1
Maximum:	0.7	12.3	2,223.5	0.7	1.6	1	1	1
%SI	12.50	12.50	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2024 00:00	0.7	12.1	2,071.6	0.7	1.5	1	1	1
07/10/2024 01:00	0.7	11.4	2,209.7	0.7	1.5	1	1	1
07/10/2024 02:00	0.7	11.4	2,215.1	0.7	1.6	1	1	1
07/10/2024 03:00	0.7	11.4	2,214.6	0.7	1.6	1	1	1
07/10/2024 04:00	0.7	11.4	2,214.7	0.7	1.6	1	1	1
07/10/2024 05:00	0.7	11.6	2,182.7	0.7	1.5	1	1	1
07/10/2024 06:00	0.7	12.1	2,056.9	0.7	1.4	1	1	1
07/10/2024 07:00	0.7	12.2	2,008.5	0.7	1.4	1	1	1
07/10/2024 08:00	0.7	12.2	2,015.7	0.7	1.4	1	1	1
07/10/2024 09:00	0.7	12.1	2,027.7	0.7	1.4	1	1	1
07/10/2024 10:00	0.7	11.9	2,045.3	0.7	1.4	1	1	1
07/10/2024 11:00	0.7	11.7	2,078.9	0.7	1.5	1	1	1
07/10/2024 12:00	0.7	11.6	2,098.7	0.7	1.5	1	1	1
07/10/2024 13:00	0.7	11.4	2,150.6	0.7	1.5	1	1	1
07/10/2024 14:00	0.7	11.4	2,156.0	0.7	1.5	1	1	1
07/10/2024 15:00	0.7	11.5	2,135.6	0.7	1.5	1	1	1
07/10/2024 16:00	0.7	11.5	2,120.3	0.7	1.5	1	1	1
07/10/2024 17:00	0.7	11.5	2,110.8	0.7	1.5	1	1	1
07/10/2024 18:00	0.7	11.3	2,143.6	0.7	1.5	1	1	1
07/10/2024 19:00	0.7	11.3	2,152.8	0.7	1.5	1	1	1
07/10/2024 20:00	0.7	11.3	2,157.7	0.7	1.5	1	1	1
07/10/2024 21:00	0.7	11.3	2,166.8	0.7	1.5	1	1	1
07/10/2024 22:00	0.7	11.4	2,167.7	0.7	1.5	1	1	1
07/10/2024 23:00	0.7	11.4	2,170.8	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.6	2,128.0	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.3	2,008.5	0.7	1.4	1	1	1
Maximum:	0.7	12.2	2,215.1	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2024 00:00	0.7	11.5	2,148.4	0.7	1.5	1	1	1
07/11/2024 01:00	0.7	11.6	2,132.0	0.7	1.5	1	1	1
07/11/2024 02:00	0.7	11.7	2,104.5	0.7	1.5	1	1	1
07/11/2024 03:00	0.7	12.0	2,063.2	0.7	1.4	1	1	1
07/11/2024 04:00	0.7	11.4	2,186.3	0.7	1.5	1	1	1
07/11/2024 05:00	0.7	12.2	2,018.9	0.7	1.4	1	1	1
07/11/2024 06:00	0.6	13.5	1,721.5	0.6	1.2	1	1	0
07/11/2024 07:00	0.6	13.5	1,712.4	0.6	1.2	1	1	0
07/11/2024 08:00	0.6	13.6	1,549.8	0.6	1.1	1	1	0
07/11/2024 09:00	0.6	13.7	1,508.7	0.6	1.1	1	1	0
07/11/2024 10:00	0.6	13.6	1,640.7	0.6	1.1	1	1	0
07/11/2024 11:00	0.6	13.7	1,471.1	0.6	1.0	1	1	0
07/11/2024 12:00	0.6	13.6	1,600.7	0.6	1.1	1	1	0
07/11/2024 13:00	0.6	13.6	1,595.5	0.6	1.1	1	1	0
07/11/2024 14:00	0.6	13.7	1,570.1	0.6	1.1	1	1	0
07/11/2024 15:00	0.6	13.8	1,331.3	0.6	0.9	1	1	0
07/11/2024 16:00	0.6	13.8	1,334.0	0.6	0.9	1	1	0
07/11/2024 17:00	0.7	12.7	1,752.1	0.7	1.2	1	1	1
07/11/2024 18:00	0.7	11.4	2,125.2	0.7	1.5	1	1	1
07/11/2024 19:00	0.7	11.3	2,128.4	0.7	1.5	1	1	1
07/11/2024 20:00	0.7	11.6	2,088.7	0.7	1.5	1	1	1
07/11/2024 21:00	0.7	11.8	2,059.2	0.7	1.4	1	1	1
07/11/2024 22:00	0.7	11.4	2,160.1	0.7	1.5	1	1	1
07/11/2024 23:00	0.7	11.8	2,099.4	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.6	1,837.6	0.7	1.3	24 #	24 #	13 #
Minimum:	0.6	11.3	1,331.3	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,186.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2024 00:00	0.7	11.8	2,092.0	0.7	1.5	1	1	1
07/12/2024 01:00	0.7	11.8	2,098.3	0.7	1.5	1	1	1
07/12/2024 02:00	0.7	12.0	2,067.1	0.7	1.4	1	1	1
07/12/2024 03:00	0.7	11.5	2,184.5	0.7	1.5	1	1	1
07/12/2024 04:00	0.7	11.8	2,128.6	0.7	1.5	1	1	1
07/12/2024 05:00	0.7	11.9	2,109.3	0.7	1.5	1	1	1
07/12/2024 06:00	0.6	13.5	1,739.2	0.6	1.2	1	1	0
07/12/2024 07:00	0.6	13.6	1,545.3	0.6	1.1	1	1	0
07/12/2024 08:00	0.6	13.7	1,477.4	0.6	1.0	1	1	0
07/12/2024 09:00	0.6	13.7	1,483.1	0.6	1.0	1	1	0
07/12/2024 10:00	0.6	13.7	1,509.1	0.6	1.1	1	1	0
07/12/2024 11:00	0.6	13.8	1,434.6	0.6	1.0	1	1	0
07/12/2024 12:00	0.6	13.7	1,477.4	0.6	1.0	1	1	0
07/12/2024 13:00	0.6	13.8	1,341.1	0.6	0.9	1	1	0
07/12/2024 14:00	0.6	13.7	1,355.7	0.6	0.9	1	1	0
07/12/2024 15:00	0.6	13.8	1,357.1	0.6	0.9	1	1	0
07/12/2024 16:00	0.6	13.8	1,342.4	0.6	0.9	1	1	0
07/12/2024 17:00	0.6	13.8	1,343.3	0.6	0.9	1	1	0
07/12/2024 18:00	0.6	13.7	1,332.5	0.6	0.9	1	1	0
07/12/2024 19:00	0.6	13.7	1,328.8	0.6	0.9	1	1	0
07/12/2024 20:00	0.6	13.7	1,329.0	0.6	0.9	1	1	0
07/12/2024 21:00	0.6	13.5	1,639.5	0.6	1.1	1	1	0
07/12/2024 22:00	0.6	13.4	1,725.0	0.6	1.2	1	1	0
07/12/2024 23:00	0.6	13.4	1,725.0	0.6	1.2	1	1	0
Average/Sum#:	0.6	13.2	1,631.9	0.6	1.1	24 #	24 #	6 #
Minimum:	0.6	11.5	1,328.8	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,184.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2024 00:00	0.6	13.4	1,725.6	0.6	1.2	1	1	0
07/13/2024 01:00	0.6	13.4	1,726.2	0.6	1.2	1	1	0
07/13/2024 02:00	0.6	13.4	1,737.2	0.6	1.2	1	1	0
07/13/2024 03:00	0.6	13.4	1,744.1	0.6	1.2	1	1	0
07/13/2024 04:00	0.6	13.5	1,721.5	0.6	1.2	1	1	0
07/13/2024 05:00	0.6	13.4	1,744.4	0.6	1.2	1	1	0
07/13/2024 06:00	0.6	13.5	1,708.0	0.6	1.2	1	1	0
07/13/2024 07:00	0.6	13.5	1,725.5	0.6	1.2	1	1	0
07/13/2024 08:00	0.6	13.5	1,711.4	0.6	1.2	1	1	0
07/13/2024 09:00	0.6	13.6	1,563.0	0.6	1.1	1	1	0
07/13/2024 10:00	0.6	13.7	1,561.4	0.6	1.1	1	1	0
07/13/2024 11:00	0.6	13.6	1,633.6	0.6	1.1	1	1	0
07/13/2024 12:00	0.6	13.6	1,651.9	0.6	1.2	1	1	0
07/13/2024 13:00	0.6	13.7	1,379.5	0.6	1.0	1	1	0
07/13/2024 14:00	0.6	13.7	1,324.3	0.6	0.9	1	1	0
07/13/2024 15:00	0.6	13.7	1,329.3	0.6	0.9	1	1	0
07/13/2024 16:00	0.6	13.7	1,324.6	0.6	0.9	1	1	0
07/13/2024 17:00	0.6	13.7	1,334.7	0.6	0.9	1	1	0
07/13/2024 18:00	0.6	13.7	1,329.5	0.6	0.9	1	1	0
07/13/2024 19:00	0.6	13.7	1,467.5	0.6	1.0	1	1	0
07/13/2024 20:00	0.6	13.4	1,720.8	0.6	1.2	1	1	0
07/13/2024 21:00	0.6	13.5	1,722.0	0.6	1.2	1	1	0
07/13/2024 22:00	0.6	13.5	1,734.9	0.6	1.2	1	1	0
07/13/2024 23:00	0.6	13.5	1,740.4	0.6	1.2	1	1	0
Average/Sum#:	0.6	13.6	1,598.4	0.6	1.1	24 #	24 #	0 #
Minimum:	0.6	13.4	1,324.3	0.6	0.9	1	1	0
Maximum:	0.6	13.7	1,744.4	0.6	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2024 00:00	0.6	13.5	1,750.7	0.6	1.2	1	1	0
07/14/2024 01:00	0.6	13.6	1,652.7	0.6	1.2	1	1	0
07/14/2024 02:00	0.0	14.6	1,043.8	0.0	0.7	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 10:00	0.0	17.6	326.4	0.0	0.2	1	0	0
07/14/2024 11:00	0.0	15.4	822.1	0.0	0.6	1	0	0
07/14/2024 12:00	0.6	13.6	1,552.1	0.6	1.1	1	1	0
07/14/2024 13:00	0.6	13.6	1,568.5	0.6	1.1	1	1	0
07/14/2024 14:00	0.6	13.6	1,695.5	0.6	1.2	1	1	0
07/14/2024 15:00	0.6	13.6	1,539.7	0.6	1.1	1	1	0
07/14/2024 16:00	0.6	13.6	1,688.4	0.6	1.2	1	1	0
07/14/2024 17:00	0.7	13.5	1,709.3	0.7	1.2	1	1	1
07/14/2024 18:00	0.7	11.6	2,130.9	0.7	1.5	1	1	1
07/14/2024 19:00	0.7	11.3	2,176.2	0.7	1.5	1	1	1
07/14/2024 20:00	0.7	11.4	2,170.4	0.7	1.5	1	1	1
07/14/2024 21:00	0.7	11.4	2,173.9	0.7	1.5	1	1	1
07/14/2024 22:00	0.7	11.8	2,081.9	0.7	1.5	1	1	1
07/14/2024 23:00	0.7	12.1	2,007.6	0.7	1.4	1	1	1
Average/Sum#:	0.5	13.3	1,652.4	0.5	1.2	17 #	14 #	7 #
Minimum:	0.0	11.3	326.4	0.0	0.2	0	0	0
Maximum:	0.7	17.6	2,176.2	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2024 00:00	0.6	13.5	1,719.3	0.6	1.2	1	1	0
07/15/2024 01:00	0.6	13.5	1,728.6	0.6	1.2	1	1	0
07/15/2024 02:00	0.6	13.6	1,619.4	0.6	1.1	1	1	0
07/15/2024 03:00	0.6	13.6	1,712.9	0.6	1.2	1	1	0
07/15/2024 04:00	0.6	13.5	1,750.5	0.6	1.2	1	1	0
07/15/2024 05:00	0.6	13.6	1,716.8	0.6	1.2	1	1	0
07/15/2024 06:00	0.6	13.6	1,699.3	0.6	1.2	1	1	0
07/15/2024 07:00	0.6	13.6	1,711.6	0.6	1.2	1	1	0
07/15/2024 08:00	0.6	13.6	1,548.1	0.6	1.1	1	1	0
07/15/2024 09:00	0.6	13.7	1,480.1	0.6	1.0	1	1	0
07/15/2024 10:00	0.6	13.7	1,621.5	0.6	1.1	1	1	0
07/15/2024 11:00	0.6	13.5	1,706.0	0.6	1.2	1	1	0
07/15/2024 12:00	0.6	13.7	1,661.6	0.6	1.2	1	1	0
07/15/2024 13:00	0.6	13.6	1,669.1	0.6	1.2	1	1	0
07/15/2024 14:00	0.6	13.6	1,664.0	0.6	1.2	1	1	0
07/15/2024 15:00	0.6	13.7	1,590.6	0.6	1.1	1	1	0
07/15/2024 16:00	0.6	13.6	1,573.9	0.6	1.1	1	1	0
07/15/2024 17:00	0.7	12.9	1,738.3	0.7	1.2	1	1	1
07/15/2024 18:00	0.7	11.5	2,141.4	0.7	1.5	1	1	1
07/15/2024 19:00	0.7	11.4	2,179.4	0.7	1.5	1	1	1
07/15/2024 20:00	0.7	11.5	2,175.5	0.7	1.5	1	1	1
07/15/2024 21:00	0.7	11.7	2,137.3	0.7	1.5	1	1	1
07/15/2024 22:00	0.7	12.5	2,008.1	0.7	1.4	1	1	1
07/15/2024 23:00	0.7	12.4	1,992.6	0.7	1.4	1	1	1
Average/Sum#:	0.6	13.1	1,772.7	0.6	1.2	24 #	24 #	7 #
Minimum:	0.6	11.4	1,480.1	0.6	1.0	1	1	0
Maximum:	0.7	13.7	2,179.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2024 00:00	0.7	13.5	1,728.4	0.7	1.2	1	1	1
07/16/2024 01:00	0.6	13.6	1,737.0	0.6	1.2	1	1	0
07/16/2024 02:00	0.6	13.6	1,744.1	0.6	1.2	1	1	0
07/16/2024 03:00	0.6	13.6	1,748.5	0.6	1.2	1	1	0
07/16/2024 04:00	0.6	13.6	1,745.4	0.6	1.2	1	1	0
07/16/2024 05:00	0.6	13.6	1,708.7	0.6	1.2	1	1	0
07/16/2024 06:00	0.6	13.6	1,689.8	0.6	1.2	1	1	0
07/16/2024 07:00	0.6	13.6	1,721.6	0.6	1.2	1	1	0
07/16/2024 08:00	0.6	13.6	1,600.4	0.6	1.1	1	1	0
07/16/2024 09:00	0.6	13.6	1,619.4	0.6	1.1	1	1	0
07/16/2024 10:00	0.6	13.6	1,659.0	0.6	1.2	1	1	0
07/16/2024 11:00	0.6	13.6	1,709.7	0.6	1.2	1	1	0
07/16/2024 12:00	0.6	13.6	1,643.1	0.6	1.2	1	1	0
07/16/2024 13:00	0.6	13.6	1,538.8	0.6	1.1	1	1	0
07/16/2024 14:00	0.6	13.8	1,325.2	0.6	0.9	1	1	0
07/16/2024 15:00	0.7	13.7	1,500.1	0.7	1.1	1	1	1
07/16/2024 16:00	0.7	11.9	2,081.4	0.7	1.5	1	1	1
07/16/2024 17:00	0.7	11.6	2,154.2	0.7	1.5	1	1	1
07/16/2024 18:00	0.7	11.5	2,202.4	0.7	1.5	1	1	1
07/16/2024 19:00	0.7	11.5	2,205.6	0.7	1.5	1	1	1
07/16/2024 20:00	0.7	11.4	2,212.3	0.7	1.5	1	1	1
07/16/2024 21:00	0.7	11.4	2,221.4	0.7	1.6	1	1	1
07/16/2024 22:00	0.7	11.6	2,207.6	0.7	1.5	1	1	1
07/16/2024 23:00	0.7	12.1	2,083.5	0.7	1.5	1	1	1
Average/Sum#:	0.6	13.0	1,824.5	0.6	1.3	24 #	24 #	10 #
Minimum:	0.6	11.4	1,325.2	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,221.4	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2024 00:00	0.7	12.4	2,046.5	0.7	1.4	1	1	1
07/17/2024 01:00	0.7	13.4	1,702.4	0.7	1.2	1	1	1
07/17/2024 02:00	0.6	13.7	1,718.8	0.6	1.2	1	1	0
07/17/2024 03:00	0.6	13.7	1,744.2	0.6	1.2	1	1	0
07/17/2024 04:00	0.6	13.7	1,739.9	0.6	1.2	1	1	0
07/17/2024 05:00	0.6	13.7	1,660.3	0.6	1.2	1	1	0
07/17/2024 06:00	0.6	13.6	1,707.4	0.6	1.2	1	1	0
07/17/2024 07:00	0.6	13.6	1,738.5	0.6	1.2	1	1	0
07/17/2024 08:00	0.6	13.6	1,705.4	0.6	1.2	1	1	0
07/17/2024 09:00	0.6	13.6	1,623.0	0.6	1.1	1	1	0
07/17/2024 10:00	0.6	13.7	1,429.3	0.6	1.0	1	1	0
07/17/2024 11:00	0.6	13.7	1,432.0	0.6	1.0	1	1	0
07/17/2024 12:00	0.6	13.7	1,542.8	0.6	1.1	1	1	0
07/17/2024 13:00	0.6	13.8	1,479.4	0.6	1.0	1	1	0
07/17/2024 14:00	0.7	13.7	1,578.9	0.7	1.1	1	1	1
07/17/2024 15:00	0.7	12.0	2,098.2	0.7	1.5	1	1	1
07/17/2024 16:00	0.7	12.1	2,074.2	0.7	1.5	1	1	1
07/17/2024 17:00	0.7	11.9	2,120.2	0.7	1.5	1	1	1
07/17/2024 18:00	0.7	11.5	2,193.1	0.7	1.5	1	1	1
07/17/2024 19:00	0.7	11.5	2,200.0	0.7	1.5	1	1	1
07/17/2024 20:00	0.7	11.5	2,200.7	0.7	1.5	1	1	1
07/17/2024 21:00	0.7	11.5	2,200.2	0.7	1.5	1	1	1
07/17/2024 22:00	0.7	11.5	2,200.5	0.7	1.5	1	1	1
07/17/2024 23:00	0.7	11.6	2,193.3	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.9	1,847.1	0.7	1.3	24 #	24 #	12 #
Minimum:	0.6	11.5	1,429.3	0.6	1.0	1	1	0
Maximum:	0.7	13.8	2,200.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2024 00:00	0.7	12.2	2,053.3	0.7	1.4	1	1	1
07/18/2024 01:00	0.7	12.2	2,071.4	0.7	1.4	1	1	1
07/18/2024 02:00	0.7	11.6	2,202.4	0.7	1.5	1	1	1
07/18/2024 03:00	0.7	11.7	2,190.2	0.7	1.5	1	1	1
07/18/2024 04:00	0.7	11.6	2,210.8	0.7	1.5	1	1	1
07/18/2024 05:00	0.7	12.0	2,153.0	0.7	1.5	1	1	1
07/18/2024 06:00	0.7	12.2	2,058.3	0.7	1.4	1	1	1
07/18/2024 07:00	0.7	12.4	2,004.0	0.7	1.4	1	1	1
07/18/2024 08:00	0.7	12.2	2,051.2	0.7	1.4	1	1	1
07/18/2024 09:00	0.7	11.8	2,136.8	0.7	1.5	1	1	1
07/18/2024 10:00	0.7	11.7	2,139.9	0.7	1.5	1	1	1
07/18/2024 11:00	0.7	11.7	2,147.8	0.7	1.5	1	1	1
07/18/2024 12:00	0.7	11.8	2,110.0	0.7	1.5	1	1	1
07/18/2024 13:00	0.7	11.5	2,171.4	0.7	1.5	1	1	1
07/18/2024 14:00	0.7	11.5	2,166.6	0.7	1.5	1	1	1
07/18/2024 15:00	0.7	11.5	2,169.0	0.7	1.5	1	1	1
07/18/2024 16:00	0.7	11.5	2,162.4	0.7	1.5	1	1	1
07/18/2024 17:00	0.7	11.5	2,159.3	0.7	1.5	1	1	1
07/18/2024 18:00	0.7	11.5	2,161.1	0.7	1.5	1	1	1
07/18/2024 19:00	0.7	11.4	2,166.4	0.7	1.5	1	1	1
07/18/2024 20:00	0.7	11.5	2,174.2	0.7	1.5	1	1	1
07/18/2024 21:00	0.7	11.5	2,178.2	0.7	1.5	1	1	1
07/18/2024 22:00	0.7	11.5	2,192.1	0.7	1.5	1	1	1
07/18/2024 23:00	0.7	11.7	2,149.0	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.7	2,140.8	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.4	2,004.0	0.7	1.4	1	1	1
Maximum:	0.7	12.4	2,210.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2024 00:00	0.7	11.9	2,123.2	0.7	1.5	1	1	1
07/19/2024 01:00	0.7	12.0	2,102.5	0.7	1.5	1	1	1
07/19/2024 02:00	0.7	11.9	2,124.3	0.7	1.5	1	1	1
07/19/2024 03:00	0.7	12.3	2,029.2	0.7	1.4	1	1	1
07/19/2024 04:00	0.7	11.6	2,203.1	0.7	1.5	1	1	1
07/19/2024 05:00	0.7	12.2	2,105.2	0.7	1.5	1	1	1
07/19/2024 06:00	0.7	13.6	1,738.3	0.7	1.2	1	1	1
07/19/2024 07:00	0.6	13.5	1,744.8	0.6	1.2	1	1	0
07/19/2024 08:00	0.6	13.6	1,746.1	0.6	1.2	1	1	0
07/19/2024 09:00	0.6	13.5	1,747.1	0.6	1.2	1	1	0
07/19/2024 10:00	0.6	13.5	1,746.7	0.6	1.2	1	1	0
07/19/2024 11:00	0.6	13.4	1,745.0	0.6	1.2	1	1	0
07/19/2024 12:00	0.7	13.4	1,733.6	0.7	1.2	1	1	1
07/19/2024 13:00	0.7	11.6	2,137.4	0.7	1.5	1	1	1
07/19/2024 14:00	0.7	11.5	2,156.4	0.7	1.5	1	1	1
07/19/2024 15:00	0.7	11.5	2,160.5	0.7	1.5	1	1	1
07/19/2024 16:00	0.7	11.5	2,162.0	0.7	1.5	1	1	1
07/19/2024 17:00	0.7	11.4	2,157.7	0.7	1.5	1	1	1
07/19/2024 18:00	0.7	11.4	2,160.6	0.7	1.5	1	1	1
07/19/2024 19:00	0.7	11.4	2,160.1	0.7	1.5	1	1	1
07/19/2024 20:00	0.7	11.5	2,168.1	0.7	1.5	1	1	1
07/19/2024 21:00	0.7	11.6	2,168.2	0.7	1.5	1	1	1
07/19/2024 22:00	0.7	11.5	2,181.6	0.7	1.5	1	1	1
07/19/2024 23:00	0.7	11.5	2,192.9	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.2	2,028.9	0.7	1.4	24 #	24 #	19 #
Minimum:	0.6	11.4	1,733.6	0.6	1.2	1	1	0
Maximum:	0.7	13.6	2,203.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2024 00:00	0.7	11.5	2,188.1	0.7	1.5	1	1	1
07/20/2024 01:00	0.7	11.5	2,200.5	0.7	1.5	1	1	1
07/20/2024 02:00	0.7	11.5	2,200.9	0.7	1.5	1	1	1
07/20/2024 03:00	0.7	11.5	2,203.6	0.7	1.5	1	1	1
07/20/2024 04:00	0.7	11.5	2,206.0	0.7	1.5	1	1	1
07/20/2024 05:00	0.7	12.0	2,135.5	0.7	1.5	1	1	1
07/20/2024 06:00	0.7	13.6	1,705.8	0.7	1.2	1	1	1
07/20/2024 07:00	0.6	13.6	1,730.8	0.6	1.2	1	1	0
07/20/2024 08:00	0.6	13.7	1,570.4	0.6	1.1	1	1	0
07/20/2024 09:00	0.6	13.6	1,604.3	0.6	1.1	1	1	0
07/20/2024 10:00	0.6	13.5	1,707.7	0.6	1.2	1	1	0
07/20/2024 11:00	0.6	13.5	1,621.4	0.6	1.1	1	1	0
07/20/2024 12:00	0.6	13.8	1,340.6	0.6	0.9	1	1	0
07/20/2024 13:00	0.7	13.6	1,639.5	0.7	1.1	1	1	1
07/20/2024 14:00	0.7	11.5	2,133.8	0.7	1.5	1	1	1
07/20/2024 15:00	0.7	11.4	2,153.1	0.7	1.5	1	1	1
07/20/2024 16:00	0.7	11.4	2,151.3	0.7	1.5	1	1	1
07/20/2024 17:00	0.7	11.4	2,146.4	0.7	1.5	1	1	1
07/20/2024 18:00	0.7	11.4	2,154.5	0.7	1.5	1	1	1
07/20/2024 19:00	0.7	11.4	2,156.5	0.7	1.5	1	1	1
07/20/2024 20:00	0.7	11.4	2,156.9	0.7	1.5	1	1	1
07/20/2024 21:00	0.7	11.5	2,159.1	0.7	1.5	1	1	1
07/20/2024 22:00	0.7	11.4	2,175.6	0.7	1.5	1	1	1
07/20/2024 23:00	0.7	11.4	2,185.8	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.2	1,984.5	0.7	1.4	24 #	24 #	18 #
Minimum:	0.6	11.4	1,340.6	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,206.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2024 00:00	0.7	11.4	2,201.5	0.7	1.5	1	1	1
07/21/2024 01:00	0.7	11.4	2,207.8	0.7	1.5	1	1	1
07/21/2024 02:00	0.7	11.5	2,212.6	0.7	1.5	1	1	1
07/21/2024 03:00	0.7	11.5	2,211.3	0.7	1.5	1	1	1
07/21/2024 04:00	0.7	11.5	2,212.5	0.7	1.5	1	1	1
07/21/2024 05:00	0.0	14.2	1,548.2	0.0	1.1	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 10:00	0.0	17.4	350.1	0.0	0.2	1	0	0
07/21/2024 11:00	0.0	14.7	1,061.7	0.0	0.7	1	0	0
07/21/2024 12:00	0.6	13.7	1,429.7	0.6	1.0	1	1	0
07/21/2024 13:00	0.6	13.7	1,396.8	0.6	1.0	1	1	0
07/21/2024 14:00	0.6	13.6	1,613.0	0.6	1.1	1	1	0
07/21/2024 15:00	0.6	13.4	1,725.3	0.6	1.2	1	1	0
07/21/2024 16:00	0.7	12.3	1,906.0	0.7	1.3	1	1	1
07/21/2024 17:00	0.7	11.4	2,161.5	0.7	1.5	1	1	1
07/21/2024 18:00	0.7	11.3	2,164.6	0.7	1.5	1	1	1
07/21/2024 19:00	0.7	11.4	2,164.6	0.7	1.5	1	1	1
07/21/2024 20:00	0.7	11.4	2,167.8	0.7	1.5	1	1	1
07/21/2024 21:00	0.7	11.4	2,172.2	0.7	1.5	1	1	1
07/21/2024 22:00	0.7	11.4	2,172.3	0.7	1.5	1	1	1
07/21/2024 23:00	0.7	11.4	2,183.0	0.7	1.5	1	1	1
Average/Sum#:	0.6	12.5	1,863.1	0.6	1.3	20 #	17 #	14 #
Minimum:	0.0	11.3	350.1	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,212.6	0.7	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2024 00:00	0.7	11.4	2,185.0	0.7	1.5	1	1	1
07/22/2024 01:00	0.7	11.4	2,185.8	0.7	1.5	1	1	1
07/22/2024 02:00	0.7	11.8	2,100.0	0.7	1.5	1	1	1
07/22/2024 03:00	0.7	12.8	1,846.4	0.7	1.3	1	1	1
07/22/2024 04:00	0.6	13.6	1,448.5	0.6	1.0	1	1	0
07/22/2024 05:00	0.6	13.4	1,632.5	0.6	1.1	1	1	0
07/22/2024 06:00	0.6	13.6	1,714.3	0.6	1.2	1	1	0
07/22/2024 07:00	0.6	13.6	1,703.2	0.6	1.2	1	1	0
07/22/2024 08:00	0.6	13.6	1,703.1	0.6	1.2	1	1	0
07/22/2024 09:00	0.6	13.6	1,689.1	0.6	1.2	1	1	0
07/22/2024 10:00	0.6	13.6	1,674.3	0.6	1.2	1	1	0
07/22/2024 11:00	0.6	13.6	1,658.5	0.6	1.2	1	1	0
07/22/2024 12:00	0.7	12.6	1,826.2	0.7	1.3	1	1	1
07/22/2024 13:00	0.7	11.4	2,149.3	0.7	1.5	1	1	1
07/22/2024 14:00	0.7	11.4	2,150.2	0.7	1.5	1	1	1
07/22/2024 15:00	0.7	11.3	2,146.7	0.7	1.5	1	1	1
07/22/2024 16:00	0.7	11.4	2,149.8	0.7	1.5	1	1	1
07/22/2024 17:00	0.7	11.4	2,152.3	0.7	1.5	1	1	1
07/22/2024 18:00	0.7	11.4	2,147.4	0.7	1.5	1	1	1
07/22/2024 19:00	0.7	11.4	2,154.0	0.7	1.5	1	1	1
07/22/2024 20:00	0.7	11.4	2,153.5	0.7	1.5	1	1	1
07/22/2024 21:00	0.7	11.4	2,148.6	0.7	1.5	1	1	1
07/22/2024 22:00	0.7	11.4	2,165.2	0.7	1.5	1	1	1
07/22/2024 23:00	0.7	11.4	2,171.5	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.2	1,960.6	0.7	1.4	24 #	24 #	16 #
Minimum:	0.6	11.3	1,448.5	0.6	1.0	1	1	0
Maximum:	0.7	13.6	2,185.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2024 00:00	0.7	11.4	2,174.4	0.7	1.5	1	1	1
07/23/2024 01:00	0.7	11.4	2,178.6	0.7	1.5	1	1	1
07/23/2024 02:00	0.7	11.4	2,186.7	0.7	1.5	1	1	1
07/23/2024 03:00	0.7	11.4	2,187.0	0.7	1.5	1	1	1
07/23/2024 04:00	0.7	11.4	2,194.6	0.7	1.5	1	1	1
07/23/2024 05:00	0.7	11.4	2,200.2	0.7	1.5	1	1	1
07/23/2024 06:00	0.7	11.9	2,093.8	0.7	1.5	1	1	1
07/23/2024 07:00	0.7	11.6	2,153.9	0.7	1.5	1	1	1
07/23/2024 08:00	0.7	12.0	2,053.7	0.7	1.4	1	1	1
07/23/2024 09:00	0.7	11.7	2,108.2	0.7	1.5	1	1	1
07/23/2024 10:00	0.7	11.5	2,141.1	0.7	1.5	1	1	1
07/23/2024 11:00	0.7	11.4	2,157.1	0.7	1.5	1	1	1
07/23/2024 12:00	0.7	11.5	2,136.5	0.7	1.5	1	1	1
07/23/2024 13:00	0.7	11.6	2,112.7	0.7	1.5	1	1	1
07/23/2024 14:00	0.7	11.5	2,142.5	0.7	1.5	1	1	1
07/23/2024 15:00	0.7	11.4	2,146.2	0.7	1.5	1	1	1
07/23/2024 16:00	0.7	11.4	2,142.8	0.7	1.5	1	1	1
07/23/2024 17:00	0.7	11.4	2,141.0	0.7	1.5	1	1	1
07/23/2024 18:00	0.7	11.4	2,146.3	0.7	1.5	1	1	1
07/23/2024 19:00	0.7	11.4	2,158.7	0.7	1.5	1	1	1
07/23/2024 20:00	0.7	11.4	2,158.8	0.7	1.5	1	1	1
07/23/2024 21:00	0.7	11.5	2,166.0	0.7	1.5	1	1	1
07/23/2024 22:00	0.7	11.5	2,179.9	0.7	1.5	1	1	1
07/23/2024 23:00	0.7	11.5	2,190.0	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.5	2,152.1	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.4	2,053.7	0.7	1.4	1	1	1
Maximum:	0.7	12.0	2,200.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2024 00:00	0.7	11.5	2,185.7	0.7	1.5	1	1	1
07/24/2024 01:00	0.7	11.5	2,178.3	0.7	1.5	1	1	1
07/24/2024 02:00	0.7	11.5	2,182.3	0.7	1.5	1	1	1
07/24/2024 03:00	0.7	11.5	2,200.5	0.7	1.5	1	1	1
07/24/2024 04:00	0.7	11.5	2,206.7	0.7	1.5	1	1	1
07/24/2024 05:00	0.7	11.5	2,211.0	0.7	1.5	1	1	1
07/24/2024 06:00	0.7	11.7	2,161.0	0.7	1.5	1	1	1
07/24/2024 07:00	0.7	11.8	2,147.9	0.7	1.5	1	1	1
07/24/2024 08:00	0.7	11.8	2,134.8	0.7	1.5	1	1	1
07/24/2024 09:00	0.7	11.8	2,118.7	0.7	1.5	1	1	1
07/24/2024 10:00	0.7	11.8	2,109.3	0.7	1.5	1	1	1
07/24/2024 11:00	0.7	11.7	2,122.8	0.7	1.5	1	1	1
07/24/2024 12:00	0.7	11.5	2,145.9	0.7	1.5	1	1	1
07/24/2024 13:00	0.7	11.6	2,113.8	0.7	1.5	1	1	1
07/24/2024 14:00	0.7	11.5	2,132.8	0.7	1.5	1	1	1
07/24/2024 15:00	0.7	11.4	2,137.7	0.7	1.5	1	1	1
07/24/2024 16:00	0.7	11.9	2,057.7	0.7	1.4	1	1	1
07/24/2024 17:00	0.7	12.0	2,034.9	0.7	1.4	1	1	1
07/24/2024 18:00	0.7	12.0	2,044.8	0.7	1.4	1	1	1
07/24/2024 19:00	0.7	12.0	2,068.7	0.7	1.4	1	1	1
07/24/2024 20:00	0.7	12.0	2,074.0	0.7	1.5	1	1	1
07/24/2024 21:00	0.7	11.8	2,152.9	0.7	1.5	1	1	1
07/24/2024 22:00	0.7	11.6	2,197.1	0.7	1.5	1	1	1
07/24/2024 23:00	0.7	11.6	2,196.0	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.7	2,138.1	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.4	2,034.9	0.7	1.4	1	1	1
Maximum:	0.7	12.0	2,211.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2024 00:00	0.7	11.9	2,131.9	0.7	1.5	1	1	1
07/25/2024 01:00	0.7	12.0	2,120.0	0.7	1.5	1	1	1
07/25/2024 02:00	0.7	12.0	2,110.3	0.7	1.5	1	1	1
07/25/2024 03:00	0.7	11.7	2,192.7	0.7	1.5	1	1	1
07/25/2024 04:00	0.7	11.6	2,206.2	0.7	1.5	1	1	1
07/25/2024 05:00	0.7	11.6	2,207.2	0.7	1.5	1	1	1
07/25/2024 06:00	0.7	11.9	2,146.3	0.7	1.5	1	1	1
07/25/2024 07:00	0.7	11.8	2,150.7	0.7	1.5	1	1	1
07/25/2024 08:00	0.7	11.8	2,141.4	0.7	1.5	1	1	1
07/25/2024 09:00	0.7	11.9	2,129.4	0.7	1.5	1	1	1
07/25/2024 10:00	0.7	12.0	2,093.8	0.7	1.5	1	1	1
07/25/2024 11:00	0.7	11.7	2,161.7	0.7	1.5	1	1	1
07/25/2024 12:00	0.7	11.6	2,160.3	0.7	1.5	1	1	1
07/25/2024 13:00	0.7	11.6	2,156.9	0.7	1.5	1	1	1
07/25/2024 14:00	0.7	11.5	2,150.7	0.7	1.5	1	1	1
07/25/2024 15:00	0.7	11.5	2,151.6	0.7	1.5	1	1	1
07/25/2024 16:00	0.7	11.6	2,127.4	0.7	1.5	1	1	1
07/25/2024 17:00	0.7	11.5	2,143.4	0.7	1.5	1	1	1
07/25/2024 18:00	0.7	11.6	2,126.2	0.7	1.5	1	1	1
07/25/2024 19:00	0.7	11.8	2,091.7	0.7	1.5	1	1	1
07/25/2024 20:00	0.7	11.6	2,145.8	0.7	1.5	1	1	1
07/25/2024 21:00	0.7	11.5	2,181.3	0.7	1.5	1	1	1
07/25/2024 22:00	0.7	11.6	2,177.0	0.7	1.5	1	1	1
07/25/2024 23:00	0.7	11.5	2,199.8	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.7	2,150.2	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.5	2,091.7	0.7	1.5	1	1	1
Maximum:	0.7	12.0	2,207.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2024 00:00	0.7	11.6	2,189.8	0.7	1.5	1	1	1
07/26/2024 01:00	0.7	12.1	2,072.5	0.7	1.5	1	1	1
07/26/2024 02:00	0.7	12.6	1,990.6	0.7	1.4	1	1	1
07/26/2024 03:00	0.7	12.6	1,993.7	0.7	1.4	1	1	1
07/26/2024 04:00	0.7	12.0	2,146.0	0.7	1.5	1	1	1
07/26/2024 05:00	0.7	12.3	2,109.5	0.7	1.5	1	1	1
07/26/2024 06:00	0.7	12.6	1,994.2	0.7	1.4	1	1	1
07/26/2024 07:00	0.7	12.5	1,995.8	0.7	1.4	1	1	1
07/26/2024 08:00	0.7	12.5	2,001.1	0.7	1.4	1	1	1
07/26/2024 09:00	0.7	12.4	2,010.1	0.7	1.4	1	1	1
07/26/2024 10:00	0.7	12.3	2,020.0	0.7	1.4	1	1	1
07/26/2024 11:00	0.7	12.2	2,030.5	0.7	1.4	1	1	1
07/26/2024 12:00	0.7	12.1	2,043.0	0.7	1.4	1	1	1
07/26/2024 13:00	0.7	11.9	2,067.5	0.7	1.4	1	1	1
07/26/2024 14:00	0.7	11.9	2,079.5	0.7	1.5	1	1	1
07/26/2024 15:00	0.7	11.7	2,108.9	0.7	1.5	1	1	1
07/26/2024 16:00	0.7	11.5	2,125.4	0.7	1.5	1	1	1
07/26/2024 17:00	0.7	11.5	2,129.2	0.7	1.5	1	1	1
07/26/2024 18:00	0.7	11.7	2,085.8	0.7	1.5	1	1	1
07/26/2024 19:00	0.7	11.7	2,139.6	0.7	1.5	1	1	1
07/26/2024 20:00	0.7	11.6	2,177.7	0.7	1.5	1	1	1
07/26/2024 21:00	0.7	12.0	2,098.9	0.7	1.5	1	1	1
07/26/2024 22:00	0.7	12.0	2,095.8	0.7	1.5	1	1	1
07/26/2024 23:00	0.7	12.5	1,993.6	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.1	2,070.8	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.5	1,990.6	0.7	1.4	1	1	1
Maximum:	0.7	12.6	2,189.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2024 00:00	0.7	12.6	1,995.6	0.7	1.4	1	1	1
07/27/2024 01:00	0.7	12.6	1,992.3	0.7	1.4	1	1	1
07/27/2024 02:00	0.7	12.7	1,988.3	0.7	1.4	1	1	1
07/27/2024 03:00	0.7	12.7	1,987.3	0.7	1.4	1	1	1
07/27/2024 04:00	0.7	12.6	2,033.3	0.7	1.4	1	1	1
07/27/2024 05:00	0.7	12.5	2,064.3	0.7	1.4	1	1	1
07/27/2024 06:00	0.0	15.4	672.5	0.0	0.5	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 11:00	0.0	18.5	157.7	0.0	0.1	1	0	0
07/27/2024 12:00	0.0	15.1	928.9	0.0	0.7	1	0	0
07/27/2024 13:00	0.6	13.7	1,424.5	0.6	1.0	1	1	0
07/27/2024 14:00	0.6	13.7	1,393.9	0.6	1.0	1	1	0
07/27/2024 15:00	0.6	13.6	1,638.5	0.6	1.1	1	1	0
07/27/2024 16:00	0.6	13.8	1,431.4	0.6	1.0	1	1	0
07/27/2024 17:00	0.6	13.5	1,733.4	0.6	1.2	1	1	0
07/27/2024 18:00	0.7	13.6	1,588.3	0.7	1.1	1	1	1
07/27/2024 19:00	0.7	12.4	2,021.6	0.7	1.4	1	1	1
07/27/2024 20:00	0.7	12.4	2,004.3	0.7	1.4	1	1	1
07/27/2024 21:00	0.7	12.5	1,995.6	0.7	1.4	1	1	1
07/27/2024 22:00	0.7	12.5	1,990.9	0.7	1.4	1	1	1
07/27/2024 23:00	0.7	12.5	1,987.5	0.7	1.4	1	1	1
Average/Sum#:	0.6	13.4	1,651.5	0.6	1.2	20 #	17 #	12 #
Minimum:	0.0	12.4	157.7	0.0	0.1	0	0	0
Maximum:	0.7	18.5	2,064.3	0.7	1.4	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2024 00:00	0.7	12.6	1,985.5	0.7	1.4	1	1	1
07/28/2024 01:00	0.7	12.6	1,986.7	0.7	1.4	1	1	1
07/28/2024 02:00	0.7	12.6	1,983.9	0.7	1.4	1	1	1
07/28/2024 03:00	0.7	12.7	1,972.9	0.7	1.4	1	1	1
07/28/2024 04:00	0.7	12.7	1,950.4	0.7	1.4	1	1	1
07/28/2024 05:00	0.6	13.6	1,699.5	0.6	1.2	1	1	0
07/28/2024 06:00	0.6	13.7	1,313.9	0.6	0.9	1	1	0
07/28/2024 07:00	0.0	16.3	323.7	0.0	0.2	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.4	1,652.1	0.6	1.2	8 #	7 #	5 #
Minimum:	0.0	12.6	323.7	0.0	0.2	0	0	0
Maximum:	0.7	16.3	1,986.7	0.7	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 10:00	0.0	17.4	331.0	0.0	0.2	1	0	0
07/29/2024 11:00	0.0	16.8	435.4	0.0	0.3	1	0	0
07/29/2024 12:00	0.0	14.4	1,116.0	0.0	0.8	1	0	0
07/29/2024 13:00	0.6	13.7	1,390.7	0.6	1.0	1	1	0
07/29/2024 14:00	0.6	13.7	1,560.9	0.6	1.1	1	1	0
07/29/2024 15:00	0.6	13.6	1,597.6	0.6	1.1	1	1	0
07/29/2024 16:00	0.6	13.6	1,501.9	0.6	1.1	1	1	0
07/29/2024 17:00	0.6	13.6	1,665.0	0.6	1.2	1	1	0
07/29/2024 18:00	0.7	12.7	1,811.3	0.7	1.3	1	1	1
07/29/2024 19:00	0.7	11.5	2,173.2	0.7	1.5	1	1	1
07/29/2024 20:00	0.7	11.5	2,183.1	0.7	1.5	1	1	1
07/29/2024 21:00	0.7	11.9	2,095.3	0.7	1.5	1	1	1
07/29/2024 22:00	0.7	11.9	2,076.1	0.7	1.5	1	1	1
07/29/2024 23:00	0.0	15.4	626.6	0.0	0.4	1	0	0
Average/Sum#:	0.5	13.7	1,468.9	0.5	1.0	14 #	10 #	5 #
Minimum:	0.0	11.5	331.0	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,183.1	0.7	1.5	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 10:00	0.0	17.4	352.8	0.0	0.2	1	0	0
07/30/2024 11:00	0.0	16.9	419.8	0.0	0.3	1	0	0
07/30/2024 12:00	0.0	15.0	908.7	0.0	0.6	1	0	0
07/30/2024 13:00	0.6	13.7	1,399.0	0.6	1.0	1	1	0
07/30/2024 14:00	0.6	13.7	1,403.0	0.6	1.0	1	1	0
07/30/2024 15:00	0.6	13.6	1,641.1	0.6	1.1	1	1	0
07/30/2024 16:00	0.6	13.7	1,412.9	0.6	1.0	1	1	0
07/30/2024 17:00	0.6	13.7	1,447.9	0.6	1.0	1	1	0
07/30/2024 18:00	0.7	13.1	1,741.4	0.7	1.2	1	1	1
07/30/2024 19:00	0.7	11.5	2,166.9	0.7	1.5	1	1	1
07/30/2024 20:00	0.7	11.5	2,170.7	0.7	1.5	1	1	1
07/30/2024 21:00	0.7	11.5	2,165.8	0.7	1.5	1	1	1
07/30/2024 22:00	0.7	11.6	2,155.7	0.7	1.5	1	1	1
07/30/2024 23:00	0.7	11.7	2,154.1	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.5	1,538.6	0.5	1.1	14 #	11 #	6 #
Minimum:	0.0	11.5	352.8	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,170.7	0.7	1.5	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2024 00:00	0.7	12.4	1,994.0	0.7	1.4	1	1	1
07/31/2024 01:00	0.7	12.5	1,987.1	0.7	1.4	1	1	1
07/31/2024 02:00	0.7	12.5	1,984.8	0.7	1.4	1	1	1
07/31/2024 03:00	0.7	12.4	2,012.8	0.7	1.4	1	1	1
07/31/2024 04:00	0.7	11.6	2,203.9	0.7	1.5	1	1	1
07/31/2024 05:00	0.7	12.0	2,121.4	0.7	1.5	1	1	1
07/31/2024 06:00	0.6	13.6	1,716.9	0.6	1.2	1	1	0
07/31/2024 07:00	0.6	13.6	1,589.9	0.6	1.1	1	1	0
07/31/2024 08:00	0.6	13.6	1,493.6	0.6	1.0	1	1	0
07/31/2024 09:00	0.6	13.6	1,498.7	0.6	1.0	1	1	0
07/31/2024 10:00	0.6	13.6	1,546.3	0.6	1.1	1	1	0
07/31/2024 11:00	0.6	13.7	1,578.7	0.6	1.1	1	1	0
07/31/2024 12:00	0.6	13.7	1,463.8	0.6	1.0	1	1	0
07/31/2024 13:00	0.6	13.6	1,627.5	0.6	1.1	1	1	0
07/31/2024 14:00	0.7	11.8	2,095.1	0.7	1.5	1	1	1
07/31/2024 15:00	0.7	11.5	2,141.7	0.7	1.5	1	1	1
07/31/2024 16:00	0.7	11.5	2,141.0	0.7	1.5	1	1	1
07/31/2024 17:00	0.7	11.5	2,139.4	0.7	1.5	1	1	1
07/31/2024 18:00	0.7	11.5	2,140.4	0.7	1.5	1	1	1
07/31/2024 19:00	0.7	11.5	2,141.2	0.7	1.5	1	1	1
07/31/2024 20:00	0.7	11.5	2,147.9	0.7	1.5	1	1	1
07/31/2024 21:00	0.7	11.5	2,150.3	0.7	1.5	1	1	1
07/31/2024 22:00	0.7	11.6	2,145.8	0.7	1.5	1	1	1
07/31/2024 23:00	0.7	11.6	2,146.6	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.4	1,925.4	0.7	1.3	24 #	24 #	16 #
Minimum:	0.6	11.5	1,463.8	0.6	1.0	1	1	0
Maximum:	0.7	13.7	2,203.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2024 00:00	0.7	11.7	2,147.3	0.7	1.5	1	1	1
08/01/2024 01:00	0.7	11.7	2,138.7	0.7	1.5	1	1	1
08/01/2024 02:00	0.7	11.8	2,132.8	0.7	1.5	1	1	1
08/01/2024 03:00	0.7	11.9	2,126.5	0.7	1.5	1	1	1
08/01/2024 04:00	0.7	12.0	2,127.2	0.7	1.5	1	1	1
08/01/2024 05:00	0.7	11.8	2,150.0	0.7	1.5	1	1	1
08/01/2024 06:00	0.7	11.9	2,113.6	0.7	1.5	1	1	1
08/01/2024 07:00	0.6	13.5	1,706.8	0.6	1.2	1	1	0
08/01/2024 08:00	0.6	13.5	1,730.0	0.6	1.2	1	1	0
08/01/2024 09:00	0.6	13.5	1,745.2	0.6	1.2	1	1	0
08/01/2024 10:00	0.6	13.5	1,734.9	0.6	1.2	1	1	0
08/01/2024 11:00	0.6	13.6	1,714.9	0.6	1.2	1	1	0
08/01/2024 12:00	0.7	13.5	1,714.1	0.7	1.2	1	1	1
08/01/2024 13:00	0.7	11.9	2,076.3	0.7	1.5	1	1	1
08/01/2024 14:00	0.7	11.7	2,093.1	0.7	1.5	1	1	1
08/01/2024 15:00	0.7	11.6	2,099.8	0.7	1.5	1	1	1
08/01/2024 16:00	0.7	11.5	2,152.7	0.7	1.5	1	1	1
08/01/2024 17:00	0.7	11.5	2,151.7	0.7	1.5	1	1	1
08/01/2024 18:00	0.7	11.5	2,155.4	0.7	1.5	1	1	1
08/01/2024 19:00	0.7	11.6	2,160.3	0.7	1.5	1	1	1
08/01/2024 20:00	0.7	11.6	2,168.8	0.7	1.5	1	1	1
08/01/2024 21:00	0.7	11.6	2,173.7	0.7	1.5	1	1	1
08/01/2024 22:00	0.7	11.6	2,174.0	0.7	1.5	1	1	1
08/01/2024 23:00	0.7	11.6	2,183.8	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.2	2,036.3	0.7	1.4	24 #	24 #	19 #
Minimum:	0.6	11.5	1,706.8	0.6	1.2	1	1	0
Maximum:	0.7	13.6	2,183.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2024 00:00	0.7	11.6	2,193.0	0.7	1.5	1	1	1
08/02/2024 01:00	0.7	11.6	2,183.2	0.7	1.5	1	1	1
08/02/2024 02:00	0.7	11.6	2,180.6	0.7	1.5	1	1	1
08/02/2024 03:00	0.7	11.7	2,189.1	0.7	1.5	1	1	1
08/02/2024 04:00	0.7	11.7	2,193.3	0.7	1.5	1	1	1
08/02/2024 05:00	0.7	11.7	2,190.4	0.7	1.5	1	1	1
08/02/2024 06:00	0.7	11.7	2,184.7	0.7	1.5	1	1	1
08/02/2024 07:00	0.7	11.6	2,185.3	0.7	1.5	1	1	1
08/02/2024 08:00	0.7	11.6	2,174.2	0.7	1.5	1	1	1
08/02/2024 09:00	0.7	11.6	2,164.8	0.7	1.5	1	1	1
08/02/2024 10:00	0.7	11.6	2,158.1	0.7	1.5	1	1	1
08/02/2024 11:00	0.7	11.6	2,148.7	0.7	1.5	1	1	1
08/02/2024 12:00	0.7	11.6	2,136.4	0.7	1.5	1	1	1
08/02/2024 13:00	0.7	11.6	2,133.7	0.7	1.5	1	1	1
08/02/2024 14:00	0.7	11.6	2,131.7	0.7	1.5	1	1	1
08/02/2024 15:00	0.7	11.6	2,125.9	0.7	1.5	1	1	1
08/02/2024 16:00	0.7	11.6	2,134.8	0.7	1.5	1	1	1
08/02/2024 17:00	0.7	11.6	2,132.9	0.7	1.5	1	1	1
08/02/2024 18:00	0.7	11.6	2,136.8	0.7	1.5	1	1	1
08/02/2024 19:00	0.7	11.6	2,150.1	0.7	1.5	1	1	1
08/02/2024 20:00	0.7	11.6	2,151.6	0.7	1.5	1	1	1
08/02/2024 21:00	0.7	11.6	2,163.5	0.7	1.5	1	1	1
08/02/2024 22:00	0.7	11.6	2,165.7	0.7	1.5	1	1	1
08/02/2024 23:00	0.7	11.6	2,165.3	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.6	2,161.4	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.6	2,125.9	0.7	1.5	1	1	1
Maximum:	0.7	11.7	2,193.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2024 00:00	0.7	11.6	2,163.0	0.7	1.5	1	1	1
08/03/2024 01:00	0.7	11.6	2,160.9	0.7	1.5	1	1	1
08/03/2024 02:00	0.7	11.6	2,159.5	0.7	1.5	1	1	1
08/03/2024 03:00	0.7	11.9	2,113.5	0.7	1.5	1	1	1
08/03/2024 04:00	0.7	12.0	2,098.2	0.7	1.5	1	1	1
08/03/2024 05:00	0.7	12.2	2,093.5	0.7	1.5	1	1	1
08/03/2024 06:00	0.7	12.2	2,051.5	0.7	1.4	1	1	1
08/03/2024 07:00	0.7	12.1	2,065.1	0.7	1.4	1	1	1
08/03/2024 08:00	0.7	11.9	2,073.1	0.7	1.5	1	1	1
08/03/2024 09:00	0.7	11.9	2,084.1	0.7	1.5	1	1	1
08/03/2024 10:00	0.7	11.9	2,089.9	0.7	1.5	1	1	1
08/03/2024 11:00	0.7	11.9	2,097.4	0.7	1.5	1	1	1
08/03/2024 12:00	0.7	11.9	2,096.4	0.7	1.5	1	1	1
08/03/2024 13:00	0.7	11.8	2,103.2	0.7	1.5	1	1	1
08/03/2024 14:00	0.7	11.7	2,115.0	0.7	1.5	1	1	1
08/03/2024 15:00	0.7	11.7	2,115.1	0.7	1.5	1	1	1
08/03/2024 16:00	0.7	11.7	2,122.0	0.7	1.5	1	1	1
08/03/2024 17:00	0.7	11.7	2,130.0	0.7	1.5	1	1	1
08/03/2024 18:00	0.7	11.7	2,132.7	0.7	1.5	1	1	1
08/03/2024 19:00	0.7	11.7	2,135.8	0.7	1.5	1	1	1
08/03/2024 20:00	0.7	11.7	2,139.6	0.7	1.5	1	1	1
08/03/2024 21:00	0.7	11.7	2,137.4	0.7	1.5	1	1	1
08/03/2024 22:00	0.7	11.7	2,143.9	0.7	1.5	1	1	1
08/03/2024 23:00	0.7	11.7	2,150.0	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.8	2,115.5	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.6	2,051.5	0.7	1.4	1	1	1
Maximum:	0.7	12.2	2,163.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2024 00:00	0.7	11.9	2,091.0	0.7	1.5	1	1	1
08/04/2024 01:00	0.7	11.9	2,103.3	0.7	1.5	1	1	1
08/04/2024 02:00	0.7	12.1	2,035.8	0.7	1.4	1	1	1
08/04/2024 03:00	0.6	13.6	1,729.5	0.6	1.2	1	1	0
08/04/2024 04:00	0.6	13.5	1,754.6	0.6	1.2	1	1	0
08/04/2024 05:00	0.6	13.5	1,752.0	0.6	1.2	1	1	0
08/04/2024 06:00	0.6	13.6	1,719.0	0.6	1.2	1	1	0
08/04/2024 07:00	0.6	13.6	1,604.0	0.6	1.1	1	1	0
08/04/2024 08:00	0.6	13.6	1,611.0	0.6	1.1	1	1	0
08/04/2024 09:00	0.6	13.6	1,472.8	0.6	1.0	1	1	0
08/04/2024 10:00	0.6	13.7	1,617.8	0.6	1.1	1	1	0
08/04/2024 11:00	0.6	13.5	1,687.6	0.6	1.2	1	1	0
08/04/2024 12:00	0.7	13.7	1,543.6	0.7	1.1	1	1	1
08/04/2024 13:00	0.7	11.7	2,119.1	0.7	1.5	1	1	1
08/04/2024 14:00	0.7	11.6	2,118.7	0.7	1.5	1	1	1
08/04/2024 15:00	0.7	11.6	2,120.6	0.7	1.5	1	1	1
08/04/2024 16:00	0.7	11.7	2,081.1	0.7	1.5	1	1	1
08/04/2024 17:00	0.7	11.6	2,097.3	0.7	1.5	1	1	1
08/04/2024 18:00	0.7	11.6	2,107.6	0.7	1.5	1	1	1
08/04/2024 19:00	0.7	11.6	2,119.4	0.7	1.5	1	1	1
08/04/2024 20:00	0.7	11.6	2,132.6	0.7	1.5	1	1	1
08/04/2024 21:00	0.7	11.6	2,141.2	0.7	1.5	1	1	1
08/04/2024 22:00	0.7	11.7	2,151.5	0.7	1.5	1	1	1
08/04/2024 23:00	0.7	11.7	2,161.6	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.5	1,919.7	0.7	1.3	24 #	24 #	15 #
Minimum:	0.6	11.6	1,472.8	0.6	1.0	1	1	0
Maximum:	0.7	13.7	2,161.6	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2024 00:00	0.7	11.7	2,167.2	0.7	1.5	1	1	1
08/05/2024 01:00	0.7	11.7	2,173.7	0.7	1.5	1	1	1
08/05/2024 02:00	0.7	11.7	2,178.0	0.7	1.5	1	1	1
08/05/2024 03:00	0.7	11.7	2,184.5	0.7	1.5	1	1	1
08/05/2024 04:00	0.7	11.7	2,184.6	0.7	1.5	1	1	1
08/05/2024 05:00	0.7	11.7	2,186.5	0.7	1.5	1	1	1
08/05/2024 06:00	0.7	11.9	2,145.6	0.7	1.5	1	1	1
08/05/2024 07:00	0.7	12.2	2,050.4	0.7	1.4	1	1	1
08/05/2024 08:00	0.7	12.3	2,029.3	0.7	1.4	1	1	1
08/05/2024 09:00	0.7	12.3	2,040.3	0.7	1.4	1	1	1
08/05/2024 10:00	0.7	12.1	2,060.4	0.7	1.4	1	1	1
08/05/2024 11:00	0.7	11.8	2,098.6	0.7	1.5	1	1	1
08/05/2024 12:00	0.7	11.6	2,127.1	0.7	1.5	1	1	1
08/05/2024 13:00	0.7	11.6	2,129.1	0.7	1.5	1	1	1
08/05/2024 14:00	0.7	11.6	2,126.5	0.7	1.5	1	1	1
08/05/2024 15:00	0.7	11.6	2,112.2	0.7	1.5	1	1	1
08/05/2024 16:00	0.7	11.6	2,110.2	0.7	1.5	1	1	1
08/05/2024 17:00	0.7	11.6	2,106.2	0.7	1.5	1	1	1
08/05/2024 18:00	0.7	11.6	2,113.4	0.7	1.5	1	1	1
08/05/2024 19:00	0.7	11.8	2,094.3	0.7	1.5	1	1	1
08/05/2024 20:00	0.7	11.6	2,140.5	0.7	1.5	1	1	1
08/05/2024 21:00	0.7	11.6	2,150.4	0.7	1.5	1	1	1
08/05/2024 22:00	0.7	11.6	2,158.5	0.7	1.5	1	1	1
08/05/2024 23:00	0.7	11.6	2,167.9	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.8	2,126.5	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.6	2,029.3	0.7	1.4	1	1	1
Maximum:	0.7	12.3	2,186.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2024 00:00	0.7	12.0	2,094.2	0.7	1.5	1	1	1
08/06/2024 01:00	0.7	12.3	2,041.0	0.7	1.4	1	1	1
08/06/2024 02:00	0.7	12.4	2,029.2	0.7	1.4	1	1	1
08/06/2024 03:00	0.7	12.4	2,029.3	0.7	1.4	1	1	1
08/06/2024 04:00	0.7	11.8	2,160.8	0.7	1.5	1	1	1
08/06/2024 05:00	0.7	11.7	2,191.4	0.7	1.5	1	1	1
08/06/2024 06:00	0.7	12.2	2,114.6	0.7	1.5	1	1	1
08/06/2024 07:00	0.7	12.4	2,030.3	0.7	1.4	1	1	1
08/06/2024 08:00	0.7	12.3	2,032.4	0.7	1.4	1	1	1
08/06/2024 09:00	0.7	12.2	2,045.4	0.7	1.4	1	1	1
08/06/2024 10:00	0.7	12.0	2,060.1	0.7	1.4	1	1	1
08/06/2024 11:00	0.7	12.0	2,072.3	0.7	1.5	1	1	1
08/06/2024 12:00	0.7	11.9	2,092.4	0.7	1.5	1	1	1
08/06/2024 13:00	0.7	11.8	2,099.2	0.7	1.5	1	1	1
08/06/2024 14:00	0.7	11.7	2,103.0	0.7	1.5	1	1	1
08/06/2024 15:00	0.7	11.7	2,108.9	0.7	1.5	1	1	1
08/06/2024 16:00	0.7	11.7	2,117.0	0.7	1.5	1	1	1
08/06/2024 17:00	0.7	11.6	2,121.7	0.7	1.5	1	1	1
08/06/2024 18:00	0.7	11.6	2,118.1	0.7	1.5	1	1	1
08/06/2024 19:00	0.7	11.6	2,122.9	0.7	1.5	1	1	1
08/06/2024 20:00	0.7	11.6	2,126.4	0.7	1.5	1	1	1
08/06/2024 21:00	0.7	11.7	2,132.3	0.7	1.5	1	1	1
08/06/2024 22:00	0.7	11.7	2,141.2	0.7	1.5	1	1	1
08/06/2024 23:00	0.7	11.7	2,138.3	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.9	2,096.8	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.6	2,029.2	0.7	1.4	1	1	1
Maximum:	0.7	12.4	2,191.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2024 00:00	0.7	11.9	2,106.2	0.7	1.5	1	1	1
08/07/2024 01:00	0.7	11.7	2,156.9	0.7	1.5	1	1	1
08/07/2024 02:00	0.7	12.0	2,099.7	0.7	1.5	1	1	1
08/07/2024 03:00	0.7	12.3	2,039.6	0.7	1.4	1	1	1
08/07/2024 04:00	0.7	12.2	2,053.4	0.7	1.4	1	1	1
08/07/2024 05:00	0.7	11.7	2,130.5	0.7	1.5	1	1	1
08/07/2024 06:00	0.7	11.8	2,141.3	0.7	1.5	1	1	1
08/07/2024 07:00	0.7	12.3	2,042.9	0.7	1.4	1	1	1
08/07/2024 08:00	0.7	12.3	2,046.7	0.7	1.4	1	1	1
08/07/2024 09:00	0.7	12.1	2,059.4	0.7	1.4	1	1	1
08/07/2024 10:00	0.7	12.0	2,076.0	0.7	1.5	1	1	1
08/07/2024 11:00	0.7	11.8	2,092.9	0.7	1.5	1	1	1
08/07/2024 12:00	0.7	11.7	2,103.9	0.7	1.5	1	1	1
08/07/2024 13:00	0.7	11.7	2,110.3	0.7	1.5	1	1	1
08/07/2024 14:00	0.7	11.7	2,113.5	0.7	1.5	1	1	1
08/07/2024 15:00	0.7	11.7	2,114.9	0.7	1.5	1	1	1
08/07/2024 16:00	0.7	11.6	2,109.4	0.7	1.5	1	1	1
08/07/2024 17:00	0.7	11.6	2,101.9	0.7	1.5	1	1	1
08/07/2024 18:00	0.7	11.6	2,109.3	0.7	1.5	1	1	1
08/07/2024 19:00	0.7	11.6	2,119.1	0.7	1.5	1	1	1
08/07/2024 20:00	0.7	11.6	2,128.7	0.7	1.5	1	1	1
08/07/2024 21:00	0.7	11.6	2,136.7	0.7	1.5	1	1	1
08/07/2024 22:00	0.7	12.0	2,060.6	0.7	1.4	1	1	1
08/07/2024 23:00	0.7	11.7	2,156.1	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.8	2,100.4	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.6	2,039.6	0.7	1.4	1	1	1
Maximum:	0.7	12.3	2,156.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2024 00:00	0.7	11.7	2,169.8	0.7	1.5	1	1	1
08/08/2024 01:00	0.7	11.9	2,108.4	0.7	1.5	1	1	1
08/08/2024 02:00	0.6	13.6	1,666.6	0.6	1.2	1	1	0
08/08/2024 03:00	0.6	13.6	1,702.4	0.6	1.2	1	1	0
08/08/2024 04:00	0.6	13.6	1,672.4	0.6	1.2	1	1	0
08/08/2024 05:00	0.6	13.6	1,740.9	0.6	1.2	1	1	0
08/08/2024 06:00	0.6	13.6	1,735.5	0.6	1.2	1	1	0
08/08/2024 07:00	0.6	13.6	1,674.4	0.6	1.2	1	1	0
08/08/2024 08:00	0.6	13.6	1,572.3	0.6	1.1	1	1	0
08/08/2024 09:00	0.6	13.6	1,566.6	0.6	1.1	1	1	0
08/08/2024 10:00	0.6	13.6	1,561.5	0.6	1.1	1	1	0
08/08/2024 11:00	0.6	13.7	1,340.3	0.6	0.9	1	1	0
08/08/2024 12:00	0.6	13.7	1,330.3	0.6	0.9	1	1	0
08/08/2024 13:00	0.6	13.8	1,334.9	0.6	0.9	1	1	0
08/08/2024 14:00	0.7	13.6	1,525.6	0.7	1.1	1	1	1
08/08/2024 15:00	0.7	11.7	2,100.7	0.7	1.5	1	1	1
08/08/2024 16:00	0.7	11.8	2,057.2	0.7	1.4	1	1	1
08/08/2024 17:00	0.7	11.9	2,039.6	0.7	1.4	1	1	1
08/08/2024 18:00	0.7	11.6	2,105.8	0.7	1.5	1	1	1
08/08/2024 19:00	0.7	11.6	2,114.9	0.7	1.5	1	1	1
08/08/2024 20:00	0.7	11.6	2,126.9	0.7	1.5	1	1	1
08/08/2024 21:00	0.7	11.6	2,135.7	0.7	1.5	1	1	1
08/08/2024 22:00	0.7	11.7	2,135.0	0.7	1.5	1	1	1
08/08/2024 23:00	0.7	11.8	2,112.5	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.8	1,817.9	0.7	1.3	24 #	24 #	12 #
Minimum:	0.6	11.6	1,330.3	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,169.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2024 00:00	0.7	13.5	1,609.1	0.7	1.1	1	1	1
08/09/2024 01:00	0.6	13.6	1,703.2	0.6	1.2	1	1	0
08/09/2024 02:00	0.6	13.6	1,733.0	0.6	1.2	1	1	0
08/09/2024 03:00	0.6	13.6	1,717.3	0.6	1.2	1	1	0
08/09/2024 04:00	0.6	13.6	1,752.4	0.6	1.2	1	1	0
08/09/2024 05:00	0.6	13.6	1,751.8	0.6	1.2	1	1	0
08/09/2024 06:00	0.6	13.6	1,714.9	0.6	1.2	1	1	0
08/09/2024 07:00	0.6	13.6	1,559.0	0.6	1.1	1	1	0
08/09/2024 08:00	0.6	13.7	1,463.2	0.6	1.0	1	1	0
08/09/2024 09:00	0.6	13.7	1,538.6	0.6	1.1	1	1	0
08/09/2024 10:00	0.6	13.7	1,571.2	0.6	1.1	1	1	0
08/09/2024 11:00	0.6	13.7	1,591.3	0.6	1.1	1	1	0
08/09/2024 12:00	0.6	13.6	1,649.6	0.6	1.2	1	1	0
08/09/2024 13:00	0.6	13.6	1,707.2	0.6	1.2	1	1	0
08/09/2024 14:00	0.7	13.5	1,605.3	0.7	1.1	1	1	1
08/09/2024 15:00	0.7	11.7	2,100.8	0.7	1.5	1	1	1
08/09/2024 16:00	0.7	11.8	2,069.7	0.7	1.4	1	1	1
08/09/2024 17:00	0.7	11.6	2,099.2	0.7	1.5	1	1	1
08/09/2024 18:00	0.7	11.7	2,107.6	0.7	1.5	1	1	1
08/09/2024 19:00	0.7	11.7	2,119.5	0.7	1.5	1	1	1
08/09/2024 20:00	0.7	11.7	2,103.0	0.7	1.5	1	1	1
08/09/2024 21:00	0.0	15.3	687.9	0.0	0.5	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.2	1,725.2	0.6	1.2	22 #	21 #	8 #
Minimum:	0.0	11.6	687.9	0.0	0.5	0	0	0
Maximum:	0.7	15.3	2,119.5	0.7	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 13:00	0.0	17.3	320.3	0.0	0.2	1	0	0
08/12/2024 14:00	0.0	16.8	408.3	0.0	0.3	1	0	0
08/12/2024 15:00	0.0	15.1	957.1	0.0	0.7	1	0	0
08/12/2024 16:00	0.6	13.5	1,687.6	0.6	1.2	1	1	0
08/12/2024 17:00	0.7	12.5	1,929.9	0.7	1.4	1	1	1
08/12/2024 18:00	0.7	13.3	1,768.9	0.7	1.2	1	1	1
08/12/2024 19:00	0.6	13.5	1,695.8	0.6	1.2	1	1	0
08/12/2024 20:00	0.6	13.6	1,497.7	0.6	1.0	1	1	0
08/12/2024 21:00	0.6	13.6	1,716.7	0.6	1.2	1	1	0
08/12/2024 22:00	0.6	13.6	1,689.2	0.6	1.2	1	1	0
08/12/2024 23:00	0.6	13.7	1,723.8	0.6	1.2	1	1	0
Average/Sum#:	0.5	14.2	1,399.6	0.5	1.0	11 #	8 #	2 #
Minimum:	0.0	12.5	320.3	0.0	0.2	0	0	0
Maximum:	0.7	17.3	1,929.9	0.7	1.4	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2024 00:00	0.6	13.6	1,683.4	0.6	1.2	1	1	0
08/13/2024 01:00	0.6	13.7	1,348.3	0.6	0.9	1	1	0
08/13/2024 02:00	0.0	15.4	639.0	0.0	0.4	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.2	1,223.6	0.4	0.8	3 #	2 #	0 #
Minimum:	0.0	13.6	639.0	0.0	0.4	0	0	0
Maximum:	0.6	15.4	1,683.4	0.6	1.2	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 17:00	0.0	17.2	339.5	0.0	0.2	1	0	0
08/15/2024 18:00	0.0	14.3	1,226.7	0.0	0.9	1	0	0
08/15/2024 19:00	0.7	12.5	1,852.5	0.7	1.3	1	1	1
08/15/2024 20:00	0.7	11.7	2,105.6	0.7	1.5	1	1	1
08/15/2024 21:00	0.6	13.6	1,692.5	0.6	1.2	1	1	0
08/15/2024 22:00	0.6	13.6	1,672.0	0.6	1.2	1	1	0
08/15/2024 23:00	0.6	13.6	1,698.4	0.6	1.2	1	1	0
Average/Sum#:	0.5	13.8	1,512.5	0.5	1.1	7 #	5 #	2 #
Minimum:	0.0	11.7	339.5	0.0	0.2	0	0	0
Maximum:	0.7	17.2	2,105.6	0.7	1.5	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2024 00:00	0.6	13.6	1,741.5	0.6	1.2	1	1	0
08/16/2024 01:00	0.6	13.6	1,689.7	0.6	1.2	1	1	0
08/16/2024 02:00	0.0	14.7	1,042.8	0.0	0.7	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 08:00	0.0	17.5	336.0	0.0	0.2	1	0	0
08/16/2024 09:00	0.0	15.0	928.1	0.0	0.6	1	0	0
08/16/2024 10:00	0.6	13.6	1,578.6	0.6	1.1	1	1	0
08/16/2024 11:00	0.6	13.7	1,426.2	0.6	1.0	1	1	0
08/16/2024 12:00	0.6	13.6	1,662.1	0.6	1.2	1	1	0
08/16/2024 13:00	0.6	13.6	1,549.8	0.6	1.1	1	1	0
08/16/2024 14:00	0.6	13.8	1,343.9	0.6	0.9	1	1	0
08/16/2024 15:00	0.7	13.6	1,580.7	0.7	1.1	1	1	1
08/16/2024 16:00	0.7	11.9	2,064.7	0.7	1.4	1	1	1
08/16/2024 17:00	0.7	11.9	2,072.0	0.7	1.5	1	1	1
08/16/2024 18:00	0.7	11.8	2,090.7	0.7	1.5	1	1	1
08/16/2024 19:00	0.7	11.8	2,100.8	0.7	1.5	1	1	1
08/16/2024 20:00	0.7	11.8	2,113.4	0.7	1.5	1	1	1
08/16/2024 21:00	0.7	11.8	2,125.2	0.7	1.5	1	1	1
08/16/2024 22:00	0.7	11.8	2,133.0	0.7	1.5	1	1	1
08/16/2024 23:00	0.7	11.8	2,136.9	0.7	1.5	1	1	1
Average/Sum#:	0.6	13.2	1,669.3	0.6	1.2	19 #	16 #	9 #
Minimum:	0.0	11.8	336.0	0.0	0.2	0	0	0
Maximum:	0.7	17.5	2,136.9	0.7	1.5	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2024 00:00	0.7	11.8	2,150.7	0.7	1.5	1	1	1
08/17/2024 01:00	0.7	12.0	2,107.5	0.7	1.5	1	1	1
08/17/2024 02:00	0.7	12.2	2,062.0	0.7	1.4	1	1	1
08/17/2024 03:00	0.7	12.3	2,040.1	0.7	1.4	1	1	1
08/17/2024 04:00	0.7	12.2	2,058.1	0.7	1.4	1	1	1
08/17/2024 05:00	0.7	12.2	2,076.1	0.7	1.5	1	1	1
08/17/2024 06:00	0.0	13.9	1,261.3	0.0	0.9	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	12.4	1,965.1	0.6	1.4	7 #	6 #	7 #
Minimum:	0.0	11.8	1,261.3	0.0	0.9	0	0	0
Maximum:	0.7	13.9	2,150.7	0.7	1.5	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 09:00	0.0	17.3	346.8	0.0	0.2	1	0	0
08/18/2024 10:00	0.0	16.9	430.4	0.0	0.3	1	0	0
08/18/2024 11:00	0.0	14.6	1,066.4	0.0	0.7	1	0	0
08/18/2024 12:00	0.6	13.8	1,395.7	0.6	1.0	1	1	0
08/18/2024 13:00	0.6	13.7	1,586.6	0.6	1.1	1	1	0
08/18/2024 14:00	0.6	13.6	1,711.3	0.6	1.2	1	1	0
08/18/2024 15:00	0.6	13.7	1,470.9	0.6	1.0	1	1	0
08/18/2024 16:00	0.6	13.6	1,693.4	0.6	1.2	1	1	0
08/18/2024 17:00	0.7	13.5	1,672.3	0.7	1.2	1	1	1
08/18/2024 18:00	0.7	12.0	2,084.4	0.7	1.5	1	1	1
08/18/2024 19:00	0.7	11.6	2,195.0	0.7	1.5	1	1	1
08/18/2024 20:00	0.7	11.4	2,228.2	0.7	1.6	1	1	1
08/18/2024 21:00	0.7	11.4	2,245.1	0.7	1.6	1	1	1
08/18/2024 22:00	0.7	11.4	2,257.9	0.7	1.6	1	1	1
08/18/2024 23:00	0.7	11.5	2,175.2	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.3	1,637.3	0.5	1.1	15 #	12 #	7 #
Minimum:	0.0	11.4	346.8	0.0	0.2	0	0	0
Maximum:	0.7	17.3	2,257.9	0.7	1.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2024 00:00	0.0	15.6	575.4	0.0	0.4	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 12:00	0.0	17.3	365.9	0.0	0.3	1	0	0
08/19/2024 13:00	0.0	14.7	1,038.7	0.0	0.7	1	0	0
08/19/2024 14:00	0.6	13.7	1,653.2	0.6	1.2	1	1	0
08/19/2024 15:00	0.6	13.7	1,515.2	0.6	1.1	1	1	0
08/19/2024 16:00	0.7	12.1	2,123.4	0.7	1.5	1	1	1
08/19/2024 17:00	0.7	12.0	2,096.7	0.7	1.5	1	1	1
08/19/2024 18:00	0.7	11.4	2,231.2	0.7	1.6	1	1	1
08/19/2024 19:00	0.7	11.8	2,142.7	0.7	1.5	1	1	1
08/19/2024 20:00	0.7	12.0	2,094.4	0.7	1.5	1	1	1
08/19/2024 21:00	0.7	11.5	2,210.4	0.7	1.5	1	1	1
08/19/2024 22:00	0.7	11.5	2,232.0	0.7	1.6	1	1	1
08/19/2024 23:00	0.7	11.8	2,148.5	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.0	1,725.2	0.5	1.2	13 #	10 #	8 #
Minimum:	0.0	11.4	365.9	0.0	0.3	0	0	0
Maximum:	0.7	17.3	2,232.0	0.7	1.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2024 00:00	0.7	12.6	1,949.8	0.7	1.4	1	1	1
08/20/2024 01:00	0.0	15.3	666.3	0.0	0.5	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 09:00	0.0	17.6	301.1	0.0	0.2	1	0	0
08/20/2024 10:00	0.0	15.0	937.1	0.0	0.7	1	0	0
08/20/2024 11:00	0.6	13.8	1,396.2	0.6	1.0	1	1	0
08/20/2024 12:00	0.6	13.7	1,540.4	0.6	1.1	1	1	0
08/20/2024 13:00	0.6	13.7	1,674.6	0.6	1.2	1	1	0
08/20/2024 14:00	0.6	13.7	1,459.3	0.6	1.0	1	1	0
08/20/2024 15:00	0.6	13.8	1,330.3	0.6	0.9	1	1	0
08/20/2024 16:00	0.7	13.7	1,557.9	0.7	1.1	1	1	1
08/20/2024 17:00	0.7	11.9	2,084.2	0.7	1.5	1	1	1
08/20/2024 18:00	0.7	11.7	2,135.7	0.7	1.5	1	1	1
08/20/2024 19:00	0.7	11.8	2,120.7	0.7	1.5	1	1	1
08/20/2024 20:00	0.7	11.9	2,104.4	0.7	1.5	1	1	1
08/20/2024 21:00	0.7	12.2	2,032.9	0.7	1.4	1	1	1
08/20/2024 22:00	0.7	11.5	2,199.5	0.7	1.5	1	1	1
08/20/2024 23:00	0.7	11.5	2,204.3	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.3	1,629.1	0.5	1.1	17 #	14 #	9 #
Minimum:	0.0	11.5	301.1	0.0	0.2	0	0	0
Maximum:	0.7	17.6	2,204.3	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2024 00:00	0.7	11.5	2,218.4	0.7	1.6	1	1	1
08/21/2024 01:00	0.7	12.5	1,994.8	0.7	1.4	1	1	1
08/21/2024 02:00	0.7	13.6	1,703.9	0.7	1.2	1	1	1
08/21/2024 03:00	0.6	13.7	1,717.5	0.6	1.2	1	1	0
08/21/2024 04:00	0.6	13.7	1,726.0	0.6	1.2	1	1	0
08/21/2024 05:00	0.6	13.7	1,736.9	0.6	1.2	1	1	0
08/21/2024 06:00	0.6	13.7	1,730.5	0.6	1.2	1	1	0
08/21/2024 07:00	0.6	13.7	1,621.6	0.6	1.1	1	1	0
08/21/2024 08:00	0.6	13.7	1,615.8	0.6	1.1	1	1	0
08/21/2024 09:00	0.6	13.8	1,330.0	0.6	0.9	1	1	0
08/21/2024 10:00	0.6	13.7	1,539.9	0.6	1.1	1	1	0
08/21/2024 11:00	0.6	13.7	1,584.8	0.6	1.1	1	1	0
08/21/2024 12:00	0.6	13.7	1,661.8	0.6	1.2	1	1	0
08/21/2024 13:00	0.6	13.6	1,742.7	0.6	1.2	1	1	0
08/21/2024 14:00	0.6	13.5	1,752.2	0.6	1.2	1	1	0
08/21/2024 15:00	0.6	13.5	1,734.0	0.6	1.2	1	1	0
08/21/2024 16:00	0.6	13.6	1,617.7	0.6	1.1	1	1	0
08/21/2024 17:00	0.7	11.9	2,105.4	0.7	1.5	1	1	1
08/21/2024 18:00	0.7	11.1	2,274.8	0.7	1.6	1	1	1
08/21/2024 19:00	0.7	11.1	2,281.6	0.7	1.6	1	1	1
08/21/2024 20:00	0.7	11.4	2,241.3	0.7	1.6	1	1	1
08/21/2024 21:00	0.7	11.6	2,194.5	0.7	1.5	1	1	1
08/21/2024 22:00	0.7	11.6	2,191.6	0.7	1.5	1	1	1
08/21/2024 23:00	0.7	11.6	2,210.4	0.7	1.5	1	1	1
Average/Sum#:	0.6	12.9	1,855.3	0.6	1.3	24 #	24 #	10 #
Minimum:	0.6	11.1	1,330.0	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,281.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2024 00:00	0.7	12.5	2,001.3	0.7	1.4	1	1	1
08/22/2024 01:00	0.7	12.7	1,969.9	0.7	1.4	1	1	1
08/22/2024 02:00	0.7	12.7	1,966.3	0.7	1.4	1	1	1
08/22/2024 03:00	0.7	12.7	1,963.8	0.7	1.4	1	1	1
08/22/2024 04:00	0.7	12.7	1,975.3	0.7	1.4	1	1	1
08/22/2024 05:00	0.7	11.9	2,123.5	0.7	1.5	1	1	1
08/22/2024 06:00	0.0	15.3	697.2	0.0	0.5	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 14:00	0.0	17.4	346.6	0.0	0.2	1	0	0
08/22/2024 15:00	0.0	15.2	896.2	0.0	0.6	1	0	0
08/22/2024 16:00	0.6	13.6	1,671.8	0.6	1.2	1	1	0
08/22/2024 17:00	0.7	12.8	1,889.6	0.7	1.3	1	1	1
08/22/2024 18:00	0.7	12.5	2,013.7	0.7	1.4	1	1	1
08/22/2024 19:00	0.7	12.6	1,992.2	0.7	1.4	1	1	1
08/22/2024 20:00	0.7	12.6	1,985.3	0.7	1.4	1	1	1
08/22/2024 21:00	0.7	12.7	1,976.9	0.7	1.4	1	1	1
08/22/2024 22:00	0.7	12.7	1,969.7	0.7	1.4	1	1	1
08/22/2024 23:00	0.7	12.8	1,962.6	0.7	1.4	1	1	1
Average/Sum#:	0.6	13.3	1,729.5	0.6	1.2	17 #	14 #	13 #
Minimum:	0.0	11.9	346.6	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,123.5	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2024 00:00	0.7	12.8	1,956.0	0.7	1.4	1	1	1
08/23/2024 01:00	0.7	12.8	1,958.0	0.7	1.4	1	1	1
08/23/2024 02:00	0.7	12.8	1,958.0	0.7	1.4	1	1	1
08/23/2024 03:00	0.7	12.8	1,960.1	0.7	1.4	1	1	1
08/23/2024 04:00	0.7	12.8	1,963.3	0.7	1.4	1	1	1
08/23/2024 05:00	0.7	12.3	2,041.5	0.7	1.4	1	1	1
08/23/2024 06:00	0.6	13.7	1,435.0	0.6	1.0	1	1	0
08/23/2024 07:00	0.0	16.1	397.5	0.0	0.3	1	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.3	1,708.7	0.6	1.2	8 #	7 #	6 #
Minimum:	0.0	12.3	397.5	0.0	0.3	0	0	0
Maximum:	0.7	16.1	2,041.5	0.7	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 13:00	0.0	17.4	337.7	0.0	0.2	1	0	0
08/25/2024 14:00	0.0	15.7	656.8	0.0	0.5	1	0	0
08/25/2024 15:00	0.0	14.4	1,204.9	0.0	0.8	1	0	0
08/25/2024 16:00	0.6	13.6	1,745.0	0.6	1.2	1	1	0
08/25/2024 17:00	0.7	12.4	2,042.9	0.7	1.4	1	1	1
08/25/2024 18:00	0.7	11.1	2,332.9	0.7	1.6	1	1	1
08/25/2024 19:00	0.7	11.1	2,337.0	0.7	1.6	1	1	1
08/25/2024 20:00	0.7	11.1	2,343.4	0.7	1.6	1	1	1
08/25/2024 21:00	0.7	12.2	2,089.9	0.7	1.5	1	1	1
08/25/2024 22:00	0.7	12.7	1,974.5	0.7	1.4	1	1	1
08/25/2024 23:00	0.6	13.6	1,762.0	0.6	1.2	1	1	0
Average/Sum#:	0.5	13.2	1,711.5	0.5	1.2	11 #	8 #	6 #
Minimum:	0.0	11.1	337.7	0.0	0.2	0	0	0
Maximum:	0.7	17.4	2,343.4	0.7	1.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2024 00:00	0.6	13.6	1,802.9	0.6	1.3	1	1	0
08/26/2024 01:00	0.6	13.6	1,762.3	0.6	1.2	1	1	0
08/26/2024 02:00	0.6	13.6	1,771.9	0.6	1.2	1	1	0
08/26/2024 03:00	0.6	13.5	1,831.5	0.6	1.3	1	1	0
08/26/2024 04:00	0.6	13.5	1,830.8	0.6	1.3	1	1	0
08/26/2024 05:00	0.6	13.5	1,828.9	0.6	1.3	1	1	0
08/26/2024 06:00	0.6	13.7	1,727.4	0.6	1.2	1	1	0
08/26/2024 07:00	0.6	13.5	1,804.8	0.6	1.3	1	1	0
08/26/2024 08:00	0.6	13.7	1,644.4	0.6	1.2	1	1	0
08/26/2024 09:00	0.6	13.7	1,736.3	0.6	1.2	1	1	0
08/26/2024 10:00	0.6	13.7	1,723.5	0.6	1.2	1	1	0
08/26/2024 11:00	0.6	13.7	1,719.3	0.6	1.2	1	1	0
08/26/2024 12:00	0.7	12.9	1,856.6	0.7	1.3	1	1	1
08/26/2024 13:00	0.7	12.4	2,032.8	0.7	1.4	1	1	1
08/26/2024 14:00	0.7	12.1	2,079.1	0.7	1.5	1	1	1
08/26/2024 15:00	0.7	12.3	2,038.7	0.7	1.4	1	1	1
08/26/2024 16:00	0.7	11.8	2,158.6	0.7	1.5	1	1	1
08/26/2024 17:00	0.7	11.2	2,263.4	0.7	1.6	1	1	1
08/26/2024 18:00	0.7	11.0	2,299.6	0.7	1.6	1	1	1
08/26/2024 19:00	0.7	11.1	2,305.2	0.7	1.6	1	1	1
08/26/2024 20:00	0.7	11.4	2,253.8	0.7	1.6	1	1	1
08/26/2024 21:00	0.7	11.4	2,258.9	0.7	1.6	1	1	1
08/26/2024 22:00	0.7	11.5	2,230.1	0.7	1.6	1	1	1
08/26/2024 23:00	0.7	12.6	2,002.1	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.7	1,956.8	0.7	1.4	24 #	24 #	12 #
Minimum:	0.6	11.0	1,644.4	0.6	1.2	1	1	0
Maximum:	0.7	13.7	2,305.2	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2024 00:00	0.7	12.7	1,988.2	0.7	1.4	1	1	1
08/27/2024 01:00	0.7	12.7	1,992.0	0.7	1.4	1	1	1
08/27/2024 02:00	0.7	12.7	1,995.7	0.7	1.4	1	1	1
08/27/2024 03:00	0.7	12.6	1,997.9	0.7	1.4	1	1	1
08/27/2024 04:00	0.7	12.7	1,979.2	0.7	1.4	1	1	1
08/27/2024 05:00	0.6	13.7	1,721.5	0.6	1.2	1	1	0
08/27/2024 06:00	0.6	13.7	1,703.9	0.6	1.2	1	1	0
08/27/2024 07:00	0.6	13.7	1,604.5	0.6	1.1	1	1	0
08/27/2024 08:00	0.6	13.8	1,317.8	0.6	0.9	1	1	0
08/27/2024 09:00	0.6	13.8	1,315.8	0.6	0.9	1	1	0
08/27/2024 10:00	0.6	13.8	1,318.6	0.6	0.9	1	1	0
08/27/2024 11:00	0.6	13.8	1,323.8	0.6	0.9	1	1	0
08/27/2024 12:00	0.6	13.7	1,621.1	0.6	1.1	1	1	0
08/27/2024 13:00	0.6	13.7	1,662.3	0.6	1.2	1	1	0
08/27/2024 14:00	0.6	13.6	1,724.1	0.6	1.2	1	1	0
08/27/2024 15:00	0.6	13.7	1,592.3	0.6	1.1	1	1	0
08/27/2024 16:00	0.7	12.3	1,950.4	0.7	1.4	1	1	1
08/27/2024 17:00	0.7	11.2	2,247.2	0.7	1.6	1	1	1
08/27/2024 18:00	0.7	11.5	2,221.4	0.7	1.6	1	1	1
08/27/2024 19:00	0.7	11.3	2,250.4	0.7	1.6	1	1	1
08/27/2024 20:00	0.7	11.2	2,280.7	0.7	1.6	1	1	1
08/27/2024 21:00	0.7	11.3	2,253.9	0.7	1.6	1	1	1
08/27/2024 22:00	0.7	12.0	2,116.9	0.7	1.5	1	1	1
08/27/2024 23:00	0.7	11.7	2,205.3	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.8	1,849.4	0.7	1.3	24 #	24 #	13 #
Minimum:	0.6	11.2	1,315.8	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,280.7	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2024 00:00	0.7	12.0	2,140.2	0.7	1.5	1	1	1
08/28/2024 01:00	0.7	12.5	2,007.6	0.7	1.4	1	1	1
08/28/2024 02:00	0.7	12.6	2,006.3	0.7	1.4	1	1	1
08/28/2024 03:00	0.7	12.2	2,087.0	0.7	1.5	1	1	1
08/28/2024 04:00	0.7	11.6	2,229.1	0.7	1.6	1	1	1
08/28/2024 05:00	0.7	11.6	2,225.9	0.7	1.6	1	1	1
08/28/2024 06:00	0.7	12.2	2,076.8	0.7	1.5	1	1	1
08/28/2024 07:00	0.7	12.5	2,004.9	0.7	1.4	1	1	1
08/28/2024 08:00	0.7	12.4	2,010.7	0.7	1.4	1	1	1
08/28/2024 09:00	0.7	12.3	2,018.0	0.7	1.4	1	1	1
08/28/2024 10:00	0.7	12.3	2,027.4	0.7	1.4	1	1	1
08/28/2024 11:00	0.7	12.2	2,036.3	0.7	1.4	1	1	1
08/28/2024 12:00	0.7	12.1	2,050.6	0.7	1.4	1	1	1
08/28/2024 13:00	0.7	11.8	2,109.7	0.7	1.5	1	1	1
08/28/2024 14:00	0.7	11.9	2,086.4	0.7	1.5	1	1	1
08/28/2024 15:00	0.7	12.0	2,065.6	0.7	1.4	1	1	1
08/28/2024 16:00	0.7	11.9	2,093.6	0.7	1.5	1	1	1
08/28/2024 17:00	0.7	12.0	2,068.3	0.7	1.4	1	1	1
08/28/2024 18:00	0.7	11.5	2,173.2	0.7	1.5	1	1	1
08/28/2024 19:00	0.7	11.1	2,274.0	0.7	1.6	1	1	1
08/28/2024 20:00	0.7	11.6	2,148.8	0.7	1.5	1	1	1
08/28/2024 21:00	0.7	12.3	2,024.7	0.7	1.4	1	1	1
08/28/2024 22:00	0.7	12.4	2,015.0	0.7	1.4	1	1	1
08/28/2024 23:00	0.7	12.6	1,999.8	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.1	2,082.5	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.1	1,999.8	0.7	1.4	1	1	1
Maximum:	0.7	12.6	2,274.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2024 00:00	0.7	12.5	2,001.6	0.7	1.4	1	1	1
08/29/2024 01:00	0.7	12.6	1,998.4	0.7	1.4	1	1	1
08/29/2024 02:00	0.7	12.6	1,993.5	0.7	1.4	1	1	1
08/29/2024 03:00	0.7	12.6	1,994.1	0.7	1.4	1	1	1
08/29/2024 04:00	0.7	12.5	2,035.7	0.7	1.4	1	1	1
08/29/2024 05:00	0.7	12.7	1,993.6	0.7	1.4	1	1	1
08/29/2024 06:00	0.6	13.7	1,744.1	0.6	1.2	1	1	0
08/29/2024 07:00	0.6	13.7	1,540.4	0.6	1.1	1	1	0
08/29/2024 08:00	0.6	13.8	1,323.8	0.6	0.9	1	1	0
08/29/2024 09:00	0.6	13.8	1,322.0	0.6	0.9	1	1	0
08/29/2024 10:00	0.6	13.8	1,322.6	0.6	0.9	1	1	0
08/29/2024 11:00	0.6	13.8	1,334.6	0.6	0.9	1	1	0
08/29/2024 12:00	0.6	13.7	1,591.4	0.6	1.1	1	1	0
08/29/2024 13:00	0.6	13.6	1,685.4	0.6	1.2	1	1	0
08/29/2024 14:00	0.6	13.6	1,729.8	0.6	1.2	1	1	0
08/29/2024 15:00	0.7	13.6	1,540.1	0.7	1.1	1	1	1
08/29/2024 16:00	0.7	12.0	2,086.2	0.7	1.5	1	1	1
08/29/2024 17:00	0.7	11.6	2,165.6	0.7	1.5	1	1	1
08/29/2024 18:00	0.7	12.0	2,082.7	0.7	1.5	1	1	1
08/29/2024 19:00	0.7	11.4	2,229.6	0.7	1.6	1	1	1
08/29/2024 20:00	0.7	11.8	2,129.1	0.7	1.5	1	1	1
08/29/2024 21:00	0.7	12.1	2,077.1	0.7	1.5	1	1	1
08/29/2024 22:00	0.7	12.5	2,006.5	0.7	1.4	1	1	1
08/29/2024 23:00	0.7	12.5	2,002.1	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.9	1,830.4	0.7	1.3	24 #	24 #	15 #
Minimum:	0.6	11.4	1,322.0	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,229.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2024 00:00	0.7	12.6	1,997.3	0.7	1.4	1	1	1
08/30/2024 01:00	0.7	12.6	1,993.5	0.7	1.4	1	1	1
08/30/2024 02:00	0.7	12.7	1,991.3	0.7	1.4	1	1	1
08/30/2024 03:00	0.7	12.7	1,989.5	0.7	1.4	1	1	1
08/30/2024 04:00	0.7	12.4	2,064.1	0.7	1.4	1	1	1
08/30/2024 05:00	0.7	12.0	2,116.4	0.7	1.5	1	1	1
08/30/2024 06:00	0.7	12.3	2,070.3	0.7	1.4	1	1	1
08/30/2024 07:00	0.7	13.6	1,400.5	0.7	1.0	1	1	1
08/30/2024 08:00	0.6	13.7	1,377.9	0.6	1.0	1	1	0
08/30/2024 09:00	0.6	13.7	1,327.3	0.6	0.9	1	1	0
08/30/2024 10:00	0.6	13.7	1,336.3	0.6	0.9	1	1	0
08/30/2024 11:00	0.6	13.8	1,374.8	0.6	1.0	1	1	0
08/30/2024 12:00	0.6	13.8	1,346.7	0.6	0.9	1	1	0
08/30/2024 13:00	0.6	13.7	1,677.6	0.6	1.2	1	1	0
08/30/2024 14:00	0.7	13.4	1,711.7	0.7	1.2	1	1	1
08/30/2024 15:00	0.7	11.9	2,084.0	0.7	1.5	1	1	1
08/30/2024 16:00	0.7	11.7	2,123.4	0.7	1.5	1	1	1
08/30/2024 17:00	0.7	11.2	2,228.6	0.7	1.6	1	1	1
08/30/2024 18:00	0.7	11.0	2,285.1	0.7	1.6	1	1	1
08/30/2024 19:00	0.7	11.1	2,276.3	0.7	1.6	1	1	1
08/30/2024 20:00	0.7	11.1	2,269.9	0.7	1.6	1	1	1
08/30/2024 21:00	0.7	11.4	2,209.0	0.7	1.5	1	1	1
08/30/2024 22:00	0.7	12.3	2,044.2	0.7	1.4	1	1	1
08/30/2024 23:00	0.7	11.4	2,234.8	0.7	1.6	1	1	1
Average/Sum#:	0.7	12.5	1,897.1	0.7	1.3	24 #	24 #	18 #
Minimum:	0.6	11.0	1,327.3	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,285.1	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2024 00:00	0.7	11.5	2,227.3	0.7	1.6	1	1	1
08/31/2024 01:00	0.7	11.6	2,219.0	0.7	1.6	1	1	1
08/31/2024 02:00	0.7	11.6	2,219.5	0.7	1.6	1	1	1
08/31/2024 03:00	0.7	11.6	2,212.7	0.7	1.5	1	1	1
08/31/2024 04:00	0.7	11.7	2,211.4	0.7	1.5	1	1	1
08/31/2024 05:00	0.7	12.1	2,092.0	0.7	1.5	1	1	1
08/31/2024 06:00	0.0	15.6	583.4	0.0	0.4	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 14:00	0.0	17.6	325.1	0.0	0.2	1	0	0
08/31/2024 15:00	0.0	14.9	1,047.9	0.0	0.7	1	0	0
08/31/2024 16:00	0.6	13.5	1,680.8	0.6	1.2	1	1	0
08/31/2024 17:00	0.7	12.8	1,829.6	0.7	1.3	1	1	1
08/31/2024 18:00	0.7	11.0	2,279.3	0.7	1.6	1	1	1
08/31/2024 19:00	0.7	11.0	2,291.1	0.7	1.6	1	1	1
08/31/2024 20:00	0.7	11.0	2,298.6	0.7	1.6	1	1	1
08/31/2024 21:00	0.7	11.0	2,303.8	0.7	1.6	1	1	1
08/31/2024 22:00	0.7	11.4	2,254.4	0.7	1.6	1	1	1
08/31/2024 23:00	0.7	11.2	2,292.0	0.7	1.6	1	1	1
Average/Sum#:	0.6	12.4	1,904.0	0.6	1.3	17 #	14 #	13 #
Minimum:	0.0	11.0	325.1	0.0	0.2	0	0	0
Maximum:	0.7	17.6	2,303.8	0.7	1.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2024 00:00	0.7	11.7	2,172.6	0.7	1.5	1	1	1
09/01/2024 01:00	0.7	11.8	2,163.1	0.7	1.5	1	1	1
09/01/2024 02:00	0.7	11.7	2,180.6	0.7	1.5	1	1	1
09/01/2024 03:00	0.7	12.2	2,084.2	0.7	1.5	1	1	1
09/01/2024 04:00	0.7	12.6	1,991.1	0.7	1.4	1	1	1
09/01/2024 05:00	0.7	12.7	1,944.5	0.7	1.4	1	1	1
09/01/2024 06:00	0.0	15.6	627.0	0.0	0.4	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 10:00	0.0	18.6	165.4	0.0	0.1	1	0	0
09/01/2024 11:00	0.0	15.6	767.1	0.0	0.5	1	0	0
09/01/2024 12:00	0.6	13.7	1,432.9	0.6	1.0	1	1	0
09/01/2024 13:00	0.6	13.7	1,384.8	0.6	1.0	1	1	0
09/01/2024 14:00	0.6	13.6	1,642.0	0.6	1.1	1	1	0
09/01/2024 15:00	0.6	13.7	1,574.0	0.6	1.1	1	1	0
09/01/2024 16:00	0.6	13.5	1,725.5	0.6	1.2	1	1	0
09/01/2024 17:00	0.7	13.4	1,726.7	0.7	1.2	1	1	1
09/01/2024 18:00	0.7	11.7	2,154.3	0.7	1.5	1	1	1
09/01/2024 19:00	0.7	11.3	2,230.2	0.7	1.6	1	1	1
09/01/2024 20:00	0.7	11.5	2,214.8	0.7	1.6	1	1	1
09/01/2024 21:00	0.7	11.3	2,254.1	0.7	1.6	1	1	1
09/01/2024 22:00	0.7	11.7	2,189.0	0.7	1.5	1	1	1
09/01/2024 23:00	0.7	11.7	2,179.7	0.7	1.5	1	1	1
Average/Sum#:	0.6	13.0	1,752.6	0.6	1.2	21 #	18 #	13 #
Minimum:	0.0	11.3	165.4	0.0	0.1	0	0	0
Maximum:	0.7	18.6	2,254.1	0.7	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2024 00:00	0.7	11.8	2,162.3	0.7	1.5	1	1	1
09/02/2024 01:00	0.7	12.1	2,090.9	0.7	1.5	1	1	1
09/02/2024 02:00	0.7	12.8	1,953.2	0.7	1.4	1	1	1
09/02/2024 03:00	0.7	12.8	1,953.4	0.7	1.4	1	1	1
09/02/2024 04:00	0.7	12.8	1,950.9	0.7	1.4	1	1	1
09/02/2024 05:00	0.7	12.8	1,953.5	0.7	1.4	1	1	1
09/02/2024 06:00	0.7	12.8	1,933.6	0.7	1.4	1	1	1
09/02/2024 07:00	0.0	15.4	642.2	0.0	0.4	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 10:00	0.0	17.2	447.6	0.0	0.3	1	0	0
09/02/2024 11:00	0.0	14.2	1,188.1	0.0	0.8	1	0	0
09/02/2024 12:00	0.6	13.8	1,374.2	0.6	1.0	1	1	0
09/02/2024 13:00	0.6	13.8	1,379.9	0.6	1.0	1	1	0
09/02/2024 14:00	0.6	13.5	1,713.1	0.6	1.2	1	1	0
09/02/2024 15:00	0.6	13.7	1,533.5	0.6	1.1	1	1	0
09/02/2024 16:00	0.6	13.6	1,691.7	0.6	1.2	1	1	0
09/02/2024 17:00	0.7	12.8	1,822.3	0.7	1.3	1	1	1
09/02/2024 18:00	0.7	11.1	2,284.0	0.7	1.6	1	1	1
09/02/2024 19:00	0.7	11.0	2,295.7	0.7	1.6	1	1	1
09/02/2024 20:00	0.7	11.5	2,196.8	0.7	1.5	1	1	1
09/02/2024 21:00	0.7	12.4	2,001.0	0.7	1.4	1	1	1
09/02/2024 22:00	0.7	12.4	2,027.3	0.7	1.4	1	1	1
09/02/2024 23:00	0.7	12.6	1,992.1	0.7	1.4	1	1	1
Average/Sum#:	0.6	13.0	1,754.0	0.6	1.2	22 #	19 #	14 #
Minimum:	0.0	11.0	447.6	0.0	0.3	0	0	0
Maximum:	0.7	17.2	2,295.7	0.7	1.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2024 00:00	0.7	12.6	1,977.4	0.7	1.4	1	1	1
09/03/2024 01:00	0.7	12.6	1,982.5	0.7	1.4	1	1	1
09/03/2024 02:00	0.7	12.7	1,979.1	0.7	1.4	1	1	1
09/03/2024 03:00	0.7	12.7	1,977.6	0.7	1.4	1	1	1
09/03/2024 04:00	0.7	12.6	1,995.8	0.7	1.4	1	1	1
09/03/2024 05:00	0.7	11.6	2,148.7	0.7	1.5	1	1	1
09/03/2024 06:00	0.7	12.2	2,092.4	0.7	1.5	1	1	1
09/03/2024 07:00	0.7	12.7	1,974.6	0.7	1.4	1	1	1
09/03/2024 08:00	0.7	12.6	1,985.5	0.7	1.4	1	1	1
09/03/2024 09:00	0.7	12.5	1,999.6	0.7	1.4	1	1	1
09/03/2024 10:00	0.7	12.4	2,019.0	0.7	1.4	1	1	1
09/03/2024 11:00	0.7	12.3	2,032.2	0.7	1.4	1	1	1
09/03/2024 12:00	0.7	11.8	2,129.7	0.7	1.5	1	1	1
09/03/2024 13:00	0.7	11.4	2,228.3	0.7	1.6	1	1	1
09/03/2024 14:00	0.7	11.3	2,255.6	0.7	1.6	1	1	1
09/03/2024 15:00	0.7	11.2	2,250.1	0.7	1.6	1	1	1
09/03/2024 16:00	0.7	11.3	2,243.1	0.7	1.6	1	1	1
09/03/2024 17:00	0.7	11.1	2,283.5	0.7	1.6	1	1	1
09/03/2024 18:00	0.7	11.1	2,293.5	0.7	1.6	1	1	1
09/03/2024 19:00	0.7	11.1	2,301.5	0.7	1.6	1	1	1
09/03/2024 20:00	0.7	11.1	2,308.6	0.7	1.6	1	1	1
09/03/2024 21:00	0.7	11.1	2,311.8	0.7	1.6	1	1	1
09/03/2024 22:00	0.7	11.1	2,311.6	0.7	1.6	1	1	1
09/03/2024 23:00	0.7	11.7	2,161.6	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.9	2,135.1	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.1	1,974.6	0.7	1.4	1	1	1
Maximum:	0.7	12.7	2,311.8	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2024 00:00	0.6	13.7	1,726.6	0.6	1.2	1	1	0
09/04/2024 01:00	0.6	13.7	1,737.4	0.6	1.2	1	1	0
09/04/2024 02:00	0.6	13.7	1,723.7	0.6	1.2	1	1	0
09/04/2024 03:00	0.6	13.7	1,740.4	0.6	1.2	1	1	0
09/04/2024 04:00	0.6	13.7	1,738.6	0.6	1.2	1	1	0
09/04/2024 05:00	0.6	13.7	1,714.3	0.6	1.2	1	1	0
09/04/2024 06:00	0.6	13.7	1,713.3	0.6	1.2	1	1	0
09/04/2024 07:00	0.6	13.7	1,744.3	0.6	1.2	1	1	0
09/04/2024 08:00	0.6	13.6	1,752.1	0.6	1.2	1	1	0
09/04/2024 09:00	0.6	13.6	1,750.7	0.6	1.2	1	1	0
09/04/2024 10:00	0.6	13.5	1,743.6	0.6	1.2	1	1	0
09/04/2024 11:00	0.6	13.5	1,752.2	0.6	1.2	1	1	0
09/04/2024 12:00	0.7	13.6	1,693.7	0.7	1.2	1	1	1
09/04/2024 13:00	0.7	11.5	2,177.8	0.7	1.5	1	1	1
09/04/2024 14:00	0.7	11.2	2,230.5	0.7	1.6	1	1	1
09/04/2024 15:00	0.7	11.5	2,154.3	0.7	1.5	1	1	1
09/04/2024 16:00	0.7	11.3	2,189.2	0.7	1.5	1	1	1
09/04/2024 17:00	0.7	11.4	2,191.0	0.7	1.5	1	1	1
09/04/2024 18:00	0.7	11.6	2,156.2	0.7	1.5	1	1	1
09/04/2024 19:00	0.7	11.0	2,268.0	0.7	1.6	1	1	1
09/04/2024 20:00	0.7	11.1	2,271.6	0.7	1.6	1	1	1
09/04/2024 21:00	0.7	11.2	2,251.1	0.7	1.6	1	1	1
09/04/2024 22:00	0.7	11.5	2,208.2	0.7	1.5	1	1	1
09/04/2024 23:00	0.7	11.4	2,239.6	0.7	1.6	1	1	1
Average/Sum#:	0.7	12.6	1,952.9	0.7	1.4	24 #	24 #	12 #
Minimum:	0.6	11.0	1,693.7	0.6	1.2	1	1	0
Maximum:	0.7	13.7	2,271.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2024 00:00	0.7	11.5	2,221.5	0.7	1.6	1	1	1
09/05/2024 01:00	0.7	11.5	2,218.0	0.7	1.6	1	1	1
09/05/2024 02:00	0.7	11.6	2,205.5	0.7	1.5	1	1	1
09/05/2024 03:00	0.7	12.3	2,042.1	0.7	1.4	1	1	1
09/05/2024 04:00	0.7	11.5	2,233.5	0.7	1.6	1	1	1
09/05/2024 05:00	0.7	11.1	2,316.0	0.7	1.6	1	1	1
09/05/2024 06:00	0.7	12.2	2,128.3	0.7	1.5	1	1	1
09/05/2024 07:00	0.6	13.7	1,729.6	0.6	1.2	1	1	0
09/05/2024 08:00	0.6	13.7	1,669.1	0.6	1.2	1	1	0
09/05/2024 09:00	0.6	13.6	1,737.2	0.6	1.2	1	1	0
09/05/2024 10:00	0.6	13.6	1,715.6	0.6	1.2	1	1	0
09/05/2024 11:00	0.6	13.5	1,736.7	0.6	1.2	1	1	0
09/05/2024 12:00	0.7	13.5	1,738.3	0.7	1.2	1	1	1
09/05/2024 13:00	0.7	11.6	2,150.9	0.7	1.5	1	1	1
09/05/2024 14:00	0.7	11.3	2,196.7	0.7	1.5	1	1	1
09/05/2024 15:00	0.7	11.3	2,191.2	0.7	1.5	1	1	1
09/05/2024 16:00	0.7	11.7	2,101.6	0.7	1.5	1	1	1
09/05/2024 17:00	0.7	11.5	2,151.6	0.7	1.5	1	1	1
09/05/2024 18:00	0.7	11.4	2,189.8	0.7	1.5	1	1	1
09/05/2024 19:00	0.7	11.4	2,193.3	0.7	1.5	1	1	1
09/05/2024 20:00	0.7	11.4	2,197.0	0.7	1.5	1	1	1
09/05/2024 21:00	0.7	11.2	2,246.8	0.7	1.6	1	1	1
09/05/2024 22:00	0.7	11.1	2,289.0	0.7	1.6	1	1	1
09/05/2024 23:00	0.7	11.5	2,211.9	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.0	2,075.5	0.7	1.4	24 #	24 #	19 #
Minimum:	0.6	11.1	1,669.1	0.6	1.2	1	1	0
Maximum:	0.7	13.7	2,316.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2024 00:00	0.7	11.5	2,208.4	0.7	1.5	1	1	1
09/06/2024 01:00	0.7	11.7	2,166.0	0.7	1.5	1	1	1
09/06/2024 02:00	0.7	12.4	2,021.3	0.7	1.4	1	1	1
09/06/2024 03:00	0.7	11.6	2,200.9	0.7	1.5	1	1	1
09/06/2024 04:00	0.7	11.5	2,238.2	0.7	1.6	1	1	1
09/06/2024 05:00	0.7	11.3	2,291.4	0.7	1.6	1	1	1
09/06/2024 06:00	0.7	11.7	2,189.2	0.7	1.5	1	1	1
09/06/2024 07:00	0.7	11.8	2,157.3	0.7	1.5	1	1	1
09/06/2024 08:00	0.7	11.9	2,114.1	0.7	1.5	1	1	1
09/06/2024 09:00	0.7	12.4	2,002.4	0.7	1.4	1	1	1
09/06/2024 10:00	0.7	12.1	2,073.9	0.7	1.5	1	1	1
09/06/2024 11:00	0.7	11.6	2,152.3	0.7	1.5	1	1	1
09/06/2024 12:00	0.7	11.4	2,189.1	0.7	1.5	1	1	1
09/06/2024 13:00	0.7	11.4	2,180.4	0.7	1.5	1	1	1
09/06/2024 14:00	0.7	11.4	2,191.1	0.7	1.5	1	1	1
09/06/2024 15:00	0.7	11.3	2,192.5	0.7	1.5	1	1	1
09/06/2024 16:00	0.7	11.6	2,130.6	0.7	1.5	1	1	1
09/06/2024 17:00	0.7	11.4	2,178.2	0.7	1.5	1	1	1
09/06/2024 18:00	0.7	11.3	2,215.2	0.7	1.6	1	1	1
09/06/2024 19:00	0.7	11.3	2,220.8	0.7	1.6	1	1	1
09/06/2024 20:00	0.7	11.4	2,229.3	0.7	1.6	1	1	1
09/06/2024 21:00	0.7	11.3	2,253.0	0.7	1.6	1	1	1
09/06/2024 22:00	0.7	11.4	2,239.5	0.7	1.6	1	1	1
09/06/2024 23:00	0.7	11.1	2,305.0	0.7	1.6	1	1	1
Average/Sum#:	0.7	11.6	2,180.8	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.1	2,002.4	0.7	1.4	1	1	1
Maximum:	0.7	12.4	2,305.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2024 00:00	0.7	11.1	2,307.9	0.7	1.6	1	1	1
09/07/2024 01:00	0.7	11.2	2,294.4	0.7	1.6	1	1	1
09/07/2024 02:00	0.7	11.6	2,209.6	0.7	1.5	1	1	1
09/07/2024 03:00	0.7	11.6	2,204.2	0.7	1.5	1	1	1
09/07/2024 04:00	0.7	11.5	2,234.7	0.7	1.6	1	1	1
09/07/2024 05:00	0.7	11.7	2,195.3	0.7	1.5	1	1	1
09/07/2024 06:00	0.7	12.0	2,112.3	0.7	1.5	1	1	1
09/07/2024 07:00	0.7	12.6	1,983.7	0.7	1.4	1	1	1
09/07/2024 08:00	0.7	12.6	1,984.4	0.7	1.4	1	1	1
09/07/2024 09:00	0.7	12.5	2,002.1	0.7	1.4	1	1	1
09/07/2024 10:00	0.7	12.0	2,105.2	0.7	1.5	1	1	1
09/07/2024 11:00	0.7	12.0	2,082.0	0.7	1.5	1	1	1
09/07/2024 12:00	0.7	11.5	2,184.7	0.7	1.5	1	1	1
09/07/2024 13:00	0.7	11.2	2,238.2	0.7	1.6	1	1	1
09/07/2024 14:00	0.7	11.1	2,259.9	0.7	1.6	1	1	1
09/07/2024 15:00	0.7	11.1	2,266.9	0.7	1.6	1	1	1
09/07/2024 16:00	0.7	11.5	2,172.6	0.7	1.5	1	1	1
09/07/2024 17:00	0.7	11.0	2,276.8	0.7	1.6	1	1	1
09/07/2024 18:00	0.7	11.0	2,293.1	0.7	1.6	1	1	1
09/07/2024 19:00	0.7	11.1	2,303.0	0.7	1.6	1	1	1
09/07/2024 20:00	0.7	11.1	2,309.0	0.7	1.6	1	1	1
09/07/2024 21:00	0.7	11.2	2,296.4	0.7	1.6	1	1	1
09/07/2024 22:00	0.7	11.7	2,202.6	0.7	1.5	1	1	1
09/07/2024 23:00	0.7	11.3	2,293.7	0.7	1.6	1	1	1
Average/Sum#:	0.7	11.6	2,200.5	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.0	1,983.7	0.7	1.4	1	1	1
Maximum:	0.7	12.6	2,309.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2024 00:00	0.7	11.9	2,157.7	0.7	1.5	1	1	1
09/08/2024 01:00	0.7	12.5	2,009.7	0.7	1.4	1	1	1
09/08/2024 02:00	0.7	11.9	2,175.8	0.7	1.5	1	1	1
09/08/2024 03:00	0.7	11.8	2,188.8	0.7	1.5	1	1	1
09/08/2024 04:00	0.7	12.5	2,027.2	0.7	1.4	1	1	1
09/08/2024 05:00	0.7	13.6	1,744.4	0.7	1.2	1	1	1
09/08/2024 06:00	0.6	13.7	1,665.7	0.6	1.2	1	1	0
09/08/2024 07:00	0.6	13.7	1,652.8	0.6	1.2	1	1	0
09/08/2024 08:00	0.6	13.7	1,622.6	0.6	1.1	1	1	0
09/08/2024 09:00	0.6	13.7	1,548.1	0.6	1.1	1	1	0
09/08/2024 10:00	0.6	13.8	1,540.0	0.6	1.1	1	1	0
09/08/2024 11:00	0.6	13.8	1,555.6	0.6	1.1	1	1	0
09/08/2024 12:00	0.6	13.7	1,644.1	0.6	1.2	1	1	0
09/08/2024 13:00	0.6	13.6	1,677.8	0.6	1.2	1	1	0
09/08/2024 14:00	0.7	12.8	1,840.0	0.7	1.3	1	1	1
09/08/2024 15:00	0.7	11.3	2,232.9	0.7	1.6	1	1	1
09/08/2024 16:00	0.7	11.7	2,138.0	0.7	1.5	1	1	1
09/08/2024 17:00	0.7	11.2	2,241.9	0.7	1.6	1	1	1
09/08/2024 18:00	0.7	11.2	2,259.7	0.7	1.6	1	1	1
09/08/2024 19:00	0.7	11.1	2,290.4	0.7	1.6	1	1	1
09/08/2024 20:00	0.7	11.1	2,292.3	0.7	1.6	1	1	1
09/08/2024 21:00	0.7	11.2	2,278.4	0.7	1.6	1	1	1
09/08/2024 22:00	0.7	11.4	2,222.3	0.7	1.6	1	1	1
09/08/2024 23:00	0.7	11.6	2,207.9	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.4	1,967.3	0.7	1.4	24 #	24 #	16 #
Minimum:	0.6	11.1	1,540.0	0.6	1.1	1	1	0
Maximum:	0.7	13.8	2,292.3	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2024 00:00	0.7	11.7	2,204.1	0.7	1.5	1	1	1
09/09/2024 01:00	0.7	12.2	2,074.2	0.7	1.5	1	1	1
09/09/2024 02:00	0.7	11.8	2,180.9	0.7	1.5	1	1	1
09/09/2024 03:00	0.7	11.6	2,202.7	0.7	1.5	1	1	1
09/09/2024 04:00	0.7	11.6	2,209.2	0.7	1.5	1	1	1
09/09/2024 05:00	0.7	11.2	2,284.3	0.7	1.6	1	1	1
09/09/2024 06:00	0.7	12.2	2,099.7	0.7	1.5	1	1	1
09/09/2024 07:00	0.7	12.7	1,982.1	0.7	1.4	1	1	1
09/09/2024 08:00	0.7	12.6	1,987.9	0.7	1.4	1	1	1
09/09/2024 09:00	0.7	11.8	2,159.4	0.7	1.5	1	1	1
09/09/2024 10:00	0.7	11.6	2,139.1	0.7	1.5	1	1	1
09/09/2024 11:00	0.7	11.8	2,094.6	0.7	1.5	1	1	1
09/09/2024 12:00	0.7	11.8	2,087.8	0.7	1.5	1	1	1
09/09/2024 13:00	0.7	11.7	2,092.1	0.7	1.5	1	1	1
09/09/2024 14:00	0.7	12.0	2,031.7	0.7	1.4	1	1	1
09/09/2024 15:00	0.7	11.6	2,094.1	0.7	1.5	1	1	1
09/09/2024 16:00	0.7	11.1	2,192.6	0.7	1.5	1	1	1
09/09/2024 17:00	0.7	11.3	2,154.1	0.7	1.5	1	1	1
09/09/2024 18:00	0.7	11.2	2,195.1	0.7	1.5	1	1	1
09/09/2024 19:00	0.7	11.3	2,180.1	0.7	1.5	1	1	1
09/09/2024 20:00	0.7	11.8	2,114.9	0.7	1.5	1	1	1
09/09/2024 21:00	0.7	11.8	2,104.3	0.7	1.5	1	1	1
09/09/2024 22:00	0.7	12.4	1,988.0	0.7	1.4	1	1	1
09/09/2024 23:00	0.7	11.6	2,172.5	0.7	1.5	1	1	1
Average/Sum#:	0.7	11.8	2,126.1	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.1	1,982.1	0.7	1.4	1	1	1
Maximum:	0.7	12.7	2,284.3	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2024 00:00	0.7	11.7	2,162.0	0.7	1.5	1	1	1
09/10/2024 01:00	0.7	12.3	2,029.7	0.7	1.4	1	1	1
09/10/2024 02:00	0.7	12.4	1,988.9	0.7	1.4	1	1	1
09/10/2024 03:00	0.7	12.3	2,023.3	0.7	1.4	1	1	1
09/10/2024 04:00	0.7	12.1	2,076.4	0.7	1.5	1	1	1
09/10/2024 05:00	0.7	11.3	2,204.5	0.7	1.5	1	1	1
09/10/2024 06:00	0.7	12.2	2,025.0	0.7	1.4	1	1	1
09/10/2024 07:00	0.6	13.7	1,553.1	0.6	1.1	1	1	0
09/10/2024 08:00	0.6	13.7	1,295.1	0.6	0.9	1	1	0
09/10/2024 09:00	0.6	13.8	1,297.4	0.6	0.9	1	1	0
09/10/2024 10:00	0.6	13.8	1,302.0	0.6	0.9	1	1	0
09/10/2024 11:00	0.6	13.8	1,299.3	0.6	0.9	1	1	0
09/10/2024 12:00	0.6	13.8	1,308.1	0.6	0.9	1	1	0
09/10/2024 13:00	0.6	13.7	1,393.8	0.6	1.0	1	1	0
09/10/2024 14:00	0.6	13.8	1,305.5	0.6	0.9	1	1	0
09/10/2024 15:00	0.6	13.8	1,322.2	0.6	0.9	1	1	0
09/10/2024 16:00	0.7	13.6	1,555.1	0.7	1.1	1	1	1
09/10/2024 17:00	0.7	12.2	1,991.1	0.7	1.4	1	1	1
09/10/2024 18:00	0.7	12.2	1,983.6	0.7	1.4	1	1	1
09/10/2024 19:00	0.7	12.4	1,967.0	0.7	1.4	1	1	1
09/10/2024 20:00	0.7	12.5	1,957.5	0.7	1.4	1	1	1
09/10/2024 21:00	0.7	12.6	1,947.8	0.7	1.4	1	1	1
09/10/2024 22:00	0.7	12.6	1,927.4	0.7	1.3	1	1	1
09/10/2024 23:00	0.0	15.4	642.6	0.0	0.4	1	0	0
Average/Sum#:	0.6	13.0	1,689.9	0.6	1.2	24 #	23 #	14 #
Minimum:	0.0	11.3	642.6	0.0	0.4	1	0	0
Maximum:	0.7	15.4	2,204.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 17:00	0.0	17.3	323.0	0.0	0.2	1	0	0
09/12/2024 18:00	0.0	16.9	400.6	0.0	0.3	1	0	0
09/12/2024 19:00	0.0	15.2	846.1	0.0	0.6	1	0	0
09/12/2024 20:00	0.6	13.8	1,587.1	0.6	1.1	1	1	0
09/12/2024 21:00	0.6	13.7	1,644.1	0.6	1.2	1	1	0
09/12/2024 22:00	0.6	13.6	1,687.5	0.6	1.2	1	1	0
09/12/2024 23:00	0.6	13.6	1,731.7	0.6	1.2	1	1	0
Average/Sum#:	0.3	14.9	1,174.3	0.3	0.8	7 #	4 #	0 #
Minimum:	0.0	13.6	323.0	0.0	0.2	0	0	0
Maximum:	0.6	17.3	1,731.7	0.6	1.2	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2024 00:00	0.6	13.6	1,723.4	0.6	1.2	1	1	0
09/13/2024 01:00	0.6	13.7	1,536.6	0.6	1.1	1	1	0
09/13/2024 02:00	0.6	13.7	1,534.9	0.6	1.1	1	1	0
09/13/2024 03:00	0.6	13.7	1,650.7	0.6	1.2	1	1	0
09/13/2024 04:00	0.6	13.7	1,725.8	0.6	1.2	1	1	0
09/13/2024 05:00	0.6	13.7	1,724.2	0.6	1.2	1	1	0
09/13/2024 06:00	0.6	13.6	1,589.8	0.6	1.1	1	1	0
09/13/2024 07:00	0.0	14.4	1,204.6	0.0	0.8	1	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 13:00	0.0	17.5	322.3	0.0	0.2	1	0	0
09/13/2024 14:00	0.0	15.4	858.0	0.0	0.6	1	0	0
09/13/2024 15:00	0.7	13.4	1,675.4	0.7	1.2	1	1	1
09/13/2024 16:00	0.7	11.4	2,149.0	0.7	1.5	1	1	1
09/13/2024 17:00	0.7	11.3	2,168.2	0.7	1.5	1	1	1
09/13/2024 18:00	0.7	13.3	1,726.8	0.7	1.2	1	1	1
09/13/2024 19:00	0.6	13.6	1,548.3	0.6	1.1	1	1	0
09/13/2024 20:00	0.6	13.6	1,672.5	0.6	1.2	1	1	0
09/13/2024 21:00	0.6	13.5	1,698.4	0.6	1.2	1	1	0
09/13/2024 22:00	0.6	13.6	1,690.6	0.6	1.2	1	1	0
09/13/2024 23:00	0.6	13.7	1,689.3	0.6	1.2	1	1	0
Average/Sum#:	0.5	13.7	1,573.1	0.5	1.1	19 #	16 #	4 #
Minimum:	0.0	11.3	322.3	0.0	0.2	0	0	0
Maximum:	0.7	17.5	2,168.2	0.7	1.5	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2024 00:00	0.6	13.7	1,689.0	0.6	1.2	1	1	0
09/14/2024 01:00	0.6	13.5	1,756.5	0.6	1.2	1	1	0
09/14/2024 02:00	0.0	14.0	1,417.7	0.0	1.0	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 16:00	0.0	16.6	464.7	0.0	0.3	1	0	0
09/14/2024 17:00	0.0	15.1	719.7	0.0	0.5	1	0	0
09/14/2024 18:00	0.0	14.2	1,229.4	0.0	0.9	1	0	0
09/14/2024 19:00	0.6	13.6	1,582.9	0.6	1.1	1	1	0
09/14/2024 20:00	0.6	13.7	1,536.3	0.6	1.1	1	1	0
09/14/2024 21:00	0.6	13.7	1,537.9	0.6	1.1	1	1	0
09/14/2024 22:00	0.6	13.6	1,571.5	0.6	1.1	1	1	0
09/14/2024 23:00	0.6	13.6	1,703.1	0.6	1.2	1	1	0
Average/Sum#:	0.4	14.1	1,382.6	0.4	1.0	11 #	7 #	0 #
Minimum:	0.0	13.5	464.7	0.0	0.3	0	0	0
Maximum:	0.6	16.6	1,756.5	0.6	1.2	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2024 00:00	0.6	13.7	1,689.9	0.6	1.2	1	1	0
09/15/2024 01:00	0.0	15.3	659.9	0.0	0.5	1	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 17:00	0.0	17.3	343.0	0.0	0.2	1	0	0
09/15/2024 18:00	0.0	15.6	672.5	0.0	0.5	1	0	0
09/15/2024 19:00	0.0	14.5	1,114.5	0.0	0.8	1	0	0
09/15/2024 20:00	0.6	13.7	1,540.3	0.6	1.1	1	1	0
09/15/2024 21:00	0.6	13.7	1,449.5	0.6	1.0	1	1	0
09/15/2024 22:00	0.6	13.7	1,471.5	0.6	1.0	1	1	0
09/15/2024 23:00	0.6	13.7	1,514.7	0.6	1.1	1	1	0
Average/Sum#:	0.3	14.6	1,161.8	0.3	0.8	9 #	5 #	0 #
Minimum:	0.0	13.7	343.0	0.0	0.2	0	0	0
Maximum:	0.6	17.3	1,689.9	0.6	1.2	1	1	0
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2024 00:00	0.6	13.7	1,655.4	0.6	1.2	1	1	0
09/16/2024 01:00	0.6	13.7	1,515.8	0.6	1.1	1	1	0
09/16/2024 02:00	0.6	13.7	1,481.7	0.6	1.0	1	1	0
09/16/2024 03:00	0.6	13.7	1,624.2	0.6	1.1	1	1	0
09/16/2024 04:00	0.6	13.6	1,724.1	0.6	1.2	1	1	0
09/16/2024 05:00	0.6	13.6	1,719.4	0.6	1.2	1	1	0
09/16/2024 06:00	0.6	13.7	1,677.1	0.6	1.2	1	1	0
09/16/2024 07:00	0.0	14.3	1,264.4	0.0	0.9	1	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.8	1,582.8	0.5	1.1	8 #	7 #	0 #
Minimum:	0.0	13.6	1,264.4	0.0	0.9	0	0	0
Maximum:	0.6	14.3	1,724.1	0.6	1.2	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 20:00	0.0	17.3	329.3	0.0	0.2	1	0	0
09/17/2024 21:00	0.0	16.9	398.0	0.0	0.3	1	0	0
09/17/2024 22:00	0.0	15.5	857.8	0.0	0.6	1	0	0
09/17/2024 23:00	0.6	13.6	1,661.2	0.6	1.2	1	1	0
Average/Sum#:	0.2	15.8	811.6	0.2	0.6	4 #	1 #	0 #
Minimum:	0.0	13.6	329.3	0.0	0.2	0	0	0
Maximum:	0.6	17.3	1,661.2	0.6	1.2	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2024 00:00	0.6	13.7	1,573.6	0.6	1.1	1	1	0
09/18/2024 01:00	0.6	13.5	1,717.9	0.6	1.2	1	1	0
09/18/2024 02:00	0.6	13.6	1,505.0	0.6	1.1	1	1	0
09/18/2024 03:00	0.6	13.7	1,489.6	0.6	1.0	1	1	0
09/18/2024 04:00	0.7	13.5	1,689.8	0.7	1.2	1	1	1
09/18/2024 05:00	0.7	11.9	2,054.3	0.7	1.4	1	1	1
09/18/2024 06:00	0.7	11.9	2,093.4	0.7	1.5	1	1	1
09/18/2024 07:00	0.7	12.6	1,956.2	0.7	1.4	1	1	1
09/18/2024 08:00	0.7	12.7	1,920.3	0.7	1.3	1	1	1
09/18/2024 09:00	0.7	12.7	1,932.4	0.7	1.4	1	1	1
09/18/2024 10:00	0.7	12.6	1,937.4	0.7	1.4	1	1	1
09/18/2024 11:00	0.7	12.6	1,943.4	0.7	1.4	1	1	1
09/18/2024 12:00	0.7	12.6	1,945.2	0.7	1.4	1	1	1
09/18/2024 13:00	0.7	12.5	1,955.5	0.7	1.4	1	1	1
09/18/2024 14:00	0.7	12.5	1,960.3	0.7	1.4	1	1	1
09/18/2024 15:00	0.7	12.5	1,949.4	0.7	1.4	1	1	1
09/18/2024 16:00	0.7	11.9	2,078.4	0.7	1.5	1	1	1
09/18/2024 17:00	0.7	11.3	2,191.0	0.7	1.5	1	1	1
09/18/2024 18:00	0.7	11.6	2,119.5	0.7	1.5	1	1	1
09/18/2024 19:00	0.7	11.6	2,136.9	0.7	1.5	1	1	1
09/18/2024 20:00	0.7	11.7	2,122.5	0.7	1.5	1	1	1
09/18/2024 21:00	0.7	11.7	2,123.6	0.7	1.5	1	1	1
09/18/2024 22:00	0.7	11.7	2,120.4	0.7	1.5	1	1	1
09/18/2024 23:00	0.7	11.7	2,122.1	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.4	1,943.3	0.7	1.4	24 #	24 #	20 #
Minimum:	0.6	11.3	1,489.6	0.6	1.0	1	1	0
Maximum:	0.7	13.7	2,191.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2024 00:00	0.7	11.7	2,123.7	0.7	1.5	1	1	1
09/19/2024 01:00	0.7	11.7	2,122.0	0.7	1.5	1	1	1
09/19/2024 02:00	0.7	11.7	2,124.9	0.7	1.5	1	1	1
09/19/2024 03:00	0.7	11.7	2,128.0	0.7	1.5	1	1	1
09/19/2024 04:00	0.7	11.7	2,126.6	0.7	1.5	1	1	1
09/19/2024 05:00	0.7	11.8	2,124.7	0.7	1.5	1	1	1
09/19/2024 06:00	0.7	12.0	2,027.8	0.7	1.4	1	1	1
09/19/2024 07:00	0.0	15.4	639.2	0.0	0.4	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	12.2	1,927.1	0.6	1.4	8 #	7 #	7 #
Minimum:	0.0	11.7	639.2	0.0	0.4	0	0	0
Maximum:	0.7	15.4	2,128.0	0.7	1.5	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 14:00	0.0	17.3	321.5	0.0	0.2	1	0	0
09/22/2024 15:00	0.0	14.8	945.5	0.0	0.7	1	0	0
09/22/2024 16:00	0.6	13.7	1,497.0	0.6	1.0	1	1	0
09/22/2024 17:00	0.7	13.7	1,614.5	0.7	1.1	1	1	1
09/22/2024 18:00	0.7	12.4	1,951.4	0.7	1.4	1	1	1
09/22/2024 19:00	0.7	12.3	1,964.3	0.7	1.4	1	1	1
09/22/2024 20:00	0.7	12.4	1,944.1	0.7	1.4	1	1	1
09/22/2024 21:00	0.7	12.4	1,940.1	0.7	1.4	1	1	1
09/22/2024 22:00	0.7	12.7	1,921.9	0.7	1.3	1	1	1
09/22/2024 23:00	0.7	12.7	1,922.9	0.7	1.3	1	1	1
Average/Sum#:	0.6	13.4	1,602.3	0.6	1.1	10 #	8 #	7 #
Minimum:	0.0	12.3	321.5	0.0	0.2	0	0	0
Maximum:	0.7	17.3	1,964.3	0.7	1.4	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2024 00:00	0.7	12.7	1,919.4	0.7	1.3	1	1	1
09/23/2024 01:00	0.7	12.7	1,916.3	0.7	1.3	1	1	1
09/23/2024 02:00	0.7	12.7	1,916.7	0.7	1.3	1	1	1
09/23/2024 03:00	0.7	12.7	1,917.8	0.7	1.3	1	1	1
09/23/2024 04:00	0.7	12.6	1,920.8	0.7	1.3	1	1	1
09/23/2024 05:00	0.7	12.6	1,909.0	0.7	1.3	1	1	1
09/23/2024 06:00	0.6	13.7	1,630.4	0.6	1.1	1	1	0
09/23/2024 07:00	0.6	13.7	1,570.3	0.6	1.1	1	1	0
09/23/2024 08:00	0.6	13.7	1,647.3	0.6	1.2	1	1	0
09/23/2024 09:00	0.6	13.7	1,511.8	0.6	1.1	1	1	0
09/23/2024 10:00	0.6	13.7	1,521.2	0.6	1.1	1	1	0
09/23/2024 11:00	0.6	13.6	1,652.4	0.6	1.2	1	1	0
09/23/2024 12:00	0.6	13.5	1,695.3	0.6	1.2	1	1	0
09/23/2024 13:00	0.7	13.5	1,694.3	0.7	1.2	1	1	1
09/23/2024 14:00	0.7	11.6	2,114.5	0.7	1.5	1	1	1
09/23/2024 15:00	0.7	11.2	2,182.0	0.7	1.5	1	1	1
09/23/2024 16:00	0.7	11.1	2,202.7	0.7	1.5	1	1	1
09/23/2024 17:00	0.7	11.0	2,210.5	0.7	1.5	1	1	1
09/23/2024 18:00	0.7	11.0	2,211.2	0.7	1.5	1	1	1
09/23/2024 19:00	0.7	11.0	2,218.2	0.7	1.6	1	1	1
09/23/2024 20:00	0.7	11.0	2,221.6	0.7	1.6	1	1	1
09/23/2024 21:00	0.7	11.1	2,228.1	0.7	1.6	1	1	1
09/23/2024 22:00	0.7	11.2	2,208.1	0.7	1.5	1	1	1
09/23/2024 23:00	0.7	12.0	2,043.0	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.4	1,927.6	0.7	1.3	24 #	24 #	17 #
Minimum:	0.6	11.0	1,511.8	0.6	1.1	1	1	0
Maximum:	0.7	13.7	2,228.1	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2024 00:00	0.7	13.6	1,693.6	0.7	1.2	1	1	1
09/24/2024 01:00	0.6	13.7	1,677.3	0.6	1.2	1	1	0
09/24/2024 02:00	0.6	13.7	1,640.8	0.6	1.1	1	1	0
09/24/2024 03:00	0.6	13.7	1,676.6	0.6	1.2	1	1	0
09/24/2024 04:00	0.6	13.7	1,686.2	0.6	1.2	1	1	0
09/24/2024 05:00	0.6	13.7	1,675.9	0.6	1.2	1	1	0
09/24/2024 06:00	0.6	13.7	1,636.9	0.6	1.1	1	1	0
09/24/2024 07:00	0.6	13.7	1,583.5	0.6	1.1	1	1	0
09/24/2024 08:00	0.6	13.7	1,509.7	0.6	1.1	1	1	0
09/24/2024 09:00	0.6	13.7	1,531.0	0.6	1.1	1	1	0
09/24/2024 10:00	0.6	13.7	1,563.2	0.6	1.1	1	1	0
09/24/2024 11:00	0.6	13.6	1,654.1	0.6	1.2	1	1	0
09/24/2024 12:00	0.6	13.7	1,390.3	0.6	1.0	1	1	0
09/24/2024 13:00	0.7	12.4	1,847.2	0.7	1.3	1	1	1
09/24/2024 14:00	0.7	11.2	2,155.9	0.7	1.5	1	1	1
09/24/2024 15:00	0.7	11.3	2,131.1	0.7	1.5	1	1	1
09/24/2024 16:00	0.7	11.1	2,170.7	0.7	1.5	1	1	1
09/24/2024 17:00	0.7	11.0	2,198.7	0.7	1.5	1	1	1
09/24/2024 18:00	0.7	11.1	2,174.2	0.7	1.5	1	1	1
09/24/2024 19:00	0.7	11.6	2,088.4	0.7	1.5	1	1	1
09/24/2024 20:00	0.7	11.4	2,145.6	0.7	1.5	1	1	1
09/24/2024 21:00	0.7	11.7	2,067.3	0.7	1.4	1	1	1
09/24/2024 22:00	0.7	12.0	2,017.7	0.7	1.4	1	1	1
09/24/2024 23:00	0.7	11.5	2,143.0	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.7	1,835.8	0.7	1.3	24 #	24 #	12 #
Minimum:	0.6	11.0	1,390.3	0.6	1.0	1	1	0
Maximum:	0.7	13.7	2,198.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2024 00:00	0.7	11.6	2,132.8	0.7	1.5	1	1	1
09/25/2024 01:00	0.7	11.7	2,100.1	0.7	1.5	1	1	1
09/25/2024 02:00	0.7	12.0	2,038.9	0.7	1.4	1	1	1
09/25/2024 03:00	0.7	11.8	2,096.4	0.7	1.5	1	1	1
09/25/2024 04:00	0.7	11.7	2,109.2	0.7	1.5	1	1	1
09/25/2024 05:00	0.7	11.7	2,106.7	0.7	1.5	1	1	1
09/25/2024 06:00	0.7	12.1	2,020.6	0.7	1.4	1	1	1
09/25/2024 07:00	0.0	15.3	682.9	0.0	0.5	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 14:00	0.0	18.1	245.0	0.0	0.2	1	0	0
09/25/2024 15:00	0.0	15.5	790.2	0.0	0.6	1	0	0
09/25/2024 16:00	0.6	13.7	1,422.7	0.6	1.0	1	1	0
09/25/2024 17:00	0.6	13.6	1,630.4	0.6	1.1	1	1	0
09/25/2024 18:00	0.6	13.5	1,651.5	0.6	1.2	1	1	0
09/25/2024 19:00	0.6	13.6	1,578.2	0.6	1.1	1	1	0
09/25/2024 20:00	0.6	13.7	1,496.2	0.6	1.0	1	1	0
09/25/2024 21:00	0.6	13.7	1,618.3	0.6	1.1	1	1	0
09/25/2024 22:00	0.6	13.7	1,401.1	0.6	1.0	1	1	0
09/25/2024 23:00	0.6	13.7	1,664.5	0.6	1.2	1	1	0
Average/Sum#:	0.5	13.4	1,599.2	0.5	1.1	18 #	15 #	7 #
Minimum:	0.0	11.6	245.0	0.0	0.2	0	0	0
Maximum:	0.7	18.1	2,132.8	0.7	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2024 00:00	0.6	13.7	1,685.2	0.6	1.2	1	1	0
09/26/2024 01:00	0.6	13.7	1,656.0	0.6	1.2	1	1	0
09/26/2024 02:00	0.6	13.7	1,628.6	0.6	1.1	1	1	0
09/26/2024 03:00	0.6	13.7	1,664.7	0.6	1.2	1	1	0
09/26/2024 04:00	0.6	13.7	1,687.6	0.6	1.2	1	1	0
09/26/2024 05:00	0.6	13.7	1,686.8	0.6	1.2	1	1	0
09/26/2024 06:00	0.6	13.7	1,630.2	0.6	1.1	1	1	0
09/26/2024 07:00	0.6	13.7	1,385.4	0.6	1.0	1	1	0
09/26/2024 08:00	0.0	15.6	566.6	0.0	0.4	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 14:00	0.0	17.6	315.4	0.0	0.2	1	0	0
09/26/2024 15:00	0.0	15.2	907.7	0.0	0.6	1	0	0
09/26/2024 16:00	0.6	13.5	1,697.3	0.6	1.2	1	1	0
09/26/2024 17:00	0.7	13.0	1,762.1	0.7	1.2	1	1	1
09/26/2024 18:00	0.7	11.7	2,092.8	0.7	1.5	1	1	1
09/26/2024 19:00	0.7	11.8	2,072.6	0.7	1.5	1	1	1
09/26/2024 20:00	0.7	12.1	2,015.7	0.7	1.4	1	1	1
09/26/2024 21:00	0.7	11.1	2,228.0	0.7	1.6	1	1	1
09/26/2024 22:00	0.7	11.5	2,145.2	0.7	1.5	1	1	1
09/26/2024 23:00	0.7	12.3	1,991.8	0.7	1.4	1	1	1
Average/Sum#:	0.5	13.4	1,622.1	0.5	1.1	19 #	16 #	7 #
Minimum:	0.0	11.1	315.4	0.0	0.2	0	0	0
Maximum:	0.7	17.6	2,228.0	0.7	1.6	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2024 00:00	0.7	12.7	1,906.1	0.7	1.3	1	1	1
09/27/2024 01:00	0.0	15.3	672.3	0.0	0.5	1	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 09:00	0.0	17.5	318.4	0.0	0.2	1	0	0
09/27/2024 10:00	0.0	15.4	834.1	0.0	0.6	1	0	0
09/27/2024 11:00	0.6	13.8	1,353.5	0.6	0.9	1	1	0
09/27/2024 12:00	0.6	13.8	1,339.5	0.6	0.9	1	1	0
09/27/2024 13:00	0.6	13.6	1,601.2	0.6	1.1	1	1	0
09/27/2024 14:00	0.6	13.7	1,435.7	0.6	1.0	1	1	0
09/27/2024 15:00	0.6	13.8	1,443.7	0.6	1.0	1	1	0
09/27/2024 16:00	0.7	13.7	1,527.4	0.7	1.1	1	1	1
09/27/2024 17:00	0.7	11.5	2,114.6	0.7	1.5	1	1	1
09/27/2024 18:00	0.7	11.0	2,217.0	0.7	1.6	1	1	1
09/27/2024 19:00	0.7	11.0	2,217.5	0.7	1.6	1	1	1
09/27/2024 20:00	0.7	11.0	2,226.3	0.7	1.6	1	1	1
09/27/2024 21:00	0.7	11.2	2,213.4	0.7	1.5	1	1	1
09/27/2024 22:00	0.7	11.6	2,132.3	0.7	1.5	1	1	1
09/27/2024 23:00	0.7	11.6	2,132.5	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.1	1,628.6	0.5	1.1	17 #	14 #	9 #
Minimum:	0.0	11.0	318.4	0.0	0.2	0	0	0
Maximum:	0.7	17.5	2,226.3	0.7	1.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2024 00:00	0.7	11.6	2,133.3	0.7	1.5	1	1	1
09/28/2024 01:00	0.7	11.6	2,132.3	0.7	1.5	1	1	1
09/28/2024 02:00	0.7	11.6	2,129.4	0.7	1.5	1	1	1
09/28/2024 03:00	0.7	11.6	2,127.1	0.7	1.5	1	1	1
09/28/2024 04:00	0.7	11.7	2,126.7	0.7	1.5	1	1	1
09/28/2024 05:00	0.7	11.7	2,126.5	0.7	1.5	1	1	1
09/28/2024 06:00	0.7	12.1	2,012.4	0.7	1.4	1	1	1
09/28/2024 07:00	0.0	15.4	629.3	0.0	0.4	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 15:00	0.0	16.2	654.0	0.0	0.5	1	0	0
09/28/2024 16:00	0.6	13.7	1,466.0	0.6	1.0	1	1	0
09/28/2024 17:00	0.6	13.7	1,491.6	0.6	1.0	1	1	0
09/28/2024 18:00	0.6	13.6	1,656.0	0.6	1.2	1	1	0
09/28/2024 19:00	0.6	13.5	1,689.8	0.6	1.2	1	1	0
09/28/2024 20:00	0.6	13.6	1,690.3	0.6	1.2	1	1	0
09/28/2024 21:00	0.6	13.6	1,689.9	0.6	1.2	1	1	0
09/28/2024 22:00	0.6	13.7	1,558.4	0.6	1.1	1	1	0
09/28/2024 23:00	0.6	13.6	1,693.7	0.6	1.2	1	1	0
Average/Sum#:	0.6	13.1	1,706.3	0.6	1.2	17 #	15 #	7 #
Minimum:	0.0	11.6	629.3	0.0	0.4	0	0	0
Maximum:	0.7	16.2	2,133.3	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2024 00:00	0.6	13.7	1,488.4	0.6	1.0	1	1	0
09/29/2024 01:00	0.6	13.7	1,494.5	0.6	1.0	1	1	0
09/29/2024 02:00	0.0	15.5	618.7	0.0	0.4	1	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 10:00	0.0	17.7	307.4	0.0	0.2	1	0	0
09/29/2024 11:00	0.0	15.4	832.1	0.0	0.6	1	0	0
09/29/2024 12:00	0.6	13.8	1,385.5	0.6	1.0	1	1	0
09/29/2024 13:00	0.6	13.8	1,351.1	0.6	0.9	1	1	0
09/29/2024 14:00	0.6	13.6	1,606.2	0.6	1.1	1	1	0
09/29/2024 15:00	0.6	13.8	1,362.9	0.6	1.0	1	1	0
09/29/2024 16:00	0.6	13.7	1,578.4	0.6	1.1	1	1	0
09/29/2024 17:00	0.7	13.4	1,715.9	0.7	1.2	1	1	1
09/29/2024 18:00	0.7	12.2	1,999.9	0.7	1.4	1	1	1
09/29/2024 19:00	0.7	11.4	2,173.1	0.7	1.5	1	1	1
09/29/2024 20:00	0.7	11.5	2,167.2	0.7	1.5	1	1	1
09/29/2024 21:00	0.7	11.9	2,091.1	0.7	1.5	1	1	1
09/29/2024 22:00	0.7	12.6	1,954.5	0.7	1.4	1	1	1
09/29/2024 23:00	0.7	11.7	2,143.8	0.7	1.5	1	1	1
Average/Sum#:	0.5	13.5	1,545.3	0.5	1.1	17 #	14 #	7 #
Minimum:	0.0	11.4	307.4	0.0	0.2	0	0	0
Maximum:	0.7	17.7	2,173.1	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:16 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2024 00:00	0.7	12.1	2,061.7	0.7	1.4	1	1	1
09/30/2024 01:00	0.7	12.6	1,943.4	0.7	1.4	1	1	1
09/30/2024 02:00	0.7	12.6	1,946.4	0.7	1.4	1	1	1
09/30/2024 03:00	0.7	12.5	1,996.6	0.7	1.4	1	1	1
09/30/2024 04:00	0.7	12.1	2,076.2	0.7	1.5	1	1	1
09/30/2024 05:00	0.7	11.8	2,141.6	0.7	1.5	1	1	1
09/30/2024 06:00	0.7	11.8	2,183.1	0.7	1.5	1	1	1
09/30/2024 07:00	0.7	12.9	1,875.0	0.7	1.3	1	1	1
09/30/2024 08:00	0.6	13.9	1,322.6	0.6	0.9	1	1	0
09/30/2024 09:00	0.6	13.9	1,317.5	0.6	0.9	1	1	0
09/30/2024 10:00	0.6	13.9	1,318.6	0.6	0.9	1	1	0
09/30/2024 11:00	0.6	13.9	1,434.4	0.6	1.0	1	1	0
09/30/2024 12:00	0.6	13.9	1,573.6	0.6	1.1	1	1	0
09/30/2024 13:00	0.7	13.7	1,683.3	0.7	1.2	1	1	1
09/30/2024 14:00	0.7	11.8	2,144.2	0.7	1.5	1	1	1
09/30/2024 15:00	0.7	11.8	2,144.9	0.7	1.5	1	1	1
09/30/2024 16:00	0.7	11.1	2,280.0	0.7	1.6	1	1	1
09/30/2024 17:00	0.7	11.1	2,293.4	0.7	1.6	1	1	1
09/30/2024 18:00	0.7	11.1	2,300.0	0.7	1.6	1	1	1
09/30/2024 19:00	0.7	11.1	2,302.3	0.7	1.6	1	1	1
09/30/2024 20:00	0.7	11.4	2,241.1	0.7	1.6	1	1	1
09/30/2024 21:00	0.7	11.2	2,304.6	0.7	1.6	1	1	1
09/30/2024 22:00	0.7	11.7	2,210.3	0.7	1.5	1	1	1
09/30/2024 23:00	0.7	12.1	2,126.8	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.3	1,967.6	0.7	1.4	24 #	24 #	19 #
Minimum:	0.6	11.1	1,317.5	0.6	0.9	1	1	0
Maximum:	0.7	13.9	2,304.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2024 00:00	0.0	15.3	740.2	0.0	0.2	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 13:00	0.0	17.6	354.5	0.0	0.1	1	0	0
07/01/2024 14:00	0.0	15.3	899.8	0.0	0.3	1	0	0
07/01/2024 15:00	0.2	14.0	1,351.1	0.3	0.4	1	1	0
07/01/2024 16:00	-0.1	13.9	1,569.4	0.1	0.5	1	1	1
07/01/2024 17:00	-0.5	12.0	2,130.6	-0.1	0.6	1	1	1
07/01/2024 18:00	-0.1	11.6	2,203.3	0.2	0.7	1	1	1
07/01/2024 19:00	-0.1	11.9	2,164.1	0.2	0.6	1	1	1
07/01/2024 20:00	-0.1	11.9	2,153.7	0.2	0.6	1	1	1
07/01/2024 21:00	-0.2	12.4	2,061.9	0.1	0.6	1	1	1
07/01/2024 22:00	-0.2	12.4	2,045.0	0.1	0.6	1	1	1
07/01/2024 23:00	0.0	15.5	701.1	0.0	0.2	1	0	0
Average/Sum#:	-0.1	13.7	1,531.2	0.1	0.5	12 #	8 #	7 #
Minimum:	-0.5	11.6	354.5	-0.1	0.1	0	0	0
Maximum:	0.2	17.6	2,203.3	0.3	0.7	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 15:00	0.0	18.5	194.3	0.0	0.1	1	0	0
07/02/2024 16:00	0.0	15.9	664.0	0.0	0.2	1	0	0
07/02/2024 17:00	0.0	13.8	1,638.1	0.0	0.5	1	0	0
07/02/2024 18:00	-0.5	12.9	1,852.0	-0.2	0.6	1	1	1
07/02/2024 19:00	-0.2	11.7	2,200.4	0.1	0.7	1	1	1
07/02/2024 20:00	-0.2	11.9	2,170.0	0.1	0.7	1	1	1
07/02/2024 21:00	-0.1	11.9	2,166.2	0.2	0.6	1	1	1
07/02/2024 22:00	-0.2	12.2	2,103.8	0.1	0.6	1	1	1
07/02/2024 23:00	-0.1	11.7	2,223.9	0.2	0.7	1	1	1
Average/Sum#:	-0.1	13.4	1,690.3	0.1	0.5	9 #	6 #	6 #
Minimum:	-0.5	11.7	194.3	-0.2	0.1	0	0	0
Maximum:	0.0	18.5	2,223.9	0.2	0.7	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2024 00:00	-0.1	11.9	2,199.5	0.2	0.7	1	1	1
07/03/2024 01:00	-0.2	12.3	2,094.1	0.1	0.6	1	1	1
07/03/2024 02:00	-0.4	12.5	2,066.0	-0.1	0.6	1	1	1
07/03/2024 03:00	-0.4	12.6	2,049.2	-0.1	0.6	1	1	1
07/03/2024 04:00	-0.4	12.5	2,055.5	-0.1	0.6	1	1	1
07/03/2024 05:00	-0.4	12.5	2,056.6	-0.1	0.6	1	1	1
07/03/2024 06:00	-0.4	12.5	2,062.4	-0.1	0.6	1	1	1
07/03/2024 07:00	-0.4	12.4	2,069.0	-0.1	0.6	1	1	1
07/03/2024 08:00	-0.4	12.4	2,075.1	-0.1	0.6	1	1	1
07/03/2024 09:00	-0.2	12.4	2,083.1	0.1	0.6	1	1	1
07/03/2024 10:00	-0.2	12.3	2,087.4	0.1	0.6	1	1	1
07/03/2024 11:00	-0.2	12.4	2,071.9	0.1	0.6	1	1	1
07/03/2024 12:00	-0.2	12.3	2,081.2	0.1	0.6	1	1	1
07/03/2024 13:00	-0.2	12.2	2,080.9	0.1	0.6	1	1	1
07/03/2024 14:00	-0.2	12.2	2,076.6	0.1	0.6	1	1	1
07/03/2024 15:00	-0.1	12.1	2,082.4	0.2	0.6	1	1	1
07/03/2024 16:00	-0.2	12.4	2,031.0	0.1	0.6	1	1	1
07/03/2024 17:00	-0.4	12.3	2,026.8	-0.1	0.6	1	1	1
07/03/2024 18:00	-0.4	12.3	2,038.8	-0.1	0.6	1	1	1
07/03/2024 19:00	-0.2	12.2	2,057.1	0.1	0.6	1	1	1
07/03/2024 20:00	-0.4	12.3	2,054.7	-0.1	0.6	1	1	1
07/03/2024 21:00	-0.2	12.4	2,052.4	0.1	0.6	1	1	1
07/03/2024 22:00	-0.2	12.4	2,050.4	0.1	0.6	1	1	1
07/03/2024 23:00	-0.4	12.5	2,039.4	-0.1	0.6	1	1	1
Average/Sum#:	-0.3	12.3	2,068.4	0.0	0.6	24 #	24 #	24 #
Minimum:	-0.4	11.9	2,026.8	-0.1	0.6	1	1	1
Maximum:	-0.1	12.6	2,199.5	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2024 00:00	-0.5	12.7	2,004.0	-0.2	0.6	1	1	1
07/04/2024 01:00	-0.5	12.7	1,977.6	-0.2	0.6	1	1	1
07/04/2024 02:00	0.0	15.5	666.5	0.0	0.2	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 13:00	0.0	17.7	329.8	0.0	0.1	1	0	0
07/04/2024 14:00	0.0	15.5	856.3	0.0	0.3	1	0	0
07/04/2024 15:00	0.2	13.9	1,531.4	0.3	0.5	1	1	0
07/04/2024 16:00	0.1	13.7	1,704.7	0.2	0.5	1	1	0
07/04/2024 17:00	-0.4	12.9	1,820.6	-0.1	0.5	1	1	1
07/04/2024 18:00	-0.1	11.8	2,143.0	0.2	0.6	1	1	1
07/04/2024 19:00	-0.1	12.0	2,116.6	0.2	0.6	1	1	1
07/04/2024 20:00	-0.2	12.3	2,050.0	0.1	0.6	1	1	1
07/04/2024 21:00	-0.2	12.3	2,041.8	0.1	0.6	1	1	1
07/04/2024 22:00	-0.4	12.5	2,028.9	-0.1	0.6	1	1	1
07/04/2024 23:00	-0.4	12.5	1,996.8	-0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.4	1,662.0	0.0	0.5	14 #	11 #	9 #
Minimum:	-0.5	11.8	329.8	-0.2	0.1	0	0	0
Maximum:	0.2	17.7	2,143.0	0.3	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2024 00:00	0.2	13.8	1,729.6	0.3	0.5	1	1	0
07/05/2024 01:00	0.1	13.8	1,722.9	0.2	0.5	1	1	0
07/05/2024 02:00	0.1	13.8	1,713.9	0.1	0.5	1	1	0
07/05/2024 03:00	0.1	13.8	1,743.3	0.2	0.5	1	1	0
07/05/2024 04:00	0.1	13.8	1,626.1	0.2	0.5	1	1	0
07/05/2024 05:00	0.1	13.8	1,659.3	0.2	0.5	1	1	0
07/05/2024 06:00	0.1	13.7	1,759.2	0.2	0.5	1	1	0
07/05/2024 07:00	0.1	13.7	1,755.4	0.2	0.5	1	1	0
07/05/2024 08:00	0.1	13.7	1,761.6	0.2	0.5	1	1	0
07/05/2024 09:00	0.1	13.6	1,758.5	0.2	0.5	1	1	0
07/05/2024 10:00	0.1	13.6	1,745.7	0.2	0.5	1	1	0
07/05/2024 11:00	0.1	13.6	1,737.0	0.2	0.5	1	1	0
07/05/2024 12:00	0.1	13.8	1,559.5	0.2	0.5	1	1	0
07/05/2024 13:00	-0.7	12.7	1,867.1	-0.2	0.6	1	1	1
07/05/2024 14:00	-0.1	11.5	2,152.1	0.2	0.6	1	1	1
07/05/2024 15:00	-0.1	11.8	2,104.0	0.2	0.6	1	1	1
07/05/2024 16:00	-0.1	11.8	2,107.0	0.2	0.6	1	1	1
07/05/2024 17:00	-0.1	11.8	2,108.5	0.2	0.6	1	1	1
07/05/2024 18:00	-0.1	11.9	2,092.2	0.2	0.6	1	1	1
07/05/2024 19:00	-0.1	11.9	2,101.2	0.2	0.6	1	1	1
07/05/2024 20:00	-0.1	12.0	2,091.4	0.2	0.6	1	1	1
07/05/2024 21:00	0.1	11.6	2,212.3	0.2	0.7	1	1	1
07/05/2024 22:00	0.1	11.8	2,140.1	0.2	0.6	1	1	1
07/05/2024 23:00	-0.2	12.4	2,046.0	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.9	1,887.2	0.2	0.6	24 #	24 #	11 #
Minimum:	-0.7	11.5	1,559.5	-0.2	0.5	1	1	0
Maximum:	0.2	13.8	2,212.3	0.3	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2024 00:00	-0.2	12.5	2,021.2	0.1	0.6	1	1	1
07/06/2024 01:00	-0.4	12.6	2,007.2	-0.1	0.6	1	1	1
07/06/2024 02:00	-0.4	12.6	2,007.7	-0.1	0.6	1	1	1
07/06/2024 03:00	-0.4	12.6	2,012.3	-0.1	0.6	1	1	1
07/06/2024 04:00	-0.4	12.7	2,005.4	-0.1	0.6	1	1	1
07/06/2024 05:00	-0.4	12.5	1,988.5	-0.1	0.6	1	1	1
07/06/2024 06:00	0.0	0.0	705.2	0.0	0.2	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 13:00	0.0	20.5	0.2	0.0	0.0	1	0	0
07/06/2024 14:00	0.0	15.5	853.7	0.0	0.3	1	0	0
07/06/2024 15:00	0.2	13.9	1,450.7	0.3	0.4	1	1	0
07/06/2024 16:00	-0.2	13.8	1,561.5	-0.1	0.5	1	1	1
07/06/2024 17:00	-0.4	12.0	2,101.8	-0.1	0.6	1	1	1
07/06/2024 18:00	-0.1	11.8	2,120.2	0.2	0.6	1	1	1
07/06/2024 19:00	-0.2	11.8	2,091.3	0.1	0.6	1	1	1
07/06/2024 20:00	-0.2	11.9	2,094.0	0.1	0.6	1	1	1
07/06/2024 21:00	-0.1	12.0	2,098.7	0.2	0.6	1	1	1
07/06/2024 22:00	-0.1	11.9	2,129.4	0.2	0.6	1	1	1
07/06/2024 23:00	0.1	11.5	2,223.4	0.2	0.7	1	1	1
Average/Sum#:	-0.2	13.1	1,748.5	0.0	0.5	18 #	15 #	14 #
Minimum:	-0.4	11.5	0.2	-0.1	0.0	0	0	0
Maximum:	0.2	20.5	2,223.4	0.3	0.7	1	1	1
%SI	29.17	29.17	25.00	29.17	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2024 00:00	-0.1	12.2	2,078.0	0.2	0.6	1	1	1
07/07/2024 01:00	-0.2	12.5	2,026.5	0.1	0.6	1	1	1
07/07/2024 02:00	-0.4	12.4	2,004.4	-0.1	0.6	1	1	1
07/07/2024 03:00	0.0	15.6	609.7	0.0	0.2	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 11:00	0.0	20.9	3.1	0.0	0.0	1	0	0
07/07/2024 12:00	0.0	16.0	720.2	0.0	0.2	1	0	0
07/07/2024 13:00	0.2	13.9	1,483.1	0.3	0.4	1	1	0
07/07/2024 14:00	0.3	13.9	1,427.5	0.4	0.4	1	1	0
07/07/2024 15:00	0.2	13.8	1,620.8	0.3	0.5	1	1	0
07/07/2024 16:00	0.2	13.8	1,560.6	0.3	0.5	1	1	0
07/07/2024 17:00	0.3	13.9	1,389.2	0.4	0.4	1	1	0
07/07/2024 18:00	-0.1	13.0	1,716.7	0.1	0.5	1	1	1
07/07/2024 19:00	-0.1	11.4	2,176.9	0.2	0.7	1	1	1
07/07/2024 20:00	0.1	11.5	2,156.9	0.2	0.6	1	1	1
07/07/2024 21:00	-0.1	12.1	2,045.2	0.2	0.6	1	1	1
07/07/2024 22:00	-0.2	12.3	2,022.3	0.1	0.6	1	1	1
07/07/2024 23:00	-0.1	12.0	2,093.4	0.2	0.6	1	1	1
Average/Sum#:	0.0	13.6	1,596.1	0.2	0.5	17 #	14 #	9 #
Minimum:	-0.4	11.4	3.1	-0.1	0.0	0	0	0
Maximum:	0.3	20.9	2,176.9	0.4	0.7	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2024 00:00	0.2	13.7	1,725.6	0.3	0.5	1	1	0
07/08/2024 01:00	0.2	13.8	1,711.5	0.3	0.5	1	1	0
07/08/2024 02:00	0.2	13.8	1,716.2	0.3	0.5	1	1	0
07/08/2024 03:00	0.2	13.8	1,717.9	0.3	0.5	1	1	0
07/08/2024 04:00	0.2	13.7	1,742.2	0.3	0.5	1	1	0
07/08/2024 05:00	0.2	13.7	1,758.7	0.3	0.5	1	1	0
07/08/2024 06:00	0.2	13.7	1,741.1	0.3	0.5	1	1	0
07/08/2024 07:00	0.2	13.7	1,728.4	0.3	0.5	1	1	0
07/08/2024 08:00	0.2	13.7	1,712.9	0.3	0.5	1	1	0
07/08/2024 09:00	0.2	13.6	1,702.8	0.3	0.5	1	1	0
07/08/2024 10:00	0.2	13.6	1,716.6	0.3	0.5	1	1	0
07/08/2024 11:00	0.2	13.5	1,710.8	0.3	0.5	1	1	0
07/08/2024 12:00	0.2	13.5	1,695.7	0.3	0.5	1	1	0
07/08/2024 13:00	0.2	13.8	1,589.0	0.3	0.5	1	1	0
07/08/2024 14:00	0.2	13.7	1,634.5	0.3	0.5	1	1	0
07/08/2024 15:00	0.2	13.6	1,672.6	0.3	0.5	1	1	0
07/08/2024 16:00	-0.1	13.6	1,587.9	0.1	0.5	1	1	1
07/08/2024 17:00	-0.2	11.8	2,105.0	0.1	0.6	1	1	1
07/08/2024 18:00	0.1	11.4	2,175.1	0.4	0.7	1	1	1
07/08/2024 19:00	0.2	11.4	2,186.1	0.4	0.7	1	1	1
07/08/2024 20:00	0.1	11.5	2,188.5	0.2	0.7	1	1	1
07/08/2024 21:00	0.1	11.7	2,148.3	0.2	0.6	1	1	1
07/08/2024 22:00	0.1	11.9	2,127.7	0.2	0.6	1	1	1
07/08/2024 23:00	0.2	11.6	2,207.6	0.4	0.7	1	1	1
Average/Sum#:	0.2	13.1	1,833.4	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	11.4	1,587.9	0.1	0.5	1	1	0
Maximum:	0.2	13.8	2,207.6	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2024 00:00	0.2	11.6	2,210.6	0.4	0.7	1	1	1
07/09/2024 01:00	0.1	11.7	2,186.7	0.2	0.7	1	1	1
07/09/2024 02:00	0.1	11.8	2,168.0	0.2	0.7	1	1	1
07/09/2024 03:00	0.1	11.9	2,167.0	0.2	0.7	1	1	1
07/09/2024 04:00	0.1	11.6	2,239.5	0.2	0.7	1	1	1
07/09/2024 05:00	0.1	11.7	2,205.6	0.2	0.7	1	1	1
07/09/2024 06:00	-0.4	12.5	2,013.5	-0.1	0.6	1	1	1
07/09/2024 07:00	-0.4	12.6	1,987.5	-0.1	0.6	1	1	1
07/09/2024 08:00	0.7	0.0	2,106.1	0.7	0.6	1	1	1
07/09/2024 09:00	0.7	0.0	2,082.6	0.7	0.6	1	1	1
07/09/2024 10:00	0.7	0.0	2,091.7	0.7	0.6	1	1	1
07/09/2024 11:00	0.7	0.0	2,189.6	0.7	0.7	1	1	1
07/09/2024 12:00	0.1	11.6	2,181.5	0.2	0.7	1	1	1
07/09/2024 13:00	0.1	11.7	2,144.3	0.2	0.6	1	1	1
07/09/2024 14:00	0.1	11.8	2,124.3	0.2	0.6	1	1	1
07/09/2024 15:00	0.1	11.8	2,127.1	0.2	0.6	1	1	1
07/09/2024 16:00	0.1	11.6	2,142.4	0.2	0.6	1	1	1
07/09/2024 17:00	0.1	11.6	2,160.8	0.2	0.6	1	1	1
07/09/2024 18:00	0.1	11.9	2,098.6	0.2	0.6	1	1	1
07/09/2024 19:00	0.2	11.5	2,186.1	0.4	0.7	1	1	1
07/09/2024 20:00	0.1	11.5	2,179.0	0.2	0.7	1	1	1
07/09/2024 21:00	0.1	11.7	2,154.4	0.2	0.6	1	1	1
07/09/2024 22:00	-0.1	11.9	2,122.5	0.2	0.6	1	1	1
07/09/2024 23:00	-0.2	12.2	2,052.9	0.1	0.6	1	1	1
Average/Sum#:	0.0	11.8	2,138.4	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,987.5	-0.1	0.6	1	1	1
Maximum:	0.2	12.6	2,239.5	0.4	0.7	1	1	1
%SI	16.67	16.67	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2024 00:00	-0.2	12.4	2,039.6	0.1	0.6	1	1	1
07/10/2024 01:00	0.1	11.6	2,204.7	0.2	0.7	1	1	1
07/10/2024 02:00	0.1	11.6	2,208.0	0.2	0.7	1	1	1
07/10/2024 03:00	0.1	11.7	2,195.8	0.2	0.7	1	1	1
07/10/2024 04:00	-0.1	11.8	2,180.3	0.2	0.7	1	1	1
07/10/2024 05:00	-0.1	11.9	2,140.4	0.2	0.6	1	1	1
07/10/2024 06:00	-0.2	12.4	2,021.0	0.1	0.6	1	1	1
07/10/2024 07:00	-0.4	12.5	1,981.9	-0.1	0.6	1	1	1
07/10/2024 08:00	-0.5	12.5	1,985.9	-0.2	0.6	1	1	1
07/10/2024 09:00	-0.4	12.4	1,996.6	-0.1	0.6	1	1	1
07/10/2024 10:00	-0.2	12.3	2,011.3	0.1	0.6	1	1	1
07/10/2024 11:00	-0.2	12.1	2,035.2	0.1	0.6	1	1	1
07/10/2024 12:00	-0.1	12.0	2,053.1	0.2	0.6	1	1	1
07/10/2024 13:00	0.1	11.6	2,158.3	0.2	0.6	1	1	1
07/10/2024 14:00	0.1	11.5	2,167.2	0.2	0.7	1	1	1
07/10/2024 15:00	0.1	11.8	2,110.5	0.2	0.6	1	1	1
07/10/2024 16:00	0.1	11.9	2,074.7	0.2	0.6	1	1	1
07/10/2024 17:00	0.1	12.0	2,064.9	0.2	0.6	1	1	1
07/10/2024 18:00	0.1	11.6	2,126.3	0.2	0.6	1	1	1
07/10/2024 19:00	0.1	11.4	2,178.2	0.4	0.7	1	1	1
07/10/2024 20:00	0.1	11.4	2,187.0	0.4	0.7	1	1	1
07/10/2024 21:00	0.1	11.4	2,195.8	0.4	0.7	1	1	1
07/10/2024 22:00	0.1	11.4	2,201.0	0.4	0.7	1	1	1
07/10/2024 23:00	0.1	11.4	2,202.4	0.4	0.7	1	1	1
Average/Sum#:	0.0	11.9	2,113.3	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.5	11.4	1,981.9	-0.2	0.6	1	1	1
Maximum:	0.1	12.5	2,208.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2024 00:00	-0.1	11.9	2,103.2	0.2	0.6	1	1	1
07/11/2024 01:00	-0.1	12.0	2,084.8	0.2	0.6	1	1	1
07/11/2024 02:00	-0.1	12.1	2,063.6	0.2	0.6	1	1	1
07/11/2024 03:00	-0.2	12.3	2,033.1	0.1	0.6	1	1	1
07/11/2024 04:00	0.1	11.5	2,203.6	0.2	0.7	1	1	1
07/11/2024 05:00	-0.2	12.4	1,996.4	0.1	0.6	1	1	1
07/11/2024 06:00	0.2	13.7	1,721.8	0.3	0.5	1	1	0
07/11/2024 07:00	0.2	13.7	1,713.9	0.3	0.5	1	1	0
07/11/2024 08:00	0.2	13.7	1,549.2	0.3	0.5	1	1	0
07/11/2024 09:00	0.2	13.9	1,505.5	0.3	0.5	1	1	0
07/11/2024 10:00	0.2	13.8	1,632.7	0.3	0.5	1	1	0
07/11/2024 11:00	0.2	13.9	1,468.0	0.3	0.4	1	1	0
07/11/2024 12:00	0.2	13.8	1,588.0	0.3	0.5	1	1	0
07/11/2024 13:00	0.2	13.8	1,582.6	0.3	0.5	1	1	0
07/11/2024 14:00	0.2	13.8	1,557.3	0.3	0.5	1	1	0
07/11/2024 15:00	0.2	14.0	1,331.5	0.3	0.4	1	1	0
07/11/2024 16:00	0.3	14.0	1,333.4	0.4	0.4	1	1	0
07/11/2024 17:00	-0.4	12.9	1,744.0	-0.1	0.5	1	1	1
07/11/2024 18:00	-0.2	11.7	2,104.3	0.1	0.6	1	1	1
07/11/2024 19:00	-0.1	11.6	2,121.1	0.2	0.6	1	1	1
07/11/2024 20:00	-0.1	12.0	2,047.6	0.2	0.6	1	1	1
07/11/2024 21:00	-0.2	12.2	2,015.3	0.1	0.6	1	1	1
07/11/2024 22:00	0.1	11.6	2,166.6	0.2	0.6	1	1	1
07/11/2024 23:00	-0.1	12.1	2,059.7	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.9	1,822.0	0.2	0.5	24 #	24 #	13 #
Minimum:	-0.4	11.5	1,331.5	-0.1	0.4	1	1	0
Maximum:	0.3	14.0	2,203.6	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2024 00:00	-0.2	12.2	2,056.0	0.1	0.6	1	1	1
07/12/2024 01:00	-0.2	12.2	2,061.7	0.1	0.6	1	1	1
07/12/2024 02:00	-0.2	12.3	2,034.1	0.1	0.6	1	1	1
07/12/2024 03:00	0.1	11.7	2,180.8	0.2	0.7	1	1	1
07/12/2024 04:00	-0.1	12.2	2,088.4	0.2	0.6	1	1	1
07/12/2024 05:00	-0.1	12.1	2,087.8	0.2	0.6	1	1	1
07/12/2024 06:00	0.2	13.7	1,733.6	0.3	0.5	1	1	0
07/12/2024 07:00	0.2	13.8	1,541.5	0.3	0.5	1	1	0
07/12/2024 08:00	0.2	13.9	1,475.4	0.3	0.4	1	1	0
07/12/2024 09:00	0.2	13.9	1,479.2	0.3	0.4	1	1	0
07/12/2024 10:00	0.2	13.9	1,503.7	0.3	0.5	1	1	0
07/12/2024 11:00	0.2	13.9	1,430.7	0.3	0.4	1	1	0
07/12/2024 12:00	0.2	13.9	1,470.7	0.3	0.4	1	1	0
07/12/2024 13:00	0.2	13.9	1,339.2	0.3	0.4	1	1	0
07/12/2024 14:00	0.1	13.9	1,352.3	0.2	0.4	1	1	0
07/12/2024 15:00	0.2	13.9	1,355.0	0.3	0.4	1	1	0
07/12/2024 16:00	0.2	14.0	1,341.5	0.3	0.4	1	1	0
07/12/2024 17:00	0.2	13.9	1,341.6	0.3	0.4	1	1	0
07/12/2024 18:00	0.2	13.9	1,331.6	0.3	0.4	1	1	0
07/12/2024 19:00	0.2	13.9	1,327.8	0.3	0.4	1	1	0
07/12/2024 20:00	0.2	13.9	1,326.9	0.3	0.4	1	1	0
07/12/2024 21:00	0.2	13.7	1,632.5	0.3	0.5	1	1	0
07/12/2024 22:00	0.2	13.6	1,733.5	0.3	0.5	1	1	0
07/12/2024 23:00	0.1	13.6	1,731.1	0.2	0.5	1	1	0
Average/Sum#:	0.1	13.4	1,623.2	0.3	0.5	24 #	24 #	6 #
Minimum:	-0.2	11.7	1,326.9	0.1	0.4	1	1	0
Maximum:	0.2	14.0	2,180.8	0.3	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2024 00:00	0.1	13.6	1,731.4	0.2	0.5	1	1	0
07/13/2024 01:00	0.1	13.6	1,731.0	0.2	0.5	1	1	0
07/13/2024 02:00	0.1	13.6	1,742.4	0.2	0.5	1	1	0
07/13/2024 03:00	0.1	13.6	1,748.8	0.2	0.5	1	1	0
07/13/2024 04:00	0.2	13.7	1,730.0	0.3	0.5	1	1	0
07/13/2024 05:00	0.2	13.6	1,752.8	0.3	0.5	1	1	0
07/13/2024 06:00	0.1	13.7	1,714.2	0.2	0.5	1	1	0
07/13/2024 07:00	0.1	13.6	1,732.9	0.1	0.5	1	1	0
07/13/2024 08:00	0.1	13.7	1,714.0	0.2	0.5	1	1	0
07/13/2024 09:00	0.2	13.8	1,559.7	0.3	0.5	1	1	0
07/13/2024 10:00	0.2	13.9	1,558.1	0.3	0.5	1	1	0
07/13/2024 11:00	0.2	13.8	1,627.8	0.3	0.5	1	1	0
07/13/2024 12:00	0.2	13.8	1,647.4	0.3	0.5	1	1	0
07/13/2024 13:00	0.2	13.9	1,377.1	0.3	0.4	1	1	0
07/13/2024 14:00	0.2	13.9	1,322.1	0.3	0.4	1	1	0
07/13/2024 15:00	0.2	13.9	1,326.9	0.3	0.4	1	1	0
07/13/2024 16:00	0.2	13.9	1,322.7	0.3	0.4	1	1	0
07/13/2024 17:00	0.2	13.9	1,333.5	0.3	0.4	1	1	0
07/13/2024 18:00	0.2	13.9	1,328.3	0.3	0.4	1	1	0
07/13/2024 19:00	0.2	13.8	1,463.2	0.3	0.4	1	1	0
07/13/2024 20:00	0.2	13.6	1,717.1	0.3	0.5	1	1	0
07/13/2024 21:00	0.2	13.6	1,714.8	0.3	0.5	1	1	0
07/13/2024 22:00	0.2	13.7	1,726.6	0.3	0.5	1	1	0
07/13/2024 23:00	0.2	13.7	1,734.3	0.3	0.5	1	1	0
Average/Sum#:	0.2	13.7	1,598.2	0.3	0.5	24 #	24 #	0 #
Minimum:	0.1	13.6	1,322.1	0.1	0.4	1	1	0
Maximum:	0.2	13.9	1,752.8	0.3	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2024 00:00	0.2	13.7	1,741.7	0.3	0.5	1	1	0
07/14/2024 01:00	0.2	13.8	1,649.7	0.3	0.5	1	1	0
07/14/2024 02:00	0.0	14.7	1,047.3	0.0	0.3	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 14:00	0.0	17.7	343.8	0.0	0.1	1	0	0
07/14/2024 15:00	0.0	14.3	1,324.5	0.0	0.4	1	0	0
07/14/2024 16:00	0.2	13.7	1,684.6	0.3	0.5	1	1	0
07/14/2024 17:00	-0.1	13.6	1,705.5	0.1	0.5	1	1	1
07/14/2024 18:00	-0.4	11.8	2,131.7	-0.1	0.6	1	1	1
07/14/2024 19:00	0.1	11.5	2,203.6	0.2	0.7	1	1	1
07/14/2024 20:00	0.1	11.6	2,187.1	0.2	0.7	1	1	1
07/14/2024 21:00	0.2	11.5	2,209.9	0.4	0.7	1	1	1
07/14/2024 22:00	-0.1	12.1	2,070.8	0.2	0.6	1	1	1
07/14/2024 23:00	-0.2	12.4	1,990.8	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.3	1,714.7	0.2	0.5	13 #	10 #	7 #
Minimum:	-0.4	11.5	343.8	-0.1	0.1	0	0	0
Maximum:	0.2	17.7	2,209.9	0.4	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2024 00:00	0.1	13.7	1,722.7	0.2	0.5	1	1	0
07/15/2024 01:00	0.2	13.7	1,736.1	0.3	0.5	1	1	0
07/15/2024 02:00	0.1	13.8	1,626.1	0.2	0.5	1	1	0
07/15/2024 03:00	0.2	13.8	1,713.3	0.3	0.5	1	1	0
07/15/2024 04:00	0.2	13.7	1,749.7	0.3	0.5	1	1	0
07/15/2024 05:00	0.2	13.8	1,715.7	0.3	0.5	1	1	0
07/15/2024 06:00	0.2	13.8	1,698.3	0.3	0.5	1	1	0
07/15/2024 07:00	0.2	13.8	1,709.8	0.3	0.5	1	1	0
07/15/2024 08:00	0.2	13.8	1,544.9	0.3	0.5	1	1	0
07/15/2024 09:00	0.3	13.8	1,486.3	0.4	0.4	1	1	0
07/15/2024 10:00	0.2	13.8	1,622.8	0.3	0.5	1	1	0
07/15/2024 11:00	0.2	13.7	1,701.0	0.3	0.5	1	1	0
07/15/2024 12:00	0.2	13.8	1,658.0	0.3	0.5	1	1	0
07/15/2024 13:00	0.2	13.8	1,661.7	0.3	0.5	1	1	0
07/15/2024 14:00	0.2	13.7	1,657.6	0.3	0.5	1	1	0
07/15/2024 15:00	0.2	13.9	1,591.1	0.3	0.5	1	1	0
07/15/2024 16:00	0.2	13.8	1,569.5	0.3	0.5	1	1	0
07/15/2024 17:00	-0.2	13.2	1,722.5	-0.1	0.5	1	1	1
07/15/2024 18:00	-0.1	11.8	2,127.9	0.2	0.6	1	1	1
07/15/2024 19:00	0.1	11.6	2,186.2	0.2	0.7	1	1	1
07/15/2024 20:00	0.1	11.7	2,178.7	0.2	0.7	1	1	1
07/15/2024 21:00	-0.1	12.0	2,119.0	0.2	0.6	1	1	1
07/15/2024 22:00	-0.4	12.8	1,987.8	-0.1	0.6	1	1	1
07/15/2024 23:00	-0.7	12.7	1,970.3	-0.2	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,769.0	0.2	0.5	24 #	24 #	7 #
Minimum:	-0.7	11.6	1,486.3	-0.2	0.4	1	1	0
Maximum:	0.3	13.9	2,186.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2024 00:00	-0.2	13.7	1,726.6	-0.1	0.5	1	1	1
07/16/2024 01:00	0.2	13.8	1,735.8	0.3	0.5	1	1	0
07/16/2024 02:00	0.2	13.8	1,743.5	0.3	0.5	1	1	0
07/16/2024 03:00	0.2	13.8	1,747.0	0.3	0.5	1	1	0
07/16/2024 04:00	0.2	13.8	1,743.6	0.3	0.5	1	1	0
07/16/2024 05:00	0.2	13.8	1,707.5	0.3	0.5	1	1	0
07/16/2024 06:00	0.3	13.8	1,689.6	0.4	0.5	1	1	0
07/16/2024 07:00	0.2	13.8	1,720.0	0.3	0.5	1	1	0
07/16/2024 08:00	0.2	13.8	1,597.3	0.3	0.5	1	1	0
07/16/2024 09:00	0.2	13.8	1,616.0	0.3	0.5	1	1	0
07/16/2024 10:00	0.2	13.8	1,655.5	0.3	0.5	1	1	0
07/16/2024 11:00	0.2	13.8	1,702.4	0.3	0.5	1	1	0
07/16/2024 12:00	0.2	13.8	1,639.4	0.3	0.5	1	1	0
07/16/2024 13:00	0.2	13.8	1,534.9	0.3	0.5	1	1	0
07/16/2024 14:00	0.3	14.0	1,324.4	0.4	0.4	1	1	0
07/16/2024 15:00	0.1	13.9	1,498.1	0.2	0.4	1	1	1
07/16/2024 16:00	-0.5	12.3	2,058.9	-0.1	0.6	1	1	1
07/16/2024 17:00	-0.1	11.8	2,152.5	0.2	0.6	1	1	1
07/16/2024 18:00	0.1	11.6	2,227.9	0.2	0.7	1	1	1
07/16/2024 19:00	0.1	11.6	2,230.5	0.2	0.7	1	1	1
07/16/2024 20:00	0.2	11.5	2,237.0	0.4	0.7	1	1	1
07/16/2024 21:00	0.1	11.5	2,244.8	0.2	0.7	1	1	1
07/16/2024 22:00	0.1	11.9	2,165.3	0.2	0.6	1	1	1
07/16/2024 23:00	-0.2	12.5	2,054.7	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,823.1	0.2	0.5	24 #	24 #	10 #
Minimum:	-0.5	11.5	1,324.4	-0.1	0.4	1	1	0
Maximum:	0.3	14.0	2,244.8	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2024 00:00	-0.4	12.7	2,023.8	-0.1	0.6	1	1	1
07/17/2024 01:00	-0.1	13.6	1,701.0	0.1	0.5	1	1	1
07/17/2024 02:00	0.3	13.8	1,715.4	0.4	0.5	1	1	0
07/17/2024 03:00	0.3	13.8	1,743.1	0.4	0.5	1	1	0
07/17/2024 04:00	0.3	13.8	1,743.7	0.4	0.5	1	1	0
07/17/2024 05:00	0.3	13.8	1,661.1	0.4	0.5	1	1	0
07/17/2024 06:00	0.3	13.8	1,705.4	0.4	0.5	1	1	0
07/17/2024 07:00	0.3	13.8	1,736.6	0.4	0.5	1	1	0
07/17/2024 08:00	0.3	13.8	1,703.5	0.4	0.5	1	1	0
07/17/2024 09:00	0.2	13.8	1,620.2	0.3	0.5	1	1	0
07/17/2024 10:00	0.2	13.9	1,428.5	0.3	0.4	1	1	0
07/17/2024 11:00	0.2	13.9	1,429.9	0.3	0.4	1	1	0
07/17/2024 12:00	0.2	13.9	1,538.1	0.3	0.5	1	1	0
07/17/2024 13:00	0.2	13.9	1,476.5	0.3	0.4	1	1	0
07/17/2024 14:00	-0.1	13.9	1,575.8	0.1	0.5	1	1	1
07/17/2024 15:00	-0.5	12.3	2,069.7	-0.1	0.6	1	1	1
07/17/2024 16:00	-0.4	12.4	2,043.3	-0.1	0.6	1	1	1
07/17/2024 17:00	-0.2	12.2	2,097.2	0.1	0.6	1	1	1
07/17/2024 18:00	0.1	11.6	2,219.2	0.2	0.7	1	1	1
07/17/2024 19:00	0.1	11.6	2,230.4	0.2	0.7	1	1	1
07/17/2024 20:00	0.1	11.6	2,230.8	0.2	0.7	1	1	1
07/17/2024 21:00	0.1	11.6	2,222.4	0.2	0.7	1	1	1
07/17/2024 22:00	0.1	11.6	2,215.7	0.2	0.7	1	1	1
07/17/2024 23:00	0.1	11.9	2,167.3	0.2	0.7	1	1	1
Average/Sum#:	0.1	13.0	1,845.8	0.2	0.6	24 #	24 #	12 #
Minimum:	-0.5	11.6	1,428.5	-0.1	0.4	1	1	0
Maximum:	0.3	13.9	2,230.8	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2024 00:00	-0.4	12.6	2,021.1	-0.1	0.6	1	1	1
07/18/2024 01:00	-0.4	12.5	2,036.6	-0.1	0.6	1	1	1
07/18/2024 02:00	-0.1	11.9	2,174.0	0.2	0.7	1	1	1
07/18/2024 03:00	-0.1	12.0	2,149.6	0.2	0.6	1	1	1
07/18/2024 04:00	-0.2	12.0	2,169.9	0.1	0.7	1	1	1
07/18/2024 05:00	-0.1	12.2	2,117.4	0.2	0.6	1	1	1
07/18/2024 06:00	-0.2	12.6	2,027.2	0.1	0.6	1	1	1
07/18/2024 07:00	-0.4	12.7	1,978.4	-0.1	0.6	1	1	1
07/18/2024 08:00	-0.4	12.6	2,020.0	-0.1	0.6	1	1	1
07/18/2024 09:00	-0.2	12.2	2,096.6	0.1	0.6	1	1	1
07/18/2024 10:00	-0.1	12.1	2,100.1	0.2	0.6	1	1	1
07/18/2024 11:00	-0.1	12.1	2,100.3	0.2	0.6	1	1	1
07/18/2024 12:00	-0.2	12.2	2,071.6	0.1	0.6	1	1	1
07/18/2024 13:00	-0.1	11.7	2,169.2	0.2	0.7	1	1	1
07/18/2024 14:00	0.1	11.6	2,179.3	0.2	0.7	1	1	1
07/18/2024 15:00	0.1	11.6	2,180.1	0.2	0.7	1	1	1
07/18/2024 16:00	0.1	11.6	2,189.3	0.2	0.7	1	1	1
07/18/2024 17:00	0.1	11.5	2,194.3	0.2	0.7	1	1	1
07/18/2024 18:00	0.1	11.5	2,196.4	0.2	0.7	1	1	1
07/18/2024 19:00	0.1	11.5	2,200.1	0.2	0.7	1	1	1
07/18/2024 20:00	0.1	11.5	2,208.5	0.2	0.7	1	1	1
07/18/2024 21:00	0.1	11.5	2,211.6	0.2	0.7	1	1	1
07/18/2024 22:00	0.1	11.5	2,224.2	0.2	0.7	1	1	1
07/18/2024 23:00	0.1	11.9	2,143.3	0.2	0.6	1	1	1
Average/Sum#:	-0.1	12.0	2,131.6	0.1	0.7	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,978.4	-0.1	0.6	1	1	1
Maximum:	0.1	12.7	2,224.2	0.2	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2024 00:00	-0.1	12.2	2,089.2	0.2	0.6	1	1	1
07/19/2024 01:00	-0.1	12.3	2,066.9	0.2	0.6	1	1	1
07/19/2024 02:00	-0.1	12.2	2,094.0	0.2	0.6	1	1	1
07/19/2024 03:00	-0.2	12.6	2,000.0	0.1	0.6	1	1	1
07/19/2024 04:00	0.1	11.9	2,180.9	0.2	0.7	1	1	1
07/19/2024 05:00	-0.1	12.3	2,074.3	0.2	0.6	1	1	1
07/19/2024 06:00	0.1	13.7	1,737.8	0.2	0.5	1	1	1
07/19/2024 07:00	0.3	13.7	1,750.7	0.4	0.5	1	1	0
07/19/2024 08:00	0.3	13.7	1,752.7	0.4	0.5	1	1	0
07/19/2024 09:00	0.2	13.7	1,756.1	0.3	0.5	1	1	0
07/19/2024 10:00	0.2	13.6	1,751.0	0.3	0.5	1	1	0
07/19/2024 11:00	0.2	13.6	1,747.5	0.3	0.5	1	1	0
07/19/2024 12:00	-0.1	13.6	1,736.9	0.1	0.5	1	1	1
07/19/2024 13:00	-0.2	11.8	2,158.5	0.1	0.6	1	1	1
07/19/2024 14:00	0.1	11.5	2,199.2	0.2	0.7	1	1	1
07/19/2024 15:00	0.1	11.5	2,195.3	0.2	0.7	1	1	1
07/19/2024 16:00	0.2	11.5	2,188.5	0.4	0.7	1	1	1
07/19/2024 17:00	0.1	11.5	2,183.5	0.2	0.7	1	1	1
07/19/2024 18:00	0.1	11.5	2,182.3	0.2	0.7	1	1	1
07/19/2024 19:00	0.1	11.5	2,176.0	0.2	0.7	1	1	1
07/19/2024 20:00	0.1	11.7	2,159.5	0.2	0.6	1	1	1
07/19/2024 21:00	0.1	12.0	2,133.2	0.2	0.6	1	1	1
07/19/2024 22:00	0.2	11.6	2,212.8	0.4	0.7	1	1	1
07/19/2024 23:00	0.1	11.5	2,222.7	0.2	0.7	1	1	1
Average/Sum#:	0.1	12.4	2,031.2	0.2	0.6	24 #	24 #	19 #
Minimum:	-0.2	11.5	1,736.9	0.1	0.5	1	1	0
Maximum:	0.3	13.7	2,222.7	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2024 00:00	0.1	11.5	2,219.7	0.2	0.7	1	1	1
07/20/2024 01:00	0.2	11.6	2,229.8	0.4	0.7	1	1	1
07/20/2024 02:00	0.2	11.6	2,230.8	0.4	0.7	1	1	1
07/20/2024 03:00	0.2	11.6	2,234.2	0.4	0.7	1	1	1
07/20/2024 04:00	0.2	11.6	2,236.4	0.4	0.7	1	1	1
07/20/2024 05:00	0.1	12.0	2,127.3	0.2	0.6	1	1	1
07/20/2024 06:00	-0.1	13.7	1,707.9	0.1	0.5	1	1	1
07/20/2024 07:00	0.2	13.8	1,733.9	0.3	0.5	1	1	0
07/20/2024 08:00	0.2	13.8	1,575.5	0.3	0.5	1	1	0
07/20/2024 09:00	0.2	13.8	1,609.3	0.3	0.5	1	1	0
07/20/2024 10:00	0.2	13.7	1,714.5	0.3	0.5	1	1	0
07/20/2024 11:00	0.2	13.7	1,623.1	0.3	0.5	1	1	0
07/20/2024 12:00	0.2	14.0	1,339.9	0.3	0.4	1	1	0
07/20/2024 13:00	-0.1	13.8	1,629.6	0.1	0.5	1	1	1
07/20/2024 14:00	-0.2	11.9	2,118.6	0.1	0.6	1	1	1
07/20/2024 15:00	-0.1	11.7	2,141.5	0.2	0.6	1	1	1
07/20/2024 16:00	0.1	11.6	2,151.8	0.2	0.6	1	1	1
07/20/2024 17:00	0.2	11.5	2,174.2	0.4	0.7	1	1	1
07/20/2024 18:00	0.2	11.4	2,179.3	0.4	0.7	1	1	1
07/20/2024 19:00	0.1	11.7	2,130.0	0.2	0.6	1	1	1
07/20/2024 20:00	0.1	11.8	2,117.5	0.2	0.6	1	1	1
07/20/2024 21:00	0.1	11.9	2,113.2	0.2	0.6	1	1	1
07/20/2024 22:00	0.1	11.5	2,198.9	0.2	0.7	1	1	1
07/20/2024 23:00	0.1	11.5	2,216.2	0.2	0.7	1	1	1
Average/Sum#:	0.1	12.4	1,989.7	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.2	11.4	1,339.9	0.1	0.4	1	1	0
Maximum:	0.2	14.0	2,236.4	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2024 00:00	0.2	11.5	2,230.7	0.4	0.7	1	1	1
07/21/2024 01:00	0.2	11.7	2,197.4	0.4	0.7	1	1	1
07/21/2024 02:00	0.1	11.9	2,171.9	0.2	0.7	1	1	1
07/21/2024 03:00	0.1	11.9	2,168.9	0.2	0.7	1	1	1
07/21/2024 04:00	0.1	11.9	2,172.3	0.2	0.7	1	1	1
07/21/2024 05:00	0.0	13.3	1,533.1	0.0	0.5	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 23:00	0.0	20.9	0.2	0.0	0.0	1	0	0
Average/Sum#:	0.1	13.3	1,782.1	0.2	0.6	7 #	5 #	6 #
Minimum:	0.0	11.5	0.2	0.0	0.0	0	0	0
Maximum:	0.2	20.9	2,230.7	0.4	0.7	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 03:00	0.0	17.0	474.6	0.0	0.1	1	0	0
07/22/2024 04:00	0.0	14.0	1,341.9	0.0	0.4	1	0	0
07/22/2024 05:00	0.3	13.7	1,637.3	0.4	0.5	1	1	0
07/22/2024 06:00	0.2	13.7	1,718.5	0.3	0.5	1	1	0
07/22/2024 07:00	0.3	13.7	1,705.8	0.4	0.5	1	1	0
07/22/2024 08:00	0.2	13.8	1,696.9	0.3	0.5	1	1	0
07/22/2024 09:00	0.2	13.8	1,683.5	0.3	0.5	1	1	0
07/22/2024 10:00	0.2	13.8	1,668.6	0.3	0.5	1	1	0
07/22/2024 11:00	0.2	13.8	1,651.5	0.3	0.5	1	1	0
07/22/2024 12:00	-0.2	12.9	1,789.8	0.1	0.5	1	1	1
07/22/2024 13:00	0.1	11.5	2,159.5	0.2	0.6	1	1	1
07/22/2024 14:00	0.2	11.6	2,150.2	0.4	0.6	1	1	1
07/22/2024 15:00	0.2	11.5	2,152.5	0.4	0.6	1	1	1
07/22/2024 16:00	0.2	11.5	2,167.5	0.4	0.7	1	1	1
07/22/2024 17:00	0.2	11.5	2,176.5	0.4	0.7	1	1	1
07/22/2024 18:00	0.2	11.5	2,173.0	0.4	0.7	1	1	1
07/22/2024 19:00	0.2	11.5	2,160.0	0.4	0.6	1	1	1
07/22/2024 20:00	0.1	11.7	2,123.2	0.2	0.6	1	1	1
07/22/2024 21:00	0.1	11.9	2,096.9	0.2	0.6	1	1	1
07/22/2024 22:00	0.2	11.5	2,185.0	0.4	0.7	1	1	1
07/22/2024 23:00	0.2	11.5	2,213.1	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.7	1,863.1	0.3	0.6	21 #	19 #	12 #
Minimum:	-0.2	11.5	474.6	0.0	0.1	0	0	0
Maximum:	0.3	17.0	2,213.1	0.4	0.7	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2024 00:00	0.2	11.5	2,215.9	0.4	0.7	1	1	1
07/23/2024 01:00	0.2	11.5	2,219.0	0.4	0.7	1	1	1
07/23/2024 02:00	0.2	11.5	2,230.8	0.4	0.7	1	1	1
07/23/2024 03:00	0.2	11.5	2,232.9	0.4	0.7	1	1	1
07/23/2024 04:00	0.2	11.5	2,239.4	0.4	0.7	1	1	1
07/23/2024 05:00	0.1	11.5	2,244.3	0.2	0.7	1	1	1
07/23/2024 06:00	-0.1	12.3	2,064.4	0.2	0.6	1	1	1
07/23/2024 07:00	0.1	12.0	2,118.2	0.2	0.6	1	1	1
07/23/2024 08:00	-0.1	12.3	2,024.9	0.2	0.6	1	1	1
07/23/2024 09:00	0.1	12.1	2,077.8	0.2	0.6	1	1	1
07/23/2024 10:00	0.1	11.9	2,112.2	0.2	0.6	1	1	1
07/23/2024 11:00	0.2	11.6	2,175.2	0.4	0.7	1	1	1
07/23/2024 12:00	0.1	11.9	2,111.8	0.2	0.6	1	1	1
07/23/2024 13:00	0.1	12.0	2,083.6	0.2	0.6	1	1	1
07/23/2024 14:00	0.2	11.8	2,128.7	0.4	0.6	1	1	1
07/23/2024 15:00	0.2	11.7	2,139.9	0.4	0.6	1	1	1
07/23/2024 16:00	0.2	11.5	2,179.1	0.4	0.7	1	1	1
07/23/2024 17:00	0.2	11.4	2,184.5	0.4	0.7	1	1	1
07/23/2024 18:00	0.2	11.4	2,185.1	0.4	0.7	1	1	1
07/23/2024 19:00	0.2	11.6	2,162.9	0.4	0.6	1	1	1
07/23/2024 20:00	0.2	11.5	2,200.7	0.4	0.7	1	1	1
07/23/2024 21:00	0.2	11.5	2,205.4	0.4	0.7	1	1	1
07/23/2024 22:00	0.2	11.8	2,163.3	0.4	0.6	1	1	1
07/23/2024 23:00	0.2	11.6	2,227.2	0.4	0.7	1	1	1
Average/Sum#:	0.2	11.7	2,163.6	0.3	0.7	24 #	24 #	24 #
Minimum:	-0.1	11.4	2,024.9	0.2	0.6	1	1	1
Maximum:	0.2	12.3	2,244.3	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2024 00:00	0.1	11.8	2,162.2	0.2	0.6	1	1	1
07/24/2024 01:00	0.1	11.9	2,143.0	0.2	0.6	1	1	1
07/24/2024 02:00	0.1	11.9	2,148.9	0.2	0.6	1	1	1
07/24/2024 03:00	0.2	11.7	2,217.3	0.4	0.7	1	1	1
07/24/2024 04:00	0.2	11.7	2,224.5	0.4	0.7	1	1	1
07/24/2024 05:00	0.2	11.6	2,243.1	0.4	0.7	1	1	1
07/24/2024 06:00	0.1	12.1	2,119.1	0.2	0.6	1	1	1
07/24/2024 07:00	0.1	12.2	2,107.8	0.2	0.6	1	1	1
07/24/2024 08:00	0.1	12.2	2,095.3	0.2	0.6	1	1	1
07/24/2024 09:00	0.1	12.2	2,084.4	0.2	0.6	1	1	1
07/24/2024 10:00	-0.1	12.2	2,076.0	0.2	0.6	1	1	1
07/24/2024 11:00	0.1	12.1	2,090.9	0.2	0.6	1	1	1
07/24/2024 12:00	0.1	11.9	2,125.1	0.2	0.6	1	1	1
07/24/2024 13:00	0.1	12.0	2,086.9	0.2	0.6	1	1	1
07/24/2024 14:00	0.2	11.8	2,115.8	0.4	0.6	1	1	1
07/24/2024 15:00	0.2	11.6	2,138.3	0.4	0.6	1	1	1
07/24/2024 16:00	0.1	12.3	2,029.2	0.2	0.6	1	1	1
07/24/2024 17:00	-0.1	12.4	2,006.3	0.2	0.6	1	1	1
07/24/2024 18:00	-0.1	12.4	2,016.7	0.2	0.6	1	1	1
07/24/2024 19:00	-0.1	12.4	2,037.3	0.2	0.6	1	1	1
07/24/2024 20:00	-0.1	12.4	2,044.5	0.2	0.6	1	1	1
07/24/2024 21:00	0.1	12.0	2,161.2	0.2	0.6	1	1	1
07/24/2024 22:00	0.2	11.7	2,227.1	0.4	0.7	1	1	1
07/24/2024 23:00	0.1	12.0	2,156.3	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.0	2,119.1	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.6	2,006.3	0.2	0.6	1	1	1
Maximum:	0.2	12.4	2,243.1	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2024 00:00	0.1	12.3	2,092.2	0.2	0.6	1	1	1
07/25/2024 01:00	-0.1	12.4	2,082.4	0.2	0.6	1	1	1
07/25/2024 02:00	-0.1	12.4	2,073.8	0.2	0.6	1	1	1
07/25/2024 03:00	0.1	12.1	2,144.4	0.2	0.6	1	1	1
07/25/2024 04:00	0.1	12.0	2,171.7	0.2	0.7	1	1	1
07/25/2024 05:00	0.2	12.0	2,164.4	0.4	0.6	1	1	1
07/25/2024 06:00	0.1	12.3	2,105.5	0.2	0.6	1	1	1
07/25/2024 07:00	0.1	12.2	2,112.2	0.2	0.6	1	1	1
07/25/2024 08:00	0.1	12.2	2,101.8	0.2	0.6	1	1	1
07/25/2024 09:00	0.1	12.3	2,090.3	0.2	0.6	1	1	1
07/25/2024 10:00	-0.1	12.4	2,059.1	0.2	0.6	1	1	1
07/25/2024 11:00	0.1	12.0	2,126.7	0.2	0.6	1	1	1
07/25/2024 12:00	0.1	12.0	2,128.3	0.2	0.6	1	1	1
07/25/2024 13:00	0.1	12.0	2,122.3	0.2	0.6	1	1	1
07/25/2024 14:00	0.1	11.8	2,135.0	0.2	0.6	1	1	1
07/25/2024 15:00	0.2	11.7	2,158.0	0.4	0.6	1	1	1
07/25/2024 16:00	0.2	11.9	2,119.5	0.4	0.6	1	1	1
07/25/2024 17:00	0.2	11.9	2,111.2	0.4	0.6	1	1	1
07/25/2024 18:00	0.1	12.1	2,078.0	0.2	0.6	1	1	1
07/25/2024 19:00	0.1	12.2	2,054.0	0.2	0.6	1	1	1
07/25/2024 20:00	0.1	11.8	2,155.7	0.2	0.6	1	1	1
07/25/2024 21:00	0.2	11.8	2,169.1	0.4	0.7	1	1	1
07/25/2024 22:00	0.1	12.0	2,135.5	0.2	0.6	1	1	1
07/25/2024 23:00	0.2	11.7	2,216.7	0.4	0.7	1	1	1
Average/Sum#:	0.1	12.1	2,121.2	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	2,054.0	0.2	0.6	1	1	1
Maximum:	0.2	12.4	2,216.7	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2024 00:00	0.2	11.9	2,173.2	0.4	0.7	1	1	1
07/26/2024 01:00	-0.1	12.5	2,042.4	0.1	0.6	1	1	1
07/26/2024 02:00	-0.4	12.9	1,967.8	-0.1	0.6	1	1	1
07/26/2024 03:00	-0.5	12.9	1,971.9	-0.2	0.6	1	1	1
07/26/2024 04:00	-0.1	12.3	2,113.9	0.2	0.6	1	1	1
07/26/2024 05:00	-0.1	12.4	2,081.0	0.2	0.6	1	1	1
07/26/2024 06:00	-0.4	12.9	1,973.1	-0.1	0.6	1	1	1
07/26/2024 07:00	-0.4	12.8	1,972.6	-0.1	0.6	1	1	1
07/26/2024 08:00	-0.4	12.8	1,976.0	-0.1	0.6	1	1	1
07/26/2024 09:00	-0.4	12.7	1,983.7	-0.1	0.6	1	1	1
07/26/2024 10:00	-0.2	12.6	1,992.4	0.1	0.6	1	1	1
07/26/2024 11:00	-0.2	12.6	2,002.2	0.1	0.6	1	1	1
07/26/2024 12:00	-0.1	12.4	2,013.1	0.2	0.6	1	1	1
07/26/2024 13:00	-0.1	12.3	2,036.9	0.2	0.6	1	1	1
07/26/2024 14:00	0.1	12.2	2,050.8	0.2	0.6	1	1	1
07/26/2024 15:00	0.1	12.0	2,089.7	0.2	0.6	1	1	1
07/26/2024 16:00	0.2	11.7	2,134.0	0.4	0.6	1	1	1
07/26/2024 17:00	0.2	11.7	2,136.6	0.4	0.6	1	1	1
07/26/2024 18:00	0.1	12.2	2,054.2	0.2	0.6	1	1	1
07/26/2024 19:00	0.1	12.1	2,104.4	0.2	0.6	1	1	1
07/26/2024 20:00	0.2	11.7	2,202.5	0.4	0.7	1	1	1
07/26/2024 21:00	0.1	12.4	2,064.6	0.2	0.6	1	1	1
07/26/2024 22:00	-0.1	12.4	2,059.4	0.2	0.6	1	1	1
07/26/2024 23:00	-0.4	12.9	1,971.9	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	12.4	2,048.7	0.1	0.6	24 #	24 #	24 #
Minimum:	-0.5	11.7	1,967.8	-0.2	0.6	1	1	1
Maximum:	0.2	12.9	2,202.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2024 00:00	-0.5	12.9	1,975.4	-0.2	0.6	1	1	1
07/27/2024 01:00	-0.4	12.9	1,974.7	-0.1	0.6	1	1	1
07/27/2024 02:00	-0.2	12.9	1,977.4	0.1	0.6	1	1	1
07/27/2024 03:00	-0.4	12.9	1,979.9	-0.1	0.6	1	1	1
07/27/2024 04:00	-0.2	12.8	2,018.0	0.1	0.6	1	1	1
07/27/2024 05:00	-0.1	12.6	2,044.3	0.1	0.6	1	1	1
07/27/2024 06:00	0.0	0.0	674.5	0.0	0.2	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 15:00	0.0	17.9	327.7	0.0	0.1	1	0	0
07/27/2024 16:00	0.0	14.8	1,036.1	0.0	0.3	1	0	0
07/27/2024 17:00	0.3	13.7	1,729.5	0.4	0.5	1	1	0
07/27/2024 18:00	0.1	13.7	1,588.0	0.2	0.5	1	1	1
07/27/2024 19:00	-0.4	12.7	1,978.4	-0.1	0.6	1	1	1
07/27/2024 20:00	-0.4	12.7	1,973.8	-0.1	0.6	1	1	1
07/27/2024 21:00	-0.4	12.8	1,968.8	-0.1	0.6	1	1	1
07/27/2024 22:00	-0.4	12.8	1,963.4	-0.1	0.6	1	1	1
07/27/2024 23:00	-0.4	12.8	1,961.2	-0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.4	1,698.2	0.0	0.5	16 #	13 #	12 #
Minimum:	-0.5	12.6	327.7	-0.2	0.1	0	0	0
Maximum:	0.3	17.9	2,044.3	0.4	0.6	1	1	1
%SI	37.50	37.50	33.33	37.50	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2024 00:00	-0.4	12.9	1,960.1	-0.1	0.6	1	1	1
07/28/2024 01:00	-0.4	12.9	1,963.6	-0.1	0.6	1	1	1
07/28/2024 02:00	-0.4	12.9	1,963.2	-0.1	0.6	1	1	1
07/28/2024 03:00	-0.5	13.0	1,960.7	-0.2	0.6	1	1	1
07/28/2024 04:00	-0.5	13.0	1,955.1	-0.2	0.6	1	1	1
07/28/2024 05:00	0.3	13.8	1,704.4	0.4	0.5	1	1	0
07/28/2024 06:00	0.3	13.9	1,314.0	0.4	0.4	1	1	0
07/28/2024 07:00	0.0	16.4	325.2	0.0	0.1	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 14:00	0.0	17.0	490.8	0.0	0.1	1	0	0
07/28/2024 15:00	0.0	14.4	1,218.9	0.0	0.4	1	0	0
07/28/2024 16:00	0.1	13.8	1,678.3	0.2	0.5	1	1	1
07/28/2024 17:00	-2.1	13.0	1,882.7	-1.4	0.6	1	1	1
07/28/2024 18:00	-1.8	13.0	1,882.5	-1.2	0.6	1	1	1
07/28/2024 19:00	-1.8	13.0	1,887.4	-1.2	0.6	1	1	1
07/28/2024 20:00	-0.8	12.7	1,958.7	-0.4	0.6	1	1	1
07/28/2024 21:00	-0.7	12.7	1,959.5	-0.2	0.6	1	1	1
07/28/2024 22:00	0.2	13.8	1,505.8	0.3	0.5	1	1	0
07/28/2024 23:00	0.3	13.8	1,668.8	0.4	0.5	1	1	0
Average/Sum#:	-0.5	13.7	1,626.7	-0.2	0.5	18 #	15 #	11 #
Minimum:	-2.1	12.7	325.2	-1.4	0.1	0	0	0
Maximum:	0.3	17.0	1,963.6	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2024 00:00	0.3	13.8	1,529.5	0.4	0.5	1	1	0
07/29/2024 01:00	0.3	13.9	1,523.7	0.4	0.5	1	1	0
07/29/2024 02:00	0.3	13.8	1,533.1	0.4	0.5	1	1	0
07/29/2024 03:00	0.0	15.6	592.0	0.0	0.2	1	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 14:00	0.0	20.9	0.2	0.0	0.0	1	0	0
07/29/2024 15:00	0.0	17.0	456.9	0.0	0.1	1	0	0
07/29/2024 16:00	0.0	14.2	1,359.6	0.0	0.4	1	0	0
07/29/2024 17:00	0.3	13.7	1,655.4	0.4	0.5	1	1	0
07/29/2024 18:00	-0.1	13.0	1,802.5	0.1	0.5	1	1	1
07/29/2024 19:00	0.1	11.5	2,207.5	0.2	0.7	1	1	1
07/29/2024 20:00	0.2	11.6	2,218.7	0.4	0.7	1	1	1
07/29/2024 21:00	0.1	12.2	2,071.6	0.2	0.6	1	1	1
07/29/2024 22:00	0.1	12.3	2,043.9	0.2	0.6	1	1	1
07/29/2024 23:00	0.0	15.5	683.3	0.0	0.2	1	0	0
Average/Sum#:	0.1	14.2	1,405.6	0.2	0.4	14 #	9 #	5 #
Minimum:	-0.1	11.5	0.2	0.0	0.0	0	0	0
Maximum:	0.3	20.9	2,218.7	0.4	0.7	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 15:00	0.0	17.0	474.0	0.0	0.1	1	0	0
07/30/2024 16:00	0.0	14.4	1,198.0	0.0	0.4	1	0	0
07/30/2024 17:00	0.4	13.9	1,447.5	0.4	0.4	1	1	0
07/30/2024 18:00	-0.4	13.2	1,750.3	-0.1	0.5	1	1	1
07/30/2024 19:00	0.1	11.7	2,204.1	0.2	0.7	1	1	1
07/30/2024 20:00	0.4	11.6	2,212.3	0.5	0.7	1	1	1
07/30/2024 21:00	0.4	11.6	2,196.4	0.5	0.7	1	1	1
07/30/2024 22:00	0.2	12.0	2,112.7	0.4	0.6	1	1	1
07/30/2024 23:00	0.1	12.0	2,123.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,746.6	0.2	0.5	9 #	7 #	6 #
Minimum:	-0.4	11.6	474.0	-0.1	0.1	0	0	0
Maximum:	0.4	17.0	2,212.3	0.5	0.7	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2024 00:00	-0.2	12.7	1,963.4	0.1	0.6	1	1	1
07/31/2024 01:00	-0.4	12.8	1,956.7	-0.1	0.6	1	1	1
07/31/2024 02:00	-0.4	12.8	1,955.8	-0.1	0.6	1	1	1
07/31/2024 03:00	-0.4	12.7	1,981.9	-0.1	0.6	1	1	1
07/31/2024 04:00	0.2	11.7	2,236.4	0.4	0.7	1	1	1
07/31/2024 05:00	0.2	12.0	2,126.5	0.4	0.6	1	1	1
07/31/2024 06:00	0.4	13.8	1,715.5	0.4	0.5	1	1	0
07/31/2024 07:00	0.4	13.8	1,587.4	0.4	0.5	1	1	0
07/31/2024 08:00	0.4	13.8	1,493.0	0.4	0.4	1	1	0
07/31/2024 09:00	0.4	13.8	1,497.3	0.4	0.4	1	1	0
07/31/2024 10:00	0.4	13.8	1,544.2	0.4	0.5	1	1	0
07/31/2024 11:00	0.4	13.8	1,576.3	0.4	0.5	1	1	0
07/31/2024 12:00	0.4	13.9	1,465.8	0.4	0.4	1	1	0
07/31/2024 13:00	0.3	13.7	1,624.7	0.4	0.5	1	1	0
07/31/2024 14:00	-0.1	11.9	2,102.0	0.2	0.6	1	1	1
07/31/2024 15:00	0.2	11.5	2,192.3	0.4	0.7	1	1	1
07/31/2024 16:00	0.4	11.5	2,184.0	0.5	0.7	1	1	1
07/31/2024 17:00	0.4	11.5	2,193.3	0.5	0.7	1	1	1
07/31/2024 18:00	0.4	11.5	2,181.2	0.5	0.7	1	1	1
07/31/2024 19:00	0.4	11.7	2,154.5	0.5	0.6	1	1	1
07/31/2024 20:00	0.2	11.8	2,131.2	0.4	0.6	1	1	1
07/31/2024 21:00	0.2	11.9	2,108.1	0.4	0.6	1	1	1
07/31/2024 22:00	0.2	12.0	2,099.2	0.4	0.6	1	1	1
07/31/2024 23:00	0.2	12.0	2,096.3	0.4	0.6	1	1	1
Average/Sum#:	0.2	12.6	1,923.6	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.4	11.5	1,465.8	-0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,236.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2024 00:00	0.1	12.1	2,088.9	0.2	0.6	1	1	1
08/01/2024 01:00	0.1	12.1	2,086.6	0.2	0.6	1	1	1
08/01/2024 02:00	0.1	12.2	2,082.6	0.2	0.6	1	1	1
08/01/2024 03:00	0.1	12.3	2,076.8	0.2	0.6	1	1	1
08/01/2024 04:00	0.1	12.3	2,080.7	0.2	0.6	1	1	1
08/01/2024 05:00	0.2	11.7	2,215.0	0.4	0.7	1	1	1
08/01/2024 06:00	0.2	12.2	2,103.6	0.4	0.6	1	1	1
08/01/2024 07:00	0.4	13.7	1,704.4	0.4	0.5	1	1	0
08/01/2024 08:00	0.3	13.7	1,732.1	0.4	0.5	1	1	0
08/01/2024 09:00	0.3	13.7	1,742.0	0.4	0.5	1	1	0
08/01/2024 10:00	0.3	13.7	1,727.8	0.4	0.5	1	1	0
08/01/2024 11:00	0.3	13.7	1,710.0	0.4	0.5	1	1	0
08/01/2024 12:00	-0.1	13.7	1,703.5	0.1	0.5	1	1	1
08/01/2024 13:00	-0.1	11.9	2,126.9	0.2	0.6	1	1	1
08/01/2024 14:00	0.2	11.6	2,177.1	0.4	0.7	1	1	1
08/01/2024 15:00	0.2	11.5	2,199.0	0.4	0.7	1	1	1
08/01/2024 16:00	0.4	11.5	2,206.4	0.5	0.7	1	1	1
08/01/2024 17:00	0.4	11.5	2,203.4	0.5	0.7	1	1	1
08/01/2024 18:00	0.4	11.6	2,192.8	0.5	0.7	1	1	1
08/01/2024 19:00	0.2	11.8	2,149.2	0.4	0.6	1	1	1
08/01/2024 20:00	0.2	12.0	2,115.9	0.4	0.6	1	1	1
08/01/2024 21:00	0.1	12.3	2,071.8	0.2	0.6	1	1	1
08/01/2024 22:00	0.1	12.3	2,074.7	0.2	0.6	1	1	1
08/01/2024 23:00	0.2	11.7	2,235.6	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.4	2,033.6	0.3	0.6	24 #	24 #	19 #
Minimum:	-0.1	11.5	1,703.5	0.1	0.5	1	1	0
Maximum:	0.4	13.7	2,235.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2024 00:00	0.2	11.7	2,233.9	0.4	0.7	1	1	1
08/02/2024 01:00	0.2	11.7	2,227.3	0.4	0.7	1	1	1
08/02/2024 02:00	0.4	11.6	2,249.8	0.5	0.7	1	1	1
08/02/2024 03:00	0.4	11.6	2,258.1	0.5	0.7	1	1	1
08/02/2024 04:00	0.4	11.6	2,253.9	0.5	0.7	1	1	1
08/02/2024 05:00	0.4	11.6	2,260.7	0.5	0.7	1	1	1
08/02/2024 06:00	0.4	11.6	2,252.2	0.5	0.7	1	1	1
08/02/2024 07:00	0.4	11.6	2,245.9	0.5	0.7	1	1	1
08/02/2024 08:00	0.2	11.6	2,247.2	0.4	0.7	1	1	1
08/02/2024 09:00	0.2	11.6	2,236.9	0.4	0.7	1	1	1
08/02/2024 10:00	0.2	11.6	2,230.4	0.4	0.7	1	1	1
08/02/2024 11:00	0.4	11.5	2,221.6	0.5	0.7	1	1	1
08/02/2024 12:00	0.4	11.5	2,210.7	0.5	0.7	1	1	1
08/02/2024 13:00	0.4	11.5	2,211.0	0.5	0.7	1	1	1
08/02/2024 14:00	0.4	11.5	2,210.0	0.5	0.7	1	1	1
08/02/2024 15:00	0.4	11.5	2,206.6	0.5	0.7	1	1	1
08/02/2024 16:00	0.4	11.5	2,215.5	0.5	0.7	1	1	1
08/02/2024 17:00	0.4	11.5	2,211.7	0.5	0.7	1	1	1
08/02/2024 18:00	0.4	11.5	2,213.8	0.5	0.7	1	1	1
08/02/2024 19:00	0.4	11.6	2,196.2	0.5	0.7	1	1	1
08/02/2024 20:00	0.4	11.7	2,184.9	0.5	0.7	1	1	1
08/02/2024 21:00	0.4	11.5	2,236.7	0.5	0.7	1	1	1
08/02/2024 22:00	0.4	11.5	2,240.1	0.5	0.7	1	1	1
08/02/2024 23:00	0.4	11.5	2,240.1	0.5	0.7	1	1	1
Average/Sum#:	0.4	11.6	2,229.0	0.5	0.7	24 #	24 #	24 #
Minimum:	0.2	11.5	2,184.9	0.4	0.7	1	1	1
Maximum:	0.4	11.7	2,260.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2024 00:00	0.4	11.5	2,238.4	0.5	0.7	1	1	1
08/03/2024 01:00	0.4	11.5	2,235.6	0.5	0.7	1	1	1
08/03/2024 02:00	0.2	11.8	2,165.9	0.4	0.6	1	1	1
08/03/2024 03:00	-0.1	12.5	2,014.5	0.1	0.6	1	1	1
08/03/2024 04:00	-0.2	12.6	2,008.0	0.1	0.6	1	1	1
08/03/2024 05:00	-0.1	12.5	2,027.8	0.1	0.6	1	1	1
08/03/2024 06:00	-0.2	12.7	1,968.4	0.1	0.6	1	1	1
08/03/2024 07:00	-0.2	12.7	1,975.9	0.1	0.6	1	1	1
08/03/2024 08:00	-0.4	12.6	1,979.7	-0.1	0.6	1	1	1
08/03/2024 09:00	-0.2	12.6	1,988.9	0.1	0.6	1	1	1
08/03/2024 10:00	-0.2	12.6	1,993.7	0.1	0.6	1	1	1
08/03/2024 11:00	-0.1	12.5	1,998.6	0.1	0.6	1	1	1
08/03/2024 12:00	-0.1	12.5	1,997.0	0.1	0.6	1	1	1
08/03/2024 13:00	-0.1	12.5	2,000.2	0.1	0.6	1	1	1
08/03/2024 14:00	-0.1	12.2	2,043.5	0.2	0.6	1	1	1
08/03/2024 15:00	0.1	12.3	2,031.1	0.2	0.6	1	1	1
08/03/2024 16:00	0.1	12.2	2,044.8	0.2	0.6	1	1	1
08/03/2024 17:00	0.2	11.9	2,123.2	0.4	0.6	1	1	1
08/03/2024 18:00	0.4	11.6	2,198.4	0.5	0.7	1	1	1
08/03/2024 19:00	0.4	11.7	2,182.3	0.5	0.7	1	1	1
08/03/2024 20:00	0.4	11.8	2,155.9	0.5	0.6	1	1	1
08/03/2024 21:00	0.2	11.9	2,143.2	0.4	0.6	1	1	1
08/03/2024 22:00	0.2	12.0	2,125.4	0.4	0.6	1	1	1
08/03/2024 23:00	0.4	11.6	2,213.3	0.5	0.7	1	1	1
Average/Sum#:	0.1	12.2	2,077.2	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,968.4	-0.1	0.6	1	1	1
Maximum:	0.4	12.7	2,238.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2024 00:00	0.1	12.5	1,999.9	0.2	0.6	1	1	1
08/04/2024 01:00	-0.1	12.5	2,012.4	0.1	0.6	1	1	1
08/04/2024 02:00	-0.2	12.7	1,951.1	0.1	0.6	1	1	1
08/04/2024 03:00	0.4	13.8	1,718.2	0.4	0.5	1	1	0
08/04/2024 04:00	0.3	13.7	1,744.7	0.4	0.5	1	1	0
08/04/2024 05:00	0.2	13.7	1,745.0	0.3	0.5	1	1	0
08/04/2024 06:00	0.3	13.8	1,713.1	0.4	0.5	1	1	0
08/04/2024 07:00	0.3	13.8	1,595.9	0.4	0.5	1	1	0
08/04/2024 08:00	0.2	13.8	1,599.6	0.3	0.5	1	1	0
08/04/2024 09:00	0.2	13.8	1,466.3	0.3	0.4	1	1	0
08/04/2024 10:00	0.3	13.8	1,604.6	0.4	0.5	1	1	0
08/04/2024 11:00	0.3	13.7	1,666.6	0.4	0.5	1	1	0
08/04/2024 12:00	0.1	13.8	1,538.3	0.2	0.5	1	1	1
08/04/2024 13:00	-0.2	12.3	2,027.1	0.1	0.6	1	1	1
08/04/2024 14:00	-0.1	12.1	2,047.0	0.2	0.6	1	1	1
08/04/2024 15:00	0.1	12.1	2,043.5	0.2	0.6	1	1	1
08/04/2024 16:00	0.2	11.9	2,086.0	0.4	0.6	1	1	1
08/04/2024 17:00	0.4	11.5	2,174.8	0.5	0.7	1	1	1
08/04/2024 18:00	0.2	11.5	2,171.5	0.4	0.7	1	1	1
08/04/2024 19:00	0.2	12.0	2,085.4	0.4	0.6	1	1	1
08/04/2024 20:00	0.2	11.6	2,201.7	0.4	0.7	1	1	1
08/04/2024 21:00	0.2	11.5	2,220.0	0.4	0.7	1	1	1
08/04/2024 22:00	0.2	11.5	2,231.1	0.4	0.7	1	1	1
08/04/2024 23:00	0.2	11.5	2,240.4	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.7	1,911.8	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.2	11.5	1,466.3	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,240.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2024 00:00	0.2	11.5	2,240.8	0.4	0.7	1	1	1
08/05/2024 01:00	0.2	11.7	2,224.8	0.4	0.7	1	1	1
08/05/2024 02:00	0.2	11.8	2,207.4	0.4	0.7	1	1	1
08/05/2024 03:00	0.2	11.9	2,194.3	0.4	0.7	1	1	1
08/05/2024 04:00	0.2	11.6	2,262.5	0.4	0.7	1	1	1
08/05/2024 05:00	0.2	11.6	2,264.3	0.4	0.7	1	1	1
08/05/2024 06:00	-0.1	12.4	2,101.9	0.2	0.6	1	1	1
08/05/2024 07:00	-0.4	12.8	1,968.0	-0.1	0.6	1	1	1
08/05/2024 08:00	-0.5	12.8	1,950.1	-0.2	0.6	1	1	1
08/05/2024 09:00	-0.4	12.8	1,956.1	-0.1	0.6	1	1	1
08/05/2024 10:00	-0.2	12.7	1,965.3	0.1	0.6	1	1	1
08/05/2024 11:00	-0.2	12.5	2,009.5	0.1	0.6	1	1	1
08/05/2024 12:00	-0.1	12.3	2,048.3	0.2	0.6	1	1	1
08/05/2024 13:00	-0.1	12.3	2,046.5	0.2	0.6	1	1	1
08/05/2024 14:00	0.2	11.6	2,184.4	0.4	0.7	1	1	1
08/05/2024 15:00	0.1	12.2	2,045.2	0.2	0.6	1	1	1
08/05/2024 16:00	-0.1	12.4	2,001.6	0.2	0.6	1	1	1
08/05/2024 17:00	-0.1	12.3	2,027.7	0.2	0.6	1	1	1
08/05/2024 18:00	0.2	11.8	2,131.0	0.4	0.6	1	1	1
08/05/2024 19:00	-0.1	12.5	2,002.2	0.1	0.6	1	1	1
08/05/2024 20:00	0.2	11.6	2,216.1	0.4	0.7	1	1	1
08/05/2024 21:00	0.2	11.5	2,230.5	0.4	0.7	1	1	1
08/05/2024 22:00	0.2	11.5	2,231.7	0.4	0.7	1	1	1
08/05/2024 23:00	0.2	11.7	2,211.1	0.4	0.7	1	1	1
Average/Sum#:	0.0	12.1	2,113.4	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.5	11.5	1,950.1	-0.2	0.6	1	1	1
Maximum:	0.2	12.8	2,264.3	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2024 00:00	0.1	12.5	2,034.1	0.2	0.6	1	1	1
08/06/2024 01:00	-0.4	12.9	1,959.5	-0.1	0.6	1	1	1
08/06/2024 02:00	-0.4	12.9	1,951.3	-0.1	0.6	1	1	1
08/06/2024 03:00	-0.4	12.9	1,952.1	-0.1	0.6	1	1	1
08/06/2024 04:00	-0.1	12.2	2,124.8	0.2	0.6	1	1	1
08/06/2024 05:00	0.1	12.0	2,190.2	0.2	0.7	1	1	1
08/06/2024 06:00	-0.1	12.6	2,055.4	0.1	0.6	1	1	1
08/06/2024 07:00	-0.4	12.9	1,952.6	-0.1	0.6	1	1	1
08/06/2024 08:00	-0.2	12.9	1,951.8	0.1	0.6	1	1	1
08/06/2024 09:00	-0.2	12.8	1,957.5	0.1	0.6	1	1	1
08/06/2024 10:00	-0.2	12.7	1,965.4	0.1	0.6	1	1	1
08/06/2024 11:00	-0.2	12.7	1,974.3	0.1	0.6	1	1	1
08/06/2024 12:00	-0.1	12.6	1,984.8	0.1	0.6	1	1	1
08/06/2024 13:00	-0.1	12.5	1,989.0	0.1	0.6	1	1	1
08/06/2024 14:00	-0.1	12.5	1,993.7	0.1	0.6	1	1	1
08/06/2024 15:00	-0.1	12.5	1,998.0	0.1	0.6	1	1	1
08/06/2024 16:00	0.1	12.1	2,084.9	0.2	0.6	1	1	1
08/06/2024 17:00	0.2	11.8	2,143.8	0.4	0.6	1	1	1
08/06/2024 18:00	0.2	11.5	2,196.2	0.4	0.7	1	1	1
08/06/2024 19:00	0.2	11.7	2,164.5	0.4	0.6	1	1	1
08/06/2024 20:00	0.2	12.0	2,111.5	0.4	0.6	1	1	1
08/06/2024 21:00	0.2	11.9	2,130.1	0.4	0.6	1	1	1
08/06/2024 22:00	0.2	11.8	2,171.1	0.4	0.7	1	1	1
08/06/2024 23:00	-0.1	12.4	2,032.3	0.2	0.6	1	1	1
Average/Sum#:	-0.1	12.4	2,044.5	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,951.3	-0.1	0.6	1	1	1
Maximum:	0.2	12.9	2,196.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2024 00:00	-0.2	12.6	2,005.7	0.1	0.6	1	1	1
08/07/2024 01:00	0.2	11.8	2,197.5	0.4	0.7	1	1	1
08/07/2024 02:00	0.1	12.3	2,062.8	0.2	0.6	1	1	1
08/07/2024 03:00	-0.2	12.8	1,956.0	0.1	0.6	1	1	1
08/07/2024 04:00	-0.2	12.8	1,967.1	0.1	0.6	1	1	1
08/07/2024 05:00	-0.1	12.2	2,106.8	0.2	0.6	1	1	1
08/07/2024 06:00	0.1	12.3	2,128.3	0.2	0.6	1	1	1
08/07/2024 07:00	-0.2	12.8	1,959.1	0.1	0.6	1	1	1
08/07/2024 08:00	-0.4	12.8	1,962.8	-0.1	0.6	1	1	1
08/07/2024 09:00	-0.4	12.8	1,969.1	-0.1	0.6	1	1	1
08/07/2024 10:00	-0.4	12.7	1,979.4	-0.1	0.6	1	1	1
08/07/2024 11:00	-0.2	12.5	1,987.9	0.1	0.6	1	1	1
08/07/2024 12:00	-0.2	12.4	1,998.3	0.1	0.6	1	1	1
08/07/2024 13:00	-0.1	12.3	2,029.2	0.2	0.6	1	1	1
08/07/2024 14:00	-0.1	12.1	2,070.8	0.2	0.6	1	1	1
08/07/2024 15:00	-0.1	12.2	2,041.6	0.2	0.6	1	1	1
08/07/2024 16:00	-0.1	12.2	2,037.4	0.2	0.6	1	1	1
08/07/2024 17:00	0.1	11.7	2,145.9	0.2	0.6	1	1	1
08/07/2024 18:00	0.2	11.5	2,191.9	0.4	0.7	1	1	1
08/07/2024 19:00	0.2	11.7	2,162.0	0.4	0.6	1	1	1
08/07/2024 20:00	0.1	11.9	2,118.3	0.2	0.6	1	1	1
08/07/2024 21:00	0.1	12.2	2,062.5	0.2	0.6	1	1	1
08/07/2024 22:00	-0.2	12.7	1,968.4	0.1	0.6	1	1	1
08/07/2024 23:00	0.1	11.8	2,183.4	0.2	0.7	1	1	1
Average/Sum#:	-0.1	12.3	2,053.8	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,956.0	-0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,197.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2024 00:00	0.2	11.6	2,242.0	0.4	0.7	1	1	1
08/08/2024 01:00	0.1	12.2	2,090.8	0.2	0.6	1	1	1
08/08/2024 02:00	0.4	13.8	1,658.7	0.4	0.5	1	1	0
08/08/2024 03:00	0.3	13.8	1,695.2	0.4	0.5	1	1	0
08/08/2024 04:00	0.3	13.8	1,665.4	0.4	0.5	1	1	0
08/08/2024 05:00	0.4	13.8	1,732.3	0.4	0.5	1	1	0
08/08/2024 06:00	0.4	13.8	1,728.1	0.4	0.5	1	1	0
08/08/2024 07:00	0.3	13.8	1,668.4	0.4	0.5	1	1	0
08/08/2024 08:00	0.4	13.8	1,564.0	0.4	0.5	1	1	0
08/08/2024 09:00	0.4	13.8	1,556.1	0.4	0.5	1	1	0
08/08/2024 10:00	0.3	13.8	1,550.2	0.4	0.5	1	1	0
08/08/2024 11:00	0.3	13.9	1,340.5	0.4	0.4	1	1	0
08/08/2024 12:00	0.4	14.0	1,328.2	0.4	0.4	1	1	0
08/08/2024 13:00	0.4	14.0	1,330.7	0.4	0.4	1	1	0
08/08/2024 14:00	0.1	13.8	1,517.8	0.2	0.5	1	1	1
08/08/2024 15:00	-0.4	12.2	2,021.9	-0.1	0.6	1	1	1
08/08/2024 16:00	-0.1	12.1	2,046.9	0.2	0.6	1	1	1
08/08/2024 17:00	0.1	12.1	2,062.1	0.2	0.6	1	1	1
08/08/2024 18:00	0.2	11.5	2,183.3	0.4	0.7	1	1	1
08/08/2024 19:00	0.2	11.6	2,161.9	0.4	0.6	1	1	1
08/08/2024 20:00	0.1	11.9	2,120.8	0.2	0.6	1	1	1
08/08/2024 21:00	0.1	12.1	2,085.5	0.2	0.6	1	1	1
08/08/2024 22:00	-0.1	12.4	2,024.3	0.2	0.6	1	1	1
08/08/2024 23:00	-0.1	12.2	2,080.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,810.7	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.4	11.5	1,328.2	-0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,242.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2024 00:00	0.1	13.8	1,601.0	0.2	0.5	1	1	1
08/09/2024 01:00	0.3	13.8	1,696.1	0.4	0.5	1	1	0
08/09/2024 02:00	0.3	13.8	1,724.0	0.4	0.5	1	1	0
08/09/2024 03:00	0.3	13.8	1,709.1	0.4	0.5	1	1	0
08/09/2024 04:00	0.3	13.8	1,743.7	0.4	0.5	1	1	0
08/09/2024 05:00	0.3	13.8	1,743.5	0.4	0.5	1	1	0
08/09/2024 06:00	0.3	13.8	1,708.3	0.4	0.5	1	1	0
08/09/2024 07:00	0.3	13.8	1,551.5	0.4	0.5	1	1	0
08/09/2024 08:00	0.3	13.9	1,455.8	0.4	0.4	1	1	0
08/09/2024 09:00	0.3	13.9	1,529.7	0.4	0.5	1	1	0
08/09/2024 10:00	0.3	13.9	1,561.7	0.4	0.5	1	1	0
08/09/2024 11:00	0.3	13.9	1,580.2	0.4	0.5	1	1	0
08/09/2024 12:00	0.3	13.8	1,637.8	0.4	0.5	1	1	0
08/09/2024 13:00	0.3	13.8	1,693.4	0.4	0.5	1	1	0
08/09/2024 14:00	-0.1	13.7	1,594.2	0.1	0.5	1	1	1
08/09/2024 15:00	-0.4	12.3	2,011.3	-0.1	0.6	1	1	1
08/09/2024 16:00	-0.1	12.1	2,064.4	0.2	0.6	1	1	1
08/09/2024 17:00	0.1	11.7	2,132.2	0.2	0.6	1	1	1
08/09/2024 18:00	0.2	11.5	2,187.3	0.4	0.7	1	1	1
08/09/2024 19:00	0.2	11.8	2,143.2	0.4	0.6	1	1	1
08/09/2024 20:00	0.1	12.0	2,081.7	0.2	0.6	1	1	1
08/09/2024 21:00	0.0	15.4	689.3	0.0	0.2	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.4	1,720.0	0.3	0.5	22 #	21 #	8 #
Minimum:	-0.4	11.5	689.3	-0.1	0.2	0	0	0
Maximum:	0.3	15.4	2,187.3	0.4	0.7	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 13:00	0.0	17.5	357.7	0.0	0.1	1	0	0
08/10/2024 14:00	0.0	17.0	439.5	0.0	0.1	1	0	0
08/10/2024 15:00	0.0	15.3	977.0	0.0	0.3	1	0	0
08/10/2024 16:00	-0.1	13.7	1,670.0	0.1	0.5	1	1	1
08/10/2024 17:00	-0.5	12.2	2,089.4	-0.1	0.6	1	1	1
08/10/2024 18:00	-0.2	11.8	2,146.9	0.1	0.6	1	1	1
08/10/2024 19:00	-0.1	11.8	2,134.4	0.2	0.6	1	1	1
08/10/2024 20:00	-0.1	11.8	2,141.0	0.2	0.6	1	1	1
08/10/2024 21:00	-0.2	12.1	2,083.3	0.1	0.6	1	1	1
08/10/2024 22:00	-0.4	12.5	1,987.7	-0.1	0.6	1	1	1
08/10/2024 23:00	0.0	15.6	612.9	0.0	0.2	1	0	0
Average/Sum#:	-0.1	13.8	1,512.7	0.0	0.4	11 #	7 #	7 #
Minimum:	-0.5	11.8	357.7	-0.1	0.1	0	0	0
Maximum:	0.0	17.5	2,146.9	0.2	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 18:00	0.0	17.5	333.2	0.0	0.1	1	0	0
08/12/2024 19:00	0.0	16.2	592.2	0.0	0.2	1	0	0
08/12/2024 20:00	0.0	13.9	1,495.0	0.0	0.4	1	0	0
08/12/2024 21:00	0.3	13.8	1,711.5	0.4	0.5	1	1	0
08/12/2024 22:00	0.3	13.8	1,680.8	0.4	0.5	1	1	0
08/12/2024 23:00	0.3	13.8	1,713.8	0.4	0.5	1	1	0
Average/Sum#:	0.2	14.8	1,254.4	0.2	0.4	6 #	3 #	0 #
Minimum:	0.0	13.8	333.2	0.0	0.1	0	0	0
Maximum:	0.3	17.5	1,713.8	0.4	0.5	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2024 00:00	0.3	13.8	1,676.4	0.4	0.5	1	1	0
08/13/2024 01:00	0.3	13.9	1,345.3	0.4	0.4	1	1	0
08/13/2024 02:00	0.0	15.5	642.5	0.0	0.2	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 16:00	0.0	17.5	352.3	0.0	0.1	1	0	0
08/13/2024 17:00	0.0	17.1	422.6	0.0	0.1	1	0	0
08/13/2024 18:00	0.0	15.4	926.0	0.0	0.3	1	0	0
08/13/2024 19:00	-0.5	13.2	1,792.4	-0.2	0.5	1	1	1
08/13/2024 20:00	-0.5	12.5	2,024.2	-0.2	0.6	1	1	1
08/13/2024 21:00	-0.4	12.3	2,060.0	-0.1	0.6	1	1	1
08/13/2024 22:00	-0.2	13.2	1,678.4	-0.1	0.5	1	1	1
08/13/2024 23:00	0.3	13.8	1,612.0	0.4	0.5	1	1	0
Average/Sum#:	-0.1	14.4	1,321.1	0.1	0.4	11 #	7 #	4 #
Minimum:	-0.5	12.3	352.3	-0.2	0.1	0	0	0
Maximum:	0.3	17.5	2,060.0	0.4	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2024 00:00	0.3	13.9	1,649.5	0.4	0.5	1	1	0
08/14/2024 01:00	0.3	13.9	1,535.2	0.4	0.5	1	1	0
08/14/2024 02:00	0.0	14.9	949.4	0.0	0.3	1	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 10:00	0.0	17.7	328.6	0.0	0.1	1	0	0
08/14/2024 11:00	0.0	15.7	808.1	0.0	0.2	1	0	0
08/14/2024 12:00	0.4	13.8	1,518.3	0.4	0.5	1	1	0
08/14/2024 13:00	0.4	13.8	1,562.6	0.4	0.5	1	1	0
08/14/2024 14:00	0.4	13.8	1,518.3	0.4	0.5	1	1	0
08/14/2024 15:00	0.4	13.9	1,457.6	0.4	0.4	1	1	0
08/14/2024 16:00	0.4	13.8	1,622.1	0.4	0.5	1	1	0
08/14/2024 17:00	0.4	13.6	1,725.8	0.4	0.5	1	1	0
08/14/2024 18:00	0.4	13.6	1,730.9	0.4	0.5	1	1	0
08/14/2024 19:00	0.4	13.6	1,742.8	0.4	0.5	1	1	0
08/14/2024 20:00	0.4	13.7	1,730.7	0.4	0.5	1	1	0
08/14/2024 21:00	0.4	13.8	1,732.4	0.4	0.5	1	1	0
08/14/2024 22:00	0.4	13.8	1,740.1	0.4	0.5	1	1	0
08/14/2024 23:00	0.4	13.7	1,771.7	0.4	0.5	1	1	0
Average/Sum#:	0.3	14.2	1,477.9	0.3	0.4	17 #	14 #	0 #
Minimum:	0.0	13.6	328.6	0.0	0.1	0	0	0
Maximum:	0.4	17.7	1,771.7	0.4	0.5	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2024 00:00	0.0	14.7	1,126.3	0.0	0.3	1	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 12:00	0.0	17.5	361.5	0.0	0.1	1	0	0
08/15/2024 13:00	0.0	17.1	424.6	0.0	0.1	1	0	0
08/15/2024 14:00	0.0	15.4	890.0	0.0	0.3	1	0	0
08/15/2024 15:00	0.4	13.8	1,605.1	0.4	0.5	1	1	0
08/15/2024 16:00	0.4	13.7	1,699.3	0.4	0.5	1	1	0
08/15/2024 17:00	0.4	13.8	1,687.7	0.4	0.5	1	1	0
08/15/2024 18:00	0.4	13.8	1,467.7	0.4	0.4	1	1	0
08/15/2024 19:00	-0.1	13.2	1,795.8	0.1	0.5	1	1	1
08/15/2024 20:00	0.2	11.9	2,113.3	0.4	0.6	1	1	1
08/15/2024 21:00	0.4	13.8	1,688.9	0.4	0.5	1	1	0
08/15/2024 22:00	0.4	13.8	1,672.6	0.4	0.5	1	1	0
08/15/2024 23:00	0.4	13.8	1,692.1	0.4	0.5	1	1	0
Average/Sum#:	0.2	14.3	1,401.9	0.3	0.4	13 #	9 #	2 #
Minimum:	-0.1	11.9	361.5	0.0	0.1	0	0	0
Maximum:	0.4	17.5	2,113.3	0.4	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2024 00:00	0.4	13.7	1,734.5	0.4	0.5	1	1	0
08/16/2024 01:00	0.4	13.8	1,681.9	0.4	0.5	1	1	0
08/16/2024 02:00	0.0	14.9	1,041.7	0.0	0.3	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 12:00	0.0	17.1	449.2	0.0	0.1	1	0	0
08/16/2024 13:00	0.0	14.4	1,257.1	0.0	0.4	1	0	0
08/16/2024 14:00	0.4	14.0	1,342.4	0.4	0.4	1	1	0
08/16/2024 15:00	0.1	13.8	1,574.1	0.2	0.5	1	1	1
08/16/2024 16:00	-0.1	12.0	2,101.1	0.2	0.6	1	1	1
08/16/2024 17:00	0.2	12.0	2,086.7	0.4	0.6	1	1	1
08/16/2024 18:00	0.2	11.8	2,134.0	0.4	0.6	1	1	1
08/16/2024 19:00	0.2	12.0	2,104.9	0.4	0.6	1	1	1
08/16/2024 20:00	0.2	11.8	2,145.9	0.4	0.6	1	1	1
08/16/2024 21:00	0.2	12.0	2,116.9	0.4	0.6	1	1	1
08/16/2024 22:00	0.4	11.9	2,173.2	0.5	0.7	1	1	1
08/16/2024 23:00	0.2	11.9	2,178.1	0.4	0.7	1	1	1
Average/Sum#:	0.2	13.1	1,741.4	0.3	0.5	15 #	12 #	9 #
Minimum:	-0.1	11.8	449.2	0.0	0.1	0	0	0
Maximum:	0.4	17.1	2,178.1	0.5	0.7	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2024 00:00	0.2	12.0	2,143.2	0.4	0.6	1	1	1
08/17/2024 01:00	-0.2	12.8	1,978.6	0.1	0.6	1	1	1
08/17/2024 02:00	-0.8	13.0	1,933.3	-0.4	0.6	1	1	1
08/17/2024 03:00	-1.1	13.0	1,926.3	-0.7	0.6	1	1	1
08/17/2024 04:00	-0.2	12.7	2,003.0	0.1	0.6	1	1	1
08/17/2024 05:00	-0.1	12.7	2,012.6	0.1	0.6	1	1	1
08/17/2024 06:00	0.0	0.0	1,213.8	0.0	0.4	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 14:00	0.0	18.8	173.2	0.0	0.1	1	0	0
08/17/2024 15:00	0.0	15.9	766.2	0.0	0.2	1	0	0
08/17/2024 16:00	0.4	13.8	1,585.7	0.4	0.5	1	1	0
08/17/2024 17:00	-0.4	12.9	1,916.8	-0.1	0.6	1	1	1
08/17/2024 18:00	-0.2	12.5	2,022.9	0.1	0.6	1	1	1
08/17/2024 19:00	-0.2	12.7	1,987.3	0.1	0.6	1	1	1
08/17/2024 20:00	-0.4	12.7	1,983.6	-0.1	0.6	1	1	1
08/17/2024 21:00	-0.4	12.8	1,973.8	-0.1	0.6	1	1	1
08/17/2024 22:00	-0.4	12.9	1,951.7	-0.1	0.6	1	1	1
08/17/2024 23:00	0.2	13.8	1,724.1	0.4	0.5	1	1	1
Average/Sum#:	-0.2	13.4	1,723.3	0.0	0.5	17 #	14 #	14 #
Minimum:	-1.1	12.0	173.2	-0.7	0.1	0	0	0
Maximum:	0.4	18.8	2,143.2	0.4	0.6	1	1	1
%SI	33.33	33.33	29.17	33.33	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2024 00:00	-0.4	12.9	1,967.1	-0.1	0.6	1	1	1
08/18/2024 01:00	-0.4	12.9	1,930.4	-0.1	0.6	1	1	1
08/18/2024 02:00	0.0	15.8	571.0	0.0	0.2	1	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 14:00	0.0	17.7	353.3	0.0	0.1	1	0	0
08/18/2024 15:00	0.0	15.1	993.2	0.0	0.3	1	0	0
08/18/2024 16:00	0.4	13.8	1,648.4	0.4	0.5	1	1	0
08/18/2024 17:00	0.2	13.7	1,668.3	0.4	0.5	1	1	1
08/18/2024 18:00	-0.1	12.4	2,081.2	0.2	0.6	1	1	1
08/18/2024 19:00	0.4	11.6	2,240.9	0.5	0.7	1	1	1
08/18/2024 20:00	0.4	11.7	2,232.8	0.5	0.7	1	1	1
08/18/2024 21:00	0.4	11.7	2,217.7	0.5	0.7	1	1	1
08/18/2024 22:00	0.2	12.1	2,134.5	0.4	0.6	1	1	1
08/18/2024 23:00	0.2	12.1	2,112.1	0.4	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,703.9	0.2	0.5	13 #	10 #	9 #
Minimum:	-0.4	11.6	353.3	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	2,240.9	0.5	0.7	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2024 00:00	0.0	15.7	571.3	0.0	0.2	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 07:00	0.0	16.8	578.7	0.0	0.2	1	0	0
08/19/2024 08:00	0.0	13.8	1,512.1	0.0	0.5	1	0	0
08/19/2024 09:00	0.4	13.9	1,545.4	0.4	0.5	1	1	0
08/19/2024 10:00	0.4	13.9	1,558.0	0.4	0.5	1	1	0
08/19/2024 11:00	0.4	13.8	1,559.4	0.4	0.5	1	1	0
08/19/2024 12:00	0.4	13.8	1,661.6	0.4	0.5	1	1	0
08/19/2024 13:00	0.4	13.9	1,453.5	0.4	0.4	1	1	0
08/19/2024 14:00	0.4	13.8	1,643.3	0.4	0.5	1	1	0
08/19/2024 15:00	0.4	13.9	1,513.1	0.4	0.5	1	1	0
08/19/2024 16:00	-0.1	12.6	1,960.7	0.1	0.6	1	1	1
08/19/2024 17:00	-0.1	12.5	2,038.3	0.1	0.6	1	1	1
08/19/2024 18:00	0.4	11.7	2,192.8	0.5	0.7	1	1	1
08/19/2024 19:00	-0.1	12.6	2,004.3	0.1	0.6	1	1	1
08/19/2024 20:00	-0.8	12.9	1,926.0	-0.4	0.6	1	1	1
08/19/2024 21:00	0.2	11.7	2,211.7	0.4	0.7	1	1	1
08/19/2024 22:00	0.2	12.0	2,147.1	0.4	0.6	1	1	1
08/19/2024 23:00	-0.5	12.8	1,944.4	-0.2	0.6	1	1	1
Average/Sum#:	0.1	13.5	1,667.9	0.2	0.5	18 #	15 #	8 #
Minimum:	-0.8	11.7	571.3	-0.4	0.2	0	0	0
Maximum:	0.4	16.8	2,211.7	0.5	0.7	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2024 00:00	-0.7	13.0	1,890.7	-0.4	0.6	1	1	1
08/20/2024 01:00	0.0	15.5	675.7	0.0	0.2	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 13:00	0.0	17.4	386.1	0.0	0.1	1	0	0
08/20/2024 14:00	0.0	14.8	1,049.3	0.0	0.3	1	0	0
08/20/2024 15:00	0.4	14.0	1,327.6	0.4	0.4	1	1	0
08/20/2024 16:00	0.2	13.9	1,554.9	0.2	0.5	1	1	1
08/20/2024 17:00	-0.1	12.1	2,112.1	0.2	0.6	1	1	1
08/20/2024 18:00	-0.1	12.4	2,009.6	0.2	0.6	1	1	1
08/20/2024 19:00	-0.8	13.0	1,898.4	-0.4	0.6	1	1	1
08/20/2024 20:00	-0.9	13.0	1,893.0	-0.5	0.6	1	1	1
08/20/2024 21:00	-0.1	12.4	2,052.9	0.2	0.6	1	1	1
08/20/2024 22:00	0.2	12.1	2,103.2	0.4	0.6	1	1	1
08/20/2024 23:00	0.2	12.3	2,075.7	0.4	0.6	1	1	1
Average/Sum#:	-0.1	13.5	1,617.6	0.1	0.5	13 #	10 #	9 #
Minimum:	-0.9	12.1	386.1	-0.5	0.1	0	0	0
Maximum:	0.4	17.4	2,112.1	0.4	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2024 00:00	-0.1	12.7	1,977.0	0.1	0.6	1	1	1
08/21/2024 01:00	-0.5	13.0	1,932.7	-0.2	0.6	1	1	1
08/21/2024 02:00	0.2	13.7	1,698.5	0.4	0.5	1	1	1
08/21/2024 03:00	0.4	13.8	1,712.4	0.4	0.5	1	1	0
08/21/2024 04:00	0.4	13.8	1,722.8	0.4	0.5	1	1	0
08/21/2024 05:00	0.4	13.8	1,733.9	0.4	0.5	1	1	0
08/21/2024 06:00	0.4	13.8	1,729.8	0.4	0.5	1	1	0
08/21/2024 07:00	0.4	13.8	1,615.7	0.4	0.5	1	1	0
08/21/2024 08:00	0.4	13.8	1,608.9	0.4	0.5	1	1	0
08/21/2024 09:00	0.4	13.9	1,324.7	0.4	0.4	1	1	0
08/21/2024 10:00	0.4	13.9	1,531.7	0.4	0.5	1	1	0
08/21/2024 11:00	0.4	13.9	1,575.6	0.4	0.5	1	1	0
08/21/2024 12:00	0.4	13.9	1,650.3	0.4	0.5	1	1	0
08/21/2024 13:00	0.4	13.7	1,732.7	0.4	0.5	1	1	0
08/21/2024 14:00	0.4	13.7	1,744.6	0.4	0.5	1	1	0
08/21/2024 15:00	0.4	13.7	1,724.3	0.4	0.5	1	1	0
08/21/2024 16:00	0.4	13.8	1,607.4	0.4	0.5	1	1	0
08/21/2024 17:00	-0.1	12.2	2,081.1	0.2	0.6	1	1	1
08/21/2024 18:00	0.4	11.6	2,209.4	0.5	0.7	1	1	1
08/21/2024 19:00	0.4	11.7	2,187.9	0.5	0.7	1	1	1
08/21/2024 20:00	0.4	12.0	2,161.6	0.5	0.6	1	1	1
08/21/2024 21:00	0.4	11.8	2,198.3	0.5	0.7	1	1	1
08/21/2024 22:00	0.4	11.9	2,170.0	0.5	0.7	1	1	1
08/21/2024 23:00	0.2	12.1	2,120.9	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,823.0	0.4	0.6	24 #	24 #	10 #
Minimum:	-0.5	11.6	1,324.7	-0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,209.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2024 00:00	0.1	12.7	2,003.4	0.2	0.6	1	1	1
08/22/2024 01:00	-0.1	12.8	1,978.3	0.1	0.6	1	1	1
08/22/2024 02:00	-0.1	12.9	1,976.8	0.1	0.6	1	1	1
08/22/2024 03:00	-0.1	12.9	1,975.8	0.1	0.6	1	1	1
08/22/2024 04:00	-0.2	12.9	1,982.0	0.1	0.6	1	1	1
08/22/2024 05:00	0.1	12.2	2,120.5	0.2	0.6	1	1	1
08/22/2024 06:00	0.0	0.0	665.1	0.0	0.2	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	12.7	1,814.6	0.1	0.5	7 #	6 #	6 #
Minimum:	-0.2	12.2	665.1	0.1	0.2	0	0	0
Maximum:	0.1	12.9	2,120.5	0.2	0.6	1	1	1
%SI	75.00	75.00	70.83	75.00	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2024 00:00	0.0	18.5	122.6	0.0	0.0	1	0	0
08/26/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 07:00	0.0	17.5	369.2	0.0	0.1	1	0	0
08/26/2024 08:00	0.0	0.0	1,279.0	0.0	0.4	1	0	0
08/26/2024 09:00	0.4	13.8	1,730.7	0.4	0.5	1	1	0
08/26/2024 10:00	0.4	13.8	1,721.4	0.4	0.5	1	1	0
08/26/2024 11:00	0.4	13.8	1,722.7	0.4	0.5	1	1	0
08/26/2024 12:00	-0.1	13.1	1,859.3	0.1	0.6	1	1	1
08/26/2024 13:00	-0.2	12.6	2,036.0	0.1	0.6	1	1	1
08/26/2024 14:00	-0.1	12.3	2,070.0	0.2	0.6	1	1	1
08/26/2024 15:00	-0.1	12.5	2,036.1	0.1	0.6	1	1	1
08/26/2024 16:00	0.2	12.0	2,145.3	0.4	0.6	1	1	1
08/26/2024 17:00	0.4	11.6	2,241.7	0.5	0.7	1	1	1
08/26/2024 18:00	0.4	11.4	2,269.5	0.5	0.7	1	1	1
08/26/2024 19:00	0.4	11.4	2,277.8	0.5	0.7	1	1	1
08/26/2024 20:00	0.4	11.7	2,235.2	0.5	0.7	1	1	1
08/26/2024 21:00	0.4	11.7	2,238.0	0.5	0.7	1	1	1
08/26/2024 22:00	0.4	11.8	2,211.5	0.5	0.7	1	1	1
08/26/2024 23:00	-0.1	12.8	1,993.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,808.9	0.3	0.5	18 #	15 #	12 #
Minimum:	-0.2	11.4	122.6	0.0	0.0	0	0	0
Maximum:	0.4	18.5	2,277.8	0.5	0.7	1	1	1
%SI	25.00	29.17	25.00	29.17	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2024 00:00	-0.2	12.9	1,982.9	0.1	0.6	1	1	1
08/27/2024 01:00	-0.2	12.9	1,987.8	0.1	0.6	1	1	1
08/27/2024 02:00	-0.2	12.9	1,988.3	0.1	0.6	1	1	1
08/27/2024 03:00	-0.2	12.8	1,989.3	0.1	0.6	1	1	1
08/27/2024 04:00	-0.2	12.9	1,973.2	0.1	0.6	1	1	1
08/27/2024 05:00	0.4	13.8	1,714.4	0.4	0.5	1	1	0
08/27/2024 06:00	0.4	13.8	1,696.5	0.4	0.5	1	1	0
08/27/2024 07:00	0.4	13.8	1,596.0	0.4	0.5	1	1	0
08/27/2024 08:00	0.4	13.9	1,314.7	0.4	0.4	1	1	0
08/27/2024 09:00	0.4	14.0	1,311.2	0.4	0.4	1	1	0
08/27/2024 10:00	0.4	14.0	1,315.7	0.4	0.4	1	1	0
08/27/2024 11:00	0.4	14.0	1,325.7	0.4	0.4	1	1	0
08/27/2024 12:00	0.4	13.9	1,610.3	0.4	0.5	1	1	0
08/27/2024 13:00	0.4	13.8	1,651.4	0.4	0.5	1	1	0
08/27/2024 14:00	0.4	13.7	1,714.5	0.4	0.5	1	1	0
08/27/2024 15:00	0.4	13.8	1,587.0	0.4	0.5	1	1	0
08/27/2024 16:00	-0.1	12.6	1,930.9	0.1	0.6	1	1	1
08/27/2024 17:00	0.2	11.7	2,195.3	0.4	0.7	1	1	1
08/27/2024 18:00	0.4	11.9	2,175.9	0.5	0.7	1	1	1
08/27/2024 19:00	0.4	11.8	2,202.2	0.5	0.7	1	1	1
08/27/2024 20:00	0.4	11.7	2,222.7	0.5	0.7	1	1	1
08/27/2024 21:00	0.4	11.8	2,204.6	0.5	0.7	1	1	1
08/27/2024 22:00	0.2	12.3	2,093.2	0.4	0.6	1	1	1
08/27/2024 23:00	0.4	12.1	2,168.2	0.5	0.7	1	1	1
Average/Sum#:	0.2	13.0	1,831.3	0.3	0.6	24 #	24 #	13 #
Minimum:	-0.2	11.7	1,311.2	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,222.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2024 00:00	0.2	12.3	2,114.2	0.4	0.6	1	1	1
08/28/2024 01:00	0.1	12.8	1,993.1	0.2	0.6	1	1	1
08/28/2024 02:00	0.1	12.8	1,991.8	0.2	0.6	1	1	1
08/28/2024 03:00	0.1	12.5	2,063.6	0.2	0.6	1	1	1
08/28/2024 04:00	0.4	12.0	2,187.0	0.5	0.7	1	1	1
08/28/2024 05:00	0.4	12.0	2,183.2	0.5	0.7	1	1	1
08/28/2024 06:00	0.2	12.6	2,053.3	0.4	0.6	1	1	1
08/28/2024 07:00	0.1	12.8	1,987.7	0.2	0.6	1	1	1
08/28/2024 08:00	0.1	12.6	1,996.1	0.2	0.6	1	1	1
08/28/2024 09:00	0.1	12.6	2,001.7	0.2	0.6	1	1	1
08/28/2024 10:00	0.1	12.6	2,009.8	0.2	0.6	1	1	1
08/28/2024 11:00	0.1	12.5	2,018.1	0.2	0.6	1	1	1
08/28/2024 12:00	0.1	12.4	2,032.0	0.2	0.6	1	1	1
08/28/2024 13:00	0.2	12.2	2,083.3	0.4	0.6	1	1	1
08/28/2024 14:00	0.2	12.2	2,064.2	0.4	0.6	1	1	1
08/28/2024 15:00	0.2	12.3	2,047.6	0.4	0.6	1	1	1
08/28/2024 16:00	0.2	12.2	2,073.3	0.4	0.6	1	1	1
08/28/2024 17:00	0.2	12.4	2,053.1	0.4	0.6	1	1	1
08/28/2024 18:00	0.4	12.0	2,136.2	0.5	0.6	1	1	1
08/28/2024 19:00	0.4	11.6	2,208.4	0.5	0.7	1	1	1
08/28/2024 20:00	0.4	12.0	2,114.4	0.5	0.6	1	1	1
08/28/2024 21:00	0.1	12.5	2,012.1	0.2	0.6	1	1	1
08/28/2024 22:00	0.1	12.6	2,001.2	0.2	0.6	1	1	1
08/28/2024 23:00	0.1	12.8	1,986.0	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.4	2,058.8	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	11.6	1,986.0	0.2	0.6	1	1	1
Maximum:	0.4	12.8	2,208.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2024 00:00	-0.1	12.8	1,987.7	0.1	0.6	1	1	1
08/29/2024 01:00	0.1	12.8	1,985.2	0.2	0.6	1	1	1
08/29/2024 02:00	-0.1	12.9	1,978.7	0.1	0.6	1	1	1
08/29/2024 03:00	-0.1	12.8	1,981.6	0.1	0.6	1	1	1
08/29/2024 04:00	-0.1	12.7	2,017.8	0.1	0.6	1	1	1
08/29/2024 05:00	-0.1	12.8	1,979.8	0.1	0.6	1	1	1
08/29/2024 06:00	0.4	13.8	1,742.2	0.4	0.5	1	1	0
08/29/2024 07:00	0.4	13.8	1,542.6	0.4	0.5	1	1	0
08/29/2024 08:00	0.4	13.9	1,318.8	0.4	0.4	1	1	0
08/29/2024 09:00	0.4	14.0	1,319.4	0.4	0.4	1	1	0
08/29/2024 10:00	0.4	14.0	1,322.9	0.4	0.4	1	1	0
08/29/2024 11:00	0.4	14.0	1,330.1	0.4	0.4	1	1	0
08/29/2024 12:00	0.3	13.8	1,579.7	0.4	0.5	1	1	0
08/29/2024 13:00	0.3	13.8	1,673.9	0.4	0.5	1	1	0
08/29/2024 14:00	0.4	13.7	1,718.2	0.4	0.5	1	1	0
08/29/2024 15:00	0.1	13.8	1,538.1	0.2	0.5	1	1	1
08/29/2024 16:00	-0.1	12.3	2,064.7	0.2	0.6	1	1	1
08/29/2024 17:00	0.1	12.0	2,128.8	0.2	0.6	1	1	1
08/29/2024 18:00	0.2	12.3	2,060.8	0.4	0.6	1	1	1
08/29/2024 19:00	0.2	11.9	2,180.6	0.4	0.7	1	1	1
08/29/2024 20:00	0.1	12.2	2,096.1	0.2	0.6	1	1	1
08/29/2024 21:00	0.1	12.4	2,055.3	0.2	0.6	1	1	1
08/29/2024 22:00	-0.1	12.7	1,990.0	0.1	0.6	1	1	1
08/29/2024 23:00	-0.1	12.7	1,987.2	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,815.8	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	11.9	1,318.8	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,180.6	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2024 00:00	-0.1	12.8	1,981.1	0.1	0.6	1	1	1
08/30/2024 01:00	-0.1	12.9	1,979.5	0.1	0.6	1	1	1
08/30/2024 02:00	-0.1	12.9	1,980.2	0.1	0.6	1	1	1
08/30/2024 03:00	-0.2	12.9	1,981.5	0.1	0.6	1	1	1
08/30/2024 04:00	-0.1	12.6	2,052.7	0.1	0.6	1	1	1
08/30/2024 05:00	0.1	12.4	2,096.4	0.2	0.6	1	1	1
08/30/2024 06:00	0.1	12.6	2,050.6	0.2	0.6	1	1	1
08/30/2024 07:00	0.2	13.8	1,395.7	0.4	0.4	1	1	1
08/30/2024 08:00	0.4	13.9	1,375.1	0.4	0.4	1	1	0
08/30/2024 09:00	0.4	13.9	1,323.9	0.4	0.4	1	1	0
08/30/2024 10:00	0.4	13.9	1,331.8	0.4	0.4	1	1	0
08/30/2024 11:00	0.4	13.9	1,370.2	0.4	0.4	1	1	0
08/30/2024 12:00	0.4	14.0	1,341.5	0.4	0.4	1	1	0
08/30/2024 13:00	0.4	13.8	1,671.9	0.4	0.5	1	1	0
08/30/2024 14:00	0.1	13.5	1,720.8	0.2	0.5	1	1	1
08/30/2024 15:00	0.1	12.2	2,072.7	0.2	0.6	1	1	1
08/30/2024 16:00	0.2	12.1	2,103.4	0.4	0.6	1	1	1
08/30/2024 17:00	0.4	11.7	2,183.6	0.5	0.7	1	1	1
08/30/2024 18:00	0.4	11.6	2,222.8	0.5	0.7	1	1	1
08/30/2024 19:00	0.4	11.6	2,216.4	0.5	0.7	1	1	1
08/30/2024 20:00	0.4	11.6	2,214.0	0.5	0.7	1	1	1
08/30/2024 21:00	0.4	11.8	2,169.7	0.5	0.7	1	1	1
08/30/2024 22:00	0.1	12.5	2,029.6	0.2	0.6	1	1	1
08/30/2024 23:00	0.4	11.9	2,192.3	0.5	0.7	1	1	1
Average/Sum#:	0.2	12.8	1,877.4	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.2	11.6	1,323.9	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,222.8	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2024 00:00	0.2	11.9	2,188.9	0.4	0.7	1	1	1
08/31/2024 01:00	0.2	12.0	2,183.5	0.4	0.7	1	1	1
08/31/2024 02:00	0.4	12.0	2,182.9	0.5	0.7	1	1	1
08/31/2024 03:00	0.2	12.0	2,179.0	0.4	0.7	1	1	1
08/31/2024 04:00	0.4	12.0	2,178.1	0.5	0.7	1	1	1
08/31/2024 05:00	0.2	12.3	2,068.0	0.4	0.6	1	1	1
08/31/2024 06:00	0.0	14.5	582.2	0.0	0.2	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 10:00	0.0	18.8	179.2	0.0	0.1	1	0	0
08/31/2024 11:00	0.0	15.8	792.8	0.0	0.2	1	0	0
08/31/2024 12:00	0.4	13.9	1,408.7	0.4	0.4	1	1	0
08/31/2024 13:00	0.4	14.0	1,387.0	0.4	0.4	1	1	0
08/31/2024 14:00	0.3	13.8	1,621.6	0.4	0.5	1	1	0
08/31/2024 15:00	0.4	13.8	1,543.4	0.4	0.5	1	1	0
08/31/2024 16:00	0.4	13.7	1,673.8	0.4	0.5	1	1	0
08/31/2024 17:00	0.1	13.0	1,811.8	0.2	0.5	1	1	1
08/31/2024 18:00	0.4	11.4	2,242.4	0.5	0.7	1	1	1
08/31/2024 19:00	0.5	11.3	2,266.4	0.5	0.7	1	1	1
08/31/2024 20:00	0.5	11.3	2,275.9	0.5	0.7	1	1	1
08/31/2024 21:00	0.5	11.4	2,281.8	0.5	0.7	1	1	1
08/31/2024 22:00	0.4	11.7	2,230.8	0.5	0.7	1	1	1
08/31/2024 23:00	0.4	11.5	2,266.1	0.5	0.7	1	1	1
Average/Sum#:	0.3	13.0	1,787.8	0.4	0.6	21 #	18 #	13 #
Minimum:	0.0	11.3	179.2	0.0	0.1	0	0	0
Maximum:	0.5	18.8	2,281.8	0.5	0.7	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2024 00:00	0.2	12.0	2,156.0	0.4	0.6	1	1	1
09/01/2024 01:00	0.2	12.1	2,149.0	0.4	0.6	1	1	1
09/01/2024 02:00	0.2	12.0	2,165.6	0.4	0.6	1	1	1
09/01/2024 03:00	0.2	12.4	2,074.5	0.4	0.6	1	1	1
09/01/2024 04:00	-0.1	12.8	1,987.5	0.1	0.6	1	1	1
09/01/2024 05:00	-0.2	12.9	1,944.5	0.1	0.6	1	1	1
09/01/2024 06:00	0.0	14.3	619.8	0.0	0.2	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 14:00	0.0	17.8	324.8	0.0	0.1	1	0	0
09/01/2024 15:00	0.0	15.1	1,083.9	0.0	0.3	1	0	0
09/01/2024 16:00	0.4	13.6	1,720.5	0.4	0.5	1	1	0
09/01/2024 17:00	0.2	13.6	1,723.1	0.4	0.5	1	1	1
09/01/2024 18:00	0.1	11.9	2,140.5	0.2	0.6	1	1	1
09/01/2024 19:00	0.4	11.6	2,209.3	0.5	0.7	1	1	1
09/01/2024 20:00	0.4	11.7	2,196.9	0.5	0.7	1	1	1
09/01/2024 21:00	0.4	11.6	2,230.6	0.5	0.7	1	1	1
09/01/2024 22:00	0.2	11.9	2,173.7	0.4	0.7	1	1	1
09/01/2024 23:00	0.2	12.0	2,170.6	0.4	0.7	1	1	1
Average/Sum#:	0.2	12.9	1,827.7	0.3	0.5	17 #	14 #	13 #
Minimum:	-0.2	11.6	324.8	0.0	0.1	0	0	0
Maximum:	0.4	17.8	2,230.6	0.5	0.7	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2024 00:00	0.2	12.1	2,154.1	0.4	0.6	1	1	1
09/02/2024 01:00	0.1	12.3	2,085.7	0.2	0.6	1	1	1
09/02/2024 02:00	-0.2	12.9	1,962.3	0.1	0.6	1	1	1
09/02/2024 03:00	-0.2	13.0	1,971.1	0.1	0.6	1	1	1
09/02/2024 04:00	-0.4	13.0	1,964.7	-0.1	0.6	1	1	1
09/02/2024 05:00	-0.4	13.0	1,957.0	-0.1	0.6	1	1	1
09/02/2024 06:00	-0.2	13.0	1,934.2	0.1	0.6	1	1	1
09/02/2024 07:00	0.0	15.6	641.5	0.0	0.2	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 14:00	0.0	17.4	428.9	0.0	0.1	1	0	0
09/02/2024 15:00	0.0	14.5	1,215.8	0.0	0.4	1	0	0
09/02/2024 16:00	0.4	13.7	1,682.0	0.4	0.5	1	1	0
09/02/2024 17:00	0.1	13.0	1,820.6	0.2	0.5	1	1	1
09/02/2024 18:00	0.4	11.4	2,266.4	0.5	0.7	1	1	1
09/02/2024 19:00	0.5	11.3	2,284.8	0.5	0.7	1	1	1
09/02/2024 20:00	0.4	11.8	2,193.4	0.5	0.7	1	1	1
09/02/2024 21:00	0.1	12.6	2,002.0	0.2	0.6	1	1	1
09/02/2024 22:00	0.1	12.6	2,027.3	0.2	0.6	1	1	1
09/02/2024 23:00	0.1	12.8	1,991.4	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,810.2	0.2	0.5	18 #	15 #	14 #
Minimum:	-0.4	11.3	428.9	-0.1	0.1	0	0	0
Maximum:	0.5	17.4	2,284.8	0.5	0.7	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2024 00:00	-0.1	12.8	1,982.8	0.1	0.6	1	1	1
09/03/2024 01:00	-0.1	12.8	1,986.8	0.1	0.6	1	1	1
09/03/2024 02:00	-0.1	12.8	1,980.7	0.1	0.6	1	1	1
09/03/2024 03:00	-0.1	12.9	1,976.3	0.1	0.6	1	1	1
09/03/2024 04:00	-0.1	12.8	1,995.1	0.1	0.6	1	1	1
09/03/2024 05:00	0.1	12.2	2,132.6	0.2	0.6	1	1	1
09/03/2024 06:00	0.1	12.6	2,074.6	0.2	0.6	1	1	1
09/03/2024 07:00	-0.1	12.9	1,962.4	0.1	0.6	1	1	1
09/03/2024 08:00	-0.1	12.8	1,971.4	0.1	0.6	1	1	1
09/03/2024 09:00	-0.1	12.7	1,983.4	0.1	0.6	1	1	1
09/03/2024 10:00	-0.1	12.6	2,001.6	0.1	0.6	1	1	1
09/03/2024 11:00	0.1	12.5	2,014.5	0.2	0.6	1	1	1
09/03/2024 12:00	0.2	12.1	2,109.1	0.4	0.6	1	1	1
09/03/2024 13:00	0.4	11.7	2,199.5	0.5	0.7	1	1	1
09/03/2024 14:00	0.4	11.6	2,224.7	0.5	0.7	1	1	1
09/03/2024 15:00	0.5	11.6	2,219.4	0.5	0.7	1	1	1
09/03/2024 16:00	0.4	11.6	2,212.6	0.5	0.7	1	1	1
09/03/2024 17:00	0.4	11.5	2,247.1	0.5	0.7	1	1	1
09/03/2024 18:00	0.5	11.5	2,260.4	0.5	0.7	1	1	1
09/03/2024 19:00	0.5	11.5	2,264.8	0.5	0.7	1	1	1
09/03/2024 20:00	0.5	11.5	2,272.6	0.5	0.7	1	1	1
09/03/2024 21:00	0.5	11.5	2,276.9	0.5	0.7	1	1	1
09/03/2024 22:00	0.5	11.5	2,276.0	0.5	0.7	1	1	1
09/03/2024 23:00	0.4	12.0	2,134.7	0.5	0.6	1	1	1
Average/Sum#:	0.2	12.2	2,115.0	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.5	1,962.4	0.1	0.6	1	1	1
Maximum:	0.5	12.9	2,276.9	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2024 00:00	0.4	13.8	1,719.2	0.4	0.5	1	1	0
09/04/2024 01:00	0.4	13.8	1,737.2	0.4	0.5	1	1	0
09/04/2024 02:00	0.4	13.9	1,724.7	0.4	0.5	1	1	0
09/04/2024 03:00	0.4	13.9	1,741.3	0.4	0.5	1	1	0
09/04/2024 04:00	0.4	13.8	1,740.8	0.4	0.5	1	1	0
09/04/2024 05:00	0.4	13.9	1,710.5	0.4	0.5	1	1	0
09/04/2024 06:00	0.4	13.8	1,707.4	0.4	0.5	1	1	0
09/04/2024 07:00	0.4	13.8	1,738.1	0.4	0.5	1	1	0
09/04/2024 08:00	0.4	13.7	1,745.0	0.4	0.5	1	1	0
09/04/2024 09:00	0.4	13.7	1,740.8	0.4	0.5	1	1	0
09/04/2024 10:00	0.4	13.7	1,733.3	0.4	0.5	1	1	0
09/04/2024 11:00	0.4	13.7	1,741.2	0.4	0.5	1	1	0
09/04/2024 12:00	0.2	13.7	1,683.2	0.4	0.5	1	1	1
09/04/2024 13:00	0.1	12.0	2,136.2	0.2	0.6	1	1	1
09/04/2024 14:00	0.4	11.7	2,182.3	0.5	0.7	1	1	1
09/04/2024 15:00	0.4	11.9	2,122.5	0.5	0.6	1	1	1
09/04/2024 16:00	0.2	11.8	2,150.4	0.4	0.6	1	1	1
09/04/2024 17:00	0.4	11.8	2,151.1	0.5	0.6	1	1	1
09/04/2024 18:00	0.2	11.9	2,121.5	0.4	0.6	1	1	1
09/04/2024 19:00	0.4	11.6	2,203.7	0.5	0.7	1	1	1
09/04/2024 20:00	0.4	11.6	2,211.6	0.5	0.7	1	1	1
09/04/2024 21:00	0.4	11.7	2,201.3	0.5	0.7	1	1	1
09/04/2024 22:00	0.4	11.9	2,172.6	0.5	0.7	1	1	1
09/04/2024 23:00	0.4	11.8	2,196.2	0.5	0.7	1	1	1
Average/Sum#:	0.4	12.9	1,929.7	0.4	0.6	24 #	24 #	12 #
Minimum:	0.1	11.6	1,683.2	0.2	0.5	1	1	0
Maximum:	0.4	13.9	2,211.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2024 00:00	0.4	11.9	2,185.3	0.5	0.7	1	1	1
09/05/2024 01:00	0.4	11.9	2,181.9	0.5	0.7	1	1	1
09/05/2024 02:00	0.4	11.9	2,170.5	0.5	0.7	1	1	1
09/05/2024 03:00	0.1	12.6	2,028.5	0.2	0.6	1	1	1
09/05/2024 04:00	0.4	11.9	2,186.7	0.5	0.7	1	1	1
09/05/2024 05:00	0.4	11.6	2,250.1	0.5	0.7	1	1	1
09/05/2024 06:00	0.2	12.4	2,097.0	0.4	0.6	1	1	1
09/05/2024 07:00	0.4	13.8	1,723.4	0.4	0.5	1	1	0
09/05/2024 08:00	0.4	13.8	1,658.4	0.4	0.5	1	1	0
09/05/2024 09:00	0.4	13.7	1,726.0	0.4	0.5	1	1	0
09/05/2024 10:00	0.4	13.8	1,705.9	0.4	0.5	1	1	0
09/05/2024 11:00	0.4	13.7	1,729.5	0.4	0.5	1	1	0
09/05/2024 12:00	0.2	13.7	1,728.5	0.4	0.5	1	1	1
09/05/2024 13:00	0.1	11.8	2,139.4	0.2	0.6	1	1	1
09/05/2024 14:00	0.4	11.6	2,183.9	0.5	0.7	1	1	1
09/05/2024 15:00	0.4	11.6	2,176.1	0.5	0.7	1	1	1
09/05/2024 16:00	0.2	11.9	2,096.4	0.4	0.6	1	1	1
09/05/2024 17:00	0.4	11.8	2,138.8	0.5	0.6	1	1	1
09/05/2024 18:00	0.4	11.6	2,169.3	0.5	0.7	1	1	1
09/05/2024 19:00	0.4	11.7	2,174.8	0.5	0.7	1	1	1
09/05/2024 20:00	0.4	11.7	2,180.3	0.5	0.7	1	1	1
09/05/2024 21:00	0.4	11.5	2,227.0	0.5	0.7	1	1	1
09/05/2024 22:00	0.5	11.4	2,262.6	0.5	0.7	1	1	1
09/05/2024 23:00	0.4	11.8	2,196.9	0.5	0.7	1	1	1
Average/Sum#:	0.4	12.3	2,054.9	0.4	0.6	24 #	24 #	19 #
Minimum:	0.1	11.4	1,658.4	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,262.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2024 00:00	0.4	11.7	2,192.7	0.5	0.7	1	1	1
09/06/2024 01:00	0.4	11.9	2,150.9	0.5	0.6	1	1	1
09/06/2024 02:00	0.1	12.6	2,010.4	0.2	0.6	1	1	1
09/06/2024 03:00	0.2	11.9	2,182.6	0.4	0.7	1	1	1
09/06/2024 04:00	0.4	11.8	2,218.4	0.5	0.7	1	1	1
09/06/2024 05:00	0.4	11.6	2,266.4	0.5	0.7	1	1	1
09/06/2024 06:00	0.4	12.0	2,176.6	0.5	0.7	1	1	1
09/06/2024 07:00	0.4	12.1	2,145.7	0.5	0.6	1	1	1
09/06/2024 08:00	0.2	12.2	2,102.5	0.4	0.6	1	1	1
09/06/2024 09:00	0.1	12.6	1,992.5	0.2	0.6	1	1	1
09/06/2024 10:00	0.1	12.3	2,061.3	0.2	0.6	1	1	1
09/06/2024 11:00	0.2	11.9	2,136.4	0.4	0.6	1	1	1
09/06/2024 12:00	0.4	11.7	2,171.6	0.5	0.7	1	1	1
09/06/2024 13:00	0.4	11.7	2,166.0	0.5	0.6	1	1	1
09/06/2024 14:00	0.4	11.6	2,177.8	0.5	0.7	1	1	1
09/06/2024 15:00	0.4	11.6	2,177.3	0.5	0.7	1	1	1
09/06/2024 16:00	0.4	11.9	2,123.5	0.5	0.6	1	1	1
09/06/2024 17:00	0.4	11.7	2,162.3	0.5	0.6	1	1	1
09/06/2024 18:00	0.4	11.5	2,193.7	0.5	0.7	1	1	1
09/06/2024 19:00	0.4	11.6	2,201.2	0.5	0.7	1	1	1
09/06/2024 20:00	0.4	11.7	2,212.3	0.5	0.7	1	1	1
09/06/2024 21:00	0.4	11.6	2,233.1	0.5	0.7	1	1	1
09/06/2024 22:00	0.4	11.7	2,218.0	0.5	0.7	1	1	1
09/06/2024 23:00	0.5	11.5	2,276.3	0.5	0.7	1	1	1
Average/Sum#:	0.3	11.9	2,164.6	0.5	0.7	24 #	24 #	24 #
Minimum:	0.1	11.5	1,992.5	0.2	0.6	1	1	1
Maximum:	0.5	12.6	2,276.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2024 00:00	0.5	11.5	2,277.9	0.5	0.7	1	1	1
09/07/2024 01:00	0.5	11.5	2,270.1	0.5	0.7	1	1	1
09/07/2024 02:00	0.4	11.8	2,195.0	0.5	0.7	1	1	1
09/07/2024 03:00	0.4	11.8	2,190.1	0.5	0.7	1	1	1
09/07/2024 04:00	0.4	11.8	2,216.1	0.5	0.7	1	1	1
09/07/2024 05:00	0.4	11.9	2,181.3	0.5	0.7	1	1	1
09/07/2024 06:00	0.1	12.4	2,101.1	0.2	0.6	1	1	1
09/07/2024 07:00	-0.1	12.8	1,977.2	0.1	0.6	1	1	1
09/07/2024 08:00	-0.1	12.8	1,977.3	0.1	0.6	1	1	1
09/07/2024 09:00	-0.1	12.7	1,991.3	0.1	0.6	1	1	1
09/07/2024 10:00	0.2	12.2	2,091.9	0.4	0.6	1	1	1
09/07/2024 11:00	0.1	12.3	2,070.3	0.2	0.6	1	1	1
09/07/2024 12:00	0.4	11.8	2,167.4	0.5	0.7	1	1	1
09/07/2024 13:00	0.4	11.5	2,217.6	0.5	0.7	1	1	1
09/07/2024 14:00	0.4	11.4	2,238.6	0.5	0.7	1	1	1
09/07/2024 15:00	0.4	11.4	2,241.0	0.5	0.7	1	1	1
09/07/2024 16:00	0.4	11.8	2,156.7	0.5	0.6	1	1	1
09/07/2024 17:00	0.4	11.4	2,250.0	0.5	0.7	1	1	1
09/07/2024 18:00	0.5	11.4	2,264.7	0.5	0.7	1	1	1
09/07/2024 19:00	0.5	11.4	2,273.3	0.5	0.7	1	1	1
09/07/2024 20:00	0.5	11.5	2,279.4	0.5	0.7	1	1	1
09/07/2024 21:00	0.5	11.5	2,270.8	0.5	0.7	1	1	1
09/07/2024 22:00	0.4	11.9	2,188.7	0.5	0.7	1	1	1
09/07/2024 23:00	0.4	11.6	2,267.5	0.5	0.7	1	1	1
Average/Sum#:	0.3	11.8	2,181.5	0.4	0.7	24 #	24 #	24 #
Minimum:	-0.1	11.4	1,977.2	0.1	0.6	1	1	1
Maximum:	0.5	12.8	2,279.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2024 00:00	0.2	12.1	2,145.1	0.4	0.6	1	1	1
09/08/2024 01:00	0.1	12.7	2,001.6	0.2	0.6	1	1	1
09/08/2024 02:00	0.2	12.1	2,161.9	0.4	0.6	1	1	1
09/08/2024 03:00	0.4	12.0	2,177.0	0.5	0.7	1	1	1
09/08/2024 04:00	0.1	12.7	2,020.7	0.2	0.6	1	1	1
09/08/2024 05:00	0.4	13.8	1,703.7	0.4	0.5	1	1	0
09/08/2024 06:00	0.4	13.8	1,657.6	0.4	0.5	1	1	0
09/08/2024 07:00	0.4	13.8	1,646.3	0.4	0.5	1	1	0
09/08/2024 08:00	0.4	13.8	1,615.7	0.4	0.5	1	1	0
09/08/2024 09:00	0.4	13.8	1,544.2	0.4	0.5	1	1	0
09/08/2024 10:00	0.4	13.9	1,544.0	0.4	0.5	1	1	0
09/08/2024 11:00	0.4	13.9	1,559.2	0.4	0.5	1	1	0
09/08/2024 12:00	0.4	13.9	1,642.0	0.4	0.5	1	1	0
09/08/2024 13:00	0.4	13.8	1,672.1	0.4	0.5	1	1	0
09/08/2024 14:00	0.1	13.0	1,838.6	0.2	0.6	1	1	1
09/08/2024 15:00	0.4	11.6	2,219.4	0.5	0.7	1	1	1
09/08/2024 16:00	0.4	12.0	2,132.6	0.5	0.6	1	1	1
09/08/2024 17:00	0.4	11.5	2,225.6	0.5	0.7	1	1	1
09/08/2024 18:00	0.4	11.5	2,238.1	0.5	0.7	1	1	1
09/08/2024 19:00	0.5	11.4	2,264.2	0.5	0.7	1	1	1
09/08/2024 20:00	0.5	11.4	2,266.1	0.5	0.7	1	1	1
09/08/2024 21:00	0.5	11.5	2,253.8	0.5	0.7	1	1	1
09/08/2024 22:00	0.5	11.7	2,203.8	0.5	0.7	1	1	1
09/08/2024 23:00	0.4	11.8	2,189.9	0.5	0.7	1	1	1
Average/Sum#:	0.4	12.6	1,955.1	0.4	0.6	24 #	24 #	15 #
Minimum:	0.1	11.4	1,544.0	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,266.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2024 00:00	0.4	11.9	2,188.1	0.5	0.7	1	1	1
09/09/2024 01:00	0.2	12.5	2,064.1	0.4	0.6	1	1	1
09/09/2024 02:00	0.4	12.1	2,168.9	0.5	0.7	1	1	1
09/09/2024 03:00	0.4	11.9	2,186.0	0.5	0.7	1	1	1
09/09/2024 04:00	0.4	11.9	2,191.4	0.5	0.7	1	1	1
09/09/2024 05:00	0.5	11.7	2,256.7	0.5	0.7	1	1	1
09/09/2024 06:00	0.1	12.6	2,085.6	0.2	0.6	1	1	1
09/09/2024 07:00	0.1	12.9	1,975.6	0.2	0.6	1	1	1
09/09/2024 08:00	0.1	12.8	1,979.2	0.2	0.6	1	1	1
09/09/2024 09:00	0.2	12.0	2,145.7	0.4	0.6	1	1	1
09/09/2024 10:00	0.4	11.9	2,124.1	0.5	0.6	1	1	1
09/09/2024 11:00	0.4	12.1	2,080.6	0.5	0.6	1	1	1
09/09/2024 12:00	0.4	12.0	2,077.3	0.5	0.6	1	1	1
09/09/2024 13:00	0.4	12.0	2,083.8	0.5	0.6	1	1	1
09/09/2024 14:00	0.2	12.2	2,028.2	0.4	0.6	1	1	1
09/09/2024 15:00	0.2	11.9	2,082.5	0.4	0.6	1	1	1
09/09/2024 16:00	0.4	11.4	2,172.2	0.5	0.7	1	1	1
09/09/2024 17:00	0.4	11.6	2,142.6	0.5	0.6	1	1	1
09/09/2024 18:00	0.5	11.5	2,175.7	0.5	0.7	1	1	1
09/09/2024 19:00	0.5	11.6	2,161.8	0.5	0.6	1	1	1
09/09/2024 20:00	0.4	12.0	2,099.9	0.5	0.6	1	1	1
09/09/2024 21:00	0.4	12.1	2,088.7	0.5	0.6	1	1	1
09/09/2024 22:00	0.1	12.6	1,979.5	0.2	0.6	1	1	1
09/09/2024 23:00	0.4	11.9	2,154.2	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.0	2,112.2	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	11.4	1,975.6	0.2	0.6	1	1	1
Maximum:	0.5	12.9	2,256.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2024 00:00	0.4	11.9	2,145.4	0.5	0.6	1	1	1
09/10/2024 01:00	0.2	12.5	2,018.8	0.4	0.6	1	1	1
09/10/2024 02:00	0.1	12.6	1,980.9	0.2	0.6	1	1	1
09/10/2024 03:00	-0.1	12.5	2,014.8	0.1	0.6	1	1	1
09/10/2024 04:00	0.1	12.3	2,074.7	0.2	0.6	1	1	1
09/10/2024 05:00	0.2	11.8	2,204.9	0.4	0.7	1	1	1
09/10/2024 06:00	-0.1	12.5	2,034.3	0.1	0.6	1	1	1
09/10/2024 07:00	0.4	13.8	1,550.6	0.4	0.5	1	1	0
09/10/2024 08:00	0.4	13.9	1,290.7	0.4	0.4	1	1	0
09/10/2024 09:00	0.4	13.9	1,292.0	0.4	0.4	1	1	0
09/10/2024 10:00	0.4	13.9	1,297.8	0.4	0.4	1	1	0
09/10/2024 11:00	0.4	14.0	1,300.7	0.4	0.4	1	1	0
09/10/2024 12:00	0.4	13.9	1,303.8	0.4	0.4	1	1	0
09/10/2024 13:00	0.4	13.9	1,386.5	0.4	0.4	1	1	0
09/10/2024 14:00	0.4	14.0	1,301.1	0.4	0.4	1	1	0
09/10/2024 15:00	0.4	14.0	1,318.6	0.4	0.4	1	1	0
09/10/2024 16:00	0.2	13.8	1,551.7	0.4	0.5	1	1	1
09/10/2024 17:00	-0.2	12.5	1,958.2	0.1	0.6	1	1	1
09/10/2024 18:00	-0.1	12.5	1,976.9	0.1	0.6	1	1	1
09/10/2024 19:00	-0.1	12.6	1,959.0	0.1	0.6	1	1	1
09/10/2024 20:00	-0.1	12.7	1,948.0	0.1	0.6	1	1	1
09/10/2024 21:00	-0.1	12.8	1,941.4	0.1	0.6	1	1	1
09/10/2024 22:00	-0.2	12.8	1,920.9	0.1	0.6	1	1	1
09/10/2024 23:00	0.0	15.6	634.3	0.0	0.2	1	0	0
Average/Sum#:	0.2	13.2	1,683.6	0.3	0.5	24 #	23 #	14 #
Minimum:	-0.2	11.8	634.3	0.0	0.2	1	0	0
Maximum:	0.4	15.6	2,204.9	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 18:00	0.0	17.6	320.1	0.0	0.1	1	0	0
09/13/2024 19:00	0.0	15.3	874.9	0.0	0.3	1	0	0
09/13/2024 20:00	0.4	13.7	1,667.3	0.4	0.5	1	1	0
09/13/2024 21:00	0.4	13.7	1,691.4	0.4	0.5	1	1	0
09/13/2024 22:00	0.4	13.7	1,684.4	0.4	0.5	1	1	0
09/13/2024 23:00	0.4	13.8	1,689.2	0.4	0.5	1	1	0
Average/Sum#:	0.3	14.6	1,321.2	0.3	0.4	6 #	4 #	0 #
Minimum:	0.0	13.7	320.1	0.0	0.1	0	0	0
Maximum:	0.4	17.6	1,691.4	0.4	0.5	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2024 00:00	0.4	13.8	1,694.8	0.4	0.5	1	1	0
09/14/2024 01:00	0.4	13.6	1,760.8	0.4	0.5	1	1	0
09/14/2024 02:00	0.0	14.2	1,423.0	0.0	0.4	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.9	1,626.2	0.3	0.5	3 #	2 #	0 #
Minimum:	0.0	13.6	1,423.0	0.0	0.4	0	0	0
Maximum:	0.4	14.2	1,760.8	0.4	0.5	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2024 01:00	0.0	17.5	337.6	0.0	0.1	1	0	0
09/18/2024 02:00	0.0	15.4	868.5	0.0	0.3	1	0	0
09/18/2024 03:00	0.4	13.8	1,486.9	0.4	0.4	1	1	0
09/18/2024 04:00	0.4	13.7	1,688.7	0.4	0.5	1	1	1
09/18/2024 05:00	-0.2	12.6	2,049.5	0.1	0.6	1	1	1
09/18/2024 06:00	0.2	12.5	2,082.3	0.4	0.6	1	1	1
09/18/2024 07:00	0.1	12.8	1,955.6	0.2	0.6	1	1	1
09/18/2024 08:00	0.1	12.9	1,916.9	0.2	0.6	1	1	1
09/18/2024 09:00	-0.1	12.9	1,921.9	0.1	0.6	1	1	1
09/18/2024 10:00	-0.1	12.8	1,931.7	0.1	0.6	1	1	1
09/18/2024 11:00	-0.1	12.8	1,936.0	0.1	0.6	1	1	1
09/18/2024 12:00	0.1	12.8	1,935.7	0.2	0.6	1	1	1
09/18/2024 13:00	0.1	12.7	1,946.8	0.2	0.6	1	1	1
09/18/2024 14:00	0.1	12.7	1,952.7	0.2	0.6	1	1	1
09/18/2024 15:00	0.1	12.7	1,941.3	0.2	0.6	1	1	1
09/18/2024 16:00	0.2	12.2	2,065.1	0.4	0.6	1	1	1
09/18/2024 17:00	0.5	11.6	2,172.4	0.5	0.7	1	1	1
09/18/2024 18:00	0.4	11.9	2,107.2	0.5	0.6	1	1	1
09/18/2024 19:00	0.5	11.8	2,124.3	0.5	0.6	1	1	1
09/18/2024 20:00	0.4	11.9	2,109.4	0.5	0.6	1	1	1
09/18/2024 21:00	0.4	11.9	2,110.8	0.5	0.6	1	1	1
09/18/2024 22:00	0.4	12.0	2,106.6	0.5	0.6	1	1	1
09/18/2024 23:00	0.4	12.0	2,108.3	0.5	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,863.3	0.3	0.6	23 #	21 #	20 #
Minimum:	-0.2	11.6	337.6	0.0	0.1	0	0	0
Maximum:	0.5	17.5	2,172.4	0.5	0.7	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2024 00:00	0.4	11.9	2,111.6	0.5	0.6	1	1	1
09/19/2024 01:00	0.4	12.0	2,109.8	0.5	0.6	1	1	1
09/19/2024 02:00	0.5	12.0	2,112.4	0.5	0.6	1	1	1
09/19/2024 03:00	0.4	11.9	2,115.1	0.5	0.6	1	1	1
09/19/2024 04:00	0.4	12.0	2,112.3	0.5	0.6	1	1	1
09/19/2024 05:00	0.4	12.0	2,112.3	0.5	0.6	1	1	1
09/19/2024 06:00	0.2	12.4	2,031.0	0.4	0.6	1	1	1
09/19/2024 07:00	0.0	15.5	651.4	0.0	0.2	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	12.5	1,919.5	0.4	0.6	8 #	7 #	7 #
Minimum:	0.0	11.9	651.4	0.0	0.2	0	0	0
Maximum:	0.5	15.5	2,115.1	0.5	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 20:00	0.0	17.6	313.3	0.0	0.1	1	0	0
09/21/2024 21:00	0.0	17.1	392.2	0.0	0.1	1	0	0
09/21/2024 22:00	0.0	15.2	926.2	0.0	0.3	1	0	0
09/21/2024 23:00	0.4	13.9	1,560.6	0.4	0.5	1	1	0
Average/Sum#:	0.1	16.0	798.1	0.1	0.3	4 #	1 #	0 #
Minimum:	0.0	13.9	313.3	0.0	0.1	0	0	0
Maximum:	0.4	17.6	1,560.6	0.4	0.5	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2024 00:00	0.4	13.8	1,688.4	0.4	0.5	1	1	0
09/22/2024 01:00	0.4	13.8	1,700.0	0.4	0.5	1	1	0
09/22/2024 02:00	0.4	13.8	1,673.9	0.4	0.5	1	1	0
09/22/2024 03:00	0.4	13.8	1,672.3	0.4	0.5	1	1	0
09/22/2024 04:00	0.4	13.8	1,693.7	0.4	0.5	1	1	0
09/22/2024 05:00	0.4	13.8	1,695.1	0.4	0.5	1	1	0
09/22/2024 06:00	0.4	13.9	1,598.5	0.4	0.5	1	1	0
09/22/2024 07:00	0.0	15.6	609.4	0.0	0.2	1	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 10:00	0.0	17.6	391.9	0.0	0.1	1	0	0
09/22/2024 11:00	0.0	14.7	1,056.8	0.0	0.3	1	0	0
09/22/2024 12:00	0.4	14.0	1,519.1	0.4	0.5	1	1	0
09/22/2024 13:00	0.4	14.0	1,510.6	0.4	0.5	1	1	0
09/22/2024 14:00	0.4	13.8	1,652.6	0.4	0.5	1	1	0
09/22/2024 15:00	0.4	13.9	1,470.3	0.4	0.4	1	1	0
09/22/2024 16:00	0.4	13.9	1,483.9	0.4	0.4	1	1	0
09/22/2024 17:00	0.2	13.9	1,596.3	0.2	0.5	1	1	1
09/22/2024 18:00	-0.1	12.6	1,947.4	0.1	0.6	1	1	1
09/22/2024 19:00	0.1	12.5	1,957.3	0.2	0.6	1	1	1
09/22/2024 20:00	0.1	12.6	1,938.0	0.2	0.6	1	1	1
09/22/2024 21:00	0.1	12.6	1,932.7	0.2	0.6	1	1	1
09/22/2024 22:00	0.1	12.8	1,911.8	0.2	0.6	1	1	1
09/22/2024 23:00	-0.1	12.9	1,909.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.8	1,573.1	0.3	0.5	22 #	19 #	7 #
Minimum:	-0.1	12.5	391.9	0.0	0.1	0	0	0
Maximum:	0.4	17.6	1,957.3	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2024 00:00	0.1	12.9	1,909.9	0.2	0.6	1	1	1
09/23/2024 01:00	0.1	12.9	1,907.8	0.2	0.6	1	1	1
09/23/2024 02:00	-0.1	12.9	1,908.0	0.1	0.6	1	1	1
09/23/2024 03:00	0.1	12.9	1,909.5	0.2	0.6	1	1	1
09/23/2024 04:00	0.1	12.8	1,911.8	0.2	0.6	1	1	1
09/23/2024 05:00	0.1	12.8	1,898.8	0.2	0.6	1	1	1
09/23/2024 06:00	0.4	13.8	1,620.5	0.4	0.5	1	1	0
09/23/2024 07:00	0.4	13.9	1,561.7	0.4	0.5	1	1	0
09/23/2024 08:00	0.4	13.8	1,636.8	0.4	0.5	1	1	0
09/23/2024 09:00	0.4	13.9	1,503.8	0.4	0.5	1	1	0
09/23/2024 10:00	0.4	13.9	1,509.6	0.4	0.5	1	1	0
09/23/2024 11:00	0.4	13.8	1,636.6	0.4	0.5	1	1	0
09/23/2024 12:00	0.4	13.6	1,681.2	0.4	0.5	1	1	0
09/23/2024 13:00	0.2	13.6	1,681.2	0.4	0.5	1	1	1
09/23/2024 14:00	0.2	11.8	2,092.0	0.4	0.6	1	1	1
09/23/2024 15:00	0.4	11.5	2,154.6	0.5	0.6	1	1	1
09/23/2024 16:00	0.5	11.4	2,169.2	0.5	0.7	1	1	1
09/23/2024 17:00	0.5	11.3	2,180.8	0.5	0.7	1	1	1
09/23/2024 18:00	0.5	11.3	2,187.8	0.5	0.7	1	1	1
09/23/2024 19:00	0.5	11.4	2,203.9	0.5	0.7	1	1	1
09/23/2024 20:00	0.5	11.4	2,211.7	0.5	0.7	1	1	1
09/23/2024 21:00	0.5	11.4	2,208.7	0.5	0.7	1	1	1
09/23/2024 22:00	0.5	11.5	2,191.0	0.5	0.7	1	1	1
09/23/2024 23:00	0.4	12.2	2,035.4	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.6	1,913.0	0.4	0.6	24 #	24 #	17 #
Minimum:	-0.1	11.3	1,503.8	0.1	0.5	1	1	0
Maximum:	0.5	13.9	2,211.7	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2024 00:00	0.4	13.8	1,685.3	0.4	0.5	1	1	1
09/24/2024 01:00	0.4	13.9	1,667.6	0.4	0.5	1	1	0
09/24/2024 02:00	0.4	13.9	1,631.2	0.4	0.5	1	1	0
09/24/2024 03:00	0.4	13.9	1,667.0	0.4	0.5	1	1	0
09/24/2024 04:00	0.4	13.8	1,677.0	0.4	0.5	1	1	0
09/24/2024 05:00	0.4	13.9	1,666.7	0.4	0.5	1	1	0
09/24/2024 06:00	0.4	13.8	1,626.8	0.4	0.5	1	1	0
09/24/2024 07:00	0.4	13.9	1,573.7	0.4	0.5	1	1	0
09/24/2024 08:00	0.4	13.9	1,501.2	0.4	0.5	1	1	0
09/24/2024 09:00	0.4	13.8	1,519.9	0.4	0.5	1	1	0
09/24/2024 10:00	0.4	13.8	1,550.8	0.4	0.5	1	1	0
09/24/2024 11:00	0.4	13.8	1,640.5	0.4	0.5	1	1	0
09/24/2024 12:00	0.4	13.9	1,387.9	0.4	0.4	1	1	0
09/24/2024 13:00	0.1	12.6	1,830.9	0.2	0.5	1	1	1
09/24/2024 14:00	0.4	11.4	2,137.5	0.5	0.6	1	1	1
09/24/2024 15:00	0.5	11.6	2,115.3	0.5	0.6	1	1	1
09/24/2024 16:00	0.5	11.4	2,149.5	0.5	0.6	1	1	1
09/24/2024 17:00	0.5	11.3	2,175.6	0.5	0.7	1	1	1
09/24/2024 18:00	0.5	11.4	2,156.1	0.5	0.6	1	1	1
09/24/2024 19:00	0.4	11.8	2,075.4	0.5	0.6	1	1	1
09/24/2024 20:00	0.5	11.7	2,133.2	0.5	0.6	1	1	1
09/24/2024 21:00	0.4	12.0	2,058.0	0.5	0.6	1	1	1
09/24/2024 22:00	0.2	12.2	2,013.0	0.4	0.6	1	1	1
09/24/2024 23:00	0.4	11.7	2,129.8	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.9	1,823.7	0.4	0.5	24 #	24 #	12 #
Minimum:	0.1	11.3	1,387.9	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,175.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2024 00:00	0.4	11.8	2,120.6	0.5	0.6	1	1	1
09/25/2024 01:00	0.4	11.9	2,091.9	0.5	0.6	1	1	1
09/25/2024 02:00	0.2	12.2	2,040.2	0.4	0.6	1	1	1
09/25/2024 03:00	0.2	12.0	2,098.3	0.4	0.6	1	1	1
09/25/2024 04:00	0.4	11.9	2,111.2	0.5	0.6	1	1	1
09/25/2024 05:00	0.4	12.0	2,108.0	0.5	0.6	1	1	1
09/25/2024 06:00	0.2	12.3	2,024.4	0.4	0.6	1	1	1
09/25/2024 07:00	0.0	15.4	689.0	0.0	0.2	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 18:00	0.0	20.7	0.2	0.0	0.0	1	0	0
09/25/2024 19:00	0.0	15.8	745.9	0.0	0.2	1	0	0
09/25/2024 20:00	0.4	13.8	1,492.4	0.4	0.4	1	1	0
09/25/2024 21:00	0.4	13.8	1,612.7	0.4	0.5	1	1	0
09/25/2024 22:00	0.4	13.9	1,396.3	0.4	0.4	1	1	0
09/25/2024 23:00	0.4	13.8	1,666.1	0.4	0.5	1	1	0
Average/Sum#:	0.3	13.7	1,585.5	0.3	0.5	14 #	11 #	7 #
Minimum:	0.0	11.8	0.2	0.0	0.0	0	0	0
Maximum:	0.4	20.7	2,120.6	0.5	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2024 00:00	0.4	13.8	1,689.2	0.4	0.5	1	1	0
09/26/2024 01:00	0.4	13.8	1,654.0	0.4	0.5	1	1	0
09/26/2024 02:00	0.4	13.8	1,630.7	0.4	0.5	1	1	0
09/26/2024 03:00	0.4	13.8	1,659.7	0.4	0.5	1	1	0
09/26/2024 04:00	0.4	13.8	1,680.7	0.4	0.5	1	1	0
09/26/2024 05:00	0.4	13.8	1,680.7	0.4	0.5	1	1	0
09/26/2024 06:00	0.4	13.8	1,623.4	0.4	0.5	1	1	0
09/26/2024 07:00	0.4	13.9	1,383.1	0.4	0.4	1	1	0
09/26/2024 08:00	0.0	15.7	569.2	0.0	0.2	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.0	1,507.9	0.4	0.5	9 #	8 #	0 #
Minimum:	0.0	13.8	569.2	0.0	0.2	0	0	0
Maximum:	0.4	15.7	1,689.2	0.4	0.5	1	1	0
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 13:00	0.0	17.7	306.4	0.0	0.1	1	0	0
09/27/2024 14:00	0.0	15.0	1,030.4	0.0	0.3	1	0	0
09/27/2024 15:00	0.4	13.9	1,436.6	0.4	0.4	1	1	0
09/27/2024 16:00	0.2	13.8	1,521.1	0.4	0.5	1	1	1
09/27/2024 17:00	0.2	11.7	2,104.0	0.4	0.6	1	1	1
09/27/2024 18:00	0.5	11.3	2,197.4	0.5	0.7	1	1	1
09/27/2024 19:00	0.5	11.3	2,198.0	0.5	0.7	1	1	1
09/27/2024 20:00	0.5	11.3	2,204.7	0.5	0.7	1	1	1
09/27/2024 21:00	0.5	11.5	2,192.3	0.5	0.7	1	1	1
09/27/2024 22:00	0.4	11.8	2,119.2	0.5	0.6	1	1	1
09/27/2024 23:00	0.4	11.8	2,120.2	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,766.4	0.4	0.5	11 #	9 #	8 #
Minimum:	0.0	11.3	306.4	0.0	0.1	0	0	0
Maximum:	0.5	17.7	2,204.7	0.5	0.7	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2024 00:00	0.4	11.8	2,119.5	0.5	0.6	1	1	1
09/28/2024 01:00	0.4	11.9	2,118.4	0.5	0.6	1	1	1
09/28/2024 02:00	0.4	11.9	2,115.2	0.5	0.6	1	1	1
09/28/2024 03:00	0.4	11.9	2,113.4	0.5	0.6	1	1	1
09/28/2024 04:00	0.4	11.9	2,110.8	0.5	0.6	1	1	1
09/28/2024 05:00	0.4	12.0	2,113.5	0.5	0.6	1	1	1
09/28/2024 06:00	0.2	12.5	2,004.0	0.4	0.6	1	1	1
09/28/2024 07:00	0.0	15.4	693.8	0.0	0.2	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	12.4	1,923.6	0.4	0.6	8 #	7 #	7 #
Minimum:	0.0	11.8	693.8	0.0	0.2	0	0	0
Maximum:	0.4	15.4	2,119.5	0.5	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 14:00	0.0	17.8	317.0	0.0	0.1	1	0	0
09/29/2024 15:00	0.0	14.8	1,077.9	0.0	0.3	1	0	0
09/29/2024 16:00	0.4	13.8	1,571.4	0.4	0.5	1	1	0
09/29/2024 17:00	0.2	13.6	1,706.5	0.4	0.5	1	1	1
09/29/2024 18:00	-0.1	12.5	1,960.0	0.1	0.6	1	1	1
09/29/2024 19:00	0.4	11.7	2,159.0	0.5	0.6	1	1	1
09/29/2024 20:00	0.4	11.7	2,159.7	0.5	0.6	1	1	1
09/29/2024 21:00	0.4	12.1	2,079.8	0.5	0.6	1	1	1
09/29/2024 22:00	0.1	12.8	1,944.4	0.2	0.6	1	1	1
09/29/2024 23:00	0.4	12.0	2,131.4	0.5	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,710.7	0.3	0.5	10 #	8 #	7 #
Minimum:	-0.1	11.7	317.0	0.0	0.1	0	0	0
Maximum:	0.4	17.8	2,159.7	0.5	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2024 00:00	0.2	12.3	2,051.0	0.4	0.6	1	1	1
09/30/2024 01:00	0.1	12.9	1,934.2	0.2	0.6	1	1	1
09/30/2024 02:00	0.1	12.8	1,938.0	0.2	0.6	1	1	1
09/30/2024 03:00	0.1	12.7	1,982.0	0.2	0.6	1	1	1
09/30/2024 04:00	0.2	12.3	2,059.9	0.4	0.6	1	1	1
09/30/2024 05:00	0.2	12.3	2,121.7	0.4	0.6	1	1	1
09/30/2024 06:00	0.4	12.2	2,163.6	0.5	0.6	1	1	1
09/30/2024 07:00	0.2	13.0	1,863.0	0.4	0.6	1	1	1
09/30/2024 08:00	0.5	14.0	1,318.0	0.5	0.4	1	1	0
09/30/2024 09:00	0.5	14.1	1,313.4	0.5	0.4	1	1	0
09/30/2024 10:00	0.5	14.1	1,315.1	0.5	0.4	1	1	0
09/30/2024 11:00	0.5	14.1	1,427.8	0.5	0.4	1	1	0
09/30/2024 12:00	0.5	14.0	1,564.1	0.5	0.5	1	1	0
09/30/2024 13:00	0.4	13.8	1,667.3	0.4	0.5	1	1	1
09/30/2024 14:00	0.2	12.0	2,130.1	0.4	0.6	1	1	1
09/30/2024 15:00	0.4	12.0	2,131.5	0.5	0.6	1	1	1
09/30/2024 16:00	0.5	11.4	2,253.4	0.5	0.7	1	1	1
09/30/2024 17:00	0.5	11.4	2,265.6	0.5	0.7	1	1	1
09/30/2024 18:00	0.5	11.4	2,272.5	0.5	0.7	1	1	1
09/30/2024 19:00	0.5	11.4	2,275.7	0.5	0.7	1	1	1
09/30/2024 20:00	0.5	11.7	2,221.2	0.5	0.7	1	1	1
09/30/2024 21:00	0.5	11.4	2,282.1	0.5	0.7	1	1	1
09/30/2024 22:00	0.5	11.8	2,223.0	0.5	0.7	1	1	1
09/30/2024 23:00	0.4	12.2	2,121.3	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.6	1,954.0	0.4	0.6	24 #	24 #	19 #
Minimum:	0.1	11.4	1,313.4	0.2	0.4	1	1	0
Maximum:	0.5	14.1	2,282.1	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:22 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 7.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:22 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,550.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 658.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,550.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:25 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,550.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 658.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,550.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:25 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:26 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,450.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 758.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,450.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:27 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,450.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 758.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,450.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions NOX

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:27 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:28 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2024 00:00	3.1	15.4	618.6	3.3	1.70	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 08:00	18.0	17.4	351.7	30.3	23.64	1	0	0
07/01/2024 09:00	10.0	15.5	797.9	10.9	31.90	1	0	0
07/01/2024 10:00	1.2	13.7	1,590.9	1.0	6.40	1	1	0
07/01/2024 11:00	1.3	13.7	1,478.8	1.1	5.90	1	1	0
07/01/2024 12:00	1.2	13.8	1,412.5	1.0	5.70	1	1	0
07/01/2024 13:00	1.2	13.7	1,639.2	1.0	6.60	1	1	0
07/01/2024 14:00	1.2	13.7	1,543.8	1.0	6.20	1	1	0
07/01/2024 15:00	1.2	13.9	1,339.5	1.0	5.40	1	1	0
07/01/2024 16:00	1.3	13.6	1,559.1	1.1	6.20	1	1	1
07/01/2024 17:00	1.6	11.7	2,129.1	1.0	8.50	1	1	1
07/01/2024 18:00	1.6	11.4	2,189.3	1.0	8.80	1	1	1
07/01/2024 19:00	1.6	11.5	2,181.9	1.0	8.70	1	1	1
07/01/2024 20:00	1.6	11.5	2,172.0	1.0	8.70	1	1	1
07/01/2024 21:00	1.5	12.0	2,078.8	1.0	8.30	1	1	1
07/01/2024 22:00	1.5	12.1	2,065.8	1.0	8.30	1	1	1
07/01/2024 23:00	3.6	15.6	606.5	4.0	2.46	1	0	0
Average/Sum#:	3.1	13.5	1,515.0	3.6	153.40 #	17 #	13 #	7 #
Minimum:	1.2	11.4	351.7	1.0	1.70	0	0	0
Maximum:	18.0	17.4	2,189.3	30.3	31.90	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 10:00	32.1	17.5	331.6	55.7	34.00	1	0	0
07/02/2024 11:00	14.7	16.9	423.8	21.7	33.90	1	0	0
07/02/2024 12:00	10.1	15.0	986.6	10.1	36.50	1	0	0
07/02/2024 13:00	1.2	13.7	1,659.3	1.0	6.60	1	1	0
07/02/2024 14:00	1.2	13.7	1,576.4	1.0	6.30	1	1	0
07/02/2024 15:00	1.3	13.6	1,668.0	1.1	6.70	1	1	0
07/02/2024 16:00	1.1	13.7	1,581.8	0.9	4.70	1	1	0
07/02/2024 17:00	1.2	13.7	1,636.5	1.0	6.50	1	1	0
07/02/2024 18:00	1.4	12.6	1,852.2	1.0	7.40	1	1	1
07/02/2024 19:00	1.6	11.5	2,194.8	1.0	8.80	1	1	1
07/02/2024 20:00	1.6	11.5	2,184.0	1.0	8.70	1	1	1
07/02/2024 21:00	1.6	11.5	2,182.6	1.0	8.70	1	1	1
07/02/2024 22:00	1.5	11.9	2,127.1	1.0	8.50	1	1	1
07/02/2024 23:00	1.6	11.5	2,208.0	1.0	8.80	1	1	1
Average/Sum#:	5.2	13.5	1,615.2	7.0	186.10 #	14 #	11 #	6 #
Minimum:	1.1	11.5	331.6	0.9	4.70	0	0	0
Maximum:	32.1	17.5	2,208.0	55.7	36.50	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2024 00:00	1.6	11.5	2,201.3	1.0	8.80	1	1	1
07/03/2024 01:00	1.5	12.0	2,096.1	1.0	8.40	1	1	1
07/03/2024 02:00	1.5	12.2	2,062.5	1.0	8.30	1	1	1
07/03/2024 03:00	1.5	12.3	2,042.7	1.0	8.20	1	1	1
07/03/2024 04:00	1.5	12.2	2,053.8	1.0	8.20	1	1	1
07/03/2024 05:00	1.5	12.2	2,058.8	1.0	8.20	1	1	1
07/03/2024 06:00	1.5	12.1	2,070.2	1.0	8.30	1	1	1
07/03/2024 07:00	1.5	12.1	2,078.1	1.0	8.30	1	1	1
07/03/2024 08:00	1.5	12.1	2,084.4	1.0	8.30	1	1	1
07/03/2024 09:00	1.5	12.0	2,092.0	1.0	8.40	1	1	1
07/03/2024 10:00	1.5	12.0	2,098.8	1.0	8.40	1	1	1
07/03/2024 11:00	1.5	12.0	2,085.2	1.0	8.30	1	1	1
07/03/2024 12:00	1.5	11.9	2,092.6	1.0	8.40	1	1	1
07/03/2024 13:00	1.5	11.8	2,091.2	1.0	8.40	1	1	1
07/03/2024 14:00	1.5	11.8	2,093.7	1.0	8.40	1	1	1
07/03/2024 15:00	1.5	11.8	2,103.4	1.0	8.40	1	1	1
07/03/2024 16:00	1.5	12.0	2,045.5	1.0	8.20	1	1	1
07/03/2024 17:00	1.5	12.0	2,046.1	1.0	8.20	1	1	1
07/03/2024 18:00	1.5	11.9	2,060.8	1.0	8.20	1	1	1
07/03/2024 19:00	1.5	11.9	2,080.4	1.0	8.30	1	1	1
07/03/2024 20:00	1.5	11.9	2,077.8	1.0	8.30	1	1	1
07/03/2024 21:00	1.5	12.0	2,070.5	1.0	8.30	1	1	1
07/03/2024 22:00	1.5	12.1	2,065.4	1.0	8.30	1	1	1
07/03/2024 23:00	1.5	12.1	2,052.6	1.0	8.20	1	1	1
Average/Sum#:	1.5	12.0	2,079.3	1.0	199.70 #	24 #	24 #	24 #
Minimum:	1.5	11.5	2,042.7	1.0	8.20	1	1	1
Maximum:	1.6	12.3	2,201.3	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2024 00:00	1.5	12.4	2,015.8	1.0	8.10	1	1	1
07/04/2024 01:00	1.4	12.4	1,983.5	1.0	7.90	1	1	1
07/04/2024 02:00	3.2	15.4	660.6	3.4	2.32	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 09:00	12.7	17.4	344.7	21.4	14.42	1	0	0
07/04/2024 10:00	6.8	14.9	1,019.5	6.7	25.50	1	0	0
07/04/2024 11:00	1.3	13.7	1,605.0	1.1	6.40	1	1	0
07/04/2024 12:00	1.3	13.7	1,595.7	1.1	6.40	1	1	0
07/04/2024 13:00	1.2	13.7	1,553.2	1.0	6.20	1	1	0
07/04/2024 14:00	1.0	13.8	1,453.0	0.8	4.40	1	1	0
07/04/2024 15:00	1.3	13.7	1,524.6	1.1	6.10	1	1	0
07/04/2024 16:00	1.3	13.5	1,694.9	1.0	6.80	1	1	0
07/04/2024 17:00	1.5	12.6	1,830.7	1.1	7.30	1	1	1
07/04/2024 18:00	1.6	11.5	2,157.8	1.0	8.60	1	1	1
07/04/2024 19:00	1.6	11.7	2,124.4	1.0	8.50	1	1	1
07/04/2024 20:00	1.5	11.9	2,071.3	1.0	8.30	1	1	1
07/04/2024 21:00	1.5	12.0	2,062.4	1.0	8.20	1	1	1
07/04/2024 22:00	1.5	12.1	2,043.0	1.0	8.20	1	1	1
07/04/2024 23:00	1.5	12.2	2,010.4	1.0	8.00	1	1	1
Average/Sum#:	2.4	13.3	1,652.8	2.6	151.64 #	18 #	15 #	9 #
Minimum:	1.0	11.5	344.7	0.8	2.32	0	0	0
Maximum:	12.7	17.4	2,157.8	21.4	25.50	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2024 00:00	1.2	13.6	1,719.5	1.0	6.90	1	1	0
07/05/2024 01:00	1.2	13.6	1,712.9	1.0	6.90	1	1	0
07/05/2024 02:00	1.3	13.6	1,705.4	1.1	6.80	1	1	0
07/05/2024 03:00	1.3	13.6	1,730.6	1.1	6.90	1	1	0
07/05/2024 04:00	1.3	13.7	1,619.1	1.1	6.50	1	1	0
07/05/2024 05:00	1.3	13.6	1,652.1	1.1	6.60	1	1	0
07/05/2024 06:00	1.3	13.5	1,747.9	1.0	7.00	1	1	0
07/05/2024 07:00	1.3	13.5	1,746.9	1.0	7.00	1	1	0
07/05/2024 08:00	1.3	13.5	1,751.1	1.0	7.00	1	1	0
07/05/2024 09:00	1.3	13.4	1,750.7	1.0	7.00	1	1	0
07/05/2024 10:00	1.3	13.4	1,736.4	1.0	6.90	1	1	0
07/05/2024 11:00	1.3	13.5	1,730.8	1.0	6.90	1	1	0
07/05/2024 12:00	1.2	13.6	1,557.8	1.0	6.20	1	1	0
07/05/2024 13:00	1.4	12.6	1,816.1	1.0	7.30	1	1	1
07/05/2024 14:00	1.6	11.3	2,142.7	1.0	8.60	1	1	1
07/05/2024 15:00	1.6	11.4	2,122.2	1.0	8.50	1	1	1
07/05/2024 16:00	1.6	11.4	2,121.9	1.0	8.50	1	1	1
07/05/2024 17:00	1.6	11.4	2,122.1	1.0	8.50	1	1	1
07/05/2024 18:00	1.6	11.5	2,117.9	1.0	8.50	1	1	1
07/05/2024 19:00	1.6	11.5	2,126.4	1.0	8.50	1	1	1
07/05/2024 20:00	1.6	11.6	2,122.8	1.0	8.50	1	1	1
07/05/2024 21:00	1.6	11.5	2,178.0	1.0	8.70	1	1	1
07/05/2024 22:00	1.6	11.5	2,133.1	1.0	8.50	1	1	1
07/05/2024 23:00	1.5	12.0	2,062.9	1.0	8.30	1	1	1
Average/Sum#:	1.4	12.7	1,884.5	1.0	181.00 #	24 #	24 #	11 #
Minimum:	1.2	11.3	1,557.8	1.0	6.20	1	1	0
Maximum:	1.6	13.7	2,178.0	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2024 00:00	1.5	12.2	2,034.0	1.0	8.10	1	1	1
07/06/2024 01:00	1.5	12.3	2,018.6	1.0	8.10	1	1	1
07/06/2024 02:00	1.5	12.3	2,018.6	1.0	8.10	1	1	1
07/06/2024 03:00	1.5	12.3	2,023.5	1.0	8.10	1	1	1
07/06/2024 04:00	1.5	12.4	2,017.8	1.0	8.10	1	1	1
07/06/2024 05:00	1.6	12.2	2,010.1	1.1	8.00	1	1	1
07/06/2024 06:00	2.3	15.4	620.4	2.5	1.40	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 09:00	0.1	18.5	172.5	0.2	0.04	1	0	0
07/06/2024 10:00	5.2	15.3	859.8	5.5	17.20	1	0	0
07/06/2024 11:00	1.2	13.7	1,588.0	1.0	6.40	1	1	0
07/06/2024 12:00	1.3	13.6	1,610.6	1.1	6.40	1	1	0
07/06/2024 13:00	1.2	13.6	1,589.9	1.0	6.40	1	1	0
07/06/2024 14:00	1.2	13.7	1,452.7	1.0	5.80	1	1	0
07/06/2024 15:00	1.2	13.8	1,443.1	1.0	5.80	1	1	0
07/06/2024 16:00	1.3	13.6	1,555.0	1.1	6.20	1	1	1
07/06/2024 17:00	1.6	11.7	2,101.9	1.0	8.40	1	1	1
07/06/2024 18:00	1.6	11.4	2,123.7	1.0	8.50	1	1	1
07/06/2024 19:00	1.6	11.4	2,114.9	1.0	8.50	1	1	1
07/06/2024 20:00	1.6	11.5	2,116.9	1.0	8.50	1	1	1
07/06/2024 21:00	1.6	11.6	2,114.7	1.0	8.50	1	1	1
07/06/2024 22:00	1.6	11.6	2,111.9	1.0	8.40	1	1	1
07/06/2024 23:00	1.6	11.4	2,159.0	1.0	8.60	1	1	1
Average/Sum#:	1.6	13.0	1,720.8	1.3	163.54 #	22 #	19 #	14 #
Minimum:	0.1	11.4	172.5	0.2	0.04	0	0	0
Maximum:	5.2	18.5	2,159.0	5.5	17.20	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2024 00:00	1.5	11.9	2,078.6	1.0	8.30	1	1	1
07/07/2024 01:00	1.5	12.1	2,025.5	1.0	8.10	1	1	1
07/07/2024 02:00	1.5	12.1	2,005.2	1.0	8.00	1	1	1
07/07/2024 03:00	3.1	15.5	610.6	3.4	1.83	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 15:00	15.8	17.8	271.0	30.1	9.63	1	0	0
07/07/2024 16:00	14.0	15.6	735.6	15.6	41.90	1	0	0
07/07/2024 17:00	1.0	13.7	1,377.6	0.8	4.10	1	1	0
07/07/2024 18:00	1.4	13.0	1,701.9	1.0	6.80	1	1	1
07/07/2024 19:00	1.6	11.3	2,119.6	1.0	8.50	1	1	1
07/07/2024 20:00	1.5	11.3	2,143.1	0.9	6.40	1	1	1
07/07/2024 21:00	1.6	11.7	2,063.9	1.0	8.30	1	1	1
07/07/2024 22:00	1.5	11.9	2,039.6	1.0	8.20	1	1	1
07/07/2024 23:00	1.6	11.7	2,103.3	1.0	8.40	1	1	1
Average/Sum#:	3.7	13.0	1,636.6	4.5	128.46 #	13 #	10 #	9 #
Minimum:	1.0	11.3	271.0	0.8	1.83	0	0	0
Maximum:	15.8	17.8	2,143.1	30.1	41.90	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2024 00:00	1.3	13.5	1,717.6	1.0	6.90	1	1	0
07/08/2024 01:00	1.3	13.6	1,702.2	1.1	6.80	1	1	0
07/08/2024 02:00	1.3	13.6	1,705.4	1.1	6.80	1	1	0
07/08/2024 03:00	1.3	13.6	1,706.4	1.1	6.80	1	1	0
07/08/2024 04:00	1.3	13.5	1,731.9	1.0	6.90	1	1	0
07/08/2024 05:00	1.2	13.5	1,749.9	1.0	7.00	1	1	0
07/08/2024 06:00	1.3	13.5	1,731.8	1.0	6.90	1	1	0
07/08/2024 07:00	1.3	13.5	1,719.5	1.0	6.90	1	1	0
07/08/2024 08:00	1.3	13.5	1,722.0	1.0	6.90	1	1	0
07/08/2024 09:00	1.3	13.5	1,716.9	1.0	6.90	1	1	0
07/08/2024 10:00	1.3	13.4	1,732.5	1.0	6.90	1	1	0
07/08/2024 11:00	1.3	13.4	1,727.4	1.0	6.90	1	1	0
07/08/2024 12:00	1.3	13.4	1,709.4	1.0	6.80	1	1	0
07/08/2024 13:00	1.3	13.6	1,598.9	1.1	6.40	1	1	0
07/08/2024 14:00	1.3	13.5	1,650.3	1.0	6.60	1	1	0
07/08/2024 15:00	1.3	13.5	1,681.4	1.0	6.70	1	1	0
07/08/2024 16:00	1.2	13.5	1,591.2	1.0	6.40	1	1	1
07/08/2024 17:00	1.6	11.5	2,114.4	1.0	8.50	1	1	1
07/08/2024 18:00	1.6	11.3	2,147.5	1.0	8.60	1	1	1
07/08/2024 19:00	1.6	11.3	2,158.8	1.0	8.60	1	1	1
07/08/2024 20:00	1.6	11.4	2,166.7	1.0	8.70	1	1	1
07/08/2024 21:00	1.6	11.4	2,175.4	1.0	8.70	1	1	1
07/08/2024 22:00	1.6	11.5	2,170.3	1.0	8.70	1	1	1
07/08/2024 23:00	1.6	11.4	2,194.7	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.9	1,834.3	1.0	176.10 #	24 #	24 #	8 #
Minimum:	1.2	11.3	1,591.2	1.0	6.40	1	1	0
Maximum:	1.6	13.6	2,194.7	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2024 00:00	1.6	11.4	2,201.1	1.0	8.80	1	1	1
07/09/2024 01:00	1.6	11.4	2,209.0	1.0	8.80	1	1	1
07/09/2024 02:00	1.6	11.5	2,212.1	1.0	8.80	1	1	1
07/09/2024 03:00	1.6	11.5	2,210.7	1.0	8.80	1	1	1
07/09/2024 04:00	1.6	11.4	2,223.5	1.0	8.90	1	1	1
07/09/2024 05:00	1.6	11.5	2,209.9	1.0	8.80	1	1	1
07/09/2024 06:00	1.5	12.2	2,046.0	1.0	8.20	1	1	1
07/09/2024 07:00	1.5	12.3	2,016.4	1.0	8.10	1	1	1
07/09/2024 08:00	1.5	11.7	2,152.5	1.0	8.60	1	1	1
07/09/2024 09:00	0.0	0.0	2,124.2	0.0	0.00	1	1	1
07/09/2024 10:00	0.0	0.0	2,136.7	0.0	0.00	1	1	1
07/09/2024 11:00	0.0	0.0	2,175.7	0.0	0.00	1	1	1
07/09/2024 12:00	2.0	11.4	2,173.4	1.2	10.90	1	1	1
07/09/2024 13:00	1.6	11.4	2,169.4	1.0	8.70	1	1	1
07/09/2024 14:00	1.6	11.4	2,159.9	1.0	8.60	1	1	1
07/09/2024 15:00	1.6	11.4	2,161.0	1.0	8.60	1	1	1
07/09/2024 16:00	1.6	11.4	2,164.4	1.0	8.70	1	1	1
07/09/2024 17:00	1.6	11.4	2,160.6	1.0	8.60	1	1	1
07/09/2024 18:00	1.6	11.5	2,139.0	1.0	8.60	1	1	1
07/09/2024 19:00	1.6	11.3	2,162.4	1.0	8.60	1	1	1
07/09/2024 20:00	1.6	11.3	2,172.2	1.0	8.70	1	1	1
07/09/2024 21:00	1.6	11.4	2,179.5	1.0	8.70	1	1	1
07/09/2024 22:00	1.6	11.5	2,167.2	1.0	8.70	1	1	1
07/09/2024 23:00	1.5	11.9	2,082.2	1.0	8.30	1	1	1
Average/Sum#:	1.6	11.5	2,158.7	1.0	183.50 #	24 #	24 #	24 #
Minimum:	1.5	11.3	2,016.4	1.0	8.10	1	1	1
Maximum:	2.0	12.3	2,223.5	1.2	10.90	1	1	1
%SI	12.50	12.50	0.00	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2024 00:00	1.5	12.1	2,071.6	1.0	8.30	1	1	1
07/10/2024 01:00	1.6	11.4	2,209.7	1.0	8.80	1	1	1
07/10/2024 02:00	1.6	11.4	2,215.1	1.0	8.90	1	1	1
07/10/2024 03:00	1.6	11.4	2,214.6	1.0	8.90	1	1	1
07/10/2024 04:00	1.6	11.4	2,214.7	1.0	8.90	1	1	1
07/10/2024 05:00	1.6	11.6	2,182.7	1.0	8.70	1	1	1
07/10/2024 06:00	1.5	12.1	2,056.9	1.0	8.20	1	1	1
07/10/2024 07:00	1.5	12.2	2,008.5	1.0	8.00	1	1	1
07/10/2024 08:00	1.5	12.2	2,015.7	1.0	8.10	1	1	1
07/10/2024 09:00	1.5	12.1	2,027.7	1.0	8.10	1	1	1
07/10/2024 10:00	1.5	11.9	2,045.3	1.0	8.20	1	1	1
07/10/2024 11:00	1.6	11.7	2,078.9	1.0	8.30	1	1	1
07/10/2024 12:00	1.6	11.6	2,098.7	1.0	8.40	1	1	1
07/10/2024 13:00	1.6	11.4	2,150.6	1.0	8.60	1	1	1
07/10/2024 14:00	1.6	11.4	2,156.0	1.0	8.60	1	1	1
07/10/2024 15:00	1.6	11.5	2,135.6	1.0	8.50	1	1	1
07/10/2024 16:00	1.6	11.5	2,120.3	1.0	8.50	1	1	1
07/10/2024 17:00	1.6	11.5	2,110.8	1.0	8.40	1	1	1
07/10/2024 18:00	1.6	11.3	2,143.6	1.0	8.60	1	1	1
07/10/2024 19:00	1.6	11.3	2,152.8	1.0	8.60	1	1	1
07/10/2024 20:00	1.6	11.3	2,157.7	1.0	8.60	1	1	1
07/10/2024 21:00	1.6	11.3	2,166.8	1.0	8.70	1	1	1
07/10/2024 22:00	1.6	11.4	2,167.7	1.0	8.70	1	1	1
07/10/2024 23:00	1.6	11.4	2,170.8	1.0	8.70	1	1	1
Average/Sum#:	1.6	11.6	2,128.0	1.0	204.30 #	24 #	24 #	24 #
Minimum:	1.5	11.3	2,008.5	1.0	8.00	1	1	1
Maximum:	1.6	12.2	2,215.1	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2024 00:00	1.6	11.5	2,148.4	1.0	8.60	1	1	1
07/11/2024 01:00	1.6	11.6	2,132.0	1.0	8.50	1	1	1
07/11/2024 02:00	1.6	11.7	2,104.5	1.0	8.40	1	1	1
07/11/2024 03:00	1.5	12.0	2,063.2	1.0	8.30	1	1	1
07/11/2024 04:00	1.6	11.4	2,186.3	1.0	8.70	1	1	1
07/11/2024 05:00	1.5	12.2	2,018.9	1.0	8.10	1	1	1
07/11/2024 06:00	1.3	13.5	1,721.5	1.0	6.90	1	1	0
07/11/2024 07:00	1.3	13.5	1,712.4	1.0	6.80	1	1	0
07/11/2024 08:00	1.2	13.6	1,549.8	1.0	6.20	1	1	0
07/11/2024 09:00	1.3	13.7	1,508.7	1.1	6.00	1	1	0
07/11/2024 10:00	1.3	13.6	1,640.7	1.1	6.60	1	1	0
07/11/2024 11:00	1.2	13.7	1,471.1	1.0	5.90	1	1	0
07/11/2024 12:00	1.3	13.6	1,600.7	1.1	6.40	1	1	0
07/11/2024 13:00	1.2	13.6	1,595.5	1.0	6.40	1	1	0
07/11/2024 14:00	1.2	13.7	1,570.1	1.0	6.30	1	1	0
07/11/2024 15:00	1.2	13.8	1,331.3	1.0	5.30	1	1	0
07/11/2024 16:00	1.3	13.8	1,334.0	1.1	5.30	1	1	0
07/11/2024 17:00	1.4	12.7	1,752.1	1.0	7.00	1	1	1
07/11/2024 18:00	1.6	11.4	2,125.2	1.0	8.50	1	1	1
07/11/2024 19:00	1.6	11.3	2,128.4	1.0	8.50	1	1	1
07/11/2024 20:00	1.6	11.6	2,088.7	1.0	8.40	1	1	1
07/11/2024 21:00	1.5	11.8	2,059.2	1.0	8.20	1	1	1
07/11/2024 22:00	1.6	11.4	2,160.1	1.0	8.60	1	1	1
07/11/2024 23:00	1.5	11.8	2,099.4	1.0	8.40	1	1	1
Average/Sum#:	1.4	12.6	1,837.6	1.0	176.30 #	24 #	24 #	13 #
Minimum:	1.2	11.3	1,331.3	1.0	5.30	1	1	0
Maximum:	1.6	13.8	2,186.3	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2024 00:00	1.5	11.8	2,092.0	1.0	8.40	1	1	1
07/12/2024 01:00	1.6	11.8	2,098.3	1.0	8.40	1	1	1
07/12/2024 02:00	1.5	12.0	2,067.1	1.0	8.30	1	1	1
07/12/2024 03:00	1.6	11.5	2,184.5	1.0	8.70	1	1	1
07/12/2024 04:00	1.5	11.8	2,128.6	1.0	8.50	1	1	1
07/12/2024 05:00	1.3	11.9	2,109.3	0.9	6.30	1	1	1
07/12/2024 06:00	1.2	13.5	1,739.2	1.0	7.00	1	1	0
07/12/2024 07:00	1.2	13.6	1,545.3	1.0	6.20	1	1	0
07/12/2024 08:00	1.3	13.7	1,477.4	1.1	5.90	1	1	0
07/12/2024 09:00	1.2	13.7	1,483.1	1.0	5.90	1	1	0
07/12/2024 10:00	1.1	13.7	1,509.1	0.9	4.50	1	1	0
07/12/2024 11:00	1.2	13.8	1,434.6	1.0	5.70	1	1	0
07/12/2024 12:00	1.3	13.7	1,477.4	1.1	5.90	1	1	0
07/12/2024 13:00	1.2	13.8	1,341.1	1.0	5.40	1	1	0
07/12/2024 14:00	1.2	13.7	1,355.7	1.0	5.40	1	1	0
07/12/2024 15:00	1.2	13.8	1,357.1	1.0	5.40	1	1	0
07/12/2024 16:00	1.2	13.8	1,342.4	1.0	5.40	1	1	0
07/12/2024 17:00	1.2	13.8	1,343.3	1.0	5.40	1	1	0
07/12/2024 18:00	1.2	13.7	1,332.5	1.0	5.30	1	1	0
07/12/2024 19:00	1.3	13.7	1,328.8	1.1	5.30	1	1	0
07/12/2024 20:00	1.3	13.7	1,329.0	1.1	5.30	1	1	0
07/12/2024 21:00	1.3	13.5	1,639.5	1.0	6.60	1	1	0
07/12/2024 22:00	1.3	13.4	1,725.0	1.0	6.90	1	1	0
07/12/2024 23:00	1.3	13.4	1,725.0	1.0	6.90	1	1	0
Average/Sum#:	1.3	13.2	1,631.9	1.0	153.00 #	24 #	24 #	6 #
Minimum:	1.1	11.5	1,328.8	0.9	4.50	1	1	0
Maximum:	1.6	13.8	2,184.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2024 00:00	1.3	13.4	1,725.6	1.0	6.90	1	1	0
07/13/2024 01:00	1.3	13.4	1,726.2	1.0	6.90	1	1	0
07/13/2024 02:00	1.3	13.4	1,737.2	1.0	6.90	1	1	0
07/13/2024 03:00	1.3	13.4	1,744.1	1.0	7.00	1	1	0
07/13/2024 04:00	1.3	13.5	1,721.5	1.0	6.90	1	1	0
07/13/2024 05:00	1.4	13.4	1,744.4	1.1	7.00	1	1	0
07/13/2024 06:00	1.3	13.5	1,708.0	1.0	6.80	1	1	0
07/13/2024 07:00	1.3	13.5	1,725.5	1.0	6.90	1	1	0
07/13/2024 08:00	1.3	13.5	1,711.4	1.0	6.80	1	1	0
07/13/2024 09:00	1.2	13.6	1,563.0	1.0	6.30	1	1	0
07/13/2024 10:00	1.2	13.7	1,561.4	1.0	6.20	1	1	0
07/13/2024 11:00	1.3	13.6	1,633.6	1.1	6.50	1	1	0
07/13/2024 12:00	1.3	13.6	1,651.9	1.1	6.60	1	1	0
07/13/2024 13:00	1.2	13.7	1,379.5	1.0	5.50	1	1	0
07/13/2024 14:00	1.3	13.7	1,324.3	1.1	5.30	1	1	0
07/13/2024 15:00	1.3	13.7	1,329.3	1.1	5.30	1	1	0
07/13/2024 16:00	1.2	13.7	1,324.6	1.0	5.30	1	1	0
07/13/2024 17:00	1.3	13.7	1,334.7	1.1	5.30	1	1	0
07/13/2024 18:00	1.3	13.7	1,329.5	1.1	5.30	1	1	0
07/13/2024 19:00	1.3	13.7	1,467.5	1.1	5.90	1	1	0
07/13/2024 20:00	1.3	13.4	1,720.8	1.0	6.90	1	1	0
07/13/2024 21:00	1.3	13.5	1,722.0	1.0	6.90	1	1	0
07/13/2024 22:00	1.3	13.5	1,734.9	1.0	6.90	1	1	0
07/13/2024 23:00	1.3	13.5	1,740.4	1.0	7.00	1	1	0
Average/Sum#:	1.3	13.6	1,598.4	1.0	153.30 #	24 #	24 #	0 #
Minimum:	1.2	13.4	1,324.3	1.0	5.30	1	1	0
Maximum:	1.4	13.7	1,744.4	1.1	7.00	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2024 00:00	1.3	13.5	1,750.7	1.0	7.00	1	1	0
07/14/2024 01:00	1.3	13.6	1,652.7	1.1	6.60	1	1	0
07/14/2024 02:00	2.0	14.6	1,043.8	1.9	3.43	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 10:00	18.3	17.6	326.4	32.7	17.78	1	0	0
07/14/2024 11:00	12.6	15.4	822.1	13.5	41.10	1	0	0
07/14/2024 12:00	1.1	13.6	1,552.1	0.9	4.70	1	1	0
07/14/2024 13:00	1.3	13.6	1,568.5	1.1	6.30	1	1	0
07/14/2024 14:00	1.3	13.6	1,695.5	1.1	6.80	1	1	0
07/14/2024 15:00	1.2	13.6	1,539.7	1.0	6.20	1	1	0
07/14/2024 16:00	1.3	13.6	1,688.4	1.1	6.80	1	1	0
07/14/2024 17:00	1.3	13.5	1,709.3	1.0	6.80	1	1	1
07/14/2024 18:00	1.6	11.6	2,130.9	1.0	8.50	1	1	1
07/14/2024 19:00	1.6	11.3	2,176.2	1.0	8.70	1	1	1
07/14/2024 20:00	1.6	11.4	2,170.4	1.0	8.70	1	1	1
07/14/2024 21:00	1.6	11.4	2,173.9	1.0	8.70	1	1	1
07/14/2024 22:00	1.5	11.8	2,081.9	1.0	8.30	1	1	1
07/14/2024 23:00	1.5	12.1	2,007.6	1.0	8.00	1	1	1
Average/Sum#:	3.1	13.3	1,652.4	3.7	164.41 #	17 #	14 #	7 #
Minimum:	1.1	11.3	326.4	0.9	3.43	0	0	0
Maximum:	18.3	17.6	2,176.2	32.7	41.10	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2024 00:00	1.2	13.5	1,719.3	1.0	6.90	1	1	0
07/15/2024 01:00	1.3	13.5	1,728.6	1.0	6.90	1	1	0
07/15/2024 02:00	1.3	13.6	1,619.4	1.1	6.50	1	1	0
07/15/2024 03:00	1.3	13.6	1,712.9	1.1	6.90	1	1	0
07/15/2024 04:00	1.3	13.5	1,750.5	1.0	7.00	1	1	0
07/15/2024 05:00	1.2	13.6	1,716.8	1.0	6.90	1	1	0
07/15/2024 06:00	1.3	13.6	1,699.3	1.1	6.80	1	1	0
07/15/2024 07:00	1.3	13.6	1,711.6	1.1	6.80	1	1	0
07/15/2024 08:00	1.3	13.6	1,548.1	1.1	6.20	1	1	0
07/15/2024 09:00	1.3	13.7	1,480.1	1.1	5.90	1	1	0
07/15/2024 10:00	1.3	13.7	1,621.5	1.1	6.50	1	1	0
07/15/2024 11:00	1.3	13.5	1,706.0	1.0	6.80	1	1	0
07/15/2024 12:00	1.2	13.7	1,661.6	1.0	6.60	1	1	0
07/15/2024 13:00	1.2	13.6	1,669.1	1.0	6.70	1	1	0
07/15/2024 14:00	1.3	13.6	1,664.0	1.1	6.70	1	1	0
07/15/2024 15:00	1.3	13.7	1,590.6	1.1	6.40	1	1	0
07/15/2024 16:00	1.3	13.6	1,573.9	1.1	6.30	1	1	0
07/15/2024 17:00	1.4	12.9	1,738.3	1.0	7.00	1	1	1
07/15/2024 18:00	1.6	11.5	2,141.4	1.0	8.60	1	1	1
07/15/2024 19:00	1.6	11.4	2,179.4	1.0	8.70	1	1	1
07/15/2024 20:00	1.6	11.5	2,175.5	1.0	8.70	1	1	1
07/15/2024 21:00	1.6	11.7	2,137.3	1.0	8.50	1	1	1
07/15/2024 22:00	1.4	12.5	2,008.1	1.0	8.00	1	1	1
07/15/2024 23:00	1.5	12.4	1,992.6	1.0	8.00	1	1	1
Average/Sum#:	1.4	13.1	1,772.7	1.0	170.30 #	24 #	24 #	7 #
Minimum:	1.2	11.4	1,480.1	1.0	5.90	1	1	0
Maximum:	1.6	13.7	2,179.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2024 00:00	1.2	13.5	1,728.4	1.0	6.90	1	1	1
07/16/2024 01:00	1.3	13.6	1,737.0	1.1	6.90	1	1	0
07/16/2024 02:00	1.3	13.6	1,744.1	1.1	7.00	1	1	0
07/16/2024 03:00	1.3	13.6	1,748.5	1.1	7.00	1	1	0
07/16/2024 04:00	1.3	13.6	1,745.4	1.1	7.00	1	1	0
07/16/2024 05:00	1.2	13.6	1,708.7	1.0	6.80	1	1	0
07/16/2024 06:00	1.3	13.6	1,689.8	1.1	6.80	1	1	0
07/16/2024 07:00	1.3	13.6	1,721.6	1.1	6.90	1	1	0
07/16/2024 08:00	1.3	13.6	1,600.4	1.1	6.40	1	1	0
07/16/2024 09:00	1.3	13.6	1,619.4	1.1	6.50	1	1	0
07/16/2024 10:00	1.3	13.6	1,659.0	1.1	6.60	1	1	0
07/16/2024 11:00	1.3	13.6	1,709.7	1.1	6.80	1	1	0
07/16/2024 12:00	1.3	13.6	1,643.1	1.1	6.60	1	1	0
07/16/2024 13:00	1.1	13.6	1,538.8	0.9	4.60	1	1	0
07/16/2024 14:00	1.2	13.8	1,325.2	1.0	5.30	1	1	0
07/16/2024 15:00	1.2	13.7	1,500.1	1.0	6.00	1	1	1
07/16/2024 16:00	1.5	11.9	2,081.4	1.0	8.30	1	1	1
07/16/2024 17:00	1.6	11.6	2,154.2	1.0	8.60	1	1	1
07/16/2024 18:00	1.6	11.5	2,202.4	1.0	8.80	1	1	1
07/16/2024 19:00	1.6	11.5	2,205.6	1.0	8.80	1	1	1
07/16/2024 20:00	1.6	11.4	2,212.3	1.0	8.80	1	1	1
07/16/2024 21:00	1.6	11.4	2,221.4	1.0	8.90	1	1	1
07/16/2024 22:00	1.6	11.6	2,207.6	1.0	8.80	1	1	1
07/16/2024 23:00	1.5	12.1	2,083.5	1.0	8.30	1	1	1
Average/Sum#:	1.4	13.0	1,824.5	1.0	173.40 #	24 #	24 #	10 #
Minimum:	1.1	11.4	1,325.2	0.9	4.60	1	1	0
Maximum:	1.6	13.8	2,221.4	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2024 00:00	1.5	12.4	2,046.5	1.0	8.20	1	1	1
07/17/2024 01:00	1.3	13.4	1,702.4	1.0	6.80	1	1	1
07/17/2024 02:00	1.3	13.7	1,718.8	1.1	6.90	1	1	0
07/17/2024 03:00	1.3	13.7	1,744.2	1.1	7.00	1	1	0
07/17/2024 04:00	1.3	13.7	1,739.9	1.1	7.00	1	1	0
07/17/2024 05:00	1.3	13.7	1,660.3	1.1	6.60	1	1	0
07/17/2024 06:00	1.3	13.6	1,707.4	1.1	6.80	1	1	0
07/17/2024 07:00	1.3	13.6	1,738.5	1.1	7.00	1	1	0
07/17/2024 08:00	1.3	13.6	1,705.4	1.1	6.80	1	1	0
07/17/2024 09:00	1.3	13.6	1,623.0	1.1	6.50	1	1	0
07/17/2024 10:00	1.2	13.7	1,429.3	1.0	5.70	1	1	0
07/17/2024 11:00	1.3	13.7	1,432.0	1.1	5.70	1	1	0
07/17/2024 12:00	1.2	13.7	1,542.8	1.0	6.20	1	1	0
07/17/2024 13:00	1.2	13.8	1,479.4	1.0	5.90	1	1	0
07/17/2024 14:00	1.2	13.7	1,578.9	1.0	6.30	1	1	1
07/17/2024 15:00	1.5	12.0	2,098.2	1.0	8.40	1	1	1
07/17/2024 16:00	1.5	12.1	2,074.2	1.0	8.30	1	1	1
07/17/2024 17:00	1.6	11.9	2,120.2	1.0	8.50	1	1	1
07/17/2024 18:00	1.6	11.5	2,193.1	1.0	8.80	1	1	1
07/17/2024 19:00	1.6	11.5	2,200.0	1.0	8.80	1	1	1
07/17/2024 20:00	1.6	11.5	2,200.7	1.0	8.80	1	1	1
07/17/2024 21:00	1.6	11.5	2,200.2	1.0	8.80	1	1	1
07/17/2024 22:00	1.6	11.5	2,200.5	1.0	8.80	1	1	1
07/17/2024 23:00	1.6	11.6	2,193.3	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.9	1,847.1	1.0	177.40 #	24 #	24 #	12 #
Minimum:	1.2	11.5	1,429.3	1.0	5.70	1	1	0
Maximum:	1.6	13.8	2,200.7	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2024 00:00	1.5	12.2	2,053.3	1.0	8.20	1	1	1
07/18/2024 01:00	1.5	12.2	2,071.4	1.0	8.30	1	1	1
07/18/2024 02:00	1.6	11.6	2,202.4	1.0	8.80	1	1	1
07/18/2024 03:00	1.6	11.7	2,190.2	1.0	8.80	1	1	1
07/18/2024 04:00	1.6	11.6	2,210.8	1.0	8.80	1	1	1
07/18/2024 05:00	1.5	12.0	2,153.0	1.0	8.60	1	1	1
07/18/2024 06:00	1.5	12.2	2,058.3	1.0	8.20	1	1	1
07/18/2024 07:00	1.4	12.4	2,004.0	1.0	8.00	1	1	1
07/18/2024 08:00	1.5	12.2	2,051.2	1.0	8.20	1	1	1
07/18/2024 09:00	1.5	11.8	2,136.8	1.0	8.50	1	1	1
07/18/2024 10:00	1.6	11.7	2,139.9	1.0	8.60	1	1	1
07/18/2024 11:00	1.6	11.7	2,147.8	1.0	8.60	1	1	1
07/18/2024 12:00	1.5	11.8	2,110.0	1.0	8.40	1	1	1
07/18/2024 13:00	1.6	11.5	2,171.4	1.0	8.70	1	1	1
07/18/2024 14:00	1.6	11.5	2,166.6	1.0	8.70	1	1	1
07/18/2024 15:00	1.6	11.5	2,169.0	1.0	8.70	1	1	1
07/18/2024 16:00	1.6	11.5	2,162.4	1.0	8.60	1	1	1
07/18/2024 17:00	1.6	11.5	2,159.3	1.0	8.60	1	1	1
07/18/2024 18:00	1.6	11.5	2,161.1	1.0	8.60	1	1	1
07/18/2024 19:00	1.6	11.4	2,166.4	1.0	8.70	1	1	1
07/18/2024 20:00	1.6	11.5	2,174.2	1.0	8.70	1	1	1
07/18/2024 21:00	1.6	11.5	2,178.2	1.0	8.70	1	1	1
07/18/2024 22:00	1.6	11.5	2,192.1	1.0	8.80	1	1	1
07/18/2024 23:00	1.6	11.7	2,149.0	1.0	8.60	1	1	1
Average/Sum#:	1.6	11.7	2,140.8	1.0	205.40 #	24 #	24 #	24 #
Minimum:	1.4	11.4	2,004.0	1.0	8.00	1	1	1
Maximum:	1.6	12.4	2,210.8	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2024 00:00	1.5	11.9	2,123.2	1.0	8.50	1	1	1
07/19/2024 01:00	1.5	12.0	2,102.5	1.0	8.40	1	1	1
07/19/2024 02:00	1.5	11.9	2,124.3	1.0	8.50	1	1	1
07/19/2024 03:00	1.5	12.3	2,029.2	1.0	8.10	1	1	1
07/19/2024 04:00	1.6	11.6	2,203.1	1.0	8.80	1	1	1
07/19/2024 05:00	1.5	12.2	2,105.2	1.0	8.40	1	1	1
07/19/2024 06:00	1.2	13.6	1,738.3	1.0	7.00	1	1	1
07/19/2024 07:00	1.3	13.5	1,744.8	1.0	7.00	1	1	0
07/19/2024 08:00	1.3	13.6	1,746.1	1.1	7.00	1	1	0
07/19/2024 09:00	1.3	13.5	1,747.1	1.0	7.00	1	1	0
07/19/2024 10:00	1.3	13.5	1,746.7	1.0	7.00	1	1	0
07/19/2024 11:00	1.3	13.4	1,745.0	1.0	7.00	1	1	0
07/19/2024 12:00	1.3	13.4	1,733.6	1.0	6.90	1	1	1
07/19/2024 13:00	1.6	11.6	2,137.4	1.0	8.50	1	1	1
07/19/2024 14:00	1.6	11.5	2,156.4	1.0	8.60	1	1	1
07/19/2024 15:00	1.6	11.5	2,160.5	1.0	8.60	1	1	1
07/19/2024 16:00	1.6	11.5	2,162.0	1.0	8.60	1	1	1
07/19/2024 17:00	1.6	11.4	2,157.7	1.0	8.60	1	1	1
07/19/2024 18:00	1.6	11.4	2,160.6	1.0	8.60	1	1	1
07/19/2024 19:00	1.6	11.4	2,160.1	1.0	8.60	1	1	1
07/19/2024 20:00	1.6	11.5	2,168.1	1.0	8.70	1	1	1
07/19/2024 21:00	1.6	11.6	2,168.2	1.0	8.70	1	1	1
07/19/2024 22:00	1.6	11.5	2,181.6	1.0	8.70	1	1	1
07/19/2024 23:00	1.6	11.5	2,192.9	1.0	8.80	1	1	1
Average/Sum#:	1.5	12.2	2,028.9	1.0	194.60 #	24 #	24 #	19 #
Minimum:	1.2	11.4	1,733.6	1.0	6.90	1	1	0
Maximum:	1.6	13.6	2,203.1	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2024 00:00	1.6	11.5	2,188.1	1.0	8.80	1	1	1
07/20/2024 01:00	1.6	11.5	2,200.5	1.0	8.80	1	1	1
07/20/2024 02:00	1.6	11.5	2,200.9	1.0	8.80	1	1	1
07/20/2024 03:00	1.6	11.5	2,203.6	1.0	8.80	1	1	1
07/20/2024 04:00	1.5	11.5	2,206.0	0.9	6.60	1	1	1
07/20/2024 05:00	1.4	12.0	2,135.5	0.9	6.40	1	1	1
07/20/2024 06:00	1.2	13.6	1,705.8	1.0	6.80	1	1	1
07/20/2024 07:00	1.3	13.6	1,730.8	1.1	6.90	1	1	0
07/20/2024 08:00	1.3	13.7	1,570.4	1.1	6.30	1	1	0
07/20/2024 09:00	1.3	13.6	1,604.3	1.1	6.40	1	1	0
07/20/2024 10:00	1.3	13.5	1,707.7	1.0	6.80	1	1	0
07/20/2024 11:00	1.2	13.5	1,621.4	1.0	6.50	1	1	0
07/20/2024 12:00	1.2	13.8	1,340.6	1.0	5.40	1	1	0
07/20/2024 13:00	1.3	13.6	1,639.5	1.1	6.60	1	1	1
07/20/2024 14:00	1.6	11.5	2,133.8	1.0	8.50	1	1	1
07/20/2024 15:00	1.6	11.4	2,153.1	1.0	8.60	1	1	1
07/20/2024 16:00	1.6	11.4	2,151.3	1.0	8.60	1	1	1
07/20/2024 17:00	1.6	11.4	2,146.4	1.0	8.60	1	1	1
07/20/2024 18:00	1.6	11.4	2,154.5	1.0	8.60	1	1	1
07/20/2024 19:00	1.6	11.4	2,156.5	1.0	8.60	1	1	1
07/20/2024 20:00	1.6	11.4	2,156.9	1.0	8.60	1	1	1
07/20/2024 21:00	1.6	11.5	2,159.1	1.0	8.60	1	1	1
07/20/2024 22:00	1.6	11.4	2,175.6	1.0	8.70	1	1	1
07/20/2024 23:00	1.6	11.4	2,185.8	1.0	8.70	1	1	1
Average/Sum#:	1.5	12.2	1,984.5	1.0	186.00 #	24 #	24 #	18 #
Minimum:	1.2	11.4	1,340.6	0.9	5.40	1	1	0
Maximum:	1.6	13.8	2,206.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2024 00:00	1.6	11.4	2,201.5	1.0	8.80	1	1	1
07/21/2024 01:00	1.6	11.4	2,207.8	1.0	8.80	1	1	1
07/21/2024 02:00	1.6	11.5	2,212.6	1.0	8.90	1	1	1
07/21/2024 03:00	1.6	11.5	2,211.3	1.0	8.80	1	1	1
07/21/2024 04:00	1.6	11.5	2,212.5	1.0	8.90	1	1	1
07/21/2024 05:00	2.5	14.2	1,548.2	2.2	9.30	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 10:00	1.4	17.4	350.1	2.4	1.66	1	0	0
07/21/2024 11:00	7.3	14.7	1,061.7	6.9	27.60	1	0	0
07/21/2024 12:00	1.3	13.7	1,429.7	1.1	5.70	1	1	0
07/21/2024 13:00	1.2	13.7	1,396.8	1.0	5.60	1	1	0
07/21/2024 14:00	1.3	13.6	1,613.0	1.1	6.50	1	1	0
07/21/2024 15:00	1.3	13.4	1,725.3	1.0	6.90	1	1	0
07/21/2024 16:00	1.5	12.3	1,906.0	1.0	7.60	1	1	1
07/21/2024 17:00	1.7	11.4	2,161.5	1.1	8.60	1	1	1
07/21/2024 18:00	1.7	11.3	2,164.6	1.0	8.70	1	1	1
07/21/2024 19:00	1.7	11.4	2,164.6	1.1	8.70	1	1	1
07/21/2024 20:00	1.6	11.4	2,167.8	1.0	8.70	1	1	1
07/21/2024 21:00	1.7	11.4	2,172.2	1.1	8.70	1	1	1
07/21/2024 22:00	1.7	11.4	2,172.3	1.1	8.70	1	1	1
07/21/2024 23:00	1.7	11.4	2,183.0	1.1	8.70	1	1	1
Average/Sum#:	1.9	12.5	1,863.1	1.5	175.86 #	20 #	17 #	14 #
Minimum:	1.2	11.3	350.1	1.0	1.66	0	0	0
Maximum:	7.3	17.4	2,212.6	6.9	27.60	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2024 00:00	1.7	11.4	2,185.0	1.1	8.70	1	1	1
07/22/2024 01:00	1.7	11.4	2,185.8	1.1	8.70	1	1	1
07/22/2024 02:00	1.6	11.8	2,100.0	1.0	8.40	1	1	1
07/22/2024 03:00	1.4	12.8	1,846.4	1.0	7.40	1	1	1
07/22/2024 04:00	1.2	13.6	1,448.5	1.0	5.80	1	1	0
07/22/2024 05:00	1.3	13.4	1,632.5	1.0	6.50	1	1	0
07/22/2024 06:00	1.3	13.6	1,714.3	1.1	6.90	1	1	0
07/22/2024 07:00	1.3	13.6	1,703.2	1.1	6.80	1	1	0
07/22/2024 08:00	1.3	13.6	1,703.1	1.1	6.80	1	1	0
07/22/2024 09:00	1.3	13.6	1,689.1	1.1	6.80	1	1	0
07/22/2024 10:00	1.3	13.6	1,674.3	1.1	6.70	1	1	0
07/22/2024 11:00	1.3	13.6	1,658.5	1.1	6.60	1	1	0
07/22/2024 12:00	1.5	12.6	1,826.2	1.1	7.30	1	1	1
07/22/2024 13:00	1.6	11.4	2,149.3	1.0	8.60	1	1	1
07/22/2024 14:00	1.6	11.4	2,150.2	1.0	8.60	1	1	1
07/22/2024 15:00	1.6	11.3	2,146.7	1.0	8.60	1	1	1
07/22/2024 16:00	1.6	11.4	2,149.8	1.0	8.60	1	1	1
07/22/2024 17:00	1.6	11.4	2,152.3	1.0	8.60	1	1	1
07/22/2024 18:00	1.6	11.4	2,147.4	1.0	8.60	1	1	1
07/22/2024 19:00	1.6	11.4	2,154.0	1.0	8.60	1	1	1
07/22/2024 20:00	1.6	11.4	2,153.5	1.0	8.60	1	1	1
07/22/2024 21:00	1.6	11.4	2,148.6	1.0	8.60	1	1	1
07/22/2024 22:00	1.6	11.4	2,165.2	1.0	8.70	1	1	1
07/22/2024 23:00	1.6	11.4	2,171.5	1.0	8.70	1	1	1
Average/Sum#:	1.5	12.2	1,960.6	1.0	188.20 #	24 #	24 #	16 #
Minimum:	1.2	11.3	1,448.5	1.0	5.80	1	1	0
Maximum:	1.7	13.6	2,185.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2024 00:00	1.6	11.4	2,174.4	1.0	8.70	1	1	1
07/23/2024 01:00	1.6	11.4	2,178.6	1.0	8.70	1	1	1
07/23/2024 02:00	1.6	11.4	2,186.7	1.0	8.70	1	1	1
07/23/2024 03:00	1.6	11.4	2,187.0	1.0	8.70	1	1	1
07/23/2024 04:00	1.6	11.4	2,194.6	1.0	8.80	1	1	1
07/23/2024 05:00	1.4	11.4	2,200.2	0.9	6.60	1	1	1
07/23/2024 06:00	1.5	11.9	2,093.8	1.0	8.40	1	1	1
07/23/2024 07:00	1.6	11.6	2,153.9	1.0	8.60	1	1	1
07/23/2024 08:00	1.5	12.0	2,053.7	1.0	8.20	1	1	1
07/23/2024 09:00	1.5	11.7	2,108.2	1.0	8.40	1	1	1
07/23/2024 10:00	1.6	11.5	2,141.1	1.0	8.60	1	1	1
07/23/2024 11:00	1.6	11.4	2,157.1	1.0	8.60	1	1	1
07/23/2024 12:00	1.6	11.5	2,136.5	1.0	8.50	1	1	1
07/23/2024 13:00	1.6	11.6	2,112.7	1.0	8.50	1	1	1
07/23/2024 14:00	1.6	11.5	2,142.5	1.0	8.60	1	1	1
07/23/2024 15:00	1.6	11.4	2,146.2	1.0	8.60	1	1	1
07/23/2024 16:00	1.6	11.4	2,142.8	1.0	8.60	1	1	1
07/23/2024 17:00	1.6	11.4	2,141.0	1.0	8.60	1	1	1
07/23/2024 18:00	1.6	11.4	2,146.3	1.0	8.60	1	1	1
07/23/2024 19:00	1.6	11.4	2,158.7	1.0	8.60	1	1	1
07/23/2024 20:00	1.6	11.4	2,158.8	1.0	8.60	1	1	1
07/23/2024 21:00	1.6	11.5	2,166.0	1.0	8.70	1	1	1
07/23/2024 22:00	1.6	11.5	2,179.9	1.0	8.70	1	1	1
07/23/2024 23:00	1.6	11.5	2,190.0	1.0	8.80	1	1	1
Average/Sum#:	1.6	11.5	2,152.1	1.0	204.40 #	24 #	24 #	24 #
Minimum:	1.4	11.4	2,053.7	0.9	6.60	1	1	1
Maximum:	1.6	12.0	2,200.2	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2024 00:00	1.6	11.5	2,185.7	1.0	8.70	1	1	1
07/24/2024 01:00	1.6	11.5	2,178.3	1.0	8.70	1	1	1
07/24/2024 02:00	1.6	11.5	2,182.3	1.0	8.70	1	1	1
07/24/2024 03:00	1.6	11.5	2,200.5	1.0	8.80	1	1	1
07/24/2024 04:00	1.6	11.5	2,206.7	1.0	8.80	1	1	1
07/24/2024 05:00	1.7	11.5	2,211.0	1.1	8.80	1	1	1
07/24/2024 06:00	1.5	11.7	2,161.0	1.0	8.60	1	1	1
07/24/2024 07:00	1.5	11.8	2,147.9	1.0	8.60	1	1	1
07/24/2024 08:00	1.5	11.8	2,134.8	1.0	8.50	1	1	1
07/24/2024 09:00	1.6	11.8	2,118.7	1.0	8.50	1	1	1
07/24/2024 10:00	1.5	11.8	2,109.3	1.0	8.40	1	1	1
07/24/2024 11:00	1.6	11.7	2,122.8	1.0	8.50	1	1	1
07/24/2024 12:00	1.6	11.5	2,145.9	1.0	8.60	1	1	1
07/24/2024 13:00	1.6	11.6	2,113.8	1.0	8.50	1	1	1
07/24/2024 14:00	1.6	11.5	2,132.8	1.0	8.50	1	1	1
07/24/2024 15:00	1.6	11.4	2,137.7	1.0	8.60	1	1	1
07/24/2024 16:00	1.5	11.9	2,057.7	1.0	8.20	1	1	1
07/24/2024 17:00	1.5	12.0	2,034.9	1.0	8.10	1	1	1
07/24/2024 18:00	1.5	12.0	2,044.8	1.0	8.20	1	1	1
07/24/2024 19:00	1.5	12.0	2,068.7	1.0	8.30	1	1	1
07/24/2024 20:00	1.5	12.0	2,074.0	1.0	8.30	1	1	1
07/24/2024 21:00	1.5	11.8	2,152.9	1.0	8.60	1	1	1
07/24/2024 22:00	1.6	11.6	2,197.1	1.0	8.80	1	1	1
07/24/2024 23:00	1.6	11.6	2,196.0	1.0	8.80	1	1	1
Average/Sum#:	1.6	11.7	2,138.1	1.0	205.10 #	24 #	24 #	24 #
Minimum:	1.5	11.4	2,034.9	1.0	8.10	1	1	1
Maximum:	1.7	12.0	2,211.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2024 00:00	1.5	11.9	2,131.9	1.0	8.50	1	1	1
07/25/2024 01:00	1.5	12.0	2,120.0	1.0	8.50	1	1	1
07/25/2024 02:00	1.5	12.0	2,110.3	1.0	8.40	1	1	1
07/25/2024 03:00	1.6	11.7	2,192.7	1.0	8.80	1	1	1
07/25/2024 04:00	1.6	11.6	2,206.2	1.0	8.80	1	1	1
07/25/2024 05:00	1.6	11.6	2,207.2	1.0	8.80	1	1	1
07/25/2024 06:00	1.5	11.9	2,146.3	1.0	8.60	1	1	1
07/25/2024 07:00	1.5	11.8	2,150.7	1.0	8.60	1	1	1
07/25/2024 08:00	1.5	11.8	2,141.4	1.0	8.60	1	1	1
07/25/2024 09:00	1.5	11.9	2,129.4	1.0	8.50	1	1	1
07/25/2024 10:00	1.5	12.0	2,093.8	1.0	8.40	1	1	1
07/25/2024 11:00	1.6	11.7	2,161.7	1.0	8.60	1	1	1
07/25/2024 12:00	1.6	11.6	2,160.3	1.0	8.60	1	1	1
07/25/2024 13:00	1.6	11.6	2,156.9	1.0	8.60	1	1	1
07/25/2024 14:00	1.6	11.5	2,150.7	1.0	8.60	1	1	1
07/25/2024 15:00	1.6	11.5	2,151.6	1.0	8.60	1	1	1
07/25/2024 16:00	1.6	11.6	2,127.4	1.0	8.50	1	1	1
07/25/2024 17:00	1.6	11.5	2,143.4	1.0	8.60	1	1	1
07/25/2024 18:00	1.6	11.6	2,126.2	1.0	8.50	1	1	1
07/25/2024 19:00	1.5	11.8	2,091.7	1.0	8.40	1	1	1
07/25/2024 20:00	1.6	11.6	2,145.8	1.0	8.60	1	1	1
07/25/2024 21:00	1.6	11.5	2,181.3	1.0	8.70	1	1	1
07/25/2024 22:00	1.6	11.6	2,177.0	1.0	8.70	1	1	1
07/25/2024 23:00	1.6	11.5	2,199.8	1.0	8.80	1	1	1
Average/Sum#:	1.6	11.7	2,150.2	1.0	206.30 #	24 #	24 #	24 #
Minimum:	1.5	11.5	2,091.7	1.0	8.40	1	1	1
Maximum:	1.6	12.0	2,207.2	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2024 00:00	1.6	11.6	2,189.8	1.0	8.80	1	1	1
07/26/2024 01:00	1.5	12.1	2,072.5	1.0	8.30	1	1	1
07/26/2024 02:00	1.4	12.6	1,990.6	1.0	8.00	1	1	1
07/26/2024 03:00	1.4	12.6	1,993.7	1.0	8.00	1	1	1
07/26/2024 04:00	1.5	12.0	2,146.0	1.0	8.60	1	1	1
07/26/2024 05:00	1.5	12.3	2,109.5	1.0	8.40	1	1	1
07/26/2024 06:00	1.4	12.6	1,994.2	1.0	8.00	1	1	1
07/26/2024 07:00	1.4	12.5	1,995.8	1.0	8.00	1	1	1
07/26/2024 08:00	1.5	12.5	2,001.1	1.1	8.00	1	1	1
07/26/2024 09:00	1.5	12.4	2,010.1	1.0	8.00	1	1	1
07/26/2024 10:00	1.5	12.3	2,020.0	1.0	8.10	1	1	1
07/26/2024 11:00	1.5	12.2	2,030.5	1.0	8.10	1	1	1
07/26/2024 12:00	1.5	12.1	2,043.0	1.0	8.20	1	1	1
07/26/2024 13:00	1.5	11.9	2,067.5	1.0	8.30	1	1	1
07/26/2024 14:00	1.5	11.9	2,079.5	1.0	8.30	1	1	1
07/26/2024 15:00	1.6	11.7	2,108.9	1.0	8.40	1	1	1
07/26/2024 16:00	1.6	11.5	2,125.4	1.0	8.50	1	1	1
07/26/2024 17:00	1.6	11.5	2,129.2	1.0	8.50	1	1	1
07/26/2024 18:00	1.5	11.7	2,085.8	1.0	8.30	1	1	1
07/26/2024 19:00	1.6	11.7	2,139.6	1.0	8.60	1	1	1
07/26/2024 20:00	1.6	11.6	2,177.7	1.0	8.70	1	1	1
07/26/2024 21:00	1.5	12.0	2,098.9	1.0	8.40	1	1	1
07/26/2024 22:00	1.5	12.0	2,095.8	1.0	8.40	1	1	1
07/26/2024 23:00	1.4	12.5	1,993.6	1.0	8.00	1	1	1
Average/Sum#:	1.5	12.1	2,070.8	1.0	198.90 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,990.6	1.0	8.00	1	1	1
Maximum:	1.6	12.6	2,189.8	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2024 00:00	1.4	12.6	1,995.6	1.0	8.00	1	1	1
07/27/2024 01:00	1.4	12.6	1,992.3	1.0	8.00	1	1	1
07/27/2024 02:00	1.4	12.7	1,988.3	1.0	8.00	1	1	1
07/27/2024 03:00	1.4	12.7	1,987.3	1.0	7.90	1	1	1
07/27/2024 04:00	1.4	12.6	2,033.3	1.0	8.10	1	1	1
07/27/2024 05:00	1.2	12.5	2,064.3	0.8	6.20	1	1	1
07/27/2024 06:00	3.6	15.4	672.5	3.9	2.54	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 11:00	0.4	18.5	157.7	1.0	0.11	1	0	0
07/27/2024 12:00	7.6	15.1	928.9	7.7	26.00	1	0	0
07/27/2024 13:00	1.2	13.7	1,424.5	1.0	5.70	1	1	0
07/27/2024 14:00	1.3	13.7	1,393.9	1.1	5.60	1	1	0
07/27/2024 15:00	1.3	13.6	1,638.5	1.1	6.60	1	1	0
07/27/2024 16:00	1.1	13.8	1,431.4	0.9	4.30	1	1	0
07/27/2024 17:00	1.3	13.5	1,733.4	1.0	6.90	1	1	0
07/27/2024 18:00	1.1	13.6	1,588.3	0.9	4.80	1	1	1
07/27/2024 19:00	1.5	12.4	2,021.6	1.0	8.10	1	1	1
07/27/2024 20:00	1.5	12.4	2,004.3	1.0	8.00	1	1	1
07/27/2024 21:00	1.4	12.5	1,995.6	1.0	8.00	1	1	1
07/27/2024 22:00	1.5	12.5	1,990.9	1.1	8.00	1	1	1
07/27/2024 23:00	1.4	12.5	1,987.5	1.0	8.00	1	1	1
Average/Sum#:	1.7	13.4	1,651.5	1.5	148.85 #	20 #	17 #	12 #
Minimum:	0.4	12.4	157.7	0.8	0.11	0	0	0
Maximum:	7.6	18.5	2,064.3	7.7	26.00	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2024 00:00	1.4	12.6	1,985.5	1.0	7.90	1	1	1
07/28/2024 01:00	1.4	12.6	1,986.7	1.0	7.90	1	1	1
07/28/2024 02:00	1.4	12.6	1,983.9	1.0	7.90	1	1	1
07/28/2024 03:00	1.4	12.7	1,972.9	1.0	7.90	1	1	1
07/28/2024 04:00	1.4	12.7	1,950.4	1.0	7.80	1	1	1
07/28/2024 05:00	1.3	13.6	1,699.5	1.1	6.80	1	1	0
07/28/2024 06:00	1.1	13.7	1,313.9	0.9	3.90	1	1	0
07/28/2024 07:00	5.4	16.3	323.7	6.9	1.43	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	13.4	1,652.1	1.7	51.53 #	8 #	7 #	5 #
Minimum:	1.1	12.6	323.7	0.9	1.43	0	0	0
Maximum:	5.4	16.3	1,986.7	6.9	7.90	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 10:00	29.1	17.4	331.0	49.1	37.74	1	0	0
07/29/2024 11:00	9.4	16.8	435.4	13.5	21.80	1	0	0
07/29/2024 12:00	8.7	14.4	1,116.0	7.9	32.40	1	0	0
07/29/2024 13:00	1.2	13.7	1,390.7	1.0	5.60	1	1	0
07/29/2024 14:00	1.3	13.7	1,560.9	1.1	6.20	1	1	0
07/29/2024 15:00	1.2	13.6	1,597.6	1.0	6.40	1	1	0
07/29/2024 16:00	1.2	13.6	1,501.9	1.0	6.00	1	1	0
07/29/2024 17:00	1.2	13.6	1,665.0	1.0	6.70	1	1	0
07/29/2024 18:00	1.4	12.7	1,811.3	1.0	7.20	1	1	1
07/29/2024 19:00	1.6	11.5	2,173.2	1.0	8.70	1	1	1
07/29/2024 20:00	1.6	11.5	2,183.1	1.0	8.70	1	1	1
07/29/2024 21:00	1.5	11.9	2,095.3	1.0	8.40	1	1	1
07/29/2024 22:00	1.5	11.9	2,076.1	1.0	8.30	1	1	1
07/29/2024 23:00	5.3	15.4	626.6	5.7	3.30	1	0	0
Average/Sum#:	4.7	13.7	1,468.9	6.2	167.44 #	14 #	10 #	5 #
Minimum:	1.2	11.5	331.0	1.0	3.30	0	0	0
Maximum:	29.1	17.4	2,183.1	49.1	37.74	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 10:00	24.4	17.4	352.8	41.1	37.52	1	0	0
07/30/2024 11:00	7.0	16.9	419.8	10.3	16.00	1	0	0
07/30/2024 12:00	13.1	15.0	908.7	13.1	43.60	1	0	0
07/30/2024 13:00	1.1	13.7	1,399.0	0.9	4.20	1	1	0
07/30/2024 14:00	1.2	13.7	1,403.0	1.0	5.60	1	1	0
07/30/2024 15:00	1.2	13.6	1,641.1	1.0	6.60	1	1	0
07/30/2024 16:00	1.2	13.7	1,412.9	1.0	5.70	1	1	0
07/30/2024 17:00	1.3	13.7	1,447.9	1.1	5.80	1	1	0
07/30/2024 18:00	1.4	13.1	1,741.4	1.1	7.00	1	1	1
07/30/2024 19:00	1.6	11.5	2,166.9	1.0	8.70	1	1	1
07/30/2024 20:00	1.6	11.5	2,170.7	1.0	8.70	1	1	1
07/30/2024 21:00	1.6	11.5	2,165.8	1.0	8.70	1	1	1
07/30/2024 22:00	1.6	11.6	2,155.7	1.0	8.60	1	1	1
07/30/2024 23:00	1.6	11.7	2,154.1	1.0	8.60	1	1	1
Average/Sum#:	4.3	13.5	1,538.6	5.4	175.32 #	14 #	11 #	6 #
Minimum:	1.1	11.5	352.8	0.9	4.20	0	0	0
Maximum:	24.4	17.4	2,170.7	41.1	43.60	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2024 00:00	1.5	12.4	1,994.0	1.0	8.00	1	1	1
07/31/2024 01:00	1.4	12.5	1,987.1	1.0	7.90	1	1	1
07/31/2024 02:00	1.4	12.5	1,984.8	1.0	7.90	1	1	1
07/31/2024 03:00	1.5	12.4	2,012.8	1.0	8.10	1	1	1
07/31/2024 04:00	1.6	11.6	2,203.9	1.0	8.80	1	1	1
07/31/2024 05:00	1.5	12.0	2,121.4	1.0	8.50	1	1	1
07/31/2024 06:00	1.3	13.6	1,716.9	1.1	6.90	1	1	0
07/31/2024 07:00	1.3	13.6	1,589.9	1.1	6.40	1	1	0
07/31/2024 08:00	1.3	13.6	1,493.6	1.1	6.00	1	1	0
07/31/2024 09:00	1.3	13.6	1,498.7	1.1	6.00	1	1	0
07/31/2024 10:00	1.3	13.6	1,546.3	1.1	6.20	1	1	0
07/31/2024 11:00	1.3	13.7	1,578.7	1.1	6.30	1	1	0
07/31/2024 12:00	1.3	13.7	1,463.8	1.1	5.90	1	1	0
07/31/2024 13:00	1.3	13.6	1,627.5	1.1	6.50	1	1	0
07/31/2024 14:00	1.6	11.8	2,095.1	1.0	8.40	1	1	1
07/31/2024 15:00	1.6	11.5	2,141.7	1.0	8.60	1	1	1
07/31/2024 16:00	1.6	11.5	2,141.0	1.0	8.60	1	1	1
07/31/2024 17:00	1.6	11.5	2,139.4	1.0	8.60	1	1	1
07/31/2024 18:00	1.6	11.5	2,140.4	1.0	8.60	1	1	1
07/31/2024 19:00	1.6	11.5	2,141.2	1.0	8.60	1	1	1
07/31/2024 20:00	1.6	11.5	2,147.9	1.0	8.60	1	1	1
07/31/2024 21:00	1.6	11.5	2,150.3	1.0	8.60	1	1	1
07/31/2024 22:00	1.6	11.6	2,145.8	1.0	8.60	1	1	1
07/31/2024 23:00	1.6	11.6	2,146.6	1.0	8.60	1	1	1
Average/Sum#:	1.5	12.4	1,925.4	1.0	185.20 #	24 #	24 #	16 #
Minimum:	1.3	11.5	1,463.8	1.0	5.90	1	1	0
Maximum:	1.6	13.7	2,203.9	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2024 00:00	1.6	11.7	2,147.3	1.0	8.60	1	1	1
08/01/2024 01:00	1.5	11.7	2,138.7	1.0	8.60	1	1	1
08/01/2024 02:00	1.5	11.8	2,132.8	1.0	8.50	1	1	1
08/01/2024 03:00	1.5	11.9	2,126.5	1.0	8.50	1	1	1
08/01/2024 04:00	1.5	12.0	2,127.2	1.0	8.50	1	1	1
08/01/2024 05:00	1.6	11.8	2,150.0	1.0	8.60	1	1	1
08/01/2024 06:00	1.5	11.9	2,113.6	1.0	8.50	1	1	1
08/01/2024 07:00	1.3	13.5	1,706.8	1.0	6.80	1	1	0
08/01/2024 08:00	1.3	13.5	1,730.0	1.0	6.90	1	1	0
08/01/2024 09:00	1.3	13.5	1,745.2	1.0	7.00	1	1	0
08/01/2024 10:00	1.3	13.5	1,734.9	1.0	6.90	1	1	0
08/01/2024 11:00	1.3	13.6	1,714.9	1.1	6.90	1	1	0
08/01/2024 12:00	1.3	13.5	1,714.1	1.0	6.90	1	1	1
08/01/2024 13:00	1.5	11.9	2,076.3	1.0	8.30	1	1	1
08/01/2024 14:00	1.5	11.7	2,093.1	1.0	8.40	1	1	1
08/01/2024 15:00	1.5	11.6	2,099.8	1.0	8.40	1	1	1
08/01/2024 16:00	1.6	11.5	2,152.7	1.0	8.60	1	1	1
08/01/2024 17:00	1.6	11.5	2,151.7	1.0	8.60	1	1	1
08/01/2024 18:00	1.6	11.5	2,155.4	1.0	8.60	1	1	1
08/01/2024 19:00	1.6	11.6	2,160.3	1.0	8.60	1	1	1
08/01/2024 20:00	1.6	11.6	2,168.8	1.0	8.70	1	1	1
08/01/2024 21:00	1.6	11.6	2,173.7	1.0	8.70	1	1	1
08/01/2024 22:00	1.6	11.6	2,174.0	1.0	8.70	1	1	1
08/01/2024 23:00	1.6	11.6	2,183.8	1.0	8.70	1	1	1
Average/Sum#:	1.5	12.2	2,036.3	1.0	195.50 #	24 #	24 #	19 #
Minimum:	1.3	11.5	1,706.8	1.0	6.80	1	1	0
Maximum:	1.6	13.6	2,183.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2024 00:00	1.5	11.6	2,193.0	1.0	8.80	1	1	1
08/02/2024 01:00	1.6	11.6	2,183.2	1.0	8.70	1	1	1
08/02/2024 02:00	1.6	11.6	2,180.6	1.0	8.70	1	1	1
08/02/2024 03:00	1.5	11.7	2,189.1	1.0	8.80	1	1	1
08/02/2024 04:00	1.6	11.7	2,193.3	1.0	8.80	1	1	1
08/02/2024 05:00	1.6	11.7	2,190.4	1.0	8.80	1	1	1
08/02/2024 06:00	1.6	11.7	2,184.7	1.0	8.70	1	1	1
08/02/2024 07:00	1.5	11.6	2,185.3	1.0	8.70	1	1	1
08/02/2024 08:00	1.6	11.6	2,174.2	1.0	8.70	1	1	1
08/02/2024 09:00	1.6	11.6	2,164.8	1.0	8.70	1	1	1
08/02/2024 10:00	1.6	11.6	2,158.1	1.0	8.60	1	1	1
08/02/2024 11:00	1.5	11.6	2,148.7	1.0	8.60	1	1	1
08/02/2024 12:00	1.6	11.6	2,136.4	1.0	8.50	1	1	1
08/02/2024 13:00	1.6	11.6	2,133.7	1.0	8.50	1	1	1
08/02/2024 14:00	1.5	11.6	2,131.7	1.0	8.50	1	1	1
08/02/2024 15:00	1.5	11.6	2,125.9	1.0	8.50	1	1	1
08/02/2024 16:00	1.6	11.6	2,134.8	1.0	8.50	1	1	1
08/02/2024 17:00	1.6	11.6	2,132.9	1.0	8.50	1	1	1
08/02/2024 18:00	1.6	11.6	2,136.8	1.0	8.50	1	1	1
08/02/2024 19:00	1.6	11.6	2,150.1	1.0	8.60	1	1	1
08/02/2024 20:00	1.6	11.6	2,151.6	1.0	8.60	1	1	1
08/02/2024 21:00	1.6	11.6	2,163.5	1.0	8.70	1	1	1
08/02/2024 22:00	1.6	11.6	2,165.7	1.0	8.70	1	1	1
08/02/2024 23:00	1.6	11.6	2,165.3	1.0	8.70	1	1	1
Average/Sum#:	1.6	11.6	2,161.4	1.0	207.40 #	24 #	24 #	24 #
Minimum:	1.5	11.6	2,125.9	1.0	8.50	1	1	1
Maximum:	1.6	11.7	2,193.3	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2024 00:00	1.6	11.6	2,163.0	1.0	8.70	1	1	1
08/03/2024 01:00	1.5	11.6	2,160.9	1.0	8.60	1	1	1
08/03/2024 02:00	1.6	11.6	2,159.5	1.0	8.60	1	1	1
08/03/2024 03:00	1.5	11.9	2,113.5	1.0	8.50	1	1	1
08/03/2024 04:00	1.5	12.0	2,098.2	1.0	8.40	1	1	1
08/03/2024 05:00	1.3	12.2	2,093.5	0.9	6.30	1	1	1
08/03/2024 06:00	1.5	12.2	2,051.5	1.0	8.20	1	1	1
08/03/2024 07:00	1.5	12.1	2,065.1	1.0	8.30	1	1	1
08/03/2024 08:00	1.5	11.9	2,073.1	1.0	8.30	1	1	1
08/03/2024 09:00	1.5	11.9	2,084.1	1.0	8.30	1	1	1
08/03/2024 10:00	1.5	11.9	2,089.9	1.0	8.40	1	1	1
08/03/2024 11:00	1.5	11.9	2,097.4	1.0	8.40	1	1	1
08/03/2024 12:00	1.5	11.9	2,096.4	1.0	8.40	1	1	1
08/03/2024 13:00	1.5	11.8	2,103.2	1.0	8.40	1	1	1
08/03/2024 14:00	1.5	11.7	2,115.0	1.0	8.50	1	1	1
08/03/2024 15:00	1.5	11.7	2,115.1	1.0	8.50	1	1	1
08/03/2024 16:00	1.5	11.7	2,122.0	1.0	8.50	1	1	1
08/03/2024 17:00	1.5	11.7	2,130.0	1.0	8.50	1	1	1
08/03/2024 18:00	1.6	11.7	2,132.7	1.0	8.50	1	1	1
08/03/2024 19:00	1.6	11.7	2,135.8	1.0	8.50	1	1	1
08/03/2024 20:00	1.5	11.7	2,139.6	1.0	8.60	1	1	1
08/03/2024 21:00	1.5	11.7	2,137.4	1.0	8.50	1	1	1
08/03/2024 22:00	1.6	11.7	2,143.9	1.0	8.60	1	1	1
08/03/2024 23:00	1.5	11.7	2,150.0	1.0	8.60	1	1	1
Average/Sum#:	1.5	11.8	2,115.5	1.0	201.10 #	24 #	24 #	24 #
Minimum:	1.3	11.6	2,051.5	0.9	6.30	1	1	1
Maximum:	1.6	12.2	2,163.0	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2024 00:00	1.5	11.9	2,091.0	1.0	8.40	1	1	1
08/04/2024 01:00	1.5	11.9	2,103.3	1.0	8.40	1	1	1
08/04/2024 02:00	1.5	12.1	2,035.8	1.0	8.10	1	1	1
08/04/2024 03:00	1.2	13.6	1,729.5	1.0	6.90	1	1	0
08/04/2024 04:00	1.3	13.5	1,754.6	1.0	7.00	1	1	0
08/04/2024 05:00	1.2	13.5	1,752.0	1.0	7.00	1	1	0
08/04/2024 06:00	1.3	13.6	1,719.0	1.1	6.90	1	1	0
08/04/2024 07:00	1.3	13.6	1,604.0	1.1	6.40	1	1	0
08/04/2024 08:00	1.3	13.6	1,611.0	1.1	6.40	1	1	0
08/04/2024 09:00	1.3	13.6	1,472.8	1.1	5.90	1	1	0
08/04/2024 10:00	1.3	13.7	1,617.8	1.1	6.50	1	1	0
08/04/2024 11:00	1.3	13.5	1,687.6	1.0	6.80	1	1	0
08/04/2024 12:00	1.2	13.7	1,543.6	1.0	6.20	1	1	1
08/04/2024 13:00	1.6	11.7	2,119.1	1.0	8.50	1	1	1
08/04/2024 14:00	1.6	11.6	2,118.7	1.0	8.50	1	1	1
08/04/2024 15:00	1.6	11.6	2,120.6	1.0	8.50	1	1	1
08/04/2024 16:00	1.5	11.7	2,081.1	1.0	8.30	1	1	1
08/04/2024 17:00	1.6	11.6	2,097.3	1.0	8.40	1	1	1
08/04/2024 18:00	1.6	11.6	2,107.6	1.0	8.40	1	1	1
08/04/2024 19:00	1.6	11.6	2,119.4	1.0	8.50	1	1	1
08/04/2024 20:00	1.6	11.6	2,132.6	1.0	8.50	1	1	1
08/04/2024 21:00	1.6	11.6	2,141.2	1.0	8.60	1	1	1
08/04/2024 22:00	1.6	11.7	2,151.5	1.0	8.60	1	1	1
08/04/2024 23:00	1.6	11.7	2,161.6	1.0	8.60	1	1	1
Average/Sum#:	1.4	12.5	1,919.7	1.0	184.30 #	24 #	24 #	15 #
Minimum:	1.2	11.6	1,472.8	1.0	5.90	1	1	0
Maximum:	1.6	13.7	2,161.6	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2024 00:00	1.6	11.7	2,167.2	1.0	8.70	1	1	1
08/05/2024 01:00	1.6	11.7	2,173.7	1.0	8.70	1	1	1
08/05/2024 02:00	1.6	11.7	2,178.0	1.0	8.70	1	1	1
08/05/2024 03:00	1.6	11.7	2,184.5	1.0	8.70	1	1	1
08/05/2024 04:00	1.5	11.7	2,184.6	1.0	8.70	1	1	1
08/05/2024 05:00	1.6	11.7	2,186.5	1.0	8.70	1	1	1
08/05/2024 06:00	0.9	11.9	2,145.6	0.6	4.30	1	1	1
08/05/2024 07:00	1.2	12.2	2,050.4	0.8	6.20	1	1	1
08/05/2024 08:00	1.5	12.3	2,029.3	1.0	8.10	1	1	1
08/05/2024 09:00	1.5	12.3	2,040.3	1.0	8.20	1	1	1
08/05/2024 10:00	1.5	12.1	2,060.4	1.0	8.20	1	1	1
08/05/2024 11:00	1.5	11.8	2,098.6	1.0	8.40	1	1	1
08/05/2024 12:00	1.5	11.6	2,127.1	1.0	8.50	1	1	1
08/05/2024 13:00	1.5	11.6	2,129.1	1.0	8.50	1	1	1
08/05/2024 14:00	1.5	11.6	2,126.5	1.0	8.50	1	1	1
08/05/2024 15:00	1.6	11.6	2,112.2	1.0	8.40	1	1	1
08/05/2024 16:00	1.6	11.6	2,110.2	1.0	8.40	1	1	1
08/05/2024 17:00	1.5	11.6	2,106.2	1.0	8.40	1	1	1
08/05/2024 18:00	1.6	11.6	2,113.4	1.0	8.50	1	1	1
08/05/2024 19:00	1.5	11.8	2,094.3	1.0	8.40	1	1	1
08/05/2024 20:00	1.6	11.6	2,140.5	1.0	8.60	1	1	1
08/05/2024 21:00	1.6	11.6	2,150.4	1.0	8.60	1	1	1
08/05/2024 22:00	1.6	11.6	2,158.5	1.0	8.60	1	1	1
08/05/2024 23:00	1.6	11.6	2,167.9	1.0	8.70	1	1	1
Average/Sum#:	1.5	11.8	2,126.5	1.0	197.70 #	24 #	24 #	24 #
Minimum:	0.9	11.6	2,029.3	0.6	4.30	1	1	1
Maximum:	1.6	12.3	2,186.5	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2024 00:00	1.5	12.0	2,094.2	1.0	8.40	1	1	1
08/06/2024 01:00	1.4	12.3	2,041.0	1.0	8.20	1	1	1
08/06/2024 02:00	1.4	12.4	2,029.2	1.0	8.10	1	1	1
08/06/2024 03:00	1.4	12.4	2,029.3	1.0	8.10	1	1	1
08/06/2024 04:00	1.5	11.8	2,160.8	1.0	8.60	1	1	1
08/06/2024 05:00	0.0	11.7	2,191.4	0.0	0.00	1	1	1
08/06/2024 06:00	1.4	12.2	2,114.6	0.9	6.30	1	1	1
08/06/2024 07:00	1.5	12.4	2,030.3	1.0	8.10	1	1	1
08/06/2024 08:00	1.5	12.3	2,032.4	1.0	8.10	1	1	1
08/06/2024 09:00	1.5	12.2	2,045.4	1.0	8.20	1	1	1
08/06/2024 10:00	1.5	12.0	2,060.1	1.0	8.20	1	1	1
08/06/2024 11:00	1.5	12.0	2,072.3	1.0	8.30	1	1	1
08/06/2024 12:00	1.5	11.9	2,092.4	1.0	8.40	1	1	1
08/06/2024 13:00	1.5	11.8	2,099.2	1.0	8.40	1	1	1
08/06/2024 14:00	1.5	11.7	2,103.0	1.0	8.40	1	1	1
08/06/2024 15:00	1.5	11.7	2,108.9	1.0	8.40	1	1	1
08/06/2024 16:00	1.5	11.7	2,117.0	1.0	8.50	1	1	1
08/06/2024 17:00	1.5	11.6	2,121.7	1.0	8.50	1	1	1
08/06/2024 18:00	1.6	11.6	2,118.1	1.0	8.50	1	1	1
08/06/2024 19:00	1.6	11.6	2,122.9	1.0	8.50	1	1	1
08/06/2024 20:00	1.5	11.6	2,126.4	1.0	8.50	1	1	1
08/06/2024 21:00	1.5	11.7	2,132.3	1.0	8.50	1	1	1
08/06/2024 22:00	1.6	11.7	2,141.2	1.0	8.60	1	1	1
08/06/2024 23:00	1.5	11.7	2,138.3	1.0	8.60	1	1	1
Average/Sum#:	1.5	11.9	2,096.8	1.0	190.40 #	24 #	24 #	24 #
Minimum:	1.4	11.6	2,029.2	0.9	6.30	1	1	1
Maximum:	1.6	12.4	2,191.4	1.0	8.60	1	1	1
%SI	4.17	0.00	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2024 00:00	1.5	11.9	2,106.2	1.0	8.40	1	1	1
08/07/2024 01:00	1.5	11.7	2,156.9	1.0	8.60	1	1	1
08/07/2024 02:00	1.5	12.0	2,099.7	1.0	8.40	1	1	1
08/07/2024 03:00	1.5	12.3	2,039.6	1.0	8.20	1	1	1
08/07/2024 04:00	1.5	12.2	2,053.4	1.0	8.20	1	1	1
08/07/2024 05:00	1.6	11.7	2,130.5	1.0	8.50	1	1	1
08/07/2024 06:00	1.5	11.8	2,141.3	1.0	8.60	1	1	1
08/07/2024 07:00	1.5	12.3	2,042.9	1.0	8.20	1	1	1
08/07/2024 08:00	1.5	12.3	2,046.7	1.0	8.20	1	1	1
08/07/2024 09:00	1.5	12.1	2,059.4	1.0	8.20	1	1	1
08/07/2024 10:00	1.5	12.0	2,076.0	1.0	8.30	1	1	1
08/07/2024 11:00	1.5	11.8	2,092.9	1.0	8.40	1	1	1
08/07/2024 12:00	1.5	11.7	2,103.9	1.0	8.40	1	1	1
08/07/2024 13:00	1.5	11.7	2,110.3	1.0	8.40	1	1	1
08/07/2024 14:00	1.5	11.7	2,113.5	1.0	8.50	1	1	1
08/07/2024 15:00	1.5	11.7	2,114.9	1.0	8.50	1	1	1
08/07/2024 16:00	1.6	11.6	2,109.4	1.0	8.40	1	1	1
08/07/2024 17:00	1.6	11.6	2,101.9	1.0	8.40	1	1	1
08/07/2024 18:00	1.6	11.6	2,109.3	1.0	8.40	1	1	1
08/07/2024 19:00	1.6	11.6	2,119.1	1.0	8.50	1	1	1
08/07/2024 20:00	1.6	11.6	2,128.7	1.0	8.50	1	1	1
08/07/2024 21:00	1.5	11.6	2,136.7	1.0	8.50	1	1	1
08/07/2024 22:00	1.5	12.0	2,060.6	1.0	8.20	1	1	1
08/07/2024 23:00	1.5	11.7	2,156.1	1.0	8.60	1	1	1
Average/Sum#:	1.5	11.8	2,100.4	1.0	201.50 #	24 #	24 #	24 #
Minimum:	1.5	11.6	2,039.6	1.0	8.20	1	1	1
Maximum:	1.6	12.3	2,156.9	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2024 00:00	1.5	11.7	2,169.8	1.0	8.70	1	1	1
08/08/2024 01:00	1.5	11.9	2,108.4	1.0	8.40	1	1	1
08/08/2024 02:00	1.3	13.6	1,666.6	1.1	6.70	1	1	0
08/08/2024 03:00	1.3	13.6	1,702.4	1.1	6.80	1	1	0
08/08/2024 04:00	1.3	13.6	1,672.4	1.1	6.70	1	1	0
08/08/2024 05:00	1.3	13.6	1,740.9	1.1	7.00	1	1	0
08/08/2024 06:00	1.3	13.6	1,735.5	1.1	6.90	1	1	0
08/08/2024 07:00	1.3	13.6	1,674.4	1.1	6.70	1	1	0
08/08/2024 08:00	1.3	13.6	1,572.3	1.1	6.30	1	1	0
08/08/2024 09:00	1.3	13.6	1,566.6	1.1	6.30	1	1	0
08/08/2024 10:00	1.3	13.6	1,561.5	1.1	6.20	1	1	0
08/08/2024 11:00	1.1	13.7	1,340.3	0.9	4.00	1	1	0
08/08/2024 12:00	1.3	13.7	1,330.3	1.1	5.30	1	1	0
08/08/2024 13:00	1.3	13.8	1,334.9	1.1	5.30	1	1	0
08/08/2024 14:00	1.3	13.6	1,525.6	1.1	6.10	1	1	1
08/08/2024 15:00	1.6	11.7	2,100.7	1.0	8.40	1	1	1
08/08/2024 16:00	1.5	11.8	2,057.2	1.0	8.20	1	1	1
08/08/2024 17:00	1.5	11.9	2,039.6	1.0	8.20	1	1	1
08/08/2024 18:00	1.5	11.6	2,105.8	1.0	8.40	1	1	1
08/08/2024 19:00	1.6	11.6	2,114.9	1.0	8.50	1	1	1
08/08/2024 20:00	1.6	11.6	2,126.9	1.0	8.50	1	1	1
08/08/2024 21:00	1.5	11.6	2,135.7	1.0	8.50	1	1	1
08/08/2024 22:00	1.5	11.7	2,135.0	1.0	8.50	1	1	1
08/08/2024 23:00	1.5	11.8	2,112.5	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.8	1,817.9	1.0	173.10 #	24 #	24 #	12 #
Minimum:	1.1	11.6	1,330.3	0.9	4.00	1	1	0
Maximum:	1.6	13.8	2,169.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2024 00:00	1.3	13.5	1,609.1	1.0	6.40	1	1	1
08/09/2024 01:00	1.3	13.6	1,703.2	1.1	6.80	1	1	0
08/09/2024 02:00	1.3	13.6	1,733.0	1.1	6.90	1	1	0
08/09/2024 03:00	1.3	13.6	1,717.3	1.1	6.90	1	1	0
08/09/2024 04:00	1.3	13.6	1,752.4	1.1	7.00	1	1	0
08/09/2024 05:00	1.3	13.6	1,751.8	1.1	7.00	1	1	0
08/09/2024 06:00	1.3	13.6	1,714.9	1.1	6.90	1	1	0
08/09/2024 07:00	1.3	13.6	1,559.0	1.1	6.20	1	1	0
08/09/2024 08:00	1.2	13.7	1,463.2	1.0	5.90	1	1	0
08/09/2024 09:00	1.3	13.7	1,538.6	1.1	6.20	1	1	0
08/09/2024 10:00	1.3	13.7	1,571.2	1.1	6.30	1	1	0
08/09/2024 11:00	1.2	13.7	1,591.3	1.0	6.40	1	1	0
08/09/2024 12:00	1.3	13.6	1,649.6	1.1	6.60	1	1	0
08/09/2024 13:00	1.3	13.6	1,707.2	1.1	6.80	1	1	0
08/09/2024 14:00	1.2	13.5	1,605.3	1.0	6.40	1	1	1
08/09/2024 15:00	1.6	11.7	2,100.8	1.0	8.40	1	1	1
08/09/2024 16:00	1.5	11.8	2,069.7	1.0	8.30	1	1	1
08/09/2024 17:00	1.5	11.6	2,099.2	1.0	8.40	1	1	1
08/09/2024 18:00	1.5	11.7	2,107.6	1.0	8.40	1	1	1
08/09/2024 19:00	1.6	11.7	2,119.5	1.0	8.50	1	1	1
08/09/2024 20:00	1.6	11.7	2,103.0	1.0	8.40	1	1	1
08/09/2024 21:00	2.7	15.3	687.9	2.8	1.93	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.2	1,725.2	1.1	151.03 #	22 #	21 #	8 #
Minimum:	1.2	11.6	687.9	1.0	1.93	0	0	0
Maximum:	2.7	15.3	2,119.5	2.8	8.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 13:00	30.3	17.3	320.3	49.7	42.19	1	0	0
08/12/2024 14:00	14.3	16.8	408.3	20.6	31.00	1	0	0
08/12/2024 15:00	5.8	15.1	957.1	5.9	21.10	1	0	0
08/12/2024 16:00	1.3	13.5	1,687.6	1.0	6.80	1	1	0
08/12/2024 17:00	1.5	12.5	1,929.9	1.1	7.70	1	1	1
08/12/2024 18:00	1.3	13.3	1,768.9	1.0	7.10	1	1	1
08/12/2024 19:00	1.3	13.5	1,695.8	1.0	6.80	1	1	0
08/12/2024 20:00	1.1	13.6	1,497.7	0.9	4.50	1	1	0
08/12/2024 21:00	1.3	13.6	1,716.7	1.1	6.90	1	1	0
08/12/2024 22:00	1.3	13.6	1,689.2	1.1	6.80	1	1	0
08/12/2024 23:00	1.3	13.7	1,723.8	1.1	6.90	1	1	0
Average/Sum#:	5.5	14.2	1,399.6	7.7	147.79 #	11 #	8 #	2 #
Minimum:	1.1	12.5	320.3	0.9	4.50	0	0	0
Maximum:	30.3	17.3	1,929.9	49.7	42.19	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2024 00:00	1.3	13.6	1,683.4	1.1	6.70	1	1	0
08/13/2024 01:00	1.1	13.7	1,348.3	0.9	4.00	1	1	0
08/13/2024 02:00	4.6	15.4	639.0	4.9	2.88	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.3	14.2	1,223.6	2.3	13.58 #	3 #	2 #	0 #
Minimum:	1.1	13.6	639.0	0.9	2.88	0	0	0
Maximum:	4.6	15.4	1,683.4	4.9	6.70	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 17:00	33.3	17.2	339.5	53.1	63.18	1	0	0
08/15/2024 18:00	5.5	14.3	1,226.7	4.9	22.10	1	0	0
08/15/2024 19:00	1.4	12.5	1,852.5	1.0	7.40	1	1	1
08/15/2024 20:00	1.5	11.7	2,105.6	1.0	8.40	1	1	1
08/15/2024 21:00	1.2	13.6	1,692.5	1.0	6.80	1	1	0
08/15/2024 22:00	1.3	13.6	1,672.0	1.1	6.70	1	1	0
08/15/2024 23:00	1.3	13.6	1,698.4	1.1	6.80	1	1	0
Average/Sum#:	6.5	13.8	1,512.5	9.0	121.38 #	7 #	5 #	2 #
Minimum:	1.2	11.7	339.5	1.0	6.70	0	0	0
Maximum:	33.3	17.2	2,105.6	53.1	63.18	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2024 00:00	1.3	13.6	1,741.5	1.1	7.00	1	1	0
08/16/2024 01:00	1.3	13.6	1,689.7	1.1	6.80	1	1	0
08/16/2024 02:00	2.4	14.7	1,042.8	2.3	3.74	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 08:00	2.6	17.5	336.0	4.5	2.74	1	0	0
08/16/2024 09:00	11.0	15.0	928.1	11.0	38.10	1	0	0
08/16/2024 10:00	1.2	13.6	1,578.6	1.0	6.30	1	1	0
08/16/2024 11:00	1.2	13.7	1,426.2	1.0	5.70	1	1	0
08/16/2024 12:00	1.2	13.6	1,662.1	1.0	6.60	1	1	0
08/16/2024 13:00	1.2	13.6	1,549.8	1.0	6.20	1	1	0
08/16/2024 14:00	1.2	13.8	1,343.9	1.0	5.40	1	1	0
08/16/2024 15:00	1.2	13.6	1,580.7	1.0	6.30	1	1	1
08/16/2024 16:00	1.5	11.9	2,064.7	1.0	8.30	1	1	1
08/16/2024 17:00	1.5	11.9	2,072.0	1.0	8.30	1	1	1
08/16/2024 18:00	1.5	11.8	2,090.7	1.0	8.40	1	1	1
08/16/2024 19:00	1.5	11.8	2,100.8	1.0	8.40	1	1	1
08/16/2024 20:00	1.5	11.8	2,113.4	1.0	8.50	1	1	1
08/16/2024 21:00	1.6	11.8	2,125.2	1.0	8.50	1	1	1
08/16/2024 22:00	1.5	11.8	2,133.0	1.0	8.50	1	1	1
08/16/2024 23:00	1.5	11.8	2,136.9	1.0	8.50	1	1	1
Average/Sum#:	2.0	13.2	1,669.3	1.8	162.28 #	19 #	16 #	9 #
Minimum:	1.2	11.8	336.0	1.0	2.74	0	0	0
Maximum:	11.0	17.5	2,136.9	11.0	38.10	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2024 00:00	1.5	11.8	2,150.7	1.0	8.60	1	1	1
08/17/2024 01:00	1.5	12.0	2,107.5	1.0	8.40	1	1	1
08/17/2024 02:00	1.5	12.2	2,062.0	1.0	8.20	1	1	1
08/17/2024 03:00	1.5	12.3	2,040.1	1.0	8.20	1	1	1
08/17/2024 04:00	1.5	12.2	2,058.1	1.0	8.20	1	1	1
08/17/2024 05:00	1.2	12.2	2,076.1	0.8	6.20	1	1	1
08/17/2024 06:00	2.3	13.9	1,261.3	1.9	4.58	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	12.4	1,965.1	1.1	52.38 #	7 #	6 #	7 #
Minimum:	1.2	11.8	1,261.3	0.8	4.58	0	0	0
Maximum:	2.3	13.9	2,150.7	1.9	8.60	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 09:00	27.9	17.3	346.8	45.7	43.73	1	0	0
08/18/2024 10:00	6.8	16.9	430.4	10.0	15.90	1	0	0
08/18/2024 11:00	12.4	14.6	1,066.4	11.6	45.90	1	0	0
08/18/2024 12:00	1.1	13.8	1,395.7	0.9	4.20	1	1	0
08/18/2024 13:00	1.2	13.7	1,586.6	1.0	6.30	1	1	0
08/18/2024 14:00	1.3	13.6	1,711.3	1.1	6.80	1	1	0
08/18/2024 15:00	1.2	13.7	1,470.9	1.0	5.90	1	1	0
08/18/2024 16:00	1.2	13.6	1,693.4	1.0	6.80	1	1	0
08/18/2024 17:00	1.3	13.5	1,672.3	1.0	6.70	1	1	1
08/18/2024 18:00	1.5	12.0	2,084.4	1.0	8.30	1	1	1
08/18/2024 19:00	1.6	11.6	2,195.0	1.0	8.80	1	1	1
08/18/2024 20:00	1.6	11.4	2,228.2	1.0	8.90	1	1	1
08/18/2024 21:00	1.6	11.4	2,245.1	1.0	9.00	1	1	1
08/18/2024 22:00	1.6	11.4	2,257.9	1.0	9.00	1	1	1
08/18/2024 23:00	1.5	11.5	2,175.2	0.9	6.50	1	1	1
Average/Sum#:	4.3	13.3	1,637.3	5.3	192.73 #	15 #	12 #	7 #
Minimum:	1.1	11.4	346.8	0.9	4.20	0	0	0
Maximum:	27.9	17.3	2,257.9	45.7	45.90	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2024 00:00	2.8	15.6	575.4	3.1	1.45	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 12:00	22.6	17.3	365.9	37.0	38.84	1	0	0
08/19/2024 13:00	13.6	14.7	1,038.7	12.9	49.90	1	0	0
08/19/2024 14:00	1.2	13.7	1,653.2	1.0	6.60	1	1	0
08/19/2024 15:00	1.2	13.7	1,515.2	1.0	6.10	1	1	0
08/19/2024 16:00	1.6	12.1	2,123.4	1.1	8.50	1	1	1
08/19/2024 17:00	1.5	12.0	2,096.7	1.0	8.40	1	1	1
08/19/2024 18:00	1.6	11.4	2,231.2	1.0	8.90	1	1	1
08/19/2024 19:00	1.5	11.8	2,142.7	1.0	8.60	1	1	1
08/19/2024 20:00	1.5	12.0	2,094.4	1.0	8.40	1	1	1
08/19/2024 21:00	1.6	11.5	2,210.4	1.0	8.80	1	1	1
08/19/2024 22:00	1.6	11.5	2,232.0	1.0	8.90	1	1	1
08/19/2024 23:00	1.5	11.8	2,148.5	1.0	8.60	1	1	1
Average/Sum#:	4.1	13.0	1,725.2	4.9	171.99 #	13 #	10 #	8 #
Minimum:	1.2	11.4	365.9	1.0	1.45	0	0	0
Maximum:	22.6	17.3	2,232.0	37.0	49.90	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2024 00:00	1.4	12.6	1,949.8	1.0	7.80	1	1	1
08/20/2024 01:00	3.4	15.3	666.3	3.6	2.18	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 09:00	16.9	17.6	301.1	30.2	21.71	1	0	0
08/20/2024 10:00	13.3	15.0	937.1	13.3	45.90	1	0	0
08/20/2024 11:00	1.0	13.8	1,396.2	0.8	4.20	1	1	0
08/20/2024 12:00	1.2	13.7	1,540.4	1.0	6.20	1	1	0
08/20/2024 13:00	1.3	13.7	1,674.6	1.1	6.70	1	1	0
08/20/2024 14:00	1.2	13.7	1,459.3	1.0	5.80	1	1	0
08/20/2024 15:00	1.2	13.8	1,330.3	1.0	5.30	1	1	0
08/20/2024 16:00	1.3	13.7	1,557.9	1.1	6.20	1	1	1
08/20/2024 17:00	1.5	11.9	2,084.2	1.0	8.30	1	1	1
08/20/2024 18:00	1.5	11.7	2,135.7	1.0	8.50	1	1	1
08/20/2024 19:00	1.5	11.8	2,120.7	1.0	8.50	1	1	1
08/20/2024 20:00	1.5	11.9	2,104.4	1.0	8.40	1	1	1
08/20/2024 21:00	1.5	12.2	2,032.9	1.0	8.10	1	1	1
08/20/2024 22:00	1.6	11.5	2,199.5	1.0	8.80	1	1	1
08/20/2024 23:00	1.6	11.5	2,204.3	1.0	8.80	1	1	1
Average/Sum#:	3.1	13.3	1,629.1	3.6	171.39 #	17 #	14 #	9 #
Minimum:	1.0	11.5	301.1	0.8	2.18	0	0	0
Maximum:	16.9	17.6	2,204.3	30.2	45.90	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2024 00:00	1.6	11.5	2,218.4	1.0	8.90	1	1	1
08/21/2024 01:00	1.4	12.5	1,994.8	1.0	8.00	1	1	1
08/21/2024 02:00	1.3	13.6	1,703.9	1.1	6.80	1	1	1
08/21/2024 03:00	1.3	13.7	1,717.5	1.1	6.90	1	1	0
08/21/2024 04:00	1.3	13.7	1,726.0	1.1	6.90	1	1	0
08/21/2024 05:00	1.3	13.7	1,736.9	1.1	6.90	1	1	0
08/21/2024 06:00	1.3	13.7	1,730.5	1.1	6.90	1	1	0
08/21/2024 07:00	1.3	13.7	1,621.6	1.1	6.50	1	1	0
08/21/2024 08:00	1.3	13.7	1,615.8	1.1	6.50	1	1	0
08/21/2024 09:00	1.2	13.8	1,330.0	1.0	5.30	1	1	0
08/21/2024 10:00	1.2	13.7	1,539.9	1.0	6.20	1	1	0
08/21/2024 11:00	1.3	13.7	1,584.8	1.1	6.30	1	1	0
08/21/2024 12:00	1.2	13.7	1,661.8	1.0	6.60	1	1	0
08/21/2024 13:00	1.3	13.6	1,742.7	1.1	7.00	1	1	0
08/21/2024 14:00	1.3	13.5	1,752.2	1.0	7.00	1	1	0
08/21/2024 15:00	1.2	13.5	1,734.0	1.0	6.90	1	1	0
08/21/2024 16:00	1.3	13.6	1,617.7	1.1	6.50	1	1	0
08/21/2024 17:00	1.5	11.9	2,105.4	1.0	8.40	1	1	1
08/21/2024 18:00	1.7	11.1	2,274.8	1.0	9.10	1	1	1
08/21/2024 19:00	1.6	11.1	2,281.6	1.0	9.10	1	1	1
08/21/2024 20:00	1.6	11.4	2,241.3	1.0	9.00	1	1	1
08/21/2024 21:00	1.6	11.6	2,194.5	1.0	8.80	1	1	1
08/21/2024 22:00	1.6	11.6	2,191.6	1.0	8.80	1	1	1
08/21/2024 23:00	1.5	11.6	2,210.4	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.9	1,855.3	1.0	178.10 #	24 #	24 #	10 #
Minimum:	1.2	11.1	1,330.0	1.0	5.30	1	1	0
Maximum:	1.7	13.8	2,281.6	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2024 00:00	1.4	12.5	2,001.3	1.0	8.00	1	1	1
08/22/2024 01:00	1.4	12.7	1,969.9	1.0	7.90	1	1	1
08/22/2024 02:00	1.4	12.7	1,966.3	1.0	7.90	1	1	1
08/22/2024 03:00	1.4	12.7	1,963.8	1.0	7.90	1	1	1
08/22/2024 04:00	1.4	12.7	1,975.3	1.0	7.90	1	1	1
08/22/2024 05:00	1.5	11.9	2,123.5	1.0	8.50	1	1	1
08/22/2024 06:00	4.3	15.3	697.2	4.5	2.98	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 14:00	21.9	17.4	346.6	36.9	31.56	1	0	0
08/22/2024 15:00	9.7	15.2	896.2	10.0	33.20	1	0	0
08/22/2024 16:00	1.2	13.6	1,671.8	1.0	6.70	1	1	0
08/22/2024 17:00	1.4	12.8	1,889.6	1.0	7.60	1	1	1
08/22/2024 18:00	1.5	12.5	2,013.7	1.1	8.10	1	1	1
08/22/2024 19:00	1.5	12.6	1,992.2	1.1	8.00	1	1	1
08/22/2024 20:00	1.5	12.6	1,985.3	1.1	7.90	1	1	1
08/22/2024 21:00	1.4	12.7	1,976.9	1.0	7.90	1	1	1
08/22/2024 22:00	1.4	12.7	1,969.7	1.0	7.90	1	1	1
08/22/2024 23:00	1.4	12.8	1,962.6	1.0	7.90	1	1	1
Average/Sum#:	3.3	13.3	1,729.5	3.9	177.84 #	17 #	14 #	13 #
Minimum:	1.2	11.9	346.6	1.0	2.98	0	0	0
Maximum:	21.9	17.4	2,123.5	36.9	33.20	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2024 00:00	1.4	12.8	1,956.0	1.0	7.80	1	1	1
08/23/2024 01:00	1.4	12.8	1,958.0	1.0	7.80	1	1	1
08/23/2024 02:00	1.4	12.8	1,958.0	1.0	7.80	1	1	1
08/23/2024 03:00	1.4	12.8	1,960.1	1.0	7.80	1	1	1
08/23/2024 04:00	1.4	12.8	1,963.3	1.0	7.90	1	1	1
08/23/2024 05:00	1.4	12.3	2,041.5	1.0	8.20	1	1	1
08/23/2024 06:00	1.1	13.7	1,435.0	0.9	4.30	1	1	0
08/23/2024 07:00	6.0	16.1	397.5	7.4	1.82	1	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	13.3	1,708.7	1.8	53.42 #	8 #	7 #	6 #
Minimum:	1.1	12.3	397.5	0.9	1.82	0	0	0
Maximum:	6.0	16.1	2,041.5	7.4	8.20	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 13:00	37.0	17.4	337.7	62.4	54.39	1	0	0
08/25/2024 14:00	27.6	15.7	656.8	31.3	75.50	1	0	0
08/25/2024 15:00	9.4	14.4	1,204.9	8.5	37.40	1	0	0
08/25/2024 16:00	1.3	13.6	1,745.0	1.1	7.00	1	1	0
08/25/2024 17:00	1.5	12.4	2,042.9	1.0	8.20	1	1	1
08/25/2024 18:00	1.6	11.1	2,332.9	1.0	9.30	1	1	1
08/25/2024 19:00	1.7	11.1	2,337.0	1.0	9.30	1	1	1
08/25/2024 20:00	1.7	11.1	2,343.4	1.0	9.40	1	1	1
08/25/2024 21:00	1.5	12.2	2,089.9	1.0	8.40	1	1	1
08/25/2024 22:00	1.4	12.7	1,974.5	1.0	7.90	1	1	1
08/25/2024 23:00	1.3	13.6	1,762.0	1.1	7.00	1	1	0
Average/Sum#:	7.8	13.2	1,711.5	10.0	233.79 #	11 #	8 #	6 #
Minimum:	1.3	11.1	337.7	1.0	7.00	0	0	0
Maximum:	37.0	17.4	2,343.4	62.4	75.50	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2024 00:00	1.3	13.6	1,802.9	1.1	7.20	1	1	0
08/26/2024 01:00	1.3	13.6	1,762.3	1.1	7.00	1	1	0
08/26/2024 02:00	1.3	13.6	1,771.9	1.1	7.10	1	1	0
08/26/2024 03:00	1.3	13.5	1,831.5	1.0	7.30	1	1	0
08/26/2024 04:00	1.3	13.5	1,830.8	1.0	7.30	1	1	0
08/26/2024 05:00	1.3	13.5	1,828.9	1.0	7.30	1	1	0
08/26/2024 06:00	1.3	13.7	1,727.4	1.1	6.90	1	1	0
08/26/2024 07:00	1.3	13.5	1,804.8	1.0	7.20	1	1	0
08/26/2024 08:00	1.2	13.7	1,644.4	1.0	6.60	1	1	0
08/26/2024 09:00	1.3	13.7	1,736.3	1.1	6.90	1	1	0
08/26/2024 10:00	1.3	13.7	1,723.5	1.1	6.90	1	1	0
08/26/2024 11:00	1.3	13.7	1,719.3	1.1	6.90	1	1	0
08/26/2024 12:00	1.4	12.9	1,856.6	1.0	7.40	1	1	1
08/26/2024 13:00	1.5	12.4	2,032.8	1.0	8.10	1	1	1
08/26/2024 14:00	1.5	12.1	2,079.1	1.0	8.30	1	1	1
08/26/2024 15:00	1.5	12.3	2,038.7	1.0	8.20	1	1	1
08/26/2024 16:00	1.5	11.8	2,158.6	1.0	8.60	1	1	1
08/26/2024 17:00	1.6	11.2	2,263.4	1.0	9.10	1	1	1
08/26/2024 18:00	1.6	11.0	2,299.6	1.0	9.20	1	1	1
08/26/2024 19:00	1.6	11.1	2,305.2	1.0	9.20	1	1	1
08/26/2024 20:00	1.6	11.4	2,253.8	1.0	9.00	1	1	1
08/26/2024 21:00	1.6	11.4	2,258.9	1.0	9.00	1	1	1
08/26/2024 22:00	1.6	11.5	2,230.1	1.0	8.90	1	1	1
08/26/2024 23:00	1.4	12.6	2,002.1	1.0	8.00	1	1	1
Average/Sum#:	1.4	12.7	1,956.8	1.0	187.60 #	24 #	24 #	12 #
Minimum:	1.2	11.0	1,644.4	1.0	6.60	1	1	0
Maximum:	1.6	13.7	2,305.2	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2024 00:00	1.4	12.7	1,988.2	1.0	8.00	1	1	1
08/27/2024 01:00	1.4	12.7	1,992.0	1.0	8.00	1	1	1
08/27/2024 02:00	1.4	12.7	1,995.7	1.0	8.00	1	1	1
08/27/2024 03:00	1.4	12.6	1,997.9	1.0	8.00	1	1	1
08/27/2024 04:00	1.4	12.7	1,979.2	1.0	7.90	1	1	1
08/27/2024 05:00	1.1	13.7	1,721.5	0.9	5.20	1	1	0
08/27/2024 06:00	1.3	13.7	1,703.9	1.1	6.80	1	1	0
08/27/2024 07:00	1.3	13.7	1,604.5	1.1	6.40	1	1	0
08/27/2024 08:00	1.2	13.8	1,317.8	1.0	5.30	1	1	0
08/27/2024 09:00	1.3	13.8	1,315.8	1.1	5.30	1	1	0
08/27/2024 10:00	1.3	13.8	1,318.6	1.1	5.30	1	1	0
08/27/2024 11:00	1.3	13.8	1,323.8	1.1	5.30	1	1	0
08/27/2024 12:00	1.2	13.7	1,621.1	1.0	6.50	1	1	0
08/27/2024 13:00	1.3	13.7	1,662.3	1.1	6.60	1	1	0
08/27/2024 14:00	1.3	13.6	1,724.1	1.1	6.90	1	1	0
08/27/2024 15:00	1.2	13.7	1,592.3	1.0	6.40	1	1	0
08/27/2024 16:00	1.5	12.3	1,950.4	1.0	7.80	1	1	1
08/27/2024 17:00	1.6	11.2	2,247.2	1.0	9.00	1	1	1
08/27/2024 18:00	1.6	11.5	2,221.4	1.0	8.90	1	1	1
08/27/2024 19:00	1.6	11.3	2,250.4	1.0	9.00	1	1	1
08/27/2024 20:00	1.6	11.2	2,280.7	1.0	9.10	1	1	1
08/27/2024 21:00	1.6	11.3	2,253.9	1.0	9.00	1	1	1
08/27/2024 22:00	1.5	12.0	2,116.9	1.0	8.50	1	1	1
08/27/2024 23:00	1.5	11.7	2,205.3	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.8	1,849.4	1.0	176.00 #	24 #	24 #	13 #
Minimum:	1.1	11.2	1,315.8	0.9	5.20	1	1	0
Maximum:	1.6	13.8	2,280.7	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2024 00:00	1.5	12.0	2,140.2	1.0	8.60	1	1	1
08/28/2024 01:00	1.4	12.5	2,007.6	1.0	8.00	1	1	1
08/28/2024 02:00	1.4	12.6	2,006.3	1.0	8.00	1	1	1
08/28/2024 03:00	1.5	12.2	2,087.0	1.0	8.30	1	1	1
08/28/2024 04:00	1.6	11.6	2,229.1	1.0	8.90	1	1	1
08/28/2024 05:00	1.3	11.6	2,225.9	0.8	6.70	1	1	1
08/28/2024 06:00	1.5	12.2	2,076.8	1.0	8.30	1	1	1
08/28/2024 07:00	1.4	12.5	2,004.9	1.0	8.00	1	1	1
08/28/2024 08:00	1.4	12.4	2,010.7	1.0	8.00	1	1	1
08/28/2024 09:00	1.4	12.3	2,018.0	1.0	8.10	1	1	1
08/28/2024 10:00	1.5	12.3	2,027.4	1.0	8.10	1	1	1
08/28/2024 11:00	1.5	12.2	2,036.3	1.0	8.10	1	1	1
08/28/2024 12:00	1.5	12.1	2,050.6	1.0	8.20	1	1	1
08/28/2024 13:00	1.5	11.8	2,109.7	1.0	8.40	1	1	1
08/28/2024 14:00	1.5	11.9	2,086.4	1.0	8.30	1	1	1
08/28/2024 15:00	1.5	12.0	2,065.6	1.0	8.30	1	1	1
08/28/2024 16:00	1.5	11.9	2,093.6	1.0	8.40	1	1	1
08/28/2024 17:00	1.5	12.0	2,068.3	1.0	8.30	1	1	1
08/28/2024 18:00	1.6	11.5	2,173.2	1.0	8.70	1	1	1
08/28/2024 19:00	1.6	11.1	2,274.0	1.0	9.10	1	1	1
08/28/2024 20:00	1.5	11.6	2,148.8	1.0	8.60	1	1	1
08/28/2024 21:00	1.5	12.3	2,024.7	1.0	8.10	1	1	1
08/28/2024 22:00	1.4	12.4	2,015.0	1.0	8.10	1	1	1
08/28/2024 23:00	1.4	12.6	1,999.8	1.0	8.00	1	1	1
Average/Sum#:	1.5	12.1	2,082.5	1.0	197.60 #	24 #	24 #	24 #
Minimum:	1.3	11.1	1,999.8	0.8	6.70	1	1	1
Maximum:	1.6	12.6	2,274.0	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2024 00:00	1.4	12.5	2,001.6	1.0	8.00	1	1	1
08/29/2024 01:00	1.4	12.6	1,998.4	1.0	8.00	1	1	1
08/29/2024 02:00	1.4	12.6	1,993.5	1.0	8.00	1	1	1
08/29/2024 03:00	1.4	12.6	1,994.1	1.0	8.00	1	1	1
08/29/2024 04:00	1.4	12.5	2,035.7	1.0	8.10	1	1	1
08/29/2024 05:00	1.3	12.7	1,993.6	0.9	6.00	1	1	1
08/29/2024 06:00	1.2	13.7	1,744.1	1.0	7.00	1	1	0
08/29/2024 07:00	1.2	13.7	1,540.4	1.0	6.20	1	1	0
08/29/2024 08:00	1.3	13.8	1,323.8	1.1	5.30	1	1	0
08/29/2024 09:00	1.3	13.8	1,322.0	1.1	5.30	1	1	0
08/29/2024 10:00	1.3	13.8	1,322.6	1.1	5.30	1	1	0
08/29/2024 11:00	1.3	13.8	1,334.6	1.1	5.30	1	1	0
08/29/2024 12:00	1.3	13.7	1,591.4	1.1	6.40	1	1	0
08/29/2024 13:00	1.3	13.6	1,685.4	1.1	6.70	1	1	0
08/29/2024 14:00	1.3	13.6	1,729.8	1.1	6.90	1	1	0
08/29/2024 15:00	1.2	13.6	1,540.1	1.0	6.20	1	1	1
08/29/2024 16:00	1.5	12.0	2,086.2	1.0	8.30	1	1	1
08/29/2024 17:00	1.6	11.6	2,165.6	1.0	8.70	1	1	1
08/29/2024 18:00	1.5	12.0	2,082.7	1.0	8.30	1	1	1
08/29/2024 19:00	1.6	11.4	2,229.6	1.0	8.90	1	1	1
08/29/2024 20:00	1.5	11.8	2,129.1	1.0	8.50	1	1	1
08/29/2024 21:00	1.5	12.1	2,077.1	1.0	8.30	1	1	1
08/29/2024 22:00	1.4	12.5	2,006.5	1.0	8.00	1	1	1
08/29/2024 23:00	1.4	12.5	2,002.1	1.0	8.00	1	1	1
Average/Sum#:	1.4	12.9	1,830.4	1.0	173.70 #	24 #	24 #	15 #
Minimum:	1.2	11.4	1,322.0	0.9	5.30	1	1	0
Maximum:	1.6	13.8	2,229.6	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2024 00:00	1.4	12.6	1,997.3	1.0	8.00	1	1	1
08/30/2024 01:00	1.4	12.6	1,993.5	1.0	8.00	1	1	1
08/30/2024 02:00	1.4	12.7	1,991.3	1.0	8.00	1	1	1
08/30/2024 03:00	1.4	12.7	1,989.5	1.0	8.00	1	1	1
08/30/2024 04:00	1.5	12.4	2,064.1	1.0	8.30	1	1	1
08/30/2024 05:00	1.5	12.0	2,116.4	1.0	8.50	1	1	1
08/30/2024 06:00	1.4	12.3	2,070.3	1.0	8.30	1	1	1
08/30/2024 07:00	1.2	13.6	1,400.5	1.0	5.60	1	1	1
08/30/2024 08:00	1.3	13.7	1,377.9	1.1	5.50	1	1	0
08/30/2024 09:00	1.3	13.7	1,327.3	1.1	5.30	1	1	0
08/30/2024 10:00	1.3	13.7	1,336.3	1.1	5.30	1	1	0
08/30/2024 11:00	1.1	13.8	1,374.8	0.9	4.10	1	1	0
08/30/2024 12:00	1.3	13.8	1,346.7	1.1	5.40	1	1	0
08/30/2024 13:00	1.2	13.7	1,677.6	1.0	6.70	1	1	0
08/30/2024 14:00	1.3	13.4	1,711.7	1.0	6.80	1	1	1
08/30/2024 15:00	1.5	11.9	2,084.0	1.0	8.30	1	1	1
08/30/2024 16:00	1.5	11.7	2,123.4	1.0	8.50	1	1	1
08/30/2024 17:00	1.6	11.2	2,228.6	1.0	8.90	1	1	1
08/30/2024 18:00	1.7	11.0	2,285.1	1.0	9.10	1	1	1
08/30/2024 19:00	1.6	11.1	2,276.3	1.0	9.10	1	1	1
08/30/2024 20:00	1.6	11.1	2,269.9	1.0	9.10	1	1	1
08/30/2024 21:00	1.6	11.4	2,209.0	1.0	8.80	1	1	1
08/30/2024 22:00	1.5	12.3	2,044.2	1.0	8.20	1	1	1
08/30/2024 23:00	1.6	11.4	2,234.8	1.0	8.90	1	1	1
Average/Sum#:	1.4	12.5	1,897.1	1.0	180.70 #	24 #	24 #	18 #
Minimum:	1.1	11.0	1,327.3	0.9	4.10	1	1	0
Maximum:	1.7	13.8	2,285.1	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2024 00:00	1.6	11.5	2,227.3	1.0	8.90	1	1	1
08/31/2024 01:00	1.5	11.6	2,219.0	1.0	8.90	1	1	1
08/31/2024 02:00	1.5	11.6	2,219.5	1.0	8.90	1	1	1
08/31/2024 03:00	1.6	11.6	2,212.7	1.0	8.90	1	1	1
08/31/2024 04:00	1.5	11.7	2,211.4	1.0	8.80	1	1	1
08/31/2024 05:00	1.6	12.1	2,092.0	1.1	8.40	1	1	1
08/31/2024 06:00	3.2	15.6	583.4	3.6	1.75	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 14:00	18.1	17.6	325.1	32.4	17.42	1	0	0
08/31/2024 15:00	7.3	14.9	1,047.9	7.2	27.20	1	0	0
08/31/2024 16:00	1.3	13.5	1,680.8	1.0	6.70	1	1	0
08/31/2024 17:00	1.4	12.8	1,829.6	1.0	7.30	1	1	1
08/31/2024 18:00	1.6	11.0	2,279.3	1.0	9.10	1	1	1
08/31/2024 19:00	1.6	11.0	2,291.1	1.0	9.20	1	1	1
08/31/2024 20:00	1.7	11.0	2,298.6	1.0	9.20	1	1	1
08/31/2024 21:00	1.6	11.0	2,303.8	1.0	9.20	1	1	1
08/31/2024 22:00	1.6	11.4	2,254.4	1.0	9.00	1	1	1
08/31/2024 23:00	1.6	11.2	2,292.0	1.0	9.20	1	1	1
Average/Sum#:	3.0	12.4	1,904.0	3.4	168.07 #	17 #	14 #	13 #
Minimum:	1.3	11.0	325.1	1.0	1.75	0	0	0
Maximum:	18.1	17.6	2,303.8	32.4	27.20	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2024 00:00	1.5	11.7	2,172.6	1.0	8.70	1	1	1
09/01/2024 01:00	1.5	11.8	2,163.1	1.0	8.70	1	1	1
09/01/2024 02:00	1.6	11.7	2,180.6	1.0	8.70	1	1	1
09/01/2024 03:00	1.5	12.2	2,084.2	1.0	8.30	1	1	1
09/01/2024 04:00	1.4	12.6	1,991.1	1.0	8.00	1	1	1
09/01/2024 05:00	1.5	12.7	1,944.5	1.1	7.80	1	1	1
09/01/2024 06:00	3.2	15.6	627.0	3.6	2.05	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 10:00	0.3	18.6	165.4	0.8	0.10	1	0	0
09/01/2024 11:00	8.4	15.6	767.1	9.4	26.10	1	0	0
09/01/2024 12:00	0.9	13.7	1,432.9	0.7	4.30	1	1	0
09/01/2024 13:00	1.3	13.7	1,384.8	1.1	5.50	1	1	0
09/01/2024 14:00	1.3	13.6	1,642.0	1.1	6.60	1	1	0
09/01/2024 15:00	1.2	13.7	1,574.0	1.0	6.30	1	1	0
09/01/2024 16:00	1.3	13.5	1,725.5	1.0	6.90	1	1	0
09/01/2024 17:00	1.3	13.4	1,726.7	1.0	6.90	1	1	1
09/01/2024 18:00	1.6	11.7	2,154.3	1.0	8.60	1	1	1
09/01/2024 19:00	1.6	11.3	2,230.2	1.0	8.90	1	1	1
09/01/2024 20:00	1.5	11.5	2,214.8	0.9	6.60	1	1	1
09/01/2024 21:00	1.6	11.3	2,254.1	1.0	9.00	1	1	1
09/01/2024 22:00	1.5	11.7	2,189.0	1.0	8.80	1	1	1
09/01/2024 23:00	1.5	11.7	2,179.7	1.0	8.70	1	1	1
Average/Sum#:	1.8	13.0	1,752.6	1.5	165.55 #	21 #	18 #	13 #
Minimum:	0.3	11.3	165.4	0.7	0.10	0	0	0
Maximum:	8.4	18.6	2,254.1	9.4	26.10	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2024 00:00	1.6	11.8	2,162.3	1.0	8.60	1	1	1
09/02/2024 01:00	1.5	12.1	2,090.9	1.0	8.40	1	1	1
09/02/2024 02:00	1.4	12.8	1,953.2	1.0	7.80	1	1	1
09/02/2024 03:00	1.4	12.8	1,953.4	1.0	7.80	1	1	1
09/02/2024 04:00	1.4	12.8	1,950.9	1.0	7.80	1	1	1
09/02/2024 05:00	1.4	12.8	1,953.5	1.0	7.80	1	1	1
09/02/2024 06:00	1.4	12.8	1,933.6	1.0	7.70	1	1	1
09/02/2024 07:00	4.4	15.4	642.2	4.7	2.73	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 10:00	2.0	17.2	447.6	3.2	2.00	1	0	0
09/02/2024 11:00	6.1	14.2	1,188.1	5.4	23.80	1	0	0
09/02/2024 12:00	1.2	13.8	1,374.2	1.0	5.50	1	1	0
09/02/2024 13:00	1.3	13.8	1,379.9	1.1	5.50	1	1	0
09/02/2024 14:00	1.3	13.5	1,713.1	1.0	6.90	1	1	0
09/02/2024 15:00	1.2	13.7	1,533.5	1.0	6.10	1	1	0
09/02/2024 16:00	1.3	13.6	1,691.7	1.1	6.80	1	1	0
09/02/2024 17:00	1.4	12.8	1,822.3	1.0	7.30	1	1	1
09/02/2024 18:00	1.6	11.1	2,284.0	1.0	9.10	1	1	1
09/02/2024 19:00	1.6	11.0	2,295.7	1.0	9.20	1	1	1
09/02/2024 20:00	1.6	11.5	2,196.8	1.0	8.80	1	1	1
09/02/2024 21:00	1.4	12.4	2,001.0	1.0	8.00	1	1	1
09/02/2024 22:00	1.4	12.4	2,027.3	1.0	8.10	1	1	1
09/02/2024 23:00	1.4	12.6	1,992.1	1.0	8.00	1	1	1
Average/Sum#:	1.8	13.0	1,754.0	1.5	173.73 #	22 #	19 #	14 #
Minimum:	1.2	11.0	447.6	1.0	2.00	0	0	0
Maximum:	6.1	17.2	2,295.7	5.4	23.80	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2024 00:00	1.4	12.6	1,977.4	1.0	7.90	1	1	1
09/03/2024 01:00	1.4	12.6	1,982.5	1.0	7.90	1	1	1
09/03/2024 02:00	1.4	12.7	1,979.1	1.0	7.90	1	1	1
09/03/2024 03:00	1.4	12.7	1,977.6	1.0	7.90	1	1	1
09/03/2024 04:00	1.4	12.6	1,995.8	1.0	8.00	1	1	1
09/03/2024 05:00	1.3	11.6	2,148.7	0.8	6.40	1	1	1
09/03/2024 06:00	1.5	12.2	2,092.4	1.0	8.40	1	1	1
09/03/2024 07:00	1.4	12.7	1,974.6	1.0	7.90	1	1	1
09/03/2024 08:00	1.4	12.6	1,985.5	1.0	7.90	1	1	1
09/03/2024 09:00	1.4	12.5	1,999.6	1.0	8.00	1	1	1
09/03/2024 10:00	1.4	12.4	2,019.0	1.0	8.10	1	1	1
09/03/2024 11:00	1.5	12.3	2,032.2	1.0	8.10	1	1	1
09/03/2024 12:00	1.5	11.8	2,129.7	1.0	8.50	1	1	1
09/03/2024 13:00	1.6	11.4	2,228.3	1.0	8.90	1	1	1
09/03/2024 14:00	1.6	11.3	2,255.6	1.0	9.00	1	1	1
09/03/2024 15:00	1.6	11.2	2,250.1	1.0	9.00	1	1	1
09/03/2024 16:00	1.6	11.3	2,243.1	1.0	9.00	1	1	1
09/03/2024 17:00	1.6	11.1	2,283.5	1.0	9.10	1	1	1
09/03/2024 18:00	1.6	11.1	2,293.5	1.0	9.20	1	1	1
09/03/2024 19:00	1.6	11.1	2,301.5	1.0	9.20	1	1	1
09/03/2024 20:00	1.6	11.1	2,308.6	1.0	9.20	1	1	1
09/03/2024 21:00	1.6	11.1	2,311.8	1.0	9.20	1	1	1
09/03/2024 22:00	1.6	11.1	2,311.6	1.0	9.20	1	1	1
09/03/2024 23:00	1.5	11.7	2,161.6	1.0	8.60	1	1	1
Average/Sum#:	1.5	11.9	2,135.1	1.0	202.50 #	24 #	24 #	24 #
Minimum:	1.3	11.1	1,974.6	0.8	6.40	1	1	1
Maximum:	1.6	12.7	2,311.8	1.0	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2024 00:00	1.2	13.7	1,726.6	1.0	6.90	1	1	0
09/04/2024 01:00	1.3	13.7	1,737.4	1.1	6.90	1	1	0
09/04/2024 02:00	1.3	13.7	1,723.7	1.1	6.90	1	1	0
09/04/2024 03:00	1.3	13.7	1,740.4	1.1	7.00	1	1	0
09/04/2024 04:00	1.3	13.7	1,738.6	1.1	7.00	1	1	0
09/04/2024 05:00	1.3	13.7	1,714.3	1.1	6.90	1	1	0
09/04/2024 06:00	1.3	13.7	1,713.3	1.1	6.90	1	1	0
09/04/2024 07:00	1.3	13.7	1,744.3	1.1	7.00	1	1	0
09/04/2024 08:00	1.3	13.6	1,752.1	1.1	7.00	1	1	0
09/04/2024 09:00	1.3	13.6	1,750.7	1.1	7.00	1	1	0
09/04/2024 10:00	1.3	13.5	1,743.6	1.0	7.00	1	1	0
09/04/2024 11:00	1.3	13.5	1,752.2	1.0	7.00	1	1	0
09/04/2024 12:00	1.3	13.6	1,693.7	1.1	6.80	1	1	1
09/04/2024 13:00	1.6	11.5	2,177.8	1.0	8.70	1	1	1
09/04/2024 14:00	1.6	11.2	2,230.5	1.0	8.90	1	1	1
09/04/2024 15:00	1.6	11.5	2,154.3	1.0	8.60	1	1	1
09/04/2024 16:00	1.6	11.3	2,189.2	1.0	8.80	1	1	1
09/04/2024 17:00	1.6	11.4	2,191.0	1.0	8.80	1	1	1
09/04/2024 18:00	1.5	11.6	2,156.2	1.0	8.60	1	1	1
09/04/2024 19:00	1.6	11.0	2,268.0	1.0	9.10	1	1	1
09/04/2024 20:00	1.6	11.1	2,271.6	1.0	9.10	1	1	1
09/04/2024 21:00	1.6	11.2	2,251.1	1.0	9.00	1	1	1
09/04/2024 22:00	1.6	11.5	2,208.2	1.0	8.80	1	1	1
09/04/2024 23:00	1.6	11.4	2,239.6	1.0	9.00	1	1	1
Average/Sum#:	1.4	12.6	1,952.9	1.0	187.70 #	24 #	24 #	12 #
Minimum:	1.2	11.0	1,693.7	1.0	6.80	1	1	0
Maximum:	1.6	13.7	2,271.6	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2024 00:00	1.5	11.5	2,221.5	0.9	6.70	1	1	1
09/05/2024 01:00	1.6	11.5	2,218.0	1.0	8.90	1	1	1
09/05/2024 02:00	1.6	11.6	2,205.5	1.0	8.80	1	1	1
09/05/2024 03:00	1.5	12.3	2,042.1	1.0	8.20	1	1	1
09/05/2024 04:00	1.5	11.5	2,233.5	0.9	6.70	1	1	1
09/05/2024 05:00	0.0	11.1	2,316.0	0.0	0.00	1	1	1
09/05/2024 06:00	1.5	12.2	2,128.3	1.0	8.50	1	1	1
09/05/2024 07:00	1.2	13.7	1,729.6	1.0	6.90	1	1	0
09/05/2024 08:00	1.2	13.7	1,669.1	1.0	6.70	1	1	0
09/05/2024 09:00	1.3	13.6	1,737.2	1.1	6.90	1	1	0
09/05/2024 10:00	1.3	13.6	1,715.6	1.1	6.90	1	1	0
09/05/2024 11:00	1.3	13.5	1,736.7	1.0	6.90	1	1	0
09/05/2024 12:00	1.3	13.5	1,738.3	1.0	7.00	1	1	1
09/05/2024 13:00	1.6	11.6	2,150.9	1.0	8.60	1	1	1
09/05/2024 14:00	1.6	11.3	2,196.7	1.0	8.80	1	1	1
09/05/2024 15:00	1.6	11.3	2,191.2	1.0	8.80	1	1	1
09/05/2024 16:00	1.5	11.7	2,101.6	1.0	8.40	1	1	1
09/05/2024 17:00	1.6	11.5	2,151.6	1.0	8.60	1	1	1
09/05/2024 18:00	1.6	11.4	2,189.8	1.0	8.80	1	1	1
09/05/2024 19:00	1.5	11.4	2,193.3	0.9	6.60	1	1	1
09/05/2024 20:00	1.6	11.4	2,197.0	1.0	8.80	1	1	1
09/05/2024 21:00	1.6	11.2	2,246.8	1.0	9.00	1	1	1
09/05/2024 22:00	1.6	11.1	2,289.0	1.0	9.20	1	1	1
09/05/2024 23:00	1.6	11.5	2,211.9	1.0	8.80	1	1	1
Average/Sum#:	1.5	12.0	2,075.5	1.0	183.50 #	24 #	24 #	19 #
Minimum:	1.2	11.1	1,669.1	0.9	6.60	1	1	0
Maximum:	1.6	13.7	2,316.0	1.1	9.20	1	1	1
%SI	4.17	0.00	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2024 00:00	1.6	11.5	2,208.4	1.0	8.80	1	1	1
09/06/2024 01:00	1.5	11.7	2,166.0	1.0	8.70	1	1	1
09/06/2024 02:00	1.4	12.4	2,021.3	1.0	8.10	1	1	1
09/06/2024 03:00	1.6	11.6	2,200.9	1.0	8.80	1	1	1
09/06/2024 04:00	1.6	11.5	2,238.2	1.0	9.00	1	1	1
09/06/2024 05:00	1.6	11.3	2,291.4	1.0	9.20	1	1	1
09/06/2024 06:00	1.5	11.7	2,189.2	1.0	8.80	1	1	1
09/06/2024 07:00	1.5	11.8	2,157.3	1.0	8.60	1	1	1
09/06/2024 08:00	1.5	11.9	2,114.1	1.0	8.50	1	1	1
09/06/2024 09:00	1.4	12.4	2,002.4	1.0	8.00	1	1	1
09/06/2024 10:00	1.5	12.1	2,073.9	1.0	8.30	1	1	1
09/06/2024 11:00	1.5	11.6	2,152.3	1.0	8.60	1	1	1
09/06/2024 12:00	1.6	11.4	2,189.1	1.0	8.80	1	1	1
09/06/2024 13:00	1.6	11.4	2,180.4	1.0	8.70	1	1	1
09/06/2024 14:00	1.6	11.4	2,191.1	1.0	8.80	1	1	1
09/06/2024 15:00	1.6	11.3	2,192.5	1.0	8.80	1	1	1
09/06/2024 16:00	1.6	11.6	2,130.6	1.0	8.50	1	1	1
09/06/2024 17:00	1.6	11.4	2,178.2	1.0	8.70	1	1	1
09/06/2024 18:00	1.6	11.3	2,215.2	1.0	8.90	1	1	1
09/06/2024 19:00	1.6	11.3	2,220.8	1.0	8.90	1	1	1
09/06/2024 20:00	1.6	11.4	2,229.3	1.0	8.90	1	1	1
09/06/2024 21:00	1.6	11.3	2,253.0	1.0	9.00	1	1	1
09/06/2024 22:00	1.6	11.4	2,239.5	1.0	9.00	1	1	1
09/06/2024 23:00	1.6	11.1	2,305.0	1.0	9.20	1	1	1
Average/Sum#:	1.6	11.6	2,180.8	1.0	209.60 #	24 #	24 #	24 #
Minimum:	1.4	11.1	2,002.4	1.0	8.00	1	1	1
Maximum:	1.6	12.4	2,305.0	1.0	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2024 00:00	1.6	11.1	2,307.9	1.0	9.20	1	1	1
09/07/2024 01:00	1.6	11.2	2,294.4	1.0	9.20	1	1	1
09/07/2024 02:00	1.6	11.6	2,209.6	1.0	8.80	1	1	1
09/07/2024 03:00	1.5	11.6	2,204.2	1.0	8.80	1	1	1
09/07/2024 04:00	1.5	11.5	2,234.7	0.9	6.70	1	1	1
09/07/2024 05:00	1.5	11.7	2,195.3	1.0	8.80	1	1	1
09/07/2024 06:00	1.5	12.0	2,112.3	1.0	8.40	1	1	1
09/07/2024 07:00	1.4	12.6	1,983.7	1.0	7.90	1	1	1
09/07/2024 08:00	1.4	12.6	1,984.4	1.0	7.90	1	1	1
09/07/2024 09:00	1.4	12.5	2,002.1	1.0	8.00	1	1	1
09/07/2024 10:00	1.5	12.0	2,105.2	1.0	8.40	1	1	1
09/07/2024 11:00	1.5	12.0	2,082.0	1.0	8.30	1	1	1
09/07/2024 12:00	1.6	11.5	2,184.7	1.0	8.70	1	1	1
09/07/2024 13:00	1.6	11.2	2,238.2	1.0	9.00	1	1	1
09/07/2024 14:00	1.6	11.1	2,259.9	1.0	9.00	1	1	1
09/07/2024 15:00	1.6	11.1	2,266.9	1.0	9.10	1	1	1
09/07/2024 16:00	1.5	11.5	2,172.6	0.9	6.50	1	1	1
09/07/2024 17:00	1.6	11.0	2,276.8	1.0	9.10	1	1	1
09/07/2024 18:00	1.7	11.0	2,293.1	1.0	9.20	1	1	1
09/07/2024 19:00	1.6	11.1	2,303.0	1.0	9.20	1	1	1
09/07/2024 20:00	1.6	11.1	2,309.0	1.0	9.20	1	1	1
09/07/2024 21:00	1.6	11.2	2,296.4	1.0	9.20	1	1	1
09/07/2024 22:00	1.6	11.7	2,202.6	1.0	8.80	1	1	1
09/07/2024 23:00	1.6	11.3	2,293.7	1.0	9.20	1	1	1
Average/Sum#:	1.6	11.6	2,200.5	1.0	206.60 #	24 #	24 #	24 #
Minimum:	1.4	11.0	1,983.7	0.9	6.50	1	1	1
Maximum:	1.7	12.6	2,309.0	1.0	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2024 00:00	1.5	11.9	2,157.7	1.0	8.60	1	1	1
09/08/2024 01:00	1.4	12.5	2,009.7	1.0	8.00	1	1	1
09/08/2024 02:00	1.5	11.9	2,175.8	1.0	8.70	1	1	1
09/08/2024 03:00	1.5	11.8	2,188.8	1.0	8.80	1	1	1
09/08/2024 04:00	1.4	12.5	2,027.2	1.0	8.10	1	1	1
09/08/2024 05:00	1.2	13.6	1,744.4	1.0	7.00	1	1	1
09/08/2024 06:00	1.3	13.7	1,665.7	1.1	6.70	1	1	0
09/08/2024 07:00	1.3	13.7	1,652.8	1.1	6.60	1	1	0
09/08/2024 08:00	1.3	13.7	1,622.6	1.1	6.50	1	1	0
09/08/2024 09:00	1.3	13.7	1,548.1	1.1	6.20	1	1	0
09/08/2024 10:00	1.2	13.8	1,540.0	1.0	6.20	1	1	0
09/08/2024 11:00	1.3	13.8	1,555.6	1.1	6.20	1	1	0
09/08/2024 12:00	1.2	13.7	1,644.1	1.0	6.60	1	1	0
09/08/2024 13:00	1.3	13.6	1,677.8	1.1	6.70	1	1	0
09/08/2024 14:00	1.4	12.8	1,840.0	1.0	7.40	1	1	1
09/08/2024 15:00	1.6	11.3	2,232.9	1.0	8.90	1	1	1
09/08/2024 16:00	1.5	11.7	2,138.0	1.0	8.60	1	1	1
09/08/2024 17:00	1.6	11.2	2,241.9	1.0	9.00	1	1	1
09/08/2024 18:00	1.6	11.2	2,259.7	1.0	9.00	1	1	1
09/08/2024 19:00	1.6	11.1	2,290.4	1.0	9.20	1	1	1
09/08/2024 20:00	1.6	11.1	2,292.3	1.0	9.20	1	1	1
09/08/2024 21:00	1.6	11.2	2,278.4	1.0	9.10	1	1	1
09/08/2024 22:00	1.6	11.4	2,222.3	1.0	8.90	1	1	1
09/08/2024 23:00	1.5	11.6	2,207.9	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.4	1,967.3	1.0	189.00 #	24 #	24 #	16 #
Minimum:	1.2	11.1	1,540.0	1.0	6.20	1	1	0
Maximum:	1.6	13.8	2,292.3	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2024 00:00	1.6	11.7	2,204.1	1.0	8.80	1	1	1
09/09/2024 01:00	1.4	12.2	2,074.2	0.9	6.20	1	1	1
09/09/2024 02:00	1.5	11.8	2,180.9	1.0	8.70	1	1	1
09/09/2024 03:00	1.6	11.6	2,202.7	1.0	8.80	1	1	1
09/09/2024 04:00	1.6	11.6	2,209.2	1.0	8.80	1	1	1
09/09/2024 05:00	1.7	11.2	2,284.3	1.0	9.10	1	1	1
09/09/2024 06:00	1.5	12.2	2,099.7	1.0	8.40	1	1	1
09/09/2024 07:00	1.4	12.7	1,982.1	1.0	7.90	1	1	1
09/09/2024 08:00	1.4	12.6	1,987.9	1.0	8.00	1	1	1
09/09/2024 09:00	1.5	11.8	2,159.4	1.0	8.60	1	1	1
09/09/2024 10:00	1.5	11.6	2,139.1	1.0	8.60	1	1	1
09/09/2024 11:00	1.5	11.8	2,094.6	1.0	8.40	1	1	1
09/09/2024 12:00	1.5	11.8	2,087.8	1.0	8.40	1	1	1
09/09/2024 13:00	1.5	11.7	2,092.1	1.0	8.40	1	1	1
09/09/2024 14:00	1.5	12.0	2,031.7	1.0	8.10	1	1	1
09/09/2024 15:00	1.5	11.6	2,094.1	1.0	8.40	1	1	1
09/09/2024 16:00	1.6	11.1	2,192.6	1.0	8.80	1	1	1
09/09/2024 17:00	1.6	11.3	2,154.1	1.0	8.60	1	1	1
09/09/2024 18:00	1.6	11.2	2,195.1	1.0	8.80	1	1	1
09/09/2024 19:00	1.6	11.3	2,180.1	1.0	8.70	1	1	1
09/09/2024 20:00	1.5	11.8	2,114.9	1.0	8.50	1	1	1
09/09/2024 21:00	1.5	11.8	2,104.3	1.0	8.40	1	1	1
09/09/2024 22:00	1.4	12.4	1,988.0	1.0	8.00	1	1	1
09/09/2024 23:00	1.5	11.6	2,172.5	1.0	8.70	1	1	1
Average/Sum#:	1.5	11.8	2,126.1	1.0	202.10 #	24 #	24 #	24 #
Minimum:	1.4	11.1	1,982.1	0.9	6.20	1	1	1
Maximum:	1.7	12.7	2,284.3	1.0	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2024 00:00	1.5	11.7	2,162.0	1.0	8.60	1	1	1
09/10/2024 01:00	1.5	12.3	2,029.7	1.0	8.10	1	1	1
09/10/2024 02:00	1.5	12.4	1,988.9	1.0	8.00	1	1	1
09/10/2024 03:00	1.5	12.3	2,023.3	1.0	8.10	1	1	1
09/10/2024 04:00	1.5	12.1	2,076.4	1.0	8.30	1	1	1
09/10/2024 05:00	1.5	11.3	2,204.5	0.9	6.60	1	1	1
09/10/2024 06:00	1.5	12.2	2,025.0	1.0	8.10	1	1	1
09/10/2024 07:00	1.2	13.7	1,553.1	1.0	6.20	1	1	0
09/10/2024 08:00	1.2	13.7	1,295.1	1.0	5.20	1	1	0
09/10/2024 09:00	1.3	13.8	1,297.4	1.1	5.20	1	1	0
09/10/2024 10:00	1.3	13.8	1,302.0	1.1	5.20	1	1	0
09/10/2024 11:00	1.3	13.8	1,299.3	1.1	5.20	1	1	0
09/10/2024 12:00	1.3	13.8	1,308.1	1.1	5.20	1	1	0
09/10/2024 13:00	1.2	13.7	1,393.8	1.0	5.60	1	1	0
09/10/2024 14:00	1.3	13.8	1,305.5	1.1	5.20	1	1	0
09/10/2024 15:00	1.2	13.8	1,322.2	1.0	5.30	1	1	0
09/10/2024 16:00	1.3	13.6	1,555.1	1.1	6.20	1	1	1
09/10/2024 17:00	1.5	12.2	1,991.1	1.0	8.00	1	1	1
09/10/2024 18:00	1.5	12.2	1,983.6	1.0	7.90	1	1	1
09/10/2024 19:00	1.4	12.4	1,967.0	1.0	7.90	1	1	1
09/10/2024 20:00	1.4	12.5	1,957.5	1.0	7.80	1	1	1
09/10/2024 21:00	1.4	12.6	1,947.8	1.0	7.80	1	1	1
09/10/2024 22:00	1.4	12.6	1,927.4	1.0	7.70	1	1	1
09/10/2024 23:00	3.8	15.4	642.6	4.1	2.40	1	0	0
Average/Sum#:	1.5	13.0	1,689.9	1.2	159.80 #	24 #	23 #	14 #
Minimum:	1.2	11.3	642.6	0.9	2.40	1	0	0
Maximum:	3.8	15.4	2,204.5	4.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 17:00	36.0	17.3	323.0	59.0	49.07	1	0	0
09/12/2024 18:00	17.0	16.9	400.6	25.1	36.90	1	0	0
09/12/2024 19:00	15.1	15.2	846.1	15.6	49.10	1	0	0
09/12/2024 20:00	1.1	13.8	1,587.1	0.9	4.80	1	1	0
09/12/2024 21:00	1.2	13.7	1,644.1	1.0	6.60	1	1	0
09/12/2024 22:00	1.2	13.6	1,687.5	1.0	6.80	1	1	0
09/12/2024 23:00	1.3	13.6	1,731.7	1.1	6.90	1	1	0
Average/Sum#:	10.4	14.9	1,174.3	14.8	160.17 #	7 #	4 #	0 #
Minimum:	1.1	13.6	323.0	0.9	4.80	0	0	0
Maximum:	36.0	17.3	1,731.7	59.0	49.10	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2024 00:00	1.3	13.6	1,723.4	1.1	6.90	1	1	0
09/13/2024 01:00	1.3	13.7	1,536.6	1.1	6.10	1	1	0
09/13/2024 02:00	1.3	13.7	1,534.9	1.1	6.10	1	1	0
09/13/2024 03:00	1.3	13.7	1,650.7	1.1	6.60	1	1	0
09/13/2024 04:00	1.3	13.7	1,725.8	1.1	6.90	1	1	0
09/13/2024 05:00	1.2	13.7	1,724.2	1.0	6.90	1	1	0
09/13/2024 06:00	1.2	13.6	1,589.8	1.0	6.40	1	1	0
09/13/2024 07:00	2.3	14.4	1,204.6	2.1	7.01	1	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 13:00	24.2	17.5	322.3	42.0	24.00	1	0	0
09/13/2024 14:00	11.5	15.4	858.0	12.3	38.60	1	0	0
09/13/2024 15:00	1.3	13.4	1,675.4	1.0	6.70	1	1	1
09/13/2024 16:00	1.6	11.4	2,149.0	1.0	8.60	1	1	1
09/13/2024 17:00	1.7	11.3	2,168.2	1.0	8.70	1	1	1
09/13/2024 18:00	1.3	13.3	1,726.8	1.0	6.90	1	1	1
09/13/2024 19:00	1.2	13.6	1,548.3	1.0	6.20	1	1	0
09/13/2024 20:00	1.2	13.6	1,672.5	1.0	6.70	1	1	0
09/13/2024 21:00	1.3	13.5	1,698.4	1.0	6.80	1	1	0
09/13/2024 22:00	1.3	13.6	1,690.6	1.1	6.80	1	1	0
09/13/2024 23:00	1.3	13.7	1,689.3	1.1	6.80	1	1	0
Average/Sum#:	3.1	13.7	1,573.1	3.8	179.71 #	19 #	16 #	4 #
Minimum:	1.2	11.3	322.3	1.0	6.10	0	0	0
Maximum:	24.2	17.5	2,168.2	42.0	38.60	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2024 00:00	1.3	13.7	1,689.0	1.1	6.80	1	1	0
09/14/2024 01:00	1.3	13.5	1,756.5	1.0	7.00	1	1	0
09/14/2024 02:00	1.9	14.0	1,417.7	1.6	7.91	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 16:00	24.3	16.6	464.7	33.3	51.48	1	0	0
09/14/2024 17:00	10.0	15.1	719.7	10.2	26.60	1	0	0
09/14/2024 18:00	6.2	14.2	1,229.4	5.5	24.60	1	0	0
09/14/2024 19:00	1.3	13.6	1,582.9	1.1	6.30	1	1	0
09/14/2024 20:00	1.3	13.7	1,536.3	1.1	6.10	1	1	0
09/14/2024 21:00	1.2	13.7	1,537.9	1.0	6.20	1	1	0
09/14/2024 22:00	1.3	13.6	1,571.5	1.1	6.30	1	1	0
09/14/2024 23:00	1.2	13.6	1,703.1	1.0	6.80	1	1	0
Average/Sum#:	4.7	14.1	1,382.6	5.3	156.09 #	11 #	7 #	0 #
Minimum:	1.2	13.5	464.7	1.0	6.10	0	0	0
Maximum:	24.3	16.6	1,756.5	33.3	51.48	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2024 00:00	1.3	13.7	1,689.9	1.1	6.80	1	1	0
09/15/2024 01:00	2.6	15.3	659.9	2.7	1.78	1	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 17:00	28.2	17.3	343.0	46.2	41.98	1	0	0
09/15/2024 18:00	16.5	15.6	672.5	18.4	45.70	1	0	0
09/15/2024 19:00	11.9	14.5	1,114.5	11.0	44.60	1	0	0
09/15/2024 20:00	1.3	13.7	1,540.3	1.1	6.20	1	1	0
09/15/2024 21:00	1.3	13.7	1,449.5	1.1	5.80	1	1	0
09/15/2024 22:00	1.2	13.7	1,471.5	1.0	5.90	1	1	0
09/15/2024 23:00	1.3	13.7	1,514.7	1.1	6.10	1	1	0
Average/Sum#:	7.3	14.6	1,161.8	9.3	164.86 #	9 #	5 #	0 #
Minimum:	1.2	13.7	343.0	1.0	1.78	0	0	0
Maximum:	28.2	17.3	1,689.9	46.2	45.70	1	1	0
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2024 00:00	1.3	13.7	1,655.4	1.1	6.60	1	1	0
09/16/2024 01:00	1.3	13.7	1,515.8	1.1	6.10	1	1	0
09/16/2024 02:00	1.3	13.7	1,481.7	1.1	5.90	1	1	0
09/16/2024 03:00	1.3	13.7	1,624.2	1.1	6.50	1	1	0
09/16/2024 04:00	1.3	13.6	1,724.1	1.1	6.90	1	1	0
09/16/2024 05:00	1.2	13.6	1,719.4	1.0	6.90	1	1	0
09/16/2024 06:00	1.3	13.7	1,677.1	1.1	6.70	1	1	0
09/16/2024 07:00	1.8	14.3	1,264.4	1.6	5.55	1	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.8	1,582.8	1.2	51.15 #	8 #	7 #	0 #
Minimum:	1.2	13.6	1,264.4	1.0	5.55	0	0	0
Maximum:	1.8	14.3	1,724.1	1.6	6.90	1	1	0
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 20:00	29.8	17.3	329.3	48.8	54.56	1	0	0
09/17/2024 21:00	8.3	16.9	398.0	12.2	17.90	1	0	0
09/17/2024 22:00	10.1	15.5	857.8	11.0	35.20	1	0	0
09/17/2024 23:00	1.3	13.6	1,661.2	1.1	6.60	1	1	0
Average/Sum#:	12.4	15.8	811.6	18.3	114.26 #	4 #	1 #	0 #
Minimum:	1.3	13.6	329.3	1.1	6.60	0	0	0
Maximum:	29.8	17.3	1,661.2	48.8	54.56	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2024 00:00	1.3	13.7	1,573.6	1.1	6.30	1	1	0
09/18/2024 01:00	1.3	13.5	1,717.9	1.0	6.90	1	1	0
09/18/2024 02:00	1.2	13.6	1,505.0	1.0	6.00	1	1	0
09/18/2024 03:00	1.3	13.7	1,489.6	1.1	6.00	1	1	0
09/18/2024 04:00	1.3	13.5	1,689.8	1.0	6.80	1	1	1
09/18/2024 05:00	1.7	11.9	2,054.3	1.1	8.20	1	1	1
09/18/2024 06:00	1.5	11.9	2,093.4	1.0	8.40	1	1	1
09/18/2024 07:00	1.4	12.6	1,956.2	1.0	7.80	1	1	1
09/18/2024 08:00	1.4	12.7	1,920.3	1.0	7.70	1	1	1
09/18/2024 09:00	1.4	12.7	1,932.4	1.0	7.70	1	1	1
09/18/2024 10:00	1.4	12.6	1,937.4	1.0	7.70	1	1	1
09/18/2024 11:00	1.4	12.6	1,943.4	1.0	7.80	1	1	1
09/18/2024 12:00	1.4	12.6	1,945.2	1.0	7.80	1	1	1
09/18/2024 13:00	1.4	12.5	1,955.5	1.0	7.80	1	1	1
09/18/2024 14:00	1.4	12.5	1,960.3	1.0	7.80	1	1	1
09/18/2024 15:00	1.4	12.5	1,949.4	1.0	7.80	1	1	1
09/18/2024 16:00	1.5	11.9	2,078.4	1.0	8.30	1	1	1
09/18/2024 17:00	1.6	11.3	2,191.0	1.0	8.80	1	1	1
09/18/2024 18:00	1.6	11.6	2,119.5	1.0	8.50	1	1	1
09/18/2024 19:00	1.5	11.6	2,136.9	1.0	8.50	1	1	1
09/18/2024 20:00	1.5	11.7	2,122.5	1.0	8.50	1	1	1
09/18/2024 21:00	1.6	11.7	2,123.6	1.0	8.50	1	1	1
09/18/2024 22:00	1.5	11.7	2,120.4	1.0	8.50	1	1	1
09/18/2024 23:00	1.5	11.7	2,122.1	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.4	1,943.3	1.0	186.60 #	24 #	24 #	20 #
Minimum:	1.2	11.3	1,489.6	1.0	6.00	1	1	0
Maximum:	1.7	13.7	2,191.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2024 00:00	1.6	11.7	2,123.7	1.0	8.50	1	1	1
09/19/2024 01:00	1.6	11.7	2,122.0	1.0	8.50	1	1	1
09/19/2024 02:00	1.5	11.7	2,124.9	1.0	8.50	1	1	1
09/19/2024 03:00	1.5	11.7	2,128.0	1.0	8.50	1	1	1
09/19/2024 04:00	1.5	11.7	2,126.6	1.0	8.50	1	1	1
09/19/2024 05:00	1.3	11.8	2,124.7	0.8	6.40	1	1	1
09/19/2024 06:00	1.5	12.0	2,027.8	1.0	8.10	1	1	1
09/19/2024 07:00	4.4	15.4	639.2	4.7	2.73	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	12.2	1,927.1	1.4	59.73 #	8 #	7 #	7 #
Minimum:	1.3	11.7	639.2	0.8	2.73	0	0	0
Maximum:	4.4	15.4	2,128.0	4.7	8.50	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 14:00	39.1	17.3	321.5	64.1	59.20	1	0	0
09/22/2024 15:00	13.9	14.8	945.5	13.4	47.30	1	0	0
09/22/2024 16:00	1.1	13.7	1,497.0	0.9	4.50	1	1	0
09/22/2024 17:00	1.3	13.7	1,614.5	1.1	6.50	1	1	1
09/22/2024 18:00	1.5	12.4	1,951.4	1.0	7.80	1	1	1
09/22/2024 19:00	1.4	12.3	1,964.3	1.0	7.90	1	1	1
09/22/2024 20:00	1.4	12.4	1,944.1	1.0	7.80	1	1	1
09/22/2024 21:00	1.4	12.4	1,940.1	1.0	7.80	1	1	1
09/22/2024 22:00	1.4	12.7	1,921.9	1.0	7.70	1	1	1
09/22/2024 23:00	1.4	12.7	1,922.9	1.0	7.70	1	1	1
Average/Sum#:	6.4	13.4	1,602.3	8.6	164.20 #	10 #	8 #	7 #
Minimum:	1.1	12.3	321.5	0.9	4.50	0	0	0
Maximum:	39.1	17.3	1,964.3	64.1	59.20	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2024 00:00	1.4	12.7	1,919.4	1.0	7.70	1	1	1
09/23/2024 01:00	1.4	12.7	1,916.3	1.0	7.70	1	1	1
09/23/2024 02:00	1.4	12.7	1,916.7	1.0	7.70	1	1	1
09/23/2024 03:00	1.4	12.7	1,917.8	1.0	7.70	1	1	1
09/23/2024 04:00	1.4	12.6	1,920.8	1.0	7.70	1	1	1
09/23/2024 05:00	1.5	12.6	1,909.0	1.1	7.60	1	1	1
09/23/2024 06:00	1.2	13.7	1,630.4	1.0	6.50	1	1	0
09/23/2024 07:00	1.3	13.7	1,570.3	1.1	6.30	1	1	0
09/23/2024 08:00	1.2	13.7	1,647.3	1.0	6.60	1	1	0
09/23/2024 09:00	1.3	13.7	1,511.8	1.1	6.00	1	1	0
09/23/2024 10:00	1.3	13.7	1,521.2	1.1	6.10	1	1	0
09/23/2024 11:00	1.3	13.6	1,652.4	1.1	6.60	1	1	0
09/23/2024 12:00	1.3	13.5	1,695.3	1.0	6.80	1	1	0
09/23/2024 13:00	1.3	13.5	1,694.3	1.0	6.80	1	1	1
09/23/2024 14:00	1.6	11.6	2,114.5	1.0	8.50	1	1	1
09/23/2024 15:00	1.6	11.2	2,182.0	1.0	8.70	1	1	1
09/23/2024 16:00	1.6	11.1	2,202.7	1.0	8.80	1	1	1
09/23/2024 17:00	1.7	11.0	2,210.5	1.0	8.80	1	1	1
09/23/2024 18:00	1.6	11.0	2,211.2	1.0	8.80	1	1	1
09/23/2024 19:00	1.6	11.0	2,218.2	1.0	8.90	1	1	1
09/23/2024 20:00	1.6	11.0	2,221.6	1.0	8.90	1	1	1
09/23/2024 21:00	1.6	11.1	2,228.1	1.0	8.90	1	1	1
09/23/2024 22:00	1.6	11.2	2,208.1	1.0	8.80	1	1	1
09/23/2024 23:00	1.5	12.0	2,043.0	1.0	8.20	1	1	1
Average/Sum#:	1.4	12.4	1,927.6	1.0	185.10 #	24 #	24 #	17 #
Minimum:	1.2	11.0	1,511.8	1.0	6.00	1	1	0
Maximum:	1.7	13.7	2,228.1	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2024 00:00	1.2	13.6	1,693.6	1.0	6.80	1	1	1
09/24/2024 01:00	1.3	13.7	1,677.3	1.1	6.70	1	1	0
09/24/2024 02:00	1.3	13.7	1,640.8	1.1	6.60	1	1	0
09/24/2024 03:00	1.3	13.7	1,676.6	1.1	6.70	1	1	0
09/24/2024 04:00	1.3	13.7	1,686.2	1.1	6.70	1	1	0
09/24/2024 05:00	1.3	13.7	1,675.9	1.1	6.70	1	1	0
09/24/2024 06:00	1.3	13.7	1,636.9	1.1	6.50	1	1	0
09/24/2024 07:00	1.3	13.7	1,583.5	1.1	6.30	1	1	0
09/24/2024 08:00	1.3	13.7	1,509.7	1.1	6.00	1	1	0
09/24/2024 09:00	1.3	13.7	1,531.0	1.1	6.10	1	1	0
09/24/2024 10:00	1.3	13.7	1,563.2	1.1	6.30	1	1	0
09/24/2024 11:00	1.3	13.6	1,654.1	1.1	6.60	1	1	0
09/24/2024 12:00	1.3	13.7	1,390.3	1.1	5.60	1	1	0
09/24/2024 13:00	1.4	12.4	1,847.2	1.0	7.40	1	1	1
09/24/2024 14:00	1.6	11.2	2,155.9	1.0	8.60	1	1	1
09/24/2024 15:00	1.6	11.3	2,131.1	1.0	8.50	1	1	1
09/24/2024 16:00	1.6	11.1	2,170.7	1.0	8.70	1	1	1
09/24/2024 17:00	1.6	11.0	2,198.7	1.0	8.80	1	1	1
09/24/2024 18:00	1.6	11.1	2,174.2	1.0	8.70	1	1	1
09/24/2024 19:00	1.6	11.6	2,088.4	1.0	8.40	1	1	1
09/24/2024 20:00	1.6	11.4	2,145.6	1.0	8.60	1	1	1
09/24/2024 21:00	1.5	11.7	2,067.3	1.0	8.30	1	1	1
09/24/2024 22:00	1.5	12.0	2,017.7	1.0	8.10	1	1	1
09/24/2024 23:00	1.6	11.5	2,143.0	1.0	8.60	1	1	1
Average/Sum#:	1.4	12.7	1,835.8	1.1	176.30 #	24 #	24 #	12 #
Minimum:	1.2	11.0	1,390.3	1.0	5.60	1	1	0
Maximum:	1.6	13.7	2,198.7	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2024 00:00	1.6	11.6	2,132.8	1.0	8.50	1	1	1
09/25/2024 01:00	1.5	11.7	2,100.1	1.0	8.40	1	1	1
09/25/2024 02:00	1.5	12.0	2,038.9	1.0	8.20	1	1	1
09/25/2024 03:00	1.5	11.8	2,096.4	1.0	8.40	1	1	1
09/25/2024 04:00	1.6	11.7	2,109.2	1.0	8.40	1	1	1
09/25/2024 05:00	1.5	11.7	2,106.7	1.0	8.40	1	1	1
09/25/2024 06:00	1.5	12.1	2,020.6	1.0	8.10	1	1	1
09/25/2024 07:00	3.9	15.3	682.9	4.1	2.75	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 14:00	7.9	18.1	245.0	16.6	4.02	1	0	0
09/25/2024 15:00	9.5	15.5	790.2	10.4	30.00	1	0	0
09/25/2024 16:00	1.1	13.7	1,422.7	0.9	4.30	1	1	0
09/25/2024 17:00	1.3	13.6	1,630.4	1.1	6.50	1	1	0
09/25/2024 18:00	1.3	13.5	1,651.5	1.0	6.60	1	1	0
09/25/2024 19:00	1.2	13.6	1,578.2	1.0	6.30	1	1	0
09/25/2024 20:00	1.3	13.7	1,496.2	1.1	6.00	1	1	0
09/25/2024 21:00	1.2	13.7	1,618.3	1.0	6.50	1	1	0
09/25/2024 22:00	1.3	13.7	1,401.1	1.1	5.60	1	1	0
09/25/2024 23:00	1.3	13.7	1,664.5	1.1	6.70	1	1	0
Average/Sum#:	2.3	13.4	1,599.2	2.6	143.67 #	18 #	15 #	7 #
Minimum:	1.1	11.6	245.0	0.9	2.75	0	0	0
Maximum:	9.5	18.1	2,132.8	16.6	30.00	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2024 00:00	1.3	13.7	1,685.2	1.1	6.70	1	1	0
09/26/2024 01:00	1.3	13.7	1,656.0	1.1	6.60	1	1	0
09/26/2024 02:00	1.3	13.7	1,628.6	1.1	6.50	1	1	0
09/26/2024 03:00	1.3	13.7	1,664.7	1.1	6.70	1	1	0
09/26/2024 04:00	1.3	13.7	1,687.6	1.1	6.80	1	1	0
09/26/2024 05:00	1.2	13.7	1,686.8	1.0	6.70	1	1	0
09/26/2024 06:00	1.3	13.7	1,630.2	1.1	6.50	1	1	0
09/26/2024 07:00	1.2	13.7	1,385.4	1.0	5.50	1	1	0
09/26/2024 08:00	4.9	15.6	566.6	5.5	2.60	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 14:00	7.3	17.6	315.4	13.1	7.25	1	0	0
09/26/2024 15:00	11.4	15.2	907.7	11.8	39.00	1	0	0
09/26/2024 16:00	1.3	13.5	1,697.3	1.0	6.80	1	1	0
09/26/2024 17:00	1.4	13.0	1,762.1	1.0	7.00	1	1	1
09/26/2024 18:00	1.6	11.7	2,092.8	1.0	8.40	1	1	1
09/26/2024 19:00	1.5	11.8	2,072.6	1.0	8.30	1	1	1
09/26/2024 20:00	1.6	12.1	2,015.7	1.1	8.10	1	1	1
09/26/2024 21:00	1.6	11.1	2,228.0	1.0	8.90	1	1	1
09/26/2024 22:00	1.6	11.5	2,145.2	1.0	8.60	1	1	1
09/26/2024 23:00	1.5	12.3	1,991.8	1.0	8.00	1	1	1
Average/Sum#:	2.4	13.4	1,622.1	2.5	164.95 #	19 #	16 #	7 #
Minimum:	1.2	11.1	315.4	1.0	2.60	0	0	0
Maximum:	11.4	17.6	2,228.0	13.1	39.00	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2024 00:00	1.5	12.7	1,906.1	1.1	7.60	1	1	1
09/27/2024 01:00	2.2	15.3	672.3	2.3	1.65	1	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 09:00	28.1	17.5	318.4	48.8	32.66	1	0	0
09/27/2024 10:00	14.5	15.4	834.1	15.6	47.50	1	0	0
09/27/2024 11:00	1.1	13.8	1,353.5	0.9	4.10	1	1	0
09/27/2024 12:00	1.3	13.8	1,339.5	1.1	5.40	1	1	0
09/27/2024 13:00	1.2	13.6	1,601.2	1.0	6.40	1	1	0
09/27/2024 14:00	1.1	13.7	1,435.7	0.9	4.30	1	1	0
09/27/2024 15:00	1.1	13.8	1,443.7	0.9	4.30	1	1	0
09/27/2024 16:00	1.2	13.7	1,527.4	1.0	6.10	1	1	1
09/27/2024 17:00	1.6	11.5	2,114.6	1.0	8.50	1	1	1
09/27/2024 18:00	1.6	11.0	2,217.0	1.0	8.90	1	1	1
09/27/2024 19:00	1.6	11.0	2,217.5	1.0	8.90	1	1	1
09/27/2024 20:00	1.6	11.0	2,226.3	1.0	8.90	1	1	1
09/27/2024 21:00	1.6	11.2	2,213.4	1.0	8.90	1	1	1
09/27/2024 22:00	1.5	11.6	2,132.3	1.0	8.50	1	1	1
09/27/2024 23:00	1.6	11.6	2,132.5	1.0	8.50	1	1	1
Average/Sum#:	3.8	13.1	1,628.6	4.7	181.11 #	17 #	14 #	9 #
Minimum:	1.1	11.0	318.4	0.9	1.65	0	0	0
Maximum:	28.1	17.5	2,226.3	48.8	47.50	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2024 00:00	1.6	11.6	2,133.3	1.0	8.50	1	1	1
09/28/2024 01:00	1.5	11.6	2,132.3	1.0	8.50	1	1	1
09/28/2024 02:00	1.5	11.6	2,129.4	1.0	8.50	1	1	1
09/28/2024 03:00	1.6	11.6	2,127.1	1.0	8.50	1	1	1
09/28/2024 04:00	1.5	11.7	2,126.7	1.0	8.50	1	1	1
09/28/2024 05:00	1.7	11.7	2,126.5	1.1	8.50	1	1	1
09/28/2024 06:00	1.5	12.1	2,012.4	1.0	8.00	1	1	1
09/28/2024 07:00	6.5	15.4	629.3	7.0	4.10	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 15:00	15.8	16.2	654.0	19.8	47.70	1	0	0
09/28/2024 16:00	1.1	13.7	1,466.0	0.9	4.40	1	1	0
09/28/2024 17:00	1.3	13.7	1,491.6	1.1	6.00	1	1	0
09/28/2024 18:00	1.3	13.6	1,656.0	1.1	6.60	1	1	0
09/28/2024 19:00	1.3	13.5	1,689.8	1.0	6.80	1	1	0
09/28/2024 20:00	1.3	13.6	1,690.3	1.1	6.80	1	1	0
09/28/2024 21:00	1.3	13.6	1,689.9	1.1	6.80	1	1	0
09/28/2024 22:00	1.3	13.7	1,558.4	1.1	6.20	1	1	0
09/28/2024 23:00	1.3	13.6	1,693.7	1.1	6.80	1	1	0
Average/Sum#:	2.6	13.1	1,706.3	2.5	161.20 #	17 #	15 #	7 #
Minimum:	1.1	11.6	629.3	0.9	4.10	0	0	0
Maximum:	15.8	16.2	2,133.3	19.8	47.70	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2024 00:00	1.3	13.7	1,488.4	1.1	6.00	1	1	0
09/29/2024 01:00	1.3	13.7	1,494.5	1.1	6.00	1	1	0
09/29/2024 02:00	3.4	15.5	618.7	3.7	2.35	1	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 10:00	26.6	17.7	307.4	49.0	25.02	1	0	0
09/29/2024 11:00	16.9	15.4	832.1	18.1	55.80	1	0	0
09/29/2024 12:00	1.1	13.8	1,385.5	0.9	4.20	1	1	0
09/29/2024 13:00	1.3	13.8	1,351.1	1.1	5.40	1	1	0
09/29/2024 14:00	1.3	13.6	1,606.2	1.1	6.40	1	1	0
09/29/2024 15:00	0.9	13.8	1,362.9	0.7	4.10	1	1	0
09/29/2024 16:00	1.2	13.7	1,578.4	1.0	6.30	1	1	0
09/29/2024 17:00	1.3	13.4	1,715.9	1.0	6.90	1	1	1
09/29/2024 18:00	1.5	12.2	1,999.9	1.0	8.00	1	1	1
09/29/2024 19:00	1.6	11.4	2,173.1	1.0	8.70	1	1	1
09/29/2024 20:00	1.6	11.5	2,167.2	1.0	8.70	1	1	1
09/29/2024 21:00	1.5	11.9	2,091.1	1.0	8.40	1	1	1
09/29/2024 22:00	1.4	12.6	1,954.5	1.0	7.80	1	1	1
09/29/2024 23:00	1.6	11.7	2,143.8	1.0	8.60	1	1	1
Average/Sum#:	3.9	13.5	1,545.3	5.0	178.67 #	17 #	14 #	7 #
Minimum:	0.9	11.4	307.4	0.7	2.35	0	0	0
Maximum:	26.6	17.7	2,173.1	49.0	55.80	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:29 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2024 00:00	1.5	12.1	2,061.7	1.0	8.20	1	1	1
09/30/2024 01:00	1.4	12.6	1,943.4	1.0	7.80	1	1	1
09/30/2024 02:00	1.4	12.6	1,946.4	1.0	7.80	1	1	1
09/30/2024 03:00	1.4	12.5	1,996.6	1.0	8.00	1	1	1
09/30/2024 04:00	1.5	12.1	2,076.2	1.0	8.30	1	1	1
09/30/2024 05:00	1.4	11.8	2,141.6	0.9	6.40	1	1	1
09/30/2024 06:00	1.5	11.8	2,183.1	1.0	8.70	1	1	1
09/30/2024 07:00	1.3	12.9	1,875.0	1.0	7.50	1	1	1
09/30/2024 08:00	1.2	13.9	1,322.6	1.0	5.30	1	1	0
09/30/2024 09:00	1.3	13.9	1,317.5	1.1	5.30	1	1	0
09/30/2024 10:00	1.3	13.9	1,318.6	1.1	5.30	1	1	0
09/30/2024 11:00	1.2	13.9	1,434.4	1.0	5.70	1	1	0
09/30/2024 12:00	1.2	13.9	1,573.6	1.0	6.30	1	1	0
09/30/2024 13:00	1.2	13.7	1,683.3	1.0	6.70	1	1	1
09/30/2024 14:00	1.6	11.8	2,144.2	1.0	8.60	1	1	1
09/30/2024 15:00	1.6	11.8	2,144.9	1.0	8.60	1	1	1
09/30/2024 16:00	1.6	11.1	2,280.0	1.0	9.10	1	1	1
09/30/2024 17:00	1.6	11.1	2,293.4	1.0	9.20	1	1	1
09/30/2024 18:00	1.6	11.1	2,300.0	1.0	9.20	1	1	1
09/30/2024 19:00	1.6	11.1	2,302.3	1.0	9.20	1	1	1
09/30/2024 20:00	1.6	11.4	2,241.1	1.0	9.00	1	1	1
09/30/2024 21:00	1.6	11.2	2,304.6	1.0	9.20	1	1	1
09/30/2024 22:00	1.6	11.7	2,210.3	1.0	8.80	1	1	1
09/30/2024 23:00	1.5	12.1	2,126.8	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.3	1,967.6	1.0	186.70 #	24 #	24 #	19 #
Minimum:	1.2	11.1	1,317.5	0.9	5.30	1	1	0
Maximum:	1.6	13.9	2,304.6	1.1	9.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2024 00:00	3.4	15.3	740.2	3.6	2.69	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2024 13:00	27.2	17.6	354.5	48.6	39.37	1	0	0
07/01/2024 14:00	11.3	15.3	899.8	11.9	39.60	1	0	0
07/01/2024 15:00	1.2	14.0	1,351.1	1.0	5.40	1	1	0
07/01/2024 16:00	1.3	13.9	1,569.4	1.1	6.30	1	1	1
07/01/2024 17:00	1.6	12.0	2,130.6	1.1	8.50	1	1	1
07/01/2024 18:00	1.6	11.6	2,203.3	1.0	8.80	1	1	1
07/01/2024 19:00	1.6	11.9	2,164.1	1.0	8.70	1	1	1
07/01/2024 20:00	1.6	11.9	2,153.7	1.0	8.60	1	1	1
07/01/2024 21:00	1.5	12.4	2,061.9	1.0	8.20	1	1	1
07/01/2024 22:00	1.5	12.4	2,045.0	1.0	8.20	1	1	1
07/01/2024 23:00	3.5	15.5	701.1	3.8	2.94	1	0	0
Average/Sum#:	4.8	13.7	1,531.2	6.3	147.30 #	12 #	8 #	7 #
Minimum:	1.2	11.6	354.5	1.0	2.69	0	0	0
Maximum:	27.2	17.6	2,203.3	48.6	39.60	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2024 15:00	15.6	18.5	194.3	38.4	6.30	1	0	0
07/02/2024 16:00	28.7	15.9	664.0	33.9	83.00	1	0	0
07/02/2024 17:00	1.9	13.8	1,638.1	1.6	9.80	1	0	0
07/02/2024 18:00	1.5	12.9	1,852.0	1.1	7.40	1	1	1
07/02/2024 19:00	1.6	11.7	2,200.4	1.0	8.80	1	1	1
07/02/2024 20:00	1.5	11.9	2,170.0	1.0	8.70	1	1	1
07/02/2024 21:00	1.6	11.9	2,166.2	1.0	8.70	1	1	1
07/02/2024 22:00	1.6	12.2	2,103.8	1.1	8.40	1	1	1
07/02/2024 23:00	1.6	11.7	2,223.9	1.0	8.90	1	1	1
Average/Sum#:	6.2	13.4	1,690.3	8.9	150.00 #	9 #	6 #	6 #
Minimum:	1.5	11.7	194.3	1.0	6.30	0	0	0
Maximum:	28.7	18.5	2,223.9	38.4	83.00	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2024 00:00	1.6	11.9	2,199.5	1.0	8.80	1	1	1
07/03/2024 01:00	1.5	12.3	2,094.1	1.0	8.40	1	1	1
07/03/2024 02:00	1.5	12.5	2,066.0	1.1	8.30	1	1	1
07/03/2024 03:00	1.5	12.6	2,049.2	1.1	8.20	1	1	1
07/03/2024 04:00	1.5	12.5	2,055.5	1.1	8.20	1	1	1
07/03/2024 05:00	1.5	12.5	2,056.6	1.1	8.20	1	1	1
07/03/2024 06:00	1.5	12.5	2,062.4	1.1	8.20	1	1	1
07/03/2024 07:00	1.5	12.4	2,069.0	1.0	8.30	1	1	1
07/03/2024 08:00	1.5	12.4	2,075.1	1.0	8.30	1	1	1
07/03/2024 09:00	1.5	12.4	2,083.1	1.0	8.30	1	1	1
07/03/2024 10:00	1.5	12.3	2,087.4	1.0	8.30	1	1	1
07/03/2024 11:00	1.6	12.4	2,071.9	1.1	8.30	1	1	1
07/03/2024 12:00	1.5	12.3	2,081.2	1.0	8.30	1	1	1
07/03/2024 13:00	1.5	12.2	2,080.9	1.0	8.30	1	1	1
07/03/2024 14:00	1.6	12.2	2,076.6	1.1	8.30	1	1	1
07/03/2024 15:00	1.6	12.1	2,082.4	1.1	8.30	1	1	1
07/03/2024 16:00	1.5	12.4	2,031.0	1.0	8.10	1	1	1
07/03/2024 17:00	1.6	12.3	2,026.8	1.1	8.10	1	1	1
07/03/2024 18:00	1.6	12.3	2,038.8	1.1	8.20	1	1	1
07/03/2024 19:00	1.5	12.2	2,057.1	1.0	8.20	1	1	1
07/03/2024 20:00	1.5	12.3	2,054.7	1.0	8.20	1	1	1
07/03/2024 21:00	1.5	12.4	2,052.4	1.0	8.20	1	1	1
07/03/2024 22:00	1.5	12.4	2,050.4	1.0	8.20	1	1	1
07/03/2024 23:00	1.5	12.5	2,039.4	1.1	8.20	1	1	1
Average/Sum#:	1.5	12.3	2,068.4	1.0	198.40 #	24 #	24 #	24 #
Minimum:	1.5	11.9	2,026.8	1.0	8.10	1	1	1
Maximum:	1.6	12.6	2,199.5	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2024 00:00	1.5	12.7	2,004.0	1.1	8.00	1	1	1
07/04/2024 01:00	1.5	12.7	1,977.6	1.1	7.90	1	1	1
07/04/2024 02:00	2.5	15.5	666.5	2.7	1.81	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2024 13:00	24.5	17.7	329.8	45.2	22.97	1	0	0
07/04/2024 14:00	10.8	15.5	856.3	11.8	36.80	1	0	0
07/04/2024 15:00	1.3	13.9	1,531.4	1.1	6.10	1	1	0
07/04/2024 16:00	1.3	13.7	1,704.7	1.1	6.80	1	1	0
07/04/2024 17:00	1.5	12.9	1,820.6	1.1	7.30	1	1	1
07/04/2024 18:00	1.6	11.8	2,143.0	1.0	8.60	1	1	1
07/04/2024 19:00	1.6	12.0	2,116.6	1.1	8.50	1	1	1
07/04/2024 20:00	1.5	12.3	2,050.0	1.0	8.20	1	1	1
07/04/2024 21:00	1.5	12.3	2,041.8	1.0	8.20	1	1	1
07/04/2024 22:00	1.5	12.5	2,028.9	1.1	8.10	1	1	1
07/04/2024 23:00	1.5	12.5	1,996.8	1.1	8.00	1	1	1
Average/Sum#:	3.9	13.4	1,662.0	5.1	147.28 #	14 #	11 #	9 #
Minimum:	1.3	11.8	329.8	1.0	1.81	0	0	0
Maximum:	24.5	17.7	2,143.0	45.2	36.80	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2024 00:00	1.3	13.8	1,729.6	1.1	6.90	1	1	0
07/05/2024 01:00	1.3	13.8	1,722.9	1.1	6.90	1	1	0
07/05/2024 02:00	1.3	13.8	1,713.9	1.1	6.90	1	1	0
07/05/2024 03:00	1.3	13.8	1,743.3	1.1	7.00	1	1	0
07/05/2024 04:00	1.3	13.8	1,626.1	1.1	6.50	1	1	0
07/05/2024 05:00	1.3	13.8	1,659.3	1.1	6.60	1	1	0
07/05/2024 06:00	1.3	13.7	1,759.2	1.1	7.00	1	1	0
07/05/2024 07:00	1.3	13.7	1,755.4	1.1	7.00	1	1	0
07/05/2024 08:00	1.3	13.7	1,761.6	1.1	7.00	1	1	0
07/05/2024 09:00	1.4	13.6	1,758.5	1.1	7.00	1	1	0
07/05/2024 10:00	1.3	13.6	1,745.7	1.1	7.00	1	1	0
07/05/2024 11:00	1.3	13.6	1,737.0	1.1	6.90	1	1	0
07/05/2024 12:00	1.2	13.8	1,559.5	1.0	6.20	1	1	0
07/05/2024 13:00	1.5	12.7	1,867.1	1.1	7.50	1	1	1
07/05/2024 14:00	1.7	11.5	2,152.1	1.1	8.60	1	1	1
07/05/2024 15:00	1.6	11.8	2,104.0	1.0	8.40	1	1	1
07/05/2024 16:00	1.6	11.8	2,107.0	1.0	8.40	1	1	1
07/05/2024 17:00	1.6	11.8	2,108.5	1.0	8.40	1	1	1
07/05/2024 18:00	1.6	11.9	2,092.2	1.0	8.40	1	1	1
07/05/2024 19:00	1.6	11.9	2,101.2	1.0	8.40	1	1	1
07/05/2024 20:00	1.6	12.0	2,091.4	1.1	8.40	1	1	1
07/05/2024 21:00	1.6	11.6	2,212.3	1.0	8.80	1	1	1
07/05/2024 22:00	1.6	11.8	2,140.1	1.0	8.60	1	1	1
07/05/2024 23:00	1.5	12.4	2,046.0	1.0	8.20	1	1	1
Average/Sum#:	1.4	12.9	1,887.2	1.1	181.00 #	24 #	24 #	11 #
Minimum:	1.2	11.5	1,559.5	1.0	6.20	1	1	0
Maximum:	1.7	13.8	2,212.3	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2024 00:00	1.5	12.5	2,021.2	1.1	8.10	1	1	1
07/06/2024 01:00	1.5	12.6	2,007.2	1.1	8.00	1	1	1
07/06/2024 02:00	1.5	12.6	2,007.7	1.1	8.00	1	1	1
07/06/2024 03:00	1.5	12.6	2,012.3	1.1	8.00	1	1	1
07/06/2024 04:00	1.5	12.7	2,005.4	1.1	8.00	1	1	1
07/06/2024 05:00	1.5	12.5	1,988.5	1.1	8.00	1	1	1
07/06/2024 06:00	0.0	0.0	705.2	0.0	0.00	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2024 13:00	0.0	20.5	0.2	0.0	0.00	1	0	0
07/06/2024 14:00	8.6	15.5	853.7	9.4	29.90	1	0	0
07/06/2024 15:00	1.2	13.9	1,450.7	1.0	5.80	1	1	0
07/06/2024 16:00	1.3	13.8	1,561.5	1.1	6.20	1	1	1
07/06/2024 17:00	1.6	12.0	2,101.8	1.1	8.40	1	1	1
07/06/2024 18:00	1.4	11.8	2,120.2	0.9	6.40	1	1	1
07/06/2024 19:00	1.6	11.8	2,091.3	1.0	8.40	1	1	1
07/06/2024 20:00	1.6	11.9	2,094.0	1.0	8.40	1	1	1
07/06/2024 21:00	1.6	12.0	2,098.7	1.1	8.40	1	1	1
07/06/2024 22:00	1.6	11.9	2,129.4	1.0	8.50	1	1	1
07/06/2024 23:00	1.7	11.5	2,223.4	1.1	8.90	1	1	1
Average/Sum#:	1.8	13.1	1,748.5	1.5	147.40 #	18 #	15 #	14 #
Minimum:	0.0	11.5	0.2	0.0	0.00	0	0	0
Maximum:	8.6	20.5	2,223.4	9.4	29.90	1	1	1
%SI	29.17	29.17	25.00	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2024 00:00	1.5	12.2	2,078.0	1.0	8.30	1	1	1
07/07/2024 01:00	1.5	12.5	2,026.5	1.1	8.10	1	1	1
07/07/2024 02:00	1.5	12.4	2,004.4	1.0	8.00	1	1	1
07/07/2024 03:00	2.5	15.6	609.7	2.8	1.53	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2024 11:00	0.0	20.9	3.1	0.0	0.00	1	0	0
07/07/2024 12:00	17.0	16.0	720.2	20.5	54.00	1	0	0
07/07/2024 13:00	1.2	13.9	1,483.1	1.0	5.90	1	1	0
07/07/2024 14:00	1.3	13.9	1,427.5	1.1	5.70	1	1	0
07/07/2024 15:00	1.3	13.8	1,620.8	1.1	6.50	1	1	0
07/07/2024 16:00	1.2	13.8	1,560.6	1.0	6.20	1	1	0
07/07/2024 17:00	1.2	13.9	1,389.2	1.0	5.60	1	1	0
07/07/2024 18:00	1.3	13.0	1,716.7	1.0	6.90	1	1	1
07/07/2024 19:00	1.7	11.4	2,176.9	1.1	8.70	1	1	1
07/07/2024 20:00	1.6	11.5	2,156.9	1.0	8.60	1	1	1
07/07/2024 21:00	1.6	12.1	2,045.2	1.1	8.20	1	1	1
07/07/2024 22:00	1.6	12.3	2,022.3	1.1	8.10	1	1	1
07/07/2024 23:00	1.6	12.0	2,093.4	1.1	8.40	1	1	1
Average/Sum#:	2.3	13.6	1,596.1	2.2	158.73 #	17 #	14 #	9 #
Minimum:	0.0	11.4	3.1	0.0	0.00	0	0	0
Maximum:	17.0	20.9	2,176.9	20.5	54.00	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2024 00:00	1.3	13.7	1,725.6	1.1	6.90	1	1	0
07/08/2024 01:00	1.3	13.8	1,711.5	1.1	6.80	1	1	0
07/08/2024 02:00	1.3	13.8	1,716.2	1.1	6.90	1	1	0
07/08/2024 03:00	1.3	13.8	1,717.9	1.1	6.90	1	1	0
07/08/2024 04:00	1.3	13.7	1,742.2	1.1	7.00	1	1	0
07/08/2024 05:00	1.3	13.7	1,758.7	1.1	7.00	1	1	0
07/08/2024 06:00	1.3	13.7	1,741.1	1.1	7.00	1	1	0
07/08/2024 07:00	1.3	13.7	1,728.4	1.1	6.90	1	1	0
07/08/2024 08:00	1.3	13.7	1,712.9	1.1	6.90	1	1	0
07/08/2024 09:00	1.3	13.6	1,702.8	1.1	6.80	1	1	0
07/08/2024 10:00	1.4	13.6	1,716.6	1.1	6.90	1	1	0
07/08/2024 11:00	1.4	13.5	1,710.8	1.1	6.80	1	1	0
07/08/2024 12:00	1.3	13.5	1,695.7	1.0	6.80	1	1	0
07/08/2024 13:00	1.3	13.8	1,589.0	1.1	6.40	1	1	0
07/08/2024 14:00	1.3	13.7	1,634.5	1.1	6.50	1	1	0
07/08/2024 15:00	1.3	13.6	1,672.6	1.1	6.70	1	1	0
07/08/2024 16:00	1.3	13.6	1,587.9	1.1	6.40	1	1	1
07/08/2024 17:00	1.6	11.8	2,105.0	1.0	8.40	1	1	1
07/08/2024 18:00	1.7	11.4	2,175.1	1.1	8.70	1	1	1
07/08/2024 19:00	1.7	11.4	2,186.1	1.1	8.70	1	1	1
07/08/2024 20:00	1.6	11.5	2,188.5	1.0	8.80	1	1	1
07/08/2024 21:00	1.6	11.7	2,148.3	1.0	8.60	1	1	1
07/08/2024 22:00	1.6	11.9	2,127.7	1.0	8.50	1	1	1
07/08/2024 23:00	1.7	11.6	2,207.6	1.1	8.80	1	1	1
Average/Sum#:	1.4	13.1	1,833.4	1.1	176.10 #	24 #	24 #	8 #
Minimum:	1.3	11.4	1,587.9	1.0	6.40	1	1	0
Maximum:	1.7	13.8	2,207.6	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2024 00:00	1.6	11.6	2,210.6	1.0	8.80	1	1	1
07/09/2024 01:00	1.6	11.7	2,186.7	1.0	8.70	1	1	1
07/09/2024 02:00	1.6	11.8	2,168.0	1.0	8.70	1	1	1
07/09/2024 03:00	1.6	11.9	2,167.0	1.0	8.70	1	1	1
07/09/2024 04:00	1.6	11.6	2,239.5	1.0	9.00	1	1	1
07/09/2024 05:00	1.6	11.7	2,205.6	1.0	8.80	1	1	1
07/09/2024 06:00	1.4	12.5	2,013.5	1.0	8.10	1	1	1
07/09/2024 07:00	1.5	12.6	1,987.5	1.1	8.00	1	1	1
07/09/2024 08:00	0.0	0.0	2,106.1	0.0	0.00	1	1	1
07/09/2024 09:00	0.0	0.0	2,082.6	0.0	0.00	1	1	1
07/09/2024 10:00	0.0	0.0	2,091.7	0.0	0.00	1	1	1
07/09/2024 11:00	0.0	0.0	2,189.6	0.0	0.00	1	1	1
07/09/2024 12:00	1.7	11.6	2,181.5	1.1	8.70	1	1	1
07/09/2024 13:00	1.6	11.7	2,144.3	1.0	8.60	1	1	1
07/09/2024 14:00	1.6	11.8	2,124.3	1.0	8.50	1	1	1
07/09/2024 15:00	1.6	11.8	2,127.1	1.0	8.50	1	1	1
07/09/2024 16:00	1.6	11.6	2,142.4	1.0	8.60	1	1	1
07/09/2024 17:00	1.6	11.6	2,160.8	1.0	8.60	1	1	1
07/09/2024 18:00	1.6	11.9	2,098.6	1.0	8.40	1	1	1
07/09/2024 19:00	1.6	11.5	2,186.1	1.0	8.70	1	1	1
07/09/2024 20:00	1.6	11.5	2,179.0	1.0	8.70	1	1	1
07/09/2024 21:00	1.6	11.7	2,154.4	1.0	8.60	1	1	1
07/09/2024 22:00	1.6	11.9	2,122.5	1.0	8.50	1	1	1
07/09/2024 23:00	1.5	12.2	2,052.9	1.0	8.20	1	1	1
Average/Sum#:	1.6	11.8	2,138.4	1.0	171.40 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,987.5	1.0	8.00	1	1	1
Maximum:	1.7	12.6	2,239.5	1.1	9.00	1	1	1
%SI	16.67	16.67	0.00	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2024 00:00	1.5	12.4	2,039.6	1.0	8.20	1	1	1
07/10/2024 01:00	1.6	11.6	2,204.7	1.0	8.80	1	1	1
07/10/2024 02:00	1.6	11.6	2,208.0	1.0	8.80	1	1	1
07/10/2024 03:00	1.6	11.7	2,195.8	1.0	8.80	1	1	1
07/10/2024 04:00	1.6	11.8	2,180.3	1.0	8.70	1	1	1
07/10/2024 05:00	1.6	11.9	2,140.4	1.0	8.60	1	1	1
07/10/2024 06:00	1.4	12.4	2,021.0	1.0	8.10	1	1	1
07/10/2024 07:00	1.5	12.5	1,981.9	1.1	7.90	1	1	1
07/10/2024 08:00	1.5	12.5	1,985.9	1.1	7.90	1	1	1
07/10/2024 09:00	1.5	12.4	1,996.6	1.0	8.00	1	1	1
07/10/2024 10:00	1.5	12.3	2,011.3	1.0	8.00	1	1	1
07/10/2024 11:00	1.6	12.1	2,035.2	1.1	8.10	1	1	1
07/10/2024 12:00	1.6	12.0	2,053.1	1.1	8.20	1	1	1
07/10/2024 13:00	1.6	11.6	2,158.3	1.0	8.60	1	1	1
07/10/2024 14:00	1.6	11.5	2,167.2	1.0	8.70	1	1	1
07/10/2024 15:00	1.6	11.8	2,110.5	1.0	8.40	1	1	1
07/10/2024 16:00	1.6	11.9	2,074.7	1.0	8.30	1	1	1
07/10/2024 17:00	1.6	12.0	2,064.9	1.1	8.30	1	1	1
07/10/2024 18:00	1.6	11.6	2,126.3	1.0	8.50	1	1	1
07/10/2024 19:00	1.7	11.4	2,178.2	1.1	8.70	1	1	1
07/10/2024 20:00	1.6	11.4	2,187.0	1.0	8.70	1	1	1
07/10/2024 21:00	1.6	11.4	2,195.8	1.0	8.80	1	1	1
07/10/2024 22:00	1.7	11.4	2,201.0	1.1	8.80	1	1	1
07/10/2024 23:00	1.6	11.4	2,202.4	1.0	8.80	1	1	1
Average/Sum#:	1.6	11.9	2,113.3	1.0	202.70 #	24 #	24 #	24 #
Minimum:	1.4	11.4	1,981.9	1.0	7.90	1	1	1
Maximum:	1.7	12.5	2,208.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2024 00:00	1.6	11.9	2,103.2	1.0	8.40	1	1	1
07/11/2024 01:00	1.6	12.0	2,084.8	1.1	8.30	1	1	1
07/11/2024 02:00	1.5	12.1	2,063.6	1.0	8.30	1	1	1
07/11/2024 03:00	1.5	12.3	2,033.1	1.0	8.10	1	1	1
07/11/2024 04:00	1.6	11.5	2,203.6	1.0	8.80	1	1	1
07/11/2024 05:00	1.5	12.4	1,996.4	1.0	8.00	1	1	1
07/11/2024 06:00	1.3	13.7	1,721.8	1.1	6.90	1	1	0
07/11/2024 07:00	1.3	13.7	1,713.9	1.1	6.90	1	1	0
07/11/2024 08:00	1.3	13.7	1,549.2	1.1	6.20	1	1	0
07/11/2024 09:00	1.3	13.9	1,505.5	1.1	6.00	1	1	0
07/11/2024 10:00	1.3	13.8	1,632.7	1.1	6.50	1	1	0
07/11/2024 11:00	1.2	13.9	1,468.0	1.0	5.90	1	1	0
07/11/2024 12:00	1.3	13.8	1,588.0	1.1	6.40	1	1	0
07/11/2024 13:00	1.3	13.8	1,582.6	1.1	6.30	1	1	0
07/11/2024 14:00	1.3	13.8	1,557.3	1.1	6.20	1	1	0
07/11/2024 15:00	1.2	14.0	1,331.5	1.0	5.30	1	1	0
07/11/2024 16:00	1.3	14.0	1,333.4	1.1	5.30	1	1	0
07/11/2024 17:00	1.4	12.9	1,744.0	1.0	7.00	1	1	1
07/11/2024 18:00	1.6	11.7	2,104.3	1.0	8.40	1	1	1
07/11/2024 19:00	1.7	11.6	2,121.1	1.1	8.50	1	1	1
07/11/2024 20:00	1.6	12.0	2,047.6	1.1	8.20	1	1	1
07/11/2024 21:00	1.5	12.2	2,015.3	1.0	8.10	1	1	1
07/11/2024 22:00	1.6	11.6	2,166.6	1.0	8.70	1	1	1
07/11/2024 23:00	1.5	12.1	2,059.7	1.0	8.20	1	1	1
Average/Sum#:	1.4	12.9	1,822.0	1.1	174.90 #	24 #	24 #	13 #
Minimum:	1.2	11.5	1,331.5	1.0	5.30	1	1	0
Maximum:	1.7	14.0	2,203.6	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2024 00:00	1.5	12.2	2,056.0	1.0	8.20	1	1	1
07/12/2024 01:00	1.6	12.2	2,061.7	1.1	8.20	1	1	1
07/12/2024 02:00	1.5	12.3	2,034.1	1.0	8.10	1	1	1
07/12/2024 03:00	1.6	11.7	2,180.8	1.0	8.70	1	1	1
07/12/2024 04:00	1.5	12.2	2,088.4	1.0	8.40	1	1	1
07/12/2024 05:00	1.6	12.1	2,087.8	1.1	8.40	1	1	1
07/12/2024 06:00	1.2	13.7	1,733.6	1.0	6.90	1	1	0
07/12/2024 07:00	1.3	13.8	1,541.5	1.1	6.20	1	1	0
07/12/2024 08:00	1.3	13.9	1,475.4	1.1	5.90	1	1	0
07/12/2024 09:00	1.3	13.9	1,479.2	1.1	5.90	1	1	0
07/12/2024 10:00	1.2	13.9	1,503.7	1.0	6.00	1	1	0
07/12/2024 11:00	1.3	13.9	1,430.7	1.1	5.70	1	1	0
07/12/2024 12:00	1.3	13.9	1,470.7	1.1	5.90	1	1	0
07/12/2024 13:00	1.3	13.9	1,339.2	1.1	5.40	1	1	0
07/12/2024 14:00	1.3	13.9	1,352.3	1.1	5.40	1	1	0
07/12/2024 15:00	1.3	13.9	1,355.0	1.1	5.40	1	1	0
07/12/2024 16:00	1.3	14.0	1,341.5	1.1	5.40	1	1	0
07/12/2024 17:00	1.3	13.9	1,341.6	1.1	5.40	1	1	0
07/12/2024 18:00	1.3	13.9	1,331.6	1.1	5.30	1	1	0
07/12/2024 19:00	1.3	13.9	1,327.8	1.1	5.30	1	1	0
07/12/2024 20:00	1.3	13.9	1,326.9	1.1	5.30	1	1	0
07/12/2024 21:00	1.3	13.7	1,632.5	1.1	6.50	1	1	0
07/12/2024 22:00	1.3	13.6	1,733.5	1.1	6.90	1	1	0
07/12/2024 23:00	1.3	13.6	1,731.1	1.1	6.90	1	1	0
Average/Sum#:	1.4	13.4	1,623.2	1.1	155.70 #	24 #	24 #	6 #
Minimum:	1.2	11.7	1,326.9	1.0	5.30	1	1	0
Maximum:	1.6	14.0	2,180.8	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2024 00:00	1.4	13.6	1,731.4	1.1	6.90	1	1	0
07/13/2024 01:00	1.3	13.6	1,731.0	1.1	6.90	1	1	0
07/13/2024 02:00	1.4	13.6	1,742.4	1.1	7.00	1	1	0
07/13/2024 03:00	1.4	13.6	1,748.8	1.1	7.00	1	1	0
07/13/2024 04:00	1.3	13.7	1,730.0	1.1	6.90	1	1	0
07/13/2024 05:00	1.3	13.6	1,752.8	1.1	7.00	1	1	0
07/13/2024 06:00	1.3	13.7	1,714.2	1.1	6.90	1	1	0
07/13/2024 07:00	1.3	13.6	1,732.9	1.1	6.90	1	1	0
07/13/2024 08:00	1.3	13.7	1,714.0	1.1	6.90	1	1	0
07/13/2024 09:00	1.2	13.8	1,559.7	1.0	6.20	1	1	0
07/13/2024 10:00	1.3	13.9	1,558.1	1.1	6.20	1	1	0
07/13/2024 11:00	1.3	13.8	1,627.8	1.1	6.50	1	1	0
07/13/2024 12:00	1.3	13.8	1,647.4	1.1	6.60	1	1	0
07/13/2024 13:00	1.3	13.9	1,377.1	1.1	5.50	1	1	0
07/13/2024 14:00	1.3	13.9	1,322.1	1.1	5.30	1	1	0
07/13/2024 15:00	1.3	13.9	1,326.9	1.1	5.30	1	1	0
07/13/2024 16:00	1.3	13.9	1,322.7	1.1	5.30	1	1	0
07/13/2024 17:00	1.3	13.9	1,333.5	1.1	5.30	1	1	0
07/13/2024 18:00	1.3	13.9	1,328.3	1.1	5.30	1	1	0
07/13/2024 19:00	1.3	13.8	1,463.2	1.1	5.90	1	1	0
07/13/2024 20:00	1.4	13.6	1,717.1	1.1	6.90	1	1	0
07/13/2024 21:00	1.4	13.6	1,714.8	1.1	6.90	1	1	0
07/13/2024 22:00	1.3	13.7	1,726.6	1.1	6.90	1	1	0
07/13/2024 23:00	1.3	13.7	1,734.3	1.1	6.90	1	1	0
Average/Sum#:	1.3	13.7	1,598.2	1.1	153.40 #	24 #	24 #	0 #
Minimum:	1.2	13.6	1,322.1	1.0	5.30	1	1	0
Maximum:	1.4	13.9	1,752.8	1.1	7.00	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2024 00:00	1.3	13.7	1,741.7	1.1	7.00	1	1	0
07/14/2024 01:00	1.3	13.8	1,649.7	1.1	6.60	1	1	0
07/14/2024 02:00	1.9	14.7	1,047.3	1.8	3.43	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2024 14:00	24.6	17.7	343.8	45.4	27.55	1	0	0
07/14/2024 15:00	9.8	14.3	1,324.5	8.8	42.40	1	0	0
07/14/2024 16:00	1.3	13.7	1,684.6	1.1	6.70	1	1	0
07/14/2024 17:00	1.3	13.6	1,705.5	1.1	6.80	1	1	1
07/14/2024 18:00	1.6	11.8	2,131.7	1.0	8.50	1	1	1
07/14/2024 19:00	1.5	11.5	2,203.6	0.9	6.60	1	1	1
07/14/2024 20:00	1.6	11.6	2,187.1	1.0	8.70	1	1	1
07/14/2024 21:00	1.7	11.5	2,209.9	1.1	8.80	1	1	1
07/14/2024 22:00	1.5	12.1	2,070.8	1.0	8.30	1	1	1
07/14/2024 23:00	1.5	12.4	1,990.8	1.0	8.00	1	1	1
Average/Sum#:	3.9	13.3	1,714.7	5.1	149.38 #	13 #	10 #	7 #
Minimum:	1.3	11.5	343.8	0.9	3.43	0	0	0
Maximum:	24.6	17.7	2,209.9	45.4	42.40	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2024 00:00	1.3	13.7	1,722.7	1.1	6.90	1	1	0
07/15/2024 01:00	1.3	13.7	1,736.1	1.1	6.90	1	1	0
07/15/2024 02:00	1.3	13.8	1,626.1	1.1	6.50	1	1	0
07/15/2024 03:00	1.3	13.8	1,713.3	1.1	6.90	1	1	0
07/15/2024 04:00	1.3	13.7	1,749.7	1.1	7.00	1	1	0
07/15/2024 05:00	1.3	13.8	1,715.7	1.1	6.90	1	1	0
07/15/2024 06:00	1.3	13.8	1,698.3	1.1	6.80	1	1	0
07/15/2024 07:00	1.3	13.8	1,709.8	1.1	6.80	1	1	0
07/15/2024 08:00	1.3	13.8	1,544.9	1.1	6.20	1	1	0
07/15/2024 09:00	1.3	13.8	1,486.3	1.1	5.90	1	1	0
07/15/2024 10:00	1.3	13.8	1,622.8	1.1	6.50	1	1	0
07/15/2024 11:00	1.3	13.7	1,701.0	1.1	6.80	1	1	0
07/15/2024 12:00	1.3	13.8	1,658.0	1.1	6.60	1	1	0
07/15/2024 13:00	1.3	13.8	1,661.7	1.1	6.60	1	1	0
07/15/2024 14:00	1.3	13.7	1,657.6	1.1	6.60	1	1	0
07/15/2024 15:00	1.3	13.9	1,591.1	1.1	6.40	1	1	0
07/15/2024 16:00	1.3	13.8	1,569.5	1.1	6.30	1	1	0
07/15/2024 17:00	1.4	13.2	1,722.5	1.1	6.90	1	1	1
07/15/2024 18:00	1.6	11.8	2,127.9	1.0	8.50	1	1	1
07/15/2024 19:00	1.6	11.6	2,186.2	1.0	8.70	1	1	1
07/15/2024 20:00	1.6	11.7	2,178.7	1.0	8.70	1	1	1
07/15/2024 21:00	1.6	12.0	2,119.0	1.1	8.50	1	1	1
07/15/2024 22:00	1.5	12.8	1,987.8	1.1	8.00	1	1	1
07/15/2024 23:00	1.5	12.7	1,970.3	1.1	7.90	1	1	1
Average/Sum#:	1.4	13.3	1,769.0	1.1	169.80 #	24 #	24 #	7 #
Minimum:	1.3	11.6	1,486.3	1.0	5.90	1	1	0
Maximum:	1.6	13.9	2,186.2	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2024 00:00	1.3	13.7	1,726.6	1.1	6.90	1	1	1
07/16/2024 01:00	1.3	13.8	1,735.8	1.1	6.90	1	1	0
07/16/2024 02:00	1.3	13.8	1,743.5	1.1	7.00	1	1	0
07/16/2024 03:00	1.3	13.8	1,747.0	1.1	7.00	1	1	0
07/16/2024 04:00	1.3	13.8	1,743.6	1.1	7.00	1	1	0
07/16/2024 05:00	1.3	13.8	1,707.5	1.1	6.80	1	1	0
07/16/2024 06:00	1.3	13.8	1,689.6	1.1	6.80	1	1	0
07/16/2024 07:00	1.3	13.8	1,720.0	1.1	6.90	1	1	0
07/16/2024 08:00	1.3	13.8	1,597.3	1.1	6.40	1	1	0
07/16/2024 09:00	1.3	13.8	1,616.0	1.1	6.50	1	1	0
07/16/2024 10:00	1.3	13.8	1,655.5	1.1	6.60	1	1	0
07/16/2024 11:00	1.3	13.8	1,702.4	1.1	6.80	1	1	0
07/16/2024 12:00	1.3	13.8	1,639.4	1.1	6.60	1	1	0
07/16/2024 13:00	1.1	13.8	1,534.9	0.9	4.60	1	1	0
07/16/2024 14:00	1.2	14.0	1,324.4	1.0	5.30	1	1	0
07/16/2024 15:00	1.3	13.9	1,498.1	1.1	6.00	1	1	1
07/16/2024 16:00	1.5	12.3	2,058.9	1.0	8.20	1	1	1
07/16/2024 17:00	1.6	11.8	2,152.5	1.0	8.60	1	1	1
07/16/2024 18:00	1.6	11.6	2,227.9	1.0	8.90	1	1	1
07/16/2024 19:00	1.6	11.6	2,230.5	1.0	8.90	1	1	1
07/16/2024 20:00	1.6	11.5	2,237.0	1.0	8.90	1	1	1
07/16/2024 21:00	1.6	11.5	2,244.8	1.0	9.00	1	1	1
07/16/2024 22:00	1.6	11.9	2,165.3	1.0	8.70	1	1	1
07/16/2024 23:00	1.5	12.5	2,054.7	1.1	8.20	1	1	1
Average/Sum#:	1.4	13.2	1,823.1	1.1	173.50 #	24 #	24 #	10 #
Minimum:	1.1	11.5	1,324.4	0.9	4.60	1	1	0
Maximum:	1.6	14.0	2,244.8	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2024 00:00	1.4	12.7	2,023.8	1.0	8.10	1	1	1
07/17/2024 01:00	1.3	13.6	1,701.0	1.1	6.80	1	1	1
07/17/2024 02:00	1.3	13.8	1,715.4	1.1	6.90	1	1	0
07/17/2024 03:00	1.3	13.8	1,743.1	1.1	7.00	1	1	0
07/17/2024 04:00	1.3	13.8	1,743.7	1.1	7.00	1	1	0
07/17/2024 05:00	1.3	13.8	1,661.1	1.1	6.60	1	1	0
07/17/2024 06:00	1.3	13.8	1,705.4	1.1	6.80	1	1	0
07/17/2024 07:00	1.3	13.8	1,736.6	1.1	6.90	1	1	0
07/17/2024 08:00	1.3	13.8	1,703.5	1.1	6.80	1	1	0
07/17/2024 09:00	1.3	13.8	1,620.2	1.1	6.50	1	1	0
07/17/2024 10:00	1.3	13.9	1,428.5	1.1	5.70	1	1	0
07/17/2024 11:00	1.3	13.9	1,429.9	1.1	5.70	1	1	0
07/17/2024 12:00	1.2	13.9	1,538.1	1.0	6.20	1	1	0
07/17/2024 13:00	1.2	13.9	1,476.5	1.0	5.90	1	1	0
07/17/2024 14:00	1.3	13.9	1,575.8	1.1	6.30	1	1	1
07/17/2024 15:00	1.5	12.3	2,069.7	1.0	8.30	1	1	1
07/17/2024 16:00	1.5	12.4	2,043.3	1.0	8.20	1	1	1
07/17/2024 17:00	1.6	12.2	2,097.2	1.1	8.40	1	1	1
07/17/2024 18:00	1.6	11.6	2,219.2	1.0	8.90	1	1	1
07/17/2024 19:00	1.6	11.6	2,230.4	1.0	8.90	1	1	1
07/17/2024 20:00	1.6	11.6	2,230.8	1.0	8.90	1	1	1
07/17/2024 21:00	1.6	11.6	2,222.4	1.0	8.90	1	1	1
07/17/2024 22:00	1.6	11.6	2,215.7	1.0	8.90	1	1	1
07/17/2024 23:00	1.6	11.9	2,167.3	1.0	8.70	1	1	1
Average/Sum#:	1.4	13.0	1,845.8	1.1	177.30 #	24 #	24 #	12 #
Minimum:	1.2	11.6	1,428.5	1.0	5.70	1	1	0
Maximum:	1.6	13.9	2,230.8	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2024 00:00	1.5	12.6	2,021.1	1.1	8.10	1	1	1
07/18/2024 01:00	1.5	12.5	2,036.6	1.1	8.10	1	1	1
07/18/2024 02:00	1.6	11.9	2,174.0	1.0	8.70	1	1	1
07/18/2024 03:00	1.6	12.0	2,149.6	1.1	8.60	1	1	1
07/18/2024 04:00	1.6	12.0	2,169.9	1.1	8.70	1	1	1
07/18/2024 05:00	1.6	12.2	2,117.4	1.1	8.50	1	1	1
07/18/2024 06:00	1.4	12.6	2,027.2	1.0	8.10	1	1	1
07/18/2024 07:00	1.4	12.7	1,978.4	1.0	7.90	1	1	1
07/18/2024 08:00	1.5	12.6	2,020.0	1.1	8.10	1	1	1
07/18/2024 09:00	1.5	12.2	2,096.6	1.0	8.40	1	1	1
07/18/2024 10:00	1.5	12.1	2,100.1	1.0	8.40	1	1	1
07/18/2024 11:00	1.5	12.1	2,100.3	1.0	8.40	1	1	1
07/18/2024 12:00	1.6	12.2	2,071.6	1.1	8.30	1	1	1
07/18/2024 13:00	1.6	11.7	2,169.2	1.0	8.70	1	1	1
07/18/2024 14:00	1.6	11.6	2,179.3	1.0	8.70	1	1	1
07/18/2024 15:00	1.6	11.6	2,180.1	1.0	8.70	1	1	1
07/18/2024 16:00	1.6	11.6	2,189.3	1.0	8.80	1	1	1
07/18/2024 17:00	1.7	11.5	2,194.3	1.1	8.80	1	1	1
07/18/2024 18:00	1.6	11.5	2,196.4	1.0	8.80	1	1	1
07/18/2024 19:00	1.6	11.5	2,200.1	1.0	8.80	1	1	1
07/18/2024 20:00	1.6	11.5	2,208.5	1.0	8.80	1	1	1
07/18/2024 21:00	1.7	11.5	2,211.6	1.1	8.80	1	1	1
07/18/2024 22:00	1.6	11.5	2,224.2	1.0	8.90	1	1	1
07/18/2024 23:00	1.5	11.9	2,143.3	1.0	8.60	1	1	1
Average/Sum#:	1.6	12.0	2,131.6	1.0	204.70 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,978.4	1.0	7.90	1	1	1
Maximum:	1.7	12.7	2,224.2	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2024 00:00	1.5	12.2	2,089.2	1.0	8.40	1	1	1
07/19/2024 01:00	1.5	12.3	2,066.9	1.0	8.30	1	1	1
07/19/2024 02:00	1.6	12.2	2,094.0	1.1	8.40	1	1	1
07/19/2024 03:00	1.5	12.6	2,000.0	1.1	8.00	1	1	1
07/19/2024 04:00	1.6	11.9	2,180.9	1.0	8.70	1	1	1
07/19/2024 05:00	1.5	12.3	2,074.3	1.0	8.30	1	1	1
07/19/2024 06:00	1.2	13.7	1,737.8	1.0	7.00	1	1	1
07/19/2024 07:00	1.3	13.7	1,750.7	1.1	7.00	1	1	0
07/19/2024 08:00	1.3	13.7	1,752.7	1.1	7.00	1	1	0
07/19/2024 09:00	1.3	13.7	1,756.1	1.1	7.00	1	1	0
07/19/2024 10:00	1.3	13.6	1,751.0	1.1	7.00	1	1	0
07/19/2024 11:00	1.3	13.6	1,747.5	1.1	7.00	1	1	0
07/19/2024 12:00	1.3	13.6	1,736.9	1.1	6.90	1	1	1
07/19/2024 13:00	1.7	11.8	2,158.5	1.1	8.60	1	1	1
07/19/2024 14:00	1.6	11.5	2,199.2	1.0	8.80	1	1	1
07/19/2024 15:00	1.6	11.5	2,195.3	1.0	8.80	1	1	1
07/19/2024 16:00	1.6	11.5	2,188.5	1.0	8.80	1	1	1
07/19/2024 17:00	1.6	11.5	2,183.5	1.0	8.70	1	1	1
07/19/2024 18:00	1.6	11.5	2,182.3	1.0	8.70	1	1	1
07/19/2024 19:00	1.6	11.5	2,176.0	1.0	8.70	1	1	1
07/19/2024 20:00	1.6	11.7	2,159.5	1.0	8.60	1	1	1
07/19/2024 21:00	1.6	12.0	2,133.2	1.1	8.50	1	1	1
07/19/2024 22:00	1.6	11.6	2,212.8	1.0	8.90	1	1	1
07/19/2024 23:00	1.6	11.5	2,222.7	1.0	8.90	1	1	1
Average/Sum#:	1.5	12.4	2,031.2	1.0	195.00 #	24 #	24 #	19 #
Minimum:	1.2	11.5	1,736.9	1.0	6.90	1	1	0
Maximum:	1.7	13.7	2,222.7	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2024 00:00	1.6	11.5	2,219.7	1.0	8.90	1	1	1
07/20/2024 01:00	1.6	11.6	2,229.8	1.0	8.90	1	1	1
07/20/2024 02:00	1.6	11.6	2,230.8	1.0	8.90	1	1	1
07/20/2024 03:00	1.6	11.6	2,234.2	1.0	8.90	1	1	1
07/20/2024 04:00	1.6	11.6	2,236.4	1.0	8.90	1	1	1
07/20/2024 05:00	1.5	12.0	2,127.3	1.0	8.50	1	1	1
07/20/2024 06:00	1.3	13.7	1,707.9	1.1	6.80	1	1	1
07/20/2024 07:00	1.3	13.8	1,733.9	1.1	6.90	1	1	0
07/20/2024 08:00	1.3	13.8	1,575.5	1.1	6.30	1	1	0
07/20/2024 09:00	1.3	13.8	1,609.3	1.1	6.40	1	1	0
07/20/2024 10:00	1.3	13.7	1,714.5	1.1	6.90	1	1	0
07/20/2024 11:00	1.3	13.7	1,623.1	1.1	6.50	1	1	0
07/20/2024 12:00	1.3	14.0	1,339.9	1.1	5.40	1	1	0
07/20/2024 13:00	1.3	13.8	1,629.6	1.1	6.50	1	1	1
07/20/2024 14:00	1.6	11.9	2,118.6	1.0	8.50	1	1	1
07/20/2024 15:00	1.6	11.7	2,141.5	1.0	8.60	1	1	1
07/20/2024 16:00	1.6	11.6	2,151.8	1.0	8.60	1	1	1
07/20/2024 17:00	1.6	11.5	2,174.2	1.0	8.70	1	1	1
07/20/2024 18:00	1.6	11.4	2,179.3	1.0	8.70	1	1	1
07/20/2024 19:00	1.6	11.7	2,130.0	1.0	8.50	1	1	1
07/20/2024 20:00	1.6	11.8	2,117.5	1.0	8.50	1	1	1
07/20/2024 21:00	1.6	11.9	2,113.2	1.0	8.50	1	1	1
07/20/2024 22:00	1.6	11.5	2,198.9	1.0	8.80	1	1	1
07/20/2024 23:00	1.7	11.5	2,216.2	1.1	8.90	1	1	1
Average/Sum#:	1.5	12.4	1,989.7	1.0	191.00 #	24 #	24 #	18 #
Minimum:	1.3	11.4	1,339.9	1.0	5.40	1	1	0
Maximum:	1.7	14.0	2,236.4	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2024 00:00	1.6	11.5	2,230.7	1.0	8.90	1	1	1
07/21/2024 01:00	1.6	11.7	2,197.4	1.0	8.80	1	1	1
07/21/2024 02:00	1.6	11.9	2,171.9	1.0	8.70	1	1	1
07/21/2024 03:00	1.6	11.9	2,168.9	1.0	8.70	1	1	1
07/21/2024 04:00	1.6	11.9	2,172.3	1.0	8.70	1	1	1
07/21/2024 05:00	2.0	13.3	1,533.1	1.6	6.90	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2024 23:00	0.0	20.9	0.2	0.0	0.00	1	0	0
Average/Sum#:	1.4	13.3	1,782.1	0.9	50.70 #	7 #	5 #	6 #
Minimum:	0.0	11.5	0.2	0.0	0.00	0	0	0
Maximum:	2.0	20.9	2,230.7	1.6	8.90	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/22/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/22/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/22/2024 03:00	25.8	17.0	474.6	39.0	59.42	1	0	0
07/22/2024 04:00	3.9	14.0	1,341.9	3.3	16.10	1	0	0
07/22/2024 05:00	1.3	13.7	1,637.3	1.1	6.50	1	1	0
07/22/2024 06:00	1.3	13.7	1,718.5	1.1	6.90	1	1	0
07/22/2024 07:00	1.3	13.7	1,705.8	1.1	6.80	1	1	0
07/22/2024 08:00	1.3	13.8	1,696.9	1.1	6.80	1	1	0
07/22/2024 09:00	1.3	13.8	1,683.5	1.1	6.70	1	1	0
07/22/2024 10:00	1.3	13.8	1,668.6	1.1	6.70	1	1	0
07/22/2024 11:00	1.3	13.8	1,651.5	1.1	6.60	1	1	0
07/22/2024 12:00	1.4	12.9	1,789.8	1.0	7.20	1	1	1
07/22/2024 13:00	1.6	11.5	2,159.5	1.0	8.60	1	1	1
07/22/2024 14:00	1.6	11.6	2,150.2	1.0	8.60	1	1	1
07/22/2024 15:00	1.6	11.5	2,152.5	1.0	8.60	1	1	1
07/22/2024 16:00	1.7	11.5	2,167.5	1.1	8.70	1	1	1
07/22/2024 17:00	1.6	11.5	2,176.5	1.0	8.70	1	1	1
07/22/2024 18:00	1.7	11.5	2,173.0	1.1	8.70	1	1	1
07/22/2024 19:00	1.6	11.5	2,160.0	1.0	8.60	1	1	1
07/22/2024 20:00	1.6	11.7	2,123.2	1.0	8.50	1	1	1
07/22/2024 21:00	1.6	11.9	2,096.9	1.0	8.40	1	1	1
07/22/2024 22:00	1.6	11.5	2,185.0	1.0	8.70	1	1	1
07/22/2024 23:00	1.7	11.5	2,213.1	1.1	8.90	1	1	1
Average/Sum#:	2.8	12.7	1,863.1	3.0	224.72 #	21 #	19 #	12 #
Minimum:	1.3	11.5	474.6	1.0	6.50	0	0	0
Maximum:	25.8	17.0	2,213.1	39.0	59.42	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2024 00:00	1.7	11.5	2,215.9	1.1	8.90	1	1	1
07/23/2024 01:00	1.6	11.5	2,219.0	1.0	8.90	1	1	1
07/23/2024 02:00	1.6	11.5	2,230.8	1.0	8.90	1	1	1
07/23/2024 03:00	1.6	11.5	2,232.9	1.0	8.90	1	1	1
07/23/2024 04:00	1.6	11.5	2,239.4	1.0	9.00	1	1	1
07/23/2024 05:00	1.6	11.5	2,244.3	1.0	9.00	1	1	1
07/23/2024 06:00	1.5	12.3	2,064.4	1.0	8.30	1	1	1
07/23/2024 07:00	1.6	12.0	2,118.2	1.1	8.50	1	1	1
07/23/2024 08:00	1.5	12.3	2,024.9	1.0	8.10	1	1	1
07/23/2024 09:00	1.6	12.1	2,077.8	1.1	8.30	1	1	1
07/23/2024 10:00	1.6	11.9	2,112.2	1.0	8.40	1	1	1
07/23/2024 11:00	1.6	11.6	2,175.2	1.0	8.70	1	1	1
07/23/2024 12:00	1.6	11.9	2,111.8	1.0	8.40	1	1	1
07/23/2024 13:00	1.6	12.0	2,083.6	1.1	8.30	1	1	1
07/23/2024 14:00	1.6	11.8	2,128.7	1.0	8.50	1	1	1
07/23/2024 15:00	1.6	11.7	2,139.9	1.0	8.60	1	1	1
07/23/2024 16:00	1.6	11.5	2,179.1	1.0	8.70	1	1	1
07/23/2024 17:00	1.7	11.4	2,184.5	1.1	8.70	1	1	1
07/23/2024 18:00	1.6	11.4	2,185.1	1.0	8.70	1	1	1
07/23/2024 19:00	1.6	11.6	2,162.9	1.0	8.70	1	1	1
07/23/2024 20:00	1.6	11.5	2,200.7	1.0	8.80	1	1	1
07/23/2024 21:00	1.6	11.5	2,205.4	1.0	8.80	1	1	1
07/23/2024 22:00	1.6	11.8	2,163.3	1.0	8.70	1	1	1
07/23/2024 23:00	1.6	11.6	2,227.2	1.0	8.90	1	1	1
Average/Sum#:	1.6	11.7	2,163.6	1.0	207.70 #	24 #	24 #	24 #
Minimum:	1.5	11.4	2,024.9	1.0	8.10	1	1	1
Maximum:	1.7	12.3	2,244.3	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2024 00:00	1.6	11.8	2,162.2	1.0	8.60	1	1	1
07/24/2024 01:00	1.6	11.9	2,143.0	1.0	8.60	1	1	1
07/24/2024 02:00	1.6	11.9	2,148.9	1.0	8.60	1	1	1
07/24/2024 03:00	1.6	11.7	2,217.3	1.0	8.90	1	1	1
07/24/2024 04:00	1.6	11.7	2,224.5	1.0	8.90	1	1	1
07/24/2024 05:00	1.6	11.6	2,243.1	1.0	9.00	1	1	1
07/24/2024 06:00	1.7	12.1	2,119.1	1.1	8.50	1	1	1
07/24/2024 07:00	1.5	12.2	2,107.8	1.0	8.40	1	1	1
07/24/2024 08:00	1.5	12.2	2,095.3	1.0	8.40	1	1	1
07/24/2024 09:00	1.5	12.2	2,084.4	1.0	8.30	1	1	1
07/24/2024 10:00	1.5	12.2	2,076.0	1.0	8.30	1	1	1
07/24/2024 11:00	1.6	12.1	2,090.9	1.1	8.40	1	1	1
07/24/2024 12:00	1.6	11.9	2,125.1	1.0	8.50	1	1	1
07/24/2024 13:00	1.6	12.0	2,086.9	1.1	8.30	1	1	1
07/24/2024 14:00	1.6	11.8	2,115.8	1.0	8.50	1	1	1
07/24/2024 15:00	1.6	11.6	2,138.3	1.0	8.60	1	1	1
07/24/2024 16:00	1.5	12.3	2,029.2	1.0	8.10	1	1	1
07/24/2024 17:00	1.5	12.4	2,006.3	1.0	8.00	1	1	1
07/24/2024 18:00	1.5	12.4	2,016.7	1.0	8.10	1	1	1
07/24/2024 19:00	1.5	12.4	2,037.3	1.0	8.10	1	1	1
07/24/2024 20:00	1.5	12.4	2,044.5	1.0	8.20	1	1	1
07/24/2024 21:00	1.6	12.0	2,161.2	1.1	8.60	1	1	1
07/24/2024 22:00	1.6	11.7	2,227.1	1.0	8.90	1	1	1
07/24/2024 23:00	1.6	12.0	2,156.3	1.1	8.60	1	1	1
Average/Sum#:	1.6	12.0	2,119.1	1.0	203.40 #	24 #	24 #	24 #
Minimum:	1.5	11.6	2,006.3	1.0	8.00	1	1	1
Maximum:	1.7	12.4	2,243.1	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2024 00:00	1.5	12.3	2,092.2	1.0	8.40	1	1	1
07/25/2024 01:00	1.5	12.4	2,082.4	1.0	8.30	1	1	1
07/25/2024 02:00	1.5	12.4	2,073.8	1.0	8.30	1	1	1
07/25/2024 03:00	1.6	12.1	2,144.4	1.1	8.60	1	1	1
07/25/2024 04:00	1.6	12.0	2,171.7	1.1	8.70	1	1	1
07/25/2024 05:00	1.6	12.0	2,164.4	1.1	8.70	1	1	1
07/25/2024 06:00	1.4	12.3	2,105.5	1.0	8.40	1	1	1
07/25/2024 07:00	1.5	12.2	2,112.2	1.0	8.40	1	1	1
07/25/2024 08:00	1.5	12.2	2,101.8	1.0	8.40	1	1	1
07/25/2024 09:00	1.5	12.3	2,090.3	1.0	8.40	1	1	1
07/25/2024 10:00	1.5	12.4	2,059.1	1.0	8.20	1	1	1
07/25/2024 11:00	1.6	12.0	2,126.7	1.1	8.50	1	1	1
07/25/2024 12:00	1.6	12.0	2,128.3	1.1	8.50	1	1	1
07/25/2024 13:00	1.6	12.0	2,122.3	1.1	8.50	1	1	1
07/25/2024 14:00	1.6	11.8	2,135.0	1.0	8.50	1	1	1
07/25/2024 15:00	1.6	11.7	2,158.0	1.0	8.60	1	1	1
07/25/2024 16:00	1.6	11.9	2,119.5	1.0	8.50	1	1	1
07/25/2024 17:00	1.6	11.9	2,111.2	1.0	8.40	1	1	1
07/25/2024 18:00	1.5	12.1	2,078.0	1.0	8.30	1	1	1
07/25/2024 19:00	1.5	12.2	2,054.0	1.0	8.20	1	1	1
07/25/2024 20:00	1.6	11.8	2,155.7	1.0	8.60	1	1	1
07/25/2024 21:00	1.6	11.8	2,169.1	1.0	8.70	1	1	1
07/25/2024 22:00	1.6	12.0	2,135.5	1.1	8.50	1	1	1
07/25/2024 23:00	1.6	11.7	2,216.7	1.0	8.90	1	1	1
Average/Sum#:	1.6	12.1	2,121.2	1.0	203.50 #	24 #	24 #	24 #
Minimum:	1.4	11.7	2,054.0	1.0	8.20	1	1	1
Maximum:	1.6	12.4	2,216.7	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2024 00:00	1.6	11.9	2,173.2	1.0	8.70	1	1	1
07/26/2024 01:00	1.5	12.5	2,042.4	1.1	8.20	1	1	1
07/26/2024 02:00	1.5	12.9	1,967.8	1.1	7.90	1	1	1
07/26/2024 03:00	1.5	12.9	1,971.9	1.1	7.90	1	1	1
07/26/2024 04:00	1.6	12.3	2,113.9	1.1	8.50	1	1	1
07/26/2024 05:00	1.5	12.4	2,081.0	1.0	8.30	1	1	1
07/26/2024 06:00	1.3	12.9	1,973.1	1.0	7.90	1	1	1
07/26/2024 07:00	1.4	12.8	1,972.6	1.0	7.90	1	1	1
07/26/2024 08:00	1.5	12.8	1,976.0	1.1	7.90	1	1	1
07/26/2024 09:00	1.5	12.7	1,983.7	1.1	7.90	1	1	1
07/26/2024 10:00	1.5	12.6	1,992.4	1.1	8.00	1	1	1
07/26/2024 11:00	1.5	12.6	2,002.2	1.1	8.00	1	1	1
07/26/2024 12:00	1.5	12.4	2,013.1	1.0	8.10	1	1	1
07/26/2024 13:00	1.5	12.3	2,036.9	1.0	8.10	1	1	1
07/26/2024 14:00	1.6	12.2	2,050.8	1.1	8.20	1	1	1
07/26/2024 15:00	1.6	12.0	2,089.7	1.1	8.40	1	1	1
07/26/2024 16:00	1.6	11.7	2,134.0	1.0	8.50	1	1	1
07/26/2024 17:00	1.6	11.7	2,136.6	1.0	8.50	1	1	1
07/26/2024 18:00	1.6	12.2	2,054.2	1.1	8.20	1	1	1
07/26/2024 19:00	1.6	12.1	2,104.4	1.1	8.40	1	1	1
07/26/2024 20:00	1.6	11.7	2,202.5	1.0	8.80	1	1	1
07/26/2024 21:00	1.5	12.4	2,064.6	1.0	8.30	1	1	1
07/26/2024 22:00	1.5	12.4	2,059.4	1.0	8.20	1	1	1
07/26/2024 23:00	1.4	12.9	1,971.9	1.0	7.90	1	1	1
Average/Sum#:	1.5	12.4	2,048.7	1.1	196.70 #	24 #	24 #	24 #
Minimum:	1.3	11.7	1,967.8	1.0	7.90	1	1	1
Maximum:	1.6	12.9	2,202.5	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2024 00:00	1.5	12.9	1,975.4	1.1	7.90	1	1	1
07/27/2024 01:00	1.4	12.9	1,974.7	1.0	7.90	1	1	1
07/27/2024 02:00	1.4	12.9	1,977.4	1.0	7.90	1	1	1
07/27/2024 03:00	1.4	12.9	1,979.9	1.0	7.90	1	1	1
07/27/2024 04:00	1.5	12.8	2,018.0	1.1	8.10	1	1	1
07/27/2024 05:00	1.5	12.6	2,044.3	1.1	8.20	1	1	1
07/27/2024 06:00	0.0	0.0	674.5	0.0	0.00	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/27/2024 15:00	21.6	17.9	327.7	42.5	21.97	1	0	0
07/27/2024 16:00	13.0	14.8	1,036.1	12.6	47.70	1	0	0
07/27/2024 17:00	1.3	13.7	1,729.5	1.1	6.90	1	1	0
07/27/2024 18:00	1.2	13.7	1,588.0	1.0	6.40	1	1	1
07/27/2024 19:00	1.5	12.7	1,978.4	1.1	7.90	1	1	1
07/27/2024 20:00	1.5	12.7	1,973.8	1.1	7.90	1	1	1
07/27/2024 21:00	1.5	12.8	1,968.8	1.1	7.90	1	1	1
07/27/2024 22:00	1.5	12.8	1,963.4	1.1	7.90	1	1	1
07/27/2024 23:00	1.5	12.8	1,961.2	1.1	7.80	1	1	1
Average/Sum#:	3.6	13.4	1,698.2	4.6	170.27 #	16 #	13 #	12 #
Minimum:	1.2	12.6	327.7	1.0	6.40	0	0	0
Maximum:	21.6	17.9	2,044.3	42.5	47.70	1	1	1
%SI	37.50	37.50	33.33	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2024 00:00	1.4	12.9	1,960.1	1.0	7.80	1	1	1
07/28/2024 01:00	1.5	12.9	1,963.6	1.1	7.90	1	1	1
07/28/2024 02:00	1.4	12.9	1,963.2	1.0	7.90	1	1	1
07/28/2024 03:00	1.5	13.0	1,960.7	1.1	7.80	1	1	1
07/28/2024 04:00	1.4	13.0	1,955.1	1.0	7.80	1	1	1
07/28/2024 05:00	1.3	13.8	1,704.4	1.1	6.80	1	1	0
07/28/2024 06:00	1.2	13.9	1,314.0	1.0	5.30	1	1	0
07/28/2024 07:00	9.4	16.4	325.2	12.3	2.48	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/28/2024 14:00	17.8	17.0	490.8	26.9	23.33	1	0	0
07/28/2024 15:00	8.4	14.4	1,218.9	7.6	34.10	1	0	0
07/28/2024 16:00	1.3	13.8	1,678.3	1.1	6.70	1	1	1
07/28/2024 17:00	1.5	13.0	1,882.7	1.1	7.50	1	1	1
07/28/2024 18:00	1.5	13.0	1,882.5	1.1	7.50	1	1	1
07/28/2024 19:00	1.5	13.0	1,887.4	1.1	7.50	1	1	1
07/28/2024 20:00	1.5	12.7	1,958.7	1.1	7.80	1	1	1
07/28/2024 21:00	1.5	12.7	1,959.5	1.1	7.80	1	1	1
07/28/2024 22:00	1.3	13.8	1,505.8	1.1	6.00	1	1	0
07/28/2024 23:00	1.3	13.8	1,668.8	1.1	6.70	1	1	0
Average/Sum#:	3.2	13.7	1,626.7	3.5	168.71 #	18 #	15 #	11 #
Minimum:	1.2	12.7	325.2	1.0	2.48	0	0	0
Maximum:	17.8	17.0	1,963.6	26.9	34.10	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2024 00:00	1.3	13.8	1,529.5	1.1	6.10	1	1	0
07/29/2024 01:00	1.3	13.9	1,523.7	1.1	6.10	1	1	0
07/29/2024 02:00	1.3	13.8	1,533.1	1.1	6.10	1	1	0
07/29/2024 03:00	2.2	15.6	592.0	2.4	1.22	1	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/29/2024 14:00	0.0	20.9	0.2	0.0	0.00	1	0	0
07/29/2024 15:00	20.4	17.0	456.9	30.9	52.10	1	0	0
07/29/2024 16:00	6.9	14.2	1,359.6	6.1	29.90	1	0	0
07/29/2024 17:00	1.3	13.7	1,655.4	1.1	6.60	1	1	0
07/29/2024 18:00	1.4	13.0	1,802.5	1.0	7.20	1	1	1
07/29/2024 19:00	1.7	11.5	2,207.5	1.1	8.80	1	1	1
07/29/2024 20:00	1.6	11.6	2,218.7	1.0	8.90	1	1	1
07/29/2024 21:00	1.5	12.2	2,071.6	1.0	8.30	1	1	1
07/29/2024 22:00	1.6	12.3	2,043.9	1.1	8.20	1	1	1
07/29/2024 23:00	2.1	15.5	683.3	2.3	1.54	1	0	0
Average/Sum#:	3.2	14.2	1,405.6	3.7	151.06 #	14 #	9 #	5 #
Minimum:	0.0	11.5	0.2	0.0	0.00	0	0	0
Maximum:	20.4	20.9	2,218.7	30.9	52.10	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/30/2024 15:00	25.8	17.0	474.0	39.0	59.42	1	0	0
07/30/2024 16:00	8.9	14.4	1,198.0	8.1	35.90	1	0	0
07/30/2024 17:00	1.2	13.9	1,447.5	1.0	5.80	1	1	0
07/30/2024 18:00	1.3	13.2	1,750.3	1.0	7.00	1	1	1
07/30/2024 19:00	1.7	11.7	2,204.1	1.1	8.80	1	1	1
07/30/2024 20:00	1.5	11.6	2,212.3	1.0	8.80	1	1	1
07/30/2024 21:00	1.7	11.6	2,196.4	1.1	8.80	1	1	1
07/30/2024 22:00	1.6	12.0	2,112.7	1.1	8.50	1	1	1
07/30/2024 23:00	1.6	12.0	2,123.8	1.1	8.50	1	1	1
Average/Sum#:	5.0	13.0	1,746.6	6.1	151.52 #	9 #	7 #	6 #
Minimum:	1.2	11.6	474.0	1.0	5.80	0	0	0
Maximum:	25.8	17.0	2,212.3	39.0	59.42	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2024 00:00	1.5	12.7	1,963.4	1.1	7.90	1	1	1
07/31/2024 01:00	1.5	12.8	1,956.7	1.1	7.80	1	1	1
07/31/2024 02:00	1.5	12.8	1,955.8	1.1	7.80	1	1	1
07/31/2024 03:00	1.4	12.7	1,981.9	1.0	7.90	1	1	1
07/31/2024 04:00	1.6	11.7	2,236.4	1.0	8.90	1	1	1
07/31/2024 05:00	1.6	12.0	2,126.5	1.1	8.50	1	1	1
07/31/2024 06:00	1.2	13.8	1,715.5	1.0	6.90	1	1	0
07/31/2024 07:00	1.3	13.8	1,587.4	1.1	6.30	1	1	0
07/31/2024 08:00	1.3	13.8	1,493.0	1.1	6.00	1	1	0
07/31/2024 09:00	1.3	13.8	1,497.3	1.1	6.00	1	1	0
07/31/2024 10:00	1.3	13.8	1,544.2	1.1	6.20	1	1	0
07/31/2024 11:00	1.3	13.8	1,576.3	1.1	6.30	1	1	0
07/31/2024 12:00	1.3	13.9	1,465.8	1.1	5.90	1	1	0
07/31/2024 13:00	1.3	13.7	1,624.7	1.1	6.50	1	1	0
07/31/2024 14:00	1.6	11.9	2,102.0	1.0	8.40	1	1	1
07/31/2024 15:00	1.7	11.5	2,192.3	1.1	8.80	1	1	1
07/31/2024 16:00	1.6	11.5	2,184.0	1.0	8.70	1	1	1
07/31/2024 17:00	1.6	11.5	2,193.3	1.0	8.80	1	1	1
07/31/2024 18:00	1.7	11.5	2,181.2	1.1	8.70	1	1	1
07/31/2024 19:00	1.6	11.7	2,154.5	1.0	8.60	1	1	1
07/31/2024 20:00	1.6	11.8	2,131.2	1.0	8.50	1	1	1
07/31/2024 21:00	1.6	11.9	2,108.1	1.0	8.40	1	1	1
07/31/2024 22:00	1.6	12.0	2,099.2	1.1	8.40	1	1	1
07/31/2024 23:00	1.6	12.0	2,096.3	1.1	8.40	1	1	1
Average/Sum#:	1.5	12.6	1,923.6	1.1	184.60 #	24 #	24 #	16 #
Minimum:	1.2	11.5	1,465.8	1.0	5.90	1	1	0
Maximum:	1.7	13.9	2,236.4	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2024 00:00	1.6	12.1	2,088.9	1.1	8.40	1	1	1
08/01/2024 01:00	1.5	12.1	2,086.6	1.0	8.30	1	1	1
08/01/2024 02:00	1.5	12.2	2,082.6	1.0	8.30	1	1	1
08/01/2024 03:00	1.5	12.3	2,076.8	1.0	8.30	1	1	1
08/01/2024 04:00	1.5	12.3	2,080.7	1.0	8.30	1	1	1
08/01/2024 05:00	1.6	11.7	2,215.0	1.0	8.90	1	1	1
08/01/2024 06:00	1.4	12.2	2,103.6	0.9	6.30	1	1	1
08/01/2024 07:00	1.3	13.7	1,704.4	1.1	6.80	1	1	0
08/01/2024 08:00	1.3	13.7	1,732.1	1.1	6.90	1	1	0
08/01/2024 09:00	1.3	13.7	1,742.0	1.1	7.00	1	1	0
08/01/2024 10:00	1.3	13.7	1,727.8	1.1	6.90	1	1	0
08/01/2024 11:00	1.3	13.7	1,710.0	1.1	6.80	1	1	0
08/01/2024 12:00	1.3	13.7	1,703.5	1.1	6.80	1	1	1
08/01/2024 13:00	1.6	11.9	2,126.9	1.0	8.50	1	1	1
08/01/2024 14:00	1.7	11.6	2,177.1	1.1	8.70	1	1	1
08/01/2024 15:00	1.6	11.5	2,199.0	1.0	8.80	1	1	1
08/01/2024 16:00	1.6	11.5	2,206.4	1.0	8.80	1	1	1
08/01/2024 17:00	1.6	11.5	2,203.4	1.0	8.80	1	1	1
08/01/2024 18:00	1.6	11.6	2,192.8	1.0	8.80	1	1	1
08/01/2024 19:00	1.6	11.8	2,149.2	1.0	8.60	1	1	1
08/01/2024 20:00	1.6	12.0	2,115.9	1.1	8.50	1	1	1
08/01/2024 21:00	1.5	12.3	2,071.8	1.0	8.30	1	1	1
08/01/2024 22:00	1.5	12.3	2,074.7	1.0	8.30	1	1	1
08/01/2024 23:00	1.6	11.7	2,235.6	1.0	8.90	1	1	1
Average/Sum#:	1.5	12.4	2,033.6	1.0	193.00 #	24 #	24 #	19 #
Minimum:	1.3	11.5	1,703.5	0.9	6.30	1	1	0
Maximum:	1.7	13.7	2,235.6	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2024 00:00	1.6	11.7	2,233.9	1.0	8.90	1	1	1
08/02/2024 01:00	1.6	11.7	2,227.3	1.0	8.90	1	1	1
08/02/2024 02:00	1.6	11.6	2,249.8	1.0	9.00	1	1	1
08/02/2024 03:00	1.6	11.6	2,258.1	1.0	9.00	1	1	1
08/02/2024 04:00	1.6	11.6	2,253.9	1.0	9.00	1	1	1
08/02/2024 05:00	1.6	11.6	2,260.7	1.0	9.00	1	1	1
08/02/2024 06:00	1.6	11.6	2,252.2	1.0	9.00	1	1	1
08/02/2024 07:00	1.6	11.6	2,245.9	1.0	9.00	1	1	1
08/02/2024 08:00	1.6	11.6	2,247.2	1.0	9.00	1	1	1
08/02/2024 09:00	1.6	11.6	2,236.9	1.0	8.90	1	1	1
08/02/2024 10:00	1.6	11.6	2,230.4	1.0	8.90	1	1	1
08/02/2024 11:00	1.6	11.5	2,221.6	1.0	8.90	1	1	1
08/02/2024 12:00	1.6	11.5	2,210.7	1.0	8.80	1	1	1
08/02/2024 13:00	1.6	11.5	2,211.0	1.0	8.80	1	1	1
08/02/2024 14:00	1.6	11.5	2,210.0	1.0	8.80	1	1	1
08/02/2024 15:00	1.6	11.5	2,206.6	1.0	8.80	1	1	1
08/02/2024 16:00	1.6	11.5	2,215.5	1.0	8.90	1	1	1
08/02/2024 17:00	1.7	11.5	2,211.7	1.1	8.80	1	1	1
08/02/2024 18:00	1.6	11.5	2,213.8	1.0	8.90	1	1	1
08/02/2024 19:00	1.6	11.6	2,196.2	1.0	8.80	1	1	1
08/02/2024 20:00	1.6	11.7	2,184.9	1.0	8.70	1	1	1
08/02/2024 21:00	1.6	11.5	2,236.7	1.0	8.90	1	1	1
08/02/2024 22:00	1.6	11.5	2,240.1	1.0	9.00	1	1	1
08/02/2024 23:00	1.6	11.5	2,240.1	1.0	9.00	1	1	1
Average/Sum#:	1.6	11.6	2,229.0	1.0	213.70 #	24 #	24 #	24 #
Minimum:	1.6	11.5	2,184.9	1.0	8.70	1	1	1
Maximum:	1.7	11.7	2,260.7	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2024 00:00	1.6	11.5	2,238.4	1.0	9.00	1	1	1
08/03/2024 01:00	1.6	11.5	2,235.6	1.0	8.90	1	1	1
08/03/2024 02:00	1.6	11.8	2,165.9	1.0	8.70	1	1	1
08/03/2024 03:00	1.5	12.5	2,014.5	1.1	8.10	1	1	1
08/03/2024 04:00	1.5	12.6	2,008.0	1.1	8.00	1	1	1
08/03/2024 05:00	1.5	12.5	2,027.8	1.1	8.10	1	1	1
08/03/2024 06:00	1.3	12.7	1,968.4	0.9	5.90	1	1	1
08/03/2024 07:00	1.4	12.7	1,975.9	1.0	7.90	1	1	1
08/03/2024 08:00	1.5	12.6	1,979.7	1.1	7.90	1	1	1
08/03/2024 09:00	1.5	12.6	1,988.9	1.1	8.00	1	1	1
08/03/2024 10:00	1.5	12.6	1,993.7	1.1	8.00	1	1	1
08/03/2024 11:00	1.5	12.5	1,998.6	1.1	8.00	1	1	1
08/03/2024 12:00	1.5	12.5	1,997.0	1.1	8.00	1	1	1
08/03/2024 13:00	1.5	12.5	2,000.2	1.1	8.00	1	1	1
08/03/2024 14:00	1.5	12.2	2,043.5	1.0	8.20	1	1	1
08/03/2024 15:00	1.5	12.3	2,031.1	1.0	8.10	1	1	1
08/03/2024 16:00	1.5	12.2	2,044.8	1.0	8.20	1	1	1
08/03/2024 17:00	1.6	11.9	2,123.2	1.0	8.50	1	1	1
08/03/2024 18:00	1.6	11.6	2,198.4	1.0	8.80	1	1	1
08/03/2024 19:00	1.6	11.7	2,182.3	1.0	8.70	1	1	1
08/03/2024 20:00	1.6	11.8	2,155.9	1.0	8.60	1	1	1
08/03/2024 21:00	1.6	11.9	2,143.2	1.0	8.60	1	1	1
08/03/2024 22:00	1.6	12.0	2,125.4	1.1	8.50	1	1	1
08/03/2024 23:00	1.6	11.6	2,213.3	1.0	8.90	1	1	1
Average/Sum#:	1.5	12.2	2,077.2	1.0	197.60 #	24 #	24 #	24 #
Minimum:	1.3	11.5	1,968.4	0.9	5.90	1	1	1
Maximum:	1.6	12.7	2,238.4	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2024 00:00	1.5	12.5	1,999.9	1.1	8.00	1	1	1
08/04/2024 01:00	1.5	12.5	2,012.4	1.1	8.00	1	1	1
08/04/2024 02:00	1.5	12.7	1,951.1	1.1	7.80	1	1	1
08/04/2024 03:00	1.3	13.8	1,718.2	1.1	6.90	1	1	0
08/04/2024 04:00	1.3	13.7	1,744.7	1.1	7.00	1	1	0
08/04/2024 05:00	1.3	13.7	1,745.0	1.1	7.00	1	1	0
08/04/2024 06:00	1.3	13.8	1,713.1	1.1	6.90	1	1	0
08/04/2024 07:00	1.3	13.8	1,595.9	1.1	6.40	1	1	0
08/04/2024 08:00	1.3	13.8	1,599.6	1.1	6.40	1	1	0
08/04/2024 09:00	1.3	13.8	1,466.3	1.1	5.90	1	1	0
08/04/2024 10:00	1.3	13.8	1,604.6	1.1	6.40	1	1	0
08/04/2024 11:00	1.3	13.7	1,666.6	1.1	6.70	1	1	0
08/04/2024 12:00	1.3	13.8	1,538.3	1.1	6.20	1	1	1
08/04/2024 13:00	1.5	12.3	2,027.1	1.0	8.10	1	1	1
08/04/2024 14:00	1.6	12.1	2,047.0	1.1	8.20	1	1	1
08/04/2024 15:00	1.6	12.1	2,043.5	1.1	8.20	1	1	1
08/04/2024 16:00	1.6	11.9	2,086.0	1.0	8.30	1	1	1
08/04/2024 17:00	1.6	11.5	2,174.8	1.0	8.70	1	1	1
08/04/2024 18:00	1.6	11.5	2,171.5	1.0	8.70	1	1	1
08/04/2024 19:00	1.6	12.0	2,085.4	1.1	8.30	1	1	1
08/04/2024 20:00	1.7	11.6	2,201.7	1.1	8.80	1	1	1
08/04/2024 21:00	1.6	11.5	2,220.0	1.0	8.90	1	1	1
08/04/2024 22:00	1.6	11.5	2,231.1	1.0	8.90	1	1	1
08/04/2024 23:00	1.6	11.5	2,240.4	1.0	9.00	1	1	1
Average/Sum#:	1.5	12.7	1,911.8	1.1	183.70 #	24 #	24 #	15 #
Minimum:	1.3	11.5	1,466.3	1.0	5.90	1	1	0
Maximum:	1.7	13.8	2,240.4	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2024 00:00	1.7	11.5	2,240.8	1.1	9.00	1	1	1
08/05/2024 01:00	1.6	11.7	2,224.8	1.0	8.90	1	1	1
08/05/2024 02:00	1.6	11.8	2,207.4	1.0	8.80	1	1	1
08/05/2024 03:00	1.6	11.9	2,194.3	1.0	8.80	1	1	1
08/05/2024 04:00	1.6	11.6	2,262.5	1.0	9.10	1	1	1
08/05/2024 05:00	1.6	11.6	2,264.3	1.0	9.10	1	1	1
08/05/2024 06:00	1.4	12.4	2,101.9	1.0	8.40	1	1	1
08/05/2024 07:00	1.4	12.8	1,968.0	1.0	7.90	1	1	1
08/05/2024 08:00	1.5	12.8	1,950.1	1.1	7.80	1	1	1
08/05/2024 09:00	1.4	12.8	1,956.1	1.0	7.80	1	1	1
08/05/2024 10:00	1.5	12.7	1,965.3	1.1	7.90	1	1	1
08/05/2024 11:00	1.5	12.5	2,009.5	1.1	8.00	1	1	1
08/05/2024 12:00	1.5	12.3	2,048.3	1.0	8.20	1	1	1
08/05/2024 13:00	1.5	12.3	2,046.5	1.0	8.20	1	1	1
08/05/2024 14:00	1.6	11.6	2,184.4	1.0	8.70	1	1	1
08/05/2024 15:00	1.6	12.2	2,045.2	1.1	8.20	1	1	1
08/05/2024 16:00	1.5	12.4	2,001.6	1.0	8.00	1	1	1
08/05/2024 17:00	1.5	12.3	2,027.7	1.0	8.10	1	1	1
08/05/2024 18:00	1.6	11.8	2,131.0	1.0	8.50	1	1	1
08/05/2024 19:00	1.5	12.5	2,002.2	1.1	8.00	1	1	1
08/05/2024 20:00	1.6	11.6	2,216.1	1.0	8.90	1	1	1
08/05/2024 21:00	1.6	11.5	2,230.5	1.0	8.90	1	1	1
08/05/2024 22:00	1.7	11.5	2,231.7	1.1	8.90	1	1	1
08/05/2024 23:00	1.6	11.7	2,211.1	1.0	8.80	1	1	1
Average/Sum#:	1.6	12.1	2,113.4	1.0	202.90 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,950.1	1.0	7.80	1	1	1
Maximum:	1.7	12.8	2,264.3	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2024 00:00	1.5	12.5	2,034.1	1.1	8.10	1	1	1
08/06/2024 01:00	1.4	12.9	1,959.5	1.0	7.80	1	1	1
08/06/2024 02:00	1.5	12.9	1,951.3	1.1	7.80	1	1	1
08/06/2024 03:00	1.4	12.9	1,952.1	1.0	7.80	1	1	1
08/06/2024 04:00	1.5	12.2	2,124.8	1.0	8.50	1	1	1
08/06/2024 05:00	1.6	12.0	2,190.2	1.1	8.80	1	1	1
08/06/2024 06:00	1.4	12.6	2,055.4	1.0	8.20	1	1	1
08/06/2024 07:00	1.4	12.9	1,952.6	1.0	7.80	1	1	1
08/06/2024 08:00	1.4	12.9	1,951.8	1.0	7.80	1	1	1
08/06/2024 09:00	1.4	12.8	1,957.5	1.0	7.80	1	1	1
08/06/2024 10:00	1.4	12.7	1,965.4	1.0	7.90	1	1	1
08/06/2024 11:00	1.5	12.7	1,974.3	1.1	7.90	1	1	1
08/06/2024 12:00	1.5	12.6	1,984.8	1.1	7.90	1	1	1
08/06/2024 13:00	1.5	12.5	1,989.0	1.1	8.00	1	1	1
08/06/2024 14:00	1.5	12.5	1,993.7	1.1	8.00	1	1	1
08/06/2024 15:00	1.5	12.5	1,998.0	1.1	8.00	1	1	1
08/06/2024 16:00	1.5	12.1	2,084.9	1.0	8.30	1	1	1
08/06/2024 17:00	1.6	11.8	2,143.8	1.0	8.60	1	1	1
08/06/2024 18:00	1.6	11.5	2,196.2	1.0	8.80	1	1	1
08/06/2024 19:00	1.6	11.7	2,164.5	1.0	8.70	1	1	1
08/06/2024 20:00	1.6	12.0	2,111.5	1.1	8.40	1	1	1
08/06/2024 21:00	1.6	11.9	2,130.1	1.0	8.50	1	1	1
08/06/2024 22:00	1.6	11.8	2,171.1	1.0	8.70	1	1	1
08/06/2024 23:00	1.5	12.4	2,032.3	1.0	8.10	1	1	1
Average/Sum#:	1.5	12.4	2,044.5	1.0	196.20 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,951.3	1.0	7.80	1	1	1
Maximum:	1.6	12.9	2,196.2	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2024 00:00	1.5	12.6	2,005.7	1.1	8.00	1	1	1
08/07/2024 01:00	1.6	11.8	2,197.5	1.0	8.80	1	1	1
08/07/2024 02:00	1.5	12.3	2,062.8	1.0	8.30	1	1	1
08/07/2024 03:00	1.5	12.8	1,956.0	1.1	7.80	1	1	1
08/07/2024 04:00	1.4	12.8	1,967.1	1.0	7.90	1	1	1
08/07/2024 05:00	1.5	12.2	2,106.8	1.0	8.40	1	1	1
08/07/2024 06:00	1.4	12.3	2,128.3	1.0	8.50	1	1	1
08/07/2024 07:00	1.5	12.8	1,959.1	1.1	7.80	1	1	1
08/07/2024 08:00	1.4	12.8	1,962.8	1.0	7.90	1	1	1
08/07/2024 09:00	1.5	12.8	1,969.1	1.1	7.90	1	1	1
08/07/2024 10:00	1.5	12.7	1,979.4	1.1	7.90	1	1	1
08/07/2024 11:00	1.5	12.5	1,987.9	1.1	8.00	1	1	1
08/07/2024 12:00	1.5	12.4	1,998.3	1.0	8.00	1	1	1
08/07/2024 13:00	1.5	12.3	2,029.2	1.0	8.10	1	1	1
08/07/2024 14:00	1.5	12.1	2,070.8	1.0	8.30	1	1	1
08/07/2024 15:00	1.5	12.2	2,041.6	1.0	8.20	1	1	1
08/07/2024 16:00	1.5	12.2	2,037.4	1.0	8.10	1	1	1
08/07/2024 17:00	1.6	11.7	2,145.9	1.0	8.60	1	1	1
08/07/2024 18:00	1.6	11.5	2,191.9	1.0	8.80	1	1	1
08/07/2024 19:00	1.6	11.7	2,162.0	1.0	8.60	1	1	1
08/07/2024 20:00	1.6	11.9	2,118.3	1.0	8.50	1	1	1
08/07/2024 21:00	1.5	12.2	2,062.5	1.0	8.30	1	1	1
08/07/2024 22:00	1.5	12.7	1,968.4	1.1	7.90	1	1	1
08/07/2024 23:00	1.6	11.8	2,183.4	1.0	8.70	1	1	1
Average/Sum#:	1.5	12.3	2,053.8	1.0	197.30 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,956.0	1.0	7.80	1	1	1
Maximum:	1.6	12.8	2,197.5	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2024 00:00	1.6	11.6	2,242.0	1.0	9.00	1	1	1
08/08/2024 01:00	1.5	12.2	2,090.8	1.0	8.40	1	1	1
08/08/2024 02:00	1.3	13.8	1,658.7	1.1	6.60	1	1	0
08/08/2024 03:00	1.3	13.8	1,695.2	1.1	6.80	1	1	0
08/08/2024 04:00	1.3	13.8	1,665.4	1.1	6.70	1	1	0
08/08/2024 05:00	1.3	13.8	1,732.3	1.1	6.90	1	1	0
08/08/2024 06:00	1.3	13.8	1,728.1	1.1	6.90	1	1	0
08/08/2024 07:00	1.3	13.8	1,668.4	1.1	6.70	1	1	0
08/08/2024 08:00	1.3	13.8	1,564.0	1.1	6.30	1	1	0
08/08/2024 09:00	1.3	13.8	1,556.1	1.1	6.20	1	1	0
08/08/2024 10:00	1.3	13.8	1,550.2	1.1	6.20	1	1	0
08/08/2024 11:00	1.3	13.9	1,340.5	1.1	5.40	1	1	0
08/08/2024 12:00	1.3	14.0	1,328.2	1.1	5.30	1	1	0
08/08/2024 13:00	1.3	14.0	1,330.7	1.1	5.30	1	1	0
08/08/2024 14:00	1.3	13.8	1,517.8	1.1	6.10	1	1	1
08/08/2024 15:00	1.5	12.2	2,021.9	1.0	8.10	1	1	1
08/08/2024 16:00	1.6	12.1	2,046.9	1.1	8.20	1	1	1
08/08/2024 17:00	1.6	12.1	2,062.1	1.1	8.20	1	1	1
08/08/2024 18:00	1.6	11.5	2,183.3	1.0	8.70	1	1	1
08/08/2024 19:00	1.6	11.6	2,161.9	1.0	8.60	1	1	1
08/08/2024 20:00	1.6	11.9	2,120.8	1.0	8.50	1	1	1
08/08/2024 21:00	1.5	12.1	2,085.5	1.0	8.30	1	1	1
08/08/2024 22:00	1.5	12.4	2,024.3	1.0	8.10	1	1	1
08/08/2024 23:00	1.5	12.2	2,080.5	1.0	8.30	1	1	1
Average/Sum#:	1.4	13.0	1,810.7	1.1	173.80 #	24 #	24 #	12 #
Minimum:	1.3	11.5	1,328.2	1.0	5.30	1	1	0
Maximum:	1.6	14.0	2,242.0	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2024 00:00	1.2	13.8	1,601.0	1.0	6.40	1	1	1
08/09/2024 01:00	1.3	13.8	1,696.1	1.1	6.80	1	1	0
08/09/2024 02:00	1.3	13.8	1,724.0	1.1	6.90	1	1	0
08/09/2024 03:00	1.3	13.8	1,709.1	1.1	6.80	1	1	0
08/09/2024 04:00	1.3	13.8	1,743.7	1.1	7.00	1	1	0
08/09/2024 05:00	1.3	13.8	1,743.5	1.1	7.00	1	1	0
08/09/2024 06:00	1.2	13.8	1,708.3	1.0	6.80	1	1	0
08/09/2024 07:00	1.3	13.8	1,551.5	1.1	6.20	1	1	0
08/09/2024 08:00	1.3	13.9	1,455.8	1.1	5.80	1	1	0
08/09/2024 09:00	1.3	13.9	1,529.7	1.1	6.10	1	1	0
08/09/2024 10:00	1.3	13.9	1,561.7	1.1	6.20	1	1	0
08/09/2024 11:00	1.3	13.9	1,580.2	1.1	6.30	1	1	0
08/09/2024 12:00	1.3	13.8	1,637.8	1.1	6.60	1	1	0
08/09/2024 13:00	1.3	13.8	1,693.4	1.1	6.80	1	1	0
08/09/2024 14:00	1.3	13.7	1,594.2	1.1	6.40	1	1	1
08/09/2024 15:00	1.5	12.3	2,011.3	1.0	8.00	1	1	1
08/09/2024 16:00	1.6	12.1	2,064.4	1.1	8.30	1	1	1
08/09/2024 17:00	1.6	11.7	2,132.2	1.0	8.50	1	1	1
08/09/2024 18:00	1.6	11.5	2,187.3	1.0	8.70	1	1	1
08/09/2024 19:00	1.6	11.8	2,143.2	1.0	8.60	1	1	1
08/09/2024 20:00	1.6	12.0	2,081.7	1.1	8.30	1	1	1
08/09/2024 21:00	3.0	15.4	689.3	3.2	2.32	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.4	1,720.0	1.2	150.82 #	22 #	21 #	8 #
Minimum:	1.2	11.5	689.3	1.0	2.32	0	0	0
Maximum:	3.0	15.4	2,187.3	3.2	8.70	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2024 13:00	27.5	17.5	357.7	47.7	44.10	1	0	0
08/10/2024 14:00	9.4	17.0	439.5	14.2	22.90	1	0	0
08/10/2024 15:00	9.3	15.3	977.0	9.8	35.20	1	0	0
08/10/2024 16:00	1.3	13.7	1,670.0	1.1	6.70	1	1	1
08/10/2024 17:00	1.6	12.2	2,089.4	1.1	8.40	1	1	1
08/10/2024 18:00	1.6	11.8	2,146.9	1.0	8.60	1	1	1
08/10/2024 19:00	1.7	11.8	2,134.4	1.1	8.50	1	1	1
08/10/2024 20:00	1.6	11.8	2,141.0	1.0	8.60	1	1	1
08/10/2024 21:00	1.6	12.1	2,083.3	1.1	8.30	1	1	1
08/10/2024 22:00	1.6	12.5	1,987.7	1.1	8.00	1	1	1
08/10/2024 23:00	1.6	15.6	612.9	1.8	1.08	1	0	0
Average/Sum#:	5.3	13.8	1,512.7	7.4	160.38 #	11 #	7 #	7 #
Minimum:	1.3	11.8	357.7	1.0	1.08	0	0	0
Maximum:	27.5	17.5	2,146.9	47.7	44.10	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/12/2024 18:00	23.9	17.5	333.2	41.5	31.62	1	0	0
08/12/2024 19:00	18.4	16.2	592.2	23.1	50.30	1	0	0
08/12/2024 20:00	3.3	13.9	1,495.0	2.8	15.00	1	0	0
08/12/2024 21:00	1.3	13.8	1,711.5	1.1	6.80	1	1	0
08/12/2024 22:00	1.3	13.8	1,680.8	1.1	6.70	1	1	0
08/12/2024 23:00	1.3	13.8	1,713.8	1.1	6.90	1	1	0
Average/Sum#:	8.3	14.8	1,254.4	11.8	117.32 #	6 #	3 #	0 #
Minimum:	1.3	13.8	333.2	1.1	6.70	0	0	0
Maximum:	23.9	17.5	1,713.8	41.5	50.30	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2024 00:00	1.3	13.8	1,676.4	1.1	6.70	1	1	0
08/13/2024 01:00	1.1	13.9	1,345.3	0.9	4.00	1	1	0
08/13/2024 02:00	3.8	15.5	642.5	4.2	2.40	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2024 16:00	29.7	17.5	352.3	51.5	51.51	1	0	0
08/13/2024 17:00	8.4	17.1	422.6	13.0	20.30	1	0	0
08/13/2024 18:00	9.9	15.4	926.0	10.6	36.10	1	0	0
08/13/2024 19:00	1.4	13.2	1,792.4	1.1	7.20	1	1	1
08/13/2024 20:00	1.6	12.5	2,024.2	1.1	8.10	1	1	1
08/13/2024 21:00	1.6	12.3	2,060.0	1.1	8.20	1	1	1
08/13/2024 22:00	1.3	13.2	1,678.4	1.0	6.70	1	1	1
08/13/2024 23:00	1.3	13.8	1,612.0	1.1	6.40	1	1	0
Average/Sum#:	5.6	14.4	1,321.1	7.9	157.61 #	11 #	7 #	4 #
Minimum:	1.1	12.3	352.3	0.9	2.40	0	0	0
Maximum:	29.7	17.5	2,060.0	51.5	51.51	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2024 00:00	1.3	13.9	1,649.5	1.1	6.60	1	1	0
08/14/2024 01:00	1.3	13.9	1,535.2	1.1	6.10	1	1	0
08/14/2024 02:00	2.6	14.9	949.4	2.6	3.83	1	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2024 10:00	26.8	17.7	328.6	49.4	28.11	1	0	0
08/14/2024 11:00	16.3	15.7	808.1	18.5	55.00	1	0	0
08/14/2024 12:00	1.3	13.8	1,518.3	1.1	6.10	1	1	0
08/14/2024 13:00	1.3	13.8	1,562.6	1.1	6.30	1	1	0
08/14/2024 14:00	1.3	13.8	1,518.3	1.1	6.10	1	1	0
08/14/2024 15:00	1.3	13.9	1,457.6	1.1	5.80	1	1	0
08/14/2024 16:00	1.3	13.8	1,622.1	1.1	6.50	1	1	0
08/14/2024 17:00	1.4	13.6	1,725.8	1.1	6.90	1	1	0
08/14/2024 18:00	1.4	13.6	1,730.9	1.1	6.90	1	1	0
08/14/2024 19:00	1.4	13.6	1,742.8	1.1	7.00	1	1	0
08/14/2024 20:00	1.3	13.7	1,730.7	1.1	6.90	1	1	0
08/14/2024 21:00	1.3	13.8	1,732.4	1.1	6.90	1	1	0
08/14/2024 22:00	1.3	13.8	1,740.1	1.1	7.00	1	1	0
08/14/2024 23:00	1.4	13.7	1,771.7	1.1	7.10	1	1	0
Average/Sum#:	3.8	14.2	1,477.9	5.1	179.14 #	17 #	14 #	0 #
Minimum:	1.3	13.6	328.6	1.1	3.83	0	0	0
Maximum:	26.8	17.7	1,771.7	49.4	55.00	1	1	0
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2024 00:00	1.9	14.7	1,126.3	1.8	3.71	1	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2024 12:00	25.5	17.5	361.5	44.3	41.23	1	0	0
08/15/2024 13:00	8.1	17.1	424.6	12.6	19.50	1	0	0
08/15/2024 14:00	13.0	15.4	890.0	13.9	45.40	1	0	0
08/15/2024 15:00	1.3	13.8	1,605.1	1.1	6.40	1	1	0
08/15/2024 16:00	1.3	13.7	1,699.3	1.1	6.80	1	1	0
08/15/2024 17:00	1.3	13.8	1,687.7	1.1	6.80	1	1	0
08/15/2024 18:00	1.2	13.8	1,467.7	1.0	5.90	1	1	0
08/15/2024 19:00	1.4	13.2	1,795.8	1.1	7.20	1	1	1
08/15/2024 20:00	1.6	11.9	2,113.3	1.0	8.50	1	1	1
08/15/2024 21:00	1.3	13.8	1,688.9	1.1	6.80	1	1	0
08/15/2024 22:00	1.3	13.8	1,672.6	1.1	6.70	1	1	0
08/15/2024 23:00	1.3	13.8	1,692.1	1.1	6.80	1	1	0
Average/Sum#:	4.7	14.3	1,401.9	6.3	171.74 #	13 #	9 #	2 #
Minimum:	1.2	11.9	361.5	1.0	3.71	0	0	0
Maximum:	25.5	17.5	2,113.3	44.3	45.40	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2024 00:00	1.3	13.7	1,734.5	1.1	6.90	1	1	0
08/16/2024 01:00	1.3	13.8	1,681.9	1.1	6.70	1	1	0
08/16/2024 02:00	2.1	14.9	1,041.7	2.1	3.74	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2024 12:00	14.9	17.1	449.2	23.1	35.53	1	0	0
08/16/2024 13:00	10.3	14.4	1,257.1	9.3	42.70	1	0	0
08/16/2024 14:00	1.1	14.0	1,342.4	0.9	4.00	1	1	0
08/16/2024 15:00	1.2	13.8	1,574.1	1.0	6.30	1	1	1
08/16/2024 16:00	1.6	12.0	2,101.1	1.1	8.40	1	1	1
08/16/2024 17:00	1.6	12.0	2,086.7	1.1	8.30	1	1	1
08/16/2024 18:00	1.6	11.8	2,134.0	1.0	8.50	1	1	1
08/16/2024 19:00	1.6	12.0	2,104.9	1.1	8.40	1	1	1
08/16/2024 20:00	1.6	11.8	2,145.9	1.0	8.60	1	1	1
08/16/2024 21:00	1.6	12.0	2,116.9	1.1	8.50	1	1	1
08/16/2024 22:00	1.6	11.9	2,173.2	1.0	8.70	1	1	1
08/16/2024 23:00	1.6	11.9	2,178.1	1.0	8.70	1	1	1
Average/Sum#:	3.0	13.1	1,741.4	3.1	173.97 #	15 #	12 #	9 #
Minimum:	1.1	11.8	449.2	0.9	3.74	0	0	0
Maximum:	14.9	17.1	2,178.1	23.1	42.70	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2024 00:00	1.6	12.0	2,143.2	1.1	8.60	1	1	1
08/17/2024 01:00	1.4	12.8	1,978.6	1.0	7.90	1	1	1
08/17/2024 02:00	1.4	13.0	1,933.3	1.0	7.70	1	1	1
08/17/2024 03:00	1.4	13.0	1,926.3	1.0	7.70	1	1	1
08/17/2024 04:00	1.4	12.7	2,003.0	1.0	8.00	1	1	1
08/17/2024 05:00	1.5	12.7	2,012.6	1.1	8.10	1	1	1
08/17/2024 06:00	0.0	0.0	1,213.8	0.0	0.00	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2024 14:00	4.9	18.8	173.2	13.8	1.58	1	0	0
08/17/2024 15:00	19.2	15.9	766.2	22.7	63.60	1	0	0
08/17/2024 16:00	1.3	13.8	1,585.7	1.1	6.30	1	1	0
08/17/2024 17:00	1.5	12.9	1,916.8	1.1	7.70	1	1	1
08/17/2024 18:00	1.5	12.5	2,022.9	1.1	8.10	1	1	1
08/17/2024 19:00	1.5	12.7	1,987.3	1.1	7.90	1	1	1
08/17/2024 20:00	1.5	12.7	1,983.6	1.1	7.90	1	1	1
08/17/2024 21:00	1.5	12.8	1,973.8	1.1	7.90	1	1	1
08/17/2024 22:00	1.5	12.9	1,951.7	1.1	7.80	1	1	1
08/17/2024 23:00	1.3	13.8	1,724.1	1.1	6.90	1	1	1
Average/Sum#:	2.8	13.4	1,723.3	3.2	173.68 #	17 #	14 #	14 #
Minimum:	1.3	12.0	173.2	1.0	1.58	0	0	0
Maximum:	19.2	18.8	2,143.2	22.7	63.60	1	1	1
%SI	33.33	33.33	29.17	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2024 00:00	1.5	12.9	1,967.1	1.1	7.90	1	1	1
08/18/2024 01:00	1.5	12.9	1,930.4	1.1	7.70	1	1	1
08/18/2024 02:00	1.9	15.8	571.0	2.2	1.06	1	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2024 14:00	26.3	17.7	353.3	48.5	36.02	1	0	0
08/18/2024 15:00	12.9	15.1	993.2	13.1	47.70	1	0	0
08/18/2024 16:00	1.3	13.8	1,648.4	1.1	6.60	1	1	0
08/18/2024 17:00	1.3	13.7	1,668.3	1.1	6.70	1	1	1
08/18/2024 18:00	1.5	12.4	2,081.2	1.0	8.30	1	1	1
08/18/2024 19:00	1.6	11.6	2,240.9	1.0	9.00	1	1	1
08/18/2024 20:00	1.6	11.7	2,232.8	1.0	8.90	1	1	1
08/18/2024 21:00	1.6	11.7	2,217.7	1.0	8.90	1	1	1
08/18/2024 22:00	1.6	12.1	2,134.5	1.1	8.50	1	1	1
08/18/2024 23:00	1.6	12.1	2,112.1	1.1	8.40	1	1	1
Average/Sum#:	4.3	13.3	1,703.9	5.7	165.68 #	13 #	10 #	9 #
Minimum:	1.3	11.6	353.3	1.0	1.06	0	0	0
Maximum:	26.3	17.7	2,240.9	48.5	47.70	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2024 00:00	2.8	15.7	571.3	3.2	1.59	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2024 07:00	18.6	16.8	578.7	26.8	44.69	1	0	0
08/19/2024 08:00	1.1	13.8	1,512.1	0.9	4.50	1	0	0
08/19/2024 09:00	1.3	13.9	1,545.4	1.1	6.20	1	1	0
08/19/2024 10:00	1.3	13.9	1,558.0	1.1	6.20	1	1	0
08/19/2024 11:00	1.3	13.8	1,559.4	1.1	6.20	1	1	0
08/19/2024 12:00	1.2	13.8	1,661.6	1.0	6.60	1	1	0
08/19/2024 13:00	1.2	13.9	1,453.5	1.0	5.80	1	1	0
08/19/2024 14:00	1.3	13.8	1,643.3	1.1	6.60	1	1	0
08/19/2024 15:00	1.2	13.9	1,513.1	1.0	6.10	1	1	0
08/19/2024 16:00	1.5	12.6	1,960.7	1.1	7.80	1	1	1
08/19/2024 17:00	1.5	12.5	2,038.3	1.1	8.20	1	1	1
08/19/2024 18:00	1.6	11.7	2,192.8	1.0	8.80	1	1	1
08/19/2024 19:00	1.5	12.6	2,004.3	1.1	8.00	1	1	1
08/19/2024 20:00	1.4	12.9	1,926.0	1.0	7.70	1	1	1
08/19/2024 21:00	1.6	11.7	2,211.7	1.0	8.80	1	1	1
08/19/2024 22:00	1.6	12.0	2,147.1	1.1	8.60	1	1	1
08/19/2024 23:00	1.4	12.8	1,944.4	1.0	7.80	1	1	1
Average/Sum#:	2.4	13.5	1,667.9	2.6	160.18 #	18 #	15 #	8 #
Minimum:	1.1	11.7	571.3	0.9	1.59	0	0	0
Maximum:	18.6	16.8	2,211.7	26.8	44.69	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2024 00:00	1.4	13.0	1,890.7	1.0	7.60	1	1	1
08/20/2024 01:00	3.6	15.5	675.7	3.9	2.38	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2024 13:00	20.6	17.4	386.1	34.7	45.45	1	0	0
08/20/2024 14:00	14.0	14.8	1,049.3	13.5	52.50	1	0	0
08/20/2024 15:00	1.2	14.0	1,327.6	1.0	5.30	1	1	0
08/20/2024 16:00	1.3	13.9	1,554.9	1.1	6.20	1	1	1
08/20/2024 17:00	1.5	12.1	2,112.1	1.0	8.40	1	1	1
08/20/2024 18:00	1.5	12.4	2,009.6	1.0	8.00	1	1	1
08/20/2024 19:00	1.3	13.0	1,898.4	1.0	7.60	1	1	1
08/20/2024 20:00	1.4	13.0	1,893.0	1.0	7.60	1	1	1
08/20/2024 21:00	1.5	12.4	2,052.9	1.0	8.20	1	1	1
08/20/2024 22:00	1.6	12.1	2,103.2	1.1	8.40	1	1	1
08/20/2024 23:00	1.5	12.3	2,075.7	1.0	8.30	1	1	1
Average/Sum#:	4.0	13.5	1,617.6	4.8	175.93 #	13 #	10 #	9 #
Minimum:	1.2	12.1	386.1	1.0	2.38	0	0	0
Maximum:	20.6	17.4	2,112.1	34.7	52.50	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2024 00:00	1.5	12.7	1,977.0	1.1	7.90	1	1	1
08/21/2024 01:00	1.4	13.0	1,932.7	1.0	7.70	1	1	1
08/21/2024 02:00	1.3	13.7	1,698.5	1.1	6.80	1	1	1
08/21/2024 03:00	1.3	13.8	1,712.4	1.1	6.80	1	1	0
08/21/2024 04:00	1.3	13.8	1,722.8	1.1	6.90	1	1	0
08/21/2024 05:00	1.3	13.8	1,733.9	1.1	6.90	1	1	0
08/21/2024 06:00	1.3	13.8	1,729.8	1.1	6.90	1	1	0
08/21/2024 07:00	1.3	13.8	1,615.7	1.1	6.50	1	1	0
08/21/2024 08:00	1.3	13.8	1,608.9	1.1	6.40	1	1	0
08/21/2024 09:00	1.2	13.9	1,324.7	1.0	5.30	1	1	0
08/21/2024 10:00	1.3	13.9	1,531.7	1.1	6.10	1	1	0
08/21/2024 11:00	1.3	13.9	1,575.6	1.1	6.30	1	1	0
08/21/2024 12:00	1.3	13.9	1,650.3	1.1	6.60	1	1	0
08/21/2024 13:00	1.3	13.7	1,732.7	1.1	6.90	1	1	0
08/21/2024 14:00	1.3	13.7	1,744.6	1.1	7.00	1	1	0
08/21/2024 15:00	1.3	13.7	1,724.3	1.1	6.90	1	1	0
08/21/2024 16:00	1.3	13.8	1,607.4	1.1	6.40	1	1	0
08/21/2024 17:00	1.5	12.2	2,081.1	1.0	8.30	1	1	1
08/21/2024 18:00	1.6	11.6	2,209.4	1.0	8.80	1	1	1
08/21/2024 19:00	1.6	11.7	2,187.9	1.0	8.80	1	1	1
08/21/2024 20:00	1.6	12.0	2,161.6	1.1	8.60	1	1	1
08/21/2024 21:00	1.6	11.8	2,198.3	1.0	8.80	1	1	1
08/21/2024 22:00	1.6	11.9	2,170.0	1.0	8.70	1	1	1
08/21/2024 23:00	1.6	12.1	2,120.9	1.1	8.50	1	1	1
Average/Sum#:	1.4	13.2	1,823.0	1.1	174.80 #	24 #	24 #	10 #
Minimum:	1.2	11.6	1,324.7	1.0	5.30	1	1	0
Maximum:	1.6	13.9	2,209.4	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2024 00:00	1.5	12.7	2,003.4	1.1	8.00	1	1	1
08/22/2024 01:00	1.4	12.8	1,978.3	1.0	7.90	1	1	1
08/22/2024 02:00	1.5	12.9	1,976.8	1.1	7.90	1	1	1
08/22/2024 03:00	1.4	12.9	1,975.8	1.0	7.90	1	1	1
08/22/2024 04:00	1.4	12.9	1,982.0	1.0	7.90	1	1	1
08/22/2024 05:00	1.6	12.2	2,120.5	1.1	8.50	1	1	1
08/22/2024 06:00	0.0	0.0	665.1	0.0	0.00	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	12.7	1,814.6	1.1	48.10 #	7 #	6 #	6 #
Minimum:	1.4	12.2	665.1	1.0	7.90	0	0	0
Maximum:	1.6	12.9	2,120.5	1.1	8.50	1	1	1
%SI	75.00	75.00	70.83	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2024 00:00	12.7	18.5	122.6	31.2	4.65	1	0	0
08/26/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2024 07:00	30.6	17.5	369.2	53.1	56.47	1	0	0
08/26/2024 08:00	0.0	0.0	1,279.0	0.0	0.00	1	0	0
08/26/2024 09:00	1.3	13.8	1,730.7	1.1	6.90	1	1	0
08/26/2024 10:00	1.3	13.8	1,721.4	1.1	6.90	1	1	0
08/26/2024 11:00	1.3	13.8	1,722.7	1.1	6.90	1	1	0
08/26/2024 12:00	1.4	13.1	1,859.3	1.1	7.40	1	1	1
08/26/2024 13:00	1.5	12.6	2,036.0	1.1	8.10	1	1	1
08/26/2024 14:00	1.5	12.3	2,070.0	1.0	8.30	1	1	1
08/26/2024 15:00	1.5	12.5	2,036.1	1.1	8.10	1	1	1
08/26/2024 16:00	1.5	12.0	2,145.3	1.0	8.60	1	1	1
08/26/2024 17:00	1.6	11.6	2,241.7	1.0	9.00	1	1	1
08/26/2024 18:00	1.6	11.4	2,269.5	1.0	9.10	1	1	1
08/26/2024 19:00	1.5	11.4	2,277.8	0.9	6.80	1	1	1
08/26/2024 20:00	1.6	11.7	2,235.2	1.0	8.90	1	1	1
08/26/2024 21:00	1.6	11.7	2,238.0	1.0	9.00	1	1	1
08/26/2024 22:00	1.5	11.8	2,211.5	1.0	8.80	1	1	1
08/26/2024 23:00	1.5	12.8	1,993.3	1.1	8.00	1	1	1
Average/Sum#:	3.9	13.1	1,808.9	5.9	181.92 #	18 #	15 #	12 #
Minimum:	1.3	11.4	122.6	0.9	4.65	0	0	0
Maximum:	30.6	18.5	2,277.8	53.1	56.47	1	1	1
%SI	29.17	29.17	25.00	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2024 00:00	1.5	12.9	1,982.9	1.1	7.90	1	1	1
08/27/2024 01:00	1.4	12.9	1,987.8	1.0	8.00	1	1	1
08/27/2024 02:00	1.5	12.9	1,988.3	1.1	8.00	1	1	1
08/27/2024 03:00	1.4	12.8	1,989.3	1.0	8.00	1	1	1
08/27/2024 04:00	1.4	12.9	1,973.2	1.0	7.90	1	1	1
08/27/2024 05:00	1.3	13.8	1,714.4	1.1	6.90	1	1	0
08/27/2024 06:00	1.3	13.8	1,696.5	1.1	6.80	1	1	0
08/27/2024 07:00	1.3	13.8	1,596.0	1.1	6.40	1	1	0
08/27/2024 08:00	1.2	13.9	1,314.7	1.0	5.30	1	1	0
08/27/2024 09:00	1.3	14.0	1,311.2	1.1	5.20	1	1	0
08/27/2024 10:00	1.3	14.0	1,315.7	1.1	5.30	1	1	0
08/27/2024 11:00	1.3	14.0	1,325.7	1.1	5.30	1	1	0
08/27/2024 12:00	1.3	13.9	1,610.3	1.1	6.40	1	1	0
08/27/2024 13:00	1.3	13.8	1,651.4	1.1	6.60	1	1	0
08/27/2024 14:00	1.3	13.7	1,714.5	1.1	6.90	1	1	0
08/27/2024 15:00	1.3	13.8	1,587.0	1.1	6.30	1	1	0
08/27/2024 16:00	1.4	12.6	1,930.9	1.0	7.70	1	1	1
08/27/2024 17:00	1.6	11.7	2,195.3	1.0	8.80	1	1	1
08/27/2024 18:00	1.6	11.9	2,175.9	1.0	8.70	1	1	1
08/27/2024 19:00	1.5	11.8	2,202.2	1.0	8.80	1	1	1
08/27/2024 20:00	1.5	11.7	2,222.7	1.0	8.90	1	1	1
08/27/2024 21:00	1.6	11.8	2,204.6	1.0	8.80	1	1	1
08/27/2024 22:00	1.5	12.3	2,093.2	1.0	8.40	1	1	1
08/27/2024 23:00	1.6	12.1	2,168.2	1.1	8.70	1	1	1
Average/Sum#:	1.4	13.0	1,831.3	1.1	176.00 #	24 #	24 #	13 #
Minimum:	1.2	11.7	1,311.2	1.0	5.20	1	1	0
Maximum:	1.6	14.0	2,222.7	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2024 00:00	1.5	12.3	2,114.2	1.0	8.50	1	1	1
08/28/2024 01:00	1.4	12.8	1,993.1	1.0	8.00	1	1	1
08/28/2024 02:00	1.5	12.8	1,991.8	1.1	8.00	1	1	1
08/28/2024 03:00	1.5	12.5	2,063.6	1.1	8.30	1	1	1
08/28/2024 04:00	1.6	12.0	2,187.0	1.1	8.70	1	1	1
08/28/2024 05:00	1.5	12.0	2,183.2	1.0	8.70	1	1	1
08/28/2024 06:00	1.5	12.6	2,053.3	1.1	8.20	1	1	1
08/28/2024 07:00	1.5	12.8	1,987.7	1.1	8.00	1	1	1
08/28/2024 08:00	1.4	12.6	1,996.1	1.0	8.00	1	1	1
08/28/2024 09:00	1.5	12.6	2,001.7	1.1	8.00	1	1	1
08/28/2024 10:00	1.5	12.6	2,009.8	1.1	8.00	1	1	1
08/28/2024 11:00	1.5	12.5	2,018.1	1.1	8.10	1	1	1
08/28/2024 12:00	1.5	12.4	2,032.0	1.0	8.10	1	1	1
08/28/2024 13:00	1.5	12.2	2,083.3	1.0	8.30	1	1	1
08/28/2024 14:00	1.6	12.2	2,064.2	1.1	8.30	1	1	1
08/28/2024 15:00	1.5	12.3	2,047.6	1.0	8.20	1	1	1
08/28/2024 16:00	1.5	12.2	2,073.3	1.0	8.30	1	1	1
08/28/2024 17:00	1.5	12.4	2,053.1	1.0	8.20	1	1	1
08/28/2024 18:00	1.6	12.0	2,136.2	1.1	8.50	1	1	1
08/28/2024 19:00	1.6	11.6	2,208.4	1.0	8.80	1	1	1
08/28/2024 20:00	1.5	12.0	2,114.4	1.0	8.50	1	1	1
08/28/2024 21:00	1.5	12.5	2,012.1	1.1	8.00	1	1	1
08/28/2024 22:00	1.5	12.6	2,001.2	1.1	8.00	1	1	1
08/28/2024 23:00	1.5	12.8	1,986.0	1.1	7.90	1	1	1
Average/Sum#:	1.5	12.4	2,058.8	1.1	197.60 #	24 #	24 #	24 #
Minimum:	1.4	11.6	1,986.0	1.0	7.90	1	1	1
Maximum:	1.6	12.8	2,208.4	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2024 00:00	1.4	12.8	1,987.7	1.0	8.00	1	1	1
08/29/2024 01:00	1.5	12.8	1,985.2	1.1	7.90	1	1	1
08/29/2024 02:00	1.5	12.9	1,978.7	1.1	7.90	1	1	1
08/29/2024 03:00	1.4	12.8	1,981.6	1.0	7.90	1	1	1
08/29/2024 04:00	1.5	12.7	2,017.8	1.1	8.10	1	1	1
08/29/2024 05:00	1.5	12.8	1,979.8	1.1	7.90	1	1	1
08/29/2024 06:00	1.3	13.8	1,742.2	1.1	7.00	1	1	0
08/29/2024 07:00	1.3	13.8	1,542.6	1.1	6.20	1	1	0
08/29/2024 08:00	1.3	13.9	1,318.8	1.1	5.30	1	1	0
08/29/2024 09:00	1.3	14.0	1,319.4	1.1	5.30	1	1	0
08/29/2024 10:00	1.3	14.0	1,322.9	1.1	5.30	1	1	0
08/29/2024 11:00	1.3	14.0	1,330.1	1.1	5.30	1	1	0
08/29/2024 12:00	1.3	13.8	1,579.7	1.1	6.30	1	1	0
08/29/2024 13:00	1.3	13.8	1,673.9	1.1	6.70	1	1	0
08/29/2024 14:00	1.3	13.7	1,718.2	1.1	6.90	1	1	0
08/29/2024 15:00	1.3	13.8	1,538.1	1.1	6.20	1	1	1
08/29/2024 16:00	1.5	12.3	2,064.7	1.0	8.30	1	1	1
08/29/2024 17:00	1.6	12.0	2,128.8	1.1	8.50	1	1	1
08/29/2024 18:00	1.5	12.3	2,060.8	1.0	8.20	1	1	1
08/29/2024 19:00	1.6	11.9	2,180.6	1.0	8.70	1	1	1
08/29/2024 20:00	1.5	12.2	2,096.1	1.0	8.40	1	1	1
08/29/2024 21:00	1.5	12.4	2,055.3	1.0	8.20	1	1	1
08/29/2024 22:00	1.5	12.7	1,990.0	1.1	8.00	1	1	1
08/29/2024 23:00	1.4	12.7	1,987.2	1.0	7.90	1	1	1
Average/Sum#:	1.4	13.1	1,815.8	1.1	174.40 #	24 #	24 #	15 #
Minimum:	1.3	11.9	1,318.8	1.0	5.30	1	1	0
Maximum:	1.6	14.0	2,180.6	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2024 00:00	1.5	12.8	1,981.1	1.1	7.90	1	1	1
08/30/2024 01:00	1.4	12.9	1,979.5	1.0	7.90	1	1	1
08/30/2024 02:00	1.5	12.9	1,980.2	1.1	7.90	1	1	1
08/30/2024 03:00	1.4	12.9	1,981.5	1.0	7.90	1	1	1
08/30/2024 04:00	1.5	12.6	2,052.7	1.1	8.20	1	1	1
08/30/2024 05:00	1.5	12.4	2,096.4	1.0	8.40	1	1	1
08/30/2024 06:00	1.5	12.6	2,050.6	1.1	8.20	1	1	1
08/30/2024 07:00	1.2	13.8	1,395.7	1.0	5.60	1	1	1
08/30/2024 08:00	1.3	13.9	1,375.1	1.1	5.50	1	1	0
08/30/2024 09:00	1.3	13.9	1,323.9	1.1	5.30	1	1	0
08/30/2024 10:00	1.3	13.9	1,331.8	1.1	5.30	1	1	0
08/30/2024 11:00	1.2	13.9	1,370.2	1.0	5.50	1	1	0
08/30/2024 12:00	1.3	14.0	1,341.5	1.1	5.40	1	1	0
08/30/2024 13:00	1.3	13.8	1,671.9	1.1	6.70	1	1	0
08/30/2024 14:00	1.4	13.5	1,720.8	1.1	6.90	1	1	1
08/30/2024 15:00	1.6	12.2	2,072.7	1.1	8.30	1	1	1
08/30/2024 16:00	1.6	12.1	2,103.4	1.1	8.40	1	1	1
08/30/2024 17:00	1.5	11.7	2,183.6	1.0	8.70	1	1	1
08/30/2024 18:00	1.5	11.6	2,222.8	1.0	8.90	1	1	1
08/30/2024 19:00	1.6	11.6	2,216.4	1.0	8.90	1	1	1
08/30/2024 20:00	1.5	11.6	2,214.0	1.0	8.90	1	1	1
08/30/2024 21:00	1.5	11.8	2,169.7	1.0	8.70	1	1	1
08/30/2024 22:00	1.5	12.5	2,029.6	1.1	8.10	1	1	1
08/30/2024 23:00	1.6	11.9	2,192.3	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.8	1,877.4	1.1	180.30 #	24 #	24 #	18 #
Minimum:	1.2	11.6	1,323.9	1.0	5.30	1	1	0
Maximum:	1.6	14.0	2,222.8	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2024 00:00	1.5	11.9	2,188.9	1.0	8.80	1	1	1
08/31/2024 01:00	1.5	12.0	2,183.5	1.0	8.70	1	1	1
08/31/2024 02:00	1.6	12.0	2,182.9	1.1	8.70	1	1	1
08/31/2024 03:00	1.6	12.0	2,179.0	1.1	8.70	1	1	1
08/31/2024 04:00	1.6	12.0	2,178.1	1.1	8.70	1	1	1
08/31/2024 05:00	1.5	12.3	2,068.0	1.0	8.30	1	1	1
08/31/2024 06:00	6.1	14.5	582.2	5.6	2.81	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2024 10:00	0.3	18.8	179.2	0.8	0.10	1	0	0
08/31/2024 11:00	6.6	15.8	792.8	7.6	22.20	1	0	0
08/31/2024 12:00	1.2	13.9	1,408.7	1.0	5.60	1	1	0
08/31/2024 13:00	1.3	14.0	1,387.0	1.1	5.50	1	1	0
08/31/2024 14:00	1.3	13.8	1,621.6	1.1	6.50	1	1	0
08/31/2024 15:00	1.3	13.8	1,543.4	1.1	6.20	1	1	0
08/31/2024 16:00	1.3	13.7	1,673.8	1.1	6.70	1	1	0
08/31/2024 17:00	1.4	13.0	1,811.8	1.0	7.20	1	1	1
08/31/2024 18:00	1.6	11.4	2,242.4	1.0	9.00	1	1	1
08/31/2024 19:00	1.7	11.3	2,266.4	1.0	9.10	1	1	1
08/31/2024 20:00	1.5	11.3	2,275.9	0.9	6.80	1	1	1
08/31/2024 21:00	1.6	11.4	2,281.8	1.0	9.10	1	1	1
08/31/2024 22:00	1.6	11.7	2,230.8	1.0	8.90	1	1	1
08/31/2024 23:00	1.5	11.5	2,266.1	0.9	6.80	1	1	1
Average/Sum#:	1.9	13.0	1,787.8	1.5	164.41 #	21 #	18 #	13 #
Minimum:	0.3	11.3	179.2	0.8	0.10	0	0	0
Maximum:	6.6	18.8	2,281.8	7.6	22.20	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2024 00:00	1.6	12.0	2,156.0	1.1	8.60	1	1	1
09/01/2024 01:00	1.6	12.1	2,149.0	1.1	8.60	1	1	1
09/01/2024 02:00	1.5	12.0	2,165.6	1.0	8.70	1	1	1
09/01/2024 03:00	1.5	12.4	2,074.5	1.0	8.30	1	1	1
09/01/2024 04:00	1.4	12.8	1,987.5	1.0	8.00	1	1	1
09/01/2024 05:00	1.4	12.9	1,944.5	1.0	7.80	1	1	1
09/01/2024 06:00	3.6	14.3	619.8	3.2	1.85	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2024 14:00	15.6	17.8	324.8	29.7	14.87	1	0	0
09/01/2024 15:00	9.5	15.1	1,083.9	9.7	39.00	1	0	0
09/01/2024 16:00	1.3	13.6	1,720.5	1.1	6.90	1	1	0
09/01/2024 17:00	1.3	13.6	1,723.1	1.1	6.90	1	1	1
09/01/2024 18:00	1.6	11.9	2,140.5	1.0	8.60	1	1	1
09/01/2024 19:00	1.6	11.6	2,209.3	1.0	8.80	1	1	1
09/01/2024 20:00	1.5	11.7	2,196.9	1.0	8.80	1	1	1
09/01/2024 21:00	1.6	11.6	2,230.6	1.0	8.90	1	1	1
09/01/2024 22:00	1.6	11.9	2,173.7	1.0	8.70	1	1	1
09/01/2024 23:00	1.6	12.0	2,170.6	1.1	8.70	1	1	1
Average/Sum#:	2.9	12.9	1,827.7	3.4	172.02 #	17 #	14 #	13 #
Minimum:	1.3	11.6	324.8	1.0	1.85	0	0	0
Maximum:	15.6	17.8	2,230.6	29.7	39.00	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2024 00:00	1.5	12.1	2,154.1	1.0	8.60	1	1	1
09/02/2024 01:00	1.5	12.3	2,085.7	1.0	8.30	1	1	1
09/02/2024 02:00	1.4	12.9	1,962.3	1.0	7.80	1	1	1
09/02/2024 03:00	1.4	13.0	1,971.1	1.0	7.90	1	1	1
09/02/2024 04:00	1.4	13.0	1,964.7	1.0	7.90	1	1	1
09/02/2024 05:00	1.4	13.0	1,957.0	1.0	7.80	1	1	1
09/02/2024 06:00	1.4	13.0	1,934.2	1.0	7.70	1	1	1
09/02/2024 07:00	4.7	15.6	641.5	5.2	3.05	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2024 14:00	18.0	17.4	428.9	30.3	21.60	1	0	0
09/02/2024 15:00	10.6	14.5	1,215.8	9.8	43.80	1	0	0
09/02/2024 16:00	1.3	13.7	1,682.0	1.1	6.70	1	1	0
09/02/2024 17:00	1.4	13.0	1,820.6	1.0	7.30	1	1	1
09/02/2024 18:00	1.6	11.4	2,266.4	1.0	9.10	1	1	1
09/02/2024 19:00	1.6	11.3	2,284.8	1.0	9.10	1	1	1
09/02/2024 20:00	1.6	11.8	2,193.4	1.0	8.80	1	1	1
09/02/2024 21:00	1.4	12.6	2,002.0	1.0	8.00	1	1	1
09/02/2024 22:00	1.5	12.6	2,027.3	1.1	8.10	1	1	1
09/02/2024 23:00	1.4	12.8	1,991.4	1.0	8.00	1	1	1
Average/Sum#:	3.1	13.1	1,810.2	3.4	189.55 #	18 #	15 #	14 #
Minimum:	1.3	11.3	428.9	1.0	3.05	0	0	0
Maximum:	18.0	17.4	2,284.8	30.3	43.80	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2024 00:00	1.4	12.8	1,982.8	1.0	7.90	1	1	1
09/03/2024 01:00	1.5	12.8	1,986.8	1.1	7.90	1	1	1
09/03/2024 02:00	1.5	12.8	1,980.7	1.1	7.90	1	1	1
09/03/2024 03:00	1.4	12.9	1,976.3	1.0	7.90	1	1	1
09/03/2024 04:00	1.4	12.8	1,995.1	1.0	8.00	1	1	1
09/03/2024 05:00	1.6	12.2	2,132.6	1.1	8.50	1	1	1
09/03/2024 06:00	1.4	12.6	2,074.6	1.0	8.30	1	1	1
09/03/2024 07:00	1.4	12.9	1,962.4	1.0	7.80	1	1	1
09/03/2024 08:00	1.5	12.8	1,971.4	1.1	7.90	1	1	1
09/03/2024 09:00	1.5	12.7	1,983.4	1.1	7.90	1	1	1
09/03/2024 10:00	1.5	12.6	2,001.6	1.1	8.00	1	1	1
09/03/2024 11:00	1.5	12.5	2,014.5	1.1	8.10	1	1	1
09/03/2024 12:00	1.6	12.1	2,109.1	1.1	8.40	1	1	1
09/03/2024 13:00	1.6	11.7	2,199.5	1.0	8.80	1	1	1
09/03/2024 14:00	1.5	11.6	2,224.7	1.0	8.90	1	1	1
09/03/2024 15:00	1.6	11.6	2,219.4	1.0	8.90	1	1	1
09/03/2024 16:00	1.5	11.6	2,212.6	1.0	8.90	1	1	1
09/03/2024 17:00	1.6	11.5	2,247.1	1.0	9.00	1	1	1
09/03/2024 18:00	1.5	11.5	2,260.4	0.9	6.80	1	1	1
09/03/2024 19:00	1.6	11.5	2,264.8	1.0	9.10	1	1	1
09/03/2024 20:00	1.6	11.5	2,272.6	1.0	9.10	1	1	1
09/03/2024 21:00	1.6	11.5	2,276.9	1.0	9.10	1	1	1
09/03/2024 22:00	1.6	11.5	2,276.0	1.0	9.10	1	1	1
09/03/2024 23:00	1.5	12.0	2,134.7	1.0	8.50	1	1	1
Average/Sum#:	1.5	12.2	2,115.0	1.0	200.70 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,962.4	0.9	6.80	1	1	1
Maximum:	1.6	12.9	2,276.9	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2024 00:00	1.3	13.8	1,719.2	1.1	6.90	1	1	0
09/04/2024 01:00	1.3	13.8	1,737.2	1.1	6.90	1	1	0
09/04/2024 02:00	1.3	13.9	1,724.7	1.1	6.90	1	1	0
09/04/2024 03:00	1.3	13.9	1,741.3	1.1	7.00	1	1	0
09/04/2024 04:00	1.3	13.8	1,740.8	1.1	7.00	1	1	0
09/04/2024 05:00	1.3	13.9	1,710.5	1.1	6.80	1	1	0
09/04/2024 06:00	1.4	13.8	1,707.4	1.2	6.80	1	1	0
09/04/2024 07:00	1.3	13.8	1,738.1	1.1	7.00	1	1	0
09/04/2024 08:00	1.3	13.7	1,745.0	1.1	7.00	1	1	0
09/04/2024 09:00	1.3	13.7	1,740.8	1.1	7.00	1	1	0
09/04/2024 10:00	1.3	13.7	1,733.3	1.1	6.90	1	1	0
09/04/2024 11:00	1.3	13.7	1,741.2	1.1	7.00	1	1	0
09/04/2024 12:00	1.3	13.7	1,683.2	1.1	6.70	1	1	1
09/04/2024 13:00	1.6	12.0	2,136.2	1.1	8.50	1	1	1
09/04/2024 14:00	1.5	11.7	2,182.3	1.0	8.70	1	1	1
09/04/2024 15:00	1.6	11.9	2,122.5	1.0	8.50	1	1	1
09/04/2024 16:00	1.6	11.8	2,150.4	1.0	8.60	1	1	1
09/04/2024 17:00	1.5	11.8	2,151.1	1.0	8.60	1	1	1
09/04/2024 18:00	1.6	11.9	2,121.5	1.0	8.50	1	1	1
09/04/2024 19:00	1.6	11.6	2,203.7	1.0	8.80	1	1	1
09/04/2024 20:00	1.5	11.6	2,211.6	1.0	8.80	1	1	1
09/04/2024 21:00	1.6	11.7	2,201.3	1.0	8.80	1	1	1
09/04/2024 22:00	1.6	11.9	2,172.6	1.0	8.70	1	1	1
09/04/2024 23:00	1.6	11.8	2,196.2	1.0	8.80	1	1	1
Average/Sum#:	1.4	12.9	1,929.7	1.1	185.20 #	24 #	24 #	12 #
Minimum:	1.3	11.6	1,683.2	1.0	6.70	1	1	0
Maximum:	1.6	13.9	2,211.6	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2024 00:00	1.5	11.9	2,185.3	1.0	8.70	1	1	1
09/05/2024 01:00	1.6	11.9	2,181.9	1.0	8.70	1	1	1
09/05/2024 02:00	1.6	11.9	2,170.5	1.0	8.70	1	1	1
09/05/2024 03:00	1.5	12.6	2,028.5	1.1	8.10	1	1	1
09/05/2024 04:00	1.5	11.9	2,186.7	1.0	8.70	1	1	1
09/05/2024 05:00	1.6	11.6	2,250.1	1.0	9.00	1	1	1
09/05/2024 06:00	1.3	12.4	2,097.0	0.9	6.30	1	1	1
09/05/2024 07:00	1.3	13.8	1,723.4	1.1	6.90	1	1	0
09/05/2024 08:00	1.3	13.8	1,658.4	1.1	6.60	1	1	0
09/05/2024 09:00	1.3	13.7	1,726.0	1.1	6.90	1	1	0
09/05/2024 10:00	1.3	13.8	1,705.9	1.1	6.80	1	1	0
09/05/2024 11:00	1.3	13.7	1,729.5	1.1	6.90	1	1	0
09/05/2024 12:00	1.3	13.7	1,728.5	1.1	6.90	1	1	1
09/05/2024 13:00	1.6	11.8	2,139.4	1.0	8.60	1	1	1
09/05/2024 14:00	1.6	11.6	2,183.9	1.0	8.70	1	1	1
09/05/2024 15:00	1.6	11.6	2,176.1	1.0	8.70	1	1	1
09/05/2024 16:00	1.6	11.9	2,096.4	1.0	8.40	1	1	1
09/05/2024 17:00	1.6	11.8	2,138.8	1.0	8.60	1	1	1
09/05/2024 18:00	1.6	11.6	2,169.3	1.0	8.70	1	1	1
09/05/2024 19:00	1.6	11.7	2,174.8	1.0	8.70	1	1	1
09/05/2024 20:00	1.6	11.7	2,180.3	1.0	8.70	1	1	1
09/05/2024 21:00	1.5	11.5	2,227.0	0.9	6.70	1	1	1
09/05/2024 22:00	1.6	11.4	2,262.6	1.0	9.10	1	1	1
09/05/2024 23:00	1.5	11.8	2,196.9	1.0	8.80	1	1	1
Average/Sum#:	1.5	12.3	2,054.9	1.0	192.90 #	24 #	24 #	19 #
Minimum:	1.3	11.4	1,658.4	0.9	6.30	1	1	0
Maximum:	1.6	13.8	2,262.6	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2024 00:00	1.5	11.7	2,192.7	1.0	8.80	1	1	1
09/06/2024 01:00	1.6	11.9	2,150.9	1.0	8.60	1	1	1
09/06/2024 02:00	1.5	12.6	2,010.4	1.1	8.00	1	1	1
09/06/2024 03:00	1.6	11.9	2,182.6	1.0	8.70	1	1	1
09/06/2024 04:00	1.6	11.8	2,218.4	1.0	8.90	1	1	1
09/06/2024 05:00	1.6	11.6	2,266.4	1.0	9.10	1	1	1
09/06/2024 06:00	1.4	12.0	2,176.6	0.9	6.50	1	1	1
09/06/2024 07:00	1.5	12.1	2,145.7	1.0	8.60	1	1	1
09/06/2024 08:00	1.5	12.2	2,102.5	1.0	8.40	1	1	1
09/06/2024 09:00	1.5	12.6	1,992.5	1.1	8.00	1	1	1
09/06/2024 10:00	1.6	12.3	2,061.3	1.1	8.20	1	1	1
09/06/2024 11:00	1.6	11.9	2,136.4	1.0	8.50	1	1	1
09/06/2024 12:00	1.5	11.7	2,171.6	1.0	8.70	1	1	1
09/06/2024 13:00	1.6	11.7	2,166.0	1.0	8.70	1	1	1
09/06/2024 14:00	1.6	11.6	2,177.8	1.0	8.70	1	1	1
09/06/2024 15:00	1.6	11.6	2,177.3	1.0	8.70	1	1	1
09/06/2024 16:00	1.6	11.9	2,123.5	1.0	8.50	1	1	1
09/06/2024 17:00	1.6	11.7	2,162.3	1.0	8.60	1	1	1
09/06/2024 18:00	1.6	11.5	2,193.7	1.0	8.80	1	1	1
09/06/2024 19:00	1.6	11.6	2,201.2	1.0	8.80	1	1	1
09/06/2024 20:00	1.6	11.7	2,212.3	1.0	8.80	1	1	1
09/06/2024 21:00	1.6	11.6	2,233.1	1.0	8.90	1	1	1
09/06/2024 22:00	1.6	11.7	2,218.0	1.0	8.90	1	1	1
09/06/2024 23:00	1.6	11.5	2,276.3	1.0	9.10	1	1	1
Average/Sum#:	1.6	11.9	2,164.6	1.0	205.50 #	24 #	24 #	24 #
Minimum:	1.4	11.5	1,992.5	0.9	6.50	1	1	1
Maximum:	1.6	12.6	2,276.3	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2024 00:00	1.6	11.5	2,277.9	1.0	9.10	1	1	1
09/07/2024 01:00	1.6	11.5	2,270.1	1.0	9.10	1	1	1
09/07/2024 02:00	1.6	11.8	2,195.0	1.0	8.80	1	1	1
09/07/2024 03:00	1.6	11.8	2,190.1	1.0	8.80	1	1	1
09/07/2024 04:00	1.6	11.8	2,216.1	1.0	8.90	1	1	1
09/07/2024 05:00	1.6	11.9	2,181.3	1.0	8.70	1	1	1
09/07/2024 06:00	1.5	12.4	2,101.1	1.0	8.40	1	1	1
09/07/2024 07:00	1.5	12.8	1,977.2	1.1	7.90	1	1	1
09/07/2024 08:00	1.4	12.8	1,977.3	1.0	7.90	1	1	1
09/07/2024 09:00	1.5	12.7	1,991.3	1.1	8.00	1	1	1
09/07/2024 10:00	1.6	12.2	2,091.9	1.1	8.40	1	1	1
09/07/2024 11:00	1.5	12.3	2,070.3	1.0	8.30	1	1	1
09/07/2024 12:00	1.6	11.8	2,167.4	1.0	8.70	1	1	1
09/07/2024 13:00	1.6	11.5	2,217.6	1.0	8.90	1	1	1
09/07/2024 14:00	1.6	11.4	2,238.6	1.0	9.00	1	1	1
09/07/2024 15:00	1.6	11.4	2,241.0	1.0	9.00	1	1	1
09/07/2024 16:00	1.6	11.8	2,156.7	1.0	8.60	1	1	1
09/07/2024 17:00	1.6	11.4	2,250.0	1.0	9.00	1	1	1
09/07/2024 18:00	1.5	11.4	2,264.7	0.9	6.80	1	1	1
09/07/2024 19:00	1.6	11.4	2,273.3	1.0	9.10	1	1	1
09/07/2024 20:00	1.6	11.5	2,279.4	1.0	9.10	1	1	1
09/07/2024 21:00	1.5	11.5	2,270.8	0.9	6.80	1	1	1
09/07/2024 22:00	1.6	11.9	2,188.7	1.0	8.80	1	1	1
09/07/2024 23:00	1.6	11.6	2,267.5	1.0	9.10	1	1	1
Average/Sum#:	1.6	11.8	2,181.5	1.0	205.20 #	24 #	24 #	24 #
Minimum:	1.4	11.4	1,977.2	0.9	6.80	1	1	1
Maximum:	1.6	12.8	2,279.4	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2024 00:00	1.6	12.1	2,145.1	1.1	8.60	1	1	1
09/08/2024 01:00	1.4	12.7	2,001.6	1.0	8.00	1	1	1
09/08/2024 02:00	1.6	12.1	2,161.9	1.1	8.60	1	1	1
09/08/2024 03:00	1.6	12.0	2,177.0	1.1	8.70	1	1	1
09/08/2024 04:00	1.5	12.7	2,020.7	1.1	8.10	1	1	1
09/08/2024 05:00	1.3	13.8	1,703.7	1.1	6.80	1	1	0
09/08/2024 06:00	1.3	13.8	1,657.6	1.1	6.60	1	1	0
09/08/2024 07:00	1.3	13.8	1,646.3	1.1	6.60	1	1	0
09/08/2024 08:00	1.3	13.8	1,615.7	1.1	6.50	1	1	0
09/08/2024 09:00	1.3	13.8	1,544.2	1.1	6.20	1	1	0
09/08/2024 10:00	1.3	13.9	1,544.0	1.1	6.20	1	1	0
09/08/2024 11:00	1.3	13.9	1,559.2	1.1	6.20	1	1	0
09/08/2024 12:00	1.3	13.9	1,642.0	1.1	6.60	1	1	0
09/08/2024 13:00	1.3	13.8	1,672.1	1.1	6.70	1	1	0
09/08/2024 14:00	1.4	13.0	1,838.6	1.0	7.40	1	1	1
09/08/2024 15:00	1.6	11.6	2,219.4	1.0	8.90	1	1	1
09/08/2024 16:00	1.6	12.0	2,132.6	1.1	8.50	1	1	1
09/08/2024 17:00	1.6	11.5	2,225.6	1.0	8.90	1	1	1
09/08/2024 18:00	1.6	11.5	2,238.1	1.0	9.00	1	1	1
09/08/2024 19:00	1.6	11.4	2,264.2	1.0	9.10	1	1	1
09/08/2024 20:00	1.5	11.4	2,266.1	0.9	6.80	1	1	1
09/08/2024 21:00	1.6	11.5	2,253.8	1.0	9.00	1	1	1
09/08/2024 22:00	1.6	11.7	2,203.8	1.0	8.80	1	1	1
09/08/2024 23:00	1.6	11.8	2,189.9	1.0	8.80	1	1	1
Average/Sum#:	1.5	12.6	1,955.1	1.1	185.60 #	24 #	24 #	15 #
Minimum:	1.3	11.4	1,544.0	0.9	6.20	1	1	0
Maximum:	1.6	13.9	2,266.1	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2024 00:00	1.6	11.9	2,188.1	1.0	8.80	1	1	1
09/09/2024 01:00	1.5	12.5	2,064.1	1.1	8.30	1	1	1
09/09/2024 02:00	1.6	12.1	2,168.9	1.1	8.70	1	1	1
09/09/2024 03:00	1.6	11.9	2,186.0	1.0	8.70	1	1	1
09/09/2024 04:00	1.6	11.9	2,191.4	1.0	8.80	1	1	1
09/09/2024 05:00	1.6	11.7	2,256.7	1.0	9.00	1	1	1
09/09/2024 06:00	1.4	12.6	2,085.6	1.0	8.30	1	1	1
09/09/2024 07:00	1.4	12.9	1,975.6	1.0	7.90	1	1	1
09/09/2024 08:00	1.4	12.8	1,979.2	1.0	7.90	1	1	1
09/09/2024 09:00	1.6	12.0	2,145.7	1.1	8.60	1	1	1
09/09/2024 10:00	1.6	11.9	2,124.1	1.0	8.50	1	1	1
09/09/2024 11:00	1.6	12.1	2,080.6	1.1	8.30	1	1	1
09/09/2024 12:00	1.6	12.0	2,077.3	1.1	8.30	1	1	1
09/09/2024 13:00	1.5	12.0	2,083.8	1.0	8.30	1	1	1
09/09/2024 14:00	1.5	12.2	2,028.2	1.0	8.10	1	1	1
09/09/2024 15:00	1.6	11.9	2,082.5	1.0	8.30	1	1	1
09/09/2024 16:00	1.6	11.4	2,172.2	1.0	8.70	1	1	1
09/09/2024 17:00	1.6	11.6	2,142.6	1.0	8.60	1	1	1
09/09/2024 18:00	1.6	11.5	2,175.7	1.0	8.70	1	1	1
09/09/2024 19:00	1.5	11.6	2,161.8	1.0	8.60	1	1	1
09/09/2024 20:00	1.6	12.0	2,099.9	1.1	8.40	1	1	1
09/09/2024 21:00	1.6	12.1	2,088.7	1.1	8.40	1	1	1
09/09/2024 22:00	1.5	12.6	1,979.5	1.1	7.90	1	1	1
09/09/2024 23:00	1.6	11.9	2,154.2	1.0	8.60	1	1	1
Average/Sum#:	1.6	12.0	2,112.2	1.0	202.70 #	24 #	24 #	24 #
Minimum:	1.4	11.4	1,975.6	1.0	7.90	1	1	1
Maximum:	1.6	12.9	2,256.7	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2024 00:00	1.6	11.9	2,145.4	1.0	8.60	1	1	1
09/10/2024 01:00	1.5	12.5	2,018.8	1.1	8.10	1	1	1
09/10/2024 02:00	1.5	12.6	1,980.9	1.1	7.90	1	1	1
09/10/2024 03:00	1.5	12.5	2,014.8	1.1	8.10	1	1	1
09/10/2024 04:00	1.5	12.3	2,074.7	1.0	8.30	1	1	1
09/10/2024 05:00	1.6	11.8	2,204.9	1.0	8.80	1	1	1
09/10/2024 06:00	1.3	12.5	2,034.3	0.9	6.10	1	1	1
09/10/2024 07:00	1.3	13.8	1,550.6	1.1	6.20	1	1	0
09/10/2024 08:00	1.2	13.9	1,290.7	1.0	5.20	1	1	0
09/10/2024 09:00	1.3	13.9	1,292.0	1.1	5.20	1	1	0
09/10/2024 10:00	1.3	13.9	1,297.8	1.1	5.20	1	1	0
09/10/2024 11:00	1.3	14.0	1,300.7	1.1	5.20	1	1	0
09/10/2024 12:00	1.3	13.9	1,303.8	1.1	5.20	1	1	0
09/10/2024 13:00	1.2	13.9	1,386.5	1.0	5.50	1	1	0
09/10/2024 14:00	1.3	14.0	1,301.1	1.1	5.20	1	1	0
09/10/2024 15:00	1.2	14.0	1,318.6	1.0	5.30	1	1	0
09/10/2024 16:00	1.3	13.8	1,551.7	1.1	6.20	1	1	1
09/10/2024 17:00	1.5	12.5	1,958.2	1.1	7.80	1	1	1
09/10/2024 18:00	1.5	12.5	1,976.9	1.1	7.90	1	1	1
09/10/2024 19:00	1.5	12.6	1,959.0	1.1	7.80	1	1	1
09/10/2024 20:00	1.5	12.7	1,948.0	1.1	7.80	1	1	1
09/10/2024 21:00	1.4	12.8	1,941.4	1.0	7.80	1	1	1
09/10/2024 22:00	1.4	12.8	1,920.9	1.0	7.70	1	1	1
09/10/2024 23:00	5.9	15.6	634.3	6.6	3.80	1	0	0
Average/Sum#:	1.6	13.2	1,683.6	1.3	160.90 #	24 #	23 #	14 #
Minimum:	1.2	11.8	634.3	0.9	3.80	1	0	0
Maximum:	5.9	15.6	2,204.9	6.6	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/12/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/13/2024 18:00	27.1	17.6	320.1	48.5	33.06	1	0	0
09/13/2024 19:00	21.6	15.3	874.9	22.8	73.50	1	0	0
09/13/2024 20:00	1.3	13.7	1,667.3	1.1	6.70	1	1	0
09/13/2024 21:00	1.3	13.7	1,691.4	1.1	6.80	1	1	0
09/13/2024 22:00	1.3	13.7	1,684.4	1.1	6.70	1	1	0
09/13/2024 23:00	1.3	13.8	1,689.2	1.1	6.80	1	1	0
Average/Sum#:	9.0	14.6	1,321.2	12.6	133.56 #	6 #	4 #	0 #
Minimum:	1.3	13.7	320.1	1.1	6.70	0	0	0
Maximum:	27.1	17.6	1,691.4	48.5	73.50	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2024 00:00	1.3	13.8	1,694.8	1.1	6.80	1	1	0
09/14/2024 01:00	1.3	13.6	1,760.8	1.1	7.00	1	1	0
09/14/2024 02:00	1.7	14.2	1,423.0	1.5	7.91	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/14/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.9	1,626.2	1.2	21.71 #	3 #	2 #	0 #
Minimum:	1.3	13.6	1,423.0	1.1	6.80	0	0	0
Maximum:	1.7	14.2	1,760.8	1.5	7.91	1	1	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/15/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2024 01:00	27.5	17.5	337.6	47.7	46.33	1	0	0
09/18/2024 02:00	12.9	15.4	868.5	13.8	44.30	1	0	0
09/18/2024 03:00	1.3	13.8	1,486.9	1.1	5.90	1	1	0
09/18/2024 04:00	1.3	13.7	1,688.7	1.1	6.80	1	1	1
09/18/2024 05:00	1.5	12.6	2,049.5	1.1	8.20	1	1	1
09/18/2024 06:00	1.4	12.5	2,082.3	1.0	8.30	1	1	1
09/18/2024 07:00	1.5	12.8	1,955.6	1.1	7.80	1	1	1
09/18/2024 08:00	1.4	12.9	1,916.9	1.0	7.70	1	1	1
09/18/2024 09:00	1.4	12.9	1,921.9	1.0	7.70	1	1	1
09/18/2024 10:00	1.4	12.8	1,931.7	1.0	7.70	1	1	1
09/18/2024 11:00	1.5	12.8	1,936.0	1.1	7.70	1	1	1
09/18/2024 12:00	1.5	12.8	1,935.7	1.1	7.70	1	1	1
09/18/2024 13:00	1.4	12.7	1,946.8	1.0	7.80	1	1	1
09/18/2024 14:00	1.5	12.7	1,952.7	1.1	7.80	1	1	1
09/18/2024 15:00	1.5	12.7	1,941.3	1.1	7.80	1	1	1
09/18/2024 16:00	1.5	12.2	2,065.1	1.0	8.30	1	1	1
09/18/2024 17:00	1.6	11.6	2,172.4	1.0	8.70	1	1	1
09/18/2024 18:00	1.6	11.9	2,107.2	1.0	8.40	1	1	1
09/18/2024 19:00	1.5	11.8	2,124.3	1.0	8.50	1	1	1
09/18/2024 20:00	1.6	11.9	2,109.4	1.0	8.40	1	1	1
09/18/2024 21:00	1.6	11.9	2,110.8	1.0	8.40	1	1	1
09/18/2024 22:00	1.6	12.0	2,106.6	1.1	8.40	1	1	1
09/18/2024 23:00	1.6	12.0	2,108.3	1.1	8.40	1	1	1
Average/Sum#:	3.1	12.9	1,863.3	3.6	257.03 #	23 #	21 #	20 #
Minimum:	1.3	11.6	337.6	1.0	5.90	0	0	0
Maximum:	27.5	17.5	2,172.4	47.7	46.33	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2024 00:00	1.5	11.9	2,111.6	1.0	8.40	1	1	1
09/19/2024 01:00	1.6	12.0	2,109.8	1.1	8.40	1	1	1
09/19/2024 02:00	1.5	12.0	2,112.4	1.0	8.40	1	1	1
09/19/2024 03:00	1.6	11.9	2,115.1	1.0	8.50	1	1	1
09/19/2024 04:00	1.6	12.0	2,112.3	1.1	8.40	1	1	1
09/19/2024 05:00	1.6	12.0	2,112.3	1.1	8.40	1	1	1
09/19/2024 06:00	1.4	12.4	2,031.0	1.0	8.10	1	1	1
09/19/2024 07:00	1.9	15.5	651.4	2.1	1.30	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	12.5	1,919.5	1.2	59.90 #	8 #	7 #	7 #
Minimum:	1.4	11.9	651.4	1.0	1.30	0	0	0
Maximum:	1.9	15.5	2,115.1	2.1	8.50	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/21/2024 20:00	28.8	17.6	313.3	51.5	36.89	1	0	0
09/21/2024 21:00	15.5	17.1	392.2	24.1	34.90	1	0	0
09/21/2024 22:00	11.6	15.2	926.2	12.0	40.80	1	0	0
09/21/2024 23:00	1.3	13.9	1,560.6	1.1	6.20	1	1	0
Average/Sum#:	14.3	16.0	798.1	22.2	118.79 #	4 #	1 #	0 #
Minimum:	1.3	13.9	313.3	1.1	6.20	0	0	0
Maximum:	28.8	17.6	1,560.6	51.5	40.80	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2024 00:00	1.3	13.8	1,688.4	1.1	6.80	1	1	0
09/22/2024 01:00	1.3	13.8	1,700.0	1.1	6.80	1	1	0
09/22/2024 02:00	1.3	13.8	1,673.9	1.1	6.70	1	1	0
09/22/2024 03:00	1.3	13.8	1,672.3	1.1	6.70	1	1	0
09/22/2024 04:00	1.3	13.8	1,693.7	1.1	6.80	1	1	0
09/22/2024 05:00	1.3	13.8	1,695.1	1.1	6.80	1	1	0
09/22/2024 06:00	1.3	13.9	1,598.5	1.1	6.40	1	1	0
09/22/2024 07:00	3.6	15.6	609.4	4.0	2.09	1	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/22/2024 10:00	6.2	17.6	391.9	11.1	6.92	1	0	0
09/22/2024 11:00	12.4	14.7	1,056.8	11.8	45.40	1	0	0
09/22/2024 12:00	1.3	14.0	1,519.1	1.1	6.10	1	1	0
09/22/2024 13:00	1.3	14.0	1,510.6	1.1	6.00	1	1	0
09/22/2024 14:00	1.3	13.8	1,652.6	1.1	6.60	1	1	0
09/22/2024 15:00	1.2	13.9	1,470.3	1.0	5.90	1	1	0
09/22/2024 16:00	1.3	13.9	1,483.9	1.1	5.90	1	1	0
09/22/2024 17:00	1.3	13.9	1,596.3	1.1	6.40	1	1	1
09/22/2024 18:00	1.5	12.6	1,947.4	1.1	7.80	1	1	1
09/22/2024 19:00	1.5	12.5	1,957.3	1.1	7.80	1	1	1
09/22/2024 20:00	1.5	12.6	1,938.0	1.1	7.80	1	1	1
09/22/2024 21:00	1.5	12.6	1,932.7	1.1	7.70	1	1	1
09/22/2024 22:00	1.5	12.8	1,911.8	1.1	7.60	1	1	1
09/22/2024 23:00	1.5	12.9	1,909.0	1.1	7.60	1	1	1
Average/Sum#:	2.2	13.8	1,573.1	2.2	184.61 #	22 #	19 #	7 #
Minimum:	1.2	12.5	391.9	1.0	2.09	0	0	0
Maximum:	12.4	17.6	1,957.3	11.8	45.40	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2024 00:00	1.4	12.9	1,909.9	1.0	7.60	1	1	1
09/23/2024 01:00	1.5	12.9	1,907.8	1.1	7.60	1	1	1
09/23/2024 02:00	1.4	12.9	1,908.0	1.0	7.60	1	1	1
09/23/2024 03:00	1.4	12.9	1,909.5	1.0	7.60	1	1	1
09/23/2024 04:00	1.5	12.8	1,911.8	1.1	7.60	1	1	1
09/23/2024 05:00	1.4	12.8	1,898.8	1.0	7.60	1	1	1
09/23/2024 06:00	1.1	13.8	1,620.5	0.9	4.90	1	1	0
09/23/2024 07:00	1.3	13.9	1,561.7	1.1	6.20	1	1	0
09/23/2024 08:00	1.3	13.8	1,636.8	1.1	6.50	1	1	0
09/23/2024 09:00	1.3	13.9	1,503.8	1.1	6.00	1	1	0
09/23/2024 10:00	1.3	13.9	1,509.6	1.1	6.00	1	1	0
09/23/2024 11:00	1.3	13.8	1,636.6	1.1	6.50	1	1	0
09/23/2024 12:00	1.4	13.6	1,681.2	1.1	6.70	1	1	0
09/23/2024 13:00	1.3	13.6	1,681.2	1.1	6.70	1	1	1
09/23/2024 14:00	1.6	11.8	2,092.0	1.0	8.40	1	1	1
09/23/2024 15:00	1.5	11.5	2,154.6	0.9	6.50	1	1	1
09/23/2024 16:00	1.6	11.4	2,169.2	1.0	8.70	1	1	1
09/23/2024 17:00	1.6	11.3	2,180.8	1.0	8.70	1	1	1
09/23/2024 18:00	1.6	11.3	2,187.8	1.0	8.80	1	1	1
09/23/2024 19:00	1.5	11.4	2,203.9	0.9	6.60	1	1	1
09/23/2024 20:00	1.6	11.4	2,211.7	1.0	8.80	1	1	1
09/23/2024 21:00	1.5	11.4	2,208.7	0.9	6.60	1	1	1
09/23/2024 22:00	1.6	11.5	2,191.0	1.0	8.80	1	1	1
09/23/2024 23:00	1.5	12.2	2,035.4	1.0	8.10	1	1	1
Average/Sum#:	1.4	12.6	1,913.0	1.0	175.10 #	24 #	24 #	17 #
Minimum:	1.1	11.3	1,503.8	0.9	4.90	1	1	0
Maximum:	1.6	13.9	2,211.7	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2024 00:00	1.3	13.8	1,685.3	1.1	6.70	1	1	1
09/24/2024 01:00	1.3	13.9	1,667.6	1.1	6.70	1	1	0
09/24/2024 02:00	1.3	13.9	1,631.2	1.1	6.50	1	1	0
09/24/2024 03:00	1.3	13.9	1,667.0	1.1	6.70	1	1	0
09/24/2024 04:00	1.3	13.8	1,677.0	1.1	6.70	1	1	0
09/24/2024 05:00	1.3	13.9	1,666.7	1.1	6.70	1	1	0
09/24/2024 06:00	1.2	13.8	1,626.8	1.0	6.50	1	1	0
09/24/2024 07:00	1.3	13.9	1,573.7	1.1	6.30	1	1	0
09/24/2024 08:00	1.3	13.9	1,501.2	1.1	6.00	1	1	0
09/24/2024 09:00	1.3	13.8	1,519.9	1.1	6.10	1	1	0
09/24/2024 10:00	1.3	13.8	1,550.8	1.1	6.20	1	1	0
09/24/2024 11:00	1.3	13.8	1,640.5	1.1	6.60	1	1	0
09/24/2024 12:00	1.2	13.9	1,387.9	1.0	5.60	1	1	0
09/24/2024 13:00	1.5	12.6	1,830.9	1.1	7.30	1	1	1
09/24/2024 14:00	1.6	11.4	2,137.5	1.0	8.60	1	1	1
09/24/2024 15:00	1.6	11.6	2,115.3	1.0	8.50	1	1	1
09/24/2024 16:00	1.6	11.4	2,149.5	1.0	8.60	1	1	1
09/24/2024 17:00	1.6	11.3	2,175.6	1.0	8.70	1	1	1
09/24/2024 18:00	1.6	11.4	2,156.1	1.0	8.60	1	1	1
09/24/2024 19:00	1.6	11.8	2,075.4	1.0	8.30	1	1	1
09/24/2024 20:00	1.6	11.7	2,133.2	1.0	8.50	1	1	1
09/24/2024 21:00	1.5	12.0	2,058.0	1.0	8.20	1	1	1
09/24/2024 22:00	1.5	12.2	2,013.0	1.0	8.10	1	1	1
09/24/2024 23:00	1.6	11.7	2,129.8	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.9	1,823.7	1.1	175.20 #	24 #	24 #	12 #
Minimum:	1.2	11.3	1,387.9	1.0	5.60	1	1	0
Maximum:	1.6	13.9	2,175.6	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2024 00:00	1.6	11.8	2,120.6	1.0	8.50	1	1	1
09/25/2024 01:00	1.5	11.9	2,091.9	1.0	8.40	1	1	1
09/25/2024 02:00	1.5	12.2	2,040.2	1.0	8.20	1	1	1
09/25/2024 03:00	1.6	12.0	2,098.3	1.1	8.40	1	1	1
09/25/2024 04:00	1.6	11.9	2,111.2	1.0	8.40	1	1	1
09/25/2024 05:00	1.6	12.0	2,108.0	1.1	8.40	1	1	1
09/25/2024 06:00	1.5	12.3	2,024.4	1.0	8.10	1	1	1
09/25/2024 07:00	2.0	15.4	689.0	2.1	1.49	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/25/2024 18:00	0.0	20.7	0.2	0.0	0.00	1	0	0
09/25/2024 19:00	20.4	15.8	745.9	23.6	64.90	1	0	0
09/25/2024 20:00	1.2	13.8	1,492.4	1.0	6.00	1	1	0
09/25/2024 21:00	1.3	13.8	1,612.7	1.1	6.50	1	1	0
09/25/2024 22:00	1.3	13.9	1,396.3	1.1	5.60	1	1	0
09/25/2024 23:00	1.3	13.8	1,666.1	1.1	6.70	1	1	0
Average/Sum#:	2.7	13.7	1,585.5	2.7	149.59 #	14 #	11 #	7 #
Minimum:	0.0	11.8	0.2	0.0	0.00	0	0	0
Maximum:	20.4	20.7	2,120.6	23.6	64.90	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2024 00:00	1.3	13.8	1,689.2	1.1	6.80	1	1	0
09/26/2024 01:00	1.3	13.8	1,654.0	1.1	6.60	1	1	0
09/26/2024 02:00	1.3	13.8	1,630.7	1.1	6.50	1	1	0
09/26/2024 03:00	1.3	13.8	1,659.7	1.1	6.60	1	1	0
09/26/2024 04:00	1.3	13.8	1,680.7	1.1	6.70	1	1	0
09/26/2024 05:00	1.3	13.8	1,680.7	1.1	6.70	1	1	0
09/26/2024 06:00	1.3	13.8	1,623.4	1.1	6.50	1	1	0
09/26/2024 07:00	1.3	13.9	1,383.1	1.1	5.50	1	1	0
09/26/2024 08:00	4.8	15.7	569.2	5.4	2.62	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	14.0	1,507.9	1.6	54.52 #	9 #	8 #	0 #
Minimum:	1.3	13.8	569.2	1.1	2.62	0	0	0
Maximum:	4.8	15.7	1,689.2	5.4	6.80	1	1	0
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2024 13:00	28.1	17.7	306.4	51.8	27.50	1	0	0
09/27/2024 14:00	18.2	15.0	1,030.4	18.2	69.00	1	0	0
09/27/2024 15:00	1.2	13.9	1,436.6	1.0	5.70	1	1	0
09/27/2024 16:00	1.2	13.8	1,521.1	1.0	6.10	1	1	1
09/27/2024 17:00	1.6	11.7	2,104.0	1.0	8.40	1	1	1
09/27/2024 18:00	1.6	11.3	2,197.4	1.0	8.80	1	1	1
09/27/2024 19:00	1.6	11.3	2,198.0	1.0	8.80	1	1	1
09/27/2024 20:00	1.5	11.3	2,204.7	0.9	6.60	1	1	1
09/27/2024 21:00	1.6	11.5	2,192.3	1.0	8.80	1	1	1
09/27/2024 22:00	1.6	11.8	2,119.2	1.0	8.50	1	1	1
09/27/2024 23:00	1.5	11.8	2,120.2	1.0	8.50	1	1	1
Average/Sum#:	5.4	12.8	1,766.4	7.2	166.70 #	11 #	9 #	8 #
Minimum:	1.2	11.3	306.4	0.9	5.70	0	0	0
Maximum:	28.1	17.7	2,204.7	51.8	69.00	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2024 00:00	1.6	11.8	2,119.5	1.0	8.50	1	1	1
09/28/2024 01:00	1.6	11.9	2,118.4	1.0	8.50	1	1	1
09/28/2024 02:00	1.6	11.9	2,115.2	1.0	8.50	1	1	1
09/28/2024 03:00	1.6	11.9	2,113.4	1.0	8.50	1	1	1
09/28/2024 04:00	1.5	11.9	2,110.8	1.0	8.40	1	1	1
09/28/2024 05:00	1.6	12.0	2,113.5	1.1	8.50	1	1	1
09/28/2024 06:00	1.4	12.5	2,004.0	1.0	8.00	1	1	1
09/28/2024 07:00	3.1	15.4	693.8	3.3	2.24	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2024 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.8	12.4	1,923.6	1.3	61.14 #	8 #	7 #	7 #
Minimum:	1.4	11.8	693.8	1.0	2.24	0	0	0
Maximum:	3.1	15.4	2,119.5	3.3	8.50	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2024 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2024 14:00	26.6	17.8	317.0	50.6	27.87	1	0	0
09/29/2024 15:00	14.5	14.8	1,077.9	14.0	56.10	1	0	0
09/29/2024 16:00	1.3	13.8	1,571.4	1.1	6.30	1	1	0
09/29/2024 17:00	1.4	13.6	1,706.5	1.1	6.80	1	1	1
09/29/2024 18:00	1.5	12.5	1,960.0	1.1	7.80	1	1	1
09/29/2024 19:00	1.5	11.7	2,159.0	1.0	8.60	1	1	1
09/29/2024 20:00	1.6	11.7	2,159.7	1.0	8.60	1	1	1
09/29/2024 21:00	1.6	12.1	2,079.8	1.1	8.30	1	1	1
09/29/2024 22:00	1.5	12.8	1,944.4	1.1	7.80	1	1	1
09/29/2024 23:00	1.6	12.0	2,131.4	1.1	8.50	1	1	1
Average/Sum#:	5.3	13.3	1,710.7	7.3	146.67 #	10 #	8 #	7 #
Minimum:	1.3	11.7	317.0	1.0	6.30	0	0	0
Maximum:	26.6	17.8	2,159.7	50.6	56.10	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:30 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2024 00:00	1.5	12.3	2,051.0	1.0	8.20	1	1	1
09/30/2024 01:00	1.5	12.9	1,934.2	1.1	7.70	1	1	1
09/30/2024 02:00	1.5	12.8	1,938.0	1.1	7.80	1	1	1
09/30/2024 03:00	1.4	12.7	1,982.0	1.0	7.90	1	1	1
09/30/2024 04:00	1.5	12.3	2,059.9	1.0	8.20	1	1	1
09/30/2024 05:00	1.6	12.3	2,121.7	1.1	8.50	1	1	1
09/30/2024 06:00	1.4	12.2	2,163.6	0.9	6.50	1	1	1
09/30/2024 07:00	1.4	13.0	1,863.0	1.0	7.50	1	1	1
09/30/2024 08:00	1.2	14.0	1,318.0	1.0	5.30	1	1	0
09/30/2024 09:00	1.3	14.1	1,313.4	1.1	5.30	1	1	0
09/30/2024 10:00	1.3	14.1	1,315.1	1.1	5.30	1	1	0
09/30/2024 11:00	1.3	14.1	1,427.8	1.1	5.70	1	1	0
09/30/2024 12:00	1.2	14.0	1,564.1	1.0	6.30	1	1	0
09/30/2024 13:00	1.2	13.8	1,667.3	1.0	6.70	1	1	1
09/30/2024 14:00	1.6	12.0	2,130.1	1.1	8.50	1	1	1
09/30/2024 15:00	1.6	12.0	2,131.5	1.1	8.50	1	1	1
09/30/2024 16:00	1.6	11.4	2,253.4	1.0	9.00	1	1	1
09/30/2024 17:00	1.7	11.4	2,265.6	1.1	9.10	1	1	1
09/30/2024 18:00	1.6	11.4	2,272.5	1.0	9.10	1	1	1
09/30/2024 19:00	1.6	11.4	2,275.7	1.0	9.10	1	1	1
09/30/2024 20:00	1.6	11.7	2,221.2	1.0	8.90	1	1	1
09/30/2024 21:00	1.6	11.4	2,282.1	1.0	9.10	1	1	1
09/30/2024 22:00	1.6	11.8	2,223.0	1.0	8.90	1	1	1
09/30/2024 23:00	1.5	12.2	2,121.3	1.0	8.50	1	1	1
Average/Sum#:	1.5	12.6	1,954.0	1.0	185.60 #	24 #	24 #	19 #
Minimum:	1.2	11.4	1,313.4	0.9	5.30	1	1	0
Maximum:	1.7	14.1	2,282.1	1.1	9.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	34.1	15.4	618.6	0.0	11.7	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 08:00	19.9	17.4	351.7	0.0	15.8	1	0	0
07/01/2024 09:00	25.8	15.5	797.9	0.0	50.3	1	0	0
07/01/2024 10:00	0.0	13.7	1,590.9	0.0	0.0	1	0	0
07/01/2024 11:00	0.0	13.7	1,478.8	0.0	0.0	1	0	0
07/01/2024 12:00	0.0	13.8	1,412.5	0.0	0.0	1	0	0
07/01/2024 13:00	0.0	13.7	1,639.2	0.0	0.0	1	0	0
07/01/2024 14:00	0.0	13.7	1,543.8	0.0	0.0	1	0	0
07/01/2024 15:00	0.0	13.9	1,339.5	0.0	0.0	1	1	0
07/01/2024 16:00	0.0	13.6	1,559.1	0.0	0.0	1	1	1
07/01/2024 17:00	0.0	11.7	2,129.1	0.0	0.0	1	1	1
07/01/2024 18:00	0.0	11.4	2,189.3	0.0	0.0	1	1	1
07/01/2024 19:00	0.0	11.5	2,181.9	0.0	0.0	1	1	1
07/01/2024 20:00	0.0	11.5	2,172.0	0.0	0.0	1	1	1
07/01/2024 21:00	0.0	12.0	2,078.8	0.0	0.0	1	1	1
07/01/2024 22:00	0.0	12.1	2,065.8	0.0	0.0	1	1	1
07/01/2024 23:00	15.2	15.6	606.5	0.0	6.2	1	0	0
Average/Sum#:	5.6	13.5	1,515.0	0.0	84.0 #	17 #	8 #	7 #
Minimum:	0.0	11.4	351.7	0.0	0.0	0	0	0
Maximum:	34.1	17.4	2,189.3	0.0	50.3	1	1	1
%SI	29.17	29.17	29.17	54.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 10:00	20.7	17.5	331.6	0.0	13.4	1	0	0
07/02/2024 11:00	14.9	16.9	423.8	0.0	20.8	1	0	0
07/02/2024 12:00	16.4	15.0	986.6	0.0	36.2	1	0	0
07/02/2024 13:00	0.0	13.7	1,659.3	0.0	0.0	1	0	0
07/02/2024 14:00	0.0	13.7	1,576.4	0.0	0.0	1	0	0
07/02/2024 15:00	0.0	13.6	1,668.0	0.0	0.0	1	0	0
07/02/2024 16:00	0.0	13.7	1,581.8	0.0	0.0	1	0	0
07/02/2024 17:00	0.0	13.7	1,636.5	0.0	0.0	1	0	0
07/02/2024 18:00	0.0	12.6	1,852.2	0.0	0.0	1	1	1
07/02/2024 19:00	0.0	11.5	2,194.8	0.0	0.0	1	1	1
07/02/2024 20:00	0.0	11.5	2,184.0	0.0	0.0	1	1	1
07/02/2024 21:00	0.0	11.5	2,182.6	0.0	0.0	1	1	1
07/02/2024 22:00	0.0	11.9	2,127.1	0.0	0.0	1	1	1
07/02/2024 23:00	0.0	11.5	2,208.0	0.0	0.0	1	1	1
Average/Sum#:	3.7	13.5	1,615.2	0.0	70.4 #	14 #	6 #	6 #
Minimum:	0.0	11.5	331.6	0.0	0.0	0	0	0
Maximum:	20.7	17.5	2,208.0	0.0	36.2	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2024 00:00	0.0	11.5	2,201.3	0.0	0.0	1	1	1
07/03/2024 01:00	0.0	12.0	2,096.1	0.0	0.0	1	1	1
07/03/2024 02:00	0.0	12.2	2,062.5	0.0	0.0	1	1	1
07/03/2024 03:00	0.0	12.3	2,042.7	0.0	0.0	1	1	1
07/03/2024 04:00	0.0	12.2	2,053.8	0.0	0.0	1	1	1
07/03/2024 05:00	0.0	12.2	2,058.8	0.0	0.0	1	1	1
07/03/2024 06:00	0.0	12.1	2,070.2	0.0	0.0	1	1	1
07/03/2024 07:00	0.0	12.1	2,078.1	0.0	0.0	1	1	1
07/03/2024 08:00	0.0	12.1	2,084.4	0.0	0.0	1	1	1
07/03/2024 09:00	0.0	12.0	2,092.0	0.0	0.0	1	1	1
07/03/2024 10:00	0.0	12.0	2,098.8	0.0	0.0	1	1	1
07/03/2024 11:00	0.0	12.0	2,085.2	0.0	0.0	1	1	1
07/03/2024 12:00	0.0	11.9	2,092.6	0.0	0.0	1	1	1
07/03/2024 13:00	0.0	11.8	2,091.2	0.0	0.0	1	1	1
07/03/2024 14:00	0.0	11.8	2,093.7	0.0	0.0	1	1	1
07/03/2024 15:00	0.0	11.8	2,103.4	0.0	0.0	1	1	1
07/03/2024 16:00	0.0	12.0	2,045.5	0.0	0.0	1	1	1
07/03/2024 17:00	0.0	12.0	2,046.1	0.0	0.0	1	1	1
07/03/2024 18:00	0.0	11.9	2,060.8	0.0	0.0	1	1	1
07/03/2024 19:00	0.0	11.9	2,080.4	0.0	0.0	1	1	1
07/03/2024 20:00	0.0	11.9	2,077.8	0.0	0.0	1	1	1
07/03/2024 21:00	0.0	12.0	2,070.5	0.0	0.0	1	1	1
07/03/2024 22:00	0.0	12.1	2,065.4	0.0	0.0	1	1	1
07/03/2024 23:00	0.0	12.1	2,052.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.0	2,079.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	2,042.7	0.0	0.0	1	1	1
Maximum:	0.0	12.3	2,201.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	0.0	12.4	2,015.8	0.0	0.0	1	1	1
07/04/2024 01:00	0.0	12.4	1,983.5	0.0	0.0	1	1	1
07/04/2024 02:00	17.9	15.4	660.6	0.0	7.7	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 09:00	20.5	17.4	344.7	0.0	14.2	1	0	0
07/04/2024 10:00	29.4	14.9	1,019.5	0.0	66.0	1	0	0
07/04/2024 11:00	0.0	13.7	1,605.0	0.0	0.0	1	0	0
07/04/2024 12:00	0.0	13.7	1,595.7	0.0	0.0	1	0	0
07/04/2024 13:00	0.0	13.7	1,553.2	0.0	0.0	1	0	0
07/04/2024 14:00	0.0	13.8	1,453.0	0.0	0.0	1	0	0
07/04/2024 15:00	0.0	13.7	1,524.6	0.0	0.0	1	1	0
07/04/2024 16:00	0.0	13.5	1,694.9	0.0	0.0	1	1	0
07/04/2024 17:00	0.0	12.6	1,830.7	0.0	0.0	1	1	1
07/04/2024 18:00	0.0	11.5	2,157.8	0.0	0.0	1	1	1
07/04/2024 19:00	0.0	11.7	2,124.4	0.0	0.0	1	1	1
07/04/2024 20:00	0.0	11.9	2,071.3	0.0	0.0	1	1	1
07/04/2024 21:00	0.0	12.0	2,062.4	0.0	0.0	1	1	1
07/04/2024 22:00	0.0	12.1	2,043.0	0.0	0.0	1	1	1
07/04/2024 23:00	0.0	12.2	2,010.4	0.0	0.0	1	1	1
Average/Sum#:	3.8	13.3	1,652.8	0.0	87.9 #	18 #	11 #	9 #
Minimum:	0.0	11.5	344.7	0.0	0.0	0	0	0
Maximum:	29.4	17.4	2,157.8	0.0	66.0	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2024 00:00	0.0	13.6	1,719.5	0.0	0.0	1	1	0
07/05/2024 01:00	0.0	13.6	1,712.9	0.0	0.0	1	1	0
07/05/2024 02:00	0.0	13.6	1,705.4	0.0	0.0	1	1	0
07/05/2024 03:00	0.0	13.6	1,730.6	0.0	0.0	1	1	0
07/05/2024 04:00	0.0	13.7	1,619.1	0.0	0.0	1	1	0
07/05/2024 05:00	0.0	13.6	1,652.1	0.0	0.0	1	1	0
07/05/2024 06:00	0.0	13.5	1,747.9	0.0	0.0	1	1	0
07/05/2024 07:00	0.0	13.5	1,746.9	0.0	0.0	1	1	0
07/05/2024 08:00	0.0	13.5	1,751.1	0.0	0.0	1	1	0
07/05/2024 09:00	0.0	13.4	1,750.7	0.0	0.0	1	1	0
07/05/2024 10:00	0.0	13.4	1,736.4	0.0	0.0	1	1	0
07/05/2024 11:00	0.0	13.5	1,730.8	0.0	0.0	1	1	0
07/05/2024 12:00	0.0	13.6	1,557.8	0.0	0.0	1	1	0
07/05/2024 13:00	0.0	12.6	1,816.1	0.0	0.0	1	1	1
07/05/2024 14:00	0.0	11.3	2,142.7	0.0	0.0	1	1	1
07/05/2024 15:00	0.0	11.4	2,122.2	0.0	0.0	1	1	1
07/05/2024 16:00	0.0	11.4	2,121.9	0.0	0.0	1	1	1
07/05/2024 17:00	0.0	11.4	2,122.1	0.0	0.0	1	1	1
07/05/2024 18:00	0.0	11.5	2,117.9	0.0	0.0	1	1	1
07/05/2024 19:00	0.0	11.5	2,126.4	0.0	0.0	1	1	1
07/05/2024 20:00	0.0	11.6	2,122.8	0.0	0.0	1	1	1
07/05/2024 21:00	0.0	11.5	2,178.0	0.0	0.0	1	1	1
07/05/2024 22:00	0.0	11.5	2,133.1	0.0	0.0	1	1	1
07/05/2024 23:00	0.0	12.0	2,062.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,884.5	0.0	0.0 #	24 #	24 #	11 #
Minimum:	0.0	11.3	1,557.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,178.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2024 00:00	0.0	12.2	2,034.0	0.0	0.0	1	1	1
07/06/2024 01:00	0.0	12.3	2,018.6	0.0	0.0	1	1	1
07/06/2024 02:00	0.0	12.3	2,018.6	0.0	0.0	1	1	1
07/06/2024 03:00	0.0	12.3	2,023.5	0.0	0.0	1	1	1
07/06/2024 04:00	0.0	12.4	2,017.8	0.0	0.0	1	1	1
07/06/2024 05:00	0.0	12.2	2,010.1	0.0	0.0	1	1	1
07/06/2024 06:00	21.5	15.4	620.4	0.0	8.0	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 09:00	7.7	18.5	172.5	0.0	1.5	1	0	0
07/06/2024 10:00	22.5	15.3	859.8	0.0	45.6	1	0	0
07/06/2024 11:00	0.0	13.7	1,588.0	0.0	0.0	1	0	0
07/06/2024 12:00	0.0	13.6	1,610.6	0.0	0.0	1	0	0
07/06/2024 13:00	0.0	13.6	1,589.9	0.0	0.0	1	0	0
07/06/2024 14:00	0.0	13.7	1,452.7	0.0	0.0	1	0	0
07/06/2024 15:00	0.0	13.8	1,443.1	0.0	0.0	1	1	0
07/06/2024 16:00	0.0	13.6	1,555.0	0.0	0.0	1	1	1
07/06/2024 17:00	0.0	11.7	2,101.9	0.0	0.0	1	1	1
07/06/2024 18:00	0.0	11.4	2,123.7	0.0	0.0	1	1	1
07/06/2024 19:00	0.0	11.4	2,114.9	0.0	0.0	1	1	1
07/06/2024 20:00	0.0	11.5	2,116.9	0.0	0.0	1	1	1
07/06/2024 21:00	0.0	11.6	2,114.7	0.0	0.0	1	1	1
07/06/2024 22:00	0.0	11.6	2,111.9	0.0	0.0	1	1	1
07/06/2024 23:00	0.0	11.4	2,159.0	0.0	0.0	1	1	1
Average/Sum#:	2.4	13.0	1,720.8	0.0	55.1 #	22 #	15 #	14 #
Minimum:	0.0	11.4	172.5	0.0	0.0	0	0	0
Maximum:	22.5	18.5	2,159.0	0.0	45.6	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	0.0	11.9	2,078.6	0.0	0.0	1	1	1
07/07/2024 01:00	0.0	12.1	2,025.5	0.0	0.0	1	1	1
07/07/2024 02:00	0.0	12.1	2,005.2	0.0	0.0	1	1	1
07/07/2024 03:00	28.2	15.5	610.6	0.0	10.5	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/07/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/07/2024 15:00	31.0	17.8	271.0	0.0	11.5	1	1	0
07/07/2024 16:00	38.6	15.6	735.6	0.0	70.8	1	1	0
07/07/2024 17:00	0.0	13.7	1,377.6	0.0	0.0	1	1	0
07/07/2024 18:00	0.0	13.0	1,701.9	0.0	0.0	1	1	1
07/07/2024 19:00	0.0	11.3	2,119.6	0.0	0.0	1	1	1
07/07/2024 20:00	0.0	11.3	2,143.1	0.0	0.0	1	1	1
07/07/2024 21:00	0.0	11.7	2,063.9	0.0	0.0	1	1	1
07/07/2024 22:00	0.0	11.9	2,039.6	0.0	0.0	1	1	1
07/07/2024 23:00	0.0	11.7	2,103.3	0.0	0.0	1	1	1
Average/Sum#:	7.5	13.0	1,636.6	0.0	92.8 #	13 #	14 #	9 #
Minimum:	0.0	11.3	271.0	0.0	0.0	0	0	0
Maximum:	38.6	17.8	2,143.1	0.0	70.8	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	0.0	13.5	1,717.6	0.0	0.0	1	1	0
07/08/2024 01:00	0.0	13.6	1,702.2	0.0	0.0	1	1	0
07/08/2024 02:00	0.0	13.6	1,705.4	0.0	0.0	1	1	0
07/08/2024 03:00	0.0	13.6	1,706.4	0.0	0.0	1	1	0
07/08/2024 04:00	0.0	13.5	1,731.9	0.0	0.0	1	1	0
07/08/2024 05:00	0.0	13.5	1,749.9	0.0	0.0	1	1	0
07/08/2024 06:00	0.0	13.5	1,731.8	0.0	0.0	1	1	0
07/08/2024 07:00	0.0	13.5	1,719.5	0.0	0.0	1	1	0
07/08/2024 08:00	0.0	13.5	1,722.0	0.0	0.0	1	1	0
07/08/2024 09:00	0.0	13.5	1,716.9	0.0	0.0	1	1	0
07/08/2024 10:00	0.0	13.4	1,732.5	0.0	0.0	1	1	0
07/08/2024 11:00	0.0	13.4	1,727.4	0.0	0.0	1	1	0
07/08/2024 12:00	0.0	13.4	1,709.4	0.0	0.0	1	1	0
07/08/2024 13:00	0.0	13.6	1,598.9	0.0	0.0	1	1	0
07/08/2024 14:00	0.0	13.5	1,650.3	0.0	0.0	1	1	0
07/08/2024 15:00	0.0	13.5	1,681.4	0.0	0.0	1	1	0
07/08/2024 16:00	0.0	13.5	1,591.2	0.0	0.0	1	1	1
07/08/2024 17:00	0.0	11.5	2,114.4	0.0	0.0	1	1	1
07/08/2024 18:00	0.0	11.3	2,147.5	0.0	0.0	1	1	1
07/08/2024 19:00	0.0	11.3	2,158.8	0.0	0.0	1	1	1
07/08/2024 20:00	0.0	11.4	2,166.7	0.0	0.0	1	1	1
07/08/2024 21:00	0.0	11.4	2,175.4	0.0	0.0	1	1	1
07/08/2024 22:00	0.0	11.5	2,170.3	0.0	0.0	1	1	1
07/08/2024 23:00	0.0	11.4	2,194.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,834.3	0.0	0.0 #	24 #	24 #	8 #
Minimum:	0.0	11.3	1,591.2	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,194.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2024 00:00	0.0	11.4	2,201.1	0.0	0.0	1	1	1
07/09/2024 01:00	0.0	11.4	2,209.0	0.0	0.0	1	1	1
07/09/2024 02:00	0.0	11.5	2,212.1	0.0	0.0	1	1	1
07/09/2024 03:00	0.0	11.5	2,210.7	0.0	0.0	1	1	1
07/09/2024 04:00	0.0	11.4	2,223.5	0.0	0.0	1	1	1
07/09/2024 05:00	0.0	11.5	2,209.9	0.0	0.0	1	1	1
07/09/2024 06:00	0.0	12.2	2,046.0	0.0	0.0	1	1	1
07/09/2024 07:00	0.0	12.3	2,016.4	0.0	0.0	1	1	1
07/09/2024 08:00	0.0	11.7	2,152.5	0.0	0.0	1	1	1
07/09/2024 09:00	0.0	0.0	2,124.2	0.0	0.0	1	1	1
07/09/2024 10:00	0.0	0.0	2,136.7	0.0	0.0	1	1	1
07/09/2024 11:00	0.0	0.0	2,175.7	0.0	0.0	1	1	1
07/09/2024 12:00	0.0	11.4	2,173.4	0.0	0.0	1	1	1
07/09/2024 13:00	0.0	11.4	2,169.4	0.0	0.0	1	1	1
07/09/2024 14:00	0.0	11.4	2,159.9	0.0	0.0	1	1	1
07/09/2024 15:00	0.0	11.4	2,161.0	0.0	0.0	1	1	1
07/09/2024 16:00	0.0	11.4	2,164.4	0.0	0.0	1	1	1
07/09/2024 17:00	0.0	11.4	2,160.6	0.0	0.0	1	1	1
07/09/2024 18:00	0.0	11.5	2,139.0	0.0	0.0	1	1	1
07/09/2024 19:00	0.0	11.3	2,162.4	0.0	0.0	1	1	1
07/09/2024 20:00	0.0	11.3	2,172.2	0.0	0.0	1	1	1
07/09/2024 21:00	0.0	11.4	2,179.5	0.0	0.0	1	1	1
07/09/2024 22:00	0.0	11.5	2,167.2	0.0	0.0	1	1	1
07/09/2024 23:00	0.0	11.9	2,082.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.5	2,158.7	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.3	2,016.4	0.0	0.0	1	1	1
Maximum:	0.0	12.3	2,223.5	0.0	0.0	1	1	1
%SI	12.50	12.50	0.00	20.83	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2024 00:00	0.0	12.1	2,071.6	0.0	0.0	1	1	1
07/10/2024 01:00	0.0	11.4	2,209.7	0.0	0.0	1	1	1
07/10/2024 02:00	0.0	11.4	2,215.1	0.0	0.0	1	1	1
07/10/2024 03:00	0.0	11.4	2,214.6	0.0	0.0	1	1	1
07/10/2024 04:00	0.0	11.4	2,214.7	0.0	0.0	1	1	1
07/10/2024 05:00	0.0	11.6	2,182.7	0.0	0.0	1	1	1
07/10/2024 06:00	0.0	12.1	2,056.9	0.0	0.0	1	1	1
07/10/2024 07:00	0.0	12.2	2,008.5	0.0	0.0	1	1	1
07/10/2024 08:00	0.0	12.2	2,015.7	0.0	0.0	1	1	1
07/10/2024 09:00	0.0	12.1	2,027.7	0.0	0.0	1	1	1
07/10/2024 10:00	0.0	11.9	2,045.3	0.0	0.0	1	1	1
07/10/2024 11:00	0.0	11.7	2,078.9	0.0	0.0	1	1	1
07/10/2024 12:00	0.0	11.6	2,098.7	0.0	0.0	1	1	1
07/10/2024 13:00	0.0	11.4	2,150.6	0.0	0.0	1	1	1
07/10/2024 14:00	0.0	11.4	2,156.0	0.0	0.0	1	1	1
07/10/2024 15:00	0.0	11.5	2,135.6	0.0	0.0	1	1	1
07/10/2024 16:00	0.0	11.5	2,120.3	0.0	0.0	1	1	1
07/10/2024 17:00	0.0	11.5	2,110.8	0.0	0.0	1	1	1
07/10/2024 18:00	0.0	11.3	2,143.6	0.0	0.0	1	1	1
07/10/2024 19:00	0.0	11.3	2,152.8	0.0	0.0	1	1	1
07/10/2024 20:00	0.0	11.3	2,157.7	0.0	0.0	1	1	1
07/10/2024 21:00	0.0	11.3	2,166.8	0.0	0.0	1	1	1
07/10/2024 22:00	0.0	11.4	2,167.7	0.0	0.0	1	1	1
07/10/2024 23:00	0.0	11.4	2,170.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.6	2,128.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.3	2,008.5	0.0	0.0	1	1	1
Maximum:	0.0	12.2	2,215.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	0.0	11.5	2,148.4	0.0	0.0	1	1	1
07/11/2024 01:00	0.0	11.6	2,132.0	0.0	0.0	1	1	1
07/11/2024 02:00	0.0	11.7	2,104.5	0.0	0.0	1	1	1
07/11/2024 03:00	0.0	12.0	2,063.2	0.0	0.0	1	1	1
07/11/2024 04:00	0.0	11.4	2,186.3	0.0	0.0	1	1	1
07/11/2024 05:00	0.0	12.2	2,018.9	0.0	0.0	1	1	1
07/11/2024 06:00	0.0	13.5	1,721.5	0.0	0.0	1	1	0
07/11/2024 07:00	0.0	13.5	1,712.4	0.0	0.0	1	1	0
07/11/2024 08:00	0.0	13.6	1,549.8	0.0	0.0	1	1	0
07/11/2024 09:00	0.0	13.7	1,508.7	0.0	0.0	1	1	0
07/11/2024 10:00	0.0	13.6	1,640.7	0.0	0.0	1	1	0
07/11/2024 11:00	0.0	13.7	1,471.1	0.0	0.0	1	1	0
07/11/2024 12:00	0.0	13.6	1,600.7	0.0	0.0	1	1	0
07/11/2024 13:00	0.0	13.6	1,595.5	0.0	0.0	1	1	0
07/11/2024 14:00	0.0	13.7	1,570.1	0.0	0.0	1	1	0
07/11/2024 15:00	0.0	13.8	1,331.3	0.0	0.0	1	1	0
07/11/2024 16:00	0.0	13.8	1,334.0	0.0	0.0	1	1	0
07/11/2024 17:00	0.0	12.7	1,752.1	0.0	0.0	1	1	1
07/11/2024 18:00	0.0	11.4	2,125.2	0.0	0.0	1	1	1
07/11/2024 19:00	0.0	11.3	2,128.4	0.0	0.0	1	1	1
07/11/2024 20:00	0.0	11.6	2,088.7	0.0	0.0	1	1	1
07/11/2024 21:00	0.0	11.8	2,059.2	0.0	0.0	1	1	1
07/11/2024 22:00	0.0	11.4	2,160.1	0.0	0.0	1	1	1
07/11/2024 23:00	0.0	11.8	2,099.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,837.6	0.0	0.0 #	24 #	24 #	13 #
Minimum:	0.0	11.3	1,331.3	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,186.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	0.0	11.8	2,092.0	0.0	0.0	1	1	1
07/12/2024 01:00	0.0	11.8	2,098.3	0.0	0.0	1	1	1
07/12/2024 02:00	0.0	12.0	2,067.1	0.0	0.0	1	1	1
07/12/2024 03:00	0.0	11.5	2,184.5	0.0	0.0	1	1	1
07/12/2024 04:00	0.0	11.8	2,128.6	0.0	0.0	1	1	1
07/12/2024 05:00	0.0	11.9	2,109.3	0.0	0.0	1	1	1
07/12/2024 06:00	0.0	13.5	1,739.2	0.0	0.0	1	1	0
07/12/2024 07:00	0.0	13.6	1,545.3	0.0	0.0	1	1	0
07/12/2024 08:00	0.0	13.7	1,477.4	0.0	0.0	1	1	0
07/12/2024 09:00	0.0	13.7	1,483.1	0.0	0.0	1	1	0
07/12/2024 10:00	0.0	13.7	1,509.1	0.0	0.0	1	1	0
07/12/2024 11:00	0.0	13.8	1,434.6	0.0	0.0	1	1	0
07/12/2024 12:00	0.0	13.7	1,477.4	0.0	0.0	1	1	0
07/12/2024 13:00	0.0	13.8	1,341.1	0.0	0.0	1	1	0
07/12/2024 14:00	0.0	13.7	1,355.7	0.0	0.0	1	1	0
07/12/2024 15:00	0.0	13.8	1,357.1	0.0	0.0	1	1	0
07/12/2024 16:00	0.0	13.8	1,342.4	0.0	0.0	1	1	0
07/12/2024 17:00	0.0	13.8	1,343.3	0.0	0.0	1	1	0
07/12/2024 18:00	0.0	13.7	1,332.5	0.0	0.0	1	1	0
07/12/2024 19:00	0.0	13.7	1,328.8	0.0	0.0	1	1	0
07/12/2024 20:00	0.0	13.7	1,329.0	0.0	0.0	1	1	0
07/12/2024 21:00	0.0	13.5	1,639.5	0.0	0.0	1	1	0
07/12/2024 22:00	0.0	13.4	1,725.0	0.0	0.0	1	1	0
07/12/2024 23:00	0.0	13.4	1,725.0	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.2	1,631.9	0.0	0.0 #	24 #	24 #	6 #
Minimum:	0.0	11.5	1,328.8	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,184.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	0.0	13.4	1,725.6	0.0	0.0	1	1	0
07/13/2024 01:00	0.0	13.4	1,726.2	0.0	0.0	1	1	0
07/13/2024 02:00	0.0	13.4	1,737.2	0.0	0.0	1	1	0
07/13/2024 03:00	0.0	13.4	1,744.1	0.0	0.0	1	1	0
07/13/2024 04:00	0.0	13.5	1,721.5	0.0	0.0	1	1	0
07/13/2024 05:00	0.0	13.4	1,744.4	0.0	0.0	1	1	0
07/13/2024 06:00	0.0	13.5	1,708.0	0.0	0.0	1	1	0
07/13/2024 07:00	0.0	13.5	1,725.5	0.0	0.0	1	1	0
07/13/2024 08:00	0.0	13.5	1,711.4	0.0	0.0	1	1	0
07/13/2024 09:00	0.0	13.6	1,563.0	0.0	0.0	1	1	0
07/13/2024 10:00	0.0	13.7	1,561.4	0.0	0.0	1	1	0
07/13/2024 11:00	0.0	13.6	1,633.6	0.0	0.0	1	1	0
07/13/2024 12:00	0.0	13.6	1,651.9	0.0	0.0	1	1	0
07/13/2024 13:00	0.0	13.7	1,379.5	0.0	0.0	1	1	0
07/13/2024 14:00	0.0	13.7	1,324.3	0.0	0.0	1	1	0
07/13/2024 15:00	0.0	13.7	1,329.3	0.0	0.0	1	1	0
07/13/2024 16:00	0.0	13.7	1,324.6	0.0	0.0	1	1	0
07/13/2024 17:00	0.0	13.7	1,334.7	0.0	0.0	1	1	0
07/13/2024 18:00	0.0	13.7	1,329.5	0.0	0.0	1	1	0
07/13/2024 19:00	0.0	13.7	1,467.5	0.0	0.0	1	1	0
07/13/2024 20:00	0.0	13.4	1,720.8	0.0	0.0	1	1	0
07/13/2024 21:00	0.0	13.5	1,722.0	0.0	0.0	1	1	0
07/13/2024 22:00	0.0	13.5	1,734.9	0.0	0.0	1	1	0
07/13/2024 23:00	0.0	13.5	1,740.4	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.6	1,598.4	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.4	1,324.3	0.0	0.0	1	1	0
Maximum:	0.0	13.7	1,744.4	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	0.0	13.5	1,750.7	0.0	0.0	1	1	0
07/14/2024 01:00	0.0	13.6	1,652.7	0.0	0.0	1	1	0
07/14/2024 02:00	11.1	14.6	1,043.8	0.0	11.4	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 10:00	23.4	17.6	326.4	0.0	13.8	1	0	0
07/14/2024 11:00	29.9	15.4	822.1	0.0	59.0	1	0	0
07/14/2024 12:00	0.0	13.6	1,552.1	0.0	0.0	1	0	0
07/14/2024 13:00	0.0	13.6	1,568.5	0.0	0.0	1	0	0
07/14/2024 14:00	0.0	13.6	1,695.5	0.0	0.0	1	0	0
07/14/2024 15:00	0.0	13.6	1,539.7	0.0	0.0	1	0	0
07/14/2024 16:00	0.0	13.6	1,688.4	0.0	0.0	1	1	0
07/14/2024 17:00	0.0	13.5	1,709.3	0.0	0.0	1	1	1
07/14/2024 18:00	0.0	11.6	2,130.9	0.0	0.0	1	1	1
07/14/2024 19:00	0.0	11.3	2,176.2	0.0	0.0	1	1	1
07/14/2024 20:00	0.0	11.4	2,170.4	0.0	0.0	1	1	1
07/14/2024 21:00	0.0	11.4	2,173.9	0.0	0.0	1	1	1
07/14/2024 22:00	0.0	11.8	2,081.9	0.0	0.0	1	1	1
07/14/2024 23:00	0.0	12.1	2,007.6	0.0	0.0	1	1	1
Average/Sum#:	3.8	13.3	1,652.4	0.0	84.2 #	17 #	10 #	7 #
Minimum:	0.0	11.3	326.4	0.0	0.0	0	0	0
Maximum:	29.9	17.6	2,176.2	0.0	59.0	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	0.0	13.5	1,719.3	0.0	0.0	1	1	0
07/15/2024 01:00	0.0	13.5	1,728.6	0.0	0.0	1	1	0
07/15/2024 02:00	0.0	13.6	1,619.4	0.0	0.0	1	1	0
07/15/2024 03:00	0.0	13.6	1,712.9	0.0	0.0	1	1	0
07/15/2024 04:00	0.0	13.5	1,750.5	0.0	0.0	1	1	0
07/15/2024 05:00	0.0	13.6	1,716.8	0.0	0.0	1	1	0
07/15/2024 06:00	0.0	13.6	1,699.3	0.0	0.0	1	1	0
07/15/2024 07:00	0.0	13.6	1,711.6	0.0	0.0	1	1	0
07/15/2024 08:00	0.0	13.6	1,548.1	0.0	0.0	1	1	0
07/15/2024 09:00	0.0	13.7	1,480.1	0.0	0.0	1	1	0
07/15/2024 10:00	0.0	13.7	1,621.5	0.0	0.0	1	1	0
07/15/2024 11:00	0.0	13.5	1,706.0	0.0	0.0	1	1	0
07/15/2024 12:00	0.0	13.7	1,661.6	0.0	0.0	1	1	0
07/15/2024 13:00	0.0	13.6	1,669.1	0.0	0.0	1	1	0
07/15/2024 14:00	0.0	13.6	1,664.0	0.0	0.0	1	1	0
07/15/2024 15:00	0.0	13.7	1,590.6	0.0	0.0	1	1	0
07/15/2024 16:00	0.0	13.6	1,573.9	0.0	0.0	1	1	0
07/15/2024 17:00	0.0	12.9	1,738.3	0.0	0.0	1	1	1
07/15/2024 18:00	0.0	11.5	2,141.4	0.0	0.0	1	1	1
07/15/2024 19:00	0.0	11.4	2,179.4	0.0	0.0	1	1	1
07/15/2024 20:00	0.0	11.5	2,175.5	0.0	0.0	1	1	1
07/15/2024 21:00	0.0	11.7	2,137.3	0.0	0.0	1	1	1
07/15/2024 22:00	0.0	12.5	2,008.1	0.0	0.0	1	1	1
07/15/2024 23:00	0.0	12.4	1,992.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,772.7	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	11.4	1,480.1	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,179.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	0.0	13.5	1,728.4	0.0	0.0	1	1	1
07/16/2024 01:00	0.0	13.6	1,737.0	0.0	0.0	1	1	0
07/16/2024 02:00	0.0	13.6	1,744.1	0.0	0.0	1	1	0
07/16/2024 03:00	0.0	13.6	1,748.5	0.0	0.0	1	1	0
07/16/2024 04:00	0.0	13.6	1,745.4	0.0	0.0	1	1	0
07/16/2024 05:00	0.0	13.6	1,708.7	0.0	0.0	1	1	0
07/16/2024 06:00	0.0	13.6	1,689.8	0.0	0.0	1	1	0
07/16/2024 07:00	0.0	13.6	1,721.6	0.0	0.0	1	1	0
07/16/2024 08:00	0.0	13.6	1,600.4	0.0	0.0	1	1	0
07/16/2024 09:00	0.0	13.6	1,619.4	0.0	0.0	1	1	0
07/16/2024 10:00	0.0	13.6	1,659.0	0.0	0.0	1	1	0
07/16/2024 11:00	0.0	13.6	1,709.7	0.0	0.0	1	1	0
07/16/2024 12:00	0.0	13.6	1,643.1	0.0	0.0	1	1	0
07/16/2024 13:00	0.0	13.6	1,538.8	0.0	0.0	1	1	0
07/16/2024 14:00	0.0	13.8	1,325.2	0.0	0.0	1	1	0
07/16/2024 15:00	0.0	13.7	1,500.1	0.0	0.0	1	1	1
07/16/2024 16:00	0.0	11.9	2,081.4	0.0	0.0	1	1	1
07/16/2024 17:00	0.0	11.6	2,154.2	0.0	0.0	1	1	1
07/16/2024 18:00	0.0	11.5	2,202.4	0.0	0.0	1	1	1
07/16/2024 19:00	0.0	11.5	2,205.6	0.0	0.0	1	1	1
07/16/2024 20:00	0.0	11.4	2,212.3	0.0	0.0	1	1	1
07/16/2024 21:00	0.0	11.4	2,221.4	0.0	0.0	1	1	1
07/16/2024 22:00	0.0	11.6	2,207.6	0.0	0.0	1	1	1
07/16/2024 23:00	0.0	12.1	2,083.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,824.5	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	11.4	1,325.2	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,221.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2024 00:00	0.0	12.4	2,046.5	0.0	0.0	1	1	1
07/17/2024 01:00	0.0	13.4	1,702.4	0.0	0.0	1	1	1
07/17/2024 02:00	0.0	13.7	1,718.8	0.0	0.0	1	1	0
07/17/2024 03:00	0.0	13.7	1,744.2	0.0	0.0	1	1	0
07/17/2024 04:00	0.0	13.7	1,739.9	0.0	0.0	1	1	0
07/17/2024 05:00	0.0	13.7	1,660.3	0.0	0.0	1	1	0
07/17/2024 06:00	0.0	13.6	1,707.4	0.0	0.0	1	1	0
07/17/2024 07:00	0.0	13.6	1,738.5	0.0	0.0	1	1	0
07/17/2024 08:00	0.0	13.6	1,705.4	0.0	0.0	1	1	0
07/17/2024 09:00	0.0	13.6	1,623.0	0.0	0.0	1	1	0
07/17/2024 10:00	0.0	13.7	1,429.3	0.0	0.0	1	1	0
07/17/2024 11:00	0.0	13.7	1,432.0	0.0	0.0	1	1	0
07/17/2024 12:00	0.0	13.7	1,542.8	0.0	0.0	1	1	0
07/17/2024 13:00	0.0	13.8	1,479.4	0.0	0.0	1	1	0
07/17/2024 14:00	0.0	13.7	1,578.9	0.0	0.0	1	1	1
07/17/2024 15:00	0.0	12.0	2,098.2	0.0	0.0	1	1	1
07/17/2024 16:00	0.0	12.1	2,074.2	0.0	0.0	1	1	1
07/17/2024 17:00	0.0	11.9	2,120.2	0.0	0.0	1	1	1
07/17/2024 18:00	0.0	11.5	2,193.1	0.0	0.0	1	1	1
07/17/2024 19:00	0.0	11.5	2,200.0	0.0	0.0	1	1	1
07/17/2024 20:00	0.0	11.5	2,200.7	0.0	0.0	1	1	1
07/17/2024 21:00	0.0	11.5	2,200.2	0.0	0.0	1	1	1
07/17/2024 22:00	0.0	11.5	2,200.5	0.0	0.0	1	1	1
07/17/2024 23:00	0.0	11.6	2,193.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,847.1	0.0	0.0 #	24 #	24 #	12 #
Minimum:	0.0	11.5	1,429.3	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,200.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2024 00:00	0.0	12.2	2,053.3	0.0	0.0	1	1	1
07/18/2024 01:00	0.0	12.2	2,071.4	0.0	0.0	1	1	1
07/18/2024 02:00	0.0	11.6	2,202.4	0.0	0.0	1	1	1
07/18/2024 03:00	0.0	11.7	2,190.2	0.0	0.0	1	1	1
07/18/2024 04:00	0.0	11.6	2,210.8	0.0	0.0	1	1	1
07/18/2024 05:00	0.0	12.0	2,153.0	0.0	0.0	1	1	1
07/18/2024 06:00	0.0	12.2	2,058.3	0.0	0.0	1	1	1
07/18/2024 07:00	0.0	12.4	2,004.0	0.0	0.0	1	1	1
07/18/2024 08:00	0.0	12.2	2,051.2	0.0	0.0	1	1	1
07/18/2024 09:00	0.0	11.8	2,136.8	0.0	0.0	1	1	1
07/18/2024 10:00	0.0	11.7	2,139.9	0.0	0.0	1	1	1
07/18/2024 11:00	0.0	11.7	2,147.8	0.0	0.0	1	1	1
07/18/2024 12:00	0.0	11.8	2,110.0	0.0	0.0	1	1	1
07/18/2024 13:00	0.0	11.5	2,171.4	0.0	0.0	1	1	1
07/18/2024 14:00	0.0	11.5	2,166.6	0.0	0.0	1	1	1
07/18/2024 15:00	0.0	11.5	2,169.0	0.0	0.0	1	1	1
07/18/2024 16:00	0.0	11.5	2,162.4	0.0	0.0	1	1	1
07/18/2024 17:00	0.0	11.5	2,159.3	0.0	0.0	1	1	1
07/18/2024 18:00	0.0	11.5	2,161.1	0.0	0.0	1	1	1
07/18/2024 19:00	0.0	11.4	2,166.4	0.0	0.0	1	1	1
07/18/2024 20:00	0.0	11.5	2,174.2	0.0	0.0	1	1	1
07/18/2024 21:00	0.0	11.5	2,178.2	0.0	0.0	1	1	1
07/18/2024 22:00	0.0	11.5	2,192.1	0.0	0.0	1	1	1
07/18/2024 23:00	0.0	11.7	2,149.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.7	2,140.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	2,004.0	0.0	0.0	1	1	1
Maximum:	0.0	12.4	2,210.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2024 00:00	0.0	11.9	2,123.2	0.0	0.0	1	1	1
07/19/2024 01:00	0.0	12.0	2,102.5	0.0	0.0	1	1	1
07/19/2024 02:00	0.0	11.9	2,124.3	0.0	0.0	1	1	1
07/19/2024 03:00	0.0	12.3	2,029.2	0.0	0.0	1	1	1
07/19/2024 04:00	0.0	11.6	2,203.1	0.0	0.0	1	1	1
07/19/2024 05:00	0.0	12.2	2,105.2	0.0	0.0	1	1	1
07/19/2024 06:00	0.0	13.6	1,738.3	0.0	0.0	1	1	1
07/19/2024 07:00	0.0	13.5	1,744.8	0.0	0.0	1	1	0
07/19/2024 08:00	0.0	13.6	1,746.1	0.0	0.0	1	1	0
07/19/2024 09:00	0.0	13.5	1,747.1	0.0	0.0	1	1	0
07/19/2024 10:00	0.0	13.5	1,746.7	0.0	0.0	1	1	0
07/19/2024 11:00	0.0	13.4	1,745.0	0.0	0.0	1	1	0
07/19/2024 12:00	0.0	13.4	1,733.6	0.0	0.0	1	1	1
07/19/2024 13:00	0.0	11.6	2,137.4	0.0	0.0	1	1	1
07/19/2024 14:00	0.0	11.5	2,156.4	0.0	0.0	1	1	1
07/19/2024 15:00	0.0	11.5	2,160.5	0.0	0.0	1	1	1
07/19/2024 16:00	0.0	11.5	2,162.0	0.0	0.0	1	1	1
07/19/2024 17:00	0.0	11.4	2,157.7	0.0	0.0	1	1	1
07/19/2024 18:00	0.0	11.4	2,160.6	0.0	0.0	1	1	1
07/19/2024 19:00	0.0	11.4	2,160.1	0.0	0.0	1	1	1
07/19/2024 20:00	0.0	11.5	2,168.1	0.0	0.0	1	1	1
07/19/2024 21:00	0.0	11.6	2,168.2	0.0	0.0	1	1	1
07/19/2024 22:00	0.0	11.5	2,181.6	0.0	0.0	1	1	1
07/19/2024 23:00	0.0	11.5	2,192.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,028.9	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.4	1,733.6	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,203.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	0.0	11.5	2,188.1	0.0	0.0	1	1	1
07/20/2024 01:00	0.0	11.5	2,200.5	0.0	0.0	1	1	1
07/20/2024 02:00	0.0	11.5	2,200.9	0.0	0.0	1	1	1
07/20/2024 03:00	0.0	11.5	2,203.6	0.0	0.0	1	1	1
07/20/2024 04:00	0.0	11.5	2,206.0	0.0	0.0	1	1	1
07/20/2024 05:00	0.0	12.0	2,135.5	0.0	0.0	1	1	1
07/20/2024 06:00	0.0	13.6	1,705.8	0.0	0.0	1	1	1
07/20/2024 07:00	0.0	13.6	1,730.8	0.0	0.0	1	1	0
07/20/2024 08:00	0.0	13.7	1,570.4	0.0	0.0	1	1	0
07/20/2024 09:00	0.0	13.6	1,604.3	0.0	0.0	1	1	0
07/20/2024 10:00	0.0	13.5	1,707.7	0.0	0.0	1	1	0
07/20/2024 11:00	0.0	13.5	1,621.4	0.0	0.0	1	1	0
07/20/2024 12:00	0.0	13.8	1,340.6	0.0	0.0	1	1	0
07/20/2024 13:00	0.0	13.6	1,639.5	0.0	0.0	1	1	1
07/20/2024 14:00	0.0	11.5	2,133.8	0.0	0.0	1	1	1
07/20/2024 15:00	0.0	11.4	2,153.1	0.0	0.0	1	1	1
07/20/2024 16:00	0.0	11.4	2,151.3	0.0	0.0	1	1	1
07/20/2024 17:00	0.0	11.4	2,146.4	0.0	0.0	1	1	1
07/20/2024 18:00	0.0	11.4	2,154.5	0.0	0.0	1	1	1
07/20/2024 19:00	0.0	11.4	2,156.5	0.0	0.0	1	1	1
07/20/2024 20:00	0.0	11.4	2,156.9	0.0	0.0	1	1	1
07/20/2024 21:00	0.0	11.5	2,159.1	0.0	0.0	1	1	1
07/20/2024 22:00	0.0	11.4	2,175.6	0.0	0.0	1	1	1
07/20/2024 23:00	0.0	11.4	2,185.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	1,984.5	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.4	1,340.6	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,206.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2024 00:00	0.0	11.4	2,201.5	0.0	0.0	1	1	1
07/21/2024 01:00	0.0	11.4	2,207.8	0.0	0.0	1	1	1
07/21/2024 02:00	0.0	11.5	2,212.6	0.0	0.0	1	1	1
07/21/2024 03:00	0.0	11.5	2,211.3	0.0	0.0	1	1	1
07/21/2024 04:00	0.0	11.5	2,212.5	0.0	0.0	1	1	1
07/21/2024 05:00	13.2	14.2	1,548.2	0.0	30.2	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 10:00	21.7	17.4	350.1	0.0	14.9	1	0	0
07/21/2024 11:00	40.1	14.7	1,061.7	0.0	90.7	1	0	0
07/21/2024 12:00	0.0	13.7	1,429.7	0.0	0.0	1	0	0
07/21/2024 13:00	0.0	13.7	1,396.8	0.0	0.0	1	0	0
07/21/2024 14:00	0.0	13.6	1,613.0	0.0	0.0	1	0	0
07/21/2024 15:00	0.0	13.4	1,725.3	0.0	0.0	1	0	0
07/21/2024 16:00	0.0	12.3	1,906.0	0.0	0.0	1	0	1
07/21/2024 17:00	0.0	11.4	2,161.5	0.0	0.0	1	0	1
07/21/2024 18:00	0.0	11.3	2,164.6	0.0	0.0	1	0	1
07/21/2024 19:00	0.0	11.4	2,164.6	0.0	0.0	1	0	1
07/21/2024 20:00	0.0	11.4	2,167.8	0.0	0.0	1	0	1
07/21/2024 21:00	0.0	11.4	2,172.2	0.0	0.0	1	0	1
07/21/2024 22:00	0.0	11.4	2,172.3	0.0	0.0	1	0	1
07/21/2024 23:00	0.0	11.4	2,183.0	0.0	0.0	1	0	1
Average/Sum#:	3.8	12.5	1,863.1	0.0	135.8 #	20 #	5 #	14 #
Minimum:	0.0	11.3	350.1	0.0	0.0	0	0	0
Maximum:	40.1	17.4	2,212.6	0.0	90.7	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2024 00:00	0.0	11.4	2,185.0	0.0	0.0	1	0	1
07/22/2024 01:00	0.0	11.4	2,185.8	0.0	0.0	1	0	1
07/22/2024 02:00	0.0	11.8	2,100.0	0.0	0.0	1	0	1
07/22/2024 03:00	0.0	12.8	1,846.4	0.0	0.0	1	0	1
07/22/2024 04:00	0.0	13.6	1,448.5	0.0	0.0	1	0	0
07/22/2024 05:00	0.0	13.4	1,632.5	0.0	0.0	1	1	0
07/22/2024 06:00	0.0	13.6	1,714.3	0.0	0.0	1	1	0
07/22/2024 07:00	0.0	13.6	1,703.2	0.0	0.0	1	1	0
07/22/2024 08:00	0.0	13.6	1,703.1	0.0	0.0	1	1	0
07/22/2024 09:00	0.0	13.6	1,689.1	0.0	0.0	1	1	0
07/22/2024 10:00	0.0	13.6	1,674.3	0.0	0.0	1	1	0
07/22/2024 11:00	0.0	13.6	1,658.5	0.0	0.0	1	1	0
07/22/2024 12:00	0.0	12.6	1,826.2	0.0	0.0	1	1	1
07/22/2024 13:00	0.0	11.4	2,149.3	0.0	0.0	1	1	1
07/22/2024 14:00	0.0	11.4	2,150.2	0.0	0.0	1	1	1
07/22/2024 15:00	0.0	11.3	2,146.7	0.0	0.0	1	1	1
07/22/2024 16:00	0.0	11.4	2,149.8	0.0	0.0	1	1	1
07/22/2024 17:00	0.0	11.4	2,152.3	0.0	0.0	1	1	1
07/22/2024 18:00	0.0	11.4	2,147.4	0.0	0.0	1	1	1
07/22/2024 19:00	0.0	11.4	2,154.0	0.0	0.0	1	1	1
07/22/2024 20:00	0.0	11.4	2,153.5	0.0	0.0	1	1	1
07/22/2024 21:00	0.0	11.4	2,148.6	0.0	0.0	1	1	1
07/22/2024 22:00	0.0	11.4	2,165.2	0.0	0.0	1	1	1
07/22/2024 23:00	0.0	11.4	2,171.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	1,960.6	0.0	0.0 #	24 #	19 #	16 #
Minimum:	0.0	11.3	1,448.5	0.0	0.0	1	0	0
Maximum:	0.0	13.6	2,185.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2024 00:00	0.0	11.4	2,174.4	0.0	0.0	1	1	1
07/23/2024 01:00	0.0	11.4	2,178.6	0.0	0.0	1	1	1
07/23/2024 02:00	0.0	11.4	2,186.7	0.0	0.0	1	1	1
07/23/2024 03:00	0.0	11.4	2,187.0	0.0	0.0	1	1	1
07/23/2024 04:00	0.0	11.4	2,194.6	0.0	0.0	1	1	1
07/23/2024 05:00	0.0	11.4	2,200.2	0.0	0.0	1	1	1
07/23/2024 06:00	0.0	11.9	2,093.8	0.0	0.0	1	1	1
07/23/2024 07:00	0.0	11.6	2,153.9	0.0	0.0	1	1	1
07/23/2024 08:00	0.0	12.0	2,053.7	0.0	0.0	1	1	1
07/23/2024 09:00	0.0	11.7	2,108.2	0.0	0.0	1	1	1
07/23/2024 10:00	0.0	11.5	2,141.1	0.0	0.0	1	1	1
07/23/2024 11:00	0.0	11.4	2,157.1	0.0	0.0	1	1	1
07/23/2024 12:00	0.0	11.5	2,136.5	0.0	0.0	1	1	1
07/23/2024 13:00	0.0	11.6	2,112.7	0.0	0.0	1	1	1
07/23/2024 14:00	0.0	11.5	2,142.5	0.0	0.0	1	1	1
07/23/2024 15:00	0.0	11.4	2,146.2	0.0	0.0	1	1	1
07/23/2024 16:00	0.0	11.4	2,142.8	0.0	0.0	1	1	1
07/23/2024 17:00	0.0	11.4	2,141.0	0.0	0.0	1	1	1
07/23/2024 18:00	0.0	11.4	2,146.3	0.0	0.0	1	1	1
07/23/2024 19:00	0.0	11.4	2,158.7	0.0	0.0	1	1	1
07/23/2024 20:00	0.0	11.4	2,158.8	0.0	0.0	1	1	1
07/23/2024 21:00	0.0	11.5	2,166.0	0.0	0.0	1	1	1
07/23/2024 22:00	0.0	11.5	2,179.9	0.0	0.0	1	1	1
07/23/2024 23:00	0.0	11.5	2,190.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.5	2,152.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	2,053.7	0.0	0.0	1	1	1
Maximum:	0.0	12.0	2,200.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	0.0	11.5	2,185.7	0.0	0.0	1	1	1
07/24/2024 01:00	0.0	11.5	2,178.3	0.0	0.0	1	1	1
07/24/2024 02:00	0.0	11.5	2,182.3	0.0	0.0	1	1	1
07/24/2024 03:00	0.0	11.5	2,200.5	0.0	0.0	1	1	1
07/24/2024 04:00	0.0	11.5	2,206.7	0.0	0.0	1	1	1
07/24/2024 05:00	0.0	11.5	2,211.0	0.0	0.0	1	1	1
07/24/2024 06:00	0.0	11.7	2,161.0	0.0	0.0	1	1	1
07/24/2024 07:00	0.0	11.8	2,147.9	0.0	0.0	1	1	1
07/24/2024 08:00	0.0	11.8	2,134.8	0.0	0.0	1	1	1
07/24/2024 09:00	0.0	11.8	2,118.7	0.0	0.0	1	1	1
07/24/2024 10:00	0.0	11.8	2,109.3	0.0	0.0	1	1	1
07/24/2024 11:00	0.0	11.7	2,122.8	0.0	0.0	1	1	1
07/24/2024 12:00	0.0	11.5	2,145.9	0.0	0.0	1	1	1
07/24/2024 13:00	0.0	11.6	2,113.8	0.0	0.0	1	1	1
07/24/2024 14:00	0.0	11.5	2,132.8	0.0	0.0	1	1	1
07/24/2024 15:00	0.0	11.4	2,137.7	0.0	0.0	1	1	1
07/24/2024 16:00	0.0	11.9	2,057.7	0.0	0.0	1	1	1
07/24/2024 17:00	0.0	12.0	2,034.9	0.0	0.0	1	1	1
07/24/2024 18:00	0.0	12.0	2,044.8	0.0	0.0	1	1	1
07/24/2024 19:00	0.0	12.0	2,068.7	0.0	0.0	1	1	1
07/24/2024 20:00	0.0	12.0	2,074.0	0.0	0.0	1	1	1
07/24/2024 21:00	0.0	11.8	2,152.9	0.0	0.0	1	1	1
07/24/2024 22:00	0.0	11.6	2,197.1	0.0	0.0	1	1	1
07/24/2024 23:00	0.0	11.6	2,196.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.7	2,138.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	2,034.9	0.0	0.0	1	1	1
Maximum:	0.0	12.0	2,211.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	0.0	11.9	2,131.9	0.0	0.0	1	1	1
07/25/2024 01:00	0.0	12.0	2,120.0	0.0	0.0	1	1	1
07/25/2024 02:00	0.0	12.0	2,110.3	0.0	0.0	1	1	1
07/25/2024 03:00	0.0	11.7	2,192.7	0.0	0.0	1	1	1
07/25/2024 04:00	0.0	11.6	2,206.2	0.0	0.0	1	1	1
07/25/2024 05:00	0.0	11.6	2,207.2	0.0	0.0	1	1	1
07/25/2024 06:00	0.0	11.9	2,146.3	0.0	0.0	1	1	1
07/25/2024 07:00	0.0	11.8	2,150.7	0.0	0.0	1	1	1
07/25/2024 08:00	0.0	11.8	2,141.4	0.0	0.0	1	1	1
07/25/2024 09:00	0.0	11.9	2,129.4	0.0	0.0	1	1	1
07/25/2024 10:00	0.0	12.0	2,093.8	0.0	0.0	1	1	1
07/25/2024 11:00	0.0	11.7	2,161.7	0.0	0.0	1	1	1
07/25/2024 12:00	0.0	11.6	2,160.3	0.0	0.0	1	1	1
07/25/2024 13:00	0.0	11.6	2,156.9	0.0	0.0	1	1	1
07/25/2024 14:00	0.0	11.5	2,150.7	0.0	0.0	1	1	1
07/25/2024 15:00	0.0	11.5	2,151.6	0.0	0.0	1	1	1
07/25/2024 16:00	0.0	11.6	2,127.4	0.0	0.0	1	1	1
07/25/2024 17:00	0.0	11.5	2,143.4	0.0	0.0	1	1	1
07/25/2024 18:00	0.0	11.6	2,126.2	0.0	0.0	1	1	1
07/25/2024 19:00	0.0	11.8	2,091.7	0.0	0.0	1	1	1
07/25/2024 20:00	0.0	11.6	2,145.8	0.0	0.0	1	1	1
07/25/2024 21:00	0.0	11.5	2,181.3	0.0	0.0	1	1	1
07/25/2024 22:00	0.0	11.6	2,177.0	0.0	0.0	1	1	1
07/25/2024 23:00	0.0	11.5	2,199.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.7	2,150.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	2,091.7	0.0	0.0	1	1	1
Maximum:	0.0	12.0	2,207.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	0.0	11.6	2,189.8	0.0	0.0	1	1	1
07/26/2024 01:00	0.0	12.1	2,072.5	0.0	0.0	1	1	1
07/26/2024 02:00	0.0	12.6	1,990.6	0.0	0.0	1	1	1
07/26/2024 03:00	0.0	12.6	1,993.7	0.0	0.0	1	1	1
07/26/2024 04:00	0.0	12.0	2,146.0	0.0	0.0	1	1	1
07/26/2024 05:00	0.0	12.3	2,109.5	0.0	0.0	1	1	1
07/26/2024 06:00	0.0	12.6	1,994.2	0.0	0.0	1	1	1
07/26/2024 07:00	0.0	12.5	1,995.8	0.0	0.0	1	1	1
07/26/2024 08:00	0.0	12.5	2,001.1	0.0	0.0	1	1	1
07/26/2024 09:00	0.0	12.4	2,010.1	0.0	0.0	1	1	1
07/26/2024 10:00	0.0	12.3	2,020.0	0.0	0.0	1	1	1
07/26/2024 11:00	0.0	12.2	2,030.5	0.0	0.0	1	1	1
07/26/2024 12:00	0.0	12.1	2,043.0	0.0	0.0	1	1	1
07/26/2024 13:00	0.0	11.9	2,067.5	0.0	0.0	1	1	1
07/26/2024 14:00	0.0	11.9	2,079.5	0.0	0.0	1	1	1
07/26/2024 15:00	0.0	11.7	2,108.9	0.0	0.0	1	1	1
07/26/2024 16:00	0.0	11.5	2,125.4	0.0	0.0	1	1	1
07/26/2024 17:00	0.0	11.5	2,129.2	0.0	0.0	1	1	1
07/26/2024 18:00	0.0	11.7	2,085.8	0.0	0.0	1	1	1
07/26/2024 19:00	0.0	11.7	2,139.6	0.0	0.0	1	1	1
07/26/2024 20:00	0.0	11.6	2,177.7	0.0	0.0	1	1	1
07/26/2024 21:00	0.0	12.0	2,098.9	0.0	0.0	1	1	1
07/26/2024 22:00	0.0	12.0	2,095.8	0.0	0.0	1	1	1
07/26/2024 23:00	0.0	12.5	1,993.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,070.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,990.6	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,189.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	0.0	12.6	1,995.6	0.0	0.0	1	1	1
07/27/2024 01:00	0.0	12.6	1,992.3	0.0	0.0	1	1	1
07/27/2024 02:00	0.0	12.7	1,988.3	0.0	0.0	1	1	1
07/27/2024 03:00	0.0	12.7	1,987.3	0.0	0.0	1	1	1
07/27/2024 04:00	0.0	12.6	2,033.3	0.0	0.0	1	1	1
07/27/2024 05:00	0.0	12.5	2,064.3	0.0	0.0	1	1	1
07/27/2024 06:00	20.3	15.4	672.5	0.0	8.9	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 11:00	12.8	18.5	157.7	0.0	2.0	1	0	0
07/27/2024 12:00	40.2	15.1	928.9	0.0	85.0	1	0	0
07/27/2024 13:00	0.0	13.7	1,424.5	0.0	0.0	1	0	0
07/27/2024 14:00	0.0	13.7	1,393.9	0.0	0.0	1	0	0
07/27/2024 15:00	0.0	13.6	1,638.5	0.0	0.0	1	0	0
07/27/2024 16:00	0.0	13.8	1,431.4	0.0	0.0	1	0	0
07/27/2024 17:00	0.0	13.5	1,733.4	0.0	0.0	1	1	0
07/27/2024 18:00	0.0	13.6	1,588.3	0.0	0.0	1	1	1
07/27/2024 19:00	0.0	12.4	2,021.6	0.0	0.0	1	1	1
07/27/2024 20:00	0.0	12.4	2,004.3	0.0	0.0	1	1	1
07/27/2024 21:00	0.0	12.5	1,995.6	0.0	0.0	1	1	1
07/27/2024 22:00	0.0	12.5	1,990.9	0.0	0.0	1	1	1
07/27/2024 23:00	0.0	12.5	1,987.5	0.0	0.0	1	1	1
Average/Sum#:	3.7	13.4	1,651.5	0.0	95.9 #	20 #	13 #	12 #
Minimum:	0.0	12.4	157.7	0.0	0.0	0	0	0
Maximum:	40.2	18.5	2,064.3	0.0	85.0	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2024 00:00	0.0	12.6	1,985.5	0.0	0.0	1	1	1
07/28/2024 01:00	0.0	12.6	1,986.7	0.0	0.0	1	1	1
07/28/2024 02:00	0.0	12.6	1,983.9	0.0	0.0	1	1	1
07/28/2024 03:00	0.0	12.7	1,972.9	0.0	0.0	1	1	1
07/28/2024 04:00	0.0	12.7	1,950.4	0.0	0.0	1	1	1
07/28/2024 05:00	0.0	13.6	1,699.5	0.0	0.0	1	1	0
07/28/2024 06:00	0.0	13.7	1,313.9	0.0	0.0	1	1	0
07/28/2024 07:00	47.1	16.3	323.7	0.0	7.4	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	5.9	13.4	1,652.1	0.0	7.4 #	8 #	15 #	5 #
Minimum:	0.0	12.6	323.7	0.0	0.0	0	0	0
Maximum:	47.1	16.3	1,986.7	0.0	7.4	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 10:00	64.8	17.4	331.0	0.0	51.0	1	0	0
07/29/2024 11:00	25.4	16.8	435.4	0.0	35.6	1	0	0
07/29/2024 12:00	35.8	14.4	1,116.0	0.0	81.2	1	0	0
07/29/2024 13:00	0.0	13.7	1,390.7	0.0	0.0	1	0	0
07/29/2024 14:00	0.0	13.7	1,560.9	0.0	0.0	1	0	0
07/29/2024 15:00	0.0	13.6	1,597.6	0.0	0.0	1	0	0
07/29/2024 16:00	0.0	13.6	1,501.9	0.0	0.0	1	0	0
07/29/2024 17:00	0.0	13.6	1,665.0	0.0	0.0	1	1	0
07/29/2024 18:00	0.0	12.7	1,811.3	0.0	0.0	1	1	1
07/29/2024 19:00	0.0	11.5	2,173.2	0.0	0.0	1	1	1
07/29/2024 20:00	0.0	11.5	2,183.1	0.0	0.0	1	1	1
07/29/2024 21:00	0.0	11.9	2,095.3	0.0	0.0	1	1	1
07/29/2024 22:00	0.0	11.9	2,076.1	0.0	0.0	1	1	1
07/29/2024 23:00	27.4	15.4	626.6	0.0	10.3	1	0	0
Average/Sum#:	11.0	13.7	1,468.9	0.0	178.1 #	14 #	9 #	5 #
Minimum:	0.0	11.5	331.0	0.0	0.0	0	0	0
Maximum:	64.8	17.4	2,183.1	0.0	81.2	1	1	1
%SI	41.67	41.67	41.67	66.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 10:00	39.6	17.4	352.8	0.0	36.9	1	0	0
07/30/2024 11:00	21.6	16.9	419.8	0.0	29.9	1	0	0
07/30/2024 12:00	46.8	15.0	908.7	0.0	95.2	1	0	0
07/30/2024 13:00	0.0	13.7	1,399.0	0.0	0.0	1	0	0
07/30/2024 14:00	0.0	13.7	1,403.0	0.0	0.0	1	0	0
07/30/2024 15:00	0.0	13.6	1,641.1	0.0	0.0	1	0	0
07/30/2024 16:00	0.0	13.7	1,412.9	0.0	0.0	1	0	0
07/30/2024 17:00	0.0	13.7	1,447.9	0.0	0.0	1	1	0
07/30/2024 18:00	0.0	13.1	1,741.4	0.0	0.0	1	1	1
07/30/2024 19:00	0.0	11.5	2,166.9	0.0	0.0	1	1	1
07/30/2024 20:00	0.0	11.5	2,170.7	0.0	0.0	1	1	1
07/30/2024 21:00	0.0	11.5	2,165.8	0.0	0.0	1	1	1
07/30/2024 22:00	0.0	11.6	2,155.7	0.0	0.0	1	1	1
07/30/2024 23:00	0.0	11.7	2,154.1	0.0	0.0	1	1	1
Average/Sum#:	7.7	13.5	1,538.6	0.0	162.0 #	14 #	7 #	6 #
Minimum:	0.0	11.5	352.8	0.0	0.0	0	0	0
Maximum:	46.8	17.4	2,170.7	0.0	95.2	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	0.0	12.4	1,994.0	0.0	0.0	1	1	1
07/31/2024 01:00	0.0	12.5	1,987.1	0.0	0.0	1	1	1
07/31/2024 02:00	0.0	12.5	1,984.8	0.0	0.0	1	1	1
07/31/2024 03:00	0.0	12.4	2,012.8	0.0	0.0	1	1	1
07/31/2024 04:00	0.0	11.6	2,203.9	0.0	0.0	1	1	1
07/31/2024 05:00	0.0	12.0	2,121.4	0.0	0.0	1	1	1
07/31/2024 06:00	0.0	13.6	1,716.9	0.0	0.0	1	1	0
07/31/2024 07:00	0.0	13.6	1,589.9	0.0	0.0	1	1	0
07/31/2024 08:00	0.0	13.6	1,493.6	0.0	0.0	1	1	0
07/31/2024 09:00	0.0	13.6	1,498.7	0.0	0.0	1	1	0
07/31/2024 10:00	0.0	13.6	1,546.3	0.0	0.0	1	1	0
07/31/2024 11:00	0.0	13.7	1,578.7	0.0	0.0	1	1	0
07/31/2024 12:00	0.0	13.7	1,463.8	0.0	0.0	1	1	0
07/31/2024 13:00	0.0	13.6	1,627.5	0.0	0.0	1	1	0
07/31/2024 14:00	0.0	11.8	2,095.1	0.0	0.0	1	1	1
07/31/2024 15:00	0.0	11.5	2,141.7	0.0	0.0	1	1	1
07/31/2024 16:00	0.0	11.5	2,141.0	0.0	0.0	1	1	1
07/31/2024 17:00	0.0	11.5	2,139.4	0.0	0.0	1	1	1
07/31/2024 18:00	0.0	11.5	2,140.4	0.0	0.0	1	1	1
07/31/2024 19:00	0.0	11.5	2,141.2	0.0	0.0	1	1	1
07/31/2024 20:00	0.0	11.5	2,147.9	0.0	0.0	1	1	1
07/31/2024 21:00	0.0	11.5	2,150.3	0.0	0.0	1	1	1
07/31/2024 22:00	0.0	11.6	2,145.8	0.0	0.0	1	1	1
07/31/2024 23:00	0.0	11.6	2,146.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	1,925.4	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	11.5	1,463.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,203.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	0.0	11.7	2,147.3	0.0	0.0	1	1	1
08/01/2024 01:00	0.0	11.7	2,138.7	0.0	0.0	1	1	1
08/01/2024 02:00	0.0	11.8	2,132.8	0.0	0.0	1	1	1
08/01/2024 03:00	0.0	11.9	2,126.5	0.0	0.0	1	1	1
08/01/2024 04:00	0.0	12.0	2,127.2	0.0	0.0	1	1	1
08/01/2024 05:00	0.0	11.8	2,150.0	0.0	0.0	1	1	1
08/01/2024 06:00	0.0	11.9	2,113.6	0.0	0.0	1	1	1
08/01/2024 07:00	0.0	13.5	1,706.8	0.0	0.0	1	1	0
08/01/2024 08:00	0.0	13.5	1,730.0	0.0	0.0	1	1	0
08/01/2024 09:00	0.0	13.5	1,745.2	0.0	0.0	1	1	0
08/01/2024 10:00	0.0	13.5	1,734.9	0.0	0.0	1	1	0
08/01/2024 11:00	0.0	13.6	1,714.9	0.0	0.0	1	1	0
08/01/2024 12:00	0.0	13.5	1,714.1	0.0	0.0	1	1	1
08/01/2024 13:00	0.0	11.9	2,076.3	0.0	0.0	1	1	1
08/01/2024 14:00	0.0	11.7	2,093.1	0.0	0.0	1	1	1
08/01/2024 15:00	0.0	11.6	2,099.8	0.0	0.0	1	1	1
08/01/2024 16:00	0.0	11.5	2,152.7	0.0	0.0	1	1	1
08/01/2024 17:00	0.0	11.5	2,151.7	0.0	0.0	1	1	1
08/01/2024 18:00	0.0	11.5	2,155.4	0.0	0.0	1	1	1
08/01/2024 19:00	0.0	11.6	2,160.3	0.0	0.0	1	1	1
08/01/2024 20:00	0.0	11.6	2,168.8	0.0	0.0	1	1	1
08/01/2024 21:00	0.0	11.6	2,173.7	0.0	0.0	1	1	1
08/01/2024 22:00	0.0	11.6	2,174.0	0.0	0.0	1	1	1
08/01/2024 23:00	0.0	11.6	2,183.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,036.3	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.5	1,706.8	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,183.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2024 00:00	0.0	11.6	2,193.0	0.0	0.0	1	1	1
08/02/2024 01:00	0.0	11.6	2,183.2	0.0	0.0	1	1	1
08/02/2024 02:00	0.0	11.6	2,180.6	0.0	0.0	1	1	1
08/02/2024 03:00	0.0	11.7	2,189.1	0.0	0.0	1	1	1
08/02/2024 04:00	0.0	11.7	2,193.3	0.0	0.0	1	1	1
08/02/2024 05:00	0.0	11.7	2,190.4	0.0	0.0	1	1	1
08/02/2024 06:00	0.0	11.7	2,184.7	0.0	0.0	1	1	1
08/02/2024 07:00	0.0	11.6	2,185.3	0.0	0.0	1	1	1
08/02/2024 08:00	0.0	11.6	2,174.2	0.0	0.0	1	1	1
08/02/2024 09:00	0.0	11.6	2,164.8	0.0	0.0	1	1	1
08/02/2024 10:00	0.0	11.6	2,158.1	0.0	0.0	1	1	1
08/02/2024 11:00	0.0	11.6	2,148.7	0.0	0.0	1	1	1
08/02/2024 12:00	0.0	11.6	2,136.4	0.0	0.0	1	1	1
08/02/2024 13:00	0.0	11.6	2,133.7	0.0	0.0	1	1	1
08/02/2024 14:00	0.0	11.6	2,131.7	0.0	0.0	1	1	1
08/02/2024 15:00	0.0	11.6	2,125.9	0.0	0.0	1	1	1
08/02/2024 16:00	0.0	11.6	2,134.8	0.0	0.0	1	1	1
08/02/2024 17:00	0.0	11.6	2,132.9	0.0	0.0	1	1	1
08/02/2024 18:00	0.0	11.6	2,136.8	0.0	0.0	1	1	1
08/02/2024 19:00	0.0	11.6	2,150.1	0.0	0.0	1	1	1
08/02/2024 20:00	0.0	11.6	2,151.6	0.0	0.0	1	1	1
08/02/2024 21:00	0.0	11.6	2,163.5	0.0	0.0	1	1	1
08/02/2024 22:00	0.0	11.6	2,165.7	0.0	0.0	1	1	1
08/02/2024 23:00	0.0	11.6	2,165.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.6	2,161.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,125.9	0.0	0.0	1	1	1
Maximum:	0.0	11.7	2,193.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2024 00:00	0.0	11.6	2,163.0	0.0	0.0	1	1	1
08/03/2024 01:00	0.0	11.6	2,160.9	0.0	0.0	1	1	1
08/03/2024 02:00	0.0	11.6	2,159.5	0.0	0.0	1	1	1
08/03/2024 03:00	0.0	11.9	2,113.5	0.0	0.0	1	1	1
08/03/2024 04:00	0.0	12.0	2,098.2	0.0	0.0	1	1	1
08/03/2024 05:00	0.0	12.2	2,093.5	0.0	0.0	1	1	1
08/03/2024 06:00	0.0	12.2	2,051.5	0.0	0.0	1	1	1
08/03/2024 07:00	0.0	12.1	2,065.1	0.0	0.0	1	1	1
08/03/2024 08:00	0.0	11.9	2,073.1	0.0	0.0	1	1	1
08/03/2024 09:00	0.0	11.9	2,084.1	0.0	0.0	1	1	1
08/03/2024 10:00	0.0	11.9	2,089.9	0.0	0.0	1	1	1
08/03/2024 11:00	0.0	11.9	2,097.4	0.0	0.0	1	1	1
08/03/2024 12:00	0.0	11.9	2,096.4	0.0	0.0	1	1	1
08/03/2024 13:00	0.0	11.8	2,103.2	0.0	0.0	1	1	1
08/03/2024 14:00	0.0	11.7	2,115.0	0.0	0.0	1	1	1
08/03/2024 15:00	0.0	11.7	2,115.1	0.0	0.0	1	1	1
08/03/2024 16:00	0.0	11.7	2,122.0	0.0	0.0	1	1	1
08/03/2024 17:00	0.0	11.7	2,130.0	0.0	0.0	1	1	1
08/03/2024 18:00	0.0	11.7	2,132.7	0.0	0.0	1	1	1
08/03/2024 19:00	0.0	11.7	2,135.8	0.0	0.0	1	1	1
08/03/2024 20:00	0.0	11.7	2,139.6	0.0	0.0	1	1	1
08/03/2024 21:00	0.0	11.7	2,137.4	0.0	0.0	1	1	1
08/03/2024 22:00	0.0	11.7	2,143.9	0.0	0.0	1	1	1
08/03/2024 23:00	0.0	11.7	2,150.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.8	2,115.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,051.5	0.0	0.0	1	1	1
Maximum:	0.0	12.2	2,163.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2024 00:00	0.0	11.9	2,091.0	0.0	0.0	1	1	1
08/04/2024 01:00	0.0	11.9	2,103.3	0.0	0.0	1	1	1
08/04/2024 02:00	0.0	12.1	2,035.8	0.0	0.0	1	1	1
08/04/2024 03:00	0.0	13.6	1,729.5	0.0	0.0	1	1	0
08/04/2024 04:00	0.0	13.5	1,754.6	0.0	0.0	1	1	0
08/04/2024 05:00	0.0	13.5	1,752.0	0.0	0.0	1	1	0
08/04/2024 06:00	0.0	13.6	1,719.0	0.0	0.0	1	1	0
08/04/2024 07:00	0.0	13.6	1,604.0	0.0	0.0	1	1	0
08/04/2024 08:00	0.0	13.6	1,611.0	0.0	0.0	1	1	0
08/04/2024 09:00	0.0	13.6	1,472.8	0.0	0.0	1	1	0
08/04/2024 10:00	0.0	13.7	1,617.8	0.0	0.0	1	1	0
08/04/2024 11:00	0.0	13.5	1,687.6	0.0	0.0	1	1	0
08/04/2024 12:00	0.0	13.7	1,543.6	0.0	0.0	1	1	1
08/04/2024 13:00	0.0	11.7	2,119.1	0.0	0.0	1	1	1
08/04/2024 14:00	0.0	11.6	2,118.7	0.0	0.0	1	1	1
08/04/2024 15:00	0.0	11.6	2,120.6	0.0	0.0	1	1	1
08/04/2024 16:00	0.0	11.7	2,081.1	0.0	0.0	1	1	1
08/04/2024 17:00	0.0	11.6	2,097.3	0.0	0.0	1	1	1
08/04/2024 18:00	0.0	11.6	2,107.6	0.0	0.0	1	1	1
08/04/2024 19:00	0.0	11.6	2,119.4	0.0	0.0	1	1	1
08/04/2024 20:00	0.0	11.6	2,132.6	0.0	0.0	1	1	1
08/04/2024 21:00	0.0	11.6	2,141.2	0.0	0.0	1	1	1
08/04/2024 22:00	0.0	11.7	2,151.5	0.0	0.0	1	1	1
08/04/2024 23:00	0.0	11.7	2,161.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,919.7	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	11.6	1,472.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,161.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	0.0	11.7	2,167.2	0.0	0.0	1	1	1
08/05/2024 01:00	0.0	11.7	2,173.7	0.0	0.0	1	1	1
08/05/2024 02:00	0.0	11.7	2,178.0	0.0	0.0	1	1	1
08/05/2024 03:00	0.0	11.7	2,184.5	0.0	0.0	1	1	1
08/05/2024 04:00	0.0	11.7	2,184.6	0.0	0.0	1	1	1
08/05/2024 05:00	0.0	11.7	2,186.5	0.0	0.0	1	1	1
08/05/2024 06:00	0.0	11.9	2,145.6	0.0	0.0	1	1	1
08/05/2024 07:00	0.0	12.2	2,050.4	0.0	0.0	1	1	1
08/05/2024 08:00	0.0	12.3	2,029.3	0.0	0.0	1	1	1
08/05/2024 09:00	0.0	12.3	2,040.3	0.0	0.0	1	1	1
08/05/2024 10:00	0.0	12.1	2,060.4	0.0	0.0	1	1	1
08/05/2024 11:00	0.0	11.8	2,098.6	0.0	0.0	1	1	1
08/05/2024 12:00	0.0	11.6	2,127.1	0.0	0.0	1	1	1
08/05/2024 13:00	0.0	11.6	2,129.1	0.0	0.0	1	1	1
08/05/2024 14:00	0.0	11.6	2,126.5	0.0	0.0	1	1	1
08/05/2024 15:00	0.0	11.6	2,112.2	0.0	0.0	1	1	1
08/05/2024 16:00	0.0	11.6	2,110.2	0.0	0.0	1	1	1
08/05/2024 17:00	0.0	11.6	2,106.2	0.0	0.0	1	1	1
08/05/2024 18:00	0.0	11.6	2,113.4	0.0	0.0	1	1	1
08/05/2024 19:00	0.0	11.8	2,094.3	0.0	0.0	1	1	1
08/05/2024 20:00	0.0	11.6	2,140.5	0.0	0.0	1	1	1
08/05/2024 21:00	0.0	11.6	2,150.4	0.0	0.0	1	1	1
08/05/2024 22:00	0.0	11.6	2,158.5	0.0	0.0	1	1	1
08/05/2024 23:00	0.0	11.6	2,167.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.8	2,126.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,029.3	0.0	0.0	1	1	1
Maximum:	0.0	12.3	2,186.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2024 00:00	0.0	12.0	2,094.2	0.0	0.0	1	1	1
08/06/2024 01:00	0.0	12.3	2,041.0	0.0	0.0	1	1	1
08/06/2024 02:00	0.0	12.4	2,029.2	0.0	0.0	1	1	1
08/06/2024 03:00	0.0	12.4	2,029.3	0.0	0.0	1	1	1
08/06/2024 04:00	0.0	11.8	2,160.8	0.0	0.0	1	1	1
08/06/2024 05:00	0.0	11.7	2,191.4	0.0	0.0	1	1	1
08/06/2024 06:00	0.0	12.2	2,114.6	0.0	0.0	1	1	1
08/06/2024 07:00	0.0	12.4	2,030.3	0.0	0.0	1	1	1
08/06/2024 08:00	0.0	12.3	2,032.4	0.0	0.0	1	1	1
08/06/2024 09:00	0.0	12.2	2,045.4	0.0	0.0	1	1	1
08/06/2024 10:00	0.0	12.0	2,060.1	0.0	0.0	1	1	1
08/06/2024 11:00	0.0	12.0	2,072.3	0.0	0.0	1	1	1
08/06/2024 12:00	0.0	11.9	2,092.4	0.0	0.0	1	1	1
08/06/2024 13:00	0.0	11.8	2,099.2	0.0	0.0	1	1	1
08/06/2024 14:00	0.0	11.7	2,103.0	0.0	0.0	1	1	1
08/06/2024 15:00	0.0	11.7	2,108.9	0.0	0.0	1	1	1
08/06/2024 16:00	0.0	11.7	2,117.0	0.0	0.0	1	1	1
08/06/2024 17:00	0.0	11.6	2,121.7	0.0	0.0	1	1	1
08/06/2024 18:00	0.0	11.6	2,118.1	0.0	0.0	1	1	1
08/06/2024 19:00	0.0	11.6	2,122.9	0.0	0.0	1	1	1
08/06/2024 20:00	0.0	11.6	2,126.4	0.0	0.0	1	1	1
08/06/2024 21:00	0.0	11.7	2,132.3	0.0	0.0	1	1	1
08/06/2024 22:00	0.0	11.7	2,141.2	0.0	0.0	1	1	1
08/06/2024 23:00	0.0	11.7	2,138.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.9	2,096.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,029.2	0.0	0.0	1	1	1
Maximum:	0.0	12.4	2,191.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	0.0	11.9	2,106.2	0.0	0.0	1	1	1
08/07/2024 01:00	0.0	11.7	2,156.9	0.0	0.0	1	1	1
08/07/2024 02:00	0.0	12.0	2,099.7	0.0	0.0	1	1	1
08/07/2024 03:00	0.0	12.3	2,039.6	0.0	0.0	1	1	1
08/07/2024 04:00	0.0	12.2	2,053.4	0.0	0.0	1	1	1
08/07/2024 05:00	0.0	11.7	2,130.5	0.0	0.0	1	1	1
08/07/2024 06:00	0.0	11.8	2,141.3	0.0	0.0	1	1	1
08/07/2024 07:00	0.0	12.3	2,042.9	0.0	0.0	1	1	1
08/07/2024 08:00	0.0	12.3	2,046.7	0.0	0.0	1	1	1
08/07/2024 09:00	0.0	12.1	2,059.4	0.0	0.0	1	1	1
08/07/2024 10:00	0.0	12.0	2,076.0	0.0	0.0	1	1	1
08/07/2024 11:00	0.0	11.8	2,092.9	0.0	0.0	1	1	1
08/07/2024 12:00	0.0	11.7	2,103.9	0.0	0.0	1	1	1
08/07/2024 13:00	0.0	11.7	2,110.3	0.0	0.0	1	1	1
08/07/2024 14:00	0.0	11.7	2,113.5	0.0	0.0	1	1	1
08/07/2024 15:00	0.0	11.7	2,114.9	0.0	0.0	1	1	1
08/07/2024 16:00	0.0	11.6	2,109.4	0.0	0.0	1	1	1
08/07/2024 17:00	0.0	11.6	2,101.9	0.0	0.0	1	1	1
08/07/2024 18:00	0.0	11.6	2,109.3	0.0	0.0	1	1	1
08/07/2024 19:00	0.0	11.6	2,119.1	0.0	0.0	1	1	1
08/07/2024 20:00	0.0	11.6	2,128.7	0.0	0.0	1	1	1
08/07/2024 21:00	0.0	11.6	2,136.7	0.0	0.0	1	1	1
08/07/2024 22:00	0.0	12.0	2,060.6	0.0	0.0	1	1	1
08/07/2024 23:00	0.0	11.7	2,156.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.8	2,100.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	2,039.6	0.0	0.0	1	1	1
Maximum:	0.0	12.3	2,156.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	0.0	11.7	2,169.8	0.0	0.0	1	1	1
08/08/2024 01:00	0.0	11.9	2,108.4	0.0	0.0	1	1	1
08/08/2024 02:00	0.0	13.6	1,666.6	0.0	0.0	1	1	0
08/08/2024 03:00	0.0	13.6	1,702.4	0.0	0.0	1	1	0
08/08/2024 04:00	0.0	13.6	1,672.4	0.0	0.0	1	1	0
08/08/2024 05:00	0.0	13.6	1,740.9	0.0	0.0	1	1	0
08/08/2024 06:00	0.0	13.6	1,735.5	0.0	0.0	1	1	0
08/08/2024 07:00	0.0	13.6	1,674.4	0.0	0.0	1	1	0
08/08/2024 08:00	0.0	13.6	1,572.3	0.0	0.0	1	1	0
08/08/2024 09:00	0.0	13.6	1,566.6	0.0	0.0	1	1	0
08/08/2024 10:00	0.0	13.6	1,561.5	0.0	0.0	1	1	0
08/08/2024 11:00	0.0	13.7	1,340.3	0.0	0.0	1	1	0
08/08/2024 12:00	0.0	13.7	1,330.3	0.0	0.0	1	1	0
08/08/2024 13:00	0.0	13.8	1,334.9	0.0	0.0	1	1	0
08/08/2024 14:00	0.0	13.6	1,525.6	0.0	0.0	1	1	1
08/08/2024 15:00	0.0	11.7	2,100.7	0.0	0.0	1	1	1
08/08/2024 16:00	0.0	11.8	2,057.2	0.0	0.0	1	1	1
08/08/2024 17:00	0.0	11.9	2,039.6	0.0	0.0	1	1	1
08/08/2024 18:00	0.0	11.6	2,105.8	0.0	0.0	1	1	1
08/08/2024 19:00	0.0	11.6	2,114.9	0.0	0.0	1	1	1
08/08/2024 20:00	0.0	11.6	2,126.9	0.0	0.0	1	1	1
08/08/2024 21:00	0.0	11.6	2,135.7	0.0	0.0	1	1	1
08/08/2024 22:00	0.0	11.7	2,135.0	0.0	0.0	1	1	1
08/08/2024 23:00	0.0	11.8	2,112.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,817.9	0.0	0.0 #	24 #	24 #	12 #
Minimum:	0.0	11.6	1,330.3	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,169.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2024 00:00	0.0	13.5	1,609.1	0.0	0.0	1	1	1
08/09/2024 01:00	0.0	13.6	1,703.2	0.0	0.0	1	1	0
08/09/2024 02:00	0.0	13.6	1,733.0	0.0	0.0	1	1	0
08/09/2024 03:00	0.0	13.6	1,717.3	0.0	0.0	1	1	0
08/09/2024 04:00	0.0	13.6	1,752.4	0.0	0.0	1	1	0
08/09/2024 05:00	0.0	13.6	1,751.8	0.0	0.0	1	1	0
08/09/2024 06:00	0.0	13.6	1,714.9	0.0	0.0	1	1	0
08/09/2024 07:00	0.0	13.6	1,559.0	0.0	0.0	1	1	0
08/09/2024 08:00	0.0	13.7	1,463.2	0.0	0.0	1	1	0
08/09/2024 09:00	0.0	13.7	1,538.6	0.0	0.0	1	1	0
08/09/2024 10:00	0.0	13.7	1,571.2	0.0	0.0	1	1	0
08/09/2024 11:00	0.0	13.7	1,591.3	0.0	0.0	1	1	0
08/09/2024 12:00	0.0	13.6	1,649.6	0.0	0.0	1	1	0
08/09/2024 13:00	0.0	13.6	1,707.2	0.0	0.0	1	1	0
08/09/2024 14:00	0.0	13.5	1,605.3	0.0	0.0	1	1	1
08/09/2024 15:00	0.0	11.7	2,100.8	0.0	0.0	1	1	1
08/09/2024 16:00	0.0	11.8	2,069.7	0.0	0.0	1	1	1
08/09/2024 17:00	0.0	11.6	2,099.2	0.0	0.0	1	1	1
08/09/2024 18:00	0.0	11.7	2,107.6	0.0	0.0	1	1	1
08/09/2024 19:00	0.0	11.7	2,119.5	0.0	0.0	1	1	1
08/09/2024 20:00	0.0	11.7	2,103.0	0.0	0.0	1	1	1
08/09/2024 21:00	20.1	15.3	687.9	0.0	9.1	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.9	13.2	1,725.2	0.0	9.1 #	22 #	21 #	8 #
Minimum:	0.0	11.6	687.9	0.0	0.0	0	0	0
Maximum:	20.1	15.3	2,119.5	0.0	9.1	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	7 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 13:00	72.3	17.3	320.3	0.0	61.2	1	0	0
08/12/2024 14:00	18.7	16.8	408.3	0.0	24.6	1	0	0
08/12/2024 15:00	17.2	15.1	957.1	0.0	37.5	1	0	0
08/12/2024 16:00	0.0	13.5	1,687.6	0.0	0.0	1	0	0
08/12/2024 17:00	0.0	12.5	1,929.9	0.0	0.0	1	0	1
08/12/2024 18:00	0.0	13.3	1,768.9	0.0	0.0	1	0	1
08/12/2024 19:00	0.0	13.5	1,695.8	0.0	0.0	1	0	0
08/12/2024 20:00	0.0	13.6	1,497.7	0.0	0.0	1	0	0
08/12/2024 21:00	0.0	13.6	1,716.7	0.0	0.0	1	1	0
08/12/2024 22:00	0.0	13.6	1,689.2	0.0	0.0	1	1	0
08/12/2024 23:00	0.0	13.7	1,723.8	0.0	0.0	1	1	0
Average/Sum#:	9.8	14.2	1,399.6	0.0	123.3 #	11 #	3 #	2 #
Minimum:	0.0	12.5	320.3	0.0	0.0	0	0	0
Maximum:	72.3	17.3	1,929.9	0.0	61.2	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	0.0	13.6	1,683.4	0.0	0.0	1	1	0
08/13/2024 01:00	0.0	13.7	1,348.3	0.0	0.0	1	1	0
08/13/2024 02:00	17.8	15.4	639.0	0.0	6.8	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/13/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/13/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/13/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/13/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	5.9	14.2	1,223.6	0.0	6.8 #	3 #	7 #	0 #
Minimum:	0.0	13.6	639.0	0.0	0.0	0	0	0
Maximum:	17.8	15.4	1,683.4	0.0	6.8	1	1	0
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	14 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/15/2024 17:00	51.1	17.2	339.5	0.0	58.8	1	1	0
08/15/2024 18:00	12.4	14.3	1,226.7	0.0	30.4	1	1	0
08/15/2024 19:00	0.0	12.5	1,852.5	0.0	0.0	1	1	1
08/15/2024 20:00	0.0	11.7	2,105.6	0.0	0.0	1	1	1
08/15/2024 21:00	0.0	13.6	1,692.5	0.0	0.0	1	1	0
08/15/2024 22:00	0.0	13.6	1,672.0	0.0	0.0	1	1	0
08/15/2024 23:00	0.0	13.6	1,698.4	0.0	0.0	1	1	0
Average/Sum#:	9.1	13.8	1,512.5	0.0	89.2 #	7 #	9 #	2 #
Minimum:	0.0	11.7	339.5	0.0	0.0	0	0	0
Maximum:	51.1	17.2	2,105.6	0.0	58.8	1	1	1
%SI	70.83	70.83	70.83	87.50	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	0.0	13.6	1,741.5	0.0	0.0	1	1	0
08/16/2024 01:00	0.0	13.6	1,689.7	0.0	0.0	1	1	0
08/16/2024 02:00	9.9	14.7	1,042.8	0.0	9.9	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 08:00	17.5	17.5	336.0	0.0	10.9	1	0	0
08/16/2024 09:00	32.5	15.0	928.1	0.0	67.5	1	0	0
08/16/2024 10:00	0.0	13.6	1,578.6	0.0	0.0	1	0	0
08/16/2024 11:00	0.0	13.7	1,426.2	0.0	0.0	1	0	0
08/16/2024 12:00	0.0	13.6	1,662.1	0.0	0.0	1	0	0
08/16/2024 13:00	0.0	13.6	1,549.8	0.0	0.0	1	0	0
08/16/2024 14:00	0.0	13.8	1,343.9	0.0	0.0	1	1	0
08/16/2024 15:00	0.0	13.6	1,580.7	0.0	0.0	1	1	1
08/16/2024 16:00	0.0	11.9	2,064.7	0.0	0.0	1	1	1
08/16/2024 17:00	0.0	11.9	2,072.0	0.0	0.0	1	1	1
08/16/2024 18:00	0.0	11.8	2,090.7	0.0	0.0	1	1	1
08/16/2024 19:00	0.0	11.8	2,100.8	0.0	0.0	1	1	1
08/16/2024 20:00	0.0	11.8	2,113.4	0.0	0.0	1	1	1
08/16/2024 21:00	0.0	11.8	2,125.2	0.0	0.0	1	1	1
08/16/2024 22:00	0.0	11.8	2,133.0	0.0	0.0	1	1	1
08/16/2024 23:00	0.0	11.8	2,136.9	0.0	0.0	1	1	1
Average/Sum#:	3.2	13.2	1,669.3	0.0	88.3 #	19 #	12 #	9 #
Minimum:	0.0	11.8	336.0	0.0	0.0	0	0	0
Maximum:	32.5	17.5	2,136.9	0.0	67.5	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2024 00:00	0.0	11.8	2,150.7	0.0	0.0	1	1	1
08/17/2024 01:00	0.0	12.0	2,107.5	0.0	0.0	1	1	1
08/17/2024 02:00	0.0	12.2	2,062.0	0.0	0.0	1	1	1
08/17/2024 03:00	0.0	12.3	2,040.1	0.0	0.0	1	1	1
08/17/2024 04:00	0.0	12.2	2,058.1	0.0	0.0	1	1	1
08/17/2024 05:00	0.0	12.2	2,076.1	0.0	0.0	1	1	1
08/17/2024 06:00	8.5	13.9	1,261.3	0.0	10.5	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.2	12.4	1,965.1	0.0	10.5 #	7 #	14 #	7 #
Minimum:	0.0	11.8	1,261.3	0.0	0.0	0	0	0
Maximum:	8.5	13.9	2,150.7	0.0	10.5	1	1	1
%SI	70.83	70.83	70.83	75.00	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/18/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/18/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 09:00	56.5	17.3	346.8	0.0	53.9	1	0	0
08/18/2024 10:00	20.1	16.9	430.4	0.0	28.6	1	0	0
08/18/2024 11:00	32.6	14.6	1,066.4	0.0	72.9	1	0	0
08/18/2024 12:00	0.0	13.8	1,395.7	0.0	0.0	1	0	0
08/18/2024 13:00	0.0	13.7	1,586.6	0.0	0.0	1	0	0
08/18/2024 14:00	0.0	13.6	1,711.3	0.0	0.0	1	0	0
08/18/2024 15:00	0.0	13.7	1,470.9	0.0	0.0	1	0	0
08/18/2024 16:00	0.0	13.6	1,693.4	0.0	0.0	1	1	0
08/18/2024 17:00	0.0	13.5	1,672.3	0.0	0.0	1	1	1
08/18/2024 18:00	0.0	12.0	2,084.4	0.0	0.0	1	1	1
08/18/2024 19:00	0.0	11.6	2,195.0	0.0	0.0	1	1	1
08/18/2024 20:00	0.0	11.4	2,228.2	0.0	0.0	1	1	1
08/18/2024 21:00	0.0	11.4	2,245.1	0.0	0.0	1	1	1
08/18/2024 22:00	0.0	11.4	2,257.9	0.0	0.0	1	1	1
08/18/2024 23:00	0.0	11.5	2,175.2	0.0	0.0	1	1	1
Average/Sum#:	7.3	13.3	1,637.3	0.0	155.4 #	15 #	10 #	7 #
Minimum:	0.0	11.4	346.8	0.0	0.0	0	0	0
Maximum:	56.5	17.3	2,257.9	0.0	72.9	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	23.8	15.6	575.4	0.0	7.8	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/19/2024 12:00	23.0	17.3	365.9	0.0	24.1	1	1	0
08/19/2024 13:00	28.6	14.7	1,038.7	0.0	63.3	1	1	0
08/19/2024 14:00	0.0	13.7	1,653.2	0.0	0.0	1	1	0
08/19/2024 15:00	0.0	13.7	1,515.2	0.0	0.0	1	1	0
08/19/2024 16:00	0.0	12.1	2,123.4	0.0	0.0	1	1	1
08/19/2024 17:00	0.0	12.0	2,096.7	0.0	0.0	1	1	1
08/19/2024 18:00	0.0	11.4	2,231.2	0.0	0.0	1	1	1
08/19/2024 19:00	0.0	11.8	2,142.7	0.0	0.0	1	1	1
08/19/2024 20:00	0.0	12.0	2,094.4	0.0	0.0	1	1	1
08/19/2024 21:00	0.0	11.5	2,210.4	0.0	0.0	1	1	1
08/19/2024 22:00	0.0	11.5	2,232.0	0.0	0.0	1	1	1
08/19/2024 23:00	0.0	11.8	2,148.5	0.0	0.0	1	1	1
Average/Sum#:	5.8	13.0	1,725.2	0.0	95.2 #	13 #	15 #	8 #
Minimum:	0.0	11.4	365.9	0.0	0.0	0	0	0
Maximum:	28.6	17.3	2,232.0	0.0	63.3	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	0.0	12.6	1,949.8	0.0	0.0	1	1	1
08/20/2024 01:00	20.7	15.3	666.3	0.0	8.1	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 09:00	25.5	17.6	301.1	0.0	20.0	1	0	0
08/20/2024 10:00	39.2	15.0	937.1	0.0	82.2	1	0	0
08/20/2024 11:00	0.0	13.8	1,396.2	0.0	0.0	1	0	0
08/20/2024 12:00	0.0	13.7	1,540.4	0.0	0.0	1	0	0
08/20/2024 13:00	0.0	13.7	1,674.6	0.0	0.0	1	0	0
08/20/2024 14:00	0.0	13.7	1,459.3	0.0	0.0	1	0	0
08/20/2024 15:00	0.0	13.8	1,330.3	0.0	0.0	1	1	0
08/20/2024 16:00	0.0	13.7	1,557.9	0.0	0.0	1	1	1
08/20/2024 17:00	0.0	11.9	2,084.2	0.0	0.0	1	1	1
08/20/2024 18:00	0.0	11.7	2,135.7	0.0	0.0	1	1	1
08/20/2024 19:00	0.0	11.8	2,120.7	0.0	0.0	1	1	1
08/20/2024 20:00	0.0	11.9	2,104.4	0.0	0.0	1	1	1
08/20/2024 21:00	0.0	12.2	2,032.9	0.0	0.0	1	1	1
08/20/2024 22:00	0.0	11.5	2,199.5	0.0	0.0	1	1	1
08/20/2024 23:00	0.0	11.5	2,204.3	0.0	0.0	1	1	1
Average/Sum#:	5.0	13.3	1,629.1	0.0	110.3 #	17 #	10 #	9 #
Minimum:	0.0	11.5	301.1	0.0	0.0	0	0	0
Maximum:	39.2	17.6	2,204.3	0.0	82.2	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	0.0	11.5	2,218.4	0.0	0.0	1	1	1
08/21/2024 01:00	0.0	12.5	1,994.8	0.0	0.0	1	1	1
08/21/2024 02:00	0.0	13.6	1,703.9	0.0	0.0	1	1	1
08/21/2024 03:00	0.0	13.7	1,717.5	0.0	0.0	1	1	0
08/21/2024 04:00	0.0	13.7	1,726.0	0.0	0.0	1	1	0
08/21/2024 05:00	0.0	13.7	1,736.9	0.0	0.0	1	1	0
08/21/2024 06:00	0.0	13.7	1,730.5	0.0	0.0	1	1	0
08/21/2024 07:00	0.0	13.7	1,621.6	0.0	0.0	1	1	0
08/21/2024 08:00	0.0	13.7	1,615.8	0.0	0.0	1	1	0
08/21/2024 09:00	0.0	13.8	1,330.0	0.0	0.0	1	1	0
08/21/2024 10:00	0.0	13.7	1,539.9	0.0	0.0	1	1	0
08/21/2024 11:00	0.0	13.7	1,584.8	0.0	0.0	1	1	0
08/21/2024 12:00	0.0	13.7	1,661.8	0.0	0.0	1	1	0
08/21/2024 13:00	0.0	13.6	1,742.7	0.0	0.0	1	1	0
08/21/2024 14:00	0.0	13.5	1,752.2	0.0	0.0	1	1	0
08/21/2024 15:00	0.0	13.5	1,734.0	0.0	0.0	1	1	0
08/21/2024 16:00	0.0	13.6	1,617.7	0.0	0.0	1	1	0
08/21/2024 17:00	0.0	11.9	2,105.4	0.0	0.0	1	1	1
08/21/2024 18:00	0.0	11.1	2,274.8	0.0	0.0	1	1	1
08/21/2024 19:00	0.0	11.1	2,281.6	0.0	0.0	1	1	1
08/21/2024 20:00	0.0	11.4	2,241.3	0.0	0.0	1	1	1
08/21/2024 21:00	0.0	11.6	2,194.5	0.0	0.0	1	1	1
08/21/2024 22:00	0.0	11.6	2,191.6	0.0	0.0	1	1	1
08/21/2024 23:00	0.0	11.6	2,210.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,855.3	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	11.1	1,330.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,281.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	0.0	12.5	2,001.3	0.0	0.0	1	1	1
08/22/2024 01:00	0.0	12.7	1,969.9	0.0	0.0	1	1	1
08/22/2024 02:00	0.0	12.7	1,966.3	0.0	0.0	1	1	1
08/22/2024 03:00	0.0	12.7	1,963.8	0.0	0.0	1	1	1
08/22/2024 04:00	0.0	12.7	1,975.3	0.0	0.0	1	1	1
08/22/2024 05:00	0.0	11.9	2,123.5	0.0	0.0	1	1	1
08/22/2024 06:00	19.4	15.3	697.2	0.0	8.0	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 14:00	21.6	17.4	346.6	0.0	18.9	1	0	0
08/22/2024 15:00	21.3	15.2	896.2	0.0	44.2	1	0	0
08/22/2024 16:00	0.0	13.6	1,671.8	0.0	0.0	1	0	0
08/22/2024 17:00	0.0	12.8	1,889.6	0.0	0.0	1	0	1
08/22/2024 18:00	0.0	12.5	2,013.7	0.0	0.0	1	0	1
08/22/2024 19:00	0.0	12.6	1,992.2	0.0	0.0	1	0	1
08/22/2024 20:00	0.0	12.6	1,985.3	0.0	0.0	1	0	1
08/22/2024 21:00	0.0	12.7	1,976.9	0.0	0.0	1	0	1
08/22/2024 22:00	0.0	12.7	1,969.7	0.0	0.0	1	0	1
08/22/2024 23:00	0.0	12.8	1,962.6	0.0	0.0	1	0	1
Average/Sum#:	3.7	13.3	1,729.5	0.0	71.1 #	17 #	6 #	13 #
Minimum:	0.0	11.9	346.6	0.0	0.0	0	0	0
Maximum:	21.6	17.4	2,123.5	0.0	44.2	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	0.0	12.8	1,956.0	0.0	0.0	1	0	1
08/23/2024 01:00	0.0	12.8	1,958.0	0.0	0.0	1	0	1
08/23/2024 02:00	0.0	12.8	1,958.0	0.0	0.0	1	0	1
08/23/2024 03:00	0.0	12.8	1,960.1	0.0	0.0	1	0	1
08/23/2024 04:00	0.0	12.8	1,963.3	0.0	0.0	1	0	1
08/23/2024 05:00	0.0	12.3	2,041.5	0.0	0.0	1	0	1
08/23/2024 06:00	0.0	13.7	1,435.0	0.0	0.0	1	0	0
08/23/2024 07:00	32.5	16.1	397.5	0.0	6.0	1	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.1	13.3	1,708.7	0.0	6.0 #	8 #	0 #	6 #
Minimum:	0.0	12.3	397.5	0.0	0.0	0	0	0
Maximum:	32.5	16.1	2,041.5	0.0	6.0	1	0	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 13:00	55.2	17.4	337.7	0.0	49.2	1	0	0
08/25/2024 14:00	40.6	15.7	656.8	0.0	67.7	1	0	0
08/25/2024 15:00	24.6	14.4	1,204.9	0.0	60.2	1	0	0
08/25/2024 16:00	0.0	13.6	1,745.0	0.0	0.0	1	0	0
08/25/2024 17:00	0.0	12.4	2,042.9	0.0	0.0	1	0	1
08/25/2024 18:00	0.0	11.1	2,332.9	0.0	0.0	1	0	1
08/25/2024 19:00	0.0	11.1	2,337.0	0.0	0.0	1	0	1
08/25/2024 20:00	0.0	11.1	2,343.4	0.0	0.0	1	0	1
08/25/2024 21:00	0.0	12.2	2,089.9	0.0	0.0	1	0	1
08/25/2024 22:00	0.0	12.7	1,974.5	0.0	0.0	1	0	1
08/25/2024 23:00	0.0	13.6	1,762.0	0.0	0.0	1	0	0
Average/Sum#:	10.9	13.2	1,711.5	0.0	177.1 #	11 #	0 #	6 #
Minimum:	0.0	11.1	337.7	0.0	0.0	0	0	0
Maximum:	55.2	17.4	2,343.4	0.0	67.7	1	0	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	0.0	13.6	1,802.9	0.0	0.0	1	0	0
08/26/2024 01:00	0.0	13.6	1,762.3	0.0	0.0	1	0	0
08/26/2024 02:00	0.0	13.6	1,771.9	0.0	0.0	1	0	0
08/26/2024 03:00	0.0	13.5	1,831.5	0.0	0.0	1	0	0
08/26/2024 04:00	0.0	13.5	1,830.8	0.0	0.0	1	0	0
08/26/2024 05:00	0.0	13.5	1,828.9	0.0	0.0	1	0	0
08/26/2024 06:00	0.0	13.7	1,727.4	0.0	0.0	1	0	0
08/26/2024 07:00	0.0	13.5	1,804.8	0.0	0.0	1	0	0
08/26/2024 08:00	0.0	13.7	1,644.4	0.0	0.0	1	0	0
08/26/2024 09:00	0.0	13.7	1,736.3	0.0	0.0	1	1	0
08/26/2024 10:00	0.0	13.7	1,723.5	0.0	0.0	1	1	0
08/26/2024 11:00	0.0	13.7	1,719.3	0.0	0.0	1	1	0
08/26/2024 12:00	0.0	12.9	1,856.6	0.0	0.0	1	1	1
08/26/2024 13:00	0.0	12.4	2,032.8	0.0	0.0	1	1	1
08/26/2024 14:00	0.0	12.1	2,079.1	0.0	0.0	1	1	1
08/26/2024 15:00	0.0	12.3	2,038.7	0.0	0.0	1	1	1
08/26/2024 16:00	0.0	11.8	2,158.6	0.0	0.0	1	1	1
08/26/2024 17:00	0.0	11.2	2,263.4	0.0	0.0	1	1	1
08/26/2024 18:00	0.0	11.0	2,299.6	0.0	0.0	1	1	1
08/26/2024 19:00	0.0	11.1	2,305.2	0.0	0.0	1	1	1
08/26/2024 20:00	0.0	11.4	2,253.8	0.0	0.0	1	1	1
08/26/2024 21:00	0.0	11.4	2,258.9	0.0	0.0	1	1	1
08/26/2024 22:00	0.0	11.5	2,230.1	0.0	0.0	1	1	1
08/26/2024 23:00	0.0	12.6	2,002.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,956.8	0.0	0.0 #	24 #	15 #	12 #
Minimum:	0.0	11.0	1,644.4	0.0	0.0	1	0	0
Maximum:	0.0	13.7	2,305.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	0.0	12.7	1,988.2	0.0	0.0	1	1	1
08/27/2024 01:00	0.0	12.7	1,992.0	0.0	0.0	1	1	1
08/27/2024 02:00	0.0	12.7	1,995.7	0.0	0.0	1	1	1
08/27/2024 03:00	0.0	12.6	1,997.9	0.0	0.0	1	1	1
08/27/2024 04:00	0.0	12.7	1,979.2	0.0	0.0	1	1	1
08/27/2024 05:00	0.0	13.7	1,721.5	0.0	0.0	1	1	0
08/27/2024 06:00	0.0	13.7	1,703.9	0.0	0.0	1	1	0
08/27/2024 07:00	0.0	13.7	1,604.5	0.0	0.0	1	1	0
08/27/2024 08:00	0.0	13.8	1,317.8	0.0	0.0	1	1	0
08/27/2024 09:00	0.0	13.8	1,315.8	0.0	0.0	1	1	0
08/27/2024 10:00	0.0	13.8	1,318.6	0.0	0.0	1	1	0
08/27/2024 11:00	0.0	13.8	1,323.8	0.0	0.0	1	1	0
08/27/2024 12:00	0.0	13.7	1,621.1	0.0	0.0	1	1	0
08/27/2024 13:00	0.0	13.7	1,662.3	0.0	0.0	1	1	0
08/27/2024 14:00	0.0	13.6	1,724.1	0.0	0.0	1	1	0
08/27/2024 15:00	0.0	13.7	1,592.3	0.0	0.0	1	1	0
08/27/2024 16:00	0.0	12.3	1,950.4	0.0	0.0	1	1	1
08/27/2024 17:00	0.0	11.2	2,247.2	0.0	0.0	1	1	1
08/27/2024 18:00	0.0	11.5	2,221.4	0.0	0.0	1	1	1
08/27/2024 19:00	0.0	11.3	2,250.4	0.0	0.0	1	1	1
08/27/2024 20:00	0.0	11.2	2,280.7	0.0	0.0	1	1	1
08/27/2024 21:00	0.0	11.3	2,253.9	0.0	0.0	1	1	1
08/27/2024 22:00	0.0	12.0	2,116.9	0.0	0.0	1	1	1
08/27/2024 23:00	0.0	11.7	2,205.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,849.4	0.0	0.0 #	24 #	24 #	13 #
Minimum:	0.0	11.2	1,315.8	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,280.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2024 00:00	0.0	12.0	2,140.2	0.0	0.0	1	1	1
08/28/2024 01:00	0.0	12.5	2,007.6	0.0	0.0	1	1	1
08/28/2024 02:00	0.0	12.6	2,006.3	0.0	0.0	1	1	1
08/28/2024 03:00	0.0	12.2	2,087.0	0.0	0.0	1	1	1
08/28/2024 04:00	0.0	11.6	2,229.1	0.0	0.0	1	1	1
08/28/2024 05:00	0.0	11.6	2,225.9	0.0	0.0	1	1	1
08/28/2024 06:00	0.0	12.2	2,076.8	0.0	0.0	1	1	1
08/28/2024 07:00	0.0	12.5	2,004.9	0.0	0.0	1	1	1
08/28/2024 08:00	0.0	12.4	2,010.7	0.0	0.0	1	1	1
08/28/2024 09:00	0.0	12.3	2,018.0	0.0	0.0	1	1	1
08/28/2024 10:00	0.0	12.3	2,027.4	0.0	0.0	1	1	1
08/28/2024 11:00	0.0	12.2	2,036.3	0.0	0.0	1	1	1
08/28/2024 12:00	0.0	12.1	2,050.6	0.0	0.0	1	1	1
08/28/2024 13:00	0.0	11.8	2,109.7	0.0	0.0	1	1	1
08/28/2024 14:00	0.0	11.9	2,086.4	0.0	0.0	1	1	1
08/28/2024 15:00	0.0	12.0	2,065.6	0.0	0.0	1	1	1
08/28/2024 16:00	0.0	11.9	2,093.6	0.0	0.0	1	1	1
08/28/2024 17:00	0.0	12.0	2,068.3	0.0	0.0	1	1	1
08/28/2024 18:00	0.0	11.5	2,173.2	0.0	0.0	1	1	1
08/28/2024 19:00	0.0	11.1	2,274.0	0.0	0.0	1	1	1
08/28/2024 20:00	0.0	11.6	2,148.8	0.0	0.0	1	1	1
08/28/2024 21:00	0.0	12.3	2,024.7	0.0	0.0	1	1	1
08/28/2024 22:00	0.0	12.4	2,015.0	0.0	0.0	1	1	1
08/28/2024 23:00	0.0	12.6	1,999.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,082.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.1	1,999.8	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,274.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	0.0	12.5	2,001.6	0.0	0.0	1	1	1
08/29/2024 01:00	0.0	12.6	1,998.4	0.0	0.0	1	1	1
08/29/2024 02:00	0.0	12.6	1,993.5	0.0	0.0	1	1	1
08/29/2024 03:00	0.0	12.6	1,994.1	0.0	0.0	1	1	1
08/29/2024 04:00	0.0	12.5	2,035.7	0.0	0.0	1	1	1
08/29/2024 05:00	0.0	12.7	1,993.6	0.0	0.0	1	1	1
08/29/2024 06:00	0.0	13.7	1,744.1	0.0	0.0	1	1	0
08/29/2024 07:00	0.0	13.7	1,540.4	0.0	0.0	1	1	0
08/29/2024 08:00	0.0	13.8	1,323.8	0.0	0.0	1	1	0
08/29/2024 09:00	0.0	13.8	1,322.0	0.0	0.0	1	1	0
08/29/2024 10:00	0.0	13.8	1,322.6	0.0	0.0	1	1	0
08/29/2024 11:00	0.0	13.8	1,334.6	0.0	0.0	1	1	0
08/29/2024 12:00	0.0	13.7	1,591.4	0.0	0.0	1	1	0
08/29/2024 13:00	0.0	13.6	1,685.4	0.0	0.0	1	1	0
08/29/2024 14:00	0.0	13.6	1,729.8	0.0	0.0	1	1	0
08/29/2024 15:00	0.0	13.6	1,540.1	0.0	0.0	1	1	1
08/29/2024 16:00	0.0	12.0	2,086.2	0.0	0.0	1	1	1
08/29/2024 17:00	0.0	11.6	2,165.6	0.0	0.0	1	1	1
08/29/2024 18:00	0.0	12.0	2,082.7	0.0	0.0	1	1	1
08/29/2024 19:00	0.0	11.4	2,229.6	0.0	0.0	1	1	1
08/29/2024 20:00	0.0	11.8	2,129.1	0.0	0.0	1	1	1
08/29/2024 21:00	0.0	12.1	2,077.1	0.0	0.0	1	1	1
08/29/2024 22:00	0.0	12.5	2,006.5	0.0	0.0	1	1	1
08/29/2024 23:00	0.0	12.5	2,002.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,830.4	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	11.4	1,322.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,229.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2024 00:00	0.0	12.6	1,997.3	0.0	0.0	1	1	1
08/30/2024 01:00	0.0	12.6	1,993.5	0.0	0.0	1	1	1
08/30/2024 02:00	0.0	12.7	1,991.3	0.0	0.0	1	1	1
08/30/2024 03:00	0.0	12.7	1,989.5	0.0	0.0	1	1	1
08/30/2024 04:00	0.0	12.4	2,064.1	0.0	0.0	1	1	1
08/30/2024 05:00	0.0	12.0	2,116.4	0.0	0.0	1	1	1
08/30/2024 06:00	0.0	12.3	2,070.3	0.0	0.0	1	1	1
08/30/2024 07:00	0.0	13.6	1,400.5	0.0	0.0	1	1	1
08/30/2024 08:00	0.0	13.7	1,377.9	0.0	0.0	1	1	0
08/30/2024 09:00	0.0	13.7	1,327.3	0.0	0.0	1	1	0
08/30/2024 10:00	0.0	13.7	1,336.3	0.0	0.0	1	1	0
08/30/2024 11:00	0.0	13.8	1,374.8	0.0	0.0	1	1	0
08/30/2024 12:00	0.0	13.8	1,346.7	0.0	0.0	1	1	0
08/30/2024 13:00	0.0	13.7	1,677.6	0.0	0.0	1	1	0
08/30/2024 14:00	0.0	13.4	1,711.7	0.0	0.0	1	1	1
08/30/2024 15:00	0.0	11.9	2,084.0	0.0	0.0	1	1	1
08/30/2024 16:00	0.0	11.7	2,123.4	0.0	0.0	1	1	1
08/30/2024 17:00	0.0	11.2	2,228.6	0.0	0.0	1	1	1
08/30/2024 18:00	0.0	11.0	2,285.1	0.0	0.0	1	1	1
08/30/2024 19:00	0.0	11.1	2,276.3	0.0	0.0	1	1	1
08/30/2024 20:00	0.0	11.1	2,269.9	0.0	0.0	1	1	1
08/30/2024 21:00	0.0	11.4	2,209.0	0.0	0.0	1	1	1
08/30/2024 22:00	0.0	12.3	2,044.2	0.0	0.0	1	1	1
08/30/2024 23:00	0.0	11.4	2,234.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,897.1	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.0	1,327.3	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,285.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	0.0	11.5	2,227.3	0.0	0.0	1	1	1
08/31/2024 01:00	0.0	11.6	2,219.0	0.0	0.0	1	1	1
08/31/2024 02:00	0.0	11.6	2,219.5	0.0	0.0	1	1	1
08/31/2024 03:00	0.0	11.6	2,212.7	0.0	0.0	1	1	1
08/31/2024 04:00	0.0	11.7	2,211.4	0.0	0.0	1	1	1
08/31/2024 05:00	0.0	12.1	2,092.0	0.0	0.0	1	1	1
08/31/2024 06:00	23.6	15.6	583.4	0.0	7.9	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/31/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/31/2024 14:00	24.4	17.6	325.1	0.0	14.3	1	1	0
08/31/2024 15:00	20.7	14.9	1,047.9	0.0	47.7	1	1	0
08/31/2024 16:00	0.0	13.5	1,680.8	0.0	0.0	1	1	0
08/31/2024 17:00	0.0	12.8	1,829.6	0.0	0.0	1	1	1
08/31/2024 18:00	0.0	11.0	2,279.3	0.0	0.0	1	1	1
08/31/2024 19:00	0.0	11.0	2,291.1	0.0	0.0	1	1	1
08/31/2024 20:00	0.0	11.0	2,298.6	0.0	0.0	1	1	1
08/31/2024 21:00	0.0	11.0	2,303.8	0.0	0.0	1	1	1
08/31/2024 22:00	0.0	11.4	2,254.4	0.0	0.0	1	1	1
08/31/2024 23:00	0.0	11.2	2,292.0	0.0	0.0	1	1	1
Average/Sum#:	4.0	12.4	1,904.0	0.0	69.9 #	17 #	18 #	13 #
Minimum:	0.0	11.0	325.1	0.0	0.0	0	0	0
Maximum:	24.4	17.6	2,303.8	0.0	47.7	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2024 00:00	0.0	11.7	2,172.6	0.0	0.0	1	1	1
09/01/2024 01:00	0.0	11.8	2,163.1	0.0	0.0	1	1	1
09/01/2024 02:00	0.0	11.7	2,180.6	0.0	0.0	1	1	1
09/01/2024 03:00	0.0	12.2	2,084.2	0.0	0.0	1	1	1
09/01/2024 04:00	0.0	12.6	1,991.1	0.0	0.0	1	1	1
09/01/2024 05:00	0.0	12.7	1,944.5	0.0	0.0	1	1	1
09/01/2024 06:00	24.0	15.6	627.0	0.0	9.4	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 10:00	12.0	18.6	165.4	0.0	2.3	1	0	0
09/01/2024 11:00	33.3	15.6	767.1	0.0	63.7	1	0	0
09/01/2024 12:00	0.0	13.7	1,432.9	0.0	0.0	1	0	0
09/01/2024 13:00	0.0	13.7	1,384.8	0.0	0.0	1	0	0
09/01/2024 14:00	0.0	13.6	1,642.0	0.0	0.0	1	0	0
09/01/2024 15:00	0.0	13.7	1,574.0	0.0	0.0	1	0	0
09/01/2024 16:00	0.0	13.5	1,725.5	0.0	0.0	1	1	0
09/01/2024 17:00	0.0	13.4	1,726.7	0.0	0.0	1	1	1
09/01/2024 18:00	0.0	11.7	2,154.3	0.0	0.0	1	1	1
09/01/2024 19:00	0.0	11.3	2,230.2	0.0	0.0	1	1	1
09/01/2024 20:00	0.0	11.5	2,214.8	0.0	0.0	1	1	1
09/01/2024 21:00	0.0	11.3	2,254.1	0.0	0.0	1	1	1
09/01/2024 22:00	0.0	11.7	2,189.0	0.0	0.0	1	1	1
09/01/2024 23:00	0.0	11.7	2,179.7	0.0	0.0	1	1	1
Average/Sum#:	3.3	13.0	1,752.6	0.0	75.4 #	21 #	14 #	13 #
Minimum:	0.0	11.3	165.4	0.0	0.0	0	0	0
Maximum:	33.3	18.6	2,254.1	0.0	63.7	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	0.0	11.8	2,162.3	0.0	0.0	1	1	1
09/02/2024 01:00	0.0	12.1	2,090.9	0.0	0.0	1	1	1
09/02/2024 02:00	0.0	12.8	1,953.2	0.0	0.0	1	1	1
09/02/2024 03:00	0.0	12.8	1,953.4	0.0	0.0	1	1	1
09/02/2024 04:00	0.0	12.8	1,950.9	0.0	0.0	1	1	1
09/02/2024 05:00	0.0	12.8	1,953.5	0.0	0.0	1	1	1
09/02/2024 06:00	0.0	12.8	1,933.6	0.0	0.0	1	1	1
09/02/2024 07:00	22.0	15.4	642.2	0.0	8.5	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 10:00	32.9	17.2	447.6	0.0	19.5	1	0	0
09/02/2024 11:00	27.2	14.2	1,188.1	0.0	63.7	1	0	0
09/02/2024 12:00	0.0	13.8	1,374.2	0.0	0.0	1	0	0
09/02/2024 13:00	0.0	13.8	1,379.9	0.0	0.0	1	0	0
09/02/2024 14:00	0.0	13.5	1,713.1	0.0	0.0	1	0	0
09/02/2024 15:00	0.0	13.7	1,533.5	0.0	0.0	1	0	0
09/02/2024 16:00	0.0	13.6	1,691.7	0.0	0.0	1	1	0
09/02/2024 17:00	0.0	12.8	1,822.3	0.0	0.0	1	1	1
09/02/2024 18:00	0.0	11.1	2,284.0	0.0	0.0	1	1	1
09/02/2024 19:00	0.0	11.0	2,295.7	0.0	0.0	1	1	1
09/02/2024 20:00	0.0	11.5	2,196.8	0.0	0.0	1	1	1
09/02/2024 21:00	0.0	12.4	2,001.0	0.0	0.0	1	1	1
09/02/2024 22:00	0.0	12.4	2,027.3	0.0	0.0	1	1	1
09/02/2024 23:00	0.0	12.6	1,992.1	0.0	0.0	1	1	1
Average/Sum#:	3.7	13.0	1,754.0	0.0	91.7 #	22 #	15 #	14 #
Minimum:	0.0	11.0	447.6	0.0	0.0	0	0	0
Maximum:	32.9	17.2	2,295.7	0.0	63.7	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	0.0	12.6	1,977.4	0.0	0.0	1	1	1
09/03/2024 01:00	0.0	12.6	1,982.5	0.0	0.0	1	1	1
09/03/2024 02:00	0.0	12.7	1,979.1	0.0	0.0	1	1	1
09/03/2024 03:00	0.0	12.7	1,977.6	0.0	0.0	1	1	1
09/03/2024 04:00	0.0	12.6	1,995.8	0.0	0.0	1	1	1
09/03/2024 05:00	0.0	11.6	2,148.7	0.0	0.0	1	1	1
09/03/2024 06:00	0.0	12.2	2,092.4	0.0	0.0	1	1	1
09/03/2024 07:00	0.0	12.7	1,974.6	0.0	0.0	1	1	1
09/03/2024 08:00	0.0	12.6	1,985.5	0.0	0.0	1	1	1
09/03/2024 09:00	0.0	12.5	1,999.6	0.0	0.0	1	1	1
09/03/2024 10:00	0.0	12.4	2,019.0	0.0	0.0	1	1	1
09/03/2024 11:00	0.0	12.3	2,032.2	0.0	0.0	1	1	1
09/03/2024 12:00	0.0	11.8	2,129.7	0.0	0.0	1	1	1
09/03/2024 13:00	0.0	11.4	2,228.3	0.0	0.0	1	1	1
09/03/2024 14:00	0.0	11.3	2,255.6	0.0	0.0	1	1	1
09/03/2024 15:00	0.0	11.2	2,250.1	0.0	0.0	1	1	1
09/03/2024 16:00	0.0	11.3	2,243.1	0.0	0.0	1	1	1
09/03/2024 17:00	0.0	11.1	2,283.5	0.0	0.0	1	1	1
09/03/2024 18:00	0.0	11.1	2,293.5	0.0	0.0	1	1	1
09/03/2024 19:00	0.0	11.1	2,301.5	0.0	0.0	1	1	1
09/03/2024 20:00	0.0	11.1	2,308.6	0.0	0.0	1	1	1
09/03/2024 21:00	0.0	11.1	2,311.8	0.0	0.0	1	1	1
09/03/2024 22:00	0.0	11.1	2,311.6	0.0	0.0	1	1	1
09/03/2024 23:00	0.0	11.7	2,161.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.9	2,135.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.1	1,974.6	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,311.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	0.0	13.7	1,726.6	0.0	0.0	1	1	0
09/04/2024 01:00	0.0	13.7	1,737.4	0.0	0.0	1	1	0
09/04/2024 02:00	0.0	13.7	1,723.7	0.0	0.0	1	1	0
09/04/2024 03:00	0.0	13.7	1,740.4	0.0	0.0	1	1	0
09/04/2024 04:00	0.0	13.7	1,738.6	0.0	0.0	1	1	0
09/04/2024 05:00	0.0	13.7	1,714.3	0.0	0.0	1	1	0
09/04/2024 06:00	0.0	13.7	1,713.3	0.0	0.0	1	1	0
09/04/2024 07:00	0.0	13.7	1,744.3	0.0	0.0	1	1	0
09/04/2024 08:00	0.0	13.6	1,752.1	0.0	0.0	1	1	0
09/04/2024 09:00	0.0	13.6	1,750.7	0.0	0.0	1	1	0
09/04/2024 10:00	0.0	13.5	1,743.6	0.0	0.0	1	1	0
09/04/2024 11:00	0.0	13.5	1,752.2	0.0	0.0	1	1	0
09/04/2024 12:00	0.0	13.6	1,693.7	0.0	0.0	1	1	1
09/04/2024 13:00	0.0	11.5	2,177.8	0.0	0.0	1	1	1
09/04/2024 14:00	0.0	11.2	2,230.5	0.0	0.0	1	1	1
09/04/2024 15:00	0.0	11.5	2,154.3	0.0	0.0	1	1	1
09/04/2024 16:00	0.0	11.3	2,189.2	0.0	0.0	1	1	1
09/04/2024 17:00	0.0	11.4	2,191.0	0.0	0.0	1	1	1
09/04/2024 18:00	0.0	11.6	2,156.2	0.0	0.0	1	1	1
09/04/2024 19:00	0.0	11.0	2,268.0	0.0	0.0	1	1	1
09/04/2024 20:00	0.0	11.1	2,271.6	0.0	0.0	1	1	1
09/04/2024 21:00	0.0	11.2	2,251.1	0.0	0.0	1	1	1
09/04/2024 22:00	0.0	11.5	2,208.2	0.0	0.0	1	1	1
09/04/2024 23:00	0.0	11.4	2,239.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,952.9	0.0	0.0 #	24 #	24 #	12 #
Minimum:	0.0	11.0	1,693.7	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,271.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	0.0	11.5	2,221.5	0.0	0.0	1	1	1
09/05/2024 01:00	0.0	11.5	2,218.0	0.0	0.0	1	1	1
09/05/2024 02:00	0.0	11.6	2,205.5	0.0	0.0	1	1	1
09/05/2024 03:00	0.0	12.3	2,042.1	0.0	0.0	1	1	1
09/05/2024 04:00	0.0	11.5	2,233.5	0.0	0.0	1	1	1
09/05/2024 05:00	0.0	11.1	2,316.0	0.0	0.0	1	1	1
09/05/2024 06:00	0.0	12.2	2,128.3	0.0	0.0	1	1	1
09/05/2024 07:00	0.0	13.7	1,729.6	0.0	0.0	1	1	0
09/05/2024 08:00	0.0	13.7	1,669.1	0.0	0.0	1	1	0
09/05/2024 09:00	0.0	13.6	1,737.2	0.0	0.0	1	1	0
09/05/2024 10:00	0.0	13.6	1,715.6	0.0	0.0	1	1	0
09/05/2024 11:00	0.0	13.5	1,736.7	0.0	0.0	1	1	0
09/05/2024 12:00	0.0	13.5	1,738.3	0.0	0.0	1	1	1
09/05/2024 13:00	0.0	11.6	2,150.9	0.0	0.0	1	1	1
09/05/2024 14:00	0.0	11.3	2,196.7	0.0	0.0	1	1	1
09/05/2024 15:00	0.0	11.3	2,191.2	0.0	0.0	1	1	1
09/05/2024 16:00	0.0	11.7	2,101.6	0.0	0.0	1	1	1
09/05/2024 17:00	0.0	11.5	2,151.6	0.0	0.0	1	1	1
09/05/2024 18:00	0.0	11.4	2,189.8	0.0	0.0	1	1	1
09/05/2024 19:00	0.0	11.4	2,193.3	0.0	0.0	1	1	1
09/05/2024 20:00	0.0	11.4	2,197.0	0.0	0.0	1	1	1
09/05/2024 21:00	0.0	11.2	2,246.8	0.0	0.0	1	1	1
09/05/2024 22:00	0.0	11.1	2,289.0	0.0	0.0	1	1	1
09/05/2024 23:00	0.0	11.5	2,211.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.0	2,075.5	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.1	1,669.1	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,316.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2024 00:00	0.0	11.5	2,208.4	0.0	0.0	1	1	1
09/06/2024 01:00	0.0	11.7	2,166.0	0.0	0.0	1	1	1
09/06/2024 02:00	0.0	12.4	2,021.3	0.0	0.0	1	1	1
09/06/2024 03:00	0.0	11.6	2,200.9	0.0	0.0	1	1	1
09/06/2024 04:00	0.0	11.5	2,238.2	0.0	0.0	1	1	1
09/06/2024 05:00	0.0	11.3	2,291.4	0.0	0.0	1	1	1
09/06/2024 06:00	0.0	11.7	2,189.2	0.0	0.0	1	1	1
09/06/2024 07:00	0.0	11.8	2,157.3	0.0	0.0	1	1	1
09/06/2024 08:00	0.0	11.9	2,114.1	0.0	0.0	1	1	1
09/06/2024 09:00	0.0	12.4	2,002.4	0.0	0.0	1	1	1
09/06/2024 10:00	0.0	12.1	2,073.9	0.0	0.0	1	1	1
09/06/2024 11:00	0.0	11.6	2,152.3	0.0	0.0	1	1	1
09/06/2024 12:00	0.0	11.4	2,189.1	0.0	0.0	1	1	1
09/06/2024 13:00	0.0	11.4	2,180.4	0.0	0.0	1	1	1
09/06/2024 14:00	0.0	11.4	2,191.1	0.0	0.0	1	1	1
09/06/2024 15:00	0.0	11.3	2,192.5	0.0	0.0	1	1	1
09/06/2024 16:00	0.0	11.6	2,130.6	0.0	0.0	1	1	1
09/06/2024 17:00	0.0	11.4	2,178.2	0.0	0.0	1	1	1
09/06/2024 18:00	0.0	11.3	2,215.2	0.0	0.0	1	1	1
09/06/2024 19:00	0.0	11.3	2,220.8	0.0	0.0	1	1	1
09/06/2024 20:00	0.0	11.4	2,229.3	0.0	0.0	1	1	1
09/06/2024 21:00	0.0	11.3	2,253.0	0.0	0.0	1	1	1
09/06/2024 22:00	0.0	11.4	2,239.5	0.0	0.0	1	1	1
09/06/2024 23:00	0.0	11.1	2,305.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.6	2,180.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.1	2,002.4	0.0	0.0	1	1	1
Maximum:	0.0	12.4	2,305.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2024 00:00	0.0	11.1	2,307.9	0.0	0.0	1	1	1
09/07/2024 01:00	0.0	11.2	2,294.4	0.0	0.0	1	1	1
09/07/2024 02:00	0.0	11.6	2,209.6	0.0	0.0	1	1	1
09/07/2024 03:00	0.0	11.6	2,204.2	0.0	0.0	1	1	1
09/07/2024 04:00	0.0	11.5	2,234.7	0.0	0.0	1	1	1
09/07/2024 05:00	0.0	11.7	2,195.3	0.0	0.0	1	1	1
09/07/2024 06:00	0.0	12.0	2,112.3	0.0	0.0	1	1	1
09/07/2024 07:00	0.0	12.6	1,983.7	0.0	0.0	1	1	1
09/07/2024 08:00	0.0	12.6	1,984.4	0.0	0.0	1	1	1
09/07/2024 09:00	0.0	12.5	2,002.1	0.0	0.0	1	1	1
09/07/2024 10:00	0.0	12.0	2,105.2	0.0	0.0	1	1	1
09/07/2024 11:00	0.0	12.0	2,082.0	0.0	0.0	1	1	1
09/07/2024 12:00	0.0	11.5	2,184.7	0.0	0.0	1	1	1
09/07/2024 13:00	0.0	11.2	2,238.2	0.0	0.0	1	1	1
09/07/2024 14:00	0.0	11.1	2,259.9	0.0	0.0	1	1	1
09/07/2024 15:00	0.0	11.1	2,266.9	0.0	0.0	1	1	1
09/07/2024 16:00	0.0	11.5	2,172.6	0.0	0.0	1	1	1
09/07/2024 17:00	0.0	11.0	2,276.8	0.0	0.0	1	1	1
09/07/2024 18:00	0.0	11.0	2,293.1	0.0	0.0	1	1	1
09/07/2024 19:00	0.0	11.1	2,303.0	0.0	0.0	1	1	1
09/07/2024 20:00	0.0	11.1	2,309.0	0.0	0.0	1	1	1
09/07/2024 21:00	0.0	11.2	2,296.4	0.0	0.0	1	1	1
09/07/2024 22:00	0.0	11.7	2,202.6	0.0	0.0	1	1	1
09/07/2024 23:00	0.0	11.3	2,293.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.6	2,200.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.0	1,983.7	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,309.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	0.0	11.9	2,157.7	0.0	0.0	1	1	1
09/08/2024 01:00	0.0	12.5	2,009.7	0.0	0.0	1	1	1
09/08/2024 02:00	0.0	11.9	2,175.8	0.0	0.0	1	1	1
09/08/2024 03:00	0.0	11.8	2,188.8	0.0	0.0	1	1	1
09/08/2024 04:00	0.0	12.5	2,027.2	0.0	0.0	1	1	1
09/08/2024 05:00	0.0	13.6	1,744.4	0.0	0.0	1	1	1
09/08/2024 06:00	0.0	13.7	1,665.7	0.0	0.0	1	1	0
09/08/2024 07:00	0.0	13.7	1,652.8	0.0	0.0	1	1	0
09/08/2024 08:00	0.0	13.7	1,622.6	0.0	0.0	1	1	0
09/08/2024 09:00	0.0	13.7	1,548.1	0.0	0.0	1	1	0
09/08/2024 10:00	0.0	13.8	1,540.0	0.0	0.0	1	1	0
09/08/2024 11:00	0.0	13.8	1,555.6	0.0	0.0	1	1	0
09/08/2024 12:00	0.0	13.7	1,644.1	0.0	0.0	1	1	0
09/08/2024 13:00	0.0	13.6	1,677.8	0.0	0.0	1	1	0
09/08/2024 14:00	0.0	12.8	1,840.0	0.0	0.0	1	1	1
09/08/2024 15:00	0.0	11.3	2,232.9	0.0	0.0	1	1	1
09/08/2024 16:00	0.0	11.7	2,138.0	0.0	0.0	1	1	1
09/08/2024 17:00	0.0	11.2	2,241.9	0.0	0.0	1	1	1
09/08/2024 18:00	0.0	11.2	2,259.7	0.0	0.0	1	1	1
09/08/2024 19:00	0.0	11.1	2,290.4	0.0	0.0	1	1	1
09/08/2024 20:00	0.0	11.1	2,292.3	0.0	0.0	1	1	1
09/08/2024 21:00	0.0	11.2	2,278.4	0.0	0.0	1	1	1
09/08/2024 22:00	0.0	11.4	2,222.3	0.0	0.0	1	1	1
09/08/2024 23:00	0.0	11.6	2,207.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	1,967.3	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	11.1	1,540.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,292.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2024 00:00	0.0	11.7	2,204.1	0.0	0.0	1	1	1
09/09/2024 01:00	0.0	12.2	2,074.2	0.0	0.0	1	1	1
09/09/2024 02:00	0.0	11.8	2,180.9	0.0	0.0	1	1	1
09/09/2024 03:00	0.0	11.6	2,202.7	0.0	0.0	1	1	1
09/09/2024 04:00	0.0	11.6	2,209.2	0.0	0.0	1	1	1
09/09/2024 05:00	0.0	11.2	2,284.3	0.0	0.0	1	1	1
09/09/2024 06:00	0.0	12.2	2,099.7	0.0	0.0	1	1	1
09/09/2024 07:00	0.0	12.7	1,982.1	0.0	0.0	1	1	1
09/09/2024 08:00	0.0	12.6	1,987.9	0.0	0.0	1	1	1
09/09/2024 09:00	0.0	11.8	2,159.4	0.0	0.0	1	1	1
09/09/2024 10:00	0.0	11.6	2,139.1	0.0	0.0	1	1	1
09/09/2024 11:00	0.0	11.8	2,094.6	0.0	0.0	1	1	1
09/09/2024 12:00	0.0	11.8	2,087.8	0.0	0.0	1	1	1
09/09/2024 13:00	0.0	11.7	2,092.1	0.0	0.0	1	1	1
09/09/2024 14:00	0.0	12.0	2,031.7	0.0	0.0	1	1	1
09/09/2024 15:00	0.0	11.6	2,094.1	0.0	0.0	1	1	1
09/09/2024 16:00	0.0	11.1	2,192.6	0.0	0.0	1	1	1
09/09/2024 17:00	0.0	11.3	2,154.1	0.0	0.0	1	1	1
09/09/2024 18:00	0.0	11.2	2,195.1	0.0	0.0	1	1	1
09/09/2024 19:00	0.0	11.3	2,180.1	0.0	0.0	1	1	1
09/09/2024 20:00	0.0	11.8	2,114.9	0.0	0.0	1	1	1
09/09/2024 21:00	0.0	11.8	2,104.3	0.0	0.0	1	1	1
09/09/2024 22:00	0.0	12.4	1,988.0	0.0	0.0	1	1	1
09/09/2024 23:00	0.0	11.6	2,172.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.8	2,126.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.1	1,982.1	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,284.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	0.0	11.7	2,162.0	0.0	0.0	1	1	1
09/10/2024 01:00	0.0	12.3	2,029.7	0.0	0.0	1	1	1
09/10/2024 02:00	0.0	12.4	1,988.9	0.0	0.0	1	1	1
09/10/2024 03:00	0.0	12.3	2,023.3	0.0	0.0	1	1	1
09/10/2024 04:00	0.0	12.1	2,076.4	0.0	0.0	1	1	1
09/10/2024 05:00	0.0	11.3	2,204.5	0.0	0.0	1	1	1
09/10/2024 06:00	0.0	12.2	2,025.0	0.0	0.0	1	1	1
09/10/2024 07:00	0.0	13.7	1,553.1	0.0	0.0	1	1	0
09/10/2024 08:00	0.0	13.7	1,295.1	0.0	0.0	1	1	0
09/10/2024 09:00	0.0	13.8	1,297.4	0.0	0.0	1	1	0
09/10/2024 10:00	0.0	13.8	1,302.0	0.0	0.0	1	1	0
09/10/2024 11:00	0.0	13.8	1,299.3	0.0	0.0	1	1	0
09/10/2024 12:00	0.0	13.8	1,308.1	0.0	0.0	1	1	0
09/10/2024 13:00	0.0	13.7	1,393.8	0.0	0.0	1	1	0
09/10/2024 14:00	0.0	13.8	1,305.5	0.0	0.0	1	1	0
09/10/2024 15:00	0.0	13.8	1,322.2	0.0	0.0	1	1	0
09/10/2024 16:00	0.0	13.6	1,555.1	0.0	0.0	1	1	1
09/10/2024 17:00	0.0	12.2	1,991.1	0.0	0.0	1	1	1
09/10/2024 18:00	0.0	12.2	1,983.6	0.0	0.0	1	1	1
09/10/2024 19:00	0.0	12.4	1,967.0	0.0	0.0	1	1	1
09/10/2024 20:00	0.0	12.5	1,957.5	0.0	0.0	1	1	1
09/10/2024 21:00	0.0	12.6	1,947.8	0.0	0.0	1	1	1
09/10/2024 22:00	0.0	12.6	1,927.4	0.0	0.0	1	1	1
09/10/2024 23:00	19.2	15.4	642.6	0.0	7.4	1	0	0
Average/Sum#:	0.8	13.0	1,689.9	0.0	7.4 #	24 #	23 #	14 #
Minimum:	0.0	11.3	642.6	0.0	0.0	1	0	0
Maximum:	19.2	15.4	2,204.5	0.0	7.4	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 17:00	58.3	17.3	323.0	0.0	48.4	1	0	0
09/12/2024 18:00	15.4	16.9	400.6	0.0	20.4	1	0	0
09/12/2024 19:00	25.9	15.2	846.1	0.0	50.8	1	0	0
09/12/2024 20:00	0.0	13.8	1,587.1	0.0	0.0	1	0	0
09/12/2024 21:00	0.0	13.7	1,644.1	0.0	0.0	1	0	0
09/12/2024 22:00	0.0	13.6	1,687.5	0.0	0.0	1	0	0
09/12/2024 23:00	0.0	13.6	1,731.7	0.0	0.0	1	0	0
Average/Sum#:	14.2	14.9	1,174.3	0.0	119.6 #	7 #	0 #	0 #
Minimum:	0.0	13.6	323.0	0.0	0.0	0	0	0
Maximum:	58.3	17.3	1,731.7	0.0	50.8	1	0	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	0.0	13.6	1,723.4	0.0	0.0	1	0	0
09/13/2024 01:00	0.0	13.7	1,536.6	0.0	0.0	1	0	0
09/13/2024 02:00	0.0	13.7	1,534.9	0.0	0.0	1	0	0
09/13/2024 03:00	0.0	13.7	1,650.7	0.0	0.0	1	0	0
09/13/2024 04:00	0.0	13.7	1,725.8	0.0	0.0	1	0	0
09/13/2024 05:00	0.0	13.7	1,724.2	0.0	0.0	1	0	0
09/13/2024 06:00	0.0	13.6	1,589.8	0.0	0.0	1	0	0
09/13/2024 07:00	5.1	14.4	1,204.6	0.0	9.1	1	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 13:00	17.1	17.5	322.3	0.0	10.3	1	0	0
09/13/2024 14:00	18.8	15.4	858.0	0.0	38.7	1	0	0
09/13/2024 15:00	0.0	13.4	1,675.4	0.0	0.0	1	0	1
09/13/2024 16:00	0.0	11.4	2,149.0	0.0	0.0	1	0	1
09/13/2024 17:00	0.0	11.3	2,168.2	0.0	0.0	1	0	1
09/13/2024 18:00	0.0	13.3	1,726.8	0.0	0.0	1	0	1
09/13/2024 19:00	0.0	13.6	1,548.3	0.0	0.0	1	0	0
09/13/2024 20:00	0.0	13.6	1,672.5	0.0	0.0	1	1	0
09/13/2024 21:00	0.0	13.5	1,698.4	0.0	0.0	1	1	0
09/13/2024 22:00	0.0	13.6	1,690.6	0.0	0.0	1	1	0
09/13/2024 23:00	0.0	13.7	1,689.3	0.0	0.0	1	1	0
Average/Sum#:	2.2	13.7	1,573.1	0.0	58.1 #	19 #	4 #	4 #
Minimum:	0.0	11.3	322.3	0.0	0.0	0	0	0
Maximum:	18.8	17.5	2,168.2	0.0	38.7	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	0.0	13.7	1,689.0	0.0	0.0	1	1	0
09/14/2024 01:00	0.0	13.5	1,756.5	0.0	0.0	1	1	0
09/14/2024 02:00	5.1	14.0	1,417.7	0.0	12.8	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 16:00	39.1	16.6	464.7	0.0	50.2	1	0	0
09/14/2024 17:00	62.4	15.1	719.7	0.0	102.3	1	0	0
09/14/2024 18:00	26.4	14.2	1,229.4	0.0	64.0	1	0	0
09/14/2024 19:00	0.0	13.6	1,582.9	0.0	0.0	1	0	0
09/14/2024 20:00	0.0	13.7	1,536.3	0.0	0.0	1	0	0
09/14/2024 21:00	0.0	13.7	1,537.9	0.0	0.0	1	0	0
09/14/2024 22:00	0.0	13.6	1,571.5	0.0	0.0	1	0	0
09/14/2024 23:00	0.0	13.6	1,703.1	0.0	0.0	1	0	0
Average/Sum#:	12.1	14.1	1,382.6	0.0	229.3 #	11 #	2 #	0 #
Minimum:	0.0	13.5	464.7	0.0	0.0	0	0	0
Maximum:	62.4	16.6	1,756.5	0.0	102.3	1	1	0
%SI	54.17	54.17	54.17	79.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	0.0	13.7	1,689.9	0.0	0.0	1	0	0
09/15/2024 01:00	39.8	15.3	659.9	0.0	16.7	1	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 17:00	54.4	17.3	343.0	0.0	49.3	1	0	0
09/15/2024 18:00	87.7	15.6	672.5	0.0	147.0	1	0	0
09/15/2024 19:00	58.2	14.5	1,114.5	0.0	133.9	1	0	0
09/15/2024 20:00	0.0	13.7	1,540.3	0.0	0.0	1	0	0
09/15/2024 21:00	0.0	13.7	1,449.5	0.0	0.0	1	0	0
09/15/2024 22:00	0.0	13.7	1,471.5	0.0	0.0	1	0	0
09/15/2024 23:00	0.0	13.7	1,514.7	0.0	0.0	1	0	0
Average/Sum#:	26.7	14.6	1,161.8	0.0	346.9 #	9 #	0 #	0 #
Minimum:	0.0	13.7	343.0	0.0	0.0	0	0	0
Maximum:	87.7	17.3	1,689.9	0.0	147.0	1	0	0
%SI	62.50	62.50	62.50	87.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	0.0	13.7	1,655.4	0.0	0.0	1	0	0
09/16/2024 01:00	0.0	13.7	1,515.8	0.0	0.0	1	0	0
09/16/2024 02:00	0.0	13.7	1,481.7	0.0	0.0	1	0	0
09/16/2024 03:00	0.0	13.7	1,624.2	0.0	0.0	1	0	0
09/16/2024 04:00	0.0	13.6	1,724.1	0.0	0.0	1	0	0
09/16/2024 05:00	0.0	13.6	1,719.4	0.0	0.0	1	0	0
09/16/2024 06:00	0.0	13.7	1,677.1	0.0	0.0	1	0	0
09/16/2024 07:00	8.0	14.3	1,264.4	0.0	14.7	1	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.0	13.8	1,582.8	0.0	14.7 #	8 #	0 #	0 #
Minimum:	0.0	13.6	1,264.4	0.0	0.0	0	0	0
Maximum:	8.0	14.3	1,724.1	0.0	14.7	1	0	0
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 20:00	54.9	17.3	329.3	0.0	61.0	1	0	0
09/17/2024 21:00	21.8	16.9	398.0	0.0	28.6	1	0	0
09/17/2024 22:00	32.5	15.5	857.8	0.0	68.2	1	0	0
09/17/2024 23:00	0.0	13.6	1,661.2	0.0	0.0	1	0	0
Average/Sum#:	27.3	15.8	811.6	0.0	157.8 #	4 #	0 #	0 #
Minimum:	0.0	13.6	329.3	0.0	0.0	0	0	0
Maximum:	54.9	17.3	1,661.2	0.0	68.2	1	0	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	0.0	13.7	1,573.6	0.0	0.0	1	0	0
09/18/2024 01:00	0.0	13.5	1,717.9	0.0	0.0	1	0	0
09/18/2024 02:00	0.0	13.6	1,505.0	0.0	0.0	1	0	0
09/18/2024 03:00	0.0	13.7	1,489.6	0.0	0.0	1	1	0
09/18/2024 04:00	0.0	13.5	1,689.8	0.0	0.0	1	1	1
09/18/2024 05:00	0.0	11.9	2,054.3	0.0	0.0	1	1	1
09/18/2024 06:00	0.0	11.9	2,093.4	0.0	0.0	1	1	1
09/18/2024 07:00	0.0	12.6	1,956.2	0.0	0.0	1	1	1
09/18/2024 08:00	0.0	12.7	1,920.3	0.0	0.0	1	1	1
09/18/2024 09:00	0.0	12.7	1,932.4	0.0	0.0	1	1	1
09/18/2024 10:00	0.0	12.6	1,937.4	0.0	0.0	1	1	1
09/18/2024 11:00	0.0	12.6	1,943.4	0.0	0.0	1	1	1
09/18/2024 12:00	0.0	12.6	1,945.2	0.0	0.0	1	1	1
09/18/2024 13:00	0.0	12.5	1,955.5	0.0	0.0	1	1	1
09/18/2024 14:00	0.0	12.5	1,960.3	0.0	0.0	1	1	1
09/18/2024 15:00	0.0	12.5	1,949.4	0.0	0.0	1	1	1
09/18/2024 16:00	0.0	11.9	2,078.4	0.0	0.0	1	1	1
09/18/2024 17:00	0.0	11.3	2,191.0	0.0	0.0	1	1	1
09/18/2024 18:00	0.0	11.6	2,119.5	0.0	0.0	1	1	1
09/18/2024 19:00	0.0	11.6	2,136.9	0.0	0.0	1	1	1
09/18/2024 20:00	0.0	11.7	2,122.5	0.0	0.0	1	1	1
09/18/2024 21:00	0.0	11.7	2,123.6	0.0	0.0	1	1	1
09/18/2024 22:00	0.0	11.7	2,120.4	0.0	0.0	1	1	1
09/18/2024 23:00	0.0	11.7	2,122.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	1,943.3	0.0	0.0 #	24 #	21 #	20 #
Minimum:	0.0	11.3	1,489.6	0.0	0.0	1	0	0
Maximum:	0.0	13.7	2,191.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2024 00:00	0.0	11.7	2,123.7	0.0	0.0	1	1	1
09/19/2024 01:00	0.0	11.7	2,122.0	0.0	0.0	1	1	1
09/19/2024 02:00	0.0	11.7	2,124.9	0.0	0.0	1	1	1
09/19/2024 03:00	0.0	11.7	2,128.0	0.0	0.0	1	1	1
09/19/2024 04:00	0.0	11.7	2,126.6	0.0	0.0	1	1	1
09/19/2024 05:00	0.0	11.8	2,124.7	0.0	0.0	1	1	1
09/19/2024 06:00	0.0	12.0	2,027.8	0.0	0.0	1	1	1
09/19/2024 07:00	19.3	15.4	639.2	0.0	7.4	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.4	12.2	1,927.1	0.0	7.4 #	8 #	7 #	7 #
Minimum:	0.0	11.7	639.2	0.0	0.0	0	0	0
Maximum:	19.3	15.4	2,128.0	0.0	7.4	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/22/2024 14:00	43.5	17.3	321.5	0.0	40.0	1	1	0
09/22/2024 15:00	21.9	14.8	945.5	0.0	44.8	1	1	0
09/22/2024 16:00	0.0	13.7	1,497.0	0.0	0.0	1	1	0
09/22/2024 17:00	0.0	13.7	1,614.5	0.0	0.0	1	1	1
09/22/2024 18:00	0.0	12.4	1,951.4	0.0	0.0	1	1	1
09/22/2024 19:00	0.0	12.3	1,964.3	0.0	0.0	1	1	1
09/22/2024 20:00	0.0	12.4	1,944.1	0.0	0.0	1	1	1
09/22/2024 21:00	0.0	12.4	1,940.1	0.0	0.0	1	1	1
09/22/2024 22:00	0.0	12.7	1,921.9	0.0	0.0	1	1	1
09/22/2024 23:00	0.0	12.7	1,922.9	0.0	0.0	1	1	1
Average/Sum#:	6.5	13.4	1,602.3	0.0	84.8 #	10 #	19 #	7 #
Minimum:	0.0	12.3	321.5	0.0	0.0	0	0	0
Maximum:	43.5	17.3	1,964.3	0.0	44.8	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2024 00:00	0.0	12.7	1,919.4	0.0	0.0	1	1	1
09/23/2024 01:00	0.0	12.7	1,916.3	0.0	0.0	1	1	1
09/23/2024 02:00	0.0	12.7	1,916.7	0.0	0.0	1	1	1
09/23/2024 03:00	0.0	12.7	1,917.8	0.0	0.0	1	1	1
09/23/2024 04:00	0.0	12.6	1,920.8	0.0	0.0	1	1	1
09/23/2024 05:00	0.0	12.6	1,909.0	0.0	0.0	1	1	1
09/23/2024 06:00	0.0	13.7	1,630.4	0.0	0.0	1	1	0
09/23/2024 07:00	0.0	13.7	1,570.3	0.0	0.0	1	1	0
09/23/2024 08:00	0.0	13.7	1,647.3	0.0	0.0	1	1	0
09/23/2024 09:00	0.0	13.7	1,511.8	0.0	0.0	1	1	0
09/23/2024 10:00	0.0	13.7	1,521.2	0.0	0.0	1	1	0
09/23/2024 11:00	0.0	13.6	1,652.4	0.0	0.0	1	1	0
09/23/2024 12:00	0.0	13.5	1,695.3	0.0	0.0	1	1	0
09/23/2024 13:00	0.0	13.5	1,694.3	0.0	0.0	1	1	1
09/23/2024 14:00	0.0	11.6	2,114.5	0.0	0.0	1	1	1
09/23/2024 15:00	0.0	11.2	2,182.0	0.0	0.0	1	1	1
09/23/2024 16:00	0.0	11.1	2,202.7	0.0	0.0	1	1	1
09/23/2024 17:00	0.0	11.0	2,210.5	0.0	0.0	1	1	1
09/23/2024 18:00	0.0	11.0	2,211.2	0.0	0.0	1	1	1
09/23/2024 19:00	0.0	11.0	2,218.2	0.0	0.0	1	1	1
09/23/2024 20:00	0.0	11.0	2,221.6	0.0	0.0	1	1	1
09/23/2024 21:00	0.0	11.1	2,228.1	0.0	0.0	1	1	1
09/23/2024 22:00	0.0	11.2	2,208.1	0.0	0.0	1	1	1
09/23/2024 23:00	0.0	12.0	2,043.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	1,927.6	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	11.0	1,511.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,228.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	0.0	13.6	1,693.6	0.0	0.0	1	1	1
09/24/2024 01:00	0.0	13.7	1,677.3	0.0	0.0	1	1	0
09/24/2024 02:00	0.0	13.7	1,640.8	0.0	0.0	1	1	0
09/24/2024 03:00	0.0	13.7	1,676.6	0.0	0.0	1	1	0
09/24/2024 04:00	0.0	13.7	1,686.2	0.0	0.0	1	1	0
09/24/2024 05:00	0.0	13.7	1,675.9	0.0	0.0	1	1	0
09/24/2024 06:00	0.0	13.7	1,636.9	0.0	0.0	1	1	0
09/24/2024 07:00	0.0	13.7	1,583.5	0.0	0.0	1	1	0
09/24/2024 08:00	0.0	13.7	1,509.7	0.0	0.0	1	1	0
09/24/2024 09:00	0.0	13.7	1,531.0	0.0	0.0	1	1	0
09/24/2024 10:00	0.0	13.7	1,563.2	0.0	0.0	1	1	0
09/24/2024 11:00	0.0	13.6	1,654.1	0.0	0.0	1	1	0
09/24/2024 12:00	0.0	13.7	1,390.3	0.0	0.0	1	1	0
09/24/2024 13:00	0.0	12.4	1,847.2	0.0	0.0	1	1	1
09/24/2024 14:00	0.0	11.2	2,155.9	0.0	0.0	1	1	1
09/24/2024 15:00	0.0	11.3	2,131.1	0.0	0.0	1	1	1
09/24/2024 16:00	0.0	11.1	2,170.7	0.0	0.0	1	1	1
09/24/2024 17:00	0.0	11.0	2,198.7	0.0	0.0	1	1	1
09/24/2024 18:00	0.0	11.1	2,174.2	0.0	0.0	1	1	1
09/24/2024 19:00	0.0	11.6	2,088.4	0.0	0.0	1	1	1
09/24/2024 20:00	0.0	11.4	2,145.6	0.0	0.0	1	1	1
09/24/2024 21:00	0.0	11.7	2,067.3	0.0	0.0	1	1	1
09/24/2024 22:00	0.0	12.0	2,017.7	0.0	0.0	1	1	1
09/24/2024 23:00	0.0	11.5	2,143.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,835.8	0.0	0.0 #	24 #	24 #	12 #
Minimum:	0.0	11.0	1,390.3	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,198.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2024 00:00	0.0	11.6	2,132.8	0.0	0.0	1	1	1
09/25/2024 01:00	0.0	11.7	2,100.1	0.0	0.0	1	1	1
09/25/2024 02:00	0.0	12.0	2,038.9	0.0	0.0	1	1	1
09/25/2024 03:00	0.0	11.8	2,096.4	0.0	0.0	1	1	1
09/25/2024 04:00	0.0	11.7	2,109.2	0.0	0.0	1	1	1
09/25/2024 05:00	0.0	11.7	2,106.7	0.0	0.0	1	1	1
09/25/2024 06:00	0.0	12.1	2,020.6	0.0	0.0	1	1	1
09/25/2024 07:00	17.6	15.3	682.9	0.0	7.6	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 14:00	17.3	18.1	245.0	0.0	5.4	1	0	0
09/25/2024 15:00	23.1	15.5	790.2	0.0	44.6	1	0	0
09/25/2024 16:00	0.0	13.7	1,422.7	0.0	0.0	1	0	0
09/25/2024 17:00	0.0	13.6	1,630.4	0.0	0.0	1	0	0
09/25/2024 18:00	0.0	13.5	1,651.5	0.0	0.0	1	0	0
09/25/2024 19:00	0.0	13.6	1,578.2	0.0	0.0	1	0	0
09/25/2024 20:00	0.0	13.7	1,496.2	0.0	0.0	1	1	0
09/25/2024 21:00	0.0	13.7	1,618.3	0.0	0.0	1	1	0
09/25/2024 22:00	0.0	13.7	1,401.1	0.0	0.0	1	1	0
09/25/2024 23:00	0.0	13.7	1,664.5	0.0	0.0	1	1	0
Average/Sum#:	3.2	13.4	1,599.2	0.0	57.6 #	18 #	11 #	7 #
Minimum:	0.0	11.6	245.0	0.0	0.0	0	0	0
Maximum:	23.1	18.1	2,132.8	0.0	44.6	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	0.0	13.7	1,685.2	0.0	0.0	1	1	0
09/26/2024 01:00	0.0	13.7	1,656.0	0.0	0.0	1	1	0
09/26/2024 02:00	0.0	13.7	1,628.6	0.0	0.0	1	1	0
09/26/2024 03:00	0.0	13.7	1,664.7	0.0	0.0	1	1	0
09/26/2024 04:00	0.0	13.7	1,687.6	0.0	0.0	1	1	0
09/26/2024 05:00	0.0	13.7	1,686.8	0.0	0.0	1	1	0
09/26/2024 06:00	0.0	13.7	1,630.2	0.0	0.0	1	1	0
09/26/2024 07:00	0.0	13.7	1,385.4	0.0	0.0	1	1	0
09/26/2024 08:00	22.9	15.6	566.6	0.0	7.4	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 14:00	15.7	17.6	315.4	0.0	9.5	1	0	0
09/26/2024 15:00	19.0	15.2	907.7	0.0	40.0	1	0	0
09/26/2024 16:00	0.0	13.5	1,697.3	0.0	0.0	1	0	0
09/26/2024 17:00	0.0	13.0	1,762.1	0.0	0.0	1	0	1
09/26/2024 18:00	0.0	11.7	2,092.8	0.0	0.0	1	0	1
09/26/2024 19:00	0.0	11.8	2,072.6	0.0	0.0	1	0	1
09/26/2024 20:00	0.0	12.1	2,015.7	0.0	0.0	1	0	1
09/26/2024 21:00	0.0	11.1	2,228.0	0.0	0.0	1	0	1
09/26/2024 22:00	0.0	11.5	2,145.2	0.0	0.0	1	0	1
09/26/2024 23:00	0.0	12.3	1,991.8	0.0	0.0	1	0	1
Average/Sum#:	3.0	13.4	1,622.1	0.0	56.9 #	19 #	8 #	7 #
Minimum:	0.0	11.1	315.4	0.0	0.0	0	0	0
Maximum:	22.9	17.6	2,228.0	0.0	40.0	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	0.0	12.7	1,906.1	0.0	0.0	1	0	1
09/27/2024 01:00	21.3	15.3	672.3	0.0	9.1	1	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 09:00	31.5	17.5	318.4	0.0	22.2	1	0	0
09/27/2024 10:00	19.6	15.4	834.1	0.0	39.3	1	0	0
09/27/2024 11:00	0.0	13.8	1,353.5	0.0	0.0	1	0	0
09/27/2024 12:00	0.0	13.8	1,339.5	0.0	0.0	1	0	0
09/27/2024 13:00	0.0	13.6	1,601.2	0.0	0.0	1	0	0
09/27/2024 14:00	0.0	13.7	1,435.7	0.0	0.0	1	0	0
09/27/2024 15:00	0.0	13.8	1,443.7	0.0	0.0	1	1	0
09/27/2024 16:00	0.0	13.7	1,527.4	0.0	0.0	1	1	1
09/27/2024 17:00	0.0	11.5	2,114.6	0.0	0.0	1	1	1
09/27/2024 18:00	0.0	11.0	2,217.0	0.0	0.0	1	1	1
09/27/2024 19:00	0.0	11.0	2,217.5	0.0	0.0	1	1	1
09/27/2024 20:00	0.0	11.0	2,226.3	0.0	0.0	1	1	1
09/27/2024 21:00	0.0	11.2	2,213.4	0.0	0.0	1	1	1
09/27/2024 22:00	0.0	11.6	2,132.3	0.0	0.0	1	1	1
09/27/2024 23:00	0.0	11.6	2,132.5	0.0	0.0	1	1	1
Average/Sum#:	4.3	13.1	1,628.6	0.0	70.6 #	17 #	9 #	9 #
Minimum:	0.0	11.0	318.4	0.0	0.0	0	0	0
Maximum:	31.5	17.5	2,226.3	0.0	39.3	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	0.0	11.6	2,133.3	0.0	0.0	1	1	1
09/28/2024 01:00	0.0	11.6	2,132.3	0.0	0.0	1	1	1
09/28/2024 02:00	0.0	11.6	2,129.4	0.0	0.0	1	1	1
09/28/2024 03:00	0.0	11.6	2,127.1	0.0	0.0	1	1	1
09/28/2024 04:00	0.0	11.7	2,126.7	0.0	0.0	1	1	1
09/28/2024 05:00	0.0	11.7	2,126.5	0.0	0.0	1	1	1
09/28/2024 06:00	0.0	12.1	2,012.4	0.0	0.0	1	1	1
09/28/2024 07:00	20.6	15.4	629.3	0.0	7.8	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 15:00	17.2	16.2	654.0	0.0	31.6	1	0	0
09/28/2024 16:00	0.0	13.7	1,466.0	0.0	0.0	1	0	0
09/28/2024 17:00	0.0	13.7	1,491.6	0.0	0.0	1	0	0
09/28/2024 18:00	0.0	13.6	1,656.0	0.0	0.0	1	0	0
09/28/2024 19:00	0.0	13.5	1,689.8	0.0	0.0	1	0	0
09/28/2024 20:00	0.0	13.6	1,690.3	0.0	0.0	1	0	0
09/28/2024 21:00	0.0	13.6	1,689.9	0.0	0.0	1	0	0
09/28/2024 22:00	0.0	13.7	1,558.4	0.0	0.0	1	0	0
09/28/2024 23:00	0.0	13.6	1,693.7	0.0	0.0	1	0	0
Average/Sum#:	2.2	13.1	1,706.3	0.0	39.4 #	17 #	7 #	7 #
Minimum:	0.0	11.6	629.3	0.0	0.0	0	0	0
Maximum:	20.6	16.2	2,133.3	0.0	31.6	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	0.0	13.7	1,488.4	0.0	0.0	1	0	0
09/29/2024 01:00	0.0	13.7	1,494.5	0.0	0.0	1	0	0
09/29/2024 02:00	19.5	15.5	618.7	0.0	8.0	1	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 10:00	42.6	17.7	307.4	0.0	24.3	1	0	0
09/29/2024 11:00	26.9	15.4	832.1	0.0	53.7	1	0	0
09/29/2024 12:00	0.0	13.8	1,385.5	0.0	0.0	1	0	0
09/29/2024 13:00	0.0	13.8	1,351.1	0.0	0.0	1	0	0
09/29/2024 14:00	0.0	13.6	1,606.2	0.0	0.0	1	0	0
09/29/2024 15:00	0.0	13.8	1,362.9	0.0	0.0	1	0	0
09/29/2024 16:00	0.0	13.7	1,578.4	0.0	0.0	1	1	0
09/29/2024 17:00	0.0	13.4	1,715.9	0.0	0.0	1	1	1
09/29/2024 18:00	0.0	12.2	1,999.9	0.0	0.0	1	1	1
09/29/2024 19:00	0.0	11.4	2,173.1	0.0	0.0	1	1	1
09/29/2024 20:00	0.0	11.5	2,167.2	0.0	0.0	1	1	1
09/29/2024 21:00	0.0	11.9	2,091.1	0.0	0.0	1	1	1
09/29/2024 22:00	0.0	12.6	1,954.5	0.0	0.0	1	1	1
09/29/2024 23:00	0.0	11.7	2,143.8	0.0	0.0	1	1	1
Average/Sum#:	5.2	13.5	1,545.3	0.0	86.0 #	17 #	8 #	7 #
Minimum:	0.0	11.4	307.4	0.0	0.0	0	0	0
Maximum:	42.6	17.7	2,173.1	0.0	53.7	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	0.0	12.1	2,061.7	0.0	0.0	1	1	1
09/30/2024 01:00	0.0	12.6	1,943.4	0.0	0.0	1	1	1
09/30/2024 02:00	0.0	12.6	1,946.4	0.0	0.0	1	1	1
09/30/2024 03:00	0.0	12.5	1,996.6	0.0	0.0	1	1	1
09/30/2024 04:00	0.0	12.1	2,076.2	0.0	0.0	1	1	1
09/30/2024 05:00	0.0	11.8	2,141.6	0.0	0.0	1	1	1
09/30/2024 06:00	0.0	11.8	2,183.1	0.0	0.0	1	1	1
09/30/2024 07:00	0.0	12.9	1,875.0	0.0	0.0	1	1	1
09/30/2024 08:00	0.0	13.9	1,322.6	0.0	0.0	1	1	0
09/30/2024 09:00	0.0	13.9	1,317.5	0.0	0.0	1	1	0
09/30/2024 10:00	0.0	13.9	1,318.6	0.0	0.0	1	1	0
09/30/2024 11:00	0.0	13.9	1,434.4	0.0	0.0	1	1	0
09/30/2024 12:00	0.0	13.9	1,573.6	0.0	0.0	1	1	0
09/30/2024 13:00	0.0	13.7	1,683.3	0.0	0.0	1	1	1
09/30/2024 14:00	0.0	11.8	2,144.2	0.0	0.0	1	1	1
09/30/2024 15:00	0.0	11.8	2,144.9	0.0	0.0	1	1	1
09/30/2024 16:00	0.0	11.1	2,280.0	0.0	0.0	1	1	1
09/30/2024 17:00	0.0	11.1	2,293.4	0.0	0.0	1	1	1
09/30/2024 18:00	0.0	11.1	2,300.0	0.0	0.0	1	1	1
09/30/2024 19:00	0.0	11.1	2,302.3	0.0	0.0	1	1	1
09/30/2024 20:00	0.0	11.4	2,241.1	0.0	0.0	1	1	1
09/30/2024 21:00	0.0	11.2	2,304.6	0.0	0.0	1	1	1
09/30/2024 22:00	0.0	11.7	2,210.3	0.0	0.0	1	1	1
09/30/2024 23:00	0.0	12.1	2,126.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	1,967.6	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.1	1,317.5	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,304.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2024 00:00	20.3	15.3	740.2	0.0	9.9	1	0	0
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2024 13:00	20.1	17.6	354.5	0.0	17.7	1	0	0
07/01/2024 14:00	21.8	15.3	899.8	0.0	46.3	1	0	0
07/01/2024 15:00	0.5	14.0	1,351.1	0.0	1.3	1	1	0
07/01/2024 16:00	0.5	13.9	1,569.4	0.0	1.5	1	1	1
07/01/2024 17:00	0.8	12.0	2,130.6	0.4	2.5	1	1	1
07/01/2024 18:00	0.5	11.6	2,203.3	0.4	1.6	1	1	1
07/01/2024 19:00	0.5	11.9	2,164.1	0.4	1.6	1	1	1
07/01/2024 20:00	0.5	11.9	2,153.7	0.3	1.6	1	1	1
07/01/2024 21:00	0.6	12.4	2,061.9	0.3	1.9	1	1	1
07/01/2024 22:00	0.6	12.4	2,045.0	0.4	1.9	1	1	1
07/01/2024 23:00	9.2	15.5	701.1	0.0	4.7	1	0	0
Average/Sum#:	6.3	13.7	1,531.2	0.4	92.5 #	12 #	8 #	7 #
Minimum:	0.5	11.6	354.5	0.3	1.3	0	0	0
Maximum:	21.8	17.6	2,203.3	0.4	46.3	1	1	1
%SI	50.00	50.00	50.00	75.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2024 15:00	31.7	18.5	194.3	0.0	7.8	1	0	0
07/02/2024 16:00	28.4	15.9	664.0	0.0	49.8	1	0	0
07/02/2024 17:00	0.6	13.8	1,638.1	0.0	1.8	1	0	0
07/02/2024 18:00	0.8	12.9	1,852.0	0.0	2.4	1	1	1
07/02/2024 19:00	0.6	11.7	2,200.4	0.0	1.9	1	1	1
07/02/2024 20:00	0.6	11.9	2,170.0	0.5	1.9	1	1	1
07/02/2024 21:00	0.5	11.9	2,166.2	0.4	1.6	1	1	1
07/02/2024 22:00	0.6	12.2	2,103.8	0.4	1.9	1	1	1
07/02/2024 23:00	0.5	11.7	2,223.9	0.3	1.6	1	1	1
Average/Sum#:	7.1	13.4	1,690.3	0.4	70.7 #	9 #	6 #	6 #
Minimum:	0.5	11.7	194.3	0.3	1.6	0	0	0
Maximum:	31.7	18.5	2,223.9	0.5	49.8	1	1	1
%SI	62.50	62.50	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2024 00:00	0.5	11.9	2,199.5	0.3	1.6	1	1	1
07/03/2024 01:00	0.6	12.3	2,094.1	0.3	1.9	1	1	1
07/03/2024 02:00	0.7	12.5	2,066.0	0.4	2.3	1	1	1
07/03/2024 03:00	0.7	12.6	2,049.2	0.5	2.3	1	1	1
07/03/2024 04:00	0.7	12.5	2,055.5	0.5	2.3	1	1	1
07/03/2024 05:00	0.7	12.5	2,056.6	0.5	2.3	1	1	1
07/03/2024 06:00	0.7	12.5	2,062.4	0.5	2.3	1	1	1
07/03/2024 07:00	0.7	12.4	2,069.0	0.5	2.3	1	1	1
07/03/2024 08:00	0.7	12.4	2,075.1	0.5	2.3	1	1	1
07/03/2024 09:00	0.6	12.4	2,083.1	0.5	1.9	1	1	1
07/03/2024 10:00	0.6	12.3	2,087.4	0.4	1.9	1	1	1
07/03/2024 11:00	0.6	12.4	2,071.9	0.4	1.9	1	1	1
07/03/2024 12:00	0.6	12.3	2,081.2	0.4	1.9	1	1	1
07/03/2024 13:00	0.6	12.2	2,080.9	0.4	1.9	1	1	1
07/03/2024 14:00	0.6	12.2	2,076.6	0.4	1.9	1	1	1
07/03/2024 15:00	0.5	12.1	2,082.4	0.4	1.6	1	1	1
07/03/2024 16:00	0.6	12.4	2,031.0	0.4	1.9	1	1	1
07/03/2024 17:00	0.7	12.3	2,026.8	0.4	2.2	1	1	1
07/03/2024 18:00	0.7	12.3	2,038.8	0.5	2.2	1	1	1
07/03/2024 19:00	0.6	12.2	2,057.1	0.5	1.9	1	1	1
07/03/2024 20:00	0.7	12.3	2,054.7	0.5	2.2	1	1	1
07/03/2024 21:00	0.6	12.4	2,052.4	0.4	1.9	1	1	1
07/03/2024 22:00	0.6	12.4	2,050.4	0.4	1.9	1	1	1
07/03/2024 23:00	0.7	12.5	2,039.4	0.4	2.2	1	1	1
Average/Sum#:	0.6	12.3	2,068.4	0.4	49.0 #	24 #	24 #	24 #
Minimum:	0.5	11.9	2,026.8	0.3	1.6	1	1	1
Maximum:	0.7	12.6	2,199.5	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2024 00:00	0.8	12.7	2,004.0	0.5	2.6	1	1	1
07/04/2024 01:00	0.8	12.7	1,977.6	0.6	2.5	1	1	1
07/04/2024 02:00	15.0	15.5	666.5	0.0	6.6	1	0	0
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2024 13:00	20.4	17.7	329.8	0.0	11.7	1	0	0
07/04/2024 14:00	24.0	15.5	856.3	0.0	50.3	1	0	0
07/04/2024 15:00	0.5	13.9	1,531.4	0.0	1.4	1	1	0
07/04/2024 16:00	0.6	13.7	1,704.7	0.0	1.9	1	1	0
07/04/2024 17:00	0.7	12.9	1,820.6	0.5	2.1	1	1	1
07/04/2024 18:00	0.5	11.8	2,143.0	0.4	1.6	1	1	1
07/04/2024 19:00	0.5	12.0	2,116.6	0.4	1.6	1	1	1
07/04/2024 20:00	0.6	12.3	2,050.0	0.3	1.9	1	1	1
07/04/2024 21:00	0.6	12.3	2,041.8	0.4	1.9	1	1	1
07/04/2024 22:00	0.7	12.5	2,028.9	0.4	2.2	1	1	1
07/04/2024 23:00	0.7	12.5	1,996.8	0.5	2.2	1	1	1
Average/Sum#:	4.7	13.4	1,662.0	0.4	90.5 #	14 #	11 #	9 #
Minimum:	0.5	11.8	329.8	0.3	1.4	0	0	0
Maximum:	24.0	17.7	2,143.0	0.6	50.3	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2024 00:00	0.5	13.8	1,729.6	0.5	1.6	1	1	0
07/05/2024 01:00	0.6	13.8	1,722.9	0.5	1.9	1	1	0
07/05/2024 02:00	0.7	13.8	1,713.9	0.5	2.2	1	1	0
07/05/2024 03:00	0.6	13.8	1,743.3	0.5	1.9	1	1	0
07/05/2024 04:00	0.6	13.8	1,626.1	0.5	1.8	1	1	0
07/05/2024 05:00	0.6	13.8	1,659.3	0.5	1.9	1	1	0
07/05/2024 06:00	0.6	13.7	1,759.2	0.5	1.9	1	1	0
07/05/2024 07:00	0.6	13.7	1,755.4	0.5	1.9	1	1	0
07/05/2024 08:00	0.6	13.7	1,761.6	0.5	1.9	1	1	0
07/05/2024 09:00	0.6	13.6	1,758.5	0.5	1.9	1	1	0
07/05/2024 10:00	0.6	13.6	1,745.7	0.5	1.9	1	1	0
07/05/2024 11:00	0.6	13.6	1,737.0	0.5	1.9	1	1	0
07/05/2024 12:00	0.6	13.8	1,559.5	0.5	1.7	1	1	0
07/05/2024 13:00	0.9	12.7	1,867.1	0.5	2.7	1	1	1
07/05/2024 14:00	0.5	11.5	2,152.1	0.5	1.5	1	1	1
07/05/2024 15:00	0.5	11.8	2,104.0	0.4	1.5	1	1	1
07/05/2024 16:00	0.5	11.8	2,107.0	0.3	1.5	1	1	1
07/05/2024 17:00	0.5	11.8	2,108.5	0.3	1.5	1	1	1
07/05/2024 18:00	0.5	11.9	2,092.2	0.3	1.5	1	1	1
07/05/2024 19:00	0.5	11.9	2,101.2	0.3	1.5	1	1	1
07/05/2024 20:00	0.5	12.0	2,091.4	0.3	1.6	1	1	1
07/05/2024 21:00	0.4	11.6	2,212.3	0.3	1.3	1	1	1
07/05/2024 22:00	0.4	11.8	2,140.1	0.3	1.2	1	1	1
07/05/2024 23:00	0.6	12.4	2,046.0	0.3	1.9	1	1	1
Average/Sum#:	0.6	12.9	1,887.2	0.4	42.1 #	24 #	24 #	11 #
Minimum:	0.4	11.5	1,559.5	0.3	1.2	1	1	0
Maximum:	0.9	13.8	2,212.3	0.5	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2024 00:00	0.6	12.5	2,021.2	0.4	1.9	1	1	1
07/06/2024 01:00	0.7	12.6	2,007.2	0.4	2.2	1	1	1
07/06/2024 02:00	0.7	12.6	2,007.7	0.5	2.2	1	1	1
07/06/2024 03:00	0.7	12.6	2,012.3	0.5	2.2	1	1	1
07/06/2024 04:00	0.7	12.7	2,005.4	0.5	2.3	1	1	1
07/06/2024 05:00	0.7	12.5	1,988.5	0.5	2.2	1	1	1
07/06/2024 06:00	0.0	0.0	705.2	0.0	0.0	1	0	0
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2024 13:00	0.5	20.5	0.2	0.0	0.0	1	0	0
07/06/2024 14:00	21.3	15.5	853.7	0.0	44.5	1	0	0
07/06/2024 15:00	0.5	13.9	1,450.7	0.0	1.4	1	1	0
07/06/2024 16:00	0.6	13.8	1,561.5	0.0	1.7	1	1	1
07/06/2024 17:00	0.7	12.0	2,101.8	0.5	2.2	1	1	1
07/06/2024 18:00	0.5	11.8	2,120.2	0.4	1.5	1	1	1
07/06/2024 19:00	0.6	11.8	2,091.3	0.4	1.8	1	1	1
07/06/2024 20:00	0.6	11.9	2,094.0	0.4	1.8	1	1	1
07/06/2024 21:00	0.5	12.0	2,098.7	0.4	1.6	1	1	1
07/06/2024 22:00	0.5	11.9	2,129.4	0.3	1.6	1	1	1
07/06/2024 23:00	0.4	11.5	2,223.4	0.3	1.2	1	1	1
Average/Sum#:	1.8	13.1	1,748.5	0.4	72.3 #	18 #	15 #	14 #
Minimum:	0.4	11.5	0.2	0.3	0.0	0	0	0
Maximum:	21.3	20.5	2,223.4	0.5	44.5	1	1	1
%SI	29.17	29.17	25.00	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2024 00:00	0.5	12.2	2,078.0	0.3	1.6	1	1	1
07/07/2024 01:00	0.6	12.5	2,026.5	0.3	1.9	1	1	1
07/07/2024 02:00	0.7	12.4	2,004.4	0.4	2.2	1	1	1
07/07/2024 03:00	23.5	15.6	609.7	0.0	8.9	1	0	0
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2024 11:00	0.1	20.9	3.1	0.0	0.0	1	0	0
07/07/2024 12:00	30.5	16.0	720.2	0.0	59.2	1	0	0
07/07/2024 13:00	0.5	13.9	1,483.1	0.0	1.4	1	1	0
07/07/2024 14:00	0.4	13.9	1,427.5	0.0	1.1	1	1	0
07/07/2024 15:00	0.5	13.8	1,620.8	0.4	1.5	1	1	0
07/07/2024 16:00	0.5	13.8	1,560.6	0.4	1.5	1	1	0
07/07/2024 17:00	0.4	13.9	1,389.2	0.4	1.0	1	1	0
07/07/2024 18:00	0.5	13.0	1,716.7	0.4	1.4	1	1	1
07/07/2024 19:00	0.5	11.4	2,176.9	0.3	1.5	1	1	1
07/07/2024 20:00	0.4	11.5	2,156.9	0.3	1.2	1	1	1
07/07/2024 21:00	0.5	12.1	2,045.2	0.3	1.5	1	1	1
07/07/2024 22:00	0.6	12.3	2,022.3	0.3	1.9	1	1	1
07/07/2024 23:00	0.5	12.0	2,093.4	0.3	1.6	1	1	1
Average/Sum#:	3.6	13.6	1,596.1	0.3	89.4 #	17 #	14 #	9 #
Minimum:	0.1	11.4	3.1	0.3	0.0	0	0	0
Maximum:	30.5	20.9	2,176.9	0.4	59.2	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2024 00:00	0.5	13.7	1,725.6	0.4	1.6	1	1	0
07/08/2024 01:00	0.5	13.8	1,711.5	0.4	1.6	1	1	0
07/08/2024 02:00	0.5	13.8	1,716.2	0.4	1.6	1	1	0
07/08/2024 03:00	0.5	13.8	1,717.9	0.4	1.6	1	1	0
07/08/2024 04:00	0.5	13.7	1,742.2	0.4	1.6	1	1	0
07/08/2024 05:00	0.5	13.7	1,758.7	0.4	1.6	1	1	0
07/08/2024 06:00	0.5	13.7	1,741.1	0.4	1.6	1	1	0
07/08/2024 07:00	0.5	13.7	1,728.4	0.4	1.6	1	1	0
07/08/2024 08:00	0.5	13.7	1,712.9	0.4	1.6	1	1	0
07/08/2024 09:00	0.5	13.6	1,702.8	0.4	1.5	1	1	0
07/08/2024 10:00	0.5	13.6	1,716.6	0.4	1.6	1	1	0
07/08/2024 11:00	0.5	13.5	1,710.8	0.4	1.5	1	1	0
07/08/2024 12:00	0.5	13.5	1,695.7	0.4	1.5	1	1	0
07/08/2024 13:00	0.5	13.8	1,589.0	0.4	1.5	1	1	0
07/08/2024 14:00	0.5	13.7	1,634.5	0.4	1.5	1	1	0
07/08/2024 15:00	0.5	13.6	1,672.6	0.4	1.5	1	1	0
07/08/2024 16:00	0.5	13.6	1,587.9	0.4	1.4	1	1	1
07/08/2024 17:00	0.6	11.8	2,105.0	0.4	1.8	1	1	1
07/08/2024 18:00	0.4	11.4	2,175.1	0.3	1.2	1	1	1
07/08/2024 19:00	0.3	11.4	2,186.1	0.3	0.9	1	1	1
07/08/2024 20:00	0.4	11.5	2,188.5	0.2	1.2	1	1	1
07/08/2024 21:00	0.4	11.7	2,148.3	0.3	1.2	1	1	1
07/08/2024 22:00	0.4	11.9	2,127.7	0.3	1.2	1	1	1
07/08/2024 23:00	0.3	11.6	2,207.6	0.3	0.9	1	1	1
Average/Sum#:	0.5	13.1	1,833.4	0.4	34.8 #	24 #	24 #	8 #
Minimum:	0.3	11.4	1,587.9	0.2	0.9	1	1	0
Maximum:	0.6	13.8	2,207.6	0.4	1.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2024 00:00	0.3	11.6	2,210.6	0.2	0.9	1	1	1
07/09/2024 01:00	0.4	11.7	2,186.7	0.2	1.3	1	1	1
07/09/2024 02:00	0.4	11.8	2,168.0	0.3	1.3	1	1	1
07/09/2024 03:00	0.4	11.9	2,167.0	0.3	1.3	1	1	1
07/09/2024 04:00	0.4	11.6	2,239.5	0.3	1.3	1	1	1
07/09/2024 05:00	0.4	11.7	2,205.6	0.3	1.3	1	1	1
07/09/2024 06:00	0.7	12.5	2,013.5	0.4	2.2	1	1	1
07/09/2024 07:00	0.7	12.6	1,987.5	0.4	2.2	1	1	1
07/09/2024 08:00	0.0	0.0	2,106.1	0.0	0.0	1	1	1
07/09/2024 09:00	0.0	0.0	2,082.6	0.0	0.0	1	1	1
07/09/2024 10:00	0.0	0.0	2,091.7	0.0	0.0	1	1	1
07/09/2024 11:00	0.0	0.0	2,189.6	0.0	0.0	1	1	1
07/09/2024 12:00	0.4	11.6	2,181.5	0.0	1.2	1	1	1
07/09/2024 13:00	0.4	11.7	2,144.3	0.0	1.2	1	1	1
07/09/2024 14:00	0.4	11.8	2,124.3	0.3	1.2	1	1	1
07/09/2024 15:00	0.4	11.8	2,127.1	0.3	1.2	1	1	1
07/09/2024 16:00	0.4	11.6	2,142.4	0.3	1.2	1	1	1
07/09/2024 17:00	0.4	11.6	2,160.8	0.3	1.2	1	1	1
07/09/2024 18:00	0.4	11.9	2,098.6	0.3	1.2	1	1	1
07/09/2024 19:00	0.3	11.5	2,186.1	0.3	0.9	1	1	1
07/09/2024 20:00	0.4	11.5	2,179.0	0.3	1.2	1	1	1
07/09/2024 21:00	0.4	11.7	2,154.4	0.3	1.2	1	1	1
07/09/2024 22:00	0.5	11.9	2,122.5	0.3	1.6	1	1	1
07/09/2024 23:00	0.6	12.2	2,052.9	0.3	1.9	1	1	1
Average/Sum#:	0.4	11.8	2,138.4	0.3	27.0 #	24 #	24 #	24 #
Minimum:	0.3	11.5	1,987.5	0.2	0.9	1	1	1
Maximum:	0.7	12.6	2,239.5	0.4	2.2	1	1	1
%SI	16.67	16.67	0.00	25.00	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2024 00:00	0.6	12.4	2,039.6	0.4	1.9	1	1	1
07/10/2024 01:00	0.4	11.6	2,204.7	0.4	1.3	1	1	1
07/10/2024 02:00	0.4	11.6	2,208.0	0.3	1.3	1	1	1
07/10/2024 03:00	0.4	11.7	2,195.8	0.3	1.3	1	1	1
07/10/2024 04:00	0.5	11.8	2,180.3	0.3	1.6	1	1	1
07/10/2024 05:00	0.5	11.9	2,140.4	0.3	1.6	1	1	1
07/10/2024 06:00	0.6	12.4	2,021.0	0.3	1.9	1	1	1
07/10/2024 07:00	0.7	12.5	1,981.9	0.4	2.2	1	1	1
07/10/2024 08:00	0.8	12.5	1,985.9	0.5	2.5	1	1	1
07/10/2024 09:00	0.7	12.4	1,996.6	0.5	2.2	1	1	1
07/10/2024 10:00	0.6	12.3	2,011.3	0.5	1.9	1	1	1
07/10/2024 11:00	0.6	12.1	2,035.2	0.4	1.8	1	1	1
07/10/2024 12:00	0.5	12.0	2,053.1	0.4	1.5	1	1	1
07/10/2024 13:00	0.4	11.6	2,158.3	0.3	1.2	1	1	1
07/10/2024 14:00	0.4	11.5	2,167.2	0.3	1.2	1	1	1
07/10/2024 15:00	0.4	11.8	2,110.5	0.3	1.2	1	1	1
07/10/2024 16:00	0.4	11.9	2,074.7	0.3	1.2	1	1	1
07/10/2024 17:00	0.4	12.0	2,064.9	0.3	1.2	1	1	1
07/10/2024 18:00	0.4	11.6	2,126.3	0.3	1.2	1	1	1
07/10/2024 19:00	0.4	11.4	2,178.2	0.3	1.2	1	1	1
07/10/2024 20:00	0.4	11.4	2,187.0	0.2	1.2	1	1	1
07/10/2024 21:00	0.4	11.4	2,195.8	0.2	1.2	1	1	1
07/10/2024 22:00	0.4	11.4	2,201.0	0.2	1.2	1	1	1
07/10/2024 23:00	0.4	11.4	2,202.4	0.2	1.2	1	1	1
Average/Sum#:	0.5	11.9	2,113.3	0.3	36.2 #	24 #	24 #	24 #
Minimum:	0.4	11.4	1,981.9	0.2	1.2	1	1	1
Maximum:	0.8	12.5	2,208.0	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2024 00:00	0.5	11.9	2,103.2	0.2	1.5	1	1	1
07/11/2024 01:00	0.5	12.0	2,084.8	0.3	1.5	1	1	1
07/11/2024 02:00	0.5	12.1	2,063.6	0.3	1.5	1	1	1
07/11/2024 03:00	0.6	12.3	2,033.1	0.3	1.9	1	1	1
07/11/2024 04:00	0.4	11.5	2,203.6	0.3	1.2	1	1	1
07/11/2024 05:00	0.6	12.4	1,996.4	0.4	1.9	1	1	1
07/11/2024 06:00	0.5	13.7	1,721.8	0.4	1.6	1	1	0
07/11/2024 07:00	0.5	13.7	1,713.9	0.4	1.6	1	1	0
07/11/2024 08:00	0.5	13.7	1,549.2	0.4	1.4	1	1	0
07/11/2024 09:00	0.5	13.9	1,505.5	0.4	1.4	1	1	0
07/11/2024 10:00	0.5	13.8	1,632.7	0.4	1.5	1	1	0
07/11/2024 11:00	0.5	13.9	1,468.0	0.4	1.4	1	1	0
07/11/2024 12:00	0.5	13.8	1,588.0	0.4	1.5	1	1	0
07/11/2024 13:00	0.5	13.8	1,582.6	0.4	1.5	1	1	0
07/11/2024 14:00	0.5	13.8	1,557.3	0.4	1.4	1	1	0
07/11/2024 15:00	0.5	14.0	1,331.5	0.4	1.3	1	1	0
07/11/2024 16:00	0.4	14.0	1,333.4	0.4	1.0	1	1	0
07/11/2024 17:00	0.7	12.9	1,744.0	0.4	2.0	1	1	1
07/11/2024 18:00	0.6	11.7	2,104.3	0.4	1.8	1	1	1
07/11/2024 19:00	0.5	11.6	2,121.1	0.4	1.5	1	1	1
07/11/2024 20:00	0.5	12.0	2,047.6	0.3	1.5	1	1	1
07/11/2024 21:00	0.6	12.2	2,015.3	0.3	1.8	1	1	1
07/11/2024 22:00	0.4	11.6	2,166.6	0.3	1.2	1	1	1
07/11/2024 23:00	0.5	12.1	2,059.7	0.3	1.5	1	1	1
Average/Sum#:	0.5	12.9	1,822.0	0.4	36.4 #	24 #	24 #	13 #
Minimum:	0.4	11.5	1,331.5	0.2	1.0	1	1	0
Maximum:	0.7	14.0	2,203.6	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2024 00:00	0.6	12.2	2,056.0	0.3	1.9	1	1	1
07/12/2024 01:00	0.6	12.2	2,061.7	0.4	1.9	1	1	1
07/12/2024 02:00	0.6	12.3	2,034.1	0.4	1.9	1	1	1
07/12/2024 03:00	0.4	11.7	2,180.8	0.4	1.3	1	1	1
07/12/2024 04:00	0.5	12.2	2,088.4	0.3	1.6	1	1	1
07/12/2024 05:00	0.5	12.1	2,087.8	0.3	1.6	1	1	1
07/12/2024 06:00	0.5	13.7	1,733.6	0.3	1.6	1	1	0
07/12/2024 07:00	0.5	13.8	1,541.5	0.4	1.4	1	1	0
07/12/2024 08:00	0.5	13.9	1,475.4	0.4	1.4	1	1	0
07/12/2024 09:00	0.5	13.9	1,479.2	0.4	1.4	1	1	0
07/12/2024 10:00	0.5	13.9	1,503.7	0.4	1.4	1	1	0
07/12/2024 11:00	0.5	13.9	1,430.7	0.4	1.3	1	1	0
07/12/2024 12:00	0.5	13.9	1,470.7	0.4	1.4	1	1	0
07/12/2024 13:00	0.5	13.9	1,339.2	0.4	1.3	1	1	0
07/12/2024 14:00	0.6	13.9	1,352.3	0.4	1.5	1	1	0
07/12/2024 15:00	0.5	13.9	1,355.0	0.4	1.3	1	1	0
07/12/2024 16:00	0.5	14.0	1,341.5	0.4	1.3	1	1	0
07/12/2024 17:00	0.5	13.9	1,341.6	0.4	1.3	1	1	0
07/12/2024 18:00	0.5	13.9	1,331.6	0.4	1.3	1	1	0
07/12/2024 19:00	0.5	13.9	1,327.8	0.4	1.3	1	1	0
07/12/2024 20:00	0.5	13.9	1,326.9	0.4	1.3	1	1	0
07/12/2024 21:00	0.5	13.7	1,632.5	0.4	1.5	1	1	0
07/12/2024 22:00	0.5	13.6	1,733.5	0.4	1.6	1	1	0
07/12/2024 23:00	0.6	13.6	1,731.1	0.4	1.9	1	1	0
Average/Sum#:	0.5	13.4	1,623.2	0.4	35.7 #	24 #	24 #	6 #
Minimum:	0.4	11.7	1,326.9	0.3	1.3	1	1	0
Maximum:	0.6	14.0	2,180.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2024 00:00	0.6	13.6	1,731.4	0.5	1.9	1	1	0
07/13/2024 01:00	0.6	13.6	1,731.0	0.5	1.9	1	1	0
07/13/2024 02:00	0.6	13.6	1,742.4	0.5	1.9	1	1	0
07/13/2024 03:00	0.6	13.6	1,748.8	0.5	1.9	1	1	0
07/13/2024 04:00	0.5	13.7	1,730.0	0.5	1.6	1	1	0
07/13/2024 05:00	0.5	13.6	1,752.8	0.4	1.6	1	1	0
07/13/2024 06:00	0.6	13.7	1,714.2	0.4	1.9	1	1	0
07/13/2024 07:00	0.7	13.6	1,732.9	0.5	2.2	1	1	0
07/13/2024 08:00	0.6	13.7	1,714.0	0.5	1.9	1	1	0
07/13/2024 09:00	0.5	13.8	1,559.7	0.5	1.5	1	1	0
07/13/2024 10:00	0.5	13.9	1,558.1	0.4	1.5	1	1	0
07/13/2024 11:00	0.5	13.8	1,627.8	0.4	1.5	1	1	0
07/13/2024 12:00	0.5	13.8	1,647.4	0.4	1.5	1	1	0
07/13/2024 13:00	0.5	13.9	1,377.1	0.4	1.3	1	1	0
07/13/2024 14:00	0.5	13.9	1,322.1	0.4	1.2	1	1	0
07/13/2024 15:00	0.5	13.9	1,326.9	0.4	1.3	1	1	0
07/13/2024 16:00	0.5	13.9	1,322.7	0.4	1.2	1	1	0
07/13/2024 17:00	0.5	13.9	1,333.5	0.4	1.3	1	1	0
07/13/2024 18:00	0.5	13.9	1,328.3	0.4	1.3	1	1	0
07/13/2024 19:00	0.5	13.8	1,463.2	0.4	1.4	1	1	0
07/13/2024 20:00	0.5	13.6	1,717.1	0.4	1.6	1	1	0
07/13/2024 21:00	0.5	13.6	1,714.8	0.4	1.6	1	1	0
07/13/2024 22:00	0.5	13.7	1,726.6	0.4	1.6	1	1	0
07/13/2024 23:00	0.5	13.7	1,734.3	0.4	1.6	1	1	0
Average/Sum#:	0.5	13.7	1,598.2	0.4	38.2 #	24 #	24 #	0 #
Minimum:	0.5	13.6	1,322.1	0.4	1.2	1	1	0
Maximum:	0.7	13.9	1,752.8	0.5	2.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2024 00:00	0.5	13.7	1,741.7	0.4	1.6	1	1	0
07/14/2024 01:00	0.5	13.8	1,649.7	0.4	1.5	1	1	0
07/14/2024 02:00	10.1	14.7	1,047.3	0.0	10.6	1	0	0
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2024 14:00	31.7	17.7	343.8	0.0	21.6	1	0	0
07/14/2024 15:00	17.4	14.3	1,324.5	0.0	46.1	1	0	0
07/14/2024 16:00	0.5	13.7	1,684.6	0.0	1.5	1	1	0
07/14/2024 17:00	0.5	13.6	1,705.5	0.0	1.5	1	1	1
07/14/2024 18:00	0.7	11.8	2,131.7	0.4	2.2	1	1	1
07/14/2024 19:00	0.4	11.5	2,203.6	0.4	1.2	1	1	1
07/14/2024 20:00	0.4	11.6	2,187.1	0.4	1.2	1	1	1
07/14/2024 21:00	0.3	11.5	2,209.9	0.3	0.9	1	1	1
07/14/2024 22:00	0.5	12.1	2,070.8	0.3	1.6	1	1	1
07/14/2024 23:00	0.6	12.4	1,990.8	0.3	1.9	1	1	1
Average/Sum#:	4.9	13.3	1,714.7	0.4	93.4 #	13 #	10 #	7 #
Minimum:	0.3	11.5	343.8	0.3	0.9	0	0	0
Maximum:	31.7	17.7	2,209.9	0.4	46.1	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2024 00:00	0.6	13.7	1,722.7	0.4	1.9	1	1	0
07/15/2024 01:00	0.5	13.7	1,736.1	0.4	1.6	1	1	0
07/15/2024 02:00	0.6	13.8	1,626.1	0.5	1.8	1	1	0
07/15/2024 03:00	0.5	13.8	1,713.3	0.4	1.6	1	1	0
07/15/2024 04:00	0.5	13.7	1,749.7	0.4	1.6	1	1	0
07/15/2024 05:00	0.5	13.8	1,715.7	0.4	1.6	1	1	0
07/15/2024 06:00	0.5	13.8	1,698.3	0.4	1.6	1	1	0
07/15/2024 07:00	0.5	13.8	1,709.8	0.4	1.6	1	1	0
07/15/2024 08:00	0.5	13.8	1,544.9	0.4	1.4	1	1	0
07/15/2024 09:00	0.4	13.8	1,486.3	0.4	1.1	1	1	0
07/15/2024 10:00	0.5	13.8	1,622.8	0.4	1.5	1	1	0
07/15/2024 11:00	0.5	13.7	1,701.0	0.4	1.6	1	1	0
07/15/2024 12:00	0.5	13.8	1,658.0	0.4	1.5	1	1	0
07/15/2024 13:00	0.5	13.8	1,661.7	0.4	1.5	1	1	0
07/15/2024 14:00	0.5	13.7	1,657.6	0.4	1.5	1	1	0
07/15/2024 15:00	0.5	13.9	1,591.1	0.4	1.5	1	1	0
07/15/2024 16:00	0.5	13.8	1,569.5	0.4	1.5	1	1	0
07/15/2024 17:00	0.6	13.2	1,722.5	0.4	1.8	1	1	1
07/15/2024 18:00	0.5	11.8	2,127.9	0.4	1.5	1	1	1
07/15/2024 19:00	0.4	11.6	2,186.2	0.4	1.2	1	1	1
07/15/2024 20:00	0.4	11.7	2,178.7	0.3	1.3	1	1	1
07/15/2024 21:00	0.5	12.0	2,119.0	0.3	1.6	1	1	1
07/15/2024 22:00	0.7	12.8	1,987.8	0.4	2.3	1	1	1
07/15/2024 23:00	0.9	12.7	1,970.3	0.5	2.9	1	1	1
Average/Sum#:	0.5	13.3	1,769.0	0.4	39.0 #	24 #	24 #	7 #
Minimum:	0.4	11.6	1,486.3	0.3	1.1	1	1	0
Maximum:	0.9	13.9	2,186.2	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2024 00:00	0.6	13.7	1,726.6	0.5	1.9	1	1	1
07/16/2024 01:00	0.5	13.8	1,735.8	0.5	1.6	1	1	0
07/16/2024 02:00	0.5	13.8	1,743.5	0.4	1.6	1	1	0
07/16/2024 03:00	0.5	13.8	1,747.0	0.4	1.6	1	1	0
07/16/2024 04:00	0.5	13.8	1,743.6	0.4	1.6	1	1	0
07/16/2024 05:00	0.5	13.8	1,707.5	0.4	1.6	1	1	0
07/16/2024 06:00	0.4	13.8	1,689.6	0.4	1.3	1	1	0
07/16/2024 07:00	0.5	13.8	1,720.0	0.4	1.6	1	1	0
07/16/2024 08:00	0.5	13.8	1,597.3	0.4	1.5	1	1	0
07/16/2024 09:00	0.5	13.8	1,616.0	0.4	1.5	1	1	0
07/16/2024 10:00	0.5	13.8	1,655.5	0.4	1.5	1	1	0
07/16/2024 11:00	0.5	13.8	1,702.4	0.4	1.6	1	1	0
07/16/2024 12:00	0.5	13.8	1,639.4	0.4	1.5	1	1	0
07/16/2024 13:00	0.5	13.8	1,534.9	0.4	1.4	1	1	0
07/16/2024 14:00	0.4	14.0	1,324.4	0.4	1.0	1	1	0
07/16/2024 15:00	0.4	13.9	1,498.1	0.3	1.1	1	1	1
07/16/2024 16:00	0.8	12.3	2,058.9	0.4	2.5	1	1	1
07/16/2024 17:00	0.5	11.8	2,152.5	0.4	1.6	1	1	1
07/16/2024 18:00	0.4	11.6	2,227.9	0.4	1.3	1	1	1
07/16/2024 19:00	0.4	11.6	2,230.5	0.3	1.3	1	1	1
07/16/2024 20:00	0.3	11.5	2,237.0	0.3	0.9	1	1	1
07/16/2024 21:00	0.4	11.5	2,244.8	0.3	1.3	1	1	1
07/16/2024 22:00	0.4	11.9	2,165.3	0.3	1.3	1	1	1
07/16/2024 23:00	0.6	12.5	2,054.7	0.3	1.9	1	1	1
Average/Sum#:	0.5	13.2	1,823.1	0.4	36.0 #	24 #	24 #	10 #
Minimum:	0.3	11.5	1,324.4	0.3	0.9	1	1	0
Maximum:	0.8	14.0	2,244.8	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2024 00:00	0.7	12.7	2,023.8	0.4	2.3	1	1	1
07/17/2024 01:00	0.5	13.6	1,701.0	0.4	1.5	1	1	1
07/17/2024 02:00	0.4	13.8	1,715.4	0.4	1.3	1	1	0
07/17/2024 03:00	0.4	13.8	1,743.1	0.3	1.3	1	1	0
07/17/2024 04:00	0.4	13.8	1,743.7	0.3	1.3	1	1	0
07/17/2024 05:00	0.4	13.8	1,661.1	0.3	1.2	1	1	0
07/17/2024 06:00	0.4	13.8	1,705.4	0.3	1.3	1	1	0
07/17/2024 07:00	0.4	13.8	1,736.6	0.3	1.3	1	1	0
07/17/2024 08:00	0.4	13.8	1,703.5	0.3	1.3	1	1	0
07/17/2024 09:00	0.5	13.8	1,620.2	0.3	1.5	1	1	0
07/17/2024 10:00	0.5	13.9	1,428.5	0.4	1.3	1	1	0
07/17/2024 11:00	0.5	13.9	1,429.9	0.4	1.3	1	1	0
07/17/2024 12:00	0.5	13.9	1,538.1	0.4	1.5	1	1	0
07/17/2024 13:00	0.5	13.9	1,476.5	0.4	1.4	1	1	0
07/17/2024 14:00	0.5	13.9	1,575.8	0.4	1.5	1	1	1
07/17/2024 15:00	0.8	12.3	2,069.7	0.4	2.5	1	1	1
07/17/2024 16:00	0.7	12.4	2,043.3	0.5	2.2	1	1	1
07/17/2024 17:00	0.6	12.2	2,097.2	0.5	1.9	1	1	1
07/17/2024 18:00	0.4	11.6	2,219.2	0.4	1.3	1	1	1
07/17/2024 19:00	0.4	11.6	2,230.4	0.3	1.3	1	1	1
07/17/2024 20:00	0.4	11.6	2,230.8	0.3	1.3	1	1	1
07/17/2024 21:00	0.4	11.6	2,222.4	0.3	1.3	1	1	1
07/17/2024 22:00	0.4	11.6	2,215.7	0.3	1.3	1	1	1
07/17/2024 23:00	0.4	11.9	2,167.3	0.3	1.3	1	1	1
Average/Sum#:	0.5	13.0	1,845.8	0.4	35.7 #	24 #	24 #	12 #
Minimum:	0.4	11.6	1,428.5	0.3	1.2	1	1	0
Maximum:	0.8	13.9	2,230.8	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2024 00:00	0.7	12.6	2,021.1	0.4	2.3	1	1	1
07/18/2024 01:00	0.7	12.5	2,036.6	0.4	2.2	1	1	1
07/18/2024 02:00	0.5	11.9	2,174.0	0.4	1.6	1	1	1
07/18/2024 03:00	0.5	12.0	2,149.6	0.4	1.6	1	1	1
07/18/2024 04:00	0.6	12.0	2,169.9	0.3	1.9	1	1	1
07/18/2024 05:00	0.5	12.2	2,117.4	0.3	1.6	1	1	1
07/18/2024 06:00	0.6	12.6	2,027.2	0.4	1.9	1	1	1
07/18/2024 07:00	0.7	12.7	1,978.4	0.4	2.2	1	1	1
07/18/2024 08:00	0.7	12.6	2,020.0	0.5	2.2	1	1	1
07/18/2024 09:00	0.6	12.2	2,096.6	0.5	1.9	1	1	1
07/18/2024 10:00	0.5	12.1	2,100.1	0.4	1.6	1	1	1
07/18/2024 11:00	0.5	12.1	2,100.3	0.3	1.6	1	1	1
07/18/2024 12:00	0.6	12.2	2,071.6	0.3	1.9	1	1	1
07/18/2024 13:00	0.5	11.7	2,169.2	0.3	1.6	1	1	1
07/18/2024 14:00	0.4	11.6	2,179.3	0.3	1.2	1	1	1
07/18/2024 15:00	0.4	11.6	2,180.1	0.3	1.2	1	1	1
07/18/2024 16:00	0.4	11.6	2,189.3	0.3	1.2	1	1	1
07/18/2024 17:00	0.4	11.5	2,194.3	0.3	1.2	1	1	1
07/18/2024 18:00	0.4	11.5	2,196.4	0.3	1.2	1	1	1
07/18/2024 19:00	0.4	11.5	2,200.1	0.3	1.2	1	1	1
07/18/2024 20:00	0.4	11.5	2,208.5	0.3	1.2	1	1	1
07/18/2024 21:00	0.4	11.5	2,211.6	0.3	1.2	1	1	1
07/18/2024 22:00	0.4	11.5	2,224.2	0.3	1.2	1	1	1
07/18/2024 23:00	0.4	11.9	2,143.3	0.3	1.3	1	1	1
Average/Sum#:	0.5	12.0	2,131.6	0.3	38.2 #	24 #	24 #	24 #
Minimum:	0.4	11.5	1,978.4	0.3	1.2	1	1	1
Maximum:	0.7	12.7	2,224.2	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2024 00:00	0.5	12.2	2,089.2	0.3	1.6	1	1	1
07/19/2024 01:00	0.5	12.3	2,066.9	0.3	1.6	1	1	1
07/19/2024 02:00	0.5	12.2	2,094.0	0.3	1.6	1	1	1
07/19/2024 03:00	0.6	12.6	2,000.0	0.3	1.9	1	1	1
07/19/2024 04:00	0.4	11.9	2,180.9	0.3	1.3	1	1	1
07/19/2024 05:00	0.5	12.3	2,074.3	0.3	1.6	1	1	1
07/19/2024 06:00	0.4	13.7	1,737.8	0.3	1.3	1	1	1
07/19/2024 07:00	0.4	13.7	1,750.7	0.3	1.3	1	1	0
07/19/2024 08:00	0.4	13.7	1,752.7	0.3	1.3	1	1	0
07/19/2024 09:00	0.5	13.7	1,756.1	0.3	1.6	1	1	0
07/19/2024 10:00	0.5	13.6	1,751.0	0.4	1.6	1	1	0
07/19/2024 11:00	0.5	13.6	1,747.5	0.4	1.6	1	1	0
07/19/2024 12:00	0.5	13.6	1,736.9	0.4	1.6	1	1	1
07/19/2024 13:00	0.6	11.8	2,158.5	0.4	1.9	1	1	1
07/19/2024 14:00	0.4	11.5	2,199.2	0.4	1.2	1	1	1
07/19/2024 15:00	0.4	11.5	2,195.3	0.3	1.2	1	1	1
07/19/2024 16:00	0.3	11.5	2,188.5	0.3	0.9	1	1	1
07/19/2024 17:00	0.4	11.5	2,183.5	0.3	1.2	1	1	1
07/19/2024 18:00	0.4	11.5	2,182.3	0.3	1.2	1	1	1
07/19/2024 19:00	0.4	11.5	2,176.0	0.3	1.2	1	1	1
07/19/2024 20:00	0.4	11.7	2,159.5	0.3	1.2	1	1	1
07/19/2024 21:00	0.4	12.0	2,133.2	0.3	1.3	1	1	1
07/19/2024 22:00	0.3	11.6	2,212.8	0.3	0.9	1	1	1
07/19/2024 23:00	0.4	11.5	2,222.7	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.4	2,031.2	0.3	33.3 #	24 #	24 #	19 #
Minimum:	0.3	11.5	1,736.9	0.3	0.9	1	1	0
Maximum:	0.6	13.7	2,222.7	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2024 00:00	0.4	11.5	2,219.7	0.3	1.2	1	1	1
07/20/2024 01:00	0.3	11.6	2,229.8	0.3	0.9	1	1	1
07/20/2024 02:00	0.3	11.6	2,230.8	0.2	1.0	1	1	1
07/20/2024 03:00	0.3	11.6	2,234.2	0.2	1.0	1	1	1
07/20/2024 04:00	0.3	11.6	2,236.4	0.2	1.0	1	1	1
07/20/2024 05:00	0.4	12.0	2,127.3	0.2	1.3	1	1	1
07/20/2024 06:00	0.5	13.7	1,707.9	0.3	1.6	1	1	1
07/20/2024 07:00	0.5	13.8	1,733.9	0.4	1.6	1	1	0
07/20/2024 08:00	0.5	13.8	1,575.5	0.4	1.5	1	1	0
07/20/2024 09:00	0.5	13.8	1,609.3	0.4	1.5	1	1	0
07/20/2024 10:00	0.5	13.7	1,714.5	0.4	1.6	1	1	0
07/20/2024 11:00	0.5	13.7	1,623.1	0.4	1.5	1	1	0
07/20/2024 12:00	0.5	14.0	1,339.9	0.4	1.3	1	1	0
07/20/2024 13:00	0.5	13.8	1,629.6	0.4	1.5	1	1	1
07/20/2024 14:00	0.6	11.9	2,118.6	0.4	1.9	1	1	1
07/20/2024 15:00	0.5	11.7	2,141.5	0.4	1.5	1	1	1
07/20/2024 16:00	0.4	11.6	2,151.8	0.3	1.2	1	1	1
07/20/2024 17:00	0.3	11.5	2,174.2	0.3	0.9	1	1	1
07/20/2024 18:00	0.3	11.4	2,179.3	0.2	0.9	1	1	1
07/20/2024 19:00	0.4	11.7	2,130.0	0.2	1.2	1	1	1
07/20/2024 20:00	0.4	11.8	2,117.5	0.3	1.2	1	1	1
07/20/2024 21:00	0.4	11.9	2,113.2	0.3	1.2	1	1	1
07/20/2024 22:00	0.4	11.5	2,198.9	0.3	1.2	1	1	1
07/20/2024 23:00	0.4	11.5	2,216.2	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.4	1,989.7	0.3	30.9 #	24 #	24 #	18 #
Minimum:	0.3	11.4	1,339.9	0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,236.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2024 00:00	0.3	11.5	2,230.7	0.3	0.9	1	1	1
07/21/2024 01:00	0.3	11.7	2,197.4	0.2	0.9	1	1	1
07/21/2024 02:00	0.4	11.9	2,171.9	0.2	1.3	1	1	1
07/21/2024 03:00	0.4	11.9	2,168.9	0.3	1.3	1	1	1
07/21/2024 04:00	0.4	11.9	2,172.3	0.3	1.3	1	1	1
07/21/2024 05:00	6.0	13.3	1,533.1	0.0	12.0	1	0	1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2024 23:00	0.0	20.9	0.2	0.0	0.0	1	0	0
Average/Sum#:	1.1	13.3	1,782.1	0.3	17.7 #	7 #	5 #	6 #
Minimum:	0.0	11.5	0.2	0.2	0.0	0	0	0
Maximum:	6.0	20.9	2,230.7	0.3	12.0	1	1	1
%SI	70.83	70.83	70.83	79.17	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/22/2024 03:00	58.5	17.0	474.6	0.0	81.8	1	0	0
07/22/2024 04:00	6.9	14.0	1,341.9	0.0	17.7	1	0	0
07/22/2024 05:00	0.4	13.7	1,637.3	0.0	1.2	1	1	0
07/22/2024 06:00	0.5	13.7	1,718.5	0.0	1.6	1	1	0
07/22/2024 07:00	0.4	13.7	1,705.8	0.3	1.3	1	1	0
07/22/2024 08:00	0.5	13.8	1,696.9	0.4	1.6	1	1	0
07/22/2024 09:00	0.5	13.8	1,683.5	0.4	1.6	1	1	0
07/22/2024 10:00	0.5	13.8	1,668.6	0.4	1.6	1	1	0
07/22/2024 11:00	0.5	13.8	1,651.5	0.4	1.5	1	1	0
07/22/2024 12:00	0.6	12.9	1,789.8	0.4	1.8	1	1	1
07/22/2024 13:00	0.4	11.5	2,159.5	0.4	1.2	1	1	1
07/22/2024 14:00	0.3	11.6	2,150.2	0.3	0.9	1	1	1
07/22/2024 15:00	0.3	11.5	2,152.5	0.2	0.9	1	1	1
07/22/2024 16:00	0.3	11.5	2,167.5	0.2	0.9	1	1	1
07/22/2024 17:00	0.3	11.5	2,176.5	0.2	0.9	1	1	1
07/22/2024 18:00	0.3	11.5	2,173.0	0.2	0.9	1	1	1
07/22/2024 19:00	0.3	11.5	2,160.0	0.2	0.9	1	1	1
07/22/2024 20:00	0.4	11.7	2,123.2	0.2	1.2	1	1	1
07/22/2024 21:00	0.4	11.9	2,096.9	0.3	1.2	1	1	1
07/22/2024 22:00	0.3	11.5	2,185.0	0.3	0.9	1	1	1
07/22/2024 23:00	0.3	11.5	2,213.1	0.2	0.9	1	1	1
Average/Sum#:	3.5	12.7	1,863.1	0.3	122.5 #	21 #	19 #	12 #
Minimum:	0.3	11.5	474.6	0.2	0.9	0	0	0
Maximum:	58.5	17.0	2,213.1	0.4	81.8	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2024 00:00	0.3	11.5	2,215.9	0.2	0.9	1	1	1
07/23/2024 01:00	0.3	11.5	2,219.0	0.2	0.9	1	1	1
07/23/2024 02:00	0.3	11.5	2,230.8	0.2	0.9	1	1	1
07/23/2024 03:00	0.3	11.5	2,232.9	0.2	0.9	1	1	1
07/23/2024 04:00	0.3	11.5	2,239.4	0.2	0.9	1	1	1
07/23/2024 05:00	0.4	11.5	2,244.3	0.2	1.3	1	1	1
07/23/2024 06:00	0.5	12.3	2,064.4	0.3	1.6	1	1	1
07/23/2024 07:00	0.4	12.0	2,118.2	0.3	1.3	1	1	1
07/23/2024 08:00	0.5	12.3	2,024.9	0.3	1.6	1	1	1
07/23/2024 09:00	0.4	12.1	2,077.8	0.3	1.2	1	1	1
07/23/2024 10:00	0.4	11.9	2,112.2	0.3	1.2	1	1	1
07/23/2024 11:00	0.3	11.6	2,175.2	0.3	0.9	1	1	1
07/23/2024 12:00	0.4	11.9	2,111.8	0.3	1.2	1	1	1
07/23/2024 13:00	0.4	12.0	2,083.6	0.3	1.2	1	1	1
07/23/2024 14:00	0.3	11.8	2,128.7	0.3	0.9	1	1	1
07/23/2024 15:00	0.3	11.7	2,139.9	0.2	0.9	1	1	1
07/23/2024 16:00	0.3	11.5	2,179.1	0.2	0.9	1	1	1
07/23/2024 17:00	0.3	11.4	2,184.5	0.2	0.9	1	1	1
07/23/2024 18:00	0.3	11.4	2,185.1	0.2	0.9	1	1	1
07/23/2024 19:00	0.3	11.6	2,162.9	0.2	0.9	1	1	1
07/23/2024 20:00	0.3	11.5	2,200.7	0.2	0.9	1	1	1
07/23/2024 21:00	0.3	11.5	2,205.4	0.2	0.9	1	1	1
07/23/2024 22:00	0.3	11.8	2,163.3	0.2	0.9	1	1	1
07/23/2024 23:00	0.3	11.6	2,227.2	0.2	0.9	1	1	1
Average/Sum#:	0.3	11.7	2,163.6	0.2	25.0 #	24 #	24 #	24 #
Minimum:	0.3	11.4	2,024.9	0.2	0.9	1	1	1
Maximum:	0.5	12.3	2,244.3	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2024 00:00	0.4	11.8	2,162.2	0.2	1.3	1	1	1
07/24/2024 01:00	0.4	11.9	2,143.0	0.3	1.3	1	1	1
07/24/2024 02:00	0.4	11.9	2,148.9	0.3	1.3	1	1	1
07/24/2024 03:00	0.3	11.7	2,217.3	0.3	1.0	1	1	1
07/24/2024 04:00	0.3	11.7	2,224.5	0.2	1.0	1	1	1
07/24/2024 05:00	0.3	11.6	2,243.1	0.2	1.0	1	1	1
07/24/2024 06:00	0.4	12.1	2,119.1	0.2	1.3	1	1	1
07/24/2024 07:00	0.4	12.2	2,107.8	0.3	1.3	1	1	1
07/24/2024 08:00	0.4	12.2	2,095.3	0.3	1.3	1	1	1
07/24/2024 09:00	0.4	12.2	2,084.4	0.3	1.3	1	1	1
07/24/2024 10:00	0.5	12.2	2,076.0	0.3	1.6	1	1	1
07/24/2024 11:00	0.4	12.1	2,090.9	0.3	1.3	1	1	1
07/24/2024 12:00	0.4	11.9	2,125.1	0.3	1.2	1	1	1
07/24/2024 13:00	0.4	12.0	2,086.9	0.3	1.2	1	1	1
07/24/2024 14:00	0.3	11.8	2,115.8	0.3	0.9	1	1	1
07/24/2024 15:00	0.3	11.6	2,138.3	0.2	0.9	1	1	1
07/24/2024 16:00	0.4	12.3	2,029.2	0.2	1.2	1	1	1
07/24/2024 17:00	0.5	12.4	2,006.3	0.3	1.6	1	1	1
07/24/2024 18:00	0.5	12.4	2,016.7	0.3	1.6	1	1	1
07/24/2024 19:00	0.5	12.4	2,037.3	0.3	1.6	1	1	1
07/24/2024 20:00	0.5	12.4	2,044.5	0.3	1.6	1	1	1
07/24/2024 21:00	0.4	12.0	2,161.2	0.3	1.3	1	1	1
07/24/2024 22:00	0.3	11.7	2,227.1	0.3	1.0	1	1	1
07/24/2024 23:00	0.4	12.0	2,156.3	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.0	2,119.1	0.3	30.4 #	24 #	24 #	24 #
Minimum:	0.3	11.6	2,006.3	0.2	0.9	1	1	1
Maximum:	0.5	12.4	2,243.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2024 00:00	0.4	12.3	2,092.2	0.3	1.3	1	1	1
07/25/2024 01:00	0.5	12.4	2,082.4	0.3	1.6	1	1	1
07/25/2024 02:00	0.5	12.4	2,073.8	0.3	1.6	1	1	1
07/25/2024 03:00	0.4	12.1	2,144.4	0.3	1.3	1	1	1
07/25/2024 04:00	0.4	12.0	2,171.7	0.3	1.3	1	1	1
07/25/2024 05:00	0.3	12.0	2,164.4	0.3	1.0	1	1	1
07/25/2024 06:00	0.4	12.3	2,105.5	0.3	1.3	1	1	1
07/25/2024 07:00	0.4	12.2	2,112.2	0.3	1.3	1	1	1
07/25/2024 08:00	0.4	12.2	2,101.8	0.3	1.3	1	1	1
07/25/2024 09:00	0.4	12.3	2,090.3	0.3	1.3	1	1	1
07/25/2024 10:00	0.5	12.4	2,059.1	0.3	1.6	1	1	1
07/25/2024 11:00	0.4	12.0	2,126.7	0.3	1.3	1	1	1
07/25/2024 12:00	0.4	12.0	2,128.3	0.3	1.3	1	1	1
07/25/2024 13:00	0.4	12.0	2,122.3	0.3	1.3	1	1	1
07/25/2024 14:00	0.4	11.8	2,135.0	0.3	1.2	1	1	1
07/25/2024 15:00	0.3	11.7	2,158.0	0.3	0.9	1	1	1
07/25/2024 16:00	0.3	11.9	2,119.5	0.2	0.9	1	1	1
07/25/2024 17:00	0.3	11.9	2,111.2	0.2	0.9	1	1	1
07/25/2024 18:00	0.4	12.1	2,078.0	0.2	1.2	1	1	1
07/25/2024 19:00	0.4	12.2	2,054.0	0.3	1.2	1	1	1
07/25/2024 20:00	0.4	11.8	2,155.7	0.3	1.3	1	1	1
07/25/2024 21:00	0.3	11.8	2,169.1	0.3	0.9	1	1	1
07/25/2024 22:00	0.4	12.0	2,135.5	0.3	1.3	1	1	1
07/25/2024 23:00	0.3	11.7	2,216.7	0.2	1.0	1	1	1
Average/Sum#:	0.4	12.1	2,121.2	0.3	29.6 #	24 #	24 #	24 #
Minimum:	0.3	11.7	2,054.0	0.2	0.9	1	1	1
Maximum:	0.5	12.4	2,216.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2024 00:00	0.3	11.9	2,173.2	0.2	1.0	1	1	1
07/26/2024 01:00	0.5	12.5	2,042.4	0.3	1.6	1	1	1
07/26/2024 02:00	0.7	12.9	1,967.8	0.4	2.3	1	1	1
07/26/2024 03:00	0.8	12.9	1,971.9	0.5	2.6	1	1	1
07/26/2024 04:00	0.5	12.3	2,113.9	0.5	1.6	1	1	1
07/26/2024 05:00	0.5	12.4	2,081.0	0.4	1.6	1	1	1
07/26/2024 06:00	0.7	12.9	1,973.1	0.4	2.3	1	1	1
07/26/2024 07:00	0.7	12.8	1,972.6	0.4	2.3	1	1	1
07/26/2024 08:00	0.7	12.8	1,976.0	0.5	2.3	1	1	1
07/26/2024 09:00	0.7	12.7	1,983.7	0.5	2.2	1	1	1
07/26/2024 10:00	0.6	12.6	1,992.4	0.5	1.9	1	1	1
07/26/2024 11:00	0.6	12.6	2,002.2	0.4	1.9	1	1	1
07/26/2024 12:00	0.5	12.4	2,013.1	0.4	1.6	1	1	1
07/26/2024 13:00	0.5	12.3	2,036.9	0.3	1.6	1	1	1
07/26/2024 14:00	0.4	12.2	2,050.8	0.3	1.2	1	1	1
07/26/2024 15:00	0.4	12.0	2,089.7	0.3	1.2	1	1	1
07/26/2024 16:00	0.3	11.7	2,134.0	0.3	0.9	1	1	1
07/26/2024 17:00	0.3	11.7	2,136.6	0.2	0.9	1	1	1
07/26/2024 18:00	0.4	12.2	2,054.2	0.2	1.2	1	1	1
07/26/2024 19:00	0.4	12.1	2,104.4	0.3	1.3	1	1	1
07/26/2024 20:00	0.3	11.7	2,202.5	0.3	0.9	1	1	1
07/26/2024 21:00	0.4	12.4	2,064.6	0.3	1.3	1	1	1
07/26/2024 22:00	0.5	12.4	2,059.4	0.3	1.6	1	1	1
07/26/2024 23:00	0.7	12.9	1,971.9	0.4	2.3	1	1	1
Average/Sum#:	0.5	12.4	2,048.7	0.4	39.6 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,967.8	0.2	0.9	1	1	1
Maximum:	0.8	12.9	2,202.5	0.5	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2024 00:00	0.8	12.9	1,975.4	0.5	2.6	1	1	1
07/27/2024 01:00	0.7	12.9	1,974.7	0.5	2.3	1	1	1
07/27/2024 02:00	0.6	12.9	1,977.4	0.5	2.0	1	1	1
07/27/2024 03:00	0.7	12.9	1,979.9	0.5	2.3	1	1	1
07/27/2024 04:00	0.6	12.8	2,018.0	0.4	2.0	1	1	1
07/27/2024 05:00	0.5	12.6	2,044.3	0.4	1.6	1	1	1
07/27/2024 06:00	0.0	0.0	674.5	0.0	0.0	1	0	0
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/27/2024 15:00	22.6	17.9	327.7	0.0	14.0	1	0	0
07/27/2024 16:00	30.4	14.8	1,036.1	0.0	68.2	1	0	0
07/27/2024 17:00	0.4	13.7	1,729.5	0.0	1.3	1	1	0
07/27/2024 18:00	0.4	13.7	1,588.0	0.0	1.2	1	1	1
07/27/2024 19:00	0.7	12.7	1,978.4	0.4	2.2	1	1	1
07/27/2024 20:00	0.7	12.7	1,973.8	0.4	2.2	1	1	1
07/27/2024 21:00	0.7	12.8	1,968.8	0.5	2.2	1	1	1
07/27/2024 22:00	0.7	12.8	1,963.4	0.5	2.2	1	1	1
07/27/2024 23:00	0.7	12.8	1,961.2	0.5	2.2	1	1	1
Average/Sum#:	4.1	13.4	1,698.2	0.5	108.5 #	16 #	13 #	12 #
Minimum:	0.4	12.6	327.7	0.4	1.2	0	0	0
Maximum:	30.4	17.9	2,044.3	0.5	68.2	1	1	1
%SI	37.50	37.50	33.33	54.17	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2024 00:00	0.7	12.9	1,960.1	0.5	2.3	1	1	1
07/28/2024 01:00	0.7	12.9	1,963.6	0.5	2.3	1	1	1
07/28/2024 02:00	0.7	12.9	1,963.2	0.5	2.3	1	1	1
07/28/2024 03:00	0.8	13.0	1,960.7	0.5	2.6	1	1	1
07/28/2024 04:00	0.8	13.0	1,955.1	0.6	2.6	1	1	1
07/28/2024 05:00	0.4	13.8	1,704.4	0.5	1.3	1	1	0
07/28/2024 06:00	0.4	13.9	1,314.0	0.4	1.0	1	1	0
07/28/2024 07:00	37.2	16.4	325.2	0.0	6.0	1	0	0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/28/2024 14:00	49.9	17.0	490.8	0.0	39.8	1	0	0
07/28/2024 15:00	22.6	14.4	1,218.9	0.0	56.0	1	0	0
07/28/2024 16:00	0.4	13.8	1,678.3	0.0	1.2	1	1	1
07/28/2024 17:00	1.9	13.0	1,882.7	0.0	6.0	1	1	1
07/28/2024 18:00	1.7	13.0	1,882.5	1.0	5.4	1	1	1
07/28/2024 19:00	1.7	13.0	1,887.4	1.3	5.4	1	1	1
07/28/2024 20:00	1.0	12.7	1,958.7	1.1	3.2	1	1	1
07/28/2024 21:00	0.9	12.7	1,959.5	0.9	2.8	1	1	1
07/28/2024 22:00	0.5	13.8	1,505.8	0.6	1.4	1	1	0
07/28/2024 23:00	0.4	13.8	1,668.8	0.4	1.2	1	1	0
Average/Sum#:	6.8	13.7	1,626.7	0.7	142.8 #	18 #	15 #	11 #
Minimum:	0.4	12.7	325.2	0.4	1.0	0	0	0
Maximum:	49.9	17.0	1,963.6	1.3	56.0	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2024 00:00	0.4	13.8	1,529.5	0.3	1.1	1	1	0
07/29/2024 01:00	0.4	13.9	1,523.7	0.3	1.1	1	1	0
07/29/2024 02:00	0.4	13.8	1,533.1	0.3	1.1	1	1	0
07/29/2024 03:00	28.6	15.6	592.0	0.0	9.7	1	0	0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/29/2024 14:00	0.0	20.9	0.2	0.0	0.0	1	0	0
07/29/2024 15:00	43.4	17.0	456.9	0.0	67.2	1	0	0
07/29/2024 16:00	18.8	14.2	1,359.6	0.0	50.4	1	0	0
07/29/2024 17:00	0.4	13.7	1,655.4	0.0	1.2	1	1	0
07/29/2024 18:00	0.5	13.0	1,802.5	0.0	1.5	1	1	1
07/29/2024 19:00	0.4	11.5	2,207.5	0.3	1.2	1	1	1
07/29/2024 20:00	0.3	11.6	2,218.7	0.3	0.9	1	1	1
07/29/2024 21:00	0.4	12.2	2,071.6	0.3	1.3	1	1	1
07/29/2024 22:00	0.4	12.3	2,043.9	0.3	1.3	1	1	1
07/29/2024 23:00	18.9	15.5	683.3	0.0	8.8	1	0	0
Average/Sum#:	8.1	14.2	1,405.6	0.3	146.8 #	14 #	9 #	5 #
Minimum:	0.0	11.5	0.2	0.3	0.0	0	0	0
Maximum:	43.4	20.9	2,218.7	0.3	67.2	1	1	1
%SI	41.67	41.67	41.67	70.83	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/30/2024 15:00	51.0	17.0	474.0	0.0	71.3	1	0	0
07/30/2024 16:00	18.6	14.4	1,198.0	0.0	45.3	1	0	0
07/30/2024 17:00	0.3	13.9	1,447.5	0.0	0.8	1	1	0
07/30/2024 18:00	0.7	13.2	1,750.3	0.0	2.1	1	1	1
07/30/2024 19:00	0.4	11.7	2,204.1	0.4	1.3	1	1	1
07/30/2024 20:00	0.2	11.6	2,212.3	0.3	0.6	1	1	1
07/30/2024 21:00	0.2	11.6	2,196.4	0.2	0.6	1	1	1
07/30/2024 22:00	0.3	12.0	2,112.7	0.1	0.9	1	1	1
07/30/2024 23:00	0.4	12.0	2,123.8	0.2	1.3	1	1	1
Average/Sum#:	8.0	13.0	1,746.6	0.2	124.2 #	9 #	7 #	6 #
Minimum:	0.2	11.6	474.0	0.1	0.6	0	0	0
Maximum:	51.0	17.0	2,212.3	0.4	71.3	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2024 00:00	0.6	12.7	1,963.4	0.3	1.9	1	1	1
07/31/2024 01:00	0.7	12.8	1,956.7	0.4	2.2	1	1	1
07/31/2024 02:00	0.7	12.8	1,955.8	0.5	2.2	1	1	1
07/31/2024 03:00	0.7	12.7	1,981.9	0.5	2.2	1	1	1
07/31/2024 04:00	0.3	11.7	2,236.4	0.4	1.0	1	1	1
07/31/2024 05:00	0.3	12.0	2,126.5	0.3	0.9	1	1	1
07/31/2024 06:00	0.3	13.8	1,715.5	0.2	1.0	1	1	0
07/31/2024 07:00	0.3	13.8	1,587.4	0.2	0.9	1	1	0
07/31/2024 08:00	0.3	13.8	1,493.0	0.2	0.8	1	1	0
07/31/2024 09:00	0.3	13.8	1,497.3	0.2	0.8	1	1	0
07/31/2024 10:00	0.3	13.8	1,544.2	0.2	0.9	1	1	0
07/31/2024 11:00	0.3	13.8	1,576.3	0.2	0.9	1	1	0
07/31/2024 12:00	0.3	13.9	1,465.8	0.2	0.8	1	1	0
07/31/2024 13:00	0.4	13.7	1,624.7	0.3	1.2	1	1	0
07/31/2024 14:00	0.5	11.9	2,102.0	0.3	1.5	1	1	1
07/31/2024 15:00	0.3	11.5	2,192.3	0.3	0.9	1	1	1
07/31/2024 16:00	0.2	11.5	2,184.0	0.2	0.6	1	1	1
07/31/2024 17:00	0.2	11.5	2,193.3	0.1	0.6	1	1	1
07/31/2024 18:00	0.2	11.5	2,181.2	0.1	0.6	1	1	1
07/31/2024 19:00	0.2	11.7	2,154.5	0.1	0.6	1	1	1
07/31/2024 20:00	0.3	11.8	2,131.2	0.1	0.9	1	1	1
07/31/2024 21:00	0.3	11.9	2,108.1	0.2	0.9	1	1	1
07/31/2024 22:00	0.3	12.0	2,099.2	0.2	0.9	1	1	1
07/31/2024 23:00	0.3	12.0	2,096.3	0.2	0.9	1	1	1
Average/Sum#:	0.4	12.6	1,923.6	0.2	26.1 #	24 #	24 #	16 #
Minimum:	0.2	11.5	1,465.8	0.1	0.6	1	1	0
Maximum:	0.7	13.9	2,236.4	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2024 00:00	0.4	12.1	2,088.9	0.2	1.3	1	1	1
08/01/2024 01:00	0.4	12.1	2,086.6	0.3	1.3	1	1	1
08/01/2024 02:00	0.4	12.2	2,082.6	0.3	1.3	1	1	1
08/01/2024 03:00	0.4	12.3	2,076.8	0.3	1.3	1	1	1
08/01/2024 04:00	0.4	12.3	2,080.7	0.3	1.3	1	1	1
08/01/2024 05:00	0.3	11.7	2,215.0	0.3	1.0	1	1	1
08/01/2024 06:00	0.3	12.2	2,103.6	0.2	1.0	1	1	1
08/01/2024 07:00	0.3	13.7	1,704.4	0.2	0.9	1	1	0
08/01/2024 08:00	0.4	13.7	1,732.1	0.2	1.3	1	1	0
08/01/2024 09:00	0.4	13.7	1,742.0	0.3	1.3	1	1	0
08/01/2024 10:00	0.4	13.7	1,727.8	0.3	1.3	1	1	0
08/01/2024 11:00	0.4	13.7	1,710.0	0.3	1.3	1	1	0
08/01/2024 12:00	0.5	13.7	1,703.5	0.3	1.6	1	1	1
08/01/2024 13:00	0.5	11.9	2,126.9	0.3	1.6	1	1	1
08/01/2024 14:00	0.3	11.6	2,177.1	0.3	0.9	1	1	1
08/01/2024 15:00	0.3	11.5	2,199.0	0.2	0.9	1	1	1
08/01/2024 16:00	0.2	11.5	2,206.4	0.2	0.6	1	1	1
08/01/2024 17:00	0.2	11.5	2,203.4	0.1	0.6	1	1	1
08/01/2024 18:00	0.2	11.6	2,192.8	0.1	0.6	1	1	1
08/01/2024 19:00	0.3	11.8	2,149.2	0.1	0.9	1	1	1
08/01/2024 20:00	0.3	12.0	2,115.9	0.2	0.9	1	1	1
08/01/2024 21:00	0.4	12.3	2,071.8	0.2	1.3	1	1	1
08/01/2024 22:00	0.4	12.3	2,074.7	0.3	1.3	1	1	1
08/01/2024 23:00	0.3	11.7	2,235.6	0.3	1.0	1	1	1
Average/Sum#:	0.4	12.4	2,033.6	0.2	26.8 #	24 #	24 #	19 #
Minimum:	0.2	11.5	1,703.5	0.1	0.6	1	1	0
Maximum:	0.5	13.7	2,235.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	0.3	11.7	2,233.9	0.2	1.0	1	1	1
08/02/2024 01:00	0.3	11.7	2,227.3	0.2	1.0	1	1	1
08/02/2024 02:00	0.2	11.6	2,249.8	0.2	0.6	1	1	1
08/02/2024 03:00	0.2	11.6	2,258.1	0.1	0.6	1	1	1
08/02/2024 04:00	0.2	11.6	2,253.9	0.1	0.6	1	1	1
08/02/2024 05:00	0.2	11.6	2,260.7	0.1	0.6	1	1	1
08/02/2024 06:00	0.2	11.6	2,252.2	0.1	0.6	1	1	1
08/02/2024 07:00	0.2	11.6	2,245.9	0.1	0.6	1	1	1
08/02/2024 08:00	0.3	11.6	2,247.2	0.1	1.0	1	1	1
08/02/2024 09:00	0.3	11.6	2,236.9	0.2	1.0	1	1	1
08/02/2024 10:00	0.3	11.6	2,230.4	0.2	1.0	1	1	1
08/02/2024 11:00	0.2	11.5	2,221.6	0.2	0.6	1	1	1
08/02/2024 12:00	0.2	11.5	2,210.7	0.1	0.6	1	1	1
08/02/2024 13:00	0.2	11.5	2,211.0	0.1	0.6	1	1	1
08/02/2024 14:00	0.2	11.5	2,210.0	0.1	0.6	1	1	1
08/02/2024 15:00	0.2	11.5	2,206.6	0.1	0.6	1	1	1
08/02/2024 16:00	0.2	11.5	2,215.5	0.1	0.6	1	1	1
08/02/2024 17:00	0.2	11.5	2,211.7	0.1	0.6	1	1	1
08/02/2024 18:00	0.2	11.5	2,213.8	0.1	0.6	1	1	1
08/02/2024 19:00	0.2	11.6	2,196.2	0.1	0.6	1	1	1
08/02/2024 20:00	0.2	11.7	2,184.9	0.1	0.6	1	1	1
08/02/2024 21:00	0.2	11.5	2,236.7	0.1	0.6	1	1	1
08/02/2024 22:00	0.2	11.5	2,240.1	0.1	0.6	1	1	1
08/02/2024 23:00	0.2	11.5	2,240.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	11.6	2,229.0	0.1	16.4 #	24 #	24 #	24 #
Minimum:	0.2	11.5	2,184.9	0.1	0.6	1	1	1
Maximum:	0.3	11.7	2,260.7	0.2	1.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2024 00:00	0.2	11.5	2,238.4	0.1	0.6	1	1	1
08/03/2024 01:00	0.2	11.5	2,235.6	0.1	0.6	1	1	1
08/03/2024 02:00	0.3	11.8	2,165.9	0.1	0.9	1	1	1
08/03/2024 03:00	0.5	12.5	2,014.5	0.2	1.6	1	1	1
08/03/2024 04:00	0.6	12.6	2,008.0	0.3	1.9	1	1	1
08/03/2024 05:00	0.5	12.5	2,027.8	0.4	1.6	1	1	1
08/03/2024 06:00	0.6	12.7	1,968.4	0.4	1.9	1	1	1
08/03/2024 07:00	0.6	12.7	1,975.9	0.4	1.9	1	1	1
08/03/2024 08:00	0.7	12.6	1,979.7	0.4	2.2	1	1	1
08/03/2024 09:00	0.6	12.6	1,988.9	0.4	1.9	1	1	1
08/03/2024 10:00	0.6	12.6	1,993.7	0.4	1.9	1	1	1
08/03/2024 11:00	0.5	12.5	1,998.6	0.4	1.6	1	1	1
08/03/2024 12:00	0.5	12.5	1,997.0	0.4	1.6	1	1	1
08/03/2024 13:00	0.5	12.5	2,000.2	0.4	1.6	1	1	1
08/03/2024 14:00	0.5	12.2	2,043.5	0.4	1.6	1	1	1
08/03/2024 15:00	0.4	12.3	2,031.1	0.3	1.2	1	1	1
08/03/2024 16:00	0.4	12.2	2,044.8	0.3	1.2	1	1	1
08/03/2024 17:00	0.3	11.9	2,123.2	0.3	0.9	1	1	1
08/03/2024 18:00	0.2	11.6	2,198.4	0.2	0.6	1	1	1
08/03/2024 19:00	0.2	11.7	2,182.3	0.1	0.6	1	1	1
08/03/2024 20:00	0.2	11.8	2,155.9	0.1	0.6	1	1	1
08/03/2024 21:00	0.3	11.9	2,143.2	0.1	0.9	1	1	1
08/03/2024 22:00	0.3	12.0	2,125.4	0.2	0.9	1	1	1
08/03/2024 23:00	0.2	11.6	2,213.3	0.2	0.6	1	1	1
Average/Sum#:	0.4	12.2	2,077.2	0.3	30.9 #	24 #	24 #	24 #
Minimum:	0.2	11.5	1,968.4	0.1	0.6	1	1	1
Maximum:	0.7	12.7	2,238.4	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2024 00:00	0.4	12.5	1,999.9	0.2	1.3	1	1	1
08/04/2024 01:00	0.5	12.5	2,012.4	0.3	1.6	1	1	1
08/04/2024 02:00	0.6	12.7	1,951.1	0.4	1.9	1	1	1
08/04/2024 03:00	0.3	13.8	1,718.2	0.3	1.0	1	1	0
08/04/2024 04:00	0.4	13.7	1,744.7	0.3	1.3	1	1	0
08/04/2024 05:00	0.5	13.7	1,745.0	0.3	1.6	1	1	0
08/04/2024 06:00	0.4	13.8	1,713.1	0.3	1.3	1	1	0
08/04/2024 07:00	0.4	13.8	1,595.9	0.3	1.2	1	1	0
08/04/2024 08:00	0.5	13.8	1,599.6	0.3	1.5	1	1	0
08/04/2024 09:00	0.5	13.8	1,466.3	0.4	1.4	1	1	0
08/04/2024 10:00	0.4	13.8	1,604.6	0.4	1.2	1	1	0
08/04/2024 11:00	0.4	13.7	1,666.6	0.3	1.2	1	1	0
08/04/2024 12:00	0.4	13.8	1,538.3	0.3	1.1	1	1	1
08/04/2024 13:00	0.6	12.3	2,027.1	0.3	1.9	1	1	1
08/04/2024 14:00	0.5	12.1	2,047.0	0.3	1.5	1	1	1
08/04/2024 15:00	0.4	12.1	2,043.5	0.3	1.2	1	1	1
08/04/2024 16:00	0.3	11.9	2,086.0	0.3	0.9	1	1	1
08/04/2024 17:00	0.2	11.5	2,174.8	0.2	0.6	1	1	1
08/04/2024 18:00	0.3	11.5	2,171.5	0.2	0.9	1	1	1
08/04/2024 19:00	0.3	12.0	2,085.4	0.2	0.9	1	1	1
08/04/2024 20:00	0.3	11.6	2,201.7	0.2	0.9	1	1	1
08/04/2024 21:00	0.3	11.5	2,220.0	0.2	0.9	1	1	1
08/04/2024 22:00	0.3	11.5	2,231.1	0.2	0.9	1	1	1
08/04/2024 23:00	0.3	11.5	2,240.4	0.2	0.9	1	1	1
Average/Sum#:	0.4	12.7	1,911.8	0.3	29.1 #	24 #	24 #	15 #
Minimum:	0.2	11.5	1,466.3	0.2	0.6	1	1	0
Maximum:	0.6	13.8	2,240.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2024 00:00	0.3	11.5	2,240.8	0.2	0.9	1	1	1
08/05/2024 01:00	0.3	11.7	2,224.8	0.2	1.0	1	1	1
08/05/2024 02:00	0.3	11.8	2,207.4	0.2	1.0	1	1	1
08/05/2024 03:00	0.3	11.9	2,194.3	0.2	1.0	1	1	1
08/05/2024 04:00	0.3	11.6	2,262.5	0.2	1.0	1	1	1
08/05/2024 05:00	0.3	11.6	2,264.3	0.2	1.0	1	1	1
08/05/2024 06:00	0.5	12.4	2,101.9	0.2	1.6	1	1	1
08/05/2024 07:00	0.7	12.8	1,968.0	0.3	2.2	1	1	1
08/05/2024 08:00	0.8	12.8	1,950.1	0.5	2.5	1	1	1
08/05/2024 09:00	0.7	12.8	1,956.1	0.5	2.2	1	1	1
08/05/2024 10:00	0.6	12.7	1,965.3	0.5	1.9	1	1	1
08/05/2024 11:00	0.6	12.5	2,009.5	0.4	1.9	1	1	1
08/05/2024 12:00	0.5	12.3	2,048.3	0.4	1.6	1	1	1
08/05/2024 13:00	0.5	12.3	2,046.5	0.3	1.6	1	1	1
08/05/2024 14:00	0.3	11.6	2,184.4	0.3	0.9	1	1	1
08/05/2024 15:00	0.4	12.2	2,045.2	0.3	1.2	1	1	1
08/05/2024 16:00	0.5	12.4	2,001.6	0.3	1.6	1	1	1
08/05/2024 17:00	0.5	12.3	2,027.7	0.3	1.6	1	1	1
08/05/2024 18:00	0.3	11.8	2,131.0	0.3	0.9	1	1	1
08/05/2024 19:00	0.5	12.5	2,002.2	0.3	1.6	1	1	1
08/05/2024 20:00	0.3	11.6	2,216.1	0.3	0.9	1	1	1
08/05/2024 21:00	0.3	11.5	2,230.5	0.3	0.9	1	1	1
08/05/2024 22:00	0.3	11.5	2,231.7	0.2	0.9	1	1	1
08/05/2024 23:00	0.3	11.7	2,211.1	0.2	1.0	1	1	1
Average/Sum#:	0.4	12.1	2,113.4	0.3	32.9 #	24 #	24 #	24 #
Minimum:	0.3	11.5	1,950.1	0.2	0.9	1	1	1
Maximum:	0.8	12.8	2,264.3	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2024 00:00	0.4	12.5	2,034.1	0.2	1.3	1	1	1
08/06/2024 01:00	0.7	12.9	1,959.5	0.3	2.3	1	1	1
08/06/2024 02:00	0.7	12.9	1,951.3	0.4	2.3	1	1	1
08/06/2024 03:00	0.7	12.9	1,952.1	0.5	2.3	1	1	1
08/06/2024 04:00	0.5	12.2	2,124.8	0.4	1.6	1	1	1
08/06/2024 05:00	0.4	12.0	2,190.2	0.4	1.3	1	1	1
08/06/2024 06:00	0.5	12.6	2,055.4	0.3	1.6	1	1	1
08/06/2024 07:00	0.7	12.9	1,952.6	0.4	2.3	1	1	1
08/06/2024 08:00	0.6	12.9	1,951.8	0.4	1.9	1	1	1
08/06/2024 09:00	0.6	12.8	1,957.5	0.4	1.9	1	1	1
08/06/2024 10:00	0.6	12.7	1,965.4	0.4	1.9	1	1	1
08/06/2024 11:00	0.6	12.7	1,974.3	0.4	1.9	1	1	1
08/06/2024 12:00	0.5	12.6	1,984.8	0.4	1.6	1	1	1
08/06/2024 13:00	0.5	12.5	1,989.0	0.4	1.6	1	1	1
08/06/2024 14:00	0.5	12.5	1,993.7	0.4	1.6	1	1	1
08/06/2024 15:00	0.5	12.5	1,998.0	0.4	1.6	1	1	1
08/06/2024 16:00	0.4	12.1	2,084.9	0.4	1.3	1	1	1
08/06/2024 17:00	0.3	11.8	2,143.8	0.3	0.9	1	1	1
08/06/2024 18:00	0.3	11.5	2,196.2	0.2	0.9	1	1	1
08/06/2024 19:00	0.3	11.7	2,164.5	0.2	0.9	1	1	1
08/06/2024 20:00	0.3	12.0	2,111.5	0.2	0.9	1	1	1
08/06/2024 21:00	0.3	11.9	2,130.1	0.2	0.9	1	1	1
08/06/2024 22:00	0.3	11.8	2,171.1	0.2	0.9	1	1	1
08/06/2024 23:00	0.5	12.4	2,032.3	0.2	1.6	1	1	1
Average/Sum#:	0.5	12.4	2,044.5	0.3	37.3 #	24 #	24 #	24 #
Minimum:	0.3	11.5	1,951.3	0.2	0.9	1	1	1
Maximum:	0.7	12.9	2,196.2	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2024 00:00	0.6	12.6	2,005.7	0.3	1.9	1	1	1
08/07/2024 01:00	0.3	11.8	2,197.5	0.3	1.0	1	1	1
08/07/2024 02:00	0.4	12.3	2,062.8	0.3	1.3	1	1	1
08/07/2024 03:00	0.6	12.8	1,956.0	0.3	1.9	1	1	1
08/07/2024 04:00	0.6	12.8	1,967.1	0.4	1.9	1	1	1
08/07/2024 05:00	0.5	12.2	2,106.8	0.4	1.6	1	1	1
08/07/2024 06:00	0.4	12.3	2,128.3	0.3	1.3	1	1	1
08/07/2024 07:00	0.6	12.8	1,959.1	0.3	1.9	1	1	1
08/07/2024 08:00	0.7	12.8	1,962.8	0.4	2.2	1	1	1
08/07/2024 09:00	0.7	12.8	1,969.1	0.5	2.2	1	1	1
08/07/2024 10:00	0.7	12.7	1,979.4	0.5	2.2	1	1	1
08/07/2024 11:00	0.6	12.5	1,987.9	0.5	1.9	1	1	1
08/07/2024 12:00	0.6	12.4	1,998.3	0.4	1.9	1	1	1
08/07/2024 13:00	0.5	12.3	2,029.2	0.4	1.6	1	1	1
08/07/2024 14:00	0.5	12.1	2,070.8	0.3	1.6	1	1	1
08/07/2024 15:00	0.5	12.2	2,041.6	0.3	1.5	1	1	1
08/07/2024 16:00	0.5	12.2	2,037.4	0.3	1.5	1	1	1
08/07/2024 17:00	0.4	11.7	2,145.9	0.3	1.2	1	1	1
08/07/2024 18:00	0.3	11.5	2,191.9	0.3	0.9	1	1	1
08/07/2024 19:00	0.3	11.7	2,162.0	0.2	0.9	1	1	1
08/07/2024 20:00	0.4	11.9	2,118.3	0.2	1.2	1	1	1
08/07/2024 21:00	0.4	12.2	2,062.5	0.3	1.3	1	1	1
08/07/2024 22:00	0.6	12.7	1,968.4	0.3	1.9	1	1	1
08/07/2024 23:00	0.4	11.8	2,183.4	0.3	1.3	1	1	1
Average/Sum#:	0.5	12.3	2,053.8	0.3	38.1 #	24 #	24 #	24 #
Minimum:	0.3	11.5	1,956.0	0.2	0.9	1	1	1
Maximum:	0.7	12.8	2,197.5	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2024 00:00	0.3	11.6	2,242.0	0.3	1.0	1	1	1
08/08/2024 01:00	0.4	12.2	2,090.8	0.3	1.3	1	1	1
08/08/2024 02:00	0.3	13.8	1,658.7	0.2	0.9	1	1	0
08/08/2024 03:00	0.4	13.8	1,695.2	0.3	1.3	1	1	0
08/08/2024 04:00	0.4	13.8	1,665.4	0.3	1.2	1	1	0
08/08/2024 05:00	0.3	13.8	1,732.3	0.3	1.0	1	1	0
08/08/2024 06:00	0.3	13.8	1,728.1	0.2	1.0	1	1	0
08/08/2024 07:00	0.4	13.8	1,668.4	0.2	1.2	1	1	0
08/08/2024 08:00	0.3	13.8	1,564.0	0.2	0.9	1	1	0
08/08/2024 09:00	0.3	13.8	1,556.1	0.2	0.9	1	1	0
08/08/2024 10:00	0.4	13.8	1,550.2	0.2	1.2	1	1	0
08/08/2024 11:00	0.4	13.9	1,340.5	0.3	1.0	1	1	0
08/08/2024 12:00	0.3	14.0	1,328.2	0.3	0.8	1	1	0
08/08/2024 13:00	0.3	14.0	1,330.7	0.3	0.8	1	1	0
08/08/2024 14:00	0.4	13.8	1,517.8	0.3	1.1	1	1	1
08/08/2024 15:00	0.7	12.2	2,021.9	0.4	2.1	1	1	1
08/08/2024 16:00	0.5	12.1	2,046.9	0.4	1.5	1	1	1
08/08/2024 17:00	0.4	12.1	2,062.1	0.4	1.2	1	1	1
08/08/2024 18:00	0.3	11.5	2,183.3	0.3	0.9	1	1	1
08/08/2024 19:00	0.3	11.6	2,161.9	0.2	0.9	1	1	1
08/08/2024 20:00	0.4	11.9	2,120.8	0.2	1.2	1	1	1
08/08/2024 21:00	0.4	12.1	2,085.5	0.3	1.3	1	1	1
08/08/2024 22:00	0.5	12.4	2,024.3	0.3	1.6	1	1	1
08/08/2024 23:00	0.5	12.2	2,080.5	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.0	1,810.7	0.3	27.9 #	24 #	24 #	12 #
Minimum:	0.3	11.5	1,328.2	0.2	0.8	1	1	0
Maximum:	0.7	14.0	2,242.0	0.4	2.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2024 00:00	0.4	13.8	1,601.0	0.3	1.2	1	1	1
08/09/2024 01:00	0.4	13.8	1,696.1	0.3	1.3	1	1	0
08/09/2024 02:00	0.4	13.8	1,724.0	0.3	1.3	1	1	0
08/09/2024 03:00	0.4	13.8	1,709.1	0.3	1.3	1	1	0
08/09/2024 04:00	0.4	13.8	1,743.7	0.3	1.3	1	1	0
08/09/2024 05:00	0.4	13.8	1,743.5	0.3	1.3	1	1	0
08/09/2024 06:00	0.4	13.8	1,708.3	0.3	1.3	1	1	0
08/09/2024 07:00	0.4	13.8	1,551.5	0.3	1.2	1	1	0
08/09/2024 08:00	0.4	13.9	1,455.8	0.3	1.1	1	1	0
08/09/2024 09:00	0.4	13.9	1,529.7	0.3	1.2	1	1	0
08/09/2024 10:00	0.4	13.9	1,561.7	0.3	1.2	1	1	0
08/09/2024 11:00	0.4	13.9	1,580.2	0.3	1.2	1	1	0
08/09/2024 12:00	0.4	13.8	1,637.8	0.3	1.2	1	1	0
08/09/2024 13:00	0.4	13.8	1,693.4	0.3	1.3	1	1	0
08/09/2024 14:00	0.5	13.7	1,594.2	0.3	1.5	1	1	1
08/09/2024 15:00	0.7	12.3	2,011.3	0.4	2.2	1	1	1
08/09/2024 16:00	0.5	12.1	2,064.4	0.4	1.5	1	1	1
08/09/2024 17:00	0.4	11.7	2,132.2	0.4	1.2	1	1	1
08/09/2024 18:00	0.3	11.5	2,187.3	0.3	0.9	1	1	1
08/09/2024 19:00	0.3	11.8	2,143.2	0.2	0.9	1	1	1
08/09/2024 20:00	0.4	12.0	2,081.7	0.2	1.2	1	1	1
08/09/2024 21:00	12.1	15.4	689.3	0.0	5.6	1	0	0
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.9	13.4	1,720.0	0.3	32.4 #	22 #	21 #	8 #
Minimum:	0.3	11.5	689.3	0.2	0.9	0	0	0
Maximum:	12.1	15.4	2,187.3	0.4	5.6	1	1	1
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2024 13:00	42.5	17.5	357.7	0.0	41.4	1	0	0
08/10/2024 14:00	18.5	17.0	439.5	0.0	27.5	1	0	0
08/10/2024 15:00	17.6	15.3	977.0	0.0	40.6	1	0	0
08/10/2024 16:00	0.5	13.7	1,670.0	0.0	1.5	1	1	1
08/10/2024 17:00	0.8	12.2	2,089.4	0.0	2.5	1	1	1
08/10/2024 18:00	0.6	11.8	2,146.9	0.4	1.9	1	1	1
08/10/2024 19:00	0.5	11.8	2,134.4	0.4	1.5	1	1	1
08/10/2024 20:00	0.5	11.8	2,141.0	0.3	1.6	1	1	1
08/10/2024 21:00	0.6	12.1	2,083.3	0.3	1.9	1	1	1
08/10/2024 22:00	0.7	12.5	1,987.7	0.4	2.2	1	1	1
08/10/2024 23:00	21.7	15.6	612.9	0.0	8.3	1	0	0
Average/Sum#:	9.5	13.8	1,512.7	0.4	130.9 #	11 #	7 #	7 #
Minimum:	0.5	11.8	357.7	0.3	1.5	0	0	0
Maximum:	42.5	17.5	2,146.9	0.4	41.4	1	1	1
%SI	54.17	54.17	54.17	79.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/12/2024 18:00	78.9	17.5	333.2	0.0	63.3	1	0	0
08/12/2024 19:00	41.1	16.2	592.2	0.0	68.4	1	0	0
08/12/2024 20:00	3.1	13.9	1,495.0	0.0	8.7	1	0	0
08/12/2024 21:00	0.4	13.8	1,711.5	0.0	1.3	1	1	0
08/12/2024 22:00	0.4	13.8	1,680.8	0.0	1.3	1	1	0
08/12/2024 23:00	0.4	13.8	1,713.8	0.3	1.3	1	1	0
Average/Sum#:	20.7	14.8	1,254.4	0.3	144.3 #	6 #	3 #	0 #
Minimum:	0.4	13.8	333.2	0.3	1.3	0	0	0
Maximum:	78.9	17.5	1,713.8	0.3	68.4	1	1	0
%SI	75.00	75.00	75.00	95.83	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2024 00:00	0.4	13.8	1,676.4	0.3	1.2	1	1	0
08/13/2024 01:00	0.4	13.9	1,345.3	0.3	1.0	1	1	0
08/13/2024 02:00	17.6	15.5	642.5	0.0	6.9	1	0	0
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2024 16:00	41.6	17.5	352.3	0.0	43.8	1	0	0
08/13/2024 17:00	20.0	17.1	422.6	0.0	29.4	1	0	0
08/13/2024 18:00	27.2	15.4	926.0	0.0	60.5	1	0	0
08/13/2024 19:00	0.8	13.2	1,792.4	0.0	2.5	1	1	1
08/13/2024 20:00	0.8	12.5	2,024.2	0.0	2.5	1	1	1
08/13/2024 21:00	0.7	12.3	2,060.0	0.6	2.2	1	1	1
08/13/2024 22:00	0.6	13.2	1,678.4	0.5	1.7	1	1	1
08/13/2024 23:00	0.4	13.8	1,612.0	0.4	1.2	1	1	0
Average/Sum#:	10.0	14.4	1,321.1	0.4	152.9 #	11 #	7 #	4 #
Minimum:	0.4	12.3	352.3	0.3	1.0	0	0	0
Maximum:	41.6	17.5	2,060.0	0.6	60.5	1	1	1
%SI	54.17	54.17	54.17	79.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2024 00:00	0.4	13.9	1,649.5	0.4	1.2	1	1	0
08/14/2024 01:00	0.4	13.9	1,535.2	0.3	1.2	1	1	0
08/14/2024 02:00	10.4	14.9	949.4	0.0	9.8	1	0	0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2024 10:00	36.4	17.7	328.6	0.0	23.2	1	0	0
08/14/2024 11:00	25.4	15.7	808.1	0.0	52.1	1	0	0
08/14/2024 12:00	0.3	13.8	1,518.3	0.0	0.8	1	1	0
08/14/2024 13:00	0.3	13.8	1,562.6	0.0	0.9	1	1	0
08/14/2024 14:00	0.3	13.8	1,518.3	0.2	0.8	1	1	0
08/14/2024 15:00	0.3	13.9	1,457.6	0.2	0.8	1	1	0
08/14/2024 16:00	0.3	13.8	1,622.1	0.2	0.9	1	1	0
08/14/2024 17:00	0.3	13.6	1,725.8	0.2	0.9	1	1	0
08/14/2024 18:00	0.3	13.6	1,730.9	0.2	0.9	1	1	0
08/14/2024 19:00	0.3	13.6	1,742.8	0.2	0.9	1	1	0
08/14/2024 20:00	0.3	13.7	1,730.7	0.2	1.0	1	1	0
08/14/2024 21:00	0.3	13.8	1,732.4	0.2	1.0	1	1	0
08/14/2024 22:00	0.3	13.8	1,740.1	0.2	1.0	1	1	0
08/14/2024 23:00	0.3	13.7	1,771.7	0.2	1.0	1	1	0
Average/Sum#:	4.5	14.2	1,477.9	0.2	98.4 #	17 #	14 #	0 #
Minimum:	0.3	13.6	328.6	0.2	0.8	0	0	0
Maximum:	36.4	17.7	1,771.7	0.4	52.1	1	1	0
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2024 00:00	8.7	14.7	1,126.3	0.0	9.8	1	0	0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2024 12:00	28.4	17.5	361.5	0.0	27.9	1	0	0
08/15/2024 13:00	17.5	17.1	424.6	0.0	25.8	1	0	0
08/15/2024 14:00	22.1	15.4	890.0	0.0	47.2	1	0	0
08/15/2024 15:00	0.3	13.8	1,605.1	0.0	0.9	1	1	0
08/15/2024 16:00	0.3	13.7	1,699.3	0.0	0.9	1	1	0
08/15/2024 17:00	0.3	13.8	1,687.7	0.2	0.9	1	1	0
08/15/2024 18:00	0.3	13.8	1,467.7	0.2	0.8	1	1	0
08/15/2024 19:00	0.5	13.2	1,795.8	0.3	1.5	1	1	1
08/15/2024 20:00	0.3	11.9	2,113.3	0.3	0.9	1	1	1
08/15/2024 21:00	0.3	13.8	1,688.9	0.3	0.9	1	1	0
08/15/2024 22:00	0.2	13.8	1,672.6	0.2	0.6	1	1	0
08/15/2024 23:00	0.3	13.8	1,692.1	0.2	0.9	1	1	0
Average/Sum#:	6.1	14.3	1,401.9	0.2	119.0 #	13 #	9 #	2 #
Minimum:	0.2	11.9	361.5	0.2	0.6	0	0	0
Maximum:	28.4	17.5	2,113.3	0.3	47.2	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2024 00:00	0.2	13.7	1,734.5	0.2	0.6	1	1	0
08/16/2024 01:00	0.3	13.8	1,681.9	0.2	0.9	1	1	0
08/16/2024 02:00	10.3	14.9	1,041.7	0.0	10.6	1	0	0
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2024 12:00	23.9	17.1	449.2	0.0	34.7	1	0	0
08/16/2024 13:00	18.0	14.4	1,257.1	0.0	46.0	1	0	0
08/16/2024 14:00	0.3	14.0	1,342.4	0.0	0.8	1	1	0
08/16/2024 15:00	0.4	13.8	1,574.1	0.0	1.2	1	1	1
08/16/2024 16:00	0.5	12.0	2,101.1	0.3	1.6	1	1	1
08/16/2024 17:00	0.3	12.0	2,086.7	0.3	0.9	1	1	1
08/16/2024 18:00	0.3	11.8	2,134.0	0.2	0.9	1	1	1
08/16/2024 19:00	0.3	12.0	2,104.9	0.2	0.9	1	1	1
08/16/2024 20:00	0.3	11.8	2,145.9	0.2	0.9	1	1	1
08/16/2024 21:00	0.3	12.0	2,116.9	0.2	0.9	1	1	1
08/16/2024 22:00	0.2	11.9	2,173.2	0.2	0.6	1	1	1
08/16/2024 23:00	0.3	11.9	2,178.1	0.2	1.0	1	1	1
Average/Sum#:	3.7	13.1	1,741.4	0.2	102.5 #	15 #	12 #	9 #
Minimum:	0.2	11.8	449.2	0.2	0.6	0	0	0
Maximum:	23.9	17.1	2,178.1	0.3	46.0	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2024 00:00	0.3	12.0	2,143.2	0.2	1.0	1	1	1
08/17/2024 01:00	0.6	12.8	1,978.6	0.3	1.9	1	1	1
08/17/2024 02:00	1.0	13.0	1,933.3	0.4	3.2	1	1	1
08/17/2024 03:00	1.2	13.0	1,926.3	0.7	3.9	1	1	1
08/17/2024 04:00	0.6	12.7	2,003.0	0.7	1.9	1	1	1
08/17/2024 05:00	0.5	12.7	2,012.6	0.6	1.6	1	1	1
08/17/2024 06:00	0.0	0.0	1,213.8	0.0	0.0	1	0	1
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2024 14:00	11.8	18.8	173.2	0.0	2.3	1	0	0
08/17/2024 15:00	25.5	15.9	766.2	0.0	51.6	1	0	0
08/17/2024 16:00	0.3	13.8	1,585.7	0.0	0.9	1	1	0
08/17/2024 17:00	0.7	12.9	1,916.8	0.0	2.2	1	1	1
08/17/2024 18:00	0.6	12.5	2,022.9	0.4	1.9	1	1	1
08/17/2024 19:00	0.6	12.7	1,987.3	0.4	1.9	1	1	1
08/17/2024 20:00	0.7	12.7	1,983.6	0.4	2.2	1	1	1
08/17/2024 21:00	0.7	12.8	1,973.8	0.5	2.3	1	1	1
08/17/2024 22:00	0.7	12.9	1,951.7	0.5	2.3	1	1	1
08/17/2024 23:00	0.3	13.8	1,724.1	0.4	1.0	1	1	1
Average/Sum#:	2.9	13.4	1,723.3	0.5	82.1 #	17 #	14 #	14 #
Minimum:	0.3	12.0	173.2	0.2	0.9	0	0	0
Maximum:	25.5	18.8	2,143.2	0.7	51.6	1	1	1
%SI	33.33	33.33	29.17	50.00	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2024 00:00	0.7	12.9	1,967.1	0.4	2.3	1	1	1
08/18/2024 01:00	0.7	12.9	1,930.4	0.4	2.2	1	1	1
08/18/2024 02:00	19.3	15.8	571.0	0.0	6.6	1	0	0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2024 14:00	38.9	17.7	353.3	0.0	32.3	1	0	0
08/18/2024 15:00	19.7	15.1	993.2	0.0	44.6	1	0	0
08/18/2024 16:00	0.3	13.8	1,648.4	0.0	0.9	1	1	0
08/18/2024 17:00	0.3	13.7	1,668.3	0.0	0.9	1	1	1
08/18/2024 18:00	0.5	12.4	2,081.2	0.2	1.6	1	1	1
08/18/2024 19:00	0.2	11.6	2,240.9	0.2	0.6	1	1	1
08/18/2024 20:00	0.2	11.7	2,232.8	0.2	0.6	1	1	1
08/18/2024 21:00	0.2	11.7	2,217.7	0.1	0.6	1	1	1
08/18/2024 22:00	0.3	12.1	2,134.5	0.1	1.0	1	1	1
08/18/2024 23:00	0.3	12.1	2,112.1	0.2	1.0	1	1	1
Average/Sum#:	6.3	13.3	1,703.9	0.2	95.2 #	13 #	10 #	9 #
Minimum:	0.2	11.6	353.3	0.1	0.6	0	0	0
Maximum:	38.9	17.7	2,240.9	0.4	44.6	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2024 00:00	20.6	15.7	571.3	0.0	6.9	1	0	0
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2024 07:00	28.3	16.8	578.7	0.0	41.2	1	0	0
08/19/2024 08:00	0.2	13.8	1,512.1	0.0	0.6	1	0	0
08/19/2024 09:00	0.2	13.9	1,545.4	0.0	0.6	1	1	0
08/19/2024 10:00	0.2	13.9	1,558.0	0.0	0.6	1	1	0
08/19/2024 11:00	0.3	13.8	1,559.4	0.2	0.9	1	1	0
08/19/2024 12:00	0.3	13.8	1,661.6	0.2	0.9	1	1	0
08/19/2024 13:00	0.2	13.9	1,453.5	0.2	0.5	1	1	0
08/19/2024 14:00	0.3	13.8	1,643.3	0.2	0.9	1	1	0
08/19/2024 15:00	0.3	13.9	1,513.1	0.2	0.9	1	1	0
08/19/2024 16:00	0.5	12.6	1,960.7	0.3	1.6	1	1	1
08/19/2024 17:00	0.5	12.5	2,038.3	0.4	1.6	1	1	1
08/19/2024 18:00	0.2	11.7	2,192.8	0.3	0.6	1	1	1
08/19/2024 19:00	0.5	12.6	2,004.3	0.3	1.6	1	1	1
08/19/2024 20:00	1.0	12.9	1,926.0	0.4	3.2	1	1	1
08/19/2024 21:00	0.3	11.7	2,211.7	0.4	1.0	1	1	1
08/19/2024 22:00	0.3	12.0	2,147.1	0.4	1.0	1	1	1
08/19/2024 23:00	0.8	12.8	1,944.4	0.3	2.5	1	1	1
Average/Sum#:	3.1	13.5	1,667.9	0.3	67.1 #	18 #	15 #	8 #
Minimum:	0.2	11.7	571.3	0.2	0.5	0	0	0
Maximum:	28.3	16.8	2,211.7	0.4	41.2	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2024 00:00	0.9	13.0	1,890.7	0.5	2.8	1	1	1
08/20/2024 01:00	18.4	15.5	675.7	0.0	7.6	1	0	0
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2024 13:00	20.6	17.4	386.1	0.0	27.6	1	0	0
08/20/2024 14:00	23.3	14.8	1,049.3	0.0	52.9	1	0	0
08/20/2024 15:00	0.2	14.0	1,327.6	0.0	0.5	1	1	0
08/20/2024 16:00	0.3	13.9	1,554.9	0.0	0.9	1	1	1
08/20/2024 17:00	0.5	12.1	2,112.1	0.3	1.6	1	1	1
08/20/2024 18:00	0.5	12.4	2,009.6	0.3	1.6	1	1	1
08/20/2024 19:00	1.0	13.0	1,898.4	0.4	3.2	1	1	1
08/20/2024 20:00	1.1	13.0	1,893.0	0.6	3.5	1	1	1
08/20/2024 21:00	0.5	12.4	2,052.9	0.6	1.6	1	1	1
08/20/2024 22:00	0.3	12.1	2,103.2	0.4	0.9	1	1	1
08/20/2024 23:00	0.3	12.3	2,075.7	0.2	1.0	1	1	1
Average/Sum#:	5.2	13.5	1,617.6	0.4	105.7 #	13 #	10 #	9 #
Minimum:	0.2	12.1	386.1	0.2	0.5	0	0	0
Maximum:	23.3	17.4	2,112.1	0.6	52.9	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	0.5	12.7	1,977.0	0.3	1.6	1	1	1
08/21/2024 01:00	0.8	13.0	1,932.7	0.4	2.6	1	1	1
08/21/2024 02:00	0.3	13.7	1,698.5	0.4	0.9	1	1	1
08/21/2024 03:00	0.2	13.8	1,712.4	0.3	0.6	1	1	0
08/21/2024 04:00	0.3	13.8	1,722.8	0.2	1.0	1	1	0
08/21/2024 05:00	0.3	13.8	1,733.9	0.2	1.0	1	1	0
08/21/2024 06:00	0.2	13.8	1,729.8	0.2	0.6	1	1	0
08/21/2024 07:00	0.2	13.8	1,615.7	0.2	0.6	1	1	0
08/21/2024 08:00	0.2	13.8	1,608.9	0.2	0.6	1	1	0
08/21/2024 09:00	0.2	13.9	1,324.7	0.2	0.5	1	1	0
08/21/2024 10:00	0.2	13.9	1,531.7	0.2	0.6	1	1	0
08/21/2024 11:00	0.2	13.9	1,575.6	0.2	0.6	1	1	0
08/21/2024 12:00	0.2	13.9	1,650.3	0.2	0.6	1	1	0
08/21/2024 13:00	0.3	13.7	1,732.7	0.2	1.0	1	1	0
08/21/2024 14:00	0.3	13.7	1,744.6	0.2	1.0	1	1	0
08/21/2024 15:00	0.3	13.7	1,724.3	0.2	0.9	1	1	0
08/21/2024 16:00	0.3	13.8	1,607.4	0.2	0.9	1	1	0
08/21/2024 17:00	0.5	12.2	2,081.1	0.2	1.6	1	1	1
08/21/2024 18:00	0.2	11.6	2,209.4	0.2	0.6	1	1	1
08/21/2024 19:00	0.2	11.7	2,187.9	0.2	0.6	1	1	1
08/21/2024 20:00	0.2	12.0	2,161.6	0.1	0.6	1	1	1
08/21/2024 21:00	0.2	11.8	2,198.3	0.1	0.6	1	1	1
08/21/2024 22:00	0.2	11.9	2,170.0	0.1	0.6	1	1	1
08/21/2024 23:00	0.3	12.1	2,120.9	0.1	1.0	1	1	1
Average/Sum#:	0.3	13.2	1,823.0	0.2	21.2 #	24 #	24 #	10 #
Minimum:	0.2	11.6	1,324.7	0.1	0.5	1	1	0
Maximum:	0.8	13.9	2,209.4	0.4	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2024 00:00	0.4	12.7	2,003.4	0.2	1.3	1	1	1
08/22/2024 01:00	0.5	12.8	1,978.3	0.3	1.6	1	1	1
08/22/2024 02:00	0.5	12.9	1,976.8	0.4	1.6	1	1	1
08/22/2024 03:00	0.5	12.9	1,975.8	0.4	1.6	1	1	1
08/22/2024 04:00	0.6	12.9	1,982.0	0.4	2.0	1	1	1
08/22/2024 05:00	0.4	12.2	2,120.5	0.4	1.3	1	1	1
08/22/2024 06:00	0.0	0.0	665.1	0.0	0.0	1	0	0
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	12.7	1,814.6	0.4	9.4 #	7 #	6 #	6 #
Minimum:	0.4	12.2	665.1	0.2	1.3	0	0	0
Maximum:	0.6	12.9	2,120.5	0.4	2.0	1	1	1
%SI	75.00	75.00	70.83	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2024 00:00	200.4	18.5	122.6	0.0	44.6	1	0	0
08/26/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2024 07:00	51.4	17.5	369.2	0.0	57.5	1	0	0
08/26/2024 08:00	19.7	0.0	1,279.0	0.0	15.9	1	0	0
08/26/2024 09:00	0.3	13.8	1,730.7	0.0	1.0	1	1	0
08/26/2024 10:00	0.3	13.8	1,721.4	0.0	1.0	1	1	0
08/26/2024 11:00	0.3	13.8	1,722.7	0.2	1.0	1	1	0
08/26/2024 12:00	0.5	13.1	1,859.3	0.3	1.6	1	1	1
08/26/2024 13:00	0.6	12.6	2,036.0	0.3	1.9	1	1	1
08/26/2024 14:00	0.5	12.3	2,070.0	0.4	1.6	1	1	1
08/26/2024 15:00	0.5	12.5	2,036.1	0.4	1.6	1	1	1
08/26/2024 16:00	0.3	12.0	2,145.3	0.3	1.0	1	1	1
08/26/2024 17:00	0.2	11.6	2,241.7	0.2	0.6	1	1	1
08/26/2024 18:00	0.2	11.4	2,269.5	0.1	0.6	1	1	1
08/26/2024 19:00	0.2	11.4	2,277.8	0.1	0.6	1	1	1
08/26/2024 20:00	0.2	11.7	2,235.2	0.1	0.6	1	1	1
08/26/2024 21:00	0.2	11.7	2,238.0	0.1	0.6	1	1	1
08/26/2024 22:00	0.2	11.8	2,211.5	0.1	0.6	1	1	1
08/26/2024 23:00	0.5	12.8	1,993.3	0.2	1.6	1	1	1
Average/Sum#:	15.4	13.1	1,808.9	0.2	118.0 #	18 #	15 #	12 #
Minimum:	0.2	11.4	122.6	0.1	0.6	0	0	0
Maximum:	200.4	18.5	2,277.8	0.4	57.5	1	1	1
%SI	25.00	29.17	25.00	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2024 00:00	0.6	12.9	1,982.9	0.3	2.0	1	1	1
08/27/2024 01:00	0.6	12.9	1,987.8	0.4	2.0	1	1	1
08/27/2024 02:00	0.6	12.9	1,988.3	0.4	2.0	1	1	1
08/27/2024 03:00	0.6	12.8	1,989.3	0.4	1.9	1	1	1
08/27/2024 04:00	0.6	12.9	1,973.2	0.4	2.0	1	1	1
08/27/2024 05:00	0.2	13.8	1,714.4	0.3	0.6	1	1	0
08/27/2024 06:00	0.2	13.8	1,696.5	0.3	0.6	1	1	0
08/27/2024 07:00	0.2	13.8	1,596.0	0.2	0.6	1	1	0
08/27/2024 08:00	0.2	13.9	1,314.7	0.2	0.5	1	1	0
08/27/2024 09:00	0.2	14.0	1,311.2	0.2	0.5	1	1	0
08/27/2024 10:00	0.2	14.0	1,315.7	0.2	0.5	1	1	0
08/27/2024 11:00	0.2	14.0	1,325.7	0.2	0.5	1	1	0
08/27/2024 12:00	0.3	13.9	1,610.3	0.2	0.9	1	1	0
08/27/2024 13:00	0.3	13.8	1,651.4	0.2	0.9	1	1	0
08/27/2024 14:00	0.3	13.7	1,714.5	0.2	0.9	1	1	0
08/27/2024 15:00	0.3	13.8	1,587.0	0.2	0.9	1	1	0
08/27/2024 16:00	0.5	12.6	1,930.9	0.3	1.5	1	1	1
08/27/2024 17:00	0.3	11.7	2,195.3	0.3	0.9	1	1	1
08/27/2024 18:00	0.2	11.9	2,175.9	0.2	0.6	1	1	1
08/27/2024 19:00	0.2	11.8	2,202.2	0.1	0.6	1	1	1
08/27/2024 20:00	0.2	11.7	2,222.7	0.1	0.6	1	1	1
08/27/2024 21:00	0.2	11.8	2,204.6	0.1	0.6	1	1	1
08/27/2024 22:00	0.3	12.3	2,093.2	0.1	1.0	1	1	1
08/27/2024 23:00	0.2	12.1	2,168.2	0.1	0.7	1	1	1
Average/Sum#:	0.3	13.0	1,831.3	0.2	23.8 #	24 #	24 #	13 #
Minimum:	0.2	11.7	1,311.2	0.1	0.5	1	1	0
Maximum:	0.6	14.0	2,222.7	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2024 00:00	0.3	12.3	2,114.2	0.2	1.0	1	1	1
08/28/2024 01:00	0.4	12.8	1,993.1	0.2	1.3	1	1	1
08/28/2024 02:00	0.4	12.8	1,991.8	0.3	1.3	1	1	1
08/28/2024 03:00	0.4	12.5	2,063.6	0.3	1.3	1	1	1
08/28/2024 04:00	0.2	12.0	2,187.0	0.2	0.6	1	1	1
08/28/2024 05:00	0.2	12.0	2,183.2	0.2	0.6	1	1	1
08/28/2024 06:00	0.3	12.6	2,053.3	0.1	1.0	1	1	1
08/28/2024 07:00	0.4	12.8	1,987.7	0.2	1.3	1	1	1
08/28/2024 08:00	0.4	12.6	1,996.1	0.3	1.3	1	1	1
08/28/2024 09:00	0.4	12.6	2,001.7	0.3	1.3	1	1	1
08/28/2024 10:00	0.4	12.6	2,009.8	0.3	1.3	1	1	1
08/28/2024 11:00	0.4	12.5	2,018.1	0.3	1.3	1	1	1
08/28/2024 12:00	0.4	12.4	2,032.0	0.3	1.3	1	1	1
08/28/2024 13:00	0.3	12.2	2,083.3	0.3	0.9	1	1	1
08/28/2024 14:00	0.3	12.2	2,064.2	0.2	0.9	1	1	1
08/28/2024 15:00	0.3	12.3	2,047.6	0.2	0.9	1	1	1
08/28/2024 16:00	0.3	12.2	2,073.3	0.2	0.9	1	1	1
08/28/2024 17:00	0.3	12.4	2,053.1	0.2	1.0	1	1	1
08/28/2024 18:00	0.2	12.0	2,136.2	0.2	0.6	1	1	1
08/28/2024 19:00	0.2	11.6	2,208.4	0.1	0.6	1	1	1
08/28/2024 20:00	0.2	12.0	2,114.4	0.1	0.6	1	1	1
08/28/2024 21:00	0.4	12.5	2,012.1	0.2	1.3	1	1	1
08/28/2024 22:00	0.4	12.6	2,001.2	0.2	1.3	1	1	1
08/28/2024 23:00	0.4	12.8	1,986.0	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.4	2,058.8	0.2	25.2 #	24 #	24 #	24 #
Minimum:	0.2	11.6	1,986.0	0.1	0.6	1	1	1
Maximum:	0.4	12.8	2,208.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2024 00:00	0.5	12.8	1,987.7	0.3	1.6	1	1	1
08/29/2024 01:00	0.4	12.8	1,985.2	0.3	1.3	1	1	1
08/29/2024 02:00	0.5	12.9	1,978.7	0.4	1.6	1	1	1
08/29/2024 03:00	0.5	12.8	1,981.6	0.4	1.6	1	1	1
08/29/2024 04:00	0.5	12.7	2,017.8	0.4	1.6	1	1	1
08/29/2024 05:00	0.5	12.8	1,979.8	0.4	1.6	1	1	1
08/29/2024 06:00	0.3	13.8	1,742.2	0.3	1.0	1	1	0
08/29/2024 07:00	0.3	13.8	1,542.6	0.3	0.9	1	1	0
08/29/2024 08:00	0.3	13.9	1,318.8	0.2	0.7	1	1	0
08/29/2024 09:00	0.3	14.0	1,319.4	0.3	0.8	1	1	0
08/29/2024 10:00	0.3	14.0	1,322.9	0.3	0.8	1	1	0
08/29/2024 11:00	0.3	14.0	1,330.1	0.3	0.8	1	1	0
08/29/2024 12:00	0.4	13.8	1,579.7	0.3	1.2	1	1	0
08/29/2024 13:00	0.4	13.8	1,673.9	0.3	1.2	1	1	0
08/29/2024 14:00	0.3	13.7	1,718.2	0.3	0.9	1	1	0
08/29/2024 15:00	0.4	13.8	1,538.1	0.3	1.1	1	1	1
08/29/2024 16:00	0.5	12.3	2,064.7	0.3	1.6	1	1	1
08/29/2024 17:00	0.4	12.0	2,128.8	0.3	1.3	1	1	1
08/29/2024 18:00	0.3	12.3	2,060.8	0.3	0.9	1	1	1
08/29/2024 19:00	0.3	11.9	2,180.6	0.2	1.0	1	1	1
08/29/2024 20:00	0.4	12.2	2,096.1	0.2	1.3	1	1	1
08/29/2024 21:00	0.4	12.4	2,055.3	0.3	1.3	1	1	1
08/29/2024 22:00	0.5	12.7	1,990.0	0.3	1.6	1	1	1
08/29/2024 23:00	0.5	12.7	1,987.2	0.4	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,815.8	0.3	29.3 #	24 #	24 #	15 #
Minimum:	0.3	11.9	1,318.8	0.2	0.7	1	1	0
Maximum:	0.5	14.0	2,180.6	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2024 00:00	0.5	12.8	1,981.1	0.4	1.6	1	1	1
08/30/2024 01:00	0.5	12.9	1,979.5	0.4	1.6	1	1	1
08/30/2024 02:00	0.5	12.9	1,980.2	0.4	1.6	1	1	1
08/30/2024 03:00	0.6	12.9	1,981.5	0.4	2.0	1	1	1
08/30/2024 04:00	0.5	12.6	2,052.7	0.4	1.6	1	1	1
08/30/2024 05:00	0.4	12.4	2,096.4	0.4	1.3	1	1	1
08/30/2024 06:00	0.4	12.6	2,050.6	0.3	1.3	1	1	1
08/30/2024 07:00	0.3	13.8	1,395.7	0.3	0.8	1	1	1
08/30/2024 08:00	0.3	13.9	1,375.1	0.3	0.8	1	1	0
08/30/2024 09:00	0.3	13.9	1,323.9	0.3	0.7	1	1	0
08/30/2024 10:00	0.3	13.9	1,331.8	0.3	0.8	1	1	0
08/30/2024 11:00	0.3	13.9	1,370.2	0.3	0.8	1	1	0
08/30/2024 12:00	0.3	14.0	1,341.5	0.3	0.8	1	1	0
08/30/2024 13:00	0.3	13.8	1,671.9	0.3	0.9	1	1	0
08/30/2024 14:00	0.4	13.5	1,720.8	0.3	1.2	1	1	1
08/30/2024 15:00	0.4	12.2	2,072.7	0.3	1.3	1	1	1
08/30/2024 16:00	0.3	12.1	2,103.4	0.3	0.9	1	1	1
08/30/2024 17:00	0.2	11.7	2,183.6	0.2	0.6	1	1	1
08/30/2024 18:00	0.2	11.6	2,222.8	0.1	0.6	1	1	1
08/30/2024 19:00	0.2	11.6	2,216.4	0.1	0.6	1	1	1
08/30/2024 20:00	0.2	11.6	2,214.0	0.1	0.6	1	1	1
08/30/2024 21:00	0.2	11.8	2,169.7	0.1	0.6	1	1	1
08/30/2024 22:00	0.4	12.5	2,029.6	0.2	1.3	1	1	1
08/30/2024 23:00	0.2	11.9	2,192.3	0.2	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,877.4	0.3	24.9 #	24 #	24 #	18 #
Minimum:	0.2	11.6	1,323.9	0.1	0.6	1	1	0
Maximum:	0.6	14.0	2,222.8	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2024 00:00	0.3	11.9	2,188.9	0.2	1.0	1	1	1
08/31/2024 01:00	0.3	12.0	2,183.5	0.2	1.0	1	1	1
08/31/2024 02:00	0.2	12.0	2,182.9	0.2	0.6	1	1	1
08/31/2024 03:00	0.3	12.0	2,179.0	0.2	1.0	1	1	1
08/31/2024 04:00	0.2	12.0	2,178.1	0.1	0.6	1	1	1
08/31/2024 05:00	0.3	12.3	2,068.0	0.2	1.0	1	1	1
08/31/2024 06:00	19.1	14.5	582.2	0.0	5.3	1	0	0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2024 10:00	9.2	18.8	179.2	0.0	2.1	1	0	0
08/31/2024 11:00	24.6	15.8	792.8	0.0	50.5	1	0	0
08/31/2024 12:00	0.3	13.9	1,408.7	0.0	0.8	1	1	0
08/31/2024 13:00	0.3	14.0	1,387.0	0.0	0.8	1	1	0
08/31/2024 14:00	0.4	13.8	1,621.6	0.3	1.2	1	1	0
08/31/2024 15:00	0.3	13.8	1,543.4	0.3	0.9	1	1	0
08/31/2024 16:00	0.3	13.7	1,673.8	0.2	0.9	1	1	0
08/31/2024 17:00	0.4	13.0	1,811.8	0.2	1.2	1	1	1
08/31/2024 18:00	0.2	11.4	2,242.4	0.2	0.6	1	1	1
08/31/2024 19:00	0.1	11.3	2,266.4	0.2	0.3	1	1	1
08/31/2024 20:00	0.1	11.3	2,275.9	0.1	0.3	1	1	1
08/31/2024 21:00	0.1	11.4	2,281.8	0.1	0.3	1	1	1
08/31/2024 22:00	0.2	11.7	2,230.8	0.1	0.6	1	1	1
08/31/2024 23:00	0.2	11.5	2,266.1	0.1	0.6	1	1	1
Average/Sum#:	2.7	13.0	1,787.8	0.2	71.6 #	21 #	18 #	13 #
Minimum:	0.1	11.3	179.2	0.1	0.3	0	0	0
Maximum:	24.6	18.8	2,281.8	0.3	50.5	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2024 00:00	0.3	12.0	2,156.0	0.1	1.0	1	1	1
09/01/2024 01:00	0.3	12.1	2,149.0	0.2	1.0	1	1	1
09/01/2024 02:00	0.3	12.0	2,165.6	0.2	1.0	1	1	1
09/01/2024 03:00	0.3	12.4	2,074.5	0.2	1.0	1	1	1
09/01/2024 04:00	0.5	12.8	1,987.5	0.3	1.6	1	1	1
09/01/2024 05:00	0.6	12.9	1,944.5	0.3	1.9	1	1	1
09/01/2024 06:00	18.6	14.3	619.8	0.0	5.8	1	0	0
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2024 14:00	21.5	17.8	324.8	0.0	12.5	1	0	0
09/01/2024 15:00	13.4	15.1	1,083.9	0.0	33.1	1	0	0
09/01/2024 16:00	0.3	13.6	1,720.5	0.0	0.9	1	1	0
09/01/2024 17:00	0.3	13.6	1,723.1	0.0	0.9	1	1	1
09/01/2024 18:00	0.4	11.9	2,140.5	0.2	1.3	1	1	1
09/01/2024 19:00	0.2	11.6	2,209.3	0.2	0.6	1	1	1
09/01/2024 20:00	0.2	11.7	2,196.9	0.2	0.6	1	1	1
09/01/2024 21:00	0.2	11.6	2,230.6	0.1	0.6	1	1	1
09/01/2024 22:00	0.3	11.9	2,173.7	0.1	1.0	1	1	1
09/01/2024 23:00	0.3	12.0	2,170.6	0.2	1.0	1	1	1
Average/Sum#:	3.4	12.9	1,827.7	0.2	65.8 #	17 #	14 #	13 #
Minimum:	0.2	11.6	324.8	0.1	0.6	0	0	0
Maximum:	21.5	17.8	2,230.6	0.3	33.1	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2024 00:00	0.3	12.1	2,154.1	0.2	1.0	1	1	1
09/02/2024 01:00	0.4	12.3	2,085.7	0.2	1.3	1	1	1
09/02/2024 02:00	0.6	12.9	1,962.3	0.3	1.9	1	1	1
09/02/2024 03:00	0.6	13.0	1,971.1	0.4	2.0	1	1	1
09/02/2024 04:00	0.7	13.0	1,964.7	0.4	2.3	1	1	1
09/02/2024 05:00	0.7	13.0	1,957.0	0.5	2.3	1	1	1
09/02/2024 06:00	0.6	13.0	1,934.2	0.5	1.9	1	1	1
09/02/2024 07:00	17.3	15.6	641.5	0.0	6.9	1	0	0
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2024 14:00	30.1	17.4	428.9	0.0	21.9	1	0	0
09/02/2024 15:00	19.1	14.5	1,215.8	0.0	47.9	1	0	0
09/02/2024 16:00	0.3	13.7	1,682.0	0.0	0.9	1	1	0
09/02/2024 17:00	0.4	13.0	1,820.6	0.0	1.2	1	1	1
09/02/2024 18:00	0.2	11.4	2,266.4	0.2	0.6	1	1	1
09/02/2024 19:00	0.1	11.3	2,284.8	0.2	0.3	1	1	1
09/02/2024 20:00	0.2	11.8	2,193.4	0.1	0.6	1	1	1
09/02/2024 21:00	0.4	12.6	2,002.0	0.2	1.3	1	1	1
09/02/2024 22:00	0.4	12.6	2,027.3	0.2	1.3	1	1	1
09/02/2024 23:00	0.4	12.8	1,991.4	0.3	1.3	1	1	1
Average/Sum#:	4.0	13.1	1,810.2	0.3	96.9 #	18 #	15 #	14 #
Minimum:	0.1	11.3	428.9	0.1	0.3	0	0	0
Maximum:	30.1	17.4	2,284.8	0.5	47.9	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2024 00:00	0.5	12.8	1,982.8	0.3	1.6	1	1	1
09/03/2024 01:00	0.5	12.8	1,986.8	0.4	1.6	1	1	1
09/03/2024 02:00	0.5	12.8	1,980.7	0.4	1.6	1	1	1
09/03/2024 03:00	0.5	12.9	1,976.3	0.4	1.6	1	1	1
09/03/2024 04:00	0.5	12.8	1,995.1	0.4	1.6	1	1	1
09/03/2024 05:00	0.4	12.2	2,132.6	0.4	1.3	1	1	1
09/03/2024 06:00	0.4	12.6	2,074.6	0.3	1.3	1	1	1
09/03/2024 07:00	0.5	12.9	1,962.4	0.3	1.6	1	1	1
09/03/2024 08:00	0.5	12.8	1,971.4	0.4	1.6	1	1	1
09/03/2024 09:00	0.5	12.7	1,983.4	0.4	1.6	1	1	1
09/03/2024 10:00	0.5	12.6	2,001.6	0.4	1.6	1	1	1
09/03/2024 11:00	0.4	12.5	2,014.5	0.4	1.3	1	1	1
09/03/2024 12:00	0.3	12.1	2,109.1	0.3	0.9	1	1	1
09/03/2024 13:00	0.2	11.7	2,199.5	0.2	0.6	1	1	1
09/03/2024 14:00	0.2	11.6	2,224.7	0.1	0.6	1	1	1
09/03/2024 15:00	0.1	11.6	2,219.4	0.1	0.3	1	1	1
09/03/2024 16:00	0.2	11.6	2,212.6	0.1	0.6	1	1	1
09/03/2024 17:00	0.2	11.5	2,247.1	0.1	0.6	1	1	1
09/03/2024 18:00	0.1	11.5	2,260.4	0.1	0.3	1	1	1
09/03/2024 19:00	0.1	11.5	2,264.8	0.1	0.3	1	1	1
09/03/2024 20:00	0.1	11.5	2,272.6	0.1	0.3	1	1	1
09/03/2024 21:00	0.1	11.5	2,276.9	0.1	0.3	1	1	1
09/03/2024 22:00	0.1	11.5	2,276.0	0.1	0.3	1	1	1
09/03/2024 23:00	0.2	12.0	2,134.7	0.1	0.6	1	1	1
Average/Sum#:	0.3	12.2	2,115.0	0.3	24.0 #	24 #	24 #	24 #
Minimum:	0.1	11.5	1,962.4	0.1	0.3	1	1	1
Maximum:	0.5	12.9	2,276.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2024 00:00	0.2	13.8	1,719.2	0.1	0.6	1	1	0
09/04/2024 01:00	0.3	13.8	1,737.2	0.2	1.0	1	1	0
09/04/2024 02:00	0.3	13.9	1,724.7	0.2	1.0	1	1	0
09/04/2024 03:00	0.2	13.9	1,741.3	0.2	0.7	1	1	0
09/04/2024 04:00	0.3	13.8	1,740.8	0.2	1.0	1	1	0
09/04/2024 05:00	0.3	13.9	1,710.5	0.2	1.0	1	1	0
09/04/2024 06:00	0.3	13.8	1,707.4	0.2	1.0	1	1	0
09/04/2024 07:00	0.3	13.8	1,738.1	0.2	1.0	1	1	0
09/04/2024 08:00	0.3	13.7	1,745.0	0.2	1.0	1	1	0
09/04/2024 09:00	0.3	13.7	1,740.8	0.2	1.0	1	1	0
09/04/2024 10:00	0.3	13.7	1,733.3	0.2	1.0	1	1	0
09/04/2024 11:00	0.3	13.7	1,741.2	0.2	1.0	1	1	0
09/04/2024 12:00	0.3	13.7	1,683.2	0.2	0.9	1	1	1
09/04/2024 13:00	0.4	12.0	2,136.2	0.2	1.3	1	1	1
09/04/2024 14:00	0.2	11.7	2,182.3	0.2	0.6	1	1	1
09/04/2024 15:00	0.2	11.9	2,122.5	0.2	0.6	1	1	1
09/04/2024 16:00	0.3	11.8	2,150.4	0.1	0.9	1	1	1
09/04/2024 17:00	0.2	11.8	2,151.1	0.1	0.6	1	1	1
09/04/2024 18:00	0.3	11.9	2,121.5	0.2	0.9	1	1	1
09/04/2024 19:00	0.2	11.6	2,203.7	0.1	0.6	1	1	1
09/04/2024 20:00	0.2	11.6	2,211.6	0.1	0.6	1	1	1
09/04/2024 21:00	0.2	11.7	2,201.3	0.1	0.6	1	1	1
09/04/2024 22:00	0.2	11.9	2,172.6	0.1	0.6	1	1	1
09/04/2024 23:00	0.2	11.8	2,196.2	0.1	0.6	1	1	1
Average/Sum#:	0.3	12.9	1,929.7	0.2	20.1 #	24 #	24 #	12 #
Minimum:	0.2	11.6	1,683.2	0.1	0.6	1	1	0
Maximum:	0.4	13.9	2,211.6	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	0.2	11.9	2,185.3	0.1	0.6	1	1	1
09/05/2024 01:00	0.2	11.9	2,181.9	0.1	0.6	1	1	1
09/05/2024 02:00	0.2	11.9	2,170.5	0.1	0.6	1	1	1
09/05/2024 03:00	0.4	12.6	2,028.5	0.2	1.3	1	1	1
09/05/2024 04:00	0.2	11.9	2,186.7	0.2	0.6	1	1	1
09/05/2024 05:00	0.2	11.6	2,250.1	0.2	0.6	1	1	1
09/05/2024 06:00	0.3	12.4	2,097.0	0.1	1.0	1	1	1
09/05/2024 07:00	0.2	13.8	1,723.4	0.2	0.6	1	1	0
09/05/2024 08:00	0.2	13.8	1,658.4	0.2	0.6	1	1	0
09/05/2024 09:00	0.3	13.7	1,726.0	0.2	0.9	1	1	0
09/05/2024 10:00	0.3	13.8	1,705.9	0.2	1.0	1	1	0
09/05/2024 11:00	0.3	13.7	1,729.5	0.2	1.0	1	1	0
09/05/2024 12:00	0.3	13.7	1,728.5	0.2	1.0	1	1	1
09/05/2024 13:00	0.4	11.8	2,139.4	0.2	1.2	1	1	1
09/05/2024 14:00	0.2	11.6	2,183.9	0.2	0.6	1	1	1
09/05/2024 15:00	0.2	11.6	2,176.1	0.2	0.6	1	1	1
09/05/2024 16:00	0.3	11.9	2,096.4	0.1	0.9	1	1	1
09/05/2024 17:00	0.2	11.8	2,138.8	0.1	0.6	1	1	1
09/05/2024 18:00	0.2	11.6	2,169.3	0.1	0.6	1	1	1
09/05/2024 19:00	0.2	11.7	2,174.8	0.1	0.6	1	1	1
09/05/2024 20:00	0.2	11.7	2,180.3	0.1	0.6	1	1	1
09/05/2024 21:00	0.2	11.5	2,227.0	0.1	0.6	1	1	1
09/05/2024 22:00	0.1	11.4	2,262.6	0.1	0.3	1	1	1
09/05/2024 23:00	0.2	11.8	2,196.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.3	2,054.9	0.2	17.6 #	24 #	24 #	19 #
Minimum:	0.1	11.4	1,658.4	0.1	0.3	1	1	0
Maximum:	0.4	13.8	2,262.6	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2024 00:00	0.2	11.7	2,192.7	0.1	0.6	1	1	1
09/06/2024 01:00	0.2	11.9	2,150.9	0.1	0.6	1	1	1
09/06/2024 02:00	0.4	12.6	2,010.4	0.2	1.3	1	1	1
09/06/2024 03:00	0.3	11.9	2,182.6	0.2	1.0	1	1	1
09/06/2024 04:00	0.2	11.8	2,218.4	0.2	0.6	1	1	1
09/06/2024 05:00	0.2	11.6	2,266.4	0.1	0.6	1	1	1
09/06/2024 06:00	0.2	12.0	2,176.6	0.1	0.6	1	1	1
09/06/2024 07:00	0.2	12.1	2,145.7	0.1	0.6	1	1	1
09/06/2024 08:00	0.3	12.2	2,102.5	0.1	1.0	1	1	1
09/06/2024 09:00	0.4	12.6	1,992.5	0.2	1.3	1	1	1
09/06/2024 10:00	0.4	12.3	2,061.3	0.3	1.3	1	1	1
09/06/2024 11:00	0.3	11.9	2,136.4	0.3	0.9	1	1	1
09/06/2024 12:00	0.2	11.7	2,171.6	0.2	0.6	1	1	1
09/06/2024 13:00	0.2	11.7	2,166.0	0.1	0.6	1	1	1
09/06/2024 14:00	0.2	11.6	2,177.8	0.1	0.6	1	1	1
09/06/2024 15:00	0.2	11.6	2,177.3	0.1	0.6	1	1	1
09/06/2024 16:00	0.2	11.9	2,123.5	0.1	0.6	1	1	1
09/06/2024 17:00	0.2	11.7	2,162.3	0.1	0.6	1	1	1
09/06/2024 18:00	0.2	11.5	2,193.7	0.1	0.6	1	1	1
09/06/2024 19:00	0.2	11.6	2,201.2	0.1	0.6	1	1	1
09/06/2024 20:00	0.2	11.7	2,212.3	0.1	0.6	1	1	1
09/06/2024 21:00	0.2	11.6	2,233.1	0.1	0.6	1	1	1
09/06/2024 22:00	0.2	11.7	2,218.0	0.1	0.6	1	1	1
09/06/2024 23:00	0.1	11.5	2,276.3	0.1	0.3	1	1	1
Average/Sum#:	0.2	11.9	2,164.6	0.1	17.3 #	24 #	24 #	24 #
Minimum:	0.1	11.5	1,992.5	0.1	0.3	1	1	1
Maximum:	0.4	12.6	2,276.3	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2024 00:00	0.1	11.5	2,277.9	0.1	0.3	1	1	1
09/07/2024 01:00	0.1	11.5	2,270.1	0.1	0.3	1	1	1
09/07/2024 02:00	0.2	11.8	2,195.0	0.1	0.6	1	1	1
09/07/2024 03:00	0.2	11.8	2,190.1	0.1	0.6	1	1	1
09/07/2024 04:00	0.2	11.8	2,216.1	0.1	0.6	1	1	1
09/07/2024 05:00	0.2	11.9	2,181.3	0.1	0.6	1	1	1
09/07/2024 06:00	0.4	12.4	2,101.1	0.2	1.3	1	1	1
09/07/2024 07:00	0.5	12.8	1,977.2	0.3	1.6	1	1	1
09/07/2024 08:00	0.5	12.8	1,977.3	0.4	1.6	1	1	1
09/07/2024 09:00	0.5	12.7	1,991.3	0.4	1.6	1	1	1
09/07/2024 10:00	0.3	12.2	2,091.9	0.3	1.0	1	1	1
09/07/2024 11:00	0.4	12.3	2,070.3	0.3	1.3	1	1	1
09/07/2024 12:00	0.2	11.8	2,167.4	0.2	0.6	1	1	1
09/07/2024 13:00	0.2	11.5	2,217.6	0.2	0.6	1	1	1
09/07/2024 14:00	0.2	11.4	2,238.6	0.1	0.6	1	1	1
09/07/2024 15:00	0.2	11.4	2,241.0	0.1	0.6	1	1	1
09/07/2024 16:00	0.2	11.8	2,156.7	0.1	0.6	1	1	1
09/07/2024 17:00	0.2	11.4	2,250.0	0.1	0.6	1	1	1
09/07/2024 18:00	0.1	11.4	2,264.7	0.1	0.3	1	1	1
09/07/2024 19:00	0.1	11.4	2,273.3	0.1	0.3	1	1	1
09/07/2024 20:00	0.1	11.5	2,279.4	0.1	0.3	1	1	1
09/07/2024 21:00	0.1	11.5	2,270.8	0.1	0.3	1	1	1
09/07/2024 22:00	0.2	11.9	2,188.7	0.1	0.6	1	1	1
09/07/2024 23:00	0.2	11.6	2,267.5	0.1	0.6	1	1	1
Average/Sum#:	0.2	11.8	2,181.5	0.2	17.4 #	24 #	24 #	24 #
Minimum:	0.1	11.4	1,977.2	0.1	0.3	1	1	1
Maximum:	0.5	12.8	2,279.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	0.3	12.1	2,145.1	0.1	1.0	1	1	1
09/08/2024 01:00	0.4	12.7	2,001.6	0.2	1.3	1	1	1
09/08/2024 02:00	0.3	12.1	2,161.9	0.2	1.0	1	1	1
09/08/2024 03:00	0.2	12.0	2,177.0	0.2	0.6	1	1	1
09/08/2024 04:00	0.4	12.7	2,020.7	0.2	1.3	1	1	1
09/08/2024 05:00	0.2	13.8	1,703.7	0.2	0.6	1	1	0
09/08/2024 06:00	0.3	13.8	1,657.6	0.2	0.9	1	1	0
09/08/2024 07:00	0.2	13.8	1,646.3	0.2	0.6	1	1	0
09/08/2024 08:00	0.3	13.8	1,615.7	0.2	0.9	1	1	0
09/08/2024 09:00	0.3	13.8	1,544.2	0.2	0.9	1	1	0
09/08/2024 10:00	0.2	13.9	1,544.0	0.2	0.6	1	1	0
09/08/2024 11:00	0.2	13.9	1,559.2	0.2	0.6	1	1	0
09/08/2024 12:00	0.2	13.9	1,642.0	0.2	0.6	1	1	0
09/08/2024 13:00	0.2	13.8	1,672.1	0.2	0.6	1	1	0
09/08/2024 14:00	0.4	13.0	1,838.6	0.2	1.2	1	1	1
09/08/2024 15:00	0.2	11.6	2,219.4	0.2	0.6	1	1	1
09/08/2024 16:00	0.2	12.0	2,132.6	0.2	0.6	1	1	1
09/08/2024 17:00	0.2	11.5	2,225.6	0.1	0.6	1	1	1
09/08/2024 18:00	0.2	11.5	2,238.1	0.1	0.6	1	1	1
09/08/2024 19:00	0.1	11.4	2,264.2	0.1	0.3	1	1	1
09/08/2024 20:00	0.1	11.4	2,266.1	0.1	0.3	1	1	1
09/08/2024 21:00	0.1	11.5	2,253.8	0.1	0.3	1	1	1
09/08/2024 22:00	0.1	11.7	2,203.8	0.1	0.3	1	1	1
09/08/2024 23:00	0.2	11.8	2,189.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.6	1,955.1	0.2	16.9 #	24 #	24 #	15 #
Minimum:	0.1	11.4	1,544.0	0.1	0.3	1	1	0
Maximum:	0.4	13.9	2,266.1	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2024 00:00	0.2	11.9	2,188.1	0.1	0.6	1	1	1
09/09/2024 01:00	0.3	12.5	2,064.1	0.1	1.0	1	1	1
09/09/2024 02:00	0.2	12.1	2,168.9	0.1	0.7	1	1	1
09/09/2024 03:00	0.2	11.9	2,186.0	0.1	0.6	1	1	1
09/09/2024 04:00	0.2	11.9	2,191.4	0.1	0.6	1	1	1
09/09/2024 05:00	0.1	11.7	2,256.7	0.1	0.3	1	1	1
09/09/2024 06:00	0.4	12.6	2,085.6	0.2	1.3	1	1	1
09/09/2024 07:00	0.4	12.9	1,975.6	0.2	1.3	1	1	1
09/09/2024 08:00	0.4	12.8	1,979.2	0.3	1.3	1	1	1
09/09/2024 09:00	0.3	12.0	2,145.7	0.3	1.0	1	1	1
09/09/2024 10:00	0.2	11.9	2,124.1	0.2	0.6	1	1	1
09/09/2024 11:00	0.2	12.1	2,080.6	0.1	0.6	1	1	1
09/09/2024 12:00	0.2	12.0	2,077.3	0.1	0.6	1	1	1
09/09/2024 13:00	0.2	12.0	2,083.8	0.1	0.6	1	1	1
09/09/2024 14:00	0.3	12.2	2,028.2	0.1	0.9	1	1	1
09/09/2024 15:00	0.3	11.9	2,082.5	0.2	0.9	1	1	1
09/09/2024 16:00	0.2	11.4	2,172.2	0.2	0.6	1	1	1
09/09/2024 17:00	0.2	11.6	2,142.6	0.1	0.6	1	1	1
09/09/2024 18:00	0.1	11.5	2,175.7	0.1	0.3	1	1	1
09/09/2024 19:00	0.1	11.6	2,161.8	0.1	0.3	1	1	1
09/09/2024 20:00	0.2	12.0	2,099.9	0.1	0.6	1	1	1
09/09/2024 21:00	0.2	12.1	2,088.7	0.1	0.6	1	1	1
09/09/2024 22:00	0.4	12.6	1,979.5	0.2	1.3	1	1	1
09/09/2024 23:00	0.2	11.9	2,154.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.0	2,112.2	0.1	17.8 #	24 #	24 #	24 #
Minimum:	0.1	11.4	1,975.6	0.1	0.3	1	1	1
Maximum:	0.4	12.9	2,256.7	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	0.2	11.9	2,145.4	0.2	0.6	1	1	1
09/10/2024 01:00	0.3	12.5	2,018.8	0.1	1.0	1	1	1
09/10/2024 02:00	0.4	12.6	1,980.9	0.2	1.3	1	1	1
09/10/2024 03:00	0.5	12.5	2,014.8	0.3	1.6	1	1	1
09/10/2024 04:00	0.4	12.3	2,074.7	0.3	1.3	1	1	1
09/10/2024 05:00	0.3	11.8	2,204.9	0.3	1.0	1	1	1
09/10/2024 06:00	0.5	12.5	2,034.3	0.3	1.6	1	1	1
09/10/2024 07:00	0.3	13.8	1,550.6	0.3	0.9	1	1	0
09/10/2024 08:00	0.3	13.9	1,290.7	0.3	0.7	1	1	0
09/10/2024 09:00	0.2	13.9	1,292.0	0.2	0.5	1	1	0
09/10/2024 10:00	0.2	13.9	1,297.8	0.2	0.5	1	1	0
09/10/2024 11:00	0.2	14.0	1,300.7	0.2	0.5	1	1	0
09/10/2024 12:00	0.2	13.9	1,303.8	0.2	0.5	1	1	0
09/10/2024 13:00	0.2	13.9	1,386.5	0.2	0.5	1	1	0
09/10/2024 14:00	0.2	14.0	1,301.1	0.2	0.5	1	1	0
09/10/2024 15:00	0.2	14.0	1,318.6	0.2	0.5	1	1	0
09/10/2024 16:00	0.3	13.8	1,551.7	0.2	0.9	1	1	1
09/10/2024 17:00	0.6	12.5	1,958.2	0.3	1.8	1	1	1
09/10/2024 18:00	0.5	12.5	1,976.9	0.3	1.6	1	1	1
09/10/2024 19:00	0.5	12.6	1,959.0	0.4	1.6	1	1	1
09/10/2024 20:00	0.5	12.7	1,948.0	0.4	1.6	1	1	1
09/10/2024 21:00	0.5	12.8	1,941.4	0.4	1.6	1	1	1
09/10/2024 22:00	0.6	12.8	1,920.9	0.4	1.9	1	1	1
09/10/2024 23:00	15.7	15.6	634.3	0.0	6.2	1	0	0
Average/Sum#:	1.0	13.2	1,683.6	0.3	30.7 #	24 #	23 #	14 #
Minimum:	0.2	11.8	634.3	0.1	0.5	1	0	0
Maximum:	15.7	15.6	2,204.9	0.4	6.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/12/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/13/2024 18:00	73.7	17.6	320.1	0.0	54.8	1	0	0
09/13/2024 19:00	23.5	15.3	874.9	0.0	48.5	1	0	0
09/13/2024 20:00	0.3	13.7	1,667.3	0.0	0.9	1	1	0
09/13/2024 21:00	0.3	13.7	1,691.4	0.0	0.9	1	1	0
09/13/2024 22:00	0.3	13.7	1,684.4	0.2	0.9	1	1	0
09/13/2024 23:00	0.3	13.8	1,689.2	0.2	0.9	1	1	0
Average/Sum#:	16.4	14.6	1,321.2	0.2	106.9 #	6 #	4 #	0 #
Minimum:	0.3	13.7	320.1	0.2	0.9	0	0	0
Maximum:	73.7	17.6	1,691.4	0.2	54.8	1	1	0
%SI	75.00	75.00	75.00	91.67	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2024 00:00	0.3	13.8	1,694.8	0.2	0.9	1	1	0
09/14/2024 01:00	0.3	13.6	1,760.8	0.2	1.0	1	1	0
09/14/2024 02:00	4.7	14.2	1,423.0	0.0	12.3	1	0	0
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.8	13.9	1,626.2	0.2	14.2 #	3 #	2 #	0 #
Minimum:	0.3	13.6	1,423.0	0.2	0.9	0	0	0
Maximum:	4.7	14.2	1,760.8	0.2	12.3	1	1	0
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/15/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2024 01:00	61.2	17.5	337.6	0.0	62.6	1	0	0
09/18/2024 02:00	25.0	15.4	868.5	0.0	52.1	1	0	0
09/18/2024 03:00	0.2	13.8	1,486.9	0.0	0.6	1	1	0
09/18/2024 04:00	0.2	13.7	1,688.7	0.0	0.6	1	1	1
09/18/2024 05:00	0.6	12.6	2,049.5	0.3	2.0	1	1	1
09/18/2024 06:00	0.3	12.5	2,082.3	0.3	1.0	1	1	1
09/18/2024 07:00	0.4	12.8	1,955.6	0.3	1.3	1	1	1
09/18/2024 08:00	0.4	12.9	1,916.9	0.3	1.3	1	1	1
09/18/2024 09:00	0.5	12.9	1,921.9	0.3	1.6	1	1	1
09/18/2024 10:00	0.5	12.8	1,931.7	0.4	1.6	1	1	1
09/18/2024 11:00	0.5	12.8	1,936.0	0.4	1.6	1	1	1
09/18/2024 12:00	0.4	12.8	1,935.7	0.4	1.3	1	1	1
09/18/2024 13:00	0.4	12.7	1,946.8	0.3	1.3	1	1	1
09/18/2024 14:00	0.4	12.7	1,952.7	0.3	1.3	1	1	1
09/18/2024 15:00	0.4	12.7	1,941.3	0.3	1.3	1	1	1
09/18/2024 16:00	0.3	12.2	2,065.1	0.3	0.9	1	1	1
09/18/2024 17:00	0.1	11.6	2,172.4	0.2	0.3	1	1	1
09/18/2024 18:00	0.2	11.9	2,107.2	0.1	0.6	1	1	1
09/18/2024 19:00	0.1	11.8	2,124.3	0.1	0.3	1	1	1
09/18/2024 20:00	0.2	11.9	2,109.4	0.1	0.6	1	1	1
09/18/2024 21:00	0.2	11.9	2,110.8	0.1	0.6	1	1	1
09/18/2024 22:00	0.2	12.0	2,106.6	0.1	0.6	1	1	1
09/18/2024 23:00	0.2	12.0	2,108.3	0.1	0.6	1	1	1
Average/Sum#:	4.0	12.9	1,863.3	0.2	136.0 #	23 #	21 #	20 #
Minimum:	0.1	11.6	337.6	0.1	0.3	0	0	0
Maximum:	61.2	17.5	2,172.4	0.4	62.6	1	1	1
%SI	4.17	4.17	4.17	20.83	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2024 00:00	0.2	11.9	2,111.6	0.1	0.6	1	1	1
09/19/2024 01:00	0.2	12.0	2,109.8	0.1	0.6	1	1	1
09/19/2024 02:00	0.1	12.0	2,112.4	0.1	0.3	1	1	1
09/19/2024 03:00	0.2	11.9	2,115.1	0.1	0.6	1	1	1
09/19/2024 04:00	0.2	12.0	2,112.3	0.1	0.6	1	1	1
09/19/2024 05:00	0.2	12.0	2,112.3	0.1	0.6	1	1	1
09/19/2024 06:00	0.3	12.4	2,031.0	0.1	0.9	1	1	1
09/19/2024 07:00	14.4	15.5	651.4	0.0	5.7	1	0	0
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.0	12.5	1,919.5	0.1	9.9 #	8 #	7 #	7 #
Minimum:	0.1	11.9	651.4	0.1	0.3	0	0	0
Maximum:	14.4	15.5	2,115.1	0.1	5.7	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/21/2024 20:00	60.5	17.6	313.3	0.0	47.1	1	0	0
09/21/2024 21:00	13.9	17.1	392.2	0.0	18.9	1	0	0
09/21/2024 22:00	17.3	15.2	926.2	0.0	37.1	1	0	0
09/21/2024 23:00	0.2	13.9	1,560.6	0.0	0.6	1	1	0
Average/Sum#:	23.0	16.0	798.1	0.0	103.7 #	4 #	1 #	0 #
Minimum:	0.2	13.9	313.3	0.0	0.6	0	0	0
Maximum:	60.5	17.6	1,560.6	0.0	47.1	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2024 00:00	0.3	13.8	1,688.4	0.0	0.9	1	1	0
09/22/2024 01:00	0.3	13.8	1,700.0	0.2	0.9	1	1	0
09/22/2024 02:00	0.3	13.8	1,673.9	0.2	0.9	1	1	0
09/22/2024 03:00	0.3	13.8	1,672.3	0.2	0.9	1	1	0
09/22/2024 04:00	0.2	13.8	1,693.7	0.2	0.6	1	1	0
09/22/2024 05:00	0.2	13.8	1,695.1	0.2	0.6	1	1	0
09/22/2024 06:00	0.3	13.9	1,598.5	0.2	0.9	1	1	0
09/22/2024 07:00	15.8	15.6	609.4	0.0	5.5	1	0	0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/22/2024 10:00	19.6	17.6	391.9	0.0	13.2	1	0	0
09/22/2024 11:00	21.0	14.7	1,056.8	0.0	47.3	1	0	0
09/22/2024 12:00	0.2	14.0	1,519.1	0.0	0.6	1	1	0
09/22/2024 13:00	0.2	14.0	1,510.6	0.0	0.6	1	1	0
09/22/2024 14:00	0.3	13.8	1,652.6	0.2	0.9	1	1	0
09/22/2024 15:00	0.3	13.9	1,470.3	0.2	0.8	1	1	0
09/22/2024 16:00	0.3	13.9	1,483.9	0.3	0.8	1	1	0
09/22/2024 17:00	0.3	13.9	1,596.3	0.3	0.9	1	1	1
09/22/2024 18:00	0.5	12.6	1,947.4	0.3	1.5	1	1	1
09/22/2024 19:00	0.4	12.5	1,957.3	0.3	1.2	1	1	1
09/22/2024 20:00	0.4	12.6	1,938.0	0.3	1.2	1	1	1
09/22/2024 21:00	0.4	12.6	1,932.7	0.3	1.2	1	1	1
09/22/2024 22:00	0.4	12.8	1,911.8	0.3	1.2	1	1	1
09/22/2024 23:00	0.5	12.9	1,909.0	0.3	1.6	1	1	1
Average/Sum#:	2.8	13.8	1,573.1	0.3	84.2 #	22 #	19 #	7 #
Minimum:	0.2	12.5	391.9	0.2	0.6	0	0	0
Maximum:	21.0	17.6	1,957.3	0.3	47.3	1	1	1
%SI	8.33	8.33	8.33	33.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	0.4	12.9	1,909.9	0.3	1.3	1	1	1
09/23/2024 01:00	0.4	12.9	1,907.8	0.3	1.3	1	1	1
09/23/2024 02:00	0.5	12.9	1,908.0	0.3	1.6	1	1	1
09/23/2024 03:00	0.4	12.9	1,909.5	0.3	1.3	1	1	1
09/23/2024 04:00	0.4	12.8	1,911.8	0.3	1.2	1	1	1
09/23/2024 05:00	0.4	12.8	1,898.8	0.3	1.2	1	1	1
09/23/2024 06:00	0.2	13.8	1,620.5	0.3	0.6	1	1	0
09/23/2024 07:00	0.2	13.9	1,561.7	0.2	0.6	1	1	0
09/23/2024 08:00	0.2	13.8	1,636.8	0.2	0.6	1	1	0
09/23/2024 09:00	0.3	13.9	1,503.8	0.2	0.9	1	1	0
09/23/2024 10:00	0.3	13.9	1,509.6	0.3	0.9	1	1	0
09/23/2024 11:00	0.3	13.8	1,636.6	0.3	0.9	1	1	0
09/23/2024 12:00	0.3	13.6	1,681.2	0.2	0.9	1	1	0
09/23/2024 13:00	0.3	13.6	1,681.2	0.2	0.9	1	1	1
09/23/2024 14:00	0.3	11.8	2,092.0	0.2	0.9	1	1	1
09/23/2024 15:00	0.2	11.5	2,154.6	0.2	0.6	1	1	1
09/23/2024 16:00	0.1	11.4	2,169.2	0.1	0.3	1	1	1
09/23/2024 17:00	0.1	11.3	2,180.8	0.1	0.3	1	1	1
09/23/2024 18:00	0.1	11.3	2,187.8	0.1	0.3	1	1	1
09/23/2024 19:00	0.1	11.4	2,203.9	0.1	0.3	1	1	1
09/23/2024 20:00	0.1	11.4	2,211.7	0.1	0.3	1	1	1
09/23/2024 21:00	0.1	11.4	2,208.7	0.1	0.3	1	1	1
09/23/2024 22:00	0.1	11.5	2,191.0	0.1	0.3	1	1	1
09/23/2024 23:00	0.2	12.2	2,035.4	0.1	0.6	1	1	1
Average/Sum#:	0.3	12.6	1,913.0	0.2	18.4 #	24 #	24 #	17 #
Minimum:	0.1	11.3	1,503.8	0.1	0.3	1	1	0
Maximum:	0.5	13.9	2,211.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	0.2	13.8	1,685.3	0.1	0.6	1	1	1
09/24/2024 01:00	0.2	13.9	1,667.6	0.2	0.6	1	1	0
09/24/2024 02:00	0.2	13.9	1,631.2	0.2	0.6	1	1	0
09/24/2024 03:00	0.3	13.9	1,667.0	0.2	0.9	1	1	0
09/24/2024 04:00	0.3	13.8	1,677.0	0.2	0.9	1	1	0
09/24/2024 05:00	0.2	13.9	1,666.7	0.2	0.6	1	1	0
09/24/2024 06:00	0.2	13.8	1,626.8	0.2	0.6	1	1	0
09/24/2024 07:00	0.2	13.9	1,573.7	0.2	0.6	1	1	0
09/24/2024 08:00	0.3	13.9	1,501.2	0.2	0.8	1	1	0
09/24/2024 09:00	0.3	13.8	1,519.9	0.2	0.8	1	1	0
09/24/2024 10:00	0.3	13.8	1,550.8	0.2	0.9	1	1	0
09/24/2024 11:00	0.3	13.8	1,640.5	0.2	0.9	1	1	0
09/24/2024 12:00	0.2	13.9	1,387.9	0.2	0.5	1	1	0
09/24/2024 13:00	0.4	12.6	1,830.9	0.2	1.2	1	1	1
09/24/2024 14:00	0.2	11.4	2,137.5	0.2	0.6	1	1	1
09/24/2024 15:00	0.1	11.6	2,115.3	0.2	0.3	1	1	1
09/24/2024 16:00	0.1	11.4	2,149.5	0.1	0.3	1	1	1
09/24/2024 17:00	0.1	11.3	2,175.6	0.1	0.3	1	1	1
09/24/2024 18:00	0.1	11.4	2,156.1	0.1	0.3	1	1	1
09/24/2024 19:00	0.2	11.8	2,075.4	0.1	0.6	1	1	1
09/24/2024 20:00	0.1	11.7	2,133.2	0.1	0.3	1	1	1
09/24/2024 21:00	0.2	12.0	2,058.0	0.1	0.6	1	1	1
09/24/2024 22:00	0.3	12.2	2,013.0	0.1	0.9	1	1	1
09/24/2024 23:00	0.2	11.7	2,129.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,823.7	0.2	15.3 #	24 #	24 #	12 #
Minimum:	0.1	11.3	1,387.9	0.1	0.3	1	1	0
Maximum:	0.4	13.9	2,175.6	0.2	1.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2024 00:00	0.2	11.8	2,120.6	0.1	0.6	1	1	1
09/25/2024 01:00	0.2	11.9	2,091.9	0.1	0.6	1	1	1
09/25/2024 02:00	0.3	12.2	2,040.2	0.1	0.9	1	1	1
09/25/2024 03:00	0.3	12.0	2,098.3	0.2	0.9	1	1	1
09/25/2024 04:00	0.2	11.9	2,111.2	0.2	0.6	1	1	1
09/25/2024 05:00	0.2	12.0	2,108.0	0.1	0.6	1	1	1
09/25/2024 06:00	0.3	12.3	2,024.4	0.1	0.9	1	1	1
09/25/2024 07:00	13.6	15.4	689.0	0.0	6.1	1	0	0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/25/2024 18:00	0.7	20.7	0.2	0.0	0.0	1	0	0
09/25/2024 19:00	32.0	15.8	745.9	0.0	61.8	1	0	0
09/25/2024 20:00	0.2	13.8	1,492.4	0.0	0.6	1	1	0
09/25/2024 21:00	0.2	13.8	1,612.7	0.0	0.6	1	1	0
09/25/2024 22:00	0.2	13.9	1,396.3	0.2	0.5	1	1	0
09/25/2024 23:00	0.2	13.8	1,666.1	0.2	0.6	1	1	0
Average/Sum#:	3.5	13.7	1,585.5	0.1	75.3 #	14 #	11 #	7 #
Minimum:	0.2	11.8	0.2	0.1	0.0	0	0	0
Maximum:	32.0	20.7	2,120.6	0.2	61.8	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2024 00:00	0.2	13.8	1,689.2	0.2	0.6	1	1	0
09/26/2024 01:00	0.2	13.8	1,654.0	0.2	0.6	1	1	0
09/26/2024 02:00	0.2	13.8	1,630.7	0.2	0.6	1	1	0
09/26/2024 03:00	0.2	13.8	1,659.7	0.2	0.6	1	1	0
09/26/2024 04:00	0.2	13.8	1,680.7	0.2	0.6	1	1	0
09/26/2024 05:00	0.2	13.8	1,680.7	0.2	0.6	1	1	0
09/26/2024 06:00	0.2	13.8	1,623.4	0.2	0.6	1	1	0
09/26/2024 07:00	0.2	13.9	1,383.1	0.2	0.5	1	1	0
09/26/2024 08:00	18.3	15.7	569.2	0.0	6.1	1	0	0
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.2	14.0	1,507.9	0.2	10.8 #	9 #	8 #	0 #
Minimum:	0.2	13.8	569.2	0.2	0.5	0	0	0
Maximum:	18.3	15.7	1,689.2	0.2	6.1	1	1	0
%SI	62.50	62.50	62.50	66.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2024 13:00	46.2	17.7	306.4	0.0	27.4	1	0	0
09/27/2024 14:00	13.6	15.0	1,030.4	0.0	31.4	1	0	0
09/27/2024 15:00	0.3	13.9	1,436.6	0.0	0.8	1	1	0
09/27/2024 16:00	0.3	13.8	1,521.1	0.0	0.8	1	1	1
09/27/2024 17:00	0.3	11.7	2,104.0	0.2	0.9	1	1	1
09/27/2024 18:00	0.1	11.3	2,197.4	0.2	0.3	1	1	1
09/27/2024 19:00	0.1	11.3	2,198.0	0.1	0.3	1	1	1
09/27/2024 20:00	0.1	11.3	2,204.7	0.1	0.3	1	1	1
09/27/2024 21:00	0.1	11.5	2,192.3	0.1	0.3	1	1	1
09/27/2024 22:00	0.2	11.8	2,119.2	0.1	0.6	1	1	1
09/27/2024 23:00	0.2	11.8	2,120.2	0.1	0.6	1	1	1
Average/Sum#:	5.6	12.8	1,766.4	0.1	63.7 #	11 #	9 #	8 #
Minimum:	0.1	11.3	306.4	0.1	0.3	0	0	0
Maximum:	46.2	17.7	2,204.7	0.2	31.4	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2024 00:00	0.2	11.8	2,119.5	0.1	0.6	1	1	1
09/28/2024 01:00	0.2	11.9	2,118.4	0.1	0.6	1	1	1
09/28/2024 02:00	0.2	11.9	2,115.2	0.1	0.6	1	1	1
09/28/2024 03:00	0.2	11.9	2,113.4	0.1	0.6	1	1	1
09/28/2024 04:00	0.2	11.9	2,110.8	0.1	0.6	1	1	1
09/28/2024 05:00	0.2	12.0	2,113.5	0.1	0.6	1	1	1
09/28/2024 06:00	0.3	12.5	2,004.0	0.1	0.9	1	1	1
09/28/2024 07:00	12.9	15.4	693.8	0.0	5.8	1	0	0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.8	12.4	1,923.6	0.1	10.3 #	8 #	7 #	7 #
Minimum:	0.2	11.8	693.8	0.1	0.6	0	0	0
Maximum:	12.9	15.4	2,119.5	0.1	5.8	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2024 14:00	55.2	17.8	317.0	0.0	35.0	1	0	0
09/29/2024 15:00	8.8	14.8	1,077.9	0.0	20.5	1	0	0
09/29/2024 16:00	0.2	13.8	1,571.4	0.0	0.6	1	1	0
09/29/2024 17:00	0.3	13.6	1,706.5	0.0	0.9	1	1	1
09/29/2024 18:00	0.5	12.5	1,960.0	0.3	1.5	1	1	1
09/29/2024 19:00	0.2	11.7	2,159.0	0.2	0.6	1	1	1
09/29/2024 20:00	0.2	11.7	2,159.7	0.2	0.6	1	1	1
09/29/2024 21:00	0.2	12.1	2,079.8	0.1	0.6	1	1	1
09/29/2024 22:00	0.4	12.8	1,944.4	0.2	1.3	1	1	1
09/29/2024 23:00	0.2	12.0	2,131.4	0.2	0.6	1	1	1
Average/Sum#:	6.6	13.3	1,710.7	0.2	62.2 #	10 #	8 #	7 #
Minimum:	0.2	11.7	317.0	0.1	0.6	0	0	0
Maximum:	55.2	17.8	2,159.7	0.3	35.0	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2024 00:00	0.3	12.3	2,051.0	0.2	0.9	1	1	1
09/30/2024 01:00	0.4	12.9	1,934.2	0.2	1.3	1	1	1
09/30/2024 02:00	0.4	12.8	1,938.0	0.3	1.3	1	1	1
09/30/2024 03:00	0.4	12.7	1,982.0	0.3	1.3	1	1	1
09/30/2024 04:00	0.3	12.3	2,059.9	0.3	0.9	1	1	1
09/30/2024 05:00	0.3	12.3	2,121.7	0.2	1.0	1	1	1
09/30/2024 06:00	0.2	12.2	2,163.6	0.2	0.7	1	1	1
09/30/2024 07:00	0.3	13.0	1,863.0	0.2	0.9	1	1	1
09/30/2024 08:00	0.1	14.0	1,318.0	0.1	0.3	1	1	0
09/30/2024 09:00	0.1	14.1	1,313.4	0.1	0.3	1	1	0
09/30/2024 10:00	0.1	14.1	1,315.1	0.1	0.3	1	1	0
09/30/2024 11:00	0.1	14.1	1,427.8	0.1	0.3	1	1	0
09/30/2024 12:00	0.1	14.0	1,564.1	0.1	0.3	1	1	0
09/30/2024 13:00	0.2	13.8	1,667.3	0.1	0.6	1	1	1
09/30/2024 14:00	0.3	12.0	2,130.1	0.2	0.9	1	1	1
09/30/2024 15:00	0.2	12.0	2,131.5	0.2	0.6	1	1	1
09/30/2024 16:00	0.1	11.4	2,253.4	0.1	0.3	1	1	1
09/30/2024 17:00	0.1	11.4	2,265.6	0.1	0.3	1	1	1
09/30/2024 18:00	0.1	11.4	2,272.5	0.1	0.3	1	1	1
09/30/2024 19:00	0.1	11.4	2,275.7	0.1	0.3	1	1	1
09/30/2024 20:00	0.1	11.7	2,221.2	0.1	0.3	1	1	1
09/30/2024 21:00	0.1	11.4	2,282.1	0.1	0.3	1	1	1
09/30/2024 22:00	0.1	11.8	2,223.0	0.1	0.3	1	1	1
09/30/2024 23:00	0.2	12.2	2,121.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.6	1,954.0	0.2	14.6 #	24 #	24 #	19 #
Minimum:	0.1	11.4	1,313.4	0.1	0.3	1	1	0
Maximum:	0.4	14.1	2,282.1	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:45 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions NH3

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/01/2024 00:00	24.3	16.1	29.9	188.1	1,540,229.0	618.6	4.0	0.9
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 08:00	43.0	17.4	72.5	101.2	1,376,075.9	351.7	0.0	0.0
07/01/2024 09:00	42.6	15.7	48.3	260.4	2,023,451.3	797.9	4.0	1.2
07/01/2024 10:00	9.9	13.9	8.3	118.0	3,025,857.3	1,590.9	1.3	0.8
07/01/2024 11:00	10.2	13.9	8.6	102.5	2,812,645.5	1,478.8	1.2	0.7
07/01/2024 12:00	10.4	14.0	8.9	99.9	2,724,383.0	1,412.5	1.2	0.7
07/01/2024 13:00	10.3	13.9	8.7	132.4	3,117,722.8	1,639.2	1.4	0.8
07/01/2024 14:00	10.2	13.9	8.6	109.5	2,936,274.1	1,543.8	1.2	0.8
07/01/2024 15:00	10.2	14.1	8.9	89.0	2,620,491.4	1,339.5	1.1	0.5
07/01/2024 16:00	10.4	13.9	8.8	127.4	2,924,752.8	1,559.1	1.5	0.9
07/01/2024 17:00	11.2	13.3	8.7	174.6	3,169,175.5	2,129.1	1.9	1.5
07/01/2024 18:00	11.1	13.3	8.6	194.7	3,155,874.5	2,189.3	2.1	1.8
07/01/2024 19:00	10.9	13.3	8.5	195.0	3,178,667.1	2,181.9	2.1	1.7
07/01/2024 20:00	10.8	13.3	8.4	195.9	3,164,244.4	2,172.0	2.2	1.7
07/01/2024 21:00	10.7	13.4	8.4	178.0	3,198,606.1	2,078.8	1.9	1.5
07/01/2024 22:00	10.7	13.4	8.4	175.7	3,214,723.7	2,065.8	1.9	1.4
07/01/2024 23:00	24.0	16.2	30.1	171.1	1,567,086.6	606.5	3.5	0.8
Average/Sum#:	15.9	14.3	17.2	153.7	2,691,191.8	1,515.0	1.9	1.0
Minimum:	9.9	13.3	8.3	89.0	1,376,075.9	351.7	0.0	0.0
Maximum:	43.0	17.4	72.5	260.4	3,214,723.7	2,189.3	4.0	1.8
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 10:00	46.3	17.4	78.0	4.1	1,335,591.5	331.6	0.0	0.0
07/02/2024 11:00	47.8	17.1	74.2	255.4	1,450,905.1	423.8	5.5	0.9
07/02/2024 12:00	33.1	15.1	33.7	232.6	2,289,956.1	986.6	3.3	1.3
07/02/2024 13:00	9.7	13.9	8.2	134.3	3,155,952.6	1,659.3	1.4	0.8
07/02/2024 14:00	10.0	13.9	8.4	113.2	2,998,278.6	1,576.4	1.3	0.8
07/02/2024 15:00	10.1	13.8	8.4	134.7	3,129,040.9	1,668.0	1.5	1.0
07/02/2024 16:00	10.1	13.9	8.5	133.6	3,008,549.3	1,581.8	1.5	0.9
07/02/2024 17:00	10.1	13.9	8.5	120.4	3,112,587.5	1,636.5	1.3	0.8
07/02/2024 18:00	10.8	13.5	8.6	151.5	3,055,961.3	1,852.2	1.7	1.3
07/02/2024 19:00	11.1	13.3	8.6	196.1	3,197,460.3	2,194.8	2.1	1.8
07/02/2024 20:00	11.1	13.3	8.6	201.5	3,181,726.4	2,184.0	2.2	1.7
07/02/2024 21:00	11.0	13.3	8.5	202.0	3,179,686.9	2,182.6	2.2	1.7
07/02/2024 22:00	10.9	13.4	8.6	187.2	3,236,558.5	2,127.1	2.0	1.7
07/02/2024 23:00	11.0	13.3	8.5	205.1	3,216,690.5	2,208.0	2.2	1.8
Average/Sum#:	17.4	14.2	20.0	162.3	2,824,924.7	1,615.2	2.0	1.2
Minimum:	9.7	13.3	8.2	4.1	1,335,591.5	331.6	0.0	0.0
Maximum:	47.8	17.4	78.0	255.4	3,236,558.5	2,208.0	5.5	1.8
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/03/2024 00:00	10.9	13.3	8.5	202.4	3,206,929.7	2,201.3	2.2	1.8
07/03/2024 01:00	10.8	13.4	8.5	182.0	3,225,225.2	2,096.1	2.0	1.7
07/03/2024 02:00	10.8	13.4	8.5	174.7	3,246,480.2	2,062.5	1.9	1.4
07/03/2024 03:00	10.7	13.4	8.4	171.0	3,252,701.4	2,042.7	1.8	1.4
07/03/2024 04:00	10.7	13.4	8.4	170.9	3,232,786.0	2,053.8	1.8	1.4
07/03/2024 05:00	10.8	13.4	8.5	164.8	3,240,656.2	2,058.8	1.7	1.4
07/03/2024 06:00	11.1	13.4	8.7	176.2	3,221,570.9	2,070.2	1.9	1.4
07/03/2024 07:00	11.0	13.4	8.7	177.0	3,233,864.6	2,078.1	1.9	1.5
07/03/2024 08:00	11.1	13.4	8.7	178.5	3,243,668.4	2,084.4	1.9	1.5
07/03/2024 09:00	11.0	13.4	8.7	181.6	3,218,916.6	2,092.0	1.9	1.5
07/03/2024 10:00	10.9	13.4	8.6	179.8	3,229,379.7	2,098.8	1.9	1.5
07/03/2024 11:00	10.8	13.4	8.5	178.5	3,208,453.6	2,085.2	1.9	1.5
07/03/2024 12:00	10.8	13.3	8.4	178.5	3,184,063.9	2,092.6	1.9	1.5
07/03/2024 13:00	10.8	13.3	8.4	180.7	3,146,967.3	2,091.2	2.0	1.7
07/03/2024 14:00	10.9	13.3	8.5	183.3	3,150,729.5	2,093.7	2.0	1.7
07/03/2024 15:00	10.9	13.3	8.5	187.0	3,165,326.6	2,103.4	2.1	1.7
07/03/2024 16:00	11.0	13.4	8.7	177.2	3,147,368.1	2,045.5	1.9	1.4
07/03/2024 17:00	11.1	13.3	8.6	175.9	3,148,291.3	2,046.1	1.9	1.4
07/03/2024 18:00	11.1	13.3	8.6	177.2	3,135,677.5	2,060.8	2.0	1.6
07/03/2024 19:00	11.1	13.3	8.6	182.7	3,165,500.5	2,080.4	2.0	1.7
07/03/2024 20:00	11.0	13.3	8.5	178.4	3,161,544.4	2,077.8	2.0	1.7
07/03/2024 21:00	10.8	13.4	8.5	176.4	3,185,835.0	2,070.5	1.9	1.4
07/03/2024 22:00	10.7	13.4	8.4	174.3	3,214,101.3	2,065.4	1.9	1.4
07/03/2024 23:00	10.7	13.4	8.4	174.1	3,194,182.4	2,052.6	1.9	1.4
Average/Sum#:	10.9	13.4	8.5	178.5	3,198,342.5	2,079.3	1.9	1.5
Minimum:	10.7	13.3	8.4	164.8	3,135,677.5	2,042.7	1.7	1.4
Maximum:	11.1	13.4	8.7	202.4	3,252,701.4	2,201.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/04/2024 00:00	10.7	13.4	8.4	168.3	3,247,630.2	2,015.8	1.8	1.4
07/04/2024 01:00	10.6	13.4	8.3	165.3	3,195,592.1	1,983.5	1.8	1.4
07/04/2024 02:00	21.8	16.0	26.2	170.2	1,644,803.2	660.6	3.4	0.9
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 09:00	41.4	17.4	69.8	142.2	1,348,687.4	344.7	0.0	0.0
07/04/2024 10:00	33.4	15.0	33.4	229.1	2,326,880.3	1,019.5	3.1	1.2
07/04/2024 11:00	10.0	13.9	8.4	115.6	3,052,675.2	1,605.0	1.3	0.8
07/04/2024 12:00	10.2	13.9	8.6	119.4	3,034,986.8	1,595.7	1.3	0.8
07/04/2024 13:00	10.7	13.9	9.0	124.0	2,954,152.7	1,553.2	1.4	0.8
07/04/2024 14:00	10.6	13.9	8.9	109.3	2,802,498.1	1,453.0	1.3	0.7
07/04/2024 15:00	10.8	13.9	9.1	123.7	2,899,756.1	1,524.6	1.4	0.8
07/04/2024 16:00	10.7	13.8	8.9	136.8	3,136,537.0	1,694.9	1.5	1.0
07/04/2024 17:00	11.4	13.4	9.0	153.0	3,020,488.2	1,830.7	1.7	1.3
07/04/2024 18:00	11.4	13.3	8.9	190.5	3,143,557.4	2,157.8	2.1	1.7
07/04/2024 19:00	11.2	13.3	8.7	188.3	3,162,179.5	2,124.4	2.1	1.7
07/04/2024 20:00	11.1	13.3	8.6	177.4	3,151,654.1	2,071.3	1.9	1.4
07/04/2024 21:00	11.0	13.3	8.5	175.4	3,173,371.7	2,062.4	1.9	1.4
07/04/2024 22:00	10.9	13.4	8.6	169.7	3,179,243.2	2,043.0	1.8	1.4
07/04/2024 23:00	10.8	13.3	8.4	170.5	3,164,472.2	2,010.4	1.9	1.4
Average/Sum#:	14.4	14.0	14.4	157.2	2,868,842.5	1,652.8	1.8	1.1
Minimum:	10.0	13.3	8.3	109.3	1,348,687.4	344.7	0.0	0.0
Maximum:	41.4	17.4	69.8	229.1	3,247,630.2	2,157.8	3.4	1.7
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/05/2024 00:00	9.9	13.8	8.2	129.3	3,225,651.0	1,719.5	1.3	0.9
07/05/2024 01:00	10.1	13.8	8.4	133.8	3,213,269.9	1,712.9	1.4	0.9
07/05/2024 02:00	10.1	13.8	8.4	124.4	3,199,200.5	1,705.4	1.3	0.9
07/05/2024 03:00	9.9	13.8	8.2	127.7	3,246,473.8	1,730.6	1.3	0.9
07/05/2024 04:00	10.0	13.9	8.4	113.9	3,079,493.1	1,619.1	1.2	0.8
07/05/2024 05:00	10.0	13.9	8.4	118.9	3,099,213.7	1,652.1	1.3	0.8
07/05/2024 06:00	10.3	13.8	8.6	134.9	3,234,617.4	1,747.9	1.4	0.9
07/05/2024 07:00	10.2	13.8	8.5	131.3	3,232,766.8	1,746.9	1.4	0.9
07/05/2024 08:00	10.5	13.7	8.6	135.8	3,240,539.2	1,751.1	1.4	0.9
07/05/2024 09:00	10.7	13.6	8.6	141.2	3,196,601.7	1,750.7	1.5	1.1
07/05/2024 10:00	10.8	13.6	8.7	145.2	3,170,491.3	1,736.4	1.5	1.0
07/05/2024 11:00	10.6	13.7	8.7	135.2	3,202,972.6	1,730.8	1.4	0.9
07/05/2024 12:00	10.6	13.9	8.9	119.6	2,922,314.1	1,557.8	1.4	0.8
07/05/2024 13:00	11.2	13.5	8.9	154.4	2,996,399.5	1,816.1	1.8	1.3
07/05/2024 14:00	11.6	13.2	8.9	184.2	3,056,526.7	2,142.7	2.1	1.7
07/05/2024 15:00	11.5	13.2	8.8	188.4	3,059,149.9	2,122.2	2.1	1.7
07/05/2024 16:00	11.4	13.2	8.7	190.1	3,058,717.5	2,121.9	2.2	1.7
07/05/2024 17:00	11.2	13.2	8.6	189.0	3,059,005.8	2,122.1	2.2	1.7
07/05/2024 18:00	11.0	13.2	8.4	184.9	3,085,429.7	2,117.9	2.1	1.7
07/05/2024 19:00	10.9	13.2	8.4	182.7	3,097,812.8	2,126.4	2.1	1.7
07/05/2024 20:00	10.7	13.3	8.3	182.3	3,125,821.6	2,122.8	2.0	1.7
07/05/2024 21:00	10.6	13.3	8.2	188.0	3,172,985.4	2,178.0	2.1	1.7
07/05/2024 22:00	11.0	13.2	8.4	189.9	3,107,573.6	2,133.1	2.1	1.7
07/05/2024 23:00	10.7	13.3	8.3	176.3	3,174,141.1	2,062.9	1.9	1.4
Average/Sum#:	10.6	13.5	8.5	154.2	3,135,715.4	1,884.5	1.7	1.2
Minimum:	9.9	13.2	8.2	113.9	2,922,314.1	1,557.8	1.2	0.8
Maximum:	11.6	13.9	8.9	190.1	3,246,473.8	2,178.0	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/06/2024 00:00	10.7	13.4	8.4	169.7	3,201,619.8	2,034.0	1.8	1.4
07/06/2024 01:00	10.6	13.4	8.3	164.9	3,214,325.7	2,018.6	1.8	1.4
07/06/2024 02:00	10.6	13.4	8.3	165.1	3,214,325.7	2,018.6	1.8	1.4
07/06/2024 03:00	10.6	13.4	8.3	164.9	3,222,128.2	2,023.5	1.8	1.4
07/06/2024 04:00	10.6	13.4	8.3	162.9	3,250,852.4	2,017.8	1.7	1.4
07/06/2024 05:00	10.8	13.3	8.4	170.8	3,163,999.9	2,010.1	1.9	1.4
07/06/2024 06:00	23.5	16.1	28.9	182.1	1,544,710.7	620.4	3.8	0.9
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 09:00	22.2	18.0	45.2	195.9	984,273.8	172.5	6.5	0.4
07/06/2024 10:00	38.4	15.5	42.0	247.4	2,102,555.5	859.8	3.6	1.2
07/06/2024 11:00	10.3	13.9	8.7	124.0	3,020,341.6	1,588.0	1.4	0.8
07/06/2024 12:00	10.4	13.8	8.6	130.7	3,021,362.9	1,610.6	1.5	1.0
07/06/2024 13:00	10.3	13.8	8.6	123.4	2,982,531.3	1,589.9	1.4	0.8
07/06/2024 14:00	10.3	13.9	8.7	100.5	2,763,003.9	1,452.7	1.2	0.7
07/06/2024 15:00	10.4	14.0	8.9	106.3	2,783,403.3	1,443.1	1.3	0.7
07/06/2024 16:00	10.6	13.9	8.9	119.1	2,917,061.5	1,555.0	1.4	0.8
07/06/2024 17:00	11.2	13.3	8.7	173.9	3,128,688.2	2,101.9	1.9	1.5
07/06/2024 18:00	11.3	13.2	8.7	184.1	3,061,312.2	2,123.7	2.1	1.7
07/06/2024 19:00	11.4	13.2	8.7	186.9	3,048,627.0	2,114.9	2.1	1.7
07/06/2024 20:00	11.2	13.2	8.6	188.0	3,083,972.8	2,116.9	2.1	1.7
07/06/2024 21:00	11.1	13.2	8.5	185.0	3,113,894.3	2,114.7	2.1	1.7
07/06/2024 22:00	10.9	13.2	8.4	182.6	3,109,771.4	2,111.9	2.0	1.7
07/06/2024 23:00	10.9	13.2	8.4	191.4	3,112,197.1	2,159.0	2.1	1.7
Average/Sum#:	13.1	13.9	12.7	164.5	2,865,680.0	1,720.8	2.2	1.2
Minimum:	10.3	13.2	8.3	100.5	984,273.8	172.5	1.2	0.4
Maximum:	38.4	18.0	45.2	247.4	3,250,852.4	2,159.0	6.5	1.7
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/07/2024 00:00	10.6	13.3	8.2	175.2	3,162,761.7	2,078.6	1.9	1.5
07/07/2024 01:00	10.5	13.3	8.2	166.2	3,152,010.3	2,025.5	1.8	1.4
07/07/2024 02:00	10.7	13.3	8.3	166.0	3,120,420.2	2,005.2	1.8	1.4
07/07/2024 03:00	21.4	16.1	26.3	175.5	1,548,463.9	610.6	3.7	0.9
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 15:00	31.3	17.5	54.3	0.1	1,197,142.0	271.0	0.0	0.0
07/07/2024 16:00	41.8	15.8	48.4	214.2	1,900,657.7	735.6	3.5	1.0
07/07/2024 17:00	10.1	13.9	8.5	97.3	2,620,165.3	1,377.6	1.2	0.7
07/07/2024 18:00	11.2	13.5	8.9	154.6	2,950,156.2	1,701.9	1.8	1.2
07/07/2024 19:00	11.7	13.1	8.9	184.7	3,023,574.9	2,119.6	2.1	1.7
07/07/2024 20:00	11.6	13.1	8.8	202.0	3,057,097.3	2,143.1	2.3	1.9
07/07/2024 21:00	11.3	13.2	8.7	181.4	3,072,125.0	2,063.9	2.0	1.7
07/07/2024 22:00	11.2	13.3	8.7	172.5	3,103,420.0	2,039.6	1.9	1.4
07/07/2024 23:00	11.0	13.2	8.4	180.4	3,130,772.1	2,103.3	2.0	1.7
Average/Sum#:	15.7	14.0	16.5	159.2	2,695,289.7	1,636.6	2.0	1.3
Minimum:	10.1	13.1	8.2	0.1	1,197,142.0	271.0	0.0	0.0
Maximum:	41.8	17.5	54.3	214.2	3,162,761.7	2,143.1	3.7	1.9
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/08/2024 00:00	10.1	13.7	8.3	134.5	3,178,545.0	1,717.6	1.4	0.9
07/08/2024 01:00	10.0	13.8	8.3	128.1	3,193,197.5	1,702.2	1.3	0.9
07/08/2024 02:00	9.9	13.8	8.2	126.5	3,199,200.5	1,705.4	1.3	0.9
07/08/2024 03:00	10.0	13.8	8.3	125.7	3,201,076.4	1,706.4	1.3	0.9
07/08/2024 04:00	10.2	13.8	8.5	133.4	3,205,008.2	1,731.9	1.4	0.9
07/08/2024 05:00	10.3	13.7	8.4	140.8	3,238,318.6	1,749.9	1.5	1.0
07/08/2024 06:00	10.3	13.8	8.6	128.9	3,204,823.2	1,731.8	1.3	0.9
07/08/2024 07:00	10.4	13.7	8.5	132.2	3,182,061.1	1,719.5	1.4	0.9
07/08/2024 08:00	10.5	13.7	8.6	135.2	3,186,687.6	1,722.0	1.4	0.9
07/08/2024 09:00	10.7	13.7	8.8	138.4	3,177,249.6	1,716.9	1.5	1.0
07/08/2024 10:00	11.0	13.6	8.9	141.9	3,163,370.3	1,732.5	1.5	1.0
07/08/2024 11:00	11.2	13.6	9.1	147.5	3,154,058.2	1,727.4	1.6	1.0
07/08/2024 12:00	11.2	13.6	9.1	144.6	3,121,192.1	1,709.4	1.6	1.0
07/08/2024 13:00	10.8	13.8	9.0	124.6	2,999,414.6	1,598.9	1.4	0.8
07/08/2024 14:00	11.0	13.7	9.0	135.2	3,054,001.4	1,650.3	1.5	1.0
07/08/2024 15:00	11.1	13.7	9.1	144.0	3,111,554.3	1,681.4	1.6	1.0
07/08/2024 16:00	11.2	13.7	9.2	134.7	2,944,632.5	1,591.2	1.5	1.0
07/08/2024 17:00	11.9	13.1	9.0	173.1	3,080,330.8	2,114.4	1.9	1.5
07/08/2024 18:00	11.7	13.1	8.9	187.3	3,063,373.8	2,147.5	2.1	1.7
07/08/2024 19:00	11.4	13.2	8.7	188.5	3,079,493.1	2,158.8	2.1	1.7
07/08/2024 20:00	11.3	13.2	8.7	194.5	3,123,296.6	2,166.7	2.2	1.7
07/08/2024 21:00	11.2	13.2	8.6	197.1	3,135,837.7	2,175.4	2.2	1.7
07/08/2024 22:00	11.1	13.2	8.5	195.2	3,161,767.8	2,170.3	2.2	1.7
07/08/2024 23:00	10.9	13.2	8.4	192.2	3,163,658.6	2,194.7	2.1	1.8
Average/Sum#:	10.8	13.6	8.7	151.0	3,138,422.9	1,834.3	1.6	1.2
Minimum:	9.9	13.1	8.2	124.6	2,944,632.5	1,591.2	1.3	0.8
Maximum:	11.9	13.8	9.2	197.1	3,238,318.6	2,194.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/09/2024 00:00	10.8	13.2	8.3	193.9	3,172,884.2	2,201.1	2.1	1.8
07/09/2024 01:00	10.8	13.2	8.3	201.9	3,184,272.1	2,209.0	2.2	1.8
07/09/2024 02:00	10.7	13.2	8.2	201.2	3,222,663.5	2,212.1	2.2	1.8
07/09/2024 03:00	10.7	13.2	8.2	195.6	3,220,623.9	2,210.7	2.1	1.8
07/09/2024 04:00	10.7	13.2	8.2	195.1	3,205,173.8	2,223.5	2.1	1.8
07/09/2024 05:00	10.7	13.2	8.2	193.7	3,219,458.5	2,209.9	2.1	1.8
07/09/2024 06:00	11.1	13.3	8.6	175.2	3,220,508.4	2,046.0	1.9	1.4
07/09/2024 07:00	0.0	0.0	0.0	166.8	3,210,822.5	2,016.4	2.0	1.6
07/09/2024 08:00	12.0	13.2	9.2	160.8	3,204,006.5	2,152.5	1.7	1.5
07/09/2024 09:00	11.7	13.2	9.0	130.1	1,391,833.1	2,124.2	3.3	2.8
07/09/2024 10:00	11.5	13.2	8.8	130.4	1,400,023.5	2,136.7	3.3	2.8
07/09/2024 11:00	11.4	13.2	8.7	138.3	1,425,577.3	2,175.7	3.4	2.8
07/09/2024 12:00	11.3	13.2	8.7	160.7	3,132,954.7	2,173.4	1.8	1.5
07/09/2024 13:00	11.3	13.2	8.7	195.0	3,127,188.7	2,169.4	2.2	1.7
07/09/2024 14:00	11.3	13.2	8.7	199.6	3,113,494.4	2,159.9	2.2	1.7
07/09/2024 15:00	11.1	13.2	8.5	199.2	3,115,080.1	2,161.0	2.2	1.7
07/09/2024 16:00	11.2	13.2	8.6	194.4	3,119,981.2	2,164.4	2.2	1.7
07/09/2024 17:00	11.2	13.2	8.6	194.2	3,114,503.5	2,160.6	2.2	1.7
07/09/2024 18:00	11.3	13.2	8.7	194.0	3,116,168.9	2,139.0	2.2	1.7
07/09/2024 19:00	11.3	13.2	8.7	196.8	3,084,628.4	2,162.4	2.2	1.7
07/09/2024 20:00	11.2	13.2	8.6	200.5	3,098,608.0	2,172.2	2.3	2.0
07/09/2024 21:00	11.2	13.1	8.5	200.3	3,141,747.8	2,179.5	2.2	1.7
07/09/2024 22:00	11.2	13.2	8.6	199.4	3,157,251.6	2,167.2	2.2	1.7
07/09/2024 23:00	11.1	13.3	8.6	184.9	3,168,239.4	2,082.2	2.0	1.7
Average/Sum#:	11.2	13.2	8.6	183.4	3,159,536.2	2,158.7	2.1	1.7
Minimum:	10.7	13.1	8.2	130.1	3,084,628.4	2,016.4	1.7	1.4
Maximum:	12.0	13.3	9.2	201.9	3,222,663.5	2,223.5	2.3	2.0
%SI	4.17	4.17	4.17	0.00	12.50	0.00	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/10/2024 00:00	11.1	13.3	8.6	179.9	3,223,749.5	2,071.6	1.9	1.5
07/10/2024 01:00	11.2	13.2	8.6	199.6	3,185,281.1	2,209.7	2.2	1.8
07/10/2024 02:00	11.0	13.2	8.4	205.0	3,193,065.2	2,215.1	2.2	1.8
07/10/2024 03:00	11.0	13.2	8.4	206.8	3,192,344.5	2,214.6	2.3	2.0
07/10/2024 04:00	11.0	13.2	8.4	202.9	3,192,488.6	2,214.7	2.2	1.8
07/10/2024 05:00	10.9	13.2	8.4	173.2	3,214,024.3	2,182.7	1.9	1.5
07/10/2024 06:00	11.2	13.3	8.7	176.1	3,200,873.9	2,056.9	1.9	1.4
07/10/2024 07:00	11.0	13.3	8.5	168.3	3,161,481.5	2,008.5	1.8	1.4
07/10/2024 08:00	11.1	13.3	8.6	172.2	3,172,814.6	2,015.7	1.9	1.4
07/10/2024 09:00	11.2	13.3	8.7	172.9	3,155,433.9	2,027.7	1.9	1.4
07/10/2024 10:00	11.3	13.3	8.8	175.9	3,112,093.0	2,045.3	1.9	1.4
07/10/2024 11:00	11.3	13.2	8.7	180.4	3,094,452.6	2,078.9	2.0	1.7
07/10/2024 12:00	11.2	13.2	8.6	184.3	3,090,334.4	2,098.7	2.1	1.7
07/10/2024 13:00	11.3	13.2	8.7	193.4	3,100,088.5	2,150.6	2.2	1.7
07/10/2024 14:00	11.0	13.2	8.4	195.4	3,107,872.6	2,156.0	2.2	1.7
07/10/2024 15:00	11.1	13.2	8.5	189.8	3,111,215.7	2,135.6	2.1	1.7
07/10/2024 16:00	11.3	13.2	8.7	188.7	3,088,926.1	2,120.3	2.1	1.7
07/10/2024 17:00	11.2	13.2	8.6	187.1	3,075,086.2	2,110.8	2.1	1.7
07/10/2024 18:00	11.4	13.2	8.7	192.0	3,057,810.5	2,143.6	2.2	1.7
07/10/2024 19:00	11.4	13.2	8.7	194.0	3,070,934.2	2,152.8	2.2	1.7
07/10/2024 20:00	11.4	13.1	8.6	193.9	3,077,924.0	2,157.7	2.2	1.7
07/10/2024 21:00	11.3	13.2	8.7	198.2	3,090,905.0	2,166.8	2.2	1.7
07/10/2024 22:00	11.1	13.2	8.5	197.8	3,124,738.1	2,167.7	2.2	1.7
07/10/2024 23:00	11.0	13.2	8.4	193.6	3,129,206.8	2,170.8	2.2	1.7
Average/Sum#:	11.2	13.2	8.6	188.4	3,134,297.7	2,128.0	2.1	1.6
Minimum:	10.9	13.1	8.4	168.3	3,057,810.5	2,008.5	1.8	1.4
Maximum:	11.4	13.3	8.8	206.8	3,223,749.5	2,215.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/11/2024 00:00	10.9	13.2	8.4	193.6	3,129,863.1	2,148.4	2.2	1.7
07/11/2024 01:00	10.9	13.2	8.4	190.0	3,139,368.6	2,132.0	2.1	1.7
07/11/2024 02:00	11.0	13.2	8.4	187.5	3,132,558.3	2,104.5	2.1	1.7
07/11/2024 03:00	10.9	13.3	8.5	178.1	3,174,602.7	2,063.2	1.9	1.4
07/11/2024 04:00	11.0	13.2	8.4	202.4	3,151,550.0	2,186.3	2.2	1.7
07/11/2024 05:00	10.8	13.3	8.4	189.6	3,177,851.6	2,018.9	2.1	1.6
07/11/2024 06:00	10.6	13.7	8.7	141.0	3,185,762.3	1,721.5	1.5	1.0
07/11/2024 07:00	10.6	13.7	8.7	141.6	3,168,922.0	1,712.4	1.5	1.0
07/11/2024 08:00	10.6	13.8	8.8	117.4	2,907,306.7	1,549.8	1.3	0.8
07/11/2024 09:00	10.8	13.9	9.1	121.4	2,869,514.7	1,508.7	1.4	0.8
07/11/2024 10:00	11.1	13.8	9.2	143.0	3,077,828.2	1,640.7	1.6	1.0
07/11/2024 11:00	10.7	13.9	9.0	112.4	2,798,000.3	1,471.1	1.3	0.7
07/11/2024 12:00	11.0	13.8	9.1	135.5	3,002,791.2	1,600.7	1.5	1.0
07/11/2024 13:00	11.1	13.8	9.2	130.7	2,993,036.4	1,595.5	1.5	1.0
07/11/2024 14:00	11.1	13.8	9.2	133.4	2,986,296.1	1,570.1	1.5	0.9
07/11/2024 15:00	10.6	14.0	9.1	92.9	2,567,767.2	1,331.3	1.2	0.7
07/11/2024 16:00	10.4	14.0	8.9	93.5	2,572,974.8	1,334.0	1.2	0.7
07/11/2024 17:00	11.5	13.5	9.2	164.7	2,926,059.1	1,752.1	1.9	1.2
07/11/2024 18:00	11.5	13.2	8.8	186.6	3,063,474.4	2,125.2	2.1	1.7
07/11/2024 19:00	11.5	13.2	8.8	193.7	3,036,128.0	2,128.4	2.2	1.7
07/11/2024 20:00	11.2	13.2	8.6	186.2	3,075,609.4	2,088.7	2.1	1.7
07/11/2024 21:00	11.0	13.3	8.5	181.6	3,098,811.7	2,059.2	2.0	1.6
07/11/2024 22:00	11.0	13.2	8.4	194.7	3,113,782.7	2,160.1	2.2	1.7
07/11/2024 23:00	10.8	13.3	8.4	184.8	3,159,307.2	2,099.4	2.0	1.7
Average/Sum#:	10.9	13.5	8.8	158.2	3,021,215.3	1,837.6	1.8	1.3
Minimum:	10.4	13.2	8.4	92.9	2,567,767.2	1,331.3	1.2	0.7
Maximum:	11.5	14.0	9.2	202.4	3,185,762.3	2,186.3	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/12/2024 00:00	10.8	13.3	8.4	180.1	3,148,171.2	2,092.0	2.0	1.7
07/12/2024 01:00	10.8	13.3	8.4	179.2	3,157,651.9	2,098.3	2.0	1.7
07/12/2024 02:00	10.7	13.3	8.3	172.9	3,180,603.5	2,067.1	1.9	1.4
07/12/2024 03:00	10.7	13.2	8.2	192.8	3,182,454.9	2,184.5	2.1	1.7
07/12/2024 04:00	10.4	13.3	8.1	182.0	3,203,249.2	2,128.6	2.0	1.7
07/12/2024 05:00	10.5	13.2	8.0	210.3	3,209,474.3	2,109.3	2.3	1.9
07/12/2024 06:00	10.1	13.7	8.3	135.7	3,218,517.4	1,739.2	1.4	0.9
07/12/2024 07:00	10.1	13.9	8.5	109.6	2,898,865.1	1,545.3	1.3	0.8
07/12/2024 08:00	10.3	13.9	8.7	111.2	2,809,982.8	1,477.4	1.3	0.7
07/12/2024 09:00	10.3	13.9	8.7	109.5	2,820,824.0	1,483.1	1.3	0.7
07/12/2024 10:00	10.5	13.9	8.9	118.2	2,870,275.5	1,509.1	1.4	0.8
07/12/2024 11:00	10.4	14.0	8.9	107.9	2,767,008.8	1,434.6	1.3	0.7
07/12/2024 12:00	10.5	13.9	8.9	111.6	2,809,982.8	1,477.4	1.3	0.7
07/12/2024 13:00	10.5	14.0	9.0	97.0	2,586,669.1	1,341.1	1.2	0.7
07/12/2024 14:00	10.7	13.9	9.0	100.9	2,578,512.0	1,355.7	1.3	0.7
07/12/2024 15:00	10.7	14.0	9.1	101.0	2,617,529.3	1,357.1	1.3	0.7
07/12/2024 16:00	10.6	14.0	9.1	96.5	2,589,176.5	1,342.4	1.2	0.7
07/12/2024 17:00	10.7	14.0	9.1	97.7	2,590,912.4	1,343.3	1.2	0.7
07/12/2024 18:00	10.6	14.0	9.1	96.3	2,534,386.1	1,332.5	1.2	0.7
07/12/2024 19:00	10.7	13.9	9.0	97.6	2,527,348.8	1,328.8	1.3	0.7
07/12/2024 20:00	10.9	13.9	9.2	97.8	2,527,729.2	1,329.0	1.3	0.7
07/12/2024 21:00	10.9	13.8	9.1	144.0	3,034,015.2	1,639.5	1.6	1.0
07/12/2024 22:00	10.8	13.7	8.9	139.3	3,149,676.1	1,725.0	1.5	1.0
07/12/2024 23:00	11.1	13.6	9.0	149.6	3,149,676.1	1,725.0	1.6	1.0
Average/Sum#:	10.6	13.7	8.7	130.8	2,881,778.8	1,631.9	1.5	1.0
Minimum:	10.1	13.2	8.0	96.3	2,527,348.8	1,328.8	1.2	0.7
Maximum:	11.1	14.0	9.2	210.3	3,218,517.4	2,184.5	2.3	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/13/2024 00:00	11.0	13.6	8.9	143.1	3,150,771.6	1,725.6	1.5	1.0
07/13/2024 01:00	10.8	13.6	8.7	144.5	3,151,867.2	1,726.2	1.6	1.0
07/13/2024 02:00	10.9	13.6	8.8	141.7	3,171,952.1	1,737.2	1.5	1.0
07/13/2024 03:00	10.8	13.6	8.7	144.7	3,184,550.8	1,744.1	1.5	1.0
07/13/2024 04:00	10.4	13.7	8.5	135.3	3,185,762.3	1,721.5	1.4	0.9
07/13/2024 05:00	10.4	13.7	8.5	139.1	3,185,098.5	1,744.4	1.5	1.0
07/13/2024 06:00	10.5	13.7	8.6	129.5	3,160,779.5	1,708.0	1.4	0.9
07/13/2024 07:00	10.7	13.7	8.8	143.2	3,193,164.6	1,725.5	1.5	1.0
07/13/2024 08:00	10.4	13.8	8.6	132.5	3,167,071.5	1,711.4	1.4	0.9
07/13/2024 09:00	10.3	13.8	8.6	109.8	2,932,068.9	1,563.0	1.2	0.8
07/13/2024 10:00	10.4	13.9	8.8	120.9	2,969,748.9	1,561.4	1.4	0.8
07/13/2024 11:00	10.3	13.8	8.6	123.4	3,064,509.1	1,633.6	1.3	0.8
07/13/2024 12:00	10.3	13.8	8.6	129.4	3,098,838.5	1,651.9	1.4	0.8
07/13/2024 13:00	10.5	13.9	8.9	99.5	2,623,779.1	1,379.5	1.2	0.7
07/13/2024 14:00	10.7	13.9	9.0	94.8	2,518,789.9	1,324.3	1.2	0.7
07/13/2024 15:00	10.6	13.9	8.9	94.7	2,528,299.8	1,329.3	1.2	0.7
07/13/2024 16:00	10.6	14.0	9.1	95.4	2,519,360.5	1,324.6	1.2	0.7
07/13/2024 17:00	10.6	13.9	8.9	96.1	2,538,570.5	1,334.7	1.2	0.7
07/13/2024 18:00	10.6	14.0	9.1	94.4	2,528,680.2	1,329.5	1.2	0.7
07/13/2024 19:00	10.8	13.9	9.1	113.2	2,791,153.2	1,467.5	1.3	0.7
07/13/2024 20:00	11.0	13.6	8.9	150.1	3,142,007.3	1,720.8	1.6	1.0
07/13/2024 21:00	10.8	13.7	8.9	139.1	3,186,687.6	1,722.0	1.5	1.0
07/13/2024 22:00	10.5	13.7	8.6	140.8	3,210,560.0	1,734.9	1.5	1.0
07/13/2024 23:00	10.2	13.8	8.5	133.0	3,220,738.1	1,740.4	1.4	0.9
Average/Sum#:	10.6	13.8	8.8	124.5	2,976,033.7	1,598.4	1.4	0.9
Minimum:	10.2	13.6	8.5	94.4	2,518,789.9	1,324.3	1.2	0.7
Maximum:	11.0	14.0	9.1	150.1	3,220,738.1	1,744.4	1.6	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/14/2024 00:00	10.1	13.8	8.4	128.2	3,239,799.0	1,750.7	1.3	0.9
07/14/2024 01:00	10.2	13.8	8.5	118.4	3,100,339.3	1,652.7	1.3	0.8
07/14/2024 02:00	16.8	15.0	16.8	143.1	2,268,897.1	1,043.8	2.0	0.8
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 10:00	35.6	17.5	61.8	46.8	1,354,485.2	326.4	0.0	0.0
07/14/2024 11:00	42.9	15.6	47.8	242.3	2,046,916.0	822.1	3.7	1.2
07/14/2024 12:00	9.8	13.8	8.1	108.3	2,911,621.4	1,552.1	1.2	0.8
07/14/2024 13:00	10.2	13.8	8.5	112.8	2,942,386.5	1,568.5	1.3	0.8
07/14/2024 14:00	10.0	13.8	8.3	127.1	3,180,628.8	1,695.5	1.3	0.8
07/14/2024 15:00	10.2	13.8	8.5	120.4	2,888,359.9	1,539.7	1.4	0.8
07/14/2024 16:00	10.3	13.8	8.6	125.7	3,167,309.8	1,688.4	1.3	0.8
07/14/2024 17:00	10.7	13.7	8.8	135.7	3,163,185.3	1,709.3	1.4	0.9
07/14/2024 18:00	11.4	13.2	8.7	173.8	3,137,748.8	2,130.9	1.9	1.5
07/14/2024 19:00	11.4	13.2	8.7	190.6	3,104,313.9	2,176.2	2.1	1.7
07/14/2024 20:00	11.1	13.2	8.5	191.9	3,128,630.2	2,170.4	2.1	1.7
07/14/2024 21:00	11.0	13.2	8.4	187.7	3,133,675.4	2,173.9	2.1	1.7
07/14/2024 22:00	10.8	13.3	8.4	179.1	3,132,972.1	2,081.9	2.0	1.7
07/14/2024 23:00	10.8	13.3	8.4	168.0	3,124,155.0	2,007.6	1.9	1.4
Average/Sum#:	14.3	14.0	14.4	147.1	2,883,848.5	1,652.4	1.7	1.1
Minimum:	9.8	13.2	8.1	46.8	1,354,485.2	326.4	0.0	0.0
Maximum:	42.9	17.5	61.8	242.3	3,239,799.0	2,176.2	3.7	1.7
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/15/2024 00:00	10.1	13.7	8.3	141.4	3,181,691.0	1,719.3	1.5	1.0
07/15/2024 01:00	10.4	13.7	8.5	140.7	3,198,901.3	1,728.6	1.5	1.0
07/15/2024 02:00	10.3	13.8	8.6	119.4	3,037,871.0	1,619.4	1.3	0.8
07/15/2024 03:00	9.9	13.8	8.2	124.0	3,213,269.9	1,712.9	1.3	0.9
07/15/2024 04:00	10.3	13.8	8.6	134.7	3,239,428.9	1,750.5	1.4	0.9
07/15/2024 05:00	10.0	13.8	8.3	127.6	3,220,586.0	1,716.8	1.3	0.9
07/15/2024 06:00	10.2	13.8	8.5	120.2	3,187,757.3	1,699.3	1.3	0.8
07/15/2024 07:00	10.0	13.8	8.3	123.6	3,210,831.2	1,711.6	1.3	0.9
07/15/2024 08:00	10.4	13.8	8.6	106.6	2,904,117.7	1,548.1	1.2	0.8
07/15/2024 09:00	10.4	13.9	8.8	103.0	2,815,118.1	1,480.1	1.2	0.7
07/15/2024 10:00	10.2	13.9	8.6	119.1	3,084,057.8	1,621.5	1.3	0.8
07/15/2024 11:00	10.4	13.8	8.6	134.6	3,157,078.4	1,706.0	1.4	0.9
07/15/2024 12:00	10.2	13.9	8.6	126.5	3,160,327.2	1,661.6	1.3	0.8
07/15/2024 13:00	10.5	13.8	8.7	133.1	3,131,104.4	1,669.1	1.4	0.8
07/15/2024 14:00	10.6	13.8	8.8	134.3	3,121,537.2	1,664.0	1.4	0.8
07/15/2024 15:00	10.4	13.9	8.8	115.1	3,025,286.7	1,590.6	1.3	0.8
07/15/2024 16:00	10.6	13.8	8.8	120.5	2,952,516.5	1,573.9	1.4	0.8
07/15/2024 17:00	11.0	13.6	8.9	150.0	2,975,588.0	1,738.3	1.7	1.2
07/15/2024 18:00	11.3	13.2	8.7	178.1	3,119,665.3	2,141.4	2.0	1.7
07/15/2024 19:00	11.0	13.2	8.4	188.8	3,141,603.7	2,179.4	2.1	1.7
07/15/2024 20:00	10.9	13.2	8.4	191.0	3,169,343.3	2,175.5	2.1	1.7
07/15/2024 21:00	10.7	13.3	8.3	187.3	3,181,381.2	2,137.3	2.0	1.7
07/15/2024 22:00	10.3	13.4	8.1	161.1	3,273,739.4	2,008.1	1.7	1.4
07/15/2024 23:00	10.8	13.3	8.4	165.5	3,210,253.0	1,992.6	1.8	1.4
Average/Sum#:	10.5	13.7	8.5	139.4	3,121,377.3	1,772.7	1.5	1.1
Minimum:	9.9	13.2	8.1	103.0	2,815,118.1	1,480.1	1.2	0.7
Maximum:	11.3	13.9	8.9	191.0	3,273,739.4	2,179.4	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/16/2024 00:00	9.8	13.8	8.1	133.7	3,198,531.2	1,728.4	1.4	0.9
07/16/2024 01:00	9.8	13.8	8.1	127.5	3,258,479.7	1,737.0	1.3	0.9
07/16/2024 02:00	9.8	13.8	8.1	126.5	3,271,798.7	1,744.1	1.3	0.9
07/16/2024 03:00	9.8	13.8	8.1	127.5	3,280,052.8	1,748.5	1.3	0.9
07/16/2024 04:00	9.8	13.9	8.3	122.5	3,274,237.4	1,745.4	1.2	0.9
07/16/2024 05:00	9.8	13.9	8.3	131.8	3,205,391.0	1,708.7	1.4	0.9
07/16/2024 06:00	10.2	13.8	8.5	118.8	3,169,936.1	1,689.8	1.2	0.8
07/16/2024 07:00	10.0	13.8	8.3	122.8	3,229,590.4	1,721.6	1.3	0.9
07/16/2024 08:00	10.3	13.8	8.6	113.0	3,002,228.5	1,600.4	1.2	0.8
07/16/2024 09:00	10.3	13.8	8.6	119.5	3,037,871.0	1,619.4	1.3	0.8
07/16/2024 10:00	10.0	13.8	8.3	120.1	3,112,157.6	1,659.0	1.3	0.8
07/16/2024 11:00	9.8	13.9	8.3	121.4	3,207,266.9	1,709.7	1.3	0.9
07/16/2024 12:00	10.2	13.8	8.5	122.4	3,082,330.4	1,643.1	1.3	0.8
07/16/2024 13:00	10.2	13.9	8.6	114.0	2,886,671.6	1,538.8	1.3	0.8
07/16/2024 14:00	10.2	14.0	8.7	88.6	2,556,001.7	1,325.2	1.1	0.5
07/16/2024 15:00	10.3	13.9	8.7	121.1	2,853,157.7	1,500.1	1.4	0.8
07/16/2024 16:00	11.2	13.3	8.7	161.3	3,167,022.1	2,081.4	1.7	1.5
07/16/2024 17:00	11.0	13.2	8.4	186.1	3,172,058.1	2,154.2	2.0	1.7
07/16/2024 18:00	10.7	13.2	8.2	193.6	3,208,532.2	2,202.4	2.1	1.8
07/16/2024 19:00	10.7	13.2	8.2	192.0	3,213,194.1	2,205.6	2.1	1.8
07/16/2024 20:00	10.7	13.2	8.2	197.8	3,189,029.0	2,212.3	2.2	1.8
07/16/2024 21:00	10.7	13.2	8.2	202.9	3,202,146.7	2,221.4	2.2	1.8
07/16/2024 22:00	10.6	13.2	8.1	195.6	3,250,689.5	2,207.6	2.1	1.8
07/16/2024 23:00	10.3	13.3	8.0	172.2	3,242,267.8	2,083.5	1.8	1.5
Average/Sum#:	10.3	13.6	8.3	143.0	3,136,276.8	1,824.5	1.5	1.1
Minimum:	9.8	13.2	8.0	88.6	2,556,001.7	1,325.2	1.1	0.5
Maximum:	11.2	14.0	8.7	202.9	3,280,052.8	2,221.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/17/2024 00:00	10.2	13.4	8.0	163.8	3,297,090.6	2,046.5	1.7	1.4
07/17/2024 01:00	9.4	13.8	7.8	123.1	3,108,410.8	1,702.4	1.3	0.9
07/17/2024 02:00	9.2	13.9	7.8	111.8	3,269,120.3	1,718.8	1.1	0.7
07/17/2024 03:00	9.2	13.9	7.8	115.9	3,317,430.6	1,744.2	1.2	0.9
07/17/2024 04:00	9.2	13.9	7.8	115.5	3,309,252.1	1,739.9	1.2	0.9
07/17/2024 05:00	9.5	13.9	8.0	113.7	3,157,854.6	1,660.3	1.2	0.8
07/17/2024 06:00	10.0	13.9	8.4	122.7	3,202,952.3	1,707.4	1.3	0.9
07/17/2024 07:00	9.8	13.9	8.3	121.8	3,261,293.5	1,738.5	1.2	0.9
07/17/2024 08:00	9.8	13.9	8.3	121.0	3,199,200.5	1,705.4	1.3	0.9
07/17/2024 09:00	10.0	13.9	8.4	117.0	3,044,624.3	1,623.0	1.3	0.8
07/17/2024 10:00	10.1	13.9	8.5	96.0	2,718,497.6	1,429.3	1.2	0.7
07/17/2024 11:00	10.0	14.0	8.6	100.0	2,723,632.9	1,432.0	1.2	0.7
07/17/2024 12:00	10.1	13.9	8.5	111.8	2,934,372.1	1,542.8	1.3	0.8
07/17/2024 13:00	10.0	14.0	8.6	106.6	2,853,417.5	1,479.4	1.2	0.7
07/17/2024 14:00	10.2	13.9	8.6	121.6	3,003,033.6	1,578.9	1.4	0.8
07/17/2024 15:00	11.0	13.4	8.7	168.7	3,228,456.5	2,098.2	1.8	1.5
07/17/2024 16:00	10.8	13.4	8.5	173.1	3,227,795.5	2,074.2	1.8	1.5
07/17/2024 17:00	10.8	13.3	8.4	181.9	3,226,059.5	2,120.2	2.0	1.7
07/17/2024 18:00	10.9	13.2	8.4	195.6	3,194,983.6	2,193.1	2.1	1.8
07/17/2024 19:00	10.7	13.2	8.2	192.8	3,205,035.8	2,200.0	2.1	1.8
07/17/2024 20:00	10.6	13.2	8.1	197.6	3,206,055.6	2,200.7	2.2	1.8
07/17/2024 21:00	10.7	13.2	8.2	202.8	3,205,327.2	2,200.2	2.2	1.8
07/17/2024 22:00	10.8	13.2	8.3	199.2	3,205,764.2	2,200.5	2.2	1.8
07/17/2024 23:00	10.7	13.2	8.2	197.3	3,229,632.8	2,193.3	2.1	1.8
Average/Sum#:	10.2	13.6	8.3	144.6	3,138,720.6	1,847.1	1.6	1.2
Minimum:	9.2	13.2	7.8	96.0	2,718,497.6	1,429.3	1.1	0.7
Maximum:	11.0	14.0	8.7	202.8	3,317,430.6	2,200.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/18/2024 00:00	10.6	13.4	8.3	175.2	3,231,999.0	2,053.3	1.9	1.4
07/18/2024 01:00	10.8	13.3	8.4	174.9	3,260,489.3	2,071.4	1.9	1.4
07/18/2024 02:00	10.9	13.2	8.4	197.3	3,243,032.5	2,202.4	2.1	1.8
07/18/2024 03:00	10.8	13.2	8.3	197.7	3,260,123.1	2,190.2	2.1	1.8
07/18/2024 04:00	10.8	13.2	8.3	200.0	3,255,401.5	2,210.8	2.1	1.8
07/18/2024 05:00	10.8	13.3	8.4	165.2	3,312,776.1	2,153.0	1.7	1.5
07/18/2024 06:00	11.0	13.4	8.7	171.0	3,239,869.2	2,058.3	1.8	1.4
07/18/2024 07:00	10.8	13.4	8.5	165.8	3,228,619.4	2,004.0	1.8	1.4
07/18/2024 08:00	10.9	13.4	8.6	172.3	3,228,693.4	2,051.2	1.8	1.4
07/18/2024 09:00	11.0	13.3	8.5	188.4	3,215,589.0	2,136.8	2.0	1.7
07/18/2024 10:00	11.0	13.3	8.5	191.8	3,185,251.3	2,139.9	2.1	1.7
07/18/2024 11:00	10.9	13.3	8.5	192.6	3,197,010.5	2,147.8	2.1	1.7
07/18/2024 12:00	10.9	13.3	8.5	184.3	3,175,258.7	2,110.0	2.0	1.7
07/18/2024 13:00	10.9	13.2	8.4	194.2	3,163,370.3	2,171.4	2.1	1.7
07/18/2024 14:00	10.8	13.2	8.3	192.2	3,156,377.5	2,166.6	2.1	1.7
07/18/2024 15:00	10.8	13.2	8.3	193.7	3,159,873.9	2,169.0	2.1	1.7
07/18/2024 16:00	10.8	13.2	8.3	195.6	3,150,258.8	2,162.4	2.2	1.7
07/18/2024 17:00	10.9	13.2	8.4	194.8	3,145,742.6	2,159.3	2.2	1.7
07/18/2024 18:00	10.9	13.2	8.4	189.1	3,148,364.9	2,161.1	2.1	1.7
07/18/2024 19:00	10.9	13.2	8.4	191.3	3,122,864.2	2,166.4	2.1	1.7
07/18/2024 20:00	10.9	13.2	8.4	197.1	3,167,449.5	2,174.2	2.2	1.7
07/18/2024 21:00	10.8	13.2	8.3	195.1	3,173,276.8	2,178.2	2.1	1.7
07/18/2024 22:00	10.8	13.2	8.3	194.6	3,193,526.8	2,192.1	2.1	1.8
07/18/2024 23:00	10.7	13.2	8.2	189.0	3,198,796.7	2,149.0	2.1	1.7
Average/Sum#:	10.9	13.3	8.4	187.6	3,200,584.0	2,140.8	2.0	1.6
Minimum:	10.6	13.2	8.2	165.2	3,122,864.2	2,004.0	1.7	1.4
Maximum:	11.0	13.4	8.7	200.0	3,312,776.1	2,210.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/19/2024 00:00	10.5	13.3	8.2	185.2	3,230,624.3	2,123.2	2.0	1.7
07/19/2024 01:00	10.6	13.3	8.2	180.4	3,235,072.8	2,102.5	1.9	1.5
07/19/2024 02:00	10.6	13.3	8.2	181.1	3,232,298.0	2,124.3	1.9	1.5
07/19/2024 03:00	10.4	13.4	8.2	163.5	3,231,204.6	2,029.2	1.7	1.4
07/19/2024 04:00	10.6	13.2	8.1	188.9	3,244,063.3	2,203.1	2.0	1.8
07/19/2024 05:00	10.5	13.3	8.2	160.7	3,313,692.2	2,105.2	1.7	1.5
07/19/2024 06:00	9.9	13.8	8.2	130.6	3,260,918.4	1,738.3	1.3	0.9
07/19/2024 07:00	10.2	13.8	8.5	142.1	3,228,880.6	1,744.8	1.5	1.0
07/19/2024 08:00	10.1	13.8	8.4	128.3	3,275,550.6	1,746.1	1.3	0.9
07/19/2024 09:00	10.3	13.7	8.4	139.8	3,233,136.9	1,747.1	1.5	1.0
07/19/2024 10:00	10.5	13.7	8.6	142.2	3,232,396.7	1,746.7	1.5	1.0
07/19/2024 11:00	10.6	13.6	8.6	139.3	3,186,194.1	1,745.0	1.5	1.0
07/19/2024 12:00	10.8	13.6	8.7	144.1	3,165,378.8	1,733.6	1.5	1.0
07/19/2024 13:00	11.3	13.2	8.7	175.8	3,147,320.1	2,137.4	1.9	1.5
07/19/2024 14:00	11.0	13.2	8.4	183.4	3,141,517.8	2,156.4	2.0	1.7
07/19/2024 15:00	10.8	13.2	8.3	187.2	3,147,490.8	2,160.5	2.1	1.7
07/19/2024 16:00	10.7	13.2	8.2	189.5	3,149,676.1	2,162.0	2.1	1.7
07/19/2024 17:00	10.7	13.2	8.2	189.6	3,110,323.2	2,157.7	2.1	1.7
07/19/2024 18:00	10.7	13.2	8.2	184.7	3,114,503.5	2,160.6	2.1	1.7
07/19/2024 19:00	10.8	13.2	8.3	186.1	3,113,782.7	2,160.1	2.1	1.7
07/19/2024 20:00	10.6	13.3	8.2	193.4	3,158,562.8	2,168.1	2.1	1.7
07/19/2024 21:00	10.5	13.3	8.2	192.2	3,192,673.1	2,168.2	2.1	1.7
07/19/2024 22:00	10.4	13.3	8.1	185.2	3,178,230.0	2,181.6	2.0	1.7
07/19/2024 23:00	10.6	13.2	8.1	195.2	3,194,692.3	2,192.9	2.1	1.8
Average/Sum#:	10.6	13.4	8.3	170.4	3,196,591.0	2,028.9	1.8	1.5
Minimum:	9.9	13.2	8.1	128.3	3,110,323.2	1,733.6	1.3	0.9
Maximum:	11.3	13.8	8.7	195.2	3,313,692.2	2,203.1	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/20/2024 00:00	10.8	13.2	8.3	200.6	3,187,699.5	2,188.1	2.2	1.8
07/20/2024 01:00	10.6	13.2	8.1	194.8	3,205,764.2	2,200.5	2.1	1.8
07/20/2024 02:00	10.5	13.3	8.2	192.1	3,206,346.9	2,200.9	2.1	1.8
07/20/2024 03:00	10.4	13.3	8.1	196.8	3,210,280.4	2,203.6	2.1	1.8
07/20/2024 04:00	10.3	13.3	8.0	193.2	3,213,776.8	2,206.0	2.1	1.8
07/20/2024 05:00	10.3	13.3	8.0	180.2	3,285,849.2	2,135.5	1.9	1.5
07/20/2024 06:00	9.9	13.9	8.3	129.6	3,199,950.8	1,705.8	1.4	0.9
07/20/2024 07:00	10.0	13.8	8.3	132.7	3,246,848.9	1,730.8	1.4	0.9
07/20/2024 08:00	10.3	13.9	8.7	113.4	2,986,866.7	1,570.4	1.3	0.8
07/20/2024 09:00	10.4	13.8	8.6	123.8	3,009,544.6	1,604.3	1.4	0.8
07/20/2024 10:00	10.5	13.7	8.6	136.1	3,160,224.4	1,707.7	1.4	0.9
07/20/2024 11:00	10.5	13.8	8.7	127.7	3,000,519.9	1,621.4	1.4	0.8
07/20/2024 12:00	10.4	14.0	8.9	91.0	2,585,704.7	1,340.6	1.1	0.5
07/20/2024 13:00	10.6	13.8	8.8	137.9	3,075,577.1	1,639.5	1.5	1.0
07/20/2024 14:00	11.3	13.2	8.7	178.2	3,108,593.4	2,133.8	2.0	1.7
07/20/2024 15:00	11.1	13.2	8.5	188.1	3,103,692.3	2,153.1	2.1	1.7
07/20/2024 16:00	11.1	13.2	8.5	188.2	3,101,097.6	2,151.3	2.1	1.7
07/20/2024 17:00	11.1	13.2	8.5	193.4	3,094,034.2	2,146.4	2.2	1.7
07/20/2024 18:00	11.2	13.2	8.6	191.3	3,105,710.4	2,154.5	2.1	1.7
07/20/2024 19:00	11.1	13.2	8.5	190.7	3,108,593.4	2,156.5	2.1	1.7
07/20/2024 20:00	11.1	13.2	8.5	194.7	3,109,170.0	2,156.9	2.2	1.7
07/20/2024 21:00	10.9	13.2	8.4	192.4	3,145,451.3	2,159.1	2.1	1.7
07/20/2024 22:00	11.1	13.2	8.5	201.7	3,136,126.0	2,175.6	2.2	1.7
07/20/2024 23:00	11.2	13.2	8.6	200.3	3,150,829.3	2,185.8	2.2	1.7
Average/Sum#:	10.7	13.4	8.5	169.5	3,114,093.8	1,984.5	1.9	1.4
Minimum:	9.9	13.2	8.0	91.0	2,585,704.7	1,340.6	1.1	0.5
Maximum:	11.3	14.0	8.9	201.7	3,285,849.2	2,206.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/21/2024 00:00	11.0	13.2	8.4	197.1	3,173,460.8	2,201.5	2.2	1.8
07/21/2024 01:00	10.8	13.2	8.3	199.5	3,182,542.3	2,207.8	2.2	1.8
07/21/2024 02:00	10.7	13.2	8.2	203.5	3,223,391.9	2,212.6	2.2	1.8
07/21/2024 03:00	10.6	13.2	8.1	194.9	3,221,498.0	2,211.3	2.1	1.8
07/21/2024 04:00	10.6	13.2	8.1	195.2	3,223,246.2	2,212.5	2.1	1.8
07/21/2024 05:00	14.2	13.5	11.3	177.8	3,164,392.3	1,548.2	1.9	1.1
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 10:00	34.0	17.4	57.3	230.2	1,369,815.6	350.1	5.1	0.7
07/21/2024 11:00	37.4	14.9	36.8	234.7	2,345,028.8	1,061.7	3.1	1.3
07/21/2024 12:00	10.2	13.9	8.6	99.5	2,719,258.4	1,429.7	1.2	0.7
07/21/2024 13:00	10.5	13.9	8.9	98.9	2,656,683.3	1,396.8	1.2	0.7
07/21/2024 14:00	10.7	13.8	8.9	139.4	3,025,865.1	1,613.0	1.6	1.0
07/21/2024 15:00	11.0	13.6	8.9	145.6	3,150,223.9	1,725.3	1.6	1.0
07/21/2024 16:00	11.3	13.4	8.9	171.1	3,035,026.6	1,906.0	1.9	1.3
07/21/2024 17:00	11.9	13.1	9.0	214.4	3,115,800.8	2,161.5	2.4	1.9
07/21/2024 18:00	11.9	13.1	9.0	209.7	3,087,766.7	2,164.6	2.4	1.9
07/21/2024 19:00	11.8	13.1	8.9	219.9	3,120,269.5	2,164.6	2.5	2.2
07/21/2024 20:00	11.8	13.1	8.9	216.9	3,124,882.3	2,167.8	2.4	2.0
07/21/2024 21:00	11.8	13.1	8.9	215.9	3,131,224.9	2,172.2	2.4	2.0
07/21/2024 22:00	11.8	13.1	8.9	222.5	3,131,369.0	2,172.3	2.5	2.2
07/21/2024 23:00	11.6	13.1	8.8	212.2	3,146,793.1	2,183.0	2.4	2.0
Average/Sum#:	13.8	13.6	12.7	189.9	2,967,427.0	1,863.1	2.3	1.6
Minimum:	10.2	13.1	8.1	98.9	1,369,815.6	350.1	1.2	0.7
Maximum:	37.4	17.4	57.3	234.7	3,223,391.9	2,212.6	5.1	2.2
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/22/2024 00:00	11.7	13.1	8.9	229.0	3,149,676.1	2,185.0	2.6	2.2
07/22/2024 01:00	11.7	13.2	9.0	214.6	3,150,829.3	2,185.8	2.4	2.0
07/22/2024 02:00	11.4	13.2	8.7	203.1	3,160,210.1	2,100.0	2.2	1.7
07/22/2024 03:00	11.0	13.4	8.7	162.5	3,121,611.3	1,846.4	1.8	1.3
07/22/2024 04:00	10.3	13.9	8.7	101.3	2,717,275.6	1,448.5	1.2	0.7
07/22/2024 05:00	10.5	13.8	8.7	127.3	2,980,780.4	1,632.5	1.4	0.8
07/22/2024 06:00	10.2	13.8	8.5	123.2	3,215,896.2	1,714.3	1.3	0.9
07/22/2024 07:00	10.2	13.8	8.5	126.4	3,195,073.4	1,703.2	1.3	0.9
07/22/2024 08:00	10.2	13.8	8.5	125.9	3,194,885.8	1,703.1	1.3	0.9
07/22/2024 09:00	10.3	13.8	8.6	128.8	3,168,622.9	1,689.1	1.4	0.8
07/22/2024 10:00	10.5	13.8	8.7	126.2	3,140,859.2	1,674.3	1.3	0.8
07/22/2024 11:00	10.6	13.8	8.8	130.1	3,111,219.6	1,658.5	1.4	0.8
07/22/2024 12:00	11.4	13.4	9.0	149.7	3,013,063.6	1,826.2	1.7	1.3
07/22/2024 13:00	11.5	13.2	8.8	185.5	3,098,214.6	2,149.3	2.1	1.7
07/22/2024 14:00	11.3	13.2	8.7	185.0	3,099,511.9	2,150.2	2.1	1.7
07/22/2024 15:00	11.3	13.2	8.7	182.3	3,062,232.6	2,146.7	2.1	1.7
07/22/2024 16:00	11.1	13.2	8.5	184.7	3,098,935.3	2,149.8	2.1	1.7
07/22/2024 17:00	10.9	13.2	8.4	187.9	3,102,539.1	2,152.3	2.1	1.7
07/22/2024 18:00	11.1	13.2	8.5	182.4	3,095,475.7	2,147.4	2.0	1.7
07/22/2024 19:00	11.1	13.2	8.5	186.0	3,104,989.6	2,154.0	2.1	1.7
07/22/2024 20:00	11.1	13.2	8.5	190.2	3,104,268.9	2,153.5	2.1	1.7
07/22/2024 21:00	11.1	13.2	8.5	192.4	3,097,205.5	2,148.6	2.2	1.7
07/22/2024 22:00	11.0	13.2	8.4	192.1	3,121,134.4	2,165.2	2.1	1.7
07/22/2024 23:00	10.9	13.2	8.4	188.9	3,130,215.8	2,171.5	2.1	1.7
Average/Sum#:	10.9	13.4	8.6	166.9	3,101,447.0	1,960.6	1.9	1.4
Minimum:	10.2	13.1	8.4	101.3	2,717,275.6	1,448.5	1.2	0.7
Maximum:	11.7	13.9	9.0	229.0	3,215,896.2	2,185.8	2.6	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/23/2024 00:00	10.8	13.2	8.3	189.5	3,134,396.2	2,174.4	2.1	1.7
07/23/2024 01:00	10.8	13.2	8.3	193.5	3,140,450.5	2,178.6	2.2	1.7
07/23/2024 02:00	10.8	13.2	8.3	196.4	3,152,126.6	2,186.7	2.2	1.7
07/23/2024 03:00	10.8	13.2	8.3	188.8	3,152,559.1	2,187.0	2.1	1.7
07/23/2024 04:00	10.7	13.2	8.2	193.0	3,163,514.5	2,194.6	2.1	1.8
07/23/2024 05:00	10.9	13.2	8.4	217.1	3,171,586.9	2,200.2	2.4	2.0
07/23/2024 06:00	11.2	13.3	8.7	179.3	3,185,889.8	2,093.8	1.9	1.5
07/23/2024 07:00	11.0	13.2	8.4	187.8	3,171,616.3	2,153.9	2.1	1.7
07/23/2024 08:00	10.7	13.3	8.3	169.4	3,159,985.2	2,053.7	1.9	1.4
07/23/2024 09:00	10.8	13.2	8.3	176.0	3,138,065.7	2,108.2	1.9	1.5
07/23/2024 10:00	10.9	13.2	8.4	185.2	3,119,228.2	2,141.1	2.1	1.7
07/23/2024 11:00	10.9	13.2	8.4	182.8	3,109,458.3	2,157.1	2.0	1.7
07/23/2024 12:00	10.8	13.2	8.3	184.8	3,112,526.8	2,136.5	2.1	1.7
07/23/2024 13:00	10.8	13.2	8.3	180.3	3,110,949.4	2,112.7	2.0	1.7
07/23/2024 14:00	10.8	13.2	8.3	185.8	3,121,267.8	2,142.5	2.1	1.7
07/23/2024 15:00	10.9	13.2	8.4	185.9	3,093,745.9	2,146.2	2.1	1.7
07/23/2024 16:00	11.0	13.2	8.4	180.3	3,088,844.8	2,142.8	2.0	1.7
07/23/2024 17:00	10.9	13.2	8.4	182.3	3,086,250.1	2,141.0	2.1	1.7
07/23/2024 18:00	10.9	13.2	8.4	187.1	3,093,890.1	2,146.3	2.1	1.7
07/23/2024 19:00	10.8	13.2	8.3	187.6	3,111,764.7	2,158.7	2.1	1.7
07/23/2024 20:00	10.9	13.2	8.4	185.4	3,111,908.8	2,158.8	2.1	1.7
07/23/2024 21:00	10.7	13.2	8.2	189.5	3,155,503.4	2,166.0	2.1	1.7
07/23/2024 22:00	10.5	13.3	8.2	196.9	3,175,753.4	2,179.9	2.2	1.7
07/23/2024 23:00	10.5	13.3	8.2	189.5	3,190,467.4	2,190.0	2.1	1.8
Average/Sum#:	10.8	13.2	8.3	187.3	3,135,489.6	2,152.1	2.1	1.7
Minimum:	10.5	13.2	8.2	169.4	3,086,250.1	2,053.7	1.9	1.4
Maximum:	11.2	13.3	8.7	217.1	3,190,467.4	2,200.2	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/24/2024 00:00	10.7	13.2	8.2	194.7	3,184,203.1	2,185.7	2.1	1.7
07/24/2024 01:00	10.8	13.2	8.3	195.6	3,173,422.5	2,178.3	2.2	1.7
07/24/2024 02:00	10.8	13.2	8.3	197.6	3,179,249.8	2,182.3	2.2	1.7
07/24/2024 03:00	10.6	13.2	8.1	194.9	3,205,764.2	2,200.5	2.1	1.8
07/24/2024 04:00	10.5	13.2	8.0	189.2	3,214,796.6	2,206.7	2.1	1.8
07/24/2024 05:00	10.5	13.2	8.0	181.3	3,221,061.0	2,211.0	2.0	1.8
07/24/2024 06:00	10.9	13.3	8.5	183.0	3,216,658.8	2,161.0	2.0	1.7
07/24/2024 07:00	10.7	13.3	8.3	180.5	3,232,293.0	2,147.9	1.9	1.5
07/24/2024 08:00	10.7	13.3	8.3	178.1	3,212,579.3	2,134.8	1.9	1.5
07/24/2024 09:00	10.7	13.3	8.3	179.4	3,188,351.0	2,118.7	2.0	1.7
07/24/2024 10:00	10.8	13.3	8.4	180.8	3,174,205.3	2,109.3	2.0	1.7
07/24/2024 11:00	10.8	13.2	8.3	182.6	3,159,797.9	2,122.8	2.0	1.7
07/24/2024 12:00	10.9	13.2	8.4	187.3	3,126,221.0	2,145.9	2.1	1.7
07/24/2024 13:00	11.0	13.2	8.4	184.7	3,112,569.1	2,113.8	2.1	1.7
07/24/2024 14:00	11.1	13.2	8.5	185.8	3,107,136.5	2,132.8	2.1	1.7
07/24/2024 15:00	11.2	13.2	8.6	184.8	3,081,493.2	2,137.7	2.1	1.7
07/24/2024 16:00	10.7	13.3	8.3	172.6	3,130,960.6	2,057.7	1.9	1.4
07/24/2024 17:00	10.6	13.4	8.3	165.9	3,131,058.1	2,034.9	1.8	1.4
07/24/2024 18:00	10.6	13.3	8.2	167.1	3,146,291.0	2,044.8	1.8	1.4
07/24/2024 19:00	10.5	13.3	8.2	170.7	3,183,065.4	2,068.7	1.9	1.4
07/24/2024 20:00	10.3	13.4	8.1	169.2	3,191,220.4	2,074.0	1.8	1.5
07/24/2024 21:00	10.4	13.3	8.1	180.6	3,239,817.3	2,152.9	1.9	1.5
07/24/2024 22:00	10.4	13.3	8.1	189.3	3,235,228.3	2,197.1	2.0	1.8
07/24/2024 23:00	10.4	13.3	8.1	196.0	3,233,608.5	2,196.0	2.1	1.8
Average/Sum#:	10.7	13.3	8.3	183.0	3,178,377.2	2,138.1	2.0	1.6
Minimum:	10.3	13.2	8.0	165.9	3,081,493.2	2,034.9	1.8	1.4
Maximum:	11.2	13.4	8.6	197.6	3,239,817.3	2,211.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/25/2024 00:00	10.4	13.3	8.1	181.2	3,243,862.0	2,131.9	1.9	1.5
07/25/2024 01:00	10.4	13.3	8.1	177.6	3,261,999.7	2,120.0	1.9	1.5
07/25/2024 02:00	10.4	13.3	8.1	171.9	3,247,074.5	2,110.3	1.8	1.5
07/25/2024 03:00	10.5	13.2	8.0	185.3	3,263,844.4	2,192.7	2.0	1.8
07/25/2024 04:00	10.4	13.2	8.0	187.7	3,248,628.0	2,206.2	2.0	1.8
07/25/2024 05:00	10.4	13.2	8.0	197.0	3,250,100.5	2,207.2	2.1	1.8
07/25/2024 06:00	10.9	13.3	8.5	177.1	3,265,772.8	2,146.3	1.9	1.5
07/25/2024 07:00	10.7	13.3	8.3	178.3	3,236,506.6	2,150.7	1.9	1.5
07/25/2024 08:00	10.6	13.3	8.2	180.4	3,222,511.4	2,141.4	1.9	1.5
07/25/2024 09:00	10.6	13.3	8.2	180.4	3,240,058.1	2,129.4	1.9	1.5
07/25/2024 10:00	10.6	13.3	8.2	176.2	3,221,686.3	2,093.8	1.9	1.5
07/25/2024 11:00	10.8	13.2	8.3	190.9	3,217,700.8	2,161.7	2.1	1.7
07/25/2024 12:00	10.9	13.2	8.4	191.0	3,181,040.3	2,160.3	2.1	1.7
07/25/2024 13:00	10.9	13.2	8.4	191.2	3,176,033.8	2,156.9	2.1	1.7
07/25/2024 14:00	10.9	13.2	8.4	185.0	3,133,213.9	2,150.7	2.1	1.7
07/25/2024 15:00	10.9	13.2	8.4	187.0	3,134,525.0	2,151.6	2.1	1.7
07/25/2024 16:00	10.9	13.2	8.4	187.6	3,132,595.1	2,127.4	2.1	1.7
07/25/2024 17:00	10.9	13.2	8.4	188.6	3,122,579.0	2,143.4	2.1	1.7
07/25/2024 18:00	10.8	13.3	8.4	186.6	3,130,828.1	2,126.2	2.1	1.7
07/25/2024 19:00	10.8	13.3	8.4	181.4	3,147,719.8	2,091.7	2.0	1.7
07/25/2024 20:00	10.8	13.2	8.3	186.6	3,159,689.1	2,145.8	2.1	1.7
07/25/2024 21:00	10.8	13.2	8.3	193.6	3,177,793.0	2,181.3	2.1	1.7
07/25/2024 22:00	10.7	13.2	8.2	189.4	3,205,631.1	2,177.0	2.1	1.7
07/25/2024 23:00	10.7	13.2	8.2	194.7	3,204,744.4	2,199.8	2.1	1.8
Average/Sum#:	10.7	13.2	8.3	185.3	3,201,089.1	2,150.2	2.0	1.7
Minimum:	10.4	13.2	8.0	171.9	3,122,579.0	2,091.7	1.8	1.5
Maximum:	10.9	13.3	8.5	197.0	3,265,772.8	2,207.2	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/26/2024 00:00	10.8	13.2	8.3	197.6	3,224,479.0	2,189.8	2.1	1.8
07/26/2024 01:00	10.5	13.3	8.2	173.8	3,225,150.0	2,072.5	1.9	1.5
07/26/2024 02:00	10.4	13.4	8.2	158.4	3,284,308.6	1,990.6	1.7	1.4
07/26/2024 03:00	10.5	13.4	8.3	157.1	3,289,423.4	1,993.7	1.6	1.2
07/26/2024 04:00	10.7	13.3	8.3	179.0	3,302,005.3	2,146.0	1.9	1.5
07/26/2024 05:00	10.6	13.3	8.2	166.0	3,359,070.6	2,109.5	1.7	1.5
07/26/2024 06:00	10.8	13.4	8.5	157.3	3,290,248.3	1,994.2	1.6	1.2
07/26/2024 07:00	10.7	13.4	8.4	156.4	3,253,687.1	1,995.8	1.6	1.2
07/26/2024 08:00	10.7	13.4	8.4	159.4	3,262,327.5	2,001.1	1.7	1.4
07/26/2024 09:00	10.8	13.4	8.5	161.7	3,238,447.0	2,010.1	1.7	1.4
07/26/2024 10:00	10.9	13.4	8.6	164.4	3,216,554.9	2,020.0	1.8	1.4
07/26/2024 11:00	10.9	13.3	8.5	165.6	3,196,110.6	2,030.5	1.8	1.4
07/26/2024 12:00	10.9	13.3	8.5	166.0	3,179,243.2	2,043.0	1.8	1.4
07/26/2024 13:00	10.8	13.3	8.4	171.1	3,145,872.1	2,067.5	1.9	1.4
07/26/2024 14:00	10.9	13.3	8.5	174.9	3,164,131.1	2,079.5	1.9	1.5
07/26/2024 15:00	10.9	13.2	8.4	180.4	3,139,107.7	2,108.9	2.0	1.7
07/26/2024 16:00	11.0	13.2	8.4	182.8	3,096,355.9	2,125.4	2.1	1.7
07/26/2024 17:00	11.0	13.2	8.4	180.4	3,101,891.9	2,129.2	2.0	1.7
07/26/2024 18:00	10.9	13.3	8.5	178.8	3,104,723.2	2,085.8	2.0	1.7
07/26/2024 19:00	10.8	13.3	8.4	183.9	3,184,804.8	2,139.6	2.0	1.7
07/26/2024 20:00	10.8	13.2	8.3	193.1	3,206,661.8	2,177.7	2.1	1.7
07/26/2024 21:00	10.6	13.3	8.2	179.3	3,229,533.5	2,098.9	1.9	1.5
07/26/2024 22:00	10.6	13.3	8.2	173.7	3,224,763.6	2,095.8	1.9	1.5
07/26/2024 23:00	10.4	13.4	8.2	156.9	3,250,100.5	1,993.6	1.7	1.4
Average/Sum#:	10.7	13.3	8.4	171.6	3,215,375.1	2,070.8	1.9	1.5
Minimum:	10.4	13.2	8.2	156.4	3,096,355.9	1,990.6	1.6	1.2
Maximum:	11.0	13.4	8.6	197.6	3,359,070.6	2,189.8	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/27/2024 00:00	10.2	13.4	8.0	151.1	3,292,558.2	1,995.6	1.6	1.2
07/27/2024 01:00	9.9	13.4	7.8	144.4	3,287,113.5	1,992.3	1.5	1.2
07/27/2024 02:00	9.7	13.5	7.7	140.4	3,320,520.1	1,988.3	1.4	1.0
07/27/2024 03:00	9.5	13.5	7.6	140.0	3,318,850.1	1,987.3	1.4	1.0
07/27/2024 04:00	9.6	13.4	7.6	149.0	3,354,759.8	2,033.3	1.5	1.2
07/27/2024 05:00	10.0	13.3	7.8	179.1	3,365,360.4	2,064.3	1.8	1.4
07/27/2024 06:00	22.2	16.0	26.7	158.7	1,674,432.5	672.5	3.1	0.8
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 11:00	19.4	18.1	40.9	165.3	899,825.9	157.7	0.0	0.0
07/27/2024 12:00	36.4	15.3	38.4	212.9	2,193,204.0	928.9	3.0	1.1
07/27/2024 13:00	10.0	13.9	8.4	93.0	2,709,368.1	1,424.5	1.1	0.6
07/27/2024 14:00	10.1	14.0	8.6	96.0	2,651,167.6	1,393.9	1.2	0.7
07/27/2024 15:00	10.3	13.8	8.6	132.8	3,073,701.2	1,638.5	1.5	1.0
07/27/2024 16:00	10.1	14.0	8.6	101.1	2,760,836.7	1,431.4	1.2	0.7
07/27/2024 17:00	10.3	13.8	8.6	137.0	3,207,784.1	1,733.4	1.4	0.9
07/27/2024 18:00	10.4	13.8	8.6	126.9	2,979,529.8	1,588.3	1.4	0.8
07/27/2024 19:00	11.1	13.3	8.6	154.9	3,256,974.5	2,021.6	1.6	1.2
07/27/2024 20:00	10.9	13.4	8.6	159.8	3,229,102.7	2,004.3	1.7	1.4
07/27/2024 21:00	10.8	13.4	8.5	161.6	3,253,361.1	1,995.6	1.7	1.4
07/27/2024 22:00	10.8	13.4	8.5	160.5	3,245,698.8	1,990.9	1.7	1.4
07/27/2024 23:00	10.7	13.4	8.4	161.6	3,240,155.9	1,987.5	1.7	1.4
Average/Sum#:	12.6	14.0	12.3	146.3	2,915,715.3	1,651.5	1.6	1.0
Minimum:	9.5	13.3	7.6	93.0	899,825.9	157.7	0.0	0.0
Maximum:	36.4	18.1	40.9	212.9	3,365,360.4	2,064.3	3.1	1.4
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/28/2024 00:00	10.7	13.4	8.4	158.5	3,275,894.1	1,985.5	1.7	1.4
07/28/2024 01:00	10.6	13.4	8.3	156.0	3,277,874.0	1,986.7	1.6	1.2
07/28/2024 02:00	10.4	13.4	8.2	154.7	3,273,254.3	1,983.9	1.6	1.2
07/28/2024 03:00	10.5	13.4	8.3	154.8	3,294,801.7	1,972.9	1.6	1.2
07/28/2024 04:00	10.4	13.4	8.2	154.0	3,257,226.0	1,950.4	1.6	1.2
07/28/2024 05:00	9.6	13.9	8.1	118.5	3,188,132.5	1,699.5	1.2	0.8
07/28/2024 06:00	10.2	14.0	8.7	91.4	2,499,009.3	1,313.9	1.2	0.7
07/28/2024 07:00	30.9	17.1	48.0	197.9	963,658.0	323.7	6.8	0.8
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.9	14.0	13.3	148.2	2,878,731.2	1,652.1	2.2	1.1
Minimum:	9.6	13.4	8.1	91.4	963,658.0	323.7	1.2	0.7
Maximum:	30.9	17.1	48.0	197.9	3,294,801.7	1,986.7	6.8	1.4
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 10:00	38.2	17.4	64.4	4.2	1,295,084.2	331.0	0.0	0.0
07/29/2024 11:00	42.1	17.0	63.7	255.2	1,454,261.9	435.4	5.5	0.9
07/29/2024 12:00	30.8	14.6	28.8	206.5	2,351,196.3	1,116.0	2.8	1.2
07/29/2024 13:00	9.9	13.9	8.3	92.6	2,645,081.2	1,390.7	1.2	0.7
07/29/2024 14:00	10.1	13.9	8.5	114.1	2,968,797.9	1,560.9	1.3	0.8
07/29/2024 15:00	10.1	13.8	8.4	120.4	2,996,975.9	1,597.6	1.3	0.8
07/29/2024 16:00	10.3	13.9	8.7	117.1	2,817,450.0	1,501.9	1.4	0.8
07/29/2024 17:00	10.5	13.8	8.7	131.8	3,123,413.1	1,665.0	1.4	0.8
07/29/2024 18:00	11.0	13.5	8.8	147.7	3,024,924.9	1,811.3	1.7	1.3
07/29/2024 19:00	11.1	13.2	8.5	183.0	3,165,992.6	2,173.2	2.0	1.7
07/29/2024 20:00	10.9	13.2	8.4	189.7	3,180,415.3	2,183.1	2.1	1.7
07/29/2024 21:00	10.7	13.3	8.3	175.6	3,188,172.1	2,095.3	1.9	1.5
07/29/2024 22:00	10.7	13.3	8.3	175.2	3,158,957.7	2,076.1	1.9	1.5
07/29/2024 23:00	21.6	16.1	26.6	169.2	1,560,147.9	626.6	3.6	0.9
Average/Sum#:	17.0	14.4	19.2	148.7	2,637,919.4	1,468.9	2.0	1.0
Minimum:	9.9	13.2	8.3	4.2	1,295,084.2	331.0	0.0	0.0
Maximum:	42.1	17.4	64.4	255.2	3,188,172.1	2,183.1	5.5	1.7
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 10:00	38.6	17.4	65.1	41.3	1,380,379.8	352.8	0.0	0.0
07/30/2024 11:00	41.2	17.1	64.0	268.7	1,437,210.9	419.8	5.8	0.9
07/30/2024 12:00	42.4	15.2	43.9	248.1	2,109,145.7	908.7	3.7	1.3
07/30/2024 13:00	9.7	14.0	8.3	94.6	2,660,867.7	1,399.0	1.2	0.7
07/30/2024 14:00	10.0	14.0	8.6	98.4	2,668,475.6	1,403.0	1.2	0.7
07/30/2024 15:00	10.1	13.8	8.4	120.9	3,078,578.6	1,641.1	1.3	0.8
07/30/2024 16:00	10.2	13.9	8.6	98.4	2,687,305.2	1,412.9	1.2	0.7
07/30/2024 17:00	10.2	13.9	8.6	103.2	2,753,874.4	1,447.9	1.2	0.7
07/30/2024 18:00	10.5	13.7	8.6	134.0	3,057,327.7	1,741.4	1.5	1.0
07/30/2024 19:00	11.1	13.2	8.5	184.7	3,156,814.6	2,166.9	2.0	1.7
07/30/2024 20:00	10.9	13.2	8.4	188.2	3,162,350.5	2,170.7	2.1	1.7
07/30/2024 21:00	10.8	13.2	8.3	184.8	3,155,212.1	2,165.8	2.0	1.7
07/30/2024 22:00	10.7	13.2	8.2	188.3	3,174,266.8	2,155.7	2.1	1.7
07/30/2024 23:00	10.7	13.2	8.2	190.4	3,206,388.1	2,154.1	2.1	1.7
Average/Sum#:	16.9	14.2	19.0	153.1	2,692,014.1	1,538.6	2.0	1.1
Minimum:	9.7	13.2	8.2	41.3	1,380,379.8	352.8	0.0	0.0
Maximum:	42.4	17.4	65.1	268.7	3,206,388.1	2,170.7	5.8	1.7
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/31/2024 00:00	10.7	13.3	8.3	165.8	3,212,508.5	1,994.0	1.8	1.4
07/31/2024 01:00	10.7	13.4	8.4	161.1	3,239,503.8	1,987.1	1.7	1.4
07/31/2024 02:00	10.6	13.4	8.3	158.4	3,235,754.2	1,984.8	1.7	1.4
07/31/2024 03:00	10.6	13.4	8.3	160.5	3,242,796.9	2,012.8	1.7	1.4
07/31/2024 04:00	10.7	13.2	8.2	192.2	3,245,241.3	2,203.9	2.1	1.8
07/31/2024 05:00	10.6	13.2	8.1	162.9	3,264,153.8	2,121.4	1.7	1.5
07/31/2024 06:00	9.8	13.8	8.1	122.5	3,220,773.6	1,716.9	1.3	0.9
07/31/2024 07:00	10.1	13.8	8.4	112.6	2,982,531.3	1,589.9	1.3	0.8
07/31/2024 08:00	10.0	13.8	8.3	102.0	2,801,879.8	1,493.6	1.2	0.7
07/31/2024 09:00	10.1	13.8	8.4	103.9	2,811,447.0	1,498.7	1.2	0.7
07/31/2024 10:00	10.2	13.8	8.5	110.7	2,900,741.0	1,546.3	1.3	0.8
07/31/2024 11:00	10.3	13.9	8.7	115.5	3,002,653.2	1,578.7	1.3	0.8
07/31/2024 12:00	10.3	13.9	8.7	100.7	2,784,115.9	1,463.8	1.2	0.7
07/31/2024 13:00	10.7	13.8	8.9	132.5	3,053,066.0	1,627.5	1.5	1.0
07/31/2024 14:00	11.3	13.2	8.7	168.5	3,152,836.3	2,095.1	1.8	1.5
07/31/2024 15:00	11.1	13.2	8.5	182.6	3,120,102.3	2,141.7	2.0	1.7
07/31/2024 16:00	10.9	13.2	8.4	180.6	3,119,082.6	2,141.0	2.0	1.7
07/31/2024 17:00	10.9	13.2	8.4	184.2	3,116,751.6	2,139.4	2.1	1.7
07/31/2024 18:00	10.8	13.2	8.3	184.2	3,118,208.5	2,140.4	2.1	1.7
07/31/2024 19:00	10.8	13.2	8.3	183.3	3,119,373.9	2,141.2	2.0	1.7
07/31/2024 20:00	10.8	13.2	8.3	186.4	3,129,134.7	2,147.9	2.1	1.7
07/31/2024 21:00	10.8	13.2	8.3	189.7	3,132,631.1	2,150.3	2.1	1.7
07/31/2024 22:00	10.9	13.2	8.4	192.1	3,159,689.1	2,145.8	2.1	1.7
07/31/2024 23:00	10.8	13.2	8.3	190.4	3,160,867.1	2,146.6	2.1	1.7
Average/Sum#:	10.6	13.4	8.4	156.0	3,096,910.1	1,925.4	1.7	1.3
Minimum:	9.8	13.2	8.1	100.7	2,784,115.9	1,463.8	1.2	0.7
Maximum:	11.3	13.9	8.9	192.2	3,264,153.8	2,203.9	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/01/2024 00:00	10.8	13.2	8.3	185.1	3,196,266.3	2,147.3	2.0	1.7
08/01/2024 01:00	10.9	13.2	8.4	185.6	3,183,465.1	2,138.7	2.0	1.7
08/01/2024 02:00	10.8	13.3	8.4	181.2	3,209,569.6	2,132.8	2.0	1.7
08/01/2024 03:00	10.7	13.3	8.3	178.7	3,235,645.5	2,126.5	1.9	1.5
08/01/2024 04:00	10.6	13.3	8.2	177.5	3,273,078.1	2,127.2	1.9	1.5
08/01/2024 05:00	10.7	13.2	8.2	184.7	3,235,453.2	2,150.0	2.0	1.7
08/01/2024 06:00	11.0	13.3	8.5	177.7	3,216,017.1	2,113.6	1.9	1.5
08/01/2024 07:00	10.0	13.8	8.3	130.4	3,158,558.8	1,706.8	1.4	0.9
08/01/2024 08:00	10.3	13.7	8.4	136.6	3,201,492.1	1,730.0	1.4	0.9
08/01/2024 09:00	10.5	13.7	8.6	142.2	3,229,620.9	1,745.2	1.5	1.0
08/01/2024 10:00	10.6	13.7	8.7	140.8	3,210,560.0	1,734.9	1.5	1.0
08/01/2024 11:00	10.4	13.8	8.6	135.3	3,217,021.7	1,714.9	1.4	0.9
08/01/2024 12:00	10.4	13.8	8.6	128.6	3,172,068.0	1,714.1	1.4	0.9
08/01/2024 13:00	11.4	13.3	8.9	169.5	3,159,262.1	2,076.3	1.8	1.5
08/01/2024 14:00	11.1	13.2	8.5	177.7	3,115,589.3	2,093.1	2.0	1.7
08/01/2024 15:00	11.1	13.2	8.5	186.1	3,091,954.1	2,099.8	2.1	1.7
08/01/2024 16:00	11.0	13.2	8.4	189.6	3,136,127.5	2,152.7	2.1	1.7
08/01/2024 17:00	10.8	13.2	8.3	192.9	3,134,670.7	2,151.7	2.1	1.7
08/01/2024 18:00	10.8	13.2	8.3	190.6	3,140,061.0	2,155.4	2.1	1.7
08/01/2024 19:00	10.7	13.2	8.2	191.4	3,181,040.3	2,160.3	2.1	1.7
08/01/2024 20:00	10.7	13.2	8.2	194.7	3,193,556.6	2,168.8	2.1	1.7
08/01/2024 21:00	10.9	13.2	8.4	201.0	3,200,771.8	2,173.7	2.2	1.7
08/01/2024 22:00	10.8	13.2	8.3	199.3	3,201,213.6	2,174.0	2.2	1.7
08/01/2024 23:00	10.6	13.2	8.1	195.6	3,215,644.1	2,183.8	2.1	1.7
Average/Sum#:	10.7	13.4	8.4	173.9	3,187,862.8	2,036.3	1.9	1.5
Minimum:	10.0	13.2	8.1	128.6	3,091,954.1	1,706.8	1.4	0.9
Maximum:	11.4	13.8	8.9	201.0	3,273,078.1	2,183.8	2.2	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/02/2024 00:00	10.5	13.2	8.0	192.0	3,229,191.0	2,193.0	2.1	1.8
08/02/2024 01:00	10.6	13.2	8.1	190.7	3,214,760.6	2,183.2	2.1	1.7
08/02/2024 02:00	10.6	13.2	8.1	195.4	3,210,932.1	2,180.6	2.1	1.7
08/02/2024 03:00	10.5	13.2	8.0	191.5	3,258,485.8	2,189.1	2.1	1.8
08/02/2024 04:00	10.4	13.2	8.0	188.8	3,264,737.5	2,193.3	2.0	1.8
08/02/2024 05:00	10.4	13.2	8.0	176.0	3,260,420.8	2,190.4	1.9	1.5
08/02/2024 06:00	10.9	13.2	8.4	193.7	3,251,936.4	2,184.7	2.1	1.7
08/02/2024 07:00	10.7	13.2	8.2	195.2	3,217,852.8	2,185.3	2.1	1.7
08/02/2024 08:00	10.8	13.2	8.3	191.5	3,201,508.1	2,174.2	2.1	1.7
08/02/2024 09:00	10.8	13.2	8.3	195.0	3,187,666.6	2,164.8	2.1	1.7
08/02/2024 10:00	10.7	13.2	8.2	195.5	3,177,800.8	2,158.1	2.2	1.7
08/02/2024 11:00	10.7	13.2	8.2	188.7	3,163,959.3	2,148.7	2.1	1.7
08/02/2024 12:00	10.8	13.2	8.3	186.1	3,145,847.6	2,136.4	2.1	1.7
08/02/2024 13:00	10.8	13.2	8.3	190.9	3,141,871.8	2,133.7	2.1	1.7
08/02/2024 14:00	10.6	13.2	8.1	189.0	3,138,926.8	2,131.7	2.1	1.7
08/02/2024 15:00	10.7	13.2	8.2	184.0	3,130,386.3	2,125.9	2.0	1.7
08/02/2024 16:00	10.7	13.2	8.2	187.3	3,143,491.6	2,134.8	2.1	1.7
08/02/2024 17:00	10.8	13.2	8.3	189.6	3,140,693.8	2,132.9	2.1	1.7
08/02/2024 18:00	10.9	13.2	8.4	188.1	3,146,436.6	2,136.8	2.1	1.7
08/02/2024 19:00	10.7	13.2	8.2	185.6	3,166,020.8	2,150.1	2.0	1.7
08/02/2024 20:00	10.6	13.2	8.1	187.0	3,168,229.6	2,151.6	2.1	1.7
08/02/2024 21:00	10.6	13.2	8.1	191.5	3,185,752.3	2,163.5	2.1	1.7
08/02/2024 22:00	10.6	13.2	8.1	184.6	3,188,991.8	2,165.7	2.0	1.7
08/02/2024 23:00	10.5	13.2	8.0	187.9	3,188,402.8	2,165.3	2.1	1.7
Average/Sum#:	10.7	13.2	8.2	189.4	3,188,512.7	2,161.4	2.1	1.7
Minimum:	10.4	13.2	8.0	176.0	3,130,386.3	2,125.9	1.9	1.5
Maximum:	10.9	13.2	8.4	195.5	3,264,737.5	2,193.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/03/2024 00:00	10.4	13.2	8.0	191.0	3,185,016.1	2,163.0	2.1	1.7
08/03/2024 01:00	10.4	13.2	8.0	185.3	3,181,923.8	2,160.9	2.0	1.7
08/03/2024 02:00	10.5	13.2	8.0	186.1	3,179,862.3	2,159.5	2.0	1.7
08/03/2024 03:00	10.6	13.2	8.1	184.8	3,215,864.9	2,113.5	2.0	1.7
08/03/2024 04:00	10.8	13.2	8.3	184.4	3,228,456.5	2,098.2	2.0	1.7
08/03/2024 05:00	10.9	13.2	8.4	189.9	3,295,275.8	2,093.5	2.0	1.7
08/03/2024 06:00	11.1	13.3	8.6	170.1	3,229,165.7	2,051.5	1.8	1.4
08/03/2024 07:00	11.0	13.3	8.5	175.9	3,213,634.4	2,065.1	1.9	1.4
08/03/2024 08:00	11.2	13.2	8.6	182.3	3,154,393.0	2,073.1	2.0	1.7
08/03/2024 09:00	11.1	13.3	8.6	183.8	3,171,130.4	2,084.1	2.0	1.7
08/03/2024 10:00	10.9	13.3	8.5	182.8	3,179,955.6	2,089.9	2.0	1.7
08/03/2024 11:00	10.9	13.2	8.4	183.1	3,191,367.4	2,097.4	2.0	1.7
08/03/2024 12:00	10.9	13.2	8.4	183.6	3,189,845.9	2,096.4	2.0	1.7
08/03/2024 13:00	10.9	13.2	8.4	185.6	3,165,025.7	2,103.2	2.0	1.7
08/03/2024 14:00	11.0	13.2	8.4	186.6	3,148,187.6	2,115.0	2.1	1.7
08/03/2024 15:00	10.9	13.2	8.4	187.5	3,148,336.4	2,115.1	2.1	1.7
08/03/2024 16:00	10.8	13.2	8.3	187.2	3,158,607.1	2,122.0	2.1	1.7
08/03/2024 17:00	10.8	13.2	8.3	187.2	3,170,515.1	2,130.0	2.1	1.7
08/03/2024 18:00	10.6	13.2	8.1	181.6	3,174,534.1	2,132.7	2.0	1.7
08/03/2024 19:00	10.6	13.2	8.1	188.4	3,179,148.5	2,135.8	2.1	1.7
08/03/2024 20:00	10.5	13.2	8.0	184.0	3,184,804.8	2,139.6	2.0	1.7
08/03/2024 21:00	10.6	13.2	8.1	186.2	3,181,530.1	2,137.4	2.0	1.7
08/03/2024 22:00	10.6	13.2	8.1	189.8	3,191,205.4	2,143.9	2.1	1.7
08/03/2024 23:00	10.3	13.2	7.9	185.1	3,200,285.2	2,150.0	2.0	1.7
Average/Sum#:	10.8	13.2	8.3	184.7	3,188,253.0	2,115.5	2.0	1.7
Minimum:	10.3	13.2	7.9	170.1	3,148,187.6	2,051.5	1.8	1.4
Maximum:	11.2	13.3	8.6	191.0	3,295,275.8	2,163.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/04/2024 00:00	10.3	13.3	8.0	175.6	3,181,629.3	2,091.0	1.9	1.5
08/04/2024 01:00	10.4	13.3	8.1	179.2	3,200,344.8	2,103.3	1.9	1.5
08/04/2024 02:00	10.4	13.3	8.1	168.0	3,168,038.8	2,035.8	1.8	1.4
08/04/2024 03:00	9.4	13.8	7.8	123.2	3,244,410.2	1,729.5	1.3	0.9
08/04/2024 04:00	9.8	13.7	8.0	133.6	3,247,016.2	1,754.6	1.4	0.9
08/04/2024 05:00	10.0	13.7	8.2	140.0	3,242,204.8	1,752.0	1.5	1.1
08/04/2024 06:00	9.9	13.8	8.2	122.6	3,224,713.0	1,719.0	1.3	0.9
08/04/2024 07:00	10.3	13.8	8.6	117.4	3,008,981.8	1,604.0	1.3	0.8
08/04/2024 08:00	10.4	13.8	8.6	119.2	3,022,113.3	1,611.0	1.3	0.8
08/04/2024 09:00	10.3	13.8	8.6	101.6	2,762,860.6	1,472.8	1.2	0.7
08/04/2024 10:00	10.4	13.9	8.8	127.2	3,077,020.5	1,617.8	1.4	0.8
08/04/2024 11:00	10.7	13.8	8.9	131.4	3,123,027.8	1,687.6	1.4	0.8
08/04/2024 12:00	10.4	13.9	8.8	120.0	2,935,893.7	1,543.6	1.4	0.8
08/04/2024 13:00	11.2	13.3	8.7	173.0	3,154,290.4	2,119.1	1.9	1.5
08/04/2024 14:00	11.0	13.2	8.4	177.2	3,119,784.3	2,118.7	2.0	1.7
08/04/2024 15:00	10.8	13.2	8.3	178.3	3,122,582.1	2,120.6	2.0	1.7
08/04/2024 16:00	10.9	13.2	8.4	174.6	3,097,727.3	2,081.1	2.0	1.7
08/04/2024 17:00	10.9	13.2	8.4	178.5	3,088,272.9	2,097.3	2.0	1.7
08/04/2024 18:00	10.8	13.2	8.3	182.7	3,103,439.6	2,107.6	2.0	1.7
08/04/2024 19:00	10.8	13.2	8.3	186.3	3,120,815.1	2,119.4	2.1	1.7
08/04/2024 20:00	10.8	13.2	8.3	184.1	3,140,252.1	2,132.6	2.0	1.7
08/04/2024 21:00	10.8	13.2	8.3	190.7	3,152,915.6	2,141.2	2.1	1.7
08/04/2024 22:00	10.8	13.2	8.3	189.7	3,202,518.0	2,151.5	2.1	1.7
08/04/2024 23:00	10.8	13.2	8.3	188.6	3,217,551.9	2,161.6	2.0	1.7
Average/Sum#:	10.5	13.5	8.4	156.8	3,123,266.8	1,919.7	1.7	1.3
Minimum:	9.4	13.2	7.8	101.6	2,762,860.6	1,472.8	1.2	0.7
Maximum:	11.2	13.9	8.9	190.7	3,247,016.2	2,161.6	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/05/2024 00:00	10.7	13.2	8.2	193.9	3,225,887.5	2,167.2	2.1	1.7
08/05/2024 01:00	10.6	13.2	8.1	187.6	3,235,562.8	2,173.7	2.0	1.7
08/05/2024 02:00	10.5	13.2	8.0	186.6	3,241,963.4	2,178.0	2.0	1.7
08/05/2024 03:00	10.4	13.2	8.0	194.2	3,251,638.7	2,184.5	2.1	1.7
08/05/2024 04:00	10.3	13.2	7.9	184.8	3,251,787.5	2,184.6	2.0	1.7
08/05/2024 05:00	10.4	13.2	8.0	171.8	3,254,615.7	2,186.5	1.8	1.5
08/05/2024 06:00	10.8	13.2	8.3	147.5	3,264,707.7	2,145.6	1.5	1.3
08/05/2024 07:00	10.6	13.3	8.2	137.7	3,227,434.2	2,050.4	1.4	1.0
08/05/2024 08:00	10.8	13.3	8.4	154.5	3,231,363.8	2,029.3	1.6	1.2
08/05/2024 09:00	10.8	13.3	8.4	154.8	3,248,879.7	2,040.3	1.6	1.2
08/05/2024 10:00	10.9	13.3	8.5	158.4	3,206,320.5	2,060.4	1.7	1.4
08/05/2024 11:00	10.9	13.2	8.4	166.0	3,158,103.3	2,098.6	1.8	1.5
08/05/2024 12:00	10.8	13.2	8.3	172.1	3,132,153.3	2,127.1	1.9	1.5
08/05/2024 13:00	10.8	13.2	8.3	171.0	3,135,098.3	2,129.1	1.9	1.5
08/05/2024 14:00	10.7	13.2	8.2	166.4	3,131,269.8	2,126.5	1.8	1.5
08/05/2024 15:00	10.8	13.2	8.3	170.6	3,110,213.1	2,112.2	1.9	1.5
08/05/2024 16:00	10.8	13.1	8.2	173.3	3,107,268.1	2,110.2	1.9	1.5
08/05/2024 17:00	10.9	13.1	8.2	169.5	3,101,378.1	2,106.2	1.9	1.5
08/05/2024 18:00	10.8	13.1	8.2	166.6	3,111,980.1	2,113.4	1.9	1.5
08/05/2024 19:00	10.8	13.2	8.3	166.3	3,151,632.4	2,094.3	1.8	1.5
08/05/2024 20:00	10.8	13.2	8.3	167.8	3,151,884.8	2,140.5	1.8	1.5
08/05/2024 21:00	10.8	13.2	8.3	172.7	3,166,462.6	2,150.4	1.9	1.5
08/05/2024 22:00	10.8	13.1	8.2	168.8	3,178,389.8	2,158.5	1.8	1.5
08/05/2024 23:00	10.7	13.1	8.1	175.0	3,192,231.3	2,167.9	1.9	1.5
Average/Sum#:	10.7	13.2	8.2	169.9	3,186,176.1	2,126.5	1.8	1.5
Minimum:	10.3	13.1	7.9	137.7	3,101,378.1	2,029.3	1.4	1.0
Maximum:	10.9	13.3	8.5	194.2	3,264,707.7	2,186.5	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/06/2024 00:00	10.4	13.3	8.1	161.0	3,222,301.7	2,094.2	1.7	1.5
08/06/2024 01:00	10.3	13.4	8.1	150.7	3,249,994.4	2,041.0	1.6	1.2
08/06/2024 02:00	10.3	13.4	8.1	146.8	3,269,218.8	2,029.2	1.5	1.2
08/06/2024 03:00	10.3	13.4	8.1	146.4	3,269,379.9	2,029.3	1.5	1.2
08/06/2024 04:00	10.6	13.2	8.1	169.4	3,251,705.7	2,160.8	1.8	1.5
08/06/2024 05:00	10.6	13.2	8.1	190.5	3,261,909.3	2,191.4	2.0	1.8
08/06/2024 06:00	10.8	13.3	8.4	151.3	3,328,488.3	2,114.6	1.5	1.3
08/06/2024 07:00	10.5	13.3	8.2	148.9	3,270,991.0	2,030.3	1.5	1.2
08/06/2024 08:00	10.7	13.3	8.3	152.4	3,236,300.1	2,032.4	1.6	1.2
08/06/2024 09:00	10.8	13.3	8.4	157.5	3,219,563.9	2,045.4	1.7	1.4
08/06/2024 10:00	10.9	13.2	8.4	163.2	3,169,832.8	2,060.1	1.8	1.4
08/06/2024 11:00	10.8	13.3	8.4	165.4	3,188,604.7	2,072.3	1.8	1.5
08/06/2024 12:00	10.9	13.2	8.4	171.5	3,183,759.5	2,092.4	1.9	1.5
08/06/2024 13:00	11.0	13.2	8.4	173.9	3,159,006.2	2,099.2	1.9	1.5
08/06/2024 14:00	11.0	13.2	8.4	175.6	3,130,325.5	2,103.0	1.9	1.5
08/06/2024 15:00	10.9	13.2	8.4	176.7	3,139,107.7	2,108.9	1.9	1.5
08/06/2024 16:00	10.9	13.2	8.4	174.5	3,151,164.6	2,117.0	1.9	1.5
08/06/2024 17:00	10.9	13.2	8.4	172.4	3,124,201.8	2,121.7	1.9	1.5
08/06/2024 18:00	10.9	13.2	8.4	170.5	3,118,900.8	2,118.1	1.9	1.5
08/06/2024 19:00	10.9	13.2	8.4	177.4	3,125,968.8	2,122.9	2.0	1.7
08/06/2024 20:00	10.9	13.2	8.4	179.8	3,131,122.6	2,126.4	2.0	1.7
08/06/2024 21:00	10.9	13.2	8.4	173.9	3,173,938.7	2,132.3	1.9	1.5
08/06/2024 22:00	10.9	13.2	8.4	175.3	3,187,186.4	2,141.2	1.9	1.5
08/06/2024 23:00	10.9	13.2	8.4	182.6	3,182,869.7	2,138.3	2.0	1.7
Average/Sum#:	10.8	13.3	8.3	167.0	3,197,743.5	2,096.8	1.8	1.4
Minimum:	10.3	13.2	8.1	146.4	3,118,900.8	2,029.2	1.5	1.2
Maximum:	11.0	13.4	8.4	190.5	3,328,488.3	2,191.4	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/07/2024 00:00	10.9	13.2	8.4	172.9	3,204,757.4	2,106.2	1.9	1.5
08/07/2024 01:00	10.9	13.2	8.4	177.4	3,210,555.9	2,156.9	1.9	1.5
08/07/2024 02:00	10.8	13.2	8.3	169.0	3,230,764.5	2,099.7	1.8	1.5
08/07/2024 03:00	10.7	13.3	8.3	158.9	3,247,765.1	2,039.6	1.7	1.4
08/07/2024 04:00	10.8	13.3	8.4	161.6	3,232,156.4	2,053.4	1.7	1.4
08/07/2024 05:00	11.0	13.2	8.4	165.2	3,171,259.4	2,130.5	1.8	1.5
08/07/2024 06:00	11.2	13.2	8.6	178.1	3,222,360.9	2,141.3	1.9	1.5
08/07/2024 07:00	10.9	13.3	8.5	159.9	3,253,019.9	2,042.9	1.7	1.4
08/07/2024 08:00	10.9	13.3	8.5	162.0	3,259,070.8	2,046.7	1.7	1.4
08/07/2024 09:00	11.0	13.3	8.5	164.9	3,204,764.3	2,059.4	1.8	1.4
08/07/2024 10:00	11.0	13.3	8.5	169.5	3,194,297.8	2,076.0	1.8	1.5
08/07/2024 11:00	11.2	13.2	8.6	175.0	3,149,525.6	2,092.9	1.9	1.5
08/07/2024 12:00	11.2	13.2	8.6	178.8	3,131,665.2	2,103.9	2.0	1.7
08/07/2024 13:00	11.1	13.2	8.5	177.2	3,141,191.6	2,110.3	2.0	1.7
08/07/2024 14:00	11.2	13.2	8.6	178.3	3,145,954.8	2,113.5	2.0	1.7
08/07/2024 15:00	11.1	13.2	8.5	176.5	3,148,038.7	2,114.9	1.9	1.5
08/07/2024 16:00	11.2	13.2	8.6	177.6	3,106,090.1	2,109.4	2.0	1.7
08/07/2024 17:00	11.1	13.2	8.5	173.8	3,095,046.4	2,101.9	1.9	1.5
08/07/2024 18:00	11.0	13.2	8.4	174.0	3,105,942.9	2,109.3	1.9	1.5
08/07/2024 19:00	11.0	13.2	8.4	171.8	3,120,373.3	2,119.1	1.9	1.5
08/07/2024 20:00	11.1	13.2	8.5	178.9	3,134,509.3	2,128.7	2.0	1.7
08/07/2024 21:00	11.1	13.2	8.5	184.2	3,146,289.3	2,136.7	2.0	1.7
08/07/2024 22:00	11.0	13.2	8.4	166.4	3,170,602.1	2,060.6	1.8	1.4
08/07/2024 23:00	11.1	13.2	8.5	178.0	3,209,365.1	2,156.1	1.9	1.5
Average/Sum#:	11.0	13.2	8.5	172.1	3,176,473.6	2,100.4	1.9	1.5
Minimum:	10.7	13.2	8.3	158.9	3,095,046.4	2,039.6	1.7	1.4
Maximum:	11.2	13.3	8.6	184.2	3,259,070.8	2,156.9	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/08/2024 00:00	10.8	13.2	8.3	175.9	3,229,757.6	2,169.8	1.9	1.5
08/08/2024 01:00	10.6	13.3	8.2	173.5	3,208,104.9	2,108.4	1.9	1.5
08/08/2024 02:00	9.7	13.8	8.1	112.6	3,126,414.6	1,666.6	1.2	0.8
08/08/2024 03:00	9.7	13.8	8.1	113.4	3,193,572.7	1,702.4	1.2	0.9
08/08/2024 04:00	9.9	13.8	8.2	112.7	3,137,295.0	1,672.4	1.2	0.8
08/08/2024 05:00	9.5	13.8	7.9	114.9	3,265,795.8	1,740.9	1.2	0.9
08/08/2024 06:00	9.9	13.8	8.2	116.3	3,255,665.8	1,735.5	1.2	0.9
08/08/2024 07:00	10.0	13.8	8.3	110.0	3,141,046.8	1,674.4	1.2	0.8
08/08/2024 08:00	10.3	13.8	8.6	106.2	2,949,515.0	1,572.3	1.2	0.8
08/08/2024 09:00	10.2	13.8	8.5	106.7	2,938,822.2	1,566.6	1.2	0.8
08/08/2024 10:00	10.3	13.8	8.6	106.1	2,929,255.0	1,561.5	1.2	0.8
08/08/2024 11:00	10.2	13.9	8.6	89.8	2,549,221.5	1,340.3	1.2	0.7
08/08/2024 12:00	10.2	14.0	8.7	88.2	2,530,201.7	1,330.3	1.1	0.5
08/08/2024 13:00	10.2	14.0	8.7	89.1	2,574,710.7	1,334.9	1.1	0.5
08/08/2024 14:00	10.5	13.8	8.7	114.7	2,861,909.4	1,525.6	1.3	0.8
08/08/2024 15:00	11.4	13.2	8.7	162.7	3,126,902.0	2,100.7	1.8	1.5
08/08/2024 16:00	11.0	13.2	8.4	163.9	3,095,802.0	2,057.2	1.8	1.4
08/08/2024 17:00	11.1	13.2	8.5	174.1	3,103,420.0	2,039.6	1.9	1.4
08/08/2024 18:00	11.2	13.1	8.5	170.3	3,100,789.1	2,105.8	1.9	1.5
08/08/2024 19:00	11.1	13.1	8.4	174.1	3,114,188.8	2,114.9	1.9	1.5
08/08/2024 20:00	10.9	13.2	8.4	181.6	3,131,858.8	2,126.9	2.0	1.7
08/08/2024 21:00	10.9	13.2	8.4	178.1	3,144,816.8	2,135.7	2.0	1.7
08/08/2024 22:00	10.9	13.2	8.4	179.1	3,177,957.7	2,135.0	2.0	1.7
08/08/2024 23:00	10.8	13.2	8.3	175.8	3,179,020.9	2,112.5	1.9	1.5
Average/Sum#:	10.5	13.5	8.4	137.1	3,044,418.5	1,817.9	1.5	1.1
Minimum:	9.5	13.1	7.9	88.2	2,530,201.7	1,330.3	1.1	0.5
Maximum:	11.4	14.0	8.7	181.6	3,265,795.8	2,169.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/09/2024 00:00	9.9	13.8	8.2	115.2	2,977,757.8	1,609.1	1.3	0.8
08/09/2024 01:00	9.8	13.8	8.1	115.9	3,195,073.4	1,703.2	1.2	0.9
08/09/2024 02:00	9.6	13.8	8.0	114.7	3,250,976.0	1,733.0	1.2	0.9
08/09/2024 03:00	9.7	13.8	8.1	114.9	3,221,524.0	1,717.3	1.2	0.9
08/09/2024 04:00	9.8	13.8	8.1	119.5	3,287,368.9	1,752.4	1.2	0.9
08/09/2024 05:00	9.8	13.8	8.1	116.8	3,286,243.3	1,751.8	1.2	0.9
08/09/2024 06:00	10.0	13.8	8.3	114.9	3,217,021.7	1,714.9	1.2	0.9
08/09/2024 07:00	10.4	13.8	8.6	104.4	2,924,565.2	1,559.0	1.2	0.8
08/09/2024 08:00	10.3	13.9	8.7	98.8	2,782,974.7	1,463.2	1.2	0.7
08/09/2024 09:00	10.3	13.9	8.7	105.8	2,926,383.8	1,538.6	1.2	0.8
08/09/2024 10:00	10.2	13.9	8.6	108.1	2,988,388.3	1,571.2	1.2	0.8
08/09/2024 11:00	10.1	13.9	8.5	109.2	3,026,618.1	1,591.3	1.2	0.8
08/09/2024 12:00	10.2	13.8	8.5	120.6	3,094,523.9	1,649.6	1.3	0.8
08/09/2024 13:00	10.2	13.8	8.5	120.5	3,202,577.1	1,707.2	1.2	0.9
08/09/2024 14:00	10.5	13.7	8.6	117.0	2,970,725.6	1,605.3	1.3	0.8
08/09/2024 15:00	11.3	13.2	8.7	161.9	3,127,050.8	2,100.8	1.8	1.5
08/09/2024 16:00	11.1	13.2	8.5	166.3	3,114,612.8	2,069.7	1.8	1.4
08/09/2024 17:00	11.1	13.2	8.5	166.1	3,091,070.6	2,099.2	1.9	1.5
08/09/2024 18:00	10.9	13.2	8.4	167.2	3,137,172.6	2,107.6	1.8	1.5
08/09/2024 19:00	10.8	13.2	8.3	168.1	3,154,885.8	2,119.5	1.8	1.5
08/09/2024 20:00	10.8	13.2	8.3	175.3	3,130,325.5	2,103.0	1.9	1.5
08/09/2024 21:00	20.4	15.9	24.1	167.7	1,682,191.1	687.9	3.3	0.9
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.7	9.1	130.4	3,035,910.5	1,725.2	1.5	1.0
Minimum:	9.6	13.2	8.0	98.8	1,682,191.1	687.9	1.2	0.7
Maximum:	20.4	15.9	24.1	175.3	3,287,368.9	2,119.5	3.3	1.5
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 13:00	37.3	17.3	61.1	0.1	1,218,407.3	320.3	0.0	0.0
08/12/2024 14:00	39.6	17.0	59.9	220.3	1,363,746.3	408.3	5.2	0.8
08/12/2024 15:00	29.5	15.2	30.5	231.8	2,259,786.3	957.1	3.3	1.2
08/12/2024 16:00	10.2	13.7	8.4	126.9	3,123,027.8	1,687.6	1.4	0.8
08/12/2024 17:00	11.0	13.3	8.5	162.9	3,146,252.5	1,929.9	1.8	1.4
08/12/2024 18:00	10.8	13.5	8.6	150.7	3,187,335.3	1,768.9	1.6	1.1
08/12/2024 19:00	10.4	13.7	8.5	123.5	3,138,202.5	1,695.8	1.3	0.8
08/12/2024 20:00	10.2	13.8	8.5	105.0	2,809,571.1	1,497.7	1.2	0.7
08/12/2024 21:00	10.0	13.8	8.3	117.5	3,220,398.4	1,716.7	1.2	0.9
08/12/2024 22:00	9.8	13.8	8.1	111.5	3,168,810.5	1,689.2	1.2	0.8
08/12/2024 23:00	9.7	13.8	8.1	113.6	3,278,630.2	1,723.8	1.1	0.7
Average/Sum#:	17.1	14.4	19.9	133.1	2,719,469.8	1,399.6	1.8	0.8
Minimum:	9.7	13.3	8.1	0.1	1,218,407.3	320.3	0.0	0.0
Maximum:	39.6	17.3	61.1	231.8	3,278,630.2	1,929.9	5.2	1.4
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/13/2024 00:00	9.9	13.8	8.2	111.0	3,157,930.1	1,683.4	1.2	0.8
08/13/2024 01:00	10.0	13.9	8.4	88.4	2,564,437.4	1,348.3	1.1	0.5
08/13/2024 02:00	24.3	16.0	29.3	167.3	1,591,022.1	639.0	3.4	0.8
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.7	14.6	15.3	122.2	2,437,796.5	1,223.6	1.9	0.7
Minimum:	9.9	13.8	8.2	88.4	1,591,022.1	639.0	1.1	0.5
Maximum:	24.3	16.0	29.3	167.3	3,157,930.1	1,683.4	3.4	0.8
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/14/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 17:00	41.7	17.2	66.5	32.1	1,256,539.4	339.5	0.0	0.0
08/15/2024 18:00	23.9	14.4	21.7	193.3	2,545,262.0	1,226.7	2.5	1.2
08/15/2024 19:00	10.8	13.4	8.5	157.7	3,020,069.8	1,852.5	1.8	1.3
08/15/2024 20:00	11.0	13.2	8.4	174.0	3,134,195.6	2,105.6	1.9	1.5
08/15/2024 21:00	9.9	13.8	8.2	119.5	3,175,001.1	1,692.5	1.3	0.8
08/15/2024 22:00	9.9	13.8	8.2	111.5	3,136,544.6	1,672.0	1.2	0.8
08/15/2024 23:00	10.1	13.8	8.4	116.6	3,186,069.0	1,698.4	1.2	0.8
Average/Sum#:	16.8	14.2	18.6	129.2	2,779,097.4	1,512.5	1.4	0.9
Minimum:	9.9	13.2	8.2	32.1	1,256,539.4	339.5	0.0	0.0
Maximum:	41.7	17.2	66.5	193.3	3,186,069.0	2,105.6	2.5	1.5
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/16/2024 00:00	10.1	13.7	8.3	121.2	3,266,921.3	1,741.5	1.2	0.9
08/16/2024 01:00	10.1	13.8	8.4	115.7	3,169,748.5	1,689.7	1.2	0.8
08/16/2024 02:00	17.3	15.1	17.6	144.2	2,303,283.5	1,042.8	2.0	0.8
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 08:00	36.0	17.4	60.7	209.7	1,353,313.5	336.0	0.0	0.0
08/16/2024 09:00	43.1	15.1	43.8	248.8	2,154,174.2	928.1	3.6	1.3
08/16/2024 10:00	10.1	13.8	8.4	109.5	2,961,333.3	1,578.6	1.2	0.8
08/16/2024 11:00	10.3	13.9	8.7	95.4	2,712,601.5	1,426.2	1.2	0.7
08/16/2024 12:00	10.4	13.8	8.6	127.0	3,117,973.0	1,662.1	1.4	0.8
08/16/2024 13:00	10.6	13.8	8.8	110.3	2,907,306.7	1,549.8	1.3	0.8
08/16/2024 14:00	10.4	14.0	8.9	90.4	2,592,069.6	1,343.9	1.1	0.5
08/16/2024 15:00	10.7	13.8	8.9	120.5	2,965,272.8	1,580.7	1.4	0.8
08/16/2024 16:00	11.4	13.2	8.7	156.7	3,141,611.7	2,064.7	1.7	1.4
08/16/2024 17:00	11.3	13.2	8.7	165.8	3,152,719.2	2,072.0	1.8	1.5
08/16/2024 18:00	11.2	13.2	8.6	169.8	3,146,214.9	2,090.7	1.9	1.5
08/16/2024 19:00	11.1	13.2	8.5	173.8	3,161,414.0	2,100.8	1.9	1.5
08/16/2024 20:00	11.0	13.2	8.4	178.6	3,180,375.3	2,113.4	1.9	1.5
08/16/2024 21:00	11.1	13.2	8.5	155.2	3,198,132.6	2,125.2	1.7	1.5
08/16/2024 22:00	11.0	13.2	8.4	179.0	3,209,870.6	2,133.0	1.9	1.5
08/16/2024 23:00	10.9	13.2	8.4	178.3	3,215,739.5	2,136.9	1.9	1.5
Average/Sum#:	14.1	13.9	13.6	150.0	2,890,004.0	1,669.3	1.6	1.1
Minimum:	10.1	13.2	8.3	90.4	1,353,313.5	336.0	0.0	0.0
Maximum:	43.1	17.4	60.7	248.8	3,266,921.3	2,136.9	3.6	1.5
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/17/2024 00:00	10.9	13.2	8.4	175.6	3,236,506.6	2,150.7	1.9	1.5
08/17/2024 01:00	10.8	13.3	8.4	171.6	3,242,766.2	2,107.5	1.8	1.5
08/17/2024 02:00	10.8	13.3	8.4	164.3	3,245,693.2	2,062.0	1.7	1.4
08/17/2024 03:00	10.7	13.3	8.3	159.3	3,248,561.3	2,040.1	1.7	1.4
08/17/2024 04:00	10.7	13.3	8.3	161.3	3,239,554.4	2,058.1	1.7	1.4
08/17/2024 05:00	10.7	13.3	8.3	191.9	3,267,887.3	2,076.1	2.0	1.7
08/17/2024 06:00	16.9	14.6	15.8	156.6	2,467,507.1	1,261.3	2.1	1.0
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.6	13.5	9.4	168.7	3,135,496.6	1,965.1	1.8	1.4
Minimum:	10.7	13.2	8.3	156.6	2,467,507.1	1,261.3	1.7	1.0
Maximum:	16.9	14.6	15.8	191.9	3,267,887.3	2,150.7	2.1	1.7
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 09:00	38.9	17.3	63.8	33.3	1,319,212.2	346.8	0.0	0.0
08/18/2024 10:00	40.2	17.1	62.4	268.6	1,473,500.6	430.4	5.7	0.9
08/18/2024 11:00	36.3	14.7	34.5	225.7	2,318,022.5	1,066.4	3.2	1.3
08/18/2024 12:00	9.6	14.0	8.2	88.6	2,691,979.7	1,395.7	1.1	0.6
08/18/2024 13:00	10.0	13.8	8.3	111.5	3,017,678.8	1,586.6	1.2	0.8
08/18/2024 14:00	10.2	13.8	8.5	125.6	3,210,268.4	1,711.3	1.3	0.9
08/18/2024 15:00	10.1	13.9	8.5	99.1	2,797,619.9	1,470.9	1.2	0.7
08/18/2024 16:00	10.2	13.8	8.5	125.9	3,176,689.4	1,693.4	1.3	0.8
08/18/2024 17:00	10.5	13.7	8.6	121.3	3,094,714.1	1,672.3	1.3	0.8
08/18/2024 18:00	11.2	13.3	8.7	162.0	3,207,222.7	2,084.4	1.7	1.5
08/18/2024 19:00	11.0	13.2	8.4	186.3	3,232,136.0	2,195.0	2.0	1.8
08/18/2024 20:00	10.9	13.2	8.4	195.0	3,211,948.9	2,228.2	2.1	1.8
08/18/2024 21:00	10.9	13.2	8.4	195.0	3,236,310.2	2,245.1	2.1	1.8
08/18/2024 22:00	10.8	13.2	8.3	198.7	3,254,761.4	2,257.9	2.1	1.8
08/18/2024 23:00	10.7	13.2	8.2	199.1	3,168,906.3	2,175.2	2.2	1.7
Average/Sum#:	16.1	14.1	17.4	155.7	2,827,398.1	1,637.3	1.9	1.1
Minimum:	9.6	13.2	8.2	33.3	1,319,212.2	346.8	0.0	0.0
Maximum:	40.2	17.3	63.8	268.6	3,254,761.4	2,257.9	5.7	1.8
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/19/2024 00:00	23.6	16.2	29.6	177.5	1,486,729.8	575.4	3.9	0.9
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 12:00	41.2	17.3	67.5	91.7	1,391,867.7	365.9	0.0	0.0
08/19/2024 13:00	38.6	14.8	37.3	224.8	2,294,227.6	1,038.7	3.1	1.2
08/19/2024 14:00	9.8	13.8	8.1	114.2	3,144,350.5	1,653.2	1.2	0.8
08/19/2024 15:00	10.2	13.8	8.5	108.9	2,881,877.5	1,515.2	1.3	0.8
08/19/2024 16:00	11.2	13.3	8.7	173.2	3,304,358.8	2,123.4	1.8	1.5
08/19/2024 17:00	11.0	13.3	8.5	166.5	3,226,148.4	2,096.7	1.8	1.5
08/19/2024 18:00	11.2	13.2	8.6	195.2	3,216,273.4	2,231.2	2.1	1.8
08/19/2024 19:00	10.9	13.3	8.5	178.3	3,224,467.7	2,142.7	1.9	1.5
08/19/2024 20:00	10.9	13.3	8.5	172.0	3,222,609.5	2,094.4	1.8	1.5
08/19/2024 21:00	11.1	13.2	8.5	193.5	3,220,186.9	2,210.4	2.1	1.8
08/19/2024 22:00	10.9	13.2	8.4	206.2	3,251,654.5	2,232.0	2.2	1.8
08/19/2024 23:00	10.9	13.3	8.5	188.8	3,233,195.9	2,148.5	2.0	1.7
Average/Sum#:	16.3	14.0	16.9	168.5	2,853,688.3	1,725.2	1.9	1.3
Minimum:	9.8	13.2	8.1	91.7	1,391,867.7	365.9	0.0	0.0
Maximum:	41.2	17.3	67.5	224.8	3,304,358.8	2,232.0	3.9	1.8
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/20/2024 00:00	10.7	13.4	8.4	156.5	3,216,992.4	1,949.8	1.7	1.4
08/20/2024 01:00	23.8	15.9	28.1	171.3	1,629,370.5	666.3	3.4	0.9
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 09:00	35.6	17.6	63.6	92.8	1,249,496.0	301.1	0.0	0.0
08/20/2024 10:00	42.5	15.1	43.2	239.5	2,175,063.7	937.1	3.5	1.2
08/20/2024 11:00	9.9	13.9	8.3	90.5	2,692,944.1	1,396.2	1.1	0.6
08/20/2024 12:00	10.1	13.9	8.5	106.5	2,929,807.4	1,540.4	1.2	0.8
08/20/2024 13:00	10.0	13.8	8.3	117.3	3,185,052.9	1,674.6	1.2	0.8
08/20/2024 14:00	10.3	13.9	8.7	97.6	2,775,556.9	1,459.3	1.2	0.7
08/20/2024 15:00	10.2	14.0	8.7	87.5	2,565,838.4	1,330.3	1.1	0.5
08/20/2024 16:00	10.6	13.8	8.8	118.8	2,963,092.0	1,557.9	1.3	0.8
08/20/2024 17:00	11.3	13.3	8.8	164.5	3,171,282.6	2,084.2	1.8	1.5
08/20/2024 18:00	11.2	13.3	8.7	178.3	3,178,999.6	2,135.7	1.9	1.5
08/20/2024 19:00	11.2	13.3	8.7	180.3	3,191,360.8	2,120.7	2.0	1.7
08/20/2024 20:00	11.1	13.3	8.6	176.5	3,202,018.5	2,104.4	1.9	1.5
08/20/2024 21:00	10.9	13.4	8.6	161.7	3,199,888.3	2,032.9	1.7	1.4
08/20/2024 22:00	11.1	13.2	8.5	196.2	3,204,307.4	2,199.5	2.1	1.8
08/20/2024 23:00	11.1	13.2	8.5	202.1	3,211,300.2	2,204.3	2.2	1.8
Average/Sum#:	14.8	14.0	15.0	149.3	2,808,374.8	1,629.1	1.7	1.1
Minimum:	9.9	13.2	8.3	87.5	1,249,496.0	301.1	0.0	0.0
Maximum:	42.5	17.6	63.6	239.5	3,216,992.4	2,204.3	3.5	1.8
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/21/2024 00:00	11.1	13.2	8.5	202.6	3,231,841.5	2,218.4	2.2	1.8
08/21/2024 01:00	10.6	13.4	8.3	156.2	3,252,056.9	1,994.8	1.6	1.2
08/21/2024 02:00	9.7	13.8	8.1	113.6	3,196,386.6	1,703.9	1.2	0.9
08/21/2024 03:00	9.7	13.8	8.1	115.6	3,266,647.7	1,717.5	1.2	0.9
08/21/2024 04:00	9.7	13.8	8.1	114.5	3,282,814.6	1,726.0	1.2	0.9
08/21/2024 05:00	9.7	13.8	8.1	116.3	3,303,546.1	1,736.9	1.2	0.9
08/21/2024 06:00	10.0	13.8	8.3	116.3	3,291,373.5	1,730.5	1.2	0.9
08/21/2024 07:00	10.2	13.8	8.5	109.5	3,084,248.0	1,621.6	1.2	0.8
08/21/2024 08:00	10.2	13.8	8.5	111.0	3,073,216.6	1,615.8	1.2	0.8
08/21/2024 09:00	10.0	14.0	8.6	87.8	2,565,259.8	1,330.0	1.1	0.5
08/21/2024 10:00	10.1	13.9	8.5	104.5	2,928,856.4	1,539.9	1.2	0.8
08/21/2024 11:00	9.9	13.9	8.3	105.1	3,014,255.2	1,584.8	1.2	0.8
08/21/2024 12:00	9.9	13.9	8.3	115.9	3,160,707.6	1,661.8	1.2	0.8
08/21/2024 13:00	10.1	13.7	8.3	127.6	3,269,172.4	1,742.7	1.3	0.9
08/21/2024 14:00	10.3	13.7	8.4	131.3	3,242,574.9	1,752.2	1.4	0.9
08/21/2024 15:00	10.2	13.7	8.4	125.2	3,208,894.4	1,734.0	1.3	0.9
08/21/2024 16:00	10.4	13.7	8.5	118.9	3,034,682.0	1,617.7	1.3	0.8
08/21/2024 17:00	11.1	13.3	8.6	163.2	3,203,540.1	2,105.4	1.7	1.5
08/21/2024 18:00	11.1	13.1	8.4	204.5	3,178,741.4	2,274.8	2.3	2.0
08/21/2024 19:00	10.9	13.1	8.2	206.5	3,188,243.5	2,281.6	2.3	2.1
08/21/2024 20:00	10.8	13.2	8.3	197.0	3,230,832.5	2,241.3	2.1	1.8
08/21/2024 21:00	10.7	13.2	8.2	183.8	3,231,399.8	2,194.5	2.0	1.8
08/21/2024 22:00	10.7	13.2	8.2	187.7	3,227,129.5	2,191.6	2.0	1.8
08/21/2024 23:00	10.6	13.2	8.1	187.7	3,254,812.5	2,210.4	2.0	1.8
Average/Sum#:	10.3	13.6	8.3	141.8	3,163,384.7	1,855.3	1.5	1.2
Minimum:	9.7	13.1	8.1	87.8	2,565,259.8	1,330.0	1.1	0.5
Maximum:	11.1	14.0	8.6	206.5	3,303,546.1	2,281.6	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/22/2024 00:00	10.4	13.4	8.2	151.3	3,262,653.6	2,001.3	1.6	1.2
08/22/2024 01:00	10.4	13.4	8.2	149.5	3,289,791.6	1,969.9	1.5	1.2
08/22/2024 02:00	10.4	13.4	8.2	146.8	3,283,779.5	1,966.3	1.5	1.2
08/22/2024 03:00	10.2	13.4	8.0	143.9	3,279,604.4	1,963.8	1.5	1.2
08/22/2024 04:00	10.1	13.4	7.9	144.7	3,298,809.7	1,975.3	1.5	1.2
08/22/2024 05:00	10.3	13.3	8.0	170.3	3,231,080.8	2,123.5	1.8	1.5
08/22/2024 06:00	23.0	15.9	27.1	169.6	1,704,933.4	697.2	3.2	0.8
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 14:00	41.5	17.4	70.0	94.1	1,356,121.4	346.6	0.0	0.0
08/22/2024 15:00	37.7	15.4	40.4	248.4	2,153,119.5	896.2	3.7	1.3
08/22/2024 16:00	9.9	13.8	8.2	119.7	3,136,169.4	1,671.8	1.3	0.8
08/22/2024 17:00	10.6	13.5	8.5	154.8	3,194,647.3	1,889.6	1.7	1.3
08/22/2024 18:00	11.0	13.4	8.7	161.0	3,282,868.9	2,013.7	1.7	1.4
08/22/2024 19:00	11.0	13.4	8.7	160.2	3,286,948.5	1,992.2	1.7	1.4
08/22/2024 20:00	11.0	13.4	8.7	157.4	3,275,564.1	1,985.3	1.6	1.2
08/22/2024 21:00	10.9	13.4	8.6	152.3	3,301,481.8	1,976.9	1.6	1.2
08/22/2024 22:00	10.9	13.4	8.6	152.4	3,289,457.6	1,969.7	1.6	1.2
08/22/2024 23:00	10.8	13.4	8.5	150.3	3,318,064.6	1,962.6	1.5	1.2
Average/Sum#:	14.7	13.9	15.0	154.5	2,996,770.4	1,729.5	1.7	1.1
Minimum:	9.9	13.3	7.9	94.1	1,356,121.4	346.6	0.0	0.0
Maximum:	41.5	17.4	70.0	248.4	3,318,064.6	2,123.5	3.7	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/23/2024 00:00	10.6	13.4	8.3	147.5	3,306,906.3	1,956.0	1.5	1.2
08/23/2024 01:00	10.6	13.4	8.3	148.2	3,310,287.6	1,958.0	1.5	1.2
08/23/2024 02:00	10.5	13.4	8.3	145.6	3,310,287.6	1,958.0	1.5	1.2
08/23/2024 03:00	10.5	13.4	8.3	146.1	3,313,837.9	1,960.1	1.5	1.2
08/23/2024 04:00	10.4	13.4	8.2	144.5	3,319,248.0	1,963.3	1.5	1.2
08/23/2024 05:00	10.5	13.4	8.3	162.1	3,250,790.6	2,041.5	1.7	1.4
08/23/2024 06:00	10.2	13.9	8.6	95.6	2,729,338.9	1,435.0	1.1	0.6
08/23/2024 07:00	30.0	16.8	43.2	201.1	1,134,054.6	397.5	5.9	0.9
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.9	13.9	12.7	148.8	2,959,343.9	1,708.7	2.0	1.1
Minimum:	10.2	13.4	8.2	95.6	1,134,054.6	397.5	1.1	0.6
Maximum:	30.0	16.8	43.2	201.1	3,319,248.0	2,041.5	5.9	1.4
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 13:00	44.5	17.3	72.9	0.1	1,321,298.9	337.7	0.0	0.0
08/25/2024 14:00	57.1	15.9	67.4	226.4	1,729,688.3	656.8	4.1	1.1
08/25/2024 15:00	29.3	14.6	27.4	211.6	2,538,491.4	1,204.9	2.7	1.2
08/25/2024 16:00	10.0	13.8	8.3	140.3	3,273,487.1	1,745.0	1.5	1.0
08/25/2024 17:00	11.2	13.4	8.8	195.8	3,291,290.7	2,042.9	2.1	1.6
08/25/2024 18:00	11.7	13.1	8.9	232.9	3,259,928.7	2,332.9	2.5	2.3
08/25/2024 19:00	11.7	13.1	8.9	228.1	3,265,657.9	2,337.0	2.4	2.1
08/25/2024 20:00	11.8	13.1	8.9	231.8	3,274,601.1	2,343.4	2.5	2.3
08/25/2024 21:00	11.3	13.3	8.8	182.9	3,289,609.2	2,089.9	1.9	1.5
08/25/2024 22:00	11.1	13.4	8.7	172.4	3,297,473.7	1,974.5	1.8	1.4
08/25/2024 23:00	10.1	13.8	8.4	122.7	3,305,377.8	1,762.0	1.2	0.9
Average/Sum#:	20.0	14.1	21.6	176.8	2,895,173.2	1,711.5	2.1	1.4
Minimum:	10.0	13.1	8.3	0.1	1,321,298.9	337.7	0.0	0.0
Maximum:	57.1	17.3	72.9	232.9	3,305,377.8	2,343.4	4.1	2.3
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/26/2024 00:00	10.4	13.7	8.5	143.3	3,382,103.0	1,802.9	1.4	0.9
08/26/2024 01:00	10.6	13.7	8.7	137.7	3,305,940.5	1,762.3	1.4	0.9
08/26/2024 02:00	10.2	13.8	8.5	127.0	3,323,949.4	1,771.9	1.3	0.9
08/26/2024 03:00	10.8	13.6	8.7	148.8	3,389,325.4	1,831.5	1.5	1.1
08/26/2024 04:00	10.7	13.6	8.6	148.1	3,388,029.9	1,830.8	1.5	1.1
08/26/2024 05:00	10.8	13.6	8.7	149.7	3,384,513.9	1,828.9	1.5	1.1
08/26/2024 06:00	10.3	13.9	8.7	117.2	3,285,477.3	1,727.4	1.2	0.9
08/26/2024 07:00	10.4	13.7	8.5	136.7	3,339,915.0	1,804.8	1.4	0.9
08/26/2024 08:00	10.3	13.8	8.6	111.4	3,127,613.1	1,644.4	1.2	0.8
08/26/2024 09:00	9.9	13.8	8.2	113.0	3,302,404.9	1,736.3	1.1	0.7
08/26/2024 10:00	9.9	13.8	8.2	115.2	3,278,059.6	1,723.5	1.2	0.9
08/26/2024 11:00	9.9	13.8	8.2	114.4	3,270,071.3	1,719.3	1.2	0.9
08/26/2024 12:00	10.7	13.5	8.5	139.8	3,178,091.6	1,856.6	1.5	1.1
08/26/2024 13:00	10.8	13.4	8.5	151.7	3,275,018.7	2,032.8	1.6	1.2
08/26/2024 14:00	10.8	13.3	8.4	157.7	3,235,420.7	2,079.1	1.7	1.5
08/26/2024 15:00	10.7	13.4	8.4	153.2	3,246,332.0	2,038.7	1.6	1.2
08/26/2024 16:00	10.8	13.2	8.3	174.5	3,248,395.0	2,158.6	1.9	1.5
08/26/2024 17:00	10.9	13.2	8.4	201.8	3,195,417.7	2,263.4	2.2	1.8
08/26/2024 18:00	10.9	13.1	8.2	207.2	3,180,937.7	2,299.6	2.3	2.1
08/26/2024 19:00	11.0	13.1	8.3	205.9	3,221,221.5	2,305.2	2.2	1.8
08/26/2024 20:00	10.8	13.2	8.3	199.8	3,248,851.2	2,253.8	2.1	1.8
08/26/2024 21:00	10.8	13.2	8.3	196.1	3,256,202.9	2,258.9	2.1	1.8
08/26/2024 22:00	10.7	13.2	8.2	188.8	3,248,886.5	2,230.1	2.0	1.8
08/26/2024 23:00	10.4	13.4	8.2	151.9	3,303,282.6	2,002.1	1.6	1.2
Average/Sum#:	10.6	13.5	8.4	153.8	3,275,644.2	1,956.8	1.6	1.2
Minimum:	9.9	13.1	8.2	111.4	3,127,613.1	1,644.4	1.1	0.7
Maximum:	11.0	13.9	8.7	207.2	3,389,325.4	2,305.2	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/27/2024 00:00	10.5	13.4	8.3	148.7	3,320,353.1	1,988.2	1.5	1.2
08/27/2024 01:00	10.6	13.4	8.3	148.6	3,326,699.2	1,992.0	1.5	1.2
08/27/2024 02:00	10.6	13.4	8.3	148.3	3,332,878.3	1,995.7	1.5	1.2
08/27/2024 03:00	10.6	13.4	8.3	148.6	3,296,353.0	1,997.9	1.5	1.2
08/27/2024 04:00	10.5	13.4	8.3	147.4	3,305,322.9	1,979.2	1.5	1.2
08/27/2024 05:00	9.9	13.8	8.2	136.2	3,274,255.7	1,721.5	1.4	0.9
08/27/2024 06:00	10.2	13.8	8.5	115.9	3,240,780.8	1,703.9	1.2	0.9
08/27/2024 07:00	10.4	13.8	8.6	110.3	3,051,724.2	1,604.5	1.2	0.8
08/27/2024 08:00	10.2	14.0	8.7	88.6	2,541,728.8	1,317.8	1.1	0.5
08/27/2024 09:00	10.1	14.0	8.6	87.3	2,537,871.3	1,315.8	1.1	0.5
08/27/2024 10:00	10.0	14.0	8.6	87.9	2,543,271.8	1,318.6	1.1	0.5
08/27/2024 11:00	9.9	14.0	8.5	86.8	2,553,301.4	1,323.8	1.1	0.5
08/27/2024 12:00	10.0	13.9	8.4	114.4	3,083,297.0	1,621.1	1.2	0.8
08/27/2024 13:00	10.1	13.8	8.4	120.1	3,161,658.5	1,662.3	1.3	0.8
08/27/2024 14:00	10.1	13.8	8.4	122.9	3,234,280.2	1,724.1	1.3	0.9
08/27/2024 15:00	10.1	13.9	8.5	106.6	3,028,520.1	1,592.3	1.2	0.8
08/27/2024 16:00	10.9	13.4	8.6	151.5	3,105,727.1	1,950.4	1.7	1.4
08/27/2024 17:00	11.1	13.2	8.5	197.5	3,172,546.9	2,247.2	2.2	1.8
08/27/2024 18:00	10.9	13.2	8.4	194.8	3,236,212.0	2,221.4	2.1	1.8
08/27/2024 19:00	10.8	13.2	8.3	192.7	3,210,159.0	2,250.4	2.1	1.8
08/27/2024 20:00	10.9	13.2	8.4	205.4	3,219,841.4	2,280.7	2.2	1.8
08/27/2024 21:00	10.7	13.2	8.2	199.7	3,215,151.7	2,253.9	2.2	1.8
08/27/2024 22:00	10.4	13.3	8.1	168.0	3,257,229.8	2,116.9	1.8	1.5
08/27/2024 23:00	10.5	13.2	8.0	178.8	3,282,599.6	2,205.3	1.9	1.5
Average/Sum#:	10.4	13.6	8.4	142.0	3,105,490.2	1,849.4	1.5	1.1
Minimum:	9.9	13.2	8.0	86.8	2,537,871.3	1,315.8	1.1	0.5
Maximum:	11.1	14.0	8.7	205.4	3,332,878.3	2,280.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/28/2024 00:00	10.5	13.3	8.2	171.7	3,293,081.0	2,140.2	1.8	1.5
08/28/2024 01:00	10.4	13.4	8.2	152.6	3,272,924.3	2,007.6	1.6	1.2
08/28/2024 02:00	10.4	13.4	8.2	147.7	3,310,212.2	2,006.3	1.5	1.2
08/28/2024 03:00	10.6	13.3	8.2	160.1	3,285,044.5	2,087.0	1.7	1.5
08/28/2024 04:00	10.7	13.2	8.2	190.3	3,282,348.3	2,229.1	2.0	1.8
08/28/2024 05:00	10.6	13.2	8.1	217.6	3,277,636.3	2,225.9	2.3	2.0
08/28/2024 06:00	10.9	13.3	8.5	163.0	3,268,989.2	2,076.8	1.7	1.5
08/28/2024 07:00	10.7	13.4	8.4	153.3	3,268,522.6	2,004.9	1.6	1.2
08/28/2024 08:00	10.7	13.3	8.3	154.0	3,239,413.7	2,010.7	1.6	1.2
08/28/2024 09:00	10.7	13.3	8.3	153.2	3,213,370.2	2,018.0	1.6	1.2
08/28/2024 10:00	10.6	13.3	8.2	154.5	3,228,338.4	2,027.4	1.6	1.2
08/28/2024 11:00	10.6	13.3	8.2	155.5	3,205,240.1	2,036.3	1.7	1.4
08/28/2024 12:00	10.6	13.3	8.2	156.0	3,191,070.0	2,050.6	1.7	1.4
08/28/2024 13:00	10.7	13.3	8.3	171.0	3,174,807.3	2,109.7	1.9	1.5
08/28/2024 14:00	10.6	13.3	8.2	164.2	3,174,630.0	2,086.4	1.8	1.5
08/28/2024 15:00	10.5	13.3	8.2	160.5	3,178,295.5	2,065.6	1.7	1.4
08/28/2024 16:00	10.6	13.3	8.2	167.2	3,185,585.4	2,093.6	1.8	1.5
08/28/2024 17:00	10.6	13.3	8.2	161.7	3,182,449.9	2,068.3	1.7	1.4
08/28/2024 18:00	10.8	13.2	8.3	186.9	3,165,992.6	2,173.2	2.1	1.7
08/28/2024 19:00	10.8	13.1	8.2	200.8	3,177,623.5	2,274.0	2.2	1.8
08/28/2024 20:00	10.5	13.2	8.0	177.7	3,164,106.6	2,148.8	2.0	1.7
08/28/2024 21:00	10.4	13.4	8.2	155.9	3,224,039.0	2,024.7	1.7	1.4
08/28/2024 22:00	10.4	13.4	8.2	154.0	3,246,341.3	2,015.0	1.6	1.2
08/28/2024 23:00	10.3	13.4	8.1	148.2	3,299,487.8	1,999.8	1.5	1.2
Average/Sum#:	10.6	13.3	8.2	165.7	3,229,564.6	2,082.5	1.8	1.4
Minimum:	10.3	13.1	8.0	147.7	3,164,106.6	1,999.8	1.5	1.2
Maximum:	10.9	13.4	8.5	217.6	3,310,212.2	2,274.0	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/29/2024 00:00	10.4	13.4	8.2	148.5	3,263,142.7	2,001.6	1.5	1.2
08/29/2024 01:00	10.4	13.4	8.2	149.2	3,297,177.9	1,998.4	1.5	1.2
08/29/2024 02:00	10.3	13.4	8.1	146.4	3,289,093.4	1,993.5	1.5	1.2
08/29/2024 03:00	10.4	13.4	8.2	148.2	3,290,083.3	1,994.1	1.5	1.2
08/29/2024 04:00	10.4	13.4	8.2	153.0	3,318,734.8	2,035.7	1.6	1.2
08/29/2024 05:00	10.3	13.4	8.1	184.3	3,329,371.3	1,993.6	1.9	1.4
08/29/2024 06:00	9.9	13.8	8.2	114.4	3,317,240.4	1,744.1	1.1	0.7
08/29/2024 07:00	10.2	13.8	8.5	105.5	2,929,807.4	1,540.4	1.2	0.8
08/29/2024 08:00	10.1	14.0	8.6	87.1	2,553,301.4	1,323.8	1.1	0.5
08/29/2024 09:00	10.2	14.0	8.7	89.2	2,549,829.6	1,322.0	1.1	0.5
08/29/2024 10:00	10.1	14.0	8.6	88.7	2,550,986.9	1,322.6	1.1	0.5
08/29/2024 11:00	10.1	14.0	8.6	88.5	2,574,132.1	1,334.6	1.1	0.5
08/29/2024 12:00	10.4	13.8	8.6	115.3	3,026,808.3	1,591.4	1.3	0.8
08/29/2024 13:00	10.3	13.8	8.6	119.8	3,161,682.0	1,685.4	1.3	0.8
08/29/2024 14:00	10.3	13.8	8.6	125.6	3,244,973.0	1,729.8	1.3	0.9
08/29/2024 15:00	10.6	13.8	8.8	114.9	2,889,110.3	1,540.1	1.3	0.8
08/29/2024 16:00	11.3	13.3	8.8	159.0	3,209,992.3	2,086.2	1.7	1.5
08/29/2024 17:00	11.2	13.2	8.6	183.8	3,188,844.6	2,165.6	2.0	1.7
08/29/2024 18:00	10.9	13.3	8.5	167.1	3,204,606.9	2,082.7	1.8	1.5
08/29/2024 19:00	11.0	13.1	8.3	190.1	3,213,967.0	2,229.6	2.1	1.8
08/29/2024 20:00	10.7	13.2	8.2	174.7	3,204,001.6	2,129.1	1.9	1.5
08/29/2024 21:00	10.7	13.3	8.3	165.5	3,232,308.4	2,077.1	1.8	1.5
08/29/2024 22:00	10.6	13.3	8.2	155.9	3,271,131.0	2,006.5	1.6	1.2
08/29/2024 23:00	10.6	13.4	8.3	151.1	3,263,957.8	2,002.1	1.6	1.2
Average/Sum#:	10.5	13.6	8.4	138.6	3,098,928.5	1,830.4	1.5	1.1
Minimum:	9.9	13.1	8.1	87.1	2,549,829.6	1,322.0	1.1	0.5
Maximum:	11.3	14.0	8.8	190.1	3,329,371.3	2,229.6	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/30/2024 00:00	10.6	13.4	8.3	149.1	3,295,363.0	1,997.3	1.5	1.2
08/30/2024 01:00	10.5	13.4	8.3	148.2	3,289,093.4	1,993.5	1.5	1.2
08/30/2024 02:00	10.5	13.4	8.3	147.3	3,325,530.2	1,991.3	1.5	1.2
08/30/2024 03:00	10.5	13.4	8.3	147.4	3,322,524.2	1,989.5	1.5	1.2
08/30/2024 04:00	10.5	13.3	8.2	156.1	3,325,445.7	2,064.1	1.6	1.2
08/30/2024 05:00	10.5	13.3	8.2	191.9	3,256,460.4	2,116.4	2.1	1.7
08/30/2024 06:00	10.8	13.3	8.4	155.6	3,296,650.4	2,070.3	1.6	1.2
08/30/2024 07:00	9.7	13.9	8.2	92.4	2,627,231.3	1,400.5	1.2	0.7
08/30/2024 08:00	9.8	13.9	8.3	89.0	2,620,735.9	1,377.9	1.1	0.6
08/30/2024 09:00	9.8	13.9	8.3	86.7	2,524,495.8	1,327.3	1.1	0.5
08/30/2024 10:00	9.9	13.9	8.3	88.4	2,541,613.6	1,336.3	1.1	0.5
08/30/2024 11:00	10.0	14.0	8.6	97.1	2,651,668.5	1,374.8	1.2	0.7
08/30/2024 12:00	10.0	14.0	8.6	88.9	2,597,470.2	1,346.7	1.1	0.5
08/30/2024 13:00	10.1	13.8	8.4	121.6	3,190,758.8	1,677.6	1.3	0.8
08/30/2024 14:00	10.6	13.6	8.6	128.2	3,125,391.6	1,711.7	1.4	0.9
08/30/2024 15:00	11.0	13.3	8.5	161.0	3,170,978.2	2,084.0	1.7	1.5
08/30/2024 16:00	10.9	13.2	8.4	171.9	3,160,691.0	2,123.4	1.9	1.5
08/30/2024 17:00	10.9	13.1	8.2	189.4	3,146,287.8	2,228.6	2.1	1.8
08/30/2024 18:00	10.8	13.1	8.2	204.5	3,160,880.5	2,285.1	2.3	2.1
08/30/2024 19:00	10.7	13.1	8.1	203.6	3,180,837.5	2,276.3	2.2	1.8
08/30/2024 20:00	10.6	13.1	8.0	196.8	3,171,894.3	2,269.9	2.2	1.8
08/30/2024 21:00	10.5	13.2	8.0	189.9	3,184,272.1	2,209.0	2.1	1.8
08/30/2024 22:00	10.3	13.3	8.0	159.5	3,255,089.9	2,044.2	1.7	1.4
08/30/2024 23:00	10.6	13.2	8.1	186.5	3,221,462.8	2,234.8	2.0	1.8
Average/Sum#:	10.4	13.5	8.3	148.0	3,068,451.1	1,897.1	1.6	1.2
Minimum:	9.7	13.1	8.0	86.7	2,524,495.8	1,327.3	1.1	0.5
Maximum:	11.0	14.0	8.6	204.5	3,325,530.2	2,285.1	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/31/2024 00:00	10.5	13.2	8.0	190.5	3,244,807.4	2,227.3	2.0	1.8
08/31/2024 01:00	10.5	13.2	8.0	190.3	3,267,476.0	2,219.0	2.0	1.8
08/31/2024 02:00	10.5	13.2	8.0	184.4	3,268,212.3	2,219.5	2.0	1.8
08/31/2024 03:00	10.5	13.2	8.0	184.9	3,258,199.3	2,212.7	2.0	1.8
08/31/2024 04:00	10.4	13.2	8.0	184.0	3,291,679.4	2,211.4	1.9	1.5
08/31/2024 05:00	10.4	13.2	8.0	161.9	3,255,495.2	2,092.0	1.7	1.5
08/31/2024 06:00	24.4	16.2	30.6	175.2	1,507,400.4	583.4	3.8	0.9
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 14:00	34.5	17.5	59.9	50.2	1,349,090.5	325.1	0.0	0.0
08/31/2024 15:00	31.8	15.0	31.8	220.1	2,391,699.7	1,047.9	2.9	1.2
08/31/2024 16:00	10.4	13.7	8.5	124.9	3,110,443.9	1,680.8	1.3	0.8
08/31/2024 17:00	10.6	13.5	8.5	135.5	3,093,208.5	1,829.6	1.5	1.1
08/31/2024 18:00	11.1	13.1	8.4	202.6	3,152,857.6	2,279.3	2.2	1.8
08/31/2024 19:00	10.8	13.1	8.2	203.2	3,169,180.0	2,291.1	2.2	1.8
08/31/2024 20:00	10.7	13.1	8.1	206.0	3,179,554.4	2,298.6	2.3	2.1
08/31/2024 21:00	10.5	13.1	7.9	207.0	3,186,747.4	2,303.8	2.3	2.1
08/31/2024 22:00	10.4	13.2	8.0	193.7	3,249,716.1	2,254.4	2.1	1.8
08/31/2024 23:00	10.6	13.1	8.0	208.5	3,235,794.5	2,292.0	2.3	2.1
Average/Sum#:	14.0	13.8	13.9	177.8	2,953,621.3	1,904.0	2.0	1.5
Minimum:	10.4	13.1	7.9	50.2	1,349,090.5	325.1	0.0	0.0
Maximum:	34.5	17.5	59.9	220.1	3,291,679.4	2,303.8	3.8	2.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/01/2024 00:00	10.5	13.2	8.0	179.9	3,233,925.5	2,172.6	1.9	1.5
09/01/2024 01:00	10.4	13.2	8.0	174.4	3,255,166.9	2,163.1	1.9	1.5
09/01/2024 02:00	10.4	13.2	8.0	181.4	3,245,833.5	2,180.6	1.9	1.5
09/01/2024 03:00	10.2	13.3	7.9	163.9	3,280,637.1	2,084.2	1.7	1.5
09/01/2024 04:00	10.2	13.4	8.0	150.7	3,285,133.6	1,991.1	1.6	1.2
09/01/2024 05:00	10.3	13.4	8.1	151.2	3,247,372.8	1,944.5	1.6	1.2
09/01/2024 06:00	23.0	16.2	28.9	169.2	1,620,054.9	627.0	3.4	0.8
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 10:00	17.8	18.2	38.9	156.2	984,794.8	165.4	0.0	0.0
09/01/2024 11:00	43.5	15.8	50.3	242.9	1,982,048.0	767.1	3.7	1.1
09/01/2024 12:00	9.9	13.9	8.3	96.6	2,725,344.7	1,432.9	1.2	0.7
09/01/2024 13:00	10.0	13.9	8.4	91.2	2,633,859.6	1,384.8	1.1	0.6
09/01/2024 14:00	10.4	13.7	8.5	128.4	3,080,266.9	1,642.0	1.4	0.8
09/01/2024 15:00	10.2	13.8	8.5	113.6	2,993,713.9	1,574.0	1.3	0.8
09/01/2024 16:00	10.5	13.6	8.5	130.6	3,193,164.6	1,725.5	1.4	0.9
09/01/2024 17:00	10.6	13.6	8.6	129.7	3,152,780.1	1,726.7	1.4	0.9
09/01/2024 18:00	11.1	13.2	8.5	170.6	3,206,685.8	2,154.3	1.8	1.5
09/01/2024 19:00	11.0	13.2	8.4	197.2	3,181,344.0	2,230.2	2.2	1.8
09/01/2024 20:00	10.8	13.2	8.3	188.0	3,226,596.9	2,214.8	2.0	1.8
09/01/2024 21:00	10.8	13.2	8.3	200.8	3,215,437.0	2,254.1	2.2	1.8
09/01/2024 22:00	10.8	13.2	8.3	191.0	3,258,336.9	2,189.0	2.0	1.8
09/01/2024 23:00	10.7	13.2	8.2	182.5	3,244,493.8	2,179.7	2.0	1.7
Average/Sum#:	13.0	13.9	12.7	161.4	2,916,523.4	1,752.6	1.8	1.2
Minimum:	9.9	13.2	7.9	91.2	984,794.8	165.4	0.0	0.0
Maximum:	43.5	18.2	50.3	242.9	3,285,133.6	2,254.1	3.7	1.8
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/02/2024 00:00	10.6	13.2	8.1	180.1	3,253,963.0	2,162.3	1.9	1.5
09/02/2024 01:00	10.5	13.3	8.2	171.5	3,253,783.5	2,090.9	1.8	1.5
09/02/2024 02:00	10.1	13.4	7.9	142.3	3,302,172.5	1,953.2	1.5	1.2
09/02/2024 03:00	10.1	13.4	7.9	144.5	3,302,510.6	1,953.4	1.5	1.2
09/02/2024 04:00	10.1	13.4	7.9	142.4	3,298,284.0	1,950.9	1.5	1.2
09/02/2024 05:00	10.2	13.4	8.0	146.6	3,302,679.7	1,953.5	1.5	1.2
09/02/2024 06:00	10.7	13.4	8.4	140.0	3,269,035.8	1,933.6	1.4	1.0
09/02/2024 07:00	23.3	16.0	28.1	171.3	1,598,989.7	642.2	3.5	0.8
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 10:00	38.5	16.9	56.8	228.4	1,656,633.4	447.6	4.0	0.7
09/02/2024 11:00	27.1	14.4	24.6	188.9	2,428,377.8	1,188.1	2.5	1.2
09/02/2024 12:00	10.0	13.9	8.4	89.1	2,650,511.3	1,374.2	1.1	0.5
09/02/2024 13:00	10.2	13.9	8.6	93.1	2,661,505.2	1,379.9	1.1	0.6
09/02/2024 14:00	10.5	13.7	8.6	142.5	3,170,217.4	1,713.1	1.5	1.0
09/02/2024 15:00	10.3	13.8	8.6	106.2	2,916,683.7	1,533.5	1.2	0.8
09/02/2024 16:00	10.3	13.7	8.4	122.0	3,173,500.3	1,691.7	1.3	0.8
09/02/2024 17:00	10.8	13.5	8.6	141.3	3,080,866.7	1,822.3	1.6	1.1
09/02/2024 18:00	11.2	13.1	8.5	207.3	3,191,597.2	2,284.0	2.3	2.1
09/02/2024 19:00	11.0	13.1	8.3	208.2	3,175,543.0	2,295.7	2.3	2.1
09/02/2024 20:00	10.8	13.2	8.3	189.5	3,200,373.9	2,196.8	2.1	1.8
09/02/2024 21:00	10.5	13.4	8.3	159.3	3,223,786.1	2,001.0	1.7	1.4
09/02/2024 22:00	10.6	13.4	8.3	158.6	3,266,157.7	2,027.3	1.7	1.4
09/02/2024 23:00	10.4	13.4	8.2	151.5	3,286,783.5	1,992.1	1.6	1.2
Average/Sum#:	13.1	13.8	12.1	155.7	2,984,725.3	1,754.0	1.8	1.2
Minimum:	10.0	13.1	7.9	89.1	1,598,989.7	447.6	1.1	0.5
Maximum:	38.5	16.9	56.8	228.4	3,302,679.7	2,295.7	4.0	2.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/03/2024 00:00	10.4	13.4	8.2	150.0	3,262,529.9	1,977.4	1.6	1.2
09/03/2024 01:00	10.5	13.4	8.3	150.1	3,270,944.4	1,982.5	1.6	1.2
09/03/2024 02:00	10.4	13.4	8.2	150.5	3,305,155.9	1,979.1	1.6	1.2
09/03/2024 03:00	10.4	13.4	8.2	147.9	3,302,650.8	1,977.6	1.5	1.2
09/03/2024 04:00	10.4	13.4	8.2	149.8	3,292,888.2	1,995.8	1.5	1.2
09/03/2024 05:00	10.5	13.3	8.2	196.3	3,163,959.3	2,148.7	2.2	1.7
09/03/2024 06:00	10.8	13.3	8.4	164.3	3,293,544.3	2,092.4	1.7	1.5
09/03/2024 07:00	10.5	13.4	8.3	149.5	3,297,640.7	1,974.6	1.5	1.2
09/03/2024 08:00	10.6	13.4	8.3	151.9	3,275,894.1	1,985.5	1.6	1.2
09/03/2024 09:00	10.6	13.4	8.3	153.6	3,259,882.1	1,999.6	1.6	1.2
09/03/2024 10:00	10.6	13.4	8.3	157.1	3,252,785.7	2,019.0	1.7	1.4
09/03/2024 11:00	10.6	13.4	8.3	158.7	3,235,981.7	2,032.2	1.7	1.4
09/03/2024 12:00	10.7	13.3	8.3	170.7	3,204,904.5	2,129.7	1.8	1.5
09/03/2024 13:00	10.7	13.2	8.2	195.1	3,212,093.0	2,228.3	2.1	1.8
09/03/2024 14:00	10.6	13.2	8.1	208.7	3,217,576.7	2,255.6	2.3	2.0
09/03/2024 15:00	10.7	13.2	8.2	201.6	3,176,641.0	2,250.1	2.2	1.8
09/03/2024 16:00	10.6	13.2	8.1	200.2	3,199,745.7	2,243.1	2.2	1.8
09/03/2024 17:00	10.8	13.2	8.3	219.6	3,190,898.6	2,283.5	2.4	2.1
09/03/2024 18:00	10.9	13.2	8.4	214.5	3,204,872.3	2,293.5	2.3	2.1
09/03/2024 19:00	10.8	13.2	8.3	213.7	3,216,051.2	2,301.5	2.3	2.1
09/03/2024 20:00	10.8	13.2	8.3	217.1	3,225,972.6	2,308.6	2.4	2.1
09/03/2024 21:00	10.7	13.2	8.2	222.6	3,230,444.2	2,311.8	2.4	2.1
09/03/2024 22:00	10.7	13.2	8.2	215.0	3,230,164.7	2,311.6	2.3	2.1
09/03/2024 23:00	10.4	13.3	8.1	189.9	3,217,551.9	2,161.6	2.1	1.7
Average/Sum#:	10.6	13.3	8.2	181.2	3,239,198.9	2,135.1	1.9	1.6
Minimum:	10.4	13.2	8.1	147.9	3,163,959.3	1,974.6	1.5	1.2
Maximum:	10.9	13.4	8.4	222.6	3,305,155.9	2,311.8	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/04/2024 00:00	9.4	13.9	7.9	117.3	3,283,955.8	1,726.6	1.2	0.9
09/04/2024 01:00	9.5	13.9	8.0	117.3	3,304,497.1	1,737.4	1.2	0.9
09/04/2024 02:00	9.6	13.9	8.1	113.2	3,278,440.0	1,723.7	1.1	0.7
09/04/2024 03:00	9.8	13.9	8.3	118.8	3,310,203.1	1,740.4	1.2	0.9
09/04/2024 04:00	9.9	13.8	8.2	122.2	3,306,779.5	1,738.6	1.2	0.9
09/04/2024 05:00	9.7	13.9	8.2	114.9	3,260,561.4	1,714.3	1.2	0.9
09/04/2024 06:00	10.0	13.9	8.4	115.2	3,258,659.4	1,713.3	1.2	0.9
09/04/2024 07:00	10.0	13.9	8.4	121.0	3,317,620.8	1,744.3	1.2	0.9
09/04/2024 08:00	10.3	13.8	8.6	128.1	3,286,806.1	1,752.1	1.3	0.9
09/04/2024 09:00	10.3	13.7	8.4	131.6	3,284,179.8	1,750.7	1.3	0.9
09/04/2024 10:00	10.5	13.7	8.6	134.6	3,226,659.9	1,743.6	1.4	0.9
09/04/2024 11:00	10.4	13.7	8.5	130.2	3,242,574.9	1,752.2	1.3	0.9
09/04/2024 12:00	10.3	13.8	8.6	123.9	3,177,252.2	1,693.7	1.3	0.8
09/04/2024 13:00	11.2	13.2	8.6	180.1	3,172,694.1	2,177.8	2.0	1.7
09/04/2024 14:00	11.0	13.2	8.4	198.8	3,148,970.2	2,230.5	2.2	1.8
09/04/2024 15:00	10.9	13.2	8.4	183.5	3,138,458.5	2,154.3	2.0	1.7
09/04/2024 16:00	10.9	13.2	8.4	191.6	3,122,858.2	2,189.2	2.1	1.8
09/04/2024 17:00	10.7	13.2	8.2	194.6	3,158,325.1	2,191.0	2.2	1.8
09/04/2024 18:00	10.7	13.2	8.2	182.2	3,175,003.1	2,156.2	2.0	1.7
09/04/2024 19:00	10.8	13.1	8.2	206.1	3,137,226.8	2,268.0	2.3	2.0
09/04/2024 20:00	10.7	13.2	8.2	215.0	3,174,269.8	2,271.6	2.4	2.0
09/04/2024 21:00	10.7	13.2	8.2	203.4	3,178,052.8	2,251.1	2.2	1.8
09/04/2024 22:00	10.6	13.2	8.1	190.5	3,216,981.8	2,208.2	2.1	1.8
09/04/2024 23:00	10.6	13.2	8.1	203.9	3,228,381.9	2,239.6	2.2	1.8
Average/Sum#:	10.4	13.5	8.3	155.8	3,224,558.8	1,952.9	1.7	1.3
Minimum:	9.4	13.1	7.9	113.2	3,122,858.2	1,693.7	1.1	0.7
Maximum:	11.2	13.9	8.6	215.0	3,317,620.8	2,271.6	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/05/2024 00:00	10.5	13.2	8.0	197.5	3,236,357.7	2,221.5	2.1	1.8
09/05/2024 01:00	10.5	13.2	8.0	192.1	3,231,258.8	2,218.0	2.1	1.8
09/05/2024 02:00	10.5	13.2	8.0	194.6	3,247,597.3	2,205.5	2.1	1.8
09/05/2024 03:00	10.4	13.4	8.2	166.2	3,251,746.0	2,042.1	1.8	1.4
09/05/2024 04:00	10.7	13.2	8.2	199.2	3,253,839.7	2,233.5	2.1	1.8
09/05/2024 05:00	10.8	13.2	8.3	185.2	3,236,313.1	2,316.0	2.0	1.9
09/05/2024 06:00	10.9	13.3	8.5	167.5	3,350,052.8	2,128.3	1.7	1.5
09/05/2024 07:00	9.7	13.8	8.1	121.1	3,289,661.7	1,729.6	1.2	0.9
09/05/2024 08:00	9.9	13.9	8.3	118.5	3,174,592.0	1,669.1	1.2	0.8
09/05/2024 09:00	10.1	13.7	8.3	129.3	3,258,854.8	1,737.2	1.3	0.9
09/05/2024 10:00	10.1	13.8	8.4	126.1	3,218,334.9	1,715.6	1.3	0.9
09/05/2024 11:00	10.3	13.7	8.4	127.9	3,213,891.0	1,736.7	1.3	0.9
09/05/2024 12:00	10.5	13.7	8.6	130.6	3,216,851.9	1,738.3	1.4	0.9
09/05/2024 13:00	11.2	13.2	8.6	173.8	3,167,198.8	2,150.9	1.9	1.5
09/05/2024 14:00	11.0	13.2	8.4	196.5	3,133,556.8	2,196.7	2.2	1.8
09/05/2024 15:00	10.9	13.2	8.4	190.6	3,125,711.2	2,191.2	2.1	1.8
09/05/2024 16:00	10.8	13.2	8.3	173.6	3,128,241.6	2,101.6	1.9	1.5
09/05/2024 17:00	10.8	13.2	8.3	185.0	3,134,525.0	2,151.6	2.1	1.7
09/05/2024 18:00	10.7	13.2	8.2	195.8	3,156,595.3	2,189.8	2.2	1.8
09/05/2024 19:00	10.7	13.2	8.2	189.2	3,161,640.5	2,193.3	2.1	1.8
09/05/2024 20:00	10.6	13.2	8.1	190.5	3,166,974.1	2,197.0	2.1	1.8
09/05/2024 21:00	10.7	13.2	8.2	206.7	3,171,982.2	2,246.8	2.3	2.0
09/05/2024 22:00	10.7	13.1	8.1	213.5	3,198,584.1	2,289.0	2.3	2.1
09/05/2024 23:00	10.6	13.2	8.1	188.6	3,222,372.1	2,211.9	2.0	1.8
Average/Sum#:	10.6	13.4	8.3	173.3	3,206,113.9	2,075.5	1.9	1.5
Minimum:	9.7	13.1	8.0	118.5	3,125,711.2	1,669.1	1.2	0.8
Maximum:	11.2	13.9	8.6	213.5	3,350,052.8	2,316.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/06/2024 00:00	10.7	13.2	8.2	195.3	3,217,273.2	2,208.4	2.1	1.8
09/06/2024 01:00	10.6	13.2	8.1	188.9	3,224,101.3	2,166.0	2.0	1.7
09/06/2024 02:00	10.5	13.4	8.3	158.0	3,256,491.2	2,021.3	1.7	1.4
09/06/2024 03:00	10.7	13.2	8.2	188.1	3,240,823.8	2,200.9	2.0	1.8
09/06/2024 04:00	10.7	13.2	8.2	202.4	3,260,686.9	2,238.2	2.2	1.8
09/06/2024 05:00	10.7	13.2	8.2	181.5	3,268,644.8	2,291.4	1.9	1.6
09/06/2024 06:00	11.0	13.3	8.5	189.6	3,258,634.6	2,189.2	2.0	1.8
09/06/2024 07:00	10.8	13.3	8.4	184.2	3,246,438.7	2,157.3	2.0	1.7
09/06/2024 08:00	10.7	13.3	8.3	171.6	3,216,777.9	2,114.1	1.8	1.5
09/06/2024 09:00	10.5	13.4	8.3	158.3	3,226,041.6	2,002.4	1.7	1.4
09/06/2024 10:00	10.7	13.3	8.3	169.8	3,227,328.7	2,073.9	1.8	1.5
09/06/2024 11:00	10.9	13.2	8.4	183.2	3,169,260.3	2,152.3	2.0	1.7
09/06/2024 12:00	10.8	13.2	8.3	188.9	3,155,586.2	2,189.1	2.1	1.8
09/06/2024 13:00	10.8	13.2	8.3	192.8	3,143,045.2	2,180.4	2.1	1.7
09/06/2024 14:00	10.8	13.2	8.3	198.7	3,158,469.2	2,191.1	2.2	1.8
09/06/2024 15:00	10.9	13.2	8.4	190.6	3,127,565.6	2,192.5	2.1	1.8
09/06/2024 16:00	10.9	13.2	8.4	182.2	3,137,307.1	2,130.6	2.0	1.7
09/06/2024 17:00	10.9	13.2	8.4	195.3	3,139,873.9	2,178.2	2.2	1.7
09/06/2024 18:00	10.8	13.2	8.3	196.0	3,159,946.8	2,215.2	2.2	1.8
09/06/2024 19:00	10.7	13.2	8.2	197.2	3,167,935.1	2,220.8	2.2	1.8
09/06/2024 20:00	10.7	13.2	8.2	205.6	3,213,534.5	2,229.3	2.2	1.8
09/06/2024 21:00	10.8	13.2	8.3	209.8	3,213,867.9	2,253.0	2.3	2.0
09/06/2024 22:00	10.7	13.2	8.2	199.6	3,228,237.8	2,239.5	2.2	1.8
09/06/2024 23:00	10.8	13.2	8.3	215.4	3,220,942.0	2,305.0	2.3	2.1
Average/Sum#:	10.8	13.2	8.3	189.3	3,203,283.9	2,180.8	2.1	1.7
Minimum:	10.5	13.2	8.1	158.0	3,127,565.6	2,002.4	1.7	1.4
Maximum:	11.0	13.4	8.5	215.4	3,268,644.8	2,305.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/07/2024 00:00	10.7	13.2	8.2	220.9	3,224,994.4	2,307.9	2.4	2.1
09/07/2024 01:00	10.6	13.2	8.1	208.9	3,239,182.8	2,294.4	2.3	2.1
09/07/2024 02:00	10.6	13.2	8.1	192.1	3,253,634.5	2,209.6	2.1	1.8
09/07/2024 03:00	10.6	13.2	8.1	196.7	3,245,683.0	2,204.2	2.1	1.8
09/07/2024 04:00	10.6	13.2	8.1	197.4	3,255,587.9	2,234.7	2.1	1.8
09/07/2024 05:00	10.6	13.3	8.2	180.4	3,267,714.5	2,195.3	1.9	1.5
09/07/2024 06:00	10.9	13.3	8.5	177.6	3,250,151.8	2,112.3	1.9	1.5
09/07/2024 07:00	10.7	13.4	8.4	155.7	3,272,924.3	1,983.7	1.6	1.2
09/07/2024 08:00	10.7	13.4	8.4	157.4	3,274,079.2	1,984.4	1.6	1.2
09/07/2024 09:00	10.7	13.4	8.4	156.5	3,263,957.8	2,002.1	1.6	1.2
09/07/2024 10:00	10.8	13.3	8.4	170.6	3,239,227.2	2,105.2	1.8	1.5
09/07/2024 11:00	10.7	13.3	8.3	165.0	3,203,529.9	2,082.0	1.8	1.5
09/07/2024 12:00	10.8	13.2	8.3	190.0	3,182,746.2	2,184.7	2.1	1.7
09/07/2024 13:00	10.8	13.2	8.3	197.8	3,159,840.9	2,238.2	2.2	1.8
09/07/2024 14:00	10.8	13.2	8.3	202.4	3,157,920.6	2,259.9	2.2	1.8
09/07/2024 15:00	10.8	13.2	8.3	211.1	3,167,702.2	2,266.9	2.3	2.0
09/07/2024 16:00	10.6	13.2	8.1	187.9	3,165,118.5	2,172.6	2.1	1.7
09/07/2024 17:00	10.8	13.1	8.2	203.6	3,149,399.4	2,276.8	2.3	2.0
09/07/2024 18:00	10.7	13.1	8.1	214.7	3,171,946.5	2,293.1	2.4	2.1
09/07/2024 19:00	10.7	13.2	8.2	210.8	3,218,147.3	2,303.0	2.3	2.1
09/07/2024 20:00	10.7	13.2	8.2	212.0	3,226,531.5	2,309.0	2.3	2.1
09/07/2024 21:00	10.6	13.2	8.1	210.8	3,242,006.3	2,296.4	2.3	2.1
09/07/2024 22:00	10.5	13.3	8.2	195.0	3,278,580.6	2,202.6	2.1	1.8
09/07/2024 23:00	10.7	13.2	8.2	212.2	3,271,925.7	2,293.7	2.3	2.1
Average/Sum#:	10.7	13.2	8.2	192.8	3,224,272.2	2,200.5	2.1	1.8
Minimum:	10.5	13.1	8.1	155.7	3,149,399.4	1,983.7	1.6	1.2
Maximum:	10.9	13.4	8.5	220.9	3,278,580.6	2,309.0	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/08/2024 00:00	10.5	13.3	8.2	177.8	3,283,118.9	2,157.7	1.9	1.5
09/08/2024 01:00	10.4	13.4	8.2	158.7	3,276,347.8	2,009.7	1.7	1.4
09/08/2024 02:00	10.6	13.3	8.2	184.1	3,310,659.5	2,175.8	1.9	1.5
09/08/2024 03:00	10.6	13.3	8.2	182.0	3,293,841.9	2,188.8	1.9	1.5
09/08/2024 04:00	10.3	13.4	8.1	157.0	3,304,877.5	2,027.2	1.6	1.2
09/08/2024 05:00	9.7	13.8	8.1	131.5	3,272,361.5	1,744.4	1.4	0.9
09/08/2024 06:00	10.1	13.9	8.5	112.3	3,168,125.3	1,665.7	1.2	0.8
09/08/2024 07:00	10.2	13.9	8.6	114.7	3,143,589.8	1,652.8	1.2	0.8
09/08/2024 08:00	10.2	13.9	8.6	112.0	3,086,150.0	1,622.6	1.2	0.8
09/08/2024 09:00	10.2	13.9	8.6	103.8	2,944,452.6	1,548.1	1.2	0.8
09/08/2024 10:00	9.9	13.9	8.3	103.6	2,970,300.8	1,540.0	1.1	0.6
09/08/2024 11:00	9.8	13.9	8.3	99.5	3,000,389.5	1,555.6	1.1	0.6
09/08/2024 12:00	9.8	13.9	8.3	113.7	3,127,042.5	1,644.1	1.2	0.8
09/08/2024 13:00	9.9	13.8	8.2	117.0	3,147,425.0	1,677.8	1.2	0.8
09/08/2024 14:00	10.6	13.5	8.5	146.3	3,110,791.2	1,840.0	1.6	1.1
09/08/2024 15:00	11.0	13.2	8.4	201.2	3,185,195.5	2,232.9	2.2	1.8
09/08/2024 16:00	10.8	13.3	8.4	179.2	3,182,423.2	2,138.0	2.0	1.7
09/08/2024 17:00	10.9	13.2	8.4	200.2	3,165,064.5	2,241.9	2.2	1.8
09/08/2024 18:00	10.8	13.2	8.3	207.9	3,190,194.1	2,259.7	2.3	2.0
09/08/2024 19:00	10.7	13.2	8.2	212.7	3,200,540.4	2,290.4	2.3	2.1
09/08/2024 20:00	10.6	13.2	8.1	208.4	3,203,195.4	2,292.3	2.3	2.1
09/08/2024 21:00	10.6	13.2	8.1	210.4	3,216,594.3	2,278.4	2.3	2.1
09/08/2024 22:00	10.5	13.2	8.0	201.1	3,203,444.0	2,222.3	2.2	1.8
09/08/2024 23:00	10.5	13.3	8.2	187.6	3,251,131.3	2,207.9	2.0	1.8
Average/Sum#:	10.4	13.5	8.3	159.3	3,176,552.4	1,967.3	1.7	1.3
Minimum:	9.7	13.2	8.0	99.5	2,944,452.6	1,540.0	1.1	0.6
Maximum:	11.0	13.9	8.6	212.7	3,310,659.5	2,292.3	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/09/2024 00:00	10.4	13.3	8.1	189.7	3,280,813.4	2,204.1	2.0	1.8
09/09/2024 01:00	10.2	13.4	8.0	167.0	3,264,896.6	2,074.2	1.8	1.5
09/09/2024 02:00	10.5	13.3	8.2	180.8	3,281,953.4	2,180.9	1.9	1.5
09/09/2024 03:00	10.5	13.3	8.2	186.4	3,243,474.3	2,202.7	2.0	1.8
09/09/2024 04:00	10.4	13.3	8.1	194.9	3,253,045.5	2,209.2	2.1	1.8
09/09/2024 05:00	10.5	13.2	8.0	199.5	3,224,923.8	2,284.3	2.2	1.8
09/09/2024 06:00	10.7	13.4	8.4	168.1	3,305,034.9	2,099.7	1.7	1.5
09/09/2024 07:00	10.4	13.5	8.3	148.0	3,310,165.9	1,982.1	1.5	1.2
09/09/2024 08:00	10.7	13.4	8.4	156.5	3,279,853.9	1,987.9	1.6	1.2
09/09/2024 09:00	10.9	13.3	8.5	187.1	3,249,598.9	2,159.4	2.0	1.7
09/09/2024 10:00	10.9	13.2	8.4	185.5	3,149,823.3	2,139.1	2.0	1.7
09/09/2024 11:00	10.7	13.3	8.3	180.0	3,152,083.9	2,094.6	2.0	1.7
09/09/2024 12:00	10.8	13.3	8.4	176.7	3,141,850.8	2,087.8	1.9	1.5
09/09/2024 13:00	10.7	13.3	8.3	180.4	3,114,100.8	2,092.1	2.0	1.7
09/09/2024 14:00	10.7	13.3	8.3	172.0	3,126,134.3	2,031.7	1.9	1.4
09/09/2024 15:00	10.9	13.2	8.4	182.1	3,083,560.9	2,094.1	2.1	1.7
09/09/2024 16:00	10.9	13.1	8.2	198.0	3,063,877.5	2,192.6	2.3	2.0
09/09/2024 17:00	10.9	13.2	8.4	197.0	3,072,788.6	2,154.1	2.2	1.7
09/09/2024 18:00	10.8	13.2	8.3	204.4	3,098,993.3	2,195.1	2.3	2.0
09/09/2024 19:00	10.8	13.2	8.3	197.1	3,109,877.2	2,180.1	2.2	1.7
09/09/2024 20:00	10.6	13.3	8.2	182.3	3,182,632.6	2,114.9	2.0	1.7
09/09/2024 21:00	10.7	13.3	8.3	184.8	3,166,681.0	2,104.3	2.0	1.7
09/09/2024 22:00	10.6	13.4	8.3	162.9	3,202,842.0	1,988.0	1.7	1.4
09/09/2024 23:00	10.9	13.3	8.5	193.8	3,199,004.8	2,172.5	2.1	1.7
Average/Sum#:	10.7	13.3	8.3	182.3	3,189,917.2	2,126.1	2.0	1.6
Minimum:	10.2	13.1	8.0	148.0	3,063,877.5	1,982.1	1.5	1.2
Maximum:	10.9	13.5	8.5	204.4	3,310,165.9	2,284.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/10/2024 00:00	10.8	13.3	8.4	187.1	3,218,147.3	2,162.0	2.0	1.7
09/10/2024 01:00	10.6	13.4	8.3	169.8	3,232,000.8	2,029.7	1.8	1.4
09/10/2024 02:00	10.7	13.4	8.4	161.2	3,204,291.9	1,988.9	1.7	1.4
09/10/2024 03:00	10.6	13.3	8.2	164.5	3,221,809.7	2,023.3	1.8	1.4
09/10/2024 04:00	10.6	13.3	8.2	166.3	3,231,219.1	2,076.4	1.8	1.5
09/10/2024 05:00	10.5	13.2	8.0	186.9	3,144,683.4	2,204.5	2.1	1.8
09/10/2024 06:00	10.9	13.3	8.5	169.3	3,187,453.3	2,025.0	1.8	1.4
09/10/2024 07:00	10.0	13.8	8.3	109.5	2,953,962.5	1,553.1	1.2	0.8
09/10/2024 08:00	10.0	13.9	8.4	87.6	2,463,252.1	1,295.1	1.2	0.6
09/10/2024 09:00	10.1	14.0	8.6	87.9	2,502,382.0	1,297.4	1.2	0.6
09/10/2024 10:00	10.0	14.0	8.6	89.3	2,511,254.3	1,302.0	1.2	0.7
09/10/2024 11:00	9.9	14.0	8.5	87.0	2,506,046.6	1,299.3	1.1	0.5
09/10/2024 12:00	9.9	14.0	8.5	87.7	2,523,019.8	1,308.1	1.1	0.5
09/10/2024 13:00	10.1	13.9	8.5	102.4	2,650,977.4	1,393.8	1.3	0.7
09/10/2024 14:00	10.1	14.0	8.6	89.6	2,518,005.0	1,305.5	1.2	0.7
09/10/2024 15:00	10.2	14.0	8.7	93.9	2,550,215.4	1,322.2	1.2	0.7
09/10/2024 16:00	10.5	13.8	8.7	125.5	2,917,249.1	1,555.1	1.4	0.8
09/10/2024 17:00	11.2	13.3	8.7	153.0	3,134,093.0	1,991.1	1.7	1.4
09/10/2024 18:00	10.9	13.3	8.5	159.7	3,122,287.6	1,983.6	1.8	1.4
09/10/2024 19:00	10.8	13.3	8.4	157.4	3,169,009.1	1,967.0	1.7	1.4
09/10/2024 20:00	10.7	13.4	8.4	153.6	3,191,247.9	1,957.5	1.6	1.2
09/10/2024 21:00	10.6	13.4	8.3	152.0	3,213,692.5	1,947.8	1.6	1.2
09/10/2024 22:00	10.4	13.4	8.2	149.2	3,180,034.4	1,927.4	1.6	1.2
09/10/2024 23:00	22.6	16.0	27.2	172.4	1,599,985.7	642.6	3.5	0.8
Average/Sum#:	10.9	13.7	9.2	136.0	2,881,096.7	1,689.9	1.6	1.1
Minimum:	9.9	13.2	8.0	87.0	1,599,985.7	642.6	1.1	0.5
Maximum:	22.6	16.0	27.2	187.1	3,232,000.8	2,204.5	3.5	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 17:00	44.3	17.4	74.7	0.1	1,228,678.0	323.0	0.0	0.0
09/12/2024 18:00	45.4	17.1	70.5	234.9	1,371,478.5	400.6	5.4	0.8
09/12/2024 19:00	42.5	15.3	44.8	256.0	2,032,754.3	846.1	4.1	1.4
09/12/2024 20:00	9.4	13.9	7.9	110.1	3,061,145.7	1,587.1	1.2	0.8
09/12/2024 21:00	9.9	13.9	8.3	122.7	3,127,042.5	1,644.1	1.3	0.8
09/12/2024 22:00	10.2	13.8	8.5	133.1	3,165,621.4	1,687.5	1.4	0.8
09/12/2024 23:00	10.3	13.7	8.4	132.2	3,248,537.3	1,731.7	1.4	0.9
Average/Sum#:	24.6	15.0	31.9	141.3	2,462,179.7	1,174.3	2.1	0.8
Minimum:	9.4	13.7	7.9	0.1	1,228,678.0	323.0	0.0	0.0
Maximum:	45.4	17.4	74.7	256.0	3,248,537.3	1,731.7	5.4	1.4
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/13/2024 00:00	9.9	13.8	8.2	123.8	3,232,967.1	1,723.4	1.3	0.9
09/13/2024 01:00	10.2	13.9	8.6	105.4	2,922,579.9	1,536.6	1.2	0.8
09/13/2024 02:00	10.2	13.9	8.6	106.2	2,919,346.5	1,534.9	1.2	0.8
09/13/2024 03:00	10.0	13.9	8.4	117.6	3,139,595.6	1,650.7	1.2	0.8
09/13/2024 04:00	9.7	13.8	8.1	118.6	3,282,434.2	1,725.8	1.2	0.9
09/13/2024 05:00	9.5	13.8	7.9	118.4	3,279,391.0	1,724.2	1.2	0.9
09/13/2024 06:00	10.3	13.8	8.6	116.1	2,982,343.7	1,589.8	1.3	0.8
09/13/2024 07:00	15.3	14.7	14.6	125.7	2,537,859.4	1,204.6	1.6	0.7
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 13:00	43.8	17.4	73.8	58.5	1,298,133.8	322.3	0.0	0.0
09/13/2024 14:00	40.3	15.6	44.9	253.0	2,136,302.0	858.0	3.7	1.2
09/13/2024 15:00	10.0	13.7	8.2	129.1	3,059,111.5	1,675.4	1.4	0.8
09/13/2024 16:00	11.2	13.1	8.5	212.8	3,097,782.1	2,149.0	2.4	1.9
09/13/2024 17:00	11.3	13.1	8.5	216.8	3,092,902.0	2,168.2	2.5	2.2
09/13/2024 18:00	10.5	13.6	8.5	143.8	3,111,476.4	1,726.8	1.6	1.0
09/13/2024 19:00	10.4	13.8	8.6	112.9	2,904,492.8	1,548.3	1.3	0.8
09/13/2024 20:00	10.4	13.8	8.6	127.8	3,137,482.6	1,672.5	1.4	0.8
09/13/2024 21:00	10.5	13.7	8.6	128.3	3,143,014.0	1,698.4	1.4	0.8
09/13/2024 22:00	10.4	13.7	8.5	128.2	3,171,436.8	1,690.6	1.4	0.8
09/13/2024 23:00	9.9	13.9	8.3	115.3	3,213,012.0	1,689.3	1.2	0.8
Average/Sum#:	13.9	14.1	14.1	134.6	2,929,561.2	1,573.1	1.5	0.9
Minimum:	9.5	13.1	7.9	58.5	1,298,133.8	322.3	0.0	0.0
Maximum:	43.8	17.4	73.8	253.0	3,282,434.2	2,168.2	3.7	2.2
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/14/2024 00:00	9.8	13.9	8.3	114.8	3,212,441.4	1,689.0	1.2	0.8
09/14/2024 01:00	10.5	13.6	8.5	136.2	3,250,532.3	1,756.5	1.4	0.9
09/14/2024 02:00	14.0	14.3	12.5	140.4	2,813,670.9	1,417.7	1.6	0.9
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 16:00	45.1	16.7	63.4	97.9	1,479,933.7	464.7	0.0	0.0
09/14/2024 17:00	46.4	15.3	48.9	266.6	1,699,266.8	719.7	5.0	1.4
09/14/2024 18:00	24.0	14.4	21.8	200.3	2,512,791.5	1,229.4	2.6	1.2
09/14/2024 19:00	10.2	13.8	8.5	128.1	2,969,399.8	1,582.9	1.5	0.9
09/14/2024 20:00	10.5	13.8	8.7	118.9	2,922,009.3	1,536.3	1.4	0.8
09/14/2024 21:00	10.4	13.8	8.6	112.1	2,925,052.4	1,537.9	1.3	0.8
09/14/2024 22:00	10.4	13.8	8.6	125.0	2,948,014.3	1,571.5	1.4	0.8
09/14/2024 23:00	10.1	13.8	8.4	125.9	3,194,885.8	1,703.1	1.3	0.9
Average/Sum#:	18.3	14.3	18.7	142.4	2,720,727.1	1,382.6	1.7	0.9
Minimum:	9.8	13.6	8.3	97.9	1,479,933.7	464.7	0.0	0.0
Maximum:	46.4	16.7	63.4	266.6	3,250,532.3	1,756.5	5.0	1.4
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/15/2024 00:00	9.9	13.9	8.3	123.3	3,214,153.1	1,689.9	1.3	0.8
09/15/2024 01:00	23.3	15.9	27.5	177.2	1,613,719.9	659.9	3.6	0.9
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 17:00	40.5	17.3	66.4	22.3	1,304,757.1	343.0	0.0	0.0
09/15/2024 18:00	51.5	15.8	59.6	264.8	1,737,618.7	672.5	4.8	1.2
09/15/2024 19:00	30.9	14.7	29.4	224.2	2,384,724.2	1,114.5	3.1	1.3
09/15/2024 20:00	9.8	13.8	8.1	108.1	2,929,617.2	1,540.3	1.2	0.8
09/15/2024 21:00	10.2	13.9	8.6	100.5	2,756,917.6	1,449.5	1.2	0.7
09/15/2024 22:00	10.2	13.9	8.6	104.5	2,798,761.1	1,471.5	1.2	0.7
09/15/2024 23:00	10.1	13.9	8.5	103.4	2,880,926.5	1,514.7	1.2	0.8
Average/Sum#:	21.8	14.8	25.0	136.5	2,402,355.0	1,161.8	2.0	0.8
Minimum:	9.8	13.8	8.1	22.3	1,304,757.1	343.0	0.0	0.0
Maximum:	51.5	17.3	66.4	264.8	3,214,153.1	1,689.9	4.8	1.3
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/16/2024 00:00	10.0	13.9	8.4	120.0	3,148,534.9	1,655.4	1.3	0.8
09/16/2024 01:00	10.0	13.9	8.4	100.2	2,883,018.7	1,515.8	1.1	0.6
09/16/2024 02:00	10.1	13.8	8.4	100.0	2,818,161.3	1,481.7	1.2	0.7
09/16/2024 03:00	10.1	13.8	8.4	119.7	3,089,193.2	1,624.2	1.3	0.8
09/16/2024 04:00	10.0	13.8	8.3	123.2	3,234,280.2	1,724.1	1.3	0.9
09/16/2024 05:00	9.9	13.8	8.2	123.3	3,225,463.4	1,719.4	1.3	0.9
09/16/2024 06:00	10.2	13.9	8.6	116.2	3,189,807.8	1,677.1	1.2	0.8
09/16/2024 07:00	15.4	14.6	14.4	133.5	2,623,485.1	1,264.4	1.6	0.8
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.7	13.9	9.1	117.0	3,026,493.1	1,582.8	1.3	0.8
Minimum:	9.9	13.8	8.2	100.0	2,623,485.1	1,264.4	1.1	0.6
Maximum:	15.4	14.6	14.4	133.5	3,234,280.2	1,724.1	1.6	0.9
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 20:00	40.1	17.4	67.6	37.9	1,252,642.9	329.3	0.0	0.0
09/17/2024 21:00	42.0	17.1	65.2	266.0	1,362,577.3	398.0	6.2	1.0
09/17/2024 22:00	36.4	15.7	41.3	249.7	2,175,356.0	857.8	3.6	1.2
09/17/2024 23:00	9.7	13.8	8.1	118.7	3,116,284.6	1,661.2	1.3	0.8
Average/Sum#:	32.1	16.0	45.6	168.1	1,976,715.2	811.6	2.8	0.8
Minimum:	9.7	13.8	8.1	37.9	1,252,642.9	329.3	0.0	0.0
Maximum:	42.0	17.4	67.6	266.0	3,116,284.6	1,661.2	6.2	1.2
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/18/2024 00:00	9.9	13.9	8.3	110.3	2,992,953.1	1,573.6	1.2	0.8
09/18/2024 01:00	10.4	13.7	8.5	142.9	3,179,100.2	1,717.9	1.5	1.0
09/18/2024 02:00	10.2	13.9	8.6	106.6	2,823,265.3	1,505.0	1.2	0.8
09/18/2024 03:00	10.2	13.8	8.5	103.0	2,833,186.9	1,489.6	1.2	0.7
09/18/2024 04:00	10.3	13.7	8.4	126.9	3,127,099.1	1,689.8	1.4	0.8
09/18/2024 05:00	10.9	13.4	8.6	155.6	3,125,787.2	2,054.3	1.7	1.4
09/18/2024 06:00	11.2	13.3	8.7	174.4	3,185,281.1	2,093.4	1.9	1.5
09/18/2024 07:00	10.7	13.4	8.4	153.4	3,227,551.8	1,956.2	1.6	1.2
09/18/2024 08:00	10.5	13.4	8.3	148.6	3,206,958.1	1,920.3	1.6	1.2
09/18/2024 09:00	10.8	13.4	8.5	154.6	3,227,165.5	1,932.4	1.6	1.2
09/18/2024 10:00	10.9	13.4	8.6	155.4	3,196,533.5	1,937.4	1.7	1.4
09/18/2024 11:00	10.9	13.4	8.6	155.2	3,206,432.9	1,943.4	1.6	1.2
09/18/2024 12:00	10.8	13.4	8.5	155.5	3,209,402.8	1,945.2	1.7	1.4
09/18/2024 13:00	10.8	13.4	8.5	157.8	3,187,987.4	1,955.5	1.7	1.4
09/18/2024 14:00	10.8	13.4	8.5	157.2	3,195,812.6	1,960.3	1.7	1.4
09/18/2024 15:00	10.8	13.4	8.5	156.4	3,178,042.7	1,949.4	1.7	1.4
09/18/2024 16:00	11.0	13.3	8.5	175.9	3,162,457.4	2,078.4	1.9	1.5
09/18/2024 17:00	11.1	13.2	8.5	200.1	3,125,425.9	2,191.0	2.2	1.8
09/18/2024 18:00	11.0	13.2	8.4	193.5	3,120,962.3	2,119.5	2.2	1.7
09/18/2024 19:00	11.0	13.2	8.4	197.2	3,146,583.8	2,136.9	2.2	1.7
09/18/2024 20:00	10.9	13.2	8.4	190.1	3,159,351.4	2,122.5	2.1	1.7
09/18/2024 21:00	10.9	13.3	8.5	192.9	3,160,988.7	2,123.6	2.1	1.7
09/18/2024 22:00	10.8	13.3	8.4	194.8	3,156,225.5	2,120.4	2.2	1.7
09/18/2024 23:00	10.9	13.3	8.5	189.9	3,158,756.0	2,122.1	2.1	1.7
Average/Sum#:	10.7	13.4	8.5	160.3	3,137,221.3	1,943.3	1.8	1.3
Minimum:	9.9	13.2	8.3	103.0	2,823,265.3	1,489.6	1.2	0.7
Maximum:	11.2	13.9	8.7	200.1	3,227,551.8	2,191.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/19/2024 00:00	10.8	13.3	8.4	188.4	3,161,137.6	2,123.7	2.1	1.7
09/19/2024 01:00	10.7	13.3	8.3	193.7	3,158,607.1	2,122.0	2.1	1.7
09/19/2024 02:00	10.8	13.3	8.4	193.8	3,162,923.8	2,124.9	2.1	1.7
09/19/2024 03:00	10.8	13.2	8.3	190.3	3,167,538.1	2,128.0	2.1	1.7
09/19/2024 04:00	10.7	13.3	8.3	191.6	3,165,454.2	2,126.6	2.1	1.7
09/19/2024 05:00	10.7	13.3	8.3	203.3	3,197,380.2	2,124.7	2.2	1.7
09/19/2024 06:00	10.8	13.3	8.4	172.4	3,120,133.4	2,027.8	1.9	1.4
09/19/2024 07:00	24.0	16.0	28.9	178.0	1,591,520.1	639.2	3.7	0.9
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.4	13.6	10.9	188.9	2,965,586.8	1,927.1	2.3	1.6
Minimum:	10.7	13.2	8.3	172.4	1,591,520.1	639.2	1.9	0.9
Maximum:	24.0	16.0	28.9	203.3	3,197,380.2	2,128.0	3.7	1.7
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 14:00	46.6	17.3	76.4	8.8	1,222,972.1	321.5	0.0	0.0
09/22/2024 15:00	36.8	14.9	36.2	224.4	2,122,607.8	945.5	3.5	1.2
09/22/2024 16:00	10.0	13.9	8.4	108.8	2,847,261.5	1,497.0	1.3	0.7
09/22/2024 17:00	10.3	13.9	8.7	121.9	3,070,744.0	1,614.5	1.3	0.8
09/22/2024 18:00	11.2	13.4	8.8	152.8	3,143,876.2	1,951.4	1.7	1.4
09/22/2024 19:00	11.1	13.4	8.7	167.4	3,127,860.8	1,964.3	1.8	1.4
09/22/2024 20:00	11.0	13.4	8.7	163.4	3,132,115.2	1,944.1	1.8	1.4
09/22/2024 21:00	11.0	13.4	8.7	163.7	3,125,670.9	1,940.1	1.8	1.4
09/22/2024 22:00	10.8	13.4	8.5	157.8	3,209,630.2	1,921.9	1.7	1.3
09/22/2024 23:00	10.8	13.4	8.5	155.7	3,211,300.2	1,922.9	1.7	1.3
Average/Sum#:	17.0	14.0	18.2	142.5	2,821,403.9	1,602.3	1.7	1.1
Minimum:	10.0	13.4	8.4	8.8	1,222,972.1	321.5	0.0	0.0
Maximum:	46.6	17.3	76.4	224.4	3,211,300.2	1,964.3	3.5	1.4
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/23/2024 00:00	10.8	13.4	8.5	157.4	3,205,455.1	1,919.4	1.7	1.3
09/23/2024 01:00	10.8	13.5	8.6	157.5	3,200,278.0	1,916.3	1.7	1.3
09/23/2024 02:00	10.8	13.4	8.5	157.2	3,200,946.0	1,916.7	1.7	1.3
09/23/2024 03:00	10.8	13.4	8.5	156.3	3,202,783.0	1,917.8	1.7	1.3
09/23/2024 04:00	10.8	13.4	8.5	156.5	3,169,145.0	1,920.8	1.7	1.3
09/23/2024 05:00	10.8	13.4	8.5	151.1	3,149,676.1	1,909.0	1.6	1.1
09/23/2024 06:00	10.3	13.9	8.7	123.7	3,100,985.4	1,630.4	1.3	0.8
09/23/2024 07:00	10.3	13.9	8.7	112.9	2,986,676.5	1,570.3	1.3	0.8
09/23/2024 08:00	10.4	13.9	8.8	126.6	3,133,128.9	1,647.3	1.3	0.8
09/23/2024 09:00	10.6	13.9	8.9	113.5	2,875,410.8	1,511.8	1.3	0.8
09/23/2024 10:00	10.7	13.8	8.9	114.5	2,893,289.4	1,521.2	1.3	0.8
09/23/2024 11:00	10.8	13.7	8.9	135.3	3,099,776.5	1,652.4	1.5	1.0
09/23/2024 12:00	10.9	13.7	8.9	137.6	3,137,277.2	1,695.3	1.5	1.0
09/23/2024 13:00	11.0	13.7	9.0	141.7	3,135,426.7	1,694.3	1.5	1.0
09/23/2024 14:00	11.6	13.3	9.0	186.1	3,113,599.8	2,114.5	2.1	1.7
09/23/2024 15:00	11.3	13.2	8.7	208.5	3,080,499.0	2,182.0	2.4	2.0
09/23/2024 16:00	11.3	13.2	8.7	211.5	3,077,990.9	2,202.7	2.4	2.0
09/23/2024 17:00	11.2	13.2	8.6	217.8	3,057,689.5	2,210.5	2.5	2.2
09/23/2024 18:00	11.1	13.2	8.5	220.1	3,058,657.8	2,211.2	2.5	2.2
09/23/2024 19:00	11.1	13.2	8.5	221.0	3,068,340.6	2,218.2	2.5	2.2
09/23/2024 20:00	11.2	13.2	8.6	217.7	3,073,043.6	2,221.6	2.5	2.2
09/23/2024 21:00	11.1	13.2	8.5	216.4	3,113,484.2	2,228.1	2.4	2.0
09/23/2024 22:00	11.0	13.2	8.4	213.8	3,117,346.4	2,208.1	2.4	2.0
09/23/2024 23:00	10.8	13.3	8.4	182.0	3,143,521.4	2,043.0	2.0	1.6
Average/Sum#:	10.9	13.5	8.7	168.2	3,099,767.8	1,927.6	1.9	1.4
Minimum:	10.3	13.2	8.4	112.9	2,875,410.8	1,511.8	1.3	0.8
Maximum:	11.6	13.9	9.0	221.0	3,205,455.1	2,228.1	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/24/2024 00:00	9.9	13.8	8.2	135.7	3,177,064.6	1,693.6	1.4	0.8
09/24/2024 01:00	9.9	13.9	8.3	122.2	3,190,188.2	1,677.3	1.3	0.8
09/24/2024 02:00	9.9	13.9	8.3	119.2	3,120,766.0	1,640.8	1.3	0.8
09/24/2024 03:00	10.0	13.9	8.4	123.3	3,188,856.8	1,676.6	1.3	0.8
09/24/2024 04:00	10.1	13.8	8.4	127.7	3,207,115.8	1,686.2	1.3	0.8
09/24/2024 05:00	10.2	13.9	8.6	120.2	3,187,525.5	1,675.9	1.3	0.8
09/24/2024 06:00	10.4	13.9	8.8	118.6	3,113,348.3	1,636.9	1.3	0.8
09/24/2024 07:00	10.6	13.9	8.9	116.3	3,011,782.7	1,583.5	1.3	0.8
09/24/2024 08:00	10.7	13.9	9.0	111.3	2,871,416.7	1,509.7	1.3	0.8
09/24/2024 09:00	10.6	13.8	8.8	113.7	2,911,928.8	1,531.0	1.3	0.8
09/24/2024 10:00	10.6	13.8	8.8	119.0	2,973,172.5	1,563.2	1.3	0.8
09/24/2024 11:00	10.6	13.7	8.7	129.1	3,102,965.6	1,654.1	1.4	0.8
09/24/2024 12:00	10.6	13.9	8.9	104.0	2,644,320.4	1,390.3	1.3	0.7
09/24/2024 13:00	11.3	13.4	8.9	165.2	2,976,000.8	1,847.2	1.9	1.3
09/24/2024 14:00	11.4	13.2	8.7	198.5	3,043,651.6	2,155.9	2.3	1.9
09/24/2024 15:00	11.3	13.2	8.7	202.3	3,039,979.5	2,131.1	2.3	1.9
09/24/2024 16:00	11.3	13.2	8.7	213.3	3,033,275.0	2,170.7	2.5	2.2
09/24/2024 17:00	11.3	13.1	8.5	214.4	3,041,367.1	2,198.7	2.5	2.2
09/24/2024 18:00	11.1	13.1	8.4	205.9	3,038,165.8	2,174.2	2.4	2.0
09/24/2024 19:00	11.0	13.3	8.5	189.8	3,075,167.6	2,088.4	2.2	1.7
09/24/2024 20:00	11.0	13.2	8.4	207.5	3,092,881.0	2,145.6	2.4	1.9
09/24/2024 21:00	10.9	13.3	8.5	188.4	3,077,185.9	2,067.3	2.1	1.7
09/24/2024 22:00	10.9	13.3	8.5	176.6	3,104,592.8	2,017.7	2.0	1.6
09/24/2024 23:00	11.0	13.2	8.4	198.3	3,121,996.2	2,143.0	2.2	1.7
Average/Sum#:	10.7	13.6	8.6	155.0	3,056,029.8	1,835.8	1.7	1.3
Minimum:	9.9	13.1	8.2	104.0	2,644,320.4	1,390.3	1.3	0.7
Maximum:	11.4	13.9	9.0	214.4	3,207,115.8	2,198.7	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/25/2024 00:00	10.9	13.3	8.5	202.6	3,140,546.6	2,132.8	2.3	1.9
09/25/2024 01:00	11.0	13.2	8.4	195.0	3,126,008.9	2,100.1	2.2	1.7
09/25/2024 02:00	10.8	13.3	8.4	176.7	3,137,212.8	2,038.9	2.0	1.6
09/25/2024 03:00	10.9	13.2	8.4	185.6	3,154,792.6	2,096.4	2.0	1.7
09/25/2024 04:00	10.9	13.2	8.4	192.5	3,139,554.3	2,109.2	2.1	1.7
09/25/2024 05:00	10.9	13.2	8.4	204.4	3,135,833.0	2,106.7	2.3	1.9
09/25/2024 06:00	11.2	13.3	8.7	172.7	3,144,385.1	2,020.6	1.9	1.4
09/25/2024 07:00	22.2	15.9	26.2	163.6	1,669,964.1	682.9	3.2	0.8
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 14:00	28.2	17.7	52.0	78.6	1,198,246.3	245.0	0.0	0.0
09/25/2024 15:00	39.1	15.6	43.5	233.7	2,003,924.3	790.2	3.6	1.1
09/25/2024 16:00	9.9	13.9	8.3	98.4	2,705,944.5	1,422.7	1.2	0.7
09/25/2024 17:00	10.3	13.8	8.6	131.7	3,058,506.2	1,630.4	1.5	1.0
09/25/2024 18:00	10.7	13.7	8.8	140.2	3,056,222.1	1,651.5	1.6	1.0
09/25/2024 19:00	10.6	13.7	8.7	120.1	2,960,583.0	1,578.2	1.4	0.8
09/25/2024 20:00	10.3	13.8	8.6	105.1	2,845,739.9	1,496.2	1.2	0.7
09/25/2024 21:00	10.2	13.8	8.5	125.8	3,077,971.5	1,618.3	1.4	0.8
09/25/2024 22:00	10.3	13.9	8.7	97.2	2,664,861.8	1,401.1	1.2	0.7
09/25/2024 23:00	9.9	13.9	8.3	120.6	3,165,842.9	1,664.5	1.3	0.8
Average/Sum#:	13.8	14.0	13.9	152.5	2,799,230.0	1,599.2	1.8	1.1
Minimum:	9.9	13.2	8.3	78.6	1,198,246.3	245.0	0.0	0.0
Maximum:	39.1	17.7	52.0	233.7	3,165,842.9	2,132.8	3.6	1.9
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/26/2024 00:00	9.8	13.9	8.3	118.8	3,205,213.8	1,685.2	1.2	0.8
09/26/2024 01:00	9.8	13.9	8.3	113.6	3,149,676.1	1,656.0	1.2	0.8
09/26/2024 02:00	9.8	13.9	8.3	111.4	3,097,561.9	1,628.6	1.2	0.8
09/26/2024 03:00	9.8	13.9	8.3	115.5	3,166,223.3	1,664.7	1.2	0.8
09/26/2024 04:00	9.6	13.9	8.1	115.8	3,209,778.6	1,687.6	1.2	0.8
09/26/2024 05:00	9.6	13.9	8.1	113.7	3,208,257.0	1,686.8	1.2	0.8
09/26/2024 06:00	10.1	13.9	8.5	110.8	3,100,605.0	1,630.2	1.2	0.8
09/26/2024 07:00	10.2	13.9	8.6	95.3	2,635,000.8	1,385.4	1.2	0.7
09/26/2024 08:00	24.4	16.2	30.6	166.4	1,463,992.2	566.6	3.7	0.8
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 14:00	41.4	17.5	71.8	183.9	1,308,837.7	315.4	0.0	0.0
09/26/2024 15:00	38.9	15.3	41.0	232.8	2,180,748.3	907.7	3.4	1.2
09/26/2024 16:00	10.4	13.6	8.4	141.2	3,140,978.4	1,697.3	1.5	1.0
09/26/2024 17:00	10.9	13.5	8.7	154.0	3,054,509.8	1,762.1	1.7	1.2
09/26/2024 18:00	11.6	13.3	9.0	208.6	3,115,142.8	2,092.8	2.3	1.9
09/26/2024 19:00	11.6	13.3	9.0	192.1	3,118,976.9	2,072.6	2.1	1.7
09/26/2024 20:00	11.4	13.3	8.9	191.0	3,136,759.9	2,015.7	2.1	1.6
09/26/2024 21:00	11.8	13.1	8.9	226.7	3,113,344.4	2,228.0	2.6	2.2
09/26/2024 22:00	11.5	13.2	8.8	206.1	3,125,201.3	2,145.2	2.3	1.9
09/26/2024 23:00	11.1	13.4	8.7	184.0	3,171,650.6	1,991.8	2.0	1.6
Average/Sum#:	14.4	14.0	14.8	156.9	2,879,076.8	1,622.1	1.8	1.1
Minimum:	9.6	13.1	8.1	95.3	1,308,837.7	315.4	0.0	0.0
Maximum:	41.4	17.5	71.8	232.8	3,209,778.6	2,228.0	3.7	2.2
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/27/2024 00:00	11.0	13.4	8.7	165.1	3,183,243.7	1,906.1	1.8	1.3
09/27/2024 01:00	23.0	16.0	27.7	183.4	1,644,042.9	672.3	3.6	0.9
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 09:00	41.1	17.5	71.3	20.1	1,282,425.7	318.4	0.0	0.0
09/27/2024 10:00	40.1	15.5	43.8	226.7	2,076,794.3	834.1	3.5	1.1
09/27/2024 11:00	10.2	14.0	8.7	93.2	2,610,585.8	1,353.5	1.2	0.7
09/27/2024 12:00	10.4	14.0	8.9	95.4	2,583,583.0	1,339.5	1.2	0.7
09/27/2024 13:00	10.7	13.8	8.9	136.3	3,003,729.2	1,601.2	1.5	1.0
09/27/2024 14:00	10.5	13.9	8.9	110.4	2,730,670.3	1,435.7	1.3	0.7
09/27/2024 15:00	10.5	14.0	9.0	105.3	2,784,560.5	1,443.7	1.2	0.7
09/27/2024 16:00	10.9	13.8	9.1	127.5	2,905,081.7	1,527.4	1.5	0.9
09/27/2024 17:00	11.9	13.2	9.1	186.3	3,080,622.1	2,114.6	2.1	1.7
09/27/2024 18:00	11.8	13.1	8.9	220.4	3,066,680.7	2,217.0	2.5	2.2
09/27/2024 19:00	11.6	13.1	8.8	221.9	3,067,372.3	2,217.5	2.5	2.2
09/27/2024 20:00	11.4	13.1	8.6	219.8	3,079,545.0	2,226.3	2.5	2.2
09/27/2024 21:00	11.1	13.2	8.5	214.5	3,124,828.8	2,213.4	2.4	2.0
09/27/2024 22:00	11.0	13.2	8.4	197.7	3,139,810.3	2,132.3	2.2	1.7
09/27/2024 23:00	10.9	13.2	8.4	197.2	3,140,104.8	2,132.5	2.2	1.7
Average/Sum#:	15.2	14.0	15.6	160.1	2,735,510.7	1,628.6	2.0	1.3
Minimum:	10.2	13.1	8.4	20.1	1,282,425.7	318.4	0.0	0.0
Maximum:	41.1	17.5	71.3	226.7	3,183,243.7	2,226.3	3.6	2.2
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/28/2024 00:00	10.9	13.2	8.4	202.0	3,141,282.8	2,133.3	2.3	1.9
09/28/2024 01:00	10.9	13.2	8.4	197.7	3,139,810.3	2,132.3	2.2	1.7
09/28/2024 02:00	11.1	13.2	8.5	195.1	3,135,540.1	2,129.4	2.2	1.7
09/28/2024 03:00	11.0	13.2	8.4	196.7	3,132,153.3	2,127.1	2.2	1.7
09/28/2024 04:00	11.0	13.2	8.4	199.4	3,165,603.1	2,126.7	2.2	1.7
09/28/2024 05:00	10.9	13.3	8.5	196.5	3,165,305.4	2,126.5	2.2	1.7
09/28/2024 06:00	11.3	13.3	8.8	176.7	3,131,624.6	2,012.4	1.9	1.4
09/28/2024 07:00	23.5	16.1	28.9	170.1	1,566,870.5	629.3	3.6	0.9
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 15:00	39.5	16.2	49.6	161.4	1,905,539.5	654.0	0.0	0.0
09/28/2024 16:00	10.5	13.8	8.7	107.5	2,788,300.2	1,466.0	1.3	0.7
09/28/2024 17:00	10.5	13.8	8.7	112.8	2,836,990.8	1,491.6	1.3	0.7
09/28/2024 18:00	10.3	13.8	8.6	126.9	3,106,529.8	1,656.0	1.4	0.8
09/28/2024 19:00	10.6	13.7	8.7	139.2	3,127,099.1	1,689.8	1.5	1.0
09/28/2024 20:00	10.6	13.7	8.7	135.3	3,170,874.0	1,690.3	1.4	0.8
09/28/2024 21:00	10.3	13.8	8.6	131.9	3,170,123.7	1,689.9	1.4	0.8
09/28/2024 22:00	10.2	13.8	8.5	108.6	2,964,043.0	1,558.4	1.2	0.8
09/28/2024 23:00	10.2	13.8	8.5	130.5	3,177,252.2	1,693.7	1.4	0.8
Average/Sum#:	13.1	13.8	12.2	158.1	2,930,879.0	1,706.3	1.7	1.1
Minimum:	10.2	13.2	8.4	107.5	1,566,870.5	629.3	0.0	0.0
Maximum:	39.5	16.2	49.6	202.0	3,177,252.2	2,133.3	3.6	1.9
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/29/2024 00:00	10.0	13.9	8.4	98.5	2,830,904.5	1,488.4	1.1	0.6
09/29/2024 01:00	9.9	13.9	8.3	102.3	2,842,506.6	1,494.5	1.2	0.7
09/29/2024 02:00	22.3	16.1	27.4	162.4	1,569,005.3	618.7	3.4	0.8
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 10:00	37.1	17.6	66.3	0.1	1,315,503.3	307.4	0.0	0.0
09/29/2024 11:00	39.8	15.5	43.5	203.8	2,071,814.6	832.1	3.1	1.0
09/29/2024 12:00	10.1	13.9	8.5	92.8	2,672,306.3	1,385.5	1.1	0.6
09/29/2024 13:00	10.3	14.0	8.8	94.3	2,605,956.7	1,351.1	1.2	0.7
09/29/2024 14:00	10.5	13.8	8.7	132.2	3,013,108.8	1,606.2	1.5	1.0
09/29/2024 15:00	10.2	14.0	8.7	104.0	2,628,716.2	1,362.9	1.3	0.7
09/29/2024 16:00	10.4	13.8	8.6	123.4	3,002,082.6	1,578.4	1.4	0.8
09/29/2024 17:00	10.9	13.6	8.8	139.8	3,133,060.4	1,715.9	1.5	1.0
09/29/2024 18:00	11.2	13.4	8.8	158.7	3,147,944.6	1,999.9	1.7	1.4
09/29/2024 19:00	11.4	13.2	8.7	202.7	3,132,522.2	2,173.1	2.3	2.0
09/29/2024 20:00	11.3	13.2	8.7	199.1	3,157,251.6	2,167.2	2.2	1.7
09/29/2024 21:00	11.0	13.3	8.5	184.9	3,181,781.5	2,091.1	2.0	1.7
09/29/2024 22:00	10.9	13.4	8.6	163.4	3,224,746.9	1,954.5	1.7	1.4
09/29/2024 23:00	11.1	13.3	8.6	197.8	3,191,056.5	2,143.8	2.2	1.7
Average/Sum#:	14.6	14.1	15.2	138.8	2,748,251.1	1,545.3	1.7	1.0
Minimum:	9.9	13.2	8.3	0.1	1,315,503.3	307.4	0.0	0.0
Maximum:	39.8	17.6	66.3	203.8	3,224,746.9	2,173.1	3.4	2.0
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/30/2024 00:00	11.0	13.3	8.5	181.4	3,208,343.5	2,061.7	2.0	1.6
09/30/2024 01:00	10.8	13.4	8.5	159.4	3,206,432.9	1,943.4	1.7	1.4
09/30/2024 02:00	10.9	13.4	8.6	159.7	3,211,382.7	1,946.4	1.7	1.4
09/30/2024 03:00	11.0	13.4	8.7	165.1	3,254,991.3	1,996.6	1.7	1.4
09/30/2024 04:00	11.0	13.4	8.7	177.4	3,230,907.8	2,076.2	1.9	1.5
09/30/2024 05:00	11.1	13.4	8.7	202.9	3,222,812.4	2,141.6	2.2	1.7
09/30/2024 06:00	11.5	13.3	8.9	196.1	3,285,264.1	2,183.1	2.1	1.7
09/30/2024 07:00	10.9	13.5	8.7	153.6	3,209,588.4	1,875.0	1.6	1.1
09/30/2024 08:00	10.2	14.1	8.9	88.7	2,587,429.6	1,322.6	1.1	0.5
09/30/2024 09:00	10.0	14.1	8.7	87.1	2,577,452.3	1,317.5	1.1	0.5
09/30/2024 10:00	9.9	14.1	8.6	87.4	2,579,604.3	1,318.6	1.1	0.5
09/30/2024 11:00	9.9	14.0	8.5	95.8	2,806,146.2	1,434.4	1.1	0.6
09/30/2024 12:00	9.9	14.0	8.5	107.9	3,078,466.0	1,573.6	1.2	0.8
09/30/2024 13:00	10.5	13.8	8.7	135.9	3,201,600.1	1,683.3	1.4	0.8
09/30/2024 14:00	11.1	13.3	8.6	174.0	3,226,725.0	2,144.2	1.9	1.5
09/30/2024 15:00	10.9	13.3	8.5	186.7	3,227,778.4	2,144.9	2.0	1.7
09/30/2024 16:00	11.0	13.2	8.4	216.8	3,186,007.8	2,280.0	2.4	2.1
09/30/2024 17:00	10.9	13.2	8.4	211.3	3,204,732.5	2,293.4	2.3	2.1
09/30/2024 18:00	10.8	13.2	8.3	213.1	3,213,955.2	2,300.0	2.3	2.1
09/30/2024 19:00	10.8	13.2	8.3	219.5	3,217,169.1	2,302.3	2.4	2.1
09/30/2024 20:00	10.8	13.3	8.4	208.1	3,230,544.2	2,241.1	2.3	2.0
09/30/2024 21:00	10.9	13.2	8.4	215.1	3,253,582.9	2,304.6	2.3	2.1
09/30/2024 22:00	10.7	13.3	8.3	192.1	3,290,042.1	2,210.3	2.0	1.8
09/30/2024 23:00	10.6	13.3	8.2	182.8	3,309,649.7	2,126.8	1.9	1.5
Average/Sum#:	10.7	13.5	8.5	167.4	3,125,858.7	1,967.6	1.8	1.4
Minimum:	9.9	13.2	8.2	87.1	2,577,452.3	1,317.5	1.1	0.5
Maximum:	11.5	14.1	8.9	219.5	3,309,649.7	2,304.6	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/01/2024 00:00	19.6	15.6	21.8	130.0	1,810,085.6	740.2	2.1	0.6
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2024 13:00	38.1	17.4	64.2	40.7	1,471,093.8	354.5	0.7	0.1
07/01/2024 14:00	32.5	15.3	34.2	224.9	2,200,371.5	899.8	3.1	1.1
07/01/2024 15:00	9.6	14.0	8.2	95.2	2,681,491.7	1,351.1	1.1	0.5
07/01/2024 16:00	10.5	13.8	8.7	147.0	3,070,249.5	1,569.4	1.5	0.9
07/01/2024 17:00	11.5	13.1	8.7	181.0	3,278,309.7	2,130.6	1.8	1.5
07/01/2024 18:00	11.4	13.0	8.5	214.3	3,244,357.8	2,203.3	2.2	1.8
07/01/2024 19:00	11.1	13.0	8.3	206.3	3,292,857.0	2,164.1	2.1	1.7
07/01/2024 20:00	11.0	13.0	8.2	205.5	3,277,032.6	2,153.7	2.1	1.7
07/01/2024 21:00	10.8	13.2	8.3	187.5	3,321,901.3	2,061.9	1.8	1.4
07/01/2024 22:00	10.8	13.2	8.3	180.0	3,294,674.0	2,045.0	1.8	1.4
07/01/2024 23:00	20.6	15.8	23.8	127.9	1,777,969.3	701.1	2.1	0.6
Average/Sum#:	16.5	14.2	17.6	161.7	2,726,699.5	1,531.2	1.9	1.1
Minimum:	9.6	13.0	8.2	40.7	1,471,093.8	354.5	0.7	0.1
Maximum:	38.1	17.4	64.2	224.9	3,321,901.3	2,203.3	3.1	1.8
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2024 15:00	26.9	18.0	54.7	0.0	1,108,663.2	194.3	-0.3	0.0
07/02/2024 16:00	46.3	15.8	53.6	167.4	1,818,595.6	664.0	2.8	0.7
07/02/2024 17:00	10.4	13.8	8.6	168.0	3,159,512.8	1,638.1	1.7	1.1
07/02/2024 18:00	11.1	13.3	8.6	168.6	3,170,217.4	1,852.0	1.7	1.3
07/02/2024 19:00	11.3	13.0	8.4	207.3	3,275,305.9	2,200.4	2.1	1.8
07/02/2024 20:00	11.1	13.0	8.3	185.1	3,301,834.3	2,170.0	1.8	1.5
07/02/2024 21:00	11.1	13.0	8.3	202.5	3,296,052.3	2,166.2	2.0	1.7
07/02/2024 22:00	10.9	13.1	8.2	192.4	3,311,488.5	2,103.8	1.9	1.5
07/02/2024 23:00	11.1	13.0	8.3	209.6	3,310,285.7	2,223.9	2.1	1.8
Average/Sum#:	16.7	14.0	18.6	166.8	2,861,328.4	1,690.3	1.8	1.3
Minimum:	10.4	13.0	8.2	0.0	1,108,663.2	194.3	-0.3	0.0
Maximum:	46.3	18.0	54.7	209.6	3,311,488.5	2,223.9	2.8	1.8
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/03/2024 00:00	11.0	13.0	8.2	201.9	3,346,721.0	2,199.5	2.0	1.8
07/03/2024 01:00	10.8	13.1	8.2	187.6	3,334,548.4	2,094.1	1.8	1.5
07/03/2024 02:00	10.8	13.2	8.3	181.2	3,368,131.9	2,066.0	1.7	1.4
07/03/2024 03:00	10.7	13.2	8.2	172.7	3,380,993.3	2,049.2	1.6	1.2
07/03/2024 04:00	10.7	13.2	8.2	179.0	3,351,014.1	2,055.5	1.7	1.4
07/03/2024 05:00	10.8	13.2	8.3	180.3	3,352,807.4	2,056.6	1.7	1.4
07/03/2024 06:00	10.8	13.2	8.3	192.5	3,362,262.9	2,062.4	1.9	1.4
07/03/2024 07:00	11.2	13.2	8.6	182.4	3,333,340.1	2,069.0	1.8	1.4
07/03/2024 08:00	11.0	13.1	8.3	176.9	3,343,167.7	2,075.1	1.7	1.5
07/03/2024 09:00	10.9	13.1	8.2	181.0	3,356,056.4	2,083.1	1.7	1.5
07/03/2024 10:00	10.9	13.1	8.2	186.9	3,323,879.6	2,087.4	1.8	1.5
07/03/2024 11:00	10.9	13.1	8.2	185.1	3,338,012.2	2,071.9	1.8	1.5
07/03/2024 12:00	11.1	13.1	8.4	184.4	3,314,007.0	2,081.2	1.8	1.5
07/03/2024 13:00	11.2	13.1	8.5	193.2	3,275,442.8	2,080.9	1.9	1.5
07/03/2024 14:00	11.3	13.1	8.5	198.0	3,268,674.3	2,076.6	2.0	1.7
07/03/2024 15:00	11.2	13.1	8.5	192.7	3,240,556.1	2,082.4	1.9	1.5
07/03/2024 16:00	11.2	13.1	8.5	189.8	3,272,118.7	2,031.0	1.9	1.4
07/03/2024 17:00	11.4	13.1	8.6	191.2	3,227,383.0	2,026.8	1.9	1.4
07/03/2024 18:00	11.5	13.1	8.7	187.2	3,246,491.2	2,038.8	1.9	1.4
07/03/2024 19:00	11.4	13.1	8.6	188.8	3,237,980.3	2,057.1	1.9	1.4
07/03/2024 20:00	11.2	13.1	8.5	191.0	3,271,809.6	2,054.7	1.9	1.4
07/03/2024 21:00	11.0	13.1	8.3	188.9	3,306,596.0	2,052.4	1.9	1.4
07/03/2024 22:00	10.9	13.2	8.4	179.7	3,303,373.8	2,050.4	1.8	1.4
07/03/2024 23:00	10.9	13.2	8.4	180.7	3,324,766.8	2,039.4	1.8	1.4
Average/Sum#:	11.0	13.1	8.4	186.4	3,311,672.3	2,068.4	1.8	1.5
Minimum:	10.7	13.0	8.2	172.7	3,227,383.0	2,026.8	1.6	1.2
Maximum:	11.5	13.2	8.7	201.9	3,380,993.3	2,199.5	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/04/2024 00:00	10.9	13.2	8.4	189.4	3,346,739.6	2,004.0	1.8	1.4
07/04/2024 01:00	10.7	13.2	8.2	171.6	3,302,650.8	1,977.6	1.7	1.4
07/04/2024 02:00	20.8	15.8	24.1	150.2	1,690,224.7	666.5	2.7	0.7
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2024 13:00	32.7	17.4	55.1	17.1	1,411,363.0	329.8	0.2	0.0
07/04/2024 14:00	31.0	15.5	33.9	216.1	2,171,552.0	856.3	3.0	1.0
07/04/2024 15:00	10.7	13.8	8.9	142.2	2,995,909.3	1,531.4	1.5	0.9
07/04/2024 16:00	11.1	13.6	9.0	169.3	3,242,302.4	1,704.7	1.7	1.2
07/04/2024 17:00	11.7	13.3	9.1	171.1	3,116,467.5	1,820.6	1.8	1.3
07/04/2024 18:00	11.5	13.0	8.6	225.6	3,224,919.2	2,143.0	2.3	1.9
07/04/2024 19:00	11.2	13.0	8.4	193.1	3,256,768.1	2,116.6	1.9	1.5
07/04/2024 20:00	11.3	13.1	8.5	189.6	3,264,325.6	2,050.0	1.9	1.4
07/04/2024 21:00	11.2	13.1	8.5	192.0	3,251,268.3	2,041.8	1.9	1.4
07/04/2024 22:00	11.1	13.2	8.5	182.1	3,307,649.0	2,028.9	1.8	1.4
07/04/2024 23:00	11.1	13.2	8.5	183.4	3,255,317.4	1,996.8	1.8	1.4
Average/Sum#:	14.8	13.9	14.8	170.9	2,916,961.2	1,662.0	1.9	1.2
Minimum:	10.7	13.0	8.2	17.1	1,411,363.0	329.8	0.2	0.0
Maximum:	32.7	17.4	55.1	225.6	3,346,739.6	2,143.0	3.0	1.9
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/05/2024 00:00	10.4	13.7	8.5	163.6	3,335,994.9	1,729.6	1.6	1.0
07/05/2024 01:00	10.8	13.7	8.9	172.1	3,323,072.2	1,722.9	1.7	1.2
07/05/2024 02:00	10.7	13.7	8.8	164.9	3,305,713.3	1,713.9	1.6	1.0
07/05/2024 03:00	10.8	13.7	8.9	170.1	3,362,419.1	1,743.3	1.6	1.0
07/05/2024 04:00	10.4	13.8	8.6	136.7	3,136,367.6	1,626.1	1.4	0.8
07/05/2024 05:00	10.4	13.8	8.6	145.7	3,200,402.6	1,659.3	1.4	0.8
07/05/2024 06:00	10.7	13.6	8.6	197.7	3,345,960.2	1,759.2	1.9	1.2
07/05/2024 07:00	11.1	13.6	9.0	168.8	3,338,732.7	1,755.4	1.6	1.1
07/05/2024 08:00	11.0	13.6	8.9	162.1	3,350,525.0	1,761.6	1.5	1.1
07/05/2024 09:00	11.2	13.5	8.9	174.0	3,298,812.0	1,758.5	1.7	1.2
07/05/2024 10:00	11.4	13.5	9.1	179.4	3,274,800.2	1,745.7	1.8	1.2
07/05/2024 11:00	11.1	13.6	9.0	168.7	3,258,479.7	1,737.0	1.7	1.2
07/05/2024 12:00	10.7	13.7	8.8	135.0	3,007,911.7	1,559.5	1.4	0.8
07/05/2024 13:00	11.8	13.2	9.0	184.1	3,118,112.5	1,867.1	1.9	1.3
07/05/2024 14:00	12.2	12.9	9.0	210.1	3,135,253.4	2,152.1	2.2	1.7
07/05/2024 15:00	12.0	12.9	8.9	204.6	3,166,229.6	2,104.0	2.1	1.7
07/05/2024 16:00	11.9	12.9	8.8	207.9	3,170,744.2	2,107.0	2.1	1.7
07/05/2024 17:00	11.7	12.9	8.6	206.1	3,173,001.4	2,108.5	2.1	1.7
07/05/2024 18:00	11.6	12.9	8.6	200.8	3,183,455.2	2,092.2	2.1	1.7
07/05/2024 19:00	11.4	13.0	8.5	194.6	3,197,149.5	2,101.2	2.0	1.7
07/05/2024 20:00	11.1	13.0	8.3	193.4	3,217,993.4	2,091.4	2.0	1.7
07/05/2024 21:00	11.1	12.9	8.2	216.2	3,257,610.3	2,212.3	2.2	1.8
07/05/2024 22:00	11.4	12.9	8.4	202.6	3,220,555.1	2,140.1	2.1	1.7
07/05/2024 23:00	11.1	13.1	8.4	189.1	3,296,285.0	2,046.0	1.9	1.4
Average/Sum#:	11.2	13.3	8.7	181.2	3,236,482.5	1,887.2	1.8	1.3
Minimum:	10.4	12.9	8.2	135.0	3,007,911.7	1,559.5	1.4	0.8
Maximum:	12.2	13.8	9.1	216.2	3,362,419.1	2,212.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/06/2024 00:00	11.0	13.1	8.3	188.4	3,295,095.9	2,021.2	1.9	1.4
07/06/2024 01:00	10.7	13.2	8.2	176.2	3,311,697.1	2,007.2	1.7	1.4
07/06/2024 02:00	10.8	13.2	8.3	174.7	3,312,522.1	2,007.7	1.7	1.4
07/06/2024 03:00	10.7	13.2	8.2	179.7	3,320,111.7	2,012.3	1.8	1.4
07/06/2024 04:00	10.7	13.2	8.2	177.5	3,349,077.6	2,005.4	1.7	1.4
07/06/2024 05:00	10.9	13.1	8.2	174.8	3,241,786.2	1,988.5	1.7	1.4
07/06/2024 06:00	19.0	15.7	21.6	147.0	462,066.1	705.2	10.7	2.9
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2024 13:00	6.9	19.3	25.4	69.1	6,847.1	0.2	354.1	0.0
07/06/2024 14:00	31.8	15.5	34.7	197.1	2,164,958.5	853.7	2.7	0.9
07/06/2024 15:00	10.4	13.8	8.6	121.4	2,838,034.2	1,450.7	1.3	0.7
07/06/2024 16:00	10.7	13.8	8.9	144.8	3,011,769.3	1,561.5	1.5	0.9
07/06/2024 17:00	11.5	13.0	8.6	180.6	3,233,995.7	2,101.8	1.8	1.5
07/06/2024 18:00	11.8	12.9	8.7	225.2	3,190,608.3	2,120.2	2.3	1.9
07/06/2024 19:00	12.1	12.9	8.9	202.5	3,147,117.8	2,091.3	2.1	1.7
07/06/2024 20:00	11.9	13.0	8.9	200.2	3,186,194.1	2,094.0	2.0	1.7
07/06/2024 21:00	11.7	13.0	8.7	201.4	3,229,225.8	2,098.7	2.0	1.7
07/06/2024 22:00	11.6	13.0	8.7	207.2	3,240,058.1	2,129.4	2.1	1.7
07/06/2024 23:00	11.5	12.9	8.5	217.8	3,239,125.7	2,223.4	2.2	1.8
Average/Sum#:	12.5	13.8	11.6	177.0	2,959,895.6	1,748.5	22.6	1.3
Minimum:	6.9	12.9	8.2	69.1	6,847.1	0.2	1.3	0.0
Maximum:	31.8	19.3	34.7	225.2	3,349,077.6	2,223.4	354.1	1.9
%SI	25.00	25.00	25.00	25.00	29.17	25.00	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/07/2024 00:00	11.2	13.1	8.5	187.3	3,270,878.0	2,078.0	1.9	1.5
07/07/2024 01:00	10.9	13.1	8.2	183.2	3,303,736.3	2,026.5	1.8	1.4
07/07/2024 02:00	11.4	13.1	8.6	193.7	3,229,263.8	2,004.4	2.0	1.6
07/07/2024 03:00	20.0	16.0	24.1	136.7	1,575,354.8	609.7	2.6	0.6
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2024 11:00	4.7	19.7	23.1	0.0	0.0	3.1	0.0	0.0
07/07/2024 12:00	32.2	15.9	38.0	154.4	2,012,774.4	720.2	2.3	0.6
07/07/2024 13:00	10.5	13.8	8.7	131.3	2,901,419.0	1,483.1	1.4	0.7
07/07/2024 14:00	10.5	13.9	8.9	111.9	2,792,647.6	1,427.5	1.2	0.7
07/07/2024 15:00	11.2	13.7	9.2	163.4	3,126,145.1	1,620.8	1.7	1.1
07/07/2024 16:00	11.2	13.7	9.2	151.0	3,010,033.4	1,560.6	1.6	0.9
07/07/2024 17:00	10.5	13.8	8.7	106.0	2,717,720.5	1,389.2	1.2	0.7
07/07/2024 18:00	12.3	13.4	9.7	235.3	2,975,811.2	1,716.7	2.6	1.7
07/07/2024 19:00	12.8	12.8	9.3	212.3	3,137,999.9	2,176.9	2.2	1.7
07/07/2024 20:00	12.5	12.8	9.1	213.3	3,142,246.2	2,156.9	2.2	1.7
07/07/2024 21:00	12.0	13.0	9.0	205.5	3,182,666.8	2,045.2	2.1	1.6
07/07/2024 22:00	12.0	13.0	9.0	204.2	3,220,217.4	2,022.3	2.1	1.6
07/07/2024 23:00	11.8	13.0	8.8	200.2	3,221,070.8	2,093.4	2.0	1.7
Average/Sum#:	12.8	14.0	12.4	164.1	2,754,116.8	1,596.1	1.8	1.2
Minimum:	4.7	12.8	8.2	0.0	0.0	3.1	0.0	0.0
Maximum:	32.2	19.7	38.0	235.3	3,303,736.3	2,176.9	2.6	1.7
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/08/2024 00:00	10.8	13.6	8.7	178.6	3,282,053.8	1,725.6	1.8	1.2
07/08/2024 01:00	10.8	13.7	8.9	163.3	3,301,084.3	1,711.5	1.6	1.0
07/08/2024 02:00	10.8	13.7	8.9	167.2	3,310,149.5	1,716.2	1.6	1.0
07/08/2024 03:00	10.7	13.7	8.8	163.8	3,313,428.4	1,717.9	1.6	1.0
07/08/2024 04:00	10.8	13.6	8.7	165.5	3,313,626.6	1,742.2	1.6	1.0
07/08/2024 05:00	10.8	13.6	8.7	167.6	3,345,009.3	1,758.7	1.6	1.1
07/08/2024 06:00	10.8	13.6	8.7	163.8	3,311,534.4	1,741.1	1.6	1.0
07/08/2024 07:00	11.2	13.6	9.1	162.0	3,287,379.3	1,728.4	1.6	1.0
07/08/2024 08:00	11.1	13.6	9.0	167.3	3,257,898.6	1,712.9	1.6	1.0
07/08/2024 09:00	11.4	13.6	9.2	175.6	3,194,323.1	1,702.8	1.8	1.2
07/08/2024 10:00	11.7	13.5	9.3	188.5	3,220,210.8	1,716.6	1.9	1.2
07/08/2024 11:00	11.9	13.5	9.5	190.0	3,165,961.1	1,710.8	1.9	1.2
07/08/2024 12:00	12.0	13.5	9.6	189.3	3,138,017.5	1,695.7	1.9	1.2
07/08/2024 13:00	11.3	13.7	9.3	153.4	3,064,810.3	1,589.0	1.6	1.0
07/08/2024 14:00	11.5	13.6	9.3	173.1	3,108,783.5	1,634.5	1.8	1.1
07/08/2024 15:00	11.7	13.6	9.5	176.6	3,137,670.2	1,672.6	1.8	1.2
07/08/2024 16:00	11.4	13.6	9.2	168.8	2,978,779.4	1,587.9	1.8	1.1
07/08/2024 17:00	12.3	12.9	9.1	188.4	3,167,734.4	2,105.0	1.9	1.5
07/08/2024 18:00	12.0	12.8	8.7	218.3	3,135,405.2	2,175.1	2.3	2.0
07/08/2024 19:00	11.9	12.8	8.7	217.4	3,151,261.7	2,186.1	2.3	2.0
07/08/2024 20:00	11.7	12.9	8.6	212.1	3,188,282.2	2,188.5	2.2	1.8
07/08/2024 21:00	11.5	12.9	8.5	211.7	3,197,754.8	2,148.3	2.2	1.7
07/08/2024 22:00	11.2	12.9	8.3	204.9	3,237,471.4	2,127.7	2.1	1.7
07/08/2024 23:00	11.2	12.9	8.3	212.7	3,250,689.5	2,207.6	2.2	1.8
Average/Sum#:	11.4	13.4	8.9	182.5	3,210,805.0	1,833.4	1.8	1.3
Minimum:	10.7	12.8	8.3	153.4	2,978,779.4	1,587.9	1.6	1.0
Maximum:	12.3	13.7	9.6	218.3	3,345,009.3	2,207.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/09/2024 00:00	11.1	12.9	8.2	210.4	3,255,107.0	2,210.6	2.1	1.8
07/09/2024 01:00	11.1	12.9	8.2	211.6	3,254,913.4	2,186.7	2.1	1.7
07/09/2024 02:00	11.0	13.0	8.2	209.6	3,262,540.7	2,168.0	2.1	1.7
07/09/2024 03:00	10.9	13.0	8.1	205.7	3,297,269.6	2,167.0	2.0	1.7
07/09/2024 04:00	11.0	12.9	8.1	218.6	3,297,662.3	2,239.5	2.2	1.8
07/09/2024 05:00	11.0	12.9	8.1	207.8	3,283,046.1	2,205.6	2.1	1.8
07/09/2024 06:00	10.9	13.1	8.2	183.8	3,282,542.9	2,013.5	1.8	1.4
07/09/2024 07:00	0.0	0.0	0.0	181.2	3,279,193.9	1,987.5	2.0	1.6
07/09/2024 08:00	12.2	13.0	9.1	151.8	1,379,973.5	2,106.1	3.7	2.9
07/09/2024 09:00	11.6	13.0	8.7	133.0	1,364,575.7	2,082.6	3.2	2.5
07/09/2024 10:00	11.6	13.0	8.7	134.0	1,370,538.3	2,091.7	3.3	2.7
07/09/2024 11:00	11.8	12.9	8.7	143.0	1,434,685.0	2,189.6	3.3	2.8
07/09/2024 12:00	11.8	12.9	8.7	185.4	3,212,257.3	2,181.5	1.9	1.5
07/09/2024 13:00	11.8	12.9	8.7	214.7	3,191,800.8	2,144.3	2.2	1.7
07/09/2024 14:00	11.7	12.9	8.6	216.4	3,196,778.3	2,124.3	2.2	1.7
07/09/2024 15:00	11.5	12.9	8.5	208.3	3,200,991.9	2,127.1	2.1	1.7
07/09/2024 16:00	11.8	12.9	8.7	210.9	3,154,682.6	2,142.4	2.2	1.7
07/09/2024 17:00	11.9	12.9	8.8	221.0	3,181,776.6	2,160.8	2.3	1.9
07/09/2024 18:00	11.7	12.9	8.6	205.3	3,193,193.3	2,098.6	2.1	1.7
07/09/2024 19:00	11.8	12.8	8.6	210.6	3,184,785.8	2,186.1	2.2	1.7
07/09/2024 20:00	11.8	12.9	8.7	221.2	3,174,442.3	2,179.0	2.3	2.0
07/09/2024 21:00	11.8	12.9	8.7	216.5	3,206,834.7	2,154.4	2.2	1.7
07/09/2024 22:00	11.8	12.9	8.7	208.0	3,229,559.2	2,122.5	2.1	1.7
07/09/2024 23:00	11.5	13.0	8.6	201.2	3,231,369.3	2,052.9	2.0	1.6
Average/Sum#:	11.5	12.9	8.5	196.3	3,228,537.4	2,138.4	2.1	1.7
Minimum:	10.9	12.8	8.1	133.0	3,154,682.6	1,987.5	1.8	1.4
Maximum:	12.2	13.1	9.1	221.2	3,297,662.3	2,239.5	2.3	2.0
%SI	4.17	4.17	4.17	0.00	16.67	0.00	20.83	20.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/10/2024 00:00	11.4	13.1	8.6	199.7	3,285,974.1	2,039.6	2.0	1.6
07/10/2024 01:00	11.5	12.9	8.5	213.4	3,246,419.3	2,204.7	2.2	1.8
07/10/2024 02:00	11.3	12.9	8.3	214.7	3,251,278.5	2,208.0	2.2	1.8
07/10/2024 03:00	11.4	12.9	8.4	215.6	3,268,458.8	2,195.8	2.2	1.8
07/10/2024 04:00	11.3	12.9	8.3	214.9	3,281,050.5	2,180.3	2.2	1.7
07/10/2024 05:00	11.2	13.0	8.4	212.1	3,256,795.5	2,140.4	2.1	1.7
07/10/2024 06:00	11.2	13.1	8.5	225.3	3,256,007.9	2,021.0	2.3	1.8
07/10/2024 07:00	11.9	13.1	9.0	186.7	3,231,026.4	1,981.9	1.9	1.4
07/10/2024 08:00	11.8	13.1	8.9	201.4	3,237,547.5	1,985.9	2.0	1.6
07/10/2024 09:00	11.8	13.1	8.9	190.2	3,216,697.3	1,996.6	1.9	1.4
07/10/2024 10:00	12.0	13.0	9.0	201.0	3,202,701.5	2,011.3	2.0	1.6
07/10/2024 11:00	12.0	13.0	9.0	207.8	3,167,105.1	2,035.2	2.1	1.6
07/10/2024 12:00	12.0	13.0	9.0	201.8	3,159,062.0	2,053.1	2.1	1.6
07/10/2024 13:00	12.0	12.9	8.9	214.2	3,178,095.3	2,158.3	2.2	1.7
07/10/2024 14:00	11.6	12.9	8.6	217.7	3,157,251.6	2,167.2	2.3	2.0
07/10/2024 15:00	11.7	12.9	8.6	209.1	3,176,011.2	2,110.5	2.2	1.7
07/10/2024 16:00	11.8	12.9	8.7	198.4	3,156,827.5	2,074.7	2.0	1.7
07/10/2024 17:00	11.7	13.0	8.7	202.1	3,177,218.4	2,064.9	2.1	1.7
07/10/2024 18:00	12.1	12.9	8.9	217.4	3,130,975.3	2,126.3	2.3	1.9
07/10/2024 19:00	12.2	12.8	8.9	218.7	3,139,873.9	2,178.2	2.3	2.0
07/10/2024 20:00	12.2	12.8	8.9	216.3	3,152,559.1	2,187.0	2.2	1.7
07/10/2024 21:00	12.2	12.8	8.9	226.5	3,165,244.3	2,195.8	2.4	2.0
07/10/2024 22:00	12.0	12.8	8.7	217.0	3,172,740.1	2,201.0	2.2	1.8
07/10/2024 23:00	11.8	12.8	8.6	219.5	3,174,758.2	2,202.4	2.3	2.0
Average/Sum#:	11.8	12.9	8.7	210.1	3,201,736.6	2,113.3	2.2	1.7
Minimum:	11.2	12.8	8.3	186.7	3,130,975.3	1,981.9	1.9	1.4
Maximum:	12.2	13.1	9.0	226.5	3,285,974.1	2,208.0	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/11/2024 00:00	11.4	13.0	8.5	211.7	3,200,192.6	2,103.2	2.2	1.7
07/11/2024 01:00	11.5	13.0	8.6	201.8	3,207,838.2	2,084.8	2.1	1.7
07/11/2024 02:00	11.4	13.0	8.5	197.4	3,211,300.2	2,063.6	2.0	1.7
07/11/2024 03:00	11.2	13.1	8.5	194.0	3,237,414.8	2,033.1	2.0	1.6
07/11/2024 04:00	11.3	12.9	8.3	221.8	3,210,280.4	2,203.6	2.3	2.0
07/11/2024 05:00	10.9	13.1	8.2	183.8	3,216,375.1	1,996.4	1.9	1.4
07/11/2024 06:00	10.7	13.6	8.6	163.0	3,274,826.3	1,721.8	1.6	1.0
07/11/2024 07:00	11.3	13.6	9.1	170.4	3,259,800.6	1,713.9	1.7	1.2
07/11/2024 08:00	11.0	13.7	9.0	141.1	2,946,544.8	1,549.2	1.5	0.9
07/11/2024 09:00	10.8	13.8	9.0	143.4	2,945,240.6	1,505.5	1.5	0.9
07/11/2024 10:00	11.2	13.7	9.2	160.0	3,149,097.5	1,632.7	1.6	1.0
07/11/2024 11:00	10.7	13.8	8.9	128.7	2,871,878.6	1,468.0	1.4	0.7
07/11/2024 12:00	11.2	13.7	9.2	152.9	3,062,881.6	1,588.0	1.6	1.0
07/11/2024 13:00	11.2	13.7	9.2	151.3	3,052,466.2	1,582.6	1.6	0.9
07/11/2024 14:00	11.0	13.8	9.1	150.6	3,003,668.4	1,557.3	1.6	0.9
07/11/2024 15:00	10.5	13.9	8.9	101.0	2,642,592.1	1,331.5	1.2	0.7
07/11/2024 16:00	10.3	13.9	8.7	101.7	2,646,363.0	1,333.4	1.2	0.7
07/11/2024 17:00	11.8	13.4	9.3	191.6	2,985,345.2	1,744.0	2.1	1.4
07/11/2024 18:00	12.0	12.9	8.9	212.5	3,132,260.6	2,104.3	2.2	1.7
07/11/2024 19:00	12.1	12.9	8.9	213.2	3,123,318.3	2,121.1	2.2	1.7
07/11/2024 20:00	11.8	13.0	8.8	201.9	3,150,599.3	2,047.6	2.1	1.6
07/11/2024 21:00	11.7	13.0	8.7	205.9	3,172,185.0	2,015.3	2.1	1.6
07/11/2024 22:00	11.5	12.9	8.5	208.6	3,190,317.1	2,166.6	2.1	1.7
07/11/2024 23:00	11.2	13.0	8.4	200.5	3,205,231.1	2,059.7	2.0	1.6
Average/Sum#:	11.2	13.4	8.8	175.4	3,087,417.4	1,822.0	1.8	1.3
Minimum:	10.3	12.9	8.2	101.0	2,642,592.1	1,331.5	1.2	0.7
Maximum:	12.1	13.9	9.3	221.8	3,274,826.3	2,203.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/12/2024 00:00	11.3	13.0	8.4	202.2	3,236,248.9	2,056.0	2.0	1.6
07/12/2024 01:00	11.3	13.0	8.4	199.9	3,245,221.0	2,061.7	2.0	1.6
07/12/2024 02:00	11.2	13.1	8.5	187.8	3,239,007.1	2,034.1	1.9	1.4
07/12/2024 03:00	11.1	12.9	8.2	206.9	3,246,131.2	2,180.8	2.1	1.7
07/12/2024 04:00	10.7	13.1	8.1	193.0	3,287,248.1	2,088.4	1.9	1.5
07/12/2024 05:00	10.6	13.1	8.0	193.6	3,248,959.4	2,087.8	2.0	1.7
07/12/2024 06:00	10.1	13.6	8.2	211.5	3,297,269.6	1,733.6	2.1	1.4
07/12/2024 07:00	10.5	13.7	8.6	131.4	2,973,193.9	1,541.5	1.4	0.8
07/12/2024 08:00	10.4	13.8	8.6	125.9	2,886,355.3	1,475.4	1.4	0.7
07/12/2024 09:00	10.5	13.8	8.7	126.1	2,893,789.4	1,479.2	1.4	0.7
07/12/2024 10:00	10.5	13.8	8.7	134.8	2,941,719.2	1,503.7	1.5	0.9
07/12/2024 11:00	10.4	13.9	8.8	118.0	2,798,907.8	1,430.7	1.3	0.7
07/12/2024 12:00	10.8	13.8	9.0	133.9	2,877,160.6	1,470.7	1.5	0.9
07/12/2024 13:00	10.6	13.9	8.9	102.9	2,619,904.5	1,339.2	1.2	0.7
07/12/2024 14:00	10.8	13.8	9.0	112.3	2,645,532.3	1,352.3	1.3	0.7
07/12/2024 15:00	10.6	13.9	8.9	108.1	2,650,814.3	1,355.0	1.3	0.7
07/12/2024 16:00	10.5	13.9	8.9	105.5	2,662,438.9	1,341.5	1.2	0.7
07/12/2024 17:00	10.7	13.9	9.0	107.6	2,624,599.6	1,341.6	1.3	0.7
07/12/2024 18:00	10.8	13.9	9.1	106.4	2,605,036.4	1,331.6	1.3	0.7
07/12/2024 19:00	10.9	13.8	9.1	108.4	2,597,602.4	1,327.8	1.3	0.7
07/12/2024 20:00	11.0	13.8	9.1	107.9	2,595,841.7	1,326.9	1.3	0.7
07/12/2024 21:00	11.6	13.7	9.5	181.3	3,104,979.6	1,632.5	1.9	1.1
07/12/2024 22:00	11.2	13.5	8.9	171.0	3,251,913.9	1,733.5	1.7	1.2
07/12/2024 23:00	11.7	13.5	9.3	191.2	3,247,411.7	1,731.1	1.9	1.2
Average/Sum#:	10.8	13.6	8.7	148.7	2,949,053.6	1,623.2	1.6	1.0
Minimum:	10.1	12.9	8.0	102.9	2,595,841.7	1,326.9	1.2	0.7
Maximum:	11.7	13.9	9.5	211.5	3,297,269.6	2,180.8	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/13/2024 00:00	11.6	13.5	9.2	180.7	3,247,974.5	1,731.4	1.8	1.2
07/13/2024 01:00	11.4	13.5	9.1	181.9	3,247,224.1	1,731.0	1.8	1.2
07/13/2024 02:00	11.5	13.5	9.2	184.8	3,268,609.7	1,742.4	1.8	1.2
07/13/2024 03:00	11.4	13.5	9.1	182.8	3,280,615.6	1,748.8	1.8	1.2
07/13/2024 04:00	10.9	13.6	8.8	167.1	3,290,422.5	1,730.0	1.6	1.0
07/13/2024 05:00	10.8	13.6	8.7	173.3	3,288,119.3	1,752.8	1.7	1.2
07/13/2024 06:00	11.0	13.6	8.9	166.0	3,260,371.2	1,714.2	1.6	1.0
07/13/2024 07:00	11.7	13.6	9.5	183.3	3,250,788.4	1,732.9	1.8	1.2
07/13/2024 08:00	11.2	13.7	9.2	172.3	3,259,990.8	1,714.0	1.7	1.2
07/13/2024 09:00	10.7	13.7	8.8	131.8	3,008,297.5	1,559.7	1.4	0.8
07/13/2024 10:00	10.5	13.8	8.7	139.6	3,048,143.0	1,558.1	1.5	0.9
07/13/2024 11:00	10.9	13.7	8.9	158.6	3,139,646.5	1,627.8	1.6	1.0
07/13/2024 12:00	11.0	13.7	9.0	161.6	3,177,450.3	1,647.4	1.6	1.0
07/13/2024 13:00	10.7	13.8	8.9	110.5	2,694,049.0	1,377.1	1.3	0.7
07/13/2024 14:00	10.9	13.8	9.1	106.1	2,586,451.4	1,322.1	1.3	0.7
07/13/2024 15:00	10.7	13.8	8.9	106.0	2,595,841.7	1,326.9	1.3	0.7
07/13/2024 16:00	10.7	13.9	9.0	102.3	2,587,625.2	1,322.7	1.2	0.7
07/13/2024 17:00	10.7	13.8	8.9	103.8	2,608,753.5	1,333.5	1.2	0.7
07/13/2024 18:00	10.6	13.9	8.9	104.1	2,598,580.6	1,328.3	1.2	0.7
07/13/2024 19:00	11.0	13.8	9.1	130.6	2,822,171.5	1,463.2	1.5	0.9
07/13/2024 20:00	12.0	13.5	9.6	197.6	3,221,148.8	1,717.1	2.0	1.4
07/13/2024 21:00	11.6	13.6	9.4	181.1	3,216,834.2	1,714.8	1.8	1.2
07/13/2024 22:00	11.2	13.6	9.1	177.4	3,283,955.8	1,726.6	1.7	1.2
07/13/2024 23:00	10.7	13.6	8.6	167.8	3,298,601.0	1,734.3	1.6	1.0
Average/Sum#:	11.1	13.7	9.0	153.0	3,053,402.8	1,598.2	1.6	1.0
Minimum:	10.5	13.5	8.6	102.3	2,586,451.4	1,322.1	1.2	0.7
Maximum:	12.0	13.9	9.6	197.6	3,298,601.0	1,752.8	2.0	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/14/2024 00:00	10.6	13.7	8.7	164.9	3,312,675.6	1,741.7	1.6	1.0
07/14/2024 01:00	10.3	13.7	8.4	140.9	3,181,886.5	1,649.7	1.4	0.8
07/14/2024 02:00	16.0	14.9	15.7	120.5	2,313,222.8	1,047.3	1.5	0.6
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2024 14:00	31.9	17.4	53.8	9.0	1,471,275.3	343.8	0.0	0.0
07/14/2024 15:00	22.2	14.2	19.5	186.4	2,748,185.8	1,324.5	2.2	1.1
07/14/2024 16:00	11.2	13.7	9.2	182.2	3,204,072.7	1,684.6	1.8	1.2
07/14/2024 17:00	11.5	13.6	9.3	180.5	3,199,388.1	1,705.5	1.8	1.2
07/14/2024 18:00	12.2	13.0	9.1	199.0	3,207,914.2	2,131.7	2.0	1.7
07/14/2024 19:00	12.0	12.9	8.9	192.4	3,210,280.4	2,203.6	1.9	1.5
07/14/2024 20:00	11.7	12.9	8.6	219.4	3,220,503.3	2,187.1	2.2	1.7
07/14/2024 21:00	11.5	12.9	8.5	217.6	3,219,458.5	2,209.9	2.2	1.8
07/14/2024 22:00	11.2	13.0	8.4	192.4	3,222,504.6	2,070.8	1.9	1.4
07/14/2024 23:00	11.1	13.1	8.4	188.4	3,207,353.0	1,990.8	1.9	1.4
Average/Sum#:	14.1	13.8	13.6	168.7	2,978,363.1	1,714.7	1.7	1.2
Minimum:	10.3	12.9	8.4	9.0	1,471,275.3	343.8	0.0	0.0
Maximum:	31.9	17.4	53.8	219.4	3,312,675.6	2,209.9	2.2	1.8
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/15/2024 00:00	10.9	13.6	8.8	180.9	3,276,538.0	1,722.7	1.8	1.2
07/15/2024 01:00	11.1	13.6	9.0	178.0	3,302,024.5	1,736.1	1.7	1.2
07/15/2024 02:00	10.7	13.7	8.8	147.2	3,136,367.6	1,626.1	1.5	1.0
07/15/2024 03:00	10.6	13.7	8.7	163.1	3,304,556.1	1,713.3	1.6	1.0
07/15/2024 04:00	10.8	13.6	8.7	170.3	3,327,891.5	1,749.7	1.6	1.0
07/15/2024 05:00	10.5	13.7	8.6	157.4	3,309,185.1	1,715.7	1.5	1.0
07/15/2024 06:00	10.4	13.7	8.5	160.4	3,275,624.6	1,698.3	1.6	1.0
07/15/2024 07:00	10.9	13.7	8.9	155.7	3,297,805.4	1,709.8	1.5	1.0
07/15/2024 08:00	10.3	13.8	8.6	120.5	2,979,751.7	1,544.9	1.3	0.8
07/15/2024 09:00	10.1	13.8	8.4	117.0	2,866,726.0	1,486.3	1.3	0.7
07/15/2024 10:00	10.6	13.8	8.8	150.8	3,130,002.7	1,622.8	1.5	1.0
07/15/2024 11:00	11.0	13.6	8.9	163.9	3,235,265.1	1,701.0	1.6	1.0
07/15/2024 12:00	10.7	13.7	8.8	150.0	3,197,895.3	1,658.0	1.5	1.0
07/15/2024 13:00	10.9	13.7	8.9	157.3	3,205,031.7	1,661.7	1.6	1.0
07/15/2024 14:00	10.9	13.7	8.9	154.2	3,152,719.2	1,657.6	1.6	1.0
07/15/2024 15:00	10.7	13.8	8.9	142.6	3,112,701.6	1,591.1	1.4	0.8
07/15/2024 16:00	10.8	13.7	8.9	145.0	3,027,199.4	1,569.5	1.5	0.9
07/15/2024 17:00	11.4	13.4	9.0	169.1	3,063,420.1	1,722.5	1.8	1.2
07/15/2024 18:00	11.6	12.9	8.6	196.3	3,202,195.8	2,127.9	2.0	1.7
07/15/2024 19:00	11.2	12.9	8.3	207.0	3,219,178.1	2,186.2	2.1	1.7
07/15/2024 20:00	11.1	12.9	8.2	209.8	3,243,005.3	2,178.7	2.1	1.7
07/15/2024 21:00	11.0	13.0	8.2	202.2	3,260,461.0	2,119.0	2.0	1.7
07/15/2024 22:00	10.3	13.3	8.0	170.3	3,360,668.9	1,987.8	1.6	1.2
07/15/2024 23:00	11.0	13.2	8.4	180.1	3,290,459.6	1,970.3	1.8	1.4
Average/Sum#:	10.8	13.5	8.7	164.5	3,199,028.1	1,769.0	1.6	1.1
Minimum:	10.1	12.9	8.0	117.0	2,866,726.0	1,486.3	1.3	0.7
Maximum:	11.6	13.8	9.0	209.8	3,360,668.9	2,186.2	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/16/2024 00:00	10.5	13.7	8.6	171.1	3,283,955.8	1,726.6	1.7	1.2
07/16/2024 01:00	10.5	13.7	8.6	166.4	3,347,953.3	1,735.8	1.6	1.0
07/16/2024 02:00	10.5	13.7	8.6	161.5	3,362,804.8	1,743.5	1.5	1.0
07/16/2024 03:00	10.5	13.7	8.6	164.4	3,369,555.5	1,747.0	1.6	1.0
07/16/2024 04:00	10.4	13.7	8.5	156.0	3,362,997.7	1,743.6	1.5	1.0
07/16/2024 05:00	10.1	13.7	8.3	144.9	3,293,369.2	1,707.5	1.4	0.9
07/16/2024 06:00	10.1	13.7	8.3	145.3	3,258,844.3	1,689.6	1.4	0.8
07/16/2024 07:00	10.7	13.7	8.8	157.5	3,317,478.8	1,720.0	1.5	1.0
07/16/2024 08:00	10.4	13.7	8.5	128.1	3,080,819.1	1,597.3	1.3	0.8
07/16/2024 09:00	10.3	13.7	8.4	139.3	3,116,887.0	1,616.0	1.4	0.8
07/16/2024 10:00	10.4	13.7	8.5	145.8	3,193,073.3	1,655.5	1.5	1.0
07/16/2024 11:00	10.4	13.7	8.5	155.6	3,283,532.5	1,702.4	1.5	1.0
07/16/2024 12:00	10.4	13.7	8.5	147.3	3,162,020.2	1,639.4	1.5	1.0
07/16/2024 13:00	10.3	13.7	8.4	131.8	2,960,464.1	1,534.9	1.4	0.8
07/16/2024 14:00	9.9	13.9	8.3	91.5	2,628,500.9	1,324.4	1.1	0.5
07/16/2024 15:00	10.2	13.8	8.5	142.3	2,930,763.8	1,498.1	1.6	0.9
07/16/2024 16:00	11.3	13.1	8.5	171.9	3,278,497.5	2,058.9	1.7	1.4
07/16/2024 17:00	11.0	13.0	8.2	197.0	3,239,215.4	2,152.5	2.0	1.7
07/16/2024 18:00	10.8	12.9	8.0	214.7	3,280,581.3	2,227.9	2.2	1.8
07/16/2024 19:00	10.8	12.9	8.0	210.2	3,284,409.8	2,230.5	2.1	1.8
07/16/2024 20:00	10.9	12.9	8.0	213.5	3,258,938.7	2,237.0	2.2	1.8
07/16/2024 21:00	11.0	12.9	8.1	219.3	3,270,302.0	2,244.8	2.2	1.8
07/16/2024 22:00	10.7	13.0	8.0	205.9	3,294,682.9	2,165.3	2.1	1.7
07/16/2024 23:00	10.4	13.2	8.0	181.6	3,349,709.9	2,054.7	1.8	1.4
Average/Sum#:	10.5	13.5	8.4	165.1	3,217,056.6	1,823.1	1.7	1.2
Minimum:	9.9	12.9	8.0	91.5	2,628,500.9	1,324.4	1.1	0.5
Maximum:	11.3	13.9	8.8	219.3	3,369,555.5	2,244.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/17/2024 00:00	10.2	13.2	7.8	173.2	3,379,806.2	2,023.8	1.7	1.4
07/17/2024 01:00	9.7	13.6	7.8	144.9	3,190,946.4	1,701.0	1.5	1.0
07/17/2024 02:00	9.9	13.7	8.1	148.8	3,308,606.5	1,715.4	1.4	0.9
07/17/2024 03:00	9.9	13.7	8.1	145.3	3,362,033.3	1,743.1	1.4	0.9
07/17/2024 04:00	9.8	13.8	8.1	146.2	3,363,190.6	1,743.7	1.4	0.9
07/17/2024 05:00	9.8	13.8	8.1	132.2	3,203,874.4	1,661.1	1.3	0.8
07/17/2024 06:00	10.1	13.7	8.3	144.3	3,289,318.8	1,705.4	1.4	0.9
07/17/2024 07:00	10.5	13.7	8.6	149.7	3,349,496.3	1,736.6	1.4	0.9
07/17/2024 08:00	10.2	13.7	8.4	148.6	3,285,654.1	1,703.5	1.4	0.9
07/17/2024 09:00	10.2	13.8	8.5	142.0	3,124,987.9	1,620.2	1.4	0.8
07/17/2024 10:00	10.0	13.8	8.3	101.5	2,794,603.9	1,428.5	1.1	0.6
07/17/2024 11:00	9.9	13.8	8.2	113.8	2,797,342.8	1,429.9	1.3	0.7
07/17/2024 12:00	10.2	13.8	8.5	131.5	3,009,016.6	1,538.1	1.4	0.8
07/17/2024 13:00	10.1	13.9	8.5	123.7	2,888,507.3	1,476.5	1.4	0.7
07/17/2024 14:00	10.4	13.8	8.6	141.2	3,082,769.9	1,575.8	1.5	0.9
07/17/2024 15:00	11.2	13.1	8.5	181.1	3,295,694.9	2,069.7	1.8	1.4
07/17/2024 16:00	10.8	13.2	8.3	180.7	3,291,935.1	2,043.3	1.8	1.4
07/17/2024 17:00	10.8	13.1	8.2	184.4	3,301,099.8	2,097.2	1.8	1.5
07/17/2024 18:00	10.9	12.9	8.0	211.4	3,267,770.5	2,219.2	2.1	1.8
07/17/2024 19:00	10.8	12.9	8.0	217.0	3,284,262.5	2,230.4	2.2	1.8
07/17/2024 20:00	10.8	12.9	8.0	217.9	3,284,851.5	2,230.8	2.2	1.8
07/17/2024 21:00	10.9	12.9	8.0	211.3	3,272,482.5	2,222.4	2.1	1.8
07/17/2024 22:00	11.0	12.9	8.1	211.7	3,262,616.8	2,215.7	2.1	1.8
07/17/2024 23:00	10.9	13.0	8.1	209.3	3,297,726.1	2,167.3	2.1	1.7
Average/Sum#:	10.4	13.4	8.2	163.0	3,207,858.1	1,845.8	1.6	1.2
Minimum:	9.7	12.9	7.8	101.5	2,794,603.9	1,428.5	1.1	0.6
Maximum:	11.2	13.9	8.6	217.9	3,379,806.2	2,230.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/18/2024 00:00	10.7	13.2	8.2	192.0	3,334,630.9	2,021.1	1.9	1.4
07/18/2024 01:00	10.9	13.1	8.2	180.2	3,320,202.0	2,036.6	1.8	1.4
07/18/2024 02:00	11.0	13.0	8.2	204.9	3,307,920.7	2,174.0	2.0	1.7
07/18/2024 03:00	10.8	13.0	8.1	205.1	3,307,544.6	2,149.6	2.0	1.7
07/18/2024 04:00	11.0	13.0	8.2	208.8	3,338,779.7	2,169.9	2.1	1.7
07/18/2024 05:00	10.6	13.1	8.0	195.2	3,332,895.6	2,117.4	1.9	1.5
07/18/2024 06:00	10.5	13.2	8.0	190.2	3,344,695.3	2,027.2	1.9	1.4
07/18/2024 07:00	11.2	13.2	8.6	178.1	3,303,986.8	1,978.4	1.7	1.4
07/18/2024 08:00	11.1	13.2	8.5	185.3	3,332,816.0	2,020.0	1.8	1.4
07/18/2024 09:00	11.2	13.1	8.5	192.5	3,300,155.4	2,096.6	1.9	1.5
07/18/2024 10:00	11.1	13.0	8.3	196.6	3,268,100.2	2,100.1	2.0	1.7
07/18/2024 11:00	11.0	13.0	8.2	198.6	3,268,411.4	2,100.3	2.0	1.7
07/18/2024 12:00	11.2	13.0	8.4	199.6	3,260,804.1	2,071.6	2.0	1.7
07/18/2024 13:00	11.2	12.9	8.3	207.4	3,228,864.5	2,169.2	2.1	1.7
07/18/2024 14:00	11.3	12.9	8.3	211.1	3,209,017.8	2,179.3	2.2	1.7
07/18/2024 15:00	11.1	12.9	8.2	213.8	3,210,195.8	2,180.1	2.2	1.7
07/18/2024 16:00	11.1	12.9	8.2	215.9	3,223,742.8	2,189.3	2.2	1.8
07/18/2024 17:00	11.4	12.9	8.4	220.1	3,196,731.8	2,194.3	2.3	2.0
07/18/2024 18:00	11.3	12.9	8.3	208.4	3,199,791.2	2,196.4	2.1	1.8
07/18/2024 19:00	11.4	12.9	8.4	217.9	3,205,181.5	2,200.1	2.2	1.8
07/18/2024 20:00	11.4	12.9	8.4	221.2	3,217,418.9	2,208.5	2.3	2.0
07/18/2024 21:00	11.4	12.9	8.4	220.6	3,221,935.1	2,211.6	2.3	2.0
07/18/2024 22:00	11.1	12.9	8.2	213.7	3,240,291.2	2,224.2	2.2	1.8
07/18/2024 23:00	11.0	13.0	8.2	207.1	3,261,208.1	2,143.3	2.1	1.7
Average/Sum#:	11.1	13.0	8.3	203.5	3,268,138.4	2,131.6	2.1	1.7
Minimum:	10.5	12.9	8.0	178.1	3,196,731.8	1,978.4	1.7	1.4
Maximum:	11.4	13.2	8.6	221.2	3,344,695.3	2,224.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/19/2024 00:00	10.6	13.1	8.0	194.5	3,288,507.4	2,089.2	1.9	1.5
07/19/2024 01:00	10.6	13.1	8.0	188.1	3,291,236.3	2,066.9	1.9	1.4
07/19/2024 02:00	10.8	13.1	8.2	189.7	3,296,062.8	2,094.0	1.9	1.5
07/19/2024 03:00	10.5	13.2	8.0	175.5	3,299,817.8	2,000.0	1.7	1.4
07/19/2024 04:00	10.7	13.0	8.0	199.9	3,318,419.6	2,180.9	2.0	1.7
07/19/2024 05:00	10.5	13.1	7.9	192.6	3,303,019.8	2,074.3	1.9	1.5
07/19/2024 06:00	10.0	13.7	8.2	205.7	3,305,257.9	1,737.8	2.0	1.4
07/19/2024 07:00	10.9	13.6	8.8	162.0	3,329,793.4	1,750.7	1.6	1.1
07/19/2024 08:00	10.6	13.7	8.7	164.4	3,333,597.4	1,752.7	1.6	1.1
07/19/2024 09:00	10.6	13.6	8.6	164.7	3,340,064.1	1,756.1	1.6	1.1
07/19/2024 10:00	10.8	13.6	8.7	169.6	3,284,742.6	1,751.0	1.7	1.2
07/19/2024 11:00	11.0	13.5	8.8	171.1	3,278,176.9	1,747.5	1.7	1.2
07/19/2024 12:00	11.3	13.5	9.0	174.7	3,258,292.1	1,736.9	1.7	1.2
07/19/2024 13:00	11.7	13.0	8.7	189.9	3,248,244.5	2,158.5	1.9	1.5
07/19/2024 14:00	11.4	12.9	8.4	212.0	3,203,870.3	2,199.2	2.2	1.8
07/19/2024 15:00	11.1	12.9	8.2	212.0	3,198,188.7	2,195.3	2.2	1.8
07/19/2024 16:00	11.0	12.9	8.1	212.2	3,188,282.2	2,188.5	2.2	1.8
07/19/2024 17:00	11.1	12.9	8.2	213.7	3,180,998.0	2,183.5	2.2	1.7
07/19/2024 18:00	11.2	12.9	8.3	214.5	3,179,249.8	2,182.3	2.2	1.7
07/19/2024 19:00	11.3	12.9	8.3	207.9	3,170,071.8	2,176.0	2.2	1.7
07/19/2024 20:00	11.0	13.0	8.2	204.2	3,214,426.0	2,159.5	2.1	1.7
07/19/2024 21:00	10.7	13.0	8.0	199.4	3,282,310.2	2,133.2	2.0	1.7
07/19/2024 22:00	10.6	12.9	7.8	213.1	3,258,346.5	2,212.8	2.2	1.8
07/19/2024 23:00	11.0	12.9	8.1	215.5	3,238,105.9	2,222.7	2.2	1.8
Average/Sum#:	10.9	13.2	8.3	193.6	3,262,045.1	2,031.2	2.0	1.5
Minimum:	10.0	12.9	7.8	162.0	3,170,071.8	1,736.9	1.6	1.1
Maximum:	11.7	13.7	9.0	215.5	3,340,064.1	2,222.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/20/2024 00:00	11.3	12.9	8.3	214.7	3,233,735.4	2,219.7	2.2	1.8
07/20/2024 01:00	10.9	12.9	8.0	217.8	3,283,379.0	2,229.8	2.2	1.8
07/20/2024 02:00	10.7	12.9	7.9	217.2	3,284,851.5	2,230.8	2.2	1.8
07/20/2024 03:00	10.5	12.9	7.7	212.0	3,289,858.0	2,234.2	2.1	1.8
07/20/2024 04:00	10.5	12.9	7.7	208.2	3,293,097.5	2,236.4	2.1	1.8
07/20/2024 05:00	10.2	13.0	7.6	193.0	3,273,232.0	2,127.3	1.9	1.5
07/20/2024 06:00	9.7	13.7	7.9	151.0	3,248,388.8	1,707.9	1.5	1.0
07/20/2024 07:00	10.7	13.7	8.8	163.7	3,344,288.6	1,733.9	1.6	1.0
07/20/2024 08:00	10.3	13.8	8.6	127.7	3,038,772.0	1,575.5	1.3	0.8
07/20/2024 09:00	10.5	13.7	8.6	142.9	3,103,964.3	1,609.3	1.5	1.0
07/20/2024 10:00	11.0	13.6	8.9	170.0	3,260,941.8	1,714.5	1.7	1.2
07/20/2024 11:00	10.9	13.6	8.8	153.0	3,087,101.0	1,623.1	1.6	1.0
07/20/2024 12:00	10.1	13.9	8.5	97.0	2,659,263.4	1,339.9	1.1	0.5
07/20/2024 13:00	10.9	13.7	8.9	165.7	3,143,118.3	1,629.6	1.7	1.1
07/20/2024 14:00	11.7	13.0	8.7	190.8	3,223,625.0	2,118.6	1.9	1.5
07/20/2024 15:00	11.4	12.9	8.4	209.5	3,187,633.0	2,141.5	2.2	1.7
07/20/2024 16:00	11.5	12.9	8.5	211.1	3,168,524.1	2,151.8	2.2	1.7
07/20/2024 17:00	11.5	12.9	8.5	209.1	3,167,449.5	2,174.2	2.2	1.7
07/20/2024 18:00	11.5	12.9	8.5	218.9	3,141,459.5	2,179.3	2.3	2.0
07/20/2024 19:00	11.4	12.9	8.4	207.4	3,170,515.1	2,130.0	2.1	1.7
07/20/2024 20:00	11.4	13.0	8.5	202.7	3,186,545.2	2,117.5	2.1	1.7
07/20/2024 21:00	11.1	13.0	8.3	198.7	3,215,408.5	2,113.2	2.0	1.7
07/20/2024 22:00	11.8	12.9	8.7	224.5	3,203,433.3	2,198.9	2.3	2.0
07/20/2024 23:00	11.8	12.9	8.7	224.8	3,228,636.5	2,216.2	2.3	2.0
Average/Sum#:	11.0	13.2	8.4	188.8	3,184,884.2	1,989.7	1.9	1.5
Minimum:	9.7	12.9	7.6	97.0	2,659,263.4	1,339.9	1.1	0.5
Maximum:	11.8	13.9	8.9	224.8	3,344,288.6	2,236.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/21/2024 00:00	11.3	12.9	8.3	212.8	3,249,760.6	2,230.7	2.2	1.8
07/21/2024 01:00	11.0	12.9	8.1	212.9	3,270,840.4	2,197.4	2.1	1.8
07/21/2024 02:00	10.8	13.0	8.1	209.9	3,304,725.4	2,171.9	2.1	1.7
07/21/2024 03:00	10.7	13.0	8.0	203.7	3,300,160.6	2,168.9	2.0	1.7
07/21/2024 04:00	10.6	13.0	7.9	199.9	3,305,334.0	2,172.3	2.0	1.7
07/21/2024 05:00	13.6	14.0	11.6	173.1	2,762,453.3	1,533.1	2.0	1.2
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2024 23:00	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
Average/Sum#:	9.7	14.3	7.4	173.2	2,741,896.3	1,782.1	1.8	1.4
Minimum:	0.0	12.9	0.0	0.0	0.0	0.2	0.0	0.0
Maximum:	13.6	21.0	11.6	212.9	3,305,334.0	2,230.7	2.2	1.8
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/22/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/22/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/22/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/22/2024 03:00	29.5	16.8	42.5	67.2	1,666,484.1	474.6	1.3	0.2
07/22/2024 04:00	13.2	13.9	11.1	141.8	2,663,232.7	1,341.9	1.7	0.9
07/22/2024 05:00	10.8	13.6	8.7	169.3	3,114,109.1	1,637.3	1.8	1.1
07/22/2024 06:00	10.8	13.7	8.9	167.3	3,268,549.7	1,718.5	1.6	1.0
07/22/2024 07:00	11.3	13.6	9.1	151.3	3,244,394.6	1,705.8	1.5	1.0
07/22/2024 08:00	11.1	13.7	9.1	182.2	3,272,924.3	1,696.9	1.8	1.2
07/22/2024 09:00	11.0	13.7	9.0	168.8	3,247,078.8	1,683.5	1.7	1.2
07/22/2024 10:00	11.2	13.7	9.2	168.8	3,218,340.2	1,668.6	1.7	1.2
07/22/2024 11:00	11.1	13.7	9.1	164.1	3,185,358.3	1,651.5	1.6	1.0
07/22/2024 12:00	11.8	13.3	9.2	183.3	3,063,744.7	1,789.8	1.9	1.3
07/22/2024 13:00	11.8	12.9	8.7	208.8	3,146,034.0	2,159.5	2.2	1.7
07/22/2024 14:00	11.5	12.9	8.5	210.2	3,166,168.1	2,150.2	2.2	1.7
07/22/2024 15:00	11.5	12.9	8.5	211.0	3,135,836.2	2,152.5	2.2	1.7
07/22/2024 16:00	11.4	12.9	8.4	211.9	3,157,688.7	2,167.5	2.2	1.7
07/22/2024 17:00	11.1	12.9	8.2	207.0	3,170,800.2	2,176.5	2.1	1.7
07/22/2024 18:00	11.2	12.9	8.3	210.4	3,165,701.3	2,173.0	2.2	1.7
07/22/2024 19:00	11.4	12.9	8.4	207.1	3,146,762.4	2,160.0	2.2	1.7
07/22/2024 20:00	11.5	12.9	8.5	204.7	3,160,393.3	2,123.2	2.1	1.7
07/22/2024 21:00	11.4	13.0	8.5	206.0	3,190,606.7	2,096.9	2.1	1.7
07/22/2024 22:00	11.4	12.9	8.4	219.5	3,183,183.3	2,185.0	2.3	2.0
07/22/2024 23:00	11.2	12.9	8.3	218.5	3,224,120.3	2,213.1	2.2	1.8
Average/Sum#:	12.2	13.4	10.4	184.7	3,085,310.0	1,863.1	1.9	1.4
Minimum:	10.8	12.9	8.2	67.2	1,666,484.1	474.6	1.3	0.2
Maximum:	29.5	16.8	42.5	219.5	3,272,924.3	2,213.1	2.3	2.0
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/23/2024 00:00	11.1	12.9	8.2	215.8	3,228,199.5	2,215.9	2.2	1.8
07/23/2024 01:00	11.1	12.9	8.2	211.0	3,232,715.6	2,219.0	2.1	1.8
07/23/2024 02:00	11.1	12.9	8.2	216.4	3,249,906.3	2,230.8	2.2	1.8
07/23/2024 03:00	11.1	12.9	8.2	221.5	3,252,965.6	2,232.9	2.2	1.8
07/23/2024 04:00	10.9	12.9	8.0	218.0	3,262,435.1	2,239.4	2.2	1.8
07/23/2024 05:00	11.3	12.9	8.3	213.0	3,269,573.6	2,244.3	2.1	1.8
07/23/2024 06:00	11.0	13.1	8.3	175.2	3,287,255.5	2,064.4	1.7	1.4
07/23/2024 07:00	11.5	13.0	8.6	195.0	3,259,230.0	2,118.2	1.9	1.5
07/23/2024 08:00	11.0	13.1	8.3	183.1	3,224,357.5	2,024.9	1.8	1.4
07/23/2024 09:00	11.1	13.0	8.3	191.3	3,233,397.7	2,077.8	1.9	1.5
07/23/2024 10:00	11.3	13.0	8.4	202.7	3,213,886.9	2,112.2	2.1	1.7
07/23/2024 11:00	11.4	12.9	8.4	214.7	3,202,980.6	2,175.2	2.2	1.7
07/23/2024 12:00	11.2	12.9	8.3	200.8	3,213,278.2	2,111.8	2.0	1.7
07/23/2024 13:00	11.2	13.0	8.4	197.4	3,205,991.7	2,083.6	2.0	1.7
07/23/2024 14:00	11.1	12.9	8.2	201.0	3,203,399.7	2,128.7	2.1	1.7
07/23/2024 15:00	11.3	12.9	8.3	206.3	3,185,251.3	2,139.9	2.1	1.7
07/23/2024 16:00	11.4	12.9	8.4	212.7	3,174,588.0	2,179.1	2.2	1.7
07/23/2024 17:00	11.4	12.9	8.4	213.9	3,148,955.3	2,184.5	2.2	1.7
07/23/2024 18:00	11.4	12.9	8.4	212.1	3,149,820.2	2,185.1	2.2	1.7
07/23/2024 19:00	11.3	12.9	8.3	209.7	3,184,868.8	2,162.9	2.2	1.7
07/23/2024 20:00	11.5	12.9	8.5	219.6	3,206,055.6	2,200.7	2.3	2.0
07/23/2024 21:00	11.1	12.9	8.2	217.4	3,212,902.7	2,205.4	2.2	1.8
07/23/2024 22:00	10.7	13.0	8.0	204.0	3,255,467.9	2,163.3	2.1	1.7
07/23/2024 23:00	10.8	12.9	8.0	217.0	3,279,550.5	2,227.2	2.2	1.8
Average/Sum#:	11.2	12.9	8.3	207.1	3,222,376.4	2,163.6	2.1	1.7
Minimum:	10.7	12.9	8.0	175.2	3,148,955.3	2,024.9	1.7	1.4
Maximum:	11.5	13.1	8.6	221.5	3,287,255.5	2,244.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/24/2024 00:00	11.0	13.0	8.2	204.4	3,253,812.5	2,162.2	2.1	1.7
07/24/2024 01:00	11.1	13.0	8.3	205.3	3,260,751.6	2,143.0	2.1	1.7
07/24/2024 02:00	10.9	13.0	8.1	201.3	3,269,729.0	2,148.9	2.0	1.7
07/24/2024 03:00	10.7	13.0	8.0	210.7	3,300,461.6	2,217.3	2.1	1.8
07/24/2024 04:00	10.7	12.9	7.9	213.6	3,311,178.9	2,224.5	2.1	1.8
07/24/2024 05:00	10.6	12.9	7.8	216.0	3,302,963.3	2,243.1	2.2	1.8
07/24/2024 06:00	10.5	13.1	7.9	187.5	3,297,667.3	2,119.1	1.9	1.5
07/24/2024 07:00	11.1	13.1	8.4	190.3	3,317,784.7	2,107.8	1.9	1.5
07/24/2024 08:00	10.8	13.1	8.2	188.9	3,298,109.1	2,095.3	1.9	1.5
07/24/2024 09:00	10.8	13.1	8.2	190.1	3,280,951.9	2,084.4	1.9	1.5
07/24/2024 10:00	11.0	13.1	8.3	192.7	3,267,729.9	2,076.0	1.9	1.5
07/24/2024 11:00	11.3	13.0	8.4	198.9	3,253,783.5	2,090.9	2.0	1.7
07/24/2024 12:00	11.2	13.0	8.4	202.9	3,233,515.3	2,125.1	2.1	1.7
07/24/2024 13:00	11.3	13.0	8.4	199.1	3,211,069.4	2,086.9	2.0	1.7
07/24/2024 14:00	11.4	12.9	8.4	202.3	3,183,986.9	2,115.8	2.1	1.7
07/24/2024 15:00	11.5	12.9	8.5	210.1	3,148,645.3	2,138.3	2.2	1.7
07/24/2024 16:00	10.8	13.1	8.2	186.6	3,231,204.6	2,029.2	1.9	1.4
07/24/2024 17:00	10.7	13.1	8.1	180.7	3,232,324.9	2,006.3	1.8	1.4
07/24/2024 18:00	10.6	13.1	8.0	178.7	3,249,080.2	2,016.7	1.8	1.4
07/24/2024 19:00	10.5	13.1	7.9	175.6	3,282,268.6	2,037.3	1.7	1.4
07/24/2024 20:00	10.3	13.2	7.9	172.6	3,293,868.4	2,044.5	1.7	1.4
07/24/2024 21:00	10.3	13.1	7.8	191.6	3,325,393.2	2,161.2	1.9	1.5
07/24/2024 22:00	10.3	13.0	7.7	205.9	3,315,049.0	2,227.1	2.0	1.8
07/24/2024 23:00	10.2	13.1	7.7	192.5	3,317,853.7	2,156.3	1.9	1.5
Average/Sum#:	10.8	13.0	8.1	195.8	3,268,299.3	2,119.1	2.0	1.6
Minimum:	10.2	12.9	7.7	172.6	3,148,645.3	2,006.3	1.7	1.4
Maximum:	11.5	13.2	8.5	216.0	3,325,393.2	2,243.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/25/2024 00:00	10.4	13.1	7.9	184.7	3,331,522.9	2,092.2	1.8	1.5
07/25/2024 01:00	10.4	13.1	7.9	183.2	3,354,928.6	2,082.4	1.8	1.5
07/25/2024 02:00	10.4	13.1	7.9	184.0	3,341,073.3	2,073.8	1.8	1.5
07/25/2024 03:00	10.4	13.1	7.9	187.5	3,337,038.2	2,144.4	1.8	1.5
07/25/2024 04:00	10.4	13.0	7.8	197.1	3,341,549.4	2,171.7	1.9	1.5
07/25/2024 05:00	10.3	13.0	7.7	197.0	3,330,317.0	2,164.4	1.9	1.5
07/25/2024 06:00	10.3	13.1	7.8	192.6	3,352,701.2	2,105.5	1.9	1.5
07/25/2024 07:00	11.0	13.1	8.3	185.6	3,324,710.6	2,112.2	1.8	1.5
07/25/2024 08:00	10.6	13.1	8.0	187.3	3,308,340.4	2,101.8	1.8	1.5
07/25/2024 09:00	10.6	13.1	8.0	186.2	3,328,497.4	2,090.3	1.8	1.5
07/25/2024 10:00	10.6	13.1	8.0	185.3	3,317,390.3	2,059.1	1.8	1.4
07/25/2024 11:00	10.8	13.0	8.1	197.4	3,272,308.8	2,126.7	2.0	1.7
07/25/2024 12:00	10.8	13.0	8.1	199.7	3,274,770.7	2,128.3	2.0	1.7
07/25/2024 13:00	10.8	13.0	8.1	196.2	3,265,538.6	2,122.3	2.0	1.7
07/25/2024 14:00	11.1	13.0	8.3	205.8	3,212,880.3	2,135.0	2.1	1.7
07/25/2024 15:00	11.1	12.9	8.2	207.2	3,212,193.3	2,158.0	2.1	1.7
07/25/2024 16:00	11.0	13.0	8.2	197.0	3,224,994.4	2,119.5	2.0	1.7
07/25/2024 17:00	11.0	13.0	8.2	198.4	3,212,365.3	2,111.2	2.0	1.7
07/25/2024 18:00	11.1	13.0	8.3	196.0	3,233,708.9	2,078.0	2.0	1.7
07/25/2024 19:00	11.1	13.1	8.4	195.0	3,233,100.8	2,054.0	2.0	1.6
07/25/2024 20:00	11.2	13.0	8.4	208.2	3,244,030.9	2,155.7	2.1	1.7
07/25/2024 21:00	10.8	13.0	8.1	203.9	3,264,196.1	2,169.1	2.0	1.7
07/25/2024 22:00	10.7	13.0	8.0	196.0	3,285,849.2	2,135.5	2.0	1.7
07/25/2024 23:00	10.7	12.9	7.9	209.3	3,299,568.5	2,216.7	2.1	1.8
Average/Sum#:	10.7	13.0	8.1	195.0	3,287,649.0	2,121.2	1.9	1.6
Minimum:	10.3	12.9	7.7	183.2	3,212,193.3	2,054.0	1.8	1.4
Maximum:	11.2	13.1	8.4	209.3	3,354,928.6	2,216.7	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/26/2024 00:00	10.6	13.0	7.9	201.8	3,306,703.4	2,173.2	2.0	1.7
07/26/2024 01:00	10.3	13.2	7.9	183.4	3,329,657.6	2,042.4	1.8	1.4
07/26/2024 02:00	10.2	13.3	7.9	169.2	3,368,441.6	1,967.8	1.6	1.2
07/26/2024 03:00	10.1	13.3	7.8	166.8	3,375,459.9	1,971.9	1.6	1.2
07/26/2024 04:00	10.3	13.1	7.8	183.1	3,366,077.0	2,113.9	1.8	1.5
07/26/2024 05:00	10.0	13.2	7.7	177.7	3,352,673.1	2,081.0	1.7	1.5
07/26/2024 06:00	10.0	13.3	7.8	176.6	3,377,514.1	1,973.1	1.7	1.4
07/26/2024 07:00	10.8	13.3	8.4	165.6	3,334,971.0	1,972.6	1.6	1.2
07/26/2024 08:00	10.6	13.2	8.1	174.0	3,340,719.2	1,976.0	1.7	1.4
07/26/2024 09:00	10.6	13.2	8.1	172.3	3,312,838.0	1,983.7	1.7	1.4
07/26/2024 10:00	10.7	13.2	8.2	173.5	3,287,278.5	1,992.4	1.7	1.4
07/26/2024 11:00	10.8	13.2	8.3	177.9	3,303,447.6	2,002.2	1.7	1.4
07/26/2024 12:00	10.8	13.1	8.2	180.5	3,243,280.3	2,013.1	1.8	1.4
07/26/2024 13:00	10.7	13.1	8.1	182.4	3,243,465.7	2,036.9	1.8	1.4
07/26/2024 14:00	10.7	13.1	8.1	182.4	3,228,063.8	2,050.8	1.8	1.4
07/26/2024 15:00	11.0	13.0	8.2	190.7	3,215,377.7	2,089.7	1.9	1.5
07/26/2024 16:00	11.1	13.0	8.3	204.1	3,176,469.2	2,134.0	2.1	1.7
07/26/2024 17:00	11.3	12.9	8.3	208.0	3,180,339.3	2,136.6	2.1	1.7
07/26/2024 18:00	10.9	13.1	8.2	189.5	3,233,415.6	2,054.2	1.9	1.4
07/26/2024 19:00	10.6	13.1	8.0	187.9	3,274,791.7	2,104.4	1.9	1.5
07/26/2024 20:00	10.7	13.0	8.0	207.8	3,278,431.7	2,202.5	2.1	1.8
07/26/2024 21:00	10.4	13.1	7.9	180.8	3,326,251.3	2,064.6	1.8	1.4
07/26/2024 22:00	10.4	13.1	7.9	175.6	3,317,873.6	2,059.4	1.7	1.4
07/26/2024 23:00	10.1	13.3	7.8	167.6	3,375,459.9	1,971.9	1.6	1.2
Average/Sum#:	10.6	13.1	8.0	182.5	3,297,875.0	2,048.7	1.8	1.4
Minimum:	10.0	12.9	7.7	165.6	3,176,469.2	1,967.8	1.6	1.2
Maximum:	11.3	13.3	8.4	208.0	3,377,514.1	2,202.5	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/27/2024 00:00	10.0	13.3	7.8	171.6	3,381,451.2	1,975.4	1.6	1.2
07/27/2024 01:00	9.9	13.3	7.7	159.7	3,380,252.9	1,974.7	1.5	1.2
07/27/2024 02:00	9.5	13.3	7.4	156.7	3,384,874.7	1,977.4	1.5	1.2
07/27/2024 03:00	9.5	13.3	7.4	159.4	3,389,154.2	1,979.9	1.5	1.2
07/27/2024 04:00	9.5	13.3	7.4	156.5	3,411,726.4	2,018.0	1.5	1.2
07/27/2024 05:00	9.5	13.2	7.3	165.3	3,372,908.8	2,044.3	1.6	1.2
07/27/2024 06:00	19.1	15.8	22.1	135.8	441,950.6	674.5	10.3	2.7
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/27/2024 15:00	28.3	17.6	50.6	3.4	1,495,867.9	327.7	-0.1	0.0
07/27/2024 16:00	24.3	14.7	23.1	185.9	2,326,001.0	1,036.1	2.6	1.0
07/27/2024 17:00	10.4	13.6	8.4	175.2	3,289,471.5	1,729.5	1.7	1.2
07/27/2024 18:00	10.4	13.6	8.4	148.6	3,020,341.6	1,588.0	1.6	1.0
07/27/2024 19:00	11.0	13.2	8.4	168.1	3,303,986.8	1,978.4	1.6	1.2
07/27/2024 20:00	10.9	13.2	8.4	178.7	3,296,304.7	1,973.8	1.8	1.4
07/27/2024 21:00	11.0	13.2	8.4	176.4	3,328,546.6	1,968.8	1.7	1.4
07/27/2024 22:00	11.1	13.2	8.5	187.1	3,319,417.1	1,963.4	1.8	1.4
07/27/2024 23:00	11.0	13.2	8.4	175.4	3,315,697.7	1,961.2	1.7	1.4
Average/Sum#:	12.8	13.8	12.5	156.5	3,134,400.2	1,698.2	1.6	1.1
Minimum:	9.5	13.2	7.3	3.4	1,495,867.9	327.7	-0.1	0.0
Maximum:	28.3	17.6	50.6	187.1	3,411,726.4	2,044.3	2.6	1.4
%SI	33.33	33.33	33.33	33.33	37.50	33.33	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/28/2024 00:00	10.9	13.2	8.4	183.7	3,355,260.9	1,960.1	1.8	1.4
07/28/2024 01:00	10.8	13.2	8.3	175.9	3,361,252.2	1,963.6	1.7	1.4
07/28/2024 02:00	10.8	13.2	8.3	180.0	3,360,567.4	1,963.2	1.7	1.4
07/28/2024 03:00	10.7	13.2	8.2	176.6	3,398,772.6	1,960.7	1.7	1.4
07/28/2024 04:00	10.6	13.3	8.2	171.1	3,389,065.3	1,955.1	1.6	1.2
07/28/2024 05:00	10.0	13.7	8.2	153.1	3,287,390.0	1,704.4	1.5	1.0
07/28/2024 06:00	10.0	13.8	8.3	94.7	2,570,605.2	1,314.0	1.1	0.5
07/28/2024 07:00	5.9	17.5	10.2	92.9	989,637.4	325.2	3.3	0.4
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/28/2024 14:00	31.7	16.7	44.5	116.4	1,723,367.9	490.8	2.0	0.4
07/28/2024 15:00	19.4	14.3	17.3	182.7	2,567,986.7	1,218.9	2.3	1.1
07/28/2024 16:00	10.6	13.7	8.7	185.0	3,237,049.2	1,678.3	1.9	1.2
07/28/2024 17:00	11.3	13.3	8.8	190.4	3,263,563.7	1,882.7	1.9	1.3
07/28/2024 18:00	11.3	13.3	8.8	193.6	3,263,217.0	1,882.5	1.9	1.3
07/28/2024 19:00	11.3	13.3	8.8	199.7	3,271,710.9	1,887.4	2.0	1.5
07/28/2024 20:00	11.4	13.2	8.7	206.9	3,271,087.2	1,958.7	2.1	1.6
07/28/2024 21:00	11.4	13.2	8.7	210.3	3,272,423.3	1,959.5	2.1	1.6
07/28/2024 22:00	10.2	13.8	8.5	119.3	2,904,337.0	1,505.8	1.3	0.8
07/28/2024 23:00	10.5	13.8	8.7	177.4	3,218,725.9	1,668.8	1.8	1.2
Average/Sum#:	12.2	13.9	11.1	167.2	2,983,667.8	1,626.7	1.9	1.2
Minimum:	5.9	13.2	8.2	92.9	989,637.4	325.2	1.1	0.4
Maximum:	31.7	17.5	44.5	210.3	3,398,772.6	1,963.6	3.3	1.6
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/29/2024 00:00	10.2	13.8	8.5	125.9	2,950,048.7	1,529.5	1.3	0.8
07/29/2024 01:00	10.1	13.8	8.4	127.7	2,980,845.6	1,523.7	1.4	0.8
07/29/2024 02:00	10.1	13.8	8.4	128.8	2,956,992.3	1,533.1	1.4	0.8
07/29/2024 03:00	22.3	16.0	26.9	149.0	1,529,621.2	592.0	2.9	0.7
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/29/2024 14:00	0.0	21.0	0.0	0.0	0.0	0.2	0.0	0.0
07/29/2024 15:00	32.8	16.9	48.4	108.9	1,604,333.3	456.9	2.0	0.4
07/29/2024 16:00	18.2	14.1	15.8	190.5	2,778,909.5	1,359.6	2.2	1.1
07/29/2024 17:00	10.6	13.7	8.7	152.9	3,148,534.9	1,655.4	1.5	1.0
07/29/2024 18:00	11.2	13.3	8.7	170.2	3,124,541.1	1,802.5	1.8	1.3
07/29/2024 19:00	11.2	12.9	8.3	204.1	3,215,962.1	2,207.5	2.1	1.8
07/29/2024 20:00	11.0	12.9	8.1	202.8	3,267,034.3	2,218.7	2.0	1.8
07/29/2024 21:00	10.7	13.1	8.1	193.6	3,260,804.1	2,071.6	1.9	1.5
07/29/2024 22:00	10.7	13.1	8.1	188.9	3,254,612.2	2,043.9	1.9	1.4
07/29/2024 23:00	18.4	15.8	21.3	134.7	1,732,829.0	683.3	2.3	0.6
Average/Sum#:	13.4	14.6	13.4	148.4	2,557,504.9	1,405.6	1.8	1.0
Minimum:	0.0	12.9	0.0	0.0	0.0	0.2	0.0	0.0
Maximum:	32.8	21.0	48.4	204.1	3,267,034.3	2,218.7	2.9	1.8
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/30/2024 15:00	33.0	16.8	47.5	74.4	1,664,377.3	474.0	1.4	0.2
07/30/2024 16:00	20.9	14.3	18.7	171.0	2,523,954.5	1,198.0	2.2	1.0
07/30/2024 17:00	10.0	13.8	8.3	120.1	2,831,774.0	1,447.5	1.3	0.7
07/30/2024 18:00	10.9	13.5	8.7	169.4	3,112,861.7	1,750.3	1.8	1.2
07/30/2024 19:00	11.2	13.0	8.4	233.7	3,280,813.4	2,204.1	2.4	2.0
07/30/2024 20:00	10.9	13.0	8.1	209.7	3,257,610.3	2,212.3	2.1	1.8
07/30/2024 21:00	10.9	12.9	8.0	213.7	3,234,197.5	2,196.4	2.2	1.8
07/30/2024 22:00	10.7	13.0	8.0	193.5	3,250,767.3	2,112.7	1.9	1.5
07/30/2024 23:00	10.8	13.0	8.1	196.6	3,267,846.6	2,123.8	2.0	1.7
Average/Sum#:	14.4	13.7	13.8	175.8	2,936,022.5	1,746.6	1.9	1.3
Minimum:	10.0	12.9	8.0	74.4	1,664,377.3	474.0	1.3	0.2
Maximum:	33.0	16.8	47.5	233.7	3,280,813.4	2,212.3	2.4	2.0
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/31/2024 00:00	10.9	13.2	8.4	183.9	3,278,936.4	1,963.4	1.8	1.4
07/31/2024 01:00	10.8	13.2	8.3	181.5	3,308,089.7	1,956.7	1.8	1.4
07/31/2024 02:00	10.6	13.2	8.1	172.5	3,306,568.2	1,955.8	1.7	1.4
07/31/2024 03:00	10.6	13.2	8.1	176.8	3,309,831.9	1,981.9	1.7	1.4
07/31/2024 04:00	10.9	12.9	8.0	213.3	3,328,892.1	2,236.4	2.1	1.8
07/31/2024 05:00	10.5	13.0	7.8	200.0	3,272,001.1	2,126.5	2.0	1.7
07/31/2024 06:00	9.8	13.7	8.0	163.3	3,308,799.3	1,715.5	1.6	1.0
07/31/2024 07:00	10.4	13.7	8.5	131.4	3,061,724.3	1,587.4	1.4	0.8
07/31/2024 08:00	9.9	13.8	8.2	114.9	2,879,648.7	1,493.0	1.3	0.7
07/31/2024 09:00	9.9	13.7	8.1	119.7	2,887,942.4	1,497.3	1.3	0.7
07/31/2024 10:00	10.2	13.7	8.4	135.3	2,978,401.6	1,544.2	1.4	0.8
07/31/2024 11:00	10.4	13.8	8.6	136.2	3,040,315.0	1,576.3	1.4	0.8
07/31/2024 12:00	10.2	13.8	8.5	115.5	2,867,574.7	1,465.8	1.3	0.7
07/31/2024 13:00	11.1	13.6	9.0	172.1	3,090,144.2	1,624.7	1.8	1.1
07/31/2024 14:00	11.8	13.0	8.8	200.7	3,198,366.7	2,102.0	2.0	1.7
07/31/2024 15:00	11.3	12.9	8.3	211.8	3,193,818.2	2,192.3	2.2	1.8
07/31/2024 16:00	11.1	12.9	8.2	207.9	3,181,726.4	2,184.0	2.1	1.7
07/31/2024 17:00	11.0	12.9	8.1	215.5	3,195,275.0	2,193.3	2.2	1.8
07/31/2024 18:00	10.9	12.9	8.0	213.8	3,177,647.3	2,181.2	2.2	1.7
07/31/2024 19:00	11.1	12.9	8.2	208.1	3,206,983.5	2,154.5	2.1	1.7
07/31/2024 20:00	11.1	12.9	8.2	202.9	3,207,161.8	2,131.2	2.1	1.7
07/31/2024 21:00	11.0	13.0	8.2	200.9	3,207,648.4	2,108.1	2.1	1.7
07/31/2024 22:00	11.2	13.0	8.4	206.7	3,229,995.1	2,099.2	2.1	1.7
07/31/2024 23:00	10.9	13.0	8.1	199.6	3,225,533.0	2,096.3	2.0	1.7
Average/Sum#:	10.7	13.2	8.3	178.5	3,164,292.7	1,923.6	1.8	1.4
Minimum:	9.8	12.9	7.8	114.9	2,867,574.7	1,465.8	1.3	0.7
Maximum:	11.8	13.8	9.0	215.5	3,328,892.1	2,236.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/01/2024 00:00	10.9	13.0	8.1	198.0	3,250,671.1	2,088.9	2.0	1.7
08/01/2024 01:00	11.1	13.0	8.3	194.6	3,247,092.0	2,086.6	2.0	1.7
08/01/2024 02:00	11.0	13.0	8.2	195.4	3,278,118.6	2,082.6	1.9	1.5
08/01/2024 03:00	10.7	13.1	8.1	190.5	3,307,000.7	2,076.8	1.9	1.5
08/01/2024 04:00	10.6	13.1	8.0	189.5	3,313,210.8	2,080.7	1.9	1.5
08/01/2024 05:00	10.8	12.9	8.0	210.6	3,297,038.1	2,215.0	2.1	1.8
08/01/2024 06:00	10.6	13.0	7.9	198.5	3,311,173.7	2,103.6	2.0	1.7
08/01/2024 07:00	10.8	13.6	8.7	160.7	3,241,731.8	1,704.4	1.6	1.0
08/01/2024 08:00	10.9	13.6	8.8	172.3	3,294,416.6	1,732.1	1.7	1.2
08/01/2024 09:00	11.0	13.6	8.9	178.6	3,313,246.2	1,742.0	1.7	1.2
08/01/2024 10:00	11.1	13.6	9.0	178.3	3,286,238.1	1,727.8	1.7	1.2
08/01/2024 11:00	10.9	13.6	8.8	170.4	3,252,382.9	1,710.0	1.7	1.2
08/01/2024 12:00	10.8	13.6	8.7	166.3	3,240,020.1	1,703.5	1.6	1.0
08/01/2024 13:00	11.5	13.0	8.6	194.6	3,236,254.1	2,126.9	2.0	1.7
08/01/2024 14:00	11.4	12.9	8.4	211.9	3,205,778.3	2,177.1	2.2	1.7
08/01/2024 15:00	11.2	12.9	8.3	205.4	3,203,579.0	2,199.0	2.1	1.8
08/01/2024 16:00	10.8	12.9	8.0	212.0	3,214,359.5	2,206.4	2.2	1.8
08/01/2024 17:00	10.9	12.9	8.0	215.8	3,209,989.0	2,203.4	2.2	1.8
08/01/2024 18:00	11.1	12.9	8.2	212.6	3,228,896.5	2,192.8	2.2	1.8
08/01/2024 19:00	10.8	13.0	8.1	198.4	3,234,249.3	2,149.2	2.0	1.7
08/01/2024 20:00	10.7	13.0	8.0	190.0	3,255,691.1	2,115.9	1.9	1.5
08/01/2024 21:00	10.8	13.1	8.2	191.9	3,299,038.9	2,071.8	1.9	1.5
08/01/2024 22:00	10.8	13.1	8.2	190.7	3,303,656.7	2,074.7	1.9	1.5
08/01/2024 23:00	10.7	13.0	8.0	211.7	3,327,701.3	2,235.6	2.1	1.8
Average/Sum#:	10.9	13.1	8.3	193.3	3,264,647.3	2,033.6	1.9	1.5
Minimum:	10.6	12.9	7.9	160.7	3,203,579.0	1,703.5	1.6	1.0
Maximum:	11.5	13.6	9.0	215.8	3,327,701.3	2,235.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/02/2024 00:00	10.5	13.0	7.8	208.5	3,325,170.8	2,233.9	2.1	1.8
08/02/2024 01:00	10.8	12.9	8.0	209.9	3,315,346.7	2,227.3	2.1	1.8
08/02/2024 02:00	10.7	12.9	7.9	219.6	3,312,829.0	2,249.8	2.2	1.8
08/02/2024 03:00	10.4	12.9	7.7	216.1	3,325,050.8	2,258.1	2.1	1.8
08/02/2024 04:00	10.3	12.9	7.6	208.9	3,318,866.3	2,253.9	2.1	1.8
08/02/2024 05:00	10.3	12.9	7.6	207.6	3,328,879.3	2,260.7	2.1	1.8
08/02/2024 06:00	10.3	12.9	7.6	183.3	3,316,363.0	2,252.2	1.8	1.6
08/02/2024 07:00	11.3	12.9	8.3	213.7	3,307,086.3	2,245.9	2.1	1.8
08/02/2024 08:00	11.2	12.9	8.3	214.3	3,309,000.5	2,247.2	2.1	1.8
08/02/2024 09:00	11.1	12.9	8.2	222.2	3,293,833.8	2,236.9	2.2	1.8
08/02/2024 10:00	11.0	12.9	8.1	218.7	3,284,262.5	2,230.4	2.2	1.8
08/02/2024 11:00	10.9	12.9	8.0	210.1	3,236,503.4	2,221.6	2.1	1.8
08/02/2024 12:00	11.2	12.9	8.3	217.6	3,220,623.9	2,210.7	2.2	1.8
08/02/2024 13:00	11.2	12.9	8.3	220.5	3,221,061.0	2,211.0	2.3	2.0
08/02/2024 14:00	11.0	12.9	8.1	209.7	3,219,604.1	2,210.0	2.1	1.8
08/02/2024 15:00	11.0	12.9	8.1	211.0	3,214,650.9	2,206.6	2.2	1.8
08/02/2024 16:00	10.9	12.9	8.0	217.4	3,227,616.7	2,215.5	2.2	1.8
08/02/2024 17:00	11.1	12.9	8.2	213.9	3,222,080.8	2,211.7	2.2	1.8
08/02/2024 18:00	11.3	12.9	8.3	212.9	3,225,140.1	2,213.8	2.2	1.8
08/02/2024 19:00	11.0	12.9	8.1	213.1	3,233,903.0	2,196.2	2.2	1.8
08/02/2024 20:00	10.9	12.9	8.0	210.6	3,252,234.1	2,184.9	2.1	1.7
08/02/2024 21:00	11.0	12.9	8.1	212.8	3,258,501.6	2,236.7	2.1	1.8
08/02/2024 22:00	10.9	12.9	8.0	211.9	3,263,454.9	2,240.1	2.1	1.8
08/02/2024 23:00	10.7	12.9	7.9	215.7	3,263,454.9	2,240.1	2.2	1.8
Average/Sum#:	10.9	12.9	8.0	212.5	3,270,646.6	2,229.0	2.1	1.8
Minimum:	10.3	12.9	7.6	183.3	3,214,650.9	2,184.9	1.8	1.6
Maximum:	11.3	13.0	8.3	222.2	3,328,879.3	2,260.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/03/2024 00:00	10.6	12.9	7.8	215.6	3,260,978.2	2,238.4	2.2	1.8
08/03/2024 01:00	10.6	12.9	7.8	214.5	3,256,899.1	2,235.6	2.2	1.8
08/03/2024 02:00	10.6	13.0	7.9	199.9	3,259,380.5	2,165.9	2.0	1.7
08/03/2024 03:00	10.5	13.1	7.9	177.2	3,284,173.1	2,014.5	1.8	1.4
08/03/2024 04:00	10.8	13.2	8.3	184.7	3,313,017.1	2,008.0	1.8	1.4
08/03/2024 05:00	10.7	13.1	8.1	186.2	3,305,855.7	2,027.8	1.8	1.4
08/03/2024 06:00	10.6	13.2	8.1	185.3	3,287,286.5	1,968.4	1.8	1.4
08/03/2024 07:00	11.2	13.2	8.6	171.5	3,299,811.8	1,975.9	1.7	1.4
08/03/2024 08:00	11.3	13.1	8.5	190.3	3,266,324.6	1,979.7	1.9	1.4
08/03/2024 09:00	11.0	13.2	8.4	172.7	3,281,503.8	1,988.9	1.7	1.4
08/03/2024 10:00	10.7	13.2	8.2	176.3	3,289,423.4	1,993.7	1.7	1.4
08/03/2024 11:00	10.6	13.2	8.1	176.3	3,258,251.9	1,998.6	1.8	1.4
08/03/2024 12:00	10.8	13.1	8.2	180.9	3,255,643.4	1,997.0	1.8	1.4
08/03/2024 13:00	10.8	13.1	8.2	175.0	3,260,860.3	2,000.2	1.7	1.4
08/03/2024 14:00	11.0	13.1	8.3	187.1	3,216,573.3	2,043.5	1.9	1.4
08/03/2024 15:00	10.8	13.1	8.2	183.7	3,234,230.1	2,031.1	1.8	1.4
08/03/2024 16:00	10.7	13.1	8.1	190.3	3,218,619.5	2,044.8	1.9	1.4
08/03/2024 17:00	10.8	13.0	8.1	196.3	3,230,624.3	2,123.2	2.0	1.7
08/03/2024 18:00	10.7	12.9	7.9	207.0	3,237,142.5	2,198.4	2.1	1.8
08/03/2024 19:00	10.6	13.0	7.9	207.8	3,248,363.9	2,182.3	2.1	1.7
08/03/2024 20:00	10.5	13.0	7.8	201.0	3,244,331.9	2,155.9	2.0	1.7
08/03/2024 21:00	10.5	13.0	7.8	199.9	3,261,055.9	2,143.2	2.0	1.7
08/03/2024 22:00	10.4	13.0	7.8	192.5	3,270,308.5	2,125.4	1.9	1.5
08/03/2024 23:00	10.4	12.9	7.7	210.8	3,259,082.8	2,213.3	2.1	1.8
Average/Sum#:	10.7	13.1	8.1	191.0	3,262,489.3	2,077.2	1.9	1.5
Minimum:	10.4	12.9	7.7	171.5	3,216,573.3	1,968.4	1.7	1.4
Maximum:	11.3	13.2	8.6	215.6	3,313,017.1	2,238.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/04/2024 00:00	10.0	13.2	7.7	172.1	3,260,371.2	1,999.9	1.7	1.4
08/04/2024 01:00	10.3	13.2	7.9	173.7	3,280,749.6	2,012.4	1.7	1.4
08/04/2024 02:00	10.2	13.2	7.8	166.7	3,258,395.0	1,951.1	1.7	1.4
08/04/2024 03:00	9.9	13.7	8.1	158.7	3,314,007.0	1,718.2	1.5	1.0
08/04/2024 04:00	10.4	13.6	8.4	170.3	3,318,381.6	1,744.7	1.7	1.2
08/04/2024 05:00	10.7	13.6	8.6	173.9	3,318,952.2	1,745.0	1.7	1.2
08/04/2024 06:00	10.5	13.7	8.6	158.1	3,304,170.3	1,713.1	1.5	1.0
08/04/2024 07:00	10.8	13.7	8.9	136.7	3,078,118.8	1,595.9	1.4	0.8
08/04/2024 08:00	10.8	13.7	8.9	143.3	3,085,255.3	1,599.6	1.5	1.0
08/04/2024 09:00	10.4	13.7	8.5	117.1	2,828,150.7	1,466.3	1.3	0.7
08/04/2024 10:00	10.5	13.7	8.6	150.0	3,094,899.1	1,604.6	1.5	1.0
08/04/2024 11:00	10.8	13.6	8.7	153.9	3,169,837.1	1,666.6	1.5	1.0
08/04/2024 12:00	10.4	13.8	8.6	134.2	2,967,021.9	1,538.3	1.4	0.8
08/04/2024 13:00	11.2	13.1	8.5	174.1	3,227,860.7	2,027.1	1.7	1.4
08/04/2024 14:00	11.1	13.0	8.3	189.9	3,185,467.9	2,047.0	1.9	1.4
08/04/2024 15:00	10.9	13.0	8.1	186.1	3,180,021.3	2,043.5	1.9	1.4
08/04/2024 16:00	11.1	13.0	8.3	194.7	3,174,021.4	2,086.0	2.0	1.7
08/04/2024 17:00	11.3	12.9	8.3	207.3	3,168,323.6	2,174.8	2.1	1.7
08/04/2024 18:00	11.2	12.9	8.3	212.8	3,163,516.0	2,171.5	2.2	1.7
08/04/2024 19:00	11.1	13.0	8.3	202.3	3,208,761.4	2,085.4	2.1	1.7
08/04/2024 20:00	11.4	12.9	8.4	218.6	3,242,001.8	2,201.7	2.2	1.8
08/04/2024 21:00	11.3	12.9	8.3	213.8	3,234,172.5	2,220.0	2.2	1.8
08/04/2024 22:00	11.2	12.9	8.3	219.9	3,250,343.3	2,231.1	2.2	1.8
08/04/2024 23:00	11.1	12.9	8.2	223.3	3,263,891.9	2,240.4	2.3	2.0
Average/Sum#:	10.8	13.3	8.4	177.1	3,190,695.5	1,911.8	1.8	1.3
Minimum:	9.9	12.9	7.7	117.1	2,828,150.7	1,466.3	1.3	0.7
Maximum:	11.4	13.8	8.9	223.3	3,318,952.2	2,240.4	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/05/2024 00:00	11.1	12.9	8.2	220.2	3,264,474.6	2,240.8	2.2	1.8
08/05/2024 01:00	10.9	12.9	8.0	210.6	3,311,625.4	2,224.8	2.1	1.8
08/05/2024 02:00	10.7	12.9	7.9	210.5	3,321,832.3	2,207.4	2.1	1.8
08/05/2024 03:00	10.6	13.0	7.9	205.9	3,338,808.8	2,194.3	2.0	1.8
08/05/2024 04:00	10.6	12.9	7.8	218.9	3,331,529.8	2,262.5	2.2	1.8
08/05/2024 05:00	10.7	12.9	7.9	220.3	3,334,180.3	2,264.3	2.2	1.8
08/05/2024 06:00	10.4	13.0	7.8	199.1	3,386,344.8	2,101.9	1.9	1.5
08/05/2024 07:00	11.0	13.2	8.4	175.7	3,327,194.1	1,968.0	1.7	1.4
08/05/2024 08:00	11.0	13.2	8.4	180.5	3,296,931.5	1,950.1	1.8	1.4
08/05/2024 09:00	10.7	13.2	8.2	168.7	3,307,075.4	1,956.1	1.6	1.2
08/05/2024 10:00	10.7	13.2	8.2	175.7	3,282,109.4	1,965.3	1.7	1.4
08/05/2024 11:00	10.9	13.1	8.2	181.2	3,276,021.8	2,009.5	1.8	1.4
08/05/2024 12:00	10.8	13.1	8.2	183.3	3,261,618.6	2,048.3	1.8	1.4
08/05/2024 13:00	10.7	13.1	8.1	185.6	3,258,752.3	2,046.5	1.9	1.4
08/05/2024 14:00	11.0	12.9	8.1	214.1	3,216,527.6	2,184.4	2.2	1.7
08/05/2024 15:00	10.8	13.0	8.1	187.7	3,219,249.1	2,045.2	1.9	1.4
08/05/2024 16:00	10.9	13.1	8.2	178.5	3,224,752.8	2,001.6	1.8	1.4
08/05/2024 17:00	10.9	13.1	8.2	186.8	3,228,816.1	2,027.7	1.9	1.4
08/05/2024 18:00	11.1	12.9	8.2	205.9	3,206,860.8	2,131.0	2.1	1.7
08/05/2024 19:00	10.7	13.1	8.1	178.0	3,264,120.8	2,002.2	1.8	1.4
08/05/2024 20:00	11.0	12.9	8.1	209.1	3,263,205.8	2,216.1	2.1	1.8
08/05/2024 21:00	10.9	12.9	8.0	218.6	3,249,469.2	2,230.5	2.2	1.8
08/05/2024 22:00	10.8	12.9	8.0	216.9	3,251,217.4	2,231.7	2.2	1.8
08/05/2024 23:00	10.8	12.9	8.0	207.9	3,291,232.9	2,211.1	2.1	1.8
Average/Sum#:	10.8	13.0	8.1	197.5	3,279,748.0	2,113.4	2.0	1.6
Minimum:	10.4	12.9	7.8	168.7	3,206,860.8	1,950.1	1.6	1.2
Maximum:	11.1	13.2	8.4	220.3	3,386,344.8	2,264.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/06/2024 00:00	10.3	13.2	7.9	180.9	3,316,126.4	2,034.1	1.8	1.4
08/06/2024 01:00	10.3	13.3	8.0	175.1	3,354,233.9	1,959.5	1.7	1.4
08/06/2024 02:00	10.1	13.3	7.8	167.2	3,340,197.3	1,951.3	1.6	1.2
08/06/2024 03:00	10.2	13.3	7.9	165.2	3,341,566.7	1,952.1	1.6	1.2
08/06/2024 04:00	10.4	13.1	7.9	187.4	3,344,543.6	2,124.8	1.8	1.5
08/06/2024 05:00	10.3	13.0	7.7	201.2	3,370,014.9	2,190.2	2.0	1.8
08/06/2024 06:00	10.1	13.1	7.6	208.7	3,391,222.7	2,055.4	2.0	1.6
08/06/2024 07:00	10.8	13.3	8.4	167.9	3,342,422.6	1,952.6	1.6	1.2
08/06/2024 08:00	10.6	13.2	8.1	171.5	3,341,053.1	1,951.8	1.7	1.4
08/06/2024 09:00	10.7	13.2	8.2	167.6	3,309,442.3	1,957.5	1.6	1.2
08/06/2024 10:00	10.8	13.2	8.3	178.1	3,282,276.4	1,965.4	1.8	1.4
08/06/2024 11:00	10.7	13.2	8.2	179.3	3,297,139.7	1,974.3	1.8	1.4
08/06/2024 12:00	10.8	13.1	8.2	178.7	3,274,739.2	1,984.8	1.8	1.4
08/06/2024 13:00	10.8	13.1	8.2	180.3	3,242,601.3	1,989.0	1.8	1.4
08/06/2024 14:00	10.8	13.1	8.2	186.1	3,250,263.6	1,993.7	1.9	1.4
08/06/2024 15:00	10.7	13.1	8.1	179.9	3,257,273.7	1,998.0	1.8	1.4
08/06/2024 16:00	10.7	13.0	8.0	188.2	3,244,446.5	2,084.9	1.9	1.5
08/06/2024 17:00	10.8	13.0	8.1	202.8	3,226,123.1	2,143.8	2.1	1.7
08/06/2024 18:00	11.0	12.9	8.1	218.7	3,199,499.8	2,196.2	2.3	2.0
08/06/2024 19:00	10.8	13.0	8.1	206.0	3,221,868.6	2,164.5	2.1	1.7
08/06/2024 20:00	10.9	13.0	8.1	201.2	3,248,920.9	2,111.5	2.0	1.7
08/06/2024 21:00	10.8	13.0	8.1	205.5	3,241,123.2	2,130.1	2.1	1.7
08/06/2024 22:00	10.8	13.0	8.1	212.3	3,267,205.8	2,171.1	2.1	1.7
08/06/2024 23:00	10.5	13.1	7.9	186.9	3,274,213.1	2,032.3	1.9	1.4
Average/Sum#:	10.6	13.1	8.1	187.4	3,290,771.6	2,044.5	1.9	1.5
Minimum:	10.1	12.9	7.6	165.2	3,199,499.8	1,951.3	1.6	1.2
Maximum:	11.0	13.3	8.4	218.7	3,391,222.7	2,196.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/07/2024 00:00	10.4	13.2	8.0	174.7	3,309,222.3	2,005.7	1.7	1.4
08/07/2024 01:00	10.8	13.0	8.1	211.0	3,306,934.2	2,197.5	2.1	1.8
08/07/2024 02:00	10.3	13.1	7.8	190.2	3,284,707.7	2,062.8	1.9	1.4
08/07/2024 03:00	10.2	13.3	7.9	174.1	3,306,906.3	1,956.0	1.7	1.4
08/07/2024 04:00	10.2	13.3	7.9	168.4	3,325,672.5	1,967.1	1.6	1.2
08/07/2024 05:00	10.4	13.1	7.9	190.7	3,316,210.7	2,106.8	1.9	1.5
08/07/2024 06:00	10.2	13.0	7.6	179.2	3,389,006.9	2,128.3	1.7	1.5
08/07/2024 07:00	10.7	13.2	8.2	176.1	3,312,147.3	1,959.1	1.7	1.4
08/07/2024 08:00	10.6	13.2	8.1	173.6	3,318,402.7	1,962.8	1.7	1.4
08/07/2024 09:00	10.7	13.2	8.2	180.9	3,329,053.8	1,969.1	1.8	1.4
08/07/2024 10:00	10.7	13.2	8.2	174.8	3,305,656.9	1,979.4	1.7	1.4
08/07/2024 11:00	10.9	13.2	8.4	184.0	3,240,808.0	1,987.9	1.8	1.4
08/07/2024 12:00	11.0	13.1	8.3	190.7	3,219,436.2	1,998.3	1.9	1.4
08/07/2024 13:00	10.8	13.1	8.2	187.0	3,231,204.6	2,029.2	1.9	1.4
08/07/2024 14:00	10.9	13.0	8.1	191.7	3,222,504.6	2,070.8	1.9	1.4
08/07/2024 15:00	10.7	13.1	8.1	189.6	3,213,582.6	2,041.6	1.9	1.4
08/07/2024 16:00	10.8	13.1	8.2	191.1	3,206,971.5	2,037.4	1.9	1.4
08/07/2024 17:00	11.2	12.9	8.3	213.5	3,194,182.4	2,145.9	2.2	1.7
08/07/2024 18:00	11.0	12.9	8.1	213.9	3,193,235.4	2,191.9	2.2	1.8
08/07/2024 19:00	11.1	12.9	8.2	206.8	3,218,147.3	2,162.0	2.1	1.7
08/07/2024 20:00	11.0	13.0	8.2	204.9	3,223,168.5	2,118.3	2.1	1.7
08/07/2024 21:00	10.8	13.1	8.2	198.1	3,246,480.2	2,062.5	2.0	1.7
08/07/2024 22:00	10.6	13.2	8.1	179.6	3,287,286.5	1,968.4	1.8	1.4
08/07/2024 23:00	10.9	13.0	8.1	208.4	3,285,715.6	2,183.4	2.1	1.7
Average/Sum#:	10.7	13.1	8.1	189.7	3,270,276.9	2,053.8	1.9	1.5
Minimum:	10.2	12.9	7.6	168.4	3,193,235.4	1,956.0	1.6	1.2
Maximum:	11.2	13.3	8.4	213.9	3,389,006.9	2,197.5	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/08/2024 00:00	10.6	12.9	7.8	220.8	3,301,343.5	2,242.0	2.2	1.8
08/08/2024 01:00	10.1	13.1	7.6	189.4	3,291,025.9	2,090.8	1.9	1.5
08/08/2024 02:00	9.6	13.7	7.9	146.6	3,199,245.4	1,658.7	1.5	1.0
08/08/2024 03:00	9.9	13.7	8.1	155.3	3,269,645.4	1,695.2	1.5	1.0
08/08/2024 04:00	10.0	13.7	8.2	148.4	3,212,168.1	1,665.4	1.5	1.0
08/08/2024 05:00	10.0	13.7	8.2	156.7	3,341,202.6	1,732.3	1.5	1.0
08/08/2024 06:00	9.9	13.7	8.1	167.1	3,333,101.8	1,728.1	1.6	1.0
08/08/2024 07:00	10.5	13.7	8.6	145.1	3,217,954.4	1,668.4	1.4	0.8
08/08/2024 08:00	10.0	13.8	8.3	130.0	3,016,591.2	1,564.0	1.4	0.8
08/08/2024 09:00	10.0	13.8	8.3	130.8	3,001,353.9	1,556.1	1.4	0.8
08/08/2024 10:00	10.1	13.7	8.3	127.1	2,989,974.2	1,550.2	1.3	0.8
08/08/2024 11:00	9.9	13.8	8.2	99.2	2,622,447.7	1,340.5	1.2	0.7
08/08/2024 12:00	9.9	13.9	8.3	99.7	2,636,042.7	1,328.2	1.2	0.7
08/08/2024 13:00	9.9	13.9	8.3	100.8	2,641,004.4	1,330.7	1.2	0.7
08/08/2024 14:00	10.6	13.7	8.7	144.7	2,927,482.2	1,517.8	1.6	0.9
08/08/2024 15:00	11.6	13.1	8.8	187.1	3,182,573.7	2,021.9	1.9	1.4
08/08/2024 16:00	11.1	13.1	8.4	197.9	3,185,312.2	2,046.9	2.0	1.6
08/08/2024 17:00	11.1	13.0	8.3	192.5	3,208,965.9	2,062.1	2.0	1.6
08/08/2024 18:00	11.3	12.9	8.3	214.1	3,180,706.7	2,183.3	2.2	1.7
08/08/2024 19:00	10.9	12.9	8.0	215.8	3,183,396.3	2,161.9	2.2	1.7
08/08/2024 20:00	10.7	13.0	8.0	201.6	3,226,972.5	2,120.8	2.1	1.7
08/08/2024 21:00	10.6	13.0	7.9	189.5	3,245,380.2	2,085.5	1.9	1.5
08/08/2024 22:00	10.5	13.1	7.9	185.0	3,261,324.4	2,024.3	1.9	1.4
08/08/2024 23:00	10.6	13.1	8.0	201.4	3,274,813.1	2,080.5	2.0	1.7
Average/Sum#:	10.4	13.4	8.2	164.4	3,122,917.9	1,810.7	1.7	1.2
Minimum:	9.6	12.9	7.6	99.2	2,622,447.7	1,328.2	1.2	0.7
Maximum:	11.6	13.9	8.8	220.8	3,341,202.6	2,242.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/09/2024 00:00	9.8	13.7	8.0	151.1	3,087,955.5	1,601.0	1.6	1.0
08/09/2024 01:00	10.2	13.7	8.4	160.0	3,271,381.3	1,696.1	1.6	1.0
08/09/2024 02:00	10.2	13.7	8.4	160.4	3,325,193.9	1,724.0	1.5	1.0
08/09/2024 03:00	10.2	13.7	8.4	154.6	3,296,455.2	1,709.1	1.5	1.0
08/09/2024 04:00	10.2	13.7	8.4	163.9	3,363,190.6	1,743.7	1.6	1.0
08/09/2024 05:00	10.1	13.7	8.3	160.7	3,362,804.8	1,743.5	1.5	1.0
08/09/2024 06:00	10.2	13.7	8.4	151.7	3,294,912.2	1,708.3	1.5	1.0
08/09/2024 07:00	10.5	13.7	8.6	128.4	2,992,481.6	1,551.5	1.4	0.8
08/09/2024 08:00	10.0	13.8	8.3	114.6	2,848,011.5	1,455.8	1.3	0.7
08/09/2024 09:00	10.1	13.8	8.4	129.9	2,992,583.5	1,529.7	1.4	0.8
08/09/2024 10:00	10.2	13.8	8.5	134.4	3,055,185.8	1,561.7	1.4	0.8
08/09/2024 11:00	10.2	13.8	8.5	135.0	3,091,377.7	1,580.2	1.4	0.8
08/09/2024 12:00	10.5	13.7	8.6	161.6	3,158,934.2	1,637.8	1.6	1.0
08/09/2024 13:00	10.6	13.7	8.7	162.8	3,266,173.6	1,693.4	1.6	1.0
08/09/2024 14:00	10.5	13.7	8.6	148.4	3,032,133.8	1,594.2	1.6	1.0
08/09/2024 15:00	11.4	13.1	8.6	182.9	3,202,701.5	2,011.3	1.9	1.4
08/09/2024 16:00	11.2	13.0	8.4	199.2	3,212,545.1	2,064.4	2.0	1.7
08/09/2024 17:00	11.2	12.9	8.3	203.8	3,173,789.9	2,132.2	2.1	1.7
08/09/2024 18:00	11.0	12.9	8.1	208.5	3,186,534.0	2,187.3	2.2	1.7
08/09/2024 19:00	10.8	13.0	8.1	204.9	3,225,220.2	2,143.2	2.1	1.7
08/09/2024 20:00	10.7	13.0	8.0	198.1	3,203,068.2	2,081.7	2.0	1.7
08/09/2024 21:00	18.3	15.7	20.8	128.9	1,716,262.2	689.3	2.3	0.6
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.6	8.9	161.1	3,107,222.6	1,720.0	1.7	1.1
Minimum:	9.8	12.9	8.0	114.6	1,716,262.2	689.3	1.3	0.6
Maximum:	18.3	15.7	20.8	208.5	3,363,190.6	2,187.3	2.3	1.7
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2024 13:00	30.9	17.4	52.1	23.5	1,440,715.0	357.7	0.5	0.1
08/10/2024 14:00	34.9	17.0	52.8	249.0	1,543,235.9	439.5	4.9	0.8
08/10/2024 15:00	27.9	15.2	28.9	215.6	2,389,156.5	977.0	2.8	1.1
08/10/2024 16:00	10.3	13.7	8.4	167.0	3,176,303.8	1,670.0	1.7	1.2
08/10/2024 17:00	11.4	13.1	8.6	226.3	3,288,822.2	2,089.4	2.3	1.9
08/10/2024 18:00	11.5	13.0	8.6	230.3	3,230,788.1	2,146.9	2.3	1.9
08/10/2024 19:00	11.6	13.0	8.7	218.1	3,211,977.4	2,134.4	2.2	1.7
08/10/2024 20:00	11.8	13.0	8.8	219.2	3,221,909.5	2,141.0	2.2	1.7
08/10/2024 21:00	11.6	13.0	8.7	213.3	3,241,956.6	2,083.3	2.2	1.7
08/10/2024 22:00	11.3	13.1	8.5	202.3	3,240,482.0	1,987.7	2.0	1.6
08/10/2024 23:00	20.4	16.0	24.6	165.3	1,583,623.0	612.9	3.2	0.7
Average/Sum#:	17.6	14.3	19.9	193.6	2,688,088.2	1,512.7	2.4	1.3
Minimum:	10.3	13.0	8.4	23.5	1,440,715.0	357.7	0.5	0.1
Maximum:	34.9	17.4	52.8	249.0	3,288,822.2	2,146.9	4.9	1.9
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/12/2024 18:00	26.9	17.3	44.1	0.0	1,342,035.9	333.2	-0.1	0.0
08/12/2024 19:00	37.8	16.2	47.5	205.8	1,725,474.7	592.2	3.7	0.8
08/12/2024 20:00	12.5	13.8	10.4	161.8	2,924,699.2	1,495.0	1.8	1.0
08/12/2024 21:00	10.5	13.7	8.6	171.2	3,301,084.3	1,711.5	1.7	1.2
08/12/2024 22:00	10.2	13.7	8.4	148.2	3,241,871.1	1,680.8	1.5	1.0
08/12/2024 23:00	10.1	13.7	8.3	150.9	3,305,520.4	1,713.8	1.5	1.0
Average/Sum#:	18.0	14.7	21.2	139.7	2,640,114.3	1,254.4	1.7	0.8
Minimum:	10.1	13.7	8.3	0.0	1,342,035.9	333.2	-0.1	0.0
Maximum:	37.8	17.3	47.5	205.8	3,305,520.4	1,713.8	3.7	1.2
%SI	75.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/13/2024 00:00	10.0	13.7	8.2	146.7	3,233,384.6	1,676.4	1.4	0.8
08/13/2024 01:00	9.7	13.8	8.1	97.7	2,631,838.0	1,345.3	1.2	0.7
08/13/2024 02:00	21.7	15.9	25.6	127.9	1,629,361.4	642.5	2.3	0.6
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2024 16:00	32.4	17.3	53.1	24.2	1,418,965.3	352.3	0.6	0.1
08/13/2024 17:00	34.0	17.1	52.8	248.8	1,522,944.1	422.6	4.9	0.8
08/13/2024 18:00	28.7	15.3	30.2	224.7	2,305,612.7	926.0	3.0	1.1
08/13/2024 19:00	10.9	13.4	8.6	187.7	3,187,735.4	1,792.4	1.9	1.3
08/13/2024 20:00	11.3	13.1	8.5	199.1	3,299,986.7	2,024.2	2.0	1.6
08/13/2024 21:00	11.4	13.1	8.6	216.4	3,280,249.1	2,060.0	2.2	1.6
08/13/2024 22:00	10.5	13.5	8.4	155.2	2,984,989.5	1,678.4	1.7	1.2
08/13/2024 23:00	10.1	13.7	8.3	129.9	3,109,172.0	1,612.0	1.3	0.8
Average/Sum#:	17.3	14.5	20.0	159.8	2,600,385.3	1,321.1	2.0	1.0
Minimum:	9.7	13.1	8.1	24.2	1,418,965.3	352.3	0.6	0.1
Maximum:	34.0	17.3	53.1	248.8	3,299,986.7	2,060.0	4.9	1.6
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/14/2024 00:00	9.9	13.8	8.2	147.1	3,226,950.7	1,649.5	1.5	1.0
08/14/2024 01:00	9.8	13.8	8.1	119.4	3,003,343.3	1,535.2	1.3	0.8
08/14/2024 02:00	16.0	15.1	16.3	115.1	2,166,885.9	949.4	1.6	0.6
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2024 10:00	30.9	17.5	53.6	0.0	1,406,227.7	328.6	-0.1	0.0
08/14/2024 11:00	30.7	15.7	34.8	189.2	2,128,138.2	808.1	2.8	0.9
08/14/2024 12:00	10.2	13.8	8.5	134.6	2,928,446.5	1,518.3	1.5	0.9
08/14/2024 13:00	10.5	13.8	8.7	143.3	3,013,890.9	1,562.6	1.5	0.9
08/14/2024 14:00	10.4	13.8	8.6	131.4	2,928,446.5	1,518.3	1.4	0.8
08/14/2024 15:00	10.3	13.8	8.6	119.6	2,851,532.8	1,457.6	1.3	0.7
08/14/2024 16:00	10.7	13.7	8.8	169.6	3,128,652.5	1,622.1	1.7	1.1
08/14/2024 17:00	11.3	13.5	9.0	184.4	3,237,469.3	1,725.8	1.8	1.2
08/14/2024 18:00	11.3	13.5	9.0	185.2	3,247,036.5	1,730.9	1.8	1.2
08/14/2024 19:00	10.9	13.6	8.8	173.6	3,269,360.0	1,742.8	1.7	1.2
08/14/2024 20:00	10.5	13.7	8.6	169.8	3,291,753.9	1,730.7	1.7	1.2
08/14/2024 21:00	10.4	13.7	8.5	164.0	3,341,395.5	1,732.4	1.6	1.0
08/14/2024 22:00	10.3	13.8	8.6	163.2	3,356,247.0	1,740.1	1.6	1.0
08/14/2024 23:00	10.4	13.7	8.5	164.1	3,369,735.0	1,771.7	1.6	1.1
Average/Sum#:	13.2	14.1	13.2	145.5	2,935,030.1	1,477.9	1.5	0.9
Minimum:	9.8	13.5	8.1	0.0	1,406,227.7	328.6	-0.1	0.0
Maximum:	30.9	17.5	53.6	189.2	3,369,735.0	1,771.7	2.8	1.2
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/15/2024 00:00	15.6	14.9	15.3	137.7	2,487,714.0	1,126.3	1.7	0.8
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2024 12:00	32.5	17.4	54.8	38.5	1,456,020.3	361.5	0.7	0.1
08/15/2024 13:00	34.4	17.1	53.4	254.5	1,530,151.6	424.6	5.0	0.8
08/15/2024 14:00	32.8	15.3	34.6	226.5	2,215,977.6	890.0	3.2	1.1
08/15/2024 15:00	10.3	13.7	8.4	144.7	3,095,863.5	1,605.1	1.5	1.0
08/15/2024 16:00	10.7	13.6	8.6	165.4	3,232,031.7	1,699.3	1.6	1.0
08/15/2024 17:00	10.6	13.7	8.7	165.0	3,255,179.6	1,687.7	1.6	1.0
08/15/2024 18:00	10.3	13.8	8.6	133.5	2,830,850.9	1,467.7	1.5	0.9
08/15/2024 19:00	11.1	13.4	8.7	159.0	3,193,782.2	1,795.8	1.6	1.1
08/15/2024 20:00	11.2	13.0	8.4	203.2	3,215,560.6	2,113.3	2.1	1.7
08/15/2024 21:00	10.2	13.7	8.4	158.0	3,257,494.1	1,688.9	1.6	1.0
08/15/2024 22:00	10.1	13.8	8.4	143.9	3,226,055.2	1,672.6	1.4	0.8
08/15/2024 23:00	10.2	13.7	8.4	149.3	3,263,666.2	1,692.1	1.5	1.0
Average/Sum#:	16.2	14.4	18.1	159.9	2,789,257.5	1,401.9	1.9	0.9
Minimum:	10.1	13.0	8.4	38.5	1,456,020.3	361.5	0.7	0.1
Maximum:	34.4	17.4	54.8	254.5	3,263,666.2	2,113.3	5.0	1.7
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/16/2024 00:00	10.3	13.7	8.4	161.5	3,298,981.4	1,734.5	1.6	1.0
08/16/2024 01:00	10.0	13.7	8.2	151.1	3,243,992.8	1,681.9	1.5	1.0
08/16/2024 02:00	15.6	15.0	15.6	125.1	2,377,549.0	1,041.7	1.6	0.6
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2024 12:00	35.5	16.9	52.4	153.1	1,618,803.8	449.2	2.7	0.4
08/16/2024 13:00	23.9	14.4	21.7	219.1	2,648,466.8	1,257.1	2.7	1.3
08/16/2024 14:00	10.0	13.9	8.4	98.7	2,664,225.1	1,342.4	1.1	0.5
08/16/2024 15:00	10.5	13.7	8.6	158.5	3,036,071.7	1,574.1	1.7	1.1
08/16/2024 16:00	11.6	13.0	8.7	188.3	3,232,918.6	2,101.1	1.9	1.5
08/16/2024 17:00	11.3	13.0	8.4	193.7	3,210,761.6	2,086.7	2.0	1.7
08/16/2024 18:00	11.3	13.0	8.4	208.8	3,211,375.4	2,134.0	2.1	1.7
08/16/2024 19:00	11.0	13.0	8.2	201.9	3,238,765.6	2,104.9	2.0	1.7
08/16/2024 20:00	11.1	13.0	8.3	211.0	3,229,283.3	2,145.9	2.1	1.7
08/16/2024 21:00	10.9	13.0	8.1	196.1	3,257,229.8	2,116.9	2.0	1.7
08/16/2024 22:00	10.9	13.0	8.1	206.9	3,306,703.4	2,173.2	2.1	1.7
08/16/2024 23:00	10.8	13.0	8.1	194.8	3,314,159.2	2,178.1	1.9	1.5
Average/Sum#:	13.6	13.7	12.6	177.9	2,992,619.2	1,741.4	1.9	1.3
Minimum:	10.0	13.0	8.1	98.7	1,618,803.8	449.2	1.1	0.4
Maximum:	35.5	16.9	52.4	219.1	3,314,159.2	2,178.1	2.7	1.7
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/17/2024 00:00	10.7	13.0	8.0	199.5	3,297,697.0	2,143.2	2.0	1.7
08/17/2024 01:00	10.4	13.2	8.0	178.5	3,345,114.9	1,978.6	1.7	1.4
08/17/2024 02:00	10.3	13.3	8.0	174.5	3,351,276.2	1,933.3	1.7	1.4
08/17/2024 03:00	10.3	13.3	8.0	162.9	3,339,142.0	1,926.3	1.6	1.2
08/17/2024 04:00	10.4	13.2	8.0	177.2	3,345,069.6	2,003.0	1.7	1.4
08/17/2024 05:00	10.2	13.2	7.8	177.6	3,361,101.8	2,012.6	1.7	1.4
08/17/2024 06:00	14.6	14.7	13.9	167.0	795,314.5	1,213.8	7.1	3.3
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2024 14:00	18.2	18.0	37.0	0.0	1,129,449.1	173.2	-0.5	0.0
08/17/2024 15:00	36.3	15.8	42.0	191.1	2,098,505.9	766.2	2.8	0.8
08/17/2024 16:00	10.4	13.7	8.5	144.1	3,058,445.4	1,585.7	1.5	1.0
08/17/2024 17:00	11.2	13.3	8.7	198.8	3,281,140.8	1,916.8	2.0	1.5
08/17/2024 18:00	11.3	13.2	8.7	196.9	3,297,867.4	2,022.9	1.9	1.4
08/17/2024 19:00	11.0	13.2	8.4	186.3	3,318,850.1	1,987.3	1.8	1.4
08/17/2024 20:00	11.0	13.2	8.4	188.6	3,312,671.0	1,983.6	1.9	1.4
08/17/2024 21:00	10.9	13.2	8.4	185.8	3,336,999.8	1,973.8	1.8	1.4
08/17/2024 22:00	10.7	13.3	8.3	185.7	3,340,882.0	1,951.7	1.8	1.4
08/17/2024 23:00	10.1	13.7	8.3	155.5	3,325,386.7	1,724.1	1.5	1.0
Average/Sum#:	12.8	13.8	12.3	168.8	3,096,225.0	1,723.3	1.7	1.2
Minimum:	10.1	13.0	7.8	0.0	1,129,449.1	173.2	-0.5	0.0
Maximum:	36.3	18.0	42.0	199.5	3,361,101.8	2,143.2	2.8	1.7
%SI	29.17	29.17	29.17	29.17	33.33	29.17	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/18/2024 00:00	10.4	13.5	8.3	189.4	3,367,243.4	1,967.1	1.8	1.4
08/18/2024 01:00	10.2	13.6	8.2	183.8	3,304,421.0	1,930.4	1.8	1.4
08/18/2024 02:00	21.2	16.1	26.1	139.4	1,533,218.3	571.0	2.7	0.6
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2024 14:00	31.3	17.5	54.3	10.5	1,511,930.1	353.3	0.1	0.0
08/18/2024 15:00	29.0	15.0	29.0	196.7	2,345,021.2	993.2	2.6	1.0
08/18/2024 16:00	10.3	13.7	8.4	158.7	3,179,379.1	1,648.4	1.6	1.0
08/18/2024 17:00	10.4	13.7	8.5	152.6	3,173,070.4	1,668.3	1.5	1.0
08/18/2024 18:00	11.1	13.1	8.4	177.5	3,352,995.3	2,081.2	1.7	1.5
08/18/2024 19:00	11.0	12.9	8.1	195.1	3,299,723.8	2,240.9	1.9	1.6
08/18/2024 20:00	10.8	13.0	8.1	209.1	3,323,533.4	2,232.8	2.1	1.8
08/18/2024 21:00	10.7	13.0	8.0	212.5	3,301,057.0	2,217.7	2.1	1.8
08/18/2024 22:00	10.5	13.1	7.9	197.8	3,321,632.2	2,134.5	2.0	1.7
08/18/2024 23:00	10.4	13.1	7.9	202.8	3,286,774.1	2,112.1	2.0	1.7
Average/Sum#:	14.4	13.9	14.7	171.2	2,946,153.8	1,703.9	1.8	1.3
Minimum:	10.2	12.9	7.9	10.5	1,511,930.1	353.3	0.1	0.0
Maximum:	31.3	17.5	54.3	212.5	3,367,243.4	2,240.9	2.7	1.8
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/19/2024 00:00	20.1	16.1	24.7	137.8	1,504,523.4	571.3	2.8	0.6
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2024 07:00	31.5	16.6	43.2	132.7	1,932,892.4	578.7	2.1	0.5
08/19/2024 08:00	9.7	13.8	8.1	127.0	2,916,488.2	1,512.1	1.4	0.8
08/19/2024 09:00	9.8	13.8	8.1	123.7	3,023,297.8	1,545.4	1.3	0.8
08/19/2024 10:00	9.9	13.8	8.2	126.0	3,047,947.4	1,558.0	1.3	0.8
08/19/2024 11:00	10.1	13.8	8.4	131.7	3,007,718.9	1,559.4	1.4	0.8
08/19/2024 12:00	10.3	13.7	8.4	156.5	3,204,838.8	1,661.6	1.6	1.0
08/19/2024 13:00	10.0	13.8	8.3	115.9	2,843,511.9	1,453.5	1.3	0.7
08/19/2024 14:00	10.3	13.8	8.6	150.4	3,169,542.4	1,643.3	1.5	1.0
08/19/2024 15:00	10.0	13.8	8.3	134.8	2,960,108.6	1,513.1	1.4	0.8
08/19/2024 16:00	11.0	13.2	8.4	164.0	3,234,976.4	1,960.7	1.6	1.2
08/19/2024 17:00	10.8	13.1	8.2	180.5	3,322,973.5	2,038.3	1.8	1.4
08/19/2024 18:00	10.9	12.9	8.0	209.7	3,263,993.2	2,192.8	2.1	1.8
08/19/2024 19:00	10.6	13.2	8.1	181.1	3,306,912.4	2,004.3	1.8	1.4
08/19/2024 20:00	10.5	13.3	8.2	164.9	3,296,889.2	1,926.0	1.6	1.2
08/19/2024 21:00	11.0	13.0	8.2	210.1	3,292,126.0	2,211.7	2.1	1.8
08/19/2024 22:00	10.6	13.0	7.9	201.9	3,303,697.9	2,147.1	2.0	1.7
08/19/2024 23:00	10.2	13.3	7.9	172.3	3,287,294.8	1,944.4	1.7	1.4
Average/Sum#:	12.1	13.8	11.1	156.7	2,995,540.7	1,667.9	1.7	1.1
Minimum:	9.7	12.9	7.9	115.9	1,504,523.4	571.3	1.3	0.5
Maximum:	31.5	16.6	43.2	210.1	3,322,973.5	2,211.7	2.8	1.8
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/20/2024 00:00	10.3	13.3	8.0	163.9	3,277,431.2	1,890.7	1.6	1.1
08/20/2024 01:00	21.0	15.8	24.3	137.2	1,713,555.7	675.7	2.4	0.6
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2024 13:00	35.0	17.3	57.4	110.7	1,510,670.7	386.1	2.1	0.3
08/20/2024 14:00	29.5	14.7	28.1	207.3	2,355,634.4	1,049.3	2.8	1.2
08/20/2024 15:00	9.6	13.9	8.1	94.8	2,634,851.9	1,327.6	1.1	0.5
08/20/2024 16:00	10.2	13.8	8.5	135.2	3,041,882.8	1,554.9	1.4	0.8
08/20/2024 17:00	11.3	13.0	8.4	196.8	3,286,774.1	2,112.1	2.0	1.7
08/20/2024 18:00	10.9	13.2	8.4	183.2	3,237,641.5	2,009.6	1.8	1.4
08/20/2024 19:00	10.7	13.3	8.3	190.3	3,290,778.8	1,898.4	1.9	1.3
08/20/2024 20:00	10.6	13.3	8.2	163.0	3,281,418.2	1,893.0	1.6	1.1
08/20/2024 21:00	10.8	13.2	8.3	190.4	3,307,401.6	2,052.9	1.9	1.4
08/20/2024 22:00	10.7	13.1	8.1	196.5	3,272,924.3	2,103.2	2.0	1.7
08/20/2024 23:00	10.6	13.1	8.0	187.3	3,305,249.1	2,075.7	1.8	1.5
Average/Sum#:	14.7	13.9	14.8	165.9	2,885,862.6	1,617.6	1.9	1.1
Minimum:	9.6	13.0	8.0	94.8	1,510,670.7	386.1	1.1	0.3
Maximum:	35.0	17.3	57.4	207.3	3,307,401.6	2,112.1	2.8	1.7
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/21/2024 00:00	10.3	13.2	7.9	168.6	3,301,648.8	1,977.0	1.7	1.4
08/21/2024 01:00	10.3	13.3	8.0	178.6	3,350,236.1	1,932.7	1.7	1.4
08/21/2024 02:00	9.8	13.7	8.0	153.6	3,230,510.2	1,698.5	1.5	1.0
08/21/2024 03:00	9.8	13.7	8.0	145.2	3,302,820.2	1,712.4	1.4	0.9
08/21/2024 04:00	9.9	13.7	8.1	157.6	3,322,879.3	1,722.8	1.5	1.0
08/21/2024 05:00	10.0	13.7	8.2	158.2	3,344,288.6	1,733.9	1.5	1.0
08/21/2024 06:00	9.9	13.7	8.1	153.9	3,336,380.7	1,729.8	1.5	1.0
08/21/2024 07:00	10.2	13.8	8.5	130.2	3,116,308.4	1,615.7	1.3	0.8
08/21/2024 08:00	10.0	13.8	8.3	135.2	3,103,192.8	1,608.9	1.4	0.8
08/21/2024 09:00	9.6	13.8	8.0	93.0	2,591,537.8	1,324.7	1.1	0.5
08/21/2024 10:00	9.7	13.8	8.1	125.6	2,996,496.2	1,531.7	1.3	0.8
08/21/2024 11:00	9.7	13.8	8.1	129.2	3,082,378.7	1,575.6	1.3	0.8
08/21/2024 12:00	9.9	13.8	8.2	145.3	3,228,515.8	1,650.3	1.4	0.8
08/21/2024 13:00	10.4	13.7	8.5	164.5	3,295,557.8	1,732.7	1.6	1.0
08/21/2024 14:00	10.7	13.6	8.6	171.1	3,318,191.4	1,744.6	1.7	1.2
08/21/2024 15:00	10.5	13.7	8.6	167.6	3,279,581.2	1,724.3	1.6	1.0
08/21/2024 16:00	10.4	13.7	8.5	143.7	3,100,299.7	1,607.4	1.5	1.0
08/21/2024 17:00	11.1	13.1	8.4	186.2	3,275,757.6	2,081.1	1.8	1.5
08/21/2024 18:00	10.8	12.9	8.0	210.1	3,253,340.0	2,209.4	2.1	1.8
08/21/2024 19:00	10.7	13.0	8.0	204.2	3,256,699.6	2,187.9	2.1	1.8
08/21/2024 20:00	10.6	13.0	7.9	199.5	3,326,008.7	2,161.6	2.0	1.7
08/21/2024 21:00	10.7	13.0	8.0	207.8	3,308,138.0	2,198.3	2.1	1.8
08/21/2024 22:00	10.7	13.0	8.0	207.3	3,301,834.3	2,170.0	2.1	1.7
08/21/2024 23:00	10.5	13.1	7.9	197.8	3,300,468.4	2,120.9	2.0	1.7
Average/Sum#:	10.3	13.5	8.2	163.9	3,221,794.6	1,823.0	1.6	1.2
Minimum:	9.6	12.9	7.9	93.0	2,591,537.8	1,324.7	1.1	0.5
Maximum:	11.1	13.8	8.6	210.1	3,350,236.1	2,209.4	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/22/2024 00:00	10.3	13.2	7.9	181.1	3,345,737.6	2,003.4	1.8	1.4
08/22/2024 01:00	10.3	13.2	7.9	174.3	3,344,607.7	1,978.3	1.7	1.4
08/22/2024 02:00	10.2	13.2	7.8	177.8	3,383,847.7	1,976.8	1.7	1.4
08/22/2024 03:00	10.2	13.3	7.9	164.9	3,382,135.9	1,975.8	1.6	1.2
08/22/2024 04:00	10.2	13.3	7.9	178.1	3,392,748.9	1,982.0	1.7	1.4
08/22/2024 05:00	10.4	13.1	7.9	187.8	3,337,775.2	2,120.5	1.8	1.5
08/22/2024 06:00	18.5	15.9	21.8	130.0	435,791.5	665.1	10.0	2.5
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.4	13.6	9.9	170.6	3,364,475.5	1,814.6	1.7	1.4
Minimum:	10.2	13.1	7.8	130.0	3,337,775.2	665.1	1.6	1.2
Maximum:	18.5	15.9	21.8	187.8	3,392,748.9	2,120.5	1.8	1.5
%SI	70.83	70.83	70.83	70.83	75.00	70.83	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/23/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/26/2024 00:00	15.2	18.3	34.5	0.0	699,547.6	122.6	-0.1	0.0
08/26/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2024 07:00	33.1	17.3	54.2	15.3	1,487,033.8	369.2	0.3	0.0
08/26/2024 08:00	24.0	14.4	21.8	204.8	838,035.3	1,279.0	8.1	4.0
08/26/2024 09:00	10.3	13.7	8.4	157.1	3,338,116.6	1,730.7	1.5	1.0
08/26/2024 10:00	10.2	13.7	8.4	153.4	3,320,179.1	1,721.4	1.5	1.0
08/26/2024 11:00	10.2	13.7	8.4	153.2	3,322,686.5	1,722.7	1.5	1.0
08/26/2024 12:00	10.8	13.4	8.5	171.4	3,264,321.5	1,859.3	1.7	1.3
08/26/2024 13:00	10.8	13.2	8.3	177.2	3,359,214.5	2,036.0	1.7	1.4
08/26/2024 14:00	10.8	13.1	8.2	189.7	3,296,172.6	2,070.0	1.9	1.4
08/26/2024 15:00	10.7	13.2	8.2	180.3	3,319,386.9	2,036.1	1.8	1.4
08/26/2024 16:00	10.9	13.0	8.1	198.5	3,300,928.2	2,145.3	2.0	1.7
08/26/2024 17:00	10.9	12.9	8.0	219.6	3,300,901.8	2,241.7	2.2	1.8
08/26/2024 18:00	10.8	12.9	8.0	210.6	3,271,482.8	2,269.5	2.1	1.8
08/26/2024 19:00	10.7	12.9	7.9	220.0	3,283,447.2	2,277.8	2.2	1.8
08/26/2024 20:00	10.5	13.0	7.8	211.9	3,327,105.9	2,235.2	2.1	1.8
08/26/2024 21:00	10.5	13.0	7.8	205.7	3,331,273.7	2,238.0	2.0	1.8
08/26/2024 22:00	10.3	13.0	7.7	205.0	3,328,002.2	2,211.5	2.0	1.8
08/26/2024 23:00	10.0	13.3	7.8	179.6	3,369,967.4	1,993.3	1.7	1.4
Average/Sum#:	12.8	13.8	12.9	169.6	3,054,104.0	1,808.9	1.7	1.3
Minimum:	10.0	12.9	7.7	0.0	699,547.6	122.6	-0.1	0.0
Maximum:	33.1	18.3	54.2	220.0	3,369,967.4	2,277.8	2.2	1.8
%SI	25.00	25.00	25.00	25.00	29.17	25.00	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/27/2024 00:00	10.1	13.3	7.8	169.0	3,394,289.5	1,982.9	1.6	1.2
08/27/2024 01:00	10.1	13.3	7.8	167.5	3,402,677.2	1,987.8	1.6	1.2
08/27/2024 02:00	10.2	13.3	7.9	178.0	3,403,533.1	1,988.3	1.7	1.4
08/27/2024 03:00	10.1	13.3	7.8	166.8	3,363,204.8	1,989.3	1.6	1.2
08/27/2024 04:00	10.0	13.3	7.8	167.9	3,377,685.2	1,973.2	1.6	1.2
08/27/2024 05:00	9.7	13.8	8.1	152.3	3,306,677.7	1,714.4	1.5	1.0
08/27/2024 06:00	9.9	13.8	8.2	151.7	3,272,152.8	1,696.5	1.5	1.0
08/27/2024 07:00	10.3	13.8	8.6	132.6	3,078,311.7	1,596.0	1.4	0.8
08/27/2024 08:00	9.9	13.9	8.3	96.8	2,571,974.6	1,314.7	1.2	0.7
08/27/2024 09:00	9.8	13.9	8.3	96.0	2,602,303.3	1,311.2	1.1	0.5
08/27/2024 10:00	9.7	13.9	8.2	97.2	2,611,234.3	1,315.7	1.2	0.7
08/27/2024 11:00	9.6	13.9	8.1	96.8	2,631,081.0	1,325.7	1.1	0.5
08/27/2024 12:00	10.1	13.8	8.4	147.7	3,150,263.0	1,610.3	1.5	1.0
08/27/2024 13:00	10.4	13.7	8.5	156.1	3,185,165.4	1,651.4	1.6	1.0
08/27/2024 14:00	10.5	13.7	8.6	165.4	3,260,941.8	1,714.5	1.6	1.0
08/27/2024 15:00	10.2	13.8	8.5	133.3	3,060,952.8	1,587.0	1.4	0.8
08/27/2024 16:00	11.0	13.2	8.4	180.7	3,185,809.1	1,930.9	1.8	1.4
08/27/2024 17:00	10.8	12.9	8.0	208.1	3,267,714.5	2,195.3	2.1	1.8
08/27/2024 18:00	10.5	13.0	7.8	201.2	3,310,811.7	2,175.9	2.0	1.7
08/27/2024 19:00	10.4	12.9	7.7	203.8	3,314,007.0	2,202.2	2.0	1.8
08/27/2024 20:00	10.5	12.9	7.7	216.0	3,308,499.5	2,222.7	2.2	1.8
08/27/2024 21:00	10.4	12.9	7.7	208.9	3,317,618.7	2,204.6	2.1	1.8
08/27/2024 22:00	10.2	13.1	7.7	190.6	3,333,115.3	2,093.2	1.9	1.5
08/27/2024 23:00	10.2	13.0	7.6	193.5	3,374,074.9	2,168.2	1.9	1.5
Average/Sum#:	10.2	13.4	8.1	161.6	3,170,170.8	1,831.3	1.6	1.2
Minimum:	9.6	12.9	7.6	96.0	2,571,974.6	1,311.2	1.1	0.5
Maximum:	11.0	13.9	8.6	216.0	3,403,533.1	2,222.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/28/2024 00:00	10.1	13.1	7.6	189.2	3,366,554.7	2,114.2	1.8	1.5
08/28/2024 01:00	10.0	13.2	7.7	173.4	3,369,629.3	1,993.1	1.7	1.4
08/28/2024 02:00	10.0	13.2	7.7	174.9	3,367,431.5	1,991.8	1.7	1.4
08/28/2024 03:00	10.3	13.1	7.8	181.4	3,364,219.2	2,063.6	1.8	1.4
08/28/2024 04:00	10.3	13.0	7.7	201.1	3,365,091.2	2,187.0	2.0	1.7
08/28/2024 05:00	10.2	13.0	7.6	202.6	3,359,244.2	2,183.2	2.0	1.7
08/28/2024 06:00	10.0	13.1	7.6	170.1	3,387,757.9	2,053.3	1.6	1.2
08/28/2024 07:00	10.6	13.2	8.1	174.6	3,360,499.8	1,987.7	1.7	1.4
08/28/2024 08:00	10.6	13.1	8.0	177.8	3,293,383.1	1,996.1	1.8	1.4
08/28/2024 09:00	10.7	13.1	8.1	184.0	3,302,622.6	2,001.7	1.8	1.4
08/28/2024 10:00	10.6	13.1	8.0	183.1	3,315,986.9	2,009.8	1.8	1.4
08/28/2024 11:00	10.6	13.1	8.0	177.2	3,290,042.1	2,018.1	1.8	1.4
08/28/2024 12:00	10.6	13.1	8.0	185.2	3,273,729.8	2,032.0	1.8	1.4
08/28/2024 13:00	10.7	13.0	8.0	195.6	3,279,220.5	2,083.3	2.0	1.7
08/28/2024 14:00	10.7	13.0	8.0	195.0	3,249,156.1	2,064.2	2.0	1.7
08/28/2024 15:00	10.7	13.0	8.0	184.6	3,260,503.9	2,047.6	1.8	1.4
08/28/2024 16:00	10.6	13.0	7.9	188.3	3,263,480.0	2,073.3	1.9	1.5
08/28/2024 17:00	10.4	13.1	7.9	186.2	3,307,723.8	2,053.1	1.8	1.4
08/28/2024 18:00	10.7	13.0	8.0	203.7	3,286,926.3	2,136.2	2.0	1.7
08/28/2024 19:00	10.7	12.9	7.9	215.3	3,251,867.5	2,208.4	2.2	1.8
08/28/2024 20:00	10.6	13.0	7.9	191.6	3,253,383.1	2,114.4	1.9	1.5
08/28/2024 21:00	10.5	13.1	7.9	181.3	3,280,260.5	2,012.1	1.8	1.4
08/28/2024 22:00	10.4	13.2	8.0	182.8	3,301,797.7	2,001.2	1.8	1.4
08/28/2024 23:00	10.1	13.2	7.7	173.2	3,357,625.7	1,986.0	1.7	1.4
Average/Sum#:	10.4	13.1	7.9	186.3	3,312,839.1	2,058.8	1.8	1.5
Minimum:	10.0	12.9	7.6	170.1	3,249,156.1	1,986.0	1.6	1.2
Maximum:	10.7	13.2	8.1	215.3	3,387,757.9	2,208.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/29/2024 00:00	10.3	13.2	7.9	171.8	3,360,499.8	1,987.7	1.7	1.4
08/29/2024 01:00	10.2	13.2	7.8	176.4	3,356,273.2	1,985.2	1.7	1.4
08/29/2024 02:00	10.3	13.2	7.9	173.7	3,387,100.0	1,978.7	1.7	1.4
08/29/2024 03:00	10.3	13.2	7.9	173.5	3,350,186.9	1,981.6	1.7	1.4
08/29/2024 04:00	10.3	13.2	7.9	179.1	3,369,786.0	2,017.8	1.7	1.4
08/29/2024 05:00	10.1	13.2	7.7	173.1	3,347,143.7	1,979.8	1.7	1.4
08/29/2024 06:00	9.7	13.7	7.9	147.6	3,360,297.4	1,742.2	1.4	0.9
08/29/2024 07:00	10.2	13.8	8.5	124.9	2,975,315.6	1,542.6	1.3	0.8
08/29/2024 08:00	9.9	13.9	8.3	96.4	2,579,995.5	1,318.8	1.2	0.7
08/29/2024 09:00	9.9	13.9	8.3	98.8	2,618,577.6	1,319.4	1.2	0.7
08/29/2024 10:00	9.9	13.9	8.3	99.0	2,625,523.9	1,322.9	1.2	0.7
08/29/2024 11:00	9.9	13.9	8.3	100.0	2,639,813.6	1,330.1	1.2	0.7
08/29/2024 12:00	10.3	13.8	8.6	146.4	3,046,872.8	1,579.7	1.5	0.9
08/29/2024 13:00	10.4	13.7	8.5	157.5	3,228,562.6	1,673.9	1.6	1.0
08/29/2024 14:00	10.4	13.7	8.5	164.4	3,267,979.1	1,718.2	1.6	1.0
08/29/2024 15:00	10.2	13.8	8.5	138.5	2,966,636.1	1,538.1	1.5	0.9
08/29/2024 16:00	10.9	13.1	8.2	174.8	3,287,733.2	2,064.7	1.7	1.4
08/29/2024 17:00	10.8	13.0	8.1	203.4	3,275,540.0	2,128.8	2.0	1.7
08/29/2024 18:00	10.6	13.1	8.0	190.9	3,281,523.0	2,060.8	1.9	1.4
08/29/2024 19:00	10.8	12.9	8.0	205.0	3,317,963.1	2,180.6	2.0	1.7
08/29/2024 20:00	10.6	13.0	7.9	200.9	3,299,368.3	2,096.1	2.0	1.7
08/29/2024 21:00	10.6	13.1	8.0	192.6	3,311,268.2	2,055.3	1.9	1.4
08/29/2024 22:00	10.5	13.2	8.0	178.4	3,323,359.2	1,990.0	1.7	1.4
08/29/2024 23:00	10.6	13.2	8.1	183.9	3,318,683.1	1,987.2	1.8	1.4
Average/Sum#:	10.3	13.4	8.1	160.5	3,162,333.4	1,815.8	1.6	1.2
Minimum:	9.7	12.9	7.7	96.4	2,579,995.5	1,318.8	1.2	0.7
Maximum:	10.9	13.9	8.6	205.0	3,387,100.0	2,180.6	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/30/2024 00:00	10.5	13.2	8.0	183.0	3,349,341.5	1,981.1	1.8	1.4
08/30/2024 01:00	10.4	13.2	8.0	172.1	3,388,469.5	1,979.5	1.6	1.2
08/30/2024 02:00	10.4	13.2	8.0	180.2	3,389,667.7	1,980.2	1.7	1.4
08/30/2024 03:00	10.3	13.2	7.9	173.3	3,391,893.0	1,981.5	1.7	1.4
08/30/2024 04:00	10.3	13.1	7.8	180.0	3,386,768.0	2,052.7	1.7	1.4
08/30/2024 05:00	10.3	13.1	7.8	188.1	3,377,483.9	2,096.4	1.8	1.5
08/30/2024 06:00	10.0	13.1	7.6	173.3	3,383,303.2	2,050.6	1.7	1.4
08/30/2024 07:00	9.7	13.8	8.1	108.3	2,691,979.7	1,395.7	1.3	0.7
08/30/2024 08:00	9.5	13.8	7.9	103.2	2,690,136.4	1,375.1	1.2	0.7
08/30/2024 09:00	9.7	13.8	8.1	97.0	2,589,972.8	1,323.9	1.2	0.7
08/30/2024 10:00	9.9	13.8	8.2	99.5	2,605,427.7	1,331.8	1.2	0.7
08/30/2024 11:00	10.0	13.9	8.4	115.7	2,680,550.4	1,370.2	1.4	0.7
08/30/2024 12:00	9.9	13.9	8.3	100.6	2,662,438.9	1,341.5	1.2	0.7
08/30/2024 13:00	10.5	13.8	8.7	162.0	3,224,705.1	1,671.9	1.6	1.0
08/30/2024 14:00	10.6	13.6	8.6	159.5	3,184,466.9	1,720.8	1.6	1.0
08/30/2024 15:00	11.0	13.0	8.2	187.4	3,262,535.5	2,072.7	1.9	1.5
08/30/2024 16:00	10.9	13.0	8.1	193.0	3,273,235.5	2,103.4	1.9	1.5
08/30/2024 17:00	10.8	12.9	8.0	206.3	3,250,299.0	2,183.6	2.1	1.7
08/30/2024 18:00	10.8	12.9	8.0	217.2	3,273,071.5	2,222.8	2.2	1.8
08/30/2024 19:00	10.7	12.9	7.9	209.5	3,263,647.5	2,216.4	2.1	1.8
08/30/2024 20:00	10.6	12.9	7.8	209.0	3,260,113.5	2,214.0	2.1	1.8
08/30/2024 21:00	10.6	12.9	7.8	210.5	3,265,099.0	2,169.7	2.1	1.7
08/30/2024 22:00	10.4	13.1	7.9	187.6	3,308,790.2	2,029.6	1.9	1.4
08/30/2024 23:00	10.6	12.9	7.8	208.6	3,335,765.6	2,192.3	2.1	1.8
Average/Sum#:	10.4	13.3	8.0	167.7	3,145,381.8	1,877.4	1.7	1.3
Minimum:	9.5	12.9	7.6	97.0	2,589,972.8	1,323.9	1.2	0.7
Maximum:	11.0	13.9	8.7	217.2	3,391,893.0	2,222.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/31/2024 00:00	10.6	12.9	7.8	204.1	3,330,592.3	2,188.9	2.0	1.8
08/31/2024 01:00	10.4	13.0	7.8	209.5	3,359,705.8	2,183.5	2.1	1.7
08/31/2024 02:00	10.4	13.0	7.8	208.3	3,358,782.6	2,182.9	2.0	1.7
08/31/2024 03:00	10.4	13.0	7.8	206.2	3,352,781.7	2,179.0	2.0	1.7
08/31/2024 04:00	10.2	13.0	7.6	201.2	3,351,396.9	2,178.1	2.0	1.7
08/31/2024 05:00	10.0	13.1	7.6	189.1	3,292,987.9	2,068.0	1.9	1.4
08/31/2024 06:00	20.5	16.1	25.2	171.7	1,245,748.2	582.2	4.4	1.0
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2024 10:00	15.5	18.2	33.9	146.1	1,168,575.5	179.2	3.7	0.3
08/31/2024 11:00	30.7	15.7	34.8	224.9	2,128,783.6	792.8	3.2	1.0
08/31/2024 12:00	9.8	13.9	8.3	106.8	2,755,868.8	1,408.7	1.2	0.7
08/31/2024 13:00	9.9	13.9	8.3	109.2	2,752,741.5	1,387.0	1.2	0.7
08/31/2024 14:00	10.7	13.7	8.8	170.6	3,127,688.1	1,621.6	1.8	1.1
08/31/2024 15:00	10.4	13.7	8.5	142.8	2,976,858.6	1,543.4	1.5	0.9
08/31/2024 16:00	10.8	13.7	8.9	161.4	3,183,531.3	1,673.8	1.6	1.0
08/31/2024 17:00	11.2	13.3	8.7	169.6	3,140,662.2	1,811.8	1.7	1.3
08/31/2024 18:00	11.3	12.9	8.3	217.2	3,232,418.1	2,242.4	2.2	1.8
08/31/2024 19:00	10.8	12.9	8.0	216.7	3,232,982.7	2,266.4	2.2	1.8
08/31/2024 20:00	10.8	12.9	8.0	212.6	3,246,534.3	2,275.9	2.2	1.8
08/31/2024 21:00	10.6	12.9	7.8	221.8	3,289,213.2	2,281.8	2.2	1.8
08/31/2024 22:00	10.4	13.0	7.8	203.3	3,320,556.4	2,230.8	2.0	1.8
08/31/2024 23:00	10.6	12.9	7.8	217.5	3,301,332.5	2,266.1	2.2	1.8
Average/Sum#:	12.2	13.7	11.4	186.2	2,959,511.5	1,787.8	2.2	1.4
Minimum:	9.8	12.9	7.6	106.8	1,168,575.5	179.2	1.2	0.3
Maximum:	30.7	18.2	34.8	224.9	3,359,705.8	2,281.8	4.4	1.8
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/01/2024 00:00	10.5	13.0	7.8	208.7	3,317,392.1	2,156.0	2.1	1.7
09/01/2024 01:00	10.4	13.0	7.8	198.6	3,344,196.6	2,149.0	1.9	1.5
09/01/2024 02:00	10.4	13.0	7.8	200.5	3,332,163.4	2,165.6	2.0	1.7
09/01/2024 03:00	10.1	13.1	7.6	186.7	3,342,201.0	2,074.5	1.8	1.5
09/01/2024 04:00	9.9	13.3	7.7	176.0	3,360,161.7	1,987.5	1.7	1.4
09/01/2024 05:00	10.0	13.3	7.8	169.2	3,328,557.1	1,944.5	1.6	1.2
09/01/2024 06:00	19.6	16.0	23.6	175.8	1,286,014.0	619.8	4.4	1.1
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2024 14:00	26.6	17.5	46.2	37.5	1,434,803.4	324.8	0.6	0.1
09/01/2024 15:00	25.2	15.0	25.2	206.3	2,559,170.8	1,083.9	2.5	1.1
09/01/2024 16:00	10.8	13.5	8.6	173.1	3,227,526.9	1,720.5	1.7	1.2
09/01/2024 17:00	10.9	13.5	8.7	177.2	3,232,404.3	1,723.1	1.8	1.2
09/01/2024 18:00	11.2	13.0	8.4	187.4	3,256,947.7	2,140.5	1.9	1.5
09/01/2024 19:00	10.9	12.9	8.0	242.2	3,253,192.8	2,209.3	2.5	2.2
09/01/2024 20:00	10.7	13.0	8.0	211.7	3,270,096.1	2,196.9	2.1	1.8
09/01/2024 21:00	10.7	12.9	7.9	216.3	3,284,557.0	2,230.6	2.2	1.8
09/01/2024 22:00	10.5	13.0	7.8	202.9	3,307,464.2	2,173.7	2.0	1.7
09/01/2024 23:00	10.4	13.0	7.8	202.9	3,339,856.8	2,170.6	2.0	1.7
Average/Sum#:	12.9	13.6	12.2	186.6	3,028,041.5	1,827.7	2.0	1.4
Minimum:	9.9	12.9	7.6	37.5	1,286,014.0	324.8	0.6	0.1
Maximum:	26.6	17.5	46.2	242.2	3,360,161.7	2,230.6	4.4	2.2
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/02/2024 00:00	10.3	13.0	7.7	199.3	3,352,133.0	2,154.1	2.0	1.7
09/02/2024 01:00	10.1	13.1	7.6	192.4	3,321,172.6	2,085.7	1.9	1.5
09/02/2024 02:00	10.0	13.3	7.8	167.3	3,359,026.8	1,962.3	1.6	1.2
09/02/2024 03:00	9.9	13.3	7.7	170.3	3,416,800.5	1,971.1	1.6	1.2
09/02/2024 04:00	9.8	13.3	7.6	165.4	3,405,706.4	1,964.7	1.6	1.2
09/02/2024 05:00	9.8	13.3	7.6	159.3	3,392,358.9	1,957.0	1.5	1.2
09/02/2024 06:00	9.9	13.3	7.7	151.8	3,352,836.3	1,934.2	1.5	1.2
09/02/2024 07:00	17.2	17.4	29.0	171.9	1,657,520.3	641.5	3.2	0.8
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2024 14:00	30.4	17.1	47.2	74.7	1,678,131.8	428.9	1.2	0.2
09/02/2024 15:00	20.4	14.4	18.5	194.5	2,601,478.4	1,215.8	2.4	1.1
09/02/2024 16:00	10.4	13.6	8.4	163.9	3,199,127.5	1,682.0	1.6	1.0
09/02/2024 17:00	10.7	13.4	8.4	164.2	3,155,916.5	1,820.6	1.7	1.3
09/02/2024 18:00	11.0	12.9	8.1	217.8	3,267,014.1	2,266.4	2.2	1.8
09/02/2024 19:00	10.8	12.9	8.0	222.6	3,259,230.0	2,284.8	2.3	2.1
09/02/2024 20:00	10.5	13.0	7.8	202.8	3,300,764.2	2,193.4	2.0	1.8
09/02/2024 21:00	10.3	13.2	7.9	184.6	3,303,117.6	2,002.0	1.8	1.4
09/02/2024 22:00	10.3	13.2	7.9	184.8	3,344,860.3	2,027.3	1.8	1.4
09/02/2024 23:00	10.1	13.3	7.8	170.9	3,366,755.2	1,991.4	1.6	1.2
Average/Sum#:	12.3	13.7	11.8	175.5	3,096,330.6	1,810.2	1.9	1.3
Minimum:	9.8	12.9	7.6	74.7	1,657,520.3	428.9	1.2	0.2
Maximum:	30.4	17.4	47.2	222.6	3,416,800.5	2,284.8	3.2	2.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/03/2024 00:00	10.2	13.3	7.9	176.0	3,352,215.6	1,982.8	1.7	1.4
09/03/2024 01:00	10.2	13.2	7.8	176.2	3,358,978.2	1,986.8	1.7	1.4
09/03/2024 02:00	10.1	13.3	7.8	171.5	3,348,665.3	1,980.7	1.7	1.4
09/03/2024 03:00	10.1	13.3	7.8	169.8	3,382,991.8	1,976.3	1.6	1.2
09/03/2024 04:00	10.0	13.3	7.8	176.6	3,373,010.6	1,995.1	1.7	1.4
09/03/2024 05:00	10.2	13.1	7.7	191.2	3,356,821.2	2,132.6	1.9	1.5
09/03/2024 06:00	10.0	13.1	7.6	193.2	3,422,901.0	2,074.6	1.8	1.5
09/03/2024 07:00	10.5	13.3	8.2	168.8	3,359,198.0	1,962.4	1.6	1.2
09/03/2024 08:00	10.4	13.2	8.0	177.2	3,332,942.3	1,971.4	1.7	1.4
09/03/2024 09:00	10.4	13.2	8.0	172.3	3,312,337.0	1,983.4	1.7	1.4
09/03/2024 10:00	10.5	13.2	8.0	181.4	3,302,457.6	2,001.6	1.8	1.4
09/03/2024 11:00	10.4	13.2	8.0	183.3	3,284,173.1	2,014.5	1.8	1.4
09/03/2024 12:00	10.6	13.0	7.9	195.4	3,282,105.6	2,109.1	2.0	1.7
09/03/2024 13:00	10.6	13.0	7.9	208.0	3,273,966.2	2,199.5	2.1	1.8
09/03/2024 14:00	10.5	12.9	7.7	214.5	3,275,869.3	2,224.7	2.2	1.8
09/03/2024 15:00	10.5	12.9	7.7	209.4	3,268,065.0	2,219.4	2.1	1.8
09/03/2024 16:00	10.5	13.0	7.8	213.3	3,258,052.0	2,212.6	2.2	1.8
09/03/2024 17:00	10.6	12.9	7.8	220.1	3,273,652.7	2,247.1	2.2	1.8
09/03/2024 18:00	10.4	12.9	7.7	209.5	3,293,028.6	2,260.4	2.1	1.8
09/03/2024 19:00	10.5	12.9	7.7	223.7	3,299,438.7	2,264.8	2.2	1.8
09/03/2024 20:00	10.3	12.9	7.6	209.4	3,310,802.0	2,272.6	2.1	1.8
09/03/2024 21:00	10.3	12.9	7.6	221.5	3,317,066.4	2,276.9	2.2	1.8
09/03/2024 22:00	10.3	12.9	7.6	211.8	3,315,755.2	2,276.0	2.1	1.8
09/03/2024 23:00	10.0	13.1	7.6	202.9	3,284,618.2	2,134.7	2.0	1.7
Average/Sum#:	10.3	13.1	7.8	194.9	3,318,296.3	2,115.0	1.9	1.6
Minimum:	10.0	12.9	7.6	168.8	3,258,052.0	1,962.4	1.6	1.2
Maximum:	10.6	13.3	8.2	223.7	3,422,901.0	2,276.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/04/2024 00:00	9.5	13.8	7.9	159.2	3,315,935.8	1,719.2	1.5	1.0
09/04/2024 01:00	9.7	13.8	8.1	149.3	3,350,653.6	1,737.2	1.4	0.9
09/04/2024 02:00	9.7	13.8	8.1	151.6	3,374,066.0	1,724.7	1.4	0.9
09/04/2024 03:00	9.8	13.8	8.1	153.8	3,406,541.0	1,741.3	1.4	0.9
09/04/2024 04:00	9.9	13.8	8.2	157.6	3,357,597.1	1,740.8	1.5	1.0
09/04/2024 05:00	9.7	13.8	8.1	145.8	3,346,286.3	1,710.5	1.4	0.9
09/04/2024 06:00	9.7	13.8	8.1	143.7	3,293,176.3	1,707.4	1.4	0.9
09/04/2024 07:00	10.3	13.8	8.6	165.8	3,352,389.5	1,738.1	1.6	1.0
09/04/2024 08:00	10.3	13.7	8.4	159.6	3,318,952.2	1,745.0	1.5	1.0
09/04/2024 09:00	10.4	13.7	8.5	165.2	3,310,963.8	1,740.8	1.6	1.0
09/04/2024 10:00	10.6	13.6	8.6	174.0	3,296,699.0	1,733.3	1.7	1.2
09/04/2024 11:00	10.5	13.6	8.5	170.1	3,311,724.6	1,741.2	1.7	1.2
09/04/2024 12:00	10.4	13.7	8.5	158.5	3,201,409.9	1,683.2	1.6	1.0
09/04/2024 13:00	11.2	13.0	8.4	187.6	3,286,926.3	2,136.2	1.9	1.5
09/04/2024 14:00	11.0	12.9	8.1	214.0	3,248,363.9	2,182.3	2.2	1.7
09/04/2024 15:00	10.9	12.9	8.0	206.4	3,229,559.2	2,122.5	2.1	1.7
09/04/2024 16:00	10.9	12.9	8.0	203.5	3,236,055.2	2,150.4	2.1	1.7
09/04/2024 17:00	10.8	12.9	8.0	210.9	3,237,108.6	2,151.1	2.1	1.7
09/04/2024 18:00	10.8	13.0	8.1	207.0	3,228,037.6	2,121.5	2.1	1.7
09/04/2024 19:00	10.9	12.9	8.0	209.9	3,244,946.8	2,203.7	2.1	1.8
09/04/2024 20:00	10.7	12.9	7.9	215.7	3,256,579.5	2,211.6	2.2	1.8
09/04/2024 21:00	10.6	12.9	7.8	215.4	3,276,645.5	2,201.3	2.2	1.8
09/04/2024 22:00	10.6	12.9	7.8	211.9	3,305,790.5	2,172.6	2.1	1.7
09/04/2024 23:00	10.5	12.9	7.7	204.5	3,304,977.8	2,196.2	2.0	1.8
Average/Sum#:	10.4	13.4	8.1	180.9	3,295,474.4	1,929.7	1.8	1.3
Minimum:	9.5	12.9	7.7	143.7	3,201,409.9	1,683.2	1.4	0.9
Maximum:	11.2	13.8	8.6	215.7	3,406,541.0	2,211.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/05/2024 00:00	10.4	13.0	7.8	210.5	3,325,114.6	2,185.3	2.1	1.7
09/05/2024 01:00	10.3	13.0	7.7	209.0	3,319,941.2	2,181.9	2.1	1.7
09/05/2024 02:00	10.4	13.0	7.8	207.3	3,302,595.1	2,170.5	2.1	1.7
09/05/2024 03:00	10.1	13.1	7.6	175.9	3,346,840.2	2,028.5	1.7	1.4
09/05/2024 04:00	10.5	13.0	7.8	207.5	3,327,244.8	2,186.7	2.1	1.7
09/05/2024 05:00	10.3	12.9	7.6	218.7	3,313,270.8	2,250.1	2.2	1.8
09/05/2024 06:00	10.2	13.0	7.6	221.0	3,378,450.5	2,097.0	2.2	1.7
09/05/2024 07:00	10.1	13.8	8.4	158.6	3,324,036.6	1,723.4	1.5	1.0
09/05/2024 08:00	10.0	13.8	8.3	150.9	3,198,666.8	1,658.4	1.5	1.0
09/05/2024 09:00	10.3	13.7	8.4	163.1	3,282,814.6	1,726.0	1.6	1.0
09/05/2024 10:00	10.3	13.7	8.4	163.9	3,290,283.2	1,705.9	1.6	1.0
09/05/2024 11:00	10.6	13.6	8.6	167.5	3,289,471.5	1,729.5	1.6	1.0
09/05/2024 12:00	10.6	13.6	8.6	169.1	3,287,569.5	1,728.5	1.7	1.2
09/05/2024 13:00	11.2	13.0	8.4	195.8	3,219,501.7	2,139.4	2.0	1.7
09/05/2024 14:00	11.0	12.9	8.1	215.0	3,215,791.3	2,183.9	2.2	1.7
09/05/2024 15:00	10.9	12.9	8.0	206.0	3,204,305.8	2,176.1	2.1	1.7
09/05/2024 16:00	10.8	13.0	8.1	200.0	3,189,845.9	2,096.4	2.1	1.7
09/05/2024 17:00	10.9	13.0	8.1	210.4	3,218,598.8	2,138.8	2.2	1.7
09/05/2024 18:00	10.9	12.9	8.0	214.9	3,194,292.8	2,169.3	2.2	1.7
09/05/2024 19:00	10.8	13.0	8.1	210.2	3,237,200.2	2,174.8	2.1	1.7
09/05/2024 20:00	10.8	13.0	8.1	207.8	3,245,386.9	2,180.3	2.1	1.7
09/05/2024 21:00	10.8	12.9	8.0	219.3	3,244,370.3	2,227.0	2.2	1.8
09/05/2024 22:00	10.6	12.9	7.8	217.3	3,261,536.4	2,262.6	2.2	1.8
09/05/2024 23:00	10.5	13.0	7.8	203.5	3,306,031.2	2,196.9	2.0	1.8
Average/Sum#:	10.6	13.2	8.0	196.8	3,271,798.4	2,054.9	2.0	1.5
Minimum:	10.0	12.9	7.6	150.9	3,189,845.9	1,658.4	1.5	1.0
Maximum:	11.2	13.8	8.6	221.0	3,378,450.5	2,262.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/06/2024 00:00	10.6	13.0	7.9	216.6	3,263,844.4	2,192.7	2.2	1.8
09/06/2024 01:00	10.6	13.0	7.9	206.3	3,272,772.1	2,150.9	2.1	1.7
09/06/2024 02:00	10.4	13.2	8.0	179.6	3,316,976.8	2,010.4	1.8	1.4
09/06/2024 03:00	10.4	13.0	7.8	203.6	3,321,006.3	2,182.6	2.0	1.7
09/06/2024 04:00	10.5	13.0	7.8	214.7	3,338,385.8	2,218.4	2.1	1.8
09/06/2024 05:00	10.3	12.9	7.6	218.0	3,337,272.5	2,266.4	2.2	1.8
09/06/2024 06:00	10.2	13.0	7.6	209.9	3,349,088.9	2,176.6	2.1	1.7
09/06/2024 07:00	10.9	13.0	8.1	197.6	3,339,061.3	2,145.7	1.9	1.5
09/06/2024 08:00	10.6	13.0	7.9	197.8	3,309,442.3	2,102.5	2.0	1.7
09/06/2024 09:00	10.4	13.2	8.0	184.6	3,287,443.5	1,992.5	1.8	1.4
09/06/2024 10:00	10.7	13.1	8.1	194.0	3,282,319.2	2,061.3	1.9	1.4
09/06/2024 11:00	10.9	13.0	8.1	202.8	3,250,709.2	2,136.4	2.0	1.7
09/06/2024 12:00	10.9	12.9	8.0	208.1	3,232,436.9	2,171.6	2.1	1.7
09/06/2024 13:00	10.9	12.9	8.0	215.4	3,224,101.3	2,166.0	2.2	1.7
09/06/2024 14:00	10.9	12.9	8.0	213.7	3,206,809.1	2,177.8	2.2	1.7
09/06/2024 15:00	10.9	12.9	8.0	208.3	3,206,072.8	2,177.3	2.1	1.7
09/06/2024 16:00	10.9	13.0	8.1	205.6	3,231,080.8	2,123.5	2.1	1.7
09/06/2024 17:00	10.9	12.9	8.0	212.0	3,218,593.9	2,162.3	2.2	1.7
09/06/2024 18:00	10.9	12.9	8.0	216.3	3,195,857.7	2,193.7	2.2	1.8
09/06/2024 19:00	10.7	13.0	8.0	215.7	3,241,265.5	2,201.2	2.2	1.8
09/06/2024 20:00	10.5	13.0	7.8	210.5	3,293,019.1	2,212.3	2.1	1.8
09/06/2024 21:00	10.5	13.0	7.8	211.8	3,288,238.3	2,233.1	2.1	1.8
09/06/2024 22:00	10.4	13.0	7.8	214.9	3,301,503.6	2,218.0	2.1	1.8
09/06/2024 23:00	10.4	12.9	7.7	221.5	3,316,192.3	2,276.3	2.2	1.8
Average/Sum#:	10.6	13.0	7.9	207.5	3,275,978.9	2,164.6	2.1	1.7
Minimum:	10.2	12.9	7.6	179.6	3,195,857.7	1,992.5	1.8	1.4
Maximum:	10.9	13.2	8.1	221.5	3,349,088.9	2,276.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/07/2024 00:00	10.3	12.9	7.6	217.4	3,318,523.2	2,277.9	2.2	1.8
09/07/2024 01:00	10.3	12.9	7.6	210.7	3,307,159.9	2,270.1	2.1	1.8
09/07/2024 02:00	10.4	13.0	7.8	213.4	3,303,172.0	2,195.0	2.1	1.8
09/07/2024 03:00	10.5	13.0	7.8	212.7	3,295,798.2	2,190.1	2.1	1.8
09/07/2024 04:00	10.4	13.0	7.8	209.1	3,334,924.6	2,216.1	2.1	1.8
09/07/2024 05:00	10.3	13.0	7.7	205.0	3,319,028.2	2,181.3	2.0	1.7
09/07/2024 06:00	10.2	13.1	7.7	170.6	3,385,056.0	2,101.1	1.6	1.3
09/07/2024 07:00	10.6	13.3	8.2	174.5	3,342,748.0	1,977.2	1.7	1.4
09/07/2024 08:00	10.4	13.3	8.1	174.7	3,342,917.1	1,977.3	1.7	1.4
09/07/2024 09:00	10.5	13.2	8.0	180.4	3,325,530.2	1,991.3	1.8	1.4
09/07/2024 10:00	10.8	13.1	8.2	197.0	3,292,757.3	2,091.9	2.0	1.7
09/07/2024 11:00	10.6	13.1	8.0	185.2	3,296,650.4	2,070.3	1.8	1.4
09/07/2024 12:00	10.8	13.0	8.1	210.1	3,261,637.8	2,167.4	2.1	1.7
09/07/2024 13:00	10.8	12.9	8.0	217.4	3,230,676.1	2,217.6	2.2	1.8
09/07/2024 14:00	10.8	12.9	8.0	212.0	3,226,940.4	2,238.6	2.2	1.8
09/07/2024 15:00	10.8	12.9	8.0	213.6	3,230,400.0	2,241.0	2.2	1.8
09/07/2024 16:00	10.8	13.0	8.1	209.1	3,245,535.8	2,156.7	2.1	1.7
09/07/2024 17:00	10.9	12.9	8.0	219.4	3,243,373.5	2,250.0	2.2	1.8
09/07/2024 18:00	10.7	12.9	7.9	212.9	3,264,563.6	2,264.7	2.1	1.8
09/07/2024 19:00	10.5	12.9	7.7	221.3	3,276,960.5	2,273.3	2.2	1.8
09/07/2024 20:00	10.4	12.9	7.7	219.2	3,320,708.4	2,279.4	2.2	1.8
09/07/2024 21:00	10.3	12.9	7.6	209.3	3,308,179.7	2,270.8	2.1	1.8
09/07/2024 22:00	10.2	13.0	7.6	206.7	3,330,287.9	2,188.7	2.0	1.8
09/07/2024 23:00	10.3	12.9	7.6	221.6	3,338,892.2	2,267.5	2.2	1.8
Average/Sum#:	10.5	13.0	7.9	205.1	3,297,600.9	2,181.5	2.0	1.7
Minimum:	10.2	12.9	7.6	170.6	3,226,940.4	1,977.2	1.6	1.3
Maximum:	10.9	13.3	8.2	221.6	3,385,056.0	2,279.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/08/2024 00:00	10.1	13.1	7.6	193.5	3,338,127.6	2,145.1	1.9	1.5
09/08/2024 01:00	9.9	13.3	7.7	175.9	3,342,731.5	2,001.6	1.7	1.4
09/08/2024 02:00	10.3	13.0	7.7	197.8	3,364,271.1	2,161.9	1.9	1.5
09/08/2024 03:00	10.1	13.0	7.5	199.7	3,349,704.4	2,177.0	2.0	1.7
09/08/2024 04:00	9.8	13.2	7.5	178.8	3,374,629.1	2,020.7	1.7	1.4
09/08/2024 05:00	9.4	13.8	7.8	141.3	3,286,039.9	1,703.7	1.4	0.9
09/08/2024 06:00	9.6	13.8	8.0	135.4	3,197,123.7	1,657.6	1.3	0.8
09/08/2024 07:00	10.1	13.8	8.4	139.1	3,175,328.7	1,646.3	1.4	0.8
09/08/2024 08:00	9.9	13.8	8.2	132.8	3,116,308.4	1,615.7	1.4	0.8
09/08/2024 09:00	9.7	13.8	8.1	121.9	2,978,401.6	1,544.2	1.3	0.8
09/08/2024 10:00	9.5	13.9	8.0	119.9	3,020,558.9	1,544.0	1.3	0.8
09/08/2024 11:00	9.3	13.9	7.8	118.9	3,050,295.0	1,559.2	1.2	0.8
09/08/2024 12:00	9.4	13.8	7.8	131.5	3,212,278.3	1,642.0	1.3	0.8
09/08/2024 13:00	9.8	13.7	8.0	138.4	3,225,090.9	1,672.1	1.4	0.8
09/08/2024 14:00	10.6	13.4	8.3	169.9	3,187,118.6	1,838.6	1.7	1.3
09/08/2024 15:00	10.8	13.0	8.1	211.6	3,268,065.0	2,219.4	2.1	1.8
09/08/2024 16:00	10.6	13.0	7.9	199.5	3,281,387.0	2,132.6	2.0	1.7
09/08/2024 17:00	10.6	12.9	7.8	216.0	3,242,330.8	2,225.6	2.2	1.8
09/08/2024 18:00	10.5	12.9	7.7	217.3	3,260,541.2	2,238.1	2.2	1.8
09/08/2024 19:00	10.5	12.9	7.7	214.3	3,263,842.8	2,264.2	2.2	1.8
09/08/2024 20:00	10.4	12.9	7.7	215.1	3,266,581.7	2,266.1	2.2	1.8
09/08/2024 21:00	10.4	12.9	7.7	217.3	3,283,413.5	2,253.8	2.2	1.8
09/08/2024 22:00	10.3	13.0	7.7	207.4	3,280,366.8	2,203.8	2.1	1.8
09/08/2024 23:00	10.2	13.0	7.6	203.4	3,295,497.2	2,189.9	2.0	1.8
Average/Sum#:	10.1	13.3	7.8	174.9	3,235,834.7	1,955.1	1.8	1.3
Minimum:	9.3	12.9	7.5	118.9	2,978,401.6	1,544.0	1.2	0.8
Maximum:	10.8	13.9	8.4	217.3	3,374,629.1	2,266.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/09/2024 00:00	10.1	13.0	7.5	204.0	3,329,375.0	2,188.1	2.0	1.8
09/09/2024 01:00	9.9	13.2	7.6	186.8	3,365,034.4	2,064.1	1.8	1.4
09/09/2024 02:00	10.1	13.0	7.5	197.2	3,375,164.3	2,168.9	1.9	1.5
09/09/2024 03:00	10.2	13.0	7.6	204.7	3,326,179.7	2,186.0	2.0	1.7
09/09/2024 04:00	10.1	13.0	7.5	206.0	3,334,396.2	2,191.4	2.0	1.8
09/09/2024 05:00	10.0	13.0	7.5	206.8	3,359,108.7	2,256.7	2.0	1.8
09/09/2024 06:00	9.7	13.1	7.3	166.1	3,441,050.0	2,085.6	1.6	1.3
09/09/2024 07:00	10.5	13.3	8.2	172.7	3,381,793.5	1,975.6	1.6	1.2
09/09/2024 08:00	10.3	13.2	7.9	173.4	3,346,129.3	1,979.2	1.7	1.4
09/09/2024 09:00	10.6	13.0	7.9	199.3	3,301,543.7	2,145.7	2.0	1.7
09/09/2024 10:00	10.6	13.0	7.9	208.8	3,231,993.7	2,124.1	2.1	1.7
09/09/2024 11:00	10.5	13.1	7.9	197.5	3,237,755.0	2,080.6	2.0	1.7
09/09/2024 12:00	10.6	13.0	7.9	198.2	3,196,298.1	2,077.3	2.0	1.7
09/09/2024 13:00	10.6	13.0	7.9	198.0	3,206,299.5	2,083.8	2.0	1.7
09/09/2024 14:00	10.5	13.1	7.9	193.1	3,192,490.3	2,028.2	2.0	1.6
09/09/2024 15:00	10.9	13.0	8.1	205.9	3,168,695.9	2,082.5	2.1	1.7
09/09/2024 16:00	10.9	12.9	8.0	217.5	3,131,224.9	2,172.2	2.3	2.0
09/09/2024 17:00	10.7	12.9	7.9	210.1	3,154,977.1	2,142.6	2.2	1.7
09/09/2024 18:00	10.6	12.9	7.8	208.4	3,169,634.7	2,175.7	2.2	1.7
09/09/2024 19:00	10.6	12.9	7.8	211.2	3,183,249.1	2,161.8	2.2	1.7
09/09/2024 20:00	10.3	13.1	7.8	200.5	3,231,072.2	2,099.9	2.0	1.7
09/09/2024 21:00	10.2	13.1	7.7	194.9	3,250,359.9	2,088.7	2.0	1.7
09/09/2024 22:00	10.1	13.2	7.7	170.9	3,265,994.7	1,979.5	1.7	1.4
09/09/2024 23:00	10.3	13.0	7.7	202.0	3,277,793.3	2,154.2	2.0	1.7
Average/Sum#:	10.4	13.0	7.8	197.3	3,269,067.2	2,112.2	2.0	1.6
Minimum:	9.7	12.9	7.3	166.1	3,131,224.9	1,975.6	1.6	1.2
Maximum:	10.9	13.3	8.2	217.5	3,441,050.0	2,256.7	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/10/2024 00:00	10.3	13.0	7.7	205.4	3,264,403.4	2,145.4	2.1	1.7
09/10/2024 01:00	10.1	13.2	7.7	189.8	3,291,183.3	2,018.8	1.9	1.4
09/10/2024 02:00	10.3	13.2	7.9	183.8	3,268,304.5	1,980.9	1.8	1.4
09/10/2024 03:00	10.5	13.2	8.0	182.9	3,284,662.2	2,014.8	1.8	1.4
09/10/2024 04:00	10.4	13.1	7.9	199.3	3,303,656.7	2,074.7	2.0	1.7
09/10/2024 05:00	10.5	13.0	7.8	214.6	3,318,070.1	2,204.9	2.1	1.8
09/10/2024 06:00	10.1	13.1	7.6	206.8	3,316,452.4	2,034.3	2.1	1.6
09/10/2024 07:00	10.0	13.8	8.3	139.1	2,990,745.7	1,550.6	1.5	0.9
09/10/2024 08:00	9.6	13.8	8.0	92.9	2,525,022.9	1,290.7	1.1	0.5
09/10/2024 09:00	9.5	13.9	8.0	95.1	2,527,566.1	1,292.0	1.2	0.6
09/10/2024 10:00	9.4	13.9	7.9	95.9	2,538,912.8	1,297.8	1.2	0.6
09/10/2024 11:00	9.5	13.9	8.0	94.9	2,581,464.2	1,300.7	1.1	0.5
09/10/2024 12:00	9.5	13.9	8.0	96.8	2,550,650.7	1,303.8	1.2	0.7
09/10/2024 13:00	9.8	13.9	8.3	116.8	2,712,438.4	1,386.5	1.4	0.7
09/10/2024 14:00	9.6	13.9	8.1	98.1	2,582,258.1	1,301.1	1.2	0.7
09/10/2024 15:00	9.6	13.9	8.1	102.7	2,616,989.8	1,318.6	1.2	0.7
09/10/2024 16:00	10.4	13.7	8.5	157.0	2,992,867.3	1,551.7	1.7	1.1
09/10/2024 17:00	11.0	13.2	8.4	170.3	3,192,389.1	1,958.2	1.7	1.4
09/10/2024 18:00	10.6	13.2	8.1	181.1	3,222,875.1	1,976.9	1.8	1.4
09/10/2024 19:00	10.4	13.2	8.0	179.8	3,232,171.5	1,959.0	1.8	1.4
09/10/2024 20:00	10.3	13.2	7.9	174.9	3,253,217.9	1,948.0	1.7	1.4
09/10/2024 21:00	10.3	13.2	7.9	172.4	3,282,222.8	1,941.4	1.7	1.4
09/10/2024 22:00	10.0	13.3	7.8	171.5	3,247,564.6	1,920.9	1.7	1.3
09/10/2024 23:00	19.8	15.9	23.4	165.4	1,638,916.8	634.3	3.2	0.8
Average/Sum#:	10.5	13.6	8.6	153.6	2,947,291.9	1,683.6	1.7	1.1
Minimum:	9.4	13.0	7.6	92.9	1,638,916.8	634.3	1.1	0.5
Maximum:	19.8	15.9	23.4	214.6	3,318,070.1	2,204.9	3.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/12/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/13/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/13/2024 18:00	0.0	17.4	0.0	0.0	1,328,341.7	320.1	1.0	0.1
09/13/2024 19:00	0.0	15.2	0.0	171.8	2,139,481.1	874.9	3.3	1.1
09/13/2024 20:00	0.0	13.7	0.0	170.8	3,171,168.4	1,667.3	1.9	1.2
09/13/2024 21:00	0.0	13.7	0.0	169.1	3,217,006.1	1,691.4	1.9	1.2
09/13/2024 22:00	0.0	13.7	0.0	161.6	3,203,692.3	1,684.4	1.8	1.2
09/13/2024 23:00	0.0	13.7	0.0	138.4	3,258,072.8	1,689.2	1.5	1.0
Average/Sum#:	0.0	14.6	0.0	135.3	2,719,627.1	1,321.2	0.0	0.0
Minimum:	0.0	13.7	0.0	0.0	1,328,341.7	320.1	0.0	0.0
Maximum:	0.0	17.4	0.0	171.8	3,258,072.8	1,691.4	0.0	0.0
%SI	100.00	75.00	100.00	75.00	75.00	75.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/14/2024 00:00	0.0	13.8	0.0	160.3	3,268,873.9	1,694.8	1.7	1.2
09/14/2024 01:00	0.0	13.6	0.0	174.9	3,303,126.7	1,760.8	1.9	1.2
09/14/2024 02:00	0.0	14.2	0.0	160.0	2,908,493.9	1,423.0	2.0	1.1
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/14/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	13.9	0.0	165.1	3,160,164.8	1,626.2	0.0	0.0
Minimum:	0.0	13.6	0.0	160.0	2,908,493.9	1,423.0	0.0	0.0
Maximum:	0.0	14.2	0.0	174.9	3,303,126.7	1,760.8	0.0	0.0
%SI	100.00	87.50	100.00	87.50	87.50	87.50	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/15/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/15/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/16/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/18/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2024 01:00	30.7	17.5	53.3	2.5	1,359,757.9	337.6	-0.1	0.0
09/18/2024 02:00	29.7	15.4	31.9	205.2	2,162,445.6	868.5	3.0	1.0
09/18/2024 03:00	9.6	13.8	8.0	121.7	2,867,883.3	1,486.9	1.3	0.7
09/18/2024 04:00	10.0	13.7	8.2	157.2	3,211,870.8	1,688.7	1.6	1.0
09/18/2024 05:00	10.5	13.2	8.0	160.4	3,381,488.3	2,049.5	1.5	1.2
09/18/2024 06:00	10.3	13.1	7.8	214.7	3,394,705.2	2,082.3	2.1	1.7
09/18/2024 07:00	10.6	13.3	8.2	168.7	3,306,230.0	1,955.6	1.6	1.2
09/18/2024 08:00	10.1	13.3	7.8	166.8	3,281,312.0	1,916.9	1.6	1.2
09/18/2024 09:00	10.5	13.3	8.2	179.5	3,289,870.9	1,921.9	1.8	1.3
09/18/2024 10:00	10.6	13.3	8.2	180.1	3,265,823.6	1,931.7	1.8	1.4
09/18/2024 11:00	10.4	13.3	8.1	175.7	3,273,093.3	1,936.0	1.7	1.4
09/18/2024 12:00	10.4	13.3	8.1	171.3	3,272,586.1	1,935.7	1.7	1.4
09/18/2024 13:00	10.4	13.3	8.1	179.8	3,251,213.9	1,946.8	1.8	1.4
09/18/2024 14:00	10.4	13.3	8.1	178.3	3,261,067.1	1,952.7	1.8	1.4
09/18/2024 15:00	10.4	13.3	8.1	171.7	3,242,028.7	1,941.3	1.7	1.4
09/18/2024 16:00	10.6	13.1	8.0	194.1	3,250,572.8	2,065.1	2.0	1.7
09/18/2024 17:00	10.6	13.0	7.9	214.2	3,198,857.6	2,172.4	2.2	1.7
09/18/2024 18:00	10.6	13.0	7.9	204.4	3,206,279.0	2,107.2	2.1	1.7
09/18/2024 19:00	10.7	13.0	8.0	207.2	3,196,778.3	2,124.3	2.1	1.7
09/18/2024 20:00	10.7	13.0	8.0	210.9	3,209,626.4	2,109.4	2.2	1.7
09/18/2024 21:00	10.6	13.0	7.9	209.6	3,211,756.7	2,110.8	2.2	1.7
09/18/2024 22:00	10.6	13.0	7.9	205.6	3,241,381.4	2,106.6	2.1	1.7
09/18/2024 23:00	10.5	13.0	7.8	203.3	3,243,997.1	2,108.3	2.1	1.7
Average/Sum#:	12.2	13.5	11.0	177.5	3,112,201.1	1,863.3	1.8	1.4
Minimum:	9.6	13.0	7.8	2.5	1,359,757.9	337.6	-0.1	0.0
Maximum:	30.7	17.5	53.3	214.7	3,394,705.2	2,172.4	3.0	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/19/2024 00:00	10.6	13.0	7.9	207.7	3,212,973.9	2,111.6	2.1	1.7
09/19/2024 01:00	10.5	13.0	7.8	207.3	3,246,305.1	2,109.8	2.1	1.7
09/19/2024 02:00	10.5	13.0	7.8	199.6	3,250,305.7	2,112.4	2.0	1.7
09/19/2024 03:00	10.7	13.0	8.0	209.4	3,218,299.5	2,115.1	2.1	1.7
09/19/2024 04:00	10.5	13.0	7.8	205.4	3,250,151.8	2,112.3	2.1	1.7
09/19/2024 05:00	10.5	13.0	7.8	209.3	3,250,151.8	2,112.3	2.1	1.7
09/19/2024 06:00	10.2	13.1	7.7	198.9	3,272,118.7	2,031.0	2.0	1.6
09/19/2024 07:00	18.1	17.2	28.9	201.0	1,651,931.6	651.4	3.7	0.9
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.5	13.5	10.5	204.8	3,044,029.8	1,919.5	2.3	1.6
Minimum:	10.2	13.0	7.7	198.9	1,651,931.6	651.4	2.0	0.9
Maximum:	18.1	17.2	28.9	209.4	3,272,118.7	2,115.1	3.7	1.7
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/21/2024 20:00	33.1	17.4	55.8	0.0	1,300,123.2	313.3	-0.1	0.0
09/21/2024 21:00	34.1	17.2	54.4	192.3	1,413,390.1	392.2	4.2	0.6
09/21/2024 22:00	29.0	15.2	30.0	209.8	2,225,194.5	926.2	2.9	1.0
09/21/2024 23:00	9.6	13.9	8.1	135.3	3,053,033.8	1,560.6	1.4	0.8
Average/Sum#:	26.5	15.9	37.1	134.4	1,997,935.4	798.1	2.1	0.6
Minimum:	9.6	13.9	8.1	0.0	1,300,123.2	313.3	-0.1	0.0
Maximum:	34.1	17.4	55.8	209.8	3,053,033.8	1,560.6	4.2	1.0
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/22/2024 00:00	10.1	13.8	8.4	174.4	3,256,529.8	1,688.4	1.7	1.2
09/22/2024 01:00	10.2	13.8	8.5	167.9	3,278,903.5	1,700.0	1.6	1.0
09/22/2024 02:00	10.1	13.8	8.4	160.5	3,228,562.6	1,673.9	1.6	1.0
09/22/2024 03:00	10.1	13.8	8.4	165.2	3,225,476.6	1,672.3	1.6	1.0
09/22/2024 04:00	10.0	13.8	8.3	165.9	3,266,752.2	1,693.7	1.6	1.0
09/22/2024 05:00	10.0	13.8	8.3	164.2	3,269,452.5	1,695.1	1.6	1.0
09/22/2024 06:00	9.9	13.8	8.2	134.6	3,127,178.4	1,598.5	1.4	0.8
09/22/2024 07:00	16.1	17.6	28.8	174.1	1,574,579.7	609.4	3.4	0.8
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/22/2024 10:00	32.5	17.3	53.3	170.4	1,626,295.2	391.9	2.8	0.4
09/22/2024 11:00	25.5	14.7	24.3	196.0	2,334,205.9	1,056.8	2.7	1.1
09/22/2024 12:00	9.8	14.0	8.4	135.8	3,014,916.8	1,519.1	1.4	0.8
09/22/2024 13:00	9.8	14.0	8.4	129.0	2,998,047.1	1,510.6	1.4	0.8
09/22/2024 14:00	10.6	13.8	8.8	185.2	3,187,479.9	1,652.6	1.9	1.2
09/22/2024 15:00	10.2	13.9	8.6	128.0	2,876,378.1	1,470.3	1.4	0.7
09/22/2024 16:00	10.2	13.9	8.6	128.7	2,902,984.1	1,483.9	1.4	0.7
09/22/2024 17:00	10.3	13.8	8.6	150.5	3,122,874.5	1,596.3	1.5	1.0
09/22/2024 18:00	11.3	13.2	8.7	170.2	3,213,032.6	1,947.4	1.7	1.4
09/22/2024 19:00	11.0	13.2	8.4	187.3	3,190,921.8	1,957.3	1.9	1.4
09/22/2024 20:00	10.8	13.2	8.3	178.8	3,197,523.4	1,938.0	1.8	1.4
09/22/2024 21:00	10.7	13.3	8.3	177.1	3,188,778.9	1,932.7	1.8	1.4
09/22/2024 22:00	10.5	13.3	8.2	179.7	3,232,179.7	1,911.8	1.8	1.3
09/22/2024 23:00	10.5	13.3	8.2	171.6	3,267,788.9	1,909.0	1.7	1.3
Average/Sum#:	12.3	14.1	12.1	163.4	2,980,947.4	1,573.1	1.8	1.0
Minimum:	9.8	13.2	8.2	128.0	1,574,579.7	391.9	1.4	0.4
Maximum:	32.5	17.6	53.3	196.0	3,278,903.5	1,957.3	3.4	1.4
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/23/2024 00:00	10.4	13.3	8.1	175.6	3,269,329.5	1,909.9	1.7	1.3
09/23/2024 01:00	10.4	13.3	8.1	177.4	3,265,734.8	1,907.8	1.8	1.3
09/23/2024 02:00	10.4	13.3	8.1	171.0	3,266,077.2	1,908.0	1.7	1.3
09/23/2024 03:00	10.4	13.3	8.1	177.5	3,268,644.8	1,909.5	1.8	1.3
09/23/2024 04:00	10.4	13.3	8.1	171.5	3,232,179.7	1,911.8	1.7	1.3
09/23/2024 05:00	10.4	13.3	8.1	176.1	3,210,201.3	1,898.8	1.8	1.3
09/23/2024 06:00	9.5	13.8	7.9	202.0	3,125,566.5	1,620.5	2.1	1.3
09/23/2024 07:00	10.2	13.8	8.5	131.1	3,055,185.8	1,561.7	1.4	0.8
09/23/2024 08:00	10.1	13.8	8.4	155.3	3,157,005.4	1,636.8	1.6	1.0
09/23/2024 09:00	10.0	13.8	8.3	129.2	2,941,914.8	1,503.8	1.4	0.8
09/23/2024 10:00	10.2	13.8	8.5	133.1	2,953,261.5	1,509.6	1.4	0.8
09/23/2024 11:00	10.6	13.7	8.7	164.1	3,156,619.6	1,636.6	1.7	1.1
09/23/2024 12:00	10.7	13.6	8.6	170.4	3,153,803.1	1,681.2	1.7	1.2
09/23/2024 13:00	10.9	13.6	8.8	171.4	3,153,803.1	1,681.2	1.8	1.2
09/23/2024 14:00	11.5	13.0	8.6	192.0	3,148,171.2	2,092.0	2.0	1.7
09/23/2024 15:00	11.2	12.9	8.3	218.9	3,138,895.5	2,154.6	2.3	1.9
09/23/2024 16:00	11.2	12.9	8.3	211.8	3,126,900.4	2,169.2	2.2	1.7
09/23/2024 17:00	11.2	12.9	8.3	222.9	3,110,875.7	2,180.8	2.4	2.0
09/23/2024 18:00	11.1	12.9	8.2	218.6	3,120,861.1	2,187.8	2.3	2.0
09/23/2024 19:00	11.1	12.9	8.2	214.6	3,176,920.4	2,203.9	2.2	1.8
09/23/2024 20:00	11.0	12.9	8.1	224.1	3,188,164.1	2,211.7	2.3	2.0
09/23/2024 21:00	10.9	12.9	8.0	210.5	3,183,839.6	2,208.7	2.2	1.8
09/23/2024 22:00	10.8	13.0	8.1	222.4	3,191,924.3	2,191.0	2.3	2.0
09/23/2024 23:00	10.5	13.1	7.9	195.9	3,203,823.4	2,035.4	2.0	1.6
Average/Sum#:	10.6	13.3	8.3	184.9	3,158,321.0	1,913.0	1.9	1.4
Minimum:	9.5	12.9	7.9	129.2	2,941,914.8	1,503.8	1.4	0.8
Maximum:	11.5	13.8	8.8	224.1	3,269,329.5	2,211.7	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/24/2024 00:00	9.8	13.8	8.1	161.8	3,250,550.6	1,685.3	1.6	1.0
09/24/2024 01:00	9.8	13.8	8.1	151.7	3,262,360.1	1,667.6	1.5	1.0
09/24/2024 02:00	9.7	13.8	8.1	146.6	3,191,150.1	1,631.2	1.5	1.0
09/24/2024 03:00	9.9	13.8	8.2	157.9	3,261,186.4	1,667.0	1.6	1.0
09/24/2024 04:00	9.9	13.8	8.2	156.3	3,234,541.8	1,677.0	1.6	1.0
09/24/2024 05:00	9.9	13.8	8.2	151.7	3,260,599.5	1,666.7	1.5	1.0
09/24/2024 06:00	9.8	13.8	8.1	145.6	3,137,717.7	1,626.8	1.5	1.0
09/24/2024 07:00	10.2	13.8	8.5	134.4	3,078,661.6	1,573.7	1.4	0.8
09/24/2024 08:00	10.1	13.8	8.4	130.9	2,936,828.4	1,501.2	1.4	0.8
09/24/2024 09:00	10.0	13.8	8.3	133.3	2,931,532.6	1,519.9	1.4	0.8
09/24/2024 10:00	10.2	13.8	8.5	137.5	2,991,131.5	1,550.8	1.5	0.9
09/24/2024 11:00	10.5	13.7	8.6	162.6	3,164,141.8	1,640.5	1.7	1.1
09/24/2024 12:00	10.0	13.9	8.4	125.2	2,715,177.3	1,387.9	1.5	0.8
09/24/2024 13:00	11.3	13.3	8.8	175.4	3,020,818.2	1,830.9	1.9	1.3
09/24/2024 14:00	11.3	12.9	8.3	217.3	3,081,204.9	2,137.5	2.3	1.9
09/24/2024 15:00	11.2	12.9	8.3	205.0	3,114,777.8	2,115.3	2.2	1.7
09/24/2024 16:00	11.2	12.9	8.3	220.3	3,098,502.9	2,149.5	2.3	1.9
09/24/2024 17:00	11.1	12.9	8.2	212.3	3,103,458.0	2,175.6	2.3	2.0
09/24/2024 18:00	11.0	12.9	8.1	214.0	3,108,016.8	2,156.1	2.3	1.9
09/24/2024 19:00	10.9	13.0	8.1	212.0	3,123,190.5	2,075.4	2.2	1.7
09/24/2024 20:00	11.0	13.0	8.2	215.2	3,175,278.4	2,133.2	2.2	1.7
09/24/2024 21:00	10.9	13.1	8.2	199.6	3,166,601.6	2,058.0	2.1	1.6
09/24/2024 22:00	10.9	13.1	8.2	198.4	3,168,564.7	2,013.0	2.1	1.6
09/24/2024 23:00	11.0	13.0	8.2	217.6	3,170,217.4	2,129.8	2.3	1.9
Average/Sum#:	10.5	13.4	8.3	174.3	3,114,425.4	1,823.7	1.8	1.3
Minimum:	9.7	12.9	8.1	125.2	2,715,177.3	1,387.9	1.4	0.8
Maximum:	11.3	13.9	8.8	220.3	3,262,360.1	2,175.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/25/2024 00:00	10.8	13.0	8.1	208.5	3,191,210.3	2,120.6	2.1	1.7
09/25/2024 01:00	10.8	13.0	8.1	204.7	3,182,998.7	2,091.9	2.1	1.7
09/25/2024 02:00	10.6	13.1	8.0	201.4	3,211,378.9	2,040.2	2.1	1.6
09/25/2024 03:00	10.7	13.0	8.0	205.2	3,228,610.3	2,098.3	2.1	1.7
09/25/2024 04:00	10.6	13.0	7.9	202.9	3,212,365.3	2,111.2	2.1	1.7
09/25/2024 05:00	10.5	13.0	7.8	201.2	3,243,535.5	2,108.0	2.0	1.7
09/25/2024 06:00	10.4	13.1	7.9	183.9	3,223,561.3	2,024.4	1.9	1.4
09/25/2024 07:00	0.0	0.0	0.0	188.8	1,715,515.3	689.0	3.9	1.0
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/25/2024 18:00	6.2	19.4	24.4	0.0	13,694.2	0.2	-0.5	0.0
09/25/2024 19:00	29.3	15.8	33.9	140.5	2,002,850.3	745.9	2.3	0.7
09/25/2024 20:00	10.0	13.8	8.3	129.1	2,878,491.5	1,492.4	1.4	0.7
09/25/2024 21:00	10.2	13.8	8.5	157.3	3,110,522.1	1,612.7	1.6	1.0
09/25/2024 22:00	9.8	13.9	8.3	110.9	2,731,610.4	1,396.3	1.3	0.7
09/25/2024 23:00	10.1	13.8	8.4	161.2	3,213,518.3	1,666.1	1.6	1.0
Average/Sum#:	11.5	14.0	11.4	164.0	2,725,704.5	1,585.5	1.7	1.2
Minimum:	6.2	13.0	7.8	0.0	13,694.2	0.2	-0.5	0.0
Maximum:	29.3	19.4	33.9	208.5	3,243,535.5	2,120.6	2.3	1.7
%SI	45.83	45.83	45.83	41.67	41.67	41.67	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/26/2024 00:00	9.9	13.8	8.2	157.0	3,258,072.8	1,689.2	1.5	1.0
09/26/2024 01:00	9.9	13.8	8.2	146.4	3,190,180.2	1,654.0	1.5	1.0
09/26/2024 02:00	9.8	13.8	8.1	144.5	3,145,239.9	1,630.7	1.5	1.0
09/26/2024 03:00	9.9	13.8	8.2	154.4	3,201,174.2	1,659.7	1.5	1.0
09/26/2024 04:00	9.9	13.8	8.2	148.9	3,241,678.3	1,680.7	1.5	1.0
09/26/2024 05:00	9.8	13.8	8.1	149.1	3,241,678.3	1,680.7	1.5	1.0
09/26/2024 06:00	9.6	13.8	8.0	136.0	3,131,159.9	1,623.4	1.4	0.8
09/26/2024 07:00	10.0	13.9	8.4	104.7	2,705,787.0	1,383.1	1.2	0.7
09/26/2024 08:00	21.9	16.1	26.9	163.5	1,498,993.0	569.2	3.4	0.7
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.2	14.1	10.3	144.9	2,957,107.1	1,507.9	1.7	0.9
Minimum:	9.6	13.8	8.0	104.7	1,498,993.0	569.2	1.2	0.7
Maximum:	21.9	16.1	26.9	163.5	3,258,072.8	1,689.2	3.4	1.0
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/27/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2024 13:00	33.1	17.5	57.4	0.0	1,311,223.8	306.4	-0.1	0.0
09/27/2024 14:00	28.7	15.0	28.7	161.9	2,391,618.4	1,030.4	2.2	0.8
09/27/2024 15:00	10.0	13.9	8.4	132.9	2,810,450.1	1,436.6	1.5	0.9
09/27/2024 16:00	10.5	13.8	8.7	144.8	2,933,847.1	1,521.1	1.6	0.9
09/27/2024 17:00	11.5	13.0	8.6	198.4	3,131,814.0	2,104.0	2.1	1.7
09/27/2024 18:00	11.3	12.9	8.3	193.2	3,134,555.4	2,197.4	2.0	1.8
09/27/2024 19:00	11.1	12.9	8.2	222.7	3,135,411.2	2,198.0	2.3	2.0
09/27/2024 20:00	11.0	12.9	8.1	211.2	3,144,968.7	2,204.7	2.2	1.8
09/27/2024 21:00	10.7	13.0	8.0	220.4	3,193,818.2	2,192.3	2.3	2.0
09/27/2024 22:00	10.5	13.0	7.8	202.7	3,189,103.5	2,119.2	2.1	1.7
09/27/2024 23:00	10.7	13.0	8.0	208.8	3,190,608.3	2,120.2	2.2	1.7
Average/Sum#:	14.5	13.7	14.6	172.5	2,869,765.3	1,766.4	1.9	1.4
Minimum:	10.0	12.9	7.8	0.0	1,311,223.8	306.4	-0.1	0.0
Maximum:	33.1	17.5	57.4	222.7	3,193,818.2	2,204.7	2.3	2.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/28/2024 00:00	10.5	13.0	7.8	206.5	3,189,554.9	2,119.5	2.1	1.7
09/28/2024 01:00	10.6	13.0	7.9	212.1	3,223,320.7	2,118.4	2.2	1.7
09/28/2024 02:00	10.5	13.0	7.8	205.1	3,218,451.6	2,115.2	2.1	1.7
09/28/2024 03:00	10.5	13.0	7.8	203.1	3,215,712.8	2,113.4	2.1	1.7
09/28/2024 04:00	10.6	13.0	7.9	210.7	3,211,756.7	2,110.8	2.2	1.7
09/28/2024 05:00	10.4	13.1	7.9	208.9	3,251,998.2	2,113.5	2.1	1.7
09/28/2024 06:00	10.5	13.1	7.9	194.8	3,267,055.3	2,004.0	2.0	1.6
09/28/2024 07:00	0.0	0.0	0.0	178.7	1,727,466.6	693.8	3.7	1.0
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2024 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.5	13.0	7.9	202.5	3,038,164.6	1,923.6	2.1	1.7
Minimum:	10.4	13.0	7.8	178.7	1,727,466.6	693.8	2.0	1.6
Maximum:	10.6	13.1	7.9	212.1	3,267,055.3	2,119.5	2.2	1.7
%SI	70.83	70.83	70.83	66.67	66.67	66.67	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/29/2024 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2024 14:00	31.5	17.6	56.3	0.0	1,400,346.9	317.0	-0.1	0.0
09/29/2024 15:00	22.3	14.8	21.6	124.8	2,419,840.2	1,077.9	1.7	0.8
09/29/2024 16:00	10.2	13.8	8.5	155.5	3,030,864.1	1,571.4	1.7	1.1
09/29/2024 17:00	10.7	13.6	8.6	162.0	3,201,264.0	1,706.5	1.6	1.0
09/29/2024 18:00	10.6	13.3	8.2	159.6	3,195,323.6	1,960.0	1.6	1.2
09/29/2024 19:00	10.5	13.0	7.8	216.1	3,213,681.8	2,159.0	2.2	1.7
09/29/2024 20:00	10.5	13.0	7.8	207.7	3,214,723.7	2,159.7	2.1	1.7
09/29/2024 21:00	10.0	13.1	7.6	190.2	3,236,510.0	2,079.8	1.9	1.5
09/29/2024 22:00	9.9	13.3	7.7	169.7	3,287,294.8	1,944.4	1.7	1.4
09/29/2024 23:00	10.3	13.1	7.8	192.3	3,279,540.6	2,131.4	1.9	1.5
Average/Sum#:	13.7	13.9	14.2	157.8	2,947,939.0	1,710.7	1.6	1.2
Minimum:	9.9	13.0	7.6	0.0	1,400,346.9	317.0	-0.1	0.0
Maximum:	31.5	17.6	56.3	216.1	3,287,294.8	2,159.7	2.2	1.7
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/30/2024 00:00	10.1	13.2	7.7	188.7	3,265,917.9	2,051.0	1.9	1.4
09/30/2024 01:00	10.0	13.3	7.8	167.2	3,310,925.8	1,934.2	1.6	1.2
09/30/2024 02:00	10.0	13.3	7.8	166.9	3,276,474.6	1,938.0	1.7	1.4
09/30/2024 03:00	10.2	13.3	7.9	172.4	3,309,998.9	1,982.0	1.7	1.4
09/30/2024 04:00	10.1	13.2	7.7	185.0	3,280,089.9	2,059.9	1.8	1.4
09/30/2024 05:00	10.1	13.2	7.7	190.4	3,378,497.3	2,121.7	1.8	1.5
09/30/2024 06:00	10.2	13.1	7.7	203.7	3,405,616.8	2,163.6	2.0	1.7
09/30/2024 07:00	10.2	13.5	8.1	161.4	3,229,414.7	1,863.0	1.6	1.1
09/30/2024 08:00	9.1	14.0	7.8	90.5	2,615,799.0	1,318.0	1.1	0.5
09/30/2024 09:00	8.8	14.0	7.5	88.2	2,645,002.9	1,313.4	1.0	0.5
09/30/2024 10:00	8.8	14.0	7.5	88.7	2,648,426.5	1,315.1	1.0	0.5
09/30/2024 11:00	8.8	14.0	7.5	103.6	2,875,388.4	1,427.8	1.1	0.6
09/30/2024 12:00	9.0	14.0	7.7	115.9	3,104,227.1	1,564.1	1.2	0.8
09/30/2024 13:00	9.7	13.8	8.1	152.1	3,215,832.8	1,667.3	1.5	1.0
09/30/2024 14:00	10.7	13.1	8.1	175.8	3,277,540.3	2,130.1	1.7	1.5
09/30/2024 15:00	10.4	13.1	7.9	188.8	3,279,694.5	2,131.5	1.9	1.5
09/30/2024 16:00	10.6	13.0	7.9	218.0	3,248,274.6	2,253.4	2.2	1.8
09/30/2024 17:00	10.4	13.0	7.8	213.0	3,265,860.9	2,265.6	2.2	1.8
09/30/2024 18:00	10.3	13.0	7.7	209.4	3,275,807.3	2,272.5	2.1	1.8
09/30/2024 19:00	10.3	13.0	7.7	219.2	3,280,420.1	2,275.7	2.2	1.8
09/30/2024 20:00	10.2	13.0	7.6	209.1	3,306,266.8	2,221.2	2.1	1.8
09/30/2024 21:00	10.3	13.0	7.7	209.9	3,289,645.7	2,282.1	2.1	1.8
09/30/2024 22:00	9.9	13.0	7.4	202.3	3,345,308.1	2,223.0	2.0	1.8
09/30/2024 23:00	9.8	13.2	7.5	187.9	3,339,034.4	2,121.3	1.8	1.5
Average/Sum#:	9.9	13.3	7.7	171.2	3,186,227.7	1,954.0	1.7	1.3
Minimum:	8.8	13.0	7.4	88.2	2,615,799.0	1,313.4	1.0	0.5
Maximum:	10.7	14.0	8.1	219.2	3,405,616.8	2,282.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:48 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:48 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,655.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 553.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,655.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:50 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:51 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,555.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 653.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,555.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation and NH3 Injection)

FCD:	AQ-23, 26
Title V:	#6, 13

Emissions Limits Per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions are based on CT1 and CT2.
2. VOC Mass Emissions are based on Average Souce Test Results for lbs/MMBtu. CT1 EF = .0009 Prior to 10/30/2013 and .0007 After 10/30/2013. CT2 EF = .0007 Prior to 11/01/2014 and .0003 after 11/01/2014.
3. PM10 is based on 2010 lb/MMBtu Source Test Results. CT1 EF = .0025; CT2 EF = .003

Cumulative Emissions Report

From: 01/01/2024 00:00 **To:** 10/02/2024 10:50 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:51 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	5.9	2.0	0.7	4.1	0.9
February	4.9	2.0	0.6	3.2	0.7
March	2.6	1.4	0.2	1.4	0.3
April	0.0	0.0	0.0	0.0	0.0
May	1.4	0.6	0.1	0.6	0.1
June	2.8	1.8	0.2	1.2	0.3
July	5.4	1.4	0.6	3.3	0.7
August	4.6	1.4	0.5	2.6	0.6
September	4.1	1.3	0.4	2.3	0.5
October	0.2	0.0	0.0	0.1	0.0
Quarter 1	13.4	5.4	1.5	8.7	1.9
Quarter 2	4.2	2.4	0.3	1.8	0.4
Quarter 3	14.1	4.1	1.5	8.2	1.8
Quarter 4	0.2	0.0	0.0	0.1	0.0
YTD	31.9	11.9	3.3	18.8	4.1

Cumulative Emissions Report

CT1

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:52 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
July	10,290,489	1,427,352	11,717,838.0	657	162.3
August	7,906,371	1,084,923	8,991,292.7	503	157.6
September	7,609,356	1,047,309	8,656,663.7	495	161.0
Quarter 3	25,806,216	3,559,584	29,365,794.4	1,655	160.3
YTD	25,806,216	3,559,584	29,365,794.4	1,655	160.3

Cumulative Emissions Report

CT2

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:53 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
July	9,732,107	1,359,779	11,091,885.9	624	111,566.6
August	7,903,441	1,042,655	8,946,093.1	514	90,191.7
September	6,521,312	993,427	7,514,738.5	417	75,177.2
Quarter 3	24,156,860	3,395,861	27,552,717.5	1,555	276,935.5
YTD	24,156,860	3,395,861	27,552,717.5	1,555	276,935.5

Monthly Summary By Day Report

VOC PM10

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
07/01/2024	17.1	61.7	5.2	51.7
07/02/2024	15.6	56.2	4.6	45.2
07/03/2024	34.9	124.6	14.5	148.9
07/04/2024	20.2	72.8	6.7	67.7
07/05/2024	31.6	113.0	13.2	135.9
07/06/2024	26.0	93.1	9.2	93.1
07/07/2024	14.5	51.7	7.9	80.2
07/08/2024	30.7	110.1	13.1	131.9
07/09/2024	35.9	129.1	15.4	154.0
07/10/2024	35.8	127.5	15.4	152.1
07/11/2024	30.7	110.2	13.0	131.1
07/12/2024	27.0	98.0	11.5	116.9
07/13/2024	26.6	95.8	11.3	115.1
07/14/2024	19.2	68.2	6.4	64.7
07/15/2024	29.7	106.4	12.7	127.5
07/16/2024	30.6	109.4	13.0	131.3
07/17/2024	30.8	111.0	13.3	132.8
07/18/2024	35.5	128.2	15.6	153.4
07/19/2024	33.8	121.9	14.6	146.4
07/20/2024	32.9	119.2	14.4	143.2
07/21/2024	25.2	91.7	3.9	36.3
07/22/2024	32.9	118.0	11.6	117.4
07/23/2024	35.9	129.3	15.7	155.8
07/24/2024	35.6	128.3	14.8	152.7
07/25/2024	36.0	129.1	14.7	152.8
07/26/2024	34.9	124.3	14.6	147.4
07/27/2024	22.6	81.4	8.0	79.3
07/28/2024	9.1	32.4	8.8	86.3
07/29/2024	14.1	50.0	5.7	56.3
07/30/2024	14.8	53.5	4.7	46.9
07/31/2024	32.2	115.8	13.8	138.6
Monthly Avg/Sum*:	852.4 *	3,061.9 *	347.3 *	3,492.9 *
Daily Min:	9.1	32.4	3.9	36.3
Daily Max:	36.0	129.3	15.7	155.8
Jul 2024 - Jul 2024	852.4	3,061.9	347.3	3,492.9
QTD:	852.4 *	3,061.9 *	347.3 *	3,492.9 *
YTD 2024:	3,494.6 *	12,487.5 *	1,487.8 *	14,815.9 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
08/01/2024	34.2	122.1	14.5	146.1
08/02/2024	36.0	129.7	16.8	160.3
08/03/2024	35.8	126.7	14.9	149.4
08/04/2024	32.3	115.2	13.9	137.6
08/05/2024	35.6	127.7	15.5	152.1
08/06/2024	35.3	125.9	14.7	147.6
08/07/2024	35.4	126.1	14.7	148.0
08/08/2024	30.6	109.1	13.0	130.6
08/09/2024	26.2	93.8	11.2	112.0
08/10/2024	0.0	0.0	4.7	48.2
08/11/2024	0.0	0.0	0.0	0.0
08/12/2024	10.7	38.1	2.2	22.1
08/13/2024	2.2	8.0	4.2	41.9
08/14/2024	0.0	0.0	7.2	73.4
08/15/2024	7.5	26.4	5.1	52.7
08/16/2024	21.7	77.6	7.5	76.4
08/17/2024	9.2	33.0	8.6	85.9
08/18/2024	17.2	61.3	6.5	64.6
08/19/2024	15.5	54.7	9.1	88.2
08/20/2024	19.0	67.7	6.2	61.5
08/21/2024	31.0	111.3	13.2	131.2
08/22/2024	20.2	71.7	3.7	36.5
08/23/2024	9.5	33.4	0.0	0.0
08/24/2024	0.0	0.0	0.0	0.0
08/25/2024	12.9	46.7	0.0	0.0
08/26/2024	33.0	117.3	9.8	97.1
08/27/2024	31.1	111.1	13.5	131.8
08/28/2024	35.0	125.0	14.7	148.2
08/29/2024	30.8	109.9	13.1	130.9
08/30/2024	31.9	113.9	13.6	135.1
08/31/2024	22.3	79.1	11.3	110.7
Monthly Avg/Sum*:	662.1 *	2,362.5 *	283.4 *	2,820.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	36.0	129.7	16.8	160.3
Jul 2024 - Aug 2024	1,514.5	5,424.4	630.7	6,313.0
QTD:	1,514.5 *	5,424.4 *	630.7 *	6,313.0 *
YTD 2024:	4,156.7 *	14,850.0 *	1,771.2 *	17,636.0 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
09/01/2024	25.3	90.5	9.1	91.3
09/02/2024	26.7	94.5	9.6	95.8
09/03/2024	36.0	128.0	15.4	152.1
09/04/2024	32.6	117.3	13.7	138.8
09/05/2024	34.7	124.5	15.1	148.1
09/06/2024	36.6	131.0	15.8	155.8
09/07/2024	36.9	132.1	16.1	157.0
09/08/2024	33.2	118.1	14.4	140.7
09/09/2024	35.7	127.6	15.1	152.1
09/10/2024	28.0	100.4	12.2	119.9
09/11/2024	0.0	0.0	0.0	0.0
09/12/2024	5.7	20.3	0.0	0.0
09/13/2024	20.7	73.3	2.4	23.5
09/14/2024	10.6	37.7	1.4	14.4
09/15/2024	6.9	24.7	0.0	0.0
09/16/2024	8.7	30.8	0.0	0.0
09/17/2024	2.3	8.0	0.0	0.0
09/18/2024	33.0	116.5	12.8	128.3
09/19/2024	10.5	37.3	4.3	44.4
09/20/2024	0.0	0.0	0.0	0.0
09/21/2024	0.0	0.0	1.0	9.3
09/22/2024	11.2	39.9	10.2	101.8
09/23/2024	32.2	115.6	14.3	137.5
09/24/2024	30.9	110.1	13.0	131.3
09/25/2024	19.8	70.4	6.3	65.1
09/26/2024	21.3	75.6	3.9	39.4
09/27/2024	18.9	67.6	5.8	57.9
09/28/2024	20.1	71.0	4.3	44.6
09/29/2024	17.9	64.1	4.9	50.8
09/30/2024	33.0	118.4	14.1	140.8
Monthly Avg/Sum*:	629.4 *	2,245.3 *	235.2 *	2,340.7 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	36.9	132.1	16.1	157.0
Jul 2024 - Sep 2024	2,143.9	7,669.7	865.9	8,653.7
QTD:	2,143.9 *	7,669.7 *	865.9 *	8,653.7 *
YTD 2024:	4,786.1 *	17,095.3 *	2,006.4 *	19,976.7 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
07/01/2024	84.0	153.40	14.7	92.5	147.30	10.1
07/02/2024	70.4	186.10	13.4	70.7	150.00	9.0
07/03/2024	0.0	199.70	29.8	49.0	198.40	29.1
07/04/2024	87.9	151.64	17.4	90.5	147.28	13.5
07/05/2024	0.0	181.00	27.1	42.1	181.00	27.3
07/06/2024	55.1	163.54	22.6	72.3	147.40	18.7
07/07/2024	92.8	128.46	12.3	89.4	158.73	15.9
07/08/2024	0.0	176.10	26.1	34.8	176.10	26.2
07/09/2024	0.0	183.50	30.9	27.0	171.40	30.8
07/10/2024	0.0	204.30	30.5	36.2	202.70	30.2
07/11/2024	0.0	176.30	26.6	36.4	174.90	26.1
07/12/2024	0.0	153.00	23.5	35.7	155.70	23.3
07/13/2024	0.0	153.30	22.5	38.2	153.40	22.6
07/14/2024	84.2	164.41	16.3	93.4	149.38	12.8
07/15/2024	0.0	170.30	25.4	39.0	169.80	25.3
07/16/2024	0.0	173.40	25.9	36.0	173.50	25.8
07/17/2024	0.0	177.40	26.3	35.7	177.30	26.2
07/18/2024	0.0	205.40	30.7	38.2	204.70	30.6
07/19/2024	0.0	194.60	29.0	33.3	195.00	29.2
07/20/2024	0.0	186.00	28.5	30.9	191.00	28.5
07/21/2024	135.8	175.86	21.8	17.7	50.70	7.2
07/22/2024	0.0	188.20	28.3	122.5	224.72	23.4
07/23/2024	0.0	204.40	31.1	25.0	207.70	30.9
07/24/2024	0.0	205.10	30.7	30.4	203.40	30.6
07/25/2024	0.0	206.30	31.2	29.6	203.50	30.7
07/26/2024	0.0	198.90	29.9	39.6	196.70	29.5
07/27/2024	95.9	148.85	19.5	108.5	170.27	16.0
07/28/2024	7.4	51.53	7.8	142.8	168.71	17.2
07/29/2024	178.1	167.44	12.0	146.8	151.06	11.1
07/30/2024	162.0	175.32	12.7	124.2	151.52	9.4
07/31/2024	0.0	185.20	27.9	26.1	184.60	27.9
Monthly Avg/Sum*:	1,053.6 *	5,388.95 *	732.4 *	1,834.5 *	5,337.87 *	695.1 *
Daily Min:	0.0	51.53	7.8	17.7	50.70	7.2
Daily Max:	178.1	206.30	31.2	146.8	224.72	30.9
Jul 2024 - Jul 2024	1,053.6	5,388.95	732.4	1,834.5	5,337.87	695.1
QTD:	1,053.6 *	5,388.95 *	732.4 *	1,834.5 *	5,337.87 *	695.1 *
YTD 2024:	9,691.4 *	22,941.54 *	2,993.2 *	8,725.4 *	23,019.68 *	2,965.9 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
08/01/2024	0.0	195.50	29.3	26.8	193.00	28.9
08/02/2024	0.0	207.40	31.2	16.4	213.70	31.6
08/03/2024	0.0	201.10	30.9	30.9	197.60	29.8
08/04/2024	0.0	184.30	28.0	29.1	183.70	27.4
08/05/2024	0.0	197.70	30.8	32.9	202.90	30.3
08/06/2024	0.0	190.40	30.4	37.3	196.20	29.7
08/07/2024	0.0	201.50	30.5	38.1	197.30	29.6
08/08/2024	0.0	173.10	26.1	27.9	173.80	25.8
08/09/2024	9.1	151.03	22.6	32.4	150.82	22.1
08/10/2024	0.0	0.00	0.0	130.9	160.38	9.9
08/11/2024	0.0	0.00	0.0	0.0	0.00	0.0
08/12/2024	123.3	147.79	9.1	144.3	117.32	4.4
08/13/2024	6.8	13.58	1.9	152.9	157.61	8.5
08/14/2024	0.0	0.00	0.0	98.4	179.14	14.5
08/15/2024	89.2	121.38	6.3	119.0	171.74	10.6
08/16/2024	88.3	162.28	18.6	102.5	173.97	15.5
08/17/2024	10.5	52.38	7.8	82.1	173.68	17.4
08/18/2024	155.4	192.73	14.7	95.2	165.68	12.9
08/19/2024	95.2	171.99	13.2	67.1	160.18	17.7
08/20/2024	110.3	171.39	16.3	105.7	175.93	12.1
08/21/2024	0.0	178.10	26.6	21.2	174.80	26.0
08/22/2024	71.1	177.84	17.3	9.4	48.10	7.4
08/23/2024	6.0	53.42	8.1	0.0	0.00	0.0
08/24/2024	0.0	0.00	0.0	0.0	0.00	0.0
08/25/2024	177.1	233.79	11.2	0.0	0.00	0.0
08/26/2024	0.0	187.60	28.2	118.0	181.92	19.2
08/27/2024	0.0	176.00	26.8	23.8	176.00	26.5
08/28/2024	0.0	197.60	29.9	25.2	197.60	29.5
08/29/2024	0.0	173.70	26.2	29.3	174.40	26.0
08/30/2024	0.0	180.70	27.2	24.9	180.30	26.8
08/31/2024	69.9	168.07	19.1	71.6	164.41	22.1
Monthly Avg/Sum*:	1,012.2 *	4,462.37 *	568.3 *	1,693.3 *	4,642.18 *	562.2 *
Daily Min:	0.0	13.58	1.9	9.4	48.10	4.4
Daily Max:	177.1	233.79	31.2	152.9	213.70	31.6
Jul 2024 - Aug 2024	2,065.8	9,851.32	1,300.7	3,527.8	9,980.05	1,257.3
QTD:	2,065.8 *	9,851.32 *	1,300.7 *	3,527.8 *	9,980.05 *	1,257.3 *
YTD 2024:	10,703.6 *	27,403.91 *	3,561.5 *	10,418.7 *	27,661.86 *	3,528.1 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
09/01/2024	75.4	165.55	21.7	65.8	172.02	18.2
09/02/2024	91.7	173.73	22.8	96.9	189.55	19.3
09/03/2024	0.0	202.50	31.0	24.0	200.70	30.6
09/04/2024	0.0	187.70	27.9	20.1	185.20	27.3
09/05/2024	0.0	183.50	29.5	17.6	192.90	29.5
09/06/2024	0.0	209.60	31.2	17.3	205.50	31.1
09/07/2024	0.0	206.60	31.8	17.4	205.20	31.6
09/08/2024	0.0	189.00	28.2	16.9	185.60	28.1
09/09/2024	0.0	202.10	30.8	17.8	202.70	30.5
09/10/2024	7.4	159.80	24.1	30.7	160.90	24.1
09/11/2024	0.0	0.00	0.0	0.0	0.00	0.0
09/12/2024	119.6	160.17	4.8	0.0	0.00	0.0
09/13/2024	58.1	179.71	17.4	106.9	133.56	4.6
09/14/2024	229.3	156.09	8.9	14.2	21.71	2.9
09/15/2024	346.9	164.86	5.9	0.0	0.00	0.0
09/16/2024	14.7	51.15	7.4	0.0	0.00	0.0
09/17/2024	157.8	114.26	1.9	0.0	0.00	0.0
09/18/2024	0.0	186.60	28.3	136.0	257.03	26.1
09/19/2024	7.4	59.73	9.1	9.9	59.90	9.1
09/20/2024	0.0	0.00	0.0	0.0	0.00	0.0
09/21/2024	0.0	0.00	0.0	103.7	118.79	1.8
09/22/2024	84.8	164.20	9.9	84.2	184.61	20.4
09/23/2024	0.0	185.10	27.6	18.4	175.10	27.2
09/24/2024	0.0	176.30	26.4	15.3	175.20	26.2
09/25/2024	57.6	143.67	17.0	75.3	149.59	13.1
09/26/2024	56.9	164.95	18.1	10.8	54.52	7.9
09/27/2024	70.6	181.11	16.2	63.7	166.70	11.6
09/28/2024	39.4	161.20	17.2	10.3	61.14	9.1
09/29/2024	86.0	178.67	15.4	62.2	146.67	10.1
09/30/2024	0.0	186.70	28.4	14.6	185.60	28.4
Monthly Avg/Sum*:	1,503.6 *	4,494.55 *	538.9 *	1,050.0 *	3,790.39 *	468.8 *
Daily Min:	0.0	51.15	1.9	9.9	21.71	1.8
Daily Max:	346.9	209.60	31.8	136.0	257.03	31.6
Jul 2024 - Sep 2024	3,569.4	14,345.87	1,839.6	4,577.8	13,770.44	1,726.1
QTD:	3,569.4 *	14,345.87 *	1,839.6 *	4,577.8 *	13,770.44 *	1,726.1 *
YTD 2024:	12,207.2 *	31,898.46 *	4,100.4 *	11,468.7 *	31,452.25 *	3,996.9 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:55 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024	15.10	213,976.8	6.05	22,229.0	236,205.8	2,613.4	24,695.653
07/02/2024	13.50	193,216.7	5.60	21,586.1	214,802.8	2,271.7	22,446.900
07/03/2024	24.00	402,178.0	24.00	75,371.9	477,549.9	4,283.1	49,903.900
07/04/2024	16.80	253,786.9	8.47	24,741.0	278,527.9	2,828.7	29,106.253
07/05/2024	24.00	392,508.9	10.60	40,290.8	432,799.7	3,701.4	45,227.300
07/06/2024	20.45	314,426.9	13.00	42,073.3	356,500.2	3,619.6	37,254.300
07/07/2024	11.57	170,516.8	8.27	26,930.5	197,447.3	2,070.1	20,633.270
07/08/2024	24.00	392,482.4	7.05	28,785.5	421,267.9	3,624.1	44,022.500
07/09/2024	24.00	402,477.0	24.00	93,301.4	495,778.4	4,402.0	51,809.000
07/10/2024	24.00	399,850.1	24.00	88,884.1	488,734.2	4,521.4	51,072.800
07/11/2024	24.00	377,466.7	12.49	44,564.9	422,031.6	3,796.3	44,102.200
07/12/2024	24.00	354,220.7	5.97	20,565.7	374,786.4	3,138.7	39,165.300
07/13/2024	24.00	367,092.9	0.00	0.0	367,092.9	2,988.2	38,361.300
07/14/2024	15.92	239,486.8	6.01	22,307.4	261,794.2	2,499.9	27,357.366
07/15/2024	24.00	386,411.8	6.47	20,727.4	407,139.2	3,346.2	42,545.900
07/16/2024	24.00	388,372.4	8.07	30,649.0	419,021.4	3,432.7	43,787.600
07/17/2024	24.00	387,414.8	10.24	36,788.8	424,203.6	3,471.3	44,329.200
07/18/2024	24.00	404,634.6	24.00	87,029.3	491,663.9	4,503.2	51,378.800
07/19/2024	24.00	401,468.3	17.10	64,508.0	465,976.3	4,088.5	48,694.600
07/20/2024	24.00	390,780.8	16.10	64,991.1	455,771.9	4,068.9	47,628.100
07/21/2024	19.27	298,798.7	13.21	52,469.5	351,268.2	3,798.9	36,707.402
07/22/2024	24.00	391,138.0	15.25	59,152.7	450,290.7	4,005.5	47,055.400
07/23/2024	24.00	399,246.0	24.00	95,017.5	494,263.5	4,494.2	51,650.700
07/24/2024	24.00	403,295.1	24.00	87,761.3	491,056.4	4,391.7	51,315.300
07/25/2024	24.00	406,404.7	24.00	87,410.7	493,815.4	4,446.7	51,603.700
07/26/2024	24.00	406,135.4	24.00	69,450.5	475,585.9	4,118.0	49,698.700
07/27/2024	18.45	287,833.2	10.98	22,308.3	310,141.5	2,926.1	32,409.861
07/28/2024	7.17	115,399.8	4.97	8,504.4	123,904.2	1,185.8	12,947.829
07/29/2024	12.88	176,089.3	4.52	15,028.7	191,118.0	2,082.3	19,971.680
07/30/2024	13.70	185,046.3	5.48	20,063.2	205,109.5	2,144.0	21,433.960
07/31/2024	24.00	388,330.5	15.95	53,858.7	442,189.2	3,743.3	46,208.800
Monthly Avg/Sum*:	644.81 *	10,290,487.3 *	403.85 *	1,427,350.7 *	11,717,838.0 *	106,605.9 *	1,224,525.574 *
Daily Min:	7.17	115,399.8	0.00	0.0	123,904.2	1,185.8	12,947.829
Daily Max:	24.00	406,404.7	24.00	95,017.5	495,778.4	4,521.4	51,809.000
Jul 2024 - Jul 2024	644.81	10,290,487.3	403.85	1,427,350.7	11,717,838.0	106,605.9	1,224,525.574
QTD:	644.81 *	10,290,487.3 *	403.85 *	1,427,350.7 *	11,717,838.0 *	106,605.9 *	1,224,525.574 *
YTD 2024:	2,561.96 *	42,000,156.9 *	1,802.93 *	5,612,045.0 *	47,612,202.1 *	412,794.4 *	4,995,024.283 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:55 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024	24.00	401,360.5	17.87	63,640.3	465,000.8	4,172.8	48,871.600
08/02/2024	24.00	404,203.9	24.00	89,362.8	493,566.7	4,545.6	51,873.800
08/03/2024	24.00	402,117.4	24.00	80,955.9	483,073.3	4,432.3	50,770.800
08/04/2024	24.00	389,848.2	14.01	48,520.9	438,369.1	3,762.7	46,072.700
08/05/2024	24.00	404,905.0	24.00	80,684.4	485,589.4	4,077.9	51,035.400
08/06/2024	24.00	404,276.0	24.00	74,530.0	478,806.0	4,007.6	50,322.400
08/07/2024	24.00	402,807.7	24.00	76,832.4	479,640.1	4,129.9	50,409.900
08/08/2024	24.00	377,680.6	10.89	37,449.2	415,129.8	3,289.8	43,630.200
08/09/2024	21.28	335,639.0	6.04	20,777.1	356,416.1	2,868.9	37,459.512
08/10/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/11/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/12/2024	10.72	143,361.4	0.95	2,267.9	145,629.3	1,463.8	15,305.616
08/13/2024	2.25	30,365.4	0.00	0.0	30,365.4	366.7	3,191.450
08/14/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/15/2024	6.95	96,191.4	1.50	4,383.0	100,574.4	904.7	10,570.225
08/16/2024	17.93	267,842.6	8.05	26,809.9	294,652.5	2,849.9	30,967.840
08/17/2024	6.52	108,489.7	6.22	16,633.5	125,123.2	1,180.6	13,150.376
08/18/2024	14.75	209,287.7	5.93	23,566.8	232,854.5	2,335.7	24,472.900
08/19/2024	12.01	179,071.6	8.00	29,339.8	208,411.4	2,190.8	21,904.144
08/20/2024	15.90	231,724.1	7.97	26,025.6	257,749.7	2,537.9	27,089.590
08/21/2024	24.00	388,448.9	9.07	35,226.9	423,675.8	3,402.3	44,528.100
08/22/2024	15.92	250,537.6	12.72	23,150.4	273,688.0	2,626.7	28,764.622
08/23/2024	7.17	117,459.1	6.00	9,463.6	126,922.7	1,190.7	13,339.475
08/24/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/25/2024	10.70	156,095.4	5.75	22,074.1	178,169.5	1,945.0	18,725.690
08/26/2024	24.00	405,043.8	11.57	41,796.4	446,840.2	3,690.9	46,962.900
08/27/2024	24.00	381,794.5	12.76	40,516.4	422,310.9	3,407.0	44,384.900
08/28/2024	24.00	404,981.1	24.00	70,565.4	475,546.5	3,977.6	49,979.900
08/29/2024	24.00	382,222.2	14.04	35,760.0	417,982.2	3,325.8	43,930.000
08/30/2024	24.00	381,617.6	16.16	51,592.1	433,209.7	3,551.0	45,530.500
08/31/2024	15.68	248,996.7	12.45	52,998.8	301,995.5	3,022.9	31,739.877
Monthly Avg/Sum*:	493.78 *	7,906,369.1 *	331.95 *	1,084,923.6 *	8,991,292.7 *	79,257.5 *	944,984.417 *
Daily Min:	2.25	30,365.4	0.00	0.0	30,365.4	366.7	3,191.450
Daily Max:	24.00	405,043.8	24.00	89,362.8	493,566.7	4,545.6	51,873.800
Jul 2024 - Aug 2024	1,138.59	18,196,856.4	735.80	2,512,274.3	20,709,130.7	185,863.4	2,169,509.991
QTD:	1,138.59 *	18,196,856.4 *	735.80 *	2,512,274.3 *	20,709,130.7 *	185,863.4 *	2,169,509.991 *
YTD 2024:	3,055.74 *	49,906,526.0 *	2,134.88 *	6,696,968.6 *	56,603,494.8 *	492,051.9 *	5,940,008.700 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:55 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024	19.45	304,964.4	11.97	41,455.9	346,420.3	3,390.0	36,201.030
09/02/2024	20.62	326,922.6	13.50	35,026.8	361,949.4	3,424.6	37,823.662
09/03/2024	24.00	408,673.2	23.97	81,693.8	490,367.0	4,348.4	51,243.300
09/04/2024	24.00	399,067.7	11.02	49,431.0	448,498.7	3,738.0	46,868.400
09/05/2024	24.00	401,292.7	17.98	75,370.4	476,663.1	4,159.6	49,811.200
09/06/2024	24.00	404,693.1	24.00	96,169.0	500,862.1	4,543.0	52,340.100
09/07/2024	24.00	407,411.4	24.00	97,972.7	505,384.1	4,627.5	52,812.700
09/08/2024	24.00	394,265.1	15.03	57,545.0	451,810.1	3,822.7	47,214.100
09/09/2024	24.00	405,307.9	24.00	87,106.6	492,414.5	4,375.0	51,025.500
09/10/2024	23.25	355,412.4	13.02	33,679.1	389,091.5	3,262.8	40,076.450
09/11/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/12/2024	6.70	78,865.4	0.00	0.0	78,865.4	989.1	8,123.200
09/13/2024	18.21	276,763.9	2.29	8,634.7	285,398.6	2,558.3	29,395.962
09/14/2024	10.83	146,243.9	0.00	0.0	146,243.9	1,566.2	15,062.991
09/15/2024	7.99	95,904.3	0.00	0.0	95,904.3	1,228.3	9,878.033
09/16/2024	7.73	119,619.0	0.00	0.0	119,619.0	936.1	12,320.712
09/17/2024	3.92	31,262.4	0.00	0.0	31,262.4	672.3	3,219.956
09/18/2024	24.00	399,310.8	19.05	53,487.0	452,797.8	3,848.2	46,638.100
09/19/2024	7.25	119,697.9	6.97	25,326.0	145,023.9	1,511.5	14,937.500
09/20/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/21/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/22/2024	9.78	141,908.0	6.02	12,970.7	154,878.7	1,424.7	15,952.470
09/23/2024	24.00	391,740.0	16.00	57,414.0	449,154.0	4,036.7	46,262.900
09/24/2024	24.00	383,838.8	10.69	43,920.1	427,758.9	3,720.5	44,058.900
09/25/2024	16.54	248,516.2	6.98	24,379.2	272,895.4	2,744.5	28,108.333
09/26/2024	17.71	271,348.9	6.53	22,043.6	293,392.5	2,981.7	30,219.410
09/27/2024	15.84	229,277.6	8.01	33,419.7	262,697.3	2,721.2	27,057.809
09/28/2024	16.25	251,264.1	6.98	25,770.4	277,034.5	2,688.3	28,534.725
09/29/2024	15.72	228,499.5	6.05	20,528.8	249,028.3	2,360.2	25,649.979
09/30/2024	24.00	387,284.8	17.83	63,963.2	451,248.0	4,017.9	47,221.600
Monthly Avg/Sum*:	481.79 *	7,609,356.0 *	291.89 *	1,047,307.7 *	8,656,663.7 *	79,697.3 *	898,059.022 *
Daily Min:	3.92	31,262.4	0.00	0.0	31,262.4	672.3	3,219.956
Daily Max:	24.00	408,673.2	24.00	97,972.7	505,384.1	4,627.5	52,812.700
Jul 2024 - Sep 2024	1,620.38	25,806,212.4	1,027.69	3,559,582.0	29,365,794.4	265,560.7	3,067,569.013
QTD:	1,620.38 *	25,806,212.4 *	1,027.69 *	3,559,582.0 *	29,365,794.4 *	265,560.7 *	3,067,569.013 *
YTD 2024:	3,537.53 *	57,515,882.0 *	2,426.77 *	7,744,276.3 *	65,260,158.5 *	571,749.2 *	6,838,067.722 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:56 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024	15.10	213,976.8	6.05	22,229.0	236,205.8	2,613.4	24,695.653
07/02/2024	13.50	193,216.7	5.60	21,586.1	214,802.8	2,271.7	22,446.900
07/03/2024	24.00	402,178.0	24.00	75,371.9	477,549.9	4,283.1	49,903.900
07/04/2024	16.80	253,786.9	8.47	24,741.0	278,527.9	2,828.7	29,106.253
07/05/2024	24.00	392,508.9	10.60	40,290.8	432,799.7	3,701.4	45,227.300
07/06/2024	20.45	314,426.9	13.00	42,073.3	356,500.2	3,619.6	37,254.300
07/07/2024	11.57	170,516.8	8.27	26,930.5	197,447.3	2,070.1	20,633.270
07/08/2024	24.00	392,482.4	7.05	28,785.5	421,267.9	3,624.1	44,022.500
07/09/2024	24.00	402,477.0	24.00	93,301.4	495,778.4	4,402.0	51,809.000
07/10/2024	24.00	399,850.1	24.00	88,884.1	488,734.2	4,521.4	51,072.800
07/11/2024	24.00	377,466.7	12.49	44,564.9	422,031.6	3,796.3	44,102.200
07/12/2024	24.00	354,220.7	5.97	20,565.7	374,786.4	3,138.7	39,165.300
07/13/2024	24.00	367,092.9	0.00	0.0	367,092.9	2,988.2	38,361.300
07/14/2024	15.92	239,486.8	6.01	22,307.4	261,794.2	2,499.9	27,357.366
07/15/2024	24.00	386,411.8	6.47	20,727.4	407,139.2	3,346.2	42,545.900
07/16/2024	24.00	388,372.4	8.07	30,649.0	419,021.4	3,432.7	43,787.600
07/17/2024	24.00	387,414.8	10.24	36,788.8	424,203.6	3,471.3	44,329.200
07/18/2024	24.00	404,634.6	24.00	87,029.3	491,663.9	4,503.2	51,378.800
07/19/2024	24.00	401,468.3	17.10	64,508.0	465,976.3	4,088.5	48,694.600
07/20/2024	24.00	390,780.8	16.10	64,991.1	455,771.9	4,068.9	47,628.100
07/21/2024	19.27	298,798.7	13.21	52,469.5	351,268.2	3,798.9	36,707.402
07/22/2024	24.00	391,138.0	15.25	59,152.7	450,290.7	4,005.5	47,055.400
07/23/2024	24.00	399,246.0	24.00	95,017.5	494,263.5	4,494.2	51,650.700
07/24/2024	24.00	403,295.1	24.00	87,761.3	491,056.4	4,391.7	51,315.300
07/25/2024	24.00	406,404.7	24.00	87,410.7	493,815.4	4,446.7	51,603.700
07/26/2024	24.00	406,135.4	24.00	69,450.5	475,585.9	4,118.0	49,698.700
07/27/2024	18.45	287,833.2	10.98	22,308.3	310,141.5	2,926.1	32,409.861
07/28/2024	7.17	115,399.8	4.97	8,504.4	123,904.2	1,185.8	12,947.829
07/29/2024	12.88	176,089.3	4.52	15,028.7	191,118.0	2,082.3	19,971.680
07/30/2024	13.70	185,046.3	5.48	20,063.2	205,109.5	2,144.0	21,433.960
07/31/2024	24.00	388,330.5	15.95	53,858.7	442,189.2	3,743.3	46,208.800
Monthly Avg/Sum*:	644.81 *	10,290,487.3 *	403.85 *	1,427,350.7 *	11,717,838.0 *	106,605.9 *	1,224,525.574 *
Daily Min:	7.17	115,399.8	0.00	0.0	123,904.2	1,185.8	12,947.829
Daily Max:	24.00	406,404.7	24.00	95,017.5	495,778.4	4,521.4	51,809.000
Jul 2024 - Jul 2024	644.81	10,290,487.3	403.85	1,427,350.7	11,717,838.0	106,605.9	1,224,525.574
QTD:	644.81 *	10,290,487.3 *	403.85 *	1,427,350.7 *	11,717,838.0 *	106,605.9 *	1,224,525.574 *
YTD 2024:	2,561.96 *	42,000,156.9 *	1,802.93 *	5,612,045.0 *	47,612,202.1 *	412,794.4 *	4,995,024.283 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:56 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024	24.00	401,360.5	17.87	63,640.3	465,000.8	4,172.8	48,871.600
08/02/2024	24.00	404,203.9	24.00	89,362.8	493,566.7	4,545.6	51,873.800
08/03/2024	24.00	402,117.4	24.00	80,955.9	483,073.3	4,432.3	50,770.800
08/04/2024	24.00	389,848.2	14.01	48,520.9	438,369.1	3,762.7	46,072.700
08/05/2024	24.00	404,905.0	24.00	80,684.4	485,589.4	4,077.9	51,035.400
08/06/2024	24.00	404,276.0	24.00	74,530.0	478,806.0	4,007.6	50,322.400
08/07/2024	24.00	402,807.7	24.00	76,832.4	479,640.1	4,129.9	50,409.900
08/08/2024	24.00	377,680.6	10.89	37,449.2	415,129.8	3,289.8	43,630.200
08/09/2024	21.28	335,639.0	6.04	20,777.1	356,416.1	2,868.9	37,459.512
08/10/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/11/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/12/2024	10.72	143,361.4	0.95	2,267.9	145,629.3	1,463.8	15,305.616
08/13/2024	2.25	30,365.4	0.00	0.0	30,365.4	366.7	3,191.450
08/14/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/15/2024	6.95	96,191.4	1.50	4,383.0	100,574.4	904.7	10,570.225
08/16/2024	17.93	267,842.6	8.05	26,809.9	294,652.5	2,849.9	30,967.840
08/17/2024	6.52	108,489.7	6.22	16,633.5	125,123.2	1,180.6	13,150.376
08/18/2024	14.75	209,287.7	5.93	23,566.8	232,854.5	2,335.7	24,472.900
08/19/2024	12.01	179,071.6	8.00	29,339.8	208,411.4	2,190.8	21,904.144
08/20/2024	15.90	231,724.1	7.97	26,025.6	257,749.7	2,537.9	27,089.590
08/21/2024	24.00	388,448.9	9.07	35,226.9	423,675.8	3,402.3	44,528.100
08/22/2024	15.92	250,537.6	12.72	23,150.4	273,688.0	2,626.7	28,764.622
08/23/2024	7.17	117,459.1	6.00	9,463.6	126,922.7	1,190.7	13,339.475
08/24/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/25/2024	10.70	156,095.4	5.75	22,074.1	178,169.5	1,945.0	18,725.690
08/26/2024	24.00	405,043.8	11.57	41,796.4	446,840.2	3,690.9	46,962.900
08/27/2024	24.00	381,794.5	12.76	40,516.4	422,310.9	3,407.0	44,384.900
08/28/2024	24.00	404,981.1	24.00	70,565.4	475,546.5	3,977.6	49,979.900
08/29/2024	24.00	382,222.2	14.04	35,760.0	417,982.2	3,325.8	43,930.000
08/30/2024	24.00	381,617.6	16.16	51,592.1	433,209.7	3,551.0	45,530.500
08/31/2024	15.68	248,996.7	12.45	52,998.8	301,995.5	3,022.9	31,739.877
Monthly Avg/Sum*:	493.78 *	7,906,369.1 *	331.95 *	1,084,923.6 *	8,991,292.7 *	79,257.5 *	944,984.417 *
Daily Min:	2.25	30,365.4	0.00	0.0	30,365.4	366.7	3,191.450
Daily Max:	24.00	405,043.8	24.00	89,362.8	493,566.7	4,545.6	51,873.800
Jul 2024 - Aug 2024	1,138.59	18,196,856.4	735.80	2,512,274.3	20,709,130.7	185,863.4	2,169,509.991
QTD:	1,138.59 *	18,196,856.4 *	735.80 *	2,512,274.3 *	20,709,130.7 *	185,863.4 *	2,169,509.991 *
YTD 2024:	3,055.74 *	49,906,526.0 *	2,134.88 *	6,696,968.6 *	56,603,494.8 *	492,051.9 *	5,940,008.700 *

Monthly Summary By Day Report

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:56 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024	19.45	304,964.4	11.97	41,455.9	346,420.3	3,390.0	36,201.030
09/02/2024	20.62	326,922.6	13.50	35,026.8	361,949.4	3,424.6	37,823.662
09/03/2024	24.00	408,673.2	23.97	81,693.8	490,367.0	4,348.4	51,243.300
09/04/2024	24.00	399,067.7	11.02	49,431.0	448,498.7	3,738.0	46,868.400
09/05/2024	24.00	401,292.7	17.98	75,370.4	476,663.1	4,159.6	49,811.200
09/06/2024	24.00	404,693.1	24.00	96,169.0	500,862.1	4,543.0	52,340.100
09/07/2024	24.00	407,411.4	24.00	97,972.7	505,384.1	4,627.5	52,812.700
09/08/2024	24.00	394,265.1	15.03	57,545.0	451,810.1	3,822.7	47,214.100
09/09/2024	24.00	405,307.9	24.00	87,106.6	492,414.5	4,375.0	51,025.500
09/10/2024	23.25	355,412.4	13.02	33,679.1	389,091.5	3,262.8	40,076.450
09/11/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/12/2024	6.70	78,865.4	0.00	0.0	78,865.4	989.1	8,123.200
09/13/2024	18.21	276,763.9	2.29	8,634.7	285,398.6	2,558.3	29,395.962
09/14/2024	10.83	146,243.9	0.00	0.0	146,243.9	1,566.2	15,062.991
09/15/2024	7.99	95,904.3	0.00	0.0	95,904.3	1,228.3	9,878.033
09/16/2024	7.73	119,619.0	0.00	0.0	119,619.0	936.1	12,320.712
09/17/2024	3.92	31,262.4	0.00	0.0	31,262.4	672.3	3,219.956
09/18/2024	24.00	399,310.8	19.05	53,487.0	452,797.8	3,848.2	46,638.100
09/19/2024	7.25	119,697.9	6.97	25,326.0	145,023.9	1,511.5	14,937.500
09/20/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/21/2024	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/22/2024	9.78	141,908.0	6.02	12,970.7	154,878.7	1,424.7	15,952.470
09/23/2024	24.00	391,740.0	16.00	57,414.0	449,154.0	4,036.7	46,262.900
09/24/2024	24.00	383,838.8	10.69	43,920.1	427,758.9	3,720.5	44,058.900
09/25/2024	16.54	248,516.2	6.98	24,379.2	272,895.4	2,744.5	28,108.333
09/26/2024	17.71	271,348.9	6.53	22,043.6	293,392.5	2,981.7	30,219.410
09/27/2024	15.84	229,277.6	8.01	33,419.7	262,697.3	2,721.2	27,057.809
09/28/2024	16.25	251,264.1	6.98	25,770.4	277,034.5	2,688.3	28,534.725
09/29/2024	15.72	228,499.5	6.05	20,528.8	249,028.3	2,360.2	25,649.979
09/30/2024	24.00	387,284.8	17.83	63,963.2	451,248.0	4,017.9	47,221.600
Monthly Avg/Sum*:	481.79 *	7,609,356.0 *	291.89 *	1,047,307.7 *	8,656,663.7 *	79,697.3 *	898,059.022 *
Daily Min:	3.92	31,262.4	0.00	0.0	31,262.4	672.3	3,219.956
Daily Max:	24.00	408,673.2	24.00	97,972.7	505,384.1	4,627.5	52,812.700
Jul 2024 - Sep 2024	1,620.38	25,806,212.4	1,027.69	3,559,582.0	29,365,794.4	265,560.7	3,067,569.013
QTD:	1,620.38 *	25,806,212.4 *	1,027.69 *	3,559,582.0 *	29,365,794.4 *	265,560.7 *	3,067,569.013 *
YTD 2024:	3,537.53 *	57,515,882.0 *	2,426.77 *	7,744,276.3 *	65,260,158.5 *	571,749.2 *	6,838,067.722 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
07/01/2024	300.7	176.5	22.3	113.4	24.8
07/02/2024	336.1	141.1	20.2	101.4	22.4
07/03/2024	398.1	49.0	49.4	273.5	58.9
07/04/2024	298.9	178.4	26.9	140.5	30.9
07/05/2024	362.0	42.1	44.8	248.9	54.4
07/06/2024	310.9	127.4	35.2	186.2	41.3
07/07/2024	287.2	182.2	22.4	131.9	28.2
07/08/2024	352.2	34.8	43.8	242.0	52.3
07/09/2024	354.9	27.0	51.3	283.1	61.7
07/10/2024	407.0	36.2	51.2	279.6	60.7
07/11/2024	351.2	36.4	43.7	241.3	52.7
07/12/2024	308.7	35.7	38.5	214.9	46.8
07/13/2024	306.7	38.2	37.9	210.9	45.1
07/14/2024	313.8	177.6	25.6	132.9	29.1
07/15/2024	340.1	39.0	42.4	233.9	50.7
07/16/2024	346.9	36.0	43.6	240.7	51.7
07/17/2024	354.7	35.7	44.1	243.8	52.5
07/18/2024	410.1	38.2	51.1	281.6	61.3
07/19/2024	389.6	33.3	48.4	268.3	58.2
07/20/2024	377.0	30.9	47.3	262.4	57.0
07/21/2024	226.6	153.5	29.1	128.0	29.0
07/22/2024	412.9	122.5	44.5	235.4	51.7
07/23/2024	412.1	25.0	51.6	285.1	62.0
07/24/2024	408.5	30.4	50.4	281.0	61.3
07/25/2024	409.8	29.6	50.7	281.9	61.9
07/26/2024	395.6	39.6	49.5	271.7	59.4
07/27/2024	319.2	204.4	30.6	160.7	35.5
07/28/2024	220.2	150.2	17.9	118.7	25.0
07/29/2024	318.5	324.9	19.8	106.3	23.1
07/30/2024	326.8	286.2	19.5	100.4	22.1
07/31/2024	369.8	26.1	46.0	254.4	55.8
Monthly Avg/Sum*:	10,726.8 *	2,888.1 *	1,199.7 *	6,554.8 *	1,427.5 *
Daily Min:	220.2	25.0	17.9	100.4	22.1
Daily Max:	412.9	324.9	51.6	285.1	62.0
Jul 2024 - Jul 2024	10,726.8	2,888.1	1,199.7	6,554.8	1,427.5
QTD:	10,726.8 *	2,888.1 *	1,199.7 *	6,554.8 *	1,427.5 *
YTD 2024:	45,961.4 *	18,416.8 *	4,982.4 *	27,303.4 *	5,959.1 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
08/01/2024	388.5	26.8	48.7	268.2	58.2
08/02/2024	421.1	16.4	52.8	290.0	62.8
08/03/2024	398.7	30.9	50.7	276.1	60.7
08/04/2024	368.0	29.1	46.2	252.8	55.4
08/05/2024	400.6	32.9	51.1	279.8	61.1
08/06/2024	386.6	37.3	50.0	273.5	60.1
08/07/2024	398.8	38.1	50.1	274.1	60.1
08/08/2024	346.9	27.9	43.6	239.7	51.9
08/09/2024	301.8	41.5	37.4	205.8	44.7
08/10/2024	160.4	130.9	4.7	48.2	9.9
08/11/2024	0.0	0.0	0.0	0.0	0.0
08/12/2024	265.1	267.6	12.9	60.2	13.5
08/13/2024	171.2	159.7	6.4	49.9	10.4
08/14/2024	179.1	98.4	7.2	73.4	14.5
08/15/2024	293.1	208.2	12.6	79.1	16.9
08/16/2024	336.3	190.8	29.2	154.0	34.1
08/17/2024	226.1	92.6	17.8	118.9	25.2
08/18/2024	358.4	250.6	23.7	125.9	27.6
08/19/2024	332.2	162.3	24.6	142.9	30.9
08/20/2024	347.3	216.0	25.2	129.2	28.4
08/21/2024	352.9	21.2	44.2	242.5	52.6
08/22/2024	225.9	80.5	23.9	108.2	24.7
08/23/2024	53.4	6.0	9.5	33.4	8.1
08/24/2024	0.0	0.0	0.0	0.0	0.0
08/25/2024	233.8	177.1	12.9	46.7	11.2
08/26/2024	369.5	118.0	42.8	214.4	47.4
08/27/2024	352.0	23.8	44.6	242.9	53.3
08/28/2024	395.2	25.2	49.7	273.2	59.4
08/29/2024	348.1	29.3	43.9	240.8	52.2
08/30/2024	361.0	24.9	45.5	249.0	54.0
08/31/2024	332.5	141.5	33.6	189.8	41.2
Monthly Avg/Sum*:	9,104.5 *	2,705.5 *	945.5 *	5,182.6 *	1,130.5 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	421.1	267.6	52.8	290.0	62.8
Jul 2024 - Aug 2024	19,831.3	5,593.6	2,145.2	11,737.4	2,558.0
QTD:	19,831.3 *	5,593.6 *	2,145.2 *	11,737.4 *	2,558.0 *
YTD 2024:	55,065.9 *	21,122.3 *	5,927.9 *	32,486.0 *	7,089.6 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
09/01/2024	337.6	141.2	34.4	181.8	39.9
09/02/2024	363.3	188.6	36.3	190.3	42.1
09/03/2024	403.2	24.0	51.4	280.1	61.6
09/04/2024	372.9	20.1	46.3	256.1	55.2
09/05/2024	376.4	17.6	49.8	272.6	59.0
09/06/2024	415.1	17.3	52.4	286.8	62.3
09/07/2024	411.8	17.4	53.0	289.1	63.4
09/08/2024	374.6	16.9	47.6	258.8	56.3
09/09/2024	404.8	17.8	50.8	279.7	61.3
09/10/2024	320.7	38.1	40.2	220.3	48.2
09/11/2024	0.0	0.0	0.0	0.0	0.0
09/12/2024	160.2	119.6	5.7	20.3	4.8
09/13/2024	313.3	165.0	23.1	96.8	22.0
09/14/2024	177.8	243.5	12.0	52.1	11.8
09/15/2024	164.9	346.9	6.9	24.7	5.9
09/16/2024	51.2	14.7	8.7	30.8	7.4
09/17/2024	114.3	157.8	2.3	8.0	1.9
09/18/2024	443.6	136.0	45.8	244.8	54.4
09/19/2024	119.6	17.3	14.8	81.7	18.2
09/20/2024	0.0	0.0	0.0	0.0	0.0
09/21/2024	118.8	103.7	1.0	9.3	1.8
09/22/2024	348.8	169.0	21.4	141.7	30.3
09/23/2024	360.2	18.4	46.5	253.1	54.8
09/24/2024	351.5	15.3	43.9	241.4	52.6
09/25/2024	293.3	132.9	26.1	135.5	30.1
09/26/2024	219.5	67.7	25.2	115.0	26.0
09/27/2024	347.8	134.3	24.7	125.5	27.8
09/28/2024	222.3	49.7	24.4	115.6	26.3
09/29/2024	325.4	148.2	22.8	114.9	25.5
09/30/2024	372.3	14.6	47.1	259.2	56.8
Monthly Avg/Sum*:	8,285.2 *	2,553.6 *	864.6 *	4,586.0 *	1,007.7 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	443.6	346.9	53.0	289.1	63.4
Jul 2024 - Sep 2024	28,116.5	8,147.2	3,009.8	16,323.4	3,565.7
QTD:	28,116.5 *	8,147.2 *	3,009.8 *	16,323.4 *	3,565.7 *
YTD 2024:	63,351.1 *	23,675.9 *	6,792.5 *	37,072.0 *	8,097.3 *

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/01/2024 00:00	4.4	21.6	0.2	0.9	0.2
07/01/2024 01:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 02:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 03:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/01/2024 08:00	23.6	15.8	0.1	0.5	0.1
07/01/2024 09:00	31.9	50.3	0.6	2.0	0.5
07/01/2024 10:00	6.4	0.0	1.1	4.0	1.0
07/01/2024 11:00	5.9	0.0	1.0	3.7	0.9
07/01/2024 12:00	5.7	0.0	1.0	3.5	0.8
07/01/2024 13:00	46.0	17.7	1.2	4.8	1.1
07/01/2024 14:00	45.8	46.3	1.4	6.6	1.4
07/01/2024 15:00	10.8	1.3	1.3	7.4	1.6
07/01/2024 16:00	12.5	1.5	1.6	8.6	1.8
07/01/2024 17:00	17.0	2.5	2.1	11.7	2.6
07/01/2024 18:00	17.6	1.6	2.2	12.1	2.6
07/01/2024 19:00	17.4	1.6	2.1	12.0	2.6
07/01/2024 20:00	17.3	1.6	2.1	11.9	2.6
07/01/2024 21:00	16.5	1.9	2.1	11.4	2.4
07/01/2024 22:00	16.5	1.9	2.0	11.3	2.4
07/01/2024 23:00	5.4	10.9	0.2	1.0	0.2
Average/Sum#:	300.7 #	176.5 #	22.3 #	113.4 #	24.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	46.0	50.3	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/02/2024 00:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 01:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 02:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 03:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/02/2024 10:00	34.0	13.4	0.1	0.4	0.1
07/02/2024 11:00	33.9	20.8	0.3	1.1	0.3
07/02/2024 12:00	36.5	36.2	0.7	2.5	0.6
07/02/2024 13:00	6.6	0.0	1.2	4.1	1.0
07/02/2024 14:00	6.3	0.0	1.1	3.9	0.9
07/02/2024 15:00	13.0	7.8	1.2	4.3	1.0
07/02/2024 16:00	87.7	49.8	1.3	6.0	1.3
07/02/2024 17:00	16.3	1.8	1.6	9.0	2.0
07/02/2024 18:00	14.8	2.4	1.9	10.2	2.2
07/02/2024 19:00	17.6	1.9	2.2	12.1	2.6
07/02/2024 20:00	17.4	1.9	2.2	12.0	2.6
07/02/2024 21:00	17.4	1.6	2.1	12.0	2.6
07/02/2024 22:00	16.9	1.9	2.1	11.6	2.6
07/02/2024 23:00	17.7	1.6	2.2	12.2	2.6
Average/Sum#:	336.1 #	141.1 #	20.2 #	101.4 #	22.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	87.7	49.8	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/03/2024 00:00	17.6	1.6	2.2	12.1	2.6
07/03/2024 01:00	16.8	1.9	2.1	11.5	2.6
07/03/2024 02:00	16.6	2.3	2.0	11.4	2.4
07/03/2024 03:00	16.4	2.3	2.0	11.2	2.4
07/03/2024 04:00	16.4	2.3	2.0	11.3	2.4
07/03/2024 05:00	16.4	2.3	2.0	11.3	2.4
07/03/2024 06:00	16.5	2.3	2.0	11.4	2.4
07/03/2024 07:00	16.6	2.3	2.1	11.4	2.4
07/03/2024 08:00	16.6	2.3	2.1	11.4	2.5
07/03/2024 09:00	16.7	1.9	2.1	11.4	2.5
07/03/2024 10:00	16.7	1.9	2.1	11.5	2.6
07/03/2024 11:00	16.6	1.9	2.1	11.4	2.5
07/03/2024 12:00	16.7	1.9	2.1	11.4	2.5
07/03/2024 13:00	16.7	1.9	2.1	11.4	2.5
07/03/2024 14:00	16.7	1.9	2.1	11.4	2.5
07/03/2024 15:00	16.7	1.6	2.1	11.5	2.5
07/03/2024 16:00	16.3	1.9	2.0	11.2	2.4
07/03/2024 17:00	16.3	2.2	2.0	11.2	2.4
07/03/2024 18:00	16.4	2.2	2.0	11.3	2.4
07/03/2024 19:00	16.5	1.9	2.1	11.4	2.4
07/03/2024 20:00	16.5	2.2	2.1	11.4	2.4
07/03/2024 21:00	16.5	1.9	2.0	11.4	2.4
07/03/2024 22:00	16.5	1.9	2.0	11.4	2.4
07/03/2024 23:00	16.4	2.2	2.0	11.2	2.4
Average/Sum#:	398.1 #	49.0 #	49.4 #	273.5 #	58.9 #
Minimum:	16.3	1.6	2.0	11.2	2.4
Maximum:	17.6	2.3	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/04/2024 00:00	16.1	2.6	2.0	11.0	2.4
07/04/2024 01:00	15.8	2.5	2.0	10.9	2.4
07/04/2024 02:00	4.1	14.3	0.2	1.0	0.2
07/04/2024 03:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/04/2024 09:00	14.4	14.2	0.1	0.5	0.1
07/04/2024 10:00	25.5	66.0	0.7	2.5	0.6
07/04/2024 11:00	6.4	0.0	1.1	4.0	1.0
07/04/2024 12:00	6.4	0.0	1.1	4.0	1.0
07/04/2024 13:00	29.2	11.7	1.1	4.3	1.0
07/04/2024 14:00	41.2	50.3	1.3	6.2	1.4
07/04/2024 15:00	12.2	1.4	1.6	8.4	1.8
07/04/2024 16:00	13.6	1.9	1.7	9.3	2.0
07/04/2024 17:00	14.6	2.1	1.8	10.1	2.2
07/04/2024 18:00	17.2	1.6	2.1	11.8	2.6
07/04/2024 19:00	17.0	1.6	2.1	11.6	2.6
07/04/2024 20:00	16.5	1.9	2.0	11.4	2.4
07/04/2024 21:00	16.4	1.9	2.0	11.3	2.4
07/04/2024 22:00	16.3	2.2	2.0	11.2	2.4
07/04/2024 23:00	16.0	2.2	2.0	11.0	2.4
Average/Sum#:	298.9 #	178.4 #	26.9 #	140.5 #	30.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	41.2	66.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/05/2024 00:00	13.8	1.6	1.7	9.5	2.0
07/05/2024 01:00	13.8	1.9	1.7	9.5	2.0
07/05/2024 02:00	13.7	2.2	1.7	9.4	2.0
07/05/2024 03:00	13.9	1.9	1.7	9.5	2.0
07/05/2024 04:00	13.0	1.8	1.6	8.9	2.0
07/05/2024 05:00	13.2	1.9	1.7	9.1	2.0
07/05/2024 06:00	14.0	1.9	1.7	9.7	2.1
07/05/2024 07:00	14.0	1.9	1.7	9.7	2.1
07/05/2024 08:00	14.0	1.9	1.7	9.7	2.2
07/05/2024 09:00	14.0	1.9	1.7	9.7	2.2
07/05/2024 10:00	13.9	1.9	1.7	9.5	2.0
07/05/2024 11:00	13.8	1.9	1.7	9.5	2.0
07/05/2024 12:00	12.4	1.7	1.6	8.6	1.8
07/05/2024 13:00	14.8	2.7	1.9	10.1	2.2
07/05/2024 14:00	17.2	1.5	2.1	11.9	2.6
07/05/2024 15:00	16.9	1.5	2.1	11.6	2.6
07/05/2024 16:00	16.9	1.5	2.1	11.6	2.6
07/05/2024 17:00	16.9	1.5	2.1	11.6	2.6
07/05/2024 18:00	16.9	1.5	2.1	11.6	2.6
07/05/2024 19:00	16.9	1.5	2.1	11.6	2.6
07/05/2024 20:00	16.9	1.6	2.1	11.6	2.6
07/05/2024 21:00	17.5	1.3	2.2	12.0	2.6
07/05/2024 22:00	17.1	1.2	2.1	11.7	2.6
07/05/2024 23:00	16.5	1.9	2.0	11.3	2.4
Average/Sum#:	362.0 #	42.1 #	44.8 #	248.9 #	54.4 #
Minimum:	12.4	1.2	1.6	8.6	1.8
Maximum:	17.5	2.7	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/06/2024 00:00	16.2	1.9	2.0	11.2	2.4
07/06/2024 01:00	16.1	2.2	2.0	11.0	2.4
07/06/2024 02:00	16.1	2.2	2.0	11.0	2.4
07/06/2024 03:00	16.1	2.2	2.0	11.1	2.4
07/06/2024 04:00	16.1	2.3	2.0	11.0	2.4
07/06/2024 05:00	16.0	2.2	2.0	11.0	2.4
07/06/2024 06:00	1.4	8.0	0.2	1.0	0.2
07/06/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/06/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/06/2024 09:00	0.0	1.5	0.0	0.1	0.0
07/06/2024 10:00	17.2	45.6	0.6	2.1	0.5
07/06/2024 11:00	6.4	0.0	1.1	4.0	1.0
07/06/2024 12:00	6.4	0.0	1.1	4.0	1.0
07/06/2024 13:00	6.4	0.0	1.1	4.0	1.0
07/06/2024 14:00	35.7	44.5	1.3	6.2	1.4
07/06/2024 15:00	11.6	1.4	1.4	8.0	1.8
07/06/2024 16:00	12.4	1.7	1.6	8.6	1.8
07/06/2024 17:00	16.8	2.2	2.1	11.6	2.6
07/06/2024 18:00	14.9	1.5	2.1	11.7	2.6
07/06/2024 19:00	16.9	1.8	2.1	11.6	2.6
07/06/2024 20:00	16.9	1.8	2.1	11.6	2.6
07/06/2024 21:00	16.9	1.6	2.1	11.6	2.6
07/06/2024 22:00	16.9	1.6	2.1	11.7	2.6
07/06/2024 23:00	17.5	1.2	2.2	12.1	2.6
Average/Sum#:	309.5 #	119.4 #	35.2 #	186.2 #	41.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	35.7	45.6	2.2	12.1	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/07/2024 00:00	16.6	1.6	2.1	11.4	2.4
07/07/2024 01:00	16.2	1.9	2.0	11.2	2.4
07/07/2024 02:00	16.0	2.2	2.0	11.0	2.4
07/07/2024 03:00	3.4	19.4	0.2	0.9	0.2
07/07/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 10:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 11:00	0.0	0.0	0.0	0.0	0.0
07/07/2024 12:00	54.0	59.2	0.2	2.2	0.4
07/07/2024 13:00	5.9	1.4	0.4	4.4	0.9
07/07/2024 14:00	5.7	1.1	0.4	4.3	0.9
07/07/2024 15:00	16.1	13.0	0.6	5.1	1.1
07/07/2024 16:00	48.1	72.3	1.0	6.5	1.3
07/07/2024 17:00	9.7	1.0	1.4	7.6	1.6
07/07/2024 18:00	13.7	1.4	1.7	9.5	2.0
07/07/2024 19:00	17.2	1.5	2.2	11.8	2.6
07/07/2024 20:00	15.0	1.2	2.1	11.9	2.6
07/07/2024 21:00	16.5	1.5	2.0	11.3	2.4
07/07/2024 22:00	16.3	1.9	2.0	11.2	2.4
07/07/2024 23:00	16.8	1.6	2.1	11.6	2.6
Average/Sum#:	287.2 #	182.2 #	22.4 #	131.9 #	28.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.0	72.3	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/08/2024 00:00	13.8	1.6	1.7	9.5	2.0
07/08/2024 01:00	13.6	1.6	1.7	9.4	2.0
07/08/2024 02:00	13.7	1.6	1.7	9.4	2.0
07/08/2024 03:00	13.7	1.6	1.7	9.5	2.0
07/08/2024 04:00	13.9	1.6	1.7	9.5	2.0
07/08/2024 05:00	14.0	1.6	1.7	9.7	2.1
07/08/2024 06:00	13.9	1.6	1.7	9.5	2.0
07/08/2024 07:00	13.8	1.6	1.7	9.5	2.0
07/08/2024 08:00	13.8	1.6	1.7	9.4	2.0
07/08/2024 09:00	13.7	1.5	1.7	9.4	2.0
07/08/2024 10:00	13.8	1.6	1.7	9.4	2.0
07/08/2024 11:00	13.7	1.5	1.7	9.4	2.0
07/08/2024 12:00	13.6	1.5	1.7	9.4	2.0
07/08/2024 13:00	12.8	1.5	1.6	8.8	2.0
07/08/2024 14:00	13.1	1.5	1.7	9.0	2.0
07/08/2024 15:00	13.4	1.5	1.7	9.2	2.0
07/08/2024 16:00	12.8	1.4	1.6	8.8	2.0
07/08/2024 17:00	16.9	1.8	2.1	11.6	2.6
07/08/2024 18:00	17.3	1.2	2.2	11.9	2.6
07/08/2024 19:00	17.3	0.9	2.2	12.0	2.6
07/08/2024 20:00	17.5	1.2	2.2	12.0	2.6
07/08/2024 21:00	17.3	1.2	2.1	11.8	2.6
07/08/2024 22:00	17.2	1.2	2.1	11.8	2.6
07/08/2024 23:00	17.6	0.9	2.2	12.1	2.6
Average/Sum#:	352.2 #	34.8 #	43.8 #	242.0 #	52.3 #
Minimum:	12.8	0.9	1.6	8.8	2.0
Maximum:	17.6	1.8	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/09/2024 00:00	17.6	0.9	2.2	12.1	2.6
07/09/2024 01:00	17.5	1.3	2.2	12.1	2.6
07/09/2024 02:00	17.5	1.3	2.2	12.0	2.6
07/09/2024 03:00	17.5	1.3	2.2	12.0	2.6
07/09/2024 04:00	17.9	1.3	2.3	12.3	2.6
07/09/2024 05:00	17.6	1.3	2.2	12.1	2.6
07/09/2024 06:00	16.3	2.2	2.0	11.1	2.4
07/09/2024 07:00	16.1	2.2	2.0	11.0	2.4
07/09/2024 08:00	8.6	0.0	2.1	11.7	2.6
07/09/2024 09:00	0.0	0.0	2.1	11.5	2.5
07/09/2024 10:00	0.0	0.0	2.1	11.6	2.6
07/09/2024 11:00	0.0	0.0	2.2	12.0	2.6
07/09/2024 12:00	19.6	1.2	2.2	11.9	2.6
07/09/2024 13:00	17.3	1.2	2.1	11.8	2.6
07/09/2024 14:00	17.1	1.2	2.1	11.8	2.6
07/09/2024 15:00	17.1	1.2	2.1	11.8	2.6
07/09/2024 16:00	17.3	1.2	2.1	11.8	2.6
07/09/2024 17:00	17.2	1.2	2.1	11.9	2.6
07/09/2024 18:00	17.0	1.2	2.1	11.6	2.6
07/09/2024 19:00	17.3	0.9	2.2	12.0	2.6
07/09/2024 20:00	17.4	1.2	2.2	11.9	2.6
07/09/2024 21:00	17.3	1.2	2.1	11.9	2.6
07/09/2024 22:00	17.2	1.6	2.1	11.8	2.6
07/09/2024 23:00	16.5	1.9	2.1	11.4	2.4
Average/Sum#:	346.3 #	27.0 #	51.3 #	283.1 #	61.7 #
Minimum:	16.1	0.9	2.0	11.0	2.4
Maximum:	19.6	2.2	2.3	12.3	2.6
%SI	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/10/2024 00:00	16.5	1.9	2.1	11.3	2.4
07/10/2024 01:00	17.6	1.3	2.2	12.1	2.6
07/10/2024 02:00	17.7	1.3	2.3	12.1	2.6
07/10/2024 03:00	17.7	1.3	2.3	12.1	2.6
07/10/2024 04:00	17.6	1.6	2.3	12.0	2.6
07/10/2024 05:00	17.3	1.6	2.1	11.9	2.6
07/10/2024 06:00	16.3	1.9	2.0	11.2	2.4
07/10/2024 07:00	15.9	2.2	2.0	10.9	2.4
07/10/2024 08:00	16.0	2.5	2.0	11.0	2.4
07/10/2024 09:00	16.1	2.2	2.0	11.1	2.4
07/10/2024 10:00	16.2	1.9	2.0	11.1	2.4
07/10/2024 11:00	16.4	1.8	2.1	11.3	2.4
07/10/2024 12:00	16.6	1.5	2.1	11.4	2.5
07/10/2024 13:00	17.2	1.2	2.1	11.9	2.6
07/10/2024 14:00	17.3	1.2	2.2	11.9	2.6
07/10/2024 15:00	16.9	1.2	2.1	11.6	2.6
07/10/2024 16:00	16.8	1.2	2.1	11.5	2.5
07/10/2024 17:00	16.7	1.2	2.1	11.5	2.5
07/10/2024 18:00	17.1	1.2	2.1	11.8	2.6
07/10/2024 19:00	17.3	1.2	2.2	11.9	2.6
07/10/2024 20:00	17.3	1.2	2.2	12.0	2.6
07/10/2024 21:00	17.5	1.2	2.2	12.0	2.6
07/10/2024 22:00	17.5	1.2	2.2	12.0	2.6
07/10/2024 23:00	17.5	1.2	2.2	12.0	2.6
Average/Sum#:	407.0 #	36.2 #	51.2 #	279.6 #	60.7 #
Minimum:	15.9	1.2	2.0	10.9	2.4
Maximum:	17.7	2.5	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/11/2024 00:00	17.0	1.5	2.1	11.7	2.6
07/11/2024 01:00	16.8	1.5	2.1	11.6	2.6
07/11/2024 02:00	16.7	1.5	2.1	11.5	2.5
07/11/2024 03:00	16.4	1.9	2.0	11.3	2.4
07/11/2024 04:00	17.5	1.2	2.2	12.1	2.6
07/11/2024 05:00	16.1	1.9	2.0	11.0	2.4
07/11/2024 06:00	13.8	1.6	1.7	9.5	2.0
07/11/2024 07:00	13.7	1.6	1.7	9.4	2.0
07/11/2024 08:00	12.4	1.4	1.6	8.5	1.8
07/11/2024 09:00	12.0	1.4	1.6	8.3	1.8
07/11/2024 10:00	13.1	1.5	1.6	9.0	2.0
07/11/2024 11:00	11.8	1.4	1.4	8.1	1.8
07/11/2024 12:00	12.8	1.5	1.6	8.8	2.0
07/11/2024 13:00	12.7	1.5	1.6	8.7	1.9
07/11/2024 14:00	12.5	1.4	1.6	8.6	1.8
07/11/2024 15:00	10.6	1.3	1.3	7.3	1.6
07/11/2024 16:00	10.6	1.0	1.3	7.3	1.6
07/11/2024 17:00	14.0	2.0	1.7	9.6	2.1
07/11/2024 18:00	16.9	1.8	2.1	11.6	2.6
07/11/2024 19:00	17.0	1.5	2.1	11.7	2.6
07/11/2024 20:00	16.6	1.5	2.1	11.3	2.5
07/11/2024 21:00	16.3	1.8	2.0	11.1	2.4
07/11/2024 22:00	17.3	1.2	2.1	11.9	2.6
07/11/2024 23:00	16.6	1.5	2.1	11.4	2.5
Average/Sum#:	351.2 #	36.4 #	43.7 #	241.3 #	52.7 #
Minimum:	10.6	1.0	1.3	7.3	1.6
Maximum:	17.5	2.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/12/2024 00:00	16.6	1.9	2.1	11.4	2.5
07/12/2024 01:00	16.6	1.9	2.1	11.4	2.5
07/12/2024 02:00	16.4	1.9	2.0	11.3	2.4
07/12/2024 03:00	17.4	1.3	2.2	12.0	2.6
07/12/2024 04:00	16.9	1.6	2.1	11.6	2.6
07/12/2024 05:00	14.7	1.6	2.1	11.6	2.6
07/12/2024 06:00	13.9	1.6	1.7	9.5	2.0
07/12/2024 07:00	12.4	1.4	1.6	8.5	1.8
07/12/2024 08:00	11.8	1.4	1.4	8.1	1.8
07/12/2024 09:00	11.8	1.4	1.4	8.1	1.8
07/12/2024 10:00	10.5	1.4	1.6	8.3	1.8
07/12/2024 11:00	11.4	1.3	1.4	7.9	1.8
07/12/2024 12:00	11.8	1.4	1.4	8.1	1.8
07/12/2024 13:00	10.8	1.3	1.3	7.4	1.6
07/12/2024 14:00	10.8	1.5	1.3	7.5	1.6
07/12/2024 15:00	10.8	1.3	1.3	7.5	1.6
07/12/2024 16:00	10.8	1.3	1.3	7.4	1.6
07/12/2024 17:00	10.8	1.3	1.3	7.4	1.6
07/12/2024 18:00	10.6	1.3	1.3	7.3	1.6
07/12/2024 19:00	10.6	1.3	1.3	7.3	1.6
07/12/2024 20:00	10.6	1.3	1.3	7.3	1.6
07/12/2024 21:00	13.1	1.5	1.6	9.0	2.0
07/12/2024 22:00	13.8	1.6	1.7	9.5	2.0
07/12/2024 23:00	13.8	1.9	1.7	9.5	2.0
Average/Sum#:	308.7 #	35.7 #	38.5 #	214.9 #	46.8 #
Minimum:	10.5	1.3	1.3	7.3	1.6
Maximum:	17.4	1.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/13/2024 00:00	13.8	1.9	1.7	9.5	2.0
07/13/2024 01:00	13.8	1.9	1.7	9.5	2.0
07/13/2024 02:00	13.9	1.9	1.7	9.5	2.0
07/13/2024 03:00	14.0	1.9	1.7	9.6	2.0
07/13/2024 04:00	13.8	1.6	1.7	9.5	2.0
07/13/2024 05:00	14.0	1.6	1.7	9.7	2.1
07/13/2024 06:00	13.7	1.9	1.7	9.4	2.0
07/13/2024 07:00	13.8	2.2	1.7	9.5	2.0
07/13/2024 08:00	13.7	1.9	1.7	9.4	2.0
07/13/2024 09:00	12.5	1.5	1.6	8.6	1.8
07/13/2024 10:00	12.4	1.5	1.6	8.6	1.8
07/13/2024 11:00	13.0	1.5	1.6	9.0	2.0
07/13/2024 12:00	13.2	1.5	1.7	9.0	2.0
07/13/2024 13:00	11.0	1.3	1.4	7.5	1.6
07/13/2024 14:00	10.6	1.2	1.3	7.3	1.6
07/13/2024 15:00	10.6	1.3	1.3	7.3	1.6
07/13/2024 16:00	10.6	1.2	1.3	7.3	1.6
07/13/2024 17:00	10.6	1.3	1.3	7.3	1.6
07/13/2024 18:00	10.6	1.3	1.3	7.3	1.6
07/13/2024 19:00	11.8	1.4	1.4	8.1	1.8
07/13/2024 20:00	13.8	1.6	1.7	9.5	2.0
07/13/2024 21:00	13.8	1.6	1.7	9.4	2.0
07/13/2024 22:00	13.8	1.6	1.7	9.5	2.0
07/13/2024 23:00	13.9	1.6	1.7	9.6	2.0
Average/Sum#:	306.7 #	38.2 #	37.9 #	210.9 #	45.1 #
Minimum:	10.6	1.2	1.3	7.3	1.6
Maximum:	14.0	2.2	1.7	9.7	2.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/14/2024 00:00	14.0	1.6	1.7	9.6	2.1
07/14/2024 01:00	13.2	1.5	1.7	9.0	2.0
07/14/2024 02:00	6.9	22.0	0.4	2.7	0.6
07/14/2024 03:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/14/2024 10:00	17.8	13.8	0.1	0.4	0.1
07/14/2024 11:00	41.1	59.0	0.6	2.1	0.5
07/14/2024 12:00	4.7	0.0	1.1	3.9	0.9
07/14/2024 13:00	6.3	0.0	1.1	3.9	0.9
07/14/2024 14:00	34.4	21.6	1.2	4.7	1.1
07/14/2024 15:00	48.6	46.1	1.5	7.8	1.7
07/14/2024 16:00	13.5	1.5	1.7	9.3	2.0
07/14/2024 17:00	13.6	1.5	1.7	9.4	2.0
07/14/2024 18:00	17.0	2.2	2.1	11.7	2.6
07/14/2024 19:00	15.3	1.2	2.2	12.0	2.6
07/14/2024 20:00	17.4	1.2	2.2	12.0	2.6
07/14/2024 21:00	17.5	0.9	2.2	12.0	2.6
07/14/2024 22:00	16.6	1.6	2.1	11.4	2.4
07/14/2024 23:00	16.0	1.9	2.0	11.0	2.4
Average/Sum#:	313.9 #	177.6 #	25.6 #	132.9 #	29.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	48.6	59.0	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/15/2024 00:00	13.8	1.9	1.7	9.5	2.0
07/15/2024 01:00	13.8	1.6	1.7	9.5	2.0
07/15/2024 02:00	13.0	1.8	1.6	8.9	2.0
07/15/2024 03:00	13.8	1.6	1.7	9.4	2.0
07/15/2024 04:00	14.0	1.6	1.7	9.6	2.1
07/15/2024 05:00	13.8	1.6	1.7	9.4	2.0
07/15/2024 06:00	13.6	1.6	1.7	9.3	2.0
07/15/2024 07:00	13.6	1.6	1.7	9.4	2.0
07/15/2024 08:00	12.4	1.4	1.6	8.5	1.8
07/15/2024 09:00	11.8	1.1	1.4	8.2	1.8
07/15/2024 10:00	13.0	1.5	1.6	9.0	2.0
07/15/2024 11:00	13.6	1.6	1.7	9.4	2.0
07/15/2024 12:00	13.2	1.5	1.7	9.2	2.0
07/15/2024 13:00	13.3	1.5	1.7	9.2	2.0
07/15/2024 14:00	13.3	1.5	1.7	9.2	2.0
07/15/2024 15:00	12.8	1.5	1.6	8.8	2.0
07/15/2024 16:00	12.6	1.5	1.6	8.6	1.8
07/15/2024 17:00	13.9	1.8	1.7	9.5	2.0
07/15/2024 18:00	17.1	1.5	2.1	11.8	2.6
07/15/2024 19:00	17.4	1.2	2.2	12.0	2.6
07/15/2024 20:00	17.4	1.3	2.2	11.9	2.6
07/15/2024 21:00	17.0	1.6	2.1	11.7	2.6
07/15/2024 22:00	16.0	2.3	2.0	11.0	2.4
07/15/2024 23:00	15.9	2.9	2.0	10.9	2.4
Average/Sum#:	340.1 #	39.0 #	42.4 #	233.9 #	50.7 #
Minimum:	11.8	1.1	1.4	8.2	1.8
Maximum:	17.4	2.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/16/2024 00:00	13.8	1.9	1.7	9.5	2.0
07/16/2024 01:00	13.8	1.6	1.7	9.5	2.0
07/16/2024 02:00	14.0	1.6	1.7	9.6	2.0
07/16/2024 03:00	14.0	1.6	1.7	9.6	2.0
07/16/2024 04:00	14.0	1.6	1.7	9.6	2.0
07/16/2024 05:00	13.6	1.6	1.7	9.4	2.0
07/16/2024 06:00	13.6	1.3	1.7	9.3	2.0
07/16/2024 07:00	13.8	1.6	1.7	9.5	2.0
07/16/2024 08:00	12.8	1.5	1.6	8.8	2.0
07/16/2024 09:00	13.0	1.5	1.6	8.8	2.0
07/16/2024 10:00	13.2	1.5	1.7	9.1	2.0
07/16/2024 11:00	13.6	1.6	1.7	9.4	2.0
07/16/2024 12:00	13.2	1.5	1.7	9.0	2.0
07/16/2024 13:00	9.2	1.4	1.6	8.4	1.8
07/16/2024 14:00	10.6	1.0	1.3	7.3	1.6
07/16/2024 15:00	12.0	1.1	1.5	8.3	1.8
07/16/2024 16:00	16.5	2.5	2.1	11.4	2.4
07/16/2024 17:00	17.2	1.6	2.1	11.9	2.6
07/16/2024 18:00	17.7	1.3	2.2	12.2	2.6
07/16/2024 19:00	17.7	1.3	2.2	12.2	2.6
07/16/2024 20:00	17.7	0.9	2.2	12.2	2.6
07/16/2024 21:00	17.9	1.3	2.3	12.3	2.6
07/16/2024 22:00	17.5	1.3	2.1	12.0	2.6
07/16/2024 23:00	16.5	1.9	2.1	11.4	2.5
Average/Sum#:	346.9 #	36.0 #	43.6 #	240.7 #	51.7 #
Minimum:	9.2	0.9	1.3	7.3	1.6
Maximum:	17.9	2.5	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/17/2024 00:00	16.3	2.3	2.0	11.2	2.4
07/17/2024 01:00	13.6	1.5	1.7	9.4	2.0
07/17/2024 02:00	13.8	1.3	1.7	9.4	2.0
07/17/2024 03:00	14.0	1.3	1.7	9.6	2.0
07/17/2024 04:00	14.0	1.3	1.7	9.5	2.0
07/17/2024 05:00	13.2	1.2	1.7	9.2	2.0
07/17/2024 06:00	13.6	1.3	1.7	9.4	2.0
07/17/2024 07:00	13.9	1.3	1.7	9.5	2.0
07/17/2024 08:00	13.6	1.3	1.7	9.4	2.0
07/17/2024 09:00	13.0	1.5	1.6	9.0	2.0
07/17/2024 10:00	11.4	1.3	1.4	7.9	1.8
07/17/2024 11:00	11.4	1.3	1.4	7.9	1.8
07/17/2024 12:00	12.4	1.5	1.6	8.5	1.8
07/17/2024 13:00	11.8	1.4	1.4	8.1	1.8
07/17/2024 14:00	12.6	1.5	1.6	8.6	1.8
07/17/2024 15:00	16.7	2.5	2.1	11.4	2.5
07/17/2024 16:00	16.5	2.2	2.1	11.3	2.4
07/17/2024 17:00	16.9	1.9	2.1	11.6	2.6
07/17/2024 18:00	17.7	1.3	2.2	12.2	2.6
07/17/2024 19:00	17.7	1.3	2.2	12.2	2.6
07/17/2024 20:00	17.7	1.3	2.2	12.2	2.6
07/17/2024 21:00	17.7	1.3	2.2	12.2	2.6
07/17/2024 22:00	17.7	1.3	2.2	12.1	2.6
07/17/2024 23:00	17.5	1.3	2.2	12.0	2.6
Average/Sum#:	354.7 #	35.7 #	44.1 #	243.8 #	52.5 #
Minimum:	11.4	1.2	1.4	7.9	1.8
Maximum:	17.7	2.5	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/18/2024 00:00	16.3	2.3	2.0	11.2	2.4
07/18/2024 01:00	16.4	2.2	2.0	11.3	2.4
07/18/2024 02:00	17.5	1.6	2.2	12.0	2.6
07/18/2024 03:00	17.4	1.6	2.1	11.9	2.6
07/18/2024 04:00	17.5	1.9	2.2	12.0	2.6
07/18/2024 05:00	17.1	1.6	2.1	11.8	2.6
07/18/2024 06:00	16.3	1.9	2.0	11.2	2.4
07/18/2024 07:00	15.9	2.2	2.0	10.9	2.4
07/18/2024 08:00	16.3	2.2	2.0	11.2	2.4
07/18/2024 09:00	16.9	1.9	2.1	11.6	2.6
07/18/2024 10:00	17.0	1.6	2.1	11.6	2.6
07/18/2024 11:00	17.0	1.6	2.1	11.7	2.6
07/18/2024 12:00	16.7	1.9	2.1	11.5	2.5
07/18/2024 13:00	17.4	1.6	2.2	11.9	2.6
07/18/2024 14:00	17.4	1.2	2.2	11.9	2.6
07/18/2024 15:00	17.4	1.2	2.2	11.9	2.6
07/18/2024 16:00	17.4	1.2	2.2	12.0	2.6
07/18/2024 17:00	17.4	1.2	2.2	12.0	2.6
07/18/2024 18:00	17.4	1.2	2.2	12.0	2.6
07/18/2024 19:00	17.5	1.2	2.2	12.0	2.6
07/18/2024 20:00	17.5	1.2	2.2	12.0	2.6
07/18/2024 21:00	17.5	1.2	2.2	12.0	2.6
07/18/2024 22:00	17.7	1.2	2.2	12.2	2.6
07/18/2024 23:00	17.2	1.3	2.1	11.8	2.6
Average/Sum#:	410.1 #	38.2 #	51.1 #	281.6 #	61.3 #
Minimum:	15.9	1.2	2.0	10.9	2.4
Maximum:	17.7	2.3	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/19/2024 00:00	16.9	1.6	2.1	11.6	2.6
07/19/2024 01:00	16.7	1.6	2.1	11.5	2.5
07/19/2024 02:00	16.9	1.6	2.1	11.6	2.6
07/19/2024 03:00	16.1	1.9	2.0	11.1	2.4
07/19/2024 04:00	17.5	1.3	2.2	12.0	2.6
07/19/2024 05:00	16.7	1.6	2.1	11.5	2.5
07/19/2024 06:00	14.0	1.3	1.7	9.5	2.0
07/19/2024 07:00	14.0	1.3	1.7	9.7	2.1
07/19/2024 08:00	14.0	1.3	1.7	9.7	2.1
07/19/2024 09:00	14.0	1.6	1.7	9.7	2.1
07/19/2024 10:00	14.0	1.6	1.7	9.7	2.1
07/19/2024 11:00	14.0	1.6	1.7	9.6	2.0
07/19/2024 12:00	13.8	1.6	1.7	9.5	2.0
07/19/2024 13:00	17.1	1.9	2.1	11.8	2.6
07/19/2024 14:00	17.4	1.2	2.2	12.0	2.6
07/19/2024 15:00	17.4	1.2	2.2	12.0	2.6
07/19/2024 16:00	17.4	0.9	2.2	12.0	2.6
07/19/2024 17:00	17.3	1.2	2.2	12.0	2.6
07/19/2024 18:00	17.3	1.2	2.2	11.9	2.6
07/19/2024 19:00	17.3	1.2	2.2	11.9	2.6
07/19/2024 20:00	17.3	1.2	2.1	11.9	2.6
07/19/2024 21:00	17.2	1.3	2.1	11.8	2.6
07/19/2024 22:00	17.6	0.9	2.2	12.1	2.6
07/19/2024 23:00	17.7	1.2	2.2	12.2	2.6
Average/Sum#:	389.6 #	33.3 #	48.4 #	268.3 #	58.2 #
Minimum:	13.8	0.9	1.7	9.5	2.0
Maximum:	17.7	1.9	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/20/2024 00:00	17.7	1.2	2.2	12.2	2.6
07/20/2024 01:00	17.7	0.9	2.2	12.2	2.6
07/20/2024 02:00	17.7	1.0	2.2	12.2	2.6
07/20/2024 03:00	17.7	1.0	2.2	12.2	2.6
07/20/2024 04:00	15.5	1.0	2.2	12.2	2.6
07/20/2024 05:00	14.9	1.3	2.1	11.7	2.6
07/20/2024 06:00	13.6	1.6	1.7	9.4	2.0
07/20/2024 07:00	13.8	1.6	1.7	9.5	2.0
07/20/2024 08:00	12.6	1.5	1.6	8.6	1.8
07/20/2024 09:00	12.8	1.5	1.6	8.8	2.0
07/20/2024 10:00	13.7	1.6	1.7	9.4	2.0
07/20/2024 11:00	13.0	1.5	1.6	9.0	2.0
07/20/2024 12:00	10.8	1.3	1.3	7.4	1.6
07/20/2024 13:00	13.1	1.5	1.6	9.0	2.0
07/20/2024 14:00	17.0	1.9	2.1	11.7	2.6
07/20/2024 15:00	17.2	1.5	2.1	11.8	2.6
07/20/2024 16:00	17.2	1.2	2.1	11.9	2.6
07/20/2024 17:00	17.3	0.9	2.2	11.9	2.6
07/20/2024 18:00	17.3	0.9	2.2	11.9	2.6
07/20/2024 19:00	17.1	1.2	2.1	11.8	2.6
07/20/2024 20:00	17.1	1.2	2.1	11.8	2.6
07/20/2024 21:00	17.1	1.2	2.1	11.7	2.6
07/20/2024 22:00	17.5	1.2	2.2	12.0	2.6
07/20/2024 23:00	17.6	1.2	2.2	12.1	2.6
Average/Sum#:	377.0 #	30.9 #	47.3 #	262.4 #	57.0 #
Minimum:	10.8	0.9	1.3	7.4	1.6
Maximum:	17.7	1.9	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/21/2024 00:00	17.7	0.9	2.2	12.2	2.6
07/21/2024 01:00	17.6	0.9	2.2	12.1	2.6
07/21/2024 02:00	17.6	1.3	2.2	12.0	2.6
07/21/2024 03:00	17.5	1.3	2.2	12.0	2.6
07/21/2024 04:00	17.6	1.3	2.2	12.0	2.6
07/21/2024 05:00	16.2	42.2	1.2	6.4	1.4
07/21/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/21/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/21/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/21/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/21/2024 10:00	1.7	14.9	0.1	0.5	0.1
07/21/2024 11:00	27.6	90.7	0.7	2.7	0.6
07/21/2024 12:00	5.7	0.0	1.0	3.6	0.9
07/21/2024 13:00	5.6	0.0	1.0	3.5	0.8
07/21/2024 14:00	6.5	0.0	1.1	4.0	1.0
07/21/2024 15:00	6.9	0.0	1.2	4.3	1.0
07/21/2024 16:00	7.6	0.0	1.3	4.8	1.1
07/21/2024 17:00	8.6	0.0	1.5	5.4	1.3
07/21/2024 18:00	8.7	0.0	1.5	5.4	1.3
07/21/2024 19:00	8.7	0.0	1.5	5.4	1.3
07/21/2024 20:00	8.7	0.0	1.5	5.4	1.3
07/21/2024 21:00	8.7	0.0	1.5	5.4	1.3
07/21/2024 22:00	8.7	0.0	1.5	5.4	1.3
07/21/2024 23:00	8.7	0.0	1.5	5.5	1.3
Average/Sum#:	226.6 #	153.5 #	29.1 #	128.0 #	29.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	27.6	90.7	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/22/2024 00:00	8.7	0.0	1.5	5.5	1.3
07/22/2024 01:00	8.7	0.0	1.5	5.5	1.3
07/22/2024 02:00	8.4	0.0	1.5	5.3	1.3
07/22/2024 03:00	66.8	81.8	1.4	5.8	1.3
07/22/2024 04:00	21.9	17.7	1.4	7.6	1.7
07/22/2024 05:00	13.0	1.2	1.6	9.0	2.0
07/22/2024 06:00	13.8	1.6	1.7	9.5	2.0
07/22/2024 07:00	13.6	1.3	1.7	9.4	2.0
07/22/2024 08:00	13.6	1.6	1.7	9.4	2.0
07/22/2024 09:00	13.5	1.6	1.7	9.3	2.0
07/22/2024 10:00	13.4	1.6	1.7	9.2	2.0
07/22/2024 11:00	13.2	1.5	1.7	9.1	2.0
07/22/2024 12:00	14.5	1.8	1.8	10.0	2.2
07/22/2024 13:00	17.2	1.2	2.1	11.9	2.6
07/22/2024 14:00	17.2	0.9	2.1	11.9	2.6
07/22/2024 15:00	17.2	0.9	2.1	11.9	2.6
07/22/2024 16:00	17.3	0.9	2.2	11.9	2.6
07/22/2024 17:00	17.3	0.9	2.2	11.9	2.6
07/22/2024 18:00	17.3	0.9	2.2	11.9	2.6
07/22/2024 19:00	17.2	0.9	2.1	11.9	2.6
07/22/2024 20:00	17.1	1.2	2.1	11.8	2.6
07/22/2024 21:00	17.0	1.2	2.1	11.7	2.6
07/22/2024 22:00	17.4	0.9	2.2	12.0	2.6
07/22/2024 23:00	17.6	0.9	2.2	12.0	2.6
Average/Sum#:	412.9 #	122.5 #	44.5 #	235.4 #	51.7 #
Minimum:	8.4	0.0	1.4	5.3	1.3
Maximum:	66.8	81.8	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/23/2024 00:00	17.6	0.9	2.2	12.0	2.6
07/23/2024 01:00	17.6	0.9	2.2	12.1	2.6
07/23/2024 02:00	17.6	0.9	2.2	12.2	2.6
07/23/2024 03:00	17.6	0.9	2.2	12.2	2.6
07/23/2024 04:00	17.8	0.9	2.2	12.2	2.6
07/23/2024 05:00	15.6	1.3	2.2	12.2	2.6
07/23/2024 06:00	16.7	1.6	2.1	11.4	2.5
07/23/2024 07:00	17.1	1.3	2.1	11.8	2.6
07/23/2024 08:00	16.3	1.6	2.0	11.2	2.4
07/23/2024 09:00	16.7	1.2	2.1	11.5	2.5
07/23/2024 10:00	17.0	1.2	2.1	11.7	2.6
07/23/2024 11:00	17.3	0.9	2.2	11.9	2.6
07/23/2024 12:00	16.9	1.2	2.1	11.6	2.6
07/23/2024 13:00	16.8	1.2	2.1	11.6	2.6
07/23/2024 14:00	17.1	0.9	2.1	11.8	2.6
07/23/2024 15:00	17.2	0.9	2.1	11.8	2.6
07/23/2024 16:00	17.3	0.9	2.2	11.9	2.6
07/23/2024 17:00	17.3	0.9	2.2	12.0	2.6
07/23/2024 18:00	17.3	0.9	2.2	12.0	2.6
07/23/2024 19:00	17.3	0.9	2.1	11.9	2.6
07/23/2024 20:00	17.4	0.9	2.2	12.0	2.6
07/23/2024 21:00	17.5	0.9	2.2	12.0	2.6
07/23/2024 22:00	17.4	0.9	2.1	11.9	2.6
07/23/2024 23:00	17.7	0.9	2.2	12.2	2.6
Average/Sum#:	412.1 #	25.0 #	51.6 #	285.1 #	62.0 #
Minimum:	15.6	0.9	2.0	11.2	2.4
Maximum:	17.8	1.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/24/2024 00:00	17.3	1.3	2.1	12.0	2.6
07/24/2024 01:00	17.3	1.3	2.1	11.8	2.6
07/24/2024 02:00	17.3	1.3	2.1	11.9	2.6
07/24/2024 03:00	17.7	1.0	2.2	12.2	2.6
07/24/2024 04:00	17.7	1.0	2.2	12.2	2.6
07/24/2024 05:00	17.8	1.0	2.2	12.2	2.6
07/24/2024 06:00	17.1	1.3	2.1	11.8	2.6
07/24/2024 07:00	17.0	1.3	2.1	11.7	2.6
07/24/2024 08:00	16.9	1.3	2.1	11.6	2.6
07/24/2024 09:00	16.8	1.3	2.1	11.6	2.6
07/24/2024 10:00	16.7	1.6	2.1	11.5	2.5
07/24/2024 11:00	16.9	1.3	2.1	11.6	2.6
07/24/2024 12:00	17.1	1.2	2.1	11.8	2.6
07/24/2024 13:00	16.8	1.2	2.1	11.6	2.6
07/24/2024 14:00	17.0	0.9	2.1	11.6	2.6
07/24/2024 15:00	17.2	0.9	2.1	11.7	2.6
07/24/2024 16:00	16.3	1.2	2.0	11.2	2.4
07/24/2024 17:00	16.1	1.6	2.0	11.1	2.4
07/24/2024 18:00	16.3	1.6	2.0	11.2	2.4
07/24/2024 19:00	16.4	1.6	2.0	11.3	2.4
07/24/2024 20:00	16.5	1.6	2.1	11.3	2.4
07/24/2024 21:00	17.2	1.3	2.1	11.9	2.6
07/24/2024 22:00	17.7	1.0	2.2	12.2	2.6
07/24/2024 23:00	17.4	1.3	2.1	12.0	2.6
Average/Sum#:	408.5 #	30.4 #	50.4 #	281.0 #	61.3 #
Minimum:	16.1	0.9	2.0	11.1	2.4
Maximum:	17.8	1.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/25/2024 00:00	16.9	1.3	2.1	11.6	2.6
07/25/2024 01:00	16.8	1.6	2.1	11.5	2.5
07/25/2024 02:00	16.7	1.6	2.1	11.5	2.5
07/25/2024 03:00	17.4	1.3	2.1	11.9	2.6
07/25/2024 04:00	17.5	1.3	2.2	12.0	2.6
07/25/2024 05:00	17.5	1.0	2.1	12.0	2.6
07/25/2024 06:00	17.0	1.3	2.1	11.7	2.6
07/25/2024 07:00	17.0	1.3	2.1	11.7	2.6
07/25/2024 08:00	17.0	1.3	2.1	11.7	2.6
07/25/2024 09:00	16.9	1.3	2.1	11.6	2.6
07/25/2024 10:00	16.6	1.6	2.1	11.4	2.5
07/25/2024 11:00	17.1	1.3	2.1	11.8	2.6
07/25/2024 12:00	17.1	1.3	2.1	11.8	2.6
07/25/2024 13:00	17.1	1.3	2.1	11.8	2.6
07/25/2024 14:00	17.1	1.2	2.1	11.8	2.6
07/25/2024 15:00	17.2	0.9	2.1	11.9	2.6
07/25/2024 16:00	17.0	0.9	2.1	11.7	2.6
07/25/2024 17:00	17.0	0.9	2.1	11.7	2.6
07/25/2024 18:00	16.8	1.2	2.1	11.5	2.5
07/25/2024 19:00	16.6	1.2	2.1	11.4	2.5
07/25/2024 20:00	17.2	1.3	2.1	11.9	2.6
07/25/2024 21:00	17.4	0.9	2.2	12.0	2.6
07/25/2024 22:00	17.2	1.3	2.1	11.8	2.6
07/25/2024 23:00	17.7	1.0	2.2	12.2	2.6
Average/Sum#:	409.8 #	29.6 #	50.7 #	281.9 #	61.9 #
Minimum:	16.6	0.9	2.1	11.4	2.5
Maximum:	17.7	1.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/26/2024 00:00	17.5	1.0	2.2	12.0	2.6
07/26/2024 01:00	16.5	1.6	2.1	11.3	2.4
07/26/2024 02:00	15.9	2.3	2.0	10.9	2.4
07/26/2024 03:00	15.9	2.6	2.0	10.9	2.4
07/26/2024 04:00	17.1	1.6	2.1	11.7	2.6
07/26/2024 05:00	16.7	1.6	2.1	11.5	2.5
07/26/2024 06:00	15.9	2.3	2.0	10.9	2.4
07/26/2024 07:00	15.9	2.3	2.0	10.9	2.4
07/26/2024 08:00	15.9	2.3	2.0	10.9	2.4
07/26/2024 09:00	15.9	2.2	2.0	11.0	2.4
07/26/2024 10:00	16.1	1.9	2.0	11.1	2.4
07/26/2024 11:00	16.1	1.9	2.0	11.1	2.4
07/26/2024 12:00	16.3	1.6	2.0	11.1	2.4
07/26/2024 13:00	16.4	1.6	2.0	11.3	2.4
07/26/2024 14:00	16.5	1.2	2.1	11.4	2.4
07/26/2024 15:00	16.8	1.2	2.1	11.6	2.6
07/26/2024 16:00	17.0	0.9	2.1	11.7	2.6
07/26/2024 17:00	17.0	0.9	2.1	11.7	2.6
07/26/2024 18:00	16.5	1.2	2.1	11.4	2.5
07/26/2024 19:00	17.0	1.3	2.1	11.6	2.6
07/26/2024 20:00	17.5	0.9	2.2	12.0	2.6
07/26/2024 21:00	16.7	1.3	2.1	11.4	2.5
07/26/2024 22:00	16.6	1.6	2.1	11.4	2.5
07/26/2024 23:00	15.9	2.3	2.0	10.9	2.4
Average/Sum#:	395.6 #	39.6 #	49.5 #	271.7 #	59.4 #
Minimum:	15.9	0.9	2.0	10.9	2.4
Maximum:	17.5	2.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/27/2024 00:00	15.9	2.6	2.0	10.9	2.4
07/27/2024 01:00	15.9	2.3	2.0	10.9	2.4
07/27/2024 02:00	15.9	2.0	2.0	10.9	2.4
07/27/2024 03:00	15.8	2.3	2.0	10.9	2.4
07/27/2024 04:00	16.2	2.0	2.0	11.2	2.4
07/27/2024 05:00	14.4	1.6	2.0	11.3	2.4
07/27/2024 06:00	2.5	8.9	0.2	1.0	0.2
07/27/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/27/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/27/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/27/2024 10:00	0.0	0.0	0.0	0.0	0.0
07/27/2024 11:00	0.1	2.0	0.0	0.1	0.0
07/27/2024 12:00	26.0	85.0	0.7	2.3	0.6
07/27/2024 13:00	5.7	0.0	1.0	3.6	0.9
07/27/2024 14:00	5.6	0.0	1.0	3.5	0.8
07/27/2024 15:00	28.6	14.0	1.1	4.5	1.1
07/27/2024 16:00	52.0	68.2	1.3	6.7	1.5
07/27/2024 17:00	13.8	1.3	1.7	9.5	2.0
07/27/2024 18:00	11.2	1.2	1.6	8.8	2.0
07/27/2024 19:00	16.0	2.2	2.0	11.0	2.4
07/27/2024 20:00	15.9	2.2	2.0	10.9	2.4
07/27/2024 21:00	15.9	2.2	2.0	10.9	2.4
07/27/2024 22:00	15.9	2.2	2.0	10.9	2.4
07/27/2024 23:00	15.8	2.2	2.0	10.9	2.4
Average/Sum#:	316.6 #	195.5 #	30.6 #	160.7 #	35.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.0	85.0	2.0	11.3	2.4
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/28/2024 00:00	15.7	2.3	2.0	10.9	2.4
07/28/2024 01:00	15.8	2.3	2.0	10.9	2.4
07/28/2024 02:00	15.8	2.3	2.0	10.9	2.4
07/28/2024 03:00	15.7	2.6	2.0	10.8	2.4
07/28/2024 04:00	15.6	2.6	2.0	10.8	2.4
07/28/2024 05:00	13.6	1.3	1.7	9.3	2.0
07/28/2024 06:00	9.2	1.0	1.3	7.2	1.6
07/28/2024 07:00	3.9	13.4	0.0	0.3	0.0
07/28/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 10:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 11:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 12:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 13:00	0.0	0.0	0.0	0.0	0.0
07/28/2024 14:00	23.3	39.8	0.0	0.7	0.1
07/28/2024 15:00	34.1	56.0	0.4	3.7	0.7
07/28/2024 16:00	6.7	1.2	0.5	5.0	1.0
07/28/2024 17:00	7.5	6.0	0.6	5.6	1.1
07/28/2024 18:00	7.5	5.4	0.6	5.6	1.1
07/28/2024 19:00	7.5	5.4	0.6	5.7	1.1
07/28/2024 20:00	7.8	3.2	0.6	5.9	1.2
07/28/2024 21:00	7.8	2.8	0.6	5.9	1.2
07/28/2024 22:00	6.0	1.4	0.5	4.5	0.9
07/28/2024 23:00	6.7	1.2	0.5	5.0	1.0
Average/Sum#:	220.2 #	150.2 #	17.9 #	118.7 #	25.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	34.1	56.0	2.0	10.9	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/29/2024 00:00	6.1	1.1	0.5	4.6	0.9
07/29/2024 01:00	6.1	1.1	0.5	4.6	0.9
07/29/2024 02:00	6.1	1.1	0.5	4.6	0.9
07/29/2024 03:00	1.2	9.7	0.0	0.4	0.1
07/29/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/29/2024 10:00	37.7	51.0	0.1	0.5	0.1
07/29/2024 11:00	21.8	35.6	0.3	1.1	0.3
07/29/2024 12:00	32.4	81.2	0.8	2.8	0.7
07/29/2024 13:00	5.6	0.0	1.0	3.5	0.8
07/29/2024 14:00	6.2	0.0	1.1	3.9	0.9
07/29/2024 15:00	58.5	67.2	1.2	5.4	1.3
07/29/2024 16:00	35.9	50.4	1.5	7.9	1.7
07/29/2024 17:00	13.3	1.2	1.7	9.2	2.0
07/29/2024 18:00	14.4	1.5	1.8	9.9	2.2
07/29/2024 19:00	17.5	1.2	2.2	12.0	2.6
07/29/2024 20:00	17.6	0.9	2.2	12.2	2.6
07/29/2024 21:00	16.7	1.3	2.1	11.4	2.5
07/29/2024 22:00	16.5	1.3	2.1	11.3	2.4
07/29/2024 23:00	4.8	19.1	0.2	1.0	0.2
Average/Sum#:	318.4 #	324.9 #	19.8 #	106.3 #	23.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	58.5	81.2	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/30/2024 00:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 01:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 02:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 03:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 04:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 05:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 06:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 07:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 08:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 09:00	0.0	0.0	0.0	0.0	0.0
07/30/2024 10:00	37.5	36.9	0.1	0.6	0.1
07/30/2024 11:00	16.0	29.9	0.3	1.0	0.3
07/30/2024 12:00	43.6	95.2	0.6	2.3	0.5
07/30/2024 13:00	4.2	0.0	1.0	3.5	0.8
07/30/2024 14:00	5.6	0.0	1.0	3.5	0.8
07/30/2024 15:00	66.0	71.3	1.2	5.3	1.2
07/30/2024 16:00	41.6	45.3	1.4	7.1	1.5
07/30/2024 17:00	11.6	0.8	1.4	7.9	1.8
07/30/2024 18:00	14.0	2.1	1.7	9.7	2.1
07/30/2024 19:00	17.5	1.3	2.2	12.0	2.6
07/30/2024 20:00	17.5	0.6	2.2	12.0	2.6
07/30/2024 21:00	17.5	0.6	2.2	12.0	2.6
07/30/2024 22:00	17.1	0.9	2.1	11.7	2.6
07/30/2024 23:00	17.1	1.3	2.1	11.8	2.6
Average/Sum#:	326.8 #	286.2 #	19.5 #	100.4 #	22.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	66.0	95.2	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/31/2024 00:00	15.9	1.9	2.0	10.9	2.4
07/31/2024 01:00	15.7	2.2	2.0	10.9	2.4
07/31/2024 02:00	15.7	2.2	2.0	10.9	2.4
07/31/2024 03:00	16.0	2.2	2.0	10.9	2.4
07/31/2024 04:00	17.7	1.0	2.2	12.2	2.6
07/31/2024 05:00	17.0	0.9	2.1	11.7	2.6
07/31/2024 06:00	13.8	1.0	1.7	9.4	2.0
07/31/2024 07:00	12.7	0.9	1.6	8.8	2.0
07/31/2024 08:00	12.0	0.8	1.4	8.2	1.8
07/31/2024 09:00	12.0	0.8	1.4	8.2	1.8
07/31/2024 10:00	12.4	0.9	1.6	8.5	1.8
07/31/2024 11:00	12.6	0.9	1.6	8.6	1.8
07/31/2024 12:00	11.8	0.8	1.4	8.1	1.8
07/31/2024 13:00	13.0	1.2	1.6	9.0	2.0
07/31/2024 14:00	16.8	1.5	2.1	11.5	2.6
07/31/2024 15:00	17.4	0.9	2.2	12.0	2.6
07/31/2024 16:00	17.3	0.6	2.2	12.0	2.6
07/31/2024 17:00	17.4	0.6	2.2	11.9	2.6
07/31/2024 18:00	17.3	0.6	2.2	11.9	2.6
07/31/2024 19:00	17.2	0.6	2.1	11.9	2.6
07/31/2024 20:00	17.1	0.9	2.1	11.8	2.6
07/31/2024 21:00	17.0	0.9	2.1	11.7	2.6
07/31/2024 22:00	17.0	0.9	2.1	11.7	2.6
07/31/2024 23:00	17.0	0.9	2.1	11.7	2.6
Average/Sum#:	369.8 #	26.1 #	46.0 #	254.4 #	55.8 #
Minimum:	11.8	0.6	1.4	8.1	1.8
Maximum:	17.7	2.2	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/01/2024 00:00	17.0	1.3	2.1	11.7	2.6
08/01/2024 01:00	16.9	1.3	2.1	11.6	2.6
08/01/2024 02:00	16.8	1.3	2.1	11.5	2.5
08/01/2024 03:00	16.8	1.3	2.1	11.5	2.5
08/01/2024 04:00	16.8	1.3	2.1	11.5	2.5
08/01/2024 05:00	17.5	1.0	2.2	12.0	2.6
08/01/2024 06:00	14.8	1.0	2.1	11.6	2.6
08/01/2024 07:00	13.6	0.9	1.7	9.4	2.0
08/01/2024 08:00	13.8	1.3	1.7	9.5	2.0
08/01/2024 09:00	14.0	1.3	1.7	9.6	2.0
08/01/2024 10:00	13.8	1.3	1.7	9.5	2.0
08/01/2024 11:00	13.7	1.3	1.7	9.4	2.0
08/01/2024 12:00	13.7	1.6	1.7	9.4	2.0
08/01/2024 13:00	16.8	1.6	2.1	11.6	2.5
08/01/2024 14:00	17.1	0.9	2.2	11.7	2.6
08/01/2024 15:00	17.2	0.9	2.2	11.8	2.6
08/01/2024 16:00	17.4	0.6	2.2	12.0	2.6
08/01/2024 17:00	17.4	0.6	2.2	12.0	2.6
08/01/2024 18:00	17.4	0.6	2.2	12.0	2.6
08/01/2024 19:00	17.2	0.9	2.1	11.8	2.6
08/01/2024 20:00	17.2	0.9	2.1	11.7	2.6
08/01/2024 21:00	17.0	1.3	2.1	11.6	2.5
08/01/2024 22:00	17.0	1.3	2.1	11.6	2.5
08/01/2024 23:00	17.6	1.0	2.2	12.2	2.6
Average/Sum#:	388.5 #	26.8 #	48.7 #	268.2 #	58.2 #
Minimum:	13.6	0.6	1.7	9.4	2.0
Maximum:	17.6	1.6	2.2	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/02/2024 00:00	17.7	1.0	2.2	12.2	2.6
08/02/2024 01:00	17.6	1.0	2.2	12.2	2.6
08/02/2024 02:00	17.7	0.6	2.2	12.2	2.6
08/02/2024 03:00	17.8	0.6	2.2	12.3	2.7
08/02/2024 04:00	17.8	0.6	2.2	12.3	2.7
08/02/2024 05:00	17.8	0.6	2.2	12.3	2.7
08/02/2024 06:00	17.7	0.6	2.2	12.3	2.7
08/02/2024 07:00	17.7	0.6	2.2	12.2	2.6
08/02/2024 08:00	17.7	1.0	2.2	12.1	2.6
08/02/2024 09:00	17.6	1.0	2.2	12.1	2.6
08/02/2024 10:00	17.5	1.0	2.2	12.1	2.6
08/02/2024 11:00	17.5	0.6	2.2	12.1	2.6
08/02/2024 12:00	17.3	0.6	2.2	11.9	2.6
08/02/2024 13:00	17.3	0.6	2.2	11.9	2.6
08/02/2024 14:00	17.3	0.6	2.2	11.9	2.6
08/02/2024 15:00	17.3	0.6	2.2	11.9	2.6
08/02/2024 16:00	17.4	0.6	2.2	11.9	2.6
08/02/2024 17:00	17.3	0.6	2.2	11.9	2.6
08/02/2024 18:00	17.4	0.6	2.2	11.9	2.6
08/02/2024 19:00	17.4	0.6	2.2	12.0	2.6
08/02/2024 20:00	17.3	0.6	2.2	12.0	2.6
08/02/2024 21:00	17.6	0.6	2.2	12.1	2.6
08/02/2024 22:00	17.7	0.6	2.2	12.1	2.6
08/02/2024 23:00	17.7	0.6	2.2	12.1	2.6
Average/Sum#:	421.1 #	16.4 #	52.8 #	290.0 #	62.8 #
Minimum:	17.3	0.6	2.2	11.9	2.6
Maximum:	17.8	1.0	2.2	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/03/2024 00:00	17.7	0.6	2.2	12.1	2.6
08/03/2024 01:00	17.5	0.6	2.2	12.1	2.6
08/03/2024 02:00	17.3	0.9	2.1	11.9	2.6
08/03/2024 03:00	16.6	1.6	2.1	11.3	2.5
08/03/2024 04:00	16.4	1.9	2.1	11.2	2.5
08/03/2024 05:00	14.4	1.6	2.1	11.3	2.5
08/03/2024 06:00	14.1	1.9	2.0	11.0	2.4
08/03/2024 07:00	16.2	1.9	2.0	11.1	2.4
08/03/2024 08:00	16.2	2.2	2.1	11.1	2.4
08/03/2024 09:00	16.3	1.9	2.1	11.2	2.5
08/03/2024 10:00	16.4	1.9	2.1	11.2	2.5
08/03/2024 11:00	16.4	1.6	2.1	11.2	2.5
08/03/2024 12:00	16.4	1.6	2.1	11.2	2.5
08/03/2024 13:00	16.4	1.6	2.1	11.3	2.5
08/03/2024 14:00	16.7	1.6	2.1	11.4	2.5
08/03/2024 15:00	16.6	1.2	2.1	11.4	2.5
08/03/2024 16:00	16.7	1.2	2.1	11.4	2.5
08/03/2024 17:00	17.0	0.9	2.1	11.7	2.6
08/03/2024 18:00	17.3	0.6	2.2	11.9	2.6
08/03/2024 19:00	17.2	0.6	2.2	11.8	2.6
08/03/2024 20:00	17.2	0.6	2.1	11.8	2.6
08/03/2024 21:00	17.1	0.9	2.1	11.7	2.6
08/03/2024 22:00	17.1	0.9	2.1	11.8	2.6
08/03/2024 23:00	17.5	0.6	2.2	12.0	2.6
Average/Sum#:	398.7 #	30.9 #	50.7 #	276.1 #	60.7 #
Minimum:	14.1	0.6	2.0	11.0	2.4
Maximum:	17.7	2.2	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/04/2024 00:00	16.4	1.3	2.1	11.2	2.5
08/04/2024 01:00	16.4	1.6	2.1	11.3	2.5
08/04/2024 02:00	15.9	1.9	2.0	11.0	2.4
08/04/2024 03:00	13.8	1.0	1.7	9.5	2.0
08/04/2024 04:00	14.0	1.3	1.7	9.6	2.1
08/04/2024 05:00	14.0	1.6	1.7	9.6	2.1
08/04/2024 06:00	13.8	1.3	1.7	9.4	2.0
08/04/2024 07:00	12.8	1.2	1.6	8.8	2.0
08/04/2024 08:00	12.8	1.5	1.6	8.8	2.0
08/04/2024 09:00	11.8	1.4	1.4	8.1	1.8
08/04/2024 10:00	12.9	1.2	1.6	8.8	2.0
08/04/2024 11:00	13.5	1.2	1.7	9.2	2.0
08/04/2024 12:00	12.4	1.1	1.6	8.5	1.8
08/04/2024 13:00	16.6	1.9	2.1	11.4	2.5
08/04/2024 14:00	16.7	1.5	2.1	11.4	2.5
08/04/2024 15:00	16.7	1.2	2.1	11.4	2.5
08/04/2024 16:00	16.6	0.9	2.1	11.5	2.5
08/04/2024 17:00	17.1	0.6	2.2	11.7	2.6
08/04/2024 18:00	17.1	0.9	2.2	11.8	2.6
08/04/2024 19:00	16.8	0.9	2.1	11.6	2.6
08/04/2024 20:00	17.3	0.9	2.2	11.9	2.6
08/04/2024 21:00	17.5	0.9	2.2	12.1	2.6
08/04/2024 22:00	17.5	0.9	2.2	12.1	2.6
08/04/2024 23:00	17.6	0.9	2.2	12.1	2.6
Average/Sum#:	368.0 #	29.1 #	46.2 #	252.8 #	55.4 #
Minimum:	11.8	0.6	1.4	8.1	1.8
Maximum:	17.6	1.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/05/2024 00:00	17.7	0.9	2.2	12.1	2.6
08/05/2024 01:00	17.6	1.0	2.2	12.1	2.6
08/05/2024 02:00	17.5	1.0	2.2	12.0	2.6
08/05/2024 03:00	17.5	1.0	2.2	12.1	2.6
08/05/2024 04:00	17.8	1.0	2.2	12.3	2.7
08/05/2024 05:00	17.8	1.0	2.2	12.3	2.7
08/05/2024 06:00	12.7	1.6	2.1	11.7	2.6
08/05/2024 07:00	14.1	2.2	2.0	11.0	2.4
08/05/2024 08:00	15.9	2.5	2.0	11.0	2.4
08/05/2024 09:00	16.0	2.2	2.0	11.0	2.4
08/05/2024 10:00	16.1	1.9	2.0	11.1	2.4
08/05/2024 11:00	16.4	1.9	2.1	11.2	2.5
08/05/2024 12:00	16.7	1.6	2.1	11.4	2.5
08/05/2024 13:00	16.7	1.6	2.1	11.4	2.5
08/05/2024 14:00	17.2	0.9	2.2	11.9	2.6
08/05/2024 15:00	16.6	1.2	2.1	11.4	2.5
08/05/2024 16:00	16.4	1.6	2.1	11.3	2.5
08/05/2024 17:00	16.5	1.6	2.1	11.4	2.5
08/05/2024 18:00	17.0	0.9	2.1	11.7	2.6
08/05/2024 19:00	16.4	1.6	2.1	11.2	2.5
08/05/2024 20:00	17.5	0.9	2.2	12.0	2.6
08/05/2024 21:00	17.5	0.9	2.2	12.1	2.6
08/05/2024 22:00	17.5	0.9	2.2	12.1	2.6
08/05/2024 23:00	17.5	1.0	2.2	12.0	2.6
Average/Sum#:	400.6 #	32.9 #	51.1 #	279.8 #	61.1 #
Minimum:	12.7	0.9	2.0	11.0	2.4
Maximum:	17.8	2.5	2.2	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/06/2024 00:00	16.5	1.3	2.1	11.3	2.5
08/06/2024 01:00	16.0	2.3	2.0	11.0	2.4
08/06/2024 02:00	15.9	2.3	2.0	11.0	2.4
08/06/2024 03:00	15.9	2.3	2.0	11.0	2.4
08/06/2024 04:00	17.1	1.6	2.1	11.8	2.6
08/06/2024 05:00	8.8	1.3	2.2	12.1	2.6
08/06/2024 06:00	14.5	1.6	2.1	11.5	2.5
08/06/2024 07:00	15.9	2.3	2.0	11.0	2.4
08/06/2024 08:00	15.9	1.9	2.0	11.0	2.4
08/06/2024 09:00	16.0	1.9	2.0	11.0	2.4
08/06/2024 10:00	16.1	1.9	2.0	11.1	2.4
08/06/2024 11:00	16.2	1.9	2.1	11.1	2.4
08/06/2024 12:00	16.3	1.6	2.1	11.2	2.5
08/06/2024 13:00	16.4	1.6	2.1	11.2	2.5
08/06/2024 14:00	16.4	1.6	2.1	11.3	2.5
08/06/2024 15:00	16.4	1.6	2.1	11.3	2.5
08/06/2024 16:00	16.8	1.3	2.1	11.6	2.6
08/06/2024 17:00	17.1	0.9	2.1	11.7	2.6
08/06/2024 18:00	17.3	0.9	2.2	11.9	2.6
08/06/2024 19:00	17.2	0.9	2.1	11.8	2.6
08/06/2024 20:00	16.9	0.9	2.1	11.6	2.6
08/06/2024 21:00	17.0	0.9	2.1	11.7	2.6
08/06/2024 22:00	17.3	0.9	2.2	11.9	2.6
08/06/2024 23:00	16.7	1.6	2.1	11.4	2.5
Average/Sum#:	377.8 #	37.3 #	50.0 #	273.5 #	60.1 #
Minimum:	14.5	0.9	2.0	11.0	2.4
Maximum:	17.3	2.3	2.2	12.1	2.6
%SI	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/07/2024 00:00	16.4	1.9	2.1	11.3	2.5
08/07/2024 01:00	17.4	1.0	2.2	12.0	2.6
08/07/2024 02:00	16.7	1.3	2.1	11.4	2.5
08/07/2024 03:00	16.0	1.9	2.0	11.0	2.4
08/07/2024 04:00	16.1	1.9	2.0	11.0	2.4
08/07/2024 05:00	16.9	1.6	2.1	11.6	2.6
08/07/2024 06:00	17.1	1.3	2.1	11.8	2.6
08/07/2024 07:00	16.0	1.9	2.0	11.0	2.4
08/07/2024 08:00	16.1	2.2	2.0	11.0	2.4
08/07/2024 09:00	16.1	2.2	2.0	11.0	2.4
08/07/2024 10:00	16.2	2.2	2.1	11.1	2.4
08/07/2024 11:00	16.4	1.9	2.1	11.2	2.5
08/07/2024 12:00	16.4	1.9	2.1	11.3	2.5
08/07/2024 13:00	16.5	1.6	2.1	11.4	2.5
08/07/2024 14:00	16.8	1.6	2.1	11.5	2.5
08/07/2024 15:00	16.7	1.5	2.1	11.4	2.5
08/07/2024 16:00	16.5	1.5	2.1	11.4	2.5
08/07/2024 17:00	17.0	1.2	2.1	11.7	2.6
08/07/2024 18:00	17.2	0.9	2.2	11.9	2.6
08/07/2024 19:00	17.1	0.9	2.1	11.8	2.6
08/07/2024 20:00	17.0	1.2	2.1	11.7	2.6
08/07/2024 21:00	16.8	1.3	2.1	11.5	2.5
08/07/2024 22:00	16.1	1.9	2.0	11.1	2.4
08/07/2024 23:00	17.3	1.3	2.2	12.0	2.6
Average/Sum#:	398.8 #	38.1 #	50.1 #	274.1 #	60.1 #
Minimum:	16.0	0.9	2.0	11.0	2.4
Maximum:	17.4	2.2	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/08/2024 00:00	17.7	1.0	2.2	12.1	2.6
08/08/2024 01:00	16.8	1.3	2.1	11.6	2.6
08/08/2024 02:00	13.3	0.9	1.7	9.2	2.0
08/08/2024 03:00	13.6	1.3	1.7	9.4	2.0
08/08/2024 04:00	13.4	1.2	1.7	9.2	2.0
08/08/2024 05:00	13.9	1.0	1.7	9.6	2.0
08/08/2024 06:00	13.8	1.0	1.7	9.5	2.0
08/08/2024 07:00	13.4	1.2	1.7	9.2	2.0
08/08/2024 08:00	12.6	0.9	1.6	8.6	1.8
08/08/2024 09:00	12.5	0.9	1.6	8.6	1.8
08/08/2024 10:00	12.4	1.2	1.6	8.6	1.8
08/08/2024 11:00	9.4	1.0	1.3	7.4	1.6
08/08/2024 12:00	10.6	0.8	1.3	7.3	1.6
08/08/2024 13:00	10.6	0.8	1.3	7.3	1.6
08/08/2024 14:00	12.2	1.1	1.6	8.4	1.8
08/08/2024 15:00	16.5	2.1	2.1	11.4	2.5
08/08/2024 16:00	16.4	1.5	2.0	11.2	2.4
08/08/2024 17:00	16.4	1.2	2.0	11.3	2.4
08/08/2024 18:00	17.1	0.9	2.2	11.8	2.6
08/08/2024 19:00	17.1	0.9	2.1	11.8	2.6
08/08/2024 20:00	17.0	1.2	2.1	11.7	2.6
08/08/2024 21:00	16.8	1.3	2.1	11.6	2.6
08/08/2024 22:00	16.6	1.6	2.1	11.4	2.5
08/08/2024 23:00	16.8	1.6	2.1	11.5	2.5
Average/Sum#:	346.9 #	27.9 #	43.6 #	239.7 #	51.9 #
Minimum:	9.4	0.8	1.3	7.3	1.6
Maximum:	17.7	2.1	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/09/2024 00:00	12.8	1.2	1.6	8.8	2.0
08/09/2024 01:00	13.6	1.3	1.7	9.4	2.0
08/09/2024 02:00	13.8	1.3	1.7	9.5	2.0
08/09/2024 03:00	13.7	1.3	1.7	9.4	2.0
08/09/2024 04:00	14.0	1.3	1.7	9.6	2.1
08/09/2024 05:00	14.0	1.3	1.7	9.6	2.1
08/09/2024 06:00	13.7	1.3	1.7	9.4	2.0
08/09/2024 07:00	12.4	1.2	1.6	8.6	1.8
08/09/2024 08:00	11.7	1.1	1.4	8.1	1.8
08/09/2024 09:00	12.3	1.2	1.6	8.4	1.8
08/09/2024 10:00	12.5	1.2	1.6	8.6	1.8
08/09/2024 11:00	12.7	1.2	1.6	8.7	1.9
08/09/2024 12:00	13.2	1.2	1.7	9.0	2.0
08/09/2024 13:00	13.6	1.3	1.7	9.4	2.0
08/09/2024 14:00	12.8	1.5	1.6	8.8	2.0
08/09/2024 15:00	16.4	2.2	2.1	11.3	2.5
08/09/2024 16:00	16.6	1.5	2.0	11.4	2.4
08/09/2024 17:00	16.9	1.2	2.1	11.6	2.6
08/09/2024 18:00	17.1	0.9	2.2	11.9	2.6
08/09/2024 19:00	17.1	0.9	2.1	11.7	2.6
08/09/2024 20:00	16.7	1.2	2.1	11.5	2.5
08/09/2024 21:00	4.3	14.7	0.2	1.1	0.2
08/09/2024 22:00	0.0	0.0	0.0	0.0	0.0
08/09/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	301.9 #	41.5 #	37.4 #	205.8 #	44.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	17.1	14.7	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/10/2024 00:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/10/2024 13:00	44.1	41.4	0.1	0.8	0.2
08/10/2024 14:00	22.9	27.5	0.1	1.3	0.3
08/10/2024 15:00	35.2	40.6	0.3	2.9	0.6
08/10/2024 16:00	6.7	1.5	0.5	5.0	1.0
08/10/2024 17:00	8.4	2.5	0.6	6.3	1.3
08/10/2024 18:00	8.6	1.9	0.6	6.4	1.3
08/10/2024 19:00	8.5	1.5	0.6	6.4	1.3
08/10/2024 20:00	8.6	1.6	0.6	6.4	1.3
08/10/2024 21:00	8.3	1.9	0.6	6.2	1.3
08/10/2024 22:00	8.0	2.2	0.6	6.0	1.2
08/10/2024 23:00	1.1	8.3	0.1	0.5	0.1
Average/Sum#:	160.4 #	130.9 #	4.7 #	48.2 #	9.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	44.1	41.4	0.6	6.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/11/2024 00:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 14:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 15:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 16:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 17:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 18:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 19:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 20:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 21:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 22:00	0.0	0.0	0.0	0.0	0.0
08/11/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/12/2024 00:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/12/2024 13:00	42.2	61.2	0.1	0.6	0.1
08/12/2024 14:00	31.0	24.6	0.3	1.0	0.2
08/12/2024 15:00	21.1	37.5	0.7	2.4	0.6
08/12/2024 16:00	6.8	0.0	1.2	4.2	1.0
08/12/2024 17:00	7.7	0.0	1.4	4.8	1.2
08/12/2024 18:00	38.7	63.3	1.3	5.0	1.2
08/12/2024 19:00	57.1	68.4	1.4	6.0	1.4
08/12/2024 20:00	19.5	8.7	1.4	8.2	1.8
08/12/2024 21:00	13.7	1.3	1.7	9.4	2.0
08/12/2024 22:00	13.5	1.3	1.7	9.2	2.0
08/12/2024 23:00	13.8	1.3	1.7	9.4	2.0
Average/Sum#:	265.1 #	267.6 #	12.9 #	60.2 #	13.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	57.1	68.4	1.7	9.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/13/2024 00:00	13.4	1.2	1.7	9.2	2.0
08/13/2024 01:00	8.0	1.0	1.3	7.4	1.6
08/13/2024 02:00	5.3	13.7	0.2	0.9	0.2
08/13/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 14:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 15:00	0.0	0.0	0.0	0.0	0.0
08/13/2024 16:00	51.5	43.8	0.1	0.8	0.2
08/13/2024 17:00	20.3	29.4	0.1	1.3	0.3
08/13/2024 18:00	36.1	60.5	0.3	2.8	0.6
08/13/2024 19:00	7.2	2.5	0.5	5.4	1.1
08/13/2024 20:00	8.1	2.5	0.6	6.1	1.2
08/13/2024 21:00	8.2	2.2	0.6	6.2	1.2
08/13/2024 22:00	6.7	1.7	0.5	5.0	1.0
08/13/2024 23:00	6.4	1.2	0.5	4.8	1.0
Average/Sum#:	171.2 #	159.7 #	6.4 #	49.9 #	10.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.5	60.5	1.7	9.2	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/14/2024 00:00	6.6	1.2	0.5	4.9	1.0
08/14/2024 01:00	6.1	1.2	0.5	4.6	0.9
08/14/2024 02:00	3.8	9.8	0.1	1.3	0.3
08/14/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/14/2024 10:00	28.1	23.2	0.0	0.5	0.1
08/14/2024 11:00	55.0	52.1	0.2	2.4	0.5
08/14/2024 12:00	6.1	0.8	0.5	4.6	0.9
08/14/2024 13:00	6.3	0.9	0.5	4.7	0.9
08/14/2024 14:00	6.1	0.8	0.5	4.6	0.9
08/14/2024 15:00	5.8	0.8	0.4	4.4	0.9
08/14/2024 16:00	6.5	0.9	0.5	4.9	1.0
08/14/2024 17:00	6.9	0.9	0.5	5.2	1.0
08/14/2024 18:00	6.9	0.9	0.5	5.2	1.0
08/14/2024 19:00	7.0	0.9	0.5	5.2	1.0
08/14/2024 20:00	6.9	1.0	0.5	5.2	1.0
08/14/2024 21:00	6.9	1.0	0.5	5.2	1.0
08/14/2024 22:00	7.0	1.0	0.5	5.2	1.0
08/14/2024 23:00	7.1	1.0	0.5	5.3	1.1
Average/Sum#:	179.1 #	98.4 #	7.2 #	73.4 #	14.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	55.0	52.1	0.5	5.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/15/2024 00:00	3.7	9.8	0.1	1.6	0.3
08/15/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/15/2024 12:00	41.2	27.9	0.1	0.8	0.2
08/15/2024 13:00	19.5	25.8	0.1	1.3	0.3
08/15/2024 14:00	45.4	47.2	0.3	2.7	0.5
08/15/2024 15:00	6.4	0.9	0.5	4.8	1.0
08/15/2024 16:00	6.8	0.9	0.5	5.1	1.0
08/15/2024 17:00	70.0	59.7	0.7	5.9	1.2
08/15/2024 18:00	28.0	31.2	1.3	7.5	1.6
08/15/2024 19:00	14.6	1.5	1.8	10.0	2.2
08/15/2024 20:00	16.9	0.9	2.1	11.6	2.6
08/15/2024 21:00	13.6	0.9	1.7	9.3	2.0
08/15/2024 22:00	13.4	0.6	1.7	9.2	2.0
08/15/2024 23:00	13.6	0.9	1.7	9.3	2.0
Average/Sum#:	293.1 #	208.2 #	12.6 #	79.1 #	16.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.0	59.7	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/16/2024 00:00	13.9	0.6	1.7	9.6	2.0
08/16/2024 01:00	13.5	0.9	1.7	9.2	2.0
08/16/2024 02:00	7.5	20.5	0.4	2.6	0.6
08/16/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/16/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/16/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/16/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/16/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/16/2024 08:00	2.7	10.9	0.1	0.4	0.1
08/16/2024 09:00	38.1	67.5	0.6	2.3	0.6
08/16/2024 10:00	6.3	0.0	1.1	3.9	0.9
08/16/2024 11:00	5.7	0.0	1.0	3.6	0.9
08/16/2024 12:00	42.1	34.7	1.3	5.4	1.3
08/16/2024 13:00	48.9	46.0	1.5	7.7	1.7
08/16/2024 14:00	9.4	0.8	1.3	7.4	1.6
08/16/2024 15:00	12.6	1.2	1.6	8.7	1.8
08/16/2024 16:00	16.7	1.6	2.0	11.5	2.5
08/16/2024 17:00	16.6	0.9	2.1	11.5	2.5
08/16/2024 18:00	16.9	0.9	2.1	11.6	2.6
08/16/2024 19:00	16.8	0.9	2.1	11.6	2.6
08/16/2024 20:00	17.1	0.9	2.1	11.7	2.6
08/16/2024 21:00	17.0	0.9	2.1	11.7	2.6
08/16/2024 22:00	17.2	0.6	2.2	11.8	2.6
08/16/2024 23:00	17.2	1.0	2.2	11.8	2.6
Average/Sum#:	336.2 #	190.8 #	29.2 #	154.0 #	34.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	48.9	67.5	2.2	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/17/2024 00:00	17.2	1.0	2.1	11.8	2.6
08/17/2024 01:00	16.3	1.9	2.1	11.2	2.5
08/17/2024 02:00	15.9	3.2	2.0	11.0	2.4
08/17/2024 03:00	15.9	3.9	2.0	10.9	2.4
08/17/2024 04:00	16.2	1.9	2.0	11.1	2.4
08/17/2024 05:00	14.3	1.6	2.1	11.2	2.4
08/17/2024 06:00	4.6	10.5	0.7	3.6	0.8
08/17/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/17/2024 14:00	1.6	2.3	0.0	0.1	0.0
08/17/2024 15:00	63.6	51.6	0.2	2.3	0.5
08/17/2024 16:00	6.3	0.9	0.5	4.8	1.0
08/17/2024 17:00	7.7	2.2	0.6	5.8	1.2
08/17/2024 18:00	8.1	1.9	0.6	6.1	1.2
08/17/2024 19:00	7.9	1.9	0.6	6.0	1.2
08/17/2024 20:00	7.9	2.2	0.6	6.0	1.2
08/17/2024 21:00	7.9	2.3	0.6	5.9	1.2
08/17/2024 22:00	7.8	2.3	0.6	5.9	1.2
08/17/2024 23:00	6.9	1.0	0.5	5.2	1.0
Average/Sum#:	221.5 #	82.1 #	17.8 #	118.9 #	25.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.6	51.6	2.1	11.8	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/18/2024 00:00	7.9	2.3	0.6	5.9	1.2
08/18/2024 01:00	7.7	2.2	0.6	5.8	1.2
08/18/2024 02:00	1.1	6.6	0.0	0.4	0.1
08/18/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/18/2024 09:00	43.7	53.9	0.2	0.7	0.2
08/18/2024 10:00	15.9	28.6	0.3	1.1	0.3
08/18/2024 11:00	45.9	72.9	0.7	2.7	0.6
08/18/2024 12:00	4.2	0.0	1.0	3.5	0.8
08/18/2024 13:00	6.3	0.0	1.1	4.0	1.0
08/18/2024 14:00	42.8	32.3	1.3	4.9	1.1
08/18/2024 15:00	53.6	44.6	1.3	6.7	1.5
08/18/2024 16:00	13.4	0.9	1.7	9.1	2.0
08/18/2024 17:00	13.4	0.9	1.7	9.2	2.0
08/18/2024 18:00	16.6	1.6	2.1	11.4	2.5
08/18/2024 19:00	17.8	0.6	2.2	12.2	2.6
08/18/2024 20:00	17.8	0.6	2.3	12.3	2.6
08/18/2024 21:00	17.9	0.6	2.3	12.3	2.6
08/18/2024 22:00	17.5	1.0	2.2	12.0	2.7
08/18/2024 23:00	14.9	1.0	2.1	11.7	2.6
Average/Sum#:	358.4 #	250.6 #	23.7 #	125.9 #	27.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	53.6	72.9	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/19/2024 00:00	3.0	14.7	0.1	0.7	0.2
08/19/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/19/2024 07:00	44.7	41.2	0.2	1.3	0.3
08/19/2024 08:00	4.5	0.6	0.5	4.5	0.9
08/19/2024 09:00	6.2	0.6	0.5	4.6	0.9
08/19/2024 10:00	6.2	0.6	0.5	4.7	0.9
08/19/2024 11:00	6.2	0.9	0.5	4.7	0.9
08/19/2024 12:00	45.4	25.0	0.7	5.7	1.2
08/19/2024 13:00	55.7	63.8	1.1	7.0	1.5
08/19/2024 14:00	13.2	0.9	1.7	9.0	2.0
08/19/2024 15:00	12.2	0.9	1.6	8.3	1.8
08/19/2024 16:00	16.3	1.6	2.1	11.2	2.5
08/19/2024 17:00	16.6	1.6	2.1	11.3	2.5
08/19/2024 18:00	17.7	0.6	2.3	12.2	2.6
08/19/2024 19:00	16.6	1.6	2.1	11.4	2.5
08/19/2024 20:00	16.1	3.2	2.1	11.0	2.5
08/19/2024 21:00	17.6	1.0	2.2	12.1	2.6
08/19/2024 22:00	17.5	1.0	2.2	12.0	2.6
08/19/2024 23:00	16.4	2.5	2.1	11.2	2.5
Average/Sum#:	332.1 #	162.3 #	24.6 #	142.9 #	30.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	55.7	63.8	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/20/2024 00:00	15.4	2.8	2.0	10.6	2.3
08/20/2024 01:00	4.6	15.7	0.2	0.9	0.2
08/20/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/20/2024 09:00	21.7	20.0	0.1	0.5	0.1
08/20/2024 10:00	45.9	82.2	0.7	2.3	0.6
08/20/2024 11:00	4.2	0.0	1.0	3.5	0.8
08/20/2024 12:00	6.2	0.0	1.1	3.9	0.9
08/20/2024 13:00	52.2	27.6	1.3	5.3	1.2
08/20/2024 14:00	58.3	52.9	1.3	6.7	1.5
08/20/2024 15:00	10.6	0.5	1.3	7.3	1.6
08/20/2024 16:00	12.4	0.9	1.6	8.6	1.8
08/20/2024 17:00	16.7	1.6	2.1	11.5	2.6
08/20/2024 18:00	16.5	1.6	2.1	11.3	2.5
08/20/2024 19:00	16.1	3.2	2.1	11.0	2.4
08/20/2024 20:00	16.0	3.5	2.1	11.0	2.4
08/20/2024 21:00	16.3	1.6	2.0	11.3	2.4
08/20/2024 22:00	17.2	0.9	2.1	11.8	2.6
08/20/2024 23:00	17.1	1.0	2.1	11.7	2.5
Average/Sum#:	347.4 #	216.0 #	25.2 #	129.2 #	28.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	58.3	82.2	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/21/2024 00:00	16.8	1.6	2.2	11.4	2.5
08/21/2024 01:00	15.7	2.6	2.0	10.8	2.4
08/21/2024 02:00	13.6	0.9	1.7	9.4	2.0
08/21/2024 03:00	13.7	0.6	1.7	9.4	2.0
08/21/2024 04:00	13.8	1.0	1.7	9.5	2.0
08/21/2024 05:00	13.8	1.0	1.7	9.5	2.0
08/21/2024 06:00	13.8	0.6	1.7	9.5	2.0
08/21/2024 07:00	13.0	0.6	1.6	8.9	2.0
08/21/2024 08:00	12.9	0.6	1.6	8.8	2.0
08/21/2024 09:00	10.6	0.5	1.3	7.3	1.6
08/21/2024 10:00	12.3	0.6	1.6	8.4	1.8
08/21/2024 11:00	12.6	0.6	1.6	8.7	1.9
08/21/2024 12:00	13.2	0.6	1.7	9.2	2.0
08/21/2024 13:00	13.9	1.0	1.7	9.6	2.0
08/21/2024 14:00	14.0	1.0	1.7	9.6	2.1
08/21/2024 15:00	13.8	0.9	1.7	9.5	2.0
08/21/2024 16:00	12.9	0.9	1.6	8.8	2.0
08/21/2024 17:00	16.7	1.6	2.1	11.5	2.5
08/21/2024 18:00	17.9	0.6	2.3	12.3	2.7
08/21/2024 19:00	17.9	0.6	2.3	12.3	2.7
08/21/2024 20:00	17.6	0.6	2.2	12.1	2.6
08/21/2024 21:00	17.6	0.6	2.2	12.1	2.6
08/21/2024 22:00	17.5	0.6	2.2	12.0	2.6
08/21/2024 23:00	17.3	1.0	2.1	11.9	2.6
Average/Sum#:	352.9 #	21.2 #	44.2 #	242.5 #	52.6 #
Minimum:	10.6	0.5	1.3	7.3	1.6
Maximum:	17.9	2.6	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/22/2024 00:00	16.0	1.3	2.0	11.0	2.4
08/22/2024 01:00	15.8	1.6	2.0	10.8	2.4
08/22/2024 02:00	15.8	1.6	2.0	10.8	2.4
08/22/2024 03:00	15.8	1.6	2.0	10.8	2.4
08/22/2024 04:00	15.8	2.0	2.0	10.8	2.4
08/22/2024 05:00	17.0	1.3	2.1	11.7	2.6
08/22/2024 06:00	3.0	8.0	0.2	0.9	0.2
08/22/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/22/2024 14:00	31.6	18.9	0.1	0.6	0.1
08/22/2024 15:00	33.2	44.2	0.6	2.2	0.5
08/22/2024 16:00	6.7	0.0	1.2	4.2	1.0
08/22/2024 17:00	7.6	0.0	1.3	4.7	1.1
08/22/2024 18:00	8.1	0.0	1.4	5.0	1.2
08/22/2024 19:00	8.0	0.0	1.4	5.0	1.2
08/22/2024 20:00	7.9	0.0	1.4	5.0	1.2
08/22/2024 21:00	7.9	0.0	1.4	4.9	1.2
08/22/2024 22:00	7.9	0.0	1.4	4.9	1.2
08/22/2024 23:00	7.9	0.0	1.4	4.9	1.2
Average/Sum#:	223.0 #	72.5 #	23.9 #	108.2 #	24.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	33.2	44.2	2.1	11.7	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/23/2024 00:00	7.8	0.0	1.4	4.9	1.2
08/23/2024 01:00	7.8	0.0	1.4	4.9	1.2
08/23/2024 02:00	7.8	0.0	1.4	4.9	1.2
08/23/2024 03:00	7.8	0.0	1.4	4.9	1.2
08/23/2024 04:00	7.9	0.0	1.4	4.9	1.2
08/23/2024 05:00	8.2	0.0	1.4	5.1	1.2
08/23/2024 06:00	4.3	0.0	1.0	3.6	0.9
08/23/2024 07:00	1.8	6.0	0.1	0.2	0.0
08/23/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 14:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 15:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 16:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 17:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 18:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 19:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 20:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 21:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 22:00	0.0	0.0	0.0	0.0	0.0
08/23/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	53.4 #	6.0 #	9.5 #	33.4 #	8.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	8.2	6.0	1.4	5.1	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/24/2024 00:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 13:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 14:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 15:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 16:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 17:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 18:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 19:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 20:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 21:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 22:00	0.0	0.0	0.0	0.0	0.0
08/24/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/25/2024 00:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 01:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 02:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 03:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 04:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 05:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 06:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 10:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 11:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 12:00	0.0	0.0	0.0	0.0	0.0
08/25/2024 13:00	54.4	49.2	0.1	0.6	0.1
08/25/2024 14:00	75.5	67.7	0.5	1.6	0.4
08/25/2024 15:00	37.4	60.2	0.8	3.0	0.7
08/25/2024 16:00	7.0	0.0	1.2	4.4	1.0
08/25/2024 17:00	8.2	0.0	1.4	5.1	1.2
08/25/2024 18:00	9.3	0.0	1.6	5.8	1.4
08/25/2024 19:00	9.3	0.0	1.6	5.8	1.4
08/25/2024 20:00	9.4	0.0	1.6	5.9	1.4
08/25/2024 21:00	8.4	0.0	1.5	5.2	1.3
08/25/2024 22:00	7.9	0.0	1.4	4.9	1.2
08/25/2024 23:00	7.0	0.0	1.2	4.4	1.1
Average/Sum#:	233.8 #	177.1 #	12.9 #	46.7 #	11.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	75.5	67.7	1.6	5.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/26/2024 00:00	11.9	44.6	1.3	4.6	1.1
08/26/2024 01:00	7.0	0.0	1.2	4.4	1.1
08/26/2024 02:00	7.1	0.0	1.2	4.4	1.1
08/26/2024 03:00	7.3	0.0	1.3	4.6	1.1
08/26/2024 04:00	7.3	0.0	1.3	4.6	1.1
08/26/2024 05:00	7.3	0.0	1.3	4.6	1.1
08/26/2024 06:00	6.9	0.0	1.2	4.3	1.0
08/26/2024 07:00	63.7	57.5	1.4	5.4	1.3
08/26/2024 08:00	6.6	15.9	1.6	7.9	1.8
08/26/2024 09:00	13.8	1.0	1.7	9.5	2.0
08/26/2024 10:00	13.8	1.0	1.7	9.5	2.0
08/26/2024 11:00	13.8	1.0	1.7	9.5	2.0
08/26/2024 12:00	14.8	1.6	1.9	10.2	2.2
08/26/2024 13:00	16.2	1.9	2.0	11.2	2.4
08/26/2024 14:00	16.6	1.6	2.1	11.4	2.4
08/26/2024 15:00	16.3	1.6	2.0	11.2	2.4
08/26/2024 16:00	17.2	1.0	2.1	11.8	2.6
08/26/2024 17:00	18.1	0.6	2.3	12.4	2.7
08/26/2024 18:00	18.3	0.6	2.3	12.5	2.8
08/26/2024 19:00	16.0	0.6	2.3	12.6	2.8
08/26/2024 20:00	17.9	0.6	2.3	12.3	2.7
08/26/2024 21:00	18.0	0.6	2.3	12.3	2.7
08/26/2024 22:00	17.7	0.6	2.3	12.2	2.6
08/26/2024 23:00	16.0	1.6	2.0	11.0	2.4
Average/Sum#:	363.0 #	118.0 #	42.8 #	214.4 #	47.4 #
Minimum:	6.9	0.0	1.2	4.3	1.0
Maximum:	63.7	57.5	2.3	12.6	2.8
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/27/2024 00:00	15.9	2.0	2.0	10.9	2.4
08/27/2024 01:00	16.0	2.0	2.0	11.0	2.4
08/27/2024 02:00	16.0	2.0	2.0	11.0	2.4
08/27/2024 03:00	16.0	1.9	2.0	11.0	2.4
08/27/2024 04:00	15.8	2.0	2.0	10.8	2.4
08/27/2024 05:00	12.1	0.6	1.7	9.4	2.0
08/27/2024 06:00	13.6	0.6	1.7	9.4	2.0
08/27/2024 07:00	12.8	0.6	1.6	8.8	2.0
08/27/2024 08:00	10.6	0.5	1.3	7.2	1.6
08/27/2024 09:00	10.5	0.5	1.3	7.2	1.6
08/27/2024 10:00	10.6	0.5	1.3	7.2	1.6
08/27/2024 11:00	10.6	0.5	1.3	7.3	1.6
08/27/2024 12:00	12.9	0.9	1.6	8.9	2.0
08/27/2024 13:00	13.2	0.9	1.7	9.2	2.0
08/27/2024 14:00	13.8	0.9	1.7	9.4	2.0
08/27/2024 15:00	12.7	0.9	1.6	8.8	2.0
08/27/2024 16:00	15.5	1.5	2.0	10.7	2.4
08/27/2024 17:00	17.8	0.9	2.3	12.2	2.6
08/27/2024 18:00	17.6	0.6	2.3	12.1	2.6
08/27/2024 19:00	17.8	0.6	2.3	12.2	2.7
08/27/2024 20:00	18.0	0.6	2.3	12.4	2.7
08/27/2024 21:00	17.8	0.6	2.3	12.2	2.7
08/27/2024 22:00	16.9	1.0	2.1	11.6	2.6
08/27/2024 23:00	17.5	0.7	2.2	12.0	2.6
Average/Sum#:	352.0 #	23.8 #	44.6 #	242.9 #	53.3 #
Minimum:	10.5	0.5	1.3	7.2	1.6
Maximum:	18.0	2.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/28/2024 00:00	17.1	1.0	2.1	11.7	2.6
08/28/2024 01:00	16.0	1.3	2.0	11.0	2.4
08/28/2024 02:00	16.0	1.3	2.0	11.0	2.4
08/28/2024 03:00	16.6	1.3	2.1	11.4	2.5
08/28/2024 04:00	17.6	0.6	2.3	12.2	2.6
08/28/2024 05:00	15.4	0.6	2.3	12.1	2.6
08/28/2024 06:00	16.5	1.0	2.1	11.4	2.4
08/28/2024 07:00	16.0	1.3	2.0	11.0	2.4
08/28/2024 08:00	16.0	1.3	2.0	11.0	2.4
08/28/2024 09:00	16.1	1.3	2.0	11.0	2.4
08/28/2024 10:00	16.1	1.3	2.0	11.1	2.4
08/28/2024 11:00	16.2	1.3	2.0	11.2	2.4
08/28/2024 12:00	16.3	1.3	2.0	11.2	2.4
08/28/2024 13:00	16.7	0.9	2.1	11.5	2.6
08/28/2024 14:00	16.6	0.9	2.1	11.4	2.5
08/28/2024 15:00	16.5	0.9	2.0	11.3	2.4
08/28/2024 16:00	16.7	0.9	2.1	11.4	2.5
08/28/2024 17:00	16.5	1.0	2.0	11.4	2.4
08/28/2024 18:00	17.2	0.6	2.1	11.8	2.6
08/28/2024 19:00	17.9	0.6	2.3	12.3	2.7
08/28/2024 20:00	17.1	0.6	2.1	11.7	2.6
08/28/2024 21:00	16.1	1.3	2.0	11.1	2.4
08/28/2024 22:00	16.1	1.3	2.0	11.0	2.4
08/28/2024 23:00	15.9	1.3	2.0	11.0	2.4
Average/Sum#:	395.2 #	25.2 #	49.7 #	273.2 #	59.4 #
Minimum:	15.4	0.6	2.0	11.0	2.4
Maximum:	17.9	1.3	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/29/2024 00:00	16.0	1.6	2.0	11.0	2.4
08/29/2024 01:00	15.9	1.3	2.0	11.0	2.4
08/29/2024 02:00	15.9	1.6	2.0	10.9	2.4
08/29/2024 03:00	15.9	1.6	2.0	10.9	2.4
08/29/2024 04:00	16.2	1.6	2.0	11.2	2.4
08/29/2024 05:00	13.9	1.6	2.0	10.9	2.4
08/29/2024 06:00	14.0	1.0	1.7	9.6	2.0
08/29/2024 07:00	12.4	0.9	1.6	8.5	1.8
08/29/2024 08:00	10.6	0.7	1.3	7.3	1.6
08/29/2024 09:00	10.6	0.8	1.3	7.3	1.6
08/29/2024 10:00	10.6	0.8	1.3	7.3	1.6
08/29/2024 11:00	10.6	0.8	1.3	7.3	1.6
08/29/2024 12:00	12.7	1.2	1.6	8.7	1.9
08/29/2024 13:00	13.4	1.2	1.7	9.2	2.0
08/29/2024 14:00	13.8	0.9	1.7	9.5	2.0
08/29/2024 15:00	12.4	1.1	1.6	8.5	1.8
08/29/2024 16:00	16.6	1.6	2.1	11.4	2.5
08/29/2024 17:00	17.2	1.3	2.1	11.8	2.6
08/29/2024 18:00	16.5	0.9	2.1	11.4	2.4
08/29/2024 19:00	17.6	1.0	2.3	12.1	2.6
08/29/2024 20:00	16.9	1.3	2.1	11.6	2.6
08/29/2024 21:00	16.5	1.3	2.1	11.4	2.4
08/29/2024 22:00	16.0	1.6	2.0	11.0	2.4
08/29/2024 23:00	15.9	1.6	2.0	11.0	2.4
Average/Sum#:	348.1 #	29.3 #	43.9 #	240.8 #	52.2 #
Minimum:	10.6	0.7	1.3	7.3	1.6
Maximum:	17.6	1.6	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/30/2024 00:00	15.9	1.6	2.0	10.9	2.4
08/30/2024 01:00	15.9	1.6	2.0	10.9	2.4
08/30/2024 02:00	15.9	1.6	2.0	10.9	2.4
08/30/2024 03:00	15.9	2.0	2.0	10.9	2.4
08/30/2024 04:00	16.5	1.6	2.0	11.4	2.4
08/30/2024 05:00	16.9	1.3	2.1	11.6	2.6
08/30/2024 06:00	16.5	1.3	2.0	11.4	2.4
08/30/2024 07:00	11.2	0.8	1.4	7.7	1.6
08/30/2024 08:00	11.0	0.8	1.4	7.5	1.6
08/30/2024 09:00	10.6	0.7	1.3	7.3	1.6
08/30/2024 10:00	10.6	0.8	1.3	7.3	1.6
08/30/2024 11:00	9.6	0.8	1.4	7.5	1.6
08/30/2024 12:00	10.8	0.8	1.3	7.4	1.6
08/30/2024 13:00	13.4	0.9	1.7	9.2	2.0
08/30/2024 14:00	13.7	1.2	1.7	9.5	2.0
08/30/2024 15:00	16.6	1.3	2.1	11.4	2.5
08/30/2024 16:00	16.9	0.9	2.1	11.6	2.6
08/30/2024 17:00	17.6	0.6	2.3	12.2	2.6
08/30/2024 18:00	18.0	0.6	2.3	12.4	2.7
08/30/2024 19:00	18.0	0.6	2.3	12.3	2.7
08/30/2024 20:00	18.0	0.6	2.3	12.3	2.7
08/30/2024 21:00	17.5	0.6	2.2	12.0	2.6
08/30/2024 22:00	16.3	1.3	2.0	11.2	2.4
08/30/2024 23:00	17.7	0.6	2.3	12.2	2.6
Average/Sum#:	361.0 #	24.9 #	45.5 #	249.0 #	54.0 #
Minimum:	9.6	0.6	1.3	7.3	1.6
Maximum:	18.0	2.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/31/2024 00:00	17.7	1.0	2.3	12.2	2.6
08/31/2024 01:00	17.6	1.0	2.3	12.1	2.6
08/31/2024 02:00	17.6	0.6	2.3	12.0	2.6
08/31/2024 03:00	17.6	1.0	2.2	12.0	2.6
08/31/2024 04:00	17.5	0.6	2.2	12.0	2.6
08/31/2024 05:00	16.7	1.0	2.1	11.4	2.5
08/31/2024 06:00	4.6	13.2	0.1	0.7	0.2
08/31/2024 07:00	0.0	0.0	0.0	0.0	0.0
08/31/2024 08:00	0.0	0.0	0.0	0.0	0.0
08/31/2024 09:00	0.0	0.0	0.0	0.0	0.0
08/31/2024 10:00	0.1	2.1	0.0	0.1	0.0
08/31/2024 11:00	22.2	50.5	0.2	2.4	0.5
08/31/2024 12:00	5.6	0.8	0.4	4.2	0.8
08/31/2024 13:00	5.5	0.8	0.4	4.2	0.8
08/31/2024 14:00	23.9	15.5	0.6	5.3	1.1
08/31/2024 15:00	33.4	48.6	1.2	7.2	1.5
08/31/2024 16:00	13.4	0.9	1.7	9.2	2.0
08/31/2024 17:00	14.5	1.2	1.8	10.0	2.2
08/31/2024 18:00	18.1	0.6	2.3	12.4	2.7
08/31/2024 19:00	18.3	0.3	2.3	12.5	2.8
08/31/2024 20:00	16.0	0.3	2.3	12.5	2.8
08/31/2024 21:00	18.3	0.3	2.3	12.6	2.8
08/31/2024 22:00	17.9	0.6	2.3	12.3	2.7
08/31/2024 23:00	16.0	0.6	2.3	12.5	2.8
Average/Sum#:	332.5 #	141.5 #	33.6 #	189.8 #	41.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	33.4	50.5	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/01/2024 00:00	17.3	1.0	2.1	11.9	2.6
09/01/2024 01:00	17.3	1.0	2.1	11.8	2.6
09/01/2024 02:00	17.4	1.0	2.1	12.0	2.6
09/01/2024 03:00	16.6	1.0	2.1	11.4	2.5
09/01/2024 04:00	16.0	1.6	2.0	11.0	2.4
09/01/2024 05:00	15.6	1.9	2.0	10.7	2.4
09/01/2024 06:00	3.9	15.2	0.2	0.9	0.2
09/01/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/01/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/01/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/01/2024 10:00	0.1	2.3	0.0	0.1	0.0
09/01/2024 11:00	26.1	63.7	0.5	1.9	0.5
09/01/2024 12:00	4.3	0.0	1.0	3.6	0.9
09/01/2024 13:00	5.5	0.0	1.0	3.5	0.8
09/01/2024 14:00	21.5	12.5	1.1	4.5	1.1
09/01/2024 15:00	45.3	33.1	1.4	7.2	1.6
09/01/2024 16:00	13.8	0.9	1.7	9.5	2.0
09/01/2024 17:00	13.8	0.9	1.7	9.5	2.0
09/01/2024 18:00	17.2	1.3	2.1	11.8	2.6
09/01/2024 19:00	17.7	0.6	2.3	12.2	2.6
09/01/2024 20:00	15.4	0.6	2.3	12.1	2.6
09/01/2024 21:00	17.9	0.6	2.3	12.3	2.7
09/01/2024 22:00	17.5	1.0	2.2	12.0	2.6
09/01/2024 23:00	17.4	1.0	2.2	11.9	2.6
Average/Sum#:	337.6 #	141.2 #	34.4 #	181.8 #	39.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	45.3	63.7	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/02/2024 00:00	17.2	1.0	2.1	11.9	2.6
09/02/2024 01:00	16.7	1.3	2.1	11.5	2.6
09/02/2024 02:00	15.6	1.9	2.0	10.8	2.4
09/02/2024 03:00	15.7	2.0	2.0	10.8	2.4
09/02/2024 04:00	15.7	2.3	2.0	10.8	2.4
09/02/2024 05:00	15.6	2.3	2.0	10.8	2.4
09/02/2024 06:00	15.4	1.9	2.0	10.6	2.4
09/02/2024 07:00	5.8	15.4	0.2	0.9	0.2
09/02/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/02/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/02/2024 10:00	2.0	19.5	0.1	0.4	0.1
09/02/2024 11:00	23.8	63.7	0.8	3.0	0.7
09/02/2024 12:00	5.5	0.0	1.0	3.4	0.8
09/02/2024 13:00	5.5	0.0	1.0	3.4	0.8
09/02/2024 14:00	28.5	21.9	1.2	4.9	1.1
09/02/2024 15:00	49.9	47.9	1.5	7.4	1.6
09/02/2024 16:00	13.5	0.9	1.7	9.2	2.0
09/02/2024 17:00	14.6	1.2	1.8	10.1	2.2
09/02/2024 18:00	18.2	0.6	2.3	12.5	2.8
09/02/2024 19:00	18.3	0.3	2.3	12.6	2.8
09/02/2024 20:00	17.6	0.6	2.2	12.1	2.6
09/02/2024 21:00	16.0	1.3	2.0	11.0	2.4
09/02/2024 22:00	16.2	1.3	2.0	11.2	2.4
09/02/2024 23:00	16.0	1.3	2.0	11.0	2.4
Average/Sum#:	363.3 #	188.6 #	36.3 #	190.3 #	42.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.9	63.7	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/03/2024 00:00	15.8	1.6	2.0	10.8	2.4
09/03/2024 01:00	15.8	1.6	2.0	11.0	2.4
09/03/2024 02:00	15.8	1.6	2.0	10.8	2.4
09/03/2024 03:00	15.8	1.6	2.0	10.8	2.4
09/03/2024 04:00	16.0	1.6	2.0	11.0	2.4
09/03/2024 05:00	14.9	1.3	2.1	11.8	2.6
09/03/2024 06:00	16.7	1.3	2.1	11.4	2.5
09/03/2024 07:00	15.7	1.6	2.0	10.8	2.4
09/03/2024 08:00	15.8	1.6	2.0	10.9	2.4
09/03/2024 09:00	15.9	1.6	2.0	11.0	2.4
09/03/2024 10:00	16.1	1.6	2.0	11.0	2.4
09/03/2024 11:00	16.2	1.3	2.0	11.1	2.4
09/03/2024 12:00	16.9	0.9	2.1	11.6	2.6
09/03/2024 13:00	17.7	0.6	2.3	12.2	2.6
09/03/2024 14:00	17.9	0.6	2.3	12.3	2.7
09/03/2024 15:00	17.9	0.3	2.3	12.3	2.7
09/03/2024 16:00	17.9	0.6	2.3	12.2	2.6
09/03/2024 17:00	18.1	0.6	2.3	12.4	2.7
09/03/2024 18:00	16.0	0.3	2.3	12.5	2.8
09/03/2024 19:00	18.3	0.3	2.3	12.6	2.8
09/03/2024 20:00	18.3	0.3	2.3	12.6	2.8
09/03/2024 21:00	18.3	0.3	2.3	12.6	2.8
09/03/2024 22:00	18.3	0.3	2.3	12.6	2.8
09/03/2024 23:00	17.1	0.6	2.1	11.8	2.6
Average/Sum#:	403.2 #	24.0 #	51.4 #	280.1 #	61.6 #
Minimum:	14.9	0.3	2.0	10.8	2.4
Maximum:	18.3	1.6	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/04/2024 00:00	13.8	0.6	1.7	9.5	2.0
09/04/2024 01:00	13.8	1.0	1.7	9.5	2.0
09/04/2024 02:00	13.8	1.0	1.7	9.5	2.0
09/04/2024 03:00	14.0	0.7	1.7	9.6	2.0
09/04/2024 04:00	14.0	1.0	1.7	9.5	2.0
09/04/2024 05:00	13.7	1.0	1.7	9.4	2.0
09/04/2024 06:00	13.7	1.0	1.7	9.4	2.0
09/04/2024 07:00	14.0	1.0	1.7	9.6	2.0
09/04/2024 08:00	14.0	1.0	1.7	9.6	2.1
09/04/2024 09:00	14.0	1.0	1.7	9.6	2.1
09/04/2024 10:00	13.9	1.0	1.7	9.6	2.0
09/04/2024 11:00	14.0	1.0	1.7	9.6	2.1
09/04/2024 12:00	13.5	0.9	1.7	9.2	2.0
09/04/2024 13:00	17.2	1.3	2.1	11.8	2.6
09/04/2024 14:00	17.6	0.6	2.3	12.1	2.6
09/04/2024 15:00	17.1	0.6	2.1	11.8	2.6
09/04/2024 16:00	17.4	0.9	2.1	12.0	2.6
09/04/2024 17:00	17.4	0.6	2.1	12.0	2.6
09/04/2024 18:00	17.1	0.9	2.1	11.8	2.6
09/04/2024 19:00	17.9	0.6	2.3	12.3	2.7
09/04/2024 20:00	17.9	0.6	2.3	12.3	2.7
09/04/2024 21:00	17.8	0.6	2.3	12.2	2.7
09/04/2024 22:00	17.5	0.6	2.2	12.0	2.6
09/04/2024 23:00	17.8	0.6	2.3	12.2	2.6
Average/Sum#:	372.9 #	20.1 #	46.3 #	256.1 #	55.2 #
Minimum:	13.5	0.6	1.7	9.2	2.0
Maximum:	17.9	1.3	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/05/2024 00:00	15.4	0.6	2.3	12.2	2.6
09/05/2024 01:00	17.6	0.6	2.3	12.0	2.6
09/05/2024 02:00	17.5	0.6	2.2	12.0	2.6
09/05/2024 03:00	16.3	1.3	2.0	11.2	2.4
09/05/2024 04:00	15.4	0.6	2.3	12.2	2.6
09/05/2024 05:00	9.0	0.6	2.3	12.6	2.8
09/05/2024 06:00	14.8	1.0	2.1	11.6	2.6
09/05/2024 07:00	13.8	0.6	1.7	9.5	2.0
09/05/2024 08:00	13.3	0.6	1.7	9.2	2.0
09/05/2024 09:00	13.8	0.9	1.7	9.5	2.0
09/05/2024 10:00	13.7	1.0	1.7	9.4	2.0
09/05/2024 11:00	13.8	1.0	1.7	9.5	2.0
09/05/2024 12:00	13.9	1.0	1.7	9.5	2.0
09/05/2024 13:00	17.2	1.2	2.1	11.8	2.6
09/05/2024 14:00	17.5	0.6	2.2	12.1	2.6
09/05/2024 15:00	17.5	0.6	2.2	12.0	2.6
09/05/2024 16:00	16.8	0.9	2.1	11.6	2.6
09/05/2024 17:00	17.2	0.6	2.1	11.8	2.6
09/05/2024 18:00	17.5	0.6	2.2	12.0	2.6
09/05/2024 19:00	15.3	0.6	2.2	12.0	2.6
09/05/2024 20:00	17.5	0.6	2.2	12.0	2.6
09/05/2024 21:00	15.7	0.6	2.3	12.3	2.6
09/05/2024 22:00	18.3	0.3	2.3	12.5	2.8
09/05/2024 23:00	17.6	0.6	2.2	12.1	2.6
Average/Sum#:	367.4 #	17.6 #	49.8 #	272.6 #	59.0 #
Minimum:	13.3	0.3	1.7	9.2	2.0
Maximum:	18.3	1.3	2.3	12.6	2.8
%SI	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/06/2024 00:00	17.6	0.6	2.2	12.1	2.6
09/06/2024 01:00	17.3	0.6	2.1	11.9	2.6
09/06/2024 02:00	16.1	1.3	2.0	11.1	2.4
09/06/2024 03:00	17.5	1.0	2.2	12.0	2.6
09/06/2024 04:00	17.9	0.6	2.3	12.3	2.6
09/06/2024 05:00	18.3	0.6	2.3	12.5	2.8
09/06/2024 06:00	15.3	0.6	2.2	12.0	2.6
09/06/2024 07:00	17.2	0.6	2.1	11.8	2.6
09/06/2024 08:00	16.9	1.0	2.1	11.6	2.6
09/06/2024 09:00	16.0	1.3	2.0	11.0	2.4
09/06/2024 10:00	16.5	1.3	2.1	11.4	2.4
09/06/2024 11:00	17.1	0.9	2.1	11.8	2.6
09/06/2024 12:00	17.5	0.6	2.2	12.0	2.6
09/06/2024 13:00	17.4	0.6	2.1	12.0	2.6
09/06/2024 14:00	17.5	0.6	2.2	12.0	2.6
09/06/2024 15:00	17.5	0.6	2.2	12.0	2.6
09/06/2024 16:00	17.0	0.6	2.1	11.7	2.6
09/06/2024 17:00	17.3	0.6	2.1	11.9	2.6
09/06/2024 18:00	17.7	0.6	2.3	12.1	2.6
09/06/2024 19:00	17.7	0.6	2.3	12.2	2.6
09/06/2024 20:00	17.7	0.6	2.3	12.2	2.6
09/06/2024 21:00	17.9	0.6	2.3	12.3	2.7
09/06/2024 22:00	17.9	0.6	2.3	12.3	2.6
09/06/2024 23:00	18.3	0.3	2.3	12.6	2.8
Average/Sum#:	415.1 #	17.3 #	52.4 #	286.8 #	62.3 #
Minimum:	15.3	0.3	2.0	11.0	2.4
Maximum:	18.3	1.3	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/07/2024 00:00	18.3	0.3	2.3	12.6	2.8
09/07/2024 01:00	18.3	0.3	2.3	12.5	2.8
09/07/2024 02:00	17.6	0.6	2.2	12.1	2.6
09/07/2024 03:00	17.6	0.6	2.2	12.1	2.6
09/07/2024 04:00	15.6	0.6	2.3	12.2	2.6
09/07/2024 05:00	17.5	0.6	2.2	12.0	2.6
09/07/2024 06:00	16.8	1.3	2.1	11.6	2.6
09/07/2024 07:00	15.8	1.6	2.0	10.9	2.4
09/07/2024 08:00	15.8	1.6	2.0	10.9	2.4
09/07/2024 09:00	16.0	1.6	2.0	11.0	2.4
09/07/2024 10:00	16.8	1.0	2.1	11.6	2.6
09/07/2024 11:00	16.6	1.3	2.1	11.4	2.4
09/07/2024 12:00	17.4	0.6	2.2	12.0	2.6
09/07/2024 13:00	17.9	0.6	2.3	12.3	2.6
09/07/2024 14:00	18.0	0.6	2.3	12.3	2.7
09/07/2024 15:00	18.1	0.6	2.3	12.4	2.7
09/07/2024 16:00	15.1	0.6	2.1	11.9	2.6
09/07/2024 17:00	18.1	0.6	2.3	12.5	2.8
09/07/2024 18:00	16.0	0.3	2.3	12.5	2.8
09/07/2024 19:00	18.3	0.3	2.3	12.6	2.8
09/07/2024 20:00	18.3	0.3	2.3	12.6	2.8
09/07/2024 21:00	16.0	0.3	2.3	12.5	2.8
09/07/2024 22:00	17.6	0.6	2.2	12.1	2.6
09/07/2024 23:00	18.3	0.6	2.3	12.5	2.8
Average/Sum#:	411.8 #	17.4 #	53.0 #	289.1 #	63.4 #
Minimum:	15.1	0.3	2.0	10.9	2.4
Maximum:	18.3	1.6	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/08/2024 00:00	17.2	1.0	2.1	11.8	2.6
09/08/2024 01:00	16.0	1.3	2.0	11.0	2.4
09/08/2024 02:00	17.3	1.0	2.1	11.9	2.6
09/08/2024 03:00	17.5	0.6	2.2	12.0	2.6
09/08/2024 04:00	16.2	1.3	2.0	11.2	2.4
09/08/2024 05:00	13.8	0.6	1.7	9.5	2.0
09/08/2024 06:00	13.3	0.9	1.7	9.2	2.0
09/08/2024 07:00	13.2	0.6	1.7	9.0	2.0
09/08/2024 08:00	13.0	0.9	1.6	8.9	2.0
09/08/2024 09:00	12.4	0.9	1.6	8.5	1.8
09/08/2024 10:00	12.4	0.6	1.6	8.5	1.8
09/08/2024 11:00	12.4	0.6	1.6	8.6	1.8
09/08/2024 12:00	13.2	0.6	1.7	9.0	2.0
09/08/2024 13:00	13.4	0.6	1.7	9.2	2.0
09/08/2024 14:00	14.8	1.2	1.9	10.1	2.2
09/08/2024 15:00	17.8	0.6	2.3	12.3	2.6
09/08/2024 16:00	17.1	0.6	2.1	11.7	2.6
09/08/2024 17:00	17.9	0.6	2.3	12.3	2.6
09/08/2024 18:00	18.0	0.6	2.3	12.3	2.7
09/08/2024 19:00	18.3	0.3	2.3	12.5	2.8
09/08/2024 20:00	16.0	0.3	2.3	12.5	2.8
09/08/2024 21:00	18.1	0.3	2.3	12.5	2.8
09/08/2024 22:00	17.7	0.3	2.3	12.2	2.6
09/08/2024 23:00	17.6	0.6	2.2	12.1	2.6
Average/Sum#:	374.6 #	16.9 #	47.6 #	258.8 #	56.3 #
Minimum:	12.4	0.3	1.6	8.5	1.8
Maximum:	18.3	1.3	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/09/2024 00:00	17.6	0.6	2.2	12.1	2.6
09/09/2024 01:00	14.5	1.0	2.1	11.4	2.4
09/09/2024 02:00	17.4	0.7	2.2	12.0	2.6
09/09/2024 03:00	17.5	0.6	2.2	12.1	2.6
09/09/2024 04:00	17.6	0.6	2.2	12.1	2.6
09/09/2024 05:00	18.1	0.3	2.3	12.5	2.8
09/09/2024 06:00	16.7	1.3	2.1	11.5	2.6
09/09/2024 07:00	15.8	1.3	2.0	10.9	2.4
09/09/2024 08:00	15.9	1.3	2.0	10.9	2.4
09/09/2024 09:00	17.2	1.0	2.1	11.8	2.6
09/09/2024 10:00	17.1	0.6	2.1	11.7	2.6
09/09/2024 11:00	16.7	0.6	2.1	11.4	2.5
09/09/2024 12:00	16.7	0.6	2.1	11.4	2.5
09/09/2024 13:00	16.7	0.6	2.1	11.5	2.6
09/09/2024 14:00	16.2	0.9	2.0	11.2	2.4
09/09/2024 15:00	16.7	0.9	2.1	11.4	2.5
09/09/2024 16:00	17.5	0.6	2.2	12.0	2.6
09/09/2024 17:00	17.2	0.6	2.1	11.8	2.6
09/09/2024 18:00	17.5	0.3	2.2	12.0	2.6
09/09/2024 19:00	17.3	0.3	2.1	12.0	2.6
09/09/2024 20:00	16.9	0.6	2.1	11.6	2.6
09/09/2024 21:00	16.8	0.6	2.1	11.6	2.6
09/09/2024 22:00	15.9	1.3	2.0	10.9	2.4
09/09/2024 23:00	17.3	0.6	2.1	11.9	2.6
Average/Sum#:	404.8 #	17.8 #	50.8 #	279.7 #	61.3 #
Minimum:	14.5	0.3	2.0	10.9	2.4
Maximum:	18.1	1.3	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/10/2024 00:00	17.2	0.6	2.1	11.8	2.6
09/10/2024 01:00	16.2	1.0	2.0	11.2	2.4
09/10/2024 02:00	15.9	1.3	2.0	10.9	2.4
09/10/2024 03:00	16.2	1.6	2.0	11.1	2.4
09/10/2024 04:00	16.6	1.3	2.1	11.4	2.4
09/10/2024 05:00	15.4	1.0	2.2	12.1	2.6
09/10/2024 06:00	14.2	1.6	2.0	11.2	2.4
09/10/2024 07:00	12.4	0.9	1.6	8.6	1.8
09/10/2024 08:00	10.4	0.7	1.3	7.1	1.6
09/10/2024 09:00	10.4	0.5	1.3	7.1	1.6
09/10/2024 10:00	10.4	0.5	1.3	7.2	1.6
09/10/2024 11:00	10.4	0.5	1.3	7.1	1.6
09/10/2024 12:00	10.4	0.5	1.3	7.2	1.6
09/10/2024 13:00	11.1	0.5	1.4	7.7	1.6
09/10/2024 14:00	10.4	0.5	1.3	7.2	1.6
09/10/2024 15:00	10.6	0.5	1.3	7.3	1.6
09/10/2024 16:00	12.4	0.9	1.6	8.6	1.8
09/10/2024 17:00	15.8	1.8	2.0	10.9	2.4
09/10/2024 18:00	15.8	1.6	2.0	10.9	2.4
09/10/2024 19:00	15.7	1.6	2.0	10.8	2.4
09/10/2024 20:00	15.6	1.6	2.0	10.7	2.4
09/10/2024 21:00	15.6	1.6	2.0	10.7	2.4
09/10/2024 22:00	15.4	1.9	1.9	10.6	2.4
09/10/2024 23:00	6.2	13.6	0.2	0.9	0.2
Average/Sum#:	320.7 #	38.1 #	40.2 #	220.3 #	48.2 #
Minimum:	6.2	0.5	0.2	0.9	0.2
Maximum:	17.2	13.6	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/11/2024 00:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 01:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 20:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 21:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 22:00	0.0	0.0	0.0	0.0	0.0
09/11/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/12/2024 00:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 01:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/12/2024 17:00	49.1	48.4	0.1	0.6	0.1
09/12/2024 18:00	36.9	20.4	0.3	1.0	0.2
09/12/2024 19:00	49.1	50.8	0.6	2.1	0.5
09/12/2024 20:00	4.8	0.0	1.1	4.0	1.0
09/12/2024 21:00	6.6	0.0	1.2	4.1	1.0
09/12/2024 22:00	6.8	0.0	1.2	4.2	1.0
09/12/2024 23:00	6.9	0.0	1.2	4.3	1.0
Average/Sum#:	160.2 #	119.6 #	5.7 #	20.3 #	4.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.1	50.8	1.2	4.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/13/2024 00:00	6.9	0.0	1.2	4.3	1.0
09/13/2024 01:00	6.1	0.0	1.1	3.8	0.9
09/13/2024 02:00	6.1	0.0	1.1	3.8	0.9
09/13/2024 03:00	6.6	0.0	1.2	4.1	1.0
09/13/2024 04:00	6.9	0.0	1.2	4.3	1.0
09/13/2024 05:00	6.9	0.0	1.2	4.3	1.0
09/13/2024 06:00	6.4	0.0	1.1	4.0	1.0
09/13/2024 07:00	7.0	9.1	0.6	2.2	0.5
09/13/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/13/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/13/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/13/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/13/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/13/2024 13:00	24.0	10.3	0.1	0.4	0.1
09/13/2024 14:00	38.6	38.7	0.6	2.1	0.5
09/13/2024 15:00	6.7	0.0	1.2	4.2	1.0
09/13/2024 16:00	8.6	0.0	1.5	5.4	1.3
09/13/2024 17:00	8.7	0.0	1.5	5.4	1.3
09/13/2024 18:00	40.0	54.8	1.3	4.9	1.1
09/13/2024 19:00	79.7	48.5	1.4	6.5	1.4
09/13/2024 20:00	13.4	0.9	1.7	9.2	2.0
09/13/2024 21:00	13.6	0.9	1.7	9.3	2.0
09/13/2024 22:00	13.5	0.9	1.7	9.3	2.0
09/13/2024 23:00	13.6	0.9	1.7	9.3	2.0
Average/Sum#:	313.3 #	165.0 #	23.1 #	96.8 #	22.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	79.7	54.8	1.7	9.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/14/2024 00:00	13.6	0.9	1.7	9.3	2.0
09/14/2024 01:00	14.0	1.0	1.7	9.7	2.2
09/14/2024 02:00	15.8	25.1	1.3	7.3	1.6
09/14/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/14/2024 16:00	51.5	50.2	0.3	1.1	0.3
09/14/2024 17:00	26.6	102.3	0.5	1.8	0.4
09/14/2024 18:00	24.6	64.0	0.9	3.1	0.7
09/14/2024 19:00	6.3	0.0	1.1	4.0	0.9
09/14/2024 20:00	6.1	0.0	1.1	3.8	0.9
09/14/2024 21:00	6.2	0.0	1.1	3.8	0.9
09/14/2024 22:00	6.3	0.0	1.1	3.9	0.9
09/14/2024 23:00	6.8	0.0	1.2	4.3	1.0
Average/Sum#:	177.8 #	243.5 #	12.0 #	52.1 #	11.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.5	102.3	1.7	9.7	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/15/2024 00:00	6.8	0.0	1.2	4.2	1.0
09/15/2024 01:00	1.8	16.7	0.1	0.4	0.1
09/15/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/15/2024 17:00	42.0	49.3	0.1	0.6	0.1
09/15/2024 18:00	45.7	147.0	0.5	1.7	0.4
09/15/2024 19:00	44.6	133.9	0.8	2.8	0.7
09/15/2024 20:00	6.2	0.0	1.1	3.9	0.9
09/15/2024 21:00	5.8	0.0	1.0	3.6	0.9
09/15/2024 22:00	5.9	0.0	1.0	3.7	0.9
09/15/2024 23:00	6.1	0.0	1.1	3.8	0.9
Average/Sum#:	164.9 #	346.9 #	6.9 #	24.7 #	5.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	45.7	147.0	1.2	4.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/16/2024 00:00	6.6	0.0	1.2	4.1	1.0
09/16/2024 01:00	6.1	0.0	1.1	3.8	0.9
09/16/2024 02:00	5.9	0.0	1.0	3.7	0.9
09/16/2024 03:00	6.5	0.0	1.1	4.1	1.0
09/16/2024 04:00	6.9	0.0	1.2	4.3	1.0
09/16/2024 05:00	6.9	0.0	1.2	4.3	1.0
09/16/2024 06:00	6.7	0.0	1.2	4.2	1.0
09/16/2024 07:00	5.6	14.7	0.7	2.3	0.6
09/16/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 20:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 21:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 22:00	0.0	0.0	0.0	0.0	0.0
09/16/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	51.2 #	14.7 #	8.7 #	30.8 #	7.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	6.9	14.7	1.2	4.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/17/2024 00:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 01:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/17/2024 20:00	54.6	61.0	0.2	0.7	0.2
09/17/2024 21:00	17.9	28.6	0.3	1.0	0.2
09/17/2024 22:00	35.2	68.2	0.6	2.1	0.5
09/17/2024 23:00	6.6	0.0	1.2	4.2	1.0
Average/Sum#:	114.3 #	157.8 #	2.3 #	8.0 #	1.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.6	68.2	1.2	4.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/18/2024 00:00	6.3	0.0	1.1	3.9	0.9
09/18/2024 01:00	53.2	62.6	1.3	5.1	1.2
09/18/2024 02:00	50.3	52.1	1.4	6.4	1.4
09/18/2024 03:00	11.9	0.6	1.4	8.2	1.8
09/18/2024 04:00	13.6	0.6	1.7	9.3	2.0
09/18/2024 05:00	16.4	2.0	2.0	11.2	2.4
09/18/2024 06:00	16.7	1.0	2.1	11.4	2.5
09/18/2024 07:00	15.6	1.3	2.0	10.8	2.4
09/18/2024 08:00	15.4	1.3	1.9	10.6	2.4
09/18/2024 09:00	15.4	1.6	2.0	10.6	2.4
09/18/2024 10:00	15.4	1.6	2.0	10.6	2.4
09/18/2024 11:00	15.5	1.6	2.0	10.7	2.4
09/18/2024 12:00	15.5	1.3	2.0	10.7	2.4
09/18/2024 13:00	15.6	1.3	2.0	10.7	2.4
09/18/2024 14:00	15.6	1.3	2.0	10.8	2.4
09/18/2024 15:00	15.6	1.3	2.0	10.7	2.4
09/18/2024 16:00	16.6	0.9	2.1	11.4	2.4
09/18/2024 17:00	17.5	0.3	2.2	12.0	2.6
09/18/2024 18:00	16.9	0.6	2.1	11.6	2.6
09/18/2024 19:00	17.0	0.3	2.1	11.7	2.6
09/18/2024 20:00	16.9	0.6	2.1	11.6	2.6
09/18/2024 21:00	16.9	0.6	2.1	11.6	2.6
09/18/2024 22:00	16.9	0.6	2.1	11.6	2.6
09/18/2024 23:00	16.9	0.6	2.1	11.6	2.6
Average/Sum#:	443.6 #	136.0 #	45.8 #	244.8 #	54.4 #
Minimum:	6.3	0.0	1.1	3.9	0.9
Maximum:	53.2	62.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/19/2024 00:00	16.9	0.6	2.1	11.6	2.6
09/19/2024 01:00	16.9	0.6	2.1	11.6	2.6
09/19/2024 02:00	16.9	0.3	2.1	11.6	2.6
09/19/2024 03:00	17.0	0.6	2.1	11.6	2.6
09/19/2024 04:00	16.9	0.6	2.1	11.6	2.6
09/19/2024 05:00	14.8	0.6	2.1	11.6	2.6
09/19/2024 06:00	16.2	0.9	2.0	11.2	2.4
09/19/2024 07:00	4.0	13.1	0.2	0.9	0.2
09/19/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 20:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 21:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 22:00	0.0	0.0	0.0	0.0	0.0
09/19/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	119.6 #	17.3 #	14.8 #	81.7 #	18.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	17.0	13.1	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/20/2024 00:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 01:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 20:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 21:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 22:00	0.0	0.0	0.0	0.0	0.0
09/20/2024 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/21/2024 00:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 01:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 15:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 16:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 17:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 18:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 19:00	0.0	0.0	0.0	0.0	0.0
09/21/2024 20:00	36.9	47.1	0.1	0.6	0.1
09/21/2024 21:00	34.9	18.9	0.1	1.2	0.2
09/21/2024 22:00	40.8	37.1	0.3	2.8	0.6
09/21/2024 23:00	6.2	0.6	0.5	4.7	0.9
Average/Sum#:	118.8 #	103.7 #	1.0 #	9.3 #	1.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	40.8	47.1	0.5	4.7	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/22/2024 00:00	6.8	0.9	0.5	5.1	1.0
09/22/2024 01:00	6.8	0.9	0.5	5.1	1.0
09/22/2024 02:00	6.7	0.9	0.5	5.0	1.0
09/22/2024 03:00	6.7	0.9	0.5	5.0	1.0
09/22/2024 04:00	6.8	0.6	0.5	5.1	1.0
09/22/2024 05:00	6.8	0.6	0.5	5.1	1.0
09/22/2024 06:00	6.4	0.9	0.5	4.8	1.0
09/22/2024 07:00	2.1	5.5	0.0	0.4	0.1
09/22/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/22/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/22/2024 10:00	6.9	13.2	0.0	0.5	0.1
09/22/2024 11:00	45.4	47.3	0.3	3.2	0.6
09/22/2024 12:00	6.1	0.6	0.5	4.6	0.9
09/22/2024 13:00	6.0	0.6	0.5	4.5	0.9
09/22/2024 14:00	65.8	40.9	0.7	5.6	1.2
09/22/2024 15:00	53.2	45.6	1.1	6.8	1.5
09/22/2024 16:00	10.4	0.8	1.4	8.2	1.8
09/22/2024 17:00	12.9	0.9	1.6	8.8	2.0
09/22/2024 18:00	15.6	1.5	2.0	10.7	2.4
09/22/2024 19:00	15.7	1.2	2.0	10.8	2.4
09/22/2024 20:00	15.6	1.2	2.0	10.7	2.4
09/22/2024 21:00	15.5	1.2	2.0	10.7	2.4
09/22/2024 22:00	15.3	1.2	1.9	10.5	2.3
09/22/2024 23:00	15.3	1.6	1.9	10.5	2.3
Average/Sum#:	348.8 #	169.0 #	21.4 #	141.7 #	30.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	65.8	47.3	2.0	10.8	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/23/2024 00:00	15.3	1.3	1.9	10.5	2.3
09/23/2024 01:00	15.3	1.3	1.9	10.5	2.2
09/23/2024 02:00	15.3	1.6	1.9	10.5	2.3
09/23/2024 03:00	15.3	1.3	1.9	10.5	2.3
09/23/2024 04:00	15.3	1.2	1.9	10.5	2.3
09/23/2024 05:00	15.2	1.2	1.9	10.5	2.2
09/23/2024 06:00	11.4	0.6	1.6	9.0	2.0
09/23/2024 07:00	12.5	0.6	1.6	8.6	1.8
09/23/2024 08:00	13.1	0.6	1.7	9.0	2.0
09/23/2024 09:00	12.0	0.9	1.6	8.3	1.8
09/23/2024 10:00	12.1	0.9	1.6	8.3	1.8
09/23/2024 11:00	13.1	0.9	1.7	9.0	2.0
09/23/2024 12:00	13.5	0.9	1.7	9.2	2.0
09/23/2024 13:00	13.5	0.9	1.7	9.2	2.0
09/23/2024 14:00	16.9	0.9	2.1	11.6	2.6
09/23/2024 15:00	15.2	0.6	2.1	12.0	2.6
09/23/2024 16:00	17.5	0.3	2.2	12.0	2.6
09/23/2024 17:00	17.5	0.3	2.2	12.0	2.6
09/23/2024 18:00	17.6	0.3	2.2	12.1	2.6
09/23/2024 19:00	15.5	0.3	2.3	12.1	2.6
09/23/2024 20:00	17.7	0.3	2.3	12.2	2.6
09/23/2024 21:00	15.5	0.3	2.3	12.2	2.6
09/23/2024 22:00	17.6	0.3	2.2	12.1	2.6
09/23/2024 23:00	16.3	0.6	2.0	11.2	2.4
Average/Sum#:	360.2 #	18.4 #	46.5 #	253.1 #	54.8 #
Minimum:	11.4	0.3	1.6	8.3	1.8
Maximum:	17.7	1.6	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/24/2024 00:00	13.5	0.6	1.7	9.3	2.0
09/24/2024 01:00	13.4	0.6	1.7	9.2	2.0
09/24/2024 02:00	13.1	0.6	1.6	9.0	2.0
09/24/2024 03:00	13.4	0.9	1.7	9.2	2.0
09/24/2024 04:00	13.4	0.9	1.7	9.2	2.0
09/24/2024 05:00	13.4	0.6	1.7	9.2	2.0
09/24/2024 06:00	13.0	0.6	1.6	9.0	2.0
09/24/2024 07:00	12.6	0.6	1.6	8.7	1.9
09/24/2024 08:00	12.0	0.8	1.6	8.3	1.8
09/24/2024 09:00	12.2	0.8	1.6	8.4	1.8
09/24/2024 10:00	12.5	0.9	1.6	8.6	1.8
09/24/2024 11:00	13.2	0.9	1.7	9.0	2.0
09/24/2024 12:00	11.2	0.5	1.4	7.7	1.6
09/24/2024 13:00	14.7	1.2	1.8	10.1	2.2
09/24/2024 14:00	17.2	0.6	2.1	11.8	2.6
09/24/2024 15:00	17.0	0.3	2.1	11.6	2.6
09/24/2024 16:00	17.3	0.3	2.1	11.8	2.6
09/24/2024 17:00	17.5	0.3	2.2	12.0	2.6
09/24/2024 18:00	17.3	0.3	2.1	11.9	2.6
09/24/2024 19:00	16.7	0.6	2.1	11.4	2.5
09/24/2024 20:00	17.1	0.3	2.1	11.8	2.6
09/24/2024 21:00	16.5	0.6	2.0	11.4	2.4
09/24/2024 22:00	16.2	0.9	2.0	11.0	2.4
09/24/2024 23:00	17.1	0.6	2.1	11.8	2.6
Average/Sum#:	351.5 #	15.3 #	43.9 #	241.4 #	52.6 #
Minimum:	11.2	0.3	1.4	7.7	1.6
Maximum:	17.5	1.2	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/25/2024 00:00	17.0	0.6	2.1	11.7	2.6
09/25/2024 01:00	16.8	0.6	2.1	11.6	2.6
09/25/2024 02:00	16.4	0.9	2.0	11.2	2.4
09/25/2024 03:00	16.8	0.9	2.1	11.5	2.6
09/25/2024 04:00	16.8	0.6	2.1	11.6	2.6
09/25/2024 05:00	16.8	0.6	2.1	11.6	2.6
09/25/2024 06:00	16.2	0.9	2.0	11.2	2.4
09/25/2024 07:00	4.2	13.7	0.2	1.1	0.2
09/25/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/25/2024 14:00	4.0	5.4	0.1	0.2	0.0
09/25/2024 15:00	30.0	44.6	0.6	2.0	0.5
09/25/2024 16:00	4.3	0.0	1.0	3.6	0.9
09/25/2024 17:00	6.5	0.0	1.1	4.1	1.0
09/25/2024 18:00	6.6	0.0	1.2	4.1	1.0
09/25/2024 19:00	71.2	61.8	1.3	6.1	1.3
09/25/2024 20:00	12.0	0.6	1.4	8.2	1.8
09/25/2024 21:00	13.0	0.6	1.6	8.8	2.0
09/25/2024 22:00	11.2	0.5	1.4	7.7	1.6
09/25/2024 23:00	13.4	0.6	1.7	9.2	2.0
Average/Sum#:	293.2 #	132.9 #	26.1 #	135.5 #	30.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.2	61.8	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/26/2024 00:00	13.5	0.6	1.7	9.3	2.0
09/26/2024 01:00	13.2	0.6	1.7	9.1	2.0
09/26/2024 02:00	13.0	0.6	1.6	9.0	2.0
09/26/2024 03:00	13.3	0.6	1.7	9.2	2.0
09/26/2024 04:00	13.5	0.6	1.7	9.2	2.0
09/26/2024 05:00	13.4	0.6	1.7	9.2	2.0
09/26/2024 06:00	13.0	0.6	1.6	9.0	2.0
09/26/2024 07:00	11.0	0.5	1.4	7.6	1.6
09/26/2024 08:00	5.2	13.5	0.1	0.7	0.2
09/26/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/26/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/26/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/26/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/26/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/26/2024 14:00	7.3	9.5	0.1	0.4	0.1
09/26/2024 15:00	39.0	40.0	0.6	2.3	0.5
09/26/2024 16:00	6.8	0.0	1.2	4.2	1.0
09/26/2024 17:00	7.0	0.0	1.2	4.4	1.1
09/26/2024 18:00	8.4	0.0	1.5	5.2	1.3
09/26/2024 19:00	8.3	0.0	1.5	5.2	1.2
09/26/2024 20:00	8.1	0.0	1.4	5.0	1.2
09/26/2024 21:00	8.9	0.0	1.6	5.6	1.3
09/26/2024 22:00	8.6	0.0	1.5	5.4	1.3
09/26/2024 23:00	8.0	0.0	1.4	5.0	1.2
Average/Sum#:	219.5 #	67.7 #	25.2 #	115.0 #	26.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	39.0	40.0	1.7	9.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/27/2024 00:00	7.6	0.0	1.3	4.8	1.1
09/27/2024 01:00	1.7	9.1	0.1	0.5	0.1
09/27/2024 02:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/27/2024 09:00	32.7	22.2	0.1	0.5	0.1
09/27/2024 10:00	47.5	39.3	0.6	2.1	0.5
09/27/2024 11:00	4.1	0.0	0.9	3.4	0.8
09/27/2024 12:00	5.4	0.0	0.9	3.3	0.8
09/27/2024 13:00	33.9	27.4	1.1	4.4	1.1
09/27/2024 14:00	73.3	31.4	1.3	6.7	1.5
09/27/2024 15:00	10.0	0.8	1.4	7.9	1.8
09/27/2024 16:00	12.2	0.8	1.6	8.4	1.8
09/27/2024 17:00	16.9	0.9	2.1	11.6	2.6
09/27/2024 18:00	17.7	0.3	2.3	12.1	2.6
09/27/2024 19:00	17.7	0.3	2.3	12.1	2.6
09/27/2024 20:00	15.5	0.3	2.3	12.2	2.6
09/27/2024 21:00	17.7	0.3	2.2	12.1	2.6
09/27/2024 22:00	17.0	0.6	2.1	11.7	2.6
09/27/2024 23:00	17.0	0.6	2.1	11.7	2.6
Average/Sum#:	347.9 #	134.3 #	24.7 #	125.5 #	27.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	73.3	39.3	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/28/2024 00:00	17.0	0.6	2.1	11.7	2.6
09/28/2024 01:00	17.0	0.6	2.1	11.7	2.6
09/28/2024 02:00	17.0	0.6	2.1	11.6	2.6
09/28/2024 03:00	17.0	0.6	2.1	11.6	2.6
09/28/2024 04:00	16.9	0.6	2.1	11.6	2.6
09/28/2024 05:00	17.0	0.6	2.1	11.6	2.6
09/28/2024 06:00	16.0	0.9	2.0	11.0	2.4
09/28/2024 07:00	6.3	13.6	0.2	1.0	0.2
09/28/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 10:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 11:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 12:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 13:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 14:00	0.0	0.0	0.0	0.0	0.0
09/28/2024 15:00	47.7	31.6	0.5	1.6	0.4
09/28/2024 16:00	4.4	0.0	1.0	3.7	0.9
09/28/2024 17:00	6.0	0.0	1.0	3.7	0.9
09/28/2024 18:00	6.6	0.0	1.2	4.1	1.0
09/28/2024 19:00	6.8	0.0	1.2	4.2	1.0
09/28/2024 20:00	6.8	0.0	1.2	4.2	1.0
09/28/2024 21:00	6.8	0.0	1.2	4.2	1.0
09/28/2024 22:00	6.2	0.0	1.1	3.9	0.9
09/28/2024 23:00	6.8	0.0	1.2	4.2	1.0
Average/Sum#:	222.3 #	49.7 #	24.4 #	115.6 #	26.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	47.7	31.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/29/2024 00:00	6.0	0.0	1.0	3.7	0.9
09/29/2024 01:00	6.0	0.0	1.0	3.7	0.9
09/29/2024 02:00	2.4	8.0	0.1	0.4	0.1
09/29/2024 03:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 04:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 05:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 06:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 07:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 08:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 09:00	0.0	0.0	0.0	0.0	0.0
09/29/2024 10:00	25.0	24.3	0.1	0.4	0.1
09/29/2024 11:00	55.8	53.7	0.6	2.1	0.5
09/29/2024 12:00	4.2	0.0	1.0	3.5	0.8
09/29/2024 13:00	5.4	0.0	0.9	3.4	0.8
09/29/2024 14:00	34.3	35.0	1.1	4.5	1.1
09/29/2024 15:00	60.2	20.5	1.3	6.6	1.4
09/29/2024 16:00	12.6	0.6	1.6	8.6	1.8
09/29/2024 17:00	13.7	0.9	1.7	9.4	2.0
09/29/2024 18:00	15.8	1.5	2.0	10.9	2.4
09/29/2024 19:00	17.3	0.6	2.1	11.9	2.6
09/29/2024 20:00	17.3	0.6	2.1	11.9	2.6
09/29/2024 21:00	16.7	0.6	2.1	11.4	2.5
09/29/2024 22:00	15.6	1.3	2.0	10.7	2.4
09/29/2024 23:00	17.1	0.6	2.1	11.8	2.6
Average/Sum#:	325.4 #	148.2 #	22.8 #	114.9 #	25.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	60.2	53.7	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 10:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/30/2024 00:00	16.4	0.9	2.0	11.4	2.4
09/30/2024 01:00	15.5	1.3	2.0	10.7	2.4
09/30/2024 02:00	15.6	1.3	2.0	10.7	2.4
09/30/2024 03:00	15.9	1.3	2.0	10.9	2.4
09/30/2024 04:00	16.5	0.9	2.1	11.4	2.4
09/30/2024 05:00	14.9	1.0	2.1	11.8	2.6
09/30/2024 06:00	15.2	0.7	2.1	12.0	2.6
09/30/2024 07:00	15.0	0.9	1.9	10.3	2.2
09/30/2024 08:00	10.6	0.3	1.3	7.3	1.6
09/30/2024 09:00	10.6	0.3	1.3	7.2	1.6
09/30/2024 10:00	10.6	0.3	1.3	7.2	1.6
09/30/2024 11:00	11.4	0.3	1.4	7.9	1.8
09/30/2024 12:00	12.6	0.3	1.6	8.6	1.8
09/30/2024 13:00	13.4	0.6	1.7	9.2	2.0
09/30/2024 14:00	17.1	0.9	2.1	11.8	2.6
09/30/2024 15:00	17.1	0.6	2.1	11.8	2.6
09/30/2024 16:00	18.1	0.3	2.3	12.5	2.8
09/30/2024 17:00	18.3	0.3	2.3	12.5	2.8
09/30/2024 18:00	18.3	0.3	2.3	12.6	2.8
09/30/2024 19:00	18.3	0.3	2.3	12.6	2.8
09/30/2024 20:00	17.9	0.3	2.3	12.3	2.6
09/30/2024 21:00	18.3	0.3	2.3	12.6	2.8
09/30/2024 22:00	17.7	0.3	2.2	12.2	2.6
09/30/2024 23:00	17.0	0.6	2.1	11.7	2.6
Average/Sum#:	372.3 #	14.6 #	47.1 #	259.2 #	56.8 #
Minimum:	10.6	0.3	1.3	7.2	1.6
Maximum:	18.3	1.3	2.3	12.6	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:58 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:58 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,753.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 455.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,753.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:58 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:59 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,753.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 455.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,753.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:59 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 10:59 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,753.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 455.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,753.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:00 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:00 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,753.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 455.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,753.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:00 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,753.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 455.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,753.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Airgas
an Air Liquide company

Unit 1 CV1

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

6/20/24 In Service RB

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A42D0	Reference Number:	153-402960018-1
Cylinder Number:	CC202267	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72024	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 12, 2024

Expiration Date: Feb 12, 2032

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	182.2 PPM	G1	+/- 0.9% NIST Traceable	02/05/2024, 02/12/2024
NITRIC OXIDE	180.0 PPM	182.1 PPM	G1	+/- 0.9% NIST Traceable	02/05/2024, 02/12/2024
CARBON MONOXIDE	1150 PPM	1149 PPM	G1	+/- 0.4% NIST Traceable	02/05/2024
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	200603-08	EB0112894	250.3 PPM NITRIC OXIDE/NITROGEN	0.8%	Oct 19, 2026
PRM	12409	D913660	15.01 PPM NITROGEN DIOXIDE/AIR	1.5%	Feb 17, 2023
GMIS	1534012021103	ND73012	4.956 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	Jun 15, 2025
NTRM	21060102	CC733026	977.3 PPM CARBON MONOXIDE/NITROGEN	0.2%	Aug 31, 2027

The SRM, NTRM, PRM, or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2110269 CO HCO	FTIR	Jan 11, 2024
Nicolet iS50 AUP2110269 NO MNO	FTIR	Jan 24, 2024
Nicolet iS50 AUP2110269 NO2 impurity	FTIR NO2 impurity	Jan 26, 2024

Triad Data Available Upon Request

Approved for Release

6/20/24 In Service

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

Unit 1 CV2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI79E15AC046	Reference Number:	153-402938795-1
Cylinder Number:	EB0156978	Cylinder Volume:	146.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72024	Valve Outlet:	590
		Certification Date:	Jan 15, 2024

Expiration Date: Jan 15, 2032

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.11 %	G1	+/- 0.5% NIST Traceable	01/15/2024
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09061434	CC282492	22.53 % OXYGEN/NITROGEN	0.4%	May 13, 2025

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (DIXON)	Jan 10, 2024

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES: Nitric Oxide: <0.01PPM
Carbon Monoxide: <0.01PPM
Carbon Dioxide: <0.01PPM

Approved for Release

Airgas
an Air Liquide company

Unit 1 CV3
IS 06/07/2024 TB

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A7635	Reference Number:	153-402780637-1
Cylinder Number:	CC255469	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72023	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 05, 2023

Expiration Date: Jul 05, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.952 PPM	G1	+/- 1.1% NIST Traceable	06/26/2023, 07/05/2023
NITRIC OXIDE	9.000 PPM	8.936 PPM	G1	+/- 1.3% NIST Traceable	06/26/2023, 07/05/2023
CARBON MONOXIDE	11.00 PPM	11.08 PPM	G1	+/- 1.1% NIST Traceable	06/26/2023
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16010122	ND48023	9.95 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 07, 2026
NTRM	16010122	ND48023-NOX	9.95 PPM NOx/NITROGEN	1.0%	Jun 07, 2026
NTRM	12062802	CC365313	9.82 PPM CARBON MONOXIDE/NITROGEN	1.0%	Feb 12, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jun 26, 2023
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jun 05, 2023
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jun 05, 2023

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 03/01/22 & EOS 10/31/23 from Unit 2
I/S 10/31/23 Unit 1

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-401707159-1
Cylinder Number:	CC323032	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	111.2 PPM	G1	+/- 1.1% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	110.0 PPM	110.9 PPM	G1	+/- 1.2% NIST Traceable	01/21/2020, 01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	17060213	CC481953	100.3 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 23, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 NO LNO	FTIR	Jan 22, 2020
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jan 22, 2020

Triad Data Available Upon Request

mcl

Approved for Release

UNIT #1 CV5

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI99E15A0147	Reference Number:	153-402483623-1
Cylinder Number:	CC303316	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jul 18, 2022

Expiration Date: Jul 18, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.44 PPM	G1	+/- 1.4% NIST Traceable	07/11/2022, 07/18/2022
NITRIC OXIDE	50.00 PPM	51.22 PPM	G1	+/- 1.4% NIST Traceable	07/11/2022, 07/18/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	210607-09	CC708032	48.41 PPM NITRIC OXIDE/NITROGEN	1.2%	Sep 21, 2025
PRM	12395	D887660	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 02, 2022
GMIS	1534002020104	EB0130055	4.81 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Apr 30, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2010228 NO LNO	FTIR	Jun 29, 2022
Nicolet iS50 AUP2010228 NO2 impurity	FTIR NO2 impurity	Jun 29, 2022

Triad Data Available Upon Request

I/S: 1/25/24
RB

Approved for Release

UNIT #1 CV6

I/S: 1/25/2024
RB

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A42C9	Reference Number:	48-402476502-1
Cylinder Number:	CC281974	Cylinder Volume:	144.0 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32022	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 08, 2022

Expiration Date: Jul 08, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.883 PPM	G1	+/- 1.0% NIST Traceable	06/27/2022, 07/08/2022
NITRIC OXIDE	5.500 PPM	5.854 PPM	G1	+/- 1.0% NIST Traceable	06/27/2022, 07/08/2022
CARBON MONOXIDE	500.0 PPM	502.2 PPM	G1	+/- 0.6% NIST Traceable	06/28/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	08012119A	KAL004274	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 0.9%	Apr 27, 2024
PRM	12401	APEX1324267	5.00 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 23, 2022
GMIS	08012119A	KAL004274-NOX	5.08 PPM NOx/NITROGEN	+/- 0.9%	Apr 27, 2024
PRM	12401	APEX1324267-NOx	5.00 PPM NOx/NITROGEN	+/- 0.8%	Dec 23, 2022
NTRM	13010114	ND47902	495.4 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jul 03, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO LOW	NDIR	Jun 22, 2022
nCLD 844 S 844N0213 NO	Chemiluminescence	Jun 16, 2022
nCLD 844 S 844N0213 NOx	Chemiluminescence	Jun 16, 2022

Triad Data Available Upon Request

Approved for Release

Unit 1 CV-7 RB
IS 5/3/24

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A73F4	Reference Number:	153-402477857-1
Cylinder Number:	EB0116882	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 12, 2022

Expiration Date: Jul 12, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.532 PPM	G1	+/- 1.4% NIST Traceable	07/05/2022, 07/12/2022
NITRIC OXIDE	2.500 PPM	2.532 PPM	G1	+/- 1.2% NIST Traceable	07/05/2022, 07/12/2022
CARBON MONOXIDE	4.750 PPM	4.764 PPM	G1	+/- 1.1% NIST Traceable	07/07/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	08012126A	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	0.9%	Apr 27, 2024
PRM	12401	APEX1324267	5.00 PPM NITRIC OXIDE/NITROGEN	0.8%	Dec 23, 2022
GMIS	08012126A	KAL004291-NOX	5.08 PPM NOx/NITROGEN	0.9%	Apr 27, 2024
PRM	12401	APEX1324267-NOX	5.00 PPM NOx/NITROGEN	0.8%	Dec 23, 2022
NTRM	12062857	CC401933	9.82 PPM CARBON MONOXIDE/NITROGEN	1.0%	Feb 12, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jul 06, 2022
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jul 11, 2022
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jul 11, 2022

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

CT 1 CV8
IS 7/9/24 RB

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-401707984-1
Cylinder Number:	CC193683	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 20, 2020

Expiration Date: Jan 20, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.01 %	G1	+/- 0.5% NIST Traceable	01/20/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09060214	CC262390	9.961 % OXYGEN/NITROGEN	0.3%	Nov 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

Approved for Release

CV-9

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI94E15AC040	Reference Number:	153-402897212-1
Cylinder Number:	EB0162270	Cylinder Volume:	145.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72023	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Nov 20, 2023

Expiration Date: Nov 20, 2031

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.534 %	G1	+/- 0.8% NIST Traceable	11/20/2023
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	14060629	CC436987	4.794 % OXYGEN/NITROGEN	0.4%	Oct 29, 2025

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (DIXON)	Nov 15, 2023

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES: Nitric Oxide: <0.01PPM
Carbon Monoxide: <0.01PPM
Carbon Dioxide: <0.01PPM

1/25/24 RB
I/S

Approved for Release

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	07/09/2024	Scale:	High
Performance Spec:	5 %	Test No.:	132	Highest Error:	2.2
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2024	1145	L	200.0	51.4	50.9		25.7 %
07/09/2024	1151	M	200.0	111.2	111.1		55.6 %
07/09/2024	1157	H	200.0	184.9	181.3		92.5 %
07/09/2024	1206	L	200.0	51.4	50.9		25.7 %
07/09/2024	1212	M	200.0	111.2	110.4		55.6 %
07/09/2024	1218	H	200.0	184.9	180.4		92.5 %
07/09/2024	1226	L	200.0	51.4	51.1		25.7 %
07/09/2024	1232	M	200.0	111.2	110.6		55.6 %
07/09/2024	1238	H	200.0	184.9	181.0		92.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.400	50.967	No	**0.8**
M	111.200	110.700	No	**0.4**
H	184.900	180.900	No	**2.2**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT1
Component ID: A12
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument
Test End Date/Time: 07/09/2024
Scale: High
Performance Spec: 5 %
Test No.: 133
Highest Error: 3.6
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2024	1001	L	25.0	5.5	5.3		22.0 %
07/09/2024	1007	M	25.0	13.0	12.8		52.0 %
07/09/2024	1013	H	25.0	21.0	20.7		84.0 %
07/09/2024	1022	L	25.0	5.5	5.3		22.0 %
07/09/2024	1028	M	25.0	13.0	12.8		52.0 %
07/09/2024	1034	H	25.0	21.0	20.7		84.0 %
07/09/2024	1042	L	25.0	5.5	5.3		22.0 %
07/09/2024	1048	M	25.0	13.0	12.8		52.0 %
07/09/2024	1054	H	25.0	21.0	20.7		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	**3.6**
M	13.000	12.800	No	**1.5**
H	21.000	20.700	No	**1.4**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / Low
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT1_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	11:00	L	10	2.500	3.600	25.0 %
07/09/2024	11:06	M	10	5.900	8.800	59.0 %
07/09/2024	11:15	L	10	2.500	3.700	25.0 %
07/09/2024	11:21	M	10	5.900	8.800	59.0 %
07/09/2024	11:29	L	10	2.500	3.700	25.0 %
07/09/2024	11:35	M	10	5.900	8.800	59.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.500		3.667	Alt	**1.2**
M	5.900		8.800	Alt	**2.9**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	09:19	L	2000	502.200	481.400	25.1 %
07/09/2024	09:25	M	2000	1164.000	1148.900	58.2 %
07/09/2024	09:34	L	2000	502.200	481.900	25.1 %
07/09/2024	09:40	M	2000	1164.000	1148.100	58.2 %
07/09/2024	09:48	L	2000	502.200	481.100	25.1 %
07/09/2024	09:54	M	2000	1164.000	1148.900	58.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	502.200	481.467	Std	**4.1**
M	1164.000	1148.633	Std	**1.3**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / Low
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	08:37	L	20	4.800	3.200	24.0 %
07/09/2024	08:43	M	20	11.000	10.700	55.0 %
07/09/2024	08:52	L	20	4.800	3.100	24.0 %
07/09/2024	08:58	M	20	11.000	10.700	55.0 %
07/09/2024	09:06	L	20	4.800	3.100	24.0 %
07/09/2024	09:12	M	20	11.000	10.700	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.800	3.133	Alt	**1.7**
M	11.000	10.700	Std	**2.7**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	07:54	L	25	5.500	5.600	22.0 %
07/09/2024	08:00	M	25	13.000	13.100	52.0 %
07/09/2024	08:09	L	25	5.500	5.600	22.0 %
07/09/2024	08:15	M	25	13.000	13.100	52.0 %
07/09/2024	08:23	L	25	5.500	5.600	22.0 %
07/09/2024	08:29	M	25	13.000	13.100	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.600	Std	**1.8**
M	13.000	13.100	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT1_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	07:12	L	200	51.400	49.800	25.7 %
07/09/2024	07:18	M	200	111.200	109.800	55.6 %
07/09/2024	07:27	L	200	51.400	50.400	25.7 %
07/09/2024	07:33	M	200	111.200	111.300	55.6 %
07/09/2024	07:41	L	200	51.400	50.300	25.7 %
07/09/2024	07:47	M	200	111.200	111.200	55.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.400	50.167	Std	**2.4**
M	111.200	110.767	Std	**0.4**

6/20/2024 RB
IS

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

Unit 2 CV1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A42D0	Reference Number:	153-402960018-1
Cylinder Number:	CC315777	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72024	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 12, 2024

Expiration Date: Feb 12, 2032

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	181.1 PPM	G1	+/- 0.9% NIST Traceable	02/05/2024, 02/12/2024
NITRIC OXIDE	180.0 PPM	181.1 PPM	G1	+/- 0.9% NIST Traceable	02/05/2024, 02/12/2024
CARBON MONOXIDE	1150 PPM	1147 PPM	G1	+/- 0.4% NIST Traceable	02/05/2024
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	200603-08	EB0112894	250.3 PPM NITRIC OXIDE/NITROGEN	0.8%	Oct 19, 2026
PRM	12409	D913660	15.01 PPM NITROGEN DIOXIDE/AIR	1.5%	Feb 17, 2023
GMIS	1534012021103	ND73012	4.956 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	Jun 15, 2025
NTRM	21060102	CC733026	977.3 PPM CARBON MONOXIDE/NITROGEN	0.2%	Aug 31, 2027

The SRM, NTRM, PRM, or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2110269 CO HCO	FTIR	Jan 11, 2024
Nicolet iS50 AUP2110269 NO MNO	FTIR	Jan 24, 2024
Nicolet iS50 AUP2110269 NO2 impurity	FTIR NO2 impurity	Jan 26, 2024

Triad Data Available Upon Request

Approved for Release

Unit 2 CV2 RJS
IS 6/26/2024

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI79E15AC046	Reference Number:	153-402893116-1
Cylinder Number:	CC141241	Cylinder Volume:	146.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72023	Valve Outlet:	590
		Certification Date:	Nov 14, 2023

Expiration Date: Nov 14, 2031

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	20.98 %	G1	+/- 0.6% NIST Traceable	11/14/2023
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09061434	CC282492	22.53 % OXYGEN/NITROGEN	0.4%	May 13, 2025

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (DIXON)	Oct 17, 2023

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES: Nitric Oxide: <0.01 PPM
Carbon Monoxide: <0.01 PPM
Carbon Dioxide: <0.01 PPM

Approved for Release

07/3/2024 RB Unit 2 CV3
In Service

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A7635	Reference Number:	153-402826281-1
Cylinder Number:	EB0097319	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72023	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Aug 29, 2023

Expiration Date: Aug 29, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.964 PPM	G1	+/- 1.3% NIST Traceable	08/22/2023, 08/29/2023
NITRIC OXIDE	9.000 PPM	8.856 PPM	G1	+/- 1.4% NIST Traceable	08/22/2023, 08/29/2023
CARBON MONOXIDE	11.00 PPM	11.07 PPM	G1	+/- 1.1% NIST Traceable	08/22/2023
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16010122	ND48023	9.95 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 07, 2026
NTRM	16010122	ND48023-NOX	9.95 PPM NOx/NITROGEN	1.0%	Jun 07, 2026
NTRM	12062802	CC365313	9.82 PPM CARBON MONOXIDE/NITROGEN	1.0%	Feb 12, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jul 27, 2023
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Aug 03, 2023
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Aug 03, 2023

Triad Data Available Upon Request

Approved for Release

CV-4

Unit 2

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI99E15A0093	Reference Number:	153-402483554-1
Cylinder Number:	ALM066639	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jul 18, 2022

Expiration Date: Jul 18, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.7 PPM	G1	+/- 1.4% NIST Traceable	07/11/2022, 07/18/2022
NITRIC OXIDE	110.0 PPM	110.3 PPM	G1	+/- 1.3% NIST Traceable	07/11/2022, 07/18/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	20061036	CC733344	98.61 PPM NITRIC OXIDE/NITROGEN	0.9%	Oct 06, 2026
PRM	12395	D887660	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 02, 2022
NTRM	200610-52	CC733451	98.61 PPM NITRIC OXIDE/NITROGEN	0.9%	Oct 06, 2026
GMIS	1534002020104	EB0130055	4.81 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Apr 30, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2110269 NO LNO	FTIR	Jun 22, 2022
Nicolet iS50 AUP2110269 NO2 impurity	FTIR NO2 impurity	Jun 22, 2022

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI99E15A0147	Reference Number:	153-402483623-1
Cylinder Number:	CC436792	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jul 18, 2022

Expiration Date: Jul 18, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.83 PPM	G1	+/- 1.4% NIST Traceable	07/11/2022, 07/18/2022
NITRIC OXIDE	50.00 PPM	51.44 PPM	G1	+/- 1.4% NIST Traceable	07/11/2022, 07/18/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	210607-09	CC708032	48.41 PPM NITRIC OXIDE/NITROGEN	1.2%	Sep 21, 2025
PRM	12395	D887660	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 02, 2022
GMIS	1534002020104	EB0130055	4.81 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Apr 30, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2010228 NO LNO	FTIR	Jun 29, 2022
Nicolet iS50 AUP2010228 NO2 impurity	FTIR NO2 impurity	Jun 29, 2022

Triad Data Available Upon Request

CV-5

I/S 1/25/2024

RSLV

Approved for Release

Airgas
an Air Liquide company

Unit 2 CV-6
IS 05/03/2024

Airgas Specialty Gases
Airgas USA LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

RB

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A42C9	Reference Number:	48-402890539-1
Cylinder Number:	EB0071358	Cylinder Volume:	144.0 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32023	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Nov 21, 2023

Expiration Date: Nov 21, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.574 PPM	G1	+/- 1.0% NIST Traceable	11/14/2023, 11/21/2023
NITRIC OXIDE	5.500 PPM	5.542 PPM	G1	+/- 1.0% NIST Traceable	11/14/2023, 11/21/2023
CARBON MONOXIDE	500.0 PPM	499.6 PPM	G1	+/- 0.6% NIST Traceable	11/20/2023
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012131A	KAL004303	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Apr 27, 2024
PRM	12401	APEX1324267	5.00 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 23, 2022
GMIS	08012131A	KAL004303-NOX	5.08 PPM NOx/NITROGEN	+/- 0.9%	Apr 27, 2024
NTRM	15060510	CC449846	491.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Mar 05, 2027

The SRM, NTRM, PRM, or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO LOW	NDIR	Oct 24, 2023
nCLD 844 S 844N0213 NO	Chemiluminescence	Nov 09, 2023
nCLD 844 S 844N0213 NOx	Chemiluminescence	Nov 09, 2023

Triad Data Available Upon Request

Approved for Release

Unit 2 CV-7
IS 5/3/2024

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E03NI99E15A73F4	Reference Number:	153-402477857-1
Cylinder Number:	EB0078321	Cylinder Volume:	144.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 12, 2022

Expiration Date: Jul 12, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.563 PPM	G1	+/- 1.4% NIST Traceable	07/05/2022, 07/12/2022
NITRIC OXIDE	2.500 PPM	2.563 PPM	G1	+/- 1.1% NIST Traceable	07/05/2022, 07/12/2022
CARBON MONOXIDE	4.750 PPM	4.769 PPM	G1	+/- 1.1% NIST Traceable	07/07/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	08012126A	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	0.9%	Apr 27, 2024
PRM	12401	APEX1324267	5.00 PPM NITRIC OXIDE/NITROGEN	0.8%	Dec 23, 2022
GMIS	08012126A	KAL004291-NOX	5.08 PPM NOx/NITROGEN	0.9%	Apr 27, 2024
PRM	12401	APEX1324267-NOX	5.00 PPM NOx/NITROGEN	0.8%	Dec 23, 2022
NTRM	12062857	CC401933	9.82 PPM CARBON MONOXIDE/NITROGEN	1.0%	Feb 12, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jul 06, 2022
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jul 11, 2022
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jul 11, 2022

Triad Data Available Upon Request

Approved for Release

I/S 10/31/23

Unit 2

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CV-8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI87E15A0080	Reference Number:	153-402471595-1
Cylinder Number:	CC701616	Cylinder Volume:	146.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jun 24, 2022

Expiration Date: Jun 24, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.04 %	G1	+/- 0.8% NIST Traceable	06/24/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jun 23, 2022

Triad Data Available Upon Request

Approved for Release

CV9

Unit 2

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA PROTOCOL STANDARD

Part Number:	E02NI94E15AC040	Reference Number:	153-402477846-1
Cylinder Number:	CC701750	Cylinder Volume:	145.0 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72022	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jul 07, 2022

Expiration Date: Jul 07, 2030

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.516 %	G1	+/- 0.6% NIST Traceable	07/07/2022
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jun 23, 2022

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES: Carbon Monoxide: <0.01PPM
Carbon Dioxide: <0.01PPM
Nitric Oxide: <0.01PPM

Approved for Release

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	07/09/2024	Scale:	High
Performance Spec:	5 %	Test No.:	134	Highest Error:	3.5
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2024	1022	L	200.0	51.8	49.7		25.9 %
07/09/2024	1028	M	200.0	111.2	107.8		55.6 %
07/09/2024	1034	H	200.0	182.4	177.0		91.2 %
07/09/2024	1043	L	200.0	51.8	50.1		25.9 %
07/09/2024	1049	M	200.0	111.2	108.2		55.6 %
07/09/2024	1055	H	200.0	182.4	177.1		91.2 %
07/09/2024	1103	L	200.0	51.8	50.1		25.9 %
07/09/2024	1109	M	200.0	111.2	107.9		55.6 %
07/09/2024	1115	H	200.0	182.4	176.9		91.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.800	49.967	No	**3.5**
M	111.200	107.967	No	**2.9**
H	182.400	177.000	No	**3.0**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Instrument Name: CT2_O2D_P_Instrument
Performance Spec: 5 %

Facility Name: COLUSA GENERATION
Component ID: A22
Component Type: O2D
Test End Date/Time: 07/09/2024
Test No.: 135
Status (Pass/Fail): **Passed**

ReasonForTest: QA
Grace Period: 0
Scale: High
Highest Error: 0.0

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2024	1125	L	25.0	5.5	5.5		22.0 %
07/09/2024	1131	M	25.0	13.0	13.0		52.0 %
07/09/2024	1137	H	25.0	21.0	21.0		84.0 %
07/09/2024	1146	L	25.0	5.5	5.5		22.0 %
07/09/2024	1152	M	25.0	13.0	13.0		52.0 %
07/09/2024	1158	H	25.0	21.0	21.0		84.0 %
07/09/2024	1206	L	25.0	5.5	5.5		22.0 %
07/09/2024	1212	M	25.0	13.0	13.0		52.0 %
07/09/2024	1218	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.000	13.000	No	**0.0**
H	21.000	21.000	No	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	06:52	L	200	51.800	48.800	25.9 %
07/09/2024	06:58	M	200	111.200	107.100	55.6 %
07/09/2024	07:07	L	200	51.800	49.400	25.9 %
07/09/2024	07:13	M	200	111.200	107.800	55.6 %
07/09/2024	07:21	L	200	51.800	49.600	25.9 %
07/09/2024	07:27	M	200	111.200	108.200	55.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.800	49.267	Std	**4.9**
M	111.200	107.700	Std	**3.1**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / Low
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT2_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	09:41	L	10	2.600	2.400	26.0 %
07/09/2024	09:47	M	10	5.600	5.300	56.0 %
07/09/2024	09:56	L	10	2.600	2.300	26.0 %
07/09/2024	10:02	M	10	5.600	5.200	56.0 %
07/09/2024	10:10	L	10	2.600	2.300	26.0 %
07/09/2024	10:16	M	10	5.600	5.200	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	2.333	Std	**10.3**
M	5.600	5.233	Std	**6.5**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	09:00	L	2000	499.600	491.400	25.0 %
07/09/2024	09:06	M	2000	1168.000	1151.900	58.4 %
07/09/2024	09:15	L	2000	499.600	491.700	25.0 %
07/09/2024	09:21	M	2000	1168.000	1153.100	58.4 %
07/09/2024	09:29	L	2000	499.600	491.400	25.0 %
07/09/2024	09:35	M	2000	1168.000	1151.400	58.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	499.600	491.500	Std	**1.6**
M	1168.000	1152.133	Std	**1.4**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / Low
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	08:17	L	20	4.800	4.700	24.0 %
07/09/2024	08:23	M	20	10.900	11.100	54.5 %
07/09/2024	08:32	L	20	4.800	4.600	24.0 %
07/09/2024	08:38	M	20	10.900	11.200	54.5 %
07/09/2024	08:46	L	20	4.800	4.800	24.0 %
07/09/2024	08:52	M	20	10.900	11.000	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.800	4.700	Std	**2.1**
M	10.900	11.100	Std	**1.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High
Test Date: 07/09/2024
Test Result: **Pass**
Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2024	07:34	L	25	5.500	5.300	22.0 %
07/09/2024	07:40	M	25	13.000	12.900	52.0 %
07/09/2024	07:49	L	25	5.500	5.300	22.0 %
07/09/2024	07:55	M	25	13.000	12.900	52.0 %
07/09/2024	08:03	L	25	5.500	5.300	22.0 %
07/09/2024	08:09	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.300	Std	**3.6**
M	13.000	12.900	Std	**0.8**

ATTACHMENT 12
Startup/Shutdown Emissions

Title V: #13

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/01/2024 00:08 07/01/2024 00:13 Shut Down - Gas	6	1.2		
07/01/2024 08:24 07/01/2024 09:54 Warm Start - Gas	91	140.8		
07/01/2024 23:09 07/01/2024 23:15 Shut Down - Gas	7	0.9		
07/02/2024 10:30 07/02/2024 12:42 Warm Start - Gas	133	182.7		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.6		
07/04/2024 09:28 07/04/2024 10:40 Hot Start - Gas	73	117.0		
07/06/2024 06:09 07/06/2024 06:14 Shut Down - Gas	6	0.5		
07/06/2024 09:48 07/06/2024 10:47 Hot Start - Gas	60	97.8		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.5		
07/07/2024 15:41 07/07/2024 16:56 Warm Start - Gas	76	119.8		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	0.8		
07/14/2024 10:33 07/14/2024 11:51 Warm Start - Gas	79	124.1		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	1.0		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/21/2024 10:29 07/21/2024 11:43 Hot Start - Gas	75	129.7		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	0.6		
07/27/2024 11:49 07/27/2024 12:44 Hot Start - Gas	56	96.5		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	0.7		
07/29/2024 10:22 07/29/2024 12:33 Warm Start - Gas	132	184.5		
07/29/2024 23:09 07/29/2024 23:14 Shut Down - Gas	6	0.6		
07/30/2024 10:18 07/30/2024 12:50 Warm Start - Gas	153	216.2		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.5		
08/12/2024 13:17 08/12/2024 15:41 Warm Start - Gas	145	182.8		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	0.9		
08/15/2024 17:03 08/15/2024 18:28 Warm Start - Gas	86	122.1		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.4		
08/16/2024 08:31 08/16/2024 09:48 Hot Start - Gas	78	131.3		
08/17/2024 06:25 08/17/2024 06:30 Shut Down - Gas	6	1.1		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/18/2024 09:15 08/18/2024 11:40 Warm Start - Gas	146	205.3		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	0.6		
08/19/2024 12:13 08/19/2024 13:39 Warm Start - Gas	87	137.4		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	1.2		
08/20/2024 09:21 08/20/2024 10:46 Warm Start - Gas	86	131.3		
08/22/2024 06:10 08/22/2024 06:14 Shut Down - Gas	5	0.3		
08/22/2024 14:20 08/22/2024 15:47 Warm Start - Gas	88	131.2		
08/23/2024 07:05 08/23/2024 07:09 Shut Down - Gas	5	0.4		
08/25/2024 13:18 08/25/2024 15:33 Warm Start - Gas	136	222.2		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	0.8		
08/31/2024 14:33 08/31/2024 15:39 Warm Start - Gas	67	105.5		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	0.7		
09/01/2024 10:48 09/01/2024 11:55 Hot Start - Gas	68	112.7		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	0.8		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/02/2024 10:38 09/02/2024 11:27 Hot Start - Gas	50	95.7		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	0.9		
09/12/2024 17:18 09/12/2024 19:52 Warm Start - Gas	155	212.4		
09/13/2024 07:38 09/13/2024 07:43 Shut Down - Gas	6	0.3		
09/13/2024 13:31 09/13/2024 14:50 Hot Start - Gas	80	124.4		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.7		
09/14/2024 16:06 09/14/2024 18:29 Warm Start - Gas	144	256.4		
09/15/2024 01:10 09/15/2024 01:15 Shut Down - Gas	6	0.7		
09/15/2024 17:17 09/15/2024 19:38 Warm Start - Gas	142	240.0		
09/16/2024 07:38 09/16/2024 07:43 Shut Down - Gas	6	0.9		
09/17/2024 20:05 09/17/2024 22:48 Warm Start - Gas	164	204.3		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	0.9		
09/22/2024 14:13 09/22/2024 15:44 Cold Start - Gas	92	140.0		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	0.9		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/25/2024 14:44 09/25/2024 15:50 Hot Start - Gas	67	103.7		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	0.7		
09/26/2024 14:31 09/26/2024 15:44 Hot Start - Gas	74	113.1		
09/27/2024 01:10 09/27/2024 01:15 Shut Down - Gas	6	0.7		
09/27/2024 09:26 09/27/2024 10:45 Warm Start - Gas	80	112.8		
09/28/2024 07:09 09/28/2024 07:14 Shut Down - Gas	6	0.8		
09/28/2024 15:01 09/28/2024 15:54 Hot Start - Gas	54	85.8		
09/29/2024 02:10 09/29/2024 02:15 Shut Down - Gas	6	0.3		
09/29/2024 10:33 09/29/2024 11:48 Warm Start - Gas	76	116.3		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	5.1	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	15.8	0	1	0	0	0
07/01/2024 09:00	46.3	0	1	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	1
07/01/2024 11:00	0.0	0	0	0	0	1
07/01/2024 12:00	0.0	0	0	0	0	1
07/01/2024 13:00	0.0	0	0	0	0	1
07/01/2024 14:00	0.0	0	0	0	0	1
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	2.8	0	0	0	1	0
Average/Sum#:	70.0 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	13.4	0	1	0	0	0
07/02/2024 11:00	20.8	0	1	0	0	0
07/02/2024 12:00	26.1	0	1	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	1
07/02/2024 14:00	0.0	0	0	0	0	1
07/02/2024 15:00	0.0	0	0	0	0	1
07/02/2024 16:00	0.0	0	0	0	0	1
07/02/2024 17:00	0.0	0	0	0	0	1
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.3 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	2.8	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	14.2	0	0	1	0	0
07/04/2024 10:00	44.9	0	0	1	0	0
07/04/2024 11:00	0.0	0	0	0	0	1
07/04/2024 12:00	0.0	0	0	0	0	1
07/04/2024 13:00	0.0	0	0	0	0	1
07/04/2024 14:00	0.0	0	0	0	0	1
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	61.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	3.2	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	1.5	0	0	1	0	0
07/06/2024 10:00	36.5	0	0	1	0	0
07/06/2024 11:00	0.0	0	0	0	0	1
07/06/2024 12:00	0.0	0	0	0	0	1
07/06/2024 13:00	0.0	0	0	0	0	1
07/06/2024 14:00	0.0	0	0	0	0	1
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.2 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	4.2	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	0.0	0	0	0	0	0
07/07/2024 12:00	0.0	0	0	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	0
07/07/2024 14:00	0.0	0	0	0	0	0
07/07/2024 15:00	11.5	0	1	0	0	0
07/07/2024 16:00	67.3	0	1	0	0	0
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	83.0 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	2.4	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	13.8	0	1	0	0	0
07/14/2024 11:00	51.3	0	1	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	1
07/14/2024 13:00	0.0	0	0	0	0	1
07/14/2024 14:00	0.0	0	0	0	0	1
07/14/2024 15:00	0.0	0	0	0	0	1
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	67.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	4.0	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	14.9	0	0	1	0	0
07/21/2024 11:00	66.2	0	0	1	0	0
07/21/2024 12:00	0.0	0	0	0	0	1
07/21/2024 13:00	0.0	0	0	0	0	1
07/21/2024 14:00	0.0	0	0	0	0	1
07/21/2024 15:00	0.0	0	0	0	0	1
07/21/2024 16:00	0.0	0	0	0	0	1
07/21/2024 17:00	0.0	0	0	0	0	1
07/21/2024 18:00	0.0	0	0	0	0	1
07/21/2024 19:00	0.0	0	0	0	0	1
07/21/2024 20:00	0.0	0	0	0	0	1
07/21/2024 21:00	0.0	0	0	0	0	1
07/21/2024 22:00	0.0	0	0	0	0	1
07/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	85.1 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	1
07/22/2024 01:00	0.0	0	0	0	0	1
07/22/2024 02:00	0.0	0	0	0	0	1
07/22/2024 03:00	0.0	0	0	0	0	1
07/22/2024 04:00	0.0	0	0	0	0	1
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	3.3	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	2.0	0	0	1	0	0
07/27/2024 12:00	63.8	0	0	1	0	0
07/27/2024 13:00	0.0	0	0	0	0	1
07/27/2024 14:00	0.0	0	0	0	0	1
07/27/2024 15:00	0.0	0	0	0	0	1
07/27/2024 16:00	0.0	0	0	0	0	1
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	69.1 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	4.4	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	0.0	0	0	0	0	0
07/28/2024 15:00	0.0	0	0	0	0	0
07/28/2024 16:00	0.0	0	0	0	0	0
07/28/2024 17:00	0.0	0	0	0	0	0
07/28/2024 18:00	0.0	0	0	0	0	0
07/28/2024 19:00	0.0	0	0	0	0	0
07/28/2024 20:00	0.0	0	0	0	0	0
07/28/2024 21:00	0.0	0	0	0	0	0
07/28/2024 22:00	0.0	0	0	0	0	0
07/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	4.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	0
07/29/2024 01:00	0.0	0	0	0	0	0
07/29/2024 02:00	0.0	0	0	0	0	0
07/29/2024 03:00	0.0	0	0	0	0	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	51.0	0	1	0	0	0
07/29/2024 11:00	35.6	0	1	0	0	0
07/29/2024 12:00	46.3	0	1	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	1
07/29/2024 14:00	0.0	0	0	0	0	1
07/29/2024 15:00	0.0	0	0	0	0	1
07/29/2024 16:00	0.0	0	0	0	0	1
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	4.1	0	0	0	1	0
Average/Sum#:	137.0 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	36.9	0	1	0	0	0
07/30/2024 11:00	29.9	0	1	0	0	0
07/30/2024 12:00	80.9	0	1	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	1
07/30/2024 14:00	0.0	0	0	0	0	1
07/30/2024 15:00	0.0	0	0	0	0	1
07/30/2024 16:00	0.0	0	0	0	0	1
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	147.7 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	3.3	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.3 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	0.0	0	0	0	0	0
08/10/2024 14:00	0.0	0	0	0	0	0
08/10/2024 15:00	0.0	0	0	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	0
08/10/2024 17:00	0.0	0	0	0	0	0
08/10/2024 18:00	0.0	0	0	0	0	0
08/10/2024 19:00	0.0	0	0	0	0	0
08/10/2024 20:00	0.0	0	0	0	0	0
08/10/2024 21:00	0.0	0	0	0	0	0
08/10/2024 22:00	0.0	0	0	0	0	0
08/10/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	61.2	0	1	0	0	0
08/12/2024 14:00	24.6	0	1	0	0	0
08/12/2024 15:00	26.3	0	1	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	1
08/12/2024 17:00	0.0	0	0	0	0	1
08/12/2024 18:00	0.0	0	0	0	0	1
08/12/2024 19:00	0.0	0	0	0	0	1
08/12/2024 20:00	0.0	0	0	0	0	1
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	112.1 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	2.7	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	0.0	0	0	0	0	0
08/13/2024 17:00	0.0	0	0	0	0	0
08/13/2024 18:00	0.0	0	0	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	0
08/13/2024 20:00	0.0	0	0	0	0	0
08/13/2024 21:00	0.0	0	0	0	0	0
08/13/2024 22:00	0.0	0	0	0	0	0
08/13/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.7 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	0
08/14/2024 01:00	0.0	0	0	0	0	0
08/14/2024 02:00	0.0	0	0	0	0	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	0.0	0	0	0	0	0
08/14/2024 11:00	0.0	0	0	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	0
08/14/2024 13:00	0.0	0	0	0	0	0
08/14/2024 14:00	0.0	0	0	0	0	0
08/14/2024 15:00	0.0	0	0	0	0	0
08/14/2024 16:00	0.0	0	0	0	0	0
08/14/2024 17:00	0.0	0	0	0	0	0
08/14/2024 18:00	0.0	0	0	0	0	0
08/14/2024 19:00	0.0	0	0	0	0	0
08/14/2024 20:00	0.0	0	0	0	0	0
08/14/2024 21:00	0.0	0	0	0	0	0
08/14/2024 22:00	0.0	0	0	0	0	0
08/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	0.0	0	0	0	0	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	0.0	0	0	0	0	0
08/15/2024 13:00	0.0	0	0	0	0	0
08/15/2024 14:00	0.0	0	0	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	0
08/15/2024 16:00	0.0	0	0	0	0	0
08/15/2024 17:00	58.8	0	1	0	0	0
08/15/2024 18:00	14.6	0	1	0	0	0
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	73.4 #	0 #	2 #	0 #	0 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	2.2	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	10.9	0	0	1	0	0
08/16/2024 09:00	55.4	0	0	1	0	0
08/16/2024 10:00	0.0	0	0	0	0	1
08/16/2024 11:00	0.0	0	0	0	0	1
08/16/2024 12:00	0.0	0	0	0	0	1
08/16/2024 13:00	0.0	0	0	0	0	1
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.5 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	2.0	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	0.0	0	0	0	0	0
08/17/2024 15:00	0.0	0	0	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	0
08/17/2024 17:00	0.0	0	0	0	0	0
08/17/2024 18:00	0.0	0	0	0	0	0
08/17/2024 19:00	0.0	0	0	0	0	0
08/17/2024 20:00	0.0	0	0	0	0	0
08/17/2024 21:00	0.0	0	0	0	0	0
08/17/2024 22:00	0.0	0	0	0	0	0
08/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	0
08/18/2024 01:00	0.0	0	0	0	0	0
08/18/2024 02:00	0.0	0	0	0	0	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	53.9	0	1	0	0	0
08/18/2024 10:00	28.6	0	1	0	0	0
08/18/2024 11:00	49.6	0	1	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	1
08/18/2024 13:00	0.0	0	0	0	0	1
08/18/2024 14:00	0.0	0	0	0	0	1
08/18/2024 15:00	0.0	0	0	0	0	1
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	132.1 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	53.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	3.4	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	0.0	0	0	0	0	0
08/19/2024 08:00	0.0	0	0	0	0	0
08/19/2024 09:00	0.0	0	0	0	0	0
08/19/2024 10:00	0.0	0	0	0	0	0
08/19/2024 11:00	0.0	0	0	0	0	0
08/19/2024 12:00	24.1	0	1	0	0	0
08/19/2024 13:00	42.4	0	1	0	0	0
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	69.9 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	3.3	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	20.0	0	1	0	0	0
08/20/2024 10:00	64.1	0	1	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	1
08/20/2024 12:00	0.0	0	0	0	0	1
08/20/2024 13:00	0.0	0	0	0	0	1
08/20/2024 14:00	0.0	0	0	0	0	1
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	2.6	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	18.9	0	1	0	0	0
08/22/2024 15:00	35.4	0	1	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	1
08/22/2024 17:00	0.0	0	0	0	0	1
08/22/2024 18:00	0.0	0	0	0	0	1
08/22/2024 19:00	0.0	0	0	0	0	1
08/22/2024 20:00	0.0	0	0	0	0	1
08/22/2024 21:00	0.0	0	0	0	0	1
08/22/2024 22:00	0.0	0	0	0	0	1
08/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	56.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	1
08/23/2024 01:00	0.0	0	0	0	0	1
08/23/2024 02:00	0.0	0	0	0	0	1
08/23/2024 03:00	0.0	0	0	0	0	1
08/23/2024 04:00	0.0	0	0	0	0	1
08/23/2024 05:00	0.0	0	0	0	0	1
08/23/2024 06:00	0.0	0	0	0	0	1
08/23/2024 07:00	2.8	0	0	0	1	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	49.2	0	1	0	0	0
08/25/2024 14:00	67.7	0	1	0	0	0
08/25/2024 15:00	34.3	0	1	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	1
08/25/2024 17:00	0.0	0	0	0	0	1
08/25/2024 18:00	0.0	0	0	0	0	1
08/25/2024 19:00	0.0	0	0	0	0	1
08/25/2024 20:00	0.0	0	0	0	0	1
08/25/2024 21:00	0.0	0	0	0	0	1
08/25/2024 22:00	0.0	0	0	0	0	1
08/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	151.2 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	0.0	0	0	0	0	1
08/26/2024 01:00	0.0	0	0	0	0	1
08/26/2024 02:00	0.0	0	0	0	0	1
08/26/2024 03:00	0.0	0	0	0	0	1
08/26/2024 04:00	0.0	0	0	0	0	1
08/26/2024 05:00	0.0	0	0	0	0	1
08/26/2024 06:00	0.0	0	0	0	0	1
08/26/2024 07:00	0.0	0	0	0	0	1
08/26/2024 08:00	0.0	0	0	0	0	1
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	3.4	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	0.0	0	0	0	0	0
08/31/2024 11:00	0.0	0	0	0	0	0
08/31/2024 12:00	0.0	0	0	0	0	0
08/31/2024 13:00	0.0	0	0	0	0	0
08/31/2024 14:00	14.3	0	1	0	0	0
08/31/2024 15:00	32.0	0	1	0	0	0
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.7 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	3.8	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	2.3	0	0	1	0	0
09/01/2024 11:00	59.2	0	0	1	0	0
09/01/2024 12:00	0.0	0	0	0	0	1
09/01/2024 13:00	0.0	0	0	0	0	1
09/01/2024 14:00	0.0	0	0	0	0	1
09/01/2024 15:00	0.0	0	0	0	0	1
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.3 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	3.4	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	19.5	0	0	1	0	0
09/02/2024 11:00	29.9	0	0	1	0	0
09/02/2024 12:00	0.0	0	0	0	0	1
09/02/2024 13:00	0.0	0	0	0	0	1
09/02/2024 14:00	0.0	0	0	0	0	1
09/02/2024 15:00	0.0	0	0	0	0	1
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	52.8 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	3.0	0	0	0	1	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	48.4	0	1	0	0	0
09/12/2024 18:00	20.4	0	1	0	0	0
09/12/2024 19:00	44.7	0	1	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	1
09/12/2024 21:00	0.0	0	0	0	0	1
09/12/2024 22:00	0.0	0	0	0	0	1
09/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	113.5 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	1
09/13/2024 01:00	0.0	0	0	0	0	1
09/13/2024 02:00	0.0	0	0	0	0	1
09/13/2024 03:00	0.0	0	0	0	0	1
09/13/2024 04:00	0.0	0	0	0	0	1
09/13/2024 05:00	0.0	0	0	0	0	1
09/13/2024 06:00	0.0	0	0	0	0	1
09/13/2024 07:00	1.3	0	0	0	1	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	10.3	0	0	1	0	0
09/13/2024 14:00	32.9	0	0	1	0	0
09/13/2024 15:00	0.0	0	0	0	0	1
09/13/2024 16:00	0.0	0	0	0	0	1
09/13/2024 17:00	0.0	0	0	0	0	1
09/13/2024 18:00	0.0	0	0	0	0	1
09/13/2024 19:00	0.0	0	0	0	0	1
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.5 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	1.4	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	50.2	0	1	0	0	0
09/14/2024 17:00	102.3	0	1	0	0	0
09/14/2024 18:00	32.0	0	1	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	1
09/14/2024 20:00	0.0	0	0	0	0	1
09/14/2024 21:00	0.0	0	0	0	0	1
09/14/2024 22:00	0.0	0	0	0	0	1
09/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	185.9 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	102.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	1
09/15/2024 01:00	6.2	0	0	0	1	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	49.3	0	1	0	0	0
09/15/2024 18:00	147.0	0	1	0	0	0
09/15/2024 19:00	87.0	0	1	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	1
09/15/2024 21:00	0.0	0	0	0	0	1
09/15/2024 22:00	0.0	0	0	0	0	1
09/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	289.5 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	147.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	1
09/16/2024 01:00	0.0	0	0	0	0	1
09/16/2024 02:00	0.0	0	0	0	0	1
09/16/2024 03:00	0.0	0	0	0	0	1
09/16/2024 04:00	0.0	0	0	0	0	1
09/16/2024 05:00	0.0	0	0	0	0	1
09/16/2024 06:00	0.0	0	0	0	0	1
09/16/2024 07:00	2.0	0	0	0	1	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	61.0	0	1	0	0	0
09/17/2024 21:00	28.6	0	1	0	0	0
09/17/2024 22:00	55.9	0	1	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	145.5 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	1
09/18/2024 01:00	0.0	0	0	0	0	1
09/18/2024 02:00	0.0	0	0	0	0	1
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	3.0	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	0.0	0	0	0	0	0
09/21/2024 21:00	0.0	0	0	0	0	0
09/21/2024 22:00	0.0	0	0	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	0
09/22/2024 01:00	0.0	0	0	0	0	0
09/22/2024 02:00	0.0	0	0	0	0	0
09/22/2024 03:00	0.0	0	0	0	0	0
09/22/2024 04:00	0.0	0	0	0	0	0
09/22/2024 05:00	0.0	0	0	0	0	0
09/22/2024 06:00	0.0	0	0	0	0	0
09/22/2024 07:00	0.0	0	0	0	0	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	0.0	0	0	0	0	0
09/22/2024 11:00	0.0	0	0	0	0	0
09/22/2024 12:00	0.0	0	0	0	0	0
09/22/2024 13:00	0.0	0	0	0	0	0
09/22/2024 14:00	40.0	1	0	0	0	0
09/22/2024 15:00	33.6	1	0	0	0	0
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	73.6 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.0	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	2.8	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	5.4	0	0	1	0	0
09/25/2024 15:00	37.9	0	0	1	0	0
09/25/2024 16:00	0.0	0	0	0	0	1
09/25/2024 17:00	0.0	0	0	0	0	1
09/25/2024 18:00	0.0	0	0	0	0	1
09/25/2024 19:00	0.0	0	0	0	0	1
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	3.2	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	9.5	0	0	1	0	0
09/26/2024 15:00	30.0	0	0	1	0	0
09/26/2024 16:00	0.0	0	0	0	0	1
09/26/2024 17:00	0.0	0	0	0	0	1
09/26/2024 18:00	0.0	0	0	0	0	1
09/26/2024 19:00	0.0	0	0	0	0	1
09/26/2024 20:00	0.0	0	0	0	0	1
09/26/2024 21:00	0.0	0	0	0	0	1
09/26/2024 22:00	0.0	0	0	0	0	1
09/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	1
09/27/2024 01:00	3.4	0	0	0	1	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	22.2	0	1	0	0	0
09/27/2024 10:00	30.3	0	1	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	1
09/27/2024 12:00	0.0	0	0	0	0	1
09/27/2024 13:00	0.0	0	0	0	0	1
09/27/2024 14:00	0.0	0	0	0	0	1
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	3.1	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	28.4	0	0	1	0	0
09/28/2024 16:00	0.0	0	0	0	0	1
09/28/2024 17:00	0.0	0	0	0	0	1
09/28/2024 18:00	0.0	0	0	0	0	1
09/28/2024 19:00	0.0	0	0	0	0	1
09/28/2024 20:00	0.0	0	0	0	0	1
09/28/2024 21:00	0.0	0	0	0	0	1
09/28/2024 22:00	0.0	0	0	0	0	1
09/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	31.5 #	0 #	0 #	1 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	1
09/29/2024 01:00	0.0	0	0	0	0	1
09/29/2024 02:00	3.0	0	0	0	1	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	24.3	0	1	0	0	0
09/29/2024 11:00	44.0	0	1	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	1
09/29/2024 13:00	0.0	0	0	0	0	1
09/29/2024 14:00	0.0	0	0	0	0	1
09/29/2024 15:00	0.0	0	0	0	0	1
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	71.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	69.3	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	2,013.3	0	1	0	0	0
07/01/2024 09:00	6,437.1	0	1	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	1
07/01/2024 11:00	0.0	0	0	0	0	1
07/01/2024 12:00	0.0	0	0	0	0	1
07/01/2024 13:00	0.0	0	0	0	0	1
07/01/2024 14:00	0.0	0	0	0	0	1
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	52.4	0	0	0	1	0
Average/Sum#:	8,572.1 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,437.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	1,586.3	0	1	0	0	0
07/02/2024 11:00	4,055.2	0	1	0	0	0
07/02/2024 12:00	5,318.0	0	1	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	1
07/02/2024 14:00	0.0	0	0	0	0	1
07/02/2024 15:00	0.0	0	0	0	0	1
07/02/2024 16:00	0.0	0	0	0	0	1
07/02/2024 17:00	0.0	0	0	0	0	1
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,959.5 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,318.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	35.7	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	1,759.0	0	0	1	0	0
07/04/2024 10:00	5,263.9	0	0	1	0	0
07/04/2024 11:00	0.0	0	0	0	0	1
07/04/2024 12:00	0.0	0	0	0	0	1
07/04/2024 13:00	0.0	0	0	0	0	1
07/04/2024 14:00	0.0	0	0	0	0	1
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,058.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,263.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	32.6	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	330.1	0	0	1	0	0
07/06/2024 10:00	5,535.4	0	0	1	0	0
07/06/2024 11:00	0.0	0	0	0	0	1
07/06/2024 12:00	0.0	0	0	0	0	1
07/06/2024 13:00	0.0	0	0	0	0	1
07/06/2024 14:00	0.0	0	0	0	0	1
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,898.1 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,535.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	27.9	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	0.0	0	0	0	0	0
07/07/2024 12:00	0.0	0	0	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	0
07/07/2024 14:00	0.0	0	0	0	0	0
07/07/2024 15:00	821.0	0	1	0	0	0
07/07/2024 16:00	6,366.4	0	1	0	0	0
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,215.3 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,366.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	50.3	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	1,406.0	0	1	0	0	0
07/14/2024 11:00	6,038.0	0	1	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	1
07/14/2024 13:00	0.0	0	0	0	0	1
07/14/2024 14:00	0.0	0	0	0	0	1
07/14/2024 15:00	0.0	0	0	0	0	1
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,494.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,038.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	60.0	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	1,731.0	0	0	1	0	0
07/21/2024 11:00	6,053.1	0	0	1	0	0
07/21/2024 12:00	0.0	0	0	0	0	1
07/21/2024 13:00	0.0	0	0	0	0	1
07/21/2024 14:00	0.0	0	0	0	0	1
07/21/2024 15:00	0.0	0	0	0	0	1
07/21/2024 16:00	0.0	0	0	0	0	1
07/21/2024 17:00	0.0	0	0	0	0	1
07/21/2024 18:00	0.0	0	0	0	0	1
07/21/2024 19:00	0.0	0	0	0	0	1
07/21/2024 20:00	0.0	0	0	0	0	1
07/21/2024 21:00	0.0	0	0	0	0	1
07/21/2024 22:00	0.0	0	0	0	0	1
07/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,844.1 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,053.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	1
07/22/2024 01:00	0.0	0	0	0	0	1
07/22/2024 02:00	0.0	0	0	0	0	1
07/22/2024 03:00	0.0	0	0	0	0	1
07/22/2024 04:00	0.0	0	0	0	0	1
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	38.7	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	276.7	0	0	1	0	0
07/27/2024 12:00	5,513.8	0	0	1	0	0
07/27/2024 13:00	0.0	0	0	0	0	1
07/27/2024 14:00	0.0	0	0	0	0	1
07/27/2024 15:00	0.0	0	0	0	0	1
07/27/2024 16:00	0.0	0	0	0	0	1
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,829.2 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,513.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	43.7	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	0.0	0	0	0	0	0
07/28/2024 15:00	0.0	0	0	0	0	0
07/28/2024 16:00	0.0	0	0	0	0	0
07/28/2024 17:00	0.0	0	0	0	0	0
07/28/2024 18:00	0.0	0	0	0	0	0
07/28/2024 19:00	0.0	0	0	0	0	0
07/28/2024 20:00	0.0	0	0	0	0	0
07/28/2024 21:00	0.0	0	0	0	0	0
07/28/2024 22:00	0.0	0	0	0	0	0
07/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	43.7 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	0
07/29/2024 01:00	0.0	0	0	0	0	0
07/29/2024 02:00	0.0	0	0	0	0	0
07/29/2024 03:00	0.0	0	0	0	0	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	2,005.8	0	1	0	0	0
07/29/2024 11:00	4,167.0	0	1	0	0	0
07/29/2024 12:00	4,896.0	0	1	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	1
07/29/2024 14:00	0.0	0	0	0	0	1
07/29/2024 15:00	0.0	0	0	0	0	1
07/29/2024 16:00	0.0	0	0	0	0	1
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	33.3	0	0	0	1	0
Average/Sum#:	11,102.1 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,896.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	2,363.5	0	1	0	0	0
07/30/2024 11:00	4,017.5	0	1	0	0	0
07/30/2024 12:00	6,591.4	0	1	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	1
07/30/2024 14:00	0.0	0	0	0	0	1
07/30/2024 15:00	0.0	0	0	0	0	1
07/30/2024 16:00	0.0	0	0	0	0	1
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,972.4 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,591.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	27.1	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	27.1 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	0.0	0	0	0	0	0
08/10/2024 14:00	0.0	0	0	0	0	0
08/10/2024 15:00	0.0	0	0	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	0
08/10/2024 17:00	0.0	0	0	0	0	0
08/10/2024 18:00	0.0	0	0	0	0	0
08/10/2024 19:00	0.0	0	0	0	0	0
08/10/2024 20:00	0.0	0	0	0	0	0
08/10/2024 21:00	0.0	0	0	0	0	0
08/10/2024 22:00	0.0	0	0	0	0	0
08/10/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	2,183.7	0	1	0	0	0
08/12/2024 14:00	3,884.9	0	1	0	0	0
08/12/2024 15:00	4,902.0	0	1	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	1
08/12/2024 17:00	0.0	0	0	0	0	1
08/12/2024 18:00	0.0	0	0	0	0	1
08/12/2024 19:00	0.0	0	0	0	0	1
08/12/2024 20:00	0.0	0	0	0	0	1
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,970.6 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,902.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	51.1	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	0.0	0	0	0	0	0
08/13/2024 17:00	0.0	0	0	0	0	0
08/13/2024 18:00	0.0	0	0	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	0
08/13/2024 20:00	0.0	0	0	0	0	0
08/13/2024 21:00	0.0	0	0	0	0	0
08/13/2024 22:00	0.0	0	0	0	0	0
08/13/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	51.1 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	0
08/14/2024 01:00	0.0	0	0	0	0	0
08/14/2024 02:00	0.0	0	0	0	0	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	0.0	0	0	0	0	0
08/14/2024 11:00	0.0	0	0	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	0
08/14/2024 13:00	0.0	0	0	0	0	0
08/14/2024 14:00	0.0	0	0	0	0	0
08/14/2024 15:00	0.0	0	0	0	0	0
08/14/2024 16:00	0.0	0	0	0	0	0
08/14/2024 17:00	0.0	0	0	0	0	0
08/14/2024 18:00	0.0	0	0	0	0	0
08/14/2024 19:00	0.0	0	0	0	0	0
08/14/2024 20:00	0.0	0	0	0	0	0
08/14/2024 21:00	0.0	0	0	0	0	0
08/14/2024 22:00	0.0	0	0	0	0	0
08/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	0.0	0	0	0	0	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	0.0	0	0	0	0	0
08/15/2024 13:00	0.0	0	0	0	0	0
08/15/2024 14:00	0.0	0	0	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	0
08/15/2024 16:00	0.0	0	0	0	0	0
08/15/2024 17:00	3,068.7	0	1	0	0	0
08/15/2024 18:00	4,255.8	0	1	0	0	0
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,324.5 #	0 #	2 #	0 #	0 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,255.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	23.6	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	1,545.2	0	0	1	0	0
08/16/2024 09:00	6,333.6	0	0	1	0	0
08/16/2024 10:00	0.0	0	0	0	0	1
08/16/2024 11:00	0.0	0	0	0	0	1
08/16/2024 12:00	0.0	0	0	0	0	1
08/16/2024 13:00	0.0	0	0	0	0	1
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,902.4 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,333.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	64.4	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	0.0	0	0	0	0	0
08/17/2024 15:00	0.0	0	0	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	0
08/17/2024 17:00	0.0	0	0	0	0	0
08/17/2024 18:00	0.0	0	0	0	0	0
08/17/2024 19:00	0.0	0	0	0	0	0
08/17/2024 20:00	0.0	0	0	0	0	0
08/17/2024 21:00	0.0	0	0	0	0	0
08/17/2024 22:00	0.0	0	0	0	0	0
08/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	64.4 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	0
08/18/2024 01:00	0.0	0	0	0	0	0
08/18/2024 02:00	0.0	0	0	0	0	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	2,474.8	0	1	0	0	0
08/18/2024 10:00	4,094.6	0	1	0	0	0
08/18/2024 11:00	5,746.6	0	1	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	1
08/18/2024 13:00	0.0	0	0	0	0	1
08/18/2024 14:00	0.0	0	0	0	0	1
08/18/2024 15:00	0.0	0	0	0	0	1
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,316.0 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,746.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	38.7	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	0.0	0	0	0	0	0
08/19/2024 08:00	0.0	0	0	0	0	0
08/19/2024 09:00	0.0	0	0	0	0	0
08/19/2024 10:00	0.0	0	0	0	0	0
08/19/2024 11:00	0.0	0	0	0	0	0
08/19/2024 12:00	2,726.5	0	1	0	0	0
08/19/2024 13:00	5,516.5	0	1	0	0	0
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,281.7 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,516.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	70.8	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	1,862.4	0	1	0	0	0
08/20/2024 10:00	6,015.3	0	1	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	1
08/20/2024 12:00	0.0	0	0	0	0	1
08/20/2024 13:00	0.0	0	0	0	0	1
08/20/2024 14:00	0.0	0	0	0	0	1
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,948.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,015.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	16.4	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	2,198.8	0	1	0	0	0
08/22/2024 15:00	5,676.1	0	1	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	1
08/22/2024 17:00	0.0	0	0	0	0	1
08/22/2024 18:00	0.0	0	0	0	0	1
08/22/2024 19:00	0.0	0	0	0	0	1
08/22/2024 20:00	0.0	0	0	0	0	1
08/22/2024 21:00	0.0	0	0	0	0	1
08/22/2024 22:00	0.0	0	0	0	0	1
08/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,891.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,676.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	1
08/23/2024 01:00	0.0	0	0	0	0	1
08/23/2024 02:00	0.0	0	0	0	0	1
08/23/2024 03:00	0.0	0	0	0	0	1
08/23/2024 04:00	0.0	0	0	0	0	1
08/23/2024 05:00	0.0	0	0	0	0	1
08/23/2024 06:00	0.0	0	0	0	0	1
08/23/2024 07:00	22.3	0	0	0	1	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	22.3 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	2,249.1	0	1	0	0	0
08/25/2024 14:00	6,249.0	0	1	0	0	0
08/25/2024 15:00	4,834.1	0	1	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	1
08/25/2024 17:00	0.0	0	0	0	0	1
08/25/2024 18:00	0.0	0	0	0	0	1
08/25/2024 19:00	0.0	0	0	0	0	1
08/25/2024 20:00	0.0	0	0	0	0	1
08/25/2024 21:00	0.0	0	0	0	0	1
08/25/2024 22:00	0.0	0	0	0	0	1
08/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,332.2 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,249.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	0.0	0	0	0	0	1
08/26/2024 01:00	0.0	0	0	0	0	1
08/26/2024 02:00	0.0	0	0	0	0	1
08/26/2024 03:00	0.0	0	0	0	0	1
08/26/2024 04:00	0.0	0	0	0	0	1
08/26/2024 05:00	0.0	0	0	0	0	1
08/26/2024 06:00	0.0	0	0	0	0	1
08/26/2024 07:00	0.0	0	0	0	0	1
08/26/2024 08:00	0.0	0	0	0	0	1
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	45.0	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	0.0	0	0	0	0	0
08/31/2024 11:00	0.0	0	0	0	0	0
08/31/2024 12:00	0.0	0	0	0	0	0
08/31/2024 13:00	0.0	0	0	0	0	0
08/31/2024 14:00	1,392.1	0	1	0	0	0
08/31/2024 15:00	4,940.4	0	1	0	0	0
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,377.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,940.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	43.7	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	316.6	0	0	1	0	0
09/01/2024 11:00	6,447.8	0	0	1	0	0
09/01/2024 12:00	0.0	0	0	0	0	1
09/01/2024 13:00	0.0	0	0	0	0	1
09/01/2024 14:00	0.0	0	0	0	0	1
09/01/2024 15:00	0.0	0	0	0	0	1
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,808.1 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,447.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	46.6	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	1,570.6	0	0	1	0	0
09/02/2024 11:00	4,169.8	0	0	1	0	0
09/02/2024 12:00	0.0	0	0	0	0	1
09/02/2024 13:00	0.0	0	0	0	0	1
09/02/2024 14:00	0.0	0	0	0	0	1
09/02/2024 15:00	0.0	0	0	0	0	1
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,787.0 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,169.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	51.3	0	0	0	1	0
Average/Sum#:	51.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	2,195.1	0	1	0	0	0
09/12/2024 18:00	3,888.6	0	1	0	0	0
09/12/2024 19:00	6,662.0	0	1	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	1
09/12/2024 21:00	0.0	0	0	0	0	1
09/12/2024 22:00	0.0	0	0	0	0	1
09/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,745.7 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,662.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	1
09/13/2024 01:00	0.0	0	0	0	0	1
09/13/2024 02:00	0.0	0	0	0	0	1
09/13/2024 03:00	0.0	0	0	0	0	1
09/13/2024 04:00	0.0	0	0	0	0	1
09/13/2024 05:00	0.0	0	0	0	0	1
09/13/2024 06:00	0.0	0	0	0	0	1
09/13/2024 07:00	15.4	0	0	0	1	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	1,512.7	0	0	1	0	0
09/13/2024 14:00	5,952.8	0	0	1	0	0
09/13/2024 15:00	0.0	0	0	0	0	1
09/13/2024 16:00	0.0	0	0	0	0	1
09/13/2024 17:00	0.0	0	0	0	0	1
09/13/2024 18:00	0.0	0	0	0	0	1
09/13/2024 19:00	0.0	0	0	0	0	1
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,480.9 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,952.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	41.6	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	4,060.4	0	1	0	0	0
09/14/2024 17:00	6,987.7	0	1	0	0	0
09/14/2024 18:00	4,335.5	0	1	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	1
09/14/2024 20:00	0.0	0	0	0	0	1
09/14/2024 21:00	0.0	0	0	0	0	1
09/14/2024 22:00	0.0	0	0	0	0	1
09/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,425.2 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,987.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	1
09/15/2024 01:00	41.4	0	0	0	1	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	2,387.0	0	1	0	0	0
09/15/2024 18:00	6,529.1	0	1	0	0	0
09/15/2024 19:00	5,484.2	0	1	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	1
09/15/2024 21:00	0.0	0	0	0	0	1
09/15/2024 22:00	0.0	0	0	0	0	1
09/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,441.7 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,529.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	1
09/16/2024 01:00	0.0	0	0	0	0	1
09/16/2024 02:00	0.0	0	0	0	0	1
09/16/2024 03:00	0.0	0	0	0	0	1
09/16/2024 04:00	0.0	0	0	0	0	1
09/16/2024 05:00	0.0	0	0	0	0	1
09/16/2024 06:00	0.0	0	0	0	0	1
09/16/2024 07:00	52.7	0	0	0	1	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	52.7 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	2,931.2	0	1	0	0	0
09/17/2024 21:00	3,864.7	0	1	0	0	0
09/17/2024 22:00	5,464.3	0	1	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,260.2 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,464.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	1
09/18/2024 01:00	0.0	0	0	0	0	1
09/18/2024 02:00	0.0	0	0	0	0	1
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	51.9	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	51.9 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	0.0	0	0	0	0	0
09/21/2024 21:00	0.0	0	0	0	0	0
09/21/2024 22:00	0.0	0	0	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	0
09/22/2024 01:00	0.0	0	0	0	0	0
09/22/2024 02:00	0.0	0	0	0	0	0
09/22/2024 03:00	0.0	0	0	0	0	0
09/22/2024 04:00	0.0	0	0	0	0	0
09/22/2024 05:00	0.0	0	0	0	0	0
09/22/2024 06:00	0.0	0	0	0	0	0
09/22/2024 07:00	0.0	0	0	0	0	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	0.0	0	0	0	0	0
09/22/2024 11:00	0.0	0	0	0	0	0
09/22/2024 12:00	0.0	0	0	0	0	0
09/22/2024 13:00	0.0	0	0	0	0	0
09/22/2024 14:00	2,445.4	1	0	0	0	0
09/22/2024 15:00	5,954.8	1	0	0	0	0
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,400.2 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,954.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	51.8	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	634.4	0	0	1	0	0
09/25/2024 15:00	5,586.1	0	0	1	0	0
09/25/2024 16:00	0.0	0	0	0	0	1
09/25/2024 17:00	0.0	0	0	0	0	1
09/25/2024 18:00	0.0	0	0	0	0	1
09/25/2024 19:00	0.0	0	0	0	0	1
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,272.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,586.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	44.3	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	1,479.7	0	0	1	0	0
09/26/2024 15:00	5,305.3	0	0	1	0	0
09/26/2024 16:00	0.0	0	0	0	0	1
09/26/2024 17:00	0.0	0	0	0	0	1
09/26/2024 18:00	0.0	0	0	0	0	1
09/26/2024 19:00	0.0	0	0	0	0	1
09/26/2024 20:00	0.0	0	0	0	0	1
09/26/2024 21:00	0.0	0	0	0	0	1
09/26/2024 22:00	0.0	0	0	0	0	1
09/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,829.3 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,305.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	1
09/27/2024 01:00	39.7	0	0	0	1	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	1,751.7	0	1	0	0	0
09/27/2024 10:00	5,015.3	0	1	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	1
09/27/2024 12:00	0.0	0	0	0	0	1
09/27/2024 13:00	0.0	0	0	0	0	1
09/27/2024 14:00	0.0	0	0	0	0	1
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,806.7 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,015.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	49.1	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	5,147.2	0	0	1	0	0
09/28/2024 16:00	0.0	0	0	0	0	1
09/28/2024 17:00	0.0	0	0	0	0	1
09/28/2024 18:00	0.0	0	0	0	0	1
09/28/2024 19:00	0.0	0	0	0	0	1
09/28/2024 20:00	0.0	0	0	0	0	1
09/28/2024 21:00	0.0	0	0	0	0	1
09/28/2024 22:00	0.0	0	0	0	0	1
09/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,196.3 #	0 #	0 #	1 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,147.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	1
09/29/2024 01:00	0.0	0	0	0	0	1
09/29/2024 02:00	16.2	0	0	0	1	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	1,343.1	0	1	0	0	0
09/29/2024 11:00	5,632.1	0	1	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	1
09/29/2024 13:00	0.0	0	0	0	0	1
09/29/2024 14:00	0.0	0	0	0	0	1
09/29/2024 15:00	0.0	0	0	0	0	1
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,991.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,632.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	0.7	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	23.6	0	1	0	0	0
07/01/2024 09:00	29.3	0	1	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	1
07/01/2024 11:00	0.0	0	0	0	0	1
07/01/2024 12:00	0.0	0	0	0	0	1
07/01/2024 13:00	0.0	0	0	0	0	1
07/01/2024 14:00	0.0	0	0	0	0	1
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	1.1	0	0	0	1	0
Average/Sum#:	54.7 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	34.0	0	1	0	0	0
07/02/2024 11:00	33.9	0	1	0	0	0
07/02/2024 12:00	26.3	0	1	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	1
07/02/2024 14:00	0.0	0	0	0	0	1
07/02/2024 15:00	0.0	0	0	0	0	1
07/02/2024 16:00	0.0	0	0	0	0	1
07/02/2024 17:00	0.0	0	0	0	0	1
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	94.2 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	0.9	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	14.4	0	0	1	0	0
07/04/2024 10:00	17.3	0	0	1	0	0
07/04/2024 11:00	0.0	0	0	0	0	1
07/04/2024 12:00	0.0	0	0	0	0	1
07/04/2024 13:00	0.0	0	0	0	0	1
07/04/2024 14:00	0.0	0	0	0	0	1
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	0.6	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	0.0	0	0	1	0	0
07/06/2024 10:00	13.8	0	0	1	0	0
07/06/2024 11:00	0.0	0	0	0	0	1
07/06/2024 12:00	0.0	0	0	0	0	1
07/06/2024 13:00	0.0	0	0	0	0	1
07/06/2024 14:00	0.0	0	0	0	0	1
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	14.4 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	13.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	0.7	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	0.0	0	0	0	0	0
07/07/2024 12:00	0.0	0	0	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	0
07/07/2024 14:00	0.0	0	0	0	0	0
07/07/2024 15:00	9.6	0	1	0	0	0
07/07/2024 16:00	39.8	0	1	0	0	0
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.1 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	0.7	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	17.8	0	1	0	0	0
07/14/2024 11:00	35.8	0	1	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	1
07/14/2024 13:00	0.0	0	0	0	0	1
07/14/2024 14:00	0.0	0	0	0	0	1
07/14/2024 15:00	0.0	0	0	0	0	1
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	1.2	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	1.7	0	0	1	0	0
07/21/2024 11:00	20.1	0	0	1	0	0
07/21/2024 12:00	0.0	0	0	0	0	1
07/21/2024 13:00	0.0	0	0	0	0	1
07/21/2024 14:00	0.0	0	0	0	0	1
07/21/2024 15:00	0.0	0	0	0	0	1
07/21/2024 16:00	0.0	0	0	0	0	1
07/21/2024 17:00	0.0	0	0	0	0	1
07/21/2024 18:00	0.0	0	0	0	0	1
07/21/2024 19:00	0.0	0	0	0	0	1
07/21/2024 20:00	0.0	0	0	0	0	1
07/21/2024 21:00	0.0	0	0	0	0	1
07/21/2024 22:00	0.0	0	0	0	0	1
07/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	23.0 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	1
07/22/2024 01:00	0.0	0	0	0	0	1
07/22/2024 02:00	0.0	0	0	0	0	1
07/22/2024 03:00	0.0	0	0	0	0	1
07/22/2024 04:00	0.0	0	0	0	0	1
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	0.9	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	0.1	0	0	1	0	0
07/27/2024 12:00	19.5	0	0	1	0	0
07/27/2024 13:00	0.0	0	0	0	0	1
07/27/2024 14:00	0.0	0	0	0	0	1
07/27/2024 15:00	0.0	0	0	0	0	1
07/27/2024 16:00	0.0	0	0	0	0	1
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	20.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	0.8	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	0.0	0	0	0	0	0
07/28/2024 15:00	0.0	0	0	0	0	0
07/28/2024 16:00	0.0	0	0	0	0	0
07/28/2024 17:00	0.0	0	0	0	0	0
07/28/2024 18:00	0.0	0	0	0	0	0
07/28/2024 19:00	0.0	0	0	0	0	0
07/28/2024 20:00	0.0	0	0	0	0	0
07/28/2024 21:00	0.0	0	0	0	0	0
07/28/2024 22:00	0.0	0	0	0	0	0
07/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	0
07/29/2024 01:00	0.0	0	0	0	0	0
07/29/2024 02:00	0.0	0	0	0	0	0
07/29/2024 03:00	0.0	0	0	0	0	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	37.7	0	1	0	0	0
07/29/2024 11:00	21.8	0	1	0	0	0
07/29/2024 12:00	18.5	0	1	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	1
07/29/2024 14:00	0.0	0	0	0	0	1
07/29/2024 15:00	0.0	0	0	0	0	1
07/29/2024 16:00	0.0	0	0	0	0	1
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	1.3	0	0	0	1	0
Average/Sum#:	79.3 #	0 #	3 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	37.5	0	1	0	0	0
07/30/2024 11:00	16.0	0	1	0	0	0
07/30/2024 12:00	37.1	0	1	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	1
07/30/2024 14:00	0.0	0	0	0	0	1
07/30/2024 15:00	0.0	0	0	0	0	1
07/30/2024 16:00	0.0	0	0	0	0	1
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	90.6 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	0.7	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	0.0	0	0	0	0	0
08/10/2024 14:00	0.0	0	0	0	0	0
08/10/2024 15:00	0.0	0	0	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	0
08/10/2024 17:00	0.0	0	0	0	0	0
08/10/2024 18:00	0.0	0	0	0	0	0
08/10/2024 19:00	0.0	0	0	0	0	0
08/10/2024 20:00	0.0	0	0	0	0	0
08/10/2024 21:00	0.0	0	0	0	0	0
08/10/2024 22:00	0.0	0	0	0	0	0
08/10/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	42.2	0	1	0	0	0
08/12/2024 14:00	31.0	0	1	0	0	0
08/12/2024 15:00	14.8	0	1	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	1
08/12/2024 17:00	0.0	0	0	0	0	1
08/12/2024 18:00	0.0	0	0	0	0	1
08/12/2024 19:00	0.0	0	0	0	0	1
08/12/2024 20:00	0.0	0	0	0	0	1
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.0 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	1.2	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	0.0	0	0	0	0	0
08/13/2024 17:00	0.0	0	0	0	0	0
08/13/2024 18:00	0.0	0	0	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	0
08/13/2024 20:00	0.0	0	0	0	0	0
08/13/2024 21:00	0.0	0	0	0	0	0
08/13/2024 22:00	0.0	0	0	0	0	0
08/13/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	0
08/14/2024 01:00	0.0	0	0	0	0	0
08/14/2024 02:00	0.0	0	0	0	0	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	0.0	0	0	0	0	0
08/14/2024 11:00	0.0	0	0	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	0
08/14/2024 13:00	0.0	0	0	0	0	0
08/14/2024 14:00	0.0	0	0	0	0	0
08/14/2024 15:00	0.0	0	0	0	0	0
08/14/2024 16:00	0.0	0	0	0	0	0
08/14/2024 17:00	0.0	0	0	0	0	0
08/14/2024 18:00	0.0	0	0	0	0	0
08/14/2024 19:00	0.0	0	0	0	0	0
08/14/2024 20:00	0.0	0	0	0	0	0
08/14/2024 21:00	0.0	0	0	0	0	0
08/14/2024 22:00	0.0	0	0	0	0	0
08/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	0.0	0	0	0	0	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	0.0	0	0	0	0	0
08/15/2024 13:00	0.0	0	0	0	0	0
08/15/2024 14:00	0.0	0	0	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	0
08/15/2024 16:00	0.0	0	0	0	0	0
08/15/2024 17:00	63.2	0	1	0	0	0
08/15/2024 18:00	10.6	0	1	0	0	0
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	73.8 #	0 #	2 #	0 #	0 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	0.8	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	2.7	0	0	1	0	0
08/16/2024 09:00	31.2	0	0	1	0	0
08/16/2024 10:00	0.0	0	0	0	0	1
08/16/2024 11:00	0.0	0	0	0	0	1
08/16/2024 12:00	0.0	0	0	0	0	1
08/16/2024 13:00	0.0	0	0	0	0	1
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	34.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	0.9	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	0.0	0	0	0	0	0
08/17/2024 15:00	0.0	0	0	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	0
08/17/2024 17:00	0.0	0	0	0	0	0
08/17/2024 18:00	0.0	0	0	0	0	0
08/17/2024 19:00	0.0	0	0	0	0	0
08/17/2024 20:00	0.0	0	0	0	0	0
08/17/2024 21:00	0.0	0	0	0	0	0
08/17/2024 22:00	0.0	0	0	0	0	0
08/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	0
08/18/2024 01:00	0.0	0	0	0	0	0
08/18/2024 02:00	0.0	0	0	0	0	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	43.7	0	1	0	0	0
08/18/2024 10:00	15.9	0	1	0	0	0
08/18/2024 11:00	31.2	0	1	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	1
08/18/2024 13:00	0.0	0	0	0	0	1
08/18/2024 14:00	0.0	0	0	0	0	1
08/18/2024 15:00	0.0	0	0	0	0	1
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	90.8 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	0.6	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	0.0	0	0	0	0	0
08/19/2024 08:00	0.0	0	0	0	0	0
08/19/2024 09:00	0.0	0	0	0	0	0
08/19/2024 10:00	0.0	0	0	0	0	0
08/19/2024 11:00	0.0	0	0	0	0	0
08/19/2024 12:00	38.8	0	1	0	0	0
08/19/2024 13:00	33.4	0	1	0	0	0
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	72.8 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	0.9	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	21.7	0	1	0	0	0
08/20/2024 10:00	35.8	0	1	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	1
08/20/2024 12:00	0.0	0	0	0	0	1
08/20/2024 13:00	0.0	0	0	0	0	1
08/20/2024 14:00	0.0	0	0	0	0	1
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	1.0	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	31.6	0	1	0	0	0
08/22/2024 15:00	26.6	0	1	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	1
08/22/2024 17:00	0.0	0	0	0	0	1
08/22/2024 18:00	0.0	0	0	0	0	1
08/22/2024 19:00	0.0	0	0	0	0	1
08/22/2024 20:00	0.0	0	0	0	0	1
08/22/2024 21:00	0.0	0	0	0	0	1
08/22/2024 22:00	0.0	0	0	0	0	1
08/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	1
08/23/2024 01:00	0.0	0	0	0	0	1
08/23/2024 02:00	0.0	0	0	0	0	1
08/23/2024 03:00	0.0	0	0	0	0	1
08/23/2024 04:00	0.0	0	0	0	0	1
08/23/2024 05:00	0.0	0	0	0	0	1
08/23/2024 06:00	0.0	0	0	0	0	1
08/23/2024 07:00	0.9	0	0	0	1	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	54.4	0	1	0	0	0
08/25/2024 14:00	75.5	0	1	0	0	0
08/25/2024 15:00	21.3	0	1	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	1
08/25/2024 17:00	0.0	0	0	0	0	1
08/25/2024 18:00	0.0	0	0	0	0	1
08/25/2024 19:00	0.0	0	0	0	0	1
08/25/2024 20:00	0.0	0	0	0	0	1
08/25/2024 21:00	0.0	0	0	0	0	1
08/25/2024 22:00	0.0	0	0	0	0	1
08/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	151.2 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	0.0	0	0	0	0	1
08/26/2024 01:00	0.0	0	0	0	0	1
08/26/2024 02:00	0.0	0	0	0	0	1
08/26/2024 03:00	0.0	0	0	0	0	1
08/26/2024 04:00	0.0	0	0	0	0	1
08/26/2024 05:00	0.0	0	0	0	0	1
08/26/2024 06:00	0.0	0	0	0	0	1
08/26/2024 07:00	0.0	0	0	0	0	1
08/26/2024 08:00	0.0	0	0	0	0	1
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	0.8	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	0.0	0	0	0	0	0
08/31/2024 11:00	0.0	0	0	0	0	0
08/31/2024 12:00	0.0	0	0	0	0	0
08/31/2024 13:00	0.0	0	0	0	0	0
08/31/2024 14:00	17.4	0	1	0	0	0
08/31/2024 15:00	18.2	0	1	0	0	0
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	36.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	0.8	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	0.1	0	0	1	0	0
09/01/2024 11:00	24.3	0	0	1	0	0
09/01/2024 12:00	0.0	0	0	0	0	1
09/01/2024 13:00	0.0	0	0	0	0	1
09/01/2024 14:00	0.0	0	0	0	0	1
09/01/2024 15:00	0.0	0	0	0	0	1
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	25.2 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	1.1	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	2.0	0	0	1	0	0
09/02/2024 11:00	11.2	0	0	1	0	0
09/02/2024 12:00	0.0	0	0	0	0	1
09/02/2024 13:00	0.0	0	0	0	0	1
09/02/2024 14:00	0.0	0	0	0	0	1
09/02/2024 15:00	0.0	0	0	0	0	1
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	14.3 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	1.0	0	0	0	1	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	49.1	0	1	0	0	0
09/12/2024 18:00	36.9	0	1	0	0	0
09/12/2024 19:00	43.2	0	1	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	1
09/12/2024 21:00	0.0	0	0	0	0	1
09/12/2024 22:00	0.0	0	0	0	0	1
09/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	129.2 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	1
09/13/2024 01:00	0.0	0	0	0	0	1
09/13/2024 02:00	0.0	0	0	0	0	1
09/13/2024 03:00	0.0	0	0	0	0	1
09/13/2024 04:00	0.0	0	0	0	0	1
09/13/2024 05:00	0.0	0	0	0	0	1
09/13/2024 06:00	0.0	0	0	0	0	1
09/13/2024 07:00	1.0	0	0	0	1	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	24.0	0	0	1	0	0
09/13/2024 14:00	32.8	0	0	1	0	0
09/13/2024 15:00	0.0	0	0	0	0	1
09/13/2024 16:00	0.0	0	0	0	0	1
09/13/2024 17:00	0.0	0	0	0	0	1
09/13/2024 18:00	0.0	0	0	0	0	1
09/13/2024 19:00	0.0	0	0	0	0	1
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.8 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	0.9	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	51.5	0	1	0	0	0
09/14/2024 17:00	26.6	0	1	0	0	0
09/14/2024 18:00	12.3	0	1	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	1
09/14/2024 20:00	0.0	0	0	0	0	1
09/14/2024 21:00	0.0	0	0	0	0	1
09/14/2024 22:00	0.0	0	0	0	0	1
09/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.3 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	1
09/15/2024 01:00	0.7	0	0	0	1	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	42.0	0	1	0	0	0
09/15/2024 18:00	45.7	0	1	0	0	0
09/15/2024 19:00	29.0	0	1	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	1
09/15/2024 21:00	0.0	0	0	0	0	1
09/15/2024 22:00	0.0	0	0	0	0	1
09/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	117.4 #	0 #	3 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	1
09/16/2024 01:00	0.0	0	0	0	0	1
09/16/2024 02:00	0.0	0	0	0	0	1
09/16/2024 03:00	0.0	0	0	0	0	1
09/16/2024 04:00	0.0	0	0	0	0	1
09/16/2024 05:00	0.0	0	0	0	0	1
09/16/2024 06:00	0.0	0	0	0	0	1
09/16/2024 07:00	0.8	0	0	0	1	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	54.6	0	1	0	0	0
09/17/2024 21:00	17.9	0	1	0	0	0
09/17/2024 22:00	28.9	0	1	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	101.4 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	1
09/18/2024 01:00	0.0	0	0	0	0	1
09/18/2024 02:00	0.0	0	0	0	0	1
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	1.1	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	0.0	0	0	0	0	0
09/21/2024 21:00	0.0	0	0	0	0	0
09/21/2024 22:00	0.0	0	0	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	0
09/22/2024 01:00	0.0	0	0	0	0	0
09/22/2024 02:00	0.0	0	0	0	0	0
09/22/2024 03:00	0.0	0	0	0	0	0
09/22/2024 04:00	0.0	0	0	0	0	0
09/22/2024 05:00	0.0	0	0	0	0	0
09/22/2024 06:00	0.0	0	0	0	0	0
09/22/2024 07:00	0.0	0	0	0	0	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	0.0	0	0	0	0	0
09/22/2024 11:00	0.0	0	0	0	0	0
09/22/2024 12:00	0.0	0	0	0	0	0
09/22/2024 13:00	0.0	0	0	0	0	0
09/22/2024 14:00	59.2	1	0	0	0	0
09/22/2024 15:00	35.5	1	0	0	0	0
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	94.7 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.2	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	1.0	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	4.0	0	0	1	0	0
09/25/2024 15:00	25.5	0	0	1	0	0
09/25/2024 16:00	0.0	0	0	0	0	1
09/25/2024 17:00	0.0	0	0	0	0	1
09/25/2024 18:00	0.0	0	0	0	0	1
09/25/2024 19:00	0.0	0	0	0	0	1
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.5 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	1.1	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	7.2	0	0	1	0	0
09/26/2024 15:00	29.3	0	0	1	0	0
09/26/2024 16:00	0.0	0	0	0	0	1
09/26/2024 17:00	0.0	0	0	0	0	1
09/26/2024 18:00	0.0	0	0	0	0	1
09/26/2024 19:00	0.0	0	0	0	0	1
09/26/2024 20:00	0.0	0	0	0	0	1
09/26/2024 21:00	0.0	0	0	0	0	1
09/26/2024 22:00	0.0	0	0	0	0	1
09/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	37.6 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	1
09/27/2024 01:00	0.6	0	0	0	1	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	32.7	0	1	0	0	0
09/27/2024 10:00	36.6	0	1	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	1
09/27/2024 12:00	0.0	0	0	0	0	1
09/27/2024 13:00	0.0	0	0	0	0	1
09/27/2024 14:00	0.0	0	0	0	0	1
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	69.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	1.6	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	42.9	0	0	1	0	0
09/28/2024 16:00	0.0	0	0	0	0	1
09/28/2024 17:00	0.0	0	0	0	0	1
09/28/2024 18:00	0.0	0	0	0	0	1
09/28/2024 19:00	0.0	0	0	0	0	1
09/28/2024 20:00	0.0	0	0	0	0	1
09/28/2024 21:00	0.0	0	0	0	0	1
09/28/2024 22:00	0.0	0	0	0	0	1
09/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.5 #	0 #	0 #	1 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	1
09/29/2024 01:00	0.0	0	0	0	0	1
09/29/2024 02:00	0.9	0	0	0	1	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	25.0	0	1	0	0	0
09/29/2024 11:00	45.8	0	1	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	1
09/29/2024 13:00	0.0	0	0	0	0	1
09/29/2024 14:00	0.0	0	0	0	0	1
09/29/2024 15:00	0.0	0	0	0	0	1
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	71.7 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/01/2024 00:08 07/01/2024 00:13 Shut Down - Gas	6	2.5	483.5		
07/01/2024 08:24 07/01/2024 09:54 Warm Start - Gas	91	61.0	790.5		
07/01/2024 23:09 07/01/2024 23:15 Shut Down - Gas	7	0.9	483.5		
07/02/2024 10:30 07/02/2024 12:42 Warm Start - Gas	133	61.5	790.5		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.7	483.5		
07/04/2024 09:28 07/04/2024 10:40 Hot Start - Gas	73	67.6	679.6		
07/06/2024 06:09 07/06/2024 06:14 Shut Down - Gas	6	0.8	483.5		
07/06/2024 09:48 07/06/2024 10:47 Hot Start - Gas	60	41.4	679.6		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.9	483.5		
07/07/2024 15:41 07/07/2024 16:56 Warm Start - Gas	76	74.0	790.5		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	0.9	483.5		
07/14/2024 10:33 07/14/2024 11:51 Warm Start - Gas	79	65.4	790.5		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/21/2024 10:29 07/21/2024 11:43 Hot Start - Gas	75	86.9	679.6		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	1.0	483.5		
07/27/2024 11:49 07/27/2024 12:44 Hot Start - Gas	56	73.6	679.6		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	1.6	483.5		
07/29/2024 10:22 07/29/2024 12:33 Warm Start - Gas	132	136.5	790.5		
07/29/2024 23:09 07/29/2024 23:14 Shut Down - Gas	6	1.1	483.5		
07/30/2024 10:18 07/30/2024 12:50 Warm Start - Gas	153	140.4	790.5		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.6	483.5		
08/12/2024 13:17 08/12/2024 15:41 Warm Start - Gas	145	99.8	790.5		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	0.9	483.5		
08/15/2024 17:03 08/15/2024 18:28 Warm Start - Gas	86	69.0	790.5		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.4	483.5		
08/16/2024 08:31 08/16/2024 09:48 Hot Start - Gas	78	68.8	679.6		
08/17/2024 06:25 08/17/2024 06:30 Shut Down - Gas	6	1.1	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/18/2024 09:15 08/18/2024 11:40 Warm Start - Gas	146	124.6	790.5		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	1.0	483.5		
08/19/2024 12:13 08/19/2024 13:39 Warm Start - Gas	87	75.9	790.5		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	1.4	483.5		
08/20/2024 09:21 08/20/2024 10:46 Warm Start - Gas	86	89.7	790.5		
08/22/2024 06:10 08/22/2024 06:14 Shut Down - Gas	5	0.3	483.5		
08/22/2024 14:20 08/22/2024 15:47 Warm Start - Gas	88	56.1	790.5		
08/23/2024 07:05 08/23/2024 07:09 Shut Down - Gas	5	0.5	483.5		
08/25/2024 13:18 08/25/2024 15:33 Warm Start - Gas	136	150.3	790.5		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	1.1	483.5		
08/31/2024 14:33 08/31/2024 15:39 Warm Start - Gas	67	51.6	790.5		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	1.1	483.5		
09/01/2024 10:48 09/01/2024 11:55 Hot Start - Gas	68	59.5	679.6		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/02/2024 10:38 09/02/2024 11:27 Hot Start - Gas	50	69.8	679.6		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	1.0	483.5		
09/12/2024 17:18 09/12/2024 19:52 Warm Start - Gas	155	101.0	790.5		
09/13/2024 07:38 09/13/2024 07:43 Shut Down - Gas	6	0.3	483.5		
09/13/2024 13:31 09/13/2024 14:50 Hot Start - Gas	80	42.5	679.6		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.9	483.5		
09/14/2024 16:06 09/14/2024 18:29 Warm Start - Gas	144	193.4	790.5		
09/15/2024 01:10 09/15/2024 01:15 Shut Down - Gas	6	2.7	483.5		
09/15/2024 17:17 09/15/2024 19:38 Warm Start - Gas	142	286.6	790.5		
09/16/2024 07:38 09/16/2024 07:43 Shut Down - Gas	6	1.5	483.5		
09/17/2024 20:05 09/17/2024 22:48 Warm Start - Gas	164	133.9	790.5		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	1.1	483.5		
09/22/2024 14:13 09/22/2024 15:44 Cold Start - Gas	92	69.3	1,355.6		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/25/2024 14:44 09/25/2024 15:50 Hot Start - Gas	67	42.9	679.6		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	1.0	483.5		
09/26/2024 14:31 09/26/2024 15:44 Hot Start - Gas	74	42.1	679.6		
09/27/2024 01:10 09/27/2024 01:15 Shut Down - Gas	6	1.0	483.5		
09/27/2024 09:26 09/27/2024 10:45 Warm Start - Gas	80	48.3	790.5		
09/28/2024 07:09 09/28/2024 07:14 Shut Down - Gas	6	1.1	483.5		
09/28/2024 15:01 09/28/2024 15:54 Hot Start - Gas	54	26.1	679.6		
09/29/2024 02:10 09/29/2024 02:15 Shut Down - Gas	6	0.3	483.5		
09/29/2024 10:33 09/29/2024 11:48 Warm Start - Gas	76	62.8	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:04 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours
Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/01/2024 00:08 07/01/2024 00:13 Shut Down - Gas	6	0.24	115.00		
07/01/2024 08:24 07/01/2024 09:54 Warm Start - Gas	91	55.40	456.20		
07/01/2024 23:09 07/01/2024 23:15 Shut Down - Gas	7	0.25	115.00		
07/02/2024 10:30 07/02/2024 12:42 Warm Start - Gas	133	102.22	456.20		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.12	115.00		
07/04/2024 09:28 07/04/2024 10:40 Hot Start - Gas	73	36.81	259.90		
07/06/2024 06:09 07/06/2024 06:14 Shut Down - Gas	6	0.09	115.00		
07/06/2024 09:48 07/06/2024 10:47 Hot Start - Gas	60	16.26	259.90		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.08	115.00		
07/07/2024 15:41 07/07/2024 16:56 Warm Start - Gas	76	47.66	456.20		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	0.12	115.00		
07/14/2024 10:33 07/14/2024 11:51 Warm Start - Gas	79	55.75	456.20		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	0.21	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/21/2024 10:29 07/21/2024 11:43 Hot Start - Gas	75	23.78	259.90		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	0.16	115.00		
07/27/2024 11:49 07/27/2024 12:44 Hot Start - Gas	56	23.54	259.90		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	0.17	115.00		
07/29/2024 10:22 07/29/2024 12:33 Warm Start - Gas	132	87.60	456.20		
07/29/2024 23:09 07/29/2024 23:14 Shut Down - Gas	6	0.11	115.00		
07/30/2024 10:18 07/30/2024 12:50 Warm Start - Gas	153	94.76	456.20		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.07	115.00		
08/12/2024 13:17 08/12/2024 15:41 Warm Start - Gas	145	91.26	456.20		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	0.22	115.00		
08/15/2024 17:03 08/15/2024 18:28 Warm Start - Gas	86	81.21	456.20		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.06	115.00		
08/16/2024 08:31 08/16/2024 09:48 Hot Start - Gas	78	36.71	259.90		
08/17/2024 06:25 08/17/2024 06:30 Shut Down - Gas	6	0.25	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/18/2024 09:15 08/18/2024 11:40 Warm Start - Gas	146	99.55	456.20		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	0.11	115.00		
08/19/2024 12:13 08/19/2024 13:39 Warm Start - Gas	87	82.55	456.20		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	0.28	115.00		
08/20/2024 09:21 08/20/2024 10:46 Warm Start - Gas	86	62.83	456.20		
08/22/2024 06:10 08/22/2024 06:14 Shut Down - Gas	5	0.08	115.00		
08/22/2024 14:20 08/22/2024 15:47 Warm Start - Gas	88	62.15	456.20		
08/23/2024 07:05 08/23/2024 07:09 Shut Down - Gas	5	0.11	115.00		
08/25/2024 13:18 08/25/2024 15:33 Warm Start - Gas	136	157.96	456.20		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	0.16	115.00		
08/31/2024 14:33 08/31/2024 15:39 Warm Start - Gas	67	40.04	456.20		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	0.11	115.00		
09/01/2024 10:48 09/01/2024 11:55 Hot Start - Gas	68	25.29	259.90		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	0.22	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/02/2024 10:38 09/02/2024 11:27 Hot Start - Gas	50	20.53	259.90		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	0.20	115.00		
09/12/2024 17:18 09/12/2024 19:52 Warm Start - Gas	155	132.19	456.20		
09/13/2024 07:38 09/13/2024 07:43 Shut Down - Gas	6	0.07	115.00		
09/13/2024 13:31 09/13/2024 14:50 Hot Start - Gas	80	59.46	259.90		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.13	115.00		
09/14/2024 16:06 09/14/2024 18:29 Warm Start - Gas	144	96.47	456.20		
09/15/2024 01:10 09/15/2024 01:15 Shut Down - Gas	6	0.12	115.00		
09/15/2024 17:17 09/15/2024 19:38 Warm Start - Gas	142	123.90	456.20		
09/16/2024 07:38 09/16/2024 07:43 Shut Down - Gas	6	0.15	115.00		
09/17/2024 20:05 09/17/2024 22:48 Warm Start - Gas	164	103.11	456.20		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	0.24	115.00		
09/22/2024 14:13 09/22/2024 15:44 Cold Start - Gas	92	102.00	779.10		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	0.21	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/25/2024 14:44 09/25/2024 15:50 Hot Start - Gas	67	29.90	259.90		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	0.20	115.00		
09/26/2024 14:31 09/26/2024 15:44 Hot Start - Gas	74	40.45	259.90		
09/27/2024 01:10 09/27/2024 01:15 Shut Down - Gas	6	0.09	115.00		
09/27/2024 09:26 09/27/2024 10:45 Warm Start - Gas	80	74.09	456.20		
09/28/2024 07:09 09/28/2024 07:14 Shut Down - Gas	6	0.20	115.00		
09/28/2024 15:01 09/28/2024 15:54 Hot Start - Gas	54	39.83	259.90		
09/29/2024 02:10 09/29/2024 02:15 Shut Down - Gas	6	0.04	115.00		
09/29/2024 10:33 09/29/2024 11:48 Warm Start - Gas	76	71.86	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/01/2024 00:11 07/01/2024 00:16 Shut Down - Gas	6	0.9		
07/01/2024 13:23 07/01/2024 14:46 Warm Start - Gas	84	129.8		
07/01/2024 23:11 07/01/2024 23:17 Shut Down - Gas	7	1.2		
07/02/2024 15:46 07/02/2024 17:06 Warm Start - Gas	81	137.4		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.6		
07/04/2024 13:35 07/04/2024 14:47 Warm Start - Gas	73	111.8		
07/06/2024 06:11 07/06/2024 06:16 Shut Down - Gas	6	0.6		
07/06/2024 13:54 07/06/2024 14:47 Hot Start - Gas	54	90.4		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.4		
07/07/2024 11:56 07/07/2024 12:54 Warm Start - Gas	59	95.2		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	1.0		
07/14/2024 14:31 07/14/2024 15:26 Warm Start - Gas	56	95.2		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	1.1		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/21/2024 23:31 07/21/2024 23:31 Warm Start - Gas	1	0.0		
07/21/2024 23:32 07/21/2024 23:32 Shut Down - Gas	1	0.0		
07/22/2024 03:08 07/22/2024 04:13 Warm Start - Gas	66	108.3		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	0.7		
07/27/2024 15:34 07/27/2024 16:39 Warm Start - Gas	66	115.2		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	0.8		
07/28/2024 14:31 07/28/2024 15:26 Hot Start - Gas	56	105.5		
07/29/2024 03:08 07/29/2024 03:13 Shut Down - Gas	6	0.9		
07/29/2024 14:59 07/29/2024 16:22 Warm Start - Gas	84	131.9		
07/29/2024 23:11 07/29/2024 23:16 Shut Down - Gas	6	0.4		
07/30/2024 15:08 07/30/2024 16:27 Warm Start - Gas	80	136.6		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.5		
08/10/2024 13:18 08/10/2024 15:42 Warm Start - Gas	145	195.9		
08/10/2024 23:09 08/10/2024 23:14 Shut Down - Gas	6	0.5		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/12/2024 18:23 08/12/2024 20:11 Warm Start - Gas	109	166.4		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	0.9		
08/13/2024 16:14 08/13/2024 18:46 Warm Start - Gas	153	203.6		
08/14/2024 02:21 08/14/2024 02:26 Shut Down - Gas	6	0.5		
08/14/2024 10:32 08/14/2024 11:49 Warm Start - Gas	78	115.1		
08/15/2024 00:22 08/15/2024 00:27 Shut Down - Gas	6	0.8		
08/15/2024 12:18 08/15/2024 14:48 Warm Start - Gas	151	206.1		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.4		
08/16/2024 12:04 08/16/2024 13:31 Warm Start - Gas	88	144.6		
08/17/2024 06:25 08/17/2024 06:31 Shut Down - Gas	7	1.3		
08/17/2024 14:49 08/17/2024 15:56 Warm Start - Gas	68	113.6		
08/18/2024 02:08 08/18/2024 02:13 Shut Down - Gas	6	0.7		
08/18/2024 14:26 08/18/2024 15:40 Warm Start - Gas	75	119.1		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	0.6		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/19/2024 07:13 08/19/2024 08:02 Hot Start - Gas	50	83.0		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	1.4		
08/20/2024 13:05 08/20/2024 14:40 Warm Start - Gas	96	151.3		
08/22/2024 06:10 08/22/2024 06:15 Shut Down - Gas	6	0.5		
08/26/2024 00:10 08/26/2024 00:23 Cold Start - Gas	14	5.9		
08/26/2024 00:24 08/26/2024 00:29 Shut Down - Gas	6	0.5		
08/26/2024 07:13 08/26/2024 08:32 Cold Start - Gas	80	127.1		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	0.8		
08/31/2024 10:48 08/31/2024 11:52 Hot Start - Gas	65	104.9		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	0.6		
09/01/2024 14:35 09/01/2024 15:36 Warm Start - Gas	62	98.0		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	0.8		
09/02/2024 14:33 09/02/2024 15:29 Hot Start - Gas	57	103.9		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	0.8		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:06 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,516.23 Hours
Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
09/13/2024 18:25 09/13/2024 19:47 Warm Start - Gas	83	128.6		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.8		
09/18/2024 01:13 09/18/2024 02:46 Cold Start - Gas	94	136.7		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	1.1		
09/21/2024 20:23 09/21/2024 22:43 Warm Start - Gas	141	186.3		
09/22/2024 07:08 09/22/2024 07:13 Shut Down - Gas	6	1.3		
09/22/2024 10:34 09/22/2024 11:36 Hot Start - Gas	63	114.1		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	1.0		
09/25/2024 18:55 09/25/2024 19:54 Warm Start - Gas	60	101.8		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	0.8		
09/27/2024 13:32 09/27/2024 14:36 Warm Start - Gas	65	99.7		
09/28/2024 07:10 09/28/2024 07:15 Shut Down - Gas	6	1.2		
09/29/2024 14:32 09/29/2024 15:27 Warm Start - Gas	56	83.1		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:06 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	3.5	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	0.0	0	0	0	0	0
07/01/2024 09:00	0.0	0	0	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	0
07/01/2024 11:00	0.0	0	0	0	0	0
07/01/2024 12:00	0.0	0	0	0	0	0
07/01/2024 13:00	17.7	0	1	0	0	0
07/01/2024 14:00	36.1	0	1	0	0	0
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	1.9	0	0	0	1	0
Average/Sum#:	59.2 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	0.0	0	0	0	0	0
07/02/2024 11:00	0.0	0	0	0	0	0
07/02/2024 12:00	0.0	0	0	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	0
07/02/2024 14:00	0.0	0	0	0	0	0
07/02/2024 15:00	7.8	0	1	0	0	0
07/02/2024 16:00	49.8	0	1	0	0	0
07/02/2024 17:00	0.2	0	1	0	0	0
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.8 #	0 #	3 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	2.5	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	0.0	0	0	0	0	0
07/04/2024 10:00	0.0	0	0	0	0	0
07/04/2024 11:00	0.0	0	0	0	0	0
07/04/2024 12:00	0.0	0	0	0	0	0
07/04/2024 13:00	11.7	0	1	0	0	0
07/04/2024 14:00	40.2	0	1	0	0	0
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.4 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	0.0	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	0.0	0	0	0	0	0
07/06/2024 10:00	0.0	0	0	0	0	0
07/06/2024 11:00	0.0	0	0	0	0	0
07/06/2024 12:00	0.0	0	0	0	0	0
07/06/2024 13:00	0.0	0	0	1	0	0
07/06/2024 14:00	35.6	0	0	1	0	0
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	35.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	3.6	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	0.0	0	1	0	0	0
07/07/2024 12:00	54.5	0	1	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	1
07/07/2024 14:00	0.0	0	0	0	0	1
07/07/2024 15:00	0.0	0	0	0	0	1
07/07/2024 16:00	0.0	0	0	0	0	1
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.1 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	2.3	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	0.0	0	0	0	0	0
07/14/2024 11:00	0.0	0	0	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	0
07/14/2024 13:00	0.0	0	0	0	0	0
07/14/2024 14:00	21.6	0	1	0	0	0
07/14/2024 15:00	20.7	0	1	0	0	0
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.6 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	1.6	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	0.0	0	0	0	0	0
07/21/2024 11:00	0.0	0	0	0	0	0
07/21/2024 12:00	0.0	0	0	0	0	0
07/21/2024 13:00	0.0	0	0	0	0	0
07/21/2024 14:00	0.0	0	0	0	0	0
07/21/2024 15:00	0.0	0	0	0	0	0
07/21/2024 16:00	0.0	0	0	0	0	0
07/21/2024 17:00	0.0	0	0	0	0	0
07/21/2024 18:00	0.0	0	0	0	0	0
07/21/2024 19:00	0.0	0	0	0	0	0
07/21/2024 20:00	0.0	0	0	0	0	0
07/21/2024 21:00	0.0	0	0	0	0	0
07/21/2024 22:00	0.0	0	0	0	0	0
07/21/2024 23:00	0.0	0	1	0	1	0
Average/Sum#:	1.6 #	0 #	1 #	0 #	2 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	0
07/22/2024 01:00	0.0	0	0	0	0	0
07/22/2024 02:00	0.0	0	0	0	0	0
07/22/2024 03:00	81.8	0	1	0	0	0
07/22/2024 04:00	4.1	0	1	0	0	0
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	85.9 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	81.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	0.0	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	0.0	0	0	0	0	0
07/27/2024 12:00	0.0	0	0	0	0	0
07/27/2024 13:00	0.0	0	0	0	0	0
07/27/2024 14:00	0.0	0	0	0	0	0
07/27/2024 15:00	14.0	0	1	0	0	0
07/27/2024 16:00	45.7	0	1	0	0	0
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.7 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	3.6	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	39.8	0	0	1	0	0
07/28/2024 15:00	25.2	0	0	1	0	0
07/28/2024 16:00	0.0	0	0	0	0	1
07/28/2024 17:00	0.0	0	0	0	0	1
07/28/2024 18:00	0.0	0	0	0	0	1
07/28/2024 19:00	0.0	0	0	0	0	1
07/28/2024 20:00	0.0	0	0	0	0	1
07/28/2024 21:00	0.0	0	0	0	0	1
07/28/2024 22:00	0.0	0	0	0	0	1
07/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	1
07/29/2024 01:00	0.0	0	0	0	0	1
07/29/2024 02:00	0.0	0	0	0	0	1
07/29/2024 03:00	4.2	0	0	0	1	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	0.0	0	0	0	0	0
07/29/2024 11:00	0.0	0	0	0	0	0
07/29/2024 12:00	0.0	0	0	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	0
07/29/2024 14:00	0.0	0	1	0	0	0
07/29/2024 15:00	67.2	0	1	0	0	0
07/29/2024 16:00	19.2	0	1	0	0	0
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	3.2	0	0	0	1	0
Average/Sum#:	93.8 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	0.0	0	0	0	0	0
07/30/2024 11:00	0.0	0	0	0	0	0
07/30/2024 12:00	0.0	0	0	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	0
07/30/2024 14:00	0.0	0	0	0	0	0
07/30/2024 15:00	71.3	0	1	0	0	0
07/30/2024 16:00	21.3	0	1	0	0	0
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	92.6 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	2.0	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	41.4	0	1	0	0	0
08/10/2024 14:00	27.5	0	1	0	0	0
08/10/2024 15:00	29.2	0	1	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	1
08/10/2024 17:00	0.0	0	0	0	0	1
08/10/2024 18:00	0.0	0	0	0	0	1
08/10/2024 19:00	0.0	0	0	0	0	1
08/10/2024 20:00	0.0	0	0	0	0	1
08/10/2024 21:00	0.0	0	0	0	0	1
08/10/2024 22:00	0.0	0	0	0	0	1
08/10/2024 23:00	3.3	0	0	0	1	0
Average/Sum#:	101.4 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	0.0	0	0	0	0	0
08/12/2024 14:00	0.0	0	0	0	0	0
08/12/2024 15:00	0.0	0	0	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	0
08/12/2024 17:00	0.0	0	0	0	0	0
08/12/2024 18:00	63.3	0	1	0	0	0
08/12/2024 19:00	68.4	0	1	0	0	0
08/12/2024 20:00	1.7	0	1	0	0	0
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	133.4 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	2.8	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	43.8	0	1	0	0	0
08/13/2024 17:00	29.4	0	1	0	0	0
08/13/2024 18:00	47.2	0	1	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	1
08/13/2024 20:00	0.0	0	0	0	0	1
08/13/2024 21:00	0.0	0	0	0	0	1
08/13/2024 22:00	0.0	0	0	0	0	1
08/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	123.2 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	1
08/14/2024 01:00	0.0	0	0	0	0	1
08/14/2024 02:00	2.2	0	0	0	1	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	23.2	0	1	0	0	0
08/14/2024 11:00	43.2	0	1	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	1
08/14/2024 13:00	0.0	0	0	0	0	1
08/14/2024 14:00	0.0	0	0	0	0	1
08/14/2024 15:00	0.0	0	0	0	0	1
08/14/2024 16:00	0.0	0	0	0	0	1
08/14/2024 17:00	0.0	0	0	0	0	1
08/14/2024 18:00	0.0	0	0	0	0	1
08/14/2024 19:00	0.0	0	0	0	0	1
08/14/2024 20:00	0.0	0	0	0	0	1
08/14/2024 21:00	0.0	0	0	0	0	1
08/14/2024 22:00	0.0	0	0	0	0	1
08/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	2.1	0	0	0	1	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	27.9	0	1	0	0	0
08/15/2024 13:00	25.8	0	1	0	0	0
08/15/2024 14:00	38.7	0	1	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	1
08/15/2024 16:00	0.0	0	0	0	0	1
08/15/2024 17:00	0.0	0	0	0	0	1
08/15/2024 18:00	0.0	0	0	0	0	1
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	94.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	2.4	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	0.0	0	0	0	0	0
08/16/2024 09:00	0.0	0	0	0	0	0
08/16/2024 10:00	0.0	0	0	0	0	0
08/16/2024 11:00	0.0	0	0	0	0	0
08/16/2024 12:00	34.7	0	1	0	0	0
08/16/2024 13:00	24.4	0	1	0	0	0
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	61.5 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	0.0	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	2.3	0	1	0	0	0
08/17/2024 15:00	49.0	0	1	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	1
08/17/2024 17:00	0.0	0	0	0	0	1
08/17/2024 18:00	0.0	0	0	0	0	1
08/17/2024 19:00	0.0	0	0	0	0	1
08/17/2024 20:00	0.0	0	0	0	0	1
08/17/2024 21:00	0.0	0	0	0	0	1
08/17/2024 22:00	0.0	0	0	0	0	1
08/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	51.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	1
08/18/2024 01:00	0.0	0	0	0	0	1
08/18/2024 02:00	2.9	0	0	0	1	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	0.0	0	0	0	0	0
08/18/2024 10:00	0.0	0	0	0	0	0
08/18/2024 11:00	0.0	0	0	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	0
08/18/2024 13:00	0.0	0	0	0	0	0
08/18/2024 14:00	32.3	0	1	0	0	0
08/18/2024 15:00	30.3	0	1	0	0	0
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.5 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	3.0	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	41.2	0	0	1	0	0
08/19/2024 08:00	0.0	0	0	1	0	0
08/19/2024 09:00	0.0	0	0	0	0	1
08/19/2024 10:00	0.0	0	0	0	0	1
08/19/2024 11:00	0.0	0	0	0	0	1
08/19/2024 12:00	0.0	0	0	0	0	1
08/19/2024 13:00	0.0	0	0	0	0	1
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.2 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	3.0	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	0.0	0	0	0	0	0
08/20/2024 10:00	0.0	0	0	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	0
08/20/2024 12:00	0.0	0	0	0	0	0
08/20/2024 13:00	27.6	0	1	0	0	0
08/20/2024 14:00	36.0	0	1	0	0	0
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	66.6 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	0.0	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	0.0	0	0	0	0	0
08/22/2024 15:00	0.0	0	0	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	0
08/22/2024 17:00	0.0	0	0	0	0	0
08/22/2024 18:00	0.0	0	0	0	0	0
08/22/2024 19:00	0.0	0	0	0	0	0
08/22/2024 20:00	0.0	0	0	0	0	0
08/22/2024 21:00	0.0	0	0	0	0	0
08/22/2024 22:00	0.0	0	0	0	0	0
08/22/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	0
08/23/2024 01:00	0.0	0	0	0	0	0
08/23/2024 02:00	0.0	0	0	0	0	0
08/23/2024 03:00	0.0	0	0	0	0	0
08/23/2024 04:00	0.0	0	0	0	0	0
08/23/2024 05:00	0.0	0	0	0	0	0
08/23/2024 06:00	0.0	0	0	0	0	0
08/23/2024 07:00	0.0	0	0	0	0	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	0.0	0	0	0	0	0
08/25/2024 14:00	0.0	0	0	0	0	0
08/25/2024 15:00	0.0	0	0	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	0
08/25/2024 17:00	0.0	0	0	0	0	0
08/25/2024 18:00	0.0	0	0	0	0	0
08/25/2024 19:00	0.0	0	0	0	0	0
08/25/2024 20:00	0.0	0	0	0	0	0
08/25/2024 21:00	0.0	0	0	0	0	0
08/25/2024 22:00	0.0	0	0	0	0	0
08/25/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	13.5	1	0	0	1	0
08/26/2024 01:00	0.0	0	0	0	0	0
08/26/2024 02:00	0.0	0	0	0	0	0
08/26/2024 03:00	0.0	0	0	0	0	0
08/26/2024 04:00	0.0	0	0	0	0	0
08/26/2024 05:00	0.0	0	0	0	0	0
08/26/2024 06:00	0.0	0	0	0	0	0
08/26/2024 07:00	57.5	1	0	0	0	0
08/26/2024 08:00	8.7	1	0	0	0	0
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.7 #	3 #	0 #	0 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	2.3	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	2.1	0	0	1	0	0
08/31/2024 11:00	44.4	0	0	1	0	0
08/31/2024 12:00	0.0	0	0	0	0	1
08/31/2024 13:00	0.0	0	0	0	0	1
08/31/2024 14:00	0.0	0	0	0	0	1
08/31/2024 15:00	0.0	0	0	0	0	1
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	48.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	2.3	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	0.0	0	0	0	0	0
09/01/2024 11:00	0.0	0	0	0	0	0
09/01/2024 12:00	0.0	0	0	0	0	0
09/01/2024 13:00	0.0	0	0	0	0	0
09/01/2024 14:00	12.5	0	1	0	0	0
09/01/2024 15:00	20.5	0	1	0	0	0
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	35.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	2.8	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	0.0	0	0	0	0	0
09/02/2024 11:00	0.0	0	0	0	0	0
09/02/2024 12:00	0.0	0	0	0	0	0
09/02/2024 13:00	0.0	0	0	0	0	0
09/02/2024 14:00	21.9	0	0	1	0	0
09/02/2024 15:00	24.0	0	0	1	0	0
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	48.7 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	2.5	0	0	0	1	0
Average/Sum#:	2.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	0.0	0	0	0	0	0
09/12/2024 18:00	0.0	0	0	0	0	0
09/12/2024 19:00	0.0	0	0	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	0
09/12/2024 21:00	0.0	0	0	0	0	0
09/12/2024 22:00	0.0	0	0	0	0	0
09/12/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	0
09/13/2024 01:00	0.0	0	0	0	0	0
09/13/2024 02:00	0.0	0	0	0	0	0
09/13/2024 03:00	0.0	0	0	0	0	0
09/13/2024 04:00	0.0	0	0	0	0	0
09/13/2024 05:00	0.0	0	0	0	0	0
09/13/2024 06:00	0.0	0	0	0	0	0
09/13/2024 07:00	0.0	0	0	0	0	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	0.0	0	0	0	0	0
09/13/2024 14:00	0.0	0	0	0	0	0
09/13/2024 15:00	0.0	0	0	0	0	0
09/13/2024 16:00	0.0	0	0	0	0	0
09/13/2024 17:00	0.0	0	0	0	0	0
09/13/2024 18:00	54.8	0	1	0	0	0
09/13/2024 19:00	38.8	0	1	0	0	0
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.6 #	0 #	2 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	1.3	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	0.0	0	0	0	0	0
09/14/2024 17:00	0.0	0	0	0	0	0
09/14/2024 18:00	0.0	0	0	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	0
09/14/2024 20:00	0.0	0	0	0	0	0
09/14/2024 21:00	0.0	0	0	0	0	0
09/14/2024 22:00	0.0	0	0	0	0	0
09/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	0
09/15/2024 01:00	0.0	0	0	0	0	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	0.0	0	0	0	0	0
09/15/2024 18:00	0.0	0	0	0	0	0
09/15/2024 19:00	0.0	0	0	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	0
09/15/2024 21:00	0.0	0	0	0	0	0
09/15/2024 22:00	0.0	0	0	0	0	0
09/15/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	0
09/16/2024 01:00	0.0	0	0	0	0	0
09/16/2024 02:00	0.0	0	0	0	0	0
09/16/2024 03:00	0.0	0	0	0	0	0
09/16/2024 04:00	0.0	0	0	0	0	0
09/16/2024 05:00	0.0	0	0	0	0	0
09/16/2024 06:00	0.0	0	0	0	0	0
09/16/2024 07:00	0.0	0	0	0	0	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	0.0	0	0	0	0	0
09/17/2024 21:00	0.0	0	0	0	0	0
09/17/2024 22:00	0.0	0	0	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	0
09/18/2024 01:00	62.6	1	0	0	0	0
09/18/2024 02:00	40.6	1	0	0	0	0
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.2 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	2.3	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	47.1	0	1	0	0	0
09/21/2024 21:00	18.9	0	1	0	0	0
09/21/2024 22:00	27.1	0	1	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.1 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	1
09/22/2024 01:00	0.0	0	0	0	0	1
09/22/2024 02:00	0.0	0	0	0	0	1
09/22/2024 03:00	0.0	0	0	0	0	1
09/22/2024 04:00	0.0	0	0	0	0	1
09/22/2024 05:00	0.0	0	0	0	0	1
09/22/2024 06:00	0.0	0	0	0	0	1
09/22/2024 07:00	2.4	0	0	0	1	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	13.2	0	0	1	0	0
09/22/2024 11:00	29.3	0	0	1	0	0
09/22/2024 12:00	0.0	0	0	0	0	1
09/22/2024 13:00	0.0	0	0	0	0	1
09/22/2024 14:00	0.0	0	0	0	0	1
09/22/2024 15:00	0.0	0	0	0	0	1
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	2.3	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	0.0	0	0	0	0	0
09/25/2024 15:00	0.0	0	0	0	0	0
09/25/2024 16:00	0.0	0	0	0	0	0
09/25/2024 17:00	0.0	0	0	0	0	0
09/25/2024 18:00	0.0	0	1	0	0	0
09/25/2024 19:00	56.9	0	1	0	0	0
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.2 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	2.7	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	0.0	0	0	0	0	0
09/26/2024 15:00	0.0	0	0	0	0	0
09/26/2024 16:00	0.0	0	0	0	0	0
09/26/2024 17:00	0.0	0	0	0	0	0
09/26/2024 18:00	0.0	0	0	0	0	0
09/26/2024 19:00	0.0	0	0	0	0	0
09/26/2024 20:00	0.0	0	0	0	0	0
09/26/2024 21:00	0.0	0	0	0	0	0
09/26/2024 22:00	0.0	0	0	0	0	0
09/26/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.7 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	0
09/27/2024 01:00	0.0	0	0	0	0	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	0.0	0	0	0	0	0
09/27/2024 10:00	0.0	0	0	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	0
09/27/2024 12:00	0.0	0	0	0	0	0
09/27/2024 13:00	27.4	0	1	0	0	0
09/27/2024 14:00	19.5	0	1	0	0	0
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.9 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	2.2	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	0.0	0	0	0	0	0
09/28/2024 16:00	0.0	0	0	0	0	0
09/28/2024 17:00	0.0	0	0	0	0	0
09/28/2024 18:00	0.0	0	0	0	0	0
09/28/2024 19:00	0.0	0	0	0	0	0
09/28/2024 20:00	0.0	0	0	0	0	0
09/28/2024 21:00	0.0	0	0	0	0	0
09/28/2024 22:00	0.0	0	0	0	0	0
09/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	0
09/29/2024 01:00	0.0	0	0	0	0	0
09/29/2024 02:00	0.0	0	0	0	0	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	0.0	0	0	0	0	0
09/29/2024 11:00	0.0	0	0	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	0
09/29/2024 13:00	0.0	0	0	0	0	0
09/29/2024 14:00	35.0	0	1	0	0	0
09/29/2024 15:00	9.6	0	1	0	0	0
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.6 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	52.8	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	0.0	0	0	0	0	0
07/01/2024 09:00	0.0	0	0	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	0
07/01/2024 11:00	0.0	0	0	0	0	0
07/01/2024 12:00	0.0	0	0	0	0	0
07/01/2024 13:00	2,070.1	0	1	0	0	0
07/01/2024 14:00	5,720.8	0	1	0	0	0
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	70.2	0	0	0	1	0
Average/Sum#:	7,913.9 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,720.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	0.0	0	0	0	0	0
07/02/2024 11:00	0.0	0	0	0	0	0
07/02/2024 12:00	0.0	0	0	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	0
07/02/2024 14:00	0.0	0	0	0	0	0
07/02/2024 15:00	429.4	0	1	0	0	0
07/02/2024 16:00	6,287.5	0	1	0	0	0
07/02/2024 17:00	1,526.4	0	1	0	0	0
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,243.3 #	0 #	3 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,287.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	37.3	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	0.0	0	0	0	0	0
07/04/2024 10:00	0.0	0	0	0	0	0
07/04/2024 11:00	0.0	0	0	0	0	0
07/04/2024 12:00	0.0	0	0	0	0	0
07/04/2024 13:00	1,301.3	0	1	0	0	0
07/04/2024 14:00	5,404.4	0	1	0	0	0
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,743.0 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,404.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	34.8	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	0.0	0	0	0	0	0
07/06/2024 10:00	0.0	0	0	0	0	0
07/06/2024 11:00	0.0	0	0	0	0	0
07/06/2024 12:00	0.0	0	0	0	0	0
07/06/2024 13:00	0.0	0	0	1	0	0
07/06/2024 14:00	5,424.2	0	0	1	0	0
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,459.0 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,424.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	26.5	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	2.0	0	1	0	0	0
07/07/2024 12:00	5,710.1	0	1	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	1
07/07/2024 14:00	0.0	0	0	0	0	1
07/07/2024 15:00	0.0	0	0	0	0	1
07/07/2024 16:00	0.0	0	0	0	0	1
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,738.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,710.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	57.7	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	0.0	0	0	0	0	0
07/14/2024 11:00	0.0	0	0	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	0
07/14/2024 13:00	0.0	0	0	0	0	0
07/14/2024 14:00	1,585.6	0	1	0	0	0
07/14/2024 15:00	4,128.0	0	1	0	0	0
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,771.3 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,128.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	65.2	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	0.0	0	0	0	0	0
07/21/2024 11:00	0.0	0	0	0	0	0
07/21/2024 12:00	0.0	0	0	0	0	0
07/21/2024 13:00	0.0	0	0	0	0	0
07/21/2024 14:00	0.0	0	0	0	0	0
07/21/2024 15:00	0.0	0	0	0	0	0
07/21/2024 16:00	0.0	0	0	0	0	0
07/21/2024 17:00	0.0	0	0	0	0	0
07/21/2024 18:00	0.0	0	0	0	0	0
07/21/2024 19:00	0.0	0	0	0	0	0
07/21/2024 20:00	0.0	0	0	0	0	0
07/21/2024 21:00	0.0	0	0	0	0	0
07/21/2024 22:00	0.0	0	0	0	0	0
07/21/2024 23:00	0.0	0	1	0	1	0
Average/Sum#:	65.2 #	0 #	1 #	0 #	2 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	0
07/22/2024 01:00	0.0	0	0	0	0	0
07/22/2024 02:00	0.0	0	0	0	0	0
07/22/2024 03:00	3,924.5	0	1	0	0	0
07/22/2024 04:00	2,571.8	0	1	0	0	0
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,496.3 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,924.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	44.0	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	0.0	0	0	0	0	0
07/27/2024 12:00	0.0	0	0	0	0	0
07/27/2024 13:00	0.0	0	0	0	0	0
07/27/2024 14:00	0.0	0	0	0	0	0
07/27/2024 15:00	1,354.6	0	1	0	0	0
07/27/2024 16:00	5,556.5	0	1	0	0	0
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,955.1 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,556.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	45.0	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	2,263.3	0	0	1	0	0
07/28/2024 15:00	4,069.1	0	0	1	0	0
07/28/2024 16:00	0.0	0	0	0	0	1
07/28/2024 17:00	0.0	0	0	0	0	1
07/28/2024 18:00	0.0	0	0	0	0	1
07/28/2024 19:00	0.0	0	0	0	0	1
07/28/2024 20:00	0.0	0	0	0	0	1
07/28/2024 21:00	0.0	0	0	0	0	1
07/28/2024 22:00	0.0	0	0	0	0	1
07/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,377.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,069.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	1
07/29/2024 01:00	0.0	0	0	0	0	1
07/29/2024 02:00	0.0	0	0	0	0	1
07/29/2024 03:00	51.3	0	0	0	1	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	0.0	0	0	0	0	0
07/29/2024 11:00	0.0	0	0	0	0	0
07/29/2024 12:00	0.0	0	0	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	0
07/29/2024 14:00	0.0	0	1	0	0	0
07/29/2024 15:00	4,359.9	0	1	0	0	0
07/29/2024 16:00	3,555.8	0	1	0	0	0
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	24.6	0	0	0	1	0
Average/Sum#:	7,991.6 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,359.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	0.0	0	0	0	0	0
07/30/2024 11:00	0.0	0	0	0	0	0
07/30/2024 12:00	0.0	0	0	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	0
07/30/2024 14:00	0.0	0	0	0	0	0
07/30/2024 15:00	3,920.0	0	1	0	0	0
07/30/2024 16:00	4,275.0	0	1	0	0	0
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,195.0 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,275.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	28.2	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	28.2 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	2,382.2	0	1	0	0	0
08/10/2024 14:00	4,181.3	0	1	0	0	0
08/10/2024 15:00	5,189.9	0	1	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	1
08/10/2024 17:00	0.0	0	0	0	0	1
08/10/2024 18:00	0.0	0	0	0	0	1
08/10/2024 19:00	0.0	0	0	0	0	1
08/10/2024 20:00	0.0	0	0	0	0	1
08/10/2024 21:00	0.0	0	0	0	0	1
08/10/2024 22:00	0.0	0	0	0	0	1
08/10/2024 23:00	30.3	0	0	0	1	0
Average/Sum#:	11,783.7 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,189.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	0.0	0	0	0	0	0
08/12/2024 14:00	0.0	0	0	0	0	0
08/12/2024 15:00	0.0	0	0	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	0
08/12/2024 17:00	0.0	0	0	0	0	0
08/12/2024 18:00	1,955.0	0	1	0	0	0
08/12/2024 19:00	5,634.4	0	1	0	0	0
08/12/2024 20:00	2,392.8	0	1	0	0	0
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,982.2 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,634.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	55.7	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	2,570.0	0	1	0	0	0
08/13/2024 17:00	4,021.2	0	1	0	0	0
08/13/2024 18:00	5,623.1	0	1	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	1
08/13/2024 20:00	0.0	0	0	0	0	1
08/13/2024 21:00	0.0	0	0	0	0	1
08/13/2024 22:00	0.0	0	0	0	0	1
08/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,270.0 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,623.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	1
08/14/2024 01:00	0.0	0	0	0	0	1
08/14/2024 02:00	27.7	0	0	0	1	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	1,458.9	0	1	0	0	0
08/14/2024 11:00	5,445.0	0	1	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	1
08/14/2024 13:00	0.0	0	0	0	0	1
08/14/2024 14:00	0.0	0	0	0	0	1
08/14/2024 15:00	0.0	0	0	0	0	1
08/14/2024 16:00	0.0	0	0	0	0	1
08/14/2024 17:00	0.0	0	0	0	0	1
08/14/2024 18:00	0.0	0	0	0	0	1
08/14/2024 19:00	0.0	0	0	0	0	1
08/14/2024 20:00	0.0	0	0	0	0	1
08/14/2024 21:00	0.0	0	0	0	0	1
08/14/2024 22:00	0.0	0	0	0	0	1
08/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,931.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,445.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	49.8	0	0	0	1	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	2,408.0	0	1	0	0	0
08/15/2024 13:00	4,039.1	0	1	0	0	0
08/15/2024 14:00	5,920.6	0	1	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	1
08/15/2024 16:00	0.0	0	0	0	0	1
08/15/2024 17:00	0.0	0	0	0	0	1
08/15/2024 18:00	0.0	0	0	0	0	1
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,417.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,920.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	26.8	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	0.0	0	0	0	0	0
08/16/2024 09:00	0.0	0	0	0	0	0
08/16/2024 10:00	0.0	0	0	0	0	0
08/16/2024 11:00	0.0	0	0	0	0	0
08/16/2024 12:00	3,989.3	0	1	0	0	0
08/16/2024 13:00	4,683.8	0	1	0	0	0
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,699.9 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,683.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	79.3	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	302.2	0	1	0	0	0
08/17/2024 15:00	6,512.9	0	1	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	1
08/17/2024 17:00	0.0	0	0	0	0	1
08/17/2024 18:00	0.0	0	0	0	0	1
08/17/2024 19:00	0.0	0	0	0	0	1
08/17/2024 20:00	0.0	0	0	0	0	1
08/17/2024 21:00	0.0	0	0	0	0	1
08/17/2024 22:00	0.0	0	0	0	0	1
08/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,894.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,512.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	1
08/18/2024 01:00	0.0	0	0	0	0	1
08/18/2024 02:00	40.2	0	0	0	1	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	0.0	0	0	0	0	0
08/18/2024 10:00	0.0	0	0	0	0	0
08/18/2024 11:00	0.0	0	0	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	0
08/18/2024 13:00	0.0	0	0	0	0	0
08/18/2024 14:00	1,904.9	0	1	0	0	0
08/18/2024 15:00	5,238.6	0	1	0	0	0
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,183.7 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,238.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	38.7	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	4,313.6	0	0	1	0	0
08/19/2024 08:00	664.5	0	0	1	0	0
08/19/2024 09:00	0.0	0	0	0	0	1
08/19/2024 10:00	0.0	0	0	0	0	1
08/19/2024 11:00	0.0	0	0	0	0	1
08/19/2024 12:00	0.0	0	0	0	0	1
08/19/2024 13:00	0.0	0	0	0	0	1
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,016.8 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,313.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	81.7	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	0.0	0	0	0	0	0
08/20/2024 10:00	0.0	0	0	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	0
08/20/2024 12:00	0.0	0	0	0	0	0
08/20/2024 13:00	3,367.7	0	1	0	0	0
08/20/2024 14:00	5,710.6	0	1	0	0	0
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,160.0 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,710.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	27.1	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	0.0	0	0	0	0	0
08/22/2024 15:00	0.0	0	0	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	0
08/22/2024 17:00	0.0	0	0	0	0	0
08/22/2024 18:00	0.0	0	0	0	0	0
08/22/2024 19:00	0.0	0	0	0	0	0
08/22/2024 20:00	0.0	0	0	0	0	0
08/22/2024 21:00	0.0	0	0	0	0	0
08/22/2024 22:00	0.0	0	0	0	0	0
08/22/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	27.1 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	0
08/23/2024 01:00	0.0	0	0	0	0	0
08/23/2024 02:00	0.0	0	0	0	0	0
08/23/2024 03:00	0.0	0	0	0	0	0
08/23/2024 04:00	0.0	0	0	0	0	0
08/23/2024 05:00	0.0	0	0	0	0	0
08/23/2024 06:00	0.0	0	0	0	0	0
08/23/2024 07:00	0.0	0	0	0	0	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	0.0	0	0	0	0	0
08/25/2024 14:00	0.0	0	0	0	0	0
08/25/2024 15:00	0.0	0	0	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	0
08/25/2024 17:00	0.0	0	0	0	0	0
08/25/2024 18:00	0.0	0	0	0	0	0
08/25/2024 19:00	0.0	0	0	0	0	0
08/25/2024 20:00	0.0	0	0	0	0	0
08/25/2024 21:00	0.0	0	0	0	0	0
08/25/2024 22:00	0.0	0	0	0	0	0
08/25/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	388.8	1	0	0	1	0
08/26/2024 01:00	0.0	0	0	0	0	0
08/26/2024 02:00	0.0	0	0	0	0	0
08/26/2024 03:00	0.0	0	0	0	0	0
08/26/2024 04:00	0.0	0	0	0	0	0
08/26/2024 05:00	0.0	0	0	0	0	0
08/26/2024 06:00	0.0	0	0	0	0	0
08/26/2024 07:00	2,752.1	1	0	0	0	0
08/26/2024 08:00	4,874.2	1	0	0	0	0
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,015.1 #	3 #	0 #	0 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,874.2	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	45.1	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	341.2	0	0	1	0	0
08/31/2024 11:00	5,954.6	0	0	1	0	0
08/31/2024 12:00	0.0	0	0	0	0	1
08/31/2024 13:00	0.0	0	0	0	0	1
08/31/2024 14:00	0.0	0	0	0	0	1
08/31/2024 15:00	0.0	0	0	0	0	1
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,340.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,954.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	34.4	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	0.0	0	0	0	0	0
09/01/2024 11:00	0.0	0	0	0	0	0
09/01/2024 12:00	0.0	0	0	0	0	0
09/01/2024 13:00	0.0	0	0	0	0	0
09/01/2024 14:00	1,295.0	0	1	0	0	0
09/01/2024 15:00	4,584.5	0	1	0	0	0
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,913.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,584.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	49.0	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	0.0	0	0	0	0	0
09/02/2024 11:00	0.0	0	0	0	0	0
09/02/2024 12:00	0.0	0	0	0	0	0
09/02/2024 13:00	0.0	0	0	0	0	0
09/02/2024 14:00	1,846.8	0	0	1	0	0
09/02/2024 15:00	4,385.6	0	0	1	0	0
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,281.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,385.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	49.1	0	0	0	1	0
Average/Sum#:	49.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	0.0	0	0	0	0	0
09/12/2024 18:00	0.0	0	0	0	0	0
09/12/2024 19:00	0.0	0	0	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	0
09/12/2024 21:00	0.0	0	0	0	0	0
09/12/2024 22:00	0.0	0	0	0	0	0
09/12/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	0
09/13/2024 01:00	0.0	0	0	0	0	0
09/13/2024 02:00	0.0	0	0	0	0	0
09/13/2024 03:00	0.0	0	0	0	0	0
09/13/2024 04:00	0.0	0	0	0	0	0
09/13/2024 05:00	0.0	0	0	0	0	0
09/13/2024 06:00	0.0	0	0	0	0	0
09/13/2024 07:00	0.0	0	0	0	0	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	0.0	0	0	0	0	0
09/13/2024 14:00	0.0	0	0	0	0	0
09/13/2024 15:00	0.0	0	0	0	0	0
09/13/2024 16:00	0.0	0	0	0	0	0
09/13/2024 17:00	0.0	0	0	0	0	0
09/13/2024 18:00	1,812.7	0	1	0	0	0
09/13/2024 19:00	5,901.8	0	1	0	0	0
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,714.5 #	0 #	2 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,901.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	47.2	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	0.0	0	0	0	0	0
09/14/2024 17:00	0.0	0	0	0	0	0
09/14/2024 18:00	0.0	0	0	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	0
09/14/2024 20:00	0.0	0	0	0	0	0
09/14/2024 21:00	0.0	0	0	0	0	0
09/14/2024 22:00	0.0	0	0	0	0	0
09/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	47.2 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	0
09/15/2024 01:00	0.0	0	0	0	0	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	0.0	0	0	0	0	0
09/15/2024 18:00	0.0	0	0	0	0	0
09/15/2024 19:00	0.0	0	0	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	0
09/15/2024 21:00	0.0	0	0	0	0	0
09/15/2024 22:00	0.0	0	0	0	0	0
09/15/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	0
09/16/2024 01:00	0.0	0	0	0	0	0
09/16/2024 02:00	0.0	0	0	0	0	0
09/16/2024 03:00	0.0	0	0	0	0	0
09/16/2024 04:00	0.0	0	0	0	0	0
09/16/2024 05:00	0.0	0	0	0	0	0
09/16/2024 06:00	0.0	0	0	0	0	0
09/16/2024 07:00	0.0	0	0	0	0	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	0.0	0	0	0	0	0
09/17/2024 21:00	0.0	0	0	0	0	0
09/17/2024 22:00	0.0	0	0	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	0
09/18/2024 01:00	2,567.5	1	0	0	0	0
09/18/2024 02:00	5,636.4	1	0	0	0	0
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,203.9 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,636.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	63.4	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	63.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	1,876.0	0	1	0	0	0
09/21/2024 21:00	3,807.8	0	1	0	0	0
09/21/2024 22:00	5,495.1	0	1	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,178.9 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,495.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	1
09/22/2024 01:00	0.0	0	0	0	0	1
09/22/2024 02:00	0.0	0	0	0	0	1
09/22/2024 03:00	0.0	0	0	0	0	1
09/22/2024 04:00	0.0	0	0	0	0	1
09/22/2024 05:00	0.0	0	0	0	0	1
09/22/2024 06:00	0.0	0	0	0	0	1
09/22/2024 07:00	78.1	0	0	0	1	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	1,648.4	0	0	1	0	0
09/22/2024 11:00	5,198.4	0	0	1	0	0
09/22/2024 12:00	0.0	0	0	0	0	1
09/22/2024 13:00	0.0	0	0	0	0	1
09/22/2024 14:00	0.0	0	0	0	0	1
09/22/2024 15:00	0.0	0	0	0	0	1
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,924.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,198.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	60.6	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	0.0	0	0	0	0	0
09/25/2024 15:00	0.0	0	0	0	0	0
09/25/2024 16:00	0.0	0	0	0	0	0
09/25/2024 17:00	0.0	0	0	0	0	0
09/25/2024 18:00	0.0	0	1	0	0	0
09/25/2024 19:00	6,105.3	0	1	0	0	0
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,165.9 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,105.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	50.8	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	0.0	0	0	0	0	0
09/26/2024 15:00	0.0	0	0	0	0	0
09/26/2024 16:00	0.0	0	0	0	0	0
09/26/2024 17:00	0.0	0	0	0	0	0
09/26/2024 18:00	0.0	0	0	0	0	0
09/26/2024 19:00	0.0	0	0	0	0	0
09/26/2024 20:00	0.0	0	0	0	0	0
09/26/2024 21:00	0.0	0	0	0	0	0
09/26/2024 22:00	0.0	0	0	0	0	0
09/26/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	50.8 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	0
09/27/2024 01:00	0.0	0	0	0	0	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	0.0	0	0	0	0	0
09/27/2024 10:00	0.0	0	0	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	0
09/27/2024 12:00	0.0	0	0	0	0	0
09/27/2024 13:00	1,388.4	0	1	0	0	0
09/27/2024 14:00	4,591.3	0	1	0	0	0
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,979.7 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,591.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	73.0	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	0.0	0	0	0	0	0
09/28/2024 16:00	0.0	0	0	0	0	0
09/28/2024 17:00	0.0	0	0	0	0	0
09/28/2024 18:00	0.0	0	0	0	0	0
09/28/2024 19:00	0.0	0	0	0	0	0
09/28/2024 20:00	0.0	0	0	0	0	0
09/28/2024 21:00	0.0	0	0	0	0	0
09/28/2024 22:00	0.0	0	0	0	0	0
09/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	73.0 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	0
09/29/2024 01:00	0.0	0	0	0	0	0
09/29/2024 02:00	0.0	0	0	0	0	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	0.0	0	0	0	0	0
09/29/2024 11:00	0.0	0	0	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	0
09/29/2024 13:00	0.0	0	0	0	0	0
09/29/2024 14:00	1,436.3	0	1	0	0	0
09/29/2024 15:00	3,552.4	0	1	0	0	0
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	4,988.7 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,552.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2024 00:00	1.0	0	0	0	1	0
07/01/2024 01:00	0.0	0	0	0	0	0
07/01/2024 02:00	0.0	0	0	0	0	0
07/01/2024 03:00	0.0	0	0	0	0	0
07/01/2024 04:00	0.0	0	0	0	0	0
07/01/2024 05:00	0.0	0	0	0	0	0
07/01/2024 06:00	0.0	0	0	0	0	0
07/01/2024 07:00	0.0	0	0	0	0	0
07/01/2024 08:00	0.0	0	0	0	0	0
07/01/2024 09:00	0.0	0	0	0	0	0
07/01/2024 10:00	0.0	0	0	0	0	0
07/01/2024 11:00	0.0	0	0	0	0	0
07/01/2024 12:00	0.0	0	0	0	0	0
07/01/2024 13:00	39.4	0	1	0	0	0
07/01/2024 14:00	30.9	0	1	0	0	0
07/01/2024 15:00	0.0	0	0	0	0	1
07/01/2024 16:00	0.0	0	0	0	0	1
07/01/2024 17:00	0.0	0	0	0	0	1
07/01/2024 18:00	0.0	0	0	0	0	1
07/01/2024 19:00	0.0	0	0	0	0	1
07/01/2024 20:00	0.0	0	0	0	0	1
07/01/2024 21:00	0.0	0	0	0	0	1
07/01/2024 22:00	0.0	0	0	0	0	1
07/01/2024 23:00	1.2	0	0	0	1	0
Average/Sum#:	72.5 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2024 00:00	0.0	0	0	0	0	0
07/02/2024 01:00	0.0	0	0	0	0	0
07/02/2024 02:00	0.0	0	0	0	0	0
07/02/2024 03:00	0.0	0	0	0	0	0
07/02/2024 04:00	0.0	0	0	0	0	0
07/02/2024 05:00	0.0	0	0	0	0	0
07/02/2024 06:00	0.0	0	0	0	0	0
07/02/2024 07:00	0.0	0	0	0	0	0
07/02/2024 08:00	0.0	0	0	0	0	0
07/02/2024 09:00	0.0	0	0	0	0	0
07/02/2024 10:00	0.0	0	0	0	0	0
07/02/2024 11:00	0.0	0	0	0	0	0
07/02/2024 12:00	0.0	0	0	0	0	0
07/02/2024 13:00	0.0	0	0	0	0	0
07/02/2024 14:00	0.0	0	0	0	0	0
07/02/2024 15:00	6.3	0	1	0	0	0
07/02/2024 16:00	83.0	0	1	0	0	0
07/02/2024 17:00	1.2	0	1	0	0	0
07/02/2024 18:00	0.0	0	0	0	0	1
07/02/2024 19:00	0.0	0	0	0	0	1
07/02/2024 20:00	0.0	0	0	0	0	1
07/02/2024 21:00	0.0	0	0	0	0	1
07/02/2024 22:00	0.0	0	0	0	0	1
07/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	90.5 #	0 #	3 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2024 00:00	0.0	0	0	0	0	1
07/03/2024 01:00	0.0	0	0	0	0	1
07/03/2024 02:00	0.0	0	0	0	0	1
07/03/2024 03:00	0.0	0	0	0	0	1
07/03/2024 04:00	0.0	0	0	0	0	1
07/03/2024 05:00	0.0	0	0	0	0	1
07/03/2024 06:00	0.0	0	0	0	0	1
07/03/2024 07:00	0.0	0	0	0	0	1
07/03/2024 08:00	0.0	0	0	0	0	1
07/03/2024 09:00	0.0	0	0	0	0	1
07/03/2024 10:00	0.0	0	0	0	0	1
07/03/2024 11:00	0.0	0	0	0	0	1
07/03/2024 12:00	0.0	0	0	0	0	1
07/03/2024 13:00	0.0	0	0	0	0	1
07/03/2024 14:00	0.0	0	0	0	0	1
07/03/2024 15:00	0.0	0	0	0	0	1
07/03/2024 16:00	0.0	0	0	0	0	1
07/03/2024 17:00	0.0	0	0	0	0	1
07/03/2024 18:00	0.0	0	0	0	0	1
07/03/2024 19:00	0.0	0	0	0	0	1
07/03/2024 20:00	0.0	0	0	0	0	1
07/03/2024 21:00	0.0	0	0	0	0	1
07/03/2024 22:00	0.0	0	0	0	0	1
07/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2024 00:00	0.0	0	0	0	0	1
07/04/2024 01:00	0.0	0	0	0	0	1
07/04/2024 02:00	0.7	0	0	0	1	0
07/04/2024 03:00	0.0	0	0	0	0	0
07/04/2024 04:00	0.0	0	0	0	0	0
07/04/2024 05:00	0.0	0	0	0	0	0
07/04/2024 06:00	0.0	0	0	0	0	0
07/04/2024 07:00	0.0	0	0	0	0	0
07/04/2024 08:00	0.0	0	0	0	0	0
07/04/2024 09:00	0.0	0	0	0	0	0
07/04/2024 10:00	0.0	0	0	0	0	0
07/04/2024 11:00	0.0	0	0	0	0	0
07/04/2024 12:00	0.0	0	0	0	0	0
07/04/2024 13:00	23.0	0	1	0	0	0
07/04/2024 14:00	29.4	0	1	0	0	0
07/04/2024 15:00	0.0	0	0	0	0	1
07/04/2024 16:00	0.0	0	0	0	0	1
07/04/2024 17:00	0.0	0	0	0	0	1
07/04/2024 18:00	0.0	0	0	0	0	1
07/04/2024 19:00	0.0	0	0	0	0	1
07/04/2024 20:00	0.0	0	0	0	0	1
07/04/2024 21:00	0.0	0	0	0	0	1
07/04/2024 22:00	0.0	0	0	0	0	1
07/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.1 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2024 00:00	0.0	0	0	0	0	1
07/05/2024 01:00	0.0	0	0	0	0	1
07/05/2024 02:00	0.0	0	0	0	0	1
07/05/2024 03:00	0.0	0	0	0	0	1
07/05/2024 04:00	0.0	0	0	0	0	1
07/05/2024 05:00	0.0	0	0	0	0	1
07/05/2024 06:00	0.0	0	0	0	0	1
07/05/2024 07:00	0.0	0	0	0	0	1
07/05/2024 08:00	0.0	0	0	0	0	1
07/05/2024 09:00	0.0	0	0	0	0	1
07/05/2024 10:00	0.0	0	0	0	0	1
07/05/2024 11:00	0.0	0	0	0	0	1
07/05/2024 12:00	0.0	0	0	0	0	1
07/05/2024 13:00	0.0	0	0	0	0	1
07/05/2024 14:00	0.0	0	0	0	0	1
07/05/2024 15:00	0.0	0	0	0	0	1
07/05/2024 16:00	0.0	0	0	0	0	1
07/05/2024 17:00	0.0	0	0	0	0	1
07/05/2024 18:00	0.0	0	0	0	0	1
07/05/2024 19:00	0.0	0	0	0	0	1
07/05/2024 20:00	0.0	0	0	0	0	1
07/05/2024 21:00	0.0	0	0	0	0	1
07/05/2024 22:00	0.0	0	0	0	0	1
07/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2024 00:00	0.0	0	0	0	0	1
07/06/2024 01:00	0.0	0	0	0	0	1
07/06/2024 02:00	0.0	0	0	0	0	1
07/06/2024 03:00	0.0	0	0	0	0	1
07/06/2024 04:00	0.0	0	0	0	0	1
07/06/2024 05:00	0.0	0	0	0	0	1
07/06/2024 06:00	0.0	0	0	0	1	0
07/06/2024 07:00	0.0	0	0	0	0	0
07/06/2024 08:00	0.0	0	0	0	0	0
07/06/2024 09:00	0.0	0	0	0	0	0
07/06/2024 10:00	0.0	0	0	0	0	0
07/06/2024 11:00	0.0	0	0	0	0	0
07/06/2024 12:00	0.0	0	0	0	0	0
07/06/2024 13:00	0.0	0	0	1	0	0
07/06/2024 14:00	23.9	0	0	1	0	0
07/06/2024 15:00	0.0	0	0	0	0	1
07/06/2024 16:00	0.0	0	0	0	0	1
07/06/2024 17:00	0.0	0	0	0	0	1
07/06/2024 18:00	0.0	0	0	0	0	1
07/06/2024 19:00	0.0	0	0	0	0	1
07/06/2024 20:00	0.0	0	0	0	0	1
07/06/2024 21:00	0.0	0	0	0	0	1
07/06/2024 22:00	0.0	0	0	0	0	1
07/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	23.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2024 00:00	0.0	0	0	0	0	1
07/07/2024 01:00	0.0	0	0	0	0	1
07/07/2024 02:00	0.0	0	0	0	0	1
07/07/2024 03:00	0.6	0	0	0	1	0
07/07/2024 04:00	0.0	0	0	0	0	0
07/07/2024 05:00	0.0	0	0	0	0	0
07/07/2024 06:00	0.0	0	0	0	0	0
07/07/2024 07:00	0.0	0	0	0	0	0
07/07/2024 08:00	0.0	0	0	0	0	0
07/07/2024 09:00	0.0	0	0	0	0	0
07/07/2024 10:00	0.0	0	0	0	0	0
07/07/2024 11:00	0.0	0	1	0	0	0
07/07/2024 12:00	49.7	0	1	0	0	0
07/07/2024 13:00	0.0	0	0	0	0	1
07/07/2024 14:00	0.0	0	0	0	0	1
07/07/2024 15:00	0.0	0	0	0	0	1
07/07/2024 16:00	0.0	0	0	0	0	1
07/07/2024 17:00	0.0	0	0	0	0	1
07/07/2024 18:00	0.0	0	0	0	0	1
07/07/2024 19:00	0.0	0	0	0	0	1
07/07/2024 20:00	0.0	0	0	0	0	1
07/07/2024 21:00	0.0	0	0	0	0	1
07/07/2024 22:00	0.0	0	0	0	0	1
07/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.3 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2024 00:00	0.0	0	0	0	0	1
07/08/2024 01:00	0.0	0	0	0	0	1
07/08/2024 02:00	0.0	0	0	0	0	1
07/08/2024 03:00	0.0	0	0	0	0	1
07/08/2024 04:00	0.0	0	0	0	0	1
07/08/2024 05:00	0.0	0	0	0	0	1
07/08/2024 06:00	0.0	0	0	0	0	1
07/08/2024 07:00	0.0	0	0	0	0	1
07/08/2024 08:00	0.0	0	0	0	0	1
07/08/2024 09:00	0.0	0	0	0	0	1
07/08/2024 10:00	0.0	0	0	0	0	1
07/08/2024 11:00	0.0	0	0	0	0	1
07/08/2024 12:00	0.0	0	0	0	0	1
07/08/2024 13:00	0.0	0	0	0	0	1
07/08/2024 14:00	0.0	0	0	0	0	1
07/08/2024 15:00	0.0	0	0	0	0	1
07/08/2024 16:00	0.0	0	0	0	0	1
07/08/2024 17:00	0.0	0	0	0	0	1
07/08/2024 18:00	0.0	0	0	0	0	1
07/08/2024 19:00	0.0	0	0	0	0	1
07/08/2024 20:00	0.0	0	0	0	0	1
07/08/2024 21:00	0.0	0	0	0	0	1
07/08/2024 22:00	0.0	0	0	0	0	1
07/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2024 00:00	0.0	0	0	0	0	1
07/09/2024 01:00	0.0	0	0	0	0	1
07/09/2024 02:00	0.0	0	0	0	0	1
07/09/2024 03:00	0.0	0	0	0	0	1
07/09/2024 04:00	0.0	0	0	0	0	1
07/09/2024 05:00	0.0	0	0	0	0	1
07/09/2024 06:00	0.0	0	0	0	0	1
07/09/2024 07:00	0.0	0	0	0	0	1
07/09/2024 08:00	0.0	0	0	0	0	1
07/09/2024 09:00	0.0	0	0	0	0	1
07/09/2024 10:00	0.0	0	0	0	0	1
07/09/2024 11:00	0.0	0	0	0	0	1
07/09/2024 12:00	0.0	0	0	0	0	1
07/09/2024 13:00	0.0	0	0	0	0	1
07/09/2024 14:00	0.0	0	0	0	0	1
07/09/2024 15:00	0.0	0	0	0	0	1
07/09/2024 16:00	0.0	0	0	0	0	1
07/09/2024 17:00	0.0	0	0	0	0	1
07/09/2024 18:00	0.0	0	0	0	0	1
07/09/2024 19:00	0.0	0	0	0	0	1
07/09/2024 20:00	0.0	0	0	0	0	1
07/09/2024 21:00	0.0	0	0	0	0	1
07/09/2024 22:00	0.0	0	0	0	0	1
07/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2024 00:00	0.0	0	0	0	0	1
07/10/2024 01:00	0.0	0	0	0	0	1
07/10/2024 02:00	0.0	0	0	0	0	1
07/10/2024 03:00	0.0	0	0	0	0	1
07/10/2024 04:00	0.0	0	0	0	0	1
07/10/2024 05:00	0.0	0	0	0	0	1
07/10/2024 06:00	0.0	0	0	0	0	1
07/10/2024 07:00	0.0	0	0	0	0	1
07/10/2024 08:00	0.0	0	0	0	0	1
07/10/2024 09:00	0.0	0	0	0	0	1
07/10/2024 10:00	0.0	0	0	0	0	1
07/10/2024 11:00	0.0	0	0	0	0	1
07/10/2024 12:00	0.0	0	0	0	0	1
07/10/2024 13:00	0.0	0	0	0	0	1
07/10/2024 14:00	0.0	0	0	0	0	1
07/10/2024 15:00	0.0	0	0	0	0	1
07/10/2024 16:00	0.0	0	0	0	0	1
07/10/2024 17:00	0.0	0	0	0	0	1
07/10/2024 18:00	0.0	0	0	0	0	1
07/10/2024 19:00	0.0	0	0	0	0	1
07/10/2024 20:00	0.0	0	0	0	0	1
07/10/2024 21:00	0.0	0	0	0	0	1
07/10/2024 22:00	0.0	0	0	0	0	1
07/10/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2024 00:00	0.0	0	0	0	0	1
07/11/2024 01:00	0.0	0	0	0	0	1
07/11/2024 02:00	0.0	0	0	0	0	1
07/11/2024 03:00	0.0	0	0	0	0	1
07/11/2024 04:00	0.0	0	0	0	0	1
07/11/2024 05:00	0.0	0	0	0	0	1
07/11/2024 06:00	0.0	0	0	0	0	1
07/11/2024 07:00	0.0	0	0	0	0	1
07/11/2024 08:00	0.0	0	0	0	0	1
07/11/2024 09:00	0.0	0	0	0	0	1
07/11/2024 10:00	0.0	0	0	0	0	1
07/11/2024 11:00	0.0	0	0	0	0	1
07/11/2024 12:00	0.0	0	0	0	0	1
07/11/2024 13:00	0.0	0	0	0	0	1
07/11/2024 14:00	0.0	0	0	0	0	1
07/11/2024 15:00	0.0	0	0	0	0	1
07/11/2024 16:00	0.0	0	0	0	0	1
07/11/2024 17:00	0.0	0	0	0	0	1
07/11/2024 18:00	0.0	0	0	0	0	1
07/11/2024 19:00	0.0	0	0	0	0	1
07/11/2024 20:00	0.0	0	0	0	0	1
07/11/2024 21:00	0.0	0	0	0	0	1
07/11/2024 22:00	0.0	0	0	0	0	1
07/11/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2024 00:00	0.0	0	0	0	0	1
07/12/2024 01:00	0.0	0	0	0	0	1
07/12/2024 02:00	0.0	0	0	0	0	1
07/12/2024 03:00	0.0	0	0	0	0	1
07/12/2024 04:00	0.0	0	0	0	0	1
07/12/2024 05:00	0.0	0	0	0	0	1
07/12/2024 06:00	0.0	0	0	0	0	1
07/12/2024 07:00	0.0	0	0	0	0	1
07/12/2024 08:00	0.0	0	0	0	0	1
07/12/2024 09:00	0.0	0	0	0	0	1
07/12/2024 10:00	0.0	0	0	0	0	1
07/12/2024 11:00	0.0	0	0	0	0	1
07/12/2024 12:00	0.0	0	0	0	0	1
07/12/2024 13:00	0.0	0	0	0	0	1
07/12/2024 14:00	0.0	0	0	0	0	1
07/12/2024 15:00	0.0	0	0	0	0	1
07/12/2024 16:00	0.0	0	0	0	0	1
07/12/2024 17:00	0.0	0	0	0	0	1
07/12/2024 18:00	0.0	0	0	0	0	1
07/12/2024 19:00	0.0	0	0	0	0	1
07/12/2024 20:00	0.0	0	0	0	0	1
07/12/2024 21:00	0.0	0	0	0	0	1
07/12/2024 22:00	0.0	0	0	0	0	1
07/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2024 00:00	0.0	0	0	0	0	1
07/13/2024 01:00	0.0	0	0	0	0	1
07/13/2024 02:00	0.0	0	0	0	0	1
07/13/2024 03:00	0.0	0	0	0	0	1
07/13/2024 04:00	0.0	0	0	0	0	1
07/13/2024 05:00	0.0	0	0	0	0	1
07/13/2024 06:00	0.0	0	0	0	0	1
07/13/2024 07:00	0.0	0	0	0	0	1
07/13/2024 08:00	0.0	0	0	0	0	1
07/13/2024 09:00	0.0	0	0	0	0	1
07/13/2024 10:00	0.0	0	0	0	0	1
07/13/2024 11:00	0.0	0	0	0	0	1
07/13/2024 12:00	0.0	0	0	0	0	1
07/13/2024 13:00	0.0	0	0	0	0	1
07/13/2024 14:00	0.0	0	0	0	0	1
07/13/2024 15:00	0.0	0	0	0	0	1
07/13/2024 16:00	0.0	0	0	0	0	1
07/13/2024 17:00	0.0	0	0	0	0	1
07/13/2024 18:00	0.0	0	0	0	0	1
07/13/2024 19:00	0.0	0	0	0	0	1
07/13/2024 20:00	0.0	0	0	0	0	1
07/13/2024 21:00	0.0	0	0	0	0	1
07/13/2024 22:00	0.0	0	0	0	0	1
07/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2024 00:00	0.0	0	0	0	0	1
07/14/2024 01:00	0.0	0	0	0	0	1
07/14/2024 02:00	0.7	0	0	0	1	0
07/14/2024 03:00	0.0	0	0	0	0	0
07/14/2024 04:00	0.0	0	0	0	0	0
07/14/2024 05:00	0.0	0	0	0	0	0
07/14/2024 06:00	0.0	0	0	0	0	0
07/14/2024 07:00	0.0	0	0	0	0	0
07/14/2024 08:00	0.0	0	0	0	0	0
07/14/2024 09:00	0.0	0	0	0	0	0
07/14/2024 10:00	0.0	0	0	0	0	0
07/14/2024 11:00	0.0	0	0	0	0	0
07/14/2024 12:00	0.0	0	0	0	0	0
07/14/2024 13:00	0.0	0	0	0	0	0
07/14/2024 14:00	27.6	0	1	0	0	0
07/14/2024 15:00	19.1	0	1	0	0	0
07/14/2024 16:00	0.0	0	0	0	0	1
07/14/2024 17:00	0.0	0	0	0	0	1
07/14/2024 18:00	0.0	0	0	0	0	1
07/14/2024 19:00	0.0	0	0	0	0	1
07/14/2024 20:00	0.0	0	0	0	0	1
07/14/2024 21:00	0.0	0	0	0	0	1
07/14/2024 22:00	0.0	0	0	0	0	1
07/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	47.4 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2024 00:00	0.0	0	0	0	0	1
07/15/2024 01:00	0.0	0	0	0	0	1
07/15/2024 02:00	0.0	0	0	0	0	1
07/15/2024 03:00	0.0	0	0	0	0	1
07/15/2024 04:00	0.0	0	0	0	0	1
07/15/2024 05:00	0.0	0	0	0	0	1
07/15/2024 06:00	0.0	0	0	0	0	1
07/15/2024 07:00	0.0	0	0	0	0	1
07/15/2024 08:00	0.0	0	0	0	0	1
07/15/2024 09:00	0.0	0	0	0	0	1
07/15/2024 10:00	0.0	0	0	0	0	1
07/15/2024 11:00	0.0	0	0	0	0	1
07/15/2024 12:00	0.0	0	0	0	0	1
07/15/2024 13:00	0.0	0	0	0	0	1
07/15/2024 14:00	0.0	0	0	0	0	1
07/15/2024 15:00	0.0	0	0	0	0	1
07/15/2024 16:00	0.0	0	0	0	0	1
07/15/2024 17:00	0.0	0	0	0	0	1
07/15/2024 18:00	0.0	0	0	0	0	1
07/15/2024 19:00	0.0	0	0	0	0	1
07/15/2024 20:00	0.0	0	0	0	0	1
07/15/2024 21:00	0.0	0	0	0	0	1
07/15/2024 22:00	0.0	0	0	0	0	1
07/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2024 00:00	0.0	0	0	0	0	1
07/16/2024 01:00	0.0	0	0	0	0	1
07/16/2024 02:00	0.0	0	0	0	0	1
07/16/2024 03:00	0.0	0	0	0	0	1
07/16/2024 04:00	0.0	0	0	0	0	1
07/16/2024 05:00	0.0	0	0	0	0	1
07/16/2024 06:00	0.0	0	0	0	0	1
07/16/2024 07:00	0.0	0	0	0	0	1
07/16/2024 08:00	0.0	0	0	0	0	1
07/16/2024 09:00	0.0	0	0	0	0	1
07/16/2024 10:00	0.0	0	0	0	0	1
07/16/2024 11:00	0.0	0	0	0	0	1
07/16/2024 12:00	0.0	0	0	0	0	1
07/16/2024 13:00	0.0	0	0	0	0	1
07/16/2024 14:00	0.0	0	0	0	0	1
07/16/2024 15:00	0.0	0	0	0	0	1
07/16/2024 16:00	0.0	0	0	0	0	1
07/16/2024 17:00	0.0	0	0	0	0	1
07/16/2024 18:00	0.0	0	0	0	0	1
07/16/2024 19:00	0.0	0	0	0	0	1
07/16/2024 20:00	0.0	0	0	0	0	1
07/16/2024 21:00	0.0	0	0	0	0	1
07/16/2024 22:00	0.0	0	0	0	0	1
07/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2024 00:00	0.0	0	0	0	0	1
07/17/2024 01:00	0.0	0	0	0	0	1
07/17/2024 02:00	0.0	0	0	0	0	1
07/17/2024 03:00	0.0	0	0	0	0	1
07/17/2024 04:00	0.0	0	0	0	0	1
07/17/2024 05:00	0.0	0	0	0	0	1
07/17/2024 06:00	0.0	0	0	0	0	1
07/17/2024 07:00	0.0	0	0	0	0	1
07/17/2024 08:00	0.0	0	0	0	0	1
07/17/2024 09:00	0.0	0	0	0	0	1
07/17/2024 10:00	0.0	0	0	0	0	1
07/17/2024 11:00	0.0	0	0	0	0	1
07/17/2024 12:00	0.0	0	0	0	0	1
07/17/2024 13:00	0.0	0	0	0	0	1
07/17/2024 14:00	0.0	0	0	0	0	1
07/17/2024 15:00	0.0	0	0	0	0	1
07/17/2024 16:00	0.0	0	0	0	0	1
07/17/2024 17:00	0.0	0	0	0	0	1
07/17/2024 18:00	0.0	0	0	0	0	1
07/17/2024 19:00	0.0	0	0	0	0	1
07/17/2024 20:00	0.0	0	0	0	0	1
07/17/2024 21:00	0.0	0	0	0	0	1
07/17/2024 22:00	0.0	0	0	0	0	1
07/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2024 00:00	0.0	0	0	0	0	1
07/18/2024 01:00	0.0	0	0	0	0	1
07/18/2024 02:00	0.0	0	0	0	0	1
07/18/2024 03:00	0.0	0	0	0	0	1
07/18/2024 04:00	0.0	0	0	0	0	1
07/18/2024 05:00	0.0	0	0	0	0	1
07/18/2024 06:00	0.0	0	0	0	0	1
07/18/2024 07:00	0.0	0	0	0	0	1
07/18/2024 08:00	0.0	0	0	0	0	1
07/18/2024 09:00	0.0	0	0	0	0	1
07/18/2024 10:00	0.0	0	0	0	0	1
07/18/2024 11:00	0.0	0	0	0	0	1
07/18/2024 12:00	0.0	0	0	0	0	1
07/18/2024 13:00	0.0	0	0	0	0	1
07/18/2024 14:00	0.0	0	0	0	0	1
07/18/2024 15:00	0.0	0	0	0	0	1
07/18/2024 16:00	0.0	0	0	0	0	1
07/18/2024 17:00	0.0	0	0	0	0	1
07/18/2024 18:00	0.0	0	0	0	0	1
07/18/2024 19:00	0.0	0	0	0	0	1
07/18/2024 20:00	0.0	0	0	0	0	1
07/18/2024 21:00	0.0	0	0	0	0	1
07/18/2024 22:00	0.0	0	0	0	0	1
07/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2024 00:00	0.0	0	0	0	0	1
07/19/2024 01:00	0.0	0	0	0	0	1
07/19/2024 02:00	0.0	0	0	0	0	1
07/19/2024 03:00	0.0	0	0	0	0	1
07/19/2024 04:00	0.0	0	0	0	0	1
07/19/2024 05:00	0.0	0	0	0	0	1
07/19/2024 06:00	0.0	0	0	0	0	1
07/19/2024 07:00	0.0	0	0	0	0	1
07/19/2024 08:00	0.0	0	0	0	0	1
07/19/2024 09:00	0.0	0	0	0	0	1
07/19/2024 10:00	0.0	0	0	0	0	1
07/19/2024 11:00	0.0	0	0	0	0	1
07/19/2024 12:00	0.0	0	0	0	0	1
07/19/2024 13:00	0.0	0	0	0	0	1
07/19/2024 14:00	0.0	0	0	0	0	1
07/19/2024 15:00	0.0	0	0	0	0	1
07/19/2024 16:00	0.0	0	0	0	0	1
07/19/2024 17:00	0.0	0	0	0	0	1
07/19/2024 18:00	0.0	0	0	0	0	1
07/19/2024 19:00	0.0	0	0	0	0	1
07/19/2024 20:00	0.0	0	0	0	0	1
07/19/2024 21:00	0.0	0	0	0	0	1
07/19/2024 22:00	0.0	0	0	0	0	1
07/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2024 00:00	0.0	0	0	0	0	1
07/20/2024 01:00	0.0	0	0	0	0	1
07/20/2024 02:00	0.0	0	0	0	0	1
07/20/2024 03:00	0.0	0	0	0	0	1
07/20/2024 04:00	0.0	0	0	0	0	1
07/20/2024 05:00	0.0	0	0	0	0	1
07/20/2024 06:00	0.0	0	0	0	0	1
07/20/2024 07:00	0.0	0	0	0	0	1
07/20/2024 08:00	0.0	0	0	0	0	1
07/20/2024 09:00	0.0	0	0	0	0	1
07/20/2024 10:00	0.0	0	0	0	0	1
07/20/2024 11:00	0.0	0	0	0	0	1
07/20/2024 12:00	0.0	0	0	0	0	1
07/20/2024 13:00	0.0	0	0	0	0	1
07/20/2024 14:00	0.0	0	0	0	0	1
07/20/2024 15:00	0.0	0	0	0	0	1
07/20/2024 16:00	0.0	0	0	0	0	1
07/20/2024 17:00	0.0	0	0	0	0	1
07/20/2024 18:00	0.0	0	0	0	0	1
07/20/2024 19:00	0.0	0	0	0	0	1
07/20/2024 20:00	0.0	0	0	0	0	1
07/20/2024 21:00	0.0	0	0	0	0	1
07/20/2024 22:00	0.0	0	0	0	0	1
07/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2024 00:00	0.0	0	0	0	0	1
07/21/2024 01:00	0.0	0	0	0	0	1
07/21/2024 02:00	0.0	0	0	0	0	1
07/21/2024 03:00	0.0	0	0	0	0	1
07/21/2024 04:00	0.0	0	0	0	0	1
07/21/2024 05:00	0.9	0	0	0	1	0
07/21/2024 06:00	0.0	0	0	0	0	0
07/21/2024 07:00	0.0	0	0	0	0	0
07/21/2024 08:00	0.0	0	0	0	0	0
07/21/2024 09:00	0.0	0	0	0	0	0
07/21/2024 10:00	0.0	0	0	0	0	0
07/21/2024 11:00	0.0	0	0	0	0	0
07/21/2024 12:00	0.0	0	0	0	0	0
07/21/2024 13:00	0.0	0	0	0	0	0
07/21/2024 14:00	0.0	0	0	0	0	0
07/21/2024 15:00	0.0	0	0	0	0	0
07/21/2024 16:00	0.0	0	0	0	0	0
07/21/2024 17:00	0.0	0	0	0	0	0
07/21/2024 18:00	0.0	0	0	0	0	0
07/21/2024 19:00	0.0	0	0	0	0	0
07/21/2024 20:00	0.0	0	0	0	0	0
07/21/2024 21:00	0.0	0	0	0	0	0
07/21/2024 22:00	0.0	0	0	0	0	0
07/21/2024 23:00	0.0	0	1	0	1	0
Average/Sum#:	0.9 #	0 #	1 #	0 #	2 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2024 00:00	0.0	0	0	0	0	0
07/22/2024 01:00	0.0	0	0	0	0	0
07/22/2024 02:00	0.0	0	0	0	0	0
07/22/2024 03:00	59.4	0	1	0	0	0
07/22/2024 04:00	3.7	0	1	0	0	0
07/22/2024 05:00	0.0	0	0	0	0	1
07/22/2024 06:00	0.0	0	0	0	0	1
07/22/2024 07:00	0.0	0	0	0	0	1
07/22/2024 08:00	0.0	0	0	0	0	1
07/22/2024 09:00	0.0	0	0	0	0	1
07/22/2024 10:00	0.0	0	0	0	0	1
07/22/2024 11:00	0.0	0	0	0	0	1
07/22/2024 12:00	0.0	0	0	0	0	1
07/22/2024 13:00	0.0	0	0	0	0	1
07/22/2024 14:00	0.0	0	0	0	0	1
07/22/2024 15:00	0.0	0	0	0	0	1
07/22/2024 16:00	0.0	0	0	0	0	1
07/22/2024 17:00	0.0	0	0	0	0	1
07/22/2024 18:00	0.0	0	0	0	0	1
07/22/2024 19:00	0.0	0	0	0	0	1
07/22/2024 20:00	0.0	0	0	0	0	1
07/22/2024 21:00	0.0	0	0	0	0	1
07/22/2024 22:00	0.0	0	0	0	0	1
07/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	63.1 #	0 #	2 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2024 00:00	0.0	0	0	0	0	1
07/23/2024 01:00	0.0	0	0	0	0	1
07/23/2024 02:00	0.0	0	0	0	0	1
07/23/2024 03:00	0.0	0	0	0	0	1
07/23/2024 04:00	0.0	0	0	0	0	1
07/23/2024 05:00	0.0	0	0	0	0	1
07/23/2024 06:00	0.0	0	0	0	0	1
07/23/2024 07:00	0.0	0	0	0	0	1
07/23/2024 08:00	0.0	0	0	0	0	1
07/23/2024 09:00	0.0	0	0	0	0	1
07/23/2024 10:00	0.0	0	0	0	0	1
07/23/2024 11:00	0.0	0	0	0	0	1
07/23/2024 12:00	0.0	0	0	0	0	1
07/23/2024 13:00	0.0	0	0	0	0	1
07/23/2024 14:00	0.0	0	0	0	0	1
07/23/2024 15:00	0.0	0	0	0	0	1
07/23/2024 16:00	0.0	0	0	0	0	1
07/23/2024 17:00	0.0	0	0	0	0	1
07/23/2024 18:00	0.0	0	0	0	0	1
07/23/2024 19:00	0.0	0	0	0	0	1
07/23/2024 20:00	0.0	0	0	0	0	1
07/23/2024 21:00	0.0	0	0	0	0	1
07/23/2024 22:00	0.0	0	0	0	0	1
07/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2024 00:00	0.0	0	0	0	0	1
07/24/2024 01:00	0.0	0	0	0	0	1
07/24/2024 02:00	0.0	0	0	0	0	1
07/24/2024 03:00	0.0	0	0	0	0	1
07/24/2024 04:00	0.0	0	0	0	0	1
07/24/2024 05:00	0.0	0	0	0	0	1
07/24/2024 06:00	0.0	0	0	0	0	1
07/24/2024 07:00	0.0	0	0	0	0	1
07/24/2024 08:00	0.0	0	0	0	0	1
07/24/2024 09:00	0.0	0	0	0	0	1
07/24/2024 10:00	0.0	0	0	0	0	1
07/24/2024 11:00	0.0	0	0	0	0	1
07/24/2024 12:00	0.0	0	0	0	0	1
07/24/2024 13:00	0.0	0	0	0	0	1
07/24/2024 14:00	0.0	0	0	0	0	1
07/24/2024 15:00	0.0	0	0	0	0	1
07/24/2024 16:00	0.0	0	0	0	0	1
07/24/2024 17:00	0.0	0	0	0	0	1
07/24/2024 18:00	0.0	0	0	0	0	1
07/24/2024 19:00	0.0	0	0	0	0	1
07/24/2024 20:00	0.0	0	0	0	0	1
07/24/2024 21:00	0.0	0	0	0	0	1
07/24/2024 22:00	0.0	0	0	0	0	1
07/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2024 00:00	0.0	0	0	0	0	1
07/25/2024 01:00	0.0	0	0	0	0	1
07/25/2024 02:00	0.0	0	0	0	0	1
07/25/2024 03:00	0.0	0	0	0	0	1
07/25/2024 04:00	0.0	0	0	0	0	1
07/25/2024 05:00	0.0	0	0	0	0	1
07/25/2024 06:00	0.0	0	0	0	0	1
07/25/2024 07:00	0.0	0	0	0	0	1
07/25/2024 08:00	0.0	0	0	0	0	1
07/25/2024 09:00	0.0	0	0	0	0	1
07/25/2024 10:00	0.0	0	0	0	0	1
07/25/2024 11:00	0.0	0	0	0	0	1
07/25/2024 12:00	0.0	0	0	0	0	1
07/25/2024 13:00	0.0	0	0	0	0	1
07/25/2024 14:00	0.0	0	0	0	0	1
07/25/2024 15:00	0.0	0	0	0	0	1
07/25/2024 16:00	0.0	0	0	0	0	1
07/25/2024 17:00	0.0	0	0	0	0	1
07/25/2024 18:00	0.0	0	0	0	0	1
07/25/2024 19:00	0.0	0	0	0	0	1
07/25/2024 20:00	0.0	0	0	0	0	1
07/25/2024 21:00	0.0	0	0	0	0	1
07/25/2024 22:00	0.0	0	0	0	0	1
07/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2024 00:00	0.0	0	0	0	0	1
07/26/2024 01:00	0.0	0	0	0	0	1
07/26/2024 02:00	0.0	0	0	0	0	1
07/26/2024 03:00	0.0	0	0	0	0	1
07/26/2024 04:00	0.0	0	0	0	0	1
07/26/2024 05:00	0.0	0	0	0	0	1
07/26/2024 06:00	0.0	0	0	0	0	1
07/26/2024 07:00	0.0	0	0	0	0	1
07/26/2024 08:00	0.0	0	0	0	0	1
07/26/2024 09:00	0.0	0	0	0	0	1
07/26/2024 10:00	0.0	0	0	0	0	1
07/26/2024 11:00	0.0	0	0	0	0	1
07/26/2024 12:00	0.0	0	0	0	0	1
07/26/2024 13:00	0.0	0	0	0	0	1
07/26/2024 14:00	0.0	0	0	0	0	1
07/26/2024 15:00	0.0	0	0	0	0	1
07/26/2024 16:00	0.0	0	0	0	0	1
07/26/2024 17:00	0.0	0	0	0	0	1
07/26/2024 18:00	0.0	0	0	0	0	1
07/26/2024 19:00	0.0	0	0	0	0	1
07/26/2024 20:00	0.0	0	0	0	0	1
07/26/2024 21:00	0.0	0	0	0	0	1
07/26/2024 22:00	0.0	0	0	0	0	1
07/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2024 00:00	0.0	0	0	0	0	1
07/27/2024 01:00	0.0	0	0	0	0	1
07/27/2024 02:00	0.0	0	0	0	0	1
07/27/2024 03:00	0.0	0	0	0	0	1
07/27/2024 04:00	0.0	0	0	0	0	1
07/27/2024 05:00	0.0	0	0	0	0	1
07/27/2024 06:00	0.0	0	0	0	1	0
07/27/2024 07:00	0.0	0	0	0	0	0
07/27/2024 08:00	0.0	0	0	0	0	0
07/27/2024 09:00	0.0	0	0	0	0	0
07/27/2024 10:00	0.0	0	0	0	0	0
07/27/2024 11:00	0.0	0	0	0	0	0
07/27/2024 12:00	0.0	0	0	0	0	0
07/27/2024 13:00	0.0	0	0	0	0	0
07/27/2024 14:00	0.0	0	0	0	0	0
07/27/2024 15:00	22.0	0	1	0	0	0
07/27/2024 16:00	32.0	0	1	0	0	0
07/27/2024 17:00	0.0	0	0	0	0	1
07/27/2024 18:00	0.0	0	0	0	0	1
07/27/2024 19:00	0.0	0	0	0	0	1
07/27/2024 20:00	0.0	0	0	0	0	1
07/27/2024 21:00	0.0	0	0	0	0	1
07/27/2024 22:00	0.0	0	0	0	0	1
07/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.0 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2024 00:00	0.0	0	0	0	0	1
07/28/2024 01:00	0.0	0	0	0	0	1
07/28/2024 02:00	0.0	0	0	0	0	1
07/28/2024 03:00	0.0	0	0	0	0	1
07/28/2024 04:00	0.0	0	0	0	0	1
07/28/2024 05:00	0.0	0	0	0	0	1
07/28/2024 06:00	0.0	0	0	0	0	1
07/28/2024 07:00	1.5	0	0	0	1	0
07/28/2024 08:00	0.0	0	0	0	0	0
07/28/2024 09:00	0.0	0	0	0	0	0
07/28/2024 10:00	0.0	0	0	0	0	0
07/28/2024 11:00	0.0	0	0	0	0	0
07/28/2024 12:00	0.0	0	0	0	0	0
07/28/2024 13:00	0.0	0	0	0	0	0
07/28/2024 14:00	23.3	0	0	1	0	0
07/28/2024 15:00	15.3	0	0	1	0	0
07/28/2024 16:00	0.0	0	0	0	0	1
07/28/2024 17:00	0.0	0	0	0	0	1
07/28/2024 18:00	0.0	0	0	0	0	1
07/28/2024 19:00	0.0	0	0	0	0	1
07/28/2024 20:00	0.0	0	0	0	0	1
07/28/2024 21:00	0.0	0	0	0	0	1
07/28/2024 22:00	0.0	0	0	0	0	1
07/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	40.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2024 00:00	0.0	0	0	0	0	1
07/29/2024 01:00	0.0	0	0	0	0	1
07/29/2024 02:00	0.0	0	0	0	0	1
07/29/2024 03:00	0.5	0	0	0	1	0
07/29/2024 04:00	0.0	0	0	0	0	0
07/29/2024 05:00	0.0	0	0	0	0	0
07/29/2024 06:00	0.0	0	0	0	0	0
07/29/2024 07:00	0.0	0	0	0	0	0
07/29/2024 08:00	0.0	0	0	0	0	0
07/29/2024 09:00	0.0	0	0	0	0	0
07/29/2024 10:00	0.0	0	0	0	0	0
07/29/2024 11:00	0.0	0	0	0	0	0
07/29/2024 12:00	0.0	0	0	0	0	0
07/29/2024 13:00	0.0	0	0	0	0	0
07/29/2024 14:00	0.0	0	1	0	0	0
07/29/2024 15:00	52.1	0	1	0	0	0
07/29/2024 16:00	11.4	0	1	0	0	0
07/29/2024 17:00	0.0	0	0	0	0	1
07/29/2024 18:00	0.0	0	0	0	0	1
07/29/2024 19:00	0.0	0	0	0	0	1
07/29/2024 20:00	0.0	0	0	0	0	1
07/29/2024 21:00	0.0	0	0	0	0	1
07/29/2024 22:00	0.0	0	0	0	0	1
07/29/2024 23:00	0.6	0	0	0	1	0
Average/Sum#:	64.6 #	0 #	3 #	0 #	2 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2024 00:00	0.0	0	0	0	0	0
07/30/2024 01:00	0.0	0	0	0	0	0
07/30/2024 02:00	0.0	0	0	0	0	0
07/30/2024 03:00	0.0	0	0	0	0	0
07/30/2024 04:00	0.0	0	0	0	0	0
07/30/2024 05:00	0.0	0	0	0	0	0
07/30/2024 06:00	0.0	0	0	0	0	0
07/30/2024 07:00	0.0	0	0	0	0	0
07/30/2024 08:00	0.0	0	0	0	0	0
07/30/2024 09:00	0.0	0	0	0	0	0
07/30/2024 10:00	0.0	0	0	0	0	0
07/30/2024 11:00	0.0	0	0	0	0	0
07/30/2024 12:00	0.0	0	0	0	0	0
07/30/2024 13:00	0.0	0	0	0	0	0
07/30/2024 14:00	0.0	0	0	0	0	0
07/30/2024 15:00	59.4	0	1	0	0	0
07/30/2024 16:00	16.9	0	1	0	0	0
07/30/2024 17:00	0.0	0	0	0	0	1
07/30/2024 18:00	0.0	0	0	0	0	1
07/30/2024 19:00	0.0	0	0	0	0	1
07/30/2024 20:00	0.0	0	0	0	0	1
07/30/2024 21:00	0.0	0	0	0	0	1
07/30/2024 22:00	0.0	0	0	0	0	1
07/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.3 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2024 00:00	0.0	0	0	0	0	1
07/31/2024 01:00	0.0	0	0	0	0	1
07/31/2024 02:00	0.0	0	0	0	0	1
07/31/2024 03:00	0.0	0	0	0	0	1
07/31/2024 04:00	0.0	0	0	0	0	1
07/31/2024 05:00	0.0	0	0	0	0	1
07/31/2024 06:00	0.0	0	0	0	0	1
07/31/2024 07:00	0.0	0	0	0	0	1
07/31/2024 08:00	0.0	0	0	0	0	1
07/31/2024 09:00	0.0	0	0	0	0	1
07/31/2024 10:00	0.0	0	0	0	0	1
07/31/2024 11:00	0.0	0	0	0	0	1
07/31/2024 12:00	0.0	0	0	0	0	1
07/31/2024 13:00	0.0	0	0	0	0	1
07/31/2024 14:00	0.0	0	0	0	0	1
07/31/2024 15:00	0.0	0	0	0	0	1
07/31/2024 16:00	0.0	0	0	0	0	1
07/31/2024 17:00	0.0	0	0	0	0	1
07/31/2024 18:00	0.0	0	0	0	0	1
07/31/2024 19:00	0.0	0	0	0	0	1
07/31/2024 20:00	0.0	0	0	0	0	1
07/31/2024 21:00	0.0	0	0	0	0	1
07/31/2024 22:00	0.0	0	0	0	0	1
07/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2024 00:00	0.0	0	0	0	0	1
08/01/2024 01:00	0.0	0	0	0	0	1
08/01/2024 02:00	0.0	0	0	0	0	1
08/01/2024 03:00	0.0	0	0	0	0	1
08/01/2024 04:00	0.0	0	0	0	0	1
08/01/2024 05:00	0.0	0	0	0	0	1
08/01/2024 06:00	0.0	0	0	0	0	1
08/01/2024 07:00	0.0	0	0	0	0	1
08/01/2024 08:00	0.0	0	0	0	0	1
08/01/2024 09:00	0.0	0	0	0	0	1
08/01/2024 10:00	0.0	0	0	0	0	1
08/01/2024 11:00	0.0	0	0	0	0	1
08/01/2024 12:00	0.0	0	0	0	0	1
08/01/2024 13:00	0.0	0	0	0	0	1
08/01/2024 14:00	0.0	0	0	0	0	1
08/01/2024 15:00	0.0	0	0	0	0	1
08/01/2024 16:00	0.0	0	0	0	0	1
08/01/2024 17:00	0.0	0	0	0	0	1
08/01/2024 18:00	0.0	0	0	0	0	1
08/01/2024 19:00	0.0	0	0	0	0	1
08/01/2024 20:00	0.0	0	0	0	0	1
08/01/2024 21:00	0.0	0	0	0	0	1
08/01/2024 22:00	0.0	0	0	0	0	1
08/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2024 00:00	0.0	0	0	0	0	1
08/02/2024 01:00	0.0	0	0	0	0	1
08/02/2024 02:00	0.0	0	0	0	0	1
08/02/2024 03:00	0.0	0	0	0	0	1
08/02/2024 04:00	0.0	0	0	0	0	1
08/02/2024 05:00	0.0	0	0	0	0	1
08/02/2024 06:00	0.0	0	0	0	0	1
08/02/2024 07:00	0.0	0	0	0	0	1
08/02/2024 08:00	0.0	0	0	0	0	1
08/02/2024 09:00	0.0	0	0	0	0	1
08/02/2024 10:00	0.0	0	0	0	0	1
08/02/2024 11:00	0.0	0	0	0	0	1
08/02/2024 12:00	0.0	0	0	0	0	1
08/02/2024 13:00	0.0	0	0	0	0	1
08/02/2024 14:00	0.0	0	0	0	0	1
08/02/2024 15:00	0.0	0	0	0	0	1
08/02/2024 16:00	0.0	0	0	0	0	1
08/02/2024 17:00	0.0	0	0	0	0	1
08/02/2024 18:00	0.0	0	0	0	0	1
08/02/2024 19:00	0.0	0	0	0	0	1
08/02/2024 20:00	0.0	0	0	0	0	1
08/02/2024 21:00	0.0	0	0	0	0	1
08/02/2024 22:00	0.0	0	0	0	0	1
08/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2024 00:00	0.0	0	0	0	0	1
08/03/2024 01:00	0.0	0	0	0	0	1
08/03/2024 02:00	0.0	0	0	0	0	1
08/03/2024 03:00	0.0	0	0	0	0	1
08/03/2024 04:00	0.0	0	0	0	0	1
08/03/2024 05:00	0.0	0	0	0	0	1
08/03/2024 06:00	0.0	0	0	0	0	1
08/03/2024 07:00	0.0	0	0	0	0	1
08/03/2024 08:00	0.0	0	0	0	0	1
08/03/2024 09:00	0.0	0	0	0	0	1
08/03/2024 10:00	0.0	0	0	0	0	1
08/03/2024 11:00	0.0	0	0	0	0	1
08/03/2024 12:00	0.0	0	0	0	0	1
08/03/2024 13:00	0.0	0	0	0	0	1
08/03/2024 14:00	0.0	0	0	0	0	1
08/03/2024 15:00	0.0	0	0	0	0	1
08/03/2024 16:00	0.0	0	0	0	0	1
08/03/2024 17:00	0.0	0	0	0	0	1
08/03/2024 18:00	0.0	0	0	0	0	1
08/03/2024 19:00	0.0	0	0	0	0	1
08/03/2024 20:00	0.0	0	0	0	0	1
08/03/2024 21:00	0.0	0	0	0	0	1
08/03/2024 22:00	0.0	0	0	0	0	1
08/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2024 00:00	0.0	0	0	0	0	1
08/04/2024 01:00	0.0	0	0	0	0	1
08/04/2024 02:00	0.0	0	0	0	0	1
08/04/2024 03:00	0.0	0	0	0	0	1
08/04/2024 04:00	0.0	0	0	0	0	1
08/04/2024 05:00	0.0	0	0	0	0	1
08/04/2024 06:00	0.0	0	0	0	0	1
08/04/2024 07:00	0.0	0	0	0	0	1
08/04/2024 08:00	0.0	0	0	0	0	1
08/04/2024 09:00	0.0	0	0	0	0	1
08/04/2024 10:00	0.0	0	0	0	0	1
08/04/2024 11:00	0.0	0	0	0	0	1
08/04/2024 12:00	0.0	0	0	0	0	1
08/04/2024 13:00	0.0	0	0	0	0	1
08/04/2024 14:00	0.0	0	0	0	0	1
08/04/2024 15:00	0.0	0	0	0	0	1
08/04/2024 16:00	0.0	0	0	0	0	1
08/04/2024 17:00	0.0	0	0	0	0	1
08/04/2024 18:00	0.0	0	0	0	0	1
08/04/2024 19:00	0.0	0	0	0	0	1
08/04/2024 20:00	0.0	0	0	0	0	1
08/04/2024 21:00	0.0	0	0	0	0	1
08/04/2024 22:00	0.0	0	0	0	0	1
08/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2024 00:00	0.0	0	0	0	0	1
08/05/2024 01:00	0.0	0	0	0	0	1
08/05/2024 02:00	0.0	0	0	0	0	1
08/05/2024 03:00	0.0	0	0	0	0	1
08/05/2024 04:00	0.0	0	0	0	0	1
08/05/2024 05:00	0.0	0	0	0	0	1
08/05/2024 06:00	0.0	0	0	0	0	1
08/05/2024 07:00	0.0	0	0	0	0	1
08/05/2024 08:00	0.0	0	0	0	0	1
08/05/2024 09:00	0.0	0	0	0	0	1
08/05/2024 10:00	0.0	0	0	0	0	1
08/05/2024 11:00	0.0	0	0	0	0	1
08/05/2024 12:00	0.0	0	0	0	0	1
08/05/2024 13:00	0.0	0	0	0	0	1
08/05/2024 14:00	0.0	0	0	0	0	1
08/05/2024 15:00	0.0	0	0	0	0	1
08/05/2024 16:00	0.0	0	0	0	0	1
08/05/2024 17:00	0.0	0	0	0	0	1
08/05/2024 18:00	0.0	0	0	0	0	1
08/05/2024 19:00	0.0	0	0	0	0	1
08/05/2024 20:00	0.0	0	0	0	0	1
08/05/2024 21:00	0.0	0	0	0	0	1
08/05/2024 22:00	0.0	0	0	0	0	1
08/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2024 00:00	0.0	0	0	0	0	1
08/06/2024 01:00	0.0	0	0	0	0	1
08/06/2024 02:00	0.0	0	0	0	0	1
08/06/2024 03:00	0.0	0	0	0	0	1
08/06/2024 04:00	0.0	0	0	0	0	1
08/06/2024 05:00	0.0	0	0	0	0	1
08/06/2024 06:00	0.0	0	0	0	0	1
08/06/2024 07:00	0.0	0	0	0	0	1
08/06/2024 08:00	0.0	0	0	0	0	1
08/06/2024 09:00	0.0	0	0	0	0	1
08/06/2024 10:00	0.0	0	0	0	0	1
08/06/2024 11:00	0.0	0	0	0	0	1
08/06/2024 12:00	0.0	0	0	0	0	1
08/06/2024 13:00	0.0	0	0	0	0	1
08/06/2024 14:00	0.0	0	0	0	0	1
08/06/2024 15:00	0.0	0	0	0	0	1
08/06/2024 16:00	0.0	0	0	0	0	1
08/06/2024 17:00	0.0	0	0	0	0	1
08/06/2024 18:00	0.0	0	0	0	0	1
08/06/2024 19:00	0.0	0	0	0	0	1
08/06/2024 20:00	0.0	0	0	0	0	1
08/06/2024 21:00	0.0	0	0	0	0	1
08/06/2024 22:00	0.0	0	0	0	0	1
08/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2024 00:00	0.0	0	0	0	0	1
08/07/2024 01:00	0.0	0	0	0	0	1
08/07/2024 02:00	0.0	0	0	0	0	1
08/07/2024 03:00	0.0	0	0	0	0	1
08/07/2024 04:00	0.0	0	0	0	0	1
08/07/2024 05:00	0.0	0	0	0	0	1
08/07/2024 06:00	0.0	0	0	0	0	1
08/07/2024 07:00	0.0	0	0	0	0	1
08/07/2024 08:00	0.0	0	0	0	0	1
08/07/2024 09:00	0.0	0	0	0	0	1
08/07/2024 10:00	0.0	0	0	0	0	1
08/07/2024 11:00	0.0	0	0	0	0	1
08/07/2024 12:00	0.0	0	0	0	0	1
08/07/2024 13:00	0.0	0	0	0	0	1
08/07/2024 14:00	0.0	0	0	0	0	1
08/07/2024 15:00	0.0	0	0	0	0	1
08/07/2024 16:00	0.0	0	0	0	0	1
08/07/2024 17:00	0.0	0	0	0	0	1
08/07/2024 18:00	0.0	0	0	0	0	1
08/07/2024 19:00	0.0	0	0	0	0	1
08/07/2024 20:00	0.0	0	0	0	0	1
08/07/2024 21:00	0.0	0	0	0	0	1
08/07/2024 22:00	0.0	0	0	0	0	1
08/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2024 00:00	0.0	0	0	0	0	1
08/08/2024 01:00	0.0	0	0	0	0	1
08/08/2024 02:00	0.0	0	0	0	0	1
08/08/2024 03:00	0.0	0	0	0	0	1
08/08/2024 04:00	0.0	0	0	0	0	1
08/08/2024 05:00	0.0	0	0	0	0	1
08/08/2024 06:00	0.0	0	0	0	0	1
08/08/2024 07:00	0.0	0	0	0	0	1
08/08/2024 08:00	0.0	0	0	0	0	1
08/08/2024 09:00	0.0	0	0	0	0	1
08/08/2024 10:00	0.0	0	0	0	0	1
08/08/2024 11:00	0.0	0	0	0	0	1
08/08/2024 12:00	0.0	0	0	0	0	1
08/08/2024 13:00	0.0	0	0	0	0	1
08/08/2024 14:00	0.0	0	0	0	0	1
08/08/2024 15:00	0.0	0	0	0	0	1
08/08/2024 16:00	0.0	0	0	0	0	1
08/08/2024 17:00	0.0	0	0	0	0	1
08/08/2024 18:00	0.0	0	0	0	0	1
08/08/2024 19:00	0.0	0	0	0	0	1
08/08/2024 20:00	0.0	0	0	0	0	1
08/08/2024 21:00	0.0	0	0	0	0	1
08/08/2024 22:00	0.0	0	0	0	0	1
08/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2024 00:00	0.0	0	0	0	0	1
08/09/2024 01:00	0.0	0	0	0	0	1
08/09/2024 02:00	0.0	0	0	0	0	1
08/09/2024 03:00	0.0	0	0	0	0	1
08/09/2024 04:00	0.0	0	0	0	0	1
08/09/2024 05:00	0.0	0	0	0	0	1
08/09/2024 06:00	0.0	0	0	0	0	1
08/09/2024 07:00	0.0	0	0	0	0	1
08/09/2024 08:00	0.0	0	0	0	0	1
08/09/2024 09:00	0.0	0	0	0	0	1
08/09/2024 10:00	0.0	0	0	0	0	1
08/09/2024 11:00	0.0	0	0	0	0	1
08/09/2024 12:00	0.0	0	0	0	0	1
08/09/2024 13:00	0.0	0	0	0	0	1
08/09/2024 14:00	0.0	0	0	0	0	1
08/09/2024 15:00	0.0	0	0	0	0	1
08/09/2024 16:00	0.0	0	0	0	0	1
08/09/2024 17:00	0.0	0	0	0	0	1
08/09/2024 18:00	0.0	0	0	0	0	1
08/09/2024 19:00	0.0	0	0	0	0	1
08/09/2024 20:00	0.0	0	0	0	0	1
08/09/2024 21:00	0.8	0	0	0	1	0
08/09/2024 22:00	0.0	0	0	0	0	0
08/09/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2024 00:00	0.0	0	0	0	0	0
08/10/2024 01:00	0.0	0	0	0	0	0
08/10/2024 02:00	0.0	0	0	0	0	0
08/10/2024 03:00	0.0	0	0	0	0	0
08/10/2024 04:00	0.0	0	0	0	0	0
08/10/2024 05:00	0.0	0	0	0	0	0
08/10/2024 06:00	0.0	0	0	0	0	0
08/10/2024 07:00	0.0	0	0	0	0	0
08/10/2024 08:00	0.0	0	0	0	0	0
08/10/2024 09:00	0.0	0	0	0	0	0
08/10/2024 10:00	0.0	0	0	0	0	0
08/10/2024 11:00	0.0	0	0	0	0	0
08/10/2024 12:00	0.0	0	0	0	0	0
08/10/2024 13:00	44.1	0	1	0	0	0
08/10/2024 14:00	22.9	0	1	0	0	0
08/10/2024 15:00	25.3	0	1	0	0	0
08/10/2024 16:00	0.0	0	0	0	0	1
08/10/2024 17:00	0.0	0	0	0	0	1
08/10/2024 18:00	0.0	0	0	0	0	1
08/10/2024 19:00	0.0	0	0	0	0	1
08/10/2024 20:00	0.0	0	0	0	0	1
08/10/2024 21:00	0.0	0	0	0	0	1
08/10/2024 22:00	0.0	0	0	0	0	1
08/10/2024 23:00	0.4	0	0	0	1	0
Average/Sum#:	92.7 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2024 00:00	0.0	0	0	0	0	0
08/11/2024 01:00	0.0	0	0	0	0	0
08/11/2024 02:00	0.0	0	0	0	0	0
08/11/2024 03:00	0.0	0	0	0	0	0
08/11/2024 04:00	0.0	0	0	0	0	0
08/11/2024 05:00	0.0	0	0	0	0	0
08/11/2024 06:00	0.0	0	0	0	0	0
08/11/2024 07:00	0.0	0	0	0	0	0
08/11/2024 08:00	0.0	0	0	0	0	0
08/11/2024 09:00	0.0	0	0	0	0	0
08/11/2024 10:00	0.0	0	0	0	0	0
08/11/2024 11:00	0.0	0	0	0	0	0
08/11/2024 12:00	0.0	0	0	0	0	0
08/11/2024 13:00	0.0	0	0	0	0	0
08/11/2024 14:00	0.0	0	0	0	0	0
08/11/2024 15:00	0.0	0	0	0	0	0
08/11/2024 16:00	0.0	0	0	0	0	0
08/11/2024 17:00	0.0	0	0	0	0	0
08/11/2024 18:00	0.0	0	0	0	0	0
08/11/2024 19:00	0.0	0	0	0	0	0
08/11/2024 20:00	0.0	0	0	0	0	0
08/11/2024 21:00	0.0	0	0	0	0	0
08/11/2024 22:00	0.0	0	0	0	0	0
08/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2024 00:00	0.0	0	0	0	0	0
08/12/2024 01:00	0.0	0	0	0	0	0
08/12/2024 02:00	0.0	0	0	0	0	0
08/12/2024 03:00	0.0	0	0	0	0	0
08/12/2024 04:00	0.0	0	0	0	0	0
08/12/2024 05:00	0.0	0	0	0	0	0
08/12/2024 06:00	0.0	0	0	0	0	0
08/12/2024 07:00	0.0	0	0	0	0	0
08/12/2024 08:00	0.0	0	0	0	0	0
08/12/2024 09:00	0.0	0	0	0	0	0
08/12/2024 10:00	0.0	0	0	0	0	0
08/12/2024 11:00	0.0	0	0	0	0	0
08/12/2024 12:00	0.0	0	0	0	0	0
08/12/2024 13:00	0.0	0	0	0	0	0
08/12/2024 14:00	0.0	0	0	0	0	0
08/12/2024 15:00	0.0	0	0	0	0	0
08/12/2024 16:00	0.0	0	0	0	0	0
08/12/2024 17:00	0.0	0	0	0	0	0
08/12/2024 18:00	31.6	0	1	0	0	0
08/12/2024 19:00	50.3	0	1	0	0	0
08/12/2024 20:00	3.0	0	1	0	0	0
08/12/2024 21:00	0.0	0	0	0	0	1
08/12/2024 22:00	0.0	0	0	0	0	1
08/12/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.9 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2024 00:00	0.0	0	0	0	0	1
08/13/2024 01:00	0.0	0	0	0	0	1
08/13/2024 02:00	1.0	0	0	0	1	0
08/13/2024 03:00	0.0	0	0	0	0	0
08/13/2024 04:00	0.0	0	0	0	0	0
08/13/2024 05:00	0.0	0	0	0	0	0
08/13/2024 06:00	0.0	0	0	0	0	0
08/13/2024 07:00	0.0	0	0	0	0	0
08/13/2024 08:00	0.0	0	0	0	0	0
08/13/2024 09:00	0.0	0	0	0	0	0
08/13/2024 10:00	0.0	0	0	0	0	0
08/13/2024 11:00	0.0	0	0	0	0	0
08/13/2024 12:00	0.0	0	0	0	0	0
08/13/2024 13:00	0.0	0	0	0	0	0
08/13/2024 14:00	0.0	0	0	0	0	0
08/13/2024 15:00	0.0	0	0	0	0	0
08/13/2024 16:00	51.5	0	1	0	0	0
08/13/2024 17:00	20.3	0	1	0	0	0
08/13/2024 18:00	28.2	0	1	0	0	0
08/13/2024 19:00	0.0	0	0	0	0	1
08/13/2024 20:00	0.0	0	0	0	0	1
08/13/2024 21:00	0.0	0	0	0	0	1
08/13/2024 22:00	0.0	0	0	0	0	1
08/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	101.0 #	0 #	3 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2024 00:00	0.0	0	0	0	0	1
08/14/2024 01:00	0.0	0	0	0	0	1
08/14/2024 02:00	0.9	0	0	0	1	0
08/14/2024 03:00	0.0	0	0	0	0	0
08/14/2024 04:00	0.0	0	0	0	0	0
08/14/2024 05:00	0.0	0	0	0	0	0
08/14/2024 06:00	0.0	0	0	0	0	0
08/14/2024 07:00	0.0	0	0	0	0	0
08/14/2024 08:00	0.0	0	0	0	0	0
08/14/2024 09:00	0.0	0	0	0	0	0
08/14/2024 10:00	28.1	0	1	0	0	0
08/14/2024 11:00	45.7	0	1	0	0	0
08/14/2024 12:00	0.0	0	0	0	0	1
08/14/2024 13:00	0.0	0	0	0	0	1
08/14/2024 14:00	0.0	0	0	0	0	1
08/14/2024 15:00	0.0	0	0	0	0	1
08/14/2024 16:00	0.0	0	0	0	0	1
08/14/2024 17:00	0.0	0	0	0	0	1
08/14/2024 18:00	0.0	0	0	0	0	1
08/14/2024 19:00	0.0	0	0	0	0	1
08/14/2024 20:00	0.0	0	0	0	0	1
08/14/2024 21:00	0.0	0	0	0	0	1
08/14/2024 22:00	0.0	0	0	0	0	1
08/14/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	74.7 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2024 00:00	0.8	0	0	0	1	0
08/15/2024 01:00	0.0	0	0	0	0	0
08/15/2024 02:00	0.0	0	0	0	0	0
08/15/2024 03:00	0.0	0	0	0	0	0
08/15/2024 04:00	0.0	0	0	0	0	0
08/15/2024 05:00	0.0	0	0	0	0	0
08/15/2024 06:00	0.0	0	0	0	0	0
08/15/2024 07:00	0.0	0	0	0	0	0
08/15/2024 08:00	0.0	0	0	0	0	0
08/15/2024 09:00	0.0	0	0	0	0	0
08/15/2024 10:00	0.0	0	0	0	0	0
08/15/2024 11:00	0.0	0	0	0	0	0
08/15/2024 12:00	41.2	0	1	0	0	0
08/15/2024 13:00	19.5	0	1	0	0	0
08/15/2024 14:00	37.2	0	1	0	0	0
08/15/2024 15:00	0.0	0	0	0	0	1
08/15/2024 16:00	0.0	0	0	0	0	1
08/15/2024 17:00	0.0	0	0	0	0	1
08/15/2024 18:00	0.0	0	0	0	0	1
08/15/2024 19:00	0.0	0	0	0	0	1
08/15/2024 20:00	0.0	0	0	0	0	1
08/15/2024 21:00	0.0	0	0	0	0	1
08/15/2024 22:00	0.0	0	0	0	0	1
08/15/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	98.7 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2024 00:00	0.0	0	0	0	0	1
08/16/2024 01:00	0.0	0	0	0	0	1
08/16/2024 02:00	0.8	0	0	0	1	0
08/16/2024 03:00	0.0	0	0	0	0	0
08/16/2024 04:00	0.0	0	0	0	0	0
08/16/2024 05:00	0.0	0	0	0	0	0
08/16/2024 06:00	0.0	0	0	0	0	0
08/16/2024 07:00	0.0	0	0	0	0	0
08/16/2024 08:00	0.0	0	0	0	0	0
08/16/2024 09:00	0.0	0	0	0	0	0
08/16/2024 10:00	0.0	0	0	0	0	0
08/16/2024 11:00	0.0	0	0	0	0	0
08/16/2024 12:00	35.5	0	1	0	0	0
08/16/2024 13:00	22.6	0	1	0	0	0
08/16/2024 14:00	0.0	0	0	0	0	1
08/16/2024 15:00	0.0	0	0	0	0	1
08/16/2024 16:00	0.0	0	0	0	0	1
08/16/2024 17:00	0.0	0	0	0	0	1
08/16/2024 18:00	0.0	0	0	0	0	1
08/16/2024 19:00	0.0	0	0	0	0	1
08/16/2024 20:00	0.0	0	0	0	0	1
08/16/2024 21:00	0.0	0	0	0	0	1
08/16/2024 22:00	0.0	0	0	0	0	1
08/16/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.9 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2024 00:00	0.0	0	0	0	0	1
08/17/2024 01:00	0.0	0	0	0	0	1
08/17/2024 02:00	0.0	0	0	0	0	1
08/17/2024 03:00	0.0	0	0	0	0	1
08/17/2024 04:00	0.0	0	0	0	0	1
08/17/2024 05:00	0.0	0	0	0	0	1
08/17/2024 06:00	0.0	0	0	0	1	0
08/17/2024 07:00	0.0	0	0	0	0	0
08/17/2024 08:00	0.0	0	0	0	0	0
08/17/2024 09:00	0.0	0	0	0	0	0
08/17/2024 10:00	0.0	0	0	0	0	0
08/17/2024 11:00	0.0	0	0	0	0	0
08/17/2024 12:00	0.0	0	0	0	0	0
08/17/2024 13:00	0.0	0	0	0	0	0
08/17/2024 14:00	1.6	0	1	0	0	0
08/17/2024 15:00	60.4	0	1	0	0	0
08/17/2024 16:00	0.0	0	0	0	0	1
08/17/2024 17:00	0.0	0	0	0	0	1
08/17/2024 18:00	0.0	0	0	0	0	1
08/17/2024 19:00	0.0	0	0	0	0	1
08/17/2024 20:00	0.0	0	0	0	0	1
08/17/2024 21:00	0.0	0	0	0	0	1
08/17/2024 22:00	0.0	0	0	0	0	1
08/17/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.0 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2024 00:00	0.0	0	0	0	0	1
08/18/2024 01:00	0.0	0	0	0	0	1
08/18/2024 02:00	0.5	0	0	0	1	0
08/18/2024 03:00	0.0	0	0	0	0	0
08/18/2024 04:00	0.0	0	0	0	0	0
08/18/2024 05:00	0.0	0	0	0	0	0
08/18/2024 06:00	0.0	0	0	0	0	0
08/18/2024 07:00	0.0	0	0	0	0	0
08/18/2024 08:00	0.0	0	0	0	0	0
08/18/2024 09:00	0.0	0	0	0	0	0
08/18/2024 10:00	0.0	0	0	0	0	0
08/18/2024 11:00	0.0	0	0	0	0	0
08/18/2024 12:00	0.0	0	0	0	0	0
08/18/2024 13:00	0.0	0	0	0	0	0
08/18/2024 14:00	36.0	0	1	0	0	0
08/18/2024 15:00	32.4	0	1	0	0	0
08/18/2024 16:00	0.0	0	0	0	0	1
08/18/2024 17:00	0.0	0	0	0	0	1
08/18/2024 18:00	0.0	0	0	0	0	1
08/18/2024 19:00	0.0	0	0	0	0	1
08/18/2024 20:00	0.0	0	0	0	0	1
08/18/2024 21:00	0.0	0	0	0	0	1
08/18/2024 22:00	0.0	0	0	0	0	1
08/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.9 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2024 00:00	0.7	0	0	0	1	0
08/19/2024 01:00	0.0	0	0	0	0	0
08/19/2024 02:00	0.0	0	0	0	0	0
08/19/2024 03:00	0.0	0	0	0	0	0
08/19/2024 04:00	0.0	0	0	0	0	0
08/19/2024 05:00	0.0	0	0	0	0	0
08/19/2024 06:00	0.0	0	0	0	0	0
08/19/2024 07:00	44.7	0	0	1	0	0
08/19/2024 08:00	0.2	0	0	1	0	0
08/19/2024 09:00	0.0	0	0	0	0	1
08/19/2024 10:00	0.0	0	0	0	0	1
08/19/2024 11:00	0.0	0	0	0	0	1
08/19/2024 12:00	0.0	0	0	0	0	1
08/19/2024 13:00	0.0	0	0	0	0	1
08/19/2024 14:00	0.0	0	0	0	0	1
08/19/2024 15:00	0.0	0	0	0	0	1
08/19/2024 16:00	0.0	0	0	0	0	1
08/19/2024 17:00	0.0	0	0	0	0	1
08/19/2024 18:00	0.0	0	0	0	0	1
08/19/2024 19:00	0.0	0	0	0	0	1
08/19/2024 20:00	0.0	0	0	0	0	1
08/19/2024 21:00	0.0	0	0	0	0	1
08/19/2024 22:00	0.0	0	0	0	0	1
08/19/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	45.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2024 00:00	0.0	0	0	0	0	1
08/20/2024 01:00	1.0	0	0	0	1	0
08/20/2024 02:00	0.0	0	0	0	0	0
08/20/2024 03:00	0.0	0	0	0	0	0
08/20/2024 04:00	0.0	0	0	0	0	0
08/20/2024 05:00	0.0	0	0	0	0	0
08/20/2024 06:00	0.0	0	0	0	0	0
08/20/2024 07:00	0.0	0	0	0	0	0
08/20/2024 08:00	0.0	0	0	0	0	0
08/20/2024 09:00	0.0	0	0	0	0	0
08/20/2024 10:00	0.0	0	0	0	0	0
08/20/2024 11:00	0.0	0	0	0	0	0
08/20/2024 12:00	0.0	0	0	0	0	0
08/20/2024 13:00	45.4	0	1	0	0	0
08/20/2024 14:00	35.7	0	1	0	0	0
08/20/2024 15:00	0.0	0	0	0	0	1
08/20/2024 16:00	0.0	0	0	0	0	1
08/20/2024 17:00	0.0	0	0	0	0	1
08/20/2024 18:00	0.0	0	0	0	0	1
08/20/2024 19:00	0.0	0	0	0	0	1
08/20/2024 20:00	0.0	0	0	0	0	1
08/20/2024 21:00	0.0	0	0	0	0	1
08/20/2024 22:00	0.0	0	0	0	0	1
08/20/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	82.1 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2024 00:00	0.0	0	0	0	0	1
08/21/2024 01:00	0.0	0	0	0	0	1
08/21/2024 02:00	0.0	0	0	0	0	1
08/21/2024 03:00	0.0	0	0	0	0	1
08/21/2024 04:00	0.0	0	0	0	0	1
08/21/2024 05:00	0.0	0	0	0	0	1
08/21/2024 06:00	0.0	0	0	0	0	1
08/21/2024 07:00	0.0	0	0	0	0	1
08/21/2024 08:00	0.0	0	0	0	0	1
08/21/2024 09:00	0.0	0	0	0	0	1
08/21/2024 10:00	0.0	0	0	0	0	1
08/21/2024 11:00	0.0	0	0	0	0	1
08/21/2024 12:00	0.0	0	0	0	0	1
08/21/2024 13:00	0.0	0	0	0	0	1
08/21/2024 14:00	0.0	0	0	0	0	1
08/21/2024 15:00	0.0	0	0	0	0	1
08/21/2024 16:00	0.0	0	0	0	0	1
08/21/2024 17:00	0.0	0	0	0	0	1
08/21/2024 18:00	0.0	0	0	0	0	1
08/21/2024 19:00	0.0	0	0	0	0	1
08/21/2024 20:00	0.0	0	0	0	0	1
08/21/2024 21:00	0.0	0	0	0	0	1
08/21/2024 22:00	0.0	0	0	0	0	1
08/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2024 00:00	0.0	0	0	0	0	1
08/22/2024 01:00	0.0	0	0	0	0	1
08/22/2024 02:00	0.0	0	0	0	0	1
08/22/2024 03:00	0.0	0	0	0	0	1
08/22/2024 04:00	0.0	0	0	0	0	1
08/22/2024 05:00	0.0	0	0	0	0	1
08/22/2024 06:00	0.0	0	0	0	1	0
08/22/2024 07:00	0.0	0	0	0	0	0
08/22/2024 08:00	0.0	0	0	0	0	0
08/22/2024 09:00	0.0	0	0	0	0	0
08/22/2024 10:00	0.0	0	0	0	0	0
08/22/2024 11:00	0.0	0	0	0	0	0
08/22/2024 12:00	0.0	0	0	0	0	0
08/22/2024 13:00	0.0	0	0	0	0	0
08/22/2024 14:00	0.0	0	0	0	0	0
08/22/2024 15:00	0.0	0	0	0	0	0
08/22/2024 16:00	0.0	0	0	0	0	0
08/22/2024 17:00	0.0	0	0	0	0	0
08/22/2024 18:00	0.0	0	0	0	0	0
08/22/2024 19:00	0.0	0	0	0	0	0
08/22/2024 20:00	0.0	0	0	0	0	0
08/22/2024 21:00	0.0	0	0	0	0	0
08/22/2024 22:00	0.0	0	0	0	0	0
08/22/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2024 00:00	0.0	0	0	0	0	0
08/23/2024 01:00	0.0	0	0	0	0	0
08/23/2024 02:00	0.0	0	0	0	0	0
08/23/2024 03:00	0.0	0	0	0	0	0
08/23/2024 04:00	0.0	0	0	0	0	0
08/23/2024 05:00	0.0	0	0	0	0	0
08/23/2024 06:00	0.0	0	0	0	0	0
08/23/2024 07:00	0.0	0	0	0	0	0
08/23/2024 08:00	0.0	0	0	0	0	0
08/23/2024 09:00	0.0	0	0	0	0	0
08/23/2024 10:00	0.0	0	0	0	0	0
08/23/2024 11:00	0.0	0	0	0	0	0
08/23/2024 12:00	0.0	0	0	0	0	0
08/23/2024 13:00	0.0	0	0	0	0	0
08/23/2024 14:00	0.0	0	0	0	0	0
08/23/2024 15:00	0.0	0	0	0	0	0
08/23/2024 16:00	0.0	0	0	0	0	0
08/23/2024 17:00	0.0	0	0	0	0	0
08/23/2024 18:00	0.0	0	0	0	0	0
08/23/2024 19:00	0.0	0	0	0	0	0
08/23/2024 20:00	0.0	0	0	0	0	0
08/23/2024 21:00	0.0	0	0	0	0	0
08/23/2024 22:00	0.0	0	0	0	0	0
08/23/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2024 00:00	0.0	0	0	0	0	0
08/24/2024 01:00	0.0	0	0	0	0	0
08/24/2024 02:00	0.0	0	0	0	0	0
08/24/2024 03:00	0.0	0	0	0	0	0
08/24/2024 04:00	0.0	0	0	0	0	0
08/24/2024 05:00	0.0	0	0	0	0	0
08/24/2024 06:00	0.0	0	0	0	0	0
08/24/2024 07:00	0.0	0	0	0	0	0
08/24/2024 08:00	0.0	0	0	0	0	0
08/24/2024 09:00	0.0	0	0	0	0	0
08/24/2024 10:00	0.0	0	0	0	0	0
08/24/2024 11:00	0.0	0	0	0	0	0
08/24/2024 12:00	0.0	0	0	0	0	0
08/24/2024 13:00	0.0	0	0	0	0	0
08/24/2024 14:00	0.0	0	0	0	0	0
08/24/2024 15:00	0.0	0	0	0	0	0
08/24/2024 16:00	0.0	0	0	0	0	0
08/24/2024 17:00	0.0	0	0	0	0	0
08/24/2024 18:00	0.0	0	0	0	0	0
08/24/2024 19:00	0.0	0	0	0	0	0
08/24/2024 20:00	0.0	0	0	0	0	0
08/24/2024 21:00	0.0	0	0	0	0	0
08/24/2024 22:00	0.0	0	0	0	0	0
08/24/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2024 00:00	0.0	0	0	0	0	0
08/25/2024 01:00	0.0	0	0	0	0	0
08/25/2024 02:00	0.0	0	0	0	0	0
08/25/2024 03:00	0.0	0	0	0	0	0
08/25/2024 04:00	0.0	0	0	0	0	0
08/25/2024 05:00	0.0	0	0	0	0	0
08/25/2024 06:00	0.0	0	0	0	0	0
08/25/2024 07:00	0.0	0	0	0	0	0
08/25/2024 08:00	0.0	0	0	0	0	0
08/25/2024 09:00	0.0	0	0	0	0	0
08/25/2024 10:00	0.0	0	0	0	0	0
08/25/2024 11:00	0.0	0	0	0	0	0
08/25/2024 12:00	0.0	0	0	0	0	0
08/25/2024 13:00	0.0	0	0	0	0	0
08/25/2024 14:00	0.0	0	0	0	0	0
08/25/2024 15:00	0.0	0	0	0	0	0
08/25/2024 16:00	0.0	0	0	0	0	0
08/25/2024 17:00	0.0	0	0	0	0	0
08/25/2024 18:00	0.0	0	0	0	0	0
08/25/2024 19:00	0.0	0	0	0	0	0
08/25/2024 20:00	0.0	0	0	0	0	0
08/25/2024 21:00	0.0	0	0	0	0	0
08/25/2024 22:00	0.0	0	0	0	0	0
08/25/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2024 00:00	1.4	1	0	0	1	0
08/26/2024 01:00	0.0	0	0	0	0	0
08/26/2024 02:00	0.0	0	0	0	0	0
08/26/2024 03:00	0.0	0	0	0	0	0
08/26/2024 04:00	0.0	0	0	0	0	0
08/26/2024 05:00	0.0	0	0	0	0	0
08/26/2024 06:00	0.0	0	0	0	0	0
08/26/2024 07:00	56.5	1	0	0	0	0
08/26/2024 08:00	0.0	1	0	0	0	0
08/26/2024 09:00	0.0	0	0	0	0	1
08/26/2024 10:00	0.0	0	0	0	0	1
08/26/2024 11:00	0.0	0	0	0	0	1
08/26/2024 12:00	0.0	0	0	0	0	1
08/26/2024 13:00	0.0	0	0	0	0	1
08/26/2024 14:00	0.0	0	0	0	0	1
08/26/2024 15:00	0.0	0	0	0	0	1
08/26/2024 16:00	0.0	0	0	0	0	1
08/26/2024 17:00	0.0	0	0	0	0	1
08/26/2024 18:00	0.0	0	0	0	0	1
08/26/2024 19:00	0.0	0	0	0	0	1
08/26/2024 20:00	0.0	0	0	0	0	1
08/26/2024 21:00	0.0	0	0	0	0	1
08/26/2024 22:00	0.0	0	0	0	0	1
08/26/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.9 #	3 #	0 #	0 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2024 00:00	0.0	0	0	0	0	1
08/27/2024 01:00	0.0	0	0	0	0	1
08/27/2024 02:00	0.0	0	0	0	0	1
08/27/2024 03:00	0.0	0	0	0	0	1
08/27/2024 04:00	0.0	0	0	0	0	1
08/27/2024 05:00	0.0	0	0	0	0	1
08/27/2024 06:00	0.0	0	0	0	0	1
08/27/2024 07:00	0.0	0	0	0	0	1
08/27/2024 08:00	0.0	0	0	0	0	1
08/27/2024 09:00	0.0	0	0	0	0	1
08/27/2024 10:00	0.0	0	0	0	0	1
08/27/2024 11:00	0.0	0	0	0	0	1
08/27/2024 12:00	0.0	0	0	0	0	1
08/27/2024 13:00	0.0	0	0	0	0	1
08/27/2024 14:00	0.0	0	0	0	0	1
08/27/2024 15:00	0.0	0	0	0	0	1
08/27/2024 16:00	0.0	0	0	0	0	1
08/27/2024 17:00	0.0	0	0	0	0	1
08/27/2024 18:00	0.0	0	0	0	0	1
08/27/2024 19:00	0.0	0	0	0	0	1
08/27/2024 20:00	0.0	0	0	0	0	1
08/27/2024 21:00	0.0	0	0	0	0	1
08/27/2024 22:00	0.0	0	0	0	0	1
08/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2024 00:00	0.0	0	0	0	0	1
08/28/2024 01:00	0.0	0	0	0	0	1
08/28/2024 02:00	0.0	0	0	0	0	1
08/28/2024 03:00	0.0	0	0	0	0	1
08/28/2024 04:00	0.0	0	0	0	0	1
08/28/2024 05:00	0.0	0	0	0	0	1
08/28/2024 06:00	0.0	0	0	0	0	1
08/28/2024 07:00	0.0	0	0	0	0	1
08/28/2024 08:00	0.0	0	0	0	0	1
08/28/2024 09:00	0.0	0	0	0	0	1
08/28/2024 10:00	0.0	0	0	0	0	1
08/28/2024 11:00	0.0	0	0	0	0	1
08/28/2024 12:00	0.0	0	0	0	0	1
08/28/2024 13:00	0.0	0	0	0	0	1
08/28/2024 14:00	0.0	0	0	0	0	1
08/28/2024 15:00	0.0	0	0	0	0	1
08/28/2024 16:00	0.0	0	0	0	0	1
08/28/2024 17:00	0.0	0	0	0	0	1
08/28/2024 18:00	0.0	0	0	0	0	1
08/28/2024 19:00	0.0	0	0	0	0	1
08/28/2024 20:00	0.0	0	0	0	0	1
08/28/2024 21:00	0.0	0	0	0	0	1
08/28/2024 22:00	0.0	0	0	0	0	1
08/28/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2024 00:00	0.0	0	0	0	0	1
08/29/2024 01:00	0.0	0	0	0	0	1
08/29/2024 02:00	0.0	0	0	0	0	1
08/29/2024 03:00	0.0	0	0	0	0	1
08/29/2024 04:00	0.0	0	0	0	0	1
08/29/2024 05:00	0.0	0	0	0	0	1
08/29/2024 06:00	0.0	0	0	0	0	1
08/29/2024 07:00	0.0	0	0	0	0	1
08/29/2024 08:00	0.0	0	0	0	0	1
08/29/2024 09:00	0.0	0	0	0	0	1
08/29/2024 10:00	0.0	0	0	0	0	1
08/29/2024 11:00	0.0	0	0	0	0	1
08/29/2024 12:00	0.0	0	0	0	0	1
08/29/2024 13:00	0.0	0	0	0	0	1
08/29/2024 14:00	0.0	0	0	0	0	1
08/29/2024 15:00	0.0	0	0	0	0	1
08/29/2024 16:00	0.0	0	0	0	0	1
08/29/2024 17:00	0.0	0	0	0	0	1
08/29/2024 18:00	0.0	0	0	0	0	1
08/29/2024 19:00	0.0	0	0	0	0	1
08/29/2024 20:00	0.0	0	0	0	0	1
08/29/2024 21:00	0.0	0	0	0	0	1
08/29/2024 22:00	0.0	0	0	0	0	1
08/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2024 00:00	0.0	0	0	0	0	1
08/30/2024 01:00	0.0	0	0	0	0	1
08/30/2024 02:00	0.0	0	0	0	0	1
08/30/2024 03:00	0.0	0	0	0	0	1
08/30/2024 04:00	0.0	0	0	0	0	1
08/30/2024 05:00	0.0	0	0	0	0	1
08/30/2024 06:00	0.0	0	0	0	0	1
08/30/2024 07:00	0.0	0	0	0	0	1
08/30/2024 08:00	0.0	0	0	0	0	1
08/30/2024 09:00	0.0	0	0	0	0	1
08/30/2024 10:00	0.0	0	0	0	0	1
08/30/2024 11:00	0.0	0	0	0	0	1
08/30/2024 12:00	0.0	0	0	0	0	1
08/30/2024 13:00	0.0	0	0	0	0	1
08/30/2024 14:00	0.0	0	0	0	0	1
08/30/2024 15:00	0.0	0	0	0	0	1
08/30/2024 16:00	0.0	0	0	0	0	1
08/30/2024 17:00	0.0	0	0	0	0	1
08/30/2024 18:00	0.0	0	0	0	0	1
08/30/2024 19:00	0.0	0	0	0	0	1
08/30/2024 20:00	0.0	0	0	0	0	1
08/30/2024 21:00	0.0	0	0	0	0	1
08/30/2024 22:00	0.0	0	0	0	0	1
08/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2024 00:00	0.0	0	0	0	0	1
08/31/2024 01:00	0.0	0	0	0	0	1
08/31/2024 02:00	0.0	0	0	0	0	1
08/31/2024 03:00	0.0	0	0	0	0	1
08/31/2024 04:00	0.0	0	0	0	0	1
08/31/2024 05:00	0.0	0	0	0	0	1
08/31/2024 06:00	1.2	0	0	0	1	0
08/31/2024 07:00	0.0	0	0	0	0	0
08/31/2024 08:00	0.0	0	0	0	0	0
08/31/2024 09:00	0.0	0	0	0	0	0
08/31/2024 10:00	0.1	0	0	1	0	0
08/31/2024 11:00	19.5	0	0	1	0	0
08/31/2024 12:00	0.0	0	0	0	0	1
08/31/2024 13:00	0.0	0	0	0	0	1
08/31/2024 14:00	0.0	0	0	0	0	1
08/31/2024 15:00	0.0	0	0	0	0	1
08/31/2024 16:00	0.0	0	0	0	0	1
08/31/2024 17:00	0.0	0	0	0	0	1
08/31/2024 18:00	0.0	0	0	0	0	1
08/31/2024 19:00	0.0	0	0	0	0	1
08/31/2024 20:00	0.0	0	0	0	0	1
08/31/2024 21:00	0.0	0	0	0	0	1
08/31/2024 22:00	0.0	0	0	0	0	1
08/31/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	20.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2024 00:00	0.0	0	0	0	0	1
09/01/2024 01:00	0.0	0	0	0	0	1
09/01/2024 02:00	0.0	0	0	0	0	1
09/01/2024 03:00	0.0	0	0	0	0	1
09/01/2024 04:00	0.0	0	0	0	0	1
09/01/2024 05:00	0.0	0	0	0	0	1
09/01/2024 06:00	0.7	0	0	0	1	0
09/01/2024 07:00	0.0	0	0	0	0	0
09/01/2024 08:00	0.0	0	0	0	0	0
09/01/2024 09:00	0.0	0	0	0	0	0
09/01/2024 10:00	0.0	0	0	0	0	0
09/01/2024 11:00	0.0	0	0	0	0	0
09/01/2024 12:00	0.0	0	0	0	0	0
09/01/2024 13:00	0.0	0	0	0	0	0
09/01/2024 14:00	14.9	0	1	0	0	0
09/01/2024 15:00	24.2	0	1	0	0	0
09/01/2024 16:00	0.0	0	0	0	0	1
09/01/2024 17:00	0.0	0	0	0	0	1
09/01/2024 18:00	0.0	0	0	0	0	1
09/01/2024 19:00	0.0	0	0	0	0	1
09/01/2024 20:00	0.0	0	0	0	0	1
09/01/2024 21:00	0.0	0	0	0	0	1
09/01/2024 22:00	0.0	0	0	0	0	1
09/01/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2024 00:00	0.0	0	0	0	0	1
09/02/2024 01:00	0.0	0	0	0	0	1
09/02/2024 02:00	0.0	0	0	0	0	1
09/02/2024 03:00	0.0	0	0	0	0	1
09/02/2024 04:00	0.0	0	0	0	0	1
09/02/2024 05:00	0.0	0	0	0	0	1
09/02/2024 06:00	0.0	0	0	0	0	1
09/02/2024 07:00	1.2	0	0	0	1	0
09/02/2024 08:00	0.0	0	0	0	0	0
09/02/2024 09:00	0.0	0	0	0	0	0
09/02/2024 10:00	0.0	0	0	0	0	0
09/02/2024 11:00	0.0	0	0	0	0	0
09/02/2024 12:00	0.0	0	0	0	0	0
09/02/2024 13:00	0.0	0	0	0	0	0
09/02/2024 14:00	21.6	0	0	1	0	0
09/02/2024 15:00	21.9	0	0	1	0	0
09/02/2024 16:00	0.0	0	0	0	0	1
09/02/2024 17:00	0.0	0	0	0	0	1
09/02/2024 18:00	0.0	0	0	0	0	1
09/02/2024 19:00	0.0	0	0	0	0	1
09/02/2024 20:00	0.0	0	0	0	0	1
09/02/2024 21:00	0.0	0	0	0	0	1
09/02/2024 22:00	0.0	0	0	0	0	1
09/02/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.7 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2024 00:00	0.0	0	0	0	0	1
09/03/2024 01:00	0.0	0	0	0	0	1
09/03/2024 02:00	0.0	0	0	0	0	1
09/03/2024 03:00	0.0	0	0	0	0	1
09/03/2024 04:00	0.0	0	0	0	0	1
09/03/2024 05:00	0.0	0	0	0	0	1
09/03/2024 06:00	0.0	0	0	0	0	1
09/03/2024 07:00	0.0	0	0	0	0	1
09/03/2024 08:00	0.0	0	0	0	0	1
09/03/2024 09:00	0.0	0	0	0	0	1
09/03/2024 10:00	0.0	0	0	0	0	1
09/03/2024 11:00	0.0	0	0	0	0	1
09/03/2024 12:00	0.0	0	0	0	0	1
09/03/2024 13:00	0.0	0	0	0	0	1
09/03/2024 14:00	0.0	0	0	0	0	1
09/03/2024 15:00	0.0	0	0	0	0	1
09/03/2024 16:00	0.0	0	0	0	0	1
09/03/2024 17:00	0.0	0	0	0	0	1
09/03/2024 18:00	0.0	0	0	0	0	1
09/03/2024 19:00	0.0	0	0	0	0	1
09/03/2024 20:00	0.0	0	0	0	0	1
09/03/2024 21:00	0.0	0	0	0	0	1
09/03/2024 22:00	0.0	0	0	0	0	1
09/03/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2024 00:00	0.0	0	0	0	0	1
09/04/2024 01:00	0.0	0	0	0	0	1
09/04/2024 02:00	0.0	0	0	0	0	1
09/04/2024 03:00	0.0	0	0	0	0	1
09/04/2024 04:00	0.0	0	0	0	0	1
09/04/2024 05:00	0.0	0	0	0	0	1
09/04/2024 06:00	0.0	0	0	0	0	1
09/04/2024 07:00	0.0	0	0	0	0	1
09/04/2024 08:00	0.0	0	0	0	0	1
09/04/2024 09:00	0.0	0	0	0	0	1
09/04/2024 10:00	0.0	0	0	0	0	1
09/04/2024 11:00	0.0	0	0	0	0	1
09/04/2024 12:00	0.0	0	0	0	0	1
09/04/2024 13:00	0.0	0	0	0	0	1
09/04/2024 14:00	0.0	0	0	0	0	1
09/04/2024 15:00	0.0	0	0	0	0	1
09/04/2024 16:00	0.0	0	0	0	0	1
09/04/2024 17:00	0.0	0	0	0	0	1
09/04/2024 18:00	0.0	0	0	0	0	1
09/04/2024 19:00	0.0	0	0	0	0	1
09/04/2024 20:00	0.0	0	0	0	0	1
09/04/2024 21:00	0.0	0	0	0	0	1
09/04/2024 22:00	0.0	0	0	0	0	1
09/04/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2024 00:00	0.0	0	0	0	0	1
09/05/2024 01:00	0.0	0	0	0	0	1
09/05/2024 02:00	0.0	0	0	0	0	1
09/05/2024 03:00	0.0	0	0	0	0	1
09/05/2024 04:00	0.0	0	0	0	0	1
09/05/2024 05:00	0.0	0	0	0	0	1
09/05/2024 06:00	0.0	0	0	0	0	1
09/05/2024 07:00	0.0	0	0	0	0	1
09/05/2024 08:00	0.0	0	0	0	0	1
09/05/2024 09:00	0.0	0	0	0	0	1
09/05/2024 10:00	0.0	0	0	0	0	1
09/05/2024 11:00	0.0	0	0	0	0	1
09/05/2024 12:00	0.0	0	0	0	0	1
09/05/2024 13:00	0.0	0	0	0	0	1
09/05/2024 14:00	0.0	0	0	0	0	1
09/05/2024 15:00	0.0	0	0	0	0	1
09/05/2024 16:00	0.0	0	0	0	0	1
09/05/2024 17:00	0.0	0	0	0	0	1
09/05/2024 18:00	0.0	0	0	0	0	1
09/05/2024 19:00	0.0	0	0	0	0	1
09/05/2024 20:00	0.0	0	0	0	0	1
09/05/2024 21:00	0.0	0	0	0	0	1
09/05/2024 22:00	0.0	0	0	0	0	1
09/05/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2024 00:00	0.0	0	0	0	0	1
09/06/2024 01:00	0.0	0	0	0	0	1
09/06/2024 02:00	0.0	0	0	0	0	1
09/06/2024 03:00	0.0	0	0	0	0	1
09/06/2024 04:00	0.0	0	0	0	0	1
09/06/2024 05:00	0.0	0	0	0	0	1
09/06/2024 06:00	0.0	0	0	0	0	1
09/06/2024 07:00	0.0	0	0	0	0	1
09/06/2024 08:00	0.0	0	0	0	0	1
09/06/2024 09:00	0.0	0	0	0	0	1
09/06/2024 10:00	0.0	0	0	0	0	1
09/06/2024 11:00	0.0	0	0	0	0	1
09/06/2024 12:00	0.0	0	0	0	0	1
09/06/2024 13:00	0.0	0	0	0	0	1
09/06/2024 14:00	0.0	0	0	0	0	1
09/06/2024 15:00	0.0	0	0	0	0	1
09/06/2024 16:00	0.0	0	0	0	0	1
09/06/2024 17:00	0.0	0	0	0	0	1
09/06/2024 18:00	0.0	0	0	0	0	1
09/06/2024 19:00	0.0	0	0	0	0	1
09/06/2024 20:00	0.0	0	0	0	0	1
09/06/2024 21:00	0.0	0	0	0	0	1
09/06/2024 22:00	0.0	0	0	0	0	1
09/06/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2024 00:00	0.0	0	0	0	0	1
09/07/2024 01:00	0.0	0	0	0	0	1
09/07/2024 02:00	0.0	0	0	0	0	1
09/07/2024 03:00	0.0	0	0	0	0	1
09/07/2024 04:00	0.0	0	0	0	0	1
09/07/2024 05:00	0.0	0	0	0	0	1
09/07/2024 06:00	0.0	0	0	0	0	1
09/07/2024 07:00	0.0	0	0	0	0	1
09/07/2024 08:00	0.0	0	0	0	0	1
09/07/2024 09:00	0.0	0	0	0	0	1
09/07/2024 10:00	0.0	0	0	0	0	1
09/07/2024 11:00	0.0	0	0	0	0	1
09/07/2024 12:00	0.0	0	0	0	0	1
09/07/2024 13:00	0.0	0	0	0	0	1
09/07/2024 14:00	0.0	0	0	0	0	1
09/07/2024 15:00	0.0	0	0	0	0	1
09/07/2024 16:00	0.0	0	0	0	0	1
09/07/2024 17:00	0.0	0	0	0	0	1
09/07/2024 18:00	0.0	0	0	0	0	1
09/07/2024 19:00	0.0	0	0	0	0	1
09/07/2024 20:00	0.0	0	0	0	0	1
09/07/2024 21:00	0.0	0	0	0	0	1
09/07/2024 22:00	0.0	0	0	0	0	1
09/07/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2024 00:00	0.0	0	0	0	0	1
09/08/2024 01:00	0.0	0	0	0	0	1
09/08/2024 02:00	0.0	0	0	0	0	1
09/08/2024 03:00	0.0	0	0	0	0	1
09/08/2024 04:00	0.0	0	0	0	0	1
09/08/2024 05:00	0.0	0	0	0	0	1
09/08/2024 06:00	0.0	0	0	0	0	1
09/08/2024 07:00	0.0	0	0	0	0	1
09/08/2024 08:00	0.0	0	0	0	0	1
09/08/2024 09:00	0.0	0	0	0	0	1
09/08/2024 10:00	0.0	0	0	0	0	1
09/08/2024 11:00	0.0	0	0	0	0	1
09/08/2024 12:00	0.0	0	0	0	0	1
09/08/2024 13:00	0.0	0	0	0	0	1
09/08/2024 14:00	0.0	0	0	0	0	1
09/08/2024 15:00	0.0	0	0	0	0	1
09/08/2024 16:00	0.0	0	0	0	0	1
09/08/2024 17:00	0.0	0	0	0	0	1
09/08/2024 18:00	0.0	0	0	0	0	1
09/08/2024 19:00	0.0	0	0	0	0	1
09/08/2024 20:00	0.0	0	0	0	0	1
09/08/2024 21:00	0.0	0	0	0	0	1
09/08/2024 22:00	0.0	0	0	0	0	1
09/08/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2024 00:00	0.0	0	0	0	0	1
09/09/2024 01:00	0.0	0	0	0	0	1
09/09/2024 02:00	0.0	0	0	0	0	1
09/09/2024 03:00	0.0	0	0	0	0	1
09/09/2024 04:00	0.0	0	0	0	0	1
09/09/2024 05:00	0.0	0	0	0	0	1
09/09/2024 06:00	0.0	0	0	0	0	1
09/09/2024 07:00	0.0	0	0	0	0	1
09/09/2024 08:00	0.0	0	0	0	0	1
09/09/2024 09:00	0.0	0	0	0	0	1
09/09/2024 10:00	0.0	0	0	0	0	1
09/09/2024 11:00	0.0	0	0	0	0	1
09/09/2024 12:00	0.0	0	0	0	0	1
09/09/2024 13:00	0.0	0	0	0	0	1
09/09/2024 14:00	0.0	0	0	0	0	1
09/09/2024 15:00	0.0	0	0	0	0	1
09/09/2024 16:00	0.0	0	0	0	0	1
09/09/2024 17:00	0.0	0	0	0	0	1
09/09/2024 18:00	0.0	0	0	0	0	1
09/09/2024 19:00	0.0	0	0	0	0	1
09/09/2024 20:00	0.0	0	0	0	0	1
09/09/2024 21:00	0.0	0	0	0	0	1
09/09/2024 22:00	0.0	0	0	0	0	1
09/09/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2024 00:00	0.0	0	0	0	0	1
09/10/2024 01:00	0.0	0	0	0	0	1
09/10/2024 02:00	0.0	0	0	0	0	1
09/10/2024 03:00	0.0	0	0	0	0	1
09/10/2024 04:00	0.0	0	0	0	0	1
09/10/2024 05:00	0.0	0	0	0	0	1
09/10/2024 06:00	0.0	0	0	0	0	1
09/10/2024 07:00	0.0	0	0	0	0	1
09/10/2024 08:00	0.0	0	0	0	0	1
09/10/2024 09:00	0.0	0	0	0	0	1
09/10/2024 10:00	0.0	0	0	0	0	1
09/10/2024 11:00	0.0	0	0	0	0	1
09/10/2024 12:00	0.0	0	0	0	0	1
09/10/2024 13:00	0.0	0	0	0	0	1
09/10/2024 14:00	0.0	0	0	0	0	1
09/10/2024 15:00	0.0	0	0	0	0	1
09/10/2024 16:00	0.0	0	0	0	0	1
09/10/2024 17:00	0.0	0	0	0	0	1
09/10/2024 18:00	0.0	0	0	0	0	1
09/10/2024 19:00	0.0	0	0	0	0	1
09/10/2024 20:00	0.0	0	0	0	0	1
09/10/2024 21:00	0.0	0	0	0	0	1
09/10/2024 22:00	0.0	0	0	0	0	1
09/10/2024 23:00	1.5	0	0	0	1	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2024 00:00	0.0	0	0	0	0	0
09/11/2024 01:00	0.0	0	0	0	0	0
09/11/2024 02:00	0.0	0	0	0	0	0
09/11/2024 03:00	0.0	0	0	0	0	0
09/11/2024 04:00	0.0	0	0	0	0	0
09/11/2024 05:00	0.0	0	0	0	0	0
09/11/2024 06:00	0.0	0	0	0	0	0
09/11/2024 07:00	0.0	0	0	0	0	0
09/11/2024 08:00	0.0	0	0	0	0	0
09/11/2024 09:00	0.0	0	0	0	0	0
09/11/2024 10:00	0.0	0	0	0	0	0
09/11/2024 11:00	0.0	0	0	0	0	0
09/11/2024 12:00	0.0	0	0	0	0	0
09/11/2024 13:00	0.0	0	0	0	0	0
09/11/2024 14:00	0.0	0	0	0	0	0
09/11/2024 15:00	0.0	0	0	0	0	0
09/11/2024 16:00	0.0	0	0	0	0	0
09/11/2024 17:00	0.0	0	0	0	0	0
09/11/2024 18:00	0.0	0	0	0	0	0
09/11/2024 19:00	0.0	0	0	0	0	0
09/11/2024 20:00	0.0	0	0	0	0	0
09/11/2024 21:00	0.0	0	0	0	0	0
09/11/2024 22:00	0.0	0	0	0	0	0
09/11/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2024 00:00	0.0	0	0	0	0	0
09/12/2024 01:00	0.0	0	0	0	0	0
09/12/2024 02:00	0.0	0	0	0	0	0
09/12/2024 03:00	0.0	0	0	0	0	0
09/12/2024 04:00	0.0	0	0	0	0	0
09/12/2024 05:00	0.0	0	0	0	0	0
09/12/2024 06:00	0.0	0	0	0	0	0
09/12/2024 07:00	0.0	0	0	0	0	0
09/12/2024 08:00	0.0	0	0	0	0	0
09/12/2024 09:00	0.0	0	0	0	0	0
09/12/2024 10:00	0.0	0	0	0	0	0
09/12/2024 11:00	0.0	0	0	0	0	0
09/12/2024 12:00	0.0	0	0	0	0	0
09/12/2024 13:00	0.0	0	0	0	0	0
09/12/2024 14:00	0.0	0	0	0	0	0
09/12/2024 15:00	0.0	0	0	0	0	0
09/12/2024 16:00	0.0	0	0	0	0	0
09/12/2024 17:00	0.0	0	0	0	0	0
09/12/2024 18:00	0.0	0	0	0	0	0
09/12/2024 19:00	0.0	0	0	0	0	0
09/12/2024 20:00	0.0	0	0	0	0	0
09/12/2024 21:00	0.0	0	0	0	0	0
09/12/2024 22:00	0.0	0	0	0	0	0
09/12/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2024 00:00	0.0	0	0	0	0	0
09/13/2024 01:00	0.0	0	0	0	0	0
09/13/2024 02:00	0.0	0	0	0	0	0
09/13/2024 03:00	0.0	0	0	0	0	0
09/13/2024 04:00	0.0	0	0	0	0	0
09/13/2024 05:00	0.0	0	0	0	0	0
09/13/2024 06:00	0.0	0	0	0	0	0
09/13/2024 07:00	0.0	0	0	0	0	0
09/13/2024 08:00	0.0	0	0	0	0	0
09/13/2024 09:00	0.0	0	0	0	0	0
09/13/2024 10:00	0.0	0	0	0	0	0
09/13/2024 11:00	0.0	0	0	0	0	0
09/13/2024 12:00	0.0	0	0	0	0	0
09/13/2024 13:00	0.0	0	0	0	0	0
09/13/2024 14:00	0.0	0	0	0	0	0
09/13/2024 15:00	0.0	0	0	0	0	0
09/13/2024 16:00	0.0	0	0	0	0	0
09/13/2024 17:00	0.0	0	0	0	0	0
09/13/2024 18:00	33.1	0	1	0	0	0
09/13/2024 19:00	58.8	0	1	0	0	0
09/13/2024 20:00	0.0	0	0	0	0	1
09/13/2024 21:00	0.0	0	0	0	0	1
09/13/2024 22:00	0.0	0	0	0	0	1
09/13/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.9 #	0 #	2 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2024 00:00	0.0	0	0	0	0	1
09/14/2024 01:00	0.0	0	0	0	0	1
09/14/2024 02:00	0.9	0	0	0	1	0
09/14/2024 03:00	0.0	0	0	0	0	0
09/14/2024 04:00	0.0	0	0	0	0	0
09/14/2024 05:00	0.0	0	0	0	0	0
09/14/2024 06:00	0.0	0	0	0	0	0
09/14/2024 07:00	0.0	0	0	0	0	0
09/14/2024 08:00	0.0	0	0	0	0	0
09/14/2024 09:00	0.0	0	0	0	0	0
09/14/2024 10:00	0.0	0	0	0	0	0
09/14/2024 11:00	0.0	0	0	0	0	0
09/14/2024 12:00	0.0	0	0	0	0	0
09/14/2024 13:00	0.0	0	0	0	0	0
09/14/2024 14:00	0.0	0	0	0	0	0
09/14/2024 15:00	0.0	0	0	0	0	0
09/14/2024 16:00	0.0	0	0	0	0	0
09/14/2024 17:00	0.0	0	0	0	0	0
09/14/2024 18:00	0.0	0	0	0	0	0
09/14/2024 19:00	0.0	0	0	0	0	0
09/14/2024 20:00	0.0	0	0	0	0	0
09/14/2024 21:00	0.0	0	0	0	0	0
09/14/2024 22:00	0.0	0	0	0	0	0
09/14/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2024 00:00	0.0	0	0	0	0	0
09/15/2024 01:00	0.0	0	0	0	0	0
09/15/2024 02:00	0.0	0	0	0	0	0
09/15/2024 03:00	0.0	0	0	0	0	0
09/15/2024 04:00	0.0	0	0	0	0	0
09/15/2024 05:00	0.0	0	0	0	0	0
09/15/2024 06:00	0.0	0	0	0	0	0
09/15/2024 07:00	0.0	0	0	0	0	0
09/15/2024 08:00	0.0	0	0	0	0	0
09/15/2024 09:00	0.0	0	0	0	0	0
09/15/2024 10:00	0.0	0	0	0	0	0
09/15/2024 11:00	0.0	0	0	0	0	0
09/15/2024 12:00	0.0	0	0	0	0	0
09/15/2024 13:00	0.0	0	0	0	0	0
09/15/2024 14:00	0.0	0	0	0	0	0
09/15/2024 15:00	0.0	0	0	0	0	0
09/15/2024 16:00	0.0	0	0	0	0	0
09/15/2024 17:00	0.0	0	0	0	0	0
09/15/2024 18:00	0.0	0	0	0	0	0
09/15/2024 19:00	0.0	0	0	0	0	0
09/15/2024 20:00	0.0	0	0	0	0	0
09/15/2024 21:00	0.0	0	0	0	0	0
09/15/2024 22:00	0.0	0	0	0	0	0
09/15/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2024 00:00	0.0	0	0	0	0	0
09/16/2024 01:00	0.0	0	0	0	0	0
09/16/2024 02:00	0.0	0	0	0	0	0
09/16/2024 03:00	0.0	0	0	0	0	0
09/16/2024 04:00	0.0	0	0	0	0	0
09/16/2024 05:00	0.0	0	0	0	0	0
09/16/2024 06:00	0.0	0	0	0	0	0
09/16/2024 07:00	0.0	0	0	0	0	0
09/16/2024 08:00	0.0	0	0	0	0	0
09/16/2024 09:00	0.0	0	0	0	0	0
09/16/2024 10:00	0.0	0	0	0	0	0
09/16/2024 11:00	0.0	0	0	0	0	0
09/16/2024 12:00	0.0	0	0	0	0	0
09/16/2024 13:00	0.0	0	0	0	0	0
09/16/2024 14:00	0.0	0	0	0	0	0
09/16/2024 15:00	0.0	0	0	0	0	0
09/16/2024 16:00	0.0	0	0	0	0	0
09/16/2024 17:00	0.0	0	0	0	0	0
09/16/2024 18:00	0.0	0	0	0	0	0
09/16/2024 19:00	0.0	0	0	0	0	0
09/16/2024 20:00	0.0	0	0	0	0	0
09/16/2024 21:00	0.0	0	0	0	0	0
09/16/2024 22:00	0.0	0	0	0	0	0
09/16/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2024 00:00	0.0	0	0	0	0	0
09/17/2024 01:00	0.0	0	0	0	0	0
09/17/2024 02:00	0.0	0	0	0	0	0
09/17/2024 03:00	0.0	0	0	0	0	0
09/17/2024 04:00	0.0	0	0	0	0	0
09/17/2024 05:00	0.0	0	0	0	0	0
09/17/2024 06:00	0.0	0	0	0	0	0
09/17/2024 07:00	0.0	0	0	0	0	0
09/17/2024 08:00	0.0	0	0	0	0	0
09/17/2024 09:00	0.0	0	0	0	0	0
09/17/2024 10:00	0.0	0	0	0	0	0
09/17/2024 11:00	0.0	0	0	0	0	0
09/17/2024 12:00	0.0	0	0	0	0	0
09/17/2024 13:00	0.0	0	0	0	0	0
09/17/2024 14:00	0.0	0	0	0	0	0
09/17/2024 15:00	0.0	0	0	0	0	0
09/17/2024 16:00	0.0	0	0	0	0	0
09/17/2024 17:00	0.0	0	0	0	0	0
09/17/2024 18:00	0.0	0	0	0	0	0
09/17/2024 19:00	0.0	0	0	0	0	0
09/17/2024 20:00	0.0	0	0	0	0	0
09/17/2024 21:00	0.0	0	0	0	0	0
09/17/2024 22:00	0.0	0	0	0	0	0
09/17/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2024 00:00	0.0	0	0	0	0	0
09/18/2024 01:00	46.3	1	0	0	0	0
09/18/2024 02:00	34.6	1	0	0	0	0
09/18/2024 03:00	0.0	0	0	0	0	1
09/18/2024 04:00	0.0	0	0	0	0	1
09/18/2024 05:00	0.0	0	0	0	0	1
09/18/2024 06:00	0.0	0	0	0	0	1
09/18/2024 07:00	0.0	0	0	0	0	1
09/18/2024 08:00	0.0	0	0	0	0	1
09/18/2024 09:00	0.0	0	0	0	0	1
09/18/2024 10:00	0.0	0	0	0	0	1
09/18/2024 11:00	0.0	0	0	0	0	1
09/18/2024 12:00	0.0	0	0	0	0	1
09/18/2024 13:00	0.0	0	0	0	0	1
09/18/2024 14:00	0.0	0	0	0	0	1
09/18/2024 15:00	0.0	0	0	0	0	1
09/18/2024 16:00	0.0	0	0	0	0	1
09/18/2024 17:00	0.0	0	0	0	0	1
09/18/2024 18:00	0.0	0	0	0	0	1
09/18/2024 19:00	0.0	0	0	0	0	1
09/18/2024 20:00	0.0	0	0	0	0	1
09/18/2024 21:00	0.0	0	0	0	0	1
09/18/2024 22:00	0.0	0	0	0	0	1
09/18/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	80.9 #	2 #	0 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.3	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2024 00:00	0.0	0	0	0	0	1
09/19/2024 01:00	0.0	0	0	0	0	1
09/19/2024 02:00	0.0	0	0	0	0	1
09/19/2024 03:00	0.0	0	0	0	0	1
09/19/2024 04:00	0.0	0	0	0	0	1
09/19/2024 05:00	0.0	0	0	0	0	1
09/19/2024 06:00	0.0	0	0	0	0	1
09/19/2024 07:00	0.5	0	0	0	1	0
09/19/2024 08:00	0.0	0	0	0	0	0
09/19/2024 09:00	0.0	0	0	0	0	0
09/19/2024 10:00	0.0	0	0	0	0	0
09/19/2024 11:00	0.0	0	0	0	0	0
09/19/2024 12:00	0.0	0	0	0	0	0
09/19/2024 13:00	0.0	0	0	0	0	0
09/19/2024 14:00	0.0	0	0	0	0	0
09/19/2024 15:00	0.0	0	0	0	0	0
09/19/2024 16:00	0.0	0	0	0	0	0
09/19/2024 17:00	0.0	0	0	0	0	0
09/19/2024 18:00	0.0	0	0	0	0	0
09/19/2024 19:00	0.0	0	0	0	0	0
09/19/2024 20:00	0.0	0	0	0	0	0
09/19/2024 21:00	0.0	0	0	0	0	0
09/19/2024 22:00	0.0	0	0	0	0	0
09/19/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2024 00:00	0.0	0	0	0	0	0
09/20/2024 01:00	0.0	0	0	0	0	0
09/20/2024 02:00	0.0	0	0	0	0	0
09/20/2024 03:00	0.0	0	0	0	0	0
09/20/2024 04:00	0.0	0	0	0	0	0
09/20/2024 05:00	0.0	0	0	0	0	0
09/20/2024 06:00	0.0	0	0	0	0	0
09/20/2024 07:00	0.0	0	0	0	0	0
09/20/2024 08:00	0.0	0	0	0	0	0
09/20/2024 09:00	0.0	0	0	0	0	0
09/20/2024 10:00	0.0	0	0	0	0	0
09/20/2024 11:00	0.0	0	0	0	0	0
09/20/2024 12:00	0.0	0	0	0	0	0
09/20/2024 13:00	0.0	0	0	0	0	0
09/20/2024 14:00	0.0	0	0	0	0	0
09/20/2024 15:00	0.0	0	0	0	0	0
09/20/2024 16:00	0.0	0	0	0	0	0
09/20/2024 17:00	0.0	0	0	0	0	0
09/20/2024 18:00	0.0	0	0	0	0	0
09/20/2024 19:00	0.0	0	0	0	0	0
09/20/2024 20:00	0.0	0	0	0	0	0
09/20/2024 21:00	0.0	0	0	0	0	0
09/20/2024 22:00	0.0	0	0	0	0	0
09/20/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2024 00:00	0.0	0	0	0	0	0
09/21/2024 01:00	0.0	0	0	0	0	0
09/21/2024 02:00	0.0	0	0	0	0	0
09/21/2024 03:00	0.0	0	0	0	0	0
09/21/2024 04:00	0.0	0	0	0	0	0
09/21/2024 05:00	0.0	0	0	0	0	0
09/21/2024 06:00	0.0	0	0	0	0	0
09/21/2024 07:00	0.0	0	0	0	0	0
09/21/2024 08:00	0.0	0	0	0	0	0
09/21/2024 09:00	0.0	0	0	0	0	0
09/21/2024 10:00	0.0	0	0	0	0	0
09/21/2024 11:00	0.0	0	0	0	0	0
09/21/2024 12:00	0.0	0	0	0	0	0
09/21/2024 13:00	0.0	0	0	0	0	0
09/21/2024 14:00	0.0	0	0	0	0	0
09/21/2024 15:00	0.0	0	0	0	0	0
09/21/2024 16:00	0.0	0	0	0	0	0
09/21/2024 17:00	0.0	0	0	0	0	0
09/21/2024 18:00	0.0	0	0	0	0	0
09/21/2024 19:00	0.0	0	0	0	0	0
09/21/2024 20:00	36.9	0	1	0	0	0
09/21/2024 21:00	34.9	0	1	0	0	0
09/21/2024 22:00	29.8	0	1	0	0	0
09/21/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	101.6 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2024 00:00	0.0	0	0	0	0	1
09/22/2024 01:00	0.0	0	0	0	0	1
09/22/2024 02:00	0.0	0	0	0	0	1
09/22/2024 03:00	0.0	0	0	0	0	1
09/22/2024 04:00	0.0	0	0	0	0	1
09/22/2024 05:00	0.0	0	0	0	0	1
09/22/2024 06:00	0.0	0	0	0	0	1
09/22/2024 07:00	0.9	0	0	0	1	0
09/22/2024 08:00	0.0	0	0	0	0	0
09/22/2024 09:00	0.0	0	0	0	0	0
09/22/2024 10:00	6.9	0	0	1	0	0
09/22/2024 11:00	28.1	0	0	1	0	0
09/22/2024 12:00	0.0	0	0	0	0	1
09/22/2024 13:00	0.0	0	0	0	0	1
09/22/2024 14:00	0.0	0	0	0	0	1
09/22/2024 15:00	0.0	0	0	0	0	1
09/22/2024 16:00	0.0	0	0	0	0	1
09/22/2024 17:00	0.0	0	0	0	0	1
09/22/2024 18:00	0.0	0	0	0	0	1
09/22/2024 19:00	0.0	0	0	0	0	1
09/22/2024 20:00	0.0	0	0	0	0	1
09/22/2024 21:00	0.0	0	0	0	0	1
09/22/2024 22:00	0.0	0	0	0	0	1
09/22/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	35.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2024 00:00	0.0	0	0	0	0	1
09/23/2024 01:00	0.0	0	0	0	0	1
09/23/2024 02:00	0.0	0	0	0	0	1
09/23/2024 03:00	0.0	0	0	0	0	1
09/23/2024 04:00	0.0	0	0	0	0	1
09/23/2024 05:00	0.0	0	0	0	0	1
09/23/2024 06:00	0.0	0	0	0	0	1
09/23/2024 07:00	0.0	0	0	0	0	1
09/23/2024 08:00	0.0	0	0	0	0	1
09/23/2024 09:00	0.0	0	0	0	0	1
09/23/2024 10:00	0.0	0	0	0	0	1
09/23/2024 11:00	0.0	0	0	0	0	1
09/23/2024 12:00	0.0	0	0	0	0	1
09/23/2024 13:00	0.0	0	0	0	0	1
09/23/2024 14:00	0.0	0	0	0	0	1
09/23/2024 15:00	0.0	0	0	0	0	1
09/23/2024 16:00	0.0	0	0	0	0	1
09/23/2024 17:00	0.0	0	0	0	0	1
09/23/2024 18:00	0.0	0	0	0	0	1
09/23/2024 19:00	0.0	0	0	0	0	1
09/23/2024 20:00	0.0	0	0	0	0	1
09/23/2024 21:00	0.0	0	0	0	0	1
09/23/2024 22:00	0.0	0	0	0	0	1
09/23/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2024 00:00	0.0	0	0	0	0	1
09/24/2024 01:00	0.0	0	0	0	0	1
09/24/2024 02:00	0.0	0	0	0	0	1
09/24/2024 03:00	0.0	0	0	0	0	1
09/24/2024 04:00	0.0	0	0	0	0	1
09/24/2024 05:00	0.0	0	0	0	0	1
09/24/2024 06:00	0.0	0	0	0	0	1
09/24/2024 07:00	0.0	0	0	0	0	1
09/24/2024 08:00	0.0	0	0	0	0	1
09/24/2024 09:00	0.0	0	0	0	0	1
09/24/2024 10:00	0.0	0	0	0	0	1
09/24/2024 11:00	0.0	0	0	0	0	1
09/24/2024 12:00	0.0	0	0	0	0	1
09/24/2024 13:00	0.0	0	0	0	0	1
09/24/2024 14:00	0.0	0	0	0	0	1
09/24/2024 15:00	0.0	0	0	0	0	1
09/24/2024 16:00	0.0	0	0	0	0	1
09/24/2024 17:00	0.0	0	0	0	0	1
09/24/2024 18:00	0.0	0	0	0	0	1
09/24/2024 19:00	0.0	0	0	0	0	1
09/24/2024 20:00	0.0	0	0	0	0	1
09/24/2024 21:00	0.0	0	0	0	0	1
09/24/2024 22:00	0.0	0	0	0	0	1
09/24/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2024 00:00	0.0	0	0	0	0	1
09/25/2024 01:00	0.0	0	0	0	0	1
09/25/2024 02:00	0.0	0	0	0	0	1
09/25/2024 03:00	0.0	0	0	0	0	1
09/25/2024 04:00	0.0	0	0	0	0	1
09/25/2024 05:00	0.0	0	0	0	0	1
09/25/2024 06:00	0.0	0	0	0	0	1
09/25/2024 07:00	0.6	0	0	0	1	0
09/25/2024 08:00	0.0	0	0	0	0	0
09/25/2024 09:00	0.0	0	0	0	0	0
09/25/2024 10:00	0.0	0	0	0	0	0
09/25/2024 11:00	0.0	0	0	0	0	0
09/25/2024 12:00	0.0	0	0	0	0	0
09/25/2024 13:00	0.0	0	0	0	0	0
09/25/2024 14:00	0.0	0	0	0	0	0
09/25/2024 15:00	0.0	0	0	0	0	0
09/25/2024 16:00	0.0	0	0	0	0	0
09/25/2024 17:00	0.0	0	0	0	0	0
09/25/2024 18:00	0.0	0	1	0	0	0
09/25/2024 19:00	59.7	0	1	0	0	0
09/25/2024 20:00	0.0	0	0	0	0	1
09/25/2024 21:00	0.0	0	0	0	0	1
09/25/2024 22:00	0.0	0	0	0	0	1
09/25/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.3 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2024 00:00	0.0	0	0	0	0	1
09/26/2024 01:00	0.0	0	0	0	0	1
09/26/2024 02:00	0.0	0	0	0	0	1
09/26/2024 03:00	0.0	0	0	0	0	1
09/26/2024 04:00	0.0	0	0	0	0	1
09/26/2024 05:00	0.0	0	0	0	0	1
09/26/2024 06:00	0.0	0	0	0	0	1
09/26/2024 07:00	0.0	0	0	0	0	1
09/26/2024 08:00	1.1	0	0	0	1	0
09/26/2024 09:00	0.0	0	0	0	0	0
09/26/2024 10:00	0.0	0	0	0	0	0
09/26/2024 11:00	0.0	0	0	0	0	0
09/26/2024 12:00	0.0	0	0	0	0	0
09/26/2024 13:00	0.0	0	0	0	0	0
09/26/2024 14:00	0.0	0	0	0	0	0
09/26/2024 15:00	0.0	0	0	0	0	0
09/26/2024 16:00	0.0	0	0	0	0	0
09/26/2024 17:00	0.0	0	0	0	0	0
09/26/2024 18:00	0.0	0	0	0	0	0
09/26/2024 19:00	0.0	0	0	0	0	0
09/26/2024 20:00	0.0	0	0	0	0	0
09/26/2024 21:00	0.0	0	0	0	0	0
09/26/2024 22:00	0.0	0	0	0	0	0
09/26/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2024 00:00	0.0	0	0	0	0	0
09/27/2024 01:00	0.0	0	0	0	0	0
09/27/2024 02:00	0.0	0	0	0	0	0
09/27/2024 03:00	0.0	0	0	0	0	0
09/27/2024 04:00	0.0	0	0	0	0	0
09/27/2024 05:00	0.0	0	0	0	0	0
09/27/2024 06:00	0.0	0	0	0	0	0
09/27/2024 07:00	0.0	0	0	0	0	0
09/27/2024 08:00	0.0	0	0	0	0	0
09/27/2024 09:00	0.0	0	0	0	0	0
09/27/2024 10:00	0.0	0	0	0	0	0
09/27/2024 11:00	0.0	0	0	0	0	0
09/27/2024 12:00	0.0	0	0	0	0	0
09/27/2024 13:00	27.5	0	1	0	0	0
09/27/2024 14:00	42.8	0	1	0	0	0
09/27/2024 15:00	0.0	0	0	0	0	1
09/27/2024 16:00	0.0	0	0	0	0	1
09/27/2024 17:00	0.0	0	0	0	0	1
09/27/2024 18:00	0.0	0	0	0	0	1
09/27/2024 19:00	0.0	0	0	0	0	1
09/27/2024 20:00	0.0	0	0	0	0	1
09/27/2024 21:00	0.0	0	0	0	0	1
09/27/2024 22:00	0.0	0	0	0	0	1
09/27/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.3 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2024 00:00	0.0	0	0	0	0	1
09/28/2024 01:00	0.0	0	0	0	0	1
09/28/2024 02:00	0.0	0	0	0	0	1
09/28/2024 03:00	0.0	0	0	0	0	1
09/28/2024 04:00	0.0	0	0	0	0	1
09/28/2024 05:00	0.0	0	0	0	0	1
09/28/2024 06:00	0.0	0	0	0	0	1
09/28/2024 07:00	0.8	0	0	0	1	0
09/28/2024 08:00	0.0	0	0	0	0	0
09/28/2024 09:00	0.0	0	0	0	0	0
09/28/2024 10:00	0.0	0	0	0	0	0
09/28/2024 11:00	0.0	0	0	0	0	0
09/28/2024 12:00	0.0	0	0	0	0	0
09/28/2024 13:00	0.0	0	0	0	0	0
09/28/2024 14:00	0.0	0	0	0	0	0
09/28/2024 15:00	0.0	0	0	0	0	0
09/28/2024 16:00	0.0	0	0	0	0	0
09/28/2024 17:00	0.0	0	0	0	0	0
09/28/2024 18:00	0.0	0	0	0	0	0
09/28/2024 19:00	0.0	0	0	0	0	0
09/28/2024 20:00	0.0	0	0	0	0	0
09/28/2024 21:00	0.0	0	0	0	0	0
09/28/2024 22:00	0.0	0	0	0	0	0
09/28/2024 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2024 00:00	0.0	0	0	0	0	0
09/29/2024 01:00	0.0	0	0	0	0	0
09/29/2024 02:00	0.0	0	0	0	0	0
09/29/2024 03:00	0.0	0	0	0	0	0
09/29/2024 04:00	0.0	0	0	0	0	0
09/29/2024 05:00	0.0	0	0	0	0	0
09/29/2024 06:00	0.0	0	0	0	0	0
09/29/2024 07:00	0.0	0	0	0	0	0
09/29/2024 08:00	0.0	0	0	0	0	0
09/29/2024 09:00	0.0	0	0	0	0	0
09/29/2024 10:00	0.0	0	0	0	0	0
09/29/2024 11:00	0.0	0	0	0	0	0
09/29/2024 12:00	0.0	0	0	0	0	0
09/29/2024 13:00	0.0	0	0	0	0	0
09/29/2024 14:00	27.9	0	1	0	0	0
09/29/2024 15:00	26.4	0	1	0	0	0
09/29/2024 16:00	0.0	0	0	0	0	1
09/29/2024 17:00	0.0	0	0	0	0	1
09/29/2024 18:00	0.0	0	0	0	0	1
09/29/2024 19:00	0.0	0	0	0	0	1
09/29/2024 20:00	0.0	0	0	0	0	1
09/29/2024 21:00	0.0	0	0	0	0	1
09/29/2024 22:00	0.0	0	0	0	0	1
09/29/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.3 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2024 00:00	0.0	0	0	0	0	1
09/30/2024 01:00	0.0	0	0	0	0	1
09/30/2024 02:00	0.0	0	0	0	0	1
09/30/2024 03:00	0.0	0	0	0	0	1
09/30/2024 04:00	0.0	0	0	0	0	1
09/30/2024 05:00	0.0	0	0	0	0	1
09/30/2024 06:00	0.0	0	0	0	0	1
09/30/2024 07:00	0.0	0	0	0	0	1
09/30/2024 08:00	0.0	0	0	0	0	1
09/30/2024 09:00	0.0	0	0	0	0	1
09/30/2024 10:00	0.0	0	0	0	0	1
09/30/2024 11:00	0.0	0	0	0	0	1
09/30/2024 12:00	0.0	0	0	0	0	1
09/30/2024 13:00	0.0	0	0	0	0	1
09/30/2024 14:00	0.0	0	0	0	0	1
09/30/2024 15:00	0.0	0	0	0	0	1
09/30/2024 16:00	0.0	0	0	0	0	1
09/30/2024 17:00	0.0	0	0	0	0	1
09/30/2024 18:00	0.0	0	0	0	0	1
09/30/2024 19:00	0.0	0	0	0	0	1
09/30/2024 20:00	0.0	0	0	0	0	1
09/30/2024 21:00	0.0	0	0	0	0	1
09/30/2024 22:00	0.0	0	0	0	0	1
09/30/2024 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/01/2024 00:11 07/01/2024 00:16 Shut Down - Gas	6	1.3	483.5		
07/01/2024 13:23 07/01/2024 14:46 Warm Start - Gas	84	55.6	790.5		
07/01/2024 23:11 07/01/2024 23:17 Shut Down - Gas	7	0.7	483.5		
07/02/2024 15:46 07/02/2024 17:06 Warm Start - Gas	81	55.8	790.5		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.6	483.5		
07/04/2024 13:35 07/04/2024 14:47 Warm Start - Gas	73	54.0	790.5		
07/06/2024 06:11 07/06/2024 06:16 Shut Down - Gas	6	0.0 SI	483.5		
07/06/2024 13:54 07/06/2024 14:47 Hot Start - Gas	54	37.4	679.6		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.6	483.5		
07/07/2024 11:56 07/07/2024 12:54 Warm Start - Gas	59	49.6	790.5		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	1.0	483.5		
07/14/2024 14:31 07/14/2024 15:26 Warm Start - Gas	56	49.6	790.5		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	1.1	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/21/2024 23:31 07/21/2024 23:31 Warm Start - Gas	1	0.0	790.5		
07/21/2024 23:32 07/21/2024 23:32 Shut Down - Gas	1	0.0	483.5		
07/22/2024 03:08 07/22/2024 04:13 Warm Start - Gas	66	78.6	790.5		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	0.0 SI	483.5		
07/27/2024 15:34 07/27/2024 16:39 Warm Start - Gas	66	71.0	790.5		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	1.2	483.5		
07/28/2024 14:31 07/28/2024 15:26 Hot Start - Gas	56	84.6	679.6		
07/29/2024 03:08 07/29/2024 03:13 Shut Down - Gas	6	1.6	483.5		
07/29/2024 14:59 07/29/2024 16:22 Warm Start - Gas	84	96.9	790.5		
07/29/2024 23:11 07/29/2024 23:16 Shut Down - Gas	6	0.5	483.5		
07/30/2024 15:08 07/30/2024 16:27 Warm Start - Gas	80	92.0	790.5		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.0	483.5		
08/10/2024 13:18 08/10/2024 15:42 Warm Start - Gas	145	90.7	790.5		
08/10/2024 23:09 08/10/2024 23:14 Shut Down - Gas	6	0.6	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/12/2024 18:23 08/12/2024 20:11 Warm Start - Gas	109	125.5	790.5		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	1.0	483.5		
08/13/2024 16:14 08/13/2024 18:46 Warm Start - Gas	153	112.3	790.5		
08/14/2024 02:21 08/14/2024 02:26 Shut Down - Gas	6	0.5	483.5		
08/14/2024 10:32 08/14/2024 11:49 Warm Start - Gas	78	63.7	790.5		
08/15/2024 00:22 08/15/2024 00:27 Shut Down - Gas	6	0.8	483.5		
08/15/2024 12:18 08/15/2024 14:48 Warm Start - Gas	151	87.3	790.5		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.5	483.5		
08/16/2024 12:04 08/16/2024 13:31 Warm Start - Gas	88	68.2	790.5		
08/17/2024 06:25 08/17/2024 06:31 Shut Down - Gas	7	0.0 SI	483.5		
08/17/2024 14:49 08/17/2024 15:56 Warm Start - Gas	68	46.2	790.5		
08/18/2024 02:08 08/18/2024 02:13 Shut Down - Gas	6	0.8	483.5		
08/18/2024 14:26 08/18/2024 15:40 Warm Start - Gas	75	59.4	790.5		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/19/2024 07:13 08/19/2024 08:02 Hot Start - Gas	50	39.9	679.6		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	1.3	483.5		
08/20/2024 13:05 08/20/2024 14:40 Warm Start - Gas	96	68.6	790.5		
08/22/2024 06:10 08/22/2024 06:15 Shut Down - Gas	6	0.0 SI	483.5		
08/26/2024 00:10 08/26/2024 00:23 Cold Start - Gas	14	16.8	1,355.6		
08/26/2024 00:24 08/26/2024 00:29 Shut Down - Gas	6	1.5	483.5		
08/26/2024 07:13 08/26/2024 08:32 Cold Start - Gas	80	80.9	1,355.6		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	0.9	483.5		
08/31/2024 10:48 08/31/2024 11:52 Hot Start - Gas	65	45.9	679.6		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	0.7	483.5		
09/01/2024 14:35 09/01/2024 15:36 Warm Start - Gas	62	37.4	790.5		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	1.0	483.5		
09/02/2024 14:33 09/02/2024 15:29 Hot Start - Gas	57	58.9	679.6		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	0.8	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/13/2024 18:25 09/13/2024 19:47 Warm Start - Gas	83	82.7	790.5		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.8	483.5		
09/18/2024 01:13 09/18/2024 02:46 Cold Start - Gas	94	93.1	1,355.6		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	0.9	483.5		
09/21/2024 20:23 09/21/2024 22:43 Warm Start - Gas	141	83.9	790.5		
09/22/2024 07:08 09/22/2024 07:13 Shut Down - Gas	6	1.0	483.5		
09/22/2024 10:34 09/22/2024 11:36 Hot Start - Gas	63	50.3	679.6		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	0.8	483.5		
09/25/2024 18:55 09/25/2024 19:54 Warm Start - Gas	60	52.6	790.5		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	0.9	483.5		
09/27/2024 13:32 09/27/2024 14:36 Warm Start - Gas	65	42.9	790.5		
09/28/2024 07:10 09/28/2024 07:15 Shut Down - Gas	6	0.8	483.5		
09/29/2024 14:32 09/29/2024 15:27 Warm Start - Gas	56	40.3	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/06/2024 06:11 07/06/2024 06:16	6		
07/27/2024 06:10 07/27/2024 06:15	6		
08/17/2024 06:25 08/17/2024 06:31	7		
08/22/2024 06:10 08/22/2024 06:15	6		

Total CMS Downtime	25	Minute(s)
Total Downtime as a percentage of operating time	0.03	%
Total Availability as a percentage of operating time	99.97	%

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,620.33 Hours

Non-Operating Time: 587.67 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	25
2. Total CMS Downtime in Minute(s)	25
3. Total Downtime as a percentage of operating time	0.03
4. Total Availability as a percentage of operating time	99.97

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:09 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours
Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/01/2024 00:11 07/01/2024 00:16 Shut Down - Gas	6	0.22	115.00		
07/01/2024 13:23 07/01/2024 14:46 Warm Start - Gas	84	76.06	456.20		
07/01/2024 23:11 07/01/2024 23:17 Shut Down - Gas	7	0.35	115.00		
07/02/2024 15:46 07/02/2024 17:06 Warm Start - Gas	81	91.96	456.20		
07/04/2024 02:10 07/04/2024 02:15 Shut Down - Gas	6	0.10	115.00		
07/04/2024 13:35 07/04/2024 14:47 Warm Start - Gas	73	57.06	456.20		
07/06/2024 06:11 07/06/2024 06:16 Shut Down - Gas	6	0.00 SI	115.00		
07/06/2024 13:54 07/06/2024 14:47 Hot Start - Gas	54	25.98	259.90		
07/07/2024 03:09 07/07/2024 03:14 Shut Down - Gas	6	0.06	115.00		
07/07/2024 11:56 07/07/2024 12:54 Warm Start - Gas	59	47.58	456.20		
07/14/2024 02:22 07/14/2024 02:27 Shut Down - Gas	6	0.12	115.00		
07/14/2024 14:31 07/14/2024 15:26 Warm Start - Gas	56	59.95	456.20		
07/21/2024 05:39 07/21/2024 05:44 Shut Down - Gas	6	0.21	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/21/2024 23:31 07/21/2024 23:32 Warm Start - Gas	2	0.00	456.20		
07/21/2024 23:32 07/27/2024 06:15 Shut Down - Gas	7604	0.00	115.00		
07/22/2024 03:08 07/22/2024 04:13 Warm Start - Gas	66	70.13	456.20		
07/27/2024 06:10 07/27/2024 06:15 Shut Down - Gas	6	0.00 SI	115.00		
07/27/2024 15:34 07/27/2024 16:39 Warm Start - Gas	66	64.44	456.20		
07/28/2024 07:04 07/28/2024 07:09 Shut Down - Gas	6	0.37	115.00		
07/28/2024 14:31 07/28/2024 15:26 Hot Start - Gas	56	50.34	259.90		
07/29/2024 03:08 07/29/2024 03:13 Shut Down - Gas	6	0.10	115.00		
07/29/2024 14:59 07/29/2024 16:22 Warm Start - Gas	84	72.07	456.20		
07/29/2024 23:11 07/29/2024 23:16 Shut Down - Gas	6	0.05	115.00		
07/30/2024 15:08 07/30/2024 16:27 Warm Start - Gas	80	85.70	456.20		
08/09/2024 21:11 08/09/2024 21:16 Shut Down - Gas	6	0.07	115.00		
08/10/2024 13:18 08/10/2024 15:42 Warm Start - Gas	145	97.63	456.20		
08/10/2024 23:09 08/10/2024 23:14 Shut Down - Gas	6	0.04	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/12/2024 18:23 08/12/2024 20:11 Warm Start - Gas	109	90.86	456.20		
08/13/2024 02:09 08/13/2024 02:14 Shut Down - Gas	6	0.24	115.00		
08/13/2024 16:14 08/13/2024 18:46 Warm Start - Gas	153	103.45	456.20		
08/14/2024 02:21 08/14/2024 02:26 Shut Down - Gas	6	0.08	115.00		
08/14/2024 10:32 08/14/2024 11:49 Warm Start - Gas	78	76.34	456.20		
08/15/2024 00:22 08/15/2024 00:27 Shut Down - Gas	6	0.11	115.00		
08/15/2024 12:18 08/15/2024 14:48 Warm Start - Gas	151	102.75	456.20		
08/16/2024 02:21 08/16/2024 02:26 Shut Down - Gas	6	0.06	115.00		
08/16/2024 12:04 08/16/2024 13:31 Warm Start - Gas	88	67.44	456.20		
08/17/2024 06:25 08/17/2024 06:31 Shut Down - Gas	7	0.00 SI	115.00		
08/17/2024 14:49 08/17/2024 15:56 Warm Start - Gas	68	57.39	456.20		
08/18/2024 02:08 08/18/2024 02:13 Shut Down - Gas	6	0.07	115.00		
08/18/2024 14:26 08/18/2024 15:40 Warm Start - Gas	75	76.64	456.20		
08/19/2024 00:08 08/19/2024 00:13 Shut Down - Gas	6	0.12	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:09 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,516.23 Hours
Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/19/2024 07:13 08/19/2024 08:02 Hot Start - Gas	50	43.03	259.90		
08/20/2024 01:09 08/20/2024 01:14 Shut Down - Gas	6	0.32	115.00		
08/20/2024 13:05 08/20/2024 14:40 Warm Start - Gas	96	89.90	456.20		
08/22/2024 06:10 08/22/2024 06:15 Shut Down - Gas	6	0.00 SI	115.00		
08/26/2024 00:10 08/26/2024 00:24 Cold Start - Gas	15	5.38	779.10		
08/26/2024 00:24 08/26/2024 00:29 Shut Down - Gas	6	0.51	115.00		
08/26/2024 07:13 08/26/2024 08:32 Cold Start - Gas	80	92.73	779.10		
08/31/2024 06:08 08/31/2024 06:13 Shut Down - Gas	6	0.22	115.00		
08/31/2024 10:48 08/31/2024 11:52 Hot Start - Gas	65	20.81	259.90		
09/01/2024 06:09 09/01/2024 06:14 Shut Down - Gas	6	0.11	115.00		
09/01/2024 14:35 09/01/2024 15:36 Warm Start - Gas	62	45.00	456.20		
09/02/2024 07:09 09/02/2024 07:14 Shut Down - Gas	6	0.24	115.00		
09/02/2024 14:33 09/02/2024 15:29 Hot Start - Gas	57	55.37	259.90		
09/10/2024 23:09 09/10/2024 23:14 Shut Down - Gas	6	0.20	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:09 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,516.23 Hours
Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
09/13/2024 18:25 09/13/2024 19:47 Warm Start - Gas	83	96.01	456.20		
09/14/2024 02:50 09/14/2024 02:55 Shut Down - Gas	6	0.13	115.00		
09/18/2024 01:13 09/18/2024 02:46 Cold Start - Gas	94	85.91	779.10		
09/19/2024 07:09 09/19/2024 07:14 Shut Down - Gas	6	0.14	115.00		
09/21/2024 20:23 09/21/2024 22:43 Warm Start - Gas	141	107.12	456.20		
09/22/2024 07:08 09/22/2024 07:13 Shut Down - Gas	6	0.28	115.00		
09/22/2024 10:34 09/22/2024 11:36 Hot Start - Gas	63	45.04	259.90		
09/25/2024 07:10 09/25/2024 07:15 Shut Down - Gas	6	0.14	115.00		
09/25/2024 18:55 09/25/2024 19:54 Warm Start - Gas	60	56.66	456.20		
09/26/2024 08:08 09/26/2024 08:13 Shut Down - Gas	6	0.24	115.00		
09/27/2024 13:32 09/27/2024 14:36 Warm Start - Gas	65	80.36	456.20		
09/28/2024 07:10 09/28/2024 07:15 Shut Down - Gas	6	0.27	115.00		
09/29/2024 14:32 09/29/2024 15:27 Warm Start - Gas	56	70.20	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:09 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,516.23 Hours
Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/06/2024 06:11 07/06/2024 06:16	6		
07/27/2024 06:10 07/27/2024 06:15	6		
08/17/2024 06:25 08/17/2024 06:31	7		
08/22/2024 06:10 08/22/2024 06:15	6		

Total CMS Downtime	25	Minute(s)
Total Downtime as a percentage of operating time	0.03	%
Total Availability as a percentage of operating time	99.97	%

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/02/2024 11:09 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,516.23 Hours

Non-Operating Time: 691.77 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	25
2. Total CMS Downtime in Minute(s)	25
3. Total Downtime as a percentage of operating time	0.03
4. Total Availability as a percentage of operating time	99.97

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
07/01/2024 01:00	07/01/2024 07:00	7
07/02/2024 00:00	07/02/2024 09:00	10
07/04/2024 03:00	07/04/2024 08:00	6
07/06/2024 07:00	07/06/2024 08:00	2
07/07/2024 04:00	07/07/2024 14:00	11
07/14/2024 03:00	07/14/2024 09:00	7
07/21/2024 06:00	07/21/2024 09:00	4
07/27/2024 07:00	07/27/2024 10:00	4
07/28/2024 08:00	07/29/2024 09:00	26
07/30/2024 00:00	07/30/2024 09:00	10
08/09/2024 22:00	08/12/2024 12:00	63
08/13/2024 03:00	08/15/2024 16:00	62
08/16/2024 03:00	08/16/2024 07:00	5
08/17/2024 07:00	08/18/2024 08:00	26
08/19/2024 01:00	08/19/2024 11:00	11
08/20/2024 02:00	08/20/2024 08:00	7
08/22/2024 07:00	08/22/2024 13:00	7
08/23/2024 08:00	08/25/2024 12:00	53
08/31/2024 07:00	08/31/2024 13:00	7
09/01/2024 07:00	09/01/2024 09:00	3
09/02/2024 08:00	09/02/2024 09:00	2
09/11/2024 00:00	09/12/2024 16:00	41
09/13/2024 08:00	09/13/2024 12:00	5
09/14/2024 03:00	09/14/2024 15:00	13
09/15/2024 02:00	09/15/2024 16:00	15
09/16/2024 08:00	09/17/2024 19:00	36
09/19/2024 08:00	09/22/2024 13:00	78
09/25/2024 08:00	09/25/2024 13:00	6
09/26/2024 09:00	09/26/2024 13:00	5
09/27/2024 02:00	09/27/2024 08:00	7

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
09/28/2024 08:00	09/28/2024 14:00	7
09/29/2024 03:00	09/29/2024 09:00	7

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	553.00 Hour(s)
Offline Percentage:	25.05 %
Total Online:	1,655.00 Hour(s)
Online Percentage:	74.95 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/01/2024 08:00	07/01/2024 09:00	Warm Startup	2
2	07/02/2024 10:00	07/02/2024 12:00	Warm Startup	3
3	07/04/2024 09:00	07/04/2024 10:00	Hot Startup	2
4	07/06/2024 09:00	07/06/2024 10:00	Hot Startup	2
5	07/07/2024 15:00	07/07/2024 16:00	Warm Startup	2
6	07/14/2024 10:00	07/14/2024 11:00	Warm Startup	2
7	07/21/2024 10:00	07/21/2024 11:00	Hot Startup	2
8	07/27/2024 11:00	07/27/2024 12:00	Hot Startup	2
9	07/29/2024 10:00	07/29/2024 12:00	Warm Startup	3
10	07/30/2024 10:00	07/30/2024 12:00	Warm Startup	3
11	08/12/2024 13:00	08/12/2024 15:00	Warm Startup	3
12	08/15/2024 17:00	08/15/2024 18:00	Warm Startup	2
13	08/16/2024 08:00	08/16/2024 09:00	Hot Startup	2
14	08/18/2024 09:00	08/18/2024 11:00	Warm Startup	3
15	08/19/2024 12:00	08/19/2024 13:00	Warm Startup	2
16	08/20/2024 09:00	08/20/2024 10:00	Warm Startup	2
17	08/22/2024 14:00	08/22/2024 15:00	Warm Startup	2
18	08/25/2024 13:00	08/25/2024 15:00	Warm Startup	3
19	08/31/2024 14:00	08/31/2024 15:00	Warm Startup	2
20	09/01/2024 10:00	09/01/2024 11:00	Hot Startup	2
21	09/02/2024 10:00	09/02/2024 11:00	Hot Startup	2
22	09/12/2024 17:00	09/12/2024 19:00	Warm Startup	3

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Number	Start Time	End Time	Event Type	Duration
23	09/13/2024 13:00	09/13/2024 14:00	Hot Startup	2
24	09/14/2024 16:00	09/14/2024 18:00	Warm Startup	3
25	09/15/2024 17:00	09/15/2024 19:00	Warm Startup	3
26	09/17/2024 20:00	09/17/2024 22:00	Warm Startup	3
27	09/22/2024 14:00	09/22/2024 15:00	Cold Startup	2
28	09/25/2024 14:00	09/25/2024 15:00	Hot Startup	2
29	09/26/2024 14:00	09/26/2024 15:00	Hot Startup	2
30	09/27/2024 09:00	09/27/2024 10:00	Warm Startup	2
31	09/28/2024 15:00	09/28/2024 15:00	Hot Startup	1
32	09/29/2024 10:00	09/29/2024 11:00	Warm Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	2	0.12
Hot Startup/Startup Shutdown Event Text 02 Add	11	21	1.27
Warm Startup	20	50	3.02
Total Process Events:	32	73	4.41

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,655 Hour(s)
Total Startup Time:	73 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	73 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	4.41 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
07/01/2024 01:00	07/01/2024 12:00	12
07/02/2024 00:00	07/02/2024 14:00	15
07/04/2024 03:00	07/04/2024 12:00	10
07/06/2024 07:00	07/06/2024 12:00	6
07/07/2024 04:00	07/07/2024 10:00	7
07/14/2024 03:00	07/14/2024 13:00	11
07/21/2024 06:00	07/21/2024 22:00	17
07/22/2024 00:00	07/22/2024 02:00	3
07/27/2024 07:00	07/27/2024 14:00	8
07/28/2024 08:00	07/28/2024 13:00	6
07/29/2024 04:00	07/29/2024 13:00	10
07/30/2024 00:00	07/30/2024 14:00	15
08/09/2024 22:00	08/10/2024 12:00	15
08/11/2024 00:00	08/12/2024 17:00	42
08/13/2024 03:00	08/13/2024 15:00	13
08/14/2024 03:00	08/14/2024 09:00	7
08/15/2024 01:00	08/15/2024 11:00	11
08/16/2024 03:00	08/16/2024 11:00	9
08/17/2024 07:00	08/17/2024 13:00	7
08/18/2024 03:00	08/18/2024 13:00	11
08/19/2024 01:00	08/19/2024 06:00	6
08/20/2024 02:00	08/20/2024 12:00	11
08/22/2024 07:00	08/25/2024 23:00	89
08/26/2024 01:00	08/26/2024 06:00	6
08/31/2024 07:00	08/31/2024 09:00	3
09/01/2024 07:00	09/01/2024 13:00	7
09/02/2024 08:00	09/02/2024 13:00	6
09/11/2024 00:00	09/13/2024 17:00	66
09/14/2024 03:00	09/18/2024 00:00	94
09/19/2024 08:00	09/21/2024 19:00	60

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
09/22/2024 08:00	09/22/2024 09:00	2
09/25/2024 08:00	09/25/2024 17:00	10
09/26/2024 09:00	09/27/2024 12:00	28
09/28/2024 08:00	09/29/2024 13:00	30

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	653.00 Hour(s)
Offline Percentage:	29.57 %
Total Online:	1,555.00 Hour(s)
Online Percentage:	70.43 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/01/2024 13:00	07/01/2024 14:00	Warm startup	2
2	07/02/2024 15:00	07/02/2024 17:00	Warm startup	3
3	07/04/2024 13:00	07/04/2024 14:00	Warm startup	2
4	07/06/2024 13:00	07/06/2024 14:00	Hot Startup	2
5	07/07/2024 11:00	07/07/2024 12:00	Warm startup	2
6	07/14/2024 14:00	07/14/2024 15:00	Warm startup	2
7	07/21/2024 23:00	07/21/2024 23:00	Warm startup	1
8	07/22/2024 03:00	07/22/2024 04:00	Warm startup	2
9	07/27/2024 15:00	07/27/2024 16:00	Warm startup	2
10	07/28/2024 14:00	07/28/2024 15:00	Hot Startup	2
11	07/29/2024 14:00	07/29/2024 16:00	Warm startup	3
12	07/30/2024 15:00	07/30/2024 16:00	Warm startup	2
13	08/10/2024 13:00	08/10/2024 15:00	Warm startup	3
14	08/12/2024 18:00	08/12/2024 20:00	Warm startup	3
15	08/13/2024 16:00	08/13/2024 18:00	Warm startup	3
16	08/14/2024 10:00	08/14/2024 11:00	Warm startup	2
17	08/15/2024 12:00	08/15/2024 14:00	Warm startup	3
18	08/16/2024 12:00	08/16/2024 13:00	Warm startup	2
19	08/17/2024 14:00	08/17/2024 15:00	Warm startup	2
20	08/18/2024 14:00	08/18/2024 15:00	Warm startup	2
21	08/19/2024 07:00	08/19/2024 08:00	Hot Startup	2
22	08/20/2024 13:00	08/20/2024 14:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Number	Start Time	End Time	Event Type	Duration
23	08/26/2024 00:00	08/26/2024 00:00	Cold Startup	1
24	08/26/2024 07:00	08/26/2024 08:00	Cold Startup	2
25	08/31/2024 10:00	08/31/2024 11:00	Hot Startup	2
26	09/01/2024 14:00	09/01/2024 15:00	Warm startup	2
27	09/02/2024 14:00	09/02/2024 15:00	Hot Startup	2
28	09/13/2024 18:00	09/13/2024 19:00	Warm startup	2
29	09/18/2024 01:00	09/18/2024 02:00	Cold Startup	2
30	09/21/2024 20:00	09/21/2024 22:00	Warm startup	3
31	09/22/2024 10:00	09/22/2024 11:00	Hot Startup	2
32	09/25/2024 18:00	09/25/2024 19:00	Warm startup	2
33	09/27/2024 13:00	09/27/2024 14:00	Warm startup	2
34	09/29/2024 14:00	09/29/2024 15:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/02/2024 11:10 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	5	0.32
Hot Startup	6	12	0.77
Warm startup	25	56	3.60
Total Process Events:	34	73	4.69

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,555 Hour(s)
Total Startup Time:	73 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	73 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	4.69 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 3rd Quarter of 2024.

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 3rd Quarter of 2024.

ATTACHMENT 14
Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

I. Reporting period (specify dates): July 1st - September 30, 2024

2. Due date for submittal of report: October 30, 2024

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)